DOCKETED

Docket Number:	06-AFC-09C
Project Title:	Colusa Generating Station - Compliance
TN #:	204447
Document Title:	Pacific Gas & Electric Company's 2015 1st Quarter Operating Report
Description:	Quarterly Operating Report
Filer:	Charles Robert Price
Organization:	Pacific Gas & Electric Co.
Submitter Role:	Applicant
Submission Date:	4/29/2015 3:54:32 PM
Docketed Date:	4/29/2015

Ed Warner
Plant Manager

Mailing Address
Pacific Gas and Electric Company
Colusa Generating Station
P.O. Box 398
Maxwell, CA 95955

530.934.9061
Fax: 530.934.9024

CGS15-L-0013
April 29, 2015

Eric Veerkamp
California Energy Commission
1516 Ninth Street, MS-2000
Sacramento, CA 95814

Reference: Colusa Generating Station (06-AFC-9)

Subject: Condition of Certification AQSC-9 – Quarterly Operating Reports

Dear Eric:

Attached is the 2015 1st Quarter Operating Report and is being submitted in accordance with Condition of Certification AQSC-9. If you have any questions, please contact me at (530) 934-9007.

Sincerely,

Charles Price
Senior Environmental Consultant

cc: File No. 3.6.3.1

Ed Warner, PG&E
Sarah Gassner, PG&E

Pacific Gas and
Electric Company

Colusa Generating Station Project

(CEC# 06-AFC-9C, Title V # 21006-259)

Quarterly Operating Report

Quarter Ending March 31, 2015

PACIFIC GAS AND ELECTRIC COMPANY
COLUSA GENERATING STATION

QUARTERLY OPERATIONS REPORT

QUARTER ENDING March 31, 2015

This report documents compliance with the California Energy Commission's Conditions of Certification AQSC-9 and Colusa County Air Pollution Control Title V # 13.

Attached are summaries of relevant permit conditions and compliance status as well as corresponding required documentation.

Attachment 1:	Air Quality Complaints (AQ-5)
Attachment 2:	Fuel Quality Data (AQ-10, 11)
Attachment 3:	Compliance Demonstration with KKKK (AQ-13)
Attachment 4:	Excess Emissions/Downtime Report (AQ-4, 19)
Attachment 5:	Hourly Emissions VOC (AQ-14)
Attachment 6:	Hourly Emissions NOx (AQ-15)
Attachment 7:	Hourly Emissions CO (AQ-16)
Attachment 8:	Hourly Emissions NH3 (AQ-18)
Attachment 9:	Quarterly/Annual Emission Report (AQ-23, 26)
Attachment 10:	Maximum Emissions Both Turbines (AQ-25)
Attachment 11:	RATA/Certification Testing (AQ-19)
Attachment 12:	Startup/Shutdowns (AQ-22)
Attachment 13:	Water Bath Heater Operations (AQ-17)
Attachment 14:	Toxics (AQ-29)

ATTACHMENT 1
Complaints (AQ-5)

During the 1st quarter of 2015, there were no complaints issued from the public for the Colusa Generating Station. The site continues to be available for inspection by representatives of the CCAPCD.

ATTACHMENT 2
Fuel Quality Data

FCD: AQ-10 & 11
Title V: #16

2015 Monthly Sulfur Content - Colusa Generating Station

All Units in Grains of Sulfur per Standard Cubic Foot

Month	Jan-15	Feb-15	Mar-15	Apr-15	May-15	Jun-15	Jul-15	Aug-15	Sep-15	Oct-15	Nov-15	Dec-15	Avg
Gr/100SCF	0.168	0.193	0.188										0.183

Permit Limits:

.75 Grains/100SCF per Month (PSD Condition X.I.4); .3 Grains/100SCF Annual Average (Title V # 16)

Laboratory Test Report

Report #: 562.1-15.12

Applied Technology Services (ATS)
3400 Crow Canyon Road
San Ramon, CA 94583

Pacific Gas and Electric Company

SUBJECT: CHEMICAL ANALYSES OF GAS SAMPLES FROM COLUSA POWER PLANT
ATS CHEMISTRY SERVICES UNIT FILE 150116-2596

On January 15, 2015, Steve North collected two samples of natural gas at Colusa Power Plant, in a 1-L Tedlar bag and in a 500-ml steel cylinder.

The Tedlar bag sample was analyzed for sulfur compounds on January 15, 2015, by Eurofins/ Air Toxics Ltd. within 24 hours of the time it was collected. The Eurofins/ Air Toxics report is attached.

The steel cylinder was received at ATS on January 16, 2015, and the hydrocarbons in the sample were analyzed using an Agilent 3000 GC with a thermal conductivity detector. The results are as follows:

Table 1: Hydrocarbon Content of Natural Gas from Colusa Power Plant on 01/15/2015

GAS PHASE COMPONENT	VOLUME
METHANE, %	95.058
ETHANE, %	3.595
PROPANE, %	0.111
ISO-BUTANE, %	0.011
N-BUTANE, %	0.011
ISO-PENTANE, %	0.002
N-PENTANE, %	0.001
HEXANES, HEPTANES, OCTANES, %	0.000
CARBON DIOXIDE, %	0.807
NITROGEN, %	0.436
HYDROGEN, %	0.002
HELIUM, %	0.009
OXYGEN, %	0.003
TOTAL, %	100.000
CALC. BTU/CU.FT:	1041.35
REAL RELATIVE DENSITY	0.589
METHANE NUMBER	89.588

As shown in Table 2, the total sulfur content in the gas supply is 0.168 grains per 100 cu. ft. Please contact Surinder Sidhu at 925-866-5245 if there are any questions regarding the chemical analyses.

Attachments

pc: Charles Price

Date: January 28, 2015

Tested by: S Sidhu

Surinder Sidhu

Approved by: Clement O. Da Silva

Clement O. Da Silva

Table 2: Sulfur Analysis of Natural Gas Supply to Colusa Power Plant on January 15, 2015

(All results in ppmv)

Gas Component	Concentration
Hydrogen Sulfide	0.50
Carbonyl Sulfide	0.16
Methyl Mercaptan	0.07
Ethyl Mercaptan	0.02
Dimethyl Sulfide	<0.16
Isopropyl Mercaptan	<0.16
tert-Butyl Mercaptan	1.20
sec-Butyl Mercaptan	<0.02
Tetrahydrothiophene	0.89
Other Sulfur Compounds	<0.02
Total	2.84

Total sulfur in grains/100 cu. ft.= 0.168

eurofins | Air Toxics

1/22/2015
Mr. Clement Dasilva
PG&E
3400 Crow Canyon Road

San Ramon CA 94583

Project Name: Natural Gas Sampling
Project #:
Workorder #: 1501159

Dear Mr. Clement Dasilva

The following report includes the data for the above referenced project for sample(s) received on 1/15/2015 at Air Toxics Ltd.

The data and associated QC analyzed by ASTM D-5504 are compliant with the project requirements or laboratory criteria with the exception of the deviations noted in the attached case narrative.

Thank you for choosing Air Toxics Ltd. for your air analysis needs. Air Toxics Ltd. is committed to providing accurate data of the highest quality. Please feel free to contact the Project Manager: Kelly Buettner at 916-985-1000 if you have any questions regarding the data in this report.

Regards,

Kelly Buettner

Project Manager

eurofins | Air Toxics

WORK ORDER #: 1501159

Work Order Summary

CLIENT:	Mr. Clement Dasilva PG&E 3400 Crow Canyon Road San Ramon, CA 94583	**BILL TO:**	Mr. Clement Dasilva PG&E 3400 Crow Canyon Road San Ramon, CA 94583
PHONE:	925-866-5421	**P.O. #**	3500782251
FAX:	925-866-5681	**PROJECT #**	Natural Gas Sampling
DATE RECEIVED:	01/15/2015	**CONTACT:**	Kelly Buettner
DATE COMPLETED:	01/22/2015		

FRACTION #	NAME	TEST	RECEIPT VAC./PRES.	FINAL PRESSURE
01A	CPP-GS-JAN-A	ASTM D-5504	Tedlar Bag	Tedlar Bag
02A	Lab Blank	ASTM D-5504	NA	NA
03A	LCS	ASTM D-5504	NA	NA
03AA	LCSD	ASTM D-5504	NA	NA

CERTIFIED BY: Heidi Mayo

Technical Director

DATE: 01/22/15

Certification numbers: AZ Licensure AZ0775, NJ NELAP - CA016, NY NELAP - 11291,
TX NELAP - T104704343-14-7, UT NELAP CA009332014-5, VA NELAP - 460197, WA NELAP - C935
Name of Accreditation Body: NELAP/ORELAP (Oregon Environmental Laboratory Accreditation Program)
Accreditation number: CA300005, Effective date: 10/18/2014, Expiration date: 10/17/2015.
Eurofins Air Toxics Inc.. certifies that the test results contained in this report meet all requirements of the NELAC standards

This report shall not be reproduced, except in full, without the written approval of Eurofins Air Toxics, Inc.

180 BLUE RAVINE ROAD, SUITE B FOLSOM, CA - 9563
(916) 985-1000 . (800) 985-5955 . FAX (916) 985-1020

LABORATORY NARRATIVE
ASTM D-5504
PG&E
Workorder# 1501159

One 1 Liter Tedlar Bag sample was received on January 15, 2015. The laboratory performed the analysis of sulfur compounds via ASTM D-5504 using GC/SCD. The method involves direct injection of the air sample into the GC via a fixed 2.0 mL sampling loop. See the data sheets for the reporting limits for each compound.

Receiving Notes

There were no receiving discrepancies.

Analytical Notes

There were no analytical discrepancies.

Definition of Data Qualifying Flags

Seven qualifiers may have been used on the data analysis sheets and indicate as follows:
B - Compound present in laboratory blank greater than reporting limit.
J - Estimated value.
E - Exceeds instrument calibration range.
S - Saturated peak.
Q - Exceeds quality control limits.
U - Compound analyzed for but not detected above the detection limit.
M - Reported value may be biased due to apparent matrix interferences.
File extensions may have been used on the data analysis sheets and indicates as follows:
a-File was requantified
b-File was quantified by a second column and detector
r1-File was requantified for the purpose of reissue

eurofins | Air Toxics

Summary of Detected Compounds
SULFUR GASES BY ASTM D-5504 GC/SCD

Client Sample ID: CPP-GS-JAN-A

Lab ID#: 1501159-01A

Compound	Rpt. Limit (ppbv)	Amount (ppbv)
Hydrogen Sulfide	16	500
Carbonyl Sulfide	16	160
Methyl Mercaptan	16	74
Ethyl Mercaptan	16	21
tert-Butyl Mercaptan	16	1200
Tetrahydrothiophene	16	890

eurofins | Air Toxics

Client Sample ID: CPP-GS-JAN-A

Lab ID#: 1501159-01A

SULFUR GASES BY ASTM D-5504 GC/SCD

File Name:	**k011525**	**Date of Collection:**	**1/15/15 3:46:00 PM**
Dil. Factor:	**4.00**	**Date of Analysis:**	**1/15/15 08:24 PM**

Compound	Rpt. Limit (ppbv)	Amount (ppbv)
Hydrogen Sulfide	16	500
Carbonyl Sulfide	16	160
Methyl Mercaptan	16	74
Ethyl Mercaptan	16	21
Dimethyl Sulfide	16	Not Detected
Carbon Disulfide	20	Not Detected
Isopropyl Mercaptan	16	Not Detected
tert-Butyl Mercaptan	16	1200
n-Propyl Mercaptan	16	Not Detected
Ethyl Methyl Sulfide	16	Not Detected
Thiophene	16	Not Detected
Isobutyl Mercaptan	16	Not Detected
Diethyl Sulfide	16	Not Detected
n-Butyl Mercaptan	16	Not Detected
Dimethyl Disulfide	16	Not Detected
3-Methylthiophene	16	Not Detected
Tetrahydrothiophene	16	890
2-Ethylthiophene	16	Not Detected
2,5-Dimethylthiophene	16	Not Detected
Diethyl Disulfide	16	Not Detected

Container Type: 1 Liter Tedlar Bag

eurofins | Air Toxics

Client Sample ID: Lab Blank

Lab ID#: 1501159-02A

SULFUR GASES BY ASTM D-5504 GC/SCD

File Name:	**k011512**	**Date of Collection: NA**	
Dil. Factor:	**1.00**	**Date of Analysis: 1/15/15 12:02 PM**	

Compound	**Rpt. Limit (ppbv)**	**Amount (ppbv)**
Hydrogen Sulfide	4.0	Not Detected
Carbonyl Sulfide	4.0	Not Detected
Methyl Mercaptan	4.0	Not Detected
Ethyl Mercaptan	4.0	Not Detected
Dimethyl Sulfide	4.0	Not Detected
Carbon Disulfide	5.0	Not Detected
Isopropyl Mercaptan	4.0	Not Detected
tert-Butyl Mercaptan	4.0	Not Detected
n-Propyl Mercaptan	4.0	Not Detected
Ethyl Methyl Sulfide	4.0	Not Detected
Thiophene	4.0	Not Detected
Isobutyl Mercaptan	4.0	Not Detected
Diethyl Sulfide	4.0	Not Detected
n-Butyl Mercaptan	4.0	Not Detected
Dimethyl Disulfide	4.0	Not Detected
3-Methylthiophene	4.0	Not Detected
Tetrahydrothiophene	4.0	Not Detected
2-Ethylthiophene	4.0	Not Detected
2,5-Dimethylthiophene	4.0	Not Detected
Diethyl Disulfide	4.0	Not Detected

Container Type: NA - Not Applicable

eurofins | Air Toxics

Client Sample ID: LCS

Lab ID#: 1501159-03A

SULFUR GASES BY ASTM D-5504 GC/SCD

File Name:	**k011509**	**Date of Collection: NA**	
Dil. Factor:	**1.00**	**Date of Analysis: 1/15/15 10:54 AM**	

Compound	**%Recovery**	**Method Limits**
Hydrogen Sulfide	100	70-130
Carbonyl Sulfide	90	70-130
Methyl Mercaptan	96	70-130
Ethyl Mercaptan	85	70-130
Dimethyl Sulfide	85	70-130
Carbon Disulfide	79	70-130
Isopropyl Mercaptan	86	70-130
tert-Butyl Mercaptan	97	70-130
n-Propyl Mercaptan	94	70-130
Ethyl Methyl Sulfide	96	70-130
Thiophene	102	70-130
Isobutyl Mercaptan	105	70-130
Diethyl Sulfide	100	70-130
n-Butyl Mercaptan	94	70-130
Dimethyl Disulfide	106	70-130
3-Methylthiophene	100	70-130
Tetrahydrothiophene	108	70-130
2-Ethylthiophene	105	70-130
2,5-Dimethylthiophene	96	70-130
Diethyl Disulfide	109	70-130

Container Type: NA - Not Applicable

eurofins | Air Toxics

Client Sample ID: LCSD

Lab ID#: 1501159-03AA

SULFUR GASES BY ASTM D-5504 GC/SCD

File Name:	**k011510**	**Date of Collection: NA**	
Dil. Factor:	**1.00**	**Date of Analysis: 1/15/15 11:16 AM**	

Compound	**%Recovery**	**Method Limits**
Hydrogen Sulfide	95	70-130
Carbonyl Sulfide	90	70-130
Methyl Mercaptan	89	70-130
Ethyl Mercaptan	81	70-130
Dimethyl Sulfide	82	70-130
Carbon Disulfide	77	70-130
Isopropyl Mercaptan	78	70-130
tert-Butyl Mercaptan	91	70-130
n-Propyl Mercaptan	88	70-130
Ethyl Methyl Sulfide	88	70-130
Thiophene	102	70-130
Isobutyl Mercaptan	97	70-130
Diethyl Sulfide	96	70-130
n-Butyl Mercaptan	93	70-130
Dimethyl Disulfide	107	70-130
3-Methylthiophene	99	70-130
Tetrahydrothiophene	104	70-130
2-Ethylthiophene	106	70-130
2,5-Dimethylthiophene	106	70-130
Diethyl Disulfide	113	70-130

Container Type: NA - Not Applicable

Chain of Custody Record

Pacific Gas and Electric Company

SAM # ATS

Client: PG&E Applied technical Services	Project Manager: Clem da Silva		Date:
Address: 3400 Crow Canyon Road	Telephone Number: 925-866-5421	Email: codu@pge.com	Laboratory: ATS
City: San Ramon / State: CA / Zip: 94583	Site Contacat: Clem Da Silva 925-866-5421		Laboratory Phone:
Project Number/Name: Nat'l Gas Sampling	Sampler: Steve North 925-785-3039		Laboratory Fax:
Contract Number, PO Number:	Laboratory Contact:		

PG&E Sample ID	SAM#-ID#	Date	Time	Sample Type	Containers Volume	Containers Type	Containers No.	Preservative	Condition on Receipt/Comments	Preparation and Analysis: C1-C10
HBPP-GS-JAN-1		1/15/15	1034	Gas	500cc	cyl	1	None		X
HBPP-GS-JAN-2		↓	1037	Gas	500cc	cyl	1	None		X
CPP-GS-JAN-1		↓	1543	Gas	500cc	cyl	1	None		X

Demo ATS150116-2594 HBPP-GS-JAN-1

Demo ATS150116-2595 HBPP-GS-JAN-2

Demo ATS150116-2596 CPP-GS-JAN-1

Special Instruction:

Turn Around Time Required	QC Level	Project Specific Requirements (Specify)
☑ Normal ☐ Rush ☐ Other	☑ I. ☐ II. ☐ III.	

1. Relinquished By: Steve North	Date: 1/16/15	Time: 15:25	1. Received By	Date	Time
2. Relinquished By	Date	Time	2. Received By	Date	Time
3. Relinquished By	Date	Time	3. Received By	Date	Time

Comments

Laboratory Test Report

Report #: 562.1-15.46

Applied Technology Services (ATS)
3400 Crow Canyon Road
San Ramon, CA 94583

Pacific Gas and Electric Company

SUBJECT: CHEMICAL ANALYSES OF GAS SAMPLE FROM COLUSA POWER PLANT
ATS CHEMISTRY SERVICES UNIT FILE 150219-2760

On February 18, 2015, Steve North collected two samples of natural gas at Colusa Power Plant in a 1-L Tedlar bag and in a 500-ml steel cylinder.

The Tedlar bag sample was analyzed for sulfur compounds on February 18, 2015, by Eurofins/ Air Toxics Ltd. within 24 hours of the time it was collected. The Eurofins/ Air Toxics report is attached.

The steel cylinder was received at ATS on February 18, 2015, and the hydrocarbons in the sample were analyzed using an Agilent 3000 GC with a thermal conductivity detector. The results are as follows:

Table 1: Hydrocarbon Content of Natural Gas from Colusa Power Plant on 02/18/2015

GAS PHASE COMPONENT	VOLUME
METHANE, %	94.675
ETHANE, %	3.559
PROPANE, %	0.229
ISO-BUTANE, %	0.030
N-BUTANE, %	0.031
ISO-PENTANE, %	0.007
N-PENTANE, %	0.004
HEXANES, HEPTANES, OCTANES, %	0.001
CARBON DIOXIDE, %	0.871
NITROGEN, %	0.565
HYDROGEN, %	0.002
HELIUM, %	0.018
OXYGEN, %	0.006
TOTAL, %	100.000
CALC. BTU/CU.FT:	1032.11
REAL RELATIVE DENSITY	0.586
METHANE NUMBER	88.90

As shown in Table 2, the total sulfur content in the gas supply was 0.193 grains per 100 cu. ft. Please contact Surinder Sidhu at 925-866-5245 if there are any questions regarding the chemical analyses.

Attachments

pc: Charles Price

Date: March 11, 2015

Tested by: S Sidhu

Surinder Sidhu

Approved by: Clement O. Da Silva

Clement O. Da Silva

Table 2: Sulfur Analysis of Natural Gas Supply to Colusa Power Plant on February 18, 2015

(All results in ppmv)

Gas Component	Concentration
Hydrogen Sulfide	0.65
Carbonyl Sulfide	0.26
Methyl Mercaptan	0.045
Ethyl Mercaptan	<0.02
Dimethyl Sulfide	<0.20
Isopropyl Mercaptan	<0.20
tert-Butyl Mercaptan	1.30
sec-Butyl Mercaptan	<0.02
Tetrahydrothiophene	1.00
Other Sulfur Compounds	<0.02
Total	3.26

Total sulfur in grains/100 cu. ft.= 0.193

Chain of Custody Record

Pacific Gas and Electric Company

SAM # ATS

Client: PG&E Applied technical Services	Project Manager: Clem da Silva		Date:
Address: 3400 Crow Canyon Road	Telephone Number: 925-866-5421	Email: codu@pge.com	Laboratory: ATS
City: San Ramon / State: CA / Zip: 94583	Site Contacat: Clem Da Silva 925-866-5421		Laboratory Phone:
Project Number/Name: Nat'l Gas Sampling	Sampler: Steve North 925-785-3039		Laboratory Fax:
Contract Number, PO Number:	Laboratory Contact:		

Preparation and Analysis

PG&E Sample ID	SAM#-ID#	Date	Time	Sample Type	Containers Volume	Containers Type	Containers No.	Preservative	Condition on Receipt/Comments	C1-C10
HBPP-GS-FEB-1		2/18/15	0929	Gas	500cc	cyl	1	None		X
HBPP-GS-FEB-2		↓	0927	Gas	500cc	cyl	1	None		X
CPP-GS-FEB-1		↓	1551	Gas	500cc	cyl	1	None		X

Demo ATS150219-2758 HBPP-GS-FEB-1

Demo ATS150219-2759 HBPP-GS-FEB-2

Demo ATS150219-2760 CPP-GS-FEB-1

Special Instruction:

Turn Around Time Required	QC Level	Project Specific Requirements (Specify)
☑ Normal ☐ Rush ☐ Other	☑ I. ☐ II. ☐ III.	

1. Relinquished By: Steve North	Date: 2/19/15	Time: 1230	1. Received By	Date	Time
2. Relinquished By	Date	Time	2. Received By	Date	Time
3. Relinquished By	Date	Time	3. Received By	Date	Time

Comments

eurofins | Air Toxics

2/26/2015
Mr. Clement Dasilva
PG&E
3400 Crow Canyon Road

San Ramon CA 94583

Project Name: Natural Gas Sampling
Project #:
Workorder #: 1502294

Dear Mr. Clement Dasilva

The following report includes the data for the above referenced project for sample(s) received on 2/18/2015 at Air Toxics Ltd.

The data and associated QC analyzed by ASTM D-5504 are compliant with the project requirements or laboratory criteria with the exception of the deviations noted in the attached case narrative.

Thank you for choosing Air Toxics Ltd. for your air analysis needs. Air Toxics Ltd. is committed to providing accurate data of the highest quality. Please feel free to contact the Project Manager: Kelly Buettner at 916-985-1000 if you have any questions regarding the data in this report.

Regards,

Kelly Buettner

Project Manager

eurofins | Air Toxics

WORK ORDER #: 1502294

Work Order Summary

CLIENT:	Mr. Clement Dasilva PG&E 3400 Crow Canyon Road San Ramon, CA 94583	**BILL TO:**	Mr. Clement Dasilva PG&E 3400 Crow Canyon Road San Ramon, CA 94583
PHONE:	925-866-5421	**P.O. #**	3500782251
FAX:	925-866-5681	**PROJECT #**	Natural Gas Sampling
DATE RECEIVED:	02/18/2015	**CONTACT:**	Kelly Buettner
DATE COMPLETED:	02/26/2015		

FRACTION #	NAME	TEST	RECEIPT VAC./PRES.	FINAL PRESSURE
01A	CPP-GS-FEB-A	ASTM D-5504	Tedlar Bag	Tedlar Bag
02A	Lab Blank	ASTM D-5504	NA	NA
03A	LCS	ASTM D-5504	NA	NA
03AA	LCSD	ASTM D-5504	NA	NA

CERTIFIED BY: Heidi Mayo DATE: 02/26/15

Technical Director

Certification numbers: AZ Licensure AZ0775, CA NELAP - 12282CA, NJ NELAP - CA016, NY NELAP - 11291, TX NELAP - T104704434-13-6, UT NELAP CA009332013-4, VA NELAP - 460197, WA NELAP - C935
Name of Accrediting Agency: NELAP/ORELAP (Oregon Environmental Laboratory Accreditation Program)
Accreditation number: CA300005, Effective date: 10/18/2013, Expiration date: 10/17/2014.
Eurofins Air Toxics Inc.. certifies that the test results contained in this report meet all requirements of the NELAC standards

This report shall not be reproduced, except in full, without the written approval of Eurofins Air Toxics, Inc.

180 BLUE RAVINE ROAD, SUITE B FOLSOM, CA - 9563
(916) 985-1000 . (800) 985-5955 . FAX (916) 985-1020

eurofins | Air Toxics

LABORATORY NARRATIVE
ASTM D-5504
PG&E
Workorder# 1502294

One 1 Liter Tedlar Bag sample was received on February 18, 2015. The laboratory performed the analysis of sulfur compounds via ASTM D-5504 using GC/SCD. The method involves direct injection of the air sample into the GC via a fixed 2.0 mL sampling loop. See the data sheets for the reporting limits for each compound.

Receiving Notes

There were no receiving discrepancies.

Analytical Notes

There were no analytical discrepancies.

Definition of Data Qualifying Flags

Seven qualifiers may have been used on the data analysis sheets and indicate as follows:
B - Compound present in laboratory blank greater than reporting limit.
J - Estimated value.
E - Exceeds instrument calibration range.
S - Saturated peak.
Q - Exceeds quality control limits.
U - Compound analyzed for but not detected above the detection limit.
M - Reported value may be biased due to apparent matrix interferences.
File extensions may have been used on the data analysis sheets and indicates as follows:
a-File was requantified
b-File was quantified by a second column and detector
r1-File was requantified for the purpose of reissue

eurofins | Air Toxics

Summary of Detected Compounds
SULFUR GASES BY ASTM D-5504 GC/SCD

Client Sample ID: CPP-GS-FEB-A

Lab ID#: 1502294-01A

Compound	Rpt. Limit (ppbv)	Amount (ppbv)
Hydrogen Sulfide	20	650
Carbonyl Sulfide	20	260
Methyl Mercaptan	20	45
tert-Butyl Mercaptan	20	1300
Tetrahydrothiophene	20	1000

eurofins | Air Toxics

Client Sample ID: CPP-GS-FEB-A

Lab ID#: 1502294-01A

SULFUR GASES BY ASTM D-5504 GC/SCD

File Name:	**k021810**	**Date of Collection:**	**2/18/15 3:53:00 PM**
Dil. Factor:	**5.00**	**Date of Analysis:**	**2/18/15 07:57 PM**

Compound	Rpt. Limit (ppbv)	Amount (ppbv)
Hydrogen Sulfide	20	650
Carbonyl Sulfide	20	260
Methyl Mercaptan	20	45
Ethyl Mercaptan	20	Not Detected
Dimethyl Sulfide	20	Not Detected
Carbon Disulfide	25	Not Detected
Isopropyl Mercaptan	20	Not Detected
tert-Butyl Mercaptan	20	1300
n-Propyl Mercaptan	20	Not Detected
Ethyl Methyl Sulfide	20	Not Detected
Thiophene	20	Not Detected
Isobutyl Mercaptan	20	Not Detected
Diethyl Sulfide	20	Not Detected
n-Butyl Mercaptan	20	Not Detected
Dimethyl Disulfide	20	Not Detected
3-Methylthiophene	20	Not Detected
Tetrahydrothiophene	20	1000
2-Ethylthiophene	20	Not Detected
2,5-Dimethylthiophene	20	Not Detected
Diethyl Disulfide	20	Not Detected

Container Type: 1 Liter Tedlar Bag

eurofins | Air Toxics

Client Sample ID: Lab Blank

Lab ID#: 1502294-02A

SULFUR GASES BY ASTM D-5504 GC/SCD

File Name:	**k021805**	**Date of Collection: NA**	
Dil. Factor:	**1.00**	**Date of Analysis: 2/18/15 12:08 PM**	

Compound	**Rpt. Limit (ppbv)**	**Amount (ppbv)**
Hydrogen Sulfide	4.0	Not Detected
Carbonyl Sulfide	4.0	Not Detected
Methyl Mercaptan	4.0	Not Detected
Ethyl Mercaptan	4.0	Not Detected
Dimethyl Sulfide	4.0	Not Detected
Carbon Disulfide	5.0	Not Detected
Isopropyl Mercaptan	4.0	Not Detected
tert-Butyl Mercaptan	4.0	Not Detected
n-Propyl Mercaptan	4.0	Not Detected
Ethyl Methyl Sulfide	4.0	Not Detected
Thiophene	4.0	Not Detected
Isobutyl Mercaptan	4.0	Not Detected
Diethyl Sulfide	4.0	Not Detected
n-Butyl Mercaptan	4.0	Not Detected
Dimethyl Disulfide	4.0	Not Detected
3-Methylthiophene	4.0	Not Detected
Tetrahydrothiophene	4.0	Not Detected
2-Ethylthiophene	4.0	Not Detected
2,5-Dimethylthiophene	4.0	Not Detected
Diethyl Disulfide	4.0	Not Detected

Container Type: NA - Not Applicable

eurofins | Air Toxics

Client Sample ID: LCS

Lab ID#: 1502294-03A

SULFUR GASES BY ASTM D-5504 GC/SCD

File Name:	**k021802**	**Date of Collection: NA**	
Dil. Factor:	**1.00**	**Date of Analysis: 2/18/15 11:00 AM**	

Compound	**%Recovery**	**Method Limits**
Hydrogen Sulfide	93	70-130
Carbonyl Sulfide	89	70-130
Methyl Mercaptan	86	70-130
Ethyl Mercaptan	93	70-130
Dimethyl Sulfide	95	70-130
Carbon Disulfide	94	70-130
Isopropyl Mercaptan	86	70-130
tert-Butyl Mercaptan	98	70-130
n-Propyl Mercaptan	96	70-130
Ethyl Methyl Sulfide	104	70-130
Thiophene	98	70-130
Isobutyl Mercaptan	99	70-130
Diethyl Sulfide	98	70-130
n-Butyl Mercaptan	93	70-130
Dimethyl Disulfide	104	70-130
3-Methylthiophene	98	70-130
Tetrahydrothiophene	100	70-130
2-Ethylthiophene	104	70-130
2,5-Dimethylthiophene	100	70-130
Diethyl Disulfide	106	70-130

Container Type: NA - Not Applicable

eurofins | Air Toxics

Client Sample ID: LCSD

Lab ID#: 1502294-03AA

SULFUR GASES BY ASTM D-5504 GC/SCD

File Name:	**k021803**	**Date of Collection: NA**	
Dil. Factor:	**1.00**	**Date of Analysis: 2/18/15 11:23 AM**	

Compound	**%Recovery**	**Method Limits**
Hydrogen Sulfide	87	70-130
Carbonyl Sulfide	85	70-130
Methyl Mercaptan	86	70-130
Ethyl Mercaptan	92	70-130
Dimethyl Sulfide	93	70-130
Carbon Disulfide	92	70-130
Isopropyl Mercaptan	84	70-130
tert-Butyl Mercaptan	94	70-130
n-Propyl Mercaptan	92	70-130
Ethyl Methyl Sulfide	91	70-130
Thiophene	100	70-130
Isobutyl Mercaptan	105	70-130
Diethyl Sulfide	104	70-130
n-Butyl Mercaptan	108	70-130
Dimethyl Disulfide	108	70-130
3-Methylthiophene	101	70-130
Tetrahydrothiophene	111	70-130
2-Ethylthiophene	116	70-130
2,5-Dimethylthiophene	110	70-130
Diethyl Disulfide	122	70-130

Container Type: NA - Not Applicable

Laboratory Test Report
Applied Technology Services (ATS)
3400 Crow Canyon Road
San Ramon, CA 94583

Report #: 562.1-15.51

Pacific Gas and Electric Company

SUBJECT: CHEMICAL ANALYSES OF GAS SAMPLE FROM COLUSA POWER PLANT
ATS CHEMISTRY SERVICES UNIT FILE ATS150319-3097

On March 18, 2015, Steve North collected two samples of natural gas at Colusa Power Plant, in a 1-L Tedlar bag and in a 500-ml steel cylinder.

The Tedlar bag sample was analyzed for sulfur compounds on March 18, 2015, by Air Toxics Ltd. within 24 hours of the time it was collected. The Air Toxics report is attached.

The steel cylinder was received at ATS on March 19, 2015, and the hydrocarbons in the sample were analyzed using an Agilent 3000 GC with thermal conductivity detector. The results are as follows:

Table 1: Hydrocarbon Content of Natural Gas from Colusa Power Plant on 3/18/2015

GAS PHASE COMPONENT	VOLUME
METHANE, %	94.105
ETHANE, %	4.220
PROPANE, %	0.182
ISO-BUTANE, %	0.020
N-BUTANE, %	0.020
ISO-PENTANE, %	0.005
N-PENTANE, %	0.003
HEXANES, HEPTANES, OCTANES, %	0.001
CARBON DIOXIDE, %	0.873
NITROGEN, %	0.551
HYDROGEN, %	0.002
HELIUM, %	0.009
OXYGEN, %	0.000
TOTAL, %	100.000
CALC. BTU/CU.FT:	1036.055
REAL RELATIVE DENSITY	0.589
METHANE NUMBER	88.117

As shown in Table 2, the total sulfur content in the gas supply is 0.188 grains per 100 cu. ft. Please contact Evan Cavalli at 925-866-5510 if there are any questions regarding the chemical analyses.

Attachments

pc: Charles Price

Date: March 25, 2015

Tested by: Evan M. Cavalli

Approved by: Clement O. Da Silva

Table 2: Sulfur Analysis of Natural Gas Supply to Colusa Power Plant on March 18, 2015

(All results in ppmv)

Gas Component	Concentration
Hydrogen Sulfide	0.59
Carbonyl Sulfide	0.29
Methyl Mercaptan	0.06
Ethyl Mercaptan	<0.02
Dimethyl Sulfide	<0.02
Isopropyl Mercaptan	<0.02
tert-Butyl Mercaptan	1.30
sec-Butyl Mercaptan	<0.02
Tetrahydrothiophene	0.93
Other Sulfur Compounds	<0.02
Total	3.17

Total sulfur in grains/100 cu. ft.= 0.188

Chain of Custody Record

Pacific Gas and Electric Company

SAM # ATS

Client: PG&E Applied technical Services		Project Manager: Clem da Silva		Date:
Address: 3400 Crow Canyon Road		Telephone Number: 925-866-5421	Email: codu@pge.com	Laboratory: ATS
City: San Ramon	State: CA	Zip: 94583	Site Contacat: Clem Da Silva 925-866-5421	Laboratory Phone:
Project Number/Name: Nat'l Gas Sampling			Sampler: Steve North 925-785-3039	Laboratory Fax:
Contract Number, PO Number:		Laboratory Contact:		

PG&E Sample ID	SAM#-ID#	Date	Time	Sample Type	Containers Volume	Containers Type	Containers No.	Preservative	Condition on Receipt/Comments	Preparation and Analysis: C1-C10
HBPP-GS-MAR-1		3/18/15	0840	Gas	500cc	cyl	1	None		X
HBPP-GS-MAR-2		↓	0842	Gas	500cc	cyl	1	None	Duplicate	X
CPP-GS-MAR-1		↓	1553	Gas	500cc	cyl	1	None		X

Demo ATS150319-3095 HBPP-GS-MAR-1

Demo ATS150319-3096 HBPP-GS-MAR-2

Demo ATS150319-3097 CPP-GS-MAR-1

Special Instruction:

Turn Around Time Required	QC Level	Project Specific Requirements (Specify)
☑ Normal ☐ Rush ☐ Other	☑ I. ☐ II. ☐ III.	

1. Relinquished By: Steve North	Date: 3/18/15	Time: 1140	1. Received By:	Date: 3/19/15	Time: 1000
2. Relinquished By:	Date:	Time:	2. Received By:	Date:	Time:
3. Relinquished By:	Date:	Time:	3. Received By:	Date:	Time:

Comments:

eurofins | Air Toxics

3/24/2015
Mr. Clement Dasilva
PG&E
3400 Crow Canyon Road

San Ramon CA 94583

Project Name: Natural Gas Sampling
Project #:
Workorder #: 1503332

Dear Mr. Clement Dasilva

The following report includes the data for the above referenced project for sample(s) received on 3/18/2015 at Air Toxics Ltd.

The data and associated QC analyzed by ASTM D-5504 are compliant with the project requirements or laboratory criteria with the exception of the deviations noted in the attached case narrative.

Thank you for choosing Air Toxics Ltd. for your air analysis needs. Air Toxics Ltd. is committed to providing accurate data of the highest quality. Please feel free to contact the Project Manager: Kelly Buettner at 916-985-1000 if you have any questions regarding the data in this report.

Regards,

Kelly Buettner

Project Manager

eurofins | Air Toxics

WORK ORDER #: 1503332

Work Order Summary

CLIENT:	Mr. Clement Dasilva PG&E 3400 Crow Canyon Road San Ramon, CA 94583	**BILL TO:**	Mr. Clement Dasilva PG&E 3400 Crow Canyon Road San Ramon, CA 94583
PHONE:	925-866-5421	**P.O. #**	3500782251
FAX:	925-866-5681	**PROJECT #**	Natural Gas Sampling
DATE RECEIVED:	03/18/2015	**CONTACT:**	Kelly Buettner
DATE COMPLETED:	03/24/2015		

FRACTION #	NAME	TEST	RECEIPT VAC./PRES.	FINAL PRESSURE
01A	CPP-GS-MAR-A	ASTM D-5504	Tedlar Bag	Tedlar Bag
02A	Lab Blank	ASTM D-5504	NA	NA
03A	LCS	ASTM D-5504	NA	NA
03AA	LCSD	ASTM D-5504	NA	NA

CERTIFIED BY: Heidi Mayo

Technical Director

DATE: 03/24/15

Certification numbers: AZ Licensure AZ0775, NJ NELAP - CA016, NY NELAP - 11291,
TX NELAP - T104704343-14-7, UT NELAP CA009332014-5, VA NELAP - 460197, WA NELAP - C935
Name of Accreditation Body: NELAP/ORELAP (Oregon Environmental Laboratory Accreditation Program)
Accreditation number: CA300005, Effective date: 10/18/2014, Expiration date: 10/17/2015.
Eurofins Air Toxics Inc.. certifies that the test results contained in this report meet all requirements of the NELAC standards

This report shall not be reproduced, except in full, without the written approval of Eurofins Air Toxics, Inc.

180 BLUE RAVINE ROAD, SUITE B FOLSOM, CA - 9563
(916) 985-1000 . (800) 985-5955 . FAX (916) 985-1020

eurofins | Air Toxics

LABORATORY NARRATIVE
ASTM D-5504
PG&E
Workorder# 1503332

One 1 Liter Tedlar Bag sample was received on March 18, 2015. The laboratory performed the analysis of sulfur compounds via ASTM D-5504 using GC/SCD. The method involves direct injection of the air sample into the GC via a fixed 2.0 mL sampling loop. See the data sheets for the reporting limits for each compound.

Receiving Notes

There were no receiving discrepancies.

Analytical Notes

There were no analytical discrepancies.

Definition of Data Qualifying Flags

Seven qualifiers may have been used on the data analysis sheets and indicate as follows:
B - Compound present in laboratory blank greater than reporting limit.
J - Estimated value.
E - Exceeds instrument calibration range.
S - Saturated peak.
Q - Exceeds quality control limits.
U - Compound analyzed for but not detected above the detection limit.
M - Reported value may be biased due to apparent matrix interferences.
File extensions may have been used on the data analysis sheets and indicates as follows:
a-File was requantified
b-File was quantified by a second column and detector
r1-File was requantified for the purpose of reissue

eurofins | Air Toxics

Summary of Detected Compounds
SULFUR GASES BY ASTM D-5504 GC/SCD

Client Sample ID: CPP-GS-MAR-A

Lab ID#: 1503332-01A

Compound	Rpt. Limit (ppbv)	Amount (ppbv)
Hydrogen Sulfide	20	590
Carbonyl Sulfide	20	290
Methyl Mercaptan	20	57
tert-Butyl Mercaptan	20	1300
Tetrahydrothiophene	20	930

eurofins | Air Toxics

Client Sample ID: CPP-GS-MAR-A

Lab ID#: 1503332-01A

SULFUR GASES BY ASTM D-5504 GC/SCD

File Name:	**k031815**	**Date of Collection:**	**3/18/15 3:55:00 PM**
Dil. Factor:	**5.00**	**Date of Analysis:**	**3/18/15 07:26 PM**

Compound	**Rpt. Limit (ppbv)**	**Amount (ppbv)**
Hydrogen Sulfide	20	590
Carbonyl Sulfide	20	290
Methyl Mercaptan	20	57
Ethyl Mercaptan	20	Not Detected
Dimethyl Sulfide	20	Not Detected
Carbon Disulfide	25	Not Detected
Isopropyl Mercaptan	20	Not Detected
tert-Butyl Mercaptan	20	1300
n-Propyl Mercaptan	20	Not Detected
Ethyl Methyl Sulfide	20	Not Detected
Thiophene	20	Not Detected
Isobutyl Mercaptan	20	Not Detected
Diethyl Sulfide	20	Not Detected
n-Butyl Mercaptan	20	Not Detected
Dimethyl Disulfide	20	Not Detected
3-Methylthiophene	20	Not Detected
Tetrahydrothiophene	20	930
2-Ethylthiophene	20	Not Detected
2,5-Dimethylthiophene	20	Not Detected
Diethyl Disulfide	20	Not Detected

Container Type: 1 Liter Tedlar Bag

eurofins | Air Toxics

Client Sample ID: Lab Blank

Lab ID#: 1503332-02A

SULFUR GASES BY ASTM D-5504 GC/SCD

File Name:	**k031803**	**Date of Collection: NA**	
Dil. Factor:	**1.00**	**Date of Analysis: 3/18/15 08:29 AM**	

Compound	**Rpt. Limit (ppbv)**	**Amount (ppbv)**
Hydrogen Sulfide	4.0	Not Detected
Carbonyl Sulfide	4.0	Not Detected
Methyl Mercaptan	4.0	Not Detected
Ethyl Mercaptan	4.0	Not Detected
Dimethyl Sulfide	4.0	Not Detected
Carbon Disulfide	5.0	Not Detected
Isopropyl Mercaptan	4.0	Not Detected
tert-Butyl Mercaptan	4.0	Not Detected
n-Propyl Mercaptan	4.0	Not Detected
Ethyl Methyl Sulfide	4.0	Not Detected
Thiophene	4.0	Not Detected
Isobutyl Mercaptan	4.0	Not Detected
Diethyl Sulfide	4.0	Not Detected
n-Butyl Mercaptan	4.0	Not Detected
Dimethyl Disulfide	4.0	Not Detected
3-Methylthiophene	4.0	Not Detected
Tetrahydrothiophene	4.0	Not Detected
2-Ethylthiophene	4.0	Not Detected
2,5-Dimethylthiophene	4.0	Not Detected
Diethyl Disulfide	4.0	Not Detected

Container Type: NA - Not Applicable

eurofins | Air Toxics

Client Sample ID: LCS

Lab ID#: 1503332-03A

SULFUR GASES BY ASTM D-5504 GC/SCD

File Name:	**k031806**	**Date of Collection: NA**	
Dil. Factor:	**1.00**	**Date of Analysis: 3/18/15 09:37 AM**	

Compound	**%Recovery**	**Method Limits**
Hydrogen Sulfide	103	70-130
Carbonyl Sulfide	87	70-130
Methyl Mercaptan	98	70-130
Ethyl Mercaptan	99	70-130
Dimethyl Sulfide	94	70-130
Carbon Disulfide	94	70-130
Isopropyl Mercaptan	92	70-130
tert-Butyl Mercaptan	99	70-130
n-Propyl Mercaptan	98	70-130
Ethyl Methyl Sulfide	98	70-130
Thiophene	87	70-130
Isobutyl Mercaptan	105	70-130
Diethyl Sulfide	95	70-130
n-Butyl Mercaptan	106	70-130
Dimethyl Disulfide	102	70-130
3-Methylthiophene	95	70-130
Tetrahydrothiophene	104	70-130
2-Ethylthiophene	92	70-130
2,5-Dimethylthiophene	88	70-130
Diethyl Disulfide	96	70-130

Container Type: NA - Not Applicable

eurofins | Air Toxics

Client Sample ID: LCSD

Lab ID#: 1503332-03AA

SULFUR GASES BY ASTM D-5504 GC/SCD

File Name:	**k031807**	**Date of Collection: NA**	
Dil. Factor:	**1.00**	**Date of Analysis: 3/18/15 10:01 AM**	

Compound	**%Recovery**	**Method Limits**
Hydrogen Sulfide	98	70-130
Carbonyl Sulfide	86	70-130
Methyl Mercaptan	95	70-130
Ethyl Mercaptan	93	70-130
Dimethyl Sulfide	87	70-130
Carbon Disulfide	98	70-130
Isopropyl Mercaptan	87	70-130
tert-Butyl Mercaptan	96	70-130
n-Propyl Mercaptan	94	70-130
Ethyl Methyl Sulfide	89	70-130
Thiophene	95	70-130
Isobutyl Mercaptan	114	70-130
Diethyl Sulfide	96	70-130
n-Butyl Mercaptan	109	70-130
Dimethyl Disulfide	101	70-130
3-Methylthiophene	94	70-130
Tetrahydrothiophene	101	70-130
2-Ethylthiophene	96	70-130
2,5-Dimethylthiophene	92	70-130
Diethyl Disulfide	104	70-130

Container Type: NA - Not Applicable

ATTACHMENT 3
40 CFR 60 Section KKKK (AQ-13)

40 CFR 60 KKKK Emission Limits:

Natural Gas Fired Combustion Turbine > 850 MMBtu

15 PPMVDC @ 15% O_2; 4 Hour Rolling Average

During Normal Operations

96 PPMVDC @ 15%; 4 Hour Rolling Average

Turbines operating at less than 75% of Peak Load (Startup/Shutdown)

KKKK Compliance (Colusa Generating Station)

40 CFR Part 60 Subpart KKKK applies to all stationary gas turbines rated at greater than or equal to 10 MMBtu/hr that commence construction, modification, or reconstruction after February 18, 2005. The gas turbines involved in this project have a rating of 1612 MMBtu/hr and were installed after February 18, 2005. Therefore, this subpart applies to these gas turbines. The KKKK compliance summaries for the stationary natural gas turbines is summarized below and are based on the following applicable sections of the KKKK performance standards. The non-applicable portions of KKKK are not listed in the compliance summary:

Section	Requirement
60.4305	CGS Turbines/HRSGs are rated at larger than 10 mmbtu/hr and construction commenced after February 18, 2005. Subpart KKKK applies.
60.4310	No exemptions apply.
60.4315	Pollutants regulated under Subpart KKKK: NO_x and SO_2.
60.4320	NOx emissions limit: 15 ppmv @15%O_2
60.4330	SO2 emissions limit: 0.90 lbs SO2/MWh (gross output), or cannot burn any fuel which contains total potential sulfur emissions in excess of 0.060 lbs SO2/MMBtu (heat input).
60.4333	Operate turbine/HRSG, APC systems, and monitoring equipment to minimize emissions at all times including during startup, shutdown, and malfunction.
60.4340(b)(1)	For units with SCR, install a NO_x CEMS per 60.4335(b) or 60.4345. If Part 75 applies, NO_x can be monitored per Appendix E of Part 75. (CGS QAP applies here)
60.4345	Meet all CEMS Performance Specs and develop a QA Plan for the CEMS. . (CGS QAP applies here)
60.4350	All CEMS data must be reduced to hourly averages per 60.13(h). . (CGS QAP applies here)
60.4355	If applicable, develop and insure all parametric monitoring and monitoring plans comply with this section. . (CGS QAP applies here)
60.4360	Monitor fuel sulfur content, or invoke exemption per 60.4365.
60.4365	Exemption for fuel sulfur monitoring, if fuel is demonstrated not to exceed potential sulfur emissions of 0.060 lbs SO_2/MMBtu, Use PG&E gas quality data to show that exemption applies per 60.4365 (a) or (b).
60.4375	Submit excess emissions reports per 60.7(c). Within 30 days following the end of each 6 month period (see 60.4395). In compliance.
60.4380(b)	Determine excess emissions and monitor downtime per (b) (1-3)
60.4400	Initial and annual NO_X performance tests not required if CEMS used

	per 60.4340(b)(1)
60.4405	If NO_x CEMS used, use 60.4405 (a-d) procedures in lieu of performance test.
60.4415	Perform initial SO_2 performance test per 60.4415 (2) or (3). This test must be conducted even if the 60.4365 exemption is invoked.

Compliance with the applicable provisions of NSPS KKKK are summarized below. Specific data to support the compliance determinations listed below are included as attachments.

Section	Compliance
60.4305	KKKK is applicable to the facility. In compliance
60.4310	No exemptions apply.
60.4315	NO_x and SO_2 are in compliance with the KKKK emission standards and monitoring requirements.
60.4320	NO_x emissions limit: 9 ppmv @15%O_2 (See attached GE data sheet). In compliance.
60.4330	SO_2 emissions limit: CT1 172 MW 1.283 lb/hr (SO_2 source test date: 2010) CT2 172 MW 1.649 lb/hr (SO_2 source test date: 2010) CT1 - 1.283/172 = 0.0075 lb/MWh CT2 - 1.649/172 = 0.0096 lb/MWh In compliance with SO2 emission limits. The project will only use pipe quality natural gas with sulfur limits less than 0.06 lbs/MMBtu. See attached natural gas fuel analysis. In compliance with limits based on monthly fuel sampling.
60.4333	The facility will operate turbine/HRSG, APC systems, and monitoring equipment to minimize emissions at all times including during startup, shutdown, and malfunction. In compliance.
60.4340(b)(1)	CT1 and CT2 utilize SCR and NO_x CEMS per 60.4335(b) or 60.4345. In addition, Part 75 applies and NO_x is monitored per Appendix E of Part 75. See attached Quality Assurance Plan (attached). In compliance.
60.4345	In compliance. .
60.4350	In compliance
60.4355	In compliance
60.4360	In compliance through exemption per 60.4365.
60.4365	Requesting exemption (a) and (b) for sulfur monitoring. The fuel used is pipeline quality natural gas with an average grain loading less than 0.30 gr/100 SCF which converts to 0.0008 lb/MMBtu of SO_2. See fuel

	analysis Attachment 2. Annual compliance based on PG&E supplied fuel analysis data.
60.4375	No excess emissions during this reporting period. In compliance.
60.4380(b)	No excess emissions or monitor downtime, per (b) (1-3). In compliance.
60.4400	In compliance. NO_x CEMs used per 60.4340(b)(1). NO_x, CO, and VOC will be tested annually.
60.4405	In compliance. See QAP for CEMs certification.
60.4415	In compliance. Initial SO_2 source test results and QAP are available upon request. Future compliance under this requirement may be determined using one of three methods summarized in 60.4415.

Excess Emission Report

CT2 NOx 30 Day Rolling Average (KKKK)

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 09:22 **Location:** Maxwell, CA

Tag Name: CT2_NOx_30D_Ppmvdc_1D
Total Operating Time: 80.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 10.00 Day(s) Report Time: 90.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**80.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/01/2015 00:00	1	1
01/01/2015 01:00	1	1
01/01/2015 02:00	1	1
01/01/2015 03:00	1	1
01/01/2015 04:00	1	1
01/01/2015 05:00	1	1
01/01/2015 06:00	1	1
01/01/2015 07:00	1	1
01/01/2015 08:00	1	1
01/01/2015 09:00	1	1
01/01/2015 10:00	1	1
01/01/2015 11:00	1	1
01/01/2015 12:00	1	1
01/01/2015 13:00	1	1
01/01/2015 14:00	1	1
01/01/2015 15:00	1	1
01/01/2015 16:00	1	1
01/01/2015 17:00	1	1
01/01/2015 18:00	1	1
01/01/2015 19:00	1	1
01/01/2015 20:00	1	1
01/01/2015 21:00	1	1
01/01/2015 22:00	1	1
01/01/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/02/2015 00:00	1	1
01/02/2015 01:00	1	1
01/02/2015 02:00	1	1
01/02/2015 03:00	1	1
01/02/2015 04:00	1	1
01/02/2015 05:00	1	1
01/02/2015 06:00	1	1
01/02/2015 07:00	1	1
01/02/2015 08:00	1	1
01/02/2015 09:00	1	1
01/02/2015 10:00	1	1
01/02/2015 11:00	1	1
01/02/2015 12:00	1	1
01/02/2015 13:00	1	1
01/02/2015 14:00	1	1
01/02/2015 15:00	1	1
01/02/2015 16:00	1	1
01/02/2015 17:00	1	1
01/02/2015 18:00	1	1
01/02/2015 19:00	1	1
01/02/2015 20:00	1	1
01/02/2015 21:00	1	1
01/02/2015 22:00	1	1
01/02/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/03/2015 00:00	1	1
01/03/2015 01:00	1	1
01/03/2015 02:00	1	1
01/03/2015 03:00	1	1
01/03/2015 04:00	1	1
01/03/2015 05:00	1	1
01/03/2015 06:00	1	1
01/03/2015 07:00	1	1
01/03/2015 08:00	1	1
01/03/2015 09:00	1	1
01/03/2015 10:00	1	1
01/03/2015 11:00	1	1
01/03/2015 12:00	1	1
01/03/2015 13:00	1	1
01/03/2015 14:00	1	1
01/03/2015 15:00	1	1
01/03/2015 16:00	1	1
01/03/2015 17:00	1	1
01/03/2015 18:00	1	1
01/03/2015 19:00	1	1
01/03/2015 20:00	1	1
01/03/2015 21:00	1	1
01/03/2015 22:00	1	1
01/03/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/04/2015 00:00	1	1
01/04/2015 01:00	1	1
01/04/2015 02:00	1	1
01/04/2015 03:00	1	1
01/04/2015 04:00	1	1
01/04/2015 05:00	1	1
01/04/2015 06:00	1	1
01/04/2015 07:00	1	1
01/04/2015 08:00	1	1
01/04/2015 09:00	1	1
01/04/2015 10:00	1	1
01/04/2015 11:00	1	1
01/04/2015 12:00	1	1
01/04/2015 13:00	1	1
01/04/2015 14:00	1	1
01/04/2015 15:00	1	1
01/04/2015 16:00	1	1
01/04/2015 17:00	1	1
01/04/2015 18:00	1	1
01/04/2015 19:00	1	1
01/04/2015 20:00	1	1
01/04/2015 21:00	1	1
01/04/2015 22:00	1	1
01/04/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/05/2015 00:00	1	1
01/05/2015 01:00	1	1
01/05/2015 02:00	1	1
01/05/2015 03:00	1	1
01/05/2015 04:00	1	1
01/05/2015 05:00	1	1
01/05/2015 06:00	1	1
01/05/2015 07:00	1	1
01/05/2015 08:00	1	1
01/05/2015 09:00	1	1
01/05/2015 10:00	1	1
01/05/2015 11:00	1	1
01/05/2015 12:00	1	1
01/05/2015 13:00	1	1
01/05/2015 14:00	1	1
01/05/2015 15:00	1	1
01/05/2015 16:00	1	1
01/05/2015 17:00	1	1
01/05/2015 18:00	1	1
01/05/2015 19:00	1	1
01/05/2015 20:00	1	1
01/05/2015 21:00	1	1
01/05/2015 22:00	1	1
01/05/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/06/2015 00:00	1	1
01/06/2015 01:00	1	1
01/06/2015 02:00	1	1
01/06/2015 03:00	1	1
01/06/2015 04:00	1	1
01/06/2015 05:00	1	1
01/06/2015 06:00	1	1
01/06/2015 07:00	1	1
01/06/2015 08:00	1	1
01/06/2015 09:00	1	1
01/06/2015 10:00	1	1
01/06/2015 11:00	1	1
01/06/2015 12:00	1	1
01/06/2015 13:00	1	1
01/06/2015 14:00	1	1
01/06/2015 15:00	1	1
01/06/2015 16:00	1	1
01/06/2015 17:00	1	1
01/06/2015 18:00	1	1
01/06/2015 19:00	1	1
01/06/2015 20:00	1	1
01/06/2015 21:00	1	1
01/06/2015 22:00	1	1
01/06/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/07/2015 00:00	1	1
01/07/2015 01:00	1	1
01/07/2015 02:00	1	1
01/07/2015 03:00	1	1
01/07/2015 04:00	1	1
01/07/2015 05:00	1	1
01/07/2015 06:00	1	1
01/07/2015 07:00	1	1
01/07/2015 08:00	1	1
01/07/2015 09:00	1	1
01/07/2015 10:00	1	1
01/07/2015 11:00	1	1
01/07/2015 12:00	1	1
01/07/2015 13:00	1	1
01/07/2015 14:00	1	1
01/07/2015 15:00	1	1
01/07/2015 16:00	1	1
01/07/2015 17:00	1	1
01/07/2015 18:00	1	1
01/07/2015 19:00	1	1
01/07/2015 20:00	1	1
01/07/2015 21:00	1	1
01/07/2015 22:00	1	1
01/07/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/08/2015 00:00	1	1
01/08/2015 01:00	1	1
01/08/2015 02:00	1	1
01/08/2015 03:00	1	1
01/08/2015 04:00	1	1
01/08/2015 05:00	1	1
01/08/2015 06:00	1	1
01/08/2015 07:00	1	1
01/08/2015 08:00	1	1
01/08/2015 09:00	1	1
01/08/2015 10:00	1	1
01/08/2015 11:00	1	1
01/08/2015 12:00	1	1
01/08/2015 13:00	1	1
01/08/2015 14:00	1	1
01/08/2015 15:00	1	1
01/08/2015 16:00	1	1
01/08/2015 17:00	1	1
01/08/2015 18:00	1	1
01/08/2015 19:00	1	1
01/08/2015 20:00	1	1
01/08/2015 21:00	1	1
01/08/2015 22:00	1	1
01/08/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/09/2015 00:00	1	1
01/09/2015 01:00	1	1
01/09/2015 02:00	1	1
01/09/2015 03:00	1	1
01/09/2015 04:00	1	1
01/09/2015 05:00	1	1
01/09/2015 06:00	1	1
01/09/2015 07:00	1	1
01/09/2015 08:00	1	1
01/09/2015 09:00	1	1
01/09/2015 10:00	1	1
01/09/2015 11:00	1	1
01/09/2015 12:00	1	1
01/09/2015 13:00	1	1
01/09/2015 14:00	1	1
01/09/2015 15:00	1	1
01/09/2015 16:00	1	1
01/09/2015 17:00	1	1
01/09/2015 18:00	1	1
01/09/2015 19:00	1	1
01/09/2015 20:00	1	1
01/09/2015 21:00	1	1
01/09/2015 22:00	1	1
01/09/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/10/2015 00:00	1	1
01/10/2015 01:00	1	1
01/10/2015 02:00	1	1
01/10/2015 03:00	1	1
01/10/2015 04:00	1	1
01/10/2015 05:00	1	1
01/10/2015 06:00	1	1
01/10/2015 07:00	1	1
01/10/2015 08:00	1	1
01/10/2015 09:00	1	1
01/10/2015 10:00	1	1
01/10/2015 11:00	1	1
01/10/2015 12:00	1	1
01/10/2015 13:00	1	1
01/10/2015 14:00	1	1
01/10/2015 15:00	1	1
01/10/2015 16:00	1	1
01/10/2015 17:00	1	1
01/10/2015 18:00	1	1
01/10/2015 19:00	1	1
01/10/2015 20:00	1	1
01/10/2015 21:00	1	1
01/10/2015 22:00	1	1
01/10/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/11/2015 00:00	1	1
01/11/2015 01:00	1	1
01/11/2015 02:00	1	1
01/11/2015 03:00	1	1
01/11/2015 04:00	1	1
01/11/2015 05:00	1	1
01/11/2015 06:00	1	1
01/11/2015 07:00	1	1
01/11/2015 08:00	1	1
01/11/2015 09:00	1	1
01/11/2015 10:00	1	1
01/11/2015 11:00	1	1
01/11/2015 12:00	1	1
01/11/2015 13:00	1	1
01/11/2015 14:00	1	1
01/11/2015 15:00	1	1
01/11/2015 16:00	1	1
01/11/2015 17:00	1	1
01/11/2015 18:00	1	1
01/11/2015 19:00	1	1
01/11/2015 20:00	1	1
01/11/2015 21:00	1	1
01/11/2015 22:00	1	1
01/11/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/12/2015 00:00	1	1
01/12/2015 01:00	1	1
01/12/2015 02:00	1	1
01/12/2015 03:00	1	1
01/12/2015 04:00	1	1
01/12/2015 05:00	1	1
01/12/2015 06:00	1	1
01/12/2015 07:00	1	1
01/12/2015 08:00	1	1
01/12/2015 09:00	1	1
01/12/2015 10:00	1	1
01/12/2015 11:00	1	1
01/12/2015 12:00	1	1
01/12/2015 13:00	1	1
01/12/2015 14:00	1	1
01/12/2015 15:00	1	1
01/12/2015 16:00	1	1
01/12/2015 17:00	1	1
01/12/2015 18:00	1	1
01/12/2015 19:00	1	1
01/12/2015 20:00	1	1
01/12/2015 21:00	1	1
01/12/2015 22:00	1	1
01/12/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/13/2015 00:00	1	1
01/13/2015 01:00	1	1
01/13/2015 02:00	1	1
01/13/2015 03:00	1	1
01/13/2015 04:00	1	1
01/13/2015 05:00	1	1
01/13/2015 06:00	1	1
01/13/2015 07:00	1	1
01/13/2015 08:00	1	1
01/13/2015 09:00	1	1
01/13/2015 10:00	1	1
01/13/2015 11:00	1	1
01/13/2015 12:00	1	1
01/13/2015 13:00	1	1
01/13/2015 14:00	1	1
01/13/2015 15:00	1	1
01/13/2015 16:00	1	1
01/13/2015 17:00	1	1
01/13/2015 18:00	1	1
01/13/2015 19:00	1	1
01/13/2015 20:00	1	1
01/13/2015 21:00	1	1
01/13/2015 22:00	1	1
01/13/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/14/2015 00:00	1	1
01/14/2015 01:00	1	1
01/14/2015 02:00	1	1
01/14/2015 03:00	1	1
01/14/2015 04:00	1	1
01/14/2015 05:00	1	1
01/14/2015 06:00	1	1
01/14/2015 07:00	1	1
01/14/2015 08:00	1	1
01/14/2015 09:00	1	1
01/14/2015 10:00	1	1
01/14/2015 11:00	1	1
01/14/2015 12:00	1	1
01/14/2015 13:00	1	1
01/14/2015 14:00	1	1
01/14/2015 15:00	1	1
01/14/2015 16:00	1	1
01/14/2015 17:00	1	1
01/14/2015 18:00	1	1
01/14/2015 19:00	1	1
01/14/2015 20:00	1	1
01/14/2015 21:00	1	1
01/14/2015 22:00	1	1
01/14/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/15/2015 00:00	1	1
01/15/2015 01:00	1	1
01/15/2015 02:00	1	1
01/15/2015 03:00	1	1
01/15/2015 04:00	1	1
01/15/2015 05:00	1	1
01/15/2015 06:00	1	1
01/15/2015 07:00	1	1
01/15/2015 08:00	1	1
01/15/2015 09:00	1	1
01/15/2015 10:00	1	1
01/15/2015 11:00	1	1
01/15/2015 12:00	1	1
01/15/2015 13:00	1	1
01/15/2015 14:00	1	1
01/15/2015 15:00	1	1
01/15/2015 16:00	1	1
01/15/2015 17:00	1	1
01/15/2015 18:00	1	1
01/15/2015 19:00	1	1
01/15/2015 20:00	1	1
01/15/2015 21:00	1	1
01/15/2015 22:00	1	1
01/15/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/16/2015 00:00	1	1
01/16/2015 01:00	1	1
01/16/2015 02:00	1	1
01/16/2015 03:00	1	1
01/16/2015 04:00	1	1
01/16/2015 05:00	1	1
01/16/2015 06:00	1	1
01/16/2015 07:00	1	1
01/16/2015 08:00	1	1
01/16/2015 09:00	1	1
01/16/2015 10:00	1	1
01/16/2015 11:00	1	1
01/16/2015 12:00	1	1
01/16/2015 13:00	1	1
01/16/2015 14:00	1	1
01/16/2015 15:00	1	1
01/16/2015 16:00	1	2
01/16/2015 17:00	1	3
01/16/2015 18:00	1	5
01/16/2015 19:00	1	5
01/16/2015 20:00	1	4
01/16/2015 21:00	1	3
01/16/2015 22:00	1	1
01/16/2015 23:00	1	1
Average/Sum#:	1	2
Minimum:	1	1
Maximum:	1	5
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/17/2015 00:00	1	1
01/17/2015 01:00	1	1
01/17/2015 02:00	1	1
01/17/2015 03:00	1	1
01/17/2015 04:00	1	1
01/17/2015 05:00	1	1
01/17/2015 06:00	1	1
01/17/2015 07:00	1	1
01/17/2015 08:00	1	1
01/17/2015 09:00	1	1
01/17/2015 10:00	1	1
01/17/2015 11:00	1	1
01/17/2015 12:00	1	1
01/17/2015 13:00	1	1
01/17/2015 14:00	1	1
01/17/2015 15:00	1	1
01/17/2015 16:00	1	1
01/17/2015 17:00	1	1
01/17/2015 18:00	1	1
01/17/2015 19:00	1	1
01/17/2015 20:00	1	1
01/17/2015 21:00	1	1
01/17/2015 22:00	1	1
01/17/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/18/2015 00:00	1	1
01/18/2015 01:00	1	1
01/18/2015 02:00	1	2
01/18/2015 03:00	1	2
01/18/2015 04:00	1	2
01/18/2015 05:00	1	2
01/18/2015 06:00	1	2
01/18/2015 07:00	1	2
01/18/2015 08:00	1	2
01/18/2015 09:00	1	2
01/18/2015 10:00	1	13
01/18/2015 11:00	1	17
01/18/2015 12:00	1	17
01/18/2015 13:00	1	16
01/18/2015 14:00	11	5
01/18/2015 15:00	16	1
01/18/2015 16:00	16	1
01/18/2015 17:00	15	1
01/18/2015 18:00	5	1
01/18/2015 19:00	1	1
01/18/2015 20:00	1	1
01/18/2015 21:00	1	1
01/18/2015 22:00	1	1
01/18/2015 23:00	1	1
Average/Sum#:	3	4
Minimum:	1	1
Maximum:	16	17
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/19/2015 00:00	1	1
01/19/2015 01:00	1	1
01/19/2015 02:00	1	1
01/19/2015 03:00	1	1
01/19/2015 04:00	1	1
01/19/2015 05:00	1	1
01/19/2015 06:00	1	1
01/19/2015 07:00	1	1
01/19/2015 08:00	1	1
01/19/2015 09:00	1	1
01/19/2015 10:00	1	1
01/19/2015 11:00	1	1
01/19/2015 12:00	1	1
01/19/2015 13:00	1	1
01/19/2015 14:00	1	1
01/19/2015 15:00	1	1
01/19/2015 16:00	1	1
01/19/2015 17:00	1	1
01/19/2015 18:00	1	1
01/19/2015 19:00	1	1
01/19/2015 20:00	1	1
01/19/2015 21:00	1	1
01/19/2015 22:00	1	1
01/19/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/20/2015 00:00	1	1
01/20/2015 01:00	1	1
01/20/2015 02:00	1	1
01/20/2015 03:00	1	1
01/20/2015 04:00	1	1
01/20/2015 05:00	1	1
01/20/2015 06:00	1	1
01/20/2015 07:00	1	1
01/20/2015 08:00	1	1
01/20/2015 09:00	1	1
01/20/2015 10:00	1	1
01/20/2015 11:00	1	1
01/20/2015 12:00	1	1
01/20/2015 13:00	1	1
01/20/2015 14:00	1	1
01/20/2015 15:00	1	1
01/20/2015 16:00	1	1
01/20/2015 17:00	1	1
01/20/2015 18:00	1	1
01/20/2015 19:00	1	1
01/20/2015 20:00	1	1
01/20/2015 21:00	1	1
01/20/2015 22:00	1	1
01/20/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/21/2015 00:00	1	1
01/21/2015 01:00	1	1
01/21/2015 02:00	1	1
01/21/2015 03:00	1	1
01/21/2015 04:00	1	1
01/21/2015 05:00	1	1
01/21/2015 06:00	1	1
01/21/2015 07:00	1	1
01/21/2015 08:00	1	1
01/21/2015 09:00	1	1
01/21/2015 10:00	1	1
01/21/2015 11:00	1	1
01/21/2015 12:00	1	1
01/21/2015 13:00	1	1
01/21/2015 14:00	1	1
01/21/2015 15:00	1	1
01/21/2015 16:00	1	1
01/21/2015 17:00	1	1
01/21/2015 18:00	1	1
01/21/2015 19:00	1	1
01/21/2015 20:00	1	1
01/21/2015 21:00	1	1
01/21/2015 22:00	1	1
01/21/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/22/2015 00:00	1	1
01/22/2015 01:00	1	1
01/22/2015 02:00	1	1
01/22/2015 03:00	1	1
01/22/2015 04:00	1	1
01/22/2015 05:00	1	1
01/22/2015 06:00	1	1
01/22/2015 07:00	1	1
01/22/2015 08:00	1	1
01/22/2015 09:00	1	1
01/22/2015 10:00	1	1
01/22/2015 11:00	1	1
01/22/2015 12:00	1	1
01/22/2015 13:00	1	1
01/22/2015 14:00	1	1
01/22/2015 15:00	1	1
01/22/2015 16:00	1	1
01/22/2015 17:00	1	1
01/22/2015 18:00	1	1
01/22/2015 19:00	1	1
01/22/2015 20:00	1	1
01/22/2015 21:00	1	1
01/22/2015 22:00	1	1
01/22/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/23/2015 00:00	1	1
01/23/2015 01:00	1	1
01/23/2015 02:00	1	1
01/23/2015 03:00	1	1
01/23/2015 04:00	1	1
01/23/2015 05:00	1	1
01/23/2015 06:00	1	1
01/23/2015 07:00	1	1
01/23/2015 08:00	1	1
01/23/2015 09:00	1	1
01/23/2015 10:00	1	1
01/23/2015 11:00	1	1
01/23/2015 12:00	1	1
01/23/2015 13:00	1	1
01/23/2015 14:00	1	1
01/23/2015 15:00	1	1
01/23/2015 16:00	1	1
01/23/2015 17:00	1	1
01/23/2015 18:00	1	1
01/23/2015 19:00	1	1
01/23/2015 20:00	1	1
01/23/2015 21:00	1	1
01/23/2015 22:00	1	1
01/23/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/24/2015 00:00	1	1
01/24/2015 01:00	1	1
01/24/2015 02:00	1	1
01/24/2015 03:00	1	1
01/24/2015 04:00	1	1
01/24/2015 05:00	1	1
01/24/2015 06:00	1	1
01/24/2015 07:00	1	1
01/24/2015 08:00	1	1
01/24/2015 09:00	1	1
01/24/2015 10:00	1	1
01/24/2015 11:00	1	1
01/24/2015 12:00	1	1
01/24/2015 13:00	1	1
01/24/2015 14:00	1	1
01/24/2015 15:00	1	1
01/24/2015 16:00	1	1
01/24/2015 17:00	1	1
01/24/2015 18:00	1	1
01/24/2015 19:00	1	1
01/24/2015 20:00	1	1
01/24/2015 21:00	1	1
01/24/2015 22:00	1	1
01/24/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/25/2015 00:00	1	1
01/25/2015 01:00	2	3
01/25/2015 02:00	2	3
01/25/2015 03:00	2	3
01/25/2015 04:00	2	3
01/25/2015 05:00	2	3
01/25/2015 06:00	2	3
01/25/2015 07:00	2	3
01/25/2015 08:00	2	3
01/25/2015 09:00	2	3
01/25/2015 10:00	2	3
01/25/2015 11:00	2	3
01/25/2015 12:00	14	3
01/25/2015 13:00	19	3
01/25/2015 14:00	20	3
01/25/2015 15:00	18	3
01/25/2015 16:00	7	3
01/25/2015 17:00	2	3
01/25/2015 18:00	1	3
01/25/2015 19:00	1	3
01/25/2015 20:00	1	3
01/25/2015 21:00	1	3
01/25/2015 22:00	1	3
01/25/2015 23:00	1	3
Average/Sum#:	5	3
Minimum:	1	1
Maximum:	20	3
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/26/2015 00:00	1	3
01/26/2015 01:00	1	3
01/26/2015 02:00	1	3
01/26/2015 03:00	1	3
01/26/2015 04:00	6	3
01/26/2015 05:00	8	3
01/26/2015 06:00	8	3
01/26/2015 07:00	8	3
01/26/2015 08:00	2	3
01/26/2015 09:00	1	3
01/26/2015 10:00	1	3
01/26/2015 11:00	1	3
01/26/2015 12:00	1	3
01/26/2015 13:00	1	3
01/26/2015 14:00	1	3
01/26/2015 15:00	1	3
01/26/2015 16:00	1	3
01/26/2015 17:00	1	3
01/26/2015 18:00	1	3
01/26/2015 19:00	1	3
01/26/2015 20:00	1	3
01/26/2015 21:00	1	3
01/26/2015 22:00	1	3
01/26/2015 23:00	1	3
Average/Sum#:	2	3
Minimum:	1	3
Maximum:	8	3
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/27/2015 00:00	1	3
01/27/2015 01:00	1	3
01/27/2015 02:00	1	16
01/27/2015 03:00	1	20
01/27/2015 04:00	1	24
01/27/2015 05:00	1	24
01/27/2015 06:00	1	24
01/27/2015 07:00	1	24
01/27/2015 08:00	1	13
01/27/2015 09:00	1	9
01/27/2015 10:00	1	8
01/27/2015 11:00	1	0
01/27/2015 12:00	1	0
01/27/2015 13:00	1	0
01/27/2015 14:00	1	0
01/27/2015 15:00	1	1
01/27/2015 16:00	1	1
01/27/2015 17:00	1	1
01/27/2015 18:00	1	1
01/27/2015 19:00	1	1
01/27/2015 20:00	1	1
01/27/2015 21:00	1	1
01/27/2015 22:00	1	1
01/27/2015 23:00	1	1
Average/Sum#:	1	9
Minimum:	1	1
Maximum:	1	24
%SI	0	17

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/28/2015 00:00	1	1
01/28/2015 01:00	1	1
01/28/2015 02:00	1	1
01/28/2015 03:00	1	1
01/28/2015 04:00	1	1
01/28/2015 05:00	1	1
01/28/2015 06:00	1	1
01/28/2015 07:00	1	1
01/28/2015 08:00	1	1
01/28/2015 09:00	1	1
01/28/2015 10:00	1	1
01/28/2015 11:00	1	1
01/28/2015 12:00	1	1
01/28/2015 13:00	1	1
01/28/2015 14:00	1	1
01/28/2015 15:00	1	1
01/28/2015 16:00	1	1
01/28/2015 17:00	1	1
01/28/2015 18:00	1	1
01/28/2015 19:00	1	1
01/28/2015 20:00	1	1
01/28/2015 21:00	1	1
01/28/2015 22:00	1	1
01/28/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/29/2015 00:00	1	1
01/29/2015 01:00	1	1
01/29/2015 02:00	1	1
01/29/2015 03:00	1	1
01/29/2015 04:00	1	1
01/29/2015 05:00	1	1
01/29/2015 06:00	1	1
01/29/2015 07:00	1	1
01/29/2015 08:00	1	1
01/29/2015 09:00	1	1
01/29/2015 10:00	1	1
01/29/2015 11:00	1	1
01/29/2015 12:00	1	1
01/29/2015 13:00	1	1
01/29/2015 14:00	1	1
01/29/2015 15:00	1	1
01/29/2015 16:00	1	1
01/29/2015 17:00	1	1
01/29/2015 18:00	1	1
01/29/2015 19:00	1	1
01/29/2015 20:00	1	1
01/29/2015 21:00	1	1
01/29/2015 22:00	1	1
01/29/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/30/2015 00:00	1	1
01/30/2015 01:00	1	1
01/30/2015 02:00	1	1
01/30/2015 03:00	1	1
01/30/2015 04:00	1	1
01/30/2015 05:00	1	1
01/30/2015 06:00	1	1
01/30/2015 07:00	1	1
01/30/2015 08:00	1	1
01/30/2015 09:00	1	1
01/30/2015 10:00	1	1
01/30/2015 11:00	1	1
01/30/2015 12:00	1	1
01/30/2015 13:00	1	1
01/30/2015 14:00	1	1
01/30/2015 15:00	1	1
01/30/2015 16:00	1	1
01/30/2015 17:00	1	1
01/30/2015 18:00	1	1
01/30/2015 19:00	1	1
01/30/2015 20:00	1	1
01/30/2015 21:00	1	1
01/30/2015 22:00	1	1
01/30/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/31/2015 00:00	2	1
01/31/2015 01:00	2	1
01/31/2015 02:00	2	1
01/31/2015 03:00	4	1
01/31/2015 04:00	7	1
01/31/2015 05:00	7	1
01/31/2015 06:00	6	1
01/31/2015 07:00	4	1
01/31/2015 08:00	1	1
01/31/2015 09:00	1	1
01/31/2015 10:00	1	1
01/31/2015 11:00	1	1
01/31/2015 12:00	1	1
01/31/2015 13:00	1	1
01/31/2015 14:00	1	1
01/31/2015 15:00	1	1
01/31/2015 16:00	1	1
01/31/2015 17:00	1	1
01/31/2015 18:00	1	1
01/31/2015 19:00	1	1
01/31/2015 20:00	1	1
01/31/2015 21:00	1	1
01/31/2015 22:00	1	1
01/31/2015 23:00	1	1
Average/Sum#:	2	1
Minimum:	1	1
Maximum:	7	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/01/2015 00:00	1	1
02/01/2015 01:00	1	1
02/01/2015 02:00	2	3
02/01/2015 03:00	2	3
02/01/2015 04:00	2	3
02/01/2015 05:00	2	3
02/01/2015 06:00	2	3
02/01/2015 07:00	2	3
02/01/2015 08:00	2	3
02/01/2015 09:00	2	3
02/01/2015 10:00	14	3
02/01/2015 11:00	18	3
02/01/2015 12:00	17	3
02/01/2015 13:00	16	3
02/01/2015 14:00	5	15
02/01/2015 15:00	1	19
02/01/2015 16:00	1	19
02/01/2015 17:00	1	16
02/01/2015 18:00	1	4
02/01/2015 19:00	1	1
02/01/2015 20:00	1	1
02/01/2015 21:00	1	1
02/01/2015 22:00	1	1
02/01/2015 23:00	1	1
Average/Sum#:	4	5
Minimum:	1	1
Maximum:	18	19
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/02/2015 00:00	1	1
02/02/2015 01:00	1	1
02/02/2015 02:00	1	1
02/02/2015 03:00	1	1
02/02/2015 04:00	1	1
02/02/2015 05:00	1	1
02/02/2015 06:00	1	1
02/02/2015 07:00	1	1
02/02/2015 08:00	1	1
02/02/2015 09:00	1	1
02/02/2015 10:00	1	1
02/02/2015 11:00	1	1
02/02/2015 12:00	1	1
02/02/2015 13:00	1	1
02/02/2015 14:00	1	1
02/02/2015 15:00	1	1
02/02/2015 16:00	1	1
02/02/2015 17:00	1	1
02/02/2015 18:00	1	1
02/02/2015 19:00	1	1
02/02/2015 20:00	1	1
02/02/2015 21:00	1	1
02/02/2015 22:00	1	1
02/02/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/03/2015 00:00	1	1
02/03/2015 01:00	1	1
02/03/2015 02:00	1	1
02/03/2015 03:00	1	1
02/03/2015 04:00	1	1
02/03/2015 05:00	1	1
02/03/2015 06:00	1	1
02/03/2015 07:00	1	1
02/03/2015 08:00	1	1
02/03/2015 09:00	1	1
02/03/2015 10:00	1	1
02/03/2015 11:00	1	1
02/03/2015 12:00	1	1
02/03/2015 13:00	1	1
02/03/2015 14:00	1	1
02/03/2015 15:00	1	1
02/03/2015 16:00	1	1
02/03/2015 17:00	1	1
02/03/2015 18:00	1	1
02/03/2015 19:00	1	1
02/03/2015 20:00	1	1
02/03/2015 21:00	1	1
02/03/2015 22:00	1	1
02/03/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/04/2015 00:00	1	1
02/04/2015 01:00	1	1
02/04/2015 02:00	1	1
02/04/2015 03:00	1	1
02/04/2015 04:00	1	1
02/04/2015 05:00	1	1
02/04/2015 06:00	1	1
02/04/2015 07:00	1	1
02/04/2015 08:00	1	1
02/04/2015 09:00	1	1
02/04/2015 10:00	1	1
02/04/2015 11:00	1	1
02/04/2015 12:00	1	1
02/04/2015 13:00	1	1
02/04/2015 14:00	1	1
02/04/2015 15:00	1	1
02/04/2015 16:00	1	1
02/04/2015 17:00	1	1
02/04/2015 18:00	1	1
02/04/2015 19:00	1	1
02/04/2015 20:00	1	1
02/04/2015 21:00	1	1
02/04/2015 22:00	1	1
02/04/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/05/2015 00:00	1	1
02/05/2015 01:00	1	1
02/05/2015 02:00	1	1
02/05/2015 03:00	1	1
02/05/2015 04:00	1	1
02/05/2015 05:00	1	1
02/05/2015 06:00	1	1
02/05/2015 07:00	1	1
02/05/2015 08:00	1	1
02/05/2015 09:00	1	1
02/05/2015 10:00	1	1
02/05/2015 11:00	1	1
02/05/2015 12:00	1	1
02/05/2015 13:00	1	1
02/05/2015 14:00	1	1
02/05/2015 15:00	1	1
02/05/2015 16:00	1	1
02/05/2015 17:00	1	1
02/05/2015 18:00	1	1
02/05/2015 19:00	1	1
02/05/2015 20:00	1	1
02/05/2015 21:00	1	1
02/05/2015 22:00	1	1
02/05/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/06/2015 00:00	1	1
02/06/2015 01:00	1	1
02/06/2015 02:00	1	1
02/06/2015 03:00	1	1
02/06/2015 04:00	1	1
02/06/2015 05:00	1	1
02/06/2015 06:00	1	1
02/06/2015 07:00	1	1
02/06/2015 08:00	1	1
02/06/2015 09:00	1	1
02/06/2015 10:00	1	1
02/06/2015 11:00	1	1
02/06/2015 12:00	1	1
02/06/2015 13:00	1	1
02/06/2015 14:00	1	1
02/06/2015 15:00	1	1
02/06/2015 16:00	1	1
02/06/2015 17:00	1	1
02/06/2015 18:00	1	1
02/06/2015 19:00	1	1
02/06/2015 20:00	1	1
02/06/2015 21:00	1	1
02/06/2015 22:00	1	1
02/06/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/07/2015 00:00	1	1
02/07/2015 01:00	1	1
02/07/2015 02:00	1	1
02/07/2015 03:00	1	1
02/07/2015 04:00	1	1
02/07/2015 05:00	1	1
02/07/2015 06:00	1	1
02/07/2015 07:00	1	1
02/07/2015 08:00	1	1
02/07/2015 09:00	1	1
02/07/2015 10:00	1	1
02/07/2015 11:00	1	1
02/07/2015 12:00	1	1
02/07/2015 13:00	1	1
02/07/2015 14:00	1	1
02/07/2015 15:00	1	1
02/07/2015 16:00	1	1
02/07/2015 17:00	1	1
02/07/2015 18:00	1	1
02/07/2015 19:00	1	1
02/07/2015 20:00	1	1
02/07/2015 21:00	1	1
02/07/2015 22:00	1	1
02/07/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/08/2015 00:00	1	1
02/08/2015 01:00	1	1
02/08/2015 02:00	1	1
02/08/2015 03:00	1	1
02/08/2015 04:00	1	1
02/08/2015 05:00	1	1
02/08/2015 06:00	1	1
02/08/2015 07:00	1	1
02/08/2015 08:00	1	1
02/08/2015 09:00	1	1
02/08/2015 10:00	1	1
02/08/2015 11:00	1	1
02/08/2015 12:00	1	1
02/08/2015 13:00	1	1
02/08/2015 14:00	1	1
02/08/2015 15:00	1	1
02/08/2015 16:00	1	1
02/08/2015 17:00	1	1
02/08/2015 18:00	1	1
02/08/2015 19:00	1	1
02/08/2015 20:00	1	1
02/08/2015 21:00	1	1
02/08/2015 22:00	1	1
02/08/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/09/2015 00:00	1	1
02/09/2015 01:00	1	1
02/09/2015 02:00	1	1
02/09/2015 03:00	1	1
02/09/2015 04:00	1	1
02/09/2015 05:00	1	1
02/09/2015 06:00	1	1
02/09/2015 07:00	1	1
02/09/2015 08:00	1	1
02/09/2015 09:00	1	1
02/09/2015 10:00	1	1
02/09/2015 11:00	1	1
02/09/2015 12:00	1	1
02/09/2015 13:00	1	1
02/09/2015 14:00	1	1
02/09/2015 15:00	1	1
02/09/2015 16:00	1	1
02/09/2015 17:00	1	1
02/09/2015 18:00	1	1
02/09/2015 19:00	1	1
02/09/2015 20:00	1	1
02/09/2015 21:00	1	1
02/09/2015 22:00	1	1
02/09/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/10/2015 00:00	1	1
02/10/2015 01:00	1	1
02/10/2015 02:00	1	1
02/10/2015 03:00	1	1
02/10/2015 04:00	1	1
02/10/2015 05:00	1	1
02/10/2015 06:00	1	1
02/10/2015 07:00	1	1
02/10/2015 08:00	1	1
02/10/2015 09:00	1	1
02/10/2015 10:00	1	1
02/10/2015 11:00	1	1
02/10/2015 12:00	1	1
02/10/2015 13:00	1	1
02/10/2015 14:00	1	1
02/10/2015 15:00	1	1
02/10/2015 16:00	1	1
02/10/2015 17:00	1	1
02/10/2015 18:00	1	1
02/10/2015 19:00	1	1
02/10/2015 20:00	1	1
02/10/2015 21:00	1	1
02/10/2015 22:00	1	1
02/10/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/11/2015 00:00	1	1
02/11/2015 01:00	1	1
02/11/2015 02:00	1	1
02/11/2015 03:00	1	1
02/11/2015 04:00	1	1
02/11/2015 05:00	1	1
02/11/2015 06:00	1	1
02/11/2015 07:00	1	1
02/11/2015 08:00	1	1
02/11/2015 09:00	1	1
02/11/2015 10:00	1	1
02/11/2015 11:00	1	1
02/11/2015 12:00	1	1
02/11/2015 13:00	1	1
02/11/2015 14:00	1	1
02/11/2015 15:00	1	1
02/11/2015 16:00	1	1
02/11/2015 17:00	1	1
02/11/2015 18:00	1	1
02/11/2015 19:00	1	1
02/11/2015 20:00	1	1
02/11/2015 21:00	1	1
02/11/2015 22:00	1	1
02/11/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/12/2015 00:00	1	1
02/12/2015 01:00	1	1
02/12/2015 02:00	1	1
02/12/2015 03:00	1	1
02/12/2015 04:00	1	1
02/12/2015 05:00	1	1
02/12/2015 06:00	1	1
02/12/2015 07:00	1	1
02/12/2015 08:00	1	1
02/12/2015 09:00	1	1
02/12/2015 10:00	1	1
02/12/2015 11:00	1	1
02/12/2015 12:00	1	1
02/12/2015 13:00	1	1
02/12/2015 14:00	1	1
02/12/2015 15:00	1	1
02/12/2015 16:00	1	1
02/12/2015 17:00	1	1
02/12/2015 18:00	1	1
02/12/2015 19:00	1	1
02/12/2015 20:00	1	1
02/12/2015 21:00	1	1
02/12/2015 22:00	1	1
02/12/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/13/2015 00:00	1	1
02/13/2015 01:00	1	1
02/13/2015 02:00	1	1
02/13/2015 03:00	1	1
02/13/2015 04:00	1	1
02/13/2015 05:00	1	1
02/13/2015 06:00	1	1
02/13/2015 07:00	1	1
02/13/2015 08:00	1	1
02/13/2015 09:00	1	1
02/13/2015 10:00	1	1
02/13/2015 11:00	1	1
02/13/2015 12:00	1	1
02/13/2015 13:00	1	1
02/13/2015 14:00	1	1
02/13/2015 15:00	1	1
02/13/2015 16:00	1	1
02/13/2015 17:00	1	1
02/13/2015 18:00	1	1
02/13/2015 19:00	1	1
02/13/2015 20:00	1	1
02/13/2015 21:00	1	1
02/13/2015 22:00	1	1
02/13/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/14/2015 00:00	1	1
02/14/2015 01:00	1	1
02/14/2015 02:00	1	1
02/14/2015 03:00	1	1
02/14/2015 04:00	1	1
02/14/2015 05:00	1	1
02/14/2015 06:00	1	1
02/14/2015 07:00	1	1
02/14/2015 08:00	1	1
02/14/2015 09:00	1	1
02/14/2015 10:00	1	1
02/14/2015 11:00	1	1
02/14/2015 12:00	1	1
02/14/2015 13:00	1	1
02/14/2015 14:00	1	1
02/14/2015 15:00	1	1
02/14/2015 16:00	1	1
02/14/2015 17:00	1	1
02/14/2015 18:00	1	1
02/14/2015 19:00	1	1
02/14/2015 20:00	1	1
02/14/2015 21:00	1	1
02/14/2015 22:00	1	1
02/14/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/15/2015 00:00	1	1
02/15/2015 01:00	1	1
02/15/2015 02:00	2	3
02/15/2015 03:00	2	3
02/15/2015 04:00	2	3
02/15/2015 05:00	2	3
02/15/2015 06:00	2	3
02/15/2015 07:00	2	3
02/15/2015 08:00	2	3
02/15/2015 09:00	2	3
02/15/2015 10:00	2	13
02/15/2015 11:00	2	17
02/15/2015 12:00	2	17
02/15/2015 13:00	2	15
02/15/2015 14:00	2	5
02/15/2015 15:00	2	1
02/15/2015 16:00	10	1
02/15/2015 17:00	15	1
02/15/2015 18:00	15	1
02/15/2015 19:00	14	1
02/15/2015 20:00	6	1
02/15/2015 21:00	1	1
02/15/2015 22:00	1	1
02/15/2015 23:00	1	1
Average/Sum#:	4	4
Minimum:	1	1
Maximum:	15	17
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/16/2015 00:00	1	1
02/16/2015 01:00	1	1
02/16/2015 02:00	1	1
02/16/2015 03:00	1	1
02/16/2015 04:00	1	1
02/16/2015 05:00	1	1
02/16/2015 06:00	1	1
02/16/2015 07:00	1	1
02/16/2015 08:00	1	1
02/16/2015 09:00	1	1
02/16/2015 10:00	1	1
02/16/2015 11:00	1	1
02/16/2015 12:00	1	1
02/16/2015 13:00	1	1
02/16/2015 14:00	1	1
02/16/2015 15:00	1	1
02/16/2015 16:00	1	1
02/16/2015 17:00	1	1
02/16/2015 18:00	1	1
02/16/2015 19:00	1	1
02/16/2015 20:00	1	1
02/16/2015 21:00	1	1
02/16/2015 22:00	1	1
02/16/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/17/2015 00:00	1	1
02/17/2015 01:00	1	1
02/17/2015 02:00	1	1
02/17/2015 03:00	1	1
02/17/2015 04:00	1	1
02/17/2015 05:00	1	1
02/17/2015 06:00	1	1
02/17/2015 07:00	1	1
02/17/2015 08:00	1	1
02/17/2015 09:00	1	1
02/17/2015 10:00	1	1
02/17/2015 11:00	1	1
02/17/2015 12:00	1	1
02/17/2015 13:00	1	1
02/17/2015 14:00	1	1
02/17/2015 15:00	1	1
02/17/2015 16:00	1	1
02/17/2015 17:00	1	1
02/17/2015 18:00	1	1
02/17/2015 19:00	1	1
02/17/2015 20:00	1	1
02/17/2015 21:00	1	1
02/17/2015 22:00	1	1
02/17/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/18/2015 00:00	1	1
02/18/2015 01:00	1	1
02/18/2015 02:00	1	1
02/18/2015 03:00	1	1
02/18/2015 04:00	1	1
02/18/2015 05:00	1	1
02/18/2015 06:00	1	1
02/18/2015 07:00	1	1
02/18/2015 08:00	1	1
02/18/2015 09:00	1	1
02/18/2015 10:00	1	1
02/18/2015 11:00	1	1
02/18/2015 12:00	1	1
02/18/2015 13:00	1	1
02/18/2015 14:00	1	1
02/18/2015 15:00	1	1
02/18/2015 16:00	1	1
02/18/2015 17:00	1	1
02/18/2015 18:00	1	1
02/18/2015 19:00	1	1
02/18/2015 20:00	1	1
02/18/2015 21:00	1	1
02/18/2015 22:00	1	1
02/18/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/19/2015 00:00	1	1
02/19/2015 01:00	1	1
02/19/2015 02:00	1	1
02/19/2015 03:00	1	1
02/19/2015 04:00	1	1
02/19/2015 05:00	1	1
02/19/2015 06:00	1	1
02/19/2015 07:00	1	1
02/19/2015 08:00	1	1
02/19/2015 09:00	1	1
02/19/2015 10:00	1	1
02/19/2015 11:00	1	1
02/19/2015 12:00	1	1
02/19/2015 13:00	1	1
02/19/2015 14:00	1	1
02/19/2015 15:00	1	1
02/19/2015 16:00	1	1
02/19/2015 17:00	1	1
02/19/2015 18:00	1	1
02/19/2015 19:00	1	1
02/19/2015 20:00	1	1
02/19/2015 21:00	1	1
02/19/2015 22:00	1	1
02/19/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/20/2015 00:00	1	1
02/20/2015 01:00	2	2
02/20/2015 02:00	2	2
02/20/2015 03:00	2	2
02/20/2015 04:00	2	2
02/20/2015 05:00	2	3
02/20/2015 06:00	2	3
02/20/2015 07:00	2	2
02/20/2015 08:00	2	2
02/20/2015 09:00	2	1
02/20/2015 10:00	2	1
02/20/2015 11:00	2	1
02/20/2015 12:00	2	3
02/20/2015 13:00	2	3
02/20/2015 14:00	2	3
02/20/2015 15:00	2	3
02/20/2015 16:00	2	3
02/20/2015 17:00	2	3
02/20/2015 18:00	2	3
02/20/2015 19:00	2	3
02/20/2015 20:00	2	3
02/20/2015 21:00	2	3
02/20/2015 22:00	2	3
02/20/2015 23:00	2	3
Average/Sum#:	2	2
Minimum:	1	1
Maximum:	2	3
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/21/2015 00:00	2	3
02/21/2015 01:00	2	3
02/21/2015 02:00	2	3
02/21/2015 03:00	2	3
02/21/2015 04:00	2	3
02/21/2015 05:00	2	3
02/21/2015 06:00	2	3
02/21/2015 07:00	2	3
02/21/2015 08:00	2	3
02/21/2015 09:00	2	3
02/21/2015 10:00	2	17
02/21/2015 11:00	2	21
02/21/2015 12:00	2	23
02/21/2015 13:00	2	20
02/21/2015 14:00	2	7
02/21/2015 15:00	13	2
02/21/2015 16:00	15	1
02/21/2015 17:00	15	1
02/21/2015 18:00	15	1
02/21/2015 19:00	4	1
02/21/2015 20:00	1	1
02/21/2015 21:00	1	1
02/21/2015 22:00	1	1
02/21/2015 23:00	1	1
Average/Sum#:	4	5
Minimum:	1	1
Maximum:	15	23
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/22/2015 00:00	1	1
02/22/2015 01:00	1	1
02/22/2015 02:00	1	1
02/22/2015 03:00	1	1
02/22/2015 04:00	1	1
02/22/2015 05:00	1	1
02/22/2015 06:00	3	1
02/22/2015 07:00	3	1
02/22/2015 08:00	3	1
02/22/2015 09:00	3	1
02/22/2015 10:00	3	1
02/22/2015 11:00	3	1
02/22/2015 12:00	3	1
02/22/2015 13:00	3	1
02/22/2015 14:00	3	18
02/22/2015 15:00	3	24
02/22/2015 16:00	3	24
02/22/2015 17:00	3	19
02/22/2015 18:00	3	6
02/22/2015 19:00	3	1
02/22/2015 20:00	3	1
02/22/2015 21:00	3	1
02/22/2015 22:00	3	2
02/22/2015 23:00	3	2
Average/Sum#:	3	5
Minimum:	1	1
Maximum:	3	24
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/23/2015 00:00	3	2
02/23/2015 01:00	3	2
02/23/2015 02:00	3	2
02/23/2015 03:00	3	8
02/23/2015 04:00	3	10
02/23/2015 05:00	3	10
02/23/2015 06:00	3	9
02/23/2015 07:00	3	4
02/23/2015 08:00	3	1
02/23/2015 09:00	3	1
02/23/2015 10:00	3	1
02/23/2015 11:00	3	1
02/23/2015 12:00	3	1
02/23/2015 13:00	3	1
02/23/2015 14:00	3	1
02/23/2015 15:00	3	1
02/23/2015 16:00	3	1
02/23/2015 17:00	3	1
02/23/2015 18:00	3	1
02/23/2015 19:00	3	1
02/23/2015 20:00	3	1
02/23/2015 21:00	3	1
02/23/2015 22:00	3	1
02/23/2015 23:00	3	1
Average/Sum#:	3	3
Minimum:	3	1
Maximum:	3	10
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/24/2015 00:00	3	1
02/24/2015 01:00	3	1
02/24/2015 02:00	3	1
02/24/2015 03:00	15	1
02/24/2015 04:00	23	1
02/24/2015 05:00	25	1
02/24/2015 06:00	23	1
02/24/2015 07:00	11	1
02/24/2015 08:00	3	1
02/24/2015 09:00	1	1
02/24/2015 10:00	1	1
02/24/2015 11:00	1	1
02/24/2015 12:00	1	1
02/24/2015 13:00	1	1
02/24/2015 14:00	1	1
02/24/2015 15:00	1	1
02/24/2015 16:00	1	1
02/24/2015 17:00	1	1
02/24/2015 18:00	1	1
02/24/2015 19:00	1	1
02/24/2015 20:00	1	1
02/24/2015 21:00	1	1
02/24/2015 22:00	1	1
02/24/2015 23:00	1	1
Average/Sum#:	5	1
Minimum:	1	1
Maximum:	25	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/25/2015 00:00	1	1
02/25/2015 01:00	1	1
02/25/2015 02:00	1	1
02/25/2015 03:00	1	1
02/25/2015 04:00	1	1
02/25/2015 05:00	1	1
02/25/2015 06:00	1	1
02/25/2015 07:00	1	1
02/25/2015 08:00	1	1
02/25/2015 09:00	1	1
02/25/2015 10:00	1	1
02/25/2015 11:00	1	1
02/25/2015 12:00	1	1
02/25/2015 13:00	1	1
02/25/2015 14:00	1	1
02/25/2015 15:00	1	1
02/25/2015 16:00	1	1
02/25/2015 17:00	1	1
02/25/2015 18:00	1	1
02/25/2015 19:00	1	1
02/25/2015 20:00	1	1
02/25/2015 21:00	1	1
02/25/2015 22:00	1	1
02/25/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/26/2015 00:00	1	1
02/26/2015 01:00	1	1
02/26/2015 02:00	1	1
02/26/2015 03:00	1	1
02/26/2015 04:00	1	1
02/26/2015 05:00	1	1
02/26/2015 06:00	1	1
02/26/2015 07:00	1	1
02/26/2015 08:00	1	1
02/26/2015 09:00	1	1
02/26/2015 10:00	1	1
02/26/2015 11:00	1	1
02/26/2015 12:00	1	1
02/26/2015 13:00	1	1
02/26/2015 14:00	1	1
02/26/2015 15:00	1	1
02/26/2015 16:00	1	1
02/26/2015 17:00	1	1
02/26/2015 18:00	1	1
02/26/2015 19:00	1	1
02/26/2015 20:00	1	1
02/26/2015 21:00	1	1
02/26/2015 22:00	1	1
02/26/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/27/2015 00:00	1	1
02/27/2015 01:00	1	1
02/27/2015 02:00	1	1
02/27/2015 03:00	1	1
02/27/2015 04:00	1	1
02/27/2015 05:00	1	1
02/27/2015 06:00	1	1
02/27/2015 07:00	1	1
02/27/2015 08:00	1	1
02/27/2015 09:00	1	1
02/27/2015 10:00	1	1
02/27/2015 11:00	1	1
02/27/2015 12:00	1	1
02/27/2015 13:00	1	1
02/27/2015 14:00	1	1
02/27/2015 15:00	1	1
02/27/2015 16:00	1	1
02/27/2015 17:00	1	1
02/27/2015 18:00	1	1
02/27/2015 19:00	1	1
02/27/2015 20:00	1	1
02/27/2015 21:00	1	1
02/27/2015 22:00	1	1
02/27/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/28/2015 00:00	1	1
02/28/2015 01:00	2	3
02/28/2015 02:00	2	3
02/28/2015 03:00	2	3
02/28/2015 04:00	2	3
02/28/2015 05:00	2	3
02/28/2015 06:00	2	3
02/28/2015 07:00	2	3
02/28/2015 08:00	5	3
02/28/2015 09:00	7	3
02/28/2015 10:00	7	3
02/28/2015 11:00	6	3
02/28/2015 12:00	3	3
02/28/2015 13:00	1	3
02/28/2015 14:00	1	11
02/28/2015 15:00	1	20
02/28/2015 16:00	1	20
02/28/2015 17:00	1	18
02/28/2015 18:00	1	10
02/28/2015 19:00	1	1
02/28/2015 20:00	1	1
02/28/2015 21:00	1	1
02/28/2015 22:00	1	1
02/28/2015 23:00	1	1
Average/Sum#:	2	5
Minimum:	1	1
Maximum:	7	20
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/01/2015 00:00	1	1
03/01/2015 01:00	1	1
03/01/2015 02:00	1	1
03/01/2015 03:00	1	1
03/01/2015 04:00	1	1
03/01/2015 05:00	1	1
03/01/2015 06:00	1	1
03/01/2015 07:00	1	1
03/01/2015 08:00	1	1
03/01/2015 09:00	1	1
03/01/2015 10:00	1	1
03/01/2015 11:00	1	1
03/01/2015 12:00	1	1
03/01/2015 13:00	1	1
03/01/2015 14:00	1	1
03/01/2015 15:00	1	1
03/01/2015 16:00	1	1
03/01/2015 17:00	1	1
03/01/2015 18:00	1	1
03/01/2015 19:00	1	1
03/01/2015 20:00	1	1
03/01/2015 21:00	1	1
03/01/2015 22:00	1	1
03/01/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/02/2015 00:00	1	1
03/02/2015 01:00	1	1
03/02/2015 02:00	1	1
03/02/2015 03:00	1	1
03/02/2015 04:00	1	1
03/02/2015 05:00	1	1
03/02/2015 06:00	1	1
03/02/2015 07:00	1	1
03/02/2015 08:00	1	1
03/02/2015 09:00	1	1
03/02/2015 10:00	1	1
03/02/2015 11:00	1	1
03/02/2015 12:00	1	1
03/02/2015 13:00	1	1
03/02/2015 14:00	1	1
03/02/2015 15:00	1	1
03/02/2015 16:00	1	1
03/02/2015 17:00	1	1
03/02/2015 18:00	1	1
03/02/2015 19:00	1	1
03/02/2015 20:00	1	1
03/02/2015 21:00	1	1
03/02/2015 22:00	1	1
03/02/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/03/2015 00:00	1	1
03/03/2015 01:00	1	1
03/03/2015 02:00	1	1
03/03/2015 03:00	1	1
03/03/2015 04:00	1	1
03/03/2015 05:00	1	1
03/03/2015 06:00	1	1
03/03/2015 07:00	1	1
03/03/2015 08:00	1	1
03/03/2015 09:00	1	1
03/03/2015 10:00	1	1
03/03/2015 11:00	1	1
03/03/2015 12:00	1	1
03/03/2015 13:00	1	1
03/03/2015 14:00	1	1
03/03/2015 15:00	1	1
03/03/2015 16:00	1	1
03/03/2015 17:00	1	1
03/03/2015 18:00	1	1
03/03/2015 19:00	1	1
03/03/2015 20:00	1	1
03/03/2015 21:00	1	1
03/03/2015 22:00	1	1
03/03/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/04/2015 00:00	1	1
03/04/2015 01:00	1	1
03/04/2015 02:00	1	1
03/04/2015 03:00	1	1
03/04/2015 04:00	1	1
03/04/2015 05:00	1	1
03/04/2015 06:00	1	1
03/04/2015 07:00	1	1
03/04/2015 08:00	1	1
03/04/2015 09:00	1	1
03/04/2015 10:00	1	1
03/04/2015 11:00	1	1
03/04/2015 12:00	1	1
03/04/2015 13:00	1	1
03/04/2015 14:00	1	1
03/04/2015 15:00	1	1
03/04/2015 16:00	1	1
03/04/2015 17:00	1	1
03/04/2015 18:00	1	1
03/04/2015 19:00	1	1
03/04/2015 20:00	1	1
03/04/2015 21:00	1	1
03/04/2015 22:00	1	1
03/04/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/05/2015 00:00	1	1
03/05/2015 01:00	1	1
03/05/2015 02:00	1	1
03/05/2015 03:00	1	1
03/05/2015 04:00	1	1
03/05/2015 05:00	1	1
03/05/2015 06:00	1	1
03/05/2015 07:00	1	1
03/05/2015 08:00	1	1
03/05/2015 09:00	1	1
03/05/2015 10:00	1	1
03/05/2015 11:00	1	1
03/05/2015 12:00	1	1
03/05/2015 13:00	1	1
03/05/2015 14:00	1	1
03/05/2015 15:00	1	1
03/05/2015 16:00	1	1
03/05/2015 17:00	1	1
03/05/2015 18:00	1	1
03/05/2015 19:00	1	1
03/05/2015 20:00	1	1
03/05/2015 21:00	1	1
03/05/2015 22:00	1	1
03/05/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/06/2015 00:00	1	1
03/06/2015 01:00	1	1
03/06/2015 02:00	1	1
03/06/2015 03:00	1	1
03/06/2015 04:00	1	1
03/06/2015 05:00	1	1
03/06/2015 06:00	1	1
03/06/2015 07:00	1	1
03/06/2015 08:00	1	1
03/06/2015 09:00	1	1
03/06/2015 10:00	1	1
03/06/2015 11:00	1	1
03/06/2015 12:00	1	1
03/06/2015 13:00	1	1
03/06/2015 14:00	1	1
03/06/2015 15:00	1	1
03/06/2015 16:00	1	1
03/06/2015 17:00	1	1
03/06/2015 18:00	1	1
03/06/2015 19:00	1	1
03/06/2015 20:00	1	1
03/06/2015 21:00	1	1
03/06/2015 22:00	1	1
03/06/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/07/2015 00:00	1	1
03/07/2015 01:00	1	1
03/07/2015 02:00	3	3
03/07/2015 03:00	3	3
03/07/2015 04:00	3	3
03/07/2015 05:00	3	3
03/07/2015 06:00	3	3
03/07/2015 07:00	3	3
03/07/2015 08:00	3	3
03/07/2015 09:00	3	3
03/07/2015 10:00	8	3
03/07/2015 11:00	11	3
03/07/2015 12:00	11	3
03/07/2015 13:00	9	3
03/07/2015 14:00	4	14
03/07/2015 15:00	1	19
03/07/2015 16:00	1	18
03/07/2015 17:00	1	16
03/07/2015 18:00	1	6
03/07/2015 19:00	1	1
03/07/2015 20:00	1	1
03/07/2015 21:00	1	1
03/07/2015 22:00	1	1
03/07/2015 23:00	1	1
Average/Sum#:	3	5
Minimum:	1	1
Maximum:	11	19
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/08/2015 00:00	1	1
03/08/2015 01:00	1	1
03/08/2015 02:00	1	1
03/08/2015 03:00	1	1
03/08/2015 04:00	1	1
03/08/2015 05:00	1	1
03/08/2015 06:00	1	1
03/08/2015 07:00	1	1
03/08/2015 08:00	2	3
03/08/2015 09:00	2	3
03/08/2015 10:00	2	4
03/08/2015 11:00	2	6
03/08/2015 12:00	2	5
03/08/2015 13:00	2	4
03/08/2015 14:00	2	3
03/08/2015 15:00	5	1
03/08/2015 16:00	6	1
03/08/2015 17:00	5	1
03/08/2015 18:00	5	1
03/08/2015 19:00	2	1
03/08/2015 20:00	1	1
03/08/2015 21:00	1	1
03/08/2015 22:00	1	1
03/08/2015 23:00	1	1
Average/Sum#:	2	2
Minimum:	1	1
Maximum:	6	6
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/09/2015 00:00	1	1
03/09/2015 01:00	1	1
03/09/2015 02:00	1	1
03/09/2015 03:00	1	1
03/09/2015 04:00	1	1
03/09/2015 05:00	1	1
03/09/2015 06:00	1	1
03/09/2015 07:00	1	1
03/09/2015 08:00	1	1
03/09/2015 09:00	1	1
03/09/2015 10:00	1	1
03/09/2015 11:00	1	1
03/09/2015 12:00	1	1
03/09/2015 13:00	1	1
03/09/2015 14:00	1	1
03/09/2015 15:00	1	1
03/09/2015 16:00	1	1
03/09/2015 17:00	1	1
03/09/2015 18:00	1	1
03/09/2015 19:00	1	1
03/09/2015 20:00	1	1
03/09/2015 21:00	1	1
03/09/2015 22:00	1	1
03/09/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/10/2015 00:00	1	1
03/10/2015 01:00	1	1
03/10/2015 02:00	1	1
03/10/2015 03:00	1	1
03/10/2015 04:00	1	1
03/10/2015 05:00	1	1
03/10/2015 06:00	1	1
03/10/2015 07:00	1	1
03/10/2015 08:00	1	1
03/10/2015 09:00	1	1
03/10/2015 10:00	1	1
03/10/2015 11:00	1	1
03/10/2015 12:00	1	1
03/10/2015 13:00	1	1
03/10/2015 14:00	1	1
03/10/2015 15:00	1	1
03/10/2015 16:00	1	1
03/10/2015 17:00	1	1
03/10/2015 18:00	1	1
03/10/2015 19:00	1	1
03/10/2015 20:00	1	1
03/10/2015 21:00	1	1
03/10/2015 22:00	1	1
03/10/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/11/2015 00:00	1	1
03/11/2015 01:00	1	1
03/11/2015 02:00	1	1
03/11/2015 03:00	1	1
03/11/2015 04:00	1	1
03/11/2015 05:00	1	1
03/11/2015 06:00	1	1
03/11/2015 07:00	1	1
03/11/2015 08:00	1	1
03/11/2015 09:00	1	1
03/11/2015 10:00	1	1
03/11/2015 11:00	1	1
03/11/2015 12:00	1	1
03/11/2015 13:00	1	1
03/11/2015 14:00	1	1
03/11/2015 15:00	1	1
03/11/2015 16:00	1	1
03/11/2015 17:00	1	1
03/11/2015 18:00	1	1
03/11/2015 19:00	1	1
03/11/2015 20:00	1	1
03/11/2015 21:00	1	1
03/11/2015 22:00	1	1
03/11/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/12/2015 00:00	1	1
03/12/2015 01:00	1	1
03/12/2015 02:00	1	1
03/12/2015 03:00	1	1
03/12/2015 04:00	1	1
03/12/2015 05:00	1	1
03/12/2015 06:00	1	1
03/12/2015 07:00	1	1
03/12/2015 08:00	1	1
03/12/2015 09:00	1	1
03/12/2015 10:00	1	1
03/12/2015 11:00	1	1
03/12/2015 12:00	1	1
03/12/2015 13:00	1	1
03/12/2015 14:00	1	1
03/12/2015 15:00	1	1
03/12/2015 16:00	1	1
03/12/2015 17:00	1	1
03/12/2015 18:00	1	1
03/12/2015 19:00	1	1
03/12/2015 20:00	1	1
03/12/2015 21:00	1	1
03/12/2015 22:00	1	1
03/12/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/13/2015 00:00	1	1
03/13/2015 01:00	1	1
03/13/2015 02:00	1	1
03/13/2015 03:00	1	1
03/13/2015 04:00	1	1
03/13/2015 05:00	1	1
03/13/2015 06:00	1	1
03/13/2015 07:00	1	1
03/13/2015 08:00	1	1
03/13/2015 09:00	1	1
03/13/2015 10:00	1	1
03/13/2015 11:00	1	1
03/13/2015 12:00	1	1
03/13/2015 13:00	1	1
03/13/2015 14:00	1	1
03/13/2015 15:00	1	1
03/13/2015 16:00	1	1
03/13/2015 17:00	1	1
03/13/2015 18:00	1	1
03/13/2015 19:00	1	1
03/13/2015 20:00	1	1
03/13/2015 21:00	1	1
03/13/2015 22:00	1	1
03/13/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/14/2015 00:00	1	1
03/14/2015 01:00	1	1
03/14/2015 02:00	1	1
03/14/2015 03:00	1	1
03/14/2015 04:00	1	1
03/14/2015 05:00	1	1
03/14/2015 06:00	1	1
03/14/2015 07:00	1	1
03/14/2015 08:00	1	1
03/14/2015 09:00	1	1
03/14/2015 10:00	1	1
03/14/2015 11:00	1	1
03/14/2015 12:00	1	1
03/14/2015 13:00	1	1
03/14/2015 14:00	1	1
03/14/2015 15:00	1	1
03/14/2015 16:00	1	1
03/14/2015 17:00	1	1
03/14/2015 18:00	1	1
03/14/2015 19:00	1	1
03/14/2015 20:00	1	1
03/14/2015 21:00	1	1
03/14/2015 22:00	1	1
03/14/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/15/2015 00:00	1	1
03/15/2015 01:00	1	1
03/15/2015 02:00	1	1
03/15/2015 03:00	1	1
03/15/2015 04:00	1	1
03/15/2015 05:00	1	1
03/15/2015 06:00	1	1
03/15/2015 07:00	1	1
03/15/2015 08:00	1	1
03/15/2015 09:00	1	1
03/15/2015 10:00	1	1
03/15/2015 11:00	1	1
03/15/2015 12:00	1	1
03/15/2015 13:00	1	1
03/15/2015 14:00	1	1
03/15/2015 15:00	1	1
03/15/2015 16:00	1	1
03/15/2015 17:00	1	1
03/15/2015 18:00	1	1
03/15/2015 19:00	1	1
03/15/2015 20:00	1	1
03/15/2015 21:00	1	1
03/15/2015 22:00	1	1
03/15/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/16/2015 00:00	1	1
03/16/2015 01:00	1	1
03/16/2015 02:00	1	1
03/16/2015 03:00	1	1
03/16/2015 04:00	1	1
03/16/2015 05:00	1	1
03/16/2015 06:00	1	1
03/16/2015 07:00	1	1
03/16/2015 08:00	1	1
03/16/2015 09:00	1	1
03/16/2015 10:00	1	1
03/16/2015 11:00	1	1
03/16/2015 12:00	1	1
03/16/2015 13:00	1	1
03/16/2015 14:00	1	1
03/16/2015 15:00	1	1
03/16/2015 16:00	1	1
03/16/2015 17:00	1	1
03/16/2015 18:00	1	1
03/16/2015 19:00	1	1
03/16/2015 20:00	1	1
03/16/2015 21:00	1	1
03/16/2015 22:00	1	1
03/16/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/17/2015 00:00	1	1
03/17/2015 01:00	1	1
03/17/2015 02:00	1	1
03/17/2015 03:00	1	1
03/17/2015 04:00	1	1
03/17/2015 05:00	1	1
03/17/2015 06:00	1	1
03/17/2015 07:00	1	1
03/17/2015 08:00	1	1
03/17/2015 09:00	1	1
03/17/2015 10:00	1	1
03/17/2015 11:00	1	1
03/17/2015 12:00	1	1
03/17/2015 13:00	1	1
03/17/2015 14:00	1	1
03/17/2015 15:00	1	1
03/17/2015 16:00	1	1
03/17/2015 17:00	1	1
03/17/2015 18:00	1	1
03/17/2015 19:00	1	1
03/17/2015 20:00	1	1
03/17/2015 21:00	1	1
03/17/2015 22:00	1	1
03/17/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/18/2015 00:00	1	1
03/18/2015 01:00	1	1
03/18/2015 02:00	1	1
03/18/2015 03:00	1	1
03/18/2015 04:00	1	1
03/18/2015 05:00	1	1
03/18/2015 06:00	1	1
03/18/2015 07:00	1	1
03/18/2015 08:00	1	1
03/18/2015 09:00	1	1
03/18/2015 10:00	1	1
03/18/2015 11:00	1	1
03/18/2015 12:00	1	1
03/18/2015 13:00	1	1
03/18/2015 14:00	1	1
03/18/2015 15:00	1	1
03/18/2015 16:00	1	1
03/18/2015 17:00	1	1
03/18/2015 18:00	1	1
03/18/2015 19:00	1	1
03/18/2015 20:00	1	1
03/18/2015 21:00	1	1
03/18/2015 22:00	1	1
03/18/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/19/2015 00:00	1	1
03/19/2015 01:00	1	1
03/19/2015 02:00	1	1
03/19/2015 03:00	1	1
03/19/2015 04:00	1	1
03/19/2015 05:00	1	1
03/19/2015 06:00	1	1
03/19/2015 07:00	1	1
03/19/2015 08:00	1	1
03/19/2015 09:00	0	1
03/19/2015 10:00	0	1
03/19/2015 11:00	0	1
03/19/2015 12:00	0	1
03/19/2015 13:00	0	1
03/19/2015 14:00	1	1
03/19/2015 15:00	1	1
03/19/2015 16:00	1	1
03/19/2015 17:00	1	1
03/19/2015 18:00	1	1
03/19/2015 19:00	1	1
03/19/2015 20:00	1	1
03/19/2015 21:00	1	1
03/19/2015 22:00	1	1
03/19/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	21	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/20/2015 00:00	1	1
03/20/2015 01:00	1	1
03/20/2015 02:00	1	1
03/20/2015 03:00	1	1
03/20/2015 04:00	1	1
03/20/2015 05:00	1	1
03/20/2015 06:00	1	1
03/20/2015 07:00	1	1
03/20/2015 08:00	1	0
03/20/2015 09:00	1	0
03/20/2015 10:00	1	0
03/20/2015 11:00	1	0
03/20/2015 12:00	1	0
03/20/2015 13:00	1	1
03/20/2015 14:00	1	1
03/20/2015 15:00	1	1
03/20/2015 16:00	1	1
03/20/2015 17:00	1	1
03/20/2015 18:00	1	1
03/20/2015 19:00	1	1
03/20/2015 20:00	1	1
03/20/2015 21:00	1	1
03/20/2015 22:00	1	1
03/20/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	21

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/21/2015 00:00	1	1
03/21/2015 01:00	1	1
03/21/2015 02:00	1	1
03/21/2015 03:00	1	1
03/21/2015 04:00	1	1
03/21/2015 05:00	1	1
03/21/2015 06:00	1	1
03/21/2015 07:00	1	1
03/21/2015 08:00	1	1
03/21/2015 09:00	1	1
03/21/2015 10:00	1	1
03/21/2015 11:00	1	1
03/21/2015 12:00	1	1
03/21/2015 13:00	1	1
03/21/2015 14:00	1	1
03/21/2015 15:00	1	1
03/21/2015 16:00	1	1
03/21/2015 17:00	1	1
03/21/2015 18:00	1	1
03/21/2015 19:00	1	1
03/21/2015 20:00	1	1
03/21/2015 21:00	1	1
03/21/2015 22:00	1	1
03/21/2015 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/22/2015 00:00	1	1
03/22/2015 01:00	1	1
03/22/2015 02:00	1	1
03/22/2015 03:00	1	1
03/22/2015 04:00	1	1
03/22/2015 05:00	1	1
03/22/2015 06:00	1	1
03/22/2015 07:00	1	1
03/22/2015 08:00	1	1
03/22/2015 09:00	1	1
03/22/2015 10:00	1	1
03/22/2015 11:00	1	1
03/22/2015 12:00	1	1
03/22/2015 13:00	1	1
03/22/2015 14:00	1	1
03/22/2015 15:00	1	1
03/22/2015 16:00	1	1
03/22/2015 17:00	1	1
03/22/2015 18:00	1	1
03/22/2015 19:00	1	1
03/22/2015 20:00	1	1
03/22/2015 21:00	1	1
03/22/2015 22:00	1	1
03/22/2015 23:00	1	4
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	4
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/23/2015 00:00	1	4
03/23/2015 01:00	1	4
03/23/2015 02:00	1	4
03/23/2015 03:00	1	4
03/23/2015 04:00	1	4
03/23/2015 05:00	1	4
03/23/2015 06:00	1	4
03/23/2015 07:00	1	4
03/23/2015 08:00	1	4
03/23/2015 09:00	1	4
03/23/2015 10:00	1	4
03/23/2015 11:00	1	4
03/23/2015 12:00	1	4
03/23/2015 13:00	1	4
03/23/2015 14:00	1	4
03/23/2015 15:00	1	4
03/23/2015 16:00	1	4
03/23/2015 17:00	1	4
03/23/2015 18:00	1	4
03/23/2015 19:00	1	4
03/23/2015 20:00	1	4
03/23/2015 21:00	1	4
03/23/2015 22:00	1	4
03/23/2015 23:00	1	4
Average/Sum#:	1	4
Minimum:	1	4
Maximum:	1	4
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/24/2015 00:00	1	4
03/24/2015 01:00	1	4
03/24/2015 02:00	1	4
03/24/2015 03:00	1	4
03/24/2015 04:00	1	4
03/24/2015 05:00	1	4
03/24/2015 06:00	1	4
03/24/2015 07:00	1	4
03/24/2015 08:00	1	4
03/24/2015 09:00	1	4
03/24/2015 10:00	1	4
03/24/2015 11:00	1	4
03/24/2015 12:00	1	4
03/24/2015 13:00	1	4
03/24/2015 14:00	1	4
03/24/2015 15:00	1	4
03/24/2015 16:00	1	4
03/24/2015 17:00	1	4
03/24/2015 18:00	1	4
03/24/2015 19:00	1	4
03/24/2015 20:00	1	4
03/24/2015 21:00	1	4
03/24/2015 22:00	1	4
03/24/2015 23:00	1	4
Average/Sum#:	1	4
Minimum:	1	4
Maximum:	1	4
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/25/2015 00:00	1	4
03/25/2015 01:00	1	4
03/25/2015 02:00	1	4
03/25/2015 03:00	1	4
03/25/2015 04:00	1	4
03/25/2015 05:00	1	4
03/25/2015 06:00	1	4
03/25/2015 07:00	1	4
03/25/2015 08:00	1	4
03/25/2015 09:00	1	4
03/25/2015 10:00	1	4
03/25/2015 11:00	1	4
03/25/2015 12:00	1	4
03/25/2015 13:00	1	4
03/25/2015 14:00	1	4
03/25/2015 15:00	1	4
03/25/2015 16:00	1	4
03/25/2015 17:00	1	4
03/25/2015 18:00	1	4
03/25/2015 19:00	1	4
03/25/2015 20:00	1	4
03/25/2015 21:00	1	4
03/25/2015 22:00	1	4
03/25/2015 23:00	1	4
Average/Sum#:	1	4
Minimum:	1	4
Maximum:	1	4
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/26/2015 00:00	1	4
03/26/2015 01:00	1	4
03/26/2015 02:00	1	4
03/26/2015 03:00	12	4
03/26/2015 04:00	16	4
03/26/2015 05:00	17	4
03/26/2015 06:00	17	4
03/26/2015 07:00	5	4
03/26/2015 08:00	2	4
03/26/2015 09:00	0	4
03/26/2015 10:00	0	4
03/26/2015 11:00	0	4
03/26/2015 12:00	0	4
03/26/2015 13:00	0	4
03/26/2015 14:00	0	4
03/26/2015 15:00	1	4
03/26/2015 16:00	1	4
03/26/2015 17:00	1	4
03/26/2015 18:00	1	4
03/26/2015 19:00	1	4
03/26/2015 20:00	1	4
03/26/2015 21:00	1	4
03/26/2015 22:00	2	4
03/26/2015 23:00	2	4
Average/Sum#:	3	4
Minimum:	0	4
Maximum:	17	4
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/27/2015 00:00	2	4
03/27/2015 01:00	2	4
03/27/2015 02:00	2	4
03/27/2015 03:00	2	4
03/27/2015 04:00	2	4
03/27/2015 05:00	7	4
03/27/2015 06:00	7	4
03/27/2015 07:00	6	4
03/27/2015 08:00	6	4
03/27/2015 09:00	0	4
03/27/2015 10:00	0	4
03/27/2015 11:00	0	4
03/27/2015 12:00	0	4
03/27/2015 13:00	0	4
03/27/2015 14:00	0	4
03/27/2015 15:00	0	4
03/27/2015 16:00	0	4
03/27/2015 17:00	1	4
03/27/2015 18:00	1	4
03/27/2015 19:00	1	4
03/27/2015 20:00	1	4
03/27/2015 21:00	1	4
03/27/2015 22:00	1	4
03/27/2015 23:00	1	4
Average/Sum#:	2	4
Minimum:	0	4
Maximum:	7	4
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/28/2015 00:00	1	4
03/28/2015 01:00	1	4
03/28/2015 02:00	1	4
03/28/2015 03:00	1	4
03/28/2015 04:00	1	4
03/28/2015 05:00	1	4
03/28/2015 06:00	1	4
03/28/2015 07:00	1	4
03/28/2015 08:00	1	4
03/28/2015 09:00	1	4
03/28/2015 10:00	1	4
03/28/2015 11:00	1	4
03/28/2015 12:00	1	4
03/28/2015 13:00	1	4
03/28/2015 14:00	1	4
03/28/2015 15:00	1	4
03/28/2015 16:00	1	4
03/28/2015 17:00	1	4
03/28/2015 18:00	1	4
03/28/2015 19:00	1	4
03/28/2015 20:00	1	4
03/28/2015 21:00	1	4
03/28/2015 22:00	1	4
03/28/2015 23:00	1	4
Average/Sum#:	1	4
Minimum:	1	4
Maximum:	1	4
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/29/2015 00:00	1	4
03/29/2015 01:00	1	4
03/29/2015 02:00	1	4
03/29/2015 03:00	1	4
03/29/2015 04:00	1	4
03/29/2015 05:00	1	4
03/29/2015 06:00	1	4
03/29/2015 07:00	1	4
03/29/2015 08:00	1	4
03/29/2015 09:00	1	4
03/29/2015 10:00	1	4
03/29/2015 11:00	1	4
03/29/2015 12:00	1	4
03/29/2015 13:00	1	4
03/29/2015 14:00	1	4
03/29/2015 15:00	1	4
03/29/2015 16:00	1	4
03/29/2015 17:00	1	4
03/29/2015 18:00	1	4
03/29/2015 19:00	1	4
03/29/2015 20:00	1	4
03/29/2015 21:00	1	4
03/29/2015 22:00	1	4
03/29/2015 23:00	1	4
Average/Sum#:	1	4
Minimum:	1	4
Maximum:	1	4
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/30/2015 00:00	1	4
03/30/2015 01:00	1	4
03/30/2015 02:00	1	4
03/30/2015 03:00	13	4
03/30/2015 04:00	18	4
03/30/2015 05:00	20	4
03/30/2015 06:00	19	4
03/30/2015 07:00	7	4
03/30/2015 08:00	2	4
03/30/2015 09:00	0	4
03/30/2015 10:00	0	4
03/30/2015 11:00	0	4
03/30/2015 12:00	0	4
03/30/2015 13:00	0	4
03/30/2015 14:00	0	4
03/30/2015 15:00	0	4
03/30/2015 16:00	0	4
03/30/2015 17:00	0	4
03/30/2015 18:00	0	4
03/30/2015 19:00	0	4
03/30/2015 20:00	1	4
03/30/2015 21:00	1	4
03/30/2015 22:00	1	4
03/30/2015 23:00	1	4
Average/Sum#:	4	4
Minimum:	0	4
Maximum:	20	4
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 09:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/31/2015 00:00	1	4
03/31/2015 01:00	1	4
03/31/2015 02:00	1	4
03/31/2015 03:00	1	4
03/31/2015 04:00	12	4
03/31/2015 05:00	13	4
03/31/2015 06:00	13	4
03/31/2015 07:00	12	4
03/31/2015 08:00	1	4
03/31/2015 09:00	0	4
03/31/2015 10:00	0	4
03/31/2015 11:00	0	4
03/31/2015 12:00	0	4
03/31/2015 13:00	0	4
03/31/2015 14:00	0	4
03/31/2015 15:00	0	4
03/31/2015 16:00	0	4
03/31/2015 17:00	0	4
03/31/2015 18:00	0	4
03/31/2015 19:00	1	4
03/31/2015 20:00	1	4
03/31/2015 21:00	1	4
03/31/2015 22:00	1	4
03/31/2015 23:00	1	4
Average/Sum#:	3	4
Minimum:	0	4
Maximum:	13	4
%SI	0	0

ATTACHMENT 4
Excess Emission/Downtime Report

FCD: AQ-4
Title V: #28

EDS-CMS Reports

EDS/CMS Summary Report

CT1 - CO LbPerHr

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 09:36 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_CO_LbPerHr_1H
EDS Data from: CT1_CO_LbPerHr_1H
Emission Limitation: CT1_CO_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Operating time for EDS: 1,870.00 Hour(s)
Operating time for CMS: 1,870.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	5
e. Unknown causes	0
2. Total CMS Downtime	5
3. Total Downtime as a percentage of operating time	0.27
4. Total Availability as a percentage of operating time	99.73

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT1 - CO Ppmvdc

From: 01/01/2012 00:00 **To:** 03/31/2012 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 09:56 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_CO_Ppmvdc_1H
EDS Data from: CT1_CO_3Hr_Ppmvdc_1H
Emission Limitation: CT1_COLimit_3Hr_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Operating time for EDS: 1,409.00 Hour(s)
Operating time for CMS: 1,409.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	4
d. Other known causes	1
e. Unknown causes	0
2. Total CMS Downtime	5
3. Total Downtime as a percentage of operating time	0.35
4. Total Availability as a percentage of operating time	99.65

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT1 - NOx LbPerHr

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 09:39 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_NOx_LbPerHr_1H
EDS Data from: CT1_NOx_LbPerHr_1H
Emission Limitation: CT1_NOxLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Operating time for EDS: 1,870.00 Hour(s)
Operating time for CMS: 1,870.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	5
e. Unknown causes	0
2. Total CMS Downtime	5
3. Total Downtime as a percentage of operating time	0.27
4. Total Availability as a percentage of operating time	99.73

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT1 - NOx Ppmvdc

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 09:58 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_NOx_Ppmvdc_1H
EDS Data from: CT1_NOx_Ppmvdc_1H
Emission Limitation: CT1_NOxLimit_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Operating time for EDS: 1,870.00 Hour(s)
Operating time for CMS: 1,870.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	5
e. Unknown causes	0
2. Total CMS Downtime	5
3. Total Downtime as a percentage of operating time	0.27
4. Total Availability as a percentage of operating time	99.73

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - CO LbPerHr

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 09:59 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_CO_LbPerHr_1H
EDS Data from: CT2_CO_LbPerHr_1H
Emission Limitation: CT2_COLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Operating time for EDS: 1,811.00 Hour(s)
Operating time for CMS: 1,811.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	4
d. Other known causes	26
e. Unknown causes	0
2. Total CMS Downtime	30
3. Total Downtime as a percentage of operating time	1.66
4. Total Availability as a percentage of operating time	98.34

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - CO Ppmvdc

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 09:59 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_CO_Ppmvdc_1H
EDS Data from: CT2_CO_3Hr_Ppmvdc_1H
Emission Limitation: CT2_COLimit_3Hr_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Operating time for EDS: 1,811.00 Hour(s)
Operating time for CMS: 1,811.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	4
d. Other known causes	26
e. Unknown causes	0
2. Total CMS Downtime	30
3. Total Downtime as a percentage of operating time	1.66
4. Total Availability as a percentage of operating time	98.34

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - NOx LbPerHr

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 10:00 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_NOx_LbPerHr_1H
EDS Data from: CT2_NOx_LbPerHr_1H
Emission Limitation: CT2_NOxLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Operating time for EDS: 1,811.00 Hour(s)
Operating time for CMS: 1,811.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	4
d. Other known causes	5
e. Unknown causes	0
2. Total CMS Downtime	9
3. Total Downtime as a percentage of operating time	0.50
4. Total Availability as a percentage of operating time	99.50

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - NOx Ppmvdc

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 10:00 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_NOx_Ppmvdc_1H
EDS Data from: CT2_NOx_Ppmvdc_1H
Emission Limitation: CT2_NOxLimit_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Operating time for EDS: 1,811.00 Hour(s)
Operating time for CMS: 1,811.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	4
d. Other known causes	5
e. Unknown causes	0
2. Total CMS Downtime	9
3. Total Downtime as a percentage of operating time	0.50
4. Total Availability as a percentage of operating time	99.50

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

Excess Emission Reports

Excess Emission Report

CT1 - CO LbPerHr 1-Hour Block Average

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 09:41 **Location:** Maxwell, CA

Tag Name: CT1_CO_LbPerHr_1H
Total Operating Time: 1,870.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 290.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,870.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - CO Ppmvdc 3-Hour Rolling Average

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 10:06 **Location:** Maxwell, CA

Tag Name: CT1_CO_3Hr_Ppmvdc_1H
Total Operating Time: 1,870.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 290.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,870.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - NOx LbPerHr 1-Hour Block Average

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 10:07 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Lb_1H
Total Operating Time: 1,870.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 290.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,870.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - NOx Ppmvdc 1-Hour Block Average

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 10:07 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Ppmvdc_1H
Total Operating Time: 1,870.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 290.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,870.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - CO LbPerHr 1-Hour Block Average

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 10:08 **Location:** Maxwell, CA

Tag Name: CT2_CO_LbPerHr_1H
Total Operating Time: 1,811.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 349.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,811.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - CO Ppmvdc 3-Hour Rolling Average

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 10:08 **Location:** Maxwell, CA

Tag Name: CT2_CO_3Hr_Ppmvdc_1H
Total Operating Time: 1,811.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 349.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,811.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NOx LbPerHr 1-Hour Block Average

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 10:10 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Lb_1H
Total Operating Time: 1,811.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 349.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,811.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NOx Ppmvdc 1-Hour Block Average

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 09:41 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Ppmvdc_1H
Total Operating Time: 1,811.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 349.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,811.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Downtime Reports

Invalid Data Report

CT1 - Stack CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 10:01 **Location:** Maxwell, CA

Tag Name: CT1_CO_LbPerHr_1H

Total Operating Time: 1,870.00 Hour(s)
Non-Operating Time: 290.00 Hour(s) Report Time: 2,160.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	03/17/2015 10:00	03/17/2015 10:59	1	4 - Other known causes	8 - Quarterly Maintenance
2	03/19/2015 08:00	03/19/2015 11:59	4	4 - Other known causes	8 - Quarterly Maintenance

Total Operating Time:	1,870.00 Hour(s)
Total Monitor Downtime (Online only):	5.00 Hour(s)
Percent Monitor Availability:	99.73 %
Percent Monitor Downtime:	0.27 %

Report Code	Type	Text	Duration	Duration Percent
4	Reason	Other known causes	5	100.00
8	Action	Quarterly Maintenance	5	100.00

Invalid Data Report

CT1 - Stack NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 10:02 **Location:** Maxwell, CA

Tag Name: CT1_NOx_LbPerHr_1H

Total Operating Time: 1,870.00 Hour(s)
Non-Operating Time: 290.00 Hour(s) Report Time: 2,160.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	03/17/2015 10:00	03/17/2015 10:59	1	4 - Other known causes	8 - Quarterly Maintenance
2	03/19/2015 08:00	03/19/2015 11:59	4	4 - Other known causes	8 - Quarterly Maintenance

Total Operating Time:	1,870.00 Hour(s)
Total Monitor Downtime (Online only):	5.00 Hour(s)
Percent Monitor Availability:	99.73 %
Percent Monitor Downtime:	0.27 %

Report Code	Type	Text	Duration	Duration Percent
4	Reason	Other known causes	5	100.00
8	Action	Quarterly Maintenance	5	100.00

Invalid Data Report

CT2 - Stack CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 10:02 **Location:** Maxwell, CA

Tag Name: CT2_CO_LbPerHr_1H

Total Operating Time: 1,811.00 Hour(s)
Non-Operating Time: 349.00 Hour(s) Report Time: 2,160.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	01/27/2015 10:00	01/27/2015 12:59	3	9 - CEMS failed calibration	3 - Performed manual calibration
2	02/22/2015 06:00	02/22/2015 06:59	1	4 - Other known causes	9 - CEMS FAILED TO RECORD A VALID MINUTE DUE TO BEING IN CALIBRATION
3	03/18/2015 06:00	03/19/2015 03:59	22	4 - Other known causes	8 - Quarterly Maintenance
4	03/20/2015 07:00	03/20/2015 10:59	4	3 - Quality assurance calibration	4 - Quarterly linearity/cga

Total Operating Time:	**1,811.00 Hour(s)**
Total Monitor Downtime (Online only):	**30.00 Hour(s)**
Percent Monitor Availability:	**98.34 %**
Percent Monitor Downtime:	**1.66 %**

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Quality assurance calibration	4	13.33
4	Reason	Other known causes	23	76.67
9	Reason	CEMS failed calibration	3	10.00
3	Action	Performed manual calibration	3	10.00
4	Action	Quarterly linearity/cga	4	13.33
8	Action	Quarterly Maintenance	22	73.33
9	Action	CEMS FAILED TO RECORD A VALID MINUTE DUE TO BEING IN CALIBRATION	1	3.33

Invalid Data Report

CT2 - Stack NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 10:02 **Location:** Maxwell, CA

Tag Name: CT2_NOx_LbPerHr_1H

Total Operating Time: 1,811.00 Hour(s)
Non-Operating Time: 349.00 Hour(s) Report Time: 2,160.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	01/27/2015 10:00	01/27/2015 12:59	3	9 - CEMS failed calibration	3 - Performed manual calibration
2	02/22/2015 06:00	02/22/2015 06:59	1	4 - Other known causes	9 - CEMS FAILED TO RECORD A VALID MINUTE DUE TO BEING IN CALIBRATION
3	03/18/2015 10:00	03/18/2015 10:59	1	4 - Other known causes	8 - Quarterly Maintenance
4	03/20/2015 07:00	03/20/2015 10:59	4	3 - Quality assurance calibration	4 - Quarterly linearity/cga

Total Operating Time:	**1,811.00 Hour(s)**
Total Monitor Downtime (Online only):	**9.00 Hour(s)**
Percent Monitor Availability:	**99.50 %**
Percent Monitor Downtime:	**0.50 %**

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Quality assurance calibration	4	44.44
4	Reason	Other known causes	2	22.22
9	Reason	CEMS failed calibration	3	33.33
3	Action	Performed manual calibration	3	33.33
4	Action	Quarterly linearity/cga	4	44.44
8	Action	Quarterly Maintenance	1	11.11
9	Action	CEMS FAILED TO RECORD A VALID MINUTE DUE TO BEING IN CALIBRATION	1	11.11

ATTACHMENT 5
Hourly Emissions VOC

FCD:	AQ-14
Title V:	#6

Pursuant to the CEC conditions of certification, AQ-14 requires that a correlation be developed between emissions of CO and VOC in order to predict ongoing compliance with the VOC limits.

AQ-14 reads as follows:

AQ-14 The CTGs shall meet a VOC limit of 2.0 ppmvd with duct burner firing and 1.38 ppmvd without duct burner firing @ 15% O2 averaged over one hour. Maximum hourly steady state emission limits for each CTG are:

Pounds VOC with Duct Firing Pounds: 7.2

VOC without Duct Firing: 3.4

Verification: The project owner shall submit to the CPM and APCO CTG source test emissions data demonstrating compliance with this condition as required by condition **AQ-8** and shall provide operating data that establishes ongoing compliance with this condition using a determined relationship with CO emissions, previously approved by the CPM and APCO using source test data, as part of the Quarterly Operation Reports (**AQ-22**).

Analysis

Data derived from the December 2011 source tests were used to establish the initial correlation between CO and VOC. The 2011 tests were conducted by The Avogadro Group with concurrent testing for CO and VOC conducted on the following dates for the following load scenarios:

- Unit 1 – Baseload w/o duct burners – 11/8/11 (3 test runs)
- Unit 2 - Baseload w/o duct burners – 11/9/11 (3 test runs)
- Unit 1 – Maximum load w/duct burners – 11/11/11 (3 test runs)
- Unit 2 - Maximum load w/duct burners – 11/12/11 (3 test runs)

The summary test results for the above noted concurrent CO and VOC tests are presented in the 2011 test report at Tables 6-5, 6-6, 6-7, and 6-9. The correlation of CO versus VOC data was prepared using the six (6) test data sets for each load scenario, i.e., six values used for baseload w/o duct burners, and six values used for maximum load w/duct burners. The attached spreadsheet shows the data plots for each load scenario as well as the regression analysis for each data set.

As can be seen from the spreadsheet analysis, the correlation for both scenarios is not very robust, with the maximum load with duct burners giving the best correlation. The spreadsheet presents the predicted VOC calculations for a range of CO values, with the resultant VOC mass emissions based on a linear ratio from the average test data. It should be noted that due to the correlation equations, as CO increases the VOC decreases and begins to show “non-real” values. This is due to the small sample size for both scenarios.

Colusa GS Test Data for CO and VOC

	Date	Times	VOC, ppm	CO, ppm	
Unit 1	11/8/2011	0900-0930	0.57	0.18	
		1009-1030	0.25	0.23	w/o DB
		1431-1501	0.25	0.49	
	11/11/2011	1150-1220	0.43	0.17	
		1226-1256	0.42	0.19	w DB
		1304-1334	0.21	0.3	
Unit 2	11/9/2011	0905-0935	0.19	0.5	
		0938-1008	0.19	0.46	w/o DB
		1018-1048	0.29	0.47	
	11/12/2011	0850-0910	0.24	0.34	
		0930-1000	0.2	0.31	w DB
		1015-1045	0.15	0.35	

Permit Limits	VOC, ppm	CO, ppm
w/o DB	1.38	3
w DB	2	3

w/o DB		w DB	
VOC	CO	VOC	CO
0.57	0.18	0.43	0.17
0.25	0.23	0.42	0.19
0.25	0.49	0.21	0.3
0.19	0.5	0.24	0.34
0.19	0.46	0.2	0.31
0.29	0.47	0.15	0.35

all ppm values are dry at 15% O2
Data from Avogadro Test dated December 2011
CO and VOC data concurrent tests, see test report tables 6-5, 6-6, 6-7, and 6-9.

Without DB

With DB

SUMMARY OUTPUT - without DB

Regression Statistics	
Multiple R	0.726995721
R Square	0.528522779
Adjusted R Squ	0.410653473
Standard Error	0.109432726
Observations	6

Eq for predicting VOC based on CO:
VOC, ppm = (CO,ppm * -0.7217) + 0.5703

ANOVA

	df	*SS*	*MS*	*F*	*Significance F*
Regression	1	0.053697914	0.053697914	4.483972966	0.101623317
Residual	4	0.047902086	0.011975521		
Total	5	0.1016			

	Coefficients	*Standard Error*	*t Stat*	*P-value*	*Lower 95%*	*Upper 95%*	*Lower 95.0%*	*Upper 95.0%*
Intercept	0.570278092	0.139696681	4.082259434	0.015070461	0.182417927	0.958138257	0.182417927	0.958138257
X Variable 1	-0.72174616	0.340841909	-2.117539366	0.101623317	-1.66807501	0.22458269	-1.66807501	0.22458269

SUMMARY OUTPUT -with DB

Regression Statistics	
Multiple R	0.960221702
R Square	0.922025717
Adjusted R Squ	0.902532147
Standard Error	0.037398713
Observations	6

Eq for predicting VOC based on CO:
VOC, ppm = (CO, ppm * -1.4866) + 0.6863

ANOVA

	df	*SS*	*MS*	*F*	*Significance F*
Regression	1	0.066155345	0.066155345	47.29896497	0.002341999
Residual	4	0.005594655	0.001398664		
Total	5	0.07175			

	Coefficients	*Standard Error*	*t Stat*	*P-value*	*Lower 95%*	*Upper 95%*	*Lower 95.0%*	*Upper 95.0%*
Intercept	0.686302895	0.061722955	11.11908683	0.000372231	0.514932499	0.857673291	0.514932499	0.857673291
X Variable 1	-1.486636971	0.216161881	-6.877424298	0.002341999	-2.086798567	-0.886475375	-2.086798567	-0.886475375

Emissions Prediction-Range of Results based on Correlations

Baseload w/o duct burners

Avg VOC ppm at 15% O2 = 0.29

Avg VOC lb/hr = 0.683

CO Range Range	Predicted VOC, ppm	Predicted VOC, lb/hr	
0.1	0.50	1.17	
0.2	0.43	1.00	
0.3	0.35	0.83	
0.4	0.28	0.66	
0.5	0.21	0.49	
0.6	0.14	0.32	
0.7	0.07	0.15	
0.8	-0.01	-0.02	
0.9	-0.08	-0.19	Non-real
1	-0.15	-0.36	values

Maximum load w/duct burners

Avg VOC ppm at 15% O2 = 0.275

Avg VOC lb/hr = 0.823

CO Range Range	Predicted VOC, ppm	Predicted VOC, lb/hr	
0.1	0.54	1.61	
0.2	0.39	1.16	
0.3	0.24	0.72	
0.4	0.09	0.27	
0.5	-0.06	-0.17	
0.6	-0.21	-0.62	
0.7	-0.35	-1.06	
0.8	-0.50	-1.51	Non-real
0.9	-0.65	-1.95	Values
1	-0.80	-2.40	

Excess Emission Report

CT1 - VOC Lb 1-Day Block Average

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 10:13 **Location:** Maxwell, CA

Tag Name: CT1_VOC_Lb_1D
Total Operating Time: 84.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 6.00 Day(s) Report Time: 90.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**84.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - VOC LbPerHr 1-Hour Block Average

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 10:13 **Location:** Maxwell, CA

Tag Name: CT1_VOC_LbPerHr_1H
Total Operating Time: 1,816.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 344.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,816.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - VOC Ppmvdc 1-Hour Block Average

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 10:13 **Location:** Maxwell, CA

Tag Name: CT1_VOC_Ppmvdc_1H
Total Operating Time: 1,816.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 344.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,816.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 -VOC Lb 1-Day Block Average

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 10:14 **Location:** Maxwell, CA

Tag Name: CT2_VOC_Lb_1D
Total Operating Time: 80.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 10.00 Day(s) Report Time: 90.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**80.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - VOC LbPerHr 1-Hour Block Average

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 10:15 **Location:** Maxwell, CA

Tag Name: CT2_VOC_LbPerHr_1H
Total Operating Time: 1,765.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 395.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,765.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - VOC Ppmvdc 1-Hour Block Average

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 10:15 **Location:** Maxwell, CA

Tag Name: CT2_VOC_Ppmvdc_1H
Total Operating Time: 1,765.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 395.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,765.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/01/2015 00:00	-0.1	11.9	2,249.1	0.2	1.6	1	1	1
01/01/2015 01:00	0.1	11.7	2,288.5	0.2	1.6	1	1	1
01/01/2015 02:00	0.1	11.7	2,277.8	0.2	1.6	1	1	1
01/01/2015 03:00	0.1	11.7	2,269.6	0.2	1.6	1	1	1
01/01/2015 04:00	-0.1	12.0	2,227.2	0.2	1.6	1	1	1
01/01/2015 05:00	-0.1	12.1	2,212.8	0.2	1.5	1	1	1
01/01/2015 06:00	0.1	11.7	2,296.2	0.2	1.6	1	1	1
01/01/2015 07:00	0.1	11.8	2,269.9	0.2	1.6	1	1	1
01/01/2015 08:00	0.4	13.1	1,942.5	0.4	1.4	1	1	1
01/01/2015 09:00	0.5	13.4	1,836.7	0.5	1.3	1	1	1
01/01/2015 10:00	0.7	13.8	1,449.7	0.7	1.0	1	1	1
01/01/2015 11:00	0.6	13.9	1,269.6	0.6	0.9	1	1	0
01/01/2015 12:00	0.6	13.9	1,272.4	0.6	0.9	1	1	0
01/01/2015 13:00	0.6	13.9	1,268.6	0.6	0.9	1	1	0
01/01/2015 14:00	0.6	13.9	1,266.0	0.6	0.9	1	1	0
01/01/2015 15:00	0.5	13.6	1,599.7	0.5	1.1	1	1	1
01/01/2015 16:00	0.2	13.3	1,913.4	0.4	1.3	1	1	1
01/01/2015 17:00	0.2	13.1	1,981.6	0.4	1.4	1	1	1
01/01/2015 18:00	-0.2	12.6	2,091.4	0.1	1.5	1	1	1
01/01/2015 19:00	-0.1	11.7	2,285.5	0.2	1.6	1	1	1
01/01/2015 20:00	-0.1	11.7	2,290.4	0.2	1.6	1	1	1
01/01/2015 21:00	-0.1	11.8	2,271.5	0.2	1.6	1	1	1
01/01/2015 22:00	-0.1	11.9	2,267.4	0.2	1.6	1	1	1
01/01/2015 23:00	0.1	13.0	2,024.7	0.2	1.4	1	1	1
Average/Sum#:	0.2	12.6	1,963.4	0.3	1.4	24 #	24 #	20 #
Minimum:	-0.2	11.7	1,266.0	0.1	0.9	1	1	0
Maximum:	0.7	13.9	2,296.2	0.7	1.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/02/2015 00:00	0.2	13.1	2,002.3	0.4	1.4	1	1	1
01/02/2015 01:00	-0.1	12.7	2,069.6	0.1	1.4	1	1	1
01/02/2015 02:00	0.2	13.3	1,873.1	0.4	1.3	1	1	1
01/02/2015 03:00	-0.1	13.0	2,037.6	0.1	1.4	1	1	1
01/02/2015 04:00	0.2	13.2	1,987.7	0.4	1.4	1	1	1
01/02/2015 05:00	0.1	13.0	2,017.2	0.2	1.4	1	1	1
01/02/2015 06:00	0.2	13.2	1,971.1	0.4	1.4	1	1	1
01/02/2015 07:00	0.2	13.3	1,967.7	0.4	1.4	1	1	1
01/02/2015 08:00	0.2	13.3	1,909.2	0.4	1.3	1	1	1
01/02/2015 09:00	0.2	13.3	1,841.9	0.4	1.3	1	1	1
01/02/2015 10:00	0.5	13.7	1,458.5	0.5	1.0	1	1	1
01/02/2015 11:00	0.6	13.8	1,307.8	0.6	0.9	1	1	0
01/02/2015 12:00	0.6	13.8	1,304.8	0.6	0.9	1	1	0
01/02/2015 13:00	0.6	13.9	1,310.1	0.6	0.9	1	1	0
01/02/2015 14:00	0.6	13.9	1,304.5	0.6	0.9	1	1	0
01/02/2015 15:00	0.5	13.7	1,641.6	0.5	1.1	1	1	1
01/02/2015 16:00	0.2	13.3	1,900.3	0.4	1.3	1	1	1
01/02/2015 17:00	-0.4	12.2	2,188.5	-0.1	1.5	1	1	1
01/02/2015 18:00	-0.1	11.6	2,299.0	0.2	1.6	1	1	1
01/02/2015 19:00	-0.1	11.6	2,294.4	0.2	1.6	1	1	1
01/02/2015 20:00	-0.1	11.6	2,295.6	0.2	1.6	1	1	1
01/02/2015 21:00	-0.1	11.6	2,296.1	0.2	1.6	1	1	1
01/02/2015 22:00	-0.1	11.7	2,296.8	0.2	1.6	1	1	1
01/02/2015 23:00	-0.1	12.1	2,219.1	0.2	1.6	1	1	1
Average/Sum#:	0.2	12.9	1,908.1	0.3	1.3	24 #	24 #	20 #
Minimum:	-0.4	11.6	1,304.5	-0.1	0.9	1	1	0
Maximum:	0.6	13.9	2,299.0	0.6	1.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/03/2015 00:00	-0.2	12.4	2,158.1	0.1	1.5	1	1	1
01/03/2015 01:00	-0.2	12.0	2,246.0	0.1	1.6	1	1	1
01/03/2015 02:00	-0.1	12.4	2,149.4	0.2	1.5	1	1	1
01/03/2015 03:00	-0.2	12.0	2,246.3	0.1	1.6	1	1	1
01/03/2015 04:00	0.1	12.7	2,092.2	0.2	1.5	1	1	1
01/03/2015 05:00	0.1	12.9	2,042.2	0.2	1.4	1	1	1
01/03/2015 06:00	-0.2	12.4	2,164.0	0.1	1.5	1	1	1
01/03/2015 07:00	-0.1	12.3	2,110.4	0.2	1.5	1	1	1
01/03/2015 08:00	0.4	13.3	1,896.5	0.4	1.3	1	1	1
01/03/2015 09:00	0.2	13.3	1,843.8	0.4	1.3	1	1	1
01/03/2015 10:00	0.2	13.3	1,845.3	0.4	1.3	1	1	1
01/03/2015 11:00	0.2	13.3	1,850.6	0.4	1.3	1	1	1
01/03/2015 12:00	0.6	13.8	1,356.1	0.6	0.9	1	1	0
01/03/2015 13:00	0.6	13.8	1,304.3	0.6	0.9	1	1	0
01/03/2015 14:00	0.6	13.9	1,301.7	0.6	0.9	1	1	0
01/03/2015 15:00	0.5	13.6	1,654.7	0.5	1.2	1	1	1
01/03/2015 16:00	-0.1	13.0	1,983.0	0.1	1.4	1	1	1
01/03/2015 17:00	-0.4	12.3	2,178.3	-0.1	1.5	1	1	1
01/03/2015 18:00	-0.1	11.7	2,298.7	0.2	1.6	1	1	1
01/03/2015 19:00	-0.1	11.7	2,283.4	0.2	1.6	1	1	1
01/03/2015 20:00	-0.1	11.7	2,284.4	0.2	1.6	1	1	1
01/03/2015 21:00	-0.1	11.7	2,293.5	0.2	1.6	1	1	1
01/03/2015 22:00	-0.1	12.0	2,235.7	0.2	1.6	1	1	1
01/03/2015 23:00	-0.1	12.1	2,216.2	0.2	1.6	1	1	1
Average/Sum#:	0.1	12.7	2,001.5	0.3	1.4	24 #	24 #	21 #
Minimum:	-0.4	11.7	1,301.7	-0.1	0.9	1	1	0
Maximum:	0.6	13.9	2,298.7	0.6	1.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/04/2015 00:00	-0.2	12.2	2,218.4	0.1	1.6	1	1	1
01/04/2015 01:00	0.2	13.1	1,998.5	0.4	1.4	1	1	1
01/04/2015 02:00	0.4	13.2	1,983.0	0.4	1.4	1	1	1
01/04/2015 03:00	0.2	13.2	1,981.0	0.4	1.4	1	1	1
01/04/2015 04:00	0.2	13.2	1,962.4	0.4	1.4	1	1	1
01/04/2015 05:00	0.2	13.2	1,967.9	0.4	1.4	1	1	1
01/04/2015 06:00	-0.2	12.6	2,119.3	0.1	1.5	1	1	1
01/04/2015 07:00	-0.2	11.9	2,245.7	0.1	1.6	1	1	1
01/04/2015 08:00	0.2	13.2	1,946.0	0.4	1.4	1	1	1
01/04/2015 09:00	0.2	13.3	1,908.8	0.4	1.3	1	1	1
01/04/2015 10:00	0.2	13.3	1,893.1	0.4	1.3	1	1	1
01/04/2015 11:00	0.2	13.3	1,858.2	0.4	1.3	1	1	1
01/04/2015 12:00	0.2	13.3	1,849.9	0.4	1.3	1	1	1
01/04/2015 13:00	0.2	13.3	1,875.9	0.4	1.3	1	1	1
01/04/2015 14:00	0.1	13.1	1,989.3	0.2	1.4	1	1	1
01/04/2015 15:00	0.1	13.0	2,004.9	0.2	1.4	1	1	1
01/04/2015 16:00	-0.1	12.9	2,010.1	0.1	1.4	1	1	1
01/04/2015 17:00	-0.2	11.9	2,239.2	0.1	1.6	1	1	1
01/04/2015 18:00	-0.1	11.6	2,308.2	0.2	1.6	1	1	1
01/04/2015 19:00	-0.1	11.6	2,314.7	0.2	1.6	1	1	1
01/04/2015 20:00	0.1	11.6	2,314.8	0.2	1.6	1	1	1
01/04/2015 21:00	-0.1	11.8	2,257.8	0.2	1.6	1	1	1
01/04/2015 22:00	0.1	11.9	2,239.4	0.2	1.6	1	1	1
01/04/2015 23:00	0.4	13.2	1,897.5	0.4	1.3	1	1	1
Average/Sum#:	0.1	12.7	2,057.7	0.3	1.4	24 #	24 #	24 #
Minimum:	-0.2	11.6	1,849.9	0.1	1.3	1	1	1
Maximum:	0.4	13.3	2,314.8	0.4	1.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/05/2015 00:00	0.4	13.3	1,853.4	0.4	1.3	1	1	1
01/05/2015 01:00	0.4	13.3	1,941.2	0.4	1.4	1	1	1
01/05/2015 02:00	0.4	13.3	1,860.9	0.4	1.3	1	1	1
01/05/2015 03:00	0.2	13.2	1,969.6	0.4	1.4	1	1	1
01/05/2015 04:00	0.2	13.3	1,903.3	0.4	1.3	1	1	1
01/05/2015 05:00	0.2	13.3	1,922.6	0.4	1.3	1	1	1
01/05/2015 06:00	0.1	13.0	2,033.0	0.2	1.4	1	1	1
01/05/2015 07:00	-0.4	11.9	2,283.7	-0.1	1.6	1	1	1
01/05/2015 08:00	-0.1	11.9	2,263.0	0.2	1.6	1	1	1
01/05/2015 09:00	0.4	13.2	1,918.7	0.4	1.3	1	1	1
01/05/2015 10:00	0.4	13.3	1,850.8	0.4	1.3	1	1	1
01/05/2015 11:00	0.5	13.3	1,849.2	0.5	1.3	1	1	1
01/05/2015 12:00	0.5	13.3	1,852.4	0.5	1.3	1	1	1
01/05/2015 13:00	0.4	13.4	1,867.2	0.4	1.3	1	1	1
01/05/2015 14:00	0.1	12.9	1,987.1	0.2	1.4	1	1	1
01/05/2015 15:00	0.2	13.0	1,966.7	0.4	1.4	1	1	1
01/05/2015 16:00	0.2	12.9	1,987.0	0.4	1.4	1	1	1
01/05/2015 17:00	-0.1	11.8	2,233.2	0.2	1.6	1	1	1
01/05/2015 18:00	0.2	11.5	2,312.9	0.4	1.6	1	1	1
01/05/2015 19:00	0.2	11.4	2,317.9	0.4	1.6	1	1	1
01/05/2015 20:00	0.2	11.5	2,316.3	0.4	1.6	1	1	1
01/05/2015 21:00	-0.1	12.1	2,184.4	0.2	1.5	1	1	1
01/05/2015 22:00	0.2	12.9	2,021.9	0.4	1.4	1	1	1
01/05/2015 23:00	0.5	13.4	1,709.9	0.5	1.2	1	1	1
Average/Sum#:	0.2	12.8	2,016.9	0.4	1.4	24 #	24 #	24 #
Minimum:	-0.4	11.4	1,709.9	-0.1	1.2	1	1	1
Maximum:	0.5	13.4	2,317.9	0.5	1.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/06/2015 00:00	0.6	13.8	1,436.9	0.6	1.0	1	1	0
01/06/2015 01:00	0.6	13.8	1,653.6	0.6	1.2	1	1	0
01/06/2015 02:00	0.7	13.6	1,715.2	0.7	1.2	1	1	1
01/06/2015 03:00	0.4	13.3	1,859.9	0.4	1.3	1	1	1
01/06/2015 04:00	0.4	13.3	1,859.3	0.4	1.3	1	1	1
01/06/2015 05:00	0.4	13.3	1,919.1	0.4	1.3	1	1	1
01/06/2015 06:00	-0.1	12.8	2,049.0	0.1	1.4	1	1	1
01/06/2015 07:00	-0.1	11.7	2,286.5	0.2	1.6	1	1	1
01/06/2015 08:00	-0.1	12.5	2,085.4	0.1	1.5	1	1	1
01/06/2015 09:00	0.5	13.3	1,848.1	0.5	1.3	1	1	1
01/06/2015 10:00	0.7	13.6	1,549.8	0.7	1.1	1	1	1
01/06/2015 11:00	0.6	13.8	1,301.1	0.6	0.9	1	1	0
01/06/2015 12:00	0.6	13.9	1,301.4	0.6	0.9	1	1	0
01/06/2015 13:00	0.6	13.9	1,445.5	0.6	1.0	1	1	0
01/06/2015 14:00	0.6	13.9	1,304.6	0.6	0.9	1	1	0
01/06/2015 15:00	0.7	13.6	1,635.8	0.7	1.1	1	1	1
01/06/2015 16:00	0.2	13.1	1,931.0	0.4	1.4	1	1	1
01/06/2015 17:00	-0.1	12.7	2,026.1	0.1	1.4	1	1	1
01/06/2015 18:00	-0.1	12.5	2,061.5	0.1	1.4	1	1	1
01/06/2015 19:00	-0.2	12.5	2,089.3	0.1	1.5	1	1	1
01/06/2015 20:00	-0.1	12.2	2,136.3	0.2	1.5	1	1	1
01/06/2015 21:00	-0.2	12.3	2,131.0	0.1	1.5	1	1	1
01/06/2015 22:00	0.1	12.5	2,072.2	0.2	1.5	1	1	1
01/06/2015 23:00	0.5	13.3	1,874.4	0.5	1.3	1	1	1
Average/Sum#:	0.3	13.1	1,815.5	0.4	1.3	24 #	24 #	18 #
Minimum:	-0.2	11.7	1,301.1	0.1	0.9	1	1	0
Maximum:	0.7	13.9	2,286.5	0.7	1.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/07/2015 00:00	0.4	13.2	1,915.2	0.4	1.3	1	1	1
01/07/2015 01:00	0.4	13.3	1,868.2	0.4	1.3	1	1	1
01/07/2015 02:00	0.4	13.3	1,891.9	0.4	1.3	1	1	1
01/07/2015 03:00	0.4	13.3	1,859.0	0.4	1.3	1	1	1
01/07/2015 04:00	0.2	13.1	1,953.2	0.4	1.4	1	1	1
01/07/2015 05:00	0.4	13.2	1,903.0	0.4	1.3	1	1	1
01/07/2015 06:00	-0.1	12.8	2,072.7	0.1	1.5	1	1	1
01/07/2015 07:00	-0.2	12.0	2,242.6	0.1	1.6	1	1	1
01/07/2015 08:00	0.2	12.8	2,015.4	0.4	1.4	1	1	1
01/07/2015 09:00	0.5	13.3	1,891.2	0.5	1.3	1	1	1
01/07/2015 10:00	0.5	13.4	1,852.0	0.5	1.3	1	1	1
01/07/2015 11:00	0.5	13.4	1,837.5	0.5	1.3	1	1	1
01/07/2015 12:00	0.6	13.9	1,307.2	0.6	0.9	1	1	0
01/07/2015 13:00	0.6	13.8	1,493.8	0.6	1.0	1	1	0
01/07/2015 14:00	0.7	13.9	1,559.2	0.7	1.1	1	1	1
01/07/2015 15:00	-0.1	12.8	1,992.1	0.1	1.4	1	1	1
01/07/2015 16:00	0.1	12.9	1,973.7	0.2	1.4	1	1	1
01/07/2015 17:00	-0.1	11.9	2,181.5	0.2	1.5	1	1	1
01/07/2015 18:00	-0.1	12.6	2,054.2	0.1	1.4	1	1	1
01/07/2015 19:00	-0.1	12.8	2,015.1	0.1	1.4	1	1	1
01/07/2015 20:00	-0.1	12.7	2,017.2	0.1	1.4	1	1	1
01/07/2015 21:00	-0.1	12.7	2,024.6	0.1	1.4	1	1	1
01/07/2015 22:00	0.2	13.1	1,926.2	0.4	1.3	1	1	1
01/07/2015 23:00	0.4	13.4	1,853.9	0.4	1.3	1	1	1
Average/Sum#:	0.2	13.1	1,904.2	0.3	1.3	24 #	24 #	22 #
Minimum:	-0.2	11.9	1,307.2	0.1	0.9	1	1	0
Maximum:	0.7	13.9	2,242.6	0.7	1.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/08/2015 00:00	0.4	13.4	1,847.6	0.4	1.3	1	1	1
01/08/2015 01:00	0.4	13.4	1,849.2	0.4	1.3	1	1	1
01/08/2015 02:00	0.4	13.4	1,847.0	0.4	1.3	1	1	1
01/08/2015 03:00	0.4	13.4	1,849.8	0.4	1.3	1	1	1
01/08/2015 04:00	0.4	13.3	1,846.5	0.4	1.3	1	1	1
01/08/2015 05:00	0.4	13.3	1,851.9	0.4	1.3	1	1	1
01/08/2015 06:00	-0.1	12.7	2,075.8	0.1	1.5	1	1	1
01/08/2015 07:00	-0.1	11.6	2,294.9	0.2	1.6	1	1	1
01/08/2015 08:00	-0.1	11.7	2,266.0	0.2	1.6	1	1	1
01/08/2015 09:00	-0.2	12.1	2,179.1	0.1	1.5	1	1	1
01/08/2015 10:00	-0.2	12.6	2,060.4	0.1	1.4	1	1	1
01/08/2015 11:00	0.1	12.9	1,982.2	0.2	1.4	1	1	1
01/08/2015 12:00	0.1	12.8	2,014.7	0.2	1.4	1	1	1
01/08/2015 13:00	-0.1	12.4	2,089.5	0.2	1.5	1	1	1
01/08/2015 14:00	-0.1	12.5	2,081.3	0.1	1.5	1	1	1
01/08/2015 15:00	0.2	11.5	2,269.6	0.4	1.6	1	1	1
01/08/2015 16:00	0.1	12.6	2,021.7	0.2	1.4	1	1	1
01/08/2015 17:00	-0.1	12.5	2,052.3	0.1	1.4	1	1	1
01/08/2015 18:00	-0.1	12.5	2,057.4	0.1	1.4	1	1	1
01/08/2015 19:00	-0.1	12.8	2,002.1	0.1	1.4	1	1	1
01/08/2015 20:00	-0.1	12.7	2,016.5	0.1	1.4	1	1	1
01/08/2015 21:00	-0.1	12.3	2,103.7	0.2	1.5	1	1	1
01/08/2015 22:00	-0.1	12.7	2,016.7	0.1	1.4	1	1	1
01/08/2015 23:00	0.2	13.1	1,908.7	0.4	1.3	1	1	1
Average/Sum#:	0.1	12.7	2,024.4	0.2	1.4	24 #	24 #	24 #
Minimum:	-0.2	11.5	1,846.5	0.1	1.3	1	1	1
Maximum:	0.4	13.4	2,294.9	0.4	1.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/09/2015 00:00	0.2	13.1	1,941.5	0.4	1.4	1	1	1
01/09/2015 01:00	0.4	13.3	1,889.2	0.4	1.3	1	1	1
01/09/2015 02:00	0.4	13.3	1,852.4	0.4	1.3	1	1	1
01/09/2015 03:00	0.2	13.2	1,916.3	0.4	1.3	1	1	1
01/09/2015 04:00	0.4	13.4	1,858.6	0.4	1.3	1	1	1
01/09/2015 05:00	0.4	13.3	1,900.8	0.4	1.3	1	1	1
01/09/2015 06:00	0.2	13.1	1,945.7	0.4	1.4	1	1	1
01/09/2015 07:00	-0.4	12.4	2,144.4	-0.1	1.5	1	1	1
01/09/2015 08:00	-0.1	11.6	2,282.1	0.2	1.6	1	1	1
01/09/2015 09:00	0.1	12.6	2,050.6	0.2	1.4	1	1	1
01/09/2015 10:00	-0.1	11.9	2,217.9	0.2	1.6	1	1	1
01/09/2015 11:00	-0.1	11.7	2,236.5	0.2	1.6	1	1	1
01/09/2015 12:00	0.4	13.3	1,889.8	0.4	1.3	1	1	1
01/09/2015 13:00	0.5	13.5	1,693.1	0.5	1.2	1	1	1
01/09/2015 14:00	0.6	13.9	1,388.3	0.6	1.0	1	1	0
01/09/2015 15:00	0.6	13.9	1,374.8	0.6	1.0	1	1	0
01/09/2015 16:00	0.4	13.4	1,692.6	0.4	1.2	1	1	1
01/09/2015 17:00	0.4	13.3	1,881.0	0.4	1.3	1	1	1
01/09/2015 18:00	0.4	13.3	1,794.7	0.4	1.3	1	1	1
01/09/2015 19:00	0.5	13.4	1,802.3	0.5	1.3	1	1	1
01/09/2015 20:00	0.4	13.4	1,872.3	0.4	1.3	1	1	1
01/09/2015 21:00	0.4	13.4	1,879.5	0.4	1.3	1	1	1
01/09/2015 22:00	0.2	13.2	1,918.2	0.4	1.3	1	1	1
01/09/2015 23:00	0.1	13.0	1,968.5	0.2	1.4	1	1	1
Average/Sum#:	0.3	13.1	1,891.3	0.4	1.3	24 #	24 #	22 #
Minimum:	-0.4	11.6	1,374.8	-0.1	1.0	1	1	0
Maximum:	0.6	13.9	2,282.1	0.6	1.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/10/2015 00:00	0.4	13.4	1,871.5	0.4	1.3	1	1	1
01/10/2015 01:00	0.4	13.5	1,845.4	0.4	1.3	1	1	1
01/10/2015 02:00	0.7	13.6	1,705.9	0.7	1.2	1	1	1
01/10/2015 03:00	0.6	13.9	1,360.4	0.6	1.0	1	1	0
01/10/2015 04:00	0.5	13.6	1,625.7	0.5	1.1	1	1	1
01/10/2015 05:00	0.2	13.3	1,899.5	0.4	1.3	1	1	1
01/10/2015 06:00	0.2	13.1	1,942.2	0.4	1.4	1	1	1
01/10/2015 07:00	0.2	13.1	1,956.5	0.4	1.4	1	1	1
01/10/2015 08:00	0.2	13.3	1,876.0	0.4	1.3	1	1	1
01/10/2015 09:00	0.2	13.3	1,856.3	0.4	1.3	1	1	1
01/10/2015 10:00	0.1	13.1	1,964.4	0.2	1.4	1	1	1
01/10/2015 11:00	-0.4	11.9	2,216.0	-0.1	1.6	1	1	1
01/10/2015 12:00	-0.2	12.0	2,169.9	0.1	1.5	1	1	1
01/10/2015 13:00	0.1	13.1	1,939.5	0.2	1.4	1	1	1
01/10/2015 14:00	-0.2	12.8	1,999.8	0.1	1.4	1	1	1
01/10/2015 15:00	0.2	13.4	1,863.8	0.4	1.3	1	1	1
01/10/2015 16:00	0.2	13.2	1,899.6	0.4	1.3	1	1	1
01/10/2015 17:00	-0.2	12.6	2,055.6	0.1	1.4	1	1	1
01/10/2015 18:00	-0.1	12.9	1,985.0	0.1	1.4	1	1	1
01/10/2015 19:00	-0.2	12.6	2,057.1	0.1	1.4	1	1	1
01/10/2015 20:00	-0.1	11.6	2,267.6	0.2	1.6	1	1	1
01/10/2015 21:00	-0.2	12.3	2,106.3	0.1	1.5	1	1	1
01/10/2015 22:00	-0.1	12.7	2,026.5	0.1	1.4	1	1	1
01/10/2015 23:00	0.2	13.2	1,906.6	0.4	1.3	1	1	1
Average/Sum#:	0.1	13.0	1,933.2	0.3	1.4	24 #	24 #	23 #
Minimum:	-0.4	11.6	1,360.4	-0.1	1.0	1	1	0
Maximum:	0.7	13.9	2,267.6	0.7	1.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/11/2015 00:00	0.2	13.2	1,911.0	0.4	1.3	1	1	1
01/11/2015 01:00	0.2	13.2	1,915.6	0.4	1.3	1	1	1
01/11/2015 02:00	0.2	13.2	1,925.5	0.4	1.3	1	1	1
01/11/2015 03:00	0.2	13.4	1,855.6	0.4	1.3	1	1	1
01/11/2015 04:00	0.2	13.4	1,852.0	0.4	1.3	1	1	1
01/11/2015 05:00	0.2	13.3	1,889.3	0.4	1.3	1	1	1
01/11/2015 06:00	0.2	13.3	1,884.5	0.4	1.3	1	1	1
01/11/2015 07:00	0.2	13.2	1,927.2	0.4	1.3	1	1	1
01/11/2015 08:00	-0.2	12.5	2,100.2	0.1	1.5	1	1	1
01/11/2015 09:00	-0.2	11.7	2,268.5	0.1	1.6	1	1	1
01/11/2015 10:00	-0.1	11.7	2,254.0	0.2	1.6	1	1	1
01/11/2015 11:00	-0.1	12.1	2,168.1	0.2	1.5	1	1	1
01/11/2015 12:00	0.1	12.9	1,985.3	0.2	1.4	1	1	1
01/11/2015 13:00	0.1	12.9	1,980.1	0.2	1.4	1	1	1
01/11/2015 14:00	0.2	13.2	1,914.8	0.4	1.3	1	1	1
01/11/2015 15:00	-0.2	12.9	2,005.7	0.1	1.4	1	1	1
01/11/2015 16:00	0.2	13.3	1,903.9	0.4	1.3	1	1	1
01/11/2015 17:00	-0.2	12.3	2,127.9	0.1	1.5	1	1	1
01/11/2015 18:00	-0.1	12.3	2,130.6	0.2	1.5	1	1	1
01/11/2015 19:00	-0.1	11.8	2,223.7	0.2	1.6	1	1	1
01/11/2015 20:00	-0.1	12.3	2,117.4	0.2	1.5	1	1	1
01/11/2015 21:00	-0.2	12.1	2,149.3	0.1	1.5	1	1	1
01/11/2015 22:00	0.1	13.0	1,946.8	0.2	1.4	1	1	1
01/11/2015 23:00	0.2	13.4	1,850.7	0.4	1.3	1	1	1
Average/Sum#:	0.0	12.8	2,012.0	0.3	1.4	24 #	24 #	24 #
Minimum:	-0.2	11.7	1,850.7	0.1	1.3	1	1	1
Maximum:	0.2	13.4	2,268.5	0.4	1.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/12/2015 00:00	0.1	13.1	1,953.1	0.2	1.4	1	1	1
01/12/2015 01:00	0.2	13.3	1,886.0	0.4	1.3	1	1	1
01/12/2015 02:00	0.2	13.3	1,888.2	0.4	1.3	1	1	1
01/12/2015 03:00	0.2	13.2	1,940.7	0.4	1.4	1	1	1
01/12/2015 04:00	0.2	13.2	1,920.1	0.4	1.3	1	1	1
01/12/2015 05:00	0.2	13.2	1,912.7	0.4	1.3	1	1	1
01/12/2015 06:00	0.1	13.0	2,000.2	0.2	1.4	1	1	1
01/12/2015 07:00	0.1	13.0	1,981.3	0.2	1.4	1	1	1
01/12/2015 08:00	0.2	13.1	1,982.8	0.4	1.4	1	1	1
01/12/2015 09:00	-0.4	12.5	2,097.7	-0.1	1.5	1	1	1
01/12/2015 10:00	-0.1	12.8	2,020.9	0.1	1.4	1	1	1
01/12/2015 11:00	0.4	13.3	1,862.6	0.4	1.3	1	1	1
01/12/2015 12:00	0.4	13.4	1,857.0	0.4	1.3	1	1	1
01/12/2015 13:00	0.2	13.4	1,859.2	0.4	1.3	1	1	1
01/12/2015 14:00	0.2	13.4	1,864.3	0.4	1.3	1	1	1
01/12/2015 15:00	0.2	13.4	1,867.7	0.4	1.3	1	1	1
01/12/2015 16:00	0.2	13.3	1,900.6	0.4	1.3	1	1	1
01/12/2015 17:00	-0.1	12.9	1,982.6	0.1	1.4	1	1	1
01/12/2015 18:00	-0.1	11.8	2,237.2	0.2	1.6	1	1	1
01/12/2015 19:00	-0.1	11.5	2,283.9	0.2	1.6	1	1	1
01/12/2015 20:00	0.1	11.5	2,289.6	0.2	1.6	1	1	1
01/12/2015 21:00	-0.1	11.9	2,204.2	0.2	1.5	1	1	1
01/12/2015 22:00	-0.1	12.4	2,108.4	0.2	1.5	1	1	1
01/12/2015 23:00	0.2	13.1	1,927.1	0.4	1.3	1	1	1
Average/Sum#:	0.1	12.9	1,992.8	0.3	1.4	24 #	24 #	24 #
Minimum:	-0.4	11.5	1,857.0	-0.1	1.3	1	1	1
Maximum:	0.4	13.4	2,289.6	0.4	1.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/13/2015 00:00	-0.1	12.8	2,016.7	0.1	1.4	1	1	1
01/13/2015 01:00	-0.1	12.8	2,008.9	0.1	1.4	1	1	1
01/13/2015 02:00	-0.1	12.9	2,001.1	0.1	1.4	1	1	1
01/13/2015 03:00	0.1	13.0	1,971.8	0.2	1.4	1	1	1
01/13/2015 04:00	0.2	13.2	1,929.0	0.4	1.4	1	1	1
01/13/2015 05:00	0.4	13.4	1,860.4	0.4	1.3	1	1	1
01/13/2015 06:00	0.2	13.2	1,916.4	0.4	1.3	1	1	1
01/13/2015 07:00	-0.2	12.9	2,011.1	0.1	1.4	1	1	1
01/13/2015 08:00	0.2	13.2	1,934.7	0.4	1.4	1	1	1
01/13/2015 09:00	0.2	13.4	1,878.3	0.4	1.3	1	1	1
01/13/2015 10:00	-0.2	12.9	2,002.5	0.1	1.4	1	1	1
01/13/2015 11:00	-0.1	12.8	2,012.3	0.1	1.4	1	1	1
01/13/2015 12:00	0.1	13.1	1,936.1	0.2	1.4	1	1	1
01/13/2015 13:00	0.1	13.0	1,959.1	0.2	1.4	1	1	1
01/13/2015 14:00	0.1	13.1	1,929.7	0.2	1.4	1	1	1
01/13/2015 15:00	0.2	13.3	1,905.9	0.4	1.3	1	1	1
01/13/2015 16:00	0.2	13.3	1,907.8	0.4	1.3	1	1	1
01/13/2015 17:00	-0.2	12.3	2,138.0	0.1	1.5	1	1	1
01/13/2015 18:00	-0.1	11.6	2,281.6	0.2	1.6	1	1	1
01/13/2015 19:00	-0.1	11.6	2,281.2	0.2	1.6	1	1	1
01/13/2015 20:00	0.1	11.6	2,277.2	0.2	1.6	1	1	1
01/13/2015 21:00	-0.1	12.0	2,191.4	0.2	1.5	1	1	1
01/13/2015 22:00	-0.1	12.3	2,109.5	0.2	1.5	1	1	1
01/13/2015 23:00	0.7	13.6	1,633.9	0.7	1.1	1	1	1
Average/Sum#:	0.1	12.8	2,003.9	0.3	1.4	24 #	24 #	24 #
Minimum:	-0.2	11.6	1,633.9	0.1	1.1	1	1	1
Maximum:	0.7	13.6	2,281.6	0.7	1.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/14/2015 00:00	0.6	13.9	1,341.9	0.6	0.9	1	1	0
01/14/2015 01:00	0.6	13.8	1,577.7	0.6	1.1	1	1	0
01/14/2015 02:00	0.5	13.6	1,700.8	0.5	1.2	1	1	1
01/14/2015 03:00	0.1	13.2	1,925.6	0.2	1.3	1	1	1
01/14/2015 04:00	0.1	13.2	1,965.7	0.2	1.4	1	1	1
01/14/2015 05:00	0.1	13.3	1,872.9	0.2	1.3	1	1	1
01/14/2015 06:00	-0.1	13.0	1,972.6	0.1	1.4	1	1	1
01/14/2015 07:00	-0.5	12.0	2,240.7	-0.1	1.6	1	1	1
01/14/2015 08:00	-0.2	12.5	2,105.1	0.1	1.5	1	1	1
01/14/2015 09:00	0.2	13.1	1,965.4	0.4	1.4	1	1	1
01/14/2015 10:00	0.2	13.2	1,885.7	0.4	1.3	1	1	1
01/14/2015 11:00	0.2	13.3	1,852.0	0.4	1.3	1	1	1
01/14/2015 12:00	0.2	13.3	1,853.9	0.4	1.3	1	1	1
01/14/2015 13:00	0.2	13.3	1,861.5	0.4	1.3	1	1	1
01/14/2015 14:00	0.1	13.4	1,867.5	0.2	1.3	1	1	1
01/14/2015 15:00	0.1	13.4	1,878.6	0.2	1.3	1	1	1
01/14/2015 16:00	0.1	13.3	1,923.3	0.2	1.3	1	1	1
01/14/2015 17:00	-0.4	12.5	2,109.9	-0.1	1.5	1	1	1
01/14/2015 18:00	-0.2	11.6	2,287.7	0.1	1.6	1	1	1
01/14/2015 19:00	-0.1	11.7	2,287.9	0.2	1.6	1	1	1
01/14/2015 20:00	-0.1	11.7	2,286.7	0.2	1.6	1	1	1
01/14/2015 21:00	-0.1	11.8	2,273.1	0.2	1.6	1	1	1
01/14/2015 22:00	-0.1	12.6	2,076.8	0.1	1.5	1	1	1
01/14/2015 23:00	0.2	13.4	1,878.2	0.4	1.3	1	1	1
Average/Sum#:	0.1	12.9	1,958.0	0.3	1.4	24 #	24 #	22 #
Minimum:	-0.5	11.6	1,341.9	-0.1	0.9	1	1	0
Maximum:	0.6	13.9	2,287.9	0.6	1.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/15/2015 00:00	0.2	13.3	1,903.4	0.4	1.3	1	1	1
01/15/2015 01:00	0.2	13.4	1,848.5	0.4	1.3	1	1	1
01/15/2015 02:00	0.2	13.4	1,846.5	0.4	1.3	1	1	1
01/15/2015 03:00	0.2	13.4	1,851.6	0.4	1.3	1	1	1
01/15/2015 04:00	0.2	13.4	1,859.6	0.4	1.3	1	1	1
01/15/2015 05:00	0.2	13.4	1,856.0	0.4	1.3	1	1	1
01/15/2015 06:00	-0.1	13.1	1,984.5	0.1	1.4	1	1	1
01/15/2015 07:00	-0.5	12.3	2,207.9	-0.1	1.5	1	1	1
01/15/2015 08:00	0.1	13.0	1,979.3	0.2	1.4	1	1	1
01/15/2015 09:00	0.5	13.6	1,572.7	0.5	1.1	1	1	1
01/15/2015 10:00	0.6	13.9	1,302.2	0.6	0.9	1	1	0
01/15/2015 11:00	0.6	13.9	1,304.2	0.6	0.9	1	1	0
01/15/2015 12:00	0.6	13.9	1,304.0	0.6	0.9	1	1	0
01/15/2015 13:00	0.6	13.9	1,299.9	0.6	0.9	1	1	0
01/15/2015 14:00	0.6	13.9	1,299.7	0.6	0.9	1	1	0
01/15/2015 15:00	0.6	13.9	1,332.8	0.6	0.9	1	1	0
01/15/2015 16:00	0.2	13.4	1,880.8	0.4	1.3	1	1	1
01/15/2015 17:00	-0.4	12.1	2,218.1	-0.1	1.6	1	1	1
01/15/2015 18:00	0.5	13.2	1,881.3	0.5	1.3	1	1	1
01/15/2015 19:00	0.1	12.7	2,065.5	0.2	1.4	1	1	1
01/15/2015 20:00	-0.2	12.6	2,066.1	0.1	1.4	1	1	1
01/15/2015 21:00	-0.2	12.6	2,090.5	0.1	1.5	1	1	1
01/15/2015 22:00	-0.2	12.3	2,133.8	0.1	1.5	1	1	1
01/15/2015 23:00	0.4	13.2	1,881.8	0.4	1.3	1	1	1
Average/Sum#:	0.2	13.2	1,790.4	0.4	1.2	24 #	24 #	18 #
Minimum:	-0.5	12.1	1,299.7	-0.1	0.9	1	1	0
Maximum:	0.6	13.9	2,218.1	0.6	1.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/16/2015 00:00	0.4	13.3	1,845.7	0.4	1.3	1	1	1
01/16/2015 01:00	0.2	13.3	1,848.6	0.4	1.3	1	1	1
01/16/2015 02:00	0.2	13.3	1,853.9	0.4	1.3	1	1	1
01/16/2015 03:00	0.5	13.6	1,622.1	0.5	1.1	1	1	1
01/16/2015 04:00	0.6	13.9	1,320.0	0.6	0.9	1	1	0
01/16/2015 05:00	0.2	13.4	1,834.2	0.4	1.3	1	1	1
01/16/2015 06:00	-0.1	13.1	1,954.4	0.1	1.4	1	1	1
01/16/2015 07:00	-0.4	12.1	2,204.3	-0.1	1.5	1	1	1
01/16/2015 08:00	0.1	13.2	1,929.8	0.2	1.4	1	1	1
01/16/2015 09:00	0.4	13.5	1,853.0	0.4	1.3	1	1	1
01/16/2015 10:00	0.4	13.5	1,870.6	0.4	1.3	1	1	1
01/16/2015 11:00	0.4	13.4	1,888.8	0.4	1.3	1	1	1
01/16/2015 12:00	0.5	13.7	1,475.3	0.5	1.0	1	1	1
01/16/2015 13:00	0.6	13.9	1,284.5	0.6	0.9	1	1	0
01/16/2015 14:00	0.6	13.9	1,281.9	0.6	0.9	1	1	0
01/16/2015 15:00	0.6	13.9	1,282.9	0.6	0.9	1	1	0
01/16/2015 16:00	0.1	13.3	1,750.4	0.2	1.2	1	1	1
01/16/2015 17:00	-0.4	12.9	1,903.4	-0.1	1.3	1	1	1
01/16/2015 18:00	0.6	13.9	1,333.6	0.6	0.9	1	1	0
01/16/2015 19:00	0.6	13.9	1,294.3	0.6	0.9	1	1	0
01/16/2015 20:00	0.6	13.9	1,299.4	0.6	0.9	1	1	0
01/16/2015 21:00	0.6	13.9	1,317.3	0.6	0.9	1	1	0
01/16/2015 22:00	0.6	13.9	1,521.6	0.6	1.1	1	1	0
01/16/2015 23:00	0.6	13.9	1,306.3	0.6	0.9	1	1	0
Average/Sum#:	0.4	13.5	1,628.2	0.4	1.1	24 #	24 #	14 #
Minimum:	-0.4	12.1	1,281.9	-0.1	0.9	1	1	0
Maximum:	0.6	13.9	2,204.3	0.6	1.5	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/17/2015 00:00	0.6	13.9	1,326.5	0.6	0.9	1	1	0
01/17/2015 01:00	0.6	13.9	1,539.9	0.6	1.1	1	1	0
01/17/2015 02:00	0.6	13.9	1,429.4	0.6	1.0	1	1	0
01/17/2015 03:00	0.6	13.9	1,598.8	0.6	1.1	1	1	0
01/17/2015 04:00	0.6	13.9	1,318.4	0.6	0.9	1	1	0
01/17/2015 05:00	0.6	13.9	1,356.8	0.6	0.9	1	1	0
01/17/2015 06:00	0.7	13.8	1,821.6	0.7	1.3	1	1	1
01/17/2015 07:00	0.6	13.7	1,845.6	0.6	1.3	1	1	0
01/17/2015 08:00	0.7	13.8	1,816.3	0.7	1.3	1	1	1
01/17/2015 09:00	0.7	13.9	1,794.9	0.7	1.3	1	1	1
01/17/2015 10:00	0.5	13.6	1,819.4	0.5	1.3	1	1	1
01/17/2015 11:00	0.4	13.6	1,851.1	0.4	1.3	1	1	1
01/17/2015 12:00	0.4	13.6	1,856.8	0.4	1.3	1	1	1
01/17/2015 13:00	0.7	13.7	1,574.4	0.7	1.1	1	1	1
01/17/2015 14:00	0.6	13.9	1,302.1	0.6	0.9	1	1	0
01/17/2015 15:00	0.6	13.9	1,302.3	0.6	0.9	1	1	0
01/17/2015 16:00	0.5	13.7	1,631.7	0.5	1.1	1	1	1
01/17/2015 17:00	0.1	13.1	1,944.3	0.2	1.4	1	1	1
01/17/2015 18:00	-0.4	12.0	2,197.9	-0.1	1.5	1	1	1
01/17/2015 19:00	-0.1	12.2	2,138.8	0.2	1.5	1	1	1
01/17/2015 20:00	0.1	12.9	2,006.3	0.2	1.4	1	1	1
01/17/2015 21:00	-0.2	12.7	2,042.8	0.1	1.4	1	1	1
01/17/2015 22:00	-0.1	12.8	2,036.5	0.1	1.4	1	1	1
01/17/2015 23:00	-0.2	12.7	2,050.7	0.1	1.4	1	1	1
Average/Sum#:	0.4	13.5	1,733.5	0.5	1.2	24 #	24 #	15 #
Minimum:	-0.4	12.0	1,302.1	-0.1	0.9	1	1	0
Maximum:	0.7	13.9	2,197.9	0.7	1.5	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/18/2015 00:00	0.2	13.0	1,973.6	0.4	1.4	1	1	1
01/18/2015 01:00	0.4	13.4	1,781.2	0.4	1.2	1	1	1
01/18/2015 02:00	0.0	15.0	891.9	0.0	0.6	1	0	0
01/18/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/18/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/18/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/18/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/18/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/18/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/18/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/18/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/18/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/18/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/18/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/18/2015 14:00	0.0	17.7	462.1	0.0	0.3	1	0	0
01/18/2015 15:00	0.0	15.7	787.3	0.0	0.6	1	0	0
01/18/2015 16:00	0.0	13.9	1,439.7	0.0	1.0	1	0	1
01/18/2015 17:00	0.4	13.3	1,908.4	0.4	1.3	1	1	1
01/18/2015 18:00	0.1	12.9	2,006.6	0.2	1.4	1	1	1
01/18/2015 19:00	0.1	13.0	2,002.9	0.2	1.4	1	1	1
01/18/2015 20:00	0.1	13.1	1,973.4	0.2	1.4	1	1	1
01/18/2015 21:00	0.4	13.4	1,910.9	0.4	1.3	1	1	1
01/18/2015 22:00	0.6	13.9	1,474.8	0.6	1.0	1	1	0
01/18/2015 23:00	0.6	13.9	1,303.8	0.6	0.9	1	1	0
Average/Sum#:	0.2	14.0	1,532.0	0.3	1.1	13 #	9 #	8 #
Minimum:	0.0	12.9	462.1	0.0	0.3	0	0	0
Maximum:	0.6	17.7	2,006.6	0.6	1.4	1	1	1
%SI	45.8	45.8	45.8	45.8	45.8	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/19/2015 00:00	0.6	13.9	1,510.2	0.6	1.1	1	1	0
01/19/2015 01:00	0.6	13.9	1,353.2	0.6	0.9	1	1	0
01/19/2015 02:00	0.6	13.9	1,305.2	0.6	0.9	1	1	0
01/19/2015 03:00	0.6	13.8	1,577.9	0.6	1.1	1	1	0
01/19/2015 04:00	0.2	13.3	1,894.6	0.4	1.3	1	1	1
01/19/2015 05:00	0.2	13.1	1,977.8	0.4	1.4	1	1	1
01/19/2015 06:00	0.2	13.1	1,986.1	0.4	1.4	1	1	1
01/19/2015 07:00	-0.4	12.7	2,082.5	-0.1	1.5	1	1	1
01/19/2015 08:00	0.4	13.3	1,928.6	0.4	1.4	1	1	1
01/19/2015 09:00	0.4	13.4	1,895.4	0.4	1.3	1	1	1
01/19/2015 10:00	0.2	13.3	1,928.8	0.4	1.4	1	1	1
01/19/2015 11:00	0.4	13.4	1,857.5	0.4	1.3	1	1	1
01/19/2015 12:00	0.4	13.4	1,868.9	0.4	1.3	1	1	1
01/19/2015 13:00	0.4	13.4	1,866.3	0.4	1.3	1	1	1
01/19/2015 14:00	0.4	13.4	1,870.6	0.4	1.3	1	1	1
01/19/2015 15:00	0.2	13.3	1,913.8	0.4	1.3	1	1	1
01/19/2015 16:00	0.2	13.1	1,961.9	0.4	1.4	1	1	1
01/19/2015 17:00	-0.1	12.8	2,029.6	0.1	1.4	1	1	1
01/19/2015 18:00	-0.4	12.4	2,104.2	-0.1	1.5	1	1	1
01/19/2015 19:00	-0.4	12.5	2,085.0	-0.1	1.5	1	1	1
01/19/2015 20:00	-0.2	12.7	2,048.2	0.1	1.4	1	1	1
01/19/2015 21:00	-0.1	12.8	2,029.3	0.1	1.4	1	1	1
01/19/2015 22:00	0.2	13.2	1,922.5	0.4	1.3	1	1	1
01/19/2015 23:00	0.4	13.3	1,857.9	0.4	1.3	1	1	1
Average/Sum#:	0.2	13.2	1,869.0	0.3	1.3	24 #	24 #	20 #
Minimum:	-0.4	12.4	1,305.2	-0.1	0.9	1	1	0
Maximum:	0.6	13.9	2,104.2	0.6	1.5	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/20/2015 00:00	0.2	13.2	1,947.2	0.4	1.4	1	1	1
01/20/2015 01:00	0.4	13.3	1,850.9	0.4	1.3	1	1	1
01/20/2015 02:00	0.4	13.3	1,852.8	0.4	1.3	1	1	1
01/20/2015 03:00	0.4	13.3	1,854.0	0.4	1.3	1	1	1
01/20/2015 04:00	0.4	13.3	1,855.6	0.4	1.3	1	1	1
01/20/2015 05:00	0.4	13.3	1,854.3	0.4	1.3	1	1	1
01/20/2015 06:00	0.1	13.1	1,982.8	0.2	1.4	1	1	1
01/20/2015 07:00	0.1	13.0	2,013.5	0.2	1.4	1	1	1
01/20/2015 08:00	-0.1	13.0	2,022.0	0.1	1.4	1	1	1
01/20/2015 09:00	-0.1	13.0	2,018.2	0.1	1.4	1	1	1
01/20/2015 10:00	0.1	13.0	2,003.5	0.2	1.4	1	1	1
01/20/2015 11:00	-0.1	12.9	2,018.4	0.1	1.4	1	1	1
01/20/2015 12:00	-0.2	12.8	2,025.1	0.1	1.4	1	1	1
01/20/2015 13:00	-0.1	12.9	2,003.4	0.1	1.4	1	1	1
01/20/2015 14:00	-0.1	12.9	2,013.9	0.1	1.4	1	1	1
01/20/2015 15:00	-0.2	12.8	2,032.1	0.1	1.4	1	1	1
01/20/2015 16:00	0.4	13.3	1,880.4	0.4	1.3	1	1	1
01/20/2015 17:00	0.2	13.2	1,909.7	0.4	1.3	1	1	1
01/20/2015 18:00	-0.2	12.8	2,028.4	0.1	1.4	1	1	1
01/20/2015 19:00	-0.2	12.8	2,040.7	0.1	1.4	1	1	1
01/20/2015 20:00	-0.1	12.9	2,003.2	0.1	1.4	1	1	1
01/20/2015 21:00	-0.1	12.9	2,023.2	0.1	1.4	1	1	1
01/20/2015 22:00	0.1	13.1	1,980.3	0.2	1.4	1	1	1
01/20/2015 23:00	0.4	13.5	1,852.4	0.4	1.3	1	1	1
Average/Sum#:	0.1	13.1	1,961.1	0.2	1.4	24 #	24 #	24 #
Minimum:	-0.2	12.8	1,850.9	0.1	1.3	1	1	1
Maximum:	0.4	13.5	2,040.7	0.4	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/21/2015 00:00	0.5	13.6	1,873.4	0.5	1.3	1	1	1
01/21/2015 01:00	0.5	13.6	1,858.6	0.5	1.3	1	1	1
01/21/2015 02:00	0.4	13.5	1,891.8	0.4	1.3	1	1	1
01/21/2015 03:00	0.5	13.6	1,850.1	0.5	1.3	1	1	1
01/21/2015 04:00	0.4	13.5	1,863.1	0.4	1.3	1	1	1
01/21/2015 05:00	0.2	13.4	1,857.4	0.4	1.3	1	1	1
01/21/2015 06:00	0.2	13.3	1,940.4	0.4	1.4	1	1	1
01/21/2015 07:00	0.1	13.1	1,997.6	0.2	1.4	1	1	1
01/21/2015 08:00	-0.2	12.9	2,042.0	0.1	1.4	1	1	1
01/21/2015 09:00	-0.1	12.9	2,011.3	0.1	1.4	1	1	1
01/21/2015 10:00	0.2	13.2	1,940.3	0.4	1.4	1	1	1
01/21/2015 11:00	0.2	13.2	1,935.7	0.4	1.4	1	1	1
01/21/2015 12:00	0.2	13.3	1,916.2	0.4	1.3	1	1	1
01/21/2015 13:00	0.4	13.4	1,872.3	0.4	1.3	1	1	1
01/21/2015 14:00	0.4	13.5	1,861.8	0.4	1.3	1	1	1
01/21/2015 15:00	0.2	13.2	1,928.0	0.4	1.3	1	1	1
01/21/2015 16:00	0.1	13.0	1,961.3	0.2	1.4	1	1	1
01/21/2015 17:00	0.1	12.9	1,993.4	0.2	1.4	1	1	1
01/21/2015 18:00	-0.2	12.7	2,035.7	0.1	1.4	1	1	1
01/21/2015 19:00	-0.2	12.8	2,030.6	0.1	1.4	1	1	1
01/21/2015 20:00	0.1	13.0	2,003.0	0.2	1.4	1	1	1
01/21/2015 21:00	0.1	13.0	1,994.4	0.2	1.4	1	1	1
01/21/2015 22:00	0.2	13.2	1,917.5	0.4	1.3	1	1	1
01/21/2015 23:00	0.7	13.7	1,560.2	0.7	1.1	1	1	1
Average/Sum#:	0.2	13.2	1,922.3	0.3	1.3	24 #	24 #	24 #
Minimum:	-0.2	12.7	1,560.2	0.1	1.1	1	1	1
Maximum:	0.7	13.7	2,042.0	0.7	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/22/2015 00:00	0.6	13.9	1,405.6	0.6	1.0	1	1	0
01/22/2015 01:00	0.6	13.9	1,300.1	0.6	0.9	1	1	0
01/22/2015 02:00	0.6	13.9	1,312.8	0.6	0.9	1	1	0
01/22/2015 03:00	0.5	13.8	1,568.1	0.5	1.1	1	1	1
01/22/2015 04:00	0.2	13.3	1,873.8	0.4	1.3	1	1	1
01/22/2015 05:00	0.2	13.3	1,859.5	0.4	1.3	1	1	1
01/22/2015 06:00	0.2	13.2	1,920.1	0.4	1.3	1	1	1
01/22/2015 07:00	-0.1	12.9	2,005.8	0.1	1.4	1	1	1
01/22/2015 08:00	0.1	13.1	1,977.5	0.2	1.4	1	1	1
01/22/2015 09:00	-0.1	13.0	2,010.7	0.1	1.4	1	1	1
01/22/2015 10:00	0.4	13.3	1,862.6	0.4	1.3	1	1	1
01/22/2015 11:00	0.2	13.3	1,854.4	0.4	1.3	1	1	1
01/22/2015 12:00	0.2	13.3	1,849.5	0.4	1.3	1	1	1
01/22/2015 13:00	0.7	13.7	1,506.2	0.7	1.1	1	1	1
01/22/2015 14:00	0.6	13.9	1,646.5	0.6	1.2	1	1	0
01/22/2015 15:00	0.5	13.6	1,733.1	0.5	1.2	1	1	1
01/22/2015 16:00	0.2	13.4	1,854.7	0.4	1.3	1	1	1
01/22/2015 17:00	0.1	13.1	1,966.0	0.2	1.4	1	1	1
01/22/2015 18:00	-0.2	12.8	2,038.4	0.1	1.4	1	1	1
01/22/2015 19:00	-0.1	12.9	2,028.0	0.1	1.4	1	1	1
01/22/2015 20:00	0.1	13.1	1,991.3	0.2	1.4	1	1	1
01/22/2015 21:00	0.2	13.2	1,951.3	0.4	1.4	1	1	1
01/22/2015 22:00	0.2	13.3	1,925.8	0.4	1.3	1	1	1
01/22/2015 23:00	0.5	13.4	1,877.1	0.5	1.3	1	1	1
Average/Sum#:	0.3	13.4	1,805.0	0.4	1.3	24 #	24 #	20 #
Minimum:	-0.2	12.8	1,300.1	0.1	0.9	1	1	0
Maximum:	0.7	13.9	2,038.4	0.7	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/23/2015 00:00	0.2	13.2	1,932.9	0.4	1.4	1	1	1
01/23/2015 01:00	0.5	13.4	1,894.6	0.5	1.3	1	1	1
01/23/2015 02:00	0.2	13.1	1,990.2	0.4	1.4	1	1	1
01/23/2015 03:00	0.2	13.1	1,970.3	0.4	1.4	1	1	1
01/23/2015 04:00	0.4	13.3	1,905.7	0.4	1.3	1	1	1
01/23/2015 05:00	0.4	13.3	1,895.9	0.4	1.3	1	1	1
01/23/2015 06:00	0.2	13.2	1,954.9	0.4	1.4	1	1	1
01/23/2015 07:00	-0.1	12.9	2,022.8	0.1	1.4	1	1	1
01/23/2015 08:00	0.1	13.0	2,004.0	0.2	1.4	1	1	1
01/23/2015 09:00	0.4	13.4	1,914.9	0.4	1.3	1	1	1
01/23/2015 10:00	0.4	13.3	1,893.1	0.4	1.3	1	1	1
01/23/2015 11:00	0.4	13.4	1,859.7	0.4	1.3	1	1	1
01/23/2015 12:00	0.4	13.5	1,866.6	0.4	1.3	1	1	1
01/23/2015 13:00	0.4	13.4	1,865.8	0.4	1.3	1	1	1
01/23/2015 14:00	0.4	13.4	1,862.6	0.4	1.3	1	1	1
01/23/2015 15:00	0.4	13.3	1,877.6	0.4	1.3	1	1	1
01/23/2015 16:00	0.2	13.2	1,917.1	0.4	1.3	1	1	1
01/23/2015 17:00	0.2	13.2	1,930.0	0.4	1.4	1	1	1
01/23/2015 18:00	-0.2	12.7	2,040.9	0.1	1.4	1	1	1
01/23/2015 19:00	-0.2	12.6	2,058.2	0.1	1.4	1	1	1
01/23/2015 20:00	-0.2	12.6	2,047.5	0.1	1.4	1	1	1
01/23/2015 21:00	-0.1	12.8	2,012.3	0.1	1.4	1	1	1
01/23/2015 22:00	0.1	12.8	2,015.9	0.2	1.4	1	1	1
01/23/2015 23:00	0.2	13.3	1,915.5	0.4	1.3	1	1	1
Average/Sum#:	0.2	13.1	1,943.7	0.3	1.4	24 #	24 #	24 #
Minimum:	-0.2	12.6	1,859.7	0.1	1.3	1	1	1
Maximum:	0.5	13.5	2,058.2	0.5	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/24/2015 00:00	0.4	13.5	1,862.6	0.4	1.3	1	1	1
01/24/2015 01:00	0.4	13.4	1,881.3	0.4	1.3	1	1	1
01/24/2015 02:00	0.4	13.5	1,858.6	0.4	1.3	1	1	1
01/24/2015 03:00	0.4	13.5	1,867.4	0.4	1.3	1	1	1
01/24/2015 04:00	0.1	13.2	1,942.6	0.2	1.4	1	1	1
01/24/2015 05:00	0.1	13.0	1,988.1	0.2	1.4	1	1	1
01/24/2015 06:00	0.1	13.0	1,985.2	0.2	1.4	1	1	1
01/24/2015 07:00	-0.1	12.9	2,010.4	0.1	1.4	1	1	1
01/24/2015 08:00	0.2	13.2	1,935.9	0.4	1.4	1	1	1
01/24/2015 09:00	0.2	13.3	1,899.6	0.4	1.3	1	1	1
01/24/2015 10:00	0.2	13.4	1,847.6	0.4	1.3	1	1	1
01/24/2015 11:00	0.4	13.4	1,864.6	0.4	1.3	1	1	1
01/24/2015 12:00	0.4	13.4	1,860.5	0.4	1.3	1	1	1
01/24/2015 13:00	0.4	13.4	1,834.8	0.4	1.3	1	1	1
01/24/2015 14:00	0.6	14.0	1,300.9	0.6	0.9	1	1	0
01/24/2015 15:00	0.6	14.0	1,297.6	0.6	0.9	1	1	0
01/24/2015 16:00	0.6	14.0	1,443.9	0.6	1.0	1	1	0
01/24/2015 17:00	0.1	13.1	1,829.0	0.2	1.3	1	1	1
01/24/2015 18:00	-0.4	12.5	2,070.2	-0.1	1.4	1	1	1
01/24/2015 19:00	-0.4	12.7	2,046.6	-0.1	1.4	1	1	1
01/24/2015 20:00	0.1	13.0	1,985.7	0.2	1.4	1	1	1
01/24/2015 21:00	-0.1	12.9	2,002.8	0.1	1.4	1	1	1
01/24/2015 22:00	-0.1	12.9	2,018.4	0.1	1.4	1	1	1
01/24/2015 23:00	-0.1	13.1	1,976.8	0.1	1.4	1	1	1
Average/Sum#:	0.2	13.3	1,858.8	0.3	1.3	24 #	24 #	21 #
Minimum:	-0.4	12.5	1,297.6	-0.1	0.9	1	1	0
Maximum:	0.6	14.0	2,070.2	0.6	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/25/2015 00:00	0.6	13.9	1,469.4	0.6	1.0	1	1	0
01/25/2015 01:00	0.0	15.8	589.7	0.0	0.4	1	0	0
01/25/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 12:00	0.0	17.7	466.5	0.0	0.3	1	0	0
01/25/2015 13:00	0.0	15.9	709.9	0.0	0.5	1	0	0
01/25/2015 14:00	0.0	14.1	1,438.1	0.0	1.0	1	0	0
01/25/2015 15:00	0.6	13.9	1,776.5	0.6	1.2	1	1	0
01/25/2015 16:00	0.6	13.9	1,660.8	0.6	1.2	1	1	0
01/25/2015 17:00	0.1	13.2	1,820.2	0.2	1.3	1	1	1
01/25/2015 18:00	-0.8	12.2	2,162.4	-0.4	1.5	1	1	1
01/25/2015 19:00	0.2	13.3	1,823.5	0.4	1.3	1	1	1
01/25/2015 20:00	0.6	13.9	1,809.1	0.6	1.3	1	1	0
01/25/2015 21:00	0.6	13.9	1,710.2	0.6	1.2	1	1	0
01/25/2015 22:00	0.0	14.5	1,351.6	0.0	0.9	1	0	0
01/25/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.2	14.3	1,445.2	0.2	1.0	13 #	8 #	3 #
Minimum:	-0.8	12.2	466.5	-0.4	0.3	0	0	0
Maximum:	0.6	17.7	2,162.4	0.6	1.5	1	1	1
%SI	45.8	45.8	45.8	45.8	45.8	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/26/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 04:00	0.0	17.1	553.9	0.0	0.4	1	0	0
01/26/2015 05:00	0.0	14.4	1,288.0	0.0	0.9	1	0	0
01/26/2015 06:00	0.6	13.8	1,715.5	0.6	1.2	1	1	0
01/26/2015 07:00	0.6	13.9	1,814.9	0.6	1.3	1	1	0
01/26/2015 08:00	0.6	13.9	1,813.7	0.6	1.3	1	1	0
01/26/2015 09:00	0.6	13.8	1,815.7	0.6	1.3	1	1	0
01/26/2015 10:00	0.6	13.8	1,819.4	0.6	1.3	1	1	0
01/26/2015 11:00	0.6	13.8	1,772.5	0.6	1.2	1	1	0
01/26/2015 12:00	0.6	13.8	1,818.6	0.6	1.3	1	1	0
01/26/2015 13:00	0.6	13.8	1,798.5	0.6	1.3	1	1	0
01/26/2015 14:00	0.6	13.8	1,803.2	0.6	1.3	1	1	0
01/26/2015 15:00	0.6	13.8	1,799.5	0.6	1.3	1	1	0
01/26/2015 16:00	0.6	13.8	1,797.6	0.6	1.3	1	1	0
01/26/2015 17:00	0.6	13.9	1,615.7	0.6	1.1	1	1	0
01/26/2015 18:00	0.6	13.9	1,670.9	0.6	1.2	1	1	0
01/26/2015 19:00	0.6	13.8	1,815.6	0.6	1.3	1	1	0
01/26/2015 20:00	0.6	13.8	1,815.3	0.6	1.3	1	1	0
01/26/2015 21:00	0.6	13.9	1,593.4	0.6	1.1	1	1	0
01/26/2015 22:00	0.6	13.9	1,451.2	0.6	1.0	1	1	0
01/26/2015 23:00	0.6	13.9	1,353.0	0.6	0.9	1	1	0
Average/Sum#:	0.5	14.0	1,646.3	0.5	1.2	20 #	18 #	0 #
Minimum:	0.0	13.8	553.9	0.0	0.4	0	0	0
Maximum:	0.6	17.1	1,819.4	0.6	1.3	1	1	0
%SI	16.7	16.7	16.7	16.7	16.7	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/27/2015 00:00	0.6	13.9	1,357.9	0.6	1.0	1	1	0
01/27/2015 01:00	0.5	13.9	1,356.6	0.5	0.9	1	1	0
01/27/2015 02:00	0.6	13.9	1,557.3	0.6	1.1	1	1	0
01/27/2015 03:00	0.6	13.9	1,710.1	0.6	1.2	1	1	0
01/27/2015 04:00	0.6	13.7	1,821.4	0.6	1.3	1	1	0
01/27/2015 05:00	0.6	13.7	1,836.0	0.6	1.3	1	1	0
01/27/2015 06:00	0.6	13.7	1,841.9	0.6	1.3	1	1	0
01/27/2015 07:00	0.5	13.7	1,843.9	0.5	1.3	1	1	0
01/27/2015 08:00	0.6	13.7	1,841.8	0.6	1.3	1	1	0
01/27/2015 09:00	0.6	13.7	1,831.9	0.6	1.3	1	1	0
01/27/2015 10:00	0.5	13.9	1,386.8	0.5	1.0	1	1	0
01/27/2015 11:00	0.5	13.9	1,276.1	0.5	0.9	1	1	0
01/27/2015 12:00	0.6	13.9	1,302.4	0.6	0.9	1	1	0
01/27/2015 13:00	0.6	13.9	1,559.6	0.6	1.1	1	1	0
01/27/2015 14:00	0.6	13.9	1,295.6	0.6	0.9	1	1	0
01/27/2015 15:00	0.6	13.9	1,571.0	0.6	1.1	1	1	0
01/27/2015 16:00	0.6	13.9	1,322.9	0.6	0.9	1	1	0
01/27/2015 17:00	0.4	13.6	1,656.7	0.4	1.2	1	1	1
01/27/2015 18:00	-0.2	13.0	1,990.1	0.1	1.4	1	1	1
01/27/2015 19:00	-0.1	13.0	1,980.6	0.1	1.4	1	1	1
01/27/2015 20:00	0.1	13.1	1,962.0	0.2	1.4	1	1	1
01/27/2015 21:00	-0.1	13.1	1,971.7	0.1	1.4	1	1	1
01/27/2015 22:00	-0.1	13.0	1,963.0	0.1	1.4	1	1	1
01/27/2015 23:00	0.5	13.7	1,563.3	0.5	1.1	1	1	1
Average/Sum#:	0.4	13.7	1,658.4	0.5	1.2	24 #	24 #	7 #
Minimum:	-0.2	13.0	1,276.1	0.1	0.9	1	1	0
Maximum:	0.6	13.9	1,990.1	0.6	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/28/2015 00:00	0.6	13.9	1,278.9	0.6	0.9	1	1	0
01/28/2015 01:00	0.6	13.9	1,278.5	0.6	0.9	1	1	0
01/28/2015 02:00	0.6	13.9	1,272.6	0.6	0.9	1	1	0
01/28/2015 03:00	0.6	13.9	1,271.8	0.6	0.9	1	1	0
01/28/2015 04:00	0.6	13.9	1,281.0	0.6	0.9	1	1	0
01/28/2015 05:00	0.4	13.6	1,610.8	0.4	1.1	1	1	1
01/28/2015 06:00	0.2	13.5	1,879.1	0.4	1.3	1	1	1
01/28/2015 07:00	-0.4	12.7	2,022.9	-0.1	1.4	1	1	1
01/28/2015 08:00	0.4	13.3	1,875.2	0.4	1.3	1	1	1
01/28/2015 09:00	0.4	13.6	1,850.2	0.4	1.3	1	1	1
01/28/2015 10:00	0.4	13.6	1,851.3	0.4	1.3	1	1	1
01/28/2015 11:00	0.5	13.6	1,734.5	0.5	1.2	1	1	1
01/28/2015 12:00	0.6	14.0	1,269.0	0.6	0.9	1	1	0
01/28/2015 13:00	0.6	13.9	1,609.9	0.6	1.1	1	1	0
01/28/2015 14:00	0.2	13.4	1,834.3	0.4	1.3	1	1	1
01/28/2015 15:00	-0.4	12.4	2,058.7	-0.1	1.4	1	1	1
01/28/2015 16:00	-0.2	12.8	1,991.8	0.1	1.4	1	1	1
01/28/2015 17:00	0.1	13.0	1,944.7	0.2	1.4	1	1	1
01/28/2015 18:00	-0.2	12.8	2,005.7	0.1	1.4	1	1	1
01/28/2015 19:00	-0.2	12.8	2,006.1	0.1	1.4	1	1	1
01/28/2015 20:00	0.2	13.1	1,939.0	0.4	1.4	1	1	1
01/28/2015 21:00	0.1	13.1	1,954.1	0.2	1.4	1	1	1
01/28/2015 22:00	0.1	13.1	1,924.9	0.2	1.3	1	1	1
01/28/2015 23:00	0.4	13.4	1,847.1	0.4	1.3	1	1	1
Average/Sum#:	0.3	13.4	1,733.0	0.4	1.2	24 #	24 #	17 #
Minimum:	-0.4	12.4	1,269.0	-0.1	0.9	1	1	0
Maximum:	0.6	14.0	2,058.7	0.6	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/29/2015 00:00	0.4	13.4	1,844.4	0.4	1.3	1	1	1
01/29/2015 01:00	0.2	13.4	1,849.0	0.4	1.3	1	1	1
01/29/2015 02:00	0.4	13.4	1,850.8	0.4	1.3	1	1	1
01/29/2015 03:00	0.4	13.4	1,848.3	0.4	1.3	1	1	1
01/29/2015 04:00	0.4	13.4	1,858.4	0.4	1.3	1	1	1
01/29/2015 05:00	0.4	13.4	1,853.3	0.4	1.3	1	1	1
01/29/2015 06:00	0.2	13.2	1,936.3	0.4	1.4	1	1	1
01/29/2015 07:00	-0.2	12.9	2,016.8	0.1	1.4	1	1	1
01/29/2015 08:00	0.2	13.2	1,966.3	0.4	1.4	1	1	1
01/29/2015 09:00	0.2	13.1	1,956.0	0.4	1.4	1	1	1
01/29/2015 10:00	0.2	13.4	1,868.3	0.4	1.3	1	1	1
01/29/2015 11:00	0.5	13.5	1,853.5	0.5	1.3	1	1	1
01/29/2015 12:00	0.5	13.5	1,858.4	0.5	1.3	1	1	1
01/29/2015 13:00	0.5	13.4	1,855.8	0.5	1.3	1	1	1
01/29/2015 14:00	0.5	13.4	1,867.5	0.5	1.3	1	1	1
01/29/2015 15:00	-0.4	12.5	2,027.1	-0.1	1.4	1	1	1
01/29/2015 16:00	0.1	13.1	1,915.4	0.2	1.3	1	1	1
01/29/2015 17:00	0.2	13.3	1,896.1	0.4	1.3	1	1	1
01/29/2015 18:00	-0.2	12.8	2,006.5	0.1	1.4	1	1	1
01/29/2015 19:00	-0.2	12.7	2,025.2	0.1	1.4	1	1	1
01/29/2015 20:00	-0.2	12.7	2,044.2	0.1	1.4	1	1	1
01/29/2015 21:00	0.1	13.0	1,978.6	0.2	1.4	1	1	1
01/29/2015 22:00	0.2	13.3	1,907.6	0.4	1.3	1	1	1
01/29/2015 23:00	0.4	13.5	1,858.7	0.4	1.3	1	1	1
Average/Sum#:	0.2	13.2	1,914.3	0.3	1.3	24 #	24 #	24 #
Minimum:	-0.4	12.5	1,844.4	-0.1	1.3	1	1	1
Maximum:	0.5	13.5	2,044.2	0.5	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/30/2015 00:00	0.4	13.5	1,859.5	0.4	1.3	1	1	1
01/30/2015 01:00	0.4	13.5	1,860.3	0.4	1.3	1	1	1
01/30/2015 02:00	0.4	13.4	1,856.6	0.4	1.3	1	1	1
01/30/2015 03:00	0.4	13.4	1,854.7	0.4	1.3	1	1	1
01/30/2015 04:00	0.4	13.5	1,861.1	0.4	1.3	1	1	1
01/30/2015 05:00	0.4	13.5	1,865.0	0.4	1.3	1	1	1
01/30/2015 06:00	0.4	13.4	1,902.1	0.4	1.3	1	1	1
01/30/2015 07:00	-0.1	13.0	1,977.9	0.1	1.4	1	1	1
01/30/2015 08:00	0.1	13.0	1,968.4	0.2	1.4	1	1	1
01/30/2015 09:00	0.2	13.2	1,924.3	0.4	1.3	1	1	1
01/30/2015 10:00	0.4	13.3	1,890.8	0.4	1.3	1	1	1
01/30/2015 11:00	0.4	13.4	1,860.8	0.4	1.3	1	1	1
01/30/2015 12:00	0.7	13.8	1,629.3	0.7	1.1	1	1	1
01/30/2015 13:00	0.1	13.1	1,902.5	0.2	1.3	1	1	1
01/30/2015 14:00	-0.1	13.1	1,910.9	0.1	1.3	1	1	1
01/30/2015 15:00	0.1	13.2	1,902.4	0.2	1.3	1	1	1
01/30/2015 16:00	-0.2	12.9	1,974.9	0.1	1.4	1	1	1
01/30/2015 17:00	0.2	13.3	1,882.5	0.4	1.3	1	1	1
01/30/2015 18:00	0.2	13.4	1,870.8	0.4	1.3	1	1	1
01/30/2015 19:00	0.2	13.4	1,862.9	0.4	1.3	1	1	1
01/30/2015 20:00	0.2	13.4	1,865.4	0.4	1.3	1	1	1
01/30/2015 21:00	0.2	13.5	1,865.4	0.4	1.3	1	1	1
01/30/2015 22:00	0.4	13.6	1,696.3	0.4	1.2	1	1	1
01/30/2015 23:00	0.6	14.0	1,273.1	0.6	0.9	1	1	0
Average/Sum#:	0.3	13.4	1,846.6	0.4	1.3	24 #	24 #	23 #
Minimum:	-0.2	12.9	1,273.1	0.1	0.9	1	1	0
Maximum:	0.7	14.0	1,977.9	0.7	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/31/2015 00:00	0.0	15.9	546.3	0.0	0.4	1	0	0
01/31/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/31/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/31/2015 03:00	0.0	16.9	574.2	0.0	0.4	1	0	0
01/31/2015 04:00	0.0	14.7	1,067.9	0.0	0.7	1	0	0
01/31/2015 05:00	0.4	13.6	1,780.3	0.4	1.2	1	1	1
01/31/2015 06:00	0.2	13.5	1,873.1	0.4	1.3	1	1	1
01/31/2015 07:00	0.2	13.5	1,872.8	0.4	1.3	1	1	1
01/31/2015 08:00	0.2	13.6	1,872.0	0.4	1.3	1	1	1
01/31/2015 09:00	0.2	13.5	1,871.6	0.4	1.3	1	1	1
01/31/2015 10:00	0.2	13.5	1,869.9	0.4	1.3	1	1	1
01/31/2015 11:00	0.7	14.0	1,366.3	0.7	1.0	1	1	1
01/31/2015 12:00	0.6	14.0	1,299.3	0.6	0.9	1	1	0
01/31/2015 13:00	0.6	14.0	1,328.4	0.6	0.9	1	1	0
01/31/2015 14:00	0.6	14.0	1,522.4	0.6	1.1	1	1	0
01/31/2015 15:00	0.5	13.7	1,702.6	0.5	1.2	1	1	1
01/31/2015 16:00	0.5	13.6	1,731.2	0.5	1.2	1	1	1
01/31/2015 17:00	0.7	13.8	1,594.1	0.7	1.1	1	1	1
01/31/2015 18:00	-0.4	12.7	2,018.3	-0.1	1.4	1	1	1
01/31/2015 19:00	-0.2	12.6	2,034.1	0.1	1.4	1	1	1
01/31/2015 20:00	-0.2	12.6	2,035.0	0.1	1.4	1	1	1
01/31/2015 21:00	-0.2	12.6	2,044.7	0.1	1.4	1	1	1
01/31/2015 22:00	-0.2	12.7	2,038.4	0.1	1.4	1	1	1
01/31/2015 23:00	0.1	13.1	1,945.8	0.2	1.4	1	1	1
Average/Sum#:	0.2	13.7	1,635.9	0.3	1.1	22 #	19 #	16 #
Minimum:	-0.4	12.6	546.3	-0.1	0.4	0	0	0
Maximum:	0.7	16.9	2,044.7	0.7	1.4	1	1	1
%SI	8.3	8.3	8.3	8.3	8.3	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/01/2015 00:00	-0.2	12.9	1,991.9	0.1	1.4	1	1	1
02/01/2015 01:00	0.7	13.8	1,620.8	0.7	1.1	1	1	1
02/01/2015 02:00	0.0	15.9	592.1	0.0	0.4	1	0	0
02/01/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2015 10:00	0.0	17.5	477.6	0.0	0.3	1	0	0
02/01/2015 11:00	0.0	15.3	840.0	0.0	0.6	1	0	0
02/01/2015 12:00	0.6	13.9	1,385.6	0.6	1.0	1	1	0
02/01/2015 13:00	0.6	14.0	1,390.7	0.6	1.0	1	1	0
02/01/2015 14:00	0.6	13.9	1,728.2	0.6	1.2	1	1	0
02/01/2015 15:00	0.6	14.0	1,506.9	0.6	1.1	1	1	0
02/01/2015 16:00	0.4	13.6	1,787.5	0.4	1.3	1	1	1
02/01/2015 17:00	0.1	13.3	1,909.9	0.2	1.3	1	1	1
02/01/2015 18:00	-0.2	12.9	1,984.3	0.1	1.4	1	1	1
02/01/2015 19:00	-0.4	12.8	2,010.5	-0.1	1.4	1	1	1
02/01/2015 20:00	-0.4	12.7	2,016.9	-0.1	1.4	1	1	1
02/01/2015 21:00	-0.2	12.8	1,998.4	0.1	1.4	1	1	1
02/01/2015 22:00	0.2	13.2	1,914.4	0.4	1.3	1	1	1
02/01/2015 23:00	0.4	13.4	1,831.9	0.4	1.3	1	1	1
Average/Sum#:	0.2	13.9	1,587.5	0.3	1.1	17 #	14 #	10 #
Minimum:	-0.4	12.7	477.6	-0.1	0.3	0	0	0
Maximum:	0.7	17.5	2,016.9	0.7	1.4	1	1	1
%SI	29.2	29.2	29.2	29.2	29.2	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/02/2015 00:00	0.2	13.4	1,848.1	0.4	1.3	1	1	1
02/02/2015 01:00	-0.2	12.9	1,987.1	0.1	1.4	1	1	1
02/02/2015 02:00	0.1	13.1	1,936.2	0.2	1.4	1	1	1
02/02/2015 03:00	0.2	13.4	1,851.9	0.4	1.3	1	1	1
02/02/2015 04:00	0.2	13.4	1,841.2	0.4	1.3	1	1	1
02/02/2015 05:00	0.2	13.4	1,865.0	0.4	1.3	1	1	1
02/02/2015 06:00	-0.1	13.0	1,963.0	0.1	1.4	1	1	1
02/02/2015 07:00	-0.2	12.9	1,967.8	0.1	1.4	1	1	1
02/02/2015 08:00	0.2	13.4	1,844.1	0.4	1.3	1	1	1
02/02/2015 09:00	0.2	13.4	1,837.4	0.4	1.3	1	1	1
02/02/2015 10:00	0.2	13.4	1,841.9	0.4	1.3	1	1	1
02/02/2015 11:00	0.2	13.4	1,860.6	0.4	1.3	1	1	1
02/02/2015 12:00	0.2	13.2	1,906.3	0.4	1.3	1	1	1
02/02/2015 13:00	0.2	13.3	1,883.5	0.4	1.3	1	1	1
02/02/2015 14:00	0.2	13.4	1,858.9	0.4	1.3	1	1	1
02/02/2015 15:00	0.4	13.4	1,857.8	0.4	1.3	1	1	1
02/02/2015 16:00	0.1	13.2	1,913.3	0.2	1.3	1	1	1
02/02/2015 17:00	0.1	13.1	1,939.2	0.2	1.4	1	1	1
02/02/2015 18:00	-0.2	12.8	1,996.8	0.1	1.4	1	1	1
02/02/2015 19:00	-0.1	12.8	1,991.8	0.1	1.4	1	1	1
02/02/2015 20:00	-0.2	12.8	1,998.1	0.1	1.4	1	1	1
02/02/2015 21:00	0.1	13.0	1,954.2	0.2	1.4	1	1	1
02/02/2015 22:00	0.2	13.2	1,902.4	0.4	1.3	1	1	1
02/02/2015 23:00	0.4	13.4	1,822.9	0.4	1.3	1	1	1
Average/Sum#:	0.1	13.2	1,902.9	0.3	1.3	24 #	24 #	24 #
Minimum:	-0.2	12.8	1,822.9	0.1	1.3	1	1	1
Maximum:	0.4	13.4	1,998.1	0.4	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/03/2015 00:00	0.6	13.9	1,328.5	0.6	0.9	1	1	0
02/03/2015 01:00	0.6	13.9	1,288.5	0.6	0.9	1	1	0
02/03/2015 02:00	0.6	13.9	1,290.1	0.6	0.9	1	1	0
02/03/2015 03:00	0.6	13.9	1,368.4	0.6	1.0	1	1	0
02/03/2015 04:00	0.5	13.7	1,701.6	0.5	1.2	1	1	1
02/03/2015 05:00	0.2	13.4	1,831.8	0.4	1.3	1	1	1
02/03/2015 06:00	0.2	13.3	1,862.4	0.4	1.3	1	1	1
02/03/2015 07:00	0.2	13.4	1,830.3	0.4	1.3	1	1	1
02/03/2015 08:00	0.2	13.4	1,834.1	0.4	1.3	1	1	1
02/03/2015 09:00	0.2	13.4	1,838.5	0.4	1.3	1	1	1
02/03/2015 10:00	0.4	13.6	1,676.2	0.4	1.2	1	1	1
02/03/2015 11:00	0.6	13.9	1,260.8	0.6	0.9	1	1	0
02/03/2015 12:00	0.6	13.9	1,298.9	0.6	0.9	1	1	0
02/03/2015 13:00	0.6	13.9	1,358.6	0.6	1.0	1	1	0
02/03/2015 14:00	0.6	13.8	1,705.7	0.6	1.2	1	1	0
02/03/2015 15:00	0.6	13.9	1,582.4	0.6	1.1	1	1	0
02/03/2015 16:00	0.5	13.6	1,649.0	0.5	1.2	1	1	1
02/03/2015 17:00	-0.1	13.2	1,915.3	0.1	1.3	1	1	1
02/03/2015 18:00	-0.5	12.6	2,039.5	-0.2	1.4	1	1	1
02/03/2015 19:00	-0.2	12.8	2,000.2	0.1	1.4	1	1	1
02/03/2015 20:00	-0.2	12.9	1,978.9	0.1	1.4	1	1	1
02/03/2015 21:00	0.1	13.1	1,923.7	0.2	1.3	1	1	1
02/03/2015 22:00	0.1	13.2	1,808.6	0.2	1.3	1	1	1
02/03/2015 23:00	0.6	13.9	1,316.8	0.6	0.9	1	1	0
Average/Sum#:	0.3	13.5	1,653.7	0.4	1.2	24 #	24 #	14 #
Minimum:	-0.5	12.6	1,260.8	-0.2	0.9	1	1	0
Maximum:	0.6	13.9	2,039.5	0.6	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/04/2015 00:00	0.6	13.8	1,689.4	0.6	1.2	1	1	0
02/04/2015 01:00	0.6	13.9	1,491.3	0.6	1.0	1	1	0
02/04/2015 02:00	0.6	13.9	1,285.8	0.6	0.9	1	1	0
02/04/2015 03:00	0.6	13.9	1,288.3	0.6	0.9	1	1	0
02/04/2015 04:00	0.6	13.9	1,386.9	0.6	1.0	1	1	0
02/04/2015 05:00	0.4	13.7	1,606.1	0.4	1.1	1	1	1
02/04/2015 06:00	0.1	13.3	1,894.2	0.2	1.3	1	1	1
02/04/2015 07:00	0.1	13.3	1,876.9	0.2	1.3	1	1	1
02/04/2015 08:00	0.6	13.9	1,323.4	0.6	0.9	1	1	0
02/04/2015 09:00	0.6	13.9	1,290.3	0.6	0.9	1	1	0
02/04/2015 10:00	0.6	13.9	1,292.0	0.6	0.9	1	1	0
02/04/2015 11:00	0.6	13.9	1,292.0	0.6	0.9	1	1	0
02/04/2015 12:00	0.6	13.9	1,291.5	0.6	0.9	1	1	0
02/04/2015 13:00	0.6	13.9	1,292.0	0.6	0.9	1	1	0
02/04/2015 14:00	0.6	13.9	1,292.7	0.6	0.9	1	1	0
02/04/2015 15:00	0.7	13.9	1,351.9	0.7	0.9	1	1	1
02/04/2015 16:00	-0.1	13.3	1,856.6	0.1	1.3	1	1	1
02/04/2015 17:00	-0.2	13.1	1,924.6	-0.1	1.3	1	1	1
02/04/2015 18:00	-0.5	12.7	2,013.7	-0.2	1.4	1	1	1
02/04/2015 19:00	-0.5	12.7	1,993.9	-0.2	1.4	1	1	1
02/04/2015 20:00	-0.4	12.9	1,971.6	-0.1	1.4	1	1	1
02/04/2015 21:00	-0.4	12.8	1,992.6	-0.1	1.4	1	1	1
02/04/2015 22:00	-0.2	12.9	1,960.3	0.1	1.4	1	1	1
02/04/2015 23:00	0.5	13.6	1,554.0	0.5	1.1	1	1	1
Average/Sum#:	0.3	13.5	1,592.2	0.4	1.1	24 #	24 #	12 #
Minimum:	-0.5	12.7	1,285.8	-0.2	0.9	1	1	0
Maximum:	0.7	13.9	2,013.7	0.7	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/05/2015 00:00	0.6	13.9	1,285.5	0.6	0.9	1	1	0
02/05/2015 01:00	0.6	13.9	1,287.4	0.6	0.9	1	1	0
02/05/2015 02:00	0.6	13.9	1,289.2	0.6	0.9	1	1	0
02/05/2015 03:00	0.6	13.9	1,289.4	0.6	0.9	1	1	0
02/05/2015 04:00	0.6	13.9	1,418.9	0.6	1.0	1	1	0
02/05/2015 05:00	0.4	13.7	1,590.0	0.4	1.1	1	1	1
02/05/2015 06:00	-0.1	13.3	1,886.6	0.1	1.3	1	1	1
02/05/2015 07:00	-0.1	13.1	1,922.0	0.1	1.3	1	1	1
02/05/2015 08:00	0.7	13.8	1,427.9	0.7	1.0	1	1	1
02/05/2015 09:00	0.6	13.9	1,284.9	0.6	0.9	1	1	0
02/05/2015 10:00	0.6	13.9	1,297.7	0.6	0.9	1	1	0
02/05/2015 11:00	0.6	13.9	1,321.2	0.6	0.9	1	1	0
02/05/2015 12:00	0.6	13.9	1,350.2	0.6	0.9	1	1	0
02/05/2015 13:00	0.6	13.9	1,600.8	0.6	1.1	1	1	0
02/05/2015 14:00	0.6	13.9	1,654.4	0.6	1.2	1	1	0
02/05/2015 15:00	0.6	13.9	1,613.1	0.6	1.1	1	1	0
02/05/2015 16:00	0.2	13.4	1,836.8	0.4	1.3	1	1	1
02/05/2015 17:00	0.2	13.3	1,861.2	0.4	1.3	1	1	1
02/05/2015 18:00	-0.4	12.8	1,967.4	-0.1	1.4	1	1	1
02/05/2015 19:00	-0.2	13.0	1,946.1	0.1	1.4	1	1	1
02/05/2015 20:00	-0.4	12.9	1,962.9	-0.1	1.4	1	1	1
02/05/2015 21:00	-0.2	13.0	1,932.1	0.1	1.4	1	1	1
02/05/2015 22:00	0.6	13.9	1,456.7	0.6	1.0	1	1	0
02/05/2015 23:00	0.6	13.9	1,282.9	0.6	0.9	1	1	0
Average/Sum#:	0.4	13.6	1,573.6	0.4	1.1	24 #	24 #	10 #
Minimum:	-0.4	12.8	1,282.9	-0.1	0.9	1	1	0
Maximum:	0.7	13.9	1,967.4	0.7	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/06/2015 00:00	0.6	13.9	1,296.7	0.6	0.9	1	1	0
02/06/2015 01:00	0.6	13.9	1,288.4	0.6	0.9	1	1	0
02/06/2015 02:00	0.6	13.9	1,281.5	0.6	0.9	1	1	0
02/06/2015 03:00	0.6	13.9	1,286.3	0.6	0.9	1	1	0
02/06/2015 04:00	0.6	14.0	1,329.8	0.6	0.9	1	1	0
02/06/2015 05:00	0.2	13.4	1,772.2	0.4	1.2	1	1	1
02/06/2015 06:00	-0.2	13.1	1,912.7	-0.1	1.3	1	1	1
02/06/2015 07:00	-0.2	13.0	1,884.8	0.1	1.3	1	1	1
02/06/2015 08:00	0.4	13.4	1,837.2	0.4	1.3	1	1	1
02/06/2015 09:00	0.7	13.6	1,651.1	0.7	1.2	1	1	1
02/06/2015 10:00	0.4	13.4	1,826.6	0.4	1.3	1	1	1
02/06/2015 11:00	0.2	13.4	1,836.7	0.4	1.3	1	1	1
02/06/2015 12:00	0.7	13.8	1,610.0	0.7	1.1	1	1	1
02/06/2015 13:00	0.2	13.4	1,845.4	0.4	1.3	1	1	1
02/06/2015 14:00	0.2	13.4	1,836.5	0.4	1.3	1	1	1
02/06/2015 15:00	0.2	13.4	1,838.6	0.4	1.3	1	1	1
02/06/2015 16:00	0.2	13.3	1,863.5	0.4	1.3	1	1	1
02/06/2015 17:00	-0.4	12.7	1,977.9	-0.1	1.4	1	1	1
02/06/2015 18:00	-0.4	12.4	2,021.5	-0.1	1.4	1	1	1
02/06/2015 19:00	-0.4	12.6	1,979.7	-0.1	1.4	1	1	1
02/06/2015 20:00	-0.4	12.5	2,004.0	-0.1	1.4	1	1	1
02/06/2015 21:00	0.1	13.1	1,882.7	0.2	1.3	1	1	1
02/06/2015 22:00	0.6	14.0	1,372.7	0.6	1.0	1	1	0
02/06/2015 23:00	0.6	13.9	1,577.9	0.6	1.1	1	1	0
Average/Sum#:	0.2	13.4	1,708.9	0.4	1.2	24 #	24 #	17 #
Minimum:	-0.4	12.4	1,281.5	-0.1	0.9	1	1	0
Maximum:	0.7	14.0	2,021.5	0.7	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/07/2015 00:00	0.6	14.0	1,308.7	0.6	0.9	1	1	0
02/07/2015 01:00	0.6	13.9	1,443.0	0.6	1.0	1	1	0
02/07/2015 02:00	0.6	14.0	1,394.9	0.6	1.0	1	1	0
02/07/2015 03:00	0.6	14.0	1,338.6	0.6	0.9	1	1	0
02/07/2015 04:00	0.6	14.0	1,337.7	0.6	0.9	1	1	0
02/07/2015 05:00	0.6	14.0	1,326.8	0.6	0.9	1	1	0
02/07/2015 06:00	0.6	14.0	1,329.5	0.6	0.9	1	1	0
02/07/2015 07:00	0.6	14.0	1,311.8	0.6	0.9	1	1	0
02/07/2015 08:00	0.6	13.9	1,285.2	0.6	0.9	1	1	0
02/07/2015 09:00	0.6	13.9	1,303.4	0.6	0.9	1	1	0
02/07/2015 10:00	0.6	13.9	1,349.9	0.6	0.9	1	1	0
02/07/2015 11:00	0.6	13.9	1,330.3	0.6	0.9	1	1	0
02/07/2015 12:00	0.6	13.9	1,293.3	0.6	0.9	1	1	0
02/07/2015 13:00	0.6	14.0	1,299.3	0.6	0.9	1	1	0
02/07/2015 14:00	0.6	14.0	1,341.1	0.6	0.9	1	1	0
02/07/2015 15:00	0.6	14.0	1,318.4	0.6	0.9	1	1	0
02/07/2015 16:00	0.4	13.6	1,648.4	0.4	1.2	1	1	1
02/07/2015 17:00	0.1	13.2	1,874.7	0.2	1.3	1	1	1
02/07/2015 18:00	-0.5	12.5	2,009.9	-0.2	1.4	1	1	1
02/07/2015 19:00	0.1	12.9	1,933.7	0.2	1.4	1	1	1
02/07/2015 20:00	-0.4	12.6	2,004.3	-0.1	1.4	1	1	1
02/07/2015 21:00	0.5	13.5	1,719.0	0.5	1.2	1	1	1
02/07/2015 22:00	0.6	13.9	1,382.0	0.6	1.0	1	1	0
02/07/2015 23:00	0.6	13.9	1,285.3	0.6	0.9	1	1	0
Average/Sum#:	0.5	13.7	1,465.4	0.5	1.0	24 #	24 #	6 #
Minimum:	-0.5	12.5	1,285.2	-0.2	0.9	1	1	0
Maximum:	0.6	14.0	2,009.9	0.6	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/08/2015 00:00	0.6	13.9	1,308.2	0.6	0.9	1	1	0
02/08/2015 01:00	0.6	13.9	1,341.7	0.6	0.9	1	1	0
02/08/2015 02:00	0.6	13.9	1,337.2	0.6	0.9	1	1	0
02/08/2015 03:00	0.6	13.9	1,290.1	0.6	0.9	1	1	0
02/08/2015 04:00	0.6	13.9	1,289.0	0.6	0.9	1	1	0
02/08/2015 05:00	0.6	13.9	1,285.2	0.6	0.9	1	1	0
02/08/2015 06:00	0.6	13.9	1,326.9	0.6	0.9	1	1	0
02/08/2015 07:00	0.6	13.9	1,314.1	0.6	0.9	1	1	0
02/08/2015 08:00	0.6	13.9	1,282.8	0.6	0.9	1	1	0
02/08/2015 09:00	0.6	13.9	1,284.3	0.6	0.9	1	1	0
02/08/2015 10:00	0.6	13.9	1,283.5	0.6	0.9	1	1	0
02/08/2015 11:00	0.6	13.9	1,286.8	0.6	0.9	1	1	0
02/08/2015 12:00	0.6	13.9	1,313.0	0.6	0.9	1	1	0
02/08/2015 13:00	0.6	13.9	1,322.2	0.6	0.9	1	1	0
02/08/2015 14:00	0.6	14.0	1,296.3	0.6	0.9	1	1	0
02/08/2015 15:00	0.6	14.0	1,297.8	0.6	0.9	1	1	0
02/08/2015 16:00	0.1	13.3	1,823.8	0.2	1.3	1	1	1
02/08/2015 17:00	-0.1	13.1	1,907.1	0.1	1.3	1	1	1
02/08/2015 18:00	-0.5	12.5	2,022.9	-0.2	1.4	1	1	1
02/08/2015 19:00	-0.2	12.7	1,980.0	0.1	1.4	1	1	1
02/08/2015 20:00	-0.4	12.6	2,004.3	-0.1	1.4	1	1	1
02/08/2015 21:00	0.1	13.1	1,763.9	0.2	1.2	1	1	1
02/08/2015 22:00	0.6	14.0	1,332.1	0.6	0.9	1	1	0
02/08/2015 23:00	0.6	13.9	1,521.3	0.6	1.1	1	1	0
Average/Sum#:	0.4	13.7	1,467.3	0.5	1.0	24 #	24 #	6 #
Minimum:	-0.5	12.5	1,282.8	-0.2	0.9	1	1	0
Maximum:	0.6	14.0	2,022.9	0.6	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/09/2015 00:00	0.6	14.0	1,306.9	0.6	0.9	1	1	0
02/09/2015 01:00	0.6	14.0	1,315.0	0.6	0.9	1	1	0
02/09/2015 02:00	0.6	14.0	1,285.2	0.6	0.9	1	1	0
02/09/2015 03:00	0.6	13.9	1,285.3	0.6	0.9	1	1	0
02/09/2015 04:00	0.6	13.9	1,285.8	0.6	0.9	1	1	0
02/09/2015 05:00	0.6	14.0	1,319.3	0.6	0.9	1	1	0
02/09/2015 06:00	0.4	13.5	1,722.3	0.4	1.2	1	1	1
02/09/2015 07:00	0.2	13.4	1,841.0	0.4	1.3	1	1	1
02/09/2015 08:00	0.4	13.5	1,839.6	0.4	1.3	1	1	1
02/09/2015 09:00	0.7	13.8	1,452.6	0.7	1.0	1	1	1
02/09/2015 10:00	0.6	13.9	1,289.8	0.6	0.9	1	1	0
02/09/2015 11:00	0.6	13.9	1,288.3	0.6	0.9	1	1	0
02/09/2015 12:00	0.6	13.9	1,286.1	0.6	0.9	1	1	0
02/09/2015 13:00	0.6	14.0	1,287.9	0.6	0.9	1	1	0
02/09/2015 14:00	0.6	14.0	1,290.0	0.6	0.9	1	1	0
02/09/2015 15:00	0.6	14.0	1,286.4	0.6	0.9	1	1	0
02/09/2015 16:00	0.6	14.0	1,287.4	0.6	0.9	1	1	0
02/09/2015 17:00	0.4	13.6	1,764.7	0.4	1.2	1	1	1
02/09/2015 18:00	0.1	13.5	1,847.8	0.2	1.3	1	1	1
02/09/2015 19:00	0.2	13.4	1,847.3	0.4	1.3	1	1	1
02/09/2015 20:00	0.2	13.4	1,869.2	0.4	1.3	1	1	1
02/09/2015 21:00	0.5	13.7	1,633.4	0.5	1.1	1	1	1
02/09/2015 22:00	0.6	13.9	1,326.8	0.6	0.9	1	1	0
02/09/2015 23:00	0.6	13.9	1,318.5	0.6	0.9	1	1	0
Average/Sum#:	0.5	13.8	1,469.9	0.5	1.0	24 #	24 #	9 #
Minimum:	0.1	13.4	1,285.2	0.2	0.9	1	1	0
Maximum:	0.7	14.0	1,869.2	0.7	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/10/2015 00:00	0.6	13.9	1,292.8	0.6	0.9	1	1	0
02/10/2015 01:00	0.6	13.9	1,296.3	0.6	0.9	1	1	0
02/10/2015 02:00	0.6	13.9	1,291.7	0.6	0.9	1	1	0
02/10/2015 03:00	0.6	13.9	1,293.6	0.6	0.9	1	1	0
02/10/2015 04:00	0.6	13.9	1,297.4	0.6	0.9	1	1	0
02/10/2015 05:00	0.6	13.9	1,330.0	0.6	0.9	1	1	0
02/10/2015 06:00	0.1	13.4	1,891.8	0.2	1.3	1	1	1
02/10/2015 07:00	-0.2	13.1	1,932.9	-0.1	1.4	1	1	1
02/10/2015 08:00	0.5	13.8	1,525.3	0.5	1.1	1	1	1
02/10/2015 09:00	0.6	14.0	1,294.9	0.6	0.9	1	1	0
02/10/2015 10:00	0.6	13.9	1,294.6	0.6	0.9	1	1	0
02/10/2015 11:00	0.6	13.9	1,296.9	0.6	0.9	1	1	0
02/10/2015 12:00	0.6	14.0	1,297.3	0.6	0.9	1	1	0
02/10/2015 13:00	0.6	14.0	1,294.1	0.6	0.9	1	1	0
02/10/2015 14:00	0.6	14.0	1,294.3	0.6	0.9	1	1	0
02/10/2015 15:00	0.6	14.0	1,294.9	0.6	0.9	1	1	0
02/10/2015 16:00	0.1	13.3	1,851.3	0.2	1.3	1	1	1
02/10/2015 17:00	-0.4	12.9	1,987.4	-0.1	1.4	1	1	1
02/10/2015 18:00	-0.4	12.6	2,027.7	-0.1	1.4	1	1	1
02/10/2015 19:00	-0.4	12.6	2,029.0	-0.1	1.4	1	1	1
02/10/2015 20:00	-0.4	12.7	2,015.0	-0.1	1.4	1	1	1
02/10/2015 21:00	-0.1	12.9	1,963.3	0.1	1.4	1	1	1
02/10/2015 22:00	-0.2	12.7	2,015.1	0.1	1.4	1	1	1
02/10/2015 23:00	-0.2	12.9	1,998.4	0.1	1.4	1	1	1
Average/Sum#:	0.3	13.5	1,587.8	0.4	1.1	24 #	24 #	11 #
Minimum:	-0.4	12.6	1,291.7	-0.1	0.9	1	1	0
Maximum:	0.6	14.0	2,029.0	0.6	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/11/2015 00:00	-0.2	12.9	2,002.2	0.1	1.4	1	1	1
02/11/2015 01:00	0.2	13.3	1,890.2	0.4	1.3	1	1	1
02/11/2015 02:00	0.4	13.4	1,837.4	0.4	1.3	1	1	1
02/11/2015 03:00	0.2	13.4	1,838.6	0.4	1.3	1	1	1
02/11/2015 04:00	0.2	13.4	1,840.4	0.4	1.3	1	1	1
02/11/2015 05:00	0.2	13.4	1,865.2	0.4	1.3	1	1	1
02/11/2015 06:00	0.1	13.2	1,910.6	0.2	1.3	1	1	1
02/11/2015 07:00	0.4	13.4	1,846.2	0.4	1.3	1	1	1
02/11/2015 08:00	0.4	13.4	1,834.3	0.4	1.3	1	1	1
02/11/2015 09:00	0.4	13.4	1,837.9	0.4	1.3	1	1	1
02/11/2015 10:00	0.5	13.7	1,588.8	0.5	1.1	1	1	1
02/11/2015 11:00	0.6	13.9	1,449.6	0.6	1.0	1	1	0
02/11/2015 12:00	0.6	13.9	1,495.6	0.6	1.0	1	1	0
02/11/2015 13:00	0.6	14.0	1,292.2	0.6	0.9	1	1	0
02/11/2015 14:00	0.6	14.0	1,294.4	0.6	0.9	1	1	0
02/11/2015 15:00	0.5	13.7	1,552.7	0.5	1.1	1	1	1
02/11/2015 16:00	0.1	13.3	1,886.1	0.2	1.3	1	1	1
02/11/2015 17:00	-0.1	13.1	1,933.6	0.1	1.4	1	1	1
02/11/2015 18:00	-0.5	12.7	2,024.5	-0.2	1.4	1	1	1
02/11/2015 19:00	-0.4	12.8	1,990.0	-0.1	1.4	1	1	1
02/11/2015 20:00	-0.4	12.8	1,997.0	-0.1	1.4	1	1	1
02/11/2015 21:00	-0.1	13.0	1,960.1	0.1	1.4	1	1	1
02/11/2015 22:00	-0.2	13.0	1,970.0	0.1	1.4	1	1	1
02/11/2015 23:00	0.2	13.4	1,858.5	0.4	1.3	1	1	1
Average/Sum#:	0.2	13.4	1,791.5	0.3	1.3	24 #	24 #	20 #
Minimum:	-0.5	12.7	1,292.2	-0.2	0.9	1	1	0
Maximum:	0.6	14.0	2,024.5	0.6	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/12/2015 00:00	0.7	13.8	1,413.0	0.7	1.0	1	1	1
02/12/2015 01:00	0.6	13.9	1,367.9	0.6	1.0	1	1	0
02/12/2015 02:00	0.6	13.9	1,301.9	0.6	0.9	1	1	0
02/12/2015 03:00	0.6	13.9	1,479.6	0.6	1.0	1	1	0
02/12/2015 04:00	0.4	13.7	1,596.7	0.4	1.1	1	1	1
02/12/2015 05:00	-0.1	13.1	1,928.2	0.1	1.3	1	1	1
02/12/2015 06:00	0.1	13.2	1,912.4	0.2	1.3	1	1	1
02/12/2015 07:00	-0.1	13.0	1,915.9	0.1	1.3	1	1	1
02/12/2015 08:00	0.5	13.7	1,559.6	0.5	1.1	1	1	1
02/12/2015 09:00	0.6	13.9	1,290.2	0.6	0.9	1	1	0
02/12/2015 10:00	0.6	13.9	1,290.3	0.6	0.9	1	1	0
02/12/2015 11:00	0.6	13.9	1,291.1	0.6	0.9	1	1	0
02/12/2015 12:00	0.6	13.9	1,294.8	0.6	0.9	1	1	0
02/12/2015 13:00	0.7	13.8	1,673.8	0.7	1.2	1	1	1
02/12/2015 14:00	-0.4	12.7	1,991.9	-0.1	1.4	1	1	1
02/12/2015 15:00	0.1	13.1	1,885.8	0.2	1.3	1	1	1
02/12/2015 16:00	-0.1	13.0	1,921.0	0.1	1.3	1	1	1
02/12/2015 17:00	-0.2	12.8	1,970.2	0.1	1.4	1	1	1
02/12/2015 18:00	-0.4	12.5	2,036.2	-0.1	1.4	1	1	1
02/12/2015 19:00	-0.4	12.5	2,047.8	-0.1	1.4	1	1	1
02/12/2015 20:00	-0.4	12.6	2,032.6	-0.1	1.4	1	1	1
02/12/2015 21:00	-0.1	13.0	1,960.1	0.1	1.4	1	1	1
02/12/2015 22:00	-0.2	12.8	1,996.9	0.1	1.4	1	1	1
02/12/2015 23:00	0.7	13.8	1,631.1	0.7	1.1	1	1	1
Average/Sum#:	0.2	13.4	1,699.5	0.3	1.2	24 #	24 #	17 #
Minimum:	-0.4	12.5	1,290.2	-0.1	0.9	1	1	0
Maximum:	0.7	13.9	2,047.8	0.7	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/13/2015 00:00	0.6	13.9	1,729.9	0.6	1.2	1	1	0
02/13/2015 01:00	0.6	13.9	1,483.7	0.6	1.0	1	1	0
02/13/2015 02:00	0.6	13.9	1,475.9	0.6	1.0	1	1	0
02/13/2015 03:00	0.6	13.9	1,747.9	0.6	1.2	1	1	0
02/13/2015 04:00	0.6	13.9	1,555.2	0.6	1.1	1	1	0
02/13/2015 05:00	0.5	13.8	1,575.5	0.5	1.1	1	1	1
02/13/2015 06:00	0.2	13.3	1,906.9	0.4	1.3	1	1	1
02/13/2015 07:00	0.1	13.3	1,879.7	0.2	1.3	1	1	1
02/13/2015 08:00	0.7	13.8	1,462.7	0.7	1.0	1	1	1
02/13/2015 09:00	0.6	13.9	1,294.8	0.6	0.9	1	1	0
02/13/2015 10:00	0.6	13.9	1,295.0	0.6	0.9	1	1	0
02/13/2015 11:00	0.6	13.9	1,301.9	0.6	0.9	1	1	0
02/13/2015 12:00	0.6	13.9	1,400.6	0.6	1.0	1	1	0
02/13/2015 13:00	0.7	13.8	1,653.1	0.7	1.2	1	1	1
02/13/2015 14:00	0.1	13.3	1,878.2	0.2	1.3	1	1	1
02/13/2015 15:00	0.1	13.4	1,851.4	0.2	1.3	1	1	1
02/13/2015 16:00	0.1	13.3	1,875.7	0.2	1.3	1	1	1
02/13/2015 17:00	-0.1	13.0	1,933.9	0.1	1.4	1	1	1
02/13/2015 18:00	-0.4	12.7	2,006.9	-0.1	1.4	1	1	1
02/13/2015 19:00	-0.4	12.5	2,042.2	-0.1	1.4	1	1	1
02/13/2015 20:00	-0.4	12.6	2,024.0	-0.1	1.4	1	1	1
02/13/2015 21:00	-0.2	12.8	1,999.2	0.1	1.4	1	1	1
02/13/2015 22:00	-0.4	12.7	2,018.2	-0.1	1.4	1	1	1
02/13/2015 23:00	0.2	13.2	1,902.4	0.4	1.3	1	1	1
Average/Sum#:	0.3	13.4	1,720.6	0.4	1.2	24 #	24 #	15 #
Minimum:	-0.4	12.5	1,294.8	-0.1	0.9	1	1	0
Maximum:	0.7	13.9	2,042.2	0.7	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/14/2015 00:00	-0.2	12.9	1,983.2	0.1	1.4	1	1	1
02/14/2015 01:00	-0.1	13.0	1,957.7	0.1	1.4	1	1	1
02/14/2015 02:00	-0.5	12.9	1,973.7	-0.2	1.4	1	1	1
02/14/2015 03:00	-0.2	12.9	1,973.8	0.1	1.4	1	1	1
02/14/2015 04:00	-0.1	13.0	1,963.6	0.1	1.4	1	1	1
02/14/2015 05:00	0.2	13.4	1,843.0	0.4	1.3	1	1	1
02/14/2015 06:00	0.7	13.8	1,493.9	0.7	1.0	1	1	1
02/14/2015 07:00	0.6	13.9	1,308.4	0.6	0.9	1	1	0
02/14/2015 08:00	0.6	13.9	1,297.8	0.6	0.9	1	1	0
02/14/2015 09:00	0.6	13.9	1,309.0	0.6	0.9	1	1	0
02/14/2015 10:00	0.6	13.9	1,302.9	0.6	0.9	1	1	0
02/14/2015 11:00	0.6	14.0	1,298.7	0.6	0.9	1	1	0
02/14/2015 12:00	0.6	14.0	1,299.1	0.6	0.9	1	1	0
02/14/2015 13:00	0.6	14.0	1,298.0	0.6	0.9	1	1	0
02/14/2015 14:00	0.6	14.0	1,295.9	0.6	0.9	1	1	0
02/14/2015 15:00	0.6	14.0	1,293.8	0.6	0.9	1	1	0
02/14/2015 16:00	0.2	13.5	1,559.5	0.4	1.1	1	1	1
02/14/2015 17:00	-0.1	13.1	1,892.2	0.1	1.3	1	1	1
02/14/2015 18:00	-0.1	13.1	1,893.2	0.1	1.3	1	1	1
02/14/2015 19:00	-0.5	12.5	2,038.9	-0.2	1.4	1	1	1
02/14/2015 20:00	-0.1	13.0	1,936.5	0.1	1.4	1	1	1
02/14/2015 21:00	-0.1	13.1	1,923.0	0.1	1.3	1	1	1
02/14/2015 22:00	-0.2	12.8	1,975.3	0.1	1.4	1	1	1
02/14/2015 23:00	0.7	13.9	1,427.9	0.7	1.0	1	1	1
Average/Sum#:	0.2	13.4	1,647.5	0.3	1.2	24 #	24 #	15 #
Minimum:	-0.5	12.5	1,293.8	-0.2	0.9	1	1	0
Maximum:	0.7	14.0	2,038.9	0.7	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/15/2015 00:00	0.6	14.0	1,391.6	0.6	1.0	1	1	0
02/15/2015 01:00	0.6	13.9	1,456.7	0.6	1.0	1	1	0
02/15/2015 02:00	0.0	16.4	392.0	0.0	0.3	1	0	0
02/15/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2015 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2015 16:00	0.0	18.1	386.6	0.0	0.3	1	0	0
02/15/2015 17:00	0.0	14.9	1,052.3	0.0	0.7	1	0	0
02/15/2015 18:00	0.6	14.0	1,444.1	0.6	1.0	1	1	0
02/15/2015 19:00	-0.1	13.0	1,933.7	0.1	1.4	1	1	1
02/15/2015 20:00	-0.2	12.7	1,987.8	0.1	1.4	1	1	1
02/15/2015 21:00	-0.1	12.9	1,972.7	0.1	1.4	1	1	1
02/15/2015 22:00	-0.1	12.9	1,971.8	0.1	1.4	1	1	1
02/15/2015 23:00	-0.1	12.9	1,971.0	0.1	1.4	1	1	1
Average/Sum#:	0.1	14.2	1,450.9	0.2	1.0	11 #	8 #	5 #
Minimum:	-0.2	12.7	386.6	0.0	0.3	0	0	0
Maximum:	0.6	18.1	1,987.8	0.6	1.4	1	1	1
%SI	54.2	54.2	54.2	54.2	54.2	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/16/2015 00:00	-0.1	12.9	1,981.1	0.1	1.4	1	1	1
02/16/2015 01:00	0.2	13.2	1,910.4	0.4	1.3	1	1	1
02/16/2015 02:00	0.4	13.4	1,849.6	0.4	1.3	1	1	1
02/16/2015 03:00	0.4	13.4	1,851.4	0.4	1.3	1	1	1
02/16/2015 04:00	0.4	13.4	1,852.5	0.4	1.3	1	1	1
02/16/2015 05:00	0.2	13.3	1,882.9	0.4	1.3	1	1	1
02/16/2015 06:00	0.2	13.3	1,901.1	0.4	1.3	1	1	1
02/16/2015 07:00	0.4	13.4	1,834.3	0.4	1.3	1	1	1
02/16/2015 08:00	0.4	13.5	1,836.6	0.4	1.3	1	1	1
02/16/2015 09:00	0.4	13.5	1,846.7	0.4	1.3	1	1	1
02/16/2015 10:00	0.4	13.5	1,858.7	0.4	1.3	1	1	1
02/16/2015 11:00	0.4	13.4	1,857.5	0.4	1.3	1	1	1
02/16/2015 12:00	0.4	13.4	1,854.0	0.4	1.3	1	1	1
02/16/2015 13:00	0.5	13.6	1,558.2	0.5	1.1	1	1	1
02/16/2015 14:00	0.6	14.0	1,285.9	0.6	0.9	1	1	0
02/16/2015 15:00	0.5	13.7	1,544.6	0.5	1.1	1	1	1
02/16/2015 16:00	0.1	13.1	1,892.1	0.2	1.3	1	1	1
02/16/2015 17:00	-0.1	12.9	1,943.1	0.1	1.4	1	1	1
02/16/2015 18:00	-0.2	12.5	2,031.3	0.1	1.4	1	1	1
02/16/2015 19:00	-0.2	12.6	2,021.1	0.1	1.4	1	1	1
02/16/2015 20:00	0.4	13.4	1,854.7	0.4	1.3	1	1	1
02/16/2015 21:00	0.2	13.3	1,884.0	0.4	1.3	1	1	1
02/16/2015 22:00	0.1	13.1	1,915.3	0.2	1.3	1	1	1
02/16/2015 23:00	0.4	13.5	1,854.1	0.4	1.3	1	1	1
Average/Sum#:	0.3	13.3	1,837.6	0.4	1.3	24 #	24 #	23 #
Minimum:	-0.2	12.5	1,285.9	0.1	0.9	1	1	0
Maximum:	0.6	14.0	2,031.3	0.6	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/17/2015 00:00	0.2	13.4	1,852.3	0.4	1.3	1	1	1
02/17/2015 01:00	0.2	13.4	1,850.3	0.4	1.3	1	1	1
02/17/2015 02:00	0.4	13.4	1,851.7	0.4	1.3	1	1	1
02/17/2015 03:00	0.2	13.5	1,856.3	0.4	1.3	1	1	1
02/17/2015 04:00	0.2	13.5	1,860.3	0.4	1.3	1	1	1
02/17/2015 05:00	0.2	13.4	1,855.6	0.4	1.3	1	1	1
02/17/2015 06:00	0.2	13.4	1,874.9	0.4	1.3	1	1	1
02/17/2015 07:00	-0.1	13.0	1,915.9	0.1	1.3	1	1	1
02/17/2015 08:00	0.2	13.4	1,842.0	0.4	1.3	1	1	1
02/17/2015 09:00	0.5	13.7	1,548.6	0.5	1.1	1	1	1
02/17/2015 10:00	0.6	13.9	1,410.7	0.6	1.0	1	1	0
02/17/2015 11:00	0.6	13.9	1,580.7	0.6	1.1	1	1	0
02/17/2015 12:00	0.6	13.9	1,557.7	0.6	1.1	1	1	0
02/17/2015 13:00	0.6	13.9	1,312.3	0.6	0.9	1	1	0
02/17/2015 14:00	0.6	13.9	1,288.7	0.6	0.9	1	1	0
02/17/2015 15:00	0.6	14.0	1,300.3	0.6	0.9	1	1	0
02/17/2015 16:00	0.5	13.6	1,605.7	0.5	1.1	1	1	1
02/17/2015 17:00	0.1	13.1	1,901.2	0.2	1.3	1	1	1
02/17/2015 18:00	-0.4	12.6	2,014.9	-0.1	1.4	1	1	1
02/17/2015 19:00	-0.4	12.6	2,010.2	-0.1	1.4	1	1	1
02/17/2015 20:00	-0.1	12.9	1,964.7	0.1	1.4	1	1	1
02/17/2015 21:00	0.2	13.2	1,898.9	0.4	1.3	1	1	1
02/17/2015 22:00	-0.1	13.1	1,830.3	0.1	1.3	1	1	1
02/17/2015 23:00	0.6	13.9	1,308.1	0.6	0.9	1	1	0
Average/Sum#:	0.3	13.4	1,720.5	0.4	1.2	24 #	24 #	17 #
Minimum:	-0.4	12.6	1,288.7	-0.1	0.9	1	1	0
Maximum:	0.6	14.0	2,014.9	0.6	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/18/2015 00:00	0.6	13.9	1,491.0	0.6	1.0	1	1	0
02/18/2015 01:00	0.6	13.9	1,518.4	0.6	1.1	1	1	0
02/18/2015 02:00	0.6	13.9	1,338.1	0.6	0.9	1	1	0
02/18/2015 03:00	0.5	13.9	1,307.4	0.5	0.9	1	1	0
02/18/2015 04:00	0.5	13.7	1,694.9	0.5	1.2	1	1	1
02/18/2015 05:00	0.2	13.3	1,882.0	0.4	1.3	1	1	1
02/18/2015 06:00	0.2	13.3	1,874.6	0.4	1.3	1	1	1
02/18/2015 07:00	0.1	13.1	1,947.5	0.2	1.4	1	1	1
02/18/2015 08:00	-0.1	13.1	1,975.2	0.1	1.4	1	1	1
02/18/2015 09:00	-0.1	13.0	1,989.3	0.1	1.4	1	1	1
02/18/2015 10:00	-0.1	13.0	1,964.5	0.1	1.4	1	1	1
02/18/2015 11:00	0.2	13.4	1,844.4	0.4	1.3	1	1	1
02/18/2015 12:00	0.2	13.4	1,850.8	0.4	1.3	1	1	1
02/18/2015 13:00	0.2	13.4	1,852.8	0.4	1.3	1	1	1
02/18/2015 14:00	0.7	13.7	1,565.6	0.7	1.1	1	1	1
02/18/2015 15:00	0.6	13.9	1,658.5	0.6	1.2	1	1	0
02/18/2015 16:00	0.2	13.3	1,846.1	0.4	1.3	1	1	1
02/18/2015 17:00	-0.2	12.8	1,996.7	0.1	1.4	1	1	1
02/18/2015 18:00	-0.4	12.6	2,026.5	-0.1	1.4	1	1	1
02/18/2015 19:00	-0.2	12.8	1,993.3	0.1	1.4	1	1	1
02/18/2015 20:00	-0.2	12.8	1,986.2	0.1	1.4	1	1	1
02/18/2015 21:00	-0.1	12.9	1,974.4	0.1	1.4	1	1	1
02/18/2015 22:00	0.1	13.1	1,938.6	0.2	1.4	1	1	1
02/18/2015 23:00	0.2	13.3	1,865.1	0.4	1.3	1	1	1
Average/Sum#:	0.2	13.3	1,807.6	0.3	1.3	24 #	24 #	19 #
Minimum:	-0.4	12.6	1,307.4	-0.1	0.9	1	1	0
Maximum:	0.7	13.9	2,026.5	0.7	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/19/2015 00:00	-0.1	13.0	1,961.5	0.1	1.4	1	1	1
02/19/2015 01:00	0.2	13.4	1,835.8	0.4	1.3	1	1	1
02/19/2015 02:00	0.5	13.8	1,428.3	0.5	1.0	1	1	1
02/19/2015 03:00	0.6	13.9	1,311.3	0.6	0.9	1	1	0
02/19/2015 04:00	0.5	13.8	1,435.3	0.5	1.0	1	1	1
02/19/2015 05:00	-0.1	13.2	1,923.7	0.1	1.3	1	1	1
02/19/2015 06:00	-0.1	13.1	1,940.7	0.1	1.4	1	1	1
02/19/2015 07:00	-0.2	12.8	1,979.3	0.1	1.4	1	1	1
02/19/2015 08:00	-0.1	12.9	1,985.2	0.1	1.4	1	1	1
02/19/2015 09:00	0.1	13.1	1,945.1	0.2	1.4	1	1	1
02/19/2015 10:00	-0.4	12.7	2,021.8	-0.1	1.4	1	1	1
02/19/2015 11:00	-0.1	12.9	1,988.6	0.1	1.4	1	1	1
02/19/2015 12:00	0.1	13.0	1,942.3	0.2	1.4	1	1	1
02/19/2015 13:00	-0.1	13.0	1,950.5	0.1	1.4	1	1	1
02/19/2015 14:00	0.2	13.4	1,852.5	0.4	1.3	1	1	1
02/19/2015 15:00	0.2	13.4	1,855.5	0.4	1.3	1	1	1
02/19/2015 16:00	0.2	13.3	1,870.0	0.4	1.3	1	1	1
02/19/2015 17:00	0.4	13.4	1,851.9	0.4	1.3	1	1	1
02/19/2015 18:00	-0.1	13.0	1,939.2	0.1	1.4	1	1	1
02/19/2015 19:00	0.2	13.3	1,850.5	0.4	1.3	1	1	1
02/19/2015 20:00	0.2	13.4	1,843.1	0.4	1.3	1	1	1
02/19/2015 21:00	0.2	13.4	1,850.6	0.4	1.3	1	1	1
02/19/2015 22:00	0.2	13.3	1,881.9	0.4	1.3	1	1	1
02/19/2015 23:00	0.1	13.1	1,816.6	0.2	1.3	1	1	1
Average/Sum#:	0.1	13.2	1,844.2	0.3	1.3	24 #	24 #	23 #
Minimum:	-0.4	12.7	1,311.3	-0.1	0.9	1	1	0
Maximum:	0.6	13.9	2,021.8	0.6	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/20/2015 00:00	0.6	13.9	1,345.3	0.6	0.9	1	1	0
02/20/2015 01:00	0.0	15.9	571.2	0.0	0.4	1	0	0
02/20/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.3	14.9	958.3	0.3	0.7	2 #	1 #	0 #
Minimum:	0.0	13.9	571.2	0.0	0.4	0	0	0
Maximum:	0.6	15.9	1,345.3	0.6	0.9	1	1	0
%SI	91.7	91.7	91.7	91.7	91.7	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/21/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 15:00	0.0	17.4	509.5	0.0	0.4	1	0	0
02/21/2015 16:00	0.0	14.8	1,042.1	0.0	0.7	1	0	0
02/21/2015 17:00	0.7	13.8	1,506.1	0.7	1.1	1	1	1
02/21/2015 18:00	-0.1	12.8	1,973.2	0.1	1.4	1	1	1
02/21/2015 19:00	-0.2	12.6	2,022.8	0.1	1.4	1	1	1
02/21/2015 20:00	-0.2	12.7	2,019.2	0.1	1.4	1	1	1
02/21/2015 21:00	0.1	12.9	1,984.1	0.2	1.4	1	1	1
02/21/2015 22:00	-0.2	12.8	2,031.9	0.1	1.4	1	1	1
02/21/2015 23:00	0.1	13.1	1,943.6	0.2	1.4	1	1	1
Average/Sum#:	0.0	13.7	1,670.3	0.2	1.2	9 #	7 #	7 #
Minimum:	-0.2	12.6	509.5	0.0	0.4	0	0	0
Maximum:	0.7	17.4	2,031.9	0.7	1.4	1	1	1
%SI	62.5	62.5	62.5	62.5	62.5	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/22/2015 00:00	0.6	14.0	1,401.2	0.6	1.0	1	1	0
02/22/2015 01:00	0.6	13.9	1,549.0	0.6	1.1	1	1	0
02/22/2015 02:00	0.6	14.0	1,293.0	0.6	0.9	1	1	0
02/22/2015 03:00	0.6	14.0	1,342.6	0.6	0.9	1	1	0
02/22/2015 04:00	0.6	14.0	1,584.9	0.6	1.1	1	1	0
02/22/2015 05:00	0.6	14.0	1,500.5	0.6	1.1	1	1	0
02/22/2015 06:00	0.0	16.5	403.5	0.0	0.3	1	0	0
02/22/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2015 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2015 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2015 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2015 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2015 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2015 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.5	14.3	1,296.4	0.5	0.9	7 #	6 #	0 #
Minimum:	0.0	13.9	403.5	0.0	0.3	0	0	0
Maximum:	0.6	16.5	1,584.9	0.6	1.1	1	1	0
%SI	70.8	70.8	70.8	70.8	70.8	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/23/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2015 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2015 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2015 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2015 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2015 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2015 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/24/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2015 03:00	0.0	17.8	457.8	0.0	0.3	1	0	0
02/24/2015 04:00	0.0	15.8	718.2	0.0	0.5	1	0	0
02/24/2015 05:00	0.0	13.7	1,613.7	0.0	1.1	1	0	1
02/24/2015 06:00	-0.1	12.9	2,017.2	0.1	1.4	1	1	1
02/24/2015 07:00	-0.1	13.0	2,012.0	0.1	1.4	1	1	1
02/24/2015 08:00	0.2	13.2	1,960.4	0.4	1.4	1	1	1
02/24/2015 09:00	0.7	13.7	1,558.6	0.7	1.1	1	1	1
02/24/2015 10:00	0.6	14.0	1,325.8	0.6	0.9	1	1	0
02/24/2015 11:00	0.6	14.0	1,293.5	0.6	0.9	1	1	0
02/24/2015 12:00	0.6	14.0	1,292.0	0.6	0.9	1	1	0
02/24/2015 13:00	0.6	14.0	1,289.1	0.6	0.9	1	1	0
02/24/2015 14:00	0.6	14.0	1,310.1	0.6	0.9	1	1	0
02/24/2015 15:00	0.6	14.0	1,364.1	0.6	1.0	1	1	0
02/24/2015 16:00	0.7	13.8	1,477.7	0.7	1.0	1	1	1
02/24/2015 17:00	-0.2	12.9	1,969.0	0.1	1.4	1	1	1
02/24/2015 18:00	-0.2	12.7	2,015.2	0.1	1.4	1	1	1
02/24/2015 19:00	-0.2	12.8	2,012.3	0.1	1.4	1	1	1
02/24/2015 20:00	-0.2	12.8	2,018.9	0.1	1.4	1	1	1
02/24/2015 21:00	-0.2	12.9	2,024.7	0.1	1.4	1	1	1
02/24/2015 22:00	0.2	13.3	1,820.3	0.4	1.3	1	1	1
02/24/2015 23:00	0.6	14.0	1,489.8	0.6	1.0	1	1	0
Average/Sum#:	0.2	13.8	1,573.4	0.3	1.1	21 #	18 #	12 #
Minimum:	-0.2	12.7	457.8	0.0	0.3	0	0	0
Maximum:	0.7	17.8	2,024.7	0.7	1.4	1	1	1
%SI	12.5	12.5	12.5	12.5	12.5	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/25/2015 00:00	0.6	13.9	1,301.2	0.6	0.9	1	1	0
02/25/2015 01:00	0.6	14.0	1,754.7	0.6	1.2	1	1	0
02/25/2015 02:00	0.6	13.9	1,735.6	0.6	1.2	1	1	0
02/25/2015 03:00	0.6	13.9	1,442.5	0.6	1.0	1	1	0
02/25/2015 04:00	0.6	13.9	1,287.6	0.6	0.9	1	1	0
02/25/2015 05:00	0.4	13.6	1,632.5	0.4	1.1	1	1	1
02/25/2015 06:00	-0.1	13.1	1,991.4	0.1	1.4	1	1	1
02/25/2015 07:00	-0.1	13.1	1,971.7	0.1	1.4	1	1	1
02/25/2015 08:00	0.5	13.6	1,734.4	0.5	1.2	1	1	1
02/25/2015 09:00	0.6	13.9	1,307.2	0.6	0.9	1	1	0
02/25/2015 10:00	0.6	14.0	1,291.5	0.6	0.9	1	1	0
02/25/2015 11:00	0.6	14.0	1,292.1	0.6	0.9	1	1	0
02/25/2015 12:00	0.6	14.0	1,293.3	0.6	0.9	1	1	0
02/25/2015 13:00	0.6	14.0	1,410.7	0.6	1.0	1	1	0
02/25/2015 14:00	0.6	14.0	1,299.6	0.6	0.9	1	1	0
02/25/2015 15:00	0.6	14.0	1,292.8	0.6	0.9	1	1	0
02/25/2015 16:00	0.7	13.8	1,466.8	0.7	1.0	1	1	1
02/25/2015 17:00	-0.2	12.9	1,956.1	0.1	1.4	1	1	1
02/25/2015 18:00	-0.2	12.8	1,980.6	0.1	1.4	1	1	1
02/25/2015 19:00	0.1	13.1	1,916.9	0.2	1.3	1	1	1
02/25/2015 20:00	0.1	13.2	1,925.6	0.2	1.3	1	1	1
02/25/2015 21:00	-0.1	13.0	1,975.8	0.1	1.4	1	1	1
02/25/2015 22:00	0.1	13.3	1,790.1	0.2	1.3	1	1	1
02/25/2015 23:00	0.6	14.0	1,440.6	0.6	1.0	1	1	0
Average/Sum#:	0.4	13.6	1,603.8	0.4	1.1	24 #	24 #	11 #
Minimum:	-0.2	12.8	1,287.6	0.1	0.9	1	1	0
Maximum:	0.7	14.0	1,991.4	0.7	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/26/2015 00:00	0.6	14.0	1,288.7	0.6	0.9	1	1	0
02/26/2015 01:00	0.6	14.0	1,303.7	0.6	0.9	1	1	0
02/26/2015 02:00	0.6	13.8	1,754.7	0.6	1.2	1	1	0
02/26/2015 03:00	0.6	13.8	1,816.7	0.6	1.3	1	1	0
02/26/2015 04:00	0.5	13.7	1,760.9	0.5	1.2	1	1	1
02/26/2015 05:00	0.1	13.2	1,945.5	0.2	1.4	1	1	1
02/26/2015 06:00	0.1	13.2	1,958.0	0.2	1.4	1	1	1
02/26/2015 07:00	-0.1	13.0	1,969.6	0.1	1.4	1	1	1
02/26/2015 08:00	0.5	13.5	1,626.7	0.5	1.1	1	1	1
02/26/2015 09:00	0.6	14.0	1,374.8	0.6	1.0	1	1	0
02/26/2015 10:00	0.6	14.0	1,677.5	0.6	1.2	1	1	0
02/26/2015 11:00	0.6	13.9	1,699.9	0.6	1.2	1	1	0
02/26/2015 12:00	0.6	14.1	1,314.0	0.6	0.9	1	1	0
02/26/2015 13:00	0.6	14.0	1,289.8	0.6	0.9	1	1	0
02/26/2015 14:00	0.6	14.0	1,290.9	0.6	0.9	1	1	0
02/26/2015 15:00	0.6	14.0	1,477.3	0.6	1.0	1	1	0
02/26/2015 16:00	-0.1	13.2	1,789.9	0.1	1.3	1	1	1
02/26/2015 17:00	-0.2	12.9	1,956.0	0.1	1.4	1	1	1
02/26/2015 18:00	-0.4	12.5	2,032.6	-0.1	1.4	1	1	1
02/26/2015 19:00	-0.2	12.5	2,029.8	0.1	1.4	1	1	1
02/26/2015 20:00	-0.2	12.7	1,997.6	0.1	1.4	1	1	1
02/26/2015 21:00	-0.2	12.8	1,981.9	0.1	1.4	1	1	1
02/26/2015 22:00	0.5	13.6	1,576.2	0.5	1.1	1	1	1
02/26/2015 23:00	0.6	14.0	1,286.8	0.6	0.9	1	1	0
Average/Sum#:	0.3	13.5	1,675.0	0.4	1.2	24 #	24 #	12 #
Minimum:	-0.4	12.5	1,286.8	-0.1	0.9	1	1	0
Maximum:	0.6	14.1	2,032.6	0.6	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/27/2015 00:00	0.6	13.8	1,715.6	0.6	1.2	1	1	0
02/27/2015 01:00	0.6	13.8	1,787.0	0.6	1.3	1	1	0
02/27/2015 02:00	0.6	13.8	1,767.6	0.6	1.2	1	1	0
02/27/2015 03:00	0.6	13.9	1,499.4	0.6	1.0	1	1	0
02/27/2015 04:00	0.6	14.0	1,287.7	0.6	0.9	1	1	0
02/27/2015 05:00	0.5	13.8	1,472.7	0.5	1.0	1	1	1
02/27/2015 06:00	-0.2	13.0	1,991.1	0.1	1.4	1	1	1
02/27/2015 07:00	-0.2	13.0	1,800.5	0.1	1.3	1	1	1
02/27/2015 08:00	0.6	14.0	1,304.2	0.6	0.9	1	1	0
02/27/2015 09:00	0.6	14.0	1,285.3	0.6	0.9	1	1	0
02/27/2015 10:00	0.6	14.0	1,291.0	0.6	0.9	1	1	0
02/27/2015 11:00	0.6	13.9	1,487.1	0.6	1.0	1	1	0
02/27/2015 12:00	0.6	14.0	1,288.7	0.6	0.9	1	1	0
02/27/2015 13:00	0.6	14.0	1,289.8	0.6	0.9	1	1	0
02/27/2015 14:00	0.6	14.0	1,285.2	0.6	0.9	1	1	0
02/27/2015 15:00	0.6	14.1	1,352.5	0.6	0.9	1	1	0
02/27/2015 16:00	0.6	14.0	1,448.8	0.6	1.0	1	1	0
02/27/2015 17:00	0.1	13.4	1,658.6	0.2	1.2	1	1	1
02/27/2015 18:00	-0.5	12.6	2,050.2	-0.2	1.4	1	1	1
02/27/2015 19:00	-0.4	12.6	2,048.8	-0.1	1.4	1	1	1
02/27/2015 20:00	-0.4	12.7	2,050.2	-0.1	1.4	1	1	1
02/27/2015 21:00	-0.4	12.7	2,040.1	-0.1	1.4	1	1	1
02/27/2015 22:00	-0.4	12.8	2,022.8	-0.1	1.4	1	1	1
02/27/2015 23:00	0.5	13.6	1,587.2	0.5	1.1	1	1	1
Average/Sum#:	0.3	13.6	1,617.2	0.4	1.1	24 #	24 #	10 #
Minimum:	-0.5	12.6	1,285.2	-0.2	0.9	1	1	0
Maximum:	0.6	14.1	2,050.2	0.6	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/28/2015 00:00	0.6	14.0	1,285.3	0.6	0.9	1	1	0
02/28/2015 01:00	0.0	15.9	572.0	0.0	0.4	1	0	0
02/28/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2015 08:00	0.0	16.9	566.9	0.0	0.4	1	0	0
02/28/2015 09:00	0.0	14.5	1,155.7	0.0	0.8	1	0	0
02/28/2015 10:00	0.6	13.9	1,610.8	0.6	1.1	1	1	0
02/28/2015 11:00	0.6	13.8	1,819.7	0.6	1.3	1	1	0
02/28/2015 12:00	0.6	13.9	1,591.4	0.6	1.1	1	1	0
02/28/2015 13:00	0.6	14.0	1,519.6	0.6	1.1	1	1	0
02/28/2015 14:00	0.6	13.8	1,785.2	0.6	1.2	1	1	0
02/28/2015 15:00	0.6	14.0	1,577.6	0.6	1.1	1	1	0
02/28/2015 16:00	0.5	13.7	1,584.1	0.5	1.1	1	1	1
02/28/2015 17:00	-0.5	12.8	2,008.3	-0.2	1.4	1	1	1
02/28/2015 18:00	-0.5	12.7	2,030.8	-0.2	1.4	1	1	1
02/28/2015 19:00	-0.4	12.8	2,031.6	-0.1	1.4	1	1	1
02/28/2015 20:00	-0.4	12.8	2,038.1	-0.1	1.4	1	1	1
02/28/2015 21:00	-0.4	12.8	2,035.5	-0.1	1.4	1	1	1
02/28/2015 22:00	-0.4	12.8	2,036.7	-0.1	1.4	1	1	1
02/28/2015 23:00	-0.2	12.9	2,011.2	0.1	1.4	1	1	1
Average/Sum#:	0.1	13.8	1,625.6	0.2	1.1	18 #	15 #	8 #
Minimum:	-0.5	12.7	566.9	-0.2	0.4	0	0	0
Maximum:	0.6	16.9	2,038.1	0.6	1.4	1	1	1
%SI	25.0	25.0	25.0	25.0	25.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/01/2015 00:00	-0.1	13.0	1,991.7	0.1	1.4	1	1	1
03/01/2015 01:00	0.4	13.5	1,858.2	0.4	1.3	1	1	1
03/01/2015 02:00	0.6	14.0	1,587.3	0.6	1.1	1	1	0
03/01/2015 03:00	0.6	14.0	1,665.9	0.6	1.2	1	1	0
03/01/2015 04:00	0.6	14.0	1,379.1	0.6	1.0	1	1	0
03/01/2015 05:00	0.6	13.9	1,745.9	0.6	1.2	1	1	0
03/01/2015 06:00	0.6	13.9	1,794.8	0.6	1.3	1	1	0
03/01/2015 07:00	0.6	13.8	1,835.0	0.6	1.3	1	1	0
03/01/2015 08:00	0.2	13.4	1,881.7	0.4	1.3	1	1	1
03/01/2015 09:00	-0.4	12.8	2,040.1	-0.1	1.4	1	1	1
03/01/2015 10:00	-0.4	12.8	2,044.9	-0.1	1.4	1	1	1
03/01/2015 11:00	-0.4	12.7	2,050.5	-0.1	1.4	1	1	1
03/01/2015 12:00	-0.4	12.7	2,053.3	-0.1	1.4	1	1	1
03/01/2015 13:00	-0.1	13.0	1,986.5	0.1	1.4	1	1	1
03/01/2015 14:00	-0.2	12.8	2,025.9	0.1	1.4	1	1	1
03/01/2015 15:00	-0.4	12.6	2,053.6	-0.1	1.4	1	1	1
03/01/2015 16:00	-0.2	12.7	2,026.6	0.1	1.4	1	1	1
03/01/2015 17:00	-0.4	12.6	2,053.2	-0.1	1.4	1	1	1
03/01/2015 18:00	-0.4	12.6	2,053.4	-0.1	1.4	1	1	1
03/01/2015 19:00	-0.4	12.7	2,052.5	-0.1	1.4	1	1	1
03/01/2015 20:00	-0.4	12.7	2,053.0	-0.1	1.4	1	1	1
03/01/2015 21:00	-0.4	12.7	2,052.7	-0.1	1.4	1	1	1
03/01/2015 22:00	-0.2	12.8	2,035.8	0.1	1.4	1	1	1
03/01/2015 23:00	-0.2	13.0	1,993.3	0.1	1.4	1	1	1
Average/Sum#:	0.0	13.1	1,929.8	0.2	1.3	24 #	24 #	18 #
Minimum:	-0.4	12.6	1,379.1	-0.1	1.0	1	1	0
Maximum:	0.6	14.0	2,053.6	0.6	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/02/2015 00:00	-0.2	12.9	2,009.0	0.1	1.4	1	1	1
03/02/2015 01:00	-0.4	12.8	2,026.3	-0.1	1.4	1	1	1
03/02/2015 02:00	-0.2	13.0	1,996.9	0.1	1.4	1	1	1
03/02/2015 03:00	0.2	13.3	1,941.6	0.4	1.4	1	1	1
03/02/2015 04:00	0.4	13.6	1,816.0	0.4	1.3	1	1	1
03/02/2015 05:00	-0.2	13.1	1,977.4	-0.1	1.4	1	1	1
03/02/2015 06:00	-0.4	13.0	2,000.8	-0.1	1.4	1	1	1
03/02/2015 07:00	-0.5	12.8	2,029.4	-0.2	1.4	1	1	1
03/02/2015 08:00	-0.4	12.9	2,008.5	-0.1	1.4	1	1	1
03/02/2015 09:00	-0.4	12.9	2,013.8	-0.1	1.4	1	1	1
03/02/2015 10:00	-0.2	13.0	2,006.3	0.1	1.4	1	1	1
03/02/2015 11:00	-0.1	13.0	1,978.5	0.1	1.4	1	1	1
03/02/2015 12:00	-0.2	12.9	2,004.4	0.1	1.4	1	1	1
03/02/2015 13:00	-0.2	12.9	1,992.8	0.1	1.4	1	1	1
03/02/2015 14:00	0.5	13.6	1,699.2	0.5	1.2	1	1	1
03/02/2015 15:00	0.6	13.9	1,616.8	0.6	1.1	1	1	0
03/02/2015 16:00	0.2	13.5	1,823.6	0.4	1.3	1	1	1
03/02/2015 17:00	0.2	13.3	1,927.3	0.4	1.3	1	1	1
03/02/2015 18:00	0.2	13.3	1,932.6	0.4	1.4	1	1	1
03/02/2015 19:00	0.2	13.3	1,936.3	0.4	1.4	1	1	1
03/02/2015 20:00	0.2	13.3	1,942.8	0.4	1.4	1	1	1
03/02/2015 21:00	0.2	13.3	1,943.3	0.4	1.4	1	1	1
03/02/2015 22:00	0.4	13.5	1,801.7	0.4	1.3	1	1	1
03/02/2015 23:00	0.6	13.9	1,545.1	0.6	1.1	1	1	0
Average/Sum#:	0.0	13.2	1,915.4	0.2	1.4	24 #	24 #	22 #
Minimum:	-0.5	12.8	1,545.1	-0.2	1.1	1	1	0
Maximum:	0.6	13.9	2,029.4	0.6	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/03/2015 00:00	0.6	13.9	1,288.7	0.6	0.9	1	1	0
03/03/2015 01:00	0.6	13.9	1,289.4	0.6	0.9	1	1	0
03/03/2015 02:00	0.6	13.9	1,292.2	0.6	0.9	1	1	0
03/03/2015 03:00	0.6	13.9	1,294.3	0.6	0.9	1	1	0
03/03/2015 04:00	0.4	13.7	1,562.2	0.4	1.1	1	1	1
03/03/2015 05:00	-0.2	13.1	1,989.1	-0.1	1.4	1	1	1
03/03/2015 06:00	-0.4	12.9	2,026.0	-0.1	1.4	1	1	1
03/03/2015 07:00	-0.2	13.0	1,981.8	0.1	1.4	1	1	1
03/03/2015 08:00	0.5	13.7	1,594.7	0.5	1.1	1	1	1
03/03/2015 09:00	0.6	14.0	1,290.8	0.6	0.9	1	1	0
03/03/2015 10:00	0.6	14.0	1,293.1	0.6	0.9	1	1	0
03/03/2015 11:00	0.6	14.0	1,293.5	0.6	0.9	1	1	0
03/03/2015 12:00	0.6	14.0	1,296.6	0.6	0.9	1	1	0
03/03/2015 13:00	0.6	14.0	1,298.0	0.6	0.9	1	1	0
03/03/2015 14:00	0.6	14.0	1,292.8	0.6	0.9	1	1	0
03/03/2015 15:00	0.6	14.0	1,292.4	0.6	0.9	1	1	0
03/03/2015 16:00	0.7	13.9	1,406.7	0.7	1.0	1	1	1
03/03/2015 17:00	0.1	13.2	1,938.6	0.2	1.4	1	1	1
03/03/2015 18:00	-0.2	12.9	2,010.7	0.1	1.4	1	1	1
03/03/2015 19:00	-0.4	12.7	2,055.8	-0.1	1.4	1	1	1
03/03/2015 20:00	-0.4	12.7	2,049.7	-0.1	1.4	1	1	1
03/03/2015 21:00	-0.4	12.7	2,049.8	-0.1	1.4	1	1	1
03/03/2015 22:00	-0.2	12.9	2,011.7	0.1	1.4	1	1	1
03/03/2015 23:00	0.5	13.6	1,718.2	0.5	1.2	1	1	1
Average/Sum#:	0.3	13.5	1,609.0	0.4	1.1	24 #	24 #	13 #
Minimum:	-0.4	12.7	1,288.7	-0.1	0.9	1	1	0
Maximum:	0.7	14.0	2,055.8	0.7	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/04/2015 00:00	0.6	13.9	1,813.5	0.6	1.3	1	1	0
03/04/2015 01:00	0.6	13.9	1,786.5	0.6	1.3	1	1	0
03/04/2015 02:00	0.6	14.1	1,736.5	0.6	1.2	1	1	0
03/04/2015 03:00	0.6	13.9	1,769.1	0.6	1.2	1	1	0
03/04/2015 04:00	0.2	13.5	1,819.7	0.4	1.3	1	1	1
03/04/2015 05:00	-0.2	13.0	2,003.0	0.1	1.4	1	1	1
03/04/2015 06:00	-0.1	13.0	2,006.0	0.1	1.4	1	1	1
03/04/2015 07:00	-0.2	12.9	2,001.0	0.1	1.4	1	1	1
03/04/2015 08:00	0.1	13.1	1,977.6	0.2	1.4	1	1	1
03/04/2015 09:00	0.7	13.8	1,456.5	0.7	1.0	1	1	1
03/04/2015 10:00	0.6	14.0	1,292.8	0.6	0.9	1	1	0
03/04/2015 11:00	0.6	14.0	1,291.4	0.6	0.9	1	1	0
03/04/2015 12:00	0.6	14.0	1,290.1	0.6	0.9	1	1	0
03/04/2015 13:00	0.6	14.0	1,288.9	0.6	0.9	1	1	0
03/04/2015 14:00	0.6	14.0	1,289.0	0.6	0.9	1	1	0
03/04/2015 15:00	0.6	14.0	1,288.3	0.6	0.9	1	1	0
03/04/2015 16:00	0.4	13.7	1,545.9	0.4	1.1	1	1	1
03/04/2015 17:00	-0.5	12.8	2,008.9	-0.2	1.4	1	1	1
03/04/2015 18:00	-0.4	12.7	2,031.5	-0.1	1.4	1	1	1
03/04/2015 19:00	-0.4	12.7	2,027.5	-0.1	1.4	1	1	1
03/04/2015 20:00	-0.4	12.8	2,026.1	-0.1	1.4	1	1	1
03/04/2015 21:00	-0.2	12.9	2,009.7	0.1	1.4	1	1	1
03/04/2015 22:00	-0.2	13.0	2,013.6	0.1	1.4	1	1	1
03/04/2015 23:00	0.1	13.2	1,982.8	0.2	1.4	1	1	1
Average/Sum#:	0.2	13.5	1,739.8	0.3	1.2	24 #	24 #	14 #
Minimum:	-0.5	12.7	1,288.3	-0.2	0.9	1	1	0
Maximum:	0.7	14.1	2,031.5	0.7	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/05/2015 00:00	0.4	13.5	1,807.0	0.4	1.3	1	1	1
03/05/2015 01:00	0.6	13.9	1,591.2	0.6	1.1	1	1	0
03/05/2015 02:00	0.6	13.9	1,546.0	0.6	1.1	1	1	0
03/05/2015 03:00	0.6	13.9	1,632.9	0.6	1.1	1	1	0
03/05/2015 04:00	0.5	13.8	1,760.9	0.5	1.2	1	1	1
03/05/2015 05:00	-0.2	13.1	1,991.2	-0.1	1.4	1	1	1
03/05/2015 06:00	-0.4	13.0	2,018.4	-0.1	1.4	1	1	1
03/05/2015 07:00	-0.2	13.1	2,015.3	-0.1	1.4	1	1	1
03/05/2015 08:00	0.1	13.3	1,941.5	0.2	1.4	1	1	1
03/05/2015 09:00	0.7	13.8	1,455.1	0.7	1.0	1	1	1
03/05/2015 10:00	0.6	13.9	1,292.3	0.6	0.9	1	1	0
03/05/2015 11:00	0.6	14.0	1,292.4	0.6	0.9	1	1	0
03/05/2015 12:00	0.6	14.0	1,292.5	0.6	0.9	1	1	0
03/05/2015 13:00	0.6	14.0	1,293.4	0.6	0.9	1	1	0
03/05/2015 14:00	0.6	14.0	1,294.8	0.6	0.9	1	1	0
03/05/2015 15:00	0.6	14.0	1,295.6	0.6	0.9	1	1	0
03/05/2015 16:00	0.5	13.7	1,549.7	0.5	1.1	1	1	1
03/05/2015 17:00	-0.5	12.6	2,023.1	-0.2	1.4	1	1	1
03/05/2015 18:00	-0.4	12.6	2,035.5	-0.1	1.4	1	1	1
03/05/2015 19:00	-0.4	12.6	2,031.7	-0.1	1.4	1	1	1
03/05/2015 20:00	-0.4	12.7	2,029.0	-0.1	1.4	1	1	1
03/05/2015 21:00	-0.4	12.7	2,018.7	-0.1	1.4	1	1	1
03/05/2015 22:00	-0.2	12.8	2,010.9	0.1	1.4	1	1	1
03/05/2015 23:00	0.4	13.4	1,745.1	0.4	1.2	1	1	1
Average/Sum#:	0.2	13.4	1,706.8	0.3	1.2	24 #	24 #	15 #
Minimum:	-0.5	12.6	1,292.3	-0.2	0.9	1	1	0
Maximum:	0.7	14.0	2,035.5	0.7	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/06/2015 00:00	0.6	13.9	1,294.5	0.6	0.9	1	1	0
03/06/2015 01:00	0.6	13.9	1,292.1	0.6	0.9	1	1	0
03/06/2015 02:00	0.6	13.9	1,290.3	0.6	0.9	1	1	0
03/06/2015 03:00	0.6	13.9	1,292.0	0.6	0.9	1	1	0
03/06/2015 04:00	0.5	13.9	1,293.1	0.5	0.9	1	1	0
03/06/2015 05:00	0.2	13.6	1,570.5	0.4	1.1	1	1	1
03/06/2015 06:00	-0.2	13.1	1,994.1	-0.1	1.4	1	1	1
03/06/2015 07:00	-0.1	13.2	1,954.1	0.1	1.4	1	1	1
03/06/2015 08:00	0.2	13.3	1,941.3	0.4	1.4	1	1	1
03/06/2015 09:00	0.1	13.3	1,949.5	0.2	1.4	1	1	1
03/06/2015 10:00	0.5	13.6	1,612.8	0.5	1.1	1	1	1
03/06/2015 11:00	0.6	14.0	1,291.4	0.6	0.9	1	1	0
03/06/2015 12:00	0.6	14.0	1,292.6	0.6	0.9	1	1	0
03/06/2015 13:00	0.6	14.0	1,295.6	0.6	0.9	1	1	0
03/06/2015 14:00	0.6	14.0	1,298.0	0.6	0.9	1	1	0
03/06/2015 15:00	0.6	14.0	1,297.6	0.6	0.9	1	1	0
03/06/2015 16:00	0.4	13.7	1,535.8	0.4	1.1	1	1	1
03/06/2015 17:00	-0.5	12.6	1,996.7	-0.2	1.4	1	1	1
03/06/2015 18:00	-0.4	12.4	2,042.2	-0.1	1.4	1	1	1
03/06/2015 19:00	-0.4	12.4	2,042.1	-0.1	1.4	1	1	1
03/06/2015 20:00	-0.4	12.5	2,038.0	-0.1	1.4	1	1	1
03/06/2015 21:00	-0.2	12.8	2,003.6	0.1	1.4	1	1	1
03/06/2015 22:00	-0.2	12.8	2,009.9	0.1	1.4	1	1	1
03/06/2015 23:00	-0.1	12.9	1,995.0	0.1	1.4	1	1	1
Average/Sum#:	0.2	13.4	1,651.0	0.3	1.2	24 #	24 #	14 #
Minimum:	-0.5	12.4	1,290.3	-0.2	0.9	1	1	0
Maximum:	0.6	14.0	2,042.2	0.6	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/07/2015 00:00	0.1	13.2	1,881.1	0.2	1.3	1	1	1
03/07/2015 01:00	0.6	13.8	1,727.7	0.6	1.2	1	1	0
03/07/2015 02:00	0.0	16.1	468.2	0.0	0.3	1	0	0
03/07/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2015 10:00	0.0	16.8	573.4	0.0	0.4	1	0	0
03/07/2015 11:00	0.0	15.0	999.4	0.0	0.7	1	0	0
03/07/2015 12:00	0.6	13.9	1,751.8	0.6	1.2	1	1	0
03/07/2015 13:00	0.6	13.9	1,754.1	0.6	1.2	1	1	0
03/07/2015 14:00	0.6	13.9	1,686.5	0.6	1.2	1	1	0
03/07/2015 15:00	0.6	14.0	1,453.4	0.6	1.0	1	1	0
03/07/2015 16:00	0.2	13.5	1,700.8	0.4	1.2	1	1	1
03/07/2015 17:00	-0.5	12.4	2,038.3	-0.2	1.4	1	1	1
03/07/2015 18:00	-0.4	12.5	2,011.2	-0.1	1.4	1	1	1
03/07/2015 19:00	-0.4	12.4	2,039.0	-0.1	1.4	1	1	1
03/07/2015 20:00	-0.2	12.5	2,037.5	0.1	1.4	1	1	1
03/07/2015 21:00	-0.1	12.8	1,993.6	0.1	1.4	1	1	1
03/07/2015 22:00	-0.2	12.9	1,993.2	0.1	1.4	1	1	1
03/07/2015 23:00	0.2	13.2	1,789.3	0.4	1.3	1	1	1
Average/Sum#:	0.1	13.7	1,641.1	0.2	1.1	17 #	14 #	9 #
Minimum:	-0.5	12.4	468.2	-0.2	0.3	0	0	0
Maximum:	0.6	16.8	2,039.0	0.6	1.4	1	1	1
%SI	29.2	29.2	29.2	29.2	29.2	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/08/2015 00:00	0.6	14.0	1,286.2	0.6	0.9	1	1	0
03/08/2015 01:00	0.6	14.0	1,286.3	0.6	0.9	1	1	0
03/08/2015 02:00	0.6	14.0	1,286.7	0.6	0.9	1	1	0
03/08/2015 03:00	0.6	14.0	1,287.3	0.6	0.9	1	1	0
03/08/2015 04:00	0.6	14.0	1,288.2	0.6	0.9	1	1	0
03/08/2015 05:00	0.6	14.0	1,288.0	0.6	0.9	1	1	0
03/08/2015 06:00	0.5	13.9	1,290.3	0.5	0.9	1	1	0
03/08/2015 07:00	0.5	13.9	1,290.6	0.5	0.9	1	1	0
03/08/2015 08:00	0.0	15.8	578.5	0.0	0.4	1	0	0
03/08/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2015 14:00	0.0	21.0	0.2	0.0	0.0	1	0	0
03/08/2015 15:00	0.0	16.0	676.0	0.0	0.5	1	0	0
03/08/2015 16:00	0.0	14.0	1,295.4	0.0	0.9	1	0	0
03/08/2015 17:00	0.6	14.0	1,294.9	0.6	0.9	1	1	0
03/08/2015 18:00	0.1	13.4	1,691.0	0.2	1.2	1	1	1
03/08/2015 19:00	-0.5	12.7	1,965.3	-0.2	1.4	1	1	1
03/08/2015 20:00	-0.2	13.0	1,853.8	0.1	1.3	1	1	1
03/08/2015 21:00	0.6	14.0	1,310.9	0.6	0.9	1	1	0
03/08/2015 22:00	0.6	14.0	1,288.3	0.6	0.9	1	1	0
03/08/2015 23:00	0.6	14.0	1,288.2	0.6	0.9	1	1	0
Average/Sum#:	0.3	14.4	1,239.3	0.4	0.9	19 #	15 #	3 #
Minimum:	-0.5	12.7	0.2	-0.2	0.0	0	0	0
Maximum:	0.6	21.0	1,965.3	0.6	1.4	1	1	1
%SI	20.8	20.8	20.8	20.8	20.8	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/09/2015 00:00	0.6	14.0	1,287.1	0.6	0.9	1	1	0
03/09/2015 01:00	0.6	14.0	1,285.9	0.6	0.9	1	1	0
03/09/2015 02:00	0.6	14.0	1,286.2	0.6	0.9	1	1	0
03/09/2015 03:00	0.6	14.0	1,285.0	0.6	0.9	1	1	0
03/09/2015 04:00	0.5	13.9	1,400.9	0.5	1.0	1	1	1
03/09/2015 05:00	-0.5	12.9	1,995.2	-0.2	1.4	1	1	1
03/09/2015 06:00	-0.7	12.7	2,053.3	-0.2	1.4	1	1	1
03/09/2015 07:00	-0.2	13.0	1,970.0	0.1	1.4	1	1	1
03/09/2015 08:00	0.1	13.2	1,953.3	0.2	1.4	1	1	1
03/09/2015 09:00	0.7	13.9	1,331.1	0.7	0.9	1	1	1
03/09/2015 10:00	0.6	14.0	1,285.7	0.6	0.9	1	1	0
03/09/2015 11:00	0.6	14.0	1,285.7	0.6	0.9	1	1	0
03/09/2015 12:00	0.6	14.0	1,286.7	0.6	0.9	1	1	0
03/09/2015 13:00	0.6	14.0	1,293.4	0.6	0.9	1	1	0
03/09/2015 14:00	0.4	13.6	1,619.5	0.4	1.1	1	1	1
03/09/2015 15:00	0.6	14.0	1,285.8	0.6	0.9	1	1	0
03/09/2015 16:00	0.6	14.0	1,285.4	0.6	0.9	1	1	0
03/09/2015 17:00	-0.1	13.2	1,727.0	0.1	1.2	1	1	1
03/09/2015 18:00	-0.5	12.4	2,041.8	-0.2	1.4	1	1	1
03/09/2015 19:00	-0.5	12.5	2,041.9	-0.2	1.4	1	1	1
03/09/2015 20:00	-0.4	12.6	2,017.9	-0.1	1.4	1	1	1
03/09/2015 21:00	-0.1	12.9	1,958.2	0.1	1.4	1	1	1
03/09/2015 22:00	-0.4	12.8	1,989.9	-0.1	1.4	1	1	1
03/09/2015 23:00	-0.1	13.0	1,946.8	0.1	1.4	1	1	1
Average/Sum#:	0.2	13.4	1,621.4	0.3	1.1	24 #	24 #	14 #
Minimum:	-0.7	12.4	1,285.0	-0.2	0.9	1	1	0
Maximum:	0.7	14.0	2,053.3	0.7	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/10/2015 00:00	0.1	13.1	1,926.2	0.2	1.3	1	1	1
03/10/2015 01:00	-0.2	12.9	1,967.5	0.1	1.4	1	1	1
03/10/2015 02:00	0.1	13.2	1,914.9	0.2	1.3	1	1	1
03/10/2015 03:00	0.1	13.1	1,922.9	0.2	1.3	1	1	1
03/10/2015 04:00	-0.1	13.1	1,954.1	0.1	1.4	1	1	1
03/10/2015 05:00	-0.4	12.9	2,013.8	-0.1	1.4	1	1	1
03/10/2015 06:00	-0.5	12.8	2,046.4	-0.2	1.4	1	1	1
03/10/2015 07:00	-0.4	12.8	2,004.7	-0.1	1.4	1	1	1
03/10/2015 08:00	0.2	13.4	1,800.6	0.4	1.3	1	1	1
03/10/2015 09:00	0.6	13.9	1,414.1	0.6	1.0	1	1	0
03/10/2015 10:00	0.6	13.9	1,288.2	0.6	0.9	1	1	0
03/10/2015 11:00	0.6	14.0	1,288.1	0.6	0.9	1	1	0
03/10/2015 12:00	0.6	14.0	1,288.5	0.6	0.9	1	1	0
03/10/2015 13:00	0.6	14.0	1,288.9	0.6	0.9	1	1	0
03/10/2015 14:00	0.6	14.0	1,289.3	0.6	0.9	1	1	0
03/10/2015 15:00	0.6	14.0	1,288.7	0.6	0.9	1	1	0
03/10/2015 16:00	0.5	13.9	1,398.9	0.5	1.0	1	1	1
03/10/2015 17:00	-0.8	12.5	2,023.3	-0.4	1.4	1	1	1
03/10/2015 18:00	-0.7	12.5	2,033.7	-0.2	1.4	1	1	1
03/10/2015 19:00	-0.5	12.5	2,038.7	-0.2	1.4	1	1	1
03/10/2015 20:00	-0.5	12.5	2,035.7	-0.2	1.4	1	1	1
03/10/2015 21:00	-0.4	12.7	1,989.8	-0.1	1.4	1	1	1
03/10/2015 22:00	0.2	13.4	1,671.8	0.4	1.2	1	1	1
03/10/2015 23:00	0.6	13.9	1,287.5	0.6	0.9	1	1	0
Average/Sum#:	0.1	13.3	1,715.7	0.2	1.2	24 #	24 #	16 #
Minimum:	-0.8	12.5	1,287.5	-0.4	0.9	1	1	0
Maximum:	0.6	14.0	2,046.4	0.6	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/11/2015 00:00	0.6	13.9	1,287.4	0.6	0.9	1	1	0
03/11/2015 01:00	0.5	13.9	1,288.6	0.5	0.9	1	1	0
03/11/2015 02:00	0.5	13.9	1,288.6	0.5	0.9	1	1	0
03/11/2015 03:00	0.6	14.0	1,288.3	0.6	0.9	1	1	0
03/11/2015 04:00	0.5	13.8	1,404.7	0.5	1.0	1	1	1
03/11/2015 05:00	-0.2	13.2	1,936.8	-0.1	1.4	1	1	1
03/11/2015 06:00	-0.2	13.0	1,979.6	0.1	1.4	1	1	1
03/11/2015 07:00	-0.5	12.7	2,047.5	-0.2	1.4	1	1	1
03/11/2015 08:00	-0.5	12.7	2,049.3	-0.2	1.4	1	1	1
03/11/2015 09:00	-0.4	12.7	2,044.5	-0.1	1.4	1	1	1
03/11/2015 10:00	-0.4	12.6	2,042.8	-0.1	1.4	1	1	1
03/11/2015 11:00	-0.4	12.6	2,044.1	-0.1	1.4	1	1	1
03/11/2015 12:00	-0.4	12.6	2,038.5	-0.1	1.4	1	1	1
03/11/2015 13:00	-0.4	12.6	2,044.8	-0.1	1.4	1	1	1
03/11/2015 14:00	-0.4	12.6	2,041.6	-0.1	1.4	1	1	1
03/11/2015 15:00	-0.4	12.6	2,043.3	-0.1	1.4	1	1	1
03/11/2015 16:00	-0.4	12.6	2,042.8	-0.1	1.4	1	1	1
03/11/2015 17:00	0.1	13.0	1,961.1	0.2	1.4	1	1	1
03/11/2015 18:00	-0.4	12.6	2,042.0	-0.1	1.4	1	1	1
03/11/2015 19:00	-0.4	12.7	2,050.1	-0.1	1.4	1	1	1
03/11/2015 20:00	-0.1	12.9	2,004.1	0.1	1.4	1	1	1
03/11/2015 21:00	0.5	13.5	1,619.4	0.5	1.1	1	1	1
03/11/2015 22:00	0.6	13.9	1,292.9	0.6	0.9	1	1	0
03/11/2015 23:00	0.6	13.9	1,297.1	0.6	0.9	1	1	0
Average/Sum#:	0.0	13.1	1,799.2	0.1	1.2	24 #	24 #	18 #
Minimum:	-0.5	12.6	1,287.4	-0.2	0.9	1	1	0
Maximum:	0.6	14.0	2,050.1	0.6	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/12/2015 00:00	0.6	13.9	1,300.4	0.6	0.9	1	1	0
03/12/2015 01:00	0.6	13.9	1,305.1	0.6	0.9	1	1	0
03/12/2015 02:00	0.5	13.9	1,307.5	0.5	0.9	1	1	0
03/12/2015 03:00	0.5	13.9	1,307.7	0.5	0.9	1	1	0
03/12/2015 04:00	0.5	13.8	1,425.3	0.5	1.0	1	1	1
03/12/2015 05:00	-0.1	13.2	1,945.8	0.1	1.4	1	1	1
03/12/2015 06:00	-0.7	12.7	2,033.2	-0.2	1.4	1	1	1
03/12/2015 07:00	-0.5	12.7	2,032.8	-0.2	1.4	1	1	1
03/12/2015 08:00	-0.2	12.9	1,980.2	0.1	1.4	1	1	1
03/12/2015 09:00	0.1	13.1	1,945.5	0.2	1.4	1	1	1
03/12/2015 10:00	0.1	13.2	1,923.9	0.2	1.3	1	1	1
03/12/2015 11:00	0.6	13.9	1,352.3	0.6	0.9	1	1	0
03/12/2015 12:00	0.6	14.0	1,293.5	0.6	0.9	1	1	0
03/12/2015 13:00	0.6	14.0	1,293.0	0.6	0.9	1	1	0
03/12/2015 14:00	0.6	14.0	1,292.6	0.6	0.9	1	1	0
03/12/2015 15:00	0.6	14.0	1,291.0	0.6	0.9	1	1	0
03/12/2015 16:00	0.5	13.7	1,538.0	0.5	1.1	1	1	1
03/12/2015 17:00	-0.7	12.6	2,023.8	-0.2	1.4	1	1	1
03/12/2015 18:00	-0.5	12.6	2,041.0	-0.2	1.4	1	1	1
03/12/2015 19:00	-0.5	12.6	2,043.0	-0.2	1.4	1	1	1
03/12/2015 20:00	-0.5	12.6	2,041.8	-0.2	1.4	1	1	1
03/12/2015 21:00	-0.5	12.6	2,036.5	-0.2	1.4	1	1	1
03/12/2015 22:00	0.1	13.2	1,782.1	0.2	1.2	1	1	1
03/12/2015 23:00	0.6	14.0	1,381.1	0.6	1.0	1	1	0
Average/Sum#:	0.1	13.4	1,663.2	0.3	1.2	24 #	24 #	14 #
Minimum:	-0.7	12.6	1,291.0	-0.2	0.9	1	1	0
Maximum:	0.6	14.0	2,043.0	0.6	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/13/2015 00:00	0.6	14.0	1,382.0	0.6	1.0	1	1	0
03/13/2015 01:00	0.6	13.9	1,415.4	0.6	1.0	1	1	0
03/13/2015 02:00	0.6	13.9	1,538.8	0.6	1.1	1	1	0
03/13/2015 03:00	0.6	13.9	1,411.2	0.6	1.0	1	1	0
03/13/2015 04:00	0.4	13.7	1,555.4	0.4	1.1	1	1	1
03/13/2015 05:00	-0.1	13.0	1,976.0	0.1	1.4	1	1	1
03/13/2015 06:00	-0.2	12.9	2,001.0	0.1	1.4	1	1	1
03/13/2015 07:00	0.4	13.3	1,913.7	0.4	1.3	1	1	1
03/13/2015 08:00	0.4	13.2	1,916.6	0.4	1.3	1	1	1
03/13/2015 09:00	0.2	13.2	1,918.8	0.4	1.3	1	1	1
03/13/2015 10:00	0.5	13.6	1,625.9	0.5	1.1	1	1	1
03/13/2015 11:00	0.6	14.0	1,292.1	0.6	0.9	1	1	0
03/13/2015 12:00	0.7	13.9	1,396.7	0.7	1.0	1	1	1
03/13/2015 13:00	-0.4	12.8	1,972.5	-0.1	1.4	1	1	1
03/13/2015 14:00	-0.2	12.8	1,979.2	0.1	1.4	1	1	1
03/13/2015 15:00	-0.4	12.5	2,028.3	-0.1	1.4	1	1	1
03/13/2015 16:00	-0.4	12.4	2,040.0	-0.1	1.4	1	1	1
03/13/2015 17:00	-0.4	12.4	2,043.3	-0.1	1.4	1	1	1
03/13/2015 18:00	-0.4	12.5	2,042.4	-0.1	1.4	1	1	1
03/13/2015 19:00	-0.4	12.5	2,032.0	-0.1	1.4	1	1	1
03/13/2015 20:00	-0.4	12.5	2,035.5	-0.1	1.4	1	1	1
03/13/2015 21:00	-0.2	12.6	2,008.1	0.1	1.4	1	1	1
03/13/2015 22:00	-0.4	12.6	2,019.7	-0.1	1.4	1	1	1
03/13/2015 23:00	-0.4	12.5	2,028.4	-0.1	1.4	1	1	1
Average/Sum#:	0.1	13.1	1,815.5	0.2	1.3	24 #	24 #	19 #
Minimum:	-0.4	12.4	1,292.1	-0.1	0.9	1	1	0
Maximum:	0.7	14.0	2,043.3	0.7	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/14/2015 00:00	-0.2	12.8	1,980.0	0.1	1.4	1	1	1
03/14/2015 01:00	-0.2	12.8	1,981.4	0.1	1.4	1	1	1
03/14/2015 02:00	-0.2	12.9	1,966.4	0.1	1.4	1	1	1
03/14/2015 03:00	0.1	13.1	1,924.9	0.2	1.3	1	1	1
03/14/2015 04:00	0.2	13.1	1,919.6	0.4	1.3	1	1	1
03/14/2015 05:00	0.2	13.1	1,924.7	0.4	1.3	1	1	1
03/14/2015 06:00	-0.5	12.6	2,028.5	-0.2	1.4	1	1	1
03/14/2015 07:00	-0.4	12.7	1,998.1	-0.1	1.4	1	1	1
03/14/2015 08:00	-0.1	12.9	1,954.2	0.1	1.4	1	1	1
03/14/2015 09:00	-0.1	13.0	1,950.0	0.1	1.4	1	1	1
03/14/2015 10:00	-0.1	12.9	1,952.3	0.1	1.4	1	1	1
03/14/2015 11:00	-0.1	12.9	1,971.4	0.1	1.4	1	1	1
03/14/2015 12:00	-0.5	12.5	2,049.8	-0.2	1.4	1	1	1
03/14/2015 13:00	-0.5	12.4	2,052.3	-0.2	1.4	1	1	1
03/14/2015 14:00	-0.4	12.4	2,048.6	-0.1	1.4	1	1	1
03/14/2015 15:00	-0.4	12.5	2,013.9	-0.1	1.4	1	1	1
03/14/2015 16:00	-0.4	12.3	2,049.9	-0.1	1.4	1	1	1
03/14/2015 17:00	-0.4	12.4	2,049.7	-0.1	1.4	1	1	1
03/14/2015 18:00	-0.4	12.4	2,046.9	-0.1	1.4	1	1	1
03/14/2015 19:00	-0.4	12.4	2,045.6	-0.1	1.4	1	1	1
03/14/2015 20:00	-0.4	12.4	2,044.4	-0.1	1.4	1	1	1
03/14/2015 21:00	-0.4	12.4	2,044.5	-0.1	1.4	1	1	1
03/14/2015 22:00	-0.4	12.5	2,042.1	-0.1	1.4	1	1	1
03/14/2015 23:00	-0.4	12.6	2,006.8	-0.1	1.4	1	1	1
Average/Sum#:	-0.3	12.7	2,001.9	0.0	1.4	24 #	24 #	24 #
Minimum:	-0.5	12.3	1,919.6	-0.2	1.3	1	1	1
Maximum:	0.2	13.1	2,052.3	0.4	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/15/2015 00:00	-0.1	12.9	1,950.1	0.1	1.4	1	1	1
03/15/2015 01:00	-0.2	12.7	1,990.5	0.1	1.4	1	1	1
03/15/2015 02:00	0.2	13.2	1,813.2	0.4	1.3	1	1	1
03/15/2015 03:00	0.6	13.8	1,769.1	0.6	1.2	1	1	0
03/15/2015 04:00	0.6	13.7	1,782.6	0.6	1.2	1	1	0
03/15/2015 05:00	0.6	13.8	1,753.2	0.6	1.2	1	1	0
03/15/2015 06:00	0.6	13.7	1,784.0	0.6	1.2	1	1	0
03/15/2015 07:00	0.6	13.7	1,556.0	0.6	1.1	1	1	0
03/15/2015 08:00	0.6	13.9	1,296.8	0.6	0.9	1	1	0
03/15/2015 09:00	0.6	14.0	1,297.7	0.6	0.9	1	1	0
03/15/2015 10:00	0.6	14.0	1,299.0	0.6	0.9	1	1	0
03/15/2015 11:00	0.6	13.9	1,570.7	0.6	1.1	1	1	0
03/15/2015 12:00	0.6	13.9	1,761.6	0.6	1.2	1	1	0
03/15/2015 13:00	-0.2	13.0	1,920.1	0.1	1.3	1	1	1
03/15/2015 14:00	-0.5	12.6	2,046.5	-0.2	1.4	1	1	1
03/15/2015 15:00	-0.4	12.6	2,031.2	-0.1	1.4	1	1	1
03/15/2015 16:00	-0.4	12.6	2,036.6	-0.1	1.4	1	1	1
03/15/2015 17:00	-0.4	12.6	2,034.2	-0.1	1.4	1	1	1
03/15/2015 18:00	-0.4	12.6	2,033.7	-0.1	1.4	1	1	1
03/15/2015 19:00	-0.4	12.6	2,035.7	-0.1	1.4	1	1	1
03/15/2015 20:00	-0.4	12.6	2,034.5	-0.1	1.4	1	1	1
03/15/2015 21:00	-0.4	12.6	2,027.0	-0.1	1.4	1	1	1
03/15/2015 22:00	0.1	13.1	1,846.4	0.2	1.3	1	1	1
03/15/2015 23:00	0.6	13.9	1,294.0	0.6	0.9	1	1	0
Average/Sum#:	0.1	13.3	1,790.2	0.3	1.2	24 #	24 #	13 #
Minimum:	-0.5	12.6	1,294.0	-0.2	0.9	1	1	0
Maximum:	0.6	14.0	2,046.5	0.6	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/16/2015 00:00	0.6	14.0	1,291.5	0.6	0.9	1	1	0
03/16/2015 01:00	0.6	13.9	1,288.4	0.6	0.9	1	1	0
03/16/2015 02:00	0.6	13.9	1,291.1	0.6	0.9	1	1	0
03/16/2015 03:00	0.6	14.0	1,294.6	0.6	0.9	1	1	0
03/16/2015 04:00	0.4	13.6	1,552.3	0.4	1.1	1	1	1
03/16/2015 05:00	-0.2	12.8	1,993.5	0.1	1.4	1	1	1
03/16/2015 06:00	-0.5	12.6	2,034.4	-0.2	1.4	1	1	1
03/16/2015 07:00	-0.4	12.7	1,997.9	-0.1	1.4	1	1	1
03/16/2015 08:00	-0.4	12.6	2,033.2	-0.1	1.4	1	1	1
03/16/2015 09:00	-0.4	12.7	2,030.7	-0.1	1.4	1	1	1
03/16/2015 10:00	-0.4	12.7	2,016.3	-0.1	1.4	1	1	1
03/16/2015 11:00	-0.4	12.6	2,033.2	-0.1	1.4	1	1	1
03/16/2015 12:00	-0.4	12.6	2,031.5	-0.1	1.4	1	1	1
03/16/2015 13:00	-0.4	12.6	2,033.0	-0.1	1.4	1	1	1
03/16/2015 14:00	-0.4	12.6	2,032.2	-0.1	1.4	1	1	1
03/16/2015 15:00	-0.4	12.6	2,022.6	-0.1	1.4	1	1	1
03/16/2015 16:00	-0.2	12.8	1,978.8	0.1	1.4	1	1	1
03/16/2015 17:00	-0.1	12.9	1,950.4	0.1	1.4	1	1	1
03/16/2015 18:00	-0.4	12.7	2,010.4	-0.1	1.4	1	1	1
03/16/2015 19:00	-0.4	12.6	2,047.3	-0.1	1.4	1	1	1
03/16/2015 20:00	-0.1	12.8	2,011.6	0.1	1.4	1	1	1
03/16/2015 21:00	0.1	13.0	1,977.0	0.2	1.4	1	1	1
03/16/2015 22:00	0.7	13.8	1,459.4	0.7	1.0	1	1	1
03/16/2015 23:00	0.6	13.9	1,290.7	0.6	0.9	1	1	0
Average/Sum#:	-0.1	13.0	1,820.9	0.1	1.3	24 #	24 #	19 #
Minimum:	-0.5	12.6	1,288.4	-0.2	0.9	1	1	0
Maximum:	0.7	14.0	2,047.3	0.7	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/17/2015 00:00	0.6	13.9	1,289.0	0.6	0.9	1	1	0
03/17/2015 01:00	0.6	13.9	1,289.8	0.6	0.9	1	1	0
03/17/2015 02:00	0.6	13.9	1,289.7	0.6	0.9	1	1	0
03/17/2015 03:00	0.6	13.9	1,290.5	0.6	0.9	1	1	0
03/17/2015 04:00	0.5	13.9	1,290.1	0.5	0.9	1	1	0
03/17/2015 05:00	0.5	13.9	1,290.3	0.5	0.9	1	1	0
03/17/2015 06:00	0.5	13.9	1,290.3	0.5	0.9	1	1	0
03/17/2015 07:00	0.5	13.9	1,289.1	0.5	0.9	1	1	0
03/17/2015 08:00	0.5	13.9	1,290.7	0.5	0.9	1	1	0
03/17/2015 09:00	0.5	13.9	1,292.8	0.5	0.9	1	1	0
03/17/2015 10:00	0.6	0.0	1,295.3	0.6	0.9	1	1	0
03/17/2015 11:00	0.0	15.0	1,294.8	0.0	0.9	1	0	0
03/17/2015 12:00	0.0	16.6	1,296.9	0.0	0.9	1	0	0
03/17/2015 13:00	0.6	17.4	1,298.4	0.6	0.9	1	1	0
03/17/2015 14:00	0.6	17.5	1,299.0	0.6	0.9	1	1	0
03/17/2015 15:00	0.6	17.6	1,297.7	0.6	0.9	1	1	0
03/17/2015 16:00	0.6	18.0	1,295.9	0.6	0.9	1	1	0
03/17/2015 17:00	0.6	18.2	1,296.3	0.6	0.9	1	1	0
03/17/2015 18:00	0.6	18.2	1,295.9	0.6	0.9	1	1	0
03/17/2015 19:00	0.6	18.3	1,294.0	0.6	0.9	1	1	0
03/17/2015 20:00	0.6	18.3	1,292.2	0.6	0.9	1	1	0
03/17/2015 21:00	0.6	18.3	1,292.2	0.6	0.9	1	1	0
03/17/2015 22:00	0.6	15.3	1,290.6	0.6	0.9	1	1	0
03/17/2015 23:00	0.6	14.3	1,286.6	0.6	0.9	1	1	0
Average/Sum#:	0.5	15.7	1,292.8	0.5	0.9	24 #	22 #	0 #
Minimum:	0.0	13.9	1,286.6	0.0	0.9	1	0	0
Maximum:	0.6	18.3	1,299.0	0.6	0.9	1	1	0
%SI	4.2	4.2	0.0	4.2	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/18/2015 00:00	0.6	14.2	1,285.9	0.6	0.9	1	1	0
03/18/2015 01:00	0.6	14.2	1,290.6	0.6	0.9	1	1	0
03/18/2015 02:00	0.6	14.2	1,301.4	0.6	0.9	1	1	0
03/18/2015 03:00	0.6	14.2	1,303.6	0.6	0.9	1	1	0
03/18/2015 04:00	0.6	14.2	1,304.1	0.6	0.9	1	1	0
03/18/2015 05:00	0.6	14.2	1,302.8	0.6	0.9	1	1	0
03/18/2015 06:00	0.6	14.2	1,302.1	0.6	0.9	1	1	0
03/18/2015 07:00	0.6	14.2	1,300.7	0.6	0.9	1	1	0
03/18/2015 08:00	0.6	14.2	1,300.5	0.6	0.9	1	1	0
03/18/2015 09:00	0.6	14.2	1,300.4	0.6	0.9	1	1	0
03/18/2015 10:00	0.6	14.2	1,301.2	0.6	0.9	1	1	0
03/18/2015 11:00	0.6	14.2	1,299.5	0.6	0.9	1	1	0
03/18/2015 12:00	0.6	14.2	1,296.2	0.6	0.9	1	1	0
03/18/2015 13:00	0.6	14.2	1,296.0	0.6	0.9	1	1	0
03/18/2015 14:00	0.6	14.2	1,312.2	0.6	0.9	1	1	0
03/18/2015 15:00	0.6	14.1	1,652.2	0.6	1.2	1	1	0
03/18/2015 16:00	0.6	14.1	1,677.7	0.6	1.2	1	1	0
03/18/2015 17:00	0.6	14.2	1,282.0	0.6	0.9	1	1	0
03/18/2015 18:00	0.6	14.2	1,283.9	0.6	0.9	1	1	0
03/18/2015 19:00	0.6	14.2	1,282.4	0.6	0.9	1	1	0
03/18/2015 20:00	0.6	14.2	1,286.6	0.6	0.9	1	1	0
03/18/2015 21:00	0.6	14.2	1,286.6	0.6	0.9	1	1	0
03/18/2015 22:00	0.6	14.1	1,283.2	0.6	0.9	1	1	0
03/18/2015 23:00	0.6	14.1	1,282.7	0.6	0.9	1	1	0
Average/Sum#:	0.6	14.2	1,325.6	0.6	0.9	24 #	24 #	0 #
Minimum:	0.6	14.1	1,282.0	0.6	0.9	1	1	0
Maximum:	0.6	14.2	1,677.7	0.6	1.2	1	1	0
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/19/2015 00:00	0.6	14.1	1,282.9	0.6	0.9	1	1	0
03/19/2015 01:00	0.6	14.1	1,281.1	0.6	0.9	1	1	0
03/19/2015 02:00	0.6	14.1	1,281.4	0.6	0.9	1	1	0
03/19/2015 03:00	0.6	14.1	1,283.3	0.6	0.9	1	1	0
03/19/2015 04:00	0.6	14.1	1,285.5	0.6	0.9	1	1	0
03/19/2015 05:00	0.4	14.0	1,292.6	0.4	0.9	1	1	0
03/19/2015 06:00	0.4	13.9	1,409.9	0.4	1.0	1	1	1
03/19/2015 07:00	-0.8	12.9	1,995.0	-0.4	1.4	1	1	1
03/19/2015 08:00	0.7	0.0	1,953.0	0.7	1.4	1	1	1
03/19/2015 09:00	0.7	0.0	1,942.5	0.7	1.4	1	1	1
03/19/2015 10:00	0.7	0.0	1,947.4	0.7	1.4	1	1	1
03/19/2015 11:00	0.7	0.0	1,976.3	0.7	1.4	1	1	1
03/19/2015 12:00	-0.7	12.6	2,039.6	-0.2	1.4	1	1	1
03/19/2015 13:00	-0.4	12.9	1,981.1	-0.1	1.4	1	1	1
03/19/2015 14:00	0.4	14.0	1,564.1	0.4	1.1	1	1	1
03/19/2015 15:00	0.5	14.0	1,320.8	0.5	0.9	1	1	0
03/19/2015 16:00	0.4	13.9	1,390.8	0.4	1.0	1	1	1
03/19/2015 17:00	-0.5	13.0	1,930.3	-0.2	1.4	1	1	1
03/19/2015 18:00	-0.5	12.8	1,972.5	-0.2	1.4	1	1	1
03/19/2015 19:00	-0.8	12.5	2,038.9	-0.4	1.4	1	1	1
03/19/2015 20:00	-0.2	13.0	1,929.7	0.1	1.4	1	1	1
03/19/2015 21:00	-0.1	13.3	1,743.0	0.1	1.2	1	1	1
03/19/2015 22:00	0.5	13.9	1,465.4	0.5	1.0	1	1	0
03/19/2015 23:00	0.4	13.9	1,307.0	0.4	0.9	1	1	0
Average/Sum#:	0.1	13.6	1,650.6	0.2	1.2	24 #	24 #	15 #
Minimum:	-0.8	12.5	1,281.1	-0.4	0.9	1	1	0
Maximum:	0.6	14.1	2,039.6	0.6	1.4	1	1	1
%SI	16.7	16.7	0.0	16.7	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/20/2015 00:00	0.4	13.9	1,451.1	0.4	1.0	1	1	0
03/20/2015 01:00	0.4	13.9	1,299.2	0.4	0.9	1	1	0
03/20/2015 02:00	0.4	13.8	1,675.1	0.4	1.2	1	1	0
03/20/2015 03:00	0.4	13.9	1,330.0	0.4	0.9	1	1	0
03/20/2015 04:00	-0.2	13.4	1,687.7	-0.1	1.2	1	1	1
03/20/2015 05:00	-0.7	12.9	2,009.9	-0.4	1.4	1	1	1
03/20/2015 06:00	-0.9	12.7	2,034.0	-0.5	1.4	1	1	1
03/20/2015 07:00	-0.8	13.0	1,974.4	-0.4	1.4	1	1	1
03/20/2015 08:00	-0.5	13.0	1,929.4	-0.2	1.4	1	1	1
03/20/2015 09:00	0.5	13.7	1,831.5	0.5	1.3	1	1	0
03/20/2015 10:00	0.4	13.7	1,828.5	0.4	1.3	1	1	0
03/20/2015 11:00	0.1	13.5	1,834.0	0.2	1.3	1	1	1
03/20/2015 12:00	-0.7	12.9	1,988.6	-0.4	1.4	1	1	1
03/20/2015 13:00	-0.7	12.8	2,010.0	-0.4	1.4	1	1	1
03/20/2015 14:00	-0.7	12.9	1,978.9	-0.4	1.4	1	1	1
03/20/2015 15:00	-0.7	12.9	1,975.9	-0.4	1.4	1	1	1
03/20/2015 16:00	-0.4	13.0	1,945.4	-0.1	1.4	1	1	1
03/20/2015 17:00	-0.4	13.0	1,944.2	-0.1	1.4	1	1	1
03/20/2015 18:00	-0.5	13.0	1,950.5	-0.2	1.4	1	1	1
03/20/2015 19:00	-0.4	13.0	1,944.3	-0.1	1.4	1	1	1
03/20/2015 20:00	-0.4	13.0	1,945.8	-0.1	1.4	1	1	1
03/20/2015 21:00	-0.4	13.1	1,953.4	-0.1	1.4	1	1	1
03/20/2015 22:00	0.1	13.5	1,733.9	0.2	1.2	1	1	1
03/20/2015 23:00	0.4	13.9	1,290.6	0.4	0.9	1	1	0
Average/Sum#:	-0.2	13.3	1,814.4	0.0	1.3	24 #	24 #	17 #
Minimum:	-0.9	12.7	1,290.6	-0.5	0.9	1	1	0
Maximum:	0.5	13.9	2,034.0	0.5	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/21/2015 00:00	0.4	13.9	1,286.0	0.4	0.9	1	1	0
03/21/2015 01:00	0.4	13.9	1,530.0	0.4	1.1	1	1	0
03/21/2015 02:00	0.4	13.9	1,338.3	0.4	0.9	1	1	0
03/21/2015 03:00	0.4	13.8	1,566.9	0.4	1.1	1	1	0
03/21/2015 04:00	0.4	13.9	1,584.6	0.4	1.1	1	1	0
03/21/2015 05:00	-0.1	13.7	1,499.0	0.1	1.0	1	1	1
03/21/2015 06:00	-0.7	13.0	1,992.7	-0.4	1.4	1	1	1
03/21/2015 07:00	-0.2	13.3	1,801.1	-0.1	1.3	1	1	1
03/21/2015 08:00	0.4	13.9	1,345.0	0.4	0.9	1	1	0
03/21/2015 09:00	0.4	13.9	1,307.2	0.4	0.9	1	1	0
03/21/2015 10:00	0.4	13.9	1,311.1	0.4	0.9	1	1	0
03/21/2015 11:00	0.4	13.9	1,312.9	0.4	0.9	1	1	0
03/21/2015 12:00	0.4	14.0	1,340.6	0.4	0.9	1	1	0
03/21/2015 13:00	0.4	14.0	1,310.0	0.4	0.9	1	1	0
03/21/2015 14:00	0.4	14.0	1,403.2	0.4	1.0	1	1	0
03/21/2015 15:00	0.4	13.9	1,489.2	0.4	1.0	1	1	0
03/21/2015 16:00	0.5	13.9	1,641.6	0.5	1.1	1	1	0
03/21/2015 17:00	-0.4	13.2	1,806.3	-0.1	1.3	1	1	1
03/21/2015 18:00	-0.8	12.7	1,989.9	-0.4	1.4	1	1	1
03/21/2015 19:00	-0.7	12.7	1,996.9	-0.2	1.4	1	1	1
03/21/2015 20:00	-0.8	12.6	2,016.1	-0.4	1.4	1	1	1
03/21/2015 21:00	-0.7	12.8	1,996.3	-0.4	1.4	1	1	1
03/21/2015 22:00	0.1	13.4	1,787.5	0.2	1.3	1	1	1
03/21/2015 23:00	0.5	13.8	1,758.3	0.5	1.2	1	1	0
Average/Sum#:	0.1	13.6	1,600.4	0.2	1.1	24 #	24 #	9 #
Minimum:	-0.8	12.6	1,286.0	-0.4	0.9	1	1	0
Maximum:	0.5	14.0	2,016.1	0.5	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/22/2015 00:00	0.5	13.7	1,798.3	0.5	1.3	1	1	0
03/22/2015 01:00	0.5	13.9	1,610.8	0.5	1.1	1	1	0
03/22/2015 02:00	0.5	13.8	1,654.1	0.5	1.2	1	1	0
03/22/2015 03:00	0.5	13.9	1,765.1	0.5	1.2	1	1	0
03/22/2015 04:00	0.4	13.9	1,523.6	0.4	1.1	1	1	0
03/22/2015 05:00	0.4	13.8	1,592.0	0.4	1.1	1	1	0
03/22/2015 06:00	0.4	13.8	1,634.2	0.4	1.1	1	1	0
03/22/2015 07:00	0.1	13.7	1,672.3	0.2	1.2	1	1	1
03/22/2015 08:00	-0.9	12.6	2,040.5	-0.5	1.4	1	1	1
03/22/2015 09:00	-0.8	12.6	2,017.3	-0.4	1.4	1	1	1
03/22/2015 10:00	-0.5	12.9	1,952.7	-0.2	1.4	1	1	1
03/22/2015 11:00	-0.7	12.9	1,960.7	-0.4	1.4	1	1	1
03/22/2015 12:00	-0.5	12.9	1,973.2	-0.2	1.4	1	1	1
03/22/2015 13:00	0.1	13.5	1,697.4	0.2	1.2	1	1	1
03/22/2015 14:00	0.5	13.9	1,609.8	0.5	1.1	1	1	0
03/22/2015 15:00	0.5	13.9	1,614.0	0.5	1.1	1	1	0
03/22/2015 16:00	0.5	13.9	1,567.0	0.5	1.1	1	1	0
03/22/2015 17:00	-0.2	13.4	1,713.6	-0.1	1.2	1	1	1
03/22/2015 18:00	-0.7	12.8	1,992.7	-0.4	1.4	1	1	1
03/22/2015 19:00	-0.5	12.9	1,977.8	-0.2	1.4	1	1	1
03/22/2015 20:00	-0.4	13.0	1,960.9	-0.1	1.4	1	1	1
03/22/2015 21:00	0.2	13.7	1,470.8	0.4	1.0	1	1	1
03/22/2015 22:00	0.4	13.9	1,304.5	0.4	0.9	1	1	0
03/22/2015 23:00	0.0	14.4	1,119.6	0.0	0.8	1	0	0
Average/Sum#:	0.0	13.5	1,717.6	0.1	1.2	24 #	23 #	12 #
Minimum:	-0.9	12.6	1,119.6	-0.5	0.8	1	0	0
Maximum:	0.5	14.4	2,040.5	0.5	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/23/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/24/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/25/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/26/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 03:00	0.0	17.5	470.3	0.0	0.3	1	0	0
03/26/2015 04:00	0.0	16.7	594.4	0.0	0.4	1	0	0
03/26/2015 05:00	0.0	16.0	758.2	0.0	0.5	1	0	0
03/26/2015 06:00	0.5	13.9	1,375.5	0.5	1.0	1	1	0
03/26/2015 07:00	0.5	13.9	1,375.7	0.5	1.0	1	1	0
03/26/2015 08:00	0.5	13.9	1,381.9	0.5	1.0	1	1	0
03/26/2015 09:00	0.5	14.0	1,381.1	0.5	1.0	1	1	0
03/26/2015 10:00	0.5	14.0	1,383.7	0.5	1.0	1	1	0
03/26/2015 11:00	0.5	14.0	1,382.6	0.5	1.0	1	1	0
03/26/2015 12:00	0.5	14.0	1,385.0	0.5	1.0	1	1	0
03/26/2015 13:00	0.5	13.8	1,658.7	0.5	1.2	1	1	0
03/26/2015 14:00	0.5	13.9	1,396.3	0.5	1.0	1	1	0
03/26/2015 15:00	0.5	14.0	1,403.5	0.5	1.0	1	1	0
03/26/2015 16:00	0.5	13.8	1,679.7	0.5	1.2	1	1	0
03/26/2015 17:00	0.5	13.7	1,772.2	0.5	1.2	1	1	0
03/26/2015 18:00	0.5	13.7	1,778.2	0.5	1.2	1	1	0
03/26/2015 19:00	0.5	13.7	1,781.5	0.5	1.2	1	1	0
03/26/2015 20:00	0.5	13.7	1,785.4	0.5	1.2	1	1	0
03/26/2015 21:00	0.5	13.9	1,361.7	0.5	1.0	1	1	0
03/26/2015 22:00	0.0	16.6	334.2	0.0	0.2	1	0	0
03/26/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.4	14.4	1,322.0	0.4	0.9	20 #	16 #	0 #
Minimum:	0.0	13.7	334.2	0.0	0.2	0	0	0
Maximum:	0.5	17.5	1,785.4	0.5	1.2	1	1	0
%SI	16.7	16.7	16.7	16.7	16.7	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/27/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 04:00	0.0	19.5	170.5	0.0	0.1	1	0	0
03/27/2015 05:00	0.0	15.8	806.7	0.0	0.6	1	0	0
03/27/2015 06:00	0.4	13.9	1,385.0	0.4	1.0	1	1	0
03/27/2015 07:00	0.4	13.9	1,379.3	0.4	1.0	1	1	0
03/27/2015 08:00	0.5	14.0	1,376.2	0.5	1.0	1	1	0
03/27/2015 09:00	0.5	14.0	1,376.0	0.5	1.0	1	1	0
03/27/2015 10:00	0.5	14.0	1,377.8	0.5	1.0	1	1	0
03/27/2015 11:00	0.5	14.0	1,383.3	0.5	1.0	1	1	0
03/27/2015 12:00	0.5	14.0	1,383.1	0.5	1.0	1	1	0
03/27/2015 13:00	0.5	14.0	1,380.2	0.5	1.0	1	1	0
03/27/2015 14:00	0.5	14.0	1,379.3	0.5	1.0	1	1	0
03/27/2015 15:00	0.5	14.0	1,378.5	0.5	1.0	1	1	0
03/27/2015 16:00	0.5	14.0	1,381.3	0.5	1.0	1	1	0
03/27/2015 17:00	0.5	13.9	1,566.7	0.5	1.1	1	1	0
03/27/2015 18:00	0.5	14.0	1,393.8	0.5	1.0	1	1	0
03/27/2015 19:00	0.5	14.0	1,373.3	0.5	1.0	1	1	0
03/27/2015 20:00	0.0	14.6	1,113.2	0.0	0.8	1	0	0
03/27/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.4	14.4	1,270.8	0.4	0.9	17 #	14 #	0 #
Minimum:	0.0	13.9	170.5	0.0	0.1	0	0	0
Maximum:	0.5	19.5	1,566.7	0.5	1.1	1	1	0
%SI	29.2	29.2	29.2	29.2	29.2	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/28/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/29/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/30/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 03:00	0.0	17.5	476.6	0.0	0.3	1	0	0
03/30/2015 04:00	0.0	15.7	715.5	0.0	0.5	1	0	0
03/30/2015 05:00	0.0	14.7	1,086.2	0.0	0.8	1	0	0
03/30/2015 06:00	0.6	14.0	1,380.6	0.6	1.0	1	1	0
03/30/2015 07:00	0.6	14.0	1,386.9	0.6	1.0	1	1	0
03/30/2015 08:00	0.6	14.0	1,384.8	0.6	1.0	1	1	0
03/30/2015 09:00	0.6	14.0	1,386.0	0.6	1.0	1	1	0
03/30/2015 10:00	0.6	14.0	1,378.1	0.6	1.0	1	1	0
03/30/2015 11:00	0.6	14.0	1,376.0	0.6	1.0	1	1	0
03/30/2015 12:00	0.6	13.9	1,510.8	0.6	1.1	1	1	0
03/30/2015 13:00	0.6	14.0	1,531.3	0.6	1.1	1	1	0
03/30/2015 14:00	0.6	13.9	1,513.1	0.6	1.1	1	1	0
03/30/2015 15:00	0.6	14.0	1,351.2	0.6	0.9	1	1	0
03/30/2015 16:00	0.6	14.0	1,334.9	0.6	0.9	1	1	0
03/30/2015 17:00	0.6	13.9	1,473.4	0.6	1.0	1	1	0
03/30/2015 18:00	0.6	13.8	1,692.8	0.6	1.2	1	1	0
03/30/2015 19:00	0.6	13.9	1,609.6	0.6	1.1	1	1	0
03/30/2015 20:00	0.0	14.9	974.0	0.0	0.7	1	0	0
03/30/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.5	14.3	1,309.0	0.5	0.9	18 #	14 #	0 #
Minimum:	0.0	13.8	476.6	0.0	0.3	0	0	0
Maximum:	0.6	17.5	1,692.8	0.6	1.2	1	1	0
%SI	25.0	25.0	25.0	25.0	25.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/31/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 04:00	0.0	17.2	519.8	0.0	0.4	1	0	0
03/31/2015 05:00	0.0	14.2	1,246.4	0.0	0.9	1	0	0
03/31/2015 06:00	0.6	13.9	1,379.2	0.6	1.0	1	1	0
03/31/2015 07:00	0.6	13.9	1,382.0	0.6	1.0	1	1	0
03/31/2015 08:00	0.6	13.9	1,384.5	0.6	1.0	1	1	0
03/31/2015 09:00	0.6	14.0	1,381.1	0.6	1.0	1	1	0
03/31/2015 10:00	0.6	14.0	1,377.2	0.6	1.0	1	1	0
03/31/2015 11:00	0.6	14.0	1,372.5	0.6	1.0	1	1	0
03/31/2015 12:00	0.6	14.0	1,377.5	0.6	1.0	1	1	0
03/31/2015 13:00	0.6	14.0	1,375.2	0.6	1.0	1	1	0
03/31/2015 14:00	0.6	14.0	1,383.2	0.6	1.0	1	1	0
03/31/2015 15:00	0.6	14.0	1,379.8	0.6	1.0	1	1	0
03/31/2015 16:00	0.6	14.0	1,522.7	0.6	1.1	1	1	0
03/31/2015 17:00	0.6	14.0	1,508.6	0.6	1.1	1	1	0
03/31/2015 18:00	0.6	14.0	1,595.8	0.6	1.1	1	1	0
03/31/2015 19:00	0.6	14.0	1,771.1	0.6	1.2	1	1	0
03/31/2015 20:00	0.6	13.9	1,619.3	0.6	1.1	1	1	0
03/31/2015 21:00	0.0	14.8	1,048.4	0.0	0.7	1	0	0
03/31/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.5	14.2	1,368.0	0.5	1.0	18 #	15 #	0 #
Minimum:	0.0	13.9	519.8	0.0	0.4	0	0	0
Maximum:	0.6	17.2	1,771.1	0.6	1.2	1	1	0
%SI	25.0	25.0	25.0	25.0	25.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/01/2015 00:00	0.1	12.0	2,299.0	0.2	0.7	1	1	1
01/01/2015 01:00	0.2	11.8	2,341.5	0.4	0.7	1	1	1
01/01/2015 02:00	0.1	11.8	2,341.2	0.2	0.7	1	1	1
01/01/2015 03:00	0.2	11.8	2,341.1	0.4	0.7	1	1	1
01/01/2015 04:00	0.1	12.0	2,297.3	0.2	0.7	1	1	1
01/01/2015 05:00	0.1	12.1	2,280.3	0.2	0.7	1	1	1
01/01/2015 06:00	0.1	11.8	2,365.0	0.2	0.7	1	1	1
01/01/2015 07:00	0.1	11.9	2,342.0	0.2	0.7	1	1	1
01/01/2015 08:00	0.1	13.1	1,992.7	0.2	0.6	1	1	1
01/01/2015 09:00	0.2	13.4	1,878.9	0.4	0.6	1	1	1
01/01/2015 10:00	0.4	13.7	1,458.9	0.4	0.4	1	1	1
01/01/2015 11:00	0.4	13.9	1,274.6	0.4	0.4	1	1	0
01/01/2015 12:00	0.4	13.9	1,277.7	0.4	0.4	1	1	0
01/01/2015 13:00	0.4	13.9	1,274.3	0.4	0.4	1	1	0
01/01/2015 14:00	0.4	13.9	1,272.3	0.4	0.4	1	1	0
01/01/2015 15:00	0.1	13.6	1,619.1	0.2	0.5	1	1	1
01/01/2015 16:00	-0.1	13.2	1,951.4	0.1	0.6	1	1	1
01/01/2015 17:00	-0.1	13.1	2,025.2	0.1	0.6	1	1	1
01/01/2015 18:00	-0.1	12.6	2,152.7	0.1	0.6	1	1	1
01/01/2015 19:00	0.1	11.7	2,355.1	0.2	0.7	1	1	1
01/01/2015 20:00	0.2	11.7	2,362.2	0.4	0.7	1	1	1
01/01/2015 21:00	0.1	11.8	2,343.4	0.2	0.7	1	1	1
01/01/2015 22:00	0.1	11.8	2,338.5	0.2	0.7	1	1	1
01/01/2015 23:00	0.1	12.9	2,078.7	0.2	0.6	1	1	1
Average/Sum#:	0.2	12.6	2,011.0	0.3	0.6	24 #	24 #	20 #
Minimum:	-0.1	11.7	1,272.3	0.1	0.4	1	1	0
Maximum:	0.4	13.9	2,365.0	0.4	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/02/2015 00:00	-0.1	13.1	2,036.3	0.1	0.6	1	1	1
01/02/2015 01:00	-0.1	12.7	2,128.7	0.1	0.6	1	1	1
01/02/2015 02:00	0.1	13.2	1,915.1	0.2	0.6	1	1	1
01/02/2015 03:00	-0.1	13.0	2,084.5	0.1	0.6	1	1	1
01/02/2015 04:00	-0.1	13.2	2,031.8	0.1	0.6	1	1	1
01/02/2015 05:00	-0.1	13.0	2,067.6	0.1	0.6	1	1	1
01/02/2015 06:00	-0.1	13.2	2,012.4	0.1	0.6	1	1	1
01/02/2015 07:00	-0.1	13.2	2,005.4	0.1	0.6	1	1	1
01/02/2015 08:00	-0.1	13.2	1,949.1	0.1	0.6	1	1	1
01/02/2015 09:00	0.1	13.2	1,885.3	0.2	0.6	1	1	1
01/02/2015 10:00	0.2	13.7	1,466.9	0.4	0.4	1	1	1
01/02/2015 11:00	0.4	13.8	1,312.5	0.4	0.4	1	1	0
01/02/2015 12:00	0.4	13.8	1,309.5	0.4	0.4	1	1	0
01/02/2015 13:00	0.4	13.8	1,314.1	0.4	0.4	1	1	0
01/02/2015 14:00	0.4	13.8	1,309.5	0.4	0.4	1	1	0
01/02/2015 15:00	0.1	13.6	1,646.5	0.2	0.5	1	1	1
01/02/2015 16:00	-0.1	13.2	1,924.6	0.1	0.6	1	1	1
01/02/2015 17:00	-0.1	12.1	2,238.4	0.2	0.7	1	1	1
01/02/2015 18:00	0.1	11.6	2,355.2	0.2	0.7	1	1	1
01/02/2015 19:00	0.2	11.6	2,358.6	0.4	0.7	1	1	1
01/02/2015 20:00	0.2	11.6	2,359.5	0.4	0.7	1	1	1
01/02/2015 21:00	0.2	11.6	2,360.9	0.4	0.7	1	1	1
01/02/2015 22:00	0.2	11.7	2,357.4	0.4	0.7	1	1	1
01/02/2015 23:00	0.1	12.0	2,282.8	0.2	0.7	1	1	1
Average/Sum#:	0.1	12.9	1,946.4	0.2	0.6	24 #	24 #	20 #
Minimum:	-0.1	11.6	1,309.5	0.1	0.4	1	1	0
Maximum:	0.4	13.8	2,360.9	0.4	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/03/2015 00:00	-0.1	12.3	2,219.8	0.2	0.7	1	1	1
01/03/2015 01:00	0.1	12.0	2,309.1	0.2	0.7	1	1	1
01/03/2015 02:00	-0.1	12.3	2,211.0	0.2	0.7	1	1	1
01/03/2015 03:00	0.1	12.0	2,308.0	0.2	0.7	1	1	1
01/03/2015 04:00	0.1	12.6	2,149.4	0.2	0.6	1	1	1
01/03/2015 05:00	-0.1	12.9	2,090.8	0.1	0.6	1	1	1
01/03/2015 06:00	-0.1	12.2	2,219.7	0.2	0.7	1	1	1
01/03/2015 07:00	-0.1	12.5	2,166.1	0.1	0.6	1	1	1
01/03/2015 08:00	0.1	13.2	1,936.2	0.2	0.6	1	1	1
01/03/2015 09:00	0.1	13.2	1,887.9	0.2	0.6	1	1	1
01/03/2015 10:00	0.1	13.2	1,886.6	0.2	0.6	1	1	1
01/03/2015 11:00	0.1	13.2	1,877.8	0.2	0.6	1	1	1
01/03/2015 12:00	0.4	13.8	1,360.0	0.4	0.4	1	1	0
01/03/2015 13:00	0.4	13.8	1,308.2	0.4	0.4	1	1	0
01/03/2015 14:00	0.4	13.8	1,306.2	0.4	0.4	1	1	0
01/03/2015 15:00	0.2	13.5	1,671.5	0.4	0.5	1	1	1
01/03/2015 16:00	-0.1	12.9	2,027.1	0.1	0.6	1	1	1
01/03/2015 17:00	-0.1	12.2	2,226.6	0.2	0.7	1	1	1
01/03/2015 18:00	0.1	11.7	2,350.9	0.2	0.7	1	1	1
01/03/2015 19:00	0.1	11.7	2,344.8	0.2	0.7	1	1	1
01/03/2015 20:00	0.1	11.7	2,345.4	0.2	0.7	1	1	1
01/03/2015 21:00	0.1	11.7	2,356.8	0.2	0.7	1	1	1
01/03/2015 22:00	0.1	11.9	2,301.5	0.2	0.7	1	1	1
01/03/2015 23:00	0.1	12.0	2,279.9	0.2	0.7	1	1	1
Average/Sum#:	0.1	12.6	2,047.6	0.2	0.6	24 #	24 #	21 #
Minimum:	-0.1	11.7	1,306.2	0.1	0.4	1	1	0
Maximum:	0.4	13.8	2,356.8	0.4	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/04/2015 00:00	0.1	12.1	2,280.6	0.2	0.7	1	1	1
01/04/2015 01:00	0.1	13.0	2,039.4	0.2	0.6	1	1	1
01/04/2015 02:00	0.1	13.1	2,024.6	0.2	0.6	1	1	1
01/04/2015 03:00	0.1	13.1	2,025.0	0.2	0.6	1	1	1
01/04/2015 04:00	0.1	13.2	2,004.2	0.2	0.6	1	1	1
01/04/2015 05:00	0.1	13.2	2,013.4	0.2	0.6	1	1	1
01/04/2015 06:00	-0.1	12.3	2,174.1	0.2	0.7	1	1	1
01/04/2015 07:00	0.1	11.9	2,306.5	0.2	0.7	1	1	1
01/04/2015 08:00	0.1	13.1	1,991.2	0.2	0.6	1	1	1
01/04/2015 09:00	0.1	13.2	1,936.9	0.2	0.6	1	1	1
01/04/2015 10:00	0.1	13.2	1,923.0	0.2	0.6	1	1	1
01/04/2015 11:00	0.1	13.2	1,896.1	0.2	0.6	1	1	1
01/04/2015 12:00	0.1	13.2	1,891.0	0.2	0.6	1	1	1
01/04/2015 13:00	0.1	13.2	1,915.3	0.2	0.6	1	1	1
01/04/2015 14:00	0.1	13.0	2,022.0	0.2	0.6	1	1	1
01/04/2015 15:00	0.1	12.9	2,038.2	0.2	0.6	1	1	1
01/04/2015 16:00	-0.1	12.9	2,047.1	0.1	0.6	1	1	1
01/04/2015 17:00	0.1	11.9	2,276.6	0.2	0.7	1	1	1
01/04/2015 18:00	0.2	11.6	2,343.9	0.4	0.7	1	1	1
01/04/2015 19:00	0.2	11.6	2,353.0	0.4	0.7	1	1	1
01/04/2015 20:00	0.2	11.6	2,352.1	0.4	0.7	1	1	1
01/04/2015 21:00	0.2	11.8	2,304.6	0.4	0.7	1	1	1
01/04/2015 22:00	0.2	11.9	2,285.6	0.4	0.7	1	1	1
01/04/2015 23:00	0.2	13.2	1,934.8	0.4	0.6	1	1	1
Average/Sum#:	0.1	12.6	2,099.1	0.2	0.6	24 #	24 #	24 #
Minimum:	-0.1	11.6	1,891.0	0.1	0.6	1	1	1
Maximum:	0.2	13.2	2,353.0	0.4	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/05/2015 00:00	0.1	13.2	1,892.1	0.2	0.6	1	1	1
01/05/2015 01:00	0.1	13.2	1,980.3	0.2	0.6	1	1	1
01/05/2015 02:00	0.1	13.2	1,888.4	0.2	0.6	1	1	1
01/05/2015 03:00	0.1	13.2	2,003.5	0.2	0.6	1	1	1
01/05/2015 04:00	0.1	13.2	1,932.5	0.2	0.6	1	1	1
01/05/2015 05:00	0.1	13.2	1,955.5	0.2	0.6	1	1	1
01/05/2015 06:00	-0.1	12.8	2,078.4	0.1	0.6	1	1	1
01/05/2015 07:00	0.1	11.8	2,336.1	0.2	0.7	1	1	1
01/05/2015 08:00	0.1	11.9	2,316.2	0.2	0.7	1	1	1
01/05/2015 09:00	0.2	13.1	1,957.3	0.4	0.6	1	1	1
01/05/2015 10:00	0.2	13.2	1,886.2	0.4	0.6	1	1	1
01/05/2015 11:00	0.1	13.3	1,885.9	0.2	0.6	1	1	1
01/05/2015 12:00	0.1	13.3	1,889.8	0.2	0.6	1	1	1
01/05/2015 13:00	0.1	13.3	1,895.4	0.2	0.6	1	1	1
01/05/2015 14:00	0.1	12.9	2,012.6	0.2	0.6	1	1	1
01/05/2015 15:00	0.1	13.0	1,994.1	0.2	0.6	1	1	1
01/05/2015 16:00	0.1	12.9	2,030.4	0.2	0.6	1	1	1
01/05/2015 17:00	0.1	12.0	2,275.6	0.2	0.7	1	1	1
01/05/2015 18:00	0.2	11.6	2,351.9	0.4	0.7	1	1	1
01/05/2015 19:00	0.2	11.6	2,358.0	0.4	0.7	1	1	1
01/05/2015 20:00	0.2	11.6	2,360.0	0.4	0.7	1	1	1
01/05/2015 21:00	0.1	12.1	2,231.4	0.2	0.7	1	1	1
01/05/2015 22:00	0.1	12.8	2,061.6	0.2	0.6	1	1	1
01/05/2015 23:00	0.1	13.4	1,724.6	0.2	0.5	1	1	1
Average/Sum#:	0.1	12.7	2,054.1	0.2	0.6	24 #	24 #	24 #
Minimum:	-0.1	11.6	1,724.6	0.1	0.5	1	1	1
Maximum:	0.2	13.4	2,360.0	0.4	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/06/2015 00:00	0.4	13.8	1,441.6	0.4	0.4	1	1	0
01/06/2015 01:00	0.4	13.8	1,656.6	0.4	0.5	1	1	0
01/06/2015 02:00	0.2	13.5	1,730.7	0.4	0.5	1	1	1
01/06/2015 03:00	0.1	13.2	1,888.6	0.2	0.6	1	1	1
01/06/2015 04:00	0.1	13.2	1,887.7	0.2	0.6	1	1	1
01/06/2015 05:00	0.1	13.2	1,947.4	0.2	0.6	1	1	1
01/06/2015 06:00	-0.1	12.5	2,095.1	0.1	0.6	1	1	1
01/06/2015 07:00	0.1	11.8	2,329.4	0.2	0.7	1	1	1
01/06/2015 08:00	0.1	12.5	2,139.9	0.2	0.6	1	1	1
01/06/2015 09:00	0.1	13.2	1,887.0	0.2	0.6	1	1	1
01/06/2015 10:00	0.2	13.6	1,562.1	0.4	0.5	1	1	1
01/06/2015 11:00	0.4	13.8	1,305.0	0.4	0.4	1	1	0
01/06/2015 12:00	0.4	13.8	1,305.6	0.4	0.4	1	1	0
01/06/2015 13:00	0.4	13.9	1,449.1	0.4	0.4	1	1	0
01/06/2015 14:00	0.4	13.9	1,311.3	0.4	0.4	1	1	0
01/06/2015 15:00	0.4	13.8	1,614.6	0.4	0.5	1	1	1
01/06/2015 16:00	0.1	13.2	1,908.0	0.2	0.6	1	1	1
01/06/2015 17:00	0.1	12.7	2,040.1	0.2	0.6	1	1	1
01/06/2015 18:00	0.1	12.4	2,084.2	0.2	0.6	1	1	1
01/06/2015 19:00	0.1	12.4	2,108.3	0.2	0.6	1	1	1
01/06/2015 20:00	0.1	12.2	2,160.6	0.2	0.6	1	1	1
01/06/2015 21:00	0.1	12.3	2,171.2	0.2	0.7	1	1	1
01/06/2015 22:00	0.1	12.5	2,108.7	0.2	0.6	1	1	1
01/06/2015 23:00	0.2	13.3	1,901.6	0.4	0.6	1	1	1
Average/Sum#:	0.2	13.1	1,834.8	0.3	0.6	24 #	24 #	18 #
Minimum:	-0.1	11.8	1,305.0	0.1	0.4	1	1	0
Maximum:	0.4	13.9	2,329.4	0.4	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/07/2015 00:00	0.1	13.1	1,945.2	0.2	0.6	1	1	1
01/07/2015 01:00	0.1	13.2	1,906.3	0.2	0.6	1	1	1
01/07/2015 02:00	0.1	13.2	1,923.1	0.2	0.6	1	1	1
01/07/2015 03:00	0.1	13.3	1,889.3	0.2	0.6	1	1	1
01/07/2015 04:00	0.1	13.0	1,993.2	0.2	0.6	1	1	1
01/07/2015 05:00	0.1	13.2	1,935.2	0.2	0.6	1	1	1
01/07/2015 06:00	-0.1	12.5	2,112.6	0.1	0.6	1	1	1
01/07/2015 07:00	0.1	11.9	2,288.8	0.2	0.7	1	1	1
01/07/2015 08:00	0.1	12.8	2,067.6	0.2	0.6	1	1	1
01/07/2015 09:00	0.1	13.2	1,928.9	0.2	0.6	1	1	1
01/07/2015 10:00	0.1	13.3	1,885.4	0.2	0.6	1	1	1
01/07/2015 11:00	0.1	13.4	1,858.2	0.2	0.6	1	1	1
01/07/2015 12:00	0.4	13.9	1,312.0	0.4	0.4	1	1	0
01/07/2015 13:00	0.4	13.9	1,497.3	0.4	0.4	1	1	0
01/07/2015 14:00	0.4	13.9	1,560.7	0.4	0.5	1	1	1
01/07/2015 15:00	-0.1	12.8	2,015.4	0.1	0.6	1	1	1
01/07/2015 16:00	0.1	12.8	1,994.3	0.2	0.6	1	1	1
01/07/2015 17:00	0.1	12.0	2,192.5	0.2	0.7	1	1	1
01/07/2015 18:00	0.1	12.5	2,078.5	0.2	0.6	1	1	1
01/07/2015 19:00	-0.1	12.7	2,037.9	0.1	0.6	1	1	1
01/07/2015 20:00	-0.1	12.7	2,040.6	0.1	0.6	1	1	1
01/07/2015 21:00	-0.1	12.7	2,047.6	0.1	0.6	1	1	1
01/07/2015 22:00	0.1	13.0	1,944.4	0.2	0.6	1	1	1
01/07/2015 23:00	0.1	13.3	1,887.1	0.2	0.6	1	1	1
Average/Sum#:	0.1	13.0	1,930.9	0.2	0.6	24 #	24 #	22 #
Minimum:	-0.1	11.9	1,312.0	0.1	0.4	1	1	0
Maximum:	0.4	13.9	2,288.8	0.4	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/08/2015 00:00	0.1	13.3	1,886.3	0.2	0.6	1	1	1
01/08/2015 01:00	0.1	13.3	1,885.6	0.2	0.6	1	1	1
01/08/2015 02:00	0.1	13.3	1,887.0	0.2	0.6	1	1	1
01/08/2015 03:00	0.1	13.3	1,888.3	0.2	0.6	1	1	1
01/08/2015 04:00	0.1	13.2	1,886.1	0.2	0.6	1	1	1
01/08/2015 05:00	0.1	13.2	1,879.9	0.2	0.6	1	1	1
01/08/2015 06:00	-0.1	12.3	2,109.2	0.2	0.6	1	1	1
01/08/2015 07:00	0.1	11.7	2,318.2	0.2	0.7	1	1	1
01/08/2015 08:00	0.2	11.8	2,301.3	0.4	0.7	1	1	1
01/08/2015 09:00	0.1	12.1	2,233.7	0.2	0.7	1	1	1
01/08/2015 10:00	-0.1	12.5	2,116.6	0.1	0.6	1	1	1
01/08/2015 11:00	0.1	12.8	2,026.6	0.2	0.6	1	1	1
01/08/2015 12:00	-0.1	12.7	2,054.9	0.1	0.6	1	1	1
01/08/2015 13:00	0.1	12.3	2,126.2	0.2	0.6	1	1	1
01/08/2015 14:00	0.1	12.4	2,109.7	0.2	0.6	1	1	1
01/08/2015 15:00	0.2	11.6	2,276.6	0.4	0.7	1	1	1
01/08/2015 16:00	0.1	12.5	2,058.6	0.2	0.6	1	1	1
01/08/2015 17:00	0.1	12.5	2,089.0	0.2	0.6	1	1	1
01/08/2015 18:00	0.1	12.4	2,095.0	0.2	0.6	1	1	1
01/08/2015 19:00	-0.1	12.7	2,042.7	0.1	0.6	1	1	1
01/08/2015 20:00	0.1	12.6	2,055.3	0.2	0.6	1	1	1
01/08/2015 21:00	0.1	12.3	2,140.2	0.2	0.6	1	1	1
01/08/2015 22:00	0.1	12.6	2,053.0	0.2	0.6	1	1	1
01/08/2015 23:00	0.1	13.0	1,941.6	0.2	0.6	1	1	1
Average/Sum#:	0.1	12.6	2,060.9	0.2	0.6	24 #	24 #	24 #
Minimum:	-0.1	11.6	1,879.9	0.1	0.6	1	1	1
Maximum:	0.2	13.3	2,318.2	0.4	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/09/2015 00:00	0.1	13.0	1,979.6	0.2	0.6	1	1	1
01/09/2015 01:00	0.1	13.2	1,923.9	0.2	0.6	1	1	1
01/09/2015 02:00	0.1	13.3	1,888.0	0.2	0.6	1	1	1
01/09/2015 03:00	0.1	13.1	1,952.8	0.2	0.6	1	1	1
01/09/2015 04:00	0.1	13.3	1,897.0	0.2	0.6	1	1	1
01/09/2015 05:00	0.1	13.2	1,937.4	0.2	0.6	1	1	1
01/09/2015 06:00	-0.1	12.9	1,984.6	0.1	0.6	1	1	1
01/09/2015 07:00	0.1	12.3	2,183.7	0.2	0.7	1	1	1
01/09/2015 08:00	0.2	11.7	2,304.7	0.4	0.7	1	1	1
01/09/2015 09:00	0.1	12.6	2,093.9	0.2	0.6	1	1	1
01/09/2015 10:00	0.1	12.0	2,248.5	0.2	0.7	1	1	1
01/09/2015 11:00	0.2	11.8	2,262.0	0.4	0.7	1	1	1
01/09/2015 12:00	0.1	13.2	1,915.8	0.2	0.6	1	1	1
01/09/2015 13:00	0.2	13.4	1,705.3	0.4	0.5	1	1	1
01/09/2015 14:00	0.4	13.9	1,392.2	0.4	0.4	1	1	0
01/09/2015 15:00	0.4	13.9	1,377.4	0.4	0.4	1	1	0
01/09/2015 16:00	0.1	13.4	1,697.9	0.2	0.5	1	1	1
01/09/2015 17:00	0.1	13.2	1,909.8	0.2	0.6	1	1	1
01/09/2015 18:00	0.1	13.3	1,812.1	0.2	0.5	1	1	1
01/09/2015 19:00	0.1	13.4	1,817.2	0.2	0.5	1	1	1
01/09/2015 20:00	0.1	13.3	1,899.5	0.2	0.6	1	1	1
01/09/2015 21:00	0.1	13.4	1,904.5	0.2	0.6	1	1	1
01/09/2015 22:00	0.1	13.2	1,945.2	0.2	0.6	1	1	1
01/09/2015 23:00	-0.1	13.0	2,005.0	0.1	0.6	1	1	1
Average/Sum#:	0.1	13.0	1,918.3	0.2	0.6	24 #	24 #	22 #
Minimum:	-0.1	11.7	1,377.4	0.1	0.4	1	1	0
Maximum:	0.4	13.9	2,304.7	0.4	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/10/2015 00:00	0.1	13.4	1,903.7	0.2	0.6	1	1	1
01/10/2015 01:00	0.1	13.5	1,875.5	0.2	0.6	1	1	1
01/10/2015 02:00	0.2	13.6	1,715.7	0.4	0.5	1	1	1
01/10/2015 03:00	0.4	13.8	1,361.5	0.4	0.4	1	1	0
01/10/2015 04:00	0.2	13.5	1,637.1	0.4	0.5	1	1	1
01/10/2015 05:00	-0.1	13.2	1,928.2	0.1	0.6	1	1	1
01/10/2015 06:00	-0.1	13.0	1,978.8	0.1	0.6	1	1	1
01/10/2015 07:00	-0.1	13.0	1,995.1	0.1	0.6	1	1	1
01/10/2015 08:00	0.1	13.2	1,910.8	0.2	0.6	1	1	1
01/10/2015 09:00	0.1	13.2	1,886.2	0.2	0.6	1	1	1
01/10/2015 10:00	-0.1	13.0	1,998.8	0.1	0.6	1	1	1
01/10/2015 11:00	0.1	11.9	2,260.3	0.2	0.7	1	1	1
01/10/2015 12:00	0.2	11.9	2,214.9	0.4	0.7	1	1	1
01/10/2015 13:00	0.1	13.0	1,969.1	0.2	0.6	1	1	1
01/10/2015 14:00	-0.1	12.7	2,032.5	0.1	0.6	1	1	1
01/10/2015 15:00	0.1	13.3	1,885.8	0.2	0.6	1	1	1
01/10/2015 16:00	0.1	13.2	1,925.6	0.2	0.6	1	1	1
01/10/2015 17:00	-0.1	12.5	2,092.3	0.1	0.6	1	1	1
01/10/2015 18:00	-0.1	12.8	2,020.8	0.1	0.6	1	1	1
01/10/2015 19:00	-0.1	12.6	2,094.7	0.1	0.6	1	1	1
01/10/2015 20:00	0.2	11.6	2,306.2	0.4	0.7	1	1	1
01/10/2015 21:00	0.1	12.2	2,150.3	0.2	0.6	1	1	1
01/10/2015 22:00	0.1	12.6	2,067.2	0.2	0.6	1	1	1
01/10/2015 23:00	0.1	13.1	1,935.0	0.2	0.6	1	1	1
Average/Sum#:	0.1	12.9	1,964.4	0.2	0.6	24 #	24 #	23 #
Minimum:	-0.1	11.6	1,361.5	0.1	0.4	1	1	0
Maximum:	0.4	13.8	2,306.2	0.4	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/11/2015 00:00	0.1	13.1	1,944.1	0.2	0.6	1	1	1
01/11/2015 01:00	0.1	13.1	1,952.4	0.2	0.6	1	1	1
01/11/2015 02:00	0.1	13.1	1,963.8	0.2	0.6	1	1	1
01/11/2015 03:00	0.1	13.3	1,892.7	0.2	0.6	1	1	1
01/11/2015 04:00	0.1	13.3	1,889.4	0.2	0.6	1	1	1
01/11/2015 05:00	0.1	13.2	1,919.4	0.2	0.6	1	1	1
01/11/2015 06:00	0.1	13.2	1,920.2	0.2	0.6	1	1	1
01/11/2015 07:00	0.1	13.1	1,962.7	0.2	0.6	1	1	1
01/11/2015 08:00	-0.1	12.5	2,140.3	0.1	0.6	1	1	1
01/11/2015 09:00	0.2	11.7	2,316.9	0.4	0.7	1	1	1
01/11/2015 10:00	0.2	11.7	2,303.2	0.4	0.7	1	1	1
01/11/2015 11:00	0.2	12.0	2,215.1	0.4	0.7	1	1	1
01/11/2015 12:00	0.1	12.8	2,017.8	0.2	0.6	1	1	1
01/11/2015 13:00	0.1	12.9	2,010.9	0.2	0.6	1	1	1
01/11/2015 14:00	0.1	13.1	1,937.3	0.2	0.6	1	1	1
01/11/2015 15:00	0.1	12.8	2,024.9	0.2	0.6	1	1	1
01/11/2015 16:00	0.1	13.2	1,918.6	0.2	0.6	1	1	1
01/11/2015 17:00	0.1	12.3	2,146.3	0.2	0.6	1	1	1
01/11/2015 18:00	0.1	12.2	2,155.7	0.2	0.6	1	1	1
01/11/2015 19:00	0.2	11.8	2,257.5	0.4	0.7	1	1	1
01/11/2015 20:00	0.1	12.2	2,162.7	0.2	0.6	1	1	1
01/11/2015 21:00	0.1	12.1	2,192.8	0.2	0.7	1	1	1
01/11/2015 22:00	0.1	13.0	1,978.7	0.2	0.6	1	1	1
01/11/2015 23:00	0.1	13.3	1,876.5	0.2	0.6	1	1	1
Average/Sum#:	0.1	12.7	2,045.8	0.2	0.6	24 #	24 #	24 #
Minimum:	-0.1	11.7	1,876.5	0.1	0.6	1	1	1
Maximum:	0.2	13.3	2,316.9	0.4	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/12/2015 00:00	-0.1	13.0	1,987.1	0.1	0.6	1	1	1
01/12/2015 01:00	0.1	13.2	1,924.1	0.2	0.6	1	1	1
01/12/2015 02:00	0.1	13.2	1,920.8	0.2	0.6	1	1	1
01/12/2015 03:00	0.1	13.1	1,972.9	0.2	0.6	1	1	1
01/12/2015 04:00	0.1	13.2	1,954.8	0.2	0.6	1	1	1
01/12/2015 05:00	0.1	13.1	1,942.6	0.2	0.6	1	1	1
01/12/2015 06:00	-0.1	12.9	2,030.5	0.1	0.6	1	1	1
01/12/2015 07:00	0.1	13.0	2,011.7	0.2	0.6	1	1	1
01/12/2015 08:00	0.1	13.0	2,013.3	0.2	0.6	1	1	1
01/12/2015 09:00	-0.1	12.5	2,141.9	0.1	0.6	1	1	1
01/12/2015 10:00	0.1	12.7	2,061.7	0.2	0.6	1	1	1
01/12/2015 11:00	0.1	13.3	1,894.3	0.2	0.6	1	1	1
01/12/2015 12:00	0.1	13.3	1,882.6	0.2	0.6	1	1	1
01/12/2015 13:00	0.1	13.3	1,880.5	0.2	0.6	1	1	1
01/12/2015 14:00	0.1	13.3	1,884.6	0.2	0.6	1	1	1
01/12/2015 15:00	0.1	13.3	1,884.5	0.2	0.6	1	1	1
01/12/2015 16:00	0.1	13.2	1,915.7	0.2	0.6	1	1	1
01/12/2015 17:00	0.1	12.9	2,002.9	0.2	0.6	1	1	1
01/12/2015 18:00	0.2	11.7	2,261.3	0.4	0.7	1	1	1
01/12/2015 19:00	0.2	11.6	2,303.2	0.4	0.7	1	1	1
01/12/2015 20:00	0.4	11.5	2,310.9	0.5	0.7	1	1	1
01/12/2015 21:00	0.2	11.9	2,235.6	0.4	0.7	1	1	1
01/12/2015 22:00	0.1	12.3	2,141.7	0.2	0.6	1	1	1
01/12/2015 23:00	0.1	13.1	1,967.0	0.2	0.6	1	1	1
Average/Sum#:	0.1	12.8	2,021.9	0.2	0.6	24 #	24 #	24 #
Minimum:	-0.1	11.5	1,880.5	0.1	0.6	1	1	1
Maximum:	0.4	13.3	2,310.9	0.5	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/13/2015 00:00	0.1	12.7	2,062.5	0.2	0.6	1	1	1
01/13/2015 01:00	0.1	12.8	2,050.6	0.2	0.6	1	1	1
01/13/2015 02:00	0.1	12.8	2,035.6	0.2	0.6	1	1	1
01/13/2015 03:00	0.1	13.0	2,004.6	0.2	0.6	1	1	1
01/13/2015 04:00	0.1	13.1	1,960.9	0.2	0.6	1	1	1
01/13/2015 05:00	0.1	13.3	1,891.0	0.2	0.6	1	1	1
01/13/2015 06:00	0.1	13.1	1,943.8	0.2	0.6	1	1	1
01/13/2015 07:00	-0.1	12.9	2,042.6	0.1	0.6	1	1	1
01/13/2015 08:00	0.1	13.1	1,965.8	0.2	0.6	1	1	1
01/13/2015 09:00	0.1	13.3	1,913.2	0.2	0.6	1	1	1
01/13/2015 10:00	0.1	12.8	2,039.6	0.2	0.6	1	1	1
01/13/2015 11:00	0.1	12.7	2,043.1	0.2	0.6	1	1	1
01/13/2015 12:00	0.1	13.1	1,953.7	0.2	0.6	1	1	1
01/13/2015 13:00	0.1	13.0	1,976.1	0.2	0.6	1	1	1
01/13/2015 14:00	0.1	13.1	1,947.8	0.2	0.6	1	1	1
01/13/2015 15:00	0.1	13.2	1,922.1	0.2	0.6	1	1	1
01/13/2015 16:00	0.1	13.2	1,924.3	0.2	0.6	1	1	1
01/13/2015 17:00	0.1	12.3	2,160.4	0.2	0.6	1	1	1
01/13/2015 18:00	0.2	11.6	2,299.7	0.4	0.7	1	1	1
01/13/2015 19:00	0.2	11.6	2,301.3	0.4	0.7	1	1	1
01/13/2015 20:00	0.4	11.6	2,301.7	0.5	0.7	1	1	1
01/13/2015 21:00	0.2	12.0	2,229.7	0.4	0.7	1	1	1
01/13/2015 22:00	0.2	12.3	2,158.0	0.4	0.6	1	1	1
01/13/2015 23:00	0.4	13.6	1,639.2	0.4	0.5	1	1	1
Average/Sum#:	0.1	12.8	2,032.0	0.3	0.6	24 #	24 #	24 #
Minimum:	-0.1	11.6	1,639.2	0.1	0.5	1	1	1
Maximum:	0.4	13.6	2,301.7	0.5	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/14/2015 00:00	0.4	13.9	1,344.2	0.4	0.4	1	1	0
01/14/2015 01:00	0.4	13.8	1,579.2	0.4	0.5	1	1	0
01/14/2015 02:00	0.2	13.6	1,715.6	0.4	0.5	1	1	1
01/14/2015 03:00	-0.1	13.1	1,964.5	0.1	0.6	1	1	1
01/14/2015 04:00	-0.1	13.2	1,997.0	0.1	0.6	1	1	1
01/14/2015 05:00	0.1	13.2	1,911.6	0.2	0.6	1	1	1
01/14/2015 06:00	-0.1	12.9	2,019.8	0.1	0.6	1	1	1
01/14/2015 07:00	0.1	11.9	2,306.2	0.2	0.7	1	1	1
01/14/2015 08:00	0.1	12.4	2,168.5	0.2	0.7	1	1	1
01/14/2015 09:00	0.1	13.1	2,001.5	0.2	0.6	1	1	1
01/14/2015 10:00	0.1	13.2	1,918.9	0.2	0.6	1	1	1
01/14/2015 11:00	0.1	13.2	1,886.6	0.2	0.6	1	1	1
01/14/2015 12:00	0.1	13.3	1,885.0	0.2	0.6	1	1	1
01/14/2015 13:00	0.1	13.3	1,887.1	0.2	0.6	1	1	1
01/14/2015 14:00	0.1	13.3	1,889.6	0.2	0.6	1	1	1
01/14/2015 15:00	0.1	13.3	1,896.7	0.2	0.6	1	1	1
01/14/2015 16:00	0.1	13.1	1,953.8	0.2	0.6	1	1	1
01/14/2015 17:00	-0.1	12.4	2,157.4	0.2	0.6	1	1	1
01/14/2015 18:00	0.2	11.5	2,335.8	0.4	0.7	1	1	1
01/14/2015 19:00	0.2	11.6	2,338.2	0.4	0.7	1	1	1
01/14/2015 20:00	0.2	11.6	2,338.1	0.4	0.7	1	1	1
01/14/2015 21:00	0.2	11.6	2,328.6	0.4	0.7	1	1	1
01/14/2015 22:00	0.1	12.5	2,122.0	0.2	0.6	1	1	1
01/14/2015 23:00	0.1	13.2	1,916.9	0.2	0.6	1	1	1
Average/Sum#:	0.1	12.8	1,994.3	0.2	0.6	24 #	24 #	22 #
Minimum:	-0.1	11.5	1,344.2	0.1	0.4	1	1	0
Maximum:	0.4	13.9	2,338.2	0.4	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	VOC, Ppmvdc	VOC, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/15/2015 00:00	0.1	13.2	1,941.1	0.2	0.6	1	1	1
01/15/2015 01:00	0.1	13.2	1,884.6	0.2	0.6	1	1	1
01/15/2015 02:00	0.1	13.2	1,883.9	0.2	0.6	1	1	1
01/15/2015 03:00	0.1	13.2	1,882.8	0.2	0.6	1	1	1
01/15/2015 04:00	0.1	13.2	1,885.5	0.2	0.6	1	1	1
01/15/2015 05:00	0.1	13.2	1,881.9	0.2	0.6	1	1	1
01/15/2015 06:00	-0.1	12.9	2,012.6	0.1	0.6	1	1	1
01/15/2015 07:00	0.1	12.1	2,257.7	0.2	0.7	1	1	1
01/15/2015 08:00	0.1	12.9	2,023.5	0.2	0.6	1	1	1
01/15/2015 09:00	0.2	13.5	1,581.9	0.4	0.5	1	1	1
01/15/2015 10:00	0.4	13.8	1,305.2	0.4	0.4	1	1	0
01/15/2015 11:00	0.4	13.8	1,305.8	0.4	0.4	1	1	0
01/15/2015 12:00	0.4	13.8	1,306.8	0.4	0.4	1	1	0
01/15/2015 13:00	0.4	13.8	1,302.6	0.4	0.4	1	1	0
01/15/2015 14:00	0.4	13.8	1,302.3	0.4	0.4	1	1	0
01/15/2015 15:00	0.4	13.8	1,334.7	0.4	0.4	1	1	0
01/15/2015 16:00	0.1	13.3	1,888.2	0.2	0.6	1	1	1
01/15/2015 17:00	-0.1	11.9	2,293.0	0.2	0.7	1	1	1
01/15/2015 18:00	0.2	11.5	2,381.3	0.4	0.7	1	1	1
01/15/2015 19:00	0.1	12.0	2,261.8	0.2	0.7	1	1	1
01/15/2015 20:00	-0.1	12.6	2,115.1	0.1	0.6	1	1	1
01/15/2015 21:00	-0.1	12.5	2,145.4	0.1	0.6	1	1	1
01/15/2015 22:00	0.1	12.3	2,197.9	0.2	0.7	1	1	1
01/15/2015 23:00	0.1	13.1	1,921.2	0.2	0.6	1	1	1
Average/Sum#:	0.2	13.0	1,845.7	0.3	0.6	24 #	24 #	18 #
Minimum:	-0.1	11.5	1,302.3	0.1	0.4	1	1	0
Maximum:	0.4	13.8	2,381.3	0.4	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/16/2015 00:00	0.1	13.2	1,884.9	0.2	0.6	1	1	1
01/16/2015 01:00	0.1	13.2	1,884.0	0.2	0.6	1	1	1
01/16/2015 02:00	0.1	13.2	1,882.7	0.2	0.6	1	1	1
01/16/2015 03:00	0.2	13.5	1,628.9	0.4	0.5	1	1	1
01/16/2015 04:00	0.4	13.8	1,322.8	0.4	0.4	1	1	0
01/16/2015 05:00	0.1	13.3	1,868.8	0.2	0.6	1	1	1
01/16/2015 06:00	-0.1	12.9	1,989.7	0.1	0.6	1	1	1
01/16/2015 07:00	-0.1	11.9	2,287.1	0.2	0.7	1	1	1
01/16/2015 08:00	0.1	13.1	1,967.7	0.2	0.6	1	1	1
01/16/2015 09:00	0.1	13.4	1,872.6	0.2	0.6	1	1	1
01/16/2015 10:00	0.1	13.4	1,890.3	0.2	0.6	1	1	1
01/16/2015 11:00	0.2	13.6	1,724.9	0.4	0.5	1	1	1
01/16/2015 12:00	0.4	14.0	1,427.2	0.4	0.4	1	1	0
01/16/2015 13:00	0.4	13.9	1,358.1	0.4	0.4	1	1	0
01/16/2015 14:00	0.4	13.9	1,364.7	0.4	0.4	1	1	0
01/16/2015 15:00	0.4	13.9	1,367.1	0.4	0.4	1	1	0
01/16/2015 16:00	0.0	15.0	901.1	0.0	0.3	1	0	0
01/16/2015 17:00	0.0	16.5	620.5	0.0	0.2	1	0	0
01/16/2015 18:00	0.0	13.9	1,281.1	0.0	0.4	1	0	0
01/16/2015 19:00	0.4	13.8	1,302.1	0.4	0.4	1	1	0
01/16/2015 20:00	0.4	13.8	1,299.3	0.4	0.4	1	1	0
01/16/2015 21:00	0.4	13.8	1,323.3	0.4	0.4	1	1	0
01/16/2015 22:00	0.4	13.8	1,526.1	0.4	0.5	1	1	0
01/16/2015 23:00	0.4	13.8	1,310.4	0.4	0.4	1	1	0
Average/Sum#:	0.2	13.7	1,553.6	0.3	0.5	24 #	21 #	11 #
Minimum:	-0.1	11.9	620.5	0.0	0.2	1	0	0
Maximum:	0.4	16.5	2,287.1	0.4	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/17/2015 00:00	0.4	13.8	1,330.0	0.4	0.4	1	1	0
01/17/2015 01:00	0.4	13.8	1,545.2	0.4	0.5	1	1	0
01/17/2015 02:00	0.4	13.8	1,432.3	0.4	0.4	1	1	0
01/17/2015 03:00	0.4	13.8	1,603.7	0.4	0.5	1	1	0
01/17/2015 04:00	0.4	13.8	1,321.5	0.4	0.4	1	1	0
01/17/2015 05:00	0.4	13.8	1,359.0	0.4	0.4	1	1	0
01/17/2015 06:00	-0.1	13.0	1,965.1	0.1	0.6	1	1	1
01/17/2015 07:00	-0.1	12.8	2,053.8	0.1	0.6	1	1	1
01/17/2015 08:00	-0.1	13.1	1,982.6	0.1	0.6	1	1	1
01/17/2015 09:00	0.1	13.4	1,918.0	0.2	0.6	1	1	1
01/17/2015 10:00	0.1	13.4	1,888.5	0.2	0.6	1	1	1
01/17/2015 11:00	0.1	13.4	1,879.0	0.2	0.6	1	1	1
01/17/2015 12:00	0.1	13.4	1,879.9	0.2	0.6	1	1	1
01/17/2015 13:00	0.2	13.6	1,581.8	0.4	0.5	1	1	1
01/17/2015 14:00	0.4	13.8	1,305.8	0.4	0.4	1	1	0
01/17/2015 15:00	0.4	13.8	1,306.1	0.4	0.4	1	1	0
01/17/2015 16:00	0.2	13.5	1,650.4	0.4	0.5	1	1	1
01/17/2015 17:00	0.1	13.0	1,990.4	0.2	0.6	1	1	1
01/17/2015 18:00	-0.1	12.0	2,259.6	0.2	0.7	1	1	1
01/17/2015 19:00	0.1	12.2	2,201.3	0.2	0.7	1	1	1
01/17/2015 20:00	0.1	12.8	2,056.7	0.2	0.6	1	1	1
01/17/2015 21:00	-0.1	12.7	2,099.3	0.1	0.6	1	1	1
01/17/2015 22:00	-0.1	12.7	2,091.7	0.1	0.6	1	1	1
01/17/2015 23:00	-0.1	12.6	2,106.3	0.1	0.6	1	1	1
Average/Sum#:	0.2	13.3	1,783.7	0.3	0.5	24 #	24 #	16 #
Minimum:	-0.1	12.0	1,305.8	0.1	0.4	1	1	0
Maximum:	0.4	13.8	2,259.6	0.4	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/18/2015 00:00	0.1	13.0	2,017.0	0.2	0.6	1	1	1
01/18/2015 01:00	0.1	13.3	1,801.5	0.2	0.5	1	1	1
01/18/2015 02:00	0.0	14.8	952.4	0.0	0.3	1	0	0
01/18/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/18/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/18/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/18/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/18/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/18/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/18/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/18/2015 10:00	0.0	17.7	457.8	0.0	0.1	1	0	0
01/18/2015 11:00	0.0	15.2	929.5	0.0	0.3	1	0	0
01/18/2015 12:00	0.4	13.8	1,334.9	0.4	0.4	1	1	0
01/18/2015 13:00	0.4	13.8	1,327.0	0.4	0.4	1	1	0
01/18/2015 14:00	0.4	13.8	1,542.7	0.4	0.5	1	1	0
01/18/2015 15:00	0.4	13.8	1,487.1	0.4	0.4	1	1	0
01/18/2015 16:00	0.4	13.8	1,437.5	0.4	0.4	1	1	1
01/18/2015 17:00	0.1	13.2	1,953.5	0.2	0.6	1	1	1
01/18/2015 18:00	0.1	13.0	2,015.2	0.2	0.6	1	1	1
01/18/2015 19:00	0.1	13.0	2,020.3	0.2	0.6	1	1	1
01/18/2015 20:00	0.1	13.1	1,999.4	0.2	0.6	1	1	1
01/18/2015 21:00	0.1	13.3	1,945.9	0.2	0.6	1	1	1
01/18/2015 22:00	0.4	13.8	1,478.9	0.4	0.4	1	1	0
01/18/2015 23:00	0.4	13.8	1,306.8	0.4	0.4	1	1	0
Average/Sum#:	0.2	13.9	1,529.8	0.2	0.5	17 #	14 #	8 #
Minimum:	0.0	13.0	457.8	0.0	0.1	0	0	0
Maximum:	0.4	17.7	2,020.3	0.4	0.6	1	1	1
%SI	29.2	29.2	29.2	29.2	29.2	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/19/2015 00:00	0.4	13.8	1,511.5	0.4	0.5	1	1	0
01/19/2015 01:00	0.4	13.8	1,356.5	0.4	0.4	1	1	0
01/19/2015 02:00	0.4	13.8	1,308.7	0.4	0.4	1	1	0
01/19/2015 03:00	0.3	13.8	1,580.3	0.4	0.5	1	1	0
01/19/2015 04:00	0.1	13.2	1,910.6	0.2	0.6	1	1	1
01/19/2015 05:00	0.1	13.0	2,011.5	0.2	0.6	1	1	1
01/19/2015 06:00	0.1	13.0	2,016.0	0.2	0.6	1	1	1
01/19/2015 07:00	0.1	13.0	2,021.1	0.2	0.6	1	1	1
01/19/2015 08:00	0.1	13.1	1,955.5	0.2	0.6	1	1	1
01/19/2015 09:00	0.1	13.2	1,906.7	0.2	0.6	1	1	1
01/19/2015 10:00	0.1	13.2	1,928.6	0.2	0.6	1	1	1
01/19/2015 11:00	0.1	13.2	1,897.0	0.2	0.6	1	1	1
01/19/2015 12:00	0.1	13.3	1,901.8	0.2	0.6	1	1	1
01/19/2015 13:00	0.1	13.3	1,894.8	0.2	0.6	1	1	1
01/19/2015 14:00	0.1	13.3	1,896.4	0.2	0.6	1	1	1
01/19/2015 15:00	0.1	13.2	1,918.5	0.2	0.6	1	1	1
01/19/2015 16:00	0.1	13.1	1,949.6	0.2	0.6	1	1	1
01/19/2015 17:00	0.1	13.1	1,951.6	0.2	0.6	1	1	1
01/19/2015 18:00	0.1	13.1	1,977.3	0.2	0.6	1	1	1
01/19/2015 19:00	0.1	12.9	2,008.8	0.2	0.6	1	1	1
01/19/2015 20:00	0.1	12.9	2,025.6	0.2	0.6	1	1	1
01/19/2015 21:00	0.1	12.9	2,038.7	0.2	0.6	1	1	1
01/19/2015 22:00	0.1	13.1	1,955.1	0.2	0.6	1	1	1
01/19/2015 23:00	0.1	13.2	1,897.8	0.2	0.6	1	1	1
Average/Sum#:	0.1	13.2	1,867.5	0.2	0.6	24 #	24 #	20 #
Minimum:	0.1	12.9	1,308.7	0.2	0.4	1	1	0
Maximum:	0.4	13.8	2,038.7	0.4	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/20/2015 00:00	0.1	13.1	1,978.5	0.2	0.6	1	1	1
01/20/2015 01:00	0.1	13.2	1,878.2	0.2	0.6	1	1	1
01/20/2015 02:00	0.1	13.2	1,882.2	0.2	0.6	1	1	1
01/20/2015 03:00	0.1	13.2	1,881.8	0.2	0.6	1	1	1
01/20/2015 04:00	0.1	13.2	1,883.4	0.2	0.6	1	1	1
01/20/2015 05:00	0.1	13.2	1,881.3	0.2	0.6	1	1	1
01/20/2015 06:00	-0.1	12.9	2,029.5	0.1	0.6	1	1	1
01/20/2015 07:00	-0.1	12.9	2,068.5	0.1	0.6	1	1	1
01/20/2015 08:00	-0.1	12.8	2,079.8	0.1	0.6	1	1	1
01/20/2015 09:00	-0.1	12.8	2,077.0	0.1	0.6	1	1	1
01/20/2015 10:00	-0.1	12.9	2,048.4	0.1	0.6	1	1	1
01/20/2015 11:00	-0.1	12.8	2,061.0	0.1	0.6	1	1	1
01/20/2015 12:00	-0.1	12.7	2,066.4	0.1	0.6	1	1	1
01/20/2015 13:00	-0.1	12.8	2,039.8	0.1	0.6	1	1	1
01/20/2015 14:00	0.1	12.8	2,039.0	0.2	0.6	1	1	1
01/20/2015 15:00	-0.1	12.7	2,052.8	0.1	0.6	1	1	1
01/20/2015 16:00	0.1	13.2	1,911.3	0.2	0.6	1	1	1
01/20/2015 17:00	0.1	13.1	1,938.6	0.2	0.6	1	1	1
01/20/2015 18:00	-0.1	12.7	2,071.3	0.1	0.6	1	1	1
01/20/2015 19:00	-0.1	12.6	2,085.6	0.1	0.6	1	1	1
01/20/2015 20:00	-0.1	12.8	2,043.3	0.1	0.6	1	1	1
01/20/2015 21:00	-0.1	12.8	2,065.2	0.1	0.6	1	1	1
01/20/2015 22:00	-0.1	13.0	2,019.1	0.1	0.6	1	1	1
01/20/2015 23:00	0.1	13.3	1,881.6	0.2	0.6	1	1	1
Average/Sum#:	0.0	12.9	1,998.5	0.1	0.6	24 #	24 #	24 #
Minimum:	-0.1	12.6	1,878.2	0.1	0.6	1	1	1
Maximum:	0.1	13.3	2,085.6	0.2	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/21/2015 00:00	0.2	13.4	1,894.9	0.4	0.6	1	1	1
01/21/2015 01:00	0.2	13.5	1,884.1	0.4	0.6	1	1	1
01/21/2015 02:00	0.2	13.4	1,919.0	0.4	0.6	1	1	1
01/21/2015 03:00	0.2	13.4	1,876.6	0.4	0.6	1	1	1
01/21/2015 04:00	0.1	13.4	1,890.7	0.2	0.6	1	1	1
01/21/2015 05:00	0.1	13.2	1,887.1	0.2	0.6	1	1	1
01/21/2015 06:00	0.1	13.1	1,969.1	0.2	0.6	1	1	1
01/21/2015 07:00	-0.1	13.0	2,031.5	0.1	0.6	1	1	1
01/21/2015 08:00	-0.1	12.8	2,076.7	0.1	0.6	1	1	1
01/21/2015 09:00	-0.1	12.8	2,051.3	0.1	0.6	1	1	1
01/21/2015 10:00	0.1	13.1	1,973.1	0.2	0.6	1	1	1
01/21/2015 11:00	0.1	13.1	1,972.6	0.2	0.6	1	1	1
01/21/2015 12:00	0.1	13.1	1,949.1	0.2	0.6	1	1	1
01/21/2015 13:00	0.1	13.3	1,890.3	0.2	0.6	1	1	1
01/21/2015 14:00	0.1	13.3	1,887.2	0.2	0.6	1	1	1
01/21/2015 15:00	0.1	13.1	1,954.9	0.2	0.6	1	1	1
01/21/2015 16:00	0.1	12.8	2,016.9	0.2	0.6	1	1	1
01/21/2015 17:00	-0.1	12.8	2,042.6	0.1	0.6	1	1	1
01/21/2015 18:00	-0.1	12.6	2,079.0	0.1	0.6	1	1	1
01/21/2015 19:00	-0.1	12.7	2,073.2	0.1	0.6	1	1	1
01/21/2015 20:00	-0.1	12.8	2,045.1	0.1	0.6	1	1	1
01/21/2015 21:00	-0.1	12.9	2,033.8	0.1	0.6	1	1	1
01/21/2015 22:00	0.1	13.1	1,958.0	0.2	0.6	1	1	1
01/21/2015 23:00	0.2	13.6	1,572.1	0.4	0.5	1	1	1
Average/Sum#:	0.1	13.1	1,955.4	0.2	0.6	24 #	24 #	24 #
Minimum:	-0.1	12.6	1,572.1	0.1	0.5	1	1	1
Maximum:	0.2	13.6	2,079.0	0.4	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/22/2015 00:00	0.4	13.8	1,407.9	0.4	0.4	1	1	0
01/22/2015 01:00	0.4	13.8	1,303.9	0.4	0.4	1	1	0
01/22/2015 02:00	0.4	13.8	1,315.9	0.4	0.4	1	1	0
01/22/2015 03:00	0.2	13.7	1,575.4	0.4	0.5	1	1	1
01/22/2015 04:00	-0.1	13.2	1,904.1	0.1	0.6	1	1	1
01/22/2015 05:00	0.1	13.2	1,888.8	0.2	0.6	1	1	1
01/22/2015 06:00	-0.1	13.1	1,956.7	0.1	0.6	1	1	1
01/22/2015 07:00	-0.1	12.9	2,060.8	0.1	0.6	1	1	1
01/22/2015 08:00	-0.1	13.0	2,030.0	0.1	0.6	1	1	1
01/22/2015 09:00	-0.1	12.9	2,055.6	0.1	0.6	1	1	1
01/22/2015 10:00	0.1	13.2	1,896.3	0.2	0.6	1	1	1
01/22/2015 11:00	0.1	13.2	1,887.9	0.2	0.6	1	1	1
01/22/2015 12:00	0.1	13.2	1,891.5	0.2	0.6	1	1	1
01/22/2015 13:00	0.2	13.7	1,512.7	0.4	0.5	1	1	1
01/22/2015 14:00	0.4	13.8	1,649.9	0.4	0.5	1	1	0
01/22/2015 15:00	0.2	13.5	1,751.6	0.4	0.5	1	1	1
01/22/2015 16:00	0.1	13.2	1,895.4	0.2	0.6	1	1	1
01/22/2015 17:00	-0.1	13.0	2,006.9	0.1	0.6	1	1	1
01/22/2015 18:00	-0.1	12.8	2,081.1	0.1	0.6	1	1	1
01/22/2015 19:00	-0.1	12.8	2,071.7	0.1	0.6	1	1	1
01/22/2015 20:00	-0.1	13.0	2,034.4	0.1	0.6	1	1	1
01/22/2015 21:00	0.1	13.1	1,992.6	0.2	0.6	1	1	1
01/22/2015 22:00	0.1	13.2	1,966.2	0.2	0.6	1	1	1
01/22/2015 23:00	0.1	13.3	1,912.5	0.2	0.6	1	1	1
Average/Sum#:	0.1	13.3	1,835.4	0.2	0.6	24 #	24 #	20 #
Minimum:	-0.1	12.8	1,303.9	0.1	0.4	1	1	0
Maximum:	0.4	13.8	2,081.1	0.4	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/23/2015 00:00	0.1	13.2	1,970.8	0.2	0.6	1	1	1
01/23/2015 01:00	0.2	13.4	1,928.1	0.4	0.6	1	1	1
01/23/2015 02:00	0.1	13.0	2,024.1	0.2	0.6	1	1	1
01/23/2015 03:00	0.1	13.0	2,002.3	0.2	0.6	1	1	1
01/23/2015 04:00	0.1	13.2	1,944.4	0.2	0.6	1	1	1
01/23/2015 05:00	0.1	13.2	1,934.5	0.2	0.6	1	1	1
01/23/2015 06:00	0.1	13.0	1,992.7	0.2	0.6	1	1	1
01/23/2015 07:00	-0.1	12.9	2,060.6	0.1	0.6	1	1	1
01/23/2015 08:00	-0.1	12.9	2,046.5	0.1	0.6	1	1	1
01/23/2015 09:00	0.1	13.2	1,954.6	0.2	0.6	1	1	1
01/23/2015 10:00	0.2	13.2	1,926.9	0.4	0.6	1	1	1
01/23/2015 11:00	0.2	13.3	1,885.6	0.4	0.6	1	1	1
01/23/2015 12:00	0.2	13.4	1,886.1	0.4	0.6	1	1	1
01/23/2015 13:00	0.2	13.3	1,883.8	0.4	0.6	1	1	1
01/23/2015 14:00	0.2	13.3	1,880.4	0.4	0.6	1	1	1
01/23/2015 15:00	0.2	13.2	1,896.7	0.4	0.6	1	1	1
01/23/2015 16:00	0.1	13.0	1,938.1	0.2	0.6	1	1	1
01/23/2015 17:00	0.1	13.0	1,950.0	0.2	0.6	1	1	1
01/23/2015 18:00	0.1	12.6	2,067.0	0.2	0.6	1	1	1
01/23/2015 19:00	0.1	12.5	2,091.4	0.2	0.6	1	1	1
01/23/2015 20:00	0.1	12.6	2,084.6	0.2	0.6	1	1	1
01/23/2015 21:00	0.1	12.7	2,047.6	0.2	0.6	1	1	1
01/23/2015 22:00	0.1	12.8	2,043.3	0.2	0.6	1	1	1
01/23/2015 23:00	0.2	13.1	1,936.4	0.4	0.6	1	1	1
Average/Sum#:	0.1	13.0	1,974.0	0.3	0.6	24 #	24 #	24 #
Minimum:	-0.1	12.5	1,880.4	0.1	0.6	1	1	1
Maximum:	0.2	13.4	2,091.4	0.4	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/24/2015 00:00	0.2	13.4	1,885.1	0.4	0.6	1	1	1
01/24/2015 01:00	0.2	13.3	1,917.3	0.4	0.6	1	1	1
01/24/2015 02:00	0.1	13.4	1,885.8	0.2	0.6	1	1	1
01/24/2015 03:00	0.1	13.3	1,889.2	0.2	0.6	1	1	1
01/24/2015 04:00	0.1	13.0	1,979.2	0.2	0.6	1	1	1
01/24/2015 05:00	0.1	12.9	2,028.5	0.2	0.6	1	1	1
01/24/2015 06:00	-0.1	12.8	2,024.7	0.1	0.6	1	1	1
01/24/2015 07:00	-0.1	12.8	2,054.8	0.1	0.6	1	1	1
01/24/2015 08:00	0.1	13.1	1,973.9	0.2	0.6	1	1	1
01/24/2015 09:00	0.1	13.2	1,935.3	0.2	0.6	1	1	1
01/24/2015 10:00	0.1	13.3	1,879.4	0.2	0.6	1	1	1
01/24/2015 11:00	0.1	13.3	1,885.2	0.2	0.6	1	1	1
01/24/2015 12:00	0.2	13.3	1,876.1	0.4	0.6	1	1	1
01/24/2015 13:00	0.2	13.3	1,849.0	0.4	0.6	1	1	1
01/24/2015 14:00	0.5	13.9	1,308.9	0.5	0.4	1	1	0
01/24/2015 15:00	0.5	13.9	1,306.5	0.5	0.4	1	1	0
01/24/2015 16:00	0.5	13.9	1,447.2	0.5	0.4	1	1	0
01/24/2015 17:00	0.1	13.0	1,829.7	0.2	0.5	1	1	1
01/24/2015 18:00	0.1	12.3	2,098.9	0.2	0.6	1	1	1
01/24/2015 19:00	-0.1	12.5	2,075.7	0.1	0.6	1	1	1
01/24/2015 20:00	-0.1	12.8	2,027.5	0.1	0.6	1	1	1
01/24/2015 21:00	-0.1	12.8	2,048.9	0.1	0.6	1	1	1
01/24/2015 22:00	-0.1	12.8	2,063.1	0.1	0.6	1	1	1
01/24/2015 23:00	-0.1	12.9	2,013.4	0.1	0.6	1	1	1
Average/Sum#:	0.1	13.1	1,886.8	0.2	0.6	24 #	24 #	21 #
Minimum:	-0.1	12.3	1,306.5	0.1	0.4	1	1	0
Maximum:	0.5	13.9	2,098.9	0.5	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/25/2015 00:00	0.4	13.8	1,473.3	0.4	0.4	1	1	0
01/25/2015 01:00	0.0	15.7	647.0	0.0	0.2	1	0	0
01/25/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.2	14.8	1,060.2	0.2	0.3	2 #	1 #	0 #
Minimum:	0.0	13.8	647.0	0.0	0.2	0	0	0
Maximum:	0.4	15.7	1,473.3	0.4	0.4	1	1	0
%SI	91.7	91.7	91.7	91.7	91.7	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	VOC, Ppmvdc	VOC, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/26/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/27/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2015 02:00	0.0	17.4	507.7	0.0	0.2	1	0	0
01/27/2015 03:00	0.0	15.6	735.7	0.0	0.2	1	0	0
01/27/2015 04:00	0.0	16.6	443.8	0.0	0.1	1	0	0
01/27/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2015 07:00	0.0	18.0	416.6	0.0	0.1	1	0	0
01/27/2015 08:00	0.0	17.0	527.3	0.0	0.2	1	0	0
01/27/2015 09:00	0.0	17.3	523.9	0.0	0.2	1	0	0
01/27/2015 10:00	0.0	0.0	1,230.9	0.0	0.4	1	0	0
01/27/2015 11:00	0.4	0.0	1,300.1	0.5	0.4	1	1	0
01/27/2015 12:00	0.4	0.0	1,305.9	0.5	0.4	1	1	0
01/27/2015 13:00	0.5	13.8	1,555.0	0.5	0.5	1	1	0
01/27/2015 14:00	0.5	13.8	1,299.8	0.5	0.4	1	1	0
01/27/2015 15:00	0.4	13.7	1,570.7	0.4	0.5	1	1	1
01/27/2015 16:00	0.5	13.8	1,326.6	0.5	0.4	1	1	0
01/27/2015 17:00	0.2	13.5	1,653.6	0.4	0.5	1	1	1
01/27/2015 18:00	0.1	12.8	2,023.3	0.2	0.6	1	1	1
01/27/2015 19:00	0.1	12.9	2,013.8	0.2	0.6	1	1	1
01/27/2015 20:00	0.1	13.0	1,992.7	0.2	0.6	1	1	1
01/27/2015 21:00	0.1	13.0	1,992.8	0.2	0.6	1	1	1
01/27/2015 22:00	0.2	13.0	1,959.8	0.4	0.6	1	1	1
01/27/2015 23:00	0.4	13.6	1,557.6	0.4	0.5	1	1	1
Average/Sum#:	0.2	14.6	1,296.9	0.2	0.4	20 #	13 #	8 #
Minimum:	0.0	12.8	416.6	0.0	0.1	0	0	0
Maximum:	0.5	18.0	2,023.3	0.5	0.6	1	1	1
%SI	16.7	29.2	16.7	29.2	16.7	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/28/2015 00:00	0.5	13.9	1,281.1	0.5	0.4	1	1	0
01/28/2015 01:00	0.5	13.8	1,281.3	0.5	0.4	1	1	0
01/28/2015 02:00	0.5	13.8	1,275.8	0.5	0.4	1	1	0
01/28/2015 03:00	0.5	13.9	1,274.9	0.5	0.4	1	1	0
01/28/2015 04:00	0.5	13.8	1,283.6	0.5	0.4	1	1	0
01/28/2015 05:00	0.4	13.6	1,610.7	0.4	0.5	1	1	1
01/28/2015 06:00	0.2	13.3	1,879.4	0.4	0.6	1	1	1
01/28/2015 07:00	0.2	12.9	2,014.6	0.4	0.6	1	1	1
01/28/2015 08:00	0.2	13.3	1,892.4	0.4	0.6	1	1	1
01/28/2015 09:00	0.4	13.5	1,859.7	0.4	0.6	1	1	1
01/28/2015 10:00	0.4	13.5	1,857.1	0.4	0.6	1	1	1
01/28/2015 11:00	0.4	13.6	1,732.8	0.4	0.5	1	1	1
01/28/2015 12:00	0.5	13.9	1,272.7	0.5	0.4	1	1	0
01/28/2015 13:00	0.5	13.8	1,608.5	0.5	0.5	1	1	0
01/28/2015 14:00	0.4	13.3	1,843.2	0.4	0.6	1	1	1
01/28/2015 15:00	0.2	12.3	2,082.7	0.4	0.6	1	1	1
01/28/2015 16:00	0.2	12.7	2,017.7	0.4	0.6	1	1	1
01/28/2015 17:00	0.2	12.9	1,954.0	0.4	0.6	1	1	1
01/28/2015 18:00	0.2	12.7	2,020.5	0.4	0.6	1	1	1
01/28/2015 19:00	0.2	12.7	2,024.9	0.4	0.6	1	1	1
01/28/2015 20:00	0.2	13.0	1,954.0	0.4	0.6	1	1	1
01/28/2015 21:00	0.2	13.0	1,969.0	0.4	0.6	1	1	1
01/28/2015 22:00	0.2	13.1	1,941.3	0.4	0.6	1	1	1
01/28/2015 23:00	0.2	13.3	1,859.4	0.4	0.6	1	1	1
Average/Sum#:	0.3	13.3	1,741.3	0.4	0.5	24 #	24 #	17 #
Minimum:	0.2	12.3	1,272.7	0.4	0.4	1	1	0
Maximum:	0.5	13.9	2,082.7	0.5	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/29/2015 00:00	0.2	13.3	1,857.5	0.4	0.6	1	1	1
01/29/2015 01:00	0.2	13.2	1,861.6	0.4	0.6	1	1	1
01/29/2015 02:00	0.2	13.3	1,865.9	0.4	0.6	1	1	1
01/29/2015 03:00	0.2	13.2	1,860.1	0.4	0.6	1	1	1
01/29/2015 04:00	0.2	13.2	1,867.9	0.4	0.6	1	1	1
01/29/2015 05:00	0.2	13.2	1,860.0	0.4	0.6	1	1	1
01/29/2015 06:00	0.1	13.0	1,947.7	0.2	0.6	1	1	1
01/29/2015 07:00	0.1	12.9	2,038.0	0.2	0.6	1	1	1
01/29/2015 08:00	0.2	13.0	1,995.7	0.4	0.6	1	1	1
01/29/2015 09:00	0.2	13.0	1,987.3	0.4	0.6	1	1	1
01/29/2015 10:00	0.2	13.3	1,879.3	0.4	0.6	1	1	1
01/29/2015 11:00	0.4	13.5	1,855.3	0.4	0.6	1	1	1
01/29/2015 12:00	0.4	13.4	1,858.6	0.4	0.6	1	1	1
01/29/2015 13:00	0.4	13.4	1,855.4	0.4	0.6	1	1	1
01/29/2015 14:00	0.4	13.4	1,868.3	0.4	0.6	1	1	1
01/29/2015 15:00	0.2	12.5	2,046.6	0.4	0.6	1	1	1
01/29/2015 16:00	0.2	13.0	1,940.0	0.4	0.6	1	1	1
01/29/2015 17:00	0.2	13.2	1,901.0	0.4	0.6	1	1	1
01/29/2015 18:00	0.2	12.7	2,013.7	0.4	0.6	1	1	1
01/29/2015 19:00	0.2	12.6	2,035.8	0.4	0.6	1	1	1
01/29/2015 20:00	0.2	12.6	2,054.2	0.4	0.6	1	1	1
01/29/2015 21:00	0.2	12.9	1,989.1	0.4	0.6	1	1	1
01/29/2015 22:00	0.2	13.2	1,909.8	0.4	0.6	1	1	1
01/29/2015 23:00	0.2	13.3	1,858.9	0.4	0.6	1	1	1
Average/Sum#:	0.2	13.1	1,925.3	0.4	0.6	24 #	24 #	24 #
Minimum:	0.1	12.5	1,855.3	0.2	0.6	1	1	1
Maximum:	0.4	13.5	2,054.2	0.4	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	VOC, Ppmvdc	VOC, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/30/2015 00:00	0.2	13.3	1,864.5	0.4	0.6	1	1	1
01/30/2015 01:00	0.2	13.3	1,863.3	0.4	0.6	1	1	1
01/30/2015 02:00	0.2	13.3	1,862.1	0.4	0.6	1	1	1
01/30/2015 03:00	0.2	13.3	1,861.1	0.4	0.6	1	1	1
01/30/2015 04:00	0.2	13.3	1,864.1	0.4	0.6	1	1	1
01/30/2015 05:00	0.2	13.3	1,867.7	0.4	0.6	1	1	1
01/30/2015 06:00	0.2	13.2	1,910.6	0.4	0.6	1	1	1
01/30/2015 07:00	0.1	12.9	2,001.3	0.2	0.6	1	1	1
01/30/2015 08:00	0.2	12.9	1,999.4	0.4	0.6	1	1	1
01/30/2015 09:00	0.2	13.1	1,939.8	0.4	0.6	1	1	1
01/30/2015 10:00	0.4	13.3	1,876.1	0.4	0.6	1	1	1
01/30/2015 11:00	0.4	13.4	1,852.2	0.4	0.6	1	1	1
01/30/2015 12:00	0.5	13.7	1,626.0	0.5	0.5	1	1	1
01/30/2015 13:00	0.2	13.1	1,910.8	0.4	0.6	1	1	1
01/30/2015 14:00	0.2	13.0	1,922.4	0.4	0.6	1	1	1
01/30/2015 15:00	0.2	13.0	1,913.5	0.4	0.6	1	1	1
01/30/2015 16:00	0.2	12.7	1,993.1	0.4	0.6	1	1	1
01/30/2015 17:00	0.2	13.2	1,890.1	0.4	0.6	1	1	1
01/30/2015 18:00	0.2	13.3	1,870.1	0.4	0.6	1	1	1
01/30/2015 19:00	0.2	13.4	1,863.0	0.4	0.6	1	1	1
01/30/2015 20:00	0.2	13.4	1,867.6	0.4	0.6	1	1	1
01/30/2015 21:00	0.2	13.4	1,867.1	0.4	0.6	1	1	1
01/30/2015 22:00	0.4	13.6	1,694.5	0.4	0.5	1	1	1
01/30/2015 23:00	0.6	13.9	1,277.0	0.6	0.4	1	1	0
Average/Sum#:	0.3	13.3	1,852.4	0.4	0.6	24 #	24 #	23 #
Minimum:	0.1	12.7	1,277.0	0.2	0.4	1	1	0
Maximum:	0.6	13.9	2,001.3	0.6	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/31/2015 00:00	0.5	13.8	1,684.7	0.5	0.5	1	1	0
01/31/2015 01:00	0.5	13.9	1,790.4	0.5	0.5	1	1	0
01/31/2015 02:00	0.5	13.9	1,791.2	0.5	0.5	1	1	0
01/31/2015 03:00	0.5	13.9	1,708.9	0.5	0.5	1	1	0
01/31/2015 04:00	0.5	13.9	1,329.1	0.5	0.4	1	1	0
01/31/2015 05:00	0.4	13.6	1,766.0	0.4	0.5	1	1	1
01/31/2015 06:00	0.2	13.4	1,869.9	0.4	0.6	1	1	1
01/31/2015 07:00	0.2	13.4	1,872.8	0.4	0.6	1	1	1
01/31/2015 08:00	0.2	13.4	1,870.8	0.4	0.6	1	1	1
01/31/2015 09:00	0.2	13.4	1,867.2	0.4	0.6	1	1	1
01/31/2015 10:00	0.2	13.4	1,868.2	0.4	0.6	1	1	1
01/31/2015 11:00	0.6	13.9	1,366.2	0.6	0.4	1	1	0
01/31/2015 12:00	0.6	13.9	1,299.9	0.6	0.4	1	1	0
01/31/2015 13:00	0.6	13.9	1,330.0	0.6	0.4	1	1	0
01/31/2015 14:00	0.5	13.9	1,520.8	0.5	0.5	1	1	0
01/31/2015 15:00	0.5	13.9	1,672.6	0.5	0.5	1	1	1
01/31/2015 16:00	0.4	13.7	1,701.5	0.4	0.5	1	1	1
01/31/2015 17:00	0.5	13.7	1,593.3	0.5	0.5	1	1	1
01/31/2015 18:00	0.2	12.6	2,023.9	0.4	0.6	1	1	1
01/31/2015 19:00	0.2	12.5	2,040.8	0.4	0.6	1	1	1
01/31/2015 20:00	0.2	12.5	2,046.5	0.4	0.6	1	1	1
01/31/2015 21:00	0.2	12.5	2,055.4	0.4	0.6	1	1	1
01/31/2015 22:00	0.2	12.6	2,051.5	0.4	0.6	1	1	1
01/31/2015 23:00	0.2	13.1	1,965.6	0.4	0.6	1	1	1
Average/Sum#:	0.4	13.4	1,753.6	0.5	0.5	24 #	24 #	15 #
Minimum:	0.2	12.5	1,299.9	0.4	0.4	1	1	0
Maximum:	0.6	13.9	2,055.4	0.6	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/01/2015 00:00	0.1	12.8	2,023.1	0.2	0.6	1	1	1
02/01/2015 01:00	0.5	13.7	1,626.2	0.5	0.5	1	1	1
02/01/2015 02:00	0.0	15.7	598.6	0.0	0.2	1	0	0
02/01/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2015 14:00	0.0	17.5	486.5	0.0	0.1	1	0	0
02/01/2015 15:00	0.0	14.5	1,147.9	0.0	0.3	1	0	0
02/01/2015 16:00	0.4	13.4	1,781.9	0.4	0.5	1	1	1
02/01/2015 17:00	0.2	13.2	1,910.7	0.4	0.6	1	1	1
02/01/2015 18:00	0.2	12.8	2,004.9	0.4	0.6	1	1	1
02/01/2015 19:00	0.1	12.6	2,037.3	0.2	0.6	1	1	1
02/01/2015 20:00	0.2	12.6	2,045.1	0.4	0.6	1	1	1
02/01/2015 21:00	0.2	12.7	2,027.2	0.4	0.6	1	1	1
02/01/2015 22:00	0.2	13.1	1,939.9	0.4	0.6	1	1	1
02/01/2015 23:00	0.4	13.2	1,852.3	0.4	0.6	1	1	1
Average/Sum#:	0.2	13.7	1,652.4	0.3	0.5	13 #	10 #	10 #
Minimum:	0.0	12.6	486.5	0.0	0.1	0	0	0
Maximum:	0.5	17.5	2,045.1	0.5	0.6	1	1	1
%SI	45.8	45.8	45.8	45.8	45.8	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/02/2015 00:00	0.2	13.2	1,867.1	0.4	0.6	1	1	1
02/02/2015 01:00	0.1	12.8	2,011.0	0.2	0.6	1	1	1
02/02/2015 02:00	0.2	13.0	1,965.7	0.4	0.6	1	1	1
02/02/2015 03:00	0.4	13.2	1,869.5	0.4	0.6	1	1	1
02/02/2015 04:00	0.2	13.2	1,860.0	0.4	0.6	1	1	1
02/02/2015 05:00	0.2	13.2	1,886.8	0.4	0.6	1	1	1
02/02/2015 06:00	0.2	13.2	1,924.5	0.4	0.6	1	1	1
02/02/2015 07:00	0.2	13.0	1,981.7	0.4	0.6	1	1	1
02/02/2015 08:00	0.4	13.2	1,865.5	0.4	0.6	1	1	1
02/02/2015 09:00	0.2	13.2	1,858.2	0.4	0.6	1	1	1
02/02/2015 10:00	0.4	13.3	1,855.9	0.4	0.6	1	1	1
02/02/2015 11:00	0.4	13.3	1,868.8	0.4	0.6	1	1	1
02/02/2015 12:00	0.2	13.1	1,922.0	0.4	0.6	1	1	1
02/02/2015 13:00	0.4	13.3	1,866.9	0.4	0.6	1	1	1
02/02/2015 14:00	0.4	13.3	1,848.2	0.4	0.6	1	1	1
02/02/2015 15:00	0.4	13.3	1,848.8	0.4	0.6	1	1	1
02/02/2015 16:00	0.2	13.1	1,913.6	0.4	0.6	1	1	1
02/02/2015 17:00	0.2	13.0	1,945.8	0.4	0.6	1	1	1
02/02/2015 18:00	0.1	12.7	2,025.3	0.2	0.6	1	1	1
02/02/2015 19:00	0.2	12.7	2,021.5	0.4	0.6	1	1	1
02/02/2015 20:00	0.1	12.7	2,027.5	0.2	0.6	1	1	1
02/02/2015 21:00	0.2	12.9	1,980.5	0.4	0.6	1	1	1
02/02/2015 22:00	0.2	13.0	1,925.8	0.4	0.6	1	1	1
02/02/2015 23:00	0.4	13.2	1,842.7	0.4	0.6	1	1	1
Average/Sum#:	0.3	13.1	1,916.0	0.4	0.6	24 #	24 #	24 #
Minimum:	0.1	12.7	1,842.7	0.2	0.6	1	1	1
Maximum:	0.4	13.3	2,027.5	0.4	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/03/2015 00:00	0.5	13.8	1,331.7	0.5	0.4	1	1	0
02/03/2015 01:00	0.5	13.8	1,289.7	0.5	0.4	1	1	0
02/03/2015 02:00	0.5	13.8	1,291.0	0.5	0.4	1	1	0
02/03/2015 03:00	0.5	13.8	1,368.6	0.5	0.4	1	1	0
02/03/2015 04:00	0.4	13.5	1,706.1	0.4	0.5	1	1	1
02/03/2015 05:00	0.2	13.2	1,854.4	0.4	0.6	1	1	1
02/03/2015 06:00	0.2	13.2	1,880.7	0.4	0.6	1	1	1
02/03/2015 07:00	0.2	13.2	1,846.9	0.4	0.6	1	1	1
02/03/2015 08:00	0.2	13.2	1,849.7	0.4	0.6	1	1	1
02/03/2015 09:00	0.2	13.2	1,852.7	0.4	0.6	1	1	1
02/03/2015 10:00	0.4	13.4	1,678.9	0.4	0.5	1	1	1
02/03/2015 11:00	0.6	13.8	1,264.1	0.6	0.4	1	1	0
02/03/2015 12:00	0.6	13.8	1,301.0	0.6	0.4	1	1	0
02/03/2015 13:00	0.5	13.8	1,359.7	0.5	0.4	1	1	0
02/03/2015 14:00	0.5	13.8	1,698.6	0.5	0.5	1	1	0
02/03/2015 15:00	0.5	13.8	1,576.5	0.5	0.5	1	1	0
02/03/2015 16:00	0.4	13.5	1,641.0	0.4	0.5	1	1	1
02/03/2015 17:00	0.2	13.2	1,890.8	0.4	0.6	1	1	1
02/03/2015 18:00	0.1	12.5	2,047.3	0.2	0.6	1	1	1
02/03/2015 19:00	0.2	12.7	2,009.1	0.4	0.6	1	1	1
02/03/2015 20:00	0.2	12.8	1,996.4	0.4	0.6	1	1	1
02/03/2015 21:00	0.2	13.0	1,943.6	0.4	0.6	1	1	1
02/03/2015 22:00	0.2	13.0	1,820.2	0.4	0.5	1	1	1
02/03/2015 23:00	0.6	13.8	1,316.7	0.6	0.4	1	1	0
Average/Sum#:	0.4	13.4	1,659.0	0.4	0.5	24 #	24 #	14 #
Minimum:	0.1	12.5	1,264.1	0.2	0.4	1	1	0
Maximum:	0.6	13.8	2,047.3	0.6	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/04/2015 00:00	0.5	13.8	1,692.4	0.5	0.5	1	1	0
02/04/2015 01:00	0.5	13.8	1,488.5	0.5	0.4	1	1	0
02/04/2015 02:00	0.5	13.8	1,286.8	0.5	0.4	1	1	0
02/04/2015 03:00	0.5	13.8	1,290.3	0.5	0.4	1	1	0
02/04/2015 04:00	0.5	13.8	1,386.6	0.5	0.4	1	1	0
02/04/2015 05:00	0.4	13.5	1,611.9	0.4	0.5	1	1	1
02/04/2015 06:00	0.2	13.1	1,915.4	0.4	0.6	1	1	1
02/04/2015 07:00	0.2	13.2	1,896.3	0.4	0.6	1	1	1
02/04/2015 08:00	0.5	13.8	1,324.6	0.5	0.4	1	1	0
02/04/2015 09:00	0.5	13.8	1,291.7	0.5	0.4	1	1	0
02/04/2015 10:00	0.5	13.8	1,293.6	0.5	0.4	1	1	0
02/04/2015 11:00	0.5	13.8	1,294.7	0.5	0.4	1	1	0
02/04/2015 12:00	0.5	13.8	1,294.4	0.5	0.4	1	1	0
02/04/2015 13:00	0.5	13.8	1,294.7	0.5	0.4	1	1	0
02/04/2015 14:00	0.5	13.8	1,295.7	0.5	0.4	1	1	0
02/04/2015 15:00	0.5	13.8	1,354.0	0.5	0.4	1	1	0
02/04/2015 16:00	0.1	13.2	1,867.2	0.2	0.6	1	1	1
02/04/2015 17:00	0.1	13.0	1,940.3	0.2	0.6	1	1	1
02/04/2015 18:00	0.1	12.5	2,037.2	0.2	0.6	1	1	1
02/04/2015 19:00	0.1	12.6	2,020.9	0.2	0.6	1	1	1
02/04/2015 20:00	0.1	12.7	2,000.1	0.2	0.6	1	1	1
02/04/2015 21:00	0.1	12.7	2,018.0	0.2	0.6	1	1	1
02/04/2015 22:00	0.1	12.8	1,979.2	0.2	0.6	1	1	1
02/04/2015 23:00	0.4	13.5	1,556.6	0.4	0.5	1	1	1
Average/Sum#:	0.4	13.4	1,601.3	0.4	0.5	24 #	24 #	11 #
Minimum:	0.1	12.5	1,286.8	0.2	0.4	1	1	0
Maximum:	0.5	13.8	2,037.2	0.5	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/05/2015 00:00	0.5	13.8	1,286.3	0.5	0.4	1	1	0
02/05/2015 01:00	0.5	13.8	1,288.3	0.5	0.4	1	1	0
02/05/2015 02:00	0.5	13.8	1,292.2	0.5	0.4	1	1	0
02/05/2015 03:00	0.5	13.8	1,292.2	0.5	0.4	1	1	0
02/05/2015 04:00	0.5	13.8	1,419.6	0.5	0.4	1	1	0
02/05/2015 05:00	0.4	13.6	1,594.8	0.4	0.5	1	1	1
02/05/2015 06:00	0.1	13.1	1,907.2	0.2	0.6	1	1	1
02/05/2015 07:00	0.1	13.0	1,954.5	0.2	0.6	1	1	1
02/05/2015 08:00	0.5	13.7	1,424.7	0.5	0.4	1	1	1
02/05/2015 09:00	0.5	13.8	1,288.0	0.5	0.4	1	1	0
02/05/2015 10:00	0.5	13.8	1,301.5	0.5	0.4	1	1	0
02/05/2015 11:00	0.5	13.8	1,325.4	0.5	0.4	1	1	0
02/05/2015 12:00	0.5	13.8	1,352.8	0.5	0.4	1	1	0
02/05/2015 13:00	0.5	13.8	1,599.2	0.5	0.5	1	1	0
02/05/2015 14:00	0.5	13.8	1,658.1	0.5	0.5	1	1	0
02/05/2015 15:00	0.5	13.9	1,610.4	0.5	0.5	1	1	0
02/05/2015 16:00	0.2	13.3	1,844.4	0.4	0.6	1	1	1
02/05/2015 17:00	0.2	13.2	1,877.5	0.4	0.6	1	1	1
02/05/2015 18:00	-0.1	12.8	1,994.4	0.1	0.6	1	1	1
02/05/2015 19:00	0.1	12.9	1,974.3	0.2	0.6	1	1	1
02/05/2015 20:00	0.1	12.8	1,991.3	0.2	0.6	1	1	1
02/05/2015 21:00	0.1	12.9	1,956.9	0.2	0.6	1	1	1
02/05/2015 22:00	0.5	13.8	1,456.7	0.5	0.4	1	1	0
02/05/2015 23:00	0.5	13.8	1,287.3	0.5	0.4	1	1	0
Average/Sum#:	0.4	13.5	1,582.4	0.4	0.5	24 #	24 #	10 #
Minimum:	-0.1	12.8	1,286.3	0.1	0.4	1	1	0
Maximum:	0.5	13.9	1,994.4	0.5	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/06/2015 00:00	0.5	13.8	1,301.6	0.5	0.4	1	1	0
02/06/2015 01:00	0.5	13.8	1,290.9	0.5	0.4	1	1	0
02/06/2015 02:00	0.5	13.8	1,283.6	0.5	0.4	1	1	0
02/06/2015 03:00	0.5	13.8	1,287.9	0.5	0.4	1	1	0
02/06/2015 04:00	0.4	13.9	1,333.5	0.4	0.4	1	1	0
02/06/2015 05:00	0.1	13.3	1,787.5	0.2	0.5	1	1	1
02/06/2015 06:00	-0.1	12.8	1,932.7	0.1	0.6	1	1	1
02/06/2015 07:00	0.1	13.1	1,905.9	0.2	0.6	1	1	1
02/06/2015 08:00	0.2	13.3	1,847.7	0.4	0.6	1	1	1
02/06/2015 09:00	0.5	13.7	1,649.9	0.5	0.5	1	1	1
02/06/2015 10:00	0.2	13.3	1,829.2	0.4	0.5	1	1	1
02/06/2015 11:00	0.2	13.3	1,850.2	0.4	0.6	1	1	1
02/06/2015 12:00	0.4	13.7	1,604.6	0.4	0.5	1	1	1
02/06/2015 13:00	0.2	13.2	1,855.2	0.4	0.6	1	1	1
02/06/2015 14:00	0.2	13.2	1,848.4	0.4	0.6	1	1	1
02/06/2015 15:00	0.2	13.3	1,851.3	0.4	0.6	1	1	1
02/06/2015 16:00	0.2	13.2	1,881.7	0.4	0.6	1	1	1
02/06/2015 17:00	0.1	12.6	2,008.5	0.2	0.6	1	1	1
02/06/2015 18:00	0.2	12.3	2,049.4	0.4	0.6	1	1	1
02/06/2015 19:00	0.2	12.5	2,008.1	0.4	0.6	1	1	1
02/06/2015 20:00	0.2	12.4	2,033.9	0.4	0.6	1	1	1
02/06/2015 21:00	0.2	13.0	1,904.6	0.4	0.6	1	1	1
02/06/2015 22:00	0.5	13.8	1,371.6	0.5	0.4	1	1	0
02/06/2015 23:00	0.5	13.8	1,585.6	0.5	0.5	1	1	0
Average/Sum#:	0.3	13.3	1,721.0	0.4	0.5	24 #	24 #	17 #
Minimum:	-0.1	12.3	1,283.6	0.1	0.4	1	1	0
Maximum:	0.5	13.9	2,049.4	0.5	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/07/2015 00:00	0.5	13.8	1,310.3	0.5	0.4	1	1	0
02/07/2015 01:00	0.5	13.8	1,444.0	0.5	0.4	1	1	0
02/07/2015 02:00	0.5	13.9	1,394.7	0.5	0.4	1	1	0
02/07/2015 03:00	0.5	13.9	1,341.8	0.5	0.4	1	1	0
02/07/2015 04:00	0.5	13.9	1,344.2	0.5	0.4	1	1	0
02/07/2015 05:00	0.5	13.9	1,328.8	0.5	0.4	1	1	0
02/07/2015 06:00	0.5	13.9	1,330.4	0.5	0.4	1	1	0
02/07/2015 07:00	0.5	13.8	1,314.2	0.5	0.4	1	1	0
02/07/2015 08:00	0.5	13.8	1,285.5	0.5	0.4	1	1	0
02/07/2015 09:00	0.5	13.8	1,304.4	0.5	0.4	1	1	0
02/07/2015 10:00	0.5	13.8	1,353.4	0.5	0.4	1	1	0
02/07/2015 11:00	0.5	13.8	1,333.4	0.5	0.4	1	1	0
02/07/2015 12:00	0.5	13.8	1,293.5	0.5	0.4	1	1	0
02/07/2015 13:00	0.5	13.8	1,299.9	0.5	0.4	1	1	0
02/07/2015 14:00	0.5	13.8	1,342.0	0.5	0.4	1	1	0
02/07/2015 15:00	0.5	13.8	1,319.2	0.5	0.4	1	1	0
02/07/2015 16:00	0.4	13.5	1,642.3	0.4	0.5	1	1	1
02/07/2015 17:00	0.2	13.1	1,883.7	0.4	0.6	1	1	1
02/07/2015 18:00	0.1	12.4	2,040.2	0.2	0.6	1	1	1
02/07/2015 19:00	0.2	12.8	1,951.8	0.4	0.6	1	1	1
02/07/2015 20:00	0.1	12.5	2,019.7	0.2	0.6	1	1	1
02/07/2015 21:00	0.4	13.4	1,725.2	0.4	0.5	1	1	1
02/07/2015 22:00	0.5	13.8	1,382.4	0.5	0.4	1	1	0
02/07/2015 23:00	0.5	13.8	1,285.1	0.5	0.4	1	1	0
Average/Sum#:	0.4	13.6	1,469.6	0.5	0.4	24 #	24 #	6 #
Minimum:	0.1	12.4	1,285.1	0.2	0.4	1	1	0
Maximum:	0.5	13.9	2,040.2	0.5	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/08/2015 00:00	0.5	13.8	1,308.0	0.5	0.4	1	1	0
02/08/2015 01:00	0.5	13.8	1,341.8	0.5	0.4	1	1	0
02/08/2015 02:00	0.5	13.8	1,335.8	0.5	0.4	1	1	0
02/08/2015 03:00	0.5	13.8	1,289.7	0.5	0.4	1	1	0
02/08/2015 04:00	0.5	13.8	1,288.7	0.5	0.4	1	1	0
02/08/2015 05:00	0.5	13.8	1,285.6	0.5	0.4	1	1	0
02/08/2015 06:00	0.5	13.8	1,326.6	0.5	0.4	1	1	0
02/08/2015 07:00	0.5	13.8	1,312.4	0.5	0.4	1	1	0
02/08/2015 08:00	0.5	13.8	1,283.3	0.5	0.4	1	1	0
02/08/2015 09:00	0.5	13.8	1,285.3	0.5	0.4	1	1	0
02/08/2015 10:00	0.5	13.8	1,285.8	0.5	0.4	1	1	0
02/08/2015 11:00	0.5	13.8	1,288.9	0.5	0.4	1	1	0
02/08/2015 12:00	0.5	13.8	1,314.7	0.5	0.4	1	1	0
02/08/2015 13:00	0.5	13.8	1,322.9	0.5	0.4	1	1	0
02/08/2015 14:00	0.5	13.8	1,297.0	0.5	0.4	1	1	0
02/08/2015 15:00	0.5	13.8	1,297.8	0.5	0.4	1	1	0
02/08/2015 16:00	0.2	13.2	1,826.9	0.4	0.5	1	1	1
02/08/2015 17:00	0.2	13.0	1,922.9	0.4	0.6	1	1	1
02/08/2015 18:00	0.1	12.3	2,049.0	0.2	0.6	1	1	1
02/08/2015 19:00	0.2	12.6	2,005.3	0.4	0.6	1	1	1
02/08/2015 20:00	0.2	12.5	2,029.4	0.4	0.6	1	1	1
02/08/2015 21:00	0.4	13.0	1,779.0	0.5	0.5	1	1	1
02/08/2015 22:00	0.6	13.9	1,332.4	0.6	0.4	1	1	0
02/08/2015 23:00	0.5	13.8	1,525.9	0.5	0.5	1	1	0
Average/Sum#:	0.4	13.5	1,472.3	0.5	0.4	24 #	24 #	6 #
Minimum:	0.1	12.3	1,283.3	0.2	0.4	1	1	0
Maximum:	0.6	13.9	2,049.0	0.6	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/09/2015 00:00	0.5	13.8	1,308.4	0.5	0.4	1	1	0
02/09/2015 01:00	0.5	13.9	1,317.1	0.5	0.4	1	1	0
02/09/2015 02:00	0.5	13.8	1,285.9	0.5	0.4	1	1	0
02/09/2015 03:00	0.5	13.8	1,286.0	0.5	0.4	1	1	0
02/09/2015 04:00	0.5	13.8	1,286.3	0.5	0.4	1	1	0
02/09/2015 05:00	0.5	13.9	1,320.7	0.5	0.4	1	1	0
02/09/2015 06:00	0.2	13.1	1,733.5	0.4	0.5	1	1	1
02/09/2015 07:00	0.2	13.2	1,857.6	0.4	0.6	1	1	1
02/09/2015 08:00	0.2	13.3	1,854.4	0.4	0.6	1	1	1
02/09/2015 09:00	0.5	13.6	1,456.6	0.5	0.4	1	1	1
02/09/2015 10:00	0.6	13.8	1,289.5	0.6	0.4	1	1	0
02/09/2015 11:00	0.5	13.8	1,288.4	0.5	0.4	1	1	0
02/09/2015 12:00	0.5	13.8	1,287.0	0.5	0.4	1	1	0
02/09/2015 13:00	0.5	13.8	1,288.7	0.5	0.4	1	1	0
02/09/2015 14:00	0.5	13.8	1,291.2	0.5	0.4	1	1	0
02/09/2015 15:00	0.5	13.8	1,289.4	0.5	0.4	1	1	0
02/09/2015 16:00	0.5	13.8	1,288.8	0.5	0.4	1	1	0
02/09/2015 17:00	0.4	13.4	1,757.4	0.4	0.5	1	1	1
02/09/2015 18:00	0.2	13.2	1,845.0	0.4	0.6	1	1	1
02/09/2015 19:00	0.2	13.2	1,863.7	0.4	0.6	1	1	1
02/09/2015 20:00	0.2	13.3	1,886.6	0.4	0.6	1	1	1
02/09/2015 21:00	0.5	13.6	1,635.6	0.5	0.5	1	1	1
02/09/2015 22:00	0.5	13.8	1,326.3	0.5	0.4	1	1	0
02/09/2015 23:00	0.5	13.8	1,319.4	0.5	0.4	1	1	0
Average/Sum#:	0.4	13.6	1,473.5	0.5	0.5	24 #	24 #	9 #
Minimum:	0.2	13.1	1,285.9	0.4	0.4	1	1	0
Maximum:	0.6	13.9	1,886.6	0.6	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/10/2015 00:00	0.5	13.8	1,294.3	0.5	0.4	1	1	0
02/10/2015 01:00	0.5	13.8	1,298.3	0.5	0.4	1	1	0
02/10/2015 02:00	0.5	13.8	1,291.9	0.5	0.4	1	1	0
02/10/2015 03:00	0.5	13.8	1,295.5	0.5	0.4	1	1	0
02/10/2015 04:00	0.5	13.8	1,299.2	0.5	0.4	1	1	0
02/10/2015 05:00	0.5	13.8	1,331.7	0.5	0.4	1	1	0
02/10/2015 06:00	0.2	13.2	1,899.2	0.4	0.6	1	1	1
02/10/2015 07:00	0.2	13.1	1,939.1	0.4	0.6	1	1	1
02/10/2015 08:00	0.5	13.6	1,523.9	0.5	0.5	1	1	1
02/10/2015 09:00	0.6	13.8	1,296.8	0.6	0.4	1	1	0
02/10/2015 10:00	0.5	13.8	1,294.6	0.5	0.4	1	1	0
02/10/2015 11:00	0.5	13.8	1,296.8	0.5	0.4	1	1	0
02/10/2015 12:00	0.5	13.8	1,297.1	0.5	0.4	1	1	0
02/10/2015 13:00	0.5	13.8	1,294.3	0.5	0.4	1	1	0
02/10/2015 14:00	0.5	13.8	1,295.4	0.5	0.4	1	1	0
02/10/2015 15:00	0.5	13.8	1,296.7	0.5	0.4	1	1	0
02/10/2015 16:00	0.2	13.2	1,847.6	0.4	0.6	1	1	1
02/10/2015 17:00	0.1	12.7	1,999.1	0.2	0.6	1	1	1
02/10/2015 18:00	0.1	12.5	2,045.6	0.2	0.6	1	1	1
02/10/2015 19:00	0.2	12.5	2,050.8	0.4	0.6	1	1	1
02/10/2015 20:00	0.2	12.6	2,036.2	0.4	0.6	1	1	1
02/10/2015 21:00	0.2	12.8	1,983.4	0.4	0.6	1	1	1
02/10/2015 22:00	0.2	12.6	2,033.5	0.4	0.6	1	1	1
02/10/2015 23:00	0.2	12.8	2,026.5	0.4	0.6	1	1	1
Average/Sum#:	0.4	13.4	1,594.5	0.4	0.5	24 #	24 #	11 #
Minimum:	0.1	12.5	1,291.9	0.2	0.4	1	1	0
Maximum:	0.6	13.8	2,050.8	0.6	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/11/2015 00:00	0.2	12.7	2,029.4	0.4	0.6	1	1	1
02/11/2015 01:00	0.4	13.2	1,908.5	0.4	0.6	1	1	1
02/11/2015 02:00	0.4	13.2	1,847.6	0.4	0.6	1	1	1
02/11/2015 03:00	0.4	13.2	1,849.2	0.4	0.6	1	1	1
02/11/2015 04:00	0.4	13.2	1,848.2	0.4	0.6	1	1	1
02/11/2015 05:00	0.2	13.2	1,875.1	0.4	0.6	1	1	1
02/11/2015 06:00	0.2	13.0	1,928.7	0.4	0.6	1	1	1
02/11/2015 07:00	0.4	13.2	1,863.2	0.4	0.6	1	1	1
02/11/2015 08:00	0.4	13.3	1,851.6	0.4	0.6	1	1	1
02/11/2015 09:00	0.4	13.2	1,855.1	0.4	0.6	1	1	1
02/11/2015 10:00	0.5	13.5	1,592.2	0.5	0.5	1	1	1
02/11/2015 11:00	0.6	13.8	1,445.6	0.6	0.4	1	1	0
02/11/2015 12:00	0.6	13.8	1,491.3	0.6	0.4	1	1	0
02/11/2015 13:00	0.6	13.8	1,292.8	0.6	0.4	1	1	0
02/11/2015 14:00	0.6	13.8	1,296.3	0.6	0.4	1	1	0
02/11/2015 15:00	0.4	13.6	1,549.5	0.4	0.5	1	1	1
02/11/2015 16:00	0.2	13.2	1,886.2	0.4	0.6	1	1	1
02/11/2015 17:00	0.2	13.0	1,945.4	0.4	0.6	1	1	1
02/11/2015 18:00	0.1	12.5	2,046.0	0.2	0.6	1	1	1
02/11/2015 19:00	0.2	12.7	2,014.5	0.4	0.6	1	1	1
02/11/2015 20:00	0.2	12.7	2,019.9	0.4	0.6	1	1	1
02/11/2015 21:00	0.2	12.9	1,979.9	0.4	0.6	1	1	1
02/11/2015 22:00	0.2	12.8	1,989.0	0.4	0.6	1	1	1
02/11/2015 23:00	0.4	13.2	1,860.5	0.4	0.6	1	1	1
Average/Sum#:	0.4	13.2	1,802.7	0.4	0.6	24 #	24 #	20 #
Minimum:	0.1	12.5	1,292.8	0.2	0.4	1	1	0
Maximum:	0.6	13.8	2,046.0	0.6	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/12/2015 00:00	0.5	13.7	1,408.9	0.5	0.4	1	1	1
02/12/2015 01:00	0.6	13.8	1,367.0	0.6	0.4	1	1	0
02/12/2015 02:00	0.5	13.8	1,302.4	0.5	0.4	1	1	0
02/12/2015 03:00	0.5	13.8	1,477.7	0.5	0.4	1	1	0
02/12/2015 04:00	0.4	13.5	1,600.3	0.4	0.5	1	1	1
02/12/2015 05:00	0.2	13.2	1,911.6	0.4	0.6	1	1	1
02/12/2015 06:00	0.2	13.0	1,920.6	0.4	0.6	1	1	1
02/12/2015 07:00	0.2	13.0	1,935.8	0.4	0.6	1	1	1
02/12/2015 08:00	0.5	13.6	1,559.1	0.5	0.5	1	1	1
02/12/2015 09:00	0.6	13.8	1,289.9	0.6	0.4	1	1	0
02/12/2015 10:00	0.6	13.8	1,290.9	0.6	0.4	1	1	0
02/12/2015 11:00	0.6	13.8	1,292.3	0.6	0.4	1	1	0
02/12/2015 12:00	0.6	13.8	1,296.2	0.6	0.4	1	1	0
02/12/2015 13:00	0.5	13.7	1,671.8	0.5	0.5	1	1	1
02/12/2015 14:00	0.1	12.6	2,000.3	0.2	0.6	1	1	1
02/12/2015 15:00	0.4	13.0	1,891.8	0.5	0.6	1	1	1
02/12/2015 16:00	0.2	12.9	1,923.5	0.4	0.6	1	1	1
02/12/2015 17:00	0.2	12.7	1,980.2	0.4	0.6	1	1	1
02/12/2015 18:00	0.2	12.4	2,039.8	0.4	0.6	1	1	1
02/12/2015 19:00	0.2	12.4	2,049.6	0.4	0.6	1	1	1
02/12/2015 20:00	0.2	12.5	2,039.3	0.4	0.6	1	1	1
02/12/2015 21:00	0.2	12.9	1,965.9	0.4	0.6	1	1	1
02/12/2015 22:00	0.2	12.7	1,999.9	0.4	0.6	1	1	1
02/12/2015 23:00	0.5	13.7	1,618.0	0.5	0.5	1	1	1
Average/Sum#:	0.4	13.3	1,701.4	0.5	0.5	24 #	24 #	17 #
Minimum:	0.1	12.4	1,289.9	0.2	0.4	1	1	0
Maximum:	0.6	13.8	2,049.6	0.6	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/13/2015 00:00	0.6	13.8	1,719.9	0.6	0.5	1	1	0
02/13/2015 01:00	0.6	13.8	1,478.9	0.6	0.4	1	1	0
02/13/2015 02:00	0.5	13.8	1,472.0	0.5	0.4	1	1	0
02/13/2015 03:00	0.5	13.8	1,749.7	0.5	0.5	1	1	0
02/13/2015 04:00	0.5	13.8	1,553.6	0.5	0.5	1	1	0
02/13/2015 05:00	0.5	13.7	1,568.2	0.5	0.5	1	1	1
02/13/2015 06:00	0.2	13.1	1,915.3	0.4	0.6	1	1	1
02/13/2015 07:00	0.2	13.2	1,893.8	0.4	0.6	1	1	1
02/13/2015 08:00	0.5	13.7	1,453.2	0.5	0.4	1	1	1
02/13/2015 09:00	0.6	13.8	1,294.6	0.6	0.4	1	1	0
02/13/2015 10:00	0.6	13.8	1,294.7	0.6	0.4	1	1	0
02/13/2015 11:00	0.6	13.8	1,301.8	0.6	0.4	1	1	0
02/13/2015 12:00	0.5	13.8	1,399.5	0.5	0.4	1	1	0
02/13/2015 13:00	0.5	13.7	1,647.7	0.5	0.5	1	1	1
02/13/2015 14:00	0.2	13.1	1,882.1	0.4	0.6	1	1	1
02/13/2015 15:00	0.4	13.3	1,850.8	0.4	0.6	1	1	1
02/13/2015 16:00	0.4	13.2	1,879.0	0.4	0.6	1	1	1
02/13/2015 17:00	0.2	12.9	1,935.7	0.4	0.6	1	1	1
02/13/2015 18:00	0.2	12.6	2,011.9	0.4	0.6	1	1	1
02/13/2015 19:00	0.2	12.4	2,042.3	0.4	0.6	1	1	1
02/13/2015 20:00	0.2	12.5	2,028.1	0.4	0.6	1	1	1
02/13/2015 21:00	0.2	12.6	2,006.5	0.4	0.6	1	1	1
02/13/2015 22:00	0.2	12.6	2,023.2	0.4	0.6	1	1	1
02/13/2015 23:00	0.4	13.1	1,902.7	0.4	0.6	1	1	1
Average/Sum#:	0.4	13.3	1,721.1	0.5	0.5	24 #	24 #	15 #
Minimum:	0.2	12.4	1,294.6	0.4	0.4	1	1	0
Maximum:	0.6	13.8	2,042.3	0.6	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/14/2015 00:00	0.2	12.8	1,991.1	0.4	0.6	1	1	1
02/14/2015 01:00	0.2	12.9	1,974.7	0.4	0.6	1	1	1
02/14/2015 02:00	-0.1	12.8	1,998.4	0.1	0.6	1	1	1
02/14/2015 03:00	0.2	12.8	1,997.6	0.4	0.6	1	1	1
02/14/2015 04:00	0.2	12.8	1,984.5	0.4	0.6	1	1	1
02/14/2015 05:00	0.4	13.2	1,858.4	0.4	0.6	1	1	1
02/14/2015 06:00	0.7	13.8	1,490.9	0.7	0.4	1	1	1
02/14/2015 07:00	0.5	13.8	1,307.7	0.5	0.4	1	1	0
02/14/2015 08:00	0.5	13.8	1,297.7	0.5	0.4	1	1	0
02/14/2015 09:00	0.5	13.8	1,310.3	0.5	0.4	1	1	0
02/14/2015 10:00	0.5	13.8	1,304.6	0.5	0.4	1	1	0
02/14/2015 11:00	0.6	13.8	1,301.5	0.6	0.4	1	1	0
02/14/2015 12:00	0.6	13.8	1,302.2	0.6	0.4	1	1	0
02/14/2015 13:00	0.6	13.9	1,301.4	0.6	0.4	1	1	0
02/14/2015 14:00	0.6	13.9	1,299.0	0.6	0.4	1	1	0
02/14/2015 15:00	0.6	13.9	1,297.0	0.6	0.4	1	1	0
02/14/2015 16:00	0.4	13.4	1,565.2	0.4	0.5	1	1	1
02/14/2015 17:00	0.2	13.0	1,902.0	0.4	0.6	1	1	1
02/14/2015 18:00	0.2	13.0	1,897.5	0.4	0.6	1	1	1
02/14/2015 19:00	0.2	12.3	2,050.6	0.4	0.6	1	1	1
02/14/2015 20:00	0.2	12.8	1,945.3	0.4	0.6	1	1	1
02/14/2015 21:00	0.2	12.9	1,930.7	0.4	0.6	1	1	1
02/14/2015 22:00	0.2	12.6	1,986.7	0.4	0.6	1	1	1
02/14/2015 23:00	0.7	13.8	1,427.5	0.7	0.4	1	1	1
Average/Sum#:	0.4	13.3	1,655.1	0.5	0.5	24 #	24 #	15 #
Minimum:	-0.1	12.3	1,297.0	0.1	0.4	1	1	0
Maximum:	0.7	13.9	2,050.6	0.7	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/15/2015 00:00	0.6	13.9	1,389.4	0.6	0.4	1	1	0
02/15/2015 01:00	0.5	13.8	1,461.0	0.5	0.4	1	1	0
02/15/2015 02:00	0.0	15.8	565.1	0.0	0.2	1	0	0
02/15/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2015 10:00	0.0	17.2	522.1	0.0	0.2	1	0	0
02/15/2015 11:00	0.0	14.8	973.4	0.0	0.3	1	0	0
02/15/2015 12:00	0.6	13.9	1,323.3	0.6	0.4	1	1	0
02/15/2015 13:00	0.6	13.9	1,316.9	0.6	0.4	1	1	0
02/15/2015 14:00	0.6	13.8	1,585.1	0.6	0.5	1	1	0
02/15/2015 15:00	0.5	13.7	1,741.0	0.5	0.5	1	1	0
02/15/2015 16:00	0.5	13.7	1,741.6	0.5	0.5	1	1	0
02/15/2015 17:00	0.6	13.9	1,400.5	0.6	0.4	1	1	0
02/15/2015 18:00	0.6	13.9	1,437.5	0.6	0.4	1	1	0
02/15/2015 19:00	0.2	12.9	1,927.0	0.4	0.6	1	1	1
02/15/2015 20:00	0.4	12.7	1,990.1	0.5	0.6	1	1	1
02/15/2015 21:00	0.4	12.8	1,979.5	0.5	0.6	1	1	1
02/15/2015 22:00	0.4	12.8	1,977.7	0.5	0.6	1	1	1
02/15/2015 23:00	0.4	12.8	1,976.4	0.5	0.6	1	1	1
Average/Sum#:	0.4	13.9	1,488.7	0.4	0.4	17 #	14 #	5 #
Minimum:	0.0	12.7	522.1	0.0	0.2	0	0	0
Maximum:	0.6	17.2	1,990.1	0.6	0.6	1	1	1
%SI	29.2	29.2	29.2	29.2	29.2	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/16/2015 00:00	0.4	12.9	1,987.0	0.5	0.6	1	1	1
02/16/2015 01:00	0.4	13.1	1,909.0	0.4	0.6	1	1	1
02/16/2015 02:00	0.4	13.3	1,844.2	0.4	0.6	1	1	1
02/16/2015 03:00	0.4	13.3	1,845.2	0.4	0.6	1	1	1
02/16/2015 04:00	0.4	13.3	1,854.6	0.4	0.6	1	1	1
02/16/2015 05:00	0.4	13.2	1,892.1	0.4	0.6	1	1	1
02/16/2015 06:00	0.4	13.1	1,918.6	0.4	0.6	1	1	1
02/16/2015 07:00	0.4	13.2	1,852.9	0.4	0.6	1	1	1
02/16/2015 08:00	0.4	13.3	1,854.2	0.4	0.6	1	1	1
02/16/2015 09:00	0.4	13.3	1,853.1	0.4	0.6	1	1	1
02/16/2015 10:00	0.4	13.3	1,854.5	0.4	0.6	1	1	1
02/16/2015 11:00	0.4	13.3	1,851.0	0.4	0.6	1	1	1
02/16/2015 12:00	0.4	13.3	1,850.7	0.4	0.6	1	1	1
02/16/2015 13:00	0.5	13.5	1,561.8	0.5	0.5	1	1	1
02/16/2015 14:00	0.6	13.9	1,289.8	0.6	0.4	1	1	0
02/16/2015 15:00	0.5	13.6	1,543.5	0.5	0.5	1	1	1
02/16/2015 16:00	0.4	13.1	1,896.5	0.4	0.6	1	1	1
02/16/2015 17:00	0.2	12.8	1,948.3	0.4	0.6	1	1	1
02/16/2015 18:00	0.2	12.4	2,036.9	0.4	0.6	1	1	1
02/16/2015 19:00	0.2	12.4	2,031.3	0.4	0.6	1	1	1
02/16/2015 20:00	0.4	13.2	1,853.8	0.4	0.6	1	1	1
02/16/2015 21:00	0.4	13.2	1,875.3	0.4	0.6	1	1	1
02/16/2015 22:00	0.4	13.0	1,918.3	0.5	0.6	1	1	1
02/16/2015 23:00	0.4	13.3	1,847.8	0.4	0.6	1	1	1
Average/Sum#:	0.4	13.2	1,840.4	0.4	0.6	24 #	24 #	23 #
Minimum:	0.2	12.4	1,289.8	0.4	0.4	1	1	0
Maximum:	0.6	13.9	2,036.9	0.6	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/17/2015 00:00	0.4	13.2	1,853.0	0.4	0.6	1	1	1
02/17/2015 01:00	0.2	13.2	1,856.2	0.4	0.6	1	1	1
02/17/2015 02:00	0.4	13.3	1,854.4	0.4	0.6	1	1	1
02/17/2015 03:00	0.4	13.3	1,855.4	0.4	0.6	1	1	1
02/17/2015 04:00	0.4	13.3	1,854.3	0.4	0.6	1	1	1
02/17/2015 05:00	0.2	13.2	1,862.6	0.4	0.6	1	1	1
02/17/2015 06:00	0.2	13.2	1,880.1	0.4	0.6	1	1	1
02/17/2015 07:00	0.2	13.1	1,932.6	0.4	0.6	1	1	1
02/17/2015 08:00	0.2	13.2	1,853.8	0.4	0.6	1	1	1
02/17/2015 09:00	0.5	13.5	1,548.7	0.5	0.5	1	1	1
02/17/2015 10:00	0.6	13.8	1,409.6	0.6	0.4	1	1	0
02/17/2015 11:00	0.5	13.8	1,573.6	0.5	0.5	1	1	0
02/17/2015 12:00	0.5	13.8	1,554.8	0.5	0.5	1	1	0
02/17/2015 13:00	0.5	13.8	1,315.3	0.5	0.4	1	1	0
02/17/2015 14:00	0.5	13.8	1,292.2	0.5	0.4	1	1	0
02/17/2015 15:00	0.5	13.8	1,303.9	0.5	0.4	1	1	0
02/17/2015 16:00	0.4	13.5	1,604.3	0.4	0.5	1	1	1
02/17/2015 17:00	0.2	13.1	1,895.0	0.4	0.6	1	1	1
02/17/2015 18:00	0.1	12.5	2,031.3	0.2	0.6	1	1	1
02/17/2015 19:00	0.1	12.5	2,024.9	0.2	0.6	1	1	1
02/17/2015 20:00	0.2	12.8	1,980.7	0.4	0.6	1	1	1
02/17/2015 21:00	0.2	13.1	1,904.2	0.4	0.6	1	1	1
02/17/2015 22:00	0.2	12.9	1,842.2	0.4	0.6	1	1	1
02/17/2015 23:00	0.5	13.8	1,308.6	0.5	0.4	1	1	0
Average/Sum#:	0.3	13.3	1,724.7	0.4	0.5	24 #	24 #	17 #
Minimum:	0.1	12.5	1,292.2	0.2	0.4	1	1	0
Maximum:	0.6	13.8	2,031.3	0.6	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/18/2015 00:00	0.5	13.8	1,488.8	0.5	0.4	1	1	0
02/18/2015 01:00	0.5	13.8	1,516.0	0.5	0.5	1	1	0
02/18/2015 02:00	0.5	13.8	1,338.1	0.5	0.4	1	1	0
02/18/2015 03:00	0.5	13.8	1,307.5	0.5	0.4	1	1	0
02/18/2015 04:00	0.4	13.6	1,693.0	0.4	0.5	1	1	1
02/18/2015 05:00	0.2	13.2	1,895.4	0.4	0.6	1	1	1
02/18/2015 06:00	0.2	13.2	1,893.1	0.4	0.6	1	1	1
02/18/2015 07:00	0.2	13.1	1,961.9	0.4	0.6	1	1	1
02/18/2015 08:00	0.1	13.0	1,997.9	0.2	0.6	1	1	1
02/18/2015 09:00	0.2	13.0	2,002.6	0.4	0.6	1	1	1
02/18/2015 10:00	0.2	12.9	1,988.1	0.4	0.6	1	1	1
02/18/2015 11:00	0.2	13.2	1,858.2	0.4	0.6	1	1	1
02/18/2015 12:00	0.2	13.2	1,859.4	0.4	0.6	1	1	1
02/18/2015 13:00	0.2	13.2	1,856.6	0.4	0.6	1	1	1
02/18/2015 14:00	0.5	13.6	1,558.1	0.5	0.5	1	1	1
02/18/2015 15:00	0.6	13.8	1,654.5	0.6	0.5	1	1	0
02/18/2015 16:00	0.4	13.2	1,841.0	0.4	0.6	1	1	1
02/18/2015 17:00	0.1	12.7	2,001.0	0.2	0.6	1	1	1
02/18/2015 18:00	0.1	12.5	2,044.4	0.2	0.6	1	1	1
02/18/2015 19:00	0.2	12.6	2,015.7	0.4	0.6	1	1	1
02/18/2015 20:00	0.1	12.7	2,008.7	0.2	0.6	1	1	1
02/18/2015 21:00	0.2	12.8	1,991.2	0.4	0.6	1	1	1
02/18/2015 22:00	0.2	13.0	1,954.2	0.4	0.6	1	1	1
02/18/2015 23:00	0.2	13.2	1,878.0	0.4	0.6	1	1	1
Average/Sum#:	0.3	13.2	1,816.8	0.4	0.6	24 #	24 #	19 #
Minimum:	0.1	12.5	1,307.5	0.2	0.4	1	1	0
Maximum:	0.6	13.8	2,044.4	0.6	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/19/2015 00:00	0.1	12.8	1,981.9	0.2	0.6	1	1	1
02/19/2015 01:00	0.2	13.2	1,855.2	0.4	0.6	1	1	1
02/19/2015 02:00	0.5	13.7	1,430.1	0.5	0.4	1	1	1
02/19/2015 03:00	0.5	13.8	1,312.7	0.5	0.4	1	1	0
02/19/2015 04:00	0.5	13.7	1,437.7	0.5	0.4	1	1	1
02/19/2015 05:00	0.1	13.0	1,943.1	0.2	0.6	1	1	1
02/19/2015 06:00	0.1	12.9	1,945.6	0.2	0.6	1	1	1
02/19/2015 07:00	0.1	12.9	2,005.5	0.2	0.6	1	1	1
02/19/2015 08:00	0.2	12.8	2,012.3	0.4	0.6	1	1	1
02/19/2015 09:00	0.2	13.0	1,960.7	0.4	0.6	1	1	1
02/19/2015 10:00	0.1	12.6	2,043.3	0.2	0.6	1	1	1
02/19/2015 11:00	0.2	12.8	2,008.6	0.4	0.6	1	1	1
02/19/2015 12:00	0.2	12.9	1,959.2	0.4	0.6	1	1	1
02/19/2015 13:00	0.2	12.8	1,968.1	0.4	0.6	1	1	1
02/19/2015 14:00	0.2	13.2	1,850.0	0.4	0.6	1	1	1
02/19/2015 15:00	0.2	13.3	1,848.3	0.4	0.6	1	1	1
02/19/2015 16:00	0.2	13.2	1,875.7	0.4	0.6	1	1	1
02/19/2015 17:00	0.2	13.2	1,864.2	0.4	0.6	1	1	1
02/19/2015 18:00	0.2	12.9	1,964.8	0.4	0.6	1	1	1
02/19/2015 19:00	0.2	13.2	1,867.6	0.4	0.6	1	1	1
02/19/2015 20:00	0.2	13.2	1,850.3	0.4	0.6	1	1	1
02/19/2015 21:00	0.2	13.2	1,860.1	0.4	0.6	1	1	1
02/19/2015 22:00	0.2	13.1	1,896.7	0.4	0.6	1	1	1
02/19/2015 23:00	0.2	13.0	1,827.1	0.4	0.5	1	1	1
Average/Sum#:	0.2	13.1	1,857.0	0.4	0.6	24 #	24 #	23 #
Minimum:	0.1	12.6	1,312.7	0.2	0.4	1	1	0
Maximum:	0.5	13.8	2,043.3	0.5	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/20/2015 00:00	0.5	13.8	1,342.1	0.5	0.4	1	1	0
02/20/2015 01:00	0.0	15.7	621.7	0.0	0.2	1	0	0
02/20/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 04:00	0.0	18.7	313.2	0.0	0.1	1	0	0
02/20/2015 05:00	0.0	14.5	1,139.3	0.0	0.3	1	0	0
02/20/2015 06:00	0.5	13.8	1,586.4	0.5	0.5	1	1	0
02/20/2015 07:00	0.5	13.8	1,793.8	0.5	0.5	1	1	0
02/20/2015 08:00	0.5	13.8	1,797.4	0.5	0.5	1	1	0
02/20/2015 09:00	0.5	13.8	1,806.3	0.5	0.5	1	1	0
02/20/2015 10:00	0.5	13.7	1,798.7	0.5	0.5	1	1	0
02/20/2015 11:00	0.5	13.7	1,717.1	0.5	0.5	1	1	0
02/20/2015 12:00	0.0	16.3	441.8	0.0	0.1	1	0	0
02/20/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.3	14.7	1,305.3	0.3	0.4	11 #	7 #	0 #
Minimum:	0.0	13.7	313.2	0.0	0.1	0	0	0
Maximum:	0.5	18.7	1,806.3	0.5	0.5	1	1	0
%SI	54.2	54.2	54.2	54.2	54.2	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/21/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 10:00	0.0	17.4	488.4	0.0	0.1	1	0	0
02/21/2015 11:00	0.0	15.5	736.1	0.0	0.2	1	0	0
02/21/2015 12:00	0.0	14.2	1,247.6	0.0	0.4	1	0	0
02/21/2015 13:00	0.6	13.9	1,280.1	0.6	0.4	1	1	0
02/21/2015 14:00	0.6	13.9	1,274.8	0.6	0.4	1	1	0
02/21/2015 15:00	0.5	13.9	1,366.4	0.5	0.4	1	1	0
02/21/2015 16:00	0.5	13.9	1,365.1	0.5	0.4	1	1	0
02/21/2015 17:00	0.5	13.7	1,508.4	0.5	0.5	1	1	1
02/21/2015 18:00	0.1	12.7	2,003.0	0.2	0.6	1	1	1
02/21/2015 19:00	0.2	12.5	2,049.5	0.4	0.6	1	1	1
02/21/2015 20:00	0.2	12.5	2,044.6	0.4	0.6	1	1	1
02/21/2015 21:00	0.2	12.8	2,006.0	0.4	0.6	1	1	1
02/21/2015 22:00	0.2	12.6	2,045.5	0.4	0.6	1	1	1
02/21/2015 23:00	0.2	12.9	1,954.3	0.4	0.6	1	1	1
Average/Sum#:	0.3	13.7	1,526.4	0.4	0.5	14 #	11 #	7 #
Minimum:	0.0	12.5	488.4	0.0	0.1	0	0	0
Maximum:	0.6	17.4	2,049.5	0.6	0.6	1	1	1
%SI	41.7	41.7	41.7	41.7	41.7	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/22/2015 00:00	0.6	13.9	1,398.5	0.6	0.4	1	1	0
02/22/2015 01:00	0.6	13.8	1,549.6	0.6	0.5	1	1	0
02/22/2015 02:00	0.6	13.9	1,292.2	0.6	0.4	1	1	0
02/22/2015 03:00	0.6	13.9	1,342.6	0.6	0.4	1	1	0
02/22/2015 04:00	0.6	13.9	1,584.8	0.6	0.5	1	1	0
02/22/2015 05:00	0.6	13.9	1,505.7	0.6	0.5	1	1	0
02/22/2015 06:00	0.0	0.0	644.7	0.0	0.2	1	0	0
02/22/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2015 14:00	0.0	17.0	541.2	0.0	0.2	1	0	0
02/22/2015 15:00	0.0	15.0	943.2	0.0	0.3	1	0	0
02/22/2015 16:00	0.6	13.8	1,775.3	0.6	0.5	1	1	0
02/22/2015 17:00	0.6	13.8	1,737.5	0.6	0.5	1	1	0
02/22/2015 18:00	0.5	13.8	1,805.9	0.5	0.5	1	1	0
02/22/2015 19:00	0.5	13.8	1,811.0	0.5	0.5	1	1	0
02/22/2015 20:00	0.5	13.8	1,815.0	0.5	0.5	1	1	0
02/22/2015 21:00	0.5	13.8	1,817.9	0.5	0.5	1	1	0
02/22/2015 22:00	0.0	14.7	1,221.4	0.0	0.4	1	0	0
02/22/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.5	14.2	1,424.2	0.5	0.4	16 #	12 #	0 #
Minimum:	0.0	13.8	541.2	0.0	0.2	0	0	0
Maximum:	0.6	17.0	1,817.9	0.6	0.5	1	1	0
%SI	37.5	37.5	33.3	37.5	33.3	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/23/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2015 03:00	0.0	16.9	565.9	0.0	0.2	1	0	0
02/23/2015 04:00	0.0	14.3	1,287.3	0.0	0.4	1	0	0
02/23/2015 05:00	0.4	13.5	1,873.1	0.4	0.6	1	1	1
02/23/2015 06:00	0.1	12.9	2,032.0	0.2	0.6	1	1	1
02/23/2015 07:00	0.1	12.7	1,955.5	0.2	0.6	1	1	1
02/23/2015 08:00	0.5	13.9	1,798.5	0.5	0.5	1	1	0
02/23/2015 09:00	0.5	13.8	1,793.2	0.5	0.5	1	1	0
02/23/2015 10:00	0.5	13.8	1,809.1	0.5	0.5	1	1	0
02/23/2015 11:00	0.5	13.9	1,646.7	0.5	0.5	1	1	0
02/23/2015 12:00	0.5	13.8	1,813.3	0.5	0.5	1	1	0
02/23/2015 13:00	0.5	13.8	1,808.6	0.5	0.5	1	1	0
02/23/2015 14:00	0.5	13.8	1,630.5	0.5	0.5	1	1	0
02/23/2015 15:00	0.5	13.8	1,793.7	0.5	0.5	1	1	0
02/23/2015 16:00	0.5	13.8	1,669.3	0.5	0.5	1	1	0
02/23/2015 17:00	0.2	13.2	1,884.6	0.4	0.6	1	1	1
02/23/2015 18:00	0.1	12.1	2,159.4	0.2	0.6	1	1	1
02/23/2015 19:00	0.4	13.5	1,835.1	0.4	0.6	1	1	1
02/23/2015 20:00	0.1	12.1	2,183.2	0.2	0.7	1	1	1
02/23/2015 21:00	0.1	12.2	2,107.3	0.2	0.6	1	1	1
02/23/2015 22:00	0.5	13.8	1,809.2	0.5	0.5	1	1	0
02/23/2015 23:00	0.5	13.9	1,747.0	0.5	0.5	1	1	0
Average/Sum#:	0.3	13.6	1,771.5	0.4	0.5	21 #	19 #	8 #
Minimum:	0.0	12.1	565.9	0.0	0.2	0	0	0
Maximum:	0.5	16.9	2,183.2	0.5	0.7	1	1	1
%SI	12.5	12.5	12.5	12.5	12.5	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/24/2015 00:00	0.5	13.9	1,755.5	0.5	0.5	1	1	0
02/24/2015 01:00	0.5	13.9	1,798.6	0.5	0.5	1	1	0
02/24/2015 02:00	0.5	13.9	1,810.8	0.5	0.5	1	1	0
02/24/2015 03:00	0.5	13.9	1,792.1	0.5	0.5	1	1	0
02/24/2015 04:00	0.5	13.9	1,635.4	0.5	0.5	1	1	0
02/24/2015 05:00	0.4	13.5	1,696.6	0.4	0.5	1	1	1
02/24/2015 06:00	0.1	12.8	2,044.4	0.2	0.6	1	1	1
02/24/2015 07:00	0.2	12.8	2,039.5	0.4	0.6	1	1	1
02/24/2015 08:00	0.4	13.1	1,968.4	0.4	0.6	1	1	1
02/24/2015 09:00	0.5	13.6	1,556.8	0.5	0.5	1	1	1
02/24/2015 10:00	0.6	13.9	1,325.9	0.6	0.4	1	1	0
02/24/2015 11:00	0.6	13.9	1,293.5	0.6	0.4	1	1	0
02/24/2015 12:00	0.6	13.9	1,292.5	0.6	0.4	1	1	0
02/24/2015 13:00	0.6	13.9	1,291.8	0.6	0.4	1	1	0
02/24/2015 14:00	0.6	13.9	1,313.9	0.6	0.4	1	1	0
02/24/2015 15:00	0.6	13.9	1,368.1	0.6	0.4	1	1	0
02/24/2015 16:00	0.5	13.8	1,479.7	0.5	0.4	1	1	1
02/24/2015 17:00	0.2	12.8	2,000.5	0.4	0.6	1	1	1
02/24/2015 18:00	0.2	12.6	2,046.8	0.4	0.6	1	1	1
02/24/2015 19:00	0.2	12.6	2,040.6	0.4	0.6	1	1	1
02/24/2015 20:00	0.2	12.7	2,039.2	0.4	0.6	1	1	1
02/24/2015 21:00	0.2	12.7	2,032.0	0.4	0.6	1	1	1
02/24/2015 22:00	0.4	13.1	1,821.5	0.4	0.5	1	1	1
02/24/2015 23:00	0.6	13.8	1,488.2	0.6	0.4	1	1	0
Average/Sum#:	0.4	13.5	1,705.5	0.5	0.5	24 #	24 #	12 #
Minimum:	0.1	12.6	1,291.8	0.2	0.4	1	1	0
Maximum:	0.6	13.9	2,046.8	0.6	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/25/2015 00:00	0.5	13.8	1,302.5	0.5	0.4	1	1	0
02/25/2015 01:00	0.5	13.9	1,748.3	0.5	0.5	1	1	0
02/25/2015 02:00	0.5	13.9	1,733.9	0.5	0.5	1	1	0
02/25/2015 03:00	0.5	13.8	1,447.1	0.5	0.4	1	1	0
02/25/2015 04:00	0.5	13.8	1,291.0	0.5	0.4	1	1	0
02/25/2015 05:00	0.4	13.6	1,636.3	0.4	0.5	1	1	1
02/25/2015 06:00	0.1	12.9	2,012.3	0.2	0.6	1	1	1
02/25/2015 07:00	0.2	13.1	1,992.6	0.4	0.6	1	1	1
02/25/2015 08:00	0.4	13.5	1,736.1	0.4	0.5	1	1	1
02/25/2015 09:00	0.6	13.8	1,309.6	0.6	0.4	1	1	0
02/25/2015 10:00	0.6	13.8	1,293.2	0.6	0.4	1	1	0
02/25/2015 11:00	0.6	13.8	1,293.7	0.6	0.4	1	1	0
02/25/2015 12:00	0.6	13.8	1,295.5	0.6	0.4	1	1	0
02/25/2015 13:00	0.5	13.9	1,411.7	0.5	0.4	1	1	0
02/25/2015 14:00	0.6	13.9	1,303.4	0.6	0.4	1	1	0
02/25/2015 15:00	0.6	13.9	1,296.8	0.6	0.4	1	1	0
02/25/2015 16:00	0.5	13.8	1,468.0	0.5	0.4	1	1	1
02/25/2015 17:00	0.1	12.8	1,981.7	0.2	0.6	1	1	1
02/25/2015 18:00	0.2	12.6	2,005.5	0.4	0.6	1	1	1
02/25/2015 19:00	0.2	13.0	1,942.1	0.4	0.6	1	1	1
02/25/2015 20:00	0.2	13.1	1,943.9	0.4	0.6	1	1	1
02/25/2015 21:00	0.2	12.9	1,978.6	0.4	0.6	1	1	1
02/25/2015 22:00	0.2	13.1	1,782.6	0.4	0.5	1	1	1
02/25/2015 23:00	0.6	13.8	1,439.7	0.6	0.4	1	1	0
Average/Sum#:	0.4	13.5	1,610.3	0.5	0.5	24 #	24 #	11 #
Minimum:	0.1	12.6	1,291.0	0.2	0.4	1	1	0
Maximum:	0.6	13.9	2,012.3	0.6	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/26/2015 00:00	0.6	13.8	1,289.3	0.6	0.4	1	1	0
02/26/2015 01:00	0.5	13.8	1,304.5	0.5	0.4	1	1	0
02/26/2015 02:00	0.5	13.8	1,754.2	0.5	0.5	1	1	0
02/26/2015 03:00	0.5	13.8	1,783.3	0.5	0.5	1	1	0
02/26/2015 04:00	0.4	13.6	1,749.3	0.4	0.5	1	1	1
02/26/2015 05:00	0.2	13.2	1,937.2	0.4	0.6	1	1	1
02/26/2015 06:00	0.2	13.1	1,957.6	0.4	0.6	1	1	1
02/26/2015 07:00	0.2	13.0	1,976.3	0.4	0.6	1	1	1
02/26/2015 08:00	0.5	13.5	1,626.0	0.5	0.5	1	1	1
02/26/2015 09:00	0.6	13.8	1,374.3	0.6	0.4	1	1	0
02/26/2015 10:00	0.6	13.9	1,676.3	0.6	0.5	1	1	0
02/26/2015 11:00	0.6	13.8	1,705.7	0.6	0.5	1	1	0
02/26/2015 12:00	0.6	13.9	1,312.0	0.6	0.4	1	1	0
02/26/2015 13:00	0.6	13.9	1,290.3	0.6	0.4	1	1	0
02/26/2015 14:00	0.6	13.9	1,292.3	0.6	0.4	1	1	0
02/26/2015 15:00	0.5	13.9	1,479.2	0.5	0.4	1	1	0
02/26/2015 16:00	0.2	13.1	1,792.5	0.4	0.5	1	1	1
02/26/2015 17:00	0.2	12.7	1,984.0	0.4	0.6	1	1	1
02/26/2015 18:00	0.2	12.3	2,059.1	0.4	0.6	1	1	1
02/26/2015 19:00	0.2	12.3	2,057.7	0.4	0.6	1	1	1
02/26/2015 20:00	0.2	12.5	2,022.2	0.4	0.6	1	1	1
02/26/2015 21:00	0.2	12.6	2,006.3	0.4	0.6	1	1	1
02/26/2015 22:00	0.5	13.5	1,581.4	0.5	0.5	1	1	1
02/26/2015 23:00	0.6	13.9	1,286.3	0.6	0.4	1	1	0
Average/Sum#:	0.4	13.4	1,679.1	0.5	0.5	24 #	24 #	12 #
Minimum:	0.2	12.3	1,286.3	0.4	0.4	1	1	0
Maximum:	0.6	13.9	2,059.1	0.6	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/27/2015 00:00	0.5	13.7	1,722.3	0.5	0.5	1	1	0
02/27/2015 01:00	0.5	13.7	1,799.3	0.5	0.5	1	1	0
02/27/2015 02:00	0.5	13.7	1,774.8	0.5	0.5	1	1	0
02/27/2015 03:00	0.5	13.8	1,497.1	0.5	0.4	1	1	0
02/27/2015 04:00	0.5	13.8	1,287.9	0.5	0.4	1	1	0
02/27/2015 05:00	0.5	13.7	1,468.7	0.5	0.4	1	1	1
02/27/2015 06:00	0.1	12.7	1,994.9	0.2	0.6	1	1	1
02/27/2015 07:00	0.2	13.1	1,807.8	0.4	0.5	1	1	1
02/27/2015 08:00	0.6	13.8	1,306.0	0.6	0.4	1	1	0
02/27/2015 09:00	0.6	13.8	1,286.1	0.6	0.4	1	1	0
02/27/2015 10:00	0.6	13.9	1,289.9	0.6	0.4	1	1	0
02/27/2015 11:00	0.5	13.8	1,492.8	0.5	0.4	1	1	0
02/27/2015 12:00	0.6	13.9	1,288.7	0.6	0.4	1	1	0
02/27/2015 13:00	0.5	13.9	1,290.6	0.5	0.4	1	1	0
02/27/2015 14:00	0.5	13.9	1,288.0	0.5	0.4	1	1	0
02/27/2015 15:00	0.5	13.9	1,355.3	0.5	0.4	1	1	0
02/27/2015 16:00	0.5	13.9	1,450.5	0.5	0.4	1	1	0
02/27/2015 17:00	0.2	13.3	1,663.0	0.4	0.5	1	1	1
02/27/2015 18:00	0.1	12.5	2,050.9	0.2	0.6	1	1	1
02/27/2015 19:00	0.1	12.5	2,051.9	0.2	0.6	1	1	1
02/27/2015 20:00	0.2	12.5	2,052.8	0.4	0.6	1	1	1
02/27/2015 21:00	0.1	12.6	2,052.0	0.2	0.6	1	1	1
02/27/2015 22:00	0.1	12.6	2,048.2	0.2	0.6	1	1	1
02/27/2015 23:00	0.5	13.5	1,597.7	0.5	0.5	1	1	1
Average/Sum#:	0.4	13.4	1,621.6	0.4	0.5	24 #	24 #	10 #
Minimum:	0.1	12.5	1,286.1	0.2	0.4	1	1	0
Maximum:	0.6	13.9	2,052.8	0.6	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/28/2015 00:00	0.6	13.9	1,287.4	0.6	0.4	1	1	0
02/28/2015 01:00	0.0	15.8	577.7	0.0	0.2	1	0	0
02/28/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2015 14:00	0.0	18.6	334.3	0.0	0.1	1	0	0
02/28/2015 15:00	0.0	15.6	807.3	0.0	0.2	1	0	0
02/28/2015 16:00	0.5	13.6	1,594.0	0.5	0.5	1	1	1
02/28/2015 17:00	0.2	12.6	2,030.9	0.4	0.6	1	1	1
02/28/2015 18:00	0.2	12.6	2,048.1	0.4	0.6	1	1	1
02/28/2015 19:00	0.2	12.6	2,044.8	0.4	0.6	1	1	1
02/28/2015 20:00	0.2	12.6	2,046.4	0.4	0.6	1	1	1
02/28/2015 21:00	0.2	12.6	2,050.5	0.4	0.6	1	1	1
02/28/2015 22:00	0.2	12.6	2,051.1	0.4	0.6	1	1	1
02/28/2015 23:00	0.2	12.7	2,026.7	0.4	0.6	1	1	1
Average/Sum#:	0.2	13.8	1,574.9	0.3	0.5	12 #	9 #	8 #
Minimum:	0.0	12.6	334.3	0.0	0.1	0	0	0
Maximum:	0.6	18.6	2,051.1	0.6	0.6	1	1	1
%SI	50.0	50.0	50.0	50.0	50.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/01/2015 00:00	0.2	12.9	2,004.0	0.4	0.6	1	1	1
03/01/2015 01:00	0.4	13.4	1,843.8	0.4	0.6	1	1	1
03/01/2015 02:00	0.6	13.9	1,586.7	0.6	0.5	1	1	0
03/01/2015 03:00	0.6	13.9	1,655.5	0.6	0.5	1	1	0
03/01/2015 04:00	0.6	13.9	1,383.3	0.6	0.4	1	1	0
03/01/2015 05:00	0.6	13.8	1,731.2	0.6	0.5	1	1	0
03/01/2015 06:00	0.6	13.8	1,774.3	0.6	0.5	1	1	0
03/01/2015 07:00	0.6	13.8	1,816.5	0.6	0.5	1	1	0
03/01/2015 08:00	0.4	13.3	1,879.0	0.4	0.6	1	1	1
03/01/2015 09:00	0.2	12.7	2,054.4	0.4	0.6	1	1	1
03/01/2015 10:00	0.2	12.6	2,055.1	0.4	0.6	1	1	1
03/01/2015 11:00	0.2	12.6	2,055.3	0.4	0.6	1	1	1
03/01/2015 12:00	0.2	12.5	2,055.1	0.4	0.6	1	1	1
03/01/2015 13:00	0.4	12.8	1,988.7	0.5	0.6	1	1	1
03/01/2015 14:00	0.4	12.6	2,029.0	0.5	0.6	1	1	1
03/01/2015 15:00	0.4	12.4	2,059.7	0.5	0.6	1	1	1
03/01/2015 16:00	0.4	12.6	2,028.8	0.5	0.6	1	1	1
03/01/2015 17:00	0.2	12.5	2,053.1	0.4	0.6	1	1	1
03/01/2015 18:00	0.4	12.5	2,053.2	0.5	0.6	1	1	1
03/01/2015 19:00	0.2	12.5	2,055.7	0.4	0.6	1	1	1
03/01/2015 20:00	0.2	12.6	2,058.1	0.4	0.6	1	1	1
03/01/2015 21:00	0.2	12.6	2,059.6	0.4	0.6	1	1	1
03/01/2015 22:00	0.2	12.7	2,041.2	0.4	0.6	1	1	1
03/01/2015 23:00	0.2	12.9	2,016.9	0.4	0.6	1	1	1
Average/Sum#:	0.4	13.0	1,930.8	0.5	0.6	24 #	24 #	18 #
Minimum:	0.2	12.4	1,383.3	0.4	0.4	1	1	0
Maximum:	0.6	13.9	2,059.7	0.6	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/02/2015 00:00	0.2	12.8	2,035.4	0.4	0.6	1	1	1
03/02/2015 01:00	0.2	12.7	2,052.9	0.4	0.6	1	1	1
03/02/2015 02:00	0.2	12.9	2,020.3	0.4	0.6	1	1	1
03/02/2015 03:00	0.4	13.2	1,952.1	0.4	0.6	1	1	1
03/02/2015 04:00	0.4	13.5	1,815.4	0.4	0.5	1	1	1
03/02/2015 05:00	0.2	13.0	1,999.0	0.4	0.6	1	1	1
03/02/2015 06:00	0.1	12.7	2,012.4	0.2	0.6	1	1	1
03/02/2015 07:00	0.1	12.7	2,057.0	0.2	0.6	1	1	1
03/02/2015 08:00	0.1	12.8	2,038.1	0.2	0.6	1	1	1
03/02/2015 09:00	0.2	12.7	2,037.4	0.4	0.6	1	1	1
03/02/2015 10:00	0.2	12.9	2,003.9	0.4	0.6	1	1	1
03/02/2015 11:00	0.4	13.0	1,970.4	0.5	0.6	1	1	1
03/02/2015 12:00	0.2	12.8	2,005.4	0.4	0.6	1	1	1
03/02/2015 13:00	0.2	12.8	1,994.8	0.4	0.6	1	1	1
03/02/2015 14:00	0.5	13.4	1,698.5	0.5	0.5	1	1	1
03/02/2015 15:00	0.6	13.8	1,618.3	0.6	0.5	1	1	0
03/02/2015 16:00	0.4	13.3	1,819.6	0.4	0.5	1	1	1
03/02/2015 17:00	0.2	13.1	1,929.4	0.4	0.6	1	1	1
03/02/2015 18:00	0.4	13.1	1,933.6	0.4	0.6	1	1	1
03/02/2015 19:00	0.4	13.1	1,940.2	0.4	0.6	1	1	1
03/02/2015 20:00	0.4	13.1	1,949.2	0.4	0.6	1	1	1
03/02/2015 21:00	0.4	13.1	1,952.8	0.4	0.6	1	1	1
03/02/2015 22:00	0.4	13.3	1,806.5	0.4	0.5	1	1	1
03/02/2015 23:00	0.6	13.8	1,540.9	0.6	0.5	1	1	0
Average/Sum#:	0.3	13.1	1,924.3	0.4	0.6	24 #	24 #	22 #
Minimum:	0.1	12.7	1,540.9	0.2	0.5	1	1	0
Maximum:	0.6	13.8	2,057.0	0.6	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/03/2015 00:00	0.6	13.8	1,292.6	0.6	0.4	1	1	0
03/03/2015 01:00	0.6	13.8	1,293.6	0.6	0.4	1	1	0
03/03/2015 02:00	0.6	13.8	1,295.9	0.6	0.4	1	1	0
03/03/2015 03:00	0.5	13.8	1,298.3	0.5	0.4	1	1	0
03/03/2015 04:00	0.4	13.6	1,566.9	0.4	0.5	1	1	1
03/03/2015 05:00	0.1	12.9	2,009.7	0.2	0.6	1	1	1
03/03/2015 06:00	0.2	12.7	2,045.3	0.4	0.6	1	1	1
03/03/2015 07:00	0.2	12.9	2,004.0	0.4	0.6	1	1	1
03/03/2015 08:00	0.5	13.5	1,597.5	0.5	0.5	1	1	1
03/03/2015 09:00	0.6	13.8	1,293.5	0.6	0.4	1	1	0
03/03/2015 10:00	0.6	13.8	1,293.8	0.6	0.4	1	1	0
03/03/2015 11:00	0.6	13.8	1,294.3	0.6	0.4	1	1	0
03/03/2015 12:00	0.6	13.9	1,297.1	0.6	0.4	1	1	0
03/03/2015 13:00	0.6	13.9	1,299.1	0.6	0.4	1	1	0
03/03/2015 14:00	0.6	13.9	1,295.3	0.6	0.4	1	1	0
03/03/2015 15:00	0.6	13.9	1,295.3	0.6	0.4	1	1	0
03/03/2015 16:00	0.5	13.9	1,409.6	0.5	0.4	1	1	1
03/03/2015 17:00	0.2	13.0	1,952.6	0.4	0.6	1	1	1
03/03/2015 18:00	0.2	12.8	2,013.8	0.4	0.6	1	1	1
03/03/2015 19:00	0.2	12.6	2,054.1	0.4	0.6	1	1	1
03/03/2015 20:00	0.2	12.6	2,047.0	0.4	0.6	1	1	1
03/03/2015 21:00	0.2	12.6	2,050.8	0.4	0.6	1	1	1
03/03/2015 22:00	0.2	12.8	2,013.4	0.4	0.6	1	1	1
03/03/2015 23:00	0.5	13.5	1,716.3	0.5	0.5	1	1	1
Average/Sum#:	0.4	13.4	1,613.7	0.5	0.5	24 #	24 #	13 #
Minimum:	0.1	12.6	1,292.6	0.2	0.4	1	1	0
Maximum:	0.6	13.9	2,054.1	0.6	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/04/2015 00:00	0.6	13.9	1,816.2	0.6	0.5	1	1	0
03/04/2015 01:00	0.6	13.8	1,779.5	0.6	0.5	1	1	0
03/04/2015 02:00	0.6	13.9	1,721.1	0.6	0.5	1	1	0
03/04/2015 03:00	0.6	13.9	1,761.4	0.6	0.5	1	1	0
03/04/2015 04:00	0.4	13.4	1,812.0	0.4	0.5	1	1	1
03/04/2015 05:00	0.2	12.9	2,021.2	0.4	0.6	1	1	1
03/04/2015 06:00	0.2	12.8	2,026.0	0.4	0.6	1	1	1
03/04/2015 07:00	0.2	12.9	2,012.1	0.4	0.6	1	1	1
03/04/2015 08:00	0.2	13.1	1,975.4	0.4	0.6	1	1	1
03/04/2015 09:00	0.5	13.7	1,439.2	0.5	0.4	1	1	1
03/04/2015 10:00	0.5	13.9	1,293.9	0.5	0.4	1	1	0
03/04/2015 11:00	0.5	13.9	1,293.2	0.5	0.4	1	1	0
03/04/2015 12:00	0.5	13.9	1,293.1	0.5	0.4	1	1	0
03/04/2015 13:00	0.5	13.9	1,293.8	0.5	0.4	1	1	0
03/04/2015 14:00	0.5	13.9	1,293.7	0.5	0.4	1	1	0
03/04/2015 15:00	0.5	13.9	1,293.4	0.5	0.4	1	1	0
03/04/2015 16:00	0.4	13.5	1,560.9	0.4	0.5	1	1	1
03/04/2015 17:00	0.1	12.6	2,030.7	0.2	0.6	1	1	1
03/04/2015 18:00	0.2	12.5	2,054.2	0.4	0.6	1	1	1
03/04/2015 19:00	0.2	12.6	2,050.7	0.4	0.6	1	1	1
03/04/2015 20:00	0.2	12.6	2,051.8	0.4	0.6	1	1	1
03/04/2015 21:00	0.2	12.7	2,041.3	0.4	0.6	1	1	1
03/04/2015 22:00	0.1	12.8	2,018.8	0.2	0.6	1	1	1
03/04/2015 23:00	0.2	13.1	1,978.2	0.4	0.6	1	1	1
Average/Sum#:	0.4	13.3	1,746.3	0.4	0.5	24 #	24 #	14 #
Minimum:	0.1	12.5	1,293.1	0.2	0.4	1	1	0
Maximum:	0.6	13.9	2,054.2	0.6	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/05/2015 00:00	0.2	13.4	1,813.7	0.4	0.5	1	1	1
03/05/2015 01:00	0.5	13.9	1,588.9	0.5	0.5	1	1	0
03/05/2015 02:00	0.5	13.9	1,546.1	0.5	0.5	1	1	0
03/05/2015 03:00	0.5	13.9	1,631.3	0.5	0.5	1	1	0
03/05/2015 04:00	0.4	13.7	1,761.5	0.4	0.5	1	1	1
03/05/2015 05:00	0.1	13.0	2,006.2	0.2	0.6	1	1	1
03/05/2015 06:00	0.1	12.8	2,037.9	0.2	0.6	1	1	1
03/05/2015 07:00	0.1	12.9	2,031.6	0.2	0.6	1	1	1
03/05/2015 08:00	0.2	13.2	1,952.9	0.4	0.6	1	1	1
03/05/2015 09:00	0.5	13.7	1,456.0	0.5	0.4	1	1	1
03/05/2015 10:00	0.5	13.8	1,294.8	0.5	0.4	1	1	0
03/05/2015 11:00	0.5	13.8	1,295.8	0.5	0.4	1	1	0
03/05/2015 12:00	0.5	13.8	1,296.1	0.5	0.4	1	1	0
03/05/2015 13:00	0.5	13.9	1,298.3	0.5	0.4	1	1	0
03/05/2015 14:00	0.5	13.9	1,299.4	0.5	0.4	1	1	0
03/05/2015 15:00	0.5	13.9	1,301.1	0.5	0.4	1	1	0
03/05/2015 16:00	0.4	13.7	1,549.2	0.4	0.5	1	1	1
03/05/2015 17:00	0.1	12.6	2,047.0	0.2	0.6	1	1	1
03/05/2015 18:00	0.1	12.5	2,052.3	0.2	0.6	1	1	1
03/05/2015 19:00	0.1	12.5	2,051.5	0.2	0.6	1	1	1
03/05/2015 20:00	0.1	12.6	2,050.6	0.2	0.6	1	1	1
03/05/2015 21:00	0.1	12.6	2,044.4	0.2	0.6	1	1	1
03/05/2015 22:00	0.1	12.7	2,035.2	0.2	0.6	1	1	1
03/05/2015 23:00	0.2	13.3	1,759.2	0.4	0.5	1	1	1
Average/Sum#:	0.3	13.3	1,716.7	0.4	0.5	24 #	24 #	15 #
Minimum:	0.1	12.5	1,294.8	0.2	0.4	1	1	0
Maximum:	0.5	13.9	2,052.3	0.5	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/06/2015 00:00	0.5	13.8	1,296.1	0.5	0.4	1	1	0
03/06/2015 01:00	0.5	13.8	1,295.0	0.5	0.4	1	1	0
03/06/2015 02:00	0.5	13.8	1,293.3	0.5	0.4	1	1	0
03/06/2015 03:00	0.5	13.8	1,294.5	0.5	0.4	1	1	0
03/06/2015 04:00	0.5	13.8	1,296.0	0.5	0.4	1	1	0
03/06/2015 05:00	0.4	13.6	1,571.1	0.4	0.5	1	1	1
03/06/2015 06:00	-0.1	12.8	2,009.7	0.1	0.6	1	1	1
03/06/2015 07:00	0.2	13.2	1,966.9	0.4	0.6	1	1	1
03/06/2015 08:00	0.2	13.2	1,952.9	0.4	0.6	1	1	1
03/06/2015 09:00	0.1	13.2	1,949.3	0.2	0.6	1	1	1
03/06/2015 10:00	0.4	13.5	1,606.4	0.4	0.5	1	1	1
03/06/2015 11:00	0.5	13.8	1,294.5	0.5	0.4	1	1	0
03/06/2015 12:00	0.5	13.9	1,296.2	0.5	0.4	1	1	0
03/06/2015 13:00	0.5	13.9	1,299.2	0.5	0.4	1	1	0
03/06/2015 14:00	0.5	13.9	1,301.7	0.5	0.4	1	1	0
03/06/2015 15:00	0.5	13.9	1,301.3	0.5	0.4	1	1	0
03/06/2015 16:00	0.4	13.6	1,538.8	0.4	0.5	1	1	1
03/06/2015 17:00	0.1	12.5	2,022.2	0.2	0.6	1	1	1
03/06/2015 18:00	0.2	12.3	2,068.5	0.4	0.6	1	1	1
03/06/2015 19:00	0.2	12.3	2,067.7	0.4	0.6	1	1	1
03/06/2015 20:00	0.2	12.4	2,060.7	0.4	0.6	1	1	1
03/06/2015 21:00	0.2	12.7	2,013.4	0.4	0.6	1	1	1
03/06/2015 22:00	0.1	12.8	2,011.8	0.2	0.6	1	1	1
03/06/2015 23:00	0.1	12.8	1,992.8	0.2	0.6	1	1	1
Average/Sum#:	0.3	13.3	1,658.3	0.4	0.5	24 #	24 #	14 #
Minimum:	-0.1	12.3	1,293.3	0.1	0.4	1	1	0
Maximum:	0.5	13.9	2,068.5	0.5	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/07/2015 00:00	0.2	13.1	1,868.9	0.4	0.6	1	1	1
03/07/2015 01:00	0.5	13.8	1,722.8	0.5	0.5	1	1	0
03/07/2015 02:00	0.0	16.0	496.7	0.0	0.1	1	0	0
03/07/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2015 14:00	0.0	16.9	546.5	0.0	0.2	1	0	0
03/07/2015 15:00	0.0	15.0	916.4	0.0	0.3	1	0	0
03/07/2015 16:00	0.4	13.5	1,706.8	0.4	0.5	1	1	1
03/07/2015 17:00	0.2	12.3	2,060.4	0.4	0.6	1	1	1
03/07/2015 18:00	0.2	12.5	2,032.7	0.4	0.6	1	1	1
03/07/2015 19:00	0.2	12.3	2,063.6	0.4	0.6	1	1	1
03/07/2015 20:00	0.2	12.3	2,063.9	0.4	0.6	1	1	1
03/07/2015 21:00	0.2	12.6	2,018.8	0.4	0.6	1	1	1
03/07/2015 22:00	0.1	12.8	2,008.8	0.2	0.6	1	1	1
03/07/2015 23:00	0.2	13.2	1,779.4	0.4	0.5	1	1	1
Average/Sum#:	0.2	13.6	1,637.4	0.3	0.5	13 #	10 #	9 #
Minimum:	0.0	12.3	496.7	0.0	0.1	0	0	0
Maximum:	0.5	16.9	2,063.9	0.5	0.6	1	1	1
%SI	45.8	45.8	45.8	45.8	45.8	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/08/2015 00:00	0.5	13.9	1,286.7	0.5	0.4	1	1	0
03/08/2015 01:00	0.5	13.8	1,287.2	0.5	0.4	1	1	0
03/08/2015 02:00	0.5	13.8	1,287.7	0.5	0.4	1	1	0
03/08/2015 03:00	0.5	13.8	1,288.8	0.5	0.4	1	1	0
03/08/2015 04:00	0.5	13.8	1,289.9	0.5	0.4	1	1	0
03/08/2015 05:00	0.4	13.8	1,289.3	0.4	0.4	1	1	0
03/08/2015 06:00	0.4	13.8	1,290.9	0.4	0.4	1	1	0
03/08/2015 07:00	0.5	13.8	1,292.0	0.5	0.4	1	1	0
03/08/2015 08:00	0.0	15.8	579.0	0.0	0.2	1	0	0
03/08/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2015 10:00	0.0	16.9	551.7	0.0	0.2	1	0	0
03/08/2015 11:00	0.0	14.6	1,112.4	0.0	0.3	1	0	0
03/08/2015 12:00	0.5	13.9	1,391.7	0.5	0.4	1	1	0
03/08/2015 13:00	0.5	13.9	1,394.5	0.5	0.4	1	1	0
03/08/2015 14:00	0.5	13.9	1,511.7	0.5	0.5	1	1	0
03/08/2015 15:00	0.5	13.9	1,399.8	0.5	0.4	1	1	0
03/08/2015 16:00	0.5	13.9	1,317.5	0.5	0.4	1	1	0
03/08/2015 17:00	0.5	13.9	1,296.8	0.5	0.4	1	1	0
03/08/2015 18:00	0.4	13.8	1,636.5	0.4	0.5	1	1	1
03/08/2015 19:00	0.5	13.7	1,759.7	0.5	0.5	1	1	0
03/08/2015 20:00	0.5	13.7	1,736.2	0.5	0.5	1	1	0
03/08/2015 21:00	0.4	13.9	1,416.7	0.4	0.4	1	1	1
03/08/2015 22:00	0.5	13.9	1,291.5	0.5	0.4	1	1	0
03/08/2015 23:00	0.4	13.9	1,290.2	0.4	0.4	1	1	0
Average/Sum#:	0.4	14.1	1,304.3	0.4	0.4	23 #	20 #	2 #
Minimum:	0.0	13.7	551.7	0.0	0.2	0	0	0
Maximum:	0.5	16.9	1,759.7	0.5	0.5	1	1	1
%SI	4.2	4.2	4.2	4.2	4.2	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/09/2015 00:00	0.4	13.8	1,287.7	0.4	0.4	1	1	0
03/09/2015 01:00	0.4	13.8	1,287.2	0.4	0.4	1	1	0
03/09/2015 02:00	0.4	13.8	1,286.7	0.4	0.4	1	1	0
03/09/2015 03:00	0.4	13.8	1,286.1	0.4	0.4	1	1	0
03/09/2015 04:00	0.4	13.7	1,402.8	0.4	0.4	1	1	1
03/09/2015 05:00	-0.1	12.8	2,004.9	0.1	0.6	1	1	1
03/09/2015 06:00	0.1	12.6	2,050.5	0.2	0.6	1	1	1
03/09/2015 07:00	0.1	13.0	1,962.1	0.2	0.6	1	1	1
03/09/2015 08:00	0.1	13.1	1,938.3	0.2	0.6	1	1	1
03/09/2015 09:00	0.5	13.8	1,331.7	0.5	0.4	1	1	1
03/09/2015 10:00	0.5	13.8	1,289.2	0.5	0.4	1	1	0
03/09/2015 11:00	0.5	13.9	1,289.5	0.5	0.4	1	1	0
03/09/2015 12:00	0.5	13.9	1,290.4	0.5	0.4	1	1	0
03/09/2015 13:00	0.5	13.9	1,296.0	0.5	0.4	1	1	0
03/09/2015 14:00	0.4	13.5	1,626.5	0.4	0.5	1	1	1
03/09/2015 15:00	0.5	13.9	1,289.6	0.5	0.4	1	1	0
03/09/2015 16:00	0.5	13.9	1,288.8	0.5	0.4	1	1	0
03/09/2015 17:00	0.1	13.1	1,728.5	0.2	0.5	1	1	1
03/09/2015 18:00	0.1	12.3	2,056.2	0.2	0.6	1	1	1
03/09/2015 19:00	0.1	12.4	2,056.9	0.2	0.6	1	1	1
03/09/2015 20:00	0.1	12.5	2,035.0	0.2	0.6	1	1	1
03/09/2015 21:00	0.1	12.8	1,986.2	0.2	0.6	1	1	1
03/09/2015 22:00	0.1	12.7	2,014.0	0.2	0.6	1	1	1
03/09/2015 23:00	0.1	12.9	1,964.8	0.2	0.6	1	1	1
Average/Sum#:	0.3	13.3	1,627.1	0.3	0.5	24 #	24 #	14 #
Minimum:	-0.1	12.3	1,286.1	0.1	0.4	1	1	0
Maximum:	0.5	13.9	2,056.9	0.5	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/10/2015 00:00	0.1	13.0	1,955.6	0.2	0.6	1	1	1
03/10/2015 01:00	0.1	12.8	1,993.5	0.2	0.6	1	1	1
03/10/2015 02:00	0.1	13.0	1,943.9	0.2	0.6	1	1	1
03/10/2015 03:00	0.1	13.0	1,944.1	0.2	0.6	1	1	1
03/10/2015 04:00	0.1	12.9	1,955.7	0.2	0.6	1	1	1
03/10/2015 05:00	0.1	12.8	2,002.7	0.2	0.6	1	1	1
03/10/2015 06:00	0.1	12.6	2,043.9	0.2	0.6	1	1	1
03/10/2015 07:00	0.1	12.8	1,999.1	0.2	0.6	1	1	1
03/10/2015 08:00	0.2	13.3	1,790.9	0.4	0.5	1	1	1
03/10/2015 09:00	0.5	13.8	1,414.1	0.5	0.4	1	1	0
03/10/2015 10:00	0.5	13.8	1,290.9	0.5	0.4	1	1	0
03/10/2015 11:00	0.5	13.8	1,291.1	0.5	0.4	1	1	0
03/10/2015 12:00	0.5	13.8	1,291.4	0.5	0.4	1	1	0
03/10/2015 13:00	0.5	13.8	1,291.8	0.5	0.4	1	1	0
03/10/2015 14:00	0.5	13.8	1,291.9	0.5	0.4	1	1	0
03/10/2015 15:00	0.5	13.8	1,291.5	0.5	0.4	1	1	0
03/10/2015 16:00	0.4	13.8	1,402.9	0.4	0.4	1	1	1
03/10/2015 17:00	0.1	12.4	2,047.7	0.2	0.6	1	1	1
03/10/2015 18:00	0.1	12.3	2,054.6	0.2	0.6	1	1	1
03/10/2015 19:00	0.1	12.3	2,058.7	0.2	0.6	1	1	1
03/10/2015 20:00	0.1	12.4	2,057.3	0.2	0.6	1	1	1
03/10/2015 21:00	0.1	12.6	2,010.7	0.2	0.6	1	1	1
03/10/2015 22:00	0.4	13.3	1,679.4	0.4	0.5	1	1	1
03/10/2015 23:00	0.5	13.8	1,288.1	0.5	0.4	1	1	0
Average/Sum#:	0.3	13.2	1,724.6	0.3	0.5	24 #	24 #	16 #
Minimum:	0.1	12.3	1,288.1	0.2	0.4	1	1	0
Maximum:	0.5	13.8	2,058.7	0.5	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/11/2015 00:00	0.5	13.8	1,287.7	0.5	0.4	1	1	0
03/11/2015 01:00	0.5	13.8	1,289.0	0.5	0.4	1	1	0
03/11/2015 02:00	0.4	13.8	1,288.7	0.4	0.4	1	1	0
03/11/2015 03:00	0.4	13.8	1,288.6	0.4	0.4	1	1	0
03/11/2015 04:00	0.4	13.8	1,404.9	0.4	0.4	1	1	1
03/11/2015 05:00	0.1	13.0	1,951.4	0.2	0.6	1	1	1
03/11/2015 06:00	0.1	12.8	1,984.7	0.2	0.6	1	1	1
03/11/2015 07:00	0.1	12.6	2,047.0	0.2	0.6	1	1	1
03/11/2015 08:00	0.1	12.6	2,046.7	0.2	0.6	1	1	1
03/11/2015 09:00	0.1	12.6	2,047.6	0.2	0.6	1	1	1
03/11/2015 10:00	0.1	12.5	2,056.5	0.2	0.6	1	1	1
03/11/2015 11:00	0.1	12.5	2,059.0	0.2	0.6	1	1	1
03/11/2015 12:00	0.1	12.5	2,059.1	0.2	0.6	1	1	1
03/11/2015 13:00	0.1	12.5	2,061.3	0.2	0.6	1	1	1
03/11/2015 14:00	0.1	12.5	2,058.1	0.2	0.6	1	1	1
03/11/2015 15:00	0.1	12.5	2,052.4	0.2	0.6	1	1	1
03/11/2015 16:00	0.1	12.5	2,052.0	0.2	0.6	1	1	1
03/11/2015 17:00	0.2	12.9	1,974.6	0.4	0.6	1	1	1
03/11/2015 18:00	0.1	12.5	2,051.9	0.2	0.6	1	1	1
03/11/2015 19:00	0.1	12.6	2,050.7	0.2	0.6	1	1	1
03/11/2015 20:00	0.1	12.8	2,001.1	0.2	0.6	1	1	1
03/11/2015 21:00	0.4	13.5	1,597.0	0.4	0.5	1	1	1
03/11/2015 22:00	0.5	13.8	1,292.7	0.5	0.4	1	1	0
03/11/2015 23:00	0.5	13.8	1,295.9	0.5	0.4	1	1	0
Average/Sum#:	0.2	13.0	1,804.1	0.3	0.5	24 #	24 #	18 #
Minimum:	0.1	12.5	1,287.7	0.2	0.4	1	1	0
Maximum:	0.5	13.8	2,061.3	0.5	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/12/2015 00:00	0.5	13.8	1,298.8	0.5	0.4	1	1	0
03/12/2015 01:00	0.5	13.8	1,304.9	0.5	0.4	1	1	0
03/12/2015 02:00	0.5	13.8	1,308.5	0.5	0.4	1	1	0
03/12/2015 03:00	0.5	13.8	1,307.0	0.5	0.4	1	1	0
03/12/2015 04:00	0.5	13.8	1,427.1	0.5	0.4	1	1	1
03/12/2015 05:00	0.1	13.1	1,947.2	0.2	0.6	1	1	1
03/12/2015 06:00	0.1	12.6	2,051.5	0.2	0.6	1	1	1
03/12/2015 07:00	0.1	12.5	2,051.3	0.2	0.6	1	1	1
03/12/2015 08:00	0.2	12.8	1,993.9	0.4	0.6	1	1	1
03/12/2015 09:00	0.2	13.0	1,956.0	0.4	0.6	1	1	1
03/12/2015 10:00	0.2	13.0	1,945.2	0.4	0.6	1	1	1
03/12/2015 11:00	0.5	13.8	1,350.5	0.5	0.4	1	1	0
03/12/2015 12:00	0.5	13.8	1,293.5	0.5	0.4	1	1	0
03/12/2015 13:00	0.5	13.8	1,293.3	0.5	0.4	1	1	0
03/12/2015 14:00	0.5	13.8	1,293.1	0.5	0.4	1	1	0
03/12/2015 15:00	0.5	13.8	1,292.6	0.5	0.4	1	1	0
03/12/2015 16:00	0.4	13.6	1,537.1	0.4	0.5	1	1	1
03/12/2015 17:00	0.1	12.5	2,047.5	0.2	0.6	1	1	1
03/12/2015 18:00	0.1	12.5	2,058.7	0.2	0.6	1	1	1
03/12/2015 19:00	0.1	12.5	2,061.0	0.2	0.6	1	1	1
03/12/2015 20:00	0.1	12.5	2,062.8	0.2	0.6	1	1	1
03/12/2015 21:00	0.1	12.5	2,057.0	0.2	0.6	1	1	1
03/12/2015 22:00	0.2	13.1	1,796.4	0.4	0.5	1	1	1
03/12/2015 23:00	0.5	13.9	1,382.0	0.5	0.4	1	1	0
Average/Sum#:	0.3	13.3	1,671.5	0.4	0.5	24 #	24 #	14 #
Minimum:	0.1	12.5	1,292.6	0.2	0.4	1	1	0
Maximum:	0.5	13.9	2,062.8	0.5	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/13/2015 00:00	0.5	13.9	1,379.4	0.5	0.4	1	1	0
03/13/2015 01:00	0.5	13.8	1,416.3	0.5	0.4	1	1	0
03/13/2015 02:00	0.5	13.8	1,536.5	0.5	0.5	1	1	0
03/13/2015 03:00	0.5	13.8	1,410.3	0.5	0.4	1	1	0
03/13/2015 04:00	0.4	13.6	1,557.0	0.4	0.5	1	1	1
03/13/2015 05:00	0.1	12.9	1,999.6	0.2	0.6	1	1	1
03/13/2015 06:00	0.1	12.8	2,023.4	0.2	0.6	1	1	1
03/13/2015 07:00	0.2	13.2	1,939.4	0.4	0.6	1	1	1
03/13/2015 08:00	0.2	13.1	1,939.1	0.4	0.6	1	1	1
03/13/2015 09:00	0.2	13.0	1,944.9	0.4	0.6	1	1	1
03/13/2015 10:00	0.4	13.4	1,636.5	0.4	0.5	1	1	1
03/13/2015 11:00	0.5	13.8	1,295.2	0.5	0.4	1	1	0
03/13/2015 12:00	0.5	13.8	1,399.5	0.5	0.4	1	1	1
03/13/2015 13:00	0.1	12.7	1,988.7	0.2	0.6	1	1	1
03/13/2015 14:00	0.1	12.6	1,999.1	0.2	0.6	1	1	1
03/13/2015 15:00	0.1	12.4	2,043.3	0.2	0.6	1	1	1
03/13/2015 16:00	0.1	12.3	2,052.8	0.2	0.6	1	1	1
03/13/2015 17:00	0.1	12.3	2,058.5	0.2	0.6	1	1	1
03/13/2015 18:00	0.1	12.4	2,054.5	0.2	0.6	1	1	1
03/13/2015 19:00	0.1	12.4	2,046.6	0.2	0.6	1	1	1
03/13/2015 20:00	0.1	12.4	2,050.4	0.2	0.6	1	1	1
03/13/2015 21:00	0.1	12.5	2,027.6	0.2	0.6	1	1	1
03/13/2015 22:00	0.1	12.5	2,036.0	0.2	0.6	1	1	1
03/13/2015 23:00	0.1	12.4	2,045.6	0.2	0.6	1	1	1
Average/Sum#:	0.2	13.0	1,828.3	0.3	0.5	24 #	24 #	19 #
Minimum:	0.1	12.3	1,295.2	0.2	0.4	1	1	0
Maximum:	0.5	13.9	2,058.5	0.5	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/14/2015 00:00	0.1	12.7	2,001.8	0.2	0.6	1	1	1
03/14/2015 01:00	0.1	12.7	2,004.2	0.2	0.6	1	1	1
03/14/2015 02:00	0.1	12.8	1,991.2	0.2	0.6	1	1	1
03/14/2015 03:00	0.2	13.0	1,953.1	0.4	0.6	1	1	1
03/14/2015 04:00	0.2	13.0	1,947.3	0.4	0.6	1	1	1
03/14/2015 05:00	0.2	13.0	1,951.7	0.4	0.6	1	1	1
03/14/2015 06:00	0.1	12.5	2,050.3	0.2	0.6	1	1	1
03/14/2015 07:00	0.1	12.6	2,019.3	0.2	0.6	1	1	1
03/14/2015 08:00	0.2	12.8	1,979.1	0.4	0.6	1	1	1
03/14/2015 09:00	0.2	12.8	1,975.1	0.4	0.6	1	1	1
03/14/2015 10:00	0.2	12.8	1,975.1	0.4	0.6	1	1	1
03/14/2015 11:00	0.2	12.8	1,974.3	0.4	0.6	1	1	1
03/14/2015 12:00	0.1	12.4	2,041.1	0.2	0.6	1	1	1
03/14/2015 13:00	0.2	12.3	2,056.8	0.4	0.6	1	1	1
03/14/2015 14:00	0.2	12.3	2,058.8	0.4	0.6	1	1	1
03/14/2015 15:00	0.2	12.4	2,027.2	0.4	0.6	1	1	1
03/14/2015 16:00	0.2	12.2	2,062.9	0.4	0.6	1	1	1
03/14/2015 17:00	0.2	12.3	2,061.7	0.4	0.6	1	1	1
03/14/2015 18:00	0.2	12.3	2,059.9	0.4	0.6	1	1	1
03/14/2015 19:00	0.2	12.3	2,057.2	0.4	0.6	1	1	1
03/14/2015 20:00	0.2	12.3	2,056.8	0.4	0.6	1	1	1
03/14/2015 21:00	0.1	12.4	2,056.3	0.2	0.6	1	1	1
03/14/2015 22:00	0.1	12.4	2,053.2	0.2	0.6	1	1	1
03/14/2015 23:00	0.1	12.5	2,020.9	0.2	0.6	1	1	1
Average/Sum#:	0.2	12.6	2,018.1	0.3	0.6	24 #	24 #	24 #
Minimum:	0.1	12.2	1,947.3	0.2	0.6	1	1	1
Maximum:	0.2	13.0	2,062.9	0.4	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/15/2015 00:00	0.2	12.8	1,969.7	0.4	0.6	1	1	1
03/15/2015 01:00	0.1	12.6	2,006.5	0.2	0.6	1	1	1
03/15/2015 02:00	0.4	13.1	1,822.3	0.4	0.5	1	1	1
03/15/2015 03:00	0.5	13.7	1,781.9	0.5	0.5	1	1	0
03/15/2015 04:00	0.5	13.6	1,799.8	0.5	0.5	1	1	0
03/15/2015 05:00	0.5	13.7	1,763.4	0.5	0.5	1	1	0
03/15/2015 06:00	0.5	13.6	1,804.8	0.5	0.5	1	1	0
03/15/2015 07:00	0.5	13.7	1,565.4	0.5	0.5	1	1	0
03/15/2015 08:00	0.5	13.8	1,296.7	0.5	0.4	1	1	0
03/15/2015 09:00	0.5	13.9	1,299.1	0.5	0.4	1	1	0
03/15/2015 10:00	0.5	13.9	1,300.9	0.5	0.4	1	1	0
03/15/2015 11:00	0.5	13.8	1,576.9	0.5	0.5	1	1	0
03/15/2015 12:00	0.5	13.8	1,763.2	0.5	0.5	1	1	0
03/15/2015 13:00	0.1	13.0	1,919.9	0.2	0.6	1	1	1
03/15/2015 14:00	0.1	12.5	2,064.1	0.2	0.6	1	1	1
03/15/2015 15:00	0.1	12.5	2,052.6	0.2	0.6	1	1	1
03/15/2015 16:00	0.1	12.5	2,059.2	0.2	0.6	1	1	1
03/15/2015 17:00	0.1	12.5	2,057.7	0.2	0.6	1	1	1
03/15/2015 18:00	0.1	12.5	2,053.6	0.2	0.6	1	1	1
03/15/2015 19:00	0.1	12.5	2,055.1	0.2	0.6	1	1	1
03/15/2015 20:00	0.1	12.5	2,054.6	0.2	0.6	1	1	1
03/15/2015 21:00	0.1	12.5	2,047.5	0.2	0.6	1	1	1
03/15/2015 22:00	0.2	13.0	1,852.7	0.4	0.6	1	1	1
03/15/2015 23:00	0.5	13.8	1,294.3	0.5	0.4	1	1	0
Average/Sum#:	0.3	13.2	1,802.6	0.4	0.5	24 #	24 #	13 #
Minimum:	0.1	12.5	1,294.3	0.2	0.4	1	1	0
Maximum:	0.5	13.9	2,064.1	0.5	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/16/2015 00:00	0.5	13.8	1,292.2	0.5	0.4	1	1	0
03/16/2015 01:00	0.5	13.8	1,289.9	0.5	0.4	1	1	0
03/16/2015 02:00	0.5	13.8	1,291.4	0.5	0.4	1	1	0
03/16/2015 03:00	0.5	13.8	1,294.5	0.5	0.4	1	1	0
03/16/2015 04:00	0.4	13.5	1,558.4	0.4	0.5	1	1	1
03/16/2015 05:00	0.1	12.7	2,016.3	0.2	0.6	1	1	1
03/16/2015 06:00	0.1	12.5	2,057.1	0.2	0.6	1	1	1
03/16/2015 07:00	0.1	12.8	2,008.7	0.2	0.6	1	1	1
03/16/2015 08:00	0.1	12.6	2,050.1	0.2	0.6	1	1	1
03/16/2015 09:00	0.1	12.5	2,054.9	0.2	0.6	1	1	1
03/16/2015 10:00	0.1	12.6	2,041.6	0.2	0.6	1	1	1
03/16/2015 11:00	0.1	12.5	2,056.0	0.2	0.6	1	1	1
03/16/2015 12:00	0.1	12.5	2,052.5	0.2	0.6	1	1	1
03/16/2015 13:00	0.1	12.5	2,053.6	0.2	0.6	1	1	1
03/16/2015 14:00	0.2	12.5	2,052.9	0.4	0.6	1	1	1
03/16/2015 15:00	0.1	12.5	2,044.9	0.2	0.6	1	1	1
03/16/2015 16:00	0.2	12.7	2,005.4	0.4	0.6	1	1	1
03/16/2015 17:00	0.2	12.8	1,976.3	0.4	0.6	1	1	1
03/16/2015 18:00	0.1	12.6	2,032.7	0.2	0.6	1	1	1
03/16/2015 19:00	0.1	12.5	2,049.6	0.2	0.6	1	1	1
03/16/2015 20:00	0.2	12.7	2,010.1	0.4	0.6	1	1	1
03/16/2015 21:00	0.2	12.8	1,978.1	0.4	0.6	1	1	1
03/16/2015 22:00	0.5	13.7	1,457.7	0.5	0.4	1	1	1
03/16/2015 23:00	0.5	13.8	1,292.7	0.5	0.4	1	1	0
Average/Sum#:	0.2	12.9	1,834.1	0.3	0.5	24 #	24 #	19 #
Minimum:	0.1	12.5	1,289.9	0.2	0.4	1	1	0
Maximum:	0.5	13.8	2,057.1	0.5	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/17/2015 00:00	0.5	13.8	1,291.3	0.5	0.4	1	1	0
03/17/2015 01:00	0.5	13.8	1,291.9	0.5	0.4	1	1	0
03/17/2015 02:00	0.5	13.8	1,292.1	0.5	0.4	1	1	0
03/17/2015 03:00	0.5	13.8	1,292.8	0.5	0.4	1	1	0
03/17/2015 04:00	0.5	13.8	1,292.4	0.5	0.4	1	1	0
03/17/2015 05:00	0.5	13.8	1,292.3	0.5	0.4	1	1	0
03/17/2015 06:00	0.5	13.8	1,292.5	0.5	0.4	1	1	0
03/17/2015 07:00	0.5	13.8	1,291.2	0.5	0.4	1	1	0
03/17/2015 08:00	0.5	13.8	1,293.0	0.5	0.4	1	1	0
03/17/2015 09:00	0.5	13.8	1,295.6	0.5	0.4	1	1	0
03/17/2015 10:00	0.5	13.8	1,299.0	0.5	0.4	1	1	0
03/17/2015 11:00	0.5	13.8	1,298.7	0.5	0.4	1	1	0
03/17/2015 12:00	0.5	13.8	1,300.8	0.5	0.4	1	1	0
03/17/2015 13:00	0.5	13.8	1,302.4	0.5	0.4	1	1	0
03/17/2015 14:00	0.5	13.8	1,303.0	0.5	0.4	1	1	0
03/17/2015 15:00	0.5	13.9	1,302.2	0.5	0.4	1	1	0
03/17/2015 16:00	0.5	13.9	1,299.8	0.5	0.4	1	1	0
03/17/2015 17:00	0.5	13.9	1,299.6	0.5	0.4	1	1	0
03/17/2015 18:00	0.5	13.9	1,298.0	0.5	0.4	1	1	0
03/17/2015 19:00	0.5	13.9	1,296.5	0.5	0.4	1	1	0
03/17/2015 20:00	0.5	13.8	1,294.6	0.5	0.4	1	1	0
03/17/2015 21:00	0.5	13.9	1,294.8	0.5	0.4	1	1	0
03/17/2015 22:00	0.5	13.9	1,292.8	0.5	0.4	1	1	0
03/17/2015 23:00	0.5	13.8	1,288.5	0.5	0.4	1	1	0
Average/Sum#:	0.5	13.8	1,295.7	0.5	0.4	24 #	24 #	0 #
Minimum:	0.5	13.8	1,288.5	0.5	0.4	1	1	0
Maximum:	0.5	13.9	1,303.0	0.5	0.4	1	1	0
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/18/2015 00:00	0.5	13.8	1,287.9	0.5	0.4	1	1	0
03/18/2015 01:00	0.5	13.9	1,291.9	0.5	0.4	1	1	0
03/18/2015 02:00	0.5	13.9	1,302.5	0.5	0.4	1	1	0
03/18/2015 03:00	0.5	13.9	1,304.6	0.5	0.4	1	1	0
03/18/2015 04:00	0.5	13.9	1,304.5	0.5	0.4	1	1	0
03/18/2015 05:00	0.5	13.9	1,303.3	0.5	0.4	1	1	0
03/18/2015 06:00	0.6	13.9	1,302.9	0.6	0.4	1	1	0
03/18/2015 07:00	0.6	13.9	1,301.9	0.6	0.4	1	1	0
03/18/2015 08:00	0.6	13.9	1,302.4	0.6	0.4	1	1	0
03/18/2015 09:00	0.0	13.9	1,300.7	0.0	0.4	1	0	0
03/18/2015 10:00	0.0	0.0	1,302.2	0.0	0.4	1	0	0
03/18/2015 11:00	0.0	13.9	1,300.9	0.0	0.4	1	0	0
03/18/2015 12:00	0.6	13.9	1,298.9	0.6	0.4	1	1	0
03/18/2015 13:00	0.6	13.9	1,298.4	0.6	0.4	1	1	0
03/18/2015 14:00	0.6	13.9	1,315.0	0.6	0.4	1	1	0
03/18/2015 15:00	0.6	13.8	1,665.4	0.6	0.5	1	1	0
03/18/2015 16:00	0.6	13.8	1,686.1	0.6	0.5	1	1	0
03/18/2015 17:00	0.6	13.9	1,285.3	0.6	0.4	1	1	0
03/18/2015 18:00	0.6	13.9	1,286.7	0.6	0.4	1	1	0
03/18/2015 19:00	0.6	13.9	1,285.8	0.6	0.4	1	1	0
03/18/2015 20:00	0.6	13.9	1,287.9	0.6	0.4	1	1	0
03/18/2015 21:00	0.6	13.9	1,289.5	0.6	0.4	1	1	0
03/18/2015 22:00	0.6	13.9	1,286.0	0.6	0.4	1	1	0
03/18/2015 23:00	0.6	13.9	1,285.0	0.6	0.4	1	1	0
Average/Sum#:	0.5	13.9	1,328.2	0.5	0.4	24 #	21 #	0 #
Minimum:	0.5	13.8	1,285.0	0.5	0.4	1	0	0
Maximum:	0.5	13.9	1,686.1	0.5	0.5	1	1	0
%SI	75.0	4.2	0.0	75.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/19/2015 00:00	0.6	13.9	1,285.3	0.6	0.4	1	1	0
03/19/2015 01:00	0.6	13.9	1,283.8	0.6	0.4	1	1	0
03/19/2015 02:00	0.6	13.9	1,283.8	0.6	0.4	1	1	0
03/19/2015 03:00	0.6	13.9	1,285.7	0.6	0.4	1	1	0
03/19/2015 04:00	0.4	13.9	1,287.4	0.4	0.4	1	1	0
03/19/2015 05:00	0.4	13.9	1,293.5	0.4	0.4	1	1	0
03/19/2015 06:00	0.4	13.9	1,409.6	0.4	0.4	1	1	1
03/19/2015 07:00	-0.1	12.9	1,990.1	0.1	0.6	1	1	1
03/19/2015 08:00	0.1	13.1	1,939.4	0.2	0.6	1	1	1
03/19/2015 09:00	0.1	13.0	1,946.7	0.2	0.6	1	1	1
03/19/2015 10:00	0.1	13.0	1,953.1	0.2	0.6	1	1	1
03/19/2015 11:00	0.1	12.9	1,977.3	0.2	0.6	1	1	1
03/19/2015 12:00	0.1	12.5	2,037.8	0.2	0.6	1	1	1
03/19/2015 13:00	0.1	12.8	1,983.0	0.2	0.6	1	1	1
03/19/2015 14:00	0.4	13.5	1,573.8	0.4	0.5	1	1	1
03/19/2015 15:00	0.5	13.9	1,324.9	0.5	0.4	1	1	0
03/19/2015 16:00	0.5	13.9	1,396.2	0.5	0.4	1	1	1
03/19/2015 17:00	0.1	12.9	1,959.3	0.2	0.6	1	1	1
03/19/2015 18:00	0.1	12.7	2,001.6	0.2	0.6	1	1	1
03/19/2015 19:00	0.1	12.4	2,062.5	0.2	0.6	1	1	1
03/19/2015 20:00	0.2	12.9	1,966.9	0.4	0.6	1	1	1
03/19/2015 21:00	0.2	13.2	1,753.1	0.4	0.5	1	1	1
03/19/2015 22:00	0.5	13.8	1,465.7	0.5	0.4	1	1	0
03/19/2015 23:00	0.5	13.8	1,309.9	0.5	0.4	1	1	0
Average/Sum#:	0.2	13.4	1,657.1	0.3	0.5	24 #	24 #	15 #
Minimum:	-0.1	12.4	1,283.8	0.1	0.4	1	1	0
Maximum:	0.5	13.9	2,062.5	0.5	0.6	1	1	1
%SI	16.7	0.0	0.0	16.7	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/20/2015 00:00	0.4	13.9	1,451.5	0.4	0.4	1	1	0
03/20/2015 01:00	0.4	13.8	1,301.1	0.4	0.4	1	1	0
03/20/2015 02:00	0.4	13.7	1,678.7	0.4	0.5	1	1	0
03/20/2015 03:00	0.4	13.8	1,320.9	0.4	0.4	1	1	0
03/20/2015 04:00	0.2	13.4	1,676.5	0.4	0.5	1	1	1
03/20/2015 05:00	-0.1	12.8	2,003.1	0.1	0.6	1	1	1
03/20/2015 06:00	-0.1	12.6	2,044.9	0.1	0.6	1	1	1
03/20/2015 07:00	0.7	0.0	1,971.4	0.7	0.6	1	1	1
03/20/2015 08:00	0.7	0.0	1,931.4	0.7	0.6	1	1	1
03/20/2015 09:00	0.6	0.0	1,805.5	0.6	0.5	1	1	0
03/20/2015 10:00	0.6	0.0	1,807.5	0.6	0.5	1	1	0
03/20/2015 11:00	0.4	13.4	1,817.4	0.4	0.5	1	1	1
03/20/2015 12:00	0.1	12.8	1,993.7	0.2	0.6	1	1	1
03/20/2015 13:00	0.1	12.6	2,013.6	0.2	0.6	1	1	1
03/20/2015 14:00	0.1	12.7	1,986.2	0.2	0.6	1	1	1
03/20/2015 15:00	0.1	12.7	1,980.5	0.2	0.6	1	1	1
03/20/2015 16:00	0.2	12.9	1,950.5	0.4	0.6	1	1	1
03/20/2015 17:00	0.2	12.9	1,947.3	0.4	0.6	1	1	1
03/20/2015 18:00	0.2	12.9	1,954.3	0.4	0.6	1	1	1
03/20/2015 19:00	0.2	12.9	1,948.7	0.4	0.6	1	1	1
03/20/2015 20:00	0.2	12.9	1,947.5	0.4	0.6	1	1	1
03/20/2015 21:00	0.2	13.0	1,948.7	0.4	0.6	1	1	1
03/20/2015 22:00	0.4	13.4	1,723.6	0.4	0.5	1	1	1
03/20/2015 23:00	0.5	13.8	1,292.0	0.5	0.4	1	1	0
Average/Sum#:	0.2	13.1	1,812.4	0.3	0.5	24 #	24 #	17 #
Minimum:	-0.1	12.6	1,292.0	0.1	0.4	1	1	0
Maximum:	0.5	13.9	2,044.9	0.5	0.6	1	1	1
%SI	16.7	16.7	0.0	16.7	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/21/2015 00:00	0.5	13.8	1,287.4	0.5	0.4	1	1	0
03/21/2015 01:00	0.5	13.8	1,533.2	0.5	0.5	1	1	0
03/21/2015 02:00	0.5	13.8	1,338.6	0.5	0.4	1	1	0
03/21/2015 03:00	0.5	13.8	1,556.3	0.5	0.5	1	1	0
03/21/2015 04:00	0.5	13.8	1,583.8	0.5	0.5	1	1	0
03/21/2015 05:00	0.4	13.7	1,491.5	0.4	0.4	1	1	1
03/21/2015 06:00	0.2	13.0	1,989.6	0.4	0.6	1	1	1
03/21/2015 07:00	0.2	13.3	1,777.4	0.4	0.5	1	1	1
03/21/2015 08:00	0.5	13.8	1,346.1	0.5	0.4	1	1	0
03/21/2015 09:00	0.5	13.8	1,307.8	0.5	0.4	1	1	0
03/21/2015 10:00	0.5	13.8	1,312.2	0.5	0.4	1	1	0
03/21/2015 11:00	0.5	13.8	1,315.0	0.5	0.4	1	1	0
03/21/2015 12:00	0.5	13.9	1,344.0	0.5	0.4	1	1	0
03/21/2015 13:00	0.5	13.9	1,312.9	0.5	0.4	1	1	0
03/21/2015 14:00	0.5	13.9	1,404.3	0.5	0.4	1	1	0
03/21/2015 15:00	0.5	13.9	1,491.2	0.5	0.4	1	1	0
03/21/2015 16:00	0.5	13.8	1,641.6	0.5	0.5	1	1	0
03/21/2015 17:00	0.2	13.1	1,810.5	0.4	0.5	1	1	1
03/21/2015 18:00	0.1	12.6	2,013.6	0.2	0.6	1	1	1
03/21/2015 19:00	0.1	12.6	2,015.0	0.2	0.6	1	1	1
03/21/2015 20:00	0.1	12.6	2,034.4	0.2	0.6	1	1	1
03/21/2015 21:00	0.1	12.7	2,009.1	0.2	0.6	1	1	1
03/21/2015 22:00	0.4	13.4	1,787.0	0.4	0.5	1	1	1
03/21/2015 23:00	0.5	13.7	1,755.4	0.5	0.5	1	1	0
Average/Sum#:	0.4	13.5	1,602.4	0.4	0.5	24 #	24 #	9 #
Minimum:	0.1	12.6	1,287.4	0.2	0.4	1	1	0
Maximum:	0.5	13.9	2,034.4	0.5	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/22/2015 00:00	0.5	13.6	1,806.6	0.5	0.5	1	1	0
03/22/2015 01:00	0.5	13.8	1,607.1	0.5	0.5	1	1	0
03/22/2015 02:00	0.5	13.7	1,654.4	0.5	0.5	1	1	0
03/22/2015 03:00	0.5	13.8	1,760.9	0.5	0.5	1	1	0
03/22/2015 04:00	0.5	13.8	1,523.2	0.5	0.5	1	1	0
03/22/2015 05:00	0.5	13.8	1,596.0	0.5	0.5	1	1	0
03/22/2015 06:00	0.5	13.8	1,643.3	0.5	0.5	1	1	0
03/22/2015 07:00	0.4	13.5	1,662.4	0.4	0.5	1	1	1
03/22/2015 08:00	0.1	12.5	2,044.8	0.2	0.6	1	1	1
03/22/2015 09:00	0.2	12.5	2,015.3	0.4	0.6	1	1	1
03/22/2015 10:00	0.2	12.8	1,953.9	0.4	0.6	1	1	1
03/22/2015 11:00	0.2	12.7	1,961.5	0.4	0.6	1	1	1
03/22/2015 12:00	0.2	12.8	1,976.8	0.4	0.6	1	1	1
03/22/2015 13:00	0.4	13.4	1,698.3	0.4	0.5	1	1	1
03/22/2015 14:00	0.5	13.8	1,609.1	0.5	0.5	1	1	0
03/22/2015 15:00	0.5	13.8	1,607.9	0.5	0.5	1	1	0
03/22/2015 16:00	0.5	13.9	1,565.1	0.5	0.5	1	1	0
03/22/2015 17:00	0.2	13.3	1,718.5	0.4	0.5	1	1	1
03/22/2015 18:00	0.1	12.7	2,017.0	0.2	0.6	1	1	1
03/22/2015 19:00	0.1	12.8	2,002.4	0.2	0.6	1	1	1
03/22/2015 20:00	0.2	12.9	1,976.6	0.4	0.6	1	1	1
03/22/2015 21:00	0.5	13.6	1,462.2	0.5	0.4	1	1	1
03/22/2015 22:00	0.5	13.8	1,301.0	0.5	0.4	1	1	0
03/22/2015 23:00	0.0	16.3	439.6	0.0	0.1	1	0	0
Average/Sum#:	0.3	13.5	1,691.8	0.4	0.5	24 #	23 #	12 #
Minimum:	0.0	12.5	439.6	0.0	0.1	1	0	0
Maximum:	0.5	16.3	2,044.8	0.5	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/23/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/24/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	VOC, Ppmvdc	VOC, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/25/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	VOC, Ppmvdc	VOC, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/26/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/27/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/28/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/29/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/30/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/31/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

ATTACHMENT 6
Hourly Emissions NOX

FCD: AQ-15
Title V: #6

Excess Emission Report

CT1 - NOx Lb 1-Day Block Average

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 12:36 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Lb_1D
Total Operating Time: 1,870.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 290.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,870.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NOx Lb 1-Day Block Average

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 12:37 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Lb_1D
Total Operating Time: 1,811.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 349.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,811.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/01/2015 00:00	1.5	11.9	2,249.1	1.0	9.00	1	1	1
01/01/2015 01:00	1.5	11.7	2,288.5	1.0	9.20	1	1	1
01/01/2015 02:00	1.5	11.7	2,277.8	1.0	9.10	1	1	1
01/01/2015 03:00	1.5	11.7	2,269.6	1.0	9.10	1	1	1
01/01/2015 04:00	1.5	12.0	2,227.2	1.0	8.90	1	1	1
01/01/2015 05:00	1.5	12.1	2,212.8	1.0	8.90	1	1	1
01/01/2015 06:00	1.5	11.7	2,296.2	1.0	9.20	1	1	1
01/01/2015 07:00	1.5	11.8	2,269.9	1.0	9.10	1	1	1
01/01/2015 08:00	1.2	13.1	1,942.5	0.9	5.80	1	1	1
01/01/2015 09:00	1.1	13.4	1,836.7	0.9	5.50	1	1	1
01/01/2015 10:00	0.8	13.8	1,449.7	0.7	2.90	1	1	1
01/01/2015 11:00	0.6	13.9	1,269.6	0.5	2.50	1	1	0
01/01/2015 12:00	0.6	13.9	1,272.4	0.5	2.50	1	1	0
01/01/2015 13:00	0.6	13.9	1,268.6	0.5	2.50	1	1	0
01/01/2015 14:00	0.6	13.9	1,266.0	0.5	2.50	1	1	0
01/01/2015 15:00	0.9	13.6	1,599.7	0.7	4.80	1	1	1
01/01/2015 16:00	1.1	13.3	1,913.4	0.9	5.70	1	1	1
01/01/2015 17:00	1.3	13.1	1,981.6	1.0	7.90	1	1	1
01/01/2015 18:00	1.4	12.6	2,091.4	1.0	8.40	1	1	1
01/01/2015 19:00	1.5	11.7	2,285.5	1.0	9.10	1	1	1
01/01/2015 20:00	1.5	11.7	2,290.4	1.0	9.20	1	1	1
01/01/2015 21:00	1.5	11.8	2,271.5	1.0	9.10	1	1	1
01/01/2015 22:00	1.5	11.9	2,267.4	1.0	9.10	1	1	1
01/01/2015 23:00	1.3	13.0	2,024.7	1.0	8.10	1	1	1
Average/Sum#:	1.2	12.6	1,963.4	0.9	168.10 #	24 #	24 #	20 #
Minimum:	0.6	11.7	1,266.0	0.5	2.50	1	1	0
Maximum:	1.5	13.9	2,296.2	1.0	9.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/02/2015 00:00	1.3	13.1	2,002.3	1.0	8.00	1	1	1
01/02/2015 01:00	1.4	12.7	2,069.6	1.0	8.30	1	1	1
01/02/2015 02:00	1.1	13.3	1,873.1	0.9	5.60	1	1	1
01/02/2015 03:00	1.3	13.0	2,037.6	1.0	8.20	1	1	1
01/02/2015 04:00	1.2	13.2	1,987.7	0.9	6.00	1	1	1
01/02/2015 05:00	1.3	13.0	2,017.2	1.0	8.10	1	1	1
01/02/2015 06:00	1.2	13.2	1,971.1	0.9	5.90	1	1	1
01/02/2015 07:00	1.1	13.3	1,967.7	0.9	5.90	1	1	1
01/02/2015 08:00	1.1	13.3	1,909.2	0.9	5.70	1	1	1
01/02/2015 09:00	1.1	13.3	1,841.9	0.9	5.50	1	1	1
01/02/2015 10:00	0.8	13.7	1,458.5	0.7	2.90	1	1	1
01/02/2015 11:00	0.7	13.8	1,307.8	0.6	2.60	1	1	0
01/02/2015 12:00	0.7	13.8	1,304.8	0.6	2.60	1	1	0
01/02/2015 13:00	0.7	13.9	1,310.1	0.6	2.60	1	1	0
01/02/2015 14:00	0.7	13.9	1,304.5	0.6	2.60	1	1	0
01/02/2015 15:00	0.9	13.7	1,641.6	0.7	4.90	1	1	1
01/02/2015 16:00	1.1	13.3	1,900.3	0.9	5.70	1	1	1
01/02/2015 17:00	1.5	12.2	2,188.5	1.0	8.80	1	1	1
01/02/2015 18:00	1.5	11.6	2,299.0	1.0	9.20	1	1	1
01/02/2015 19:00	1.5	11.6	2,294.4	1.0	9.20	1	1	1
01/02/2015 20:00	1.5	11.6	2,295.6	1.0	9.20	1	1	1
01/02/2015 21:00	1.5	11.6	2,296.1	1.0	9.20	1	1	1
01/02/2015 22:00	1.5	11.7	2,296.8	1.0	9.20	1	1	1
01/02/2015 23:00	1.5	12.1	2,219.1	1.0	8.90	1	1	1
Average/Sum#:	1.2	12.9	1,908.1	0.9	154.80 #	24 #	24 #	20 #
Minimum:	0.7	11.6	1,304.5	0.6	2.60	1	1	0
Maximum:	1.5	13.9	2,299.0	1.0	9.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/03/2015 00:00	1.4	12.4	2,158.1	1.0	8.60	1	1	1
01/03/2015 01:00	1.5	12.0	2,246.0	1.0	9.00	1	1	1
01/03/2015 02:00	1.4	12.4	2,149.4	1.0	8.60	1	1	1
01/03/2015 03:00	1.4	12.0	2,246.3	0.9	6.70	1	1	1
01/03/2015 04:00	1.3	12.7	2,092.2	0.9	6.30	1	1	1
01/03/2015 05:00	1.2	12.9	2,042.2	0.9	6.10	1	1	1
01/03/2015 06:00	1.4	12.4	2,164.0	1.0	8.70	1	1	1
01/03/2015 07:00	1.2	12.3	2,110.4	0.8	6.30	1	1	1
01/03/2015 08:00	1.0	13.3	1,896.5	0.8	5.70	1	1	1
01/03/2015 09:00	1.0	13.3	1,843.8	0.8	5.50	1	1	1
01/03/2015 10:00	1.0	13.3	1,845.3	0.8	5.50	1	1	1
01/03/2015 11:00	1.0	13.3	1,850.6	0.8	5.60	1	1	1
01/03/2015 12:00	0.7	13.8	1,356.1	0.6	2.70	1	1	0
01/03/2015 13:00	0.6	13.8	1,304.3	0.5	2.60	1	1	0
01/03/2015 14:00	0.6	13.9	1,301.7	0.5	2.60	1	1	0
01/03/2015 15:00	0.9	13.6	1,654.7	0.7	5.00	1	1	1
01/03/2015 16:00	1.2	13.0	1,983.0	0.9	5.90	1	1	1
01/03/2015 17:00	1.4	12.3	2,178.3	1.0	8.70	1	1	1
01/03/2015 18:00	1.5	11.7	2,298.7	1.0	9.20	1	1	1
01/03/2015 19:00	1.4	11.7	2,283.4	0.9	6.90	1	1	1
01/03/2015 20:00	1.5	11.7	2,284.4	1.0	9.10	1	1	1
01/03/2015 21:00	1.5	11.7	2,293.5	1.0	9.20	1	1	1
01/03/2015 22:00	1.4	12.0	2,235.7	0.9	6.70	1	1	1
01/03/2015 23:00	1.4	12.1	2,216.2	0.9	6.60	1	1	1
Average/Sum#:	1.2	12.7	2,001.5	0.9	157.80 #	24 #	24 #	21 #
Minimum:	0.6	11.7	1,301.7	0.5	2.60	1	1	0
Maximum:	1.5	13.9	2,298.7	1.0	9.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/04/2015 00:00	1.4	12.2	2,218.4	0.9	6.70	1	1	1
01/04/2015 01:00	1.2	13.1	1,998.5	0.9	6.00	1	1	1
01/04/2015 02:00	1.1	13.2	1,983.0	0.8	5.90	1	1	1
01/04/2015 03:00	1.1	13.2	1,981.0	0.8	5.90	1	1	1
01/04/2015 04:00	1.1	13.2	1,962.4	0.8	5.90	1	1	1
01/04/2015 05:00	1.0	13.2	1,967.9	0.8	5.90	1	1	1
01/04/2015 06:00	1.3	12.6	2,119.3	0.9	6.40	1	1	1
01/04/2015 07:00	1.4	11.9	2,245.7	0.9	6.70	1	1	1
01/04/2015 08:00	1.1	13.2	1,946.0	0.8	5.80	1	1	1
01/04/2015 09:00	1.0	13.3	1,908.8	0.8	5.70	1	1	1
01/04/2015 10:00	1.0	13.3	1,893.1	0.8	5.70	1	1	1
01/04/2015 11:00	0.9	13.3	1,858.2	0.7	5.60	1	1	1
01/04/2015 12:00	0.9	13.3	1,849.9	0.7	5.50	1	1	1
01/04/2015 13:00	1.0	13.3	1,875.9	0.8	5.60	1	1	1
01/04/2015 14:00	1.3	13.1	1,989.3	1.0	8.00	1	1	1
01/04/2015 15:00	1.2	13.0	2,004.9	0.9	6.00	1	1	1
01/04/2015 16:00	1.2	12.9	2,010.1	0.9	6.00	1	1	1
01/04/2015 17:00	1.4	11.9	2,239.2	0.9	6.70	1	1	1
01/04/2015 18:00	1.4	11.6	2,308.2	0.9	6.90	1	1	1
01/04/2015 19:00	1.5	11.6	2,314.7	1.0	9.30	1	1	1
01/04/2015 20:00	1.5	11.6	2,314.8	1.0	9.30	1	1	1
01/04/2015 21:00	1.4	11.8	2,257.8	0.9	6.80	1	1	1
01/04/2015 22:00	1.4	11.9	2,239.4	0.9	6.70	1	1	1
01/04/2015 23:00	1.0	13.2	1,897.5	0.8	5.70	1	1	1
Average/Sum#:	1.2	12.7	2,057.7	0.9	154.70 #	24 #	24 #	24 #
Minimum:	0.9	11.6	1,849.9	0.7	5.50	1	1	1
Maximum:	1.5	13.3	2,314.8	1.0	9.30	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/05/2015 00:00	0.9	13.3	1,853.4	0.7	5.60	1	1	1
01/05/2015 01:00	1.0	13.3	1,941.2	0.8	5.80	1	1	1
01/05/2015 02:00	1.0	13.3	1,860.9	0.8	5.60	1	1	1
01/05/2015 03:00	1.1	13.2	1,969.6	0.8	5.90	1	1	1
01/05/2015 04:00	1.0	13.3	1,903.3	0.8	5.70	1	1	1
01/05/2015 05:00	1.0	13.3	1,922.6	0.8	5.80	1	1	1
01/05/2015 06:00	1.2	13.0	2,033.0	0.9	6.10	1	1	1
01/05/2015 07:00	1.4	11.9	2,283.7	0.9	6.90	1	1	1
01/05/2015 08:00	1.4	11.9	2,263.0	0.9	6.80	1	1	1
01/05/2015 09:00	1.0	13.2	1,918.7	0.8	5.80	1	1	1
01/05/2015 10:00	0.9	13.3	1,850.8	0.7	5.60	1	1	1
01/05/2015 11:00	0.9	13.3	1,849.2	0.7	5.50	1	1	1
01/05/2015 12:00	0.9	13.3	1,852.4	0.7	5.60	1	1	1
01/05/2015 13:00	0.9	13.4	1,867.2	0.7	5.60	1	1	1
01/05/2015 14:00	1.2	12.9	1,987.1	0.9	6.00	1	1	1
01/05/2015 15:00	1.2	13.0	1,966.7	0.9	5.90	1	1	1
01/05/2015 16:00	1.2	12.9	1,987.0	0.9	6.00	1	1	1
01/05/2015 17:00	1.4	11.8	2,233.2	0.9	6.70	1	1	1
01/05/2015 18:00	1.5	11.5	2,312.9	0.9	6.90	1	1	1
01/05/2015 19:00	1.5	11.4	2,317.9	0.9	7.00	1	1	1
01/05/2015 20:00	1.5	11.5	2,316.3	0.9	6.90	1	1	1
01/05/2015 21:00	1.4	12.1	2,184.4	0.9	6.60	1	1	1
01/05/2015 22:00	1.2	12.9	2,021.9	0.9	6.10	1	1	1
01/05/2015 23:00	0.9	13.4	1,709.9	0.7	5.10	1	1	1
Average/Sum#:	1.2	12.8	2,016.9	0.8	145.50 #	24 #	24 #	24 #
Minimum:	0.9	11.4	1,709.9	0.7	5.10	1	1	1
Maximum:	1.5	13.4	2,317.9	0.9	7.00	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/06/2015 00:00	0.7	13.8	1,436.9	0.6	2.90	1	1	0
01/06/2015 01:00	0.8	13.8	1,653.6	0.7	3.30	1	1	0
01/06/2015 02:00	0.8	13.6	1,715.2	0.6	3.40	1	1	1
01/06/2015 03:00	0.9	13.3	1,859.9	0.7	5.60	1	1	1
01/06/2015 04:00	1.0	13.3	1,859.3	0.8	5.60	1	1	1
01/06/2015 05:00	1.0	13.3	1,919.1	0.8	5.80	1	1	1
01/06/2015 06:00	1.2	12.8	2,049.0	0.9	6.10	1	1	1
01/06/2015 07:00	1.4	11.7	2,286.5	0.9	6.90	1	1	1
01/06/2015 08:00	1.2	12.5	2,085.4	0.8	6.30	1	1	1
01/06/2015 09:00	0.9	13.3	1,848.1	0.7	5.50	1	1	1
01/06/2015 10:00	0.8	13.6	1,549.8	0.6	3.10	1	1	1
01/06/2015 11:00	0.6	13.8	1,301.1	0.5	2.60	1	1	0
01/06/2015 12:00	0.6	13.9	1,301.4	0.5	2.60	1	1	0
01/06/2015 13:00	0.7	13.9	1,445.5	0.6	2.90	1	1	0
01/06/2015 14:00	0.6	13.9	1,304.6	0.5	2.60	1	1	0
01/06/2015 15:00	0.9	13.6	1,635.8	0.7	4.90	1	1	1
01/06/2015 16:00	1.0	13.1	1,931.0	0.8	5.80	1	1	1
01/06/2015 17:00	1.2	12.7	2,026.1	0.9	6.10	1	1	1
01/06/2015 18:00	1.3	12.5	2,061.5	0.9	6.20	1	1	1
01/06/2015 19:00	1.4	12.5	2,089.3	1.0	8.40	1	1	1
01/06/2015 20:00	1.3	12.2	2,136.3	0.9	6.40	1	1	1
01/06/2015 21:00	1.3	12.3	2,131.0	0.9	6.40	1	1	1
01/06/2015 22:00	1.3	12.5	2,072.2	0.9	6.20	1	1	1
01/06/2015 23:00	0.9	13.3	1,874.4	0.7	5.60	1	1	1
Average/Sum#:	1.0	13.1	1,815.5	0.7	121.20 #	24 #	24 #	18 #
Minimum:	0.6	11.7	1,301.1	0.5	2.60	1	1	0
Maximum:	1.4	13.9	2,286.5	1.0	8.40	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/07/2015 00:00	1.0	13.2	1,915.2	0.8	5.70	1	1	1
01/07/2015 01:00	0.9	13.3	1,868.2	0.7	5.60	1	1	1
01/07/2015 02:00	0.9	13.3	1,891.9	0.7	5.70	1	1	1
01/07/2015 03:00	0.9	13.3	1,859.0	0.7	5.60	1	1	1
01/07/2015 04:00	1.1	13.1	1,953.2	0.8	5.90	1	1	1
01/07/2015 05:00	1.0	13.2	1,903.0	0.8	5.70	1	1	1
01/07/2015 06:00	1.2	12.8	2,072.7	0.9	6.20	1	1	1
01/07/2015 07:00	1.5	12.0	2,242.6	1.0	9.00	1	1	1
01/07/2015 08:00	1.1	12.8	2,015.4	0.8	6.00	1	1	1
01/07/2015 09:00	1.0	13.3	1,891.2	0.8	5.70	1	1	1
01/07/2015 10:00	0.9	13.4	1,852.0	0.7	5.60	1	1	1
01/07/2015 11:00	0.9	13.4	1,837.5	0.7	5.50	1	1	1
01/07/2015 12:00	0.6	13.9	1,307.2	0.5	2.60	1	1	0
01/07/2015 13:00	0.7	13.8	1,493.8	0.6	3.00	1	1	0
01/07/2015 14:00	0.8	13.9	1,559.2	0.7	3.10	1	1	1
01/07/2015 15:00	1.2	12.8	1,992.1	0.9	6.00	1	1	1
01/07/2015 16:00	1.2	12.9	1,973.7	0.9	5.90	1	1	1
01/07/2015 17:00	1.4	11.9	2,181.5	0.9	6.50	1	1	1
01/07/2015 18:00	1.3	12.6	2,054.2	0.9	6.20	1	1	1
01/07/2015 19:00	1.2	12.8	2,015.1	0.9	6.00	1	1	1
01/07/2015 20:00	1.3	12.7	2,017.2	0.9	6.10	1	1	1
01/07/2015 21:00	1.3	12.7	2,024.6	0.9	6.10	1	1	1
01/07/2015 22:00	1.1	13.1	1,926.2	0.8	5.80	1	1	1
01/07/2015 23:00	0.9	13.4	1,853.9	0.7	5.60	1	1	1
Average/Sum#:	1.1	13.1	1,904.2	0.8	135.10 #	24 #	24 #	22 #
Minimum:	0.6	11.9	1,307.2	0.5	2.60	1	1	0
Maximum:	1.5	13.9	2,242.6	1.0	9.00	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/08/2015 00:00	0.9	13.4	1,847.6	0.7	5.50	1	1	1
01/08/2015 01:00	0.9	13.4	1,849.2	0.7	5.50	1	1	1
01/08/2015 02:00	0.9	13.4	1,847.0	0.7	5.50	1	1	1
01/08/2015 03:00	0.9	13.4	1,849.8	0.7	5.50	1	1	1
01/08/2015 04:00	0.9	13.3	1,846.5	0.7	5.50	1	1	1
01/08/2015 05:00	0.9	13.3	1,851.9	0.7	5.60	1	1	1
01/08/2015 06:00	1.2	12.7	2,075.8	0.9	6.20	1	1	1
01/08/2015 07:00	1.5	11.6	2,294.9	1.0	9.20	1	1	1
01/08/2015 08:00	1.5	11.7	2,266.0	1.0	9.10	1	1	1
01/08/2015 09:00	1.4	12.1	2,179.1	0.9	6.50	1	1	1
01/08/2015 10:00	1.2	12.6	2,060.4	0.9	6.20	1	1	1
01/08/2015 11:00	1.2	12.9	1,982.2	0.9	5.90	1	1	1
01/08/2015 12:00	1.2	12.8	2,014.7	0.9	6.00	1	1	1
01/08/2015 13:00	1.3	12.4	2,089.5	0.9	6.30	1	1	1
01/08/2015 14:00	1.3	12.5	2,081.3	0.9	6.20	1	1	1
01/08/2015 15:00	1.5	11.5	2,269.6	0.9	6.80	1	1	1
01/08/2015 16:00	1.2	12.6	2,021.7	0.9	6.10	1	1	1
01/08/2015 17:00	1.3	12.5	2,052.3	0.9	6.20	1	1	1
01/08/2015 18:00	1.3	12.5	2,057.4	0.9	6.20	1	1	1
01/08/2015 19:00	1.2	12.8	2,002.1	0.9	6.00	1	1	1
01/08/2015 20:00	1.2	12.7	2,016.5	0.9	6.00	1	1	1
01/08/2015 21:00	1.3	12.3	2,103.7	0.9	6.30	1	1	1
01/08/2015 22:00	1.3	12.7	2,016.7	0.9	6.10	1	1	1
01/08/2015 23:00	1.0	13.1	1,908.7	0.8	5.70	1	1	1
Average/Sum#:	1.2	12.7	2,024.4	0.9	150.10 #	24 #	24 #	24 #
Minimum:	0.9	11.5	1,846.5	0.7	5.50	1	1	1
Maximum:	1.5	13.4	2,294.9	1.0	9.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/09/2015 00:00	1.1	13.1	1,941.5	0.8	5.80	1	1	1
01/09/2015 01:00	1.0	13.3	1,889.2	0.8	5.70	1	1	1
01/09/2015 02:00	0.9	13.3	1,852.4	0.7	5.60	1	1	1
01/09/2015 03:00	1.1	13.2	1,916.3	0.8	5.70	1	1	1
01/09/2015 04:00	0.9	13.4	1,858.6	0.7	5.60	1	1	1
01/09/2015 05:00	1.0	13.3	1,900.8	0.8	5.70	1	1	1
01/09/2015 06:00	1.0	13.1	1,945.7	0.8	5.80	1	1	1
01/09/2015 07:00	1.3	12.4	2,144.4	0.9	6.40	1	1	1
01/09/2015 08:00	1.5	11.6	2,282.1	1.0	9.10	1	1	1
01/09/2015 09:00	1.2	12.6	2,050.6	0.9	6.20	1	1	1
01/09/2015 10:00	1.4	11.9	2,217.9	0.9	6.70	1	1	1
01/09/2015 11:00	1.4	11.7	2,236.5	0.9	6.70	1	1	1
01/09/2015 12:00	1.0	13.3	1,889.8	0.8	5.70	1	1	1
01/09/2015 13:00	0.8	13.5	1,693.1	0.6	3.40	1	1	1
01/09/2015 14:00	0.6	13.9	1,388.3	0.5	2.80	1	1	0
01/09/2015 15:00	0.6	13.9	1,374.8	0.5	2.70	1	1	0
01/09/2015 16:00	0.9	13.4	1,692.6	0.7	5.10	1	1	1
01/09/2015 17:00	0.9	13.3	1,881.0	0.7	5.60	1	1	1
01/09/2015 18:00	1.0	13.3	1,794.7	0.8	5.40	1	1	1
01/09/2015 19:00	1.0	13.4	1,802.3	0.8	5.40	1	1	1
01/09/2015 20:00	1.0	13.4	1,872.3	0.8	5.60	1	1	1
01/09/2015 21:00	1.0	13.4	1,879.5	0.8	5.60	1	1	1
01/09/2015 22:00	1.1	13.2	1,918.2	0.8	5.80	1	1	1
01/09/2015 23:00	1.2	13.0	1,968.5	0.9	5.90	1	1	1
Average/Sum#:	1.0	13.1	1,891.3	0.8	134.00 #	24 #	24 #	22 #
Minimum:	0.6	11.6	1,374.8	0.5	2.70	1	1	0
Maximum:	1.5	13.9	2,282.1	1.0	9.10	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/10/2015 00:00	1.0	13.4	1,871.5	0.8	5.60	1	1	1
01/10/2015 01:00	0.9	13.5	1,845.4	0.7	5.50	1	1	1
01/10/2015 02:00	0.9	13.6	1,705.9	0.7	5.10	1	1	1
01/10/2015 03:00	0.6	13.9	1,360.4	0.5	2.70	1	1	0
01/10/2015 04:00	0.8	13.6	1,625.7	0.6	3.30	1	1	1
01/10/2015 05:00	1.0	13.3	1,899.5	0.8	5.70	1	1	1
01/10/2015 06:00	1.2	13.1	1,942.2	0.9	5.80	1	1	1
01/10/2015 07:00	1.2	13.1	1,956.5	0.9	5.90	1	1	1
01/10/2015 08:00	1.0	13.3	1,876.0	0.8	5.60	1	1	1
01/10/2015 09:00	0.9	13.3	1,856.3	0.7	5.60	1	1	1
01/10/2015 10:00	1.1	13.1	1,964.4	0.8	5.90	1	1	1
01/10/2015 11:00	1.4	11.9	2,216.0	0.9	6.60	1	1	1
01/10/2015 12:00	1.4	12.0	2,169.9	0.9	6.50	1	1	1
01/10/2015 13:00	1.1	13.1	1,939.5	0.8	5.80	1	1	1
01/10/2015 14:00	1.2	12.8	1,999.8	0.9	6.00	1	1	1
01/10/2015 15:00	0.9	13.4	1,863.8	0.7	5.60	1	1	1
01/10/2015 16:00	1.0	13.2	1,899.6	0.8	5.70	1	1	1
01/10/2015 17:00	1.3	12.6	2,055.6	0.9	6.20	1	1	1
01/10/2015 18:00	1.2	12.9	1,985.0	0.9	6.00	1	1	1
01/10/2015 19:00	1.3	12.6	2,057.1	0.9	6.20	1	1	1
01/10/2015 20:00	1.5	11.6	2,267.6	1.0	9.10	1	1	1
01/10/2015 21:00	1.3	12.3	2,106.3	0.9	6.30	1	1	1
01/10/2015 22:00	1.2	12.7	2,026.5	0.9	6.10	1	1	1
01/10/2015 23:00	1.0	13.2	1,906.6	0.8	5.70	1	1	1
Average/Sum#:	1.1	13.0	1,933.2	0.8	138.50 #	24 #	24 #	23 #
Minimum:	0.6	11.6	1,360.4	0.5	2.70	1	1	0
Maximum:	1.5	13.9	2,267.6	1.0	9.10	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/11/2015 00:00	1.0	13.2	1,911.0	0.8	5.70	1	1	1
01/11/2015 01:00	1.0	13.2	1,915.6	0.8	5.70	1	1	1
01/11/2015 02:00	1.1	13.2	1,925.5	0.8	5.80	1	1	1
01/11/2015 03:00	0.9	13.4	1,855.6	0.7	5.60	1	1	1
01/11/2015 04:00	0.9	13.4	1,852.0	0.7	5.60	1	1	1
01/11/2015 05:00	1.0	13.3	1,889.3	0.8	5.70	1	1	1
01/11/2015 06:00	1.0	13.3	1,884.5	0.8	5.70	1	1	1
01/11/2015 07:00	1.0	13.2	1,927.2	0.8	5.80	1	1	1
01/11/2015 08:00	1.3	12.5	2,100.2	0.9	6.30	1	1	1
01/11/2015 09:00	1.4	11.7	2,268.5	0.9	6.80	1	1	1
01/11/2015 10:00	1.5	11.7	2,254.0	1.0	9.00	1	1	1
01/11/2015 11:00	1.4	12.1	2,168.1	0.9	6.50	1	1	1
01/11/2015 12:00	1.2	12.9	1,985.3	0.9	6.00	1	1	1
01/11/2015 13:00	1.2	12.9	1,980.1	0.9	5.90	1	1	1
01/11/2015 14:00	1.0	13.2	1,914.8	0.8	5.70	1	1	1
01/11/2015 15:00	1.2	12.9	2,005.7	0.9	6.00	1	1	1
01/11/2015 16:00	1.0	13.3	1,903.9	0.8	5.70	1	1	1
01/11/2015 17:00	1.3	12.3	2,127.9	0.9	6.40	1	1	1
01/11/2015 18:00	1.3	12.3	2,130.6	0.9	6.40	1	1	1
01/11/2015 19:00	1.4	11.8	2,223.7	0.9	6.70	1	1	1
01/11/2015 20:00	1.4	12.3	2,117.4	1.0	8.50	1	1	1
01/11/2015 21:00	1.4	12.1	2,149.3	0.9	6.40	1	1	1
01/11/2015 22:00	1.1	13.0	1,946.8	0.8	5.80	1	1	1
01/11/2015 23:00	0.9	13.4	1,850.7	0.7	5.60	1	1	1
Average/Sum#:	1.2	12.8	2,012.0	0.8	149.30 #	24 #	24 #	24 #
Minimum:	0.9	11.7	1,850.7	0.7	5.60	1	1	1
Maximum:	1.5	13.4	2,268.5	1.0	9.00	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/12/2015 00:00	1.1	13.1	1,953.1	0.8	5.90	1	1	1
01/12/2015 01:00	1.0	13.3	1,886.0	0.8	5.70	1	1	1
01/12/2015 02:00	0.9	13.3	1,888.2	0.7	5.70	1	1	1
01/12/2015 03:00	1.1	13.2	1,940.7	0.8	5.80	1	1	1
01/12/2015 04:00	1.0	13.2	1,920.1	0.8	5.80	1	1	1
01/12/2015 05:00	1.0	13.2	1,912.7	0.8	5.70	1	1	1
01/12/2015 06:00	1.2	13.0	2,000.2	0.9	6.00	1	1	1
01/12/2015 07:00	1.2	13.0	1,981.3	0.9	5.90	1	1	1
01/12/2015 08:00	1.2	13.1	1,982.8	0.9	5.90	1	1	1
01/12/2015 09:00	1.3	12.5	2,097.7	0.9	6.30	1	1	1
01/12/2015 10:00	1.2	12.8	2,020.9	0.9	6.10	1	1	1
01/12/2015 11:00	0.9	13.3	1,862.6	0.7	5.60	1	1	1
01/12/2015 12:00	0.9	13.4	1,857.0	0.7	5.60	1	1	1
01/12/2015 13:00	0.9	13.4	1,859.2	0.7	5.60	1	1	1
01/12/2015 14:00	0.9	13.4	1,864.3	0.7	5.60	1	1	1
01/12/2015 15:00	0.9	13.4	1,867.7	0.7	5.60	1	1	1
01/12/2015 16:00	1.0	13.3	1,900.6	0.8	5.70	1	1	1
01/12/2015 17:00	1.2	12.9	1,982.6	0.9	5.90	1	1	1
01/12/2015 18:00	1.5	11.8	2,237.2	1.0	8.90	1	1	1
01/12/2015 19:00	1.5	11.5	2,283.9	0.9	6.90	1	1	1
01/12/2015 20:00	1.4	11.5	2,289.6	0.9	6.90	1	1	1
01/12/2015 21:00	1.4	11.9	2,204.2	0.9	6.60	1	1	1
01/12/2015 22:00	1.3	12.4	2,108.4	0.9	6.30	1	1	1
01/12/2015 23:00	1.1	13.1	1,927.1	0.8	5.80	1	1	1
Average/Sum#:	1.1	12.9	1,992.8	0.8	145.80 #	24 #	24 #	24 #
Minimum:	0.9	11.5	1,857.0	0.7	5.60	1	1	1
Maximum:	1.5	13.4	2,289.6	1.0	8.90	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/13/2015 00:00	1.3	12.8	2,016.7	0.9	6.10	1	1	1
01/13/2015 01:00	1.3	12.8	2,008.9	0.9	6.00	1	1	1
01/13/2015 02:00	1.3	12.9	2,001.1	1.0	8.00	1	1	1
01/13/2015 03:00	1.2	13.0	1,971.8	0.9	5.90	1	1	1
01/13/2015 04:00	1.2	13.2	1,929.0	0.9	5.80	1	1	1
01/13/2015 05:00	1.0	13.4	1,860.4	0.8	5.60	1	1	1
01/13/2015 06:00	1.1	13.2	1,916.4	0.8	5.70	1	1	1
01/13/2015 07:00	1.3	12.9	2,011.1	1.0	8.00	1	1	1
01/13/2015 08:00	1.2	13.2	1,934.7	0.9	5.80	1	1	1
01/13/2015 09:00	1.0	13.4	1,878.3	0.8	5.60	1	1	1
01/13/2015 10:00	1.3	12.9	2,002.5	1.0	8.00	1	1	1
01/13/2015 11:00	1.2	12.8	2,012.3	0.9	6.00	1	1	1
01/13/2015 12:00	1.1	13.1	1,936.1	0.8	5.80	1	1	1
01/13/2015 13:00	1.2	13.0	1,959.1	0.9	5.90	1	1	1
01/13/2015 14:00	1.1	13.1	1,929.7	0.8	5.80	1	1	1
01/13/2015 15:00	1.0	13.3	1,905.9	0.8	5.70	1	1	1
01/13/2015 16:00	1.1	13.3	1,907.8	0.9	5.70	1	1	1
01/13/2015 17:00	1.4	12.3	2,138.0	1.0	8.60	1	1	1
01/13/2015 18:00	1.4	11.6	2,281.6	0.9	6.80	1	1	1
01/13/2015 19:00	1.4	11.6	2,281.2	0.9	6.80	1	1	1
01/13/2015 20:00	1.4	11.6	2,277.2	0.9	6.80	1	1	1
01/13/2015 21:00	1.4	12.0	2,191.4	0.9	6.60	1	1	1
01/13/2015 22:00	1.3	12.3	2,109.5	0.9	6.30	1	1	1
01/13/2015 23:00	0.9	13.6	1,633.9	0.7	4.90	1	1	1
Average/Sum#:	1.2	12.8	2,003.9	0.9	152.20 #	24 #	24 #	24 #
Minimum:	0.9	11.6	1,633.9	0.7	4.90	1	1	1
Maximum:	1.4	13.6	2,281.6	1.0	8.60	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/14/2015 00:00	0.6	13.9	1,341.9	0.5	2.70	1	1	0
01/14/2015 01:00	0.8	13.8	1,577.7	0.7	3.20	1	1	0
01/14/2015 02:00	0.9	13.6	1,700.8	0.7	5.10	1	1	1
01/14/2015 03:00	1.1	13.2	1,925.6	0.8	5.80	1	1	1
01/14/2015 04:00	1.2	13.2	1,965.7	0.9	5.90	1	1	1
01/14/2015 05:00	1.0	13.3	1,872.9	0.8	5.60	1	1	1
01/14/2015 06:00	1.1	13.0	1,972.6	0.8	5.90	1	1	1
01/14/2015 07:00	1.5	12.0	2,240.7	1.0	9.00	1	1	1
01/14/2015 08:00	1.3	12.5	2,105.1	0.9	6.30	1	1	1
01/14/2015 09:00	1.2	13.1	1,965.4	0.9	5.90	1	1	1
01/14/2015 10:00	1.0	13.2	1,885.7	0.8	5.70	1	1	1
01/14/2015 11:00	0.9	13.3	1,852.0	0.7	5.60	1	1	1
01/14/2015 12:00	1.0	13.3	1,853.9	0.8	5.60	1	1	1
01/14/2015 13:00	1.0	13.3	1,861.5	0.8	5.60	1	1	1
01/14/2015 14:00	1.0	13.4	1,867.5	0.8	5.60	1	1	1
01/14/2015 15:00	1.1	13.4	1,878.6	0.9	5.60	1	1	1
01/14/2015 16:00	1.2	13.3	1,923.3	0.9	5.80	1	1	1
01/14/2015 17:00	1.6	12.5	2,109.9	1.1	8.40	1	1	1
01/14/2015 18:00	2.2	11.6	2,287.7	1.4	11.40	1	1	1
01/14/2015 19:00	2.1	11.7	2,287.9	1.3	11.40	1	1	1
01/14/2015 20:00	1.5	11.7	2,286.7	1.0	9.10	1	1	1
01/14/2015 21:00	1.6	11.8	2,273.1	1.0	9.10	1	1	1
01/14/2015 22:00	1.4	12.6	2,076.8	1.0	8.30	1	1	1
01/14/2015 23:00	1.2	13.4	1,878.2	0.9	5.60	1	1	1
Average/Sum#:	1.2	12.9	1,958.0	0.9	158.20 #	24 #	24 #	22 #
Minimum:	0.6	11.6	1,341.9	0.5	2.70	1	1	0
Maximum:	2.2	13.9	2,287.9	1.4	11.40	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/15/2015 00:00	1.2	13.3	1,903.4	0.9	5.70	1	1	1
01/15/2015 01:00	1.2	13.4	1,848.5	0.9	5.50	1	1	1
01/15/2015 02:00	1.2	13.4	1,846.5	0.9	5.50	1	1	1
01/15/2015 03:00	1.2	13.4	1,851.6	0.9	5.60	1	1	1
01/15/2015 04:00	1.2	13.4	1,859.6	0.9	5.60	1	1	1
01/15/2015 05:00	1.2	13.4	1,856.0	0.9	5.60	1	1	1
01/15/2015 06:00	1.3	13.1	1,984.5	1.0	7.90	1	1	1
01/15/2015 07:00	1.5	12.3	2,207.9	1.0	8.80	1	1	1
01/15/2015 08:00	1.3	13.0	1,979.3	1.0	7.90	1	1	1
01/15/2015 09:00	1.0	13.6	1,572.7	0.8	4.70	1	1	1
01/15/2015 10:00	0.8	13.9	1,302.2	0.7	2.60	1	1	0
01/15/2015 11:00	0.8	13.9	1,304.2	0.7	2.60	1	1	0
01/15/2015 12:00	0.9	13.9	1,304.0	0.8	3.90	1	1	0
01/15/2015 13:00	0.8	13.9	1,299.9	0.7	2.60	1	1	0
01/15/2015 14:00	0.9	13.9	1,299.7	0.8	3.90	1	1	0
01/15/2015 15:00	0.9	13.9	1,332.8	0.8	4.00	1	1	0
01/15/2015 16:00	1.2	13.4	1,880.8	0.9	5.60	1	1	1
01/15/2015 17:00	1.6	12.1	2,218.1	1.1	8.90	1	1	1
01/15/2015 18:00	1.2	13.2	1,881.3	0.9	5.60	1	1	1
01/15/2015 19:00	1.4	12.7	2,065.5	1.0	8.30	1	1	1
01/15/2015 20:00	1.5	12.6	2,066.1	1.1	8.30	1	1	1
01/15/2015 21:00	1.5	12.6	2,090.5	1.1	8.40	1	1	1
01/15/2015 22:00	1.5	12.3	2,133.8	1.0	8.50	1	1	1
01/15/2015 23:00	1.2	13.2	1,881.8	0.9	5.60	1	1	1
Average/Sum#:	1.2	13.2	1,790.4	0.9	141.60 #	24 #	24 #	18 #
Minimum:	0.8	12.1	1,299.7	0.7	2.60	1	1	0
Maximum:	1.6	13.9	2,218.1	1.1	8.90	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/16/2015 00:00	1.2	13.3	1,845.7	0.9	5.50	1	1	1
01/16/2015 01:00	1.2	13.3	1,848.6	0.9	5.50	1	1	1
01/16/2015 02:00	1.2	13.3	1,853.9	0.9	5.60	1	1	1
01/16/2015 03:00	1.0	13.6	1,622.1	0.8	4.90	1	1	1
01/16/2015 04:00	0.8	13.9	1,320.0	0.7	2.60	1	1	0
01/16/2015 05:00	1.1	13.4	1,834.2	0.9	5.50	1	1	1
01/16/2015 06:00	1.3	13.1	1,954.4	1.0	7.80	1	1	1
01/16/2015 07:00	1.6	12.1	2,204.3	1.1	8.80	1	1	1
01/16/2015 08:00	1.3	13.2	1,929.8	1.0	7.70	1	1	1
01/16/2015 09:00	1.2	13.5	1,853.0	1.0	7.40	1	1	1
01/16/2015 10:00	1.2	13.5	1,870.6	1.0	7.50	1	1	1
01/16/2015 11:00	1.2	13.4	1,888.8	0.9	5.70	1	1	1
01/16/2015 12:00	0.9	13.7	1,475.3	0.7	4.40	1	1	1
01/16/2015 13:00	0.7	13.9	1,284.5	0.6	2.60	1	1	0
01/16/2015 14:00	0.7	13.9	1,281.9	0.6	2.60	1	1	0
01/16/2015 15:00	0.7	13.9	1,282.9	0.6	2.60	1	1	0
01/16/2015 16:00	1.2	13.3	1,750.4	0.9	5.30	1	1	1
01/16/2015 17:00	1.4	12.9	1,903.4	1.0	7.60	1	1	1
01/16/2015 18:00	0.7	13.9	1,333.6	0.6	2.70	1	1	0
01/16/2015 19:00	0.7	13.9	1,294.3	0.6	2.60	1	1	0
01/16/2015 20:00	0.7	13.9	1,299.4	0.6	2.60	1	1	0
01/16/2015 21:00	0.7	13.9	1,317.3	0.6	2.60	1	1	0
01/16/2015 22:00	0.9	13.9	1,521.6	0.8	4.60	1	1	0
01/16/2015 23:00	0.8	13.9	1,306.3	0.7	2.60	1	1	0
Average/Sum#:	1.0	13.5	1,628.2	0.8	117.30 #	24 #	24 #	14 #
Minimum:	0.7	12.1	1,281.9	0.6	2.60	1	1	0
Maximum:	1.6	13.9	2,204.3	1.1	8.80	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/17/2015 00:00	0.8	13.9	1,326.5	0.7	2.70	1	1	0
01/17/2015 01:00	0.9	13.9	1,539.9	0.8	4.60	1	1	0
01/17/2015 02:00	0.9	13.9	1,429.4	0.8	4.30	1	1	0
01/17/2015 03:00	1.0	13.9	1,598.8	0.8	4.80	1	1	0
01/17/2015 04:00	0.8	13.9	1,318.4	0.7	2.60	1	1	0
01/17/2015 05:00	0.8	13.9	1,356.8	0.7	2.70	1	1	0
01/17/2015 06:00	1.1	13.8	1,821.6	0.9	5.50	1	1	1
01/17/2015 07:00	1.1	13.7	1,845.6	0.9	5.50	1	1	0
01/17/2015 08:00	1.0	13.8	1,816.3	0.8	5.40	1	1	1
01/17/2015 09:00	0.9	13.9	1,794.9	0.8	5.40	1	1	1
01/17/2015 10:00	1.0	13.6	1,819.4	0.8	5.50	1	1	1
01/17/2015 11:00	1.1	13.6	1,851.1	0.9	5.60	1	1	1
01/17/2015 12:00	1.1	13.6	1,856.8	0.9	5.60	1	1	1
01/17/2015 13:00	0.9	13.7	1,574.4	0.7	4.70	1	1	1
01/17/2015 14:00	0.8	13.9	1,302.1	0.7	2.60	1	1	0
01/17/2015 15:00	0.8	13.9	1,302.3	0.7	2.60	1	1	0
01/17/2015 16:00	0.9	13.7	1,631.7	0.7	4.90	1	1	1
01/17/2015 17:00	1.2	13.1	1,944.3	0.9	5.80	1	1	1
01/17/2015 18:00	1.6	12.0	2,197.9	1.1	8.80	1	1	1
01/17/2015 19:00	1.5	12.2	2,138.8	1.0	8.60	1	1	1
01/17/2015 20:00	1.4	12.9	2,006.3	1.0	8.00	1	1	1
01/17/2015 21:00	1.4	12.7	2,042.8	1.0	8.20	1	1	1
01/17/2015 22:00	1.4	12.8	2,036.5	1.0	8.10	1	1	1
01/17/2015 23:00	1.4	12.7	2,050.7	1.0	8.20	1	1	1
Average/Sum#:	1.1	13.5	1,733.5	0.8	130.70 #	24 #	24 #	15 #
Minimum:	0.8	12.0	1,302.1	0.7	2.60	1	1	0
Maximum:	1.6	13.9	2,197.9	1.1	8.80	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/18/2015 00:00	1.3	13.0	1,973.6	1.0	7.90	1	1	1
01/18/2015 01:00	1.1	13.4	1,781.2	0.9	5.30	1	1	1
01/18/2015 02:00	2.6	15.0	891.9	2.6	3.74	1	0	0
01/18/2015 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/18/2015 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/18/2015 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/18/2015 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/18/2015 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/18/2015 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/18/2015 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/18/2015 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/18/2015 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/18/2015 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/18/2015 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/18/2015 14:00	22.3	17.7	462.1	41.1	30.01	1	0	0
01/18/2015 15:00	16.6	15.7	787.3	18.8	54.30	1	0	0
01/18/2015 16:00	0.5	13.9	1,439.7	0.4	2.90	1	0	1
01/18/2015 17:00	1.1	13.3	1,908.4	0.9	5.70	1	1	1
01/18/2015 18:00	1.3	12.9	2,006.6	1.0	8.00	1	1	1
01/18/2015 19:00	1.3	13.0	2,002.9	1.0	8.00	1	1	1
01/18/2015 20:00	1.3	13.1	1,973.4	1.0	7.90	1	1	1
01/18/2015 21:00	1.1	13.4	1,910.9	0.9	5.70	1	1	1
01/18/2015 22:00	0.8	13.9	1,474.8	0.7	2.90	1	1	0
01/18/2015 23:00	0.7	13.9	1,303.8	0.6	2.60	1	1	0
Average/Sum#:	4.0	14.0	1,532.0	5.5	144.95 #	13 #	9 #	8 #
Minimum:	0.5	12.9	462.1	0.4	2.60	0	0	0
Maximum:	22.3	17.7	2,006.6	41.1	54.30	1	1	1
%SI	45.8	45.8	45.8	45.8	45.83	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/19/2015 00:00	0.8	13.9	1,510.2	0.7	3.00	1	1	0
01/19/2015 01:00	0.7	13.9	1,353.2	0.6	2.70	1	1	0
01/19/2015 02:00	0.7	13.9	1,305.2	0.6	2.60	1	1	0
01/19/2015 03:00	0.9	13.8	1,577.9	0.7	4.70	1	1	0
01/19/2015 04:00	1.1	13.3	1,894.6	0.9	5.70	1	1	1
01/19/2015 05:00	1.3	13.1	1,977.8	1.0	7.90	1	1	1
01/19/2015 06:00	1.4	13.1	1,986.1	1.1	7.90	1	1	1
01/19/2015 07:00	1.5	12.7	2,082.5	1.1	8.30	1	1	1
01/19/2015 08:00	1.2	13.3	1,928.6	0.9	5.80	1	1	1
01/19/2015 09:00	1.1	13.4	1,895.4	0.9	5.70	1	1	1
01/19/2015 10:00	1.2	13.3	1,928.8	0.9	5.80	1	1	1
01/19/2015 11:00	1.1	13.4	1,857.5	0.9	5.60	1	1	1
01/19/2015 12:00	1.1	13.4	1,868.9	0.9	5.60	1	1	1
01/19/2015 13:00	1.1	13.4	1,866.3	0.9	5.60	1	1	1
01/19/2015 14:00	1.1	13.4	1,870.6	0.9	5.60	1	1	1
01/19/2015 15:00	1.2	13.3	1,913.8	0.9	5.70	1	1	1
01/19/2015 16:00	1.4	13.1	1,961.9	1.1	7.80	1	1	1
01/19/2015 17:00	1.4	12.8	2,029.6	1.0	8.10	1	1	1
01/19/2015 18:00	1.5	12.4	2,104.2	1.0	8.40	1	1	1
01/19/2015 19:00	1.5	12.5	2,085.0	1.1	8.30	1	1	1
01/19/2015 20:00	1.5	12.7	2,048.2	1.1	8.20	1	1	1
01/19/2015 21:00	1.4	12.8	2,029.3	1.0	8.10	1	1	1
01/19/2015 22:00	1.2	13.2	1,922.5	0.9	5.80	1	1	1
01/19/2015 23:00	1.1	13.3	1,857.9	0.9	5.60	1	1	1
Average/Sum#:	1.2	13.2	1,869.0	0.9	148.50 #	24 #	24 #	20 #
Minimum:	0.7	12.4	1,305.2	0.6	2.60	1	1	0
Maximum:	1.5	13.9	2,104.2	1.1	8.40	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/20/2015 00:00	1.3	13.2	1,947.2	1.0	7.80	1	1	1
01/20/2015 01:00	1.1	13.3	1,850.9	0.9	5.60	1	1	1
01/20/2015 02:00	1.2	13.3	1,852.8	0.9	5.60	1	1	1
01/20/2015 03:00	1.2	13.3	1,854.0	0.9	5.60	1	1	1
01/20/2015 04:00	1.2	13.3	1,855.6	0.9	5.60	1	1	1
01/20/2015 05:00	1.2	13.3	1,854.3	0.9	5.60	1	1	1
01/20/2015 06:00	1.3	13.1	1,982.8	1.0	7.90	1	1	1
01/20/2015 07:00	1.4	13.0	2,013.5	1.0	8.10	1	1	1
01/20/2015 08:00	1.4	13.0	2,022.0	1.0	8.10	1	1	1
01/20/2015 09:00	1.4	13.0	2,018.2	1.0	8.10	1	1	1
01/20/2015 10:00	1.4	13.0	2,003.5	1.0	8.00	1	1	1
01/20/2015 11:00	1.4	12.9	2,018.4	1.0	8.10	1	1	1
01/20/2015 12:00	1.4	12.8	2,025.1	1.0	8.10	1	1	1
01/20/2015 13:00	1.4	12.9	2,003.4	1.0	8.00	1	1	1
01/20/2015 14:00	1.4	12.9	2,013.9	1.0	8.10	1	1	1
01/20/2015 15:00	1.4	12.8	2,032.1	1.0	8.10	1	1	1
01/20/2015 16:00	1.2	13.3	1,880.4	0.9	5.60	1	1	1
01/20/2015 17:00	1.2	13.2	1,909.7	0.9	5.70	1	1	1
01/20/2015 18:00	1.4	12.8	2,028.4	1.0	8.10	1	1	1
01/20/2015 19:00	1.4	12.8	2,040.7	1.0	8.20	1	1	1
01/20/2015 20:00	1.4	12.9	2,003.2	1.0	8.00	1	1	1
01/20/2015 21:00	1.4	12.9	2,023.2	1.0	8.10	1	1	1
01/20/2015 22:00	1.4	13.1	1,980.3	1.1	7.90	1	1	1
01/20/2015 23:00	1.1	13.5	1,852.4	0.9	5.60	1	1	1
Average/Sum#:	1.3	13.1	1,961.1	1.0	173.60 #	24 #	24 #	24 #
Minimum:	1.1	12.8	1,850.9	0.9	5.60	1	1	1
Maximum:	1.4	13.5	2,040.7	1.1	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/21/2015 00:00	1.1	13.6	1,873.4	0.9	5.60	1	1	1
01/21/2015 01:00	1.2	13.6	1,858.6	1.0	7.40	1	1	1
01/21/2015 02:00	1.2	13.5	1,891.8	1.0	7.60	1	1	1
01/21/2015 03:00	1.2	13.6	1,850.1	1.0	7.40	1	1	1
01/21/2015 04:00	1.2	13.5	1,863.1	1.0	7.50	1	1	1
01/21/2015 05:00	1.2	13.4	1,857.4	0.9	5.60	1	1	1
01/21/2015 06:00	1.3	13.3	1,940.4	1.0	7.80	1	1	1
01/21/2015 07:00	1.4	13.1	1,997.6	1.1	8.00	1	1	1
01/21/2015 08:00	1.4	12.9	2,042.0	1.0	8.20	1	1	1
01/21/2015 09:00	1.4	12.9	2,011.3	1.0	8.00	1	1	1
01/21/2015 10:00	1.3	13.2	1,940.3	1.0	7.80	1	1	1
01/21/2015 11:00	1.3	13.2	1,935.7	1.0	7.70	1	1	1
01/21/2015 12:00	1.3	13.3	1,916.2	1.0	7.70	1	1	1
01/21/2015 13:00	1.1	13.4	1,872.3	0.9	5.60	1	1	1
01/21/2015 14:00	1.1	13.5	1,861.8	0.9	5.60	1	1	1
01/21/2015 15:00	1.3	13.2	1,928.0	1.0	7.70	1	1	1
01/21/2015 16:00	1.4	13.0	1,961.3	1.0	7.80	1	1	1
01/21/2015 17:00	1.4	12.9	1,993.4	1.0	8.00	1	1	1
01/21/2015 18:00	1.5	12.7	2,035.7	1.1	8.10	1	1	1
01/21/2015 19:00	1.4	12.8	2,030.6	1.0	8.10	1	1	1
01/21/2015 20:00	1.4	13.0	2,003.0	1.0	8.00	1	1	1
01/21/2015 21:00	1.4	13.0	1,994.4	1.0	8.00	1	1	1
01/21/2015 22:00	1.2	13.2	1,917.5	0.9	5.80	1	1	1
01/21/2015 23:00	1.0	13.7	1,560.2	0.8	4.70	1	1	1
Average/Sum#:	1.3	13.2	1,922.3	1.0	173.70 #	24 #	24 #	24 #
Minimum:	1.0	12.7	1,560.2	0.8	4.70	1	1	1
Maximum:	1.5	13.7	2,042.0	1.1	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/22/2015 00:00	0.9	13.9	1,405.6	0.8	4.20	1	1	0
01/22/2015 01:00	0.8	13.9	1,300.1	0.7	2.60	1	1	0
01/22/2015 02:00	0.8	13.9	1,312.8	0.7	2.60	1	1	0
01/22/2015 03:00	1.0	13.8	1,568.1	0.8	4.70	1	1	1
01/22/2015 04:00	1.2	13.3	1,873.8	0.9	5.60	1	1	1
01/22/2015 05:00	1.2	13.3	1,859.5	0.9	5.60	1	1	1
01/22/2015 06:00	1.2	13.2	1,920.1	0.9	5.80	1	1	1
01/22/2015 07:00	1.4	12.9	2,005.8	1.0	8.00	1	1	1
01/22/2015 08:00	1.3	13.1	1,977.5	1.0	7.90	1	1	1
01/22/2015 09:00	1.4	13.0	2,010.7	1.0	8.00	1	1	1
01/22/2015 10:00	1.1	13.3	1,862.6	0.9	5.60	1	1	1
01/22/2015 11:00	1.1	13.3	1,854.4	0.9	5.60	1	1	1
01/22/2015 12:00	1.1	13.3	1,849.5	0.9	5.50	1	1	1
01/22/2015 13:00	0.9	13.7	1,506.2	0.7	4.50	1	1	1
01/22/2015 14:00	1.0	13.9	1,646.5	0.8	4.90	1	1	0
01/22/2015 15:00	1.0	13.6	1,733.1	0.8	5.20	1	1	1
01/22/2015 16:00	1.1	13.4	1,854.7	0.9	5.60	1	1	1
01/22/2015 17:00	1.3	13.1	1,966.0	1.0	7.90	1	1	1
01/22/2015 18:00	1.4	12.8	2,038.4	1.0	8.20	1	1	1
01/22/2015 19:00	1.4	12.9	2,028.0	1.0	8.10	1	1	1
01/22/2015 20:00	1.4	13.1	1,991.3	1.1	8.00	1	1	1
01/22/2015 21:00	1.2	13.2	1,951.3	0.9	5.90	1	1	1
01/22/2015 22:00	1.2	13.3	1,925.8	0.9	5.80	1	1	1
01/22/2015 23:00	1.2	13.4	1,877.1	0.9	5.60	1	1	1
Average/Sum#:	1.2	13.4	1,805.0	0.9	141.40 #	24 #	24 #	20 #
Minimum:	0.8	12.8	1,300.1	0.7	2.60	1	1	0
Maximum:	1.4	13.9	2,038.4	1.1	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/23/2015 00:00	1.3	13.2	1,932.9	1.0	7.70	1	1	1
01/23/2015 01:00	1.2	13.4	1,894.6	0.9	5.70	1	1	1
01/23/2015 02:00	1.4	13.1	1,990.2	1.1	8.00	1	1	1
01/23/2015 03:00	1.4	13.1	1,970.3	1.1	7.90	1	1	1
01/23/2015 04:00	1.3	13.3	1,905.7	1.0	7.60	1	1	1
01/23/2015 05:00	1.2	13.3	1,895.9	0.9	5.70	1	1	1
01/23/2015 06:00	1.3	13.2	1,954.9	1.0	7.80	1	1	1
01/23/2015 07:00	1.4	12.9	2,022.8	1.0	8.10	1	1	1
01/23/2015 08:00	1.4	13.0	2,004.0	1.0	8.00	1	1	1
01/23/2015 09:00	1.2	13.4	1,914.9	0.9	5.70	1	1	1
01/23/2015 10:00	1.2	13.3	1,893.1	0.9	5.70	1	1	1
01/23/2015 11:00	1.1	13.4	1,859.7	0.9	5.60	1	1	1
01/23/2015 12:00	1.1	13.5	1,866.6	0.9	5.60	1	1	1
01/23/2015 13:00	1.1	13.4	1,865.8	0.9	5.60	1	1	1
01/23/2015 14:00	1.1	13.4	1,862.6	0.9	5.60	1	1	1
01/23/2015 15:00	1.1	13.3	1,877.6	0.9	5.60	1	1	1
01/23/2015 16:00	1.3	13.2	1,917.1	1.0	7.70	1	1	1
01/23/2015 17:00	1.3	13.2	1,930.0	1.0	7.70	1	1	1
01/23/2015 18:00	1.5	12.7	2,040.9	1.1	8.20	1	1	1
01/23/2015 19:00	1.5	12.6	2,058.2	1.1	8.20	1	1	1
01/23/2015 20:00	1.5	12.6	2,047.5	1.1	8.20	1	1	1
01/23/2015 21:00	1.5	12.8	2,012.3	1.1	8.00	1	1	1
01/23/2015 22:00	1.4	12.8	2,015.9	1.0	8.10	1	1	1
01/23/2015 23:00	1.2	13.3	1,915.5	0.9	5.70	1	1	1
Average/Sum#:	1.3	13.1	1,943.7	1.0	167.70 #	24 #	24 #	24 #
Minimum:	1.1	12.6	1,859.7	0.9	5.60	1	1	1
Maximum:	1.5	13.5	2,058.2	1.1	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/24/2015 00:00	1.1	13.5	1,862.6	0.9	5.60	1	1	1
01/24/2015 01:00	1.2	13.4	1,881.3	0.9	5.60	1	1	1
01/24/2015 02:00	1.1	13.5	1,858.6	0.9	5.60	1	1	1
01/24/2015 03:00	1.2	13.5	1,867.4	1.0	7.50	1	1	1
01/24/2015 04:00	1.3	13.2	1,942.6	1.0	7.80	1	1	1
01/24/2015 05:00	1.4	13.0	1,988.1	1.0	8.00	1	1	1
01/24/2015 06:00	1.4	13.0	1,985.2	1.0	7.90	1	1	1
01/24/2015 07:00	1.4	12.9	2,010.4	1.0	8.00	1	1	1
01/24/2015 08:00	1.3	13.2	1,935.9	1.0	7.70	1	1	1
01/24/2015 09:00	1.2	13.3	1,899.6	0.9	5.70	1	1	1
01/24/2015 10:00	1.2	13.4	1,847.6	0.9	5.50	1	1	1
01/24/2015 11:00	1.1	13.4	1,864.6	0.9	5.60	1	1	1
01/24/2015 12:00	1.2	13.4	1,860.5	0.9	5.60	1	1	1
01/24/2015 13:00	1.2	13.4	1,834.8	0.9	5.50	1	1	1
01/24/2015 14:00	0.8	14.0	1,300.9	0.7	3.90	1	1	0
01/24/2015 15:00	0.8	14.0	1,297.6	0.7	3.90	1	1	0
01/24/2015 16:00	0.9	14.0	1,443.9	0.8	4.30	1	1	0
01/24/2015 17:00	1.3	13.1	1,829.0	1.0	7.30	1	1	1
01/24/2015 18:00	1.5	12.5	2,070.2	1.1	8.30	1	1	1
01/24/2015 19:00	1.5	12.7	2,046.6	1.1	8.20	1	1	1
01/24/2015 20:00	1.4	13.0	1,985.7	1.0	7.90	1	1	1
01/24/2015 21:00	1.4	12.9	2,002.8	1.0	8.00	1	1	1
01/24/2015 22:00	1.4	12.9	2,018.4	1.0	8.10	1	1	1
01/24/2015 23:00	1.4	13.1	1,976.8	1.1	7.90	1	1	1
Average/Sum#:	1.2	13.3	1,858.8	0.9	159.40 #	24 #	24 #	21 #
Minimum:	0.8	12.5	1,297.6	0.7	3.90	1	1	0
Maximum:	1.5	14.0	2,070.2	1.1	8.30	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/25/2015 00:00	0.9	13.9	1,469.4	0.8	4.40	1	1	0
01/25/2015 01:00	5.0	15.8	589.7	5.8	2.73	1	0	0
01/25/2015 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2015 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2015 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2015 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2015 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2015 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2015 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2015 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2015 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2015 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2015 12:00	25.6	17.7	466.5	47.2	34.10	1	0	0
01/25/2015 13:00	17.7	15.9	709.9	20.9	54.70	1	0	0
01/25/2015 14:00	5.0	14.1	1,438.1	4.3	23.00	1	0	0
01/25/2015 15:00	1.0	13.9	1,776.5	0.8	5.30	1	1	0
01/25/2015 16:00	0.9	13.9	1,660.8	0.8	5.00	1	1	0
01/25/2015 17:00	1.3	13.2	1,820.2	1.0	7.30	1	1	1
01/25/2015 18:00	1.6	12.2	2,162.4	1.1	8.60	1	1	1
01/25/2015 19:00	1.2	13.3	1,823.5	0.9	5.50	1	1	1
01/25/2015 20:00	1.0	13.9	1,809.1	0.8	5.40	1	1	0
01/25/2015 21:00	1.0	13.9	1,710.2	0.8	5.10	1	1	0
01/25/2015 22:00	1.8	14.5	1,351.6	1.7	5.91	1	0	0
01/25/2015 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	4.9	14.3	1,445.2	6.7	167.04 #	13 #	8 #	3 #
Minimum:	0.9	12.2	466.5	0.8	2.73	0	0	0
Maximum:	25.6	17.7	2,162.4	47.2	54.70	1	1	1
%SI	45.8	45.8	45.8	45.8	45.83	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/26/2015 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2015 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2015 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2015 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2015 04:00	14.1	17.1	553.9	21.9	28.29	1	0	0
01/26/2015 05:00	8.0	14.4	1,288.0	7.3	34.80	1	0	0
01/26/2015 06:00	1.0	13.8	1,715.5	0.8	5.10	1	1	0
01/26/2015 07:00	1.1	13.9	1,814.9	0.9	5.40	1	1	0
01/26/2015 08:00	1.0	13.9	1,813.7	0.8	5.40	1	1	0
01/26/2015 09:00	1.0	13.8	1,815.7	0.8	5.40	1	1	0
01/26/2015 10:00	1.2	13.8	1,819.4	1.0	7.30	1	1	0
01/26/2015 11:00	1.2	13.8	1,772.5	1.0	7.10	1	1	0
01/26/2015 12:00	1.3	13.8	1,818.6	1.1	7.30	1	1	0
01/26/2015 13:00	1.3	13.8	1,798.5	1.1	7.20	1	1	0
01/26/2015 14:00	1.3	13.8	1,803.2	1.1	7.20	1	1	0
01/26/2015 15:00	1.3	13.8	1,799.5	1.1	7.20	1	1	0
01/26/2015 16:00	1.3	13.8	1,797.6	1.1	7.20	1	1	0
01/26/2015 17:00	0.9	13.9	1,615.7	0.8	4.80	1	1	0
01/26/2015 18:00	1.0	13.9	1,670.9	0.8	5.00	1	1	0
01/26/2015 19:00	1.3	13.8	1,815.6	1.1	7.30	1	1	0
01/26/2015 20:00	1.3	13.8	1,815.3	1.1	7.30	1	1	0
01/26/2015 21:00	1.0	13.9	1,593.4	0.8	4.80	1	1	0
01/26/2015 22:00	0.8	13.9	1,451.2	0.7	2.90	1	1	0
01/26/2015 23:00	0.7	13.9	1,353.0	0.6	2.70	1	1	0
Average/Sum#:	2.1	14.0	1,646.3	2.3	169.69 #	20 #	18 #	0 #
Minimum:	0.7	13.8	553.9	0.6	2.70	0	0	0
Maximum:	14.1	17.1	1,819.4	21.9	34.80	1	1	0
%SI	16.7	16.7	16.7	16.7	16.67	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/27/2015 00:00	0.8	13.9	1,357.9	0.7	2.70	1	1	0
01/27/2015 01:00	0.8	13.9	1,356.6	0.7	2.70	1	1	0
01/27/2015 02:00	1.0	13.9	1,557.3	0.8	4.70	1	1	0
01/27/2015 03:00	1.0	13.9	1,710.1	0.8	5.10	1	1	0
01/27/2015 04:00	1.3	13.7	1,821.4	1.1	7.30	1	1	0
01/27/2015 05:00	1.3	13.7	1,836.0	1.1	7.30	1	1	0
01/27/2015 06:00	1.3	13.7	1,841.9	1.1	7.40	1	1	0
01/27/2015 07:00	1.3	13.7	1,843.9	1.1	7.40	1	1	0
01/27/2015 08:00	1.3	13.7	1,841.8	1.1	7.40	1	1	0
01/27/2015 09:00	1.3	13.7	1,831.9	1.1	7.30	1	1	0
01/27/2015 10:00	0.8	13.9	1,386.8	0.7	2.80	1	1	0
01/27/2015 11:00	0.8	13.9	1,276.1	0.7	2.60	1	1	0
01/27/2015 12:00	0.8	13.9	1,302.4	0.7	2.60	1	1	0
01/27/2015 13:00	1.0	13.9	1,559.6	0.8	4.70	1	1	0
01/27/2015 14:00	0.8	13.9	1,295.6	0.7	2.60	1	1	0
01/27/2015 15:00	1.0	13.9	1,571.0	0.8	4.70	1	1	0
01/27/2015 16:00	0.8	13.9	1,322.9	0.7	2.60	1	1	0
01/27/2015 17:00	1.0	13.6	1,656.7	0.8	5.00	1	1	1
01/27/2015 18:00	1.4	13.0	1,990.1	1.0	8.00	1	1	1
01/27/2015 19:00	1.5	13.0	1,980.6	1.1	7.90	1	1	1
01/27/2015 20:00	1.4	13.1	1,962.0	1.1	7.80	1	1	1
01/27/2015 21:00	1.4	13.1	1,971.7	1.1	7.90	1	1	1
01/27/2015 22:00	1.4	13.0	1,963.0	1.0	7.90	1	1	1
01/27/2015 23:00	1.0	13.7	1,563.3	0.8	4.70	1	1	1
Average/Sum#:	1.1	13.7	1,658.4	0.9	131.10 #	24 #	24 #	7 #
Minimum:	0.8	13.0	1,276.1	0.7	2.60	1	1	0
Maximum:	1.5	13.9	1,990.1	1.1	8.00	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/28/2015 00:00	0.8	13.9	1,278.9	0.7	2.60	1	1	0
01/28/2015 01:00	0.8	13.9	1,278.5	0.7	2.60	1	1	0
01/28/2015 02:00	0.8	13.9	1,272.6	0.7	2.50	1	1	0
01/28/2015 03:00	0.8	13.9	1,271.8	0.7	2.50	1	1	0
01/28/2015 04:00	0.8	13.9	1,281.0	0.7	2.60	1	1	0
01/28/2015 05:00	1.0	13.6	1,610.8	0.8	4.80	1	1	1
01/28/2015 06:00	1.2	13.5	1,879.1	1.0	7.50	1	1	1
01/28/2015 07:00	1.4	12.7	2,022.9	1.0	8.10	1	1	1
01/28/2015 08:00	1.2	13.3	1,875.2	0.9	5.60	1	1	1
01/28/2015 09:00	1.1	13.6	1,850.2	0.9	5.60	1	1	1
01/28/2015 10:00	1.2	13.6	1,851.3	1.0	7.40	1	1	1
01/28/2015 11:00	1.1	13.6	1,734.5	0.9	5.20	1	1	1
01/28/2015 12:00	0.9	14.0	1,269.0	0.8	3.80	1	1	0
01/28/2015 13:00	1.1	13.9	1,609.9	0.9	4.80	1	1	0
01/28/2015 14:00	1.3	13.4	1,834.3	1.0	7.30	1	1	1
01/28/2015 15:00	1.5	12.4	2,058.7	1.0	8.20	1	1	1
01/28/2015 16:00	1.5	12.8	1,991.8	1.1	8.00	1	1	1
01/28/2015 17:00	1.3	13.0	1,944.7	1.0	7.80	1	1	1
01/28/2015 18:00	1.4	12.8	2,005.7	1.0	8.00	1	1	1
01/28/2015 19:00	1.4	12.8	2,006.1	1.0	8.00	1	1	1
01/28/2015 20:00	1.3	13.1	1,939.0	1.0	7.80	1	1	1
01/28/2015 21:00	1.3	13.1	1,954.1	1.0	7.80	1	1	1
01/28/2015 22:00	1.3	13.1	1,924.9	1.0	7.70	1	1	1
01/28/2015 23:00	1.2	13.4	1,847.1	0.9	5.50	1	1	1
Average/Sum#:	1.2	13.4	1,733.0	0.9	141.70 #	24 #	24 #	17 #
Minimum:	0.8	12.4	1,269.0	0.7	2.50	1	1	0
Maximum:	1.5	14.0	2,058.7	1.1	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/29/2015 00:00	1.2	13.4	1,844.4	0.9	5.50	1	1	1
01/29/2015 01:00	1.2	13.4	1,849.0	0.9	5.50	1	1	1
01/29/2015 02:00	1.2	13.4	1,850.8	0.9	5.60	1	1	1
01/29/2015 03:00	1.2	13.4	1,848.3	0.9	5.50	1	1	1
01/29/2015 04:00	1.2	13.4	1,858.4	0.9	5.60	1	1	1
01/29/2015 05:00	1.2	13.4	1,853.3	0.9	5.60	1	1	1
01/29/2015 06:00	1.3	13.2	1,936.3	1.0	7.70	1	1	1
01/29/2015 07:00	1.4	12.9	2,016.8	1.0	8.10	1	1	1
01/29/2015 08:00	1.4	13.2	1,966.3	1.1	7.90	1	1	1
01/29/2015 09:00	1.4	13.1	1,956.0	1.1	7.80	1	1	1
01/29/2015 10:00	1.1	13.4	1,868.3	0.9	5.60	1	1	1
01/29/2015 11:00	1.1	13.5	1,853.5	0.9	5.60	1	1	1
01/29/2015 12:00	1.2	13.5	1,858.4	1.0	7.40	1	1	1
01/29/2015 13:00	1.3	13.4	1,855.8	1.0	7.40	1	1	1
01/29/2015 14:00	1.2	13.4	1,867.5	0.9	5.60	1	1	1
01/29/2015 15:00	1.5	12.5	2,027.1	1.1	8.10	1	1	1
01/29/2015 16:00	1.3	13.1	1,915.4	1.0	7.70	1	1	1
01/29/2015 17:00	1.2	13.3	1,896.1	0.9	5.70	1	1	1
01/29/2015 18:00	1.5	12.8	2,006.5	1.1	8.00	1	1	1
01/29/2015 19:00	1.4	12.7	2,025.2	1.0	8.10	1	1	1
01/29/2015 20:00	1.5	12.7	2,044.2	1.1	8.20	1	1	1
01/29/2015 21:00	1.4	13.0	1,978.6	1.0	7.90	1	1	1
01/29/2015 22:00	1.3	13.3	1,907.6	1.0	7.60	1	1	1
01/29/2015 23:00	1.2	13.5	1,858.7	1.0	7.40	1	1	1
Average/Sum#:	1.3	13.2	1,914.3	1.0	165.10 #	24 #	24 #	24 #
Minimum:	1.1	12.5	1,844.4	0.9	5.50	1	1	1
Maximum:	1.5	13.5	2,044.2	1.1	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/30/2015 00:00	1.2	13.5	1,859.5	1.0	7.40	1	1	1
01/30/2015 01:00	1.2	13.5	1,860.3	1.0	7.40	1	1	1
01/30/2015 02:00	1.2	13.4	1,856.6	0.9	5.60	1	1	1
01/30/2015 03:00	1.2	13.4	1,854.7	0.9	5.60	1	1	1
01/30/2015 04:00	1.2	13.5	1,861.1	1.0	7.40	1	1	1
01/30/2015 05:00	1.2	13.5	1,865.0	1.0	7.50	1	1	1
01/30/2015 06:00	1.2	13.4	1,902.1	0.9	5.70	1	1	1
01/30/2015 07:00	1.3	13.0	1,977.9	1.0	7.90	1	1	1
01/30/2015 08:00	1.4	13.0	1,968.4	1.0	7.90	1	1	1
01/30/2015 09:00	1.3	13.2	1,924.3	1.0	7.70	1	1	1
01/30/2015 10:00	1.2	13.3	1,890.8	0.9	5.70	1	1	1
01/30/2015 11:00	1.2	13.4	1,860.8	0.9	5.60	1	1	1
01/30/2015 12:00	1.0	13.8	1,629.3	0.8	4.90	1	1	1
01/30/2015 13:00	1.3	13.1	1,902.5	1.0	7.60	1	1	1
01/30/2015 14:00	1.3	13.1	1,910.9	1.0	7.60	1	1	1
01/30/2015 15:00	1.3	13.2	1,902.4	1.0	7.60	1	1	1
01/30/2015 16:00	1.4	12.9	1,974.9	1.0	7.90	1	1	1
01/30/2015 17:00	1.2	13.3	1,882.5	0.9	5.60	1	1	1
01/30/2015 18:00	1.2	13.4	1,870.8	0.9	5.60	1	1	1
01/30/2015 19:00	1.1	13.4	1,862.9	0.9	5.60	1	1	1
01/30/2015 20:00	1.2	13.4	1,865.4	0.9	5.60	1	1	1
01/30/2015 21:00	1.2	13.5	1,865.4	1.0	7.50	1	1	1
01/30/2015 22:00	1.1	13.6	1,696.3	0.9	5.10	1	1	1
01/30/2015 23:00	0.9	14.0	1,273.1	0.8	3.80	1	1	0
Average/Sum#:	1.2	13.4	1,846.6	0.9	155.80 #	24 #	24 #	23 #
Minimum:	0.9	12.9	1,273.1	0.8	3.80	1	1	0
Maximum:	1.4	14.0	1,977.9	1.0	7.90	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/31/2015 00:00	5.7	15.9	546.3	6.7	3.01	1	0	0
01/31/2015 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/31/2015 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/31/2015 03:00	5.5	16.9	574.2	8.1	12.04	1	0	0
01/31/2015 04:00	13.3	14.7	1,067.9	12.7	50.20	1	0	0
01/31/2015 05:00	1.1	13.6	1,780.3	0.9	5.30	1	1	1
01/31/2015 06:00	1.3	13.5	1,873.1	1.0	7.50	1	1	1
01/31/2015 07:00	1.3	13.5	1,872.8	1.0	7.50	1	1	1
01/31/2015 08:00	1.3	13.6	1,872.0	1.1	7.50	1	1	1
01/31/2015 09:00	1.3	13.5	1,871.6	1.0	7.50	1	1	1
01/31/2015 10:00	1.3	13.5	1,869.9	1.0	7.50	1	1	1
01/31/2015 11:00	1.0	14.0	1,366.3	0.9	4.10	1	1	1
01/31/2015 12:00	0.9	14.0	1,299.3	0.8	3.90	1	1	0
01/31/2015 13:00	0.9	14.0	1,328.4	0.8	4.00	1	1	0
01/31/2015 14:00	1.0	14.0	1,522.4	0.9	4.60	1	1	0
01/31/2015 15:00	1.2	13.7	1,702.6	1.0	6.80	1	1	1
01/31/2015 16:00	1.2	13.6	1,731.2	1.0	6.90	1	1	1
01/31/2015 17:00	1.1	13.8	1,594.1	0.9	4.80	1	1	1
01/31/2015 18:00	1.5	12.7	2,018.3	1.1	8.10	1	1	1
01/31/2015 19:00	1.5	12.6	2,034.1	1.1	8.10	1	1	1
01/31/2015 20:00	1.5	12.6	2,035.0	1.1	8.10	1	1	1
01/31/2015 21:00	1.4	12.6	2,044.7	1.0	8.20	1	1	1
01/31/2015 22:00	1.5	12.7	2,038.4	1.1	8.20	1	1	1
01/31/2015 23:00	1.3	13.1	1,945.8	1.0	7.80	1	1	1
Average/Sum#:	2.2	13.7	1,635.9	2.1	191.65 #	22 #	19 #	16 #
Minimum:	0.9	12.6	546.3	0.8	3.01	0	0	0
Maximum:	13.3	16.9	2,044.7	12.7	50.20	1	1	1
%SI	8.3	8.3	8.3	8.3	8.33	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/01/2015 00:00	1.4	12.9	1,991.9	1.0	8.00	1	1	1
02/01/2015 01:00	1.1	13.8	1,620.8	0.9	4.90	1	1	1
02/01/2015 02:00	5.7	15.9	592.1	6.7	3.40	1	0	0
02/01/2015 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2015 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2015 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2015 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2015 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2015 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2015 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2015 10:00	26.5	17.5	477.6	46.0	50.03	1	0	0
02/01/2015 11:00	15.8	15.3	840.0	16.6	51.20	1	0	0
02/01/2015 12:00	0.6	13.9	1,385.6	0.5	2.80	1	1	0
02/01/2015 13:00	0.7	14.0	1,390.7	0.6	2.80	1	1	0
02/01/2015 14:00	1.1	13.9	1,728.2	0.9	5.20	1	1	0
02/01/2015 15:00	0.8	14.0	1,506.9	0.7	4.50	1	1	0
02/01/2015 16:00	1.1	13.6	1,787.5	0.9	5.40	1	1	1
02/01/2015 17:00	1.2	13.3	1,909.9	0.9	5.70	1	1	1
02/01/2015 18:00	1.5	12.9	1,984.3	1.1	7.90	1	1	1
02/01/2015 19:00	1.5	12.8	2,010.5	1.1	8.00	1	1	1
02/01/2015 20:00	1.5	12.7	2,016.9	1.1	8.10	1	1	1
02/01/2015 21:00	1.5	12.8	1,998.4	1.1	8.00	1	1	1
02/01/2015 22:00	1.3	13.2	1,914.4	1.0	7.70	1	1	1
02/01/2015 23:00	1.2	13.4	1,831.9	0.9	5.50	1	1	1
Average/Sum#:	3.8	13.9	1,587.5	4.8	189.13 #	17 #	14 #	10 #
Minimum:	0.6	12.7	477.6	0.5	2.80	0	0	0
Maximum:	26.5	17.5	2,016.9	46.0	51.20	1	1	1
%SI	29.2	29.2	29.2	29.2	29.17	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/02/2015 00:00	1.2	13.4	1,848.1	0.9	5.50	1	1	1
02/02/2015 01:00	1.4	12.9	1,987.1	1.0	7.90	1	1	1
02/02/2015 02:00	1.4	13.1	1,936.2	1.1	7.70	1	1	1
02/02/2015 03:00	1.2	13.4	1,851.9	0.9	5.60	1	1	1
02/02/2015 04:00	1.2	13.4	1,841.2	0.9	5.50	1	1	1
02/02/2015 05:00	1.2	13.4	1,865.0	0.9	5.60	1	1	1
02/02/2015 06:00	1.3	13.0	1,963.0	1.0	7.90	1	1	1
02/02/2015 07:00	1.4	12.9	1,967.8	1.0	7.90	1	1	1
02/02/2015 08:00	1.2	13.4	1,844.1	0.9	5.50	1	1	1
02/02/2015 09:00	1.2	13.4	1,837.4	0.9	5.50	1	1	1
02/02/2015 10:00	1.2	13.4	1,841.9	0.9	5.50	1	1	1
02/02/2015 11:00	1.2	13.4	1,860.6	0.9	5.60	1	1	1
02/02/2015 12:00	1.3	13.2	1,906.3	1.0	7.60	1	1	1
02/02/2015 13:00	1.2	13.3	1,883.5	0.9	5.70	1	1	1
02/02/2015 14:00	1.2	13.4	1,858.9	0.9	5.60	1	1	1
02/02/2015 15:00	1.1	13.4	1,857.8	0.9	5.60	1	1	1
02/02/2015 16:00	1.2	13.2	1,913.3	0.9	5.70	1	1	1
02/02/2015 17:00	1.3	13.1	1,939.2	1.0	7.80	1	1	1
02/02/2015 18:00	1.5	12.8	1,996.8	1.1	8.00	1	1	1
02/02/2015 19:00	1.4	12.8	1,991.8	1.0	8.00	1	1	1
02/02/2015 20:00	1.5	12.8	1,998.1	1.1	8.00	1	1	1
02/02/2015 21:00	1.4	13.0	1,954.2	1.0	7.80	1	1	1
02/02/2015 22:00	1.3	13.2	1,902.4	1.0	7.60	1	1	1
02/02/2015 23:00	1.1	13.4	1,822.9	0.9	5.50	1	1	1
Average/Sum#:	1.3	13.2	1,902.9	1.0	158.60 #	24 #	24 #	24 #
Minimum:	1.1	12.8	1,822.9	0.9	5.50	1	1	1
Maximum:	1.5	13.4	1,998.1	1.1	8.00	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/03/2015 00:00	0.8	13.9	1,328.5	0.7	2.70	1	1	0
02/03/2015 01:00	0.8	13.9	1,288.5	0.7	2.60	1	1	0
02/03/2015 02:00	0.8	13.9	1,290.1	0.7	2.60	1	1	0
02/03/2015 03:00	0.8	13.9	1,368.4	0.7	2.70	1	1	0
02/03/2015 04:00	1.1	13.7	1,701.6	0.9	5.10	1	1	1
02/03/2015 05:00	1.1	13.4	1,831.8	0.9	5.50	1	1	1
02/03/2015 06:00	1.2	13.3	1,862.4	0.9	5.60	1	1	1
02/03/2015 07:00	1.1	13.4	1,830.3	0.9	5.50	1	1	1
02/03/2015 08:00	1.1	13.4	1,834.1	0.9	5.50	1	1	1
02/03/2015 09:00	1.1	13.4	1,838.5	0.9	5.50	1	1	1
02/03/2015 10:00	1.0	13.6	1,676.2	0.8	5.00	1	1	1
02/03/2015 11:00	0.7	13.9	1,260.8	0.6	2.50	1	1	0
02/03/2015 12:00	0.8	13.9	1,298.9	0.7	2.60	1	1	0
02/03/2015 13:00	0.9	13.9	1,358.6	0.8	4.10	1	1	0
02/03/2015 14:00	1.1	13.8	1,705.7	0.9	5.10	1	1	0
02/03/2015 15:00	1.0	13.9	1,582.4	0.8	4.70	1	1	0
02/03/2015 16:00	1.0	13.6	1,649.0	0.8	4.90	1	1	1
02/03/2015 17:00	1.2	13.2	1,915.3	0.9	5.70	1	1	1
02/03/2015 18:00	1.5	12.6	2,039.5	1.1	8.20	1	1	1
02/03/2015 19:00	1.4	12.8	2,000.2	1.0	8.00	1	1	1
02/03/2015 20:00	1.4	12.9	1,978.9	1.0	7.90	1	1	1
02/03/2015 21:00	1.3	13.1	1,923.7	1.0	7.70	1	1	1
02/03/2015 22:00	1.3	13.2	1,808.6	1.0	7.20	1	1	1
02/03/2015 23:00	0.7	13.9	1,316.8	0.6	2.60	1	1	0
Average/Sum#:	1.1	13.5	1,653.7	0.8	119.50 #	24 #	24 #	14 #
Minimum:	0.7	12.6	1,260.8	0.6	2.50	1	1	0
Maximum:	1.5	13.9	2,039.5	1.1	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/04/2015 00:00	1.1	13.8	1,689.4	0.9	5.10	1	1	0
02/04/2015 01:00	0.9	13.9	1,491.3	0.8	4.50	1	1	0
02/04/2015 02:00	0.7	13.9	1,285.8	0.6	2.60	1	1	0
02/04/2015 03:00	0.8	13.9	1,288.3	0.7	2.60	1	1	0
02/04/2015 04:00	0.8	13.9	1,386.9	0.7	2.80	1	1	0
02/04/2015 05:00	1.0	13.7	1,606.1	0.8	4.80	1	1	1
02/04/2015 06:00	1.2	13.3	1,894.2	0.9	5.70	1	1	1
02/04/2015 07:00	1.3	13.3	1,876.9	1.0	7.50	1	1	1
02/04/2015 08:00	0.8	13.9	1,323.4	0.7	2.60	1	1	0
02/04/2015 09:00	0.7	13.9	1,290.3	0.6	2.60	1	1	0
02/04/2015 10:00	0.8	13.9	1,292.0	0.7	2.60	1	1	0
02/04/2015 11:00	0.8	13.9	1,292.0	0.7	2.60	1	1	0
02/04/2015 12:00	0.8	13.9	1,291.5	0.7	2.60	1	1	0
02/04/2015 13:00	0.8	13.9	1,292.0	0.7	2.60	1	1	0
02/04/2015 14:00	0.8	13.9	1,292.7	0.7	2.60	1	1	0
02/04/2015 15:00	0.8	13.9	1,351.9	0.7	2.70	1	1	1
02/04/2015 16:00	1.2	13.3	1,856.6	0.9	5.60	1	1	1
02/04/2015 17:00	1.3	13.1	1,924.6	1.0	7.70	1	1	1
02/04/2015 18:00	1.5	12.7	2,013.7	1.1	8.10	1	1	1
02/04/2015 19:00	1.5	12.7	1,993.9	1.1	8.00	1	1	1
02/04/2015 20:00	1.4	12.9	1,971.6	1.0	7.90	1	1	1
02/04/2015 21:00	1.4	12.8	1,992.6	1.0	8.00	1	1	1
02/04/2015 22:00	1.4	12.9	1,960.3	1.0	7.80	1	1	1
02/04/2015 23:00	1.0	13.6	1,554.0	0.8	4.70	1	1	1
Average/Sum#:	1.0	13.5	1,592.2	0.8	114.30 #	24 #	24 #	12 #
Minimum:	0.7	12.7	1,285.8	0.6	2.60	1	1	0
Maximum:	1.5	13.9	2,013.7	1.1	8.10	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/05/2015 00:00	0.8	13.9	1,285.5	0.7	2.60	1	1	0
02/05/2015 01:00	0.8	13.9	1,287.4	0.7	2.60	1	1	0
02/05/2015 02:00	0.7	13.9	1,289.2	0.6	2.60	1	1	0
02/05/2015 03:00	0.8	13.9	1,289.4	0.7	2.60	1	1	0
02/05/2015 04:00	0.9	13.9	1,418.9	0.8	4.30	1	1	0
02/05/2015 05:00	1.0	13.7	1,590.0	0.8	4.80	1	1	1
02/05/2015 06:00	1.2	13.3	1,886.6	0.9	5.70	1	1	1
02/05/2015 07:00	1.3	13.1	1,922.0	1.0	7.70	1	1	1
02/05/2015 08:00	0.9	13.8	1,427.9	0.7	4.30	1	1	1
02/05/2015 09:00	0.8	13.9	1,284.9	0.7	2.60	1	1	0
02/05/2015 10:00	0.8	13.9	1,297.7	0.7	2.60	1	1	0
02/05/2015 11:00	0.8	13.9	1,321.2	0.7	2.60	1	1	0
02/05/2015 12:00	0.8	13.9	1,350.2	0.7	2.70	1	1	0
02/05/2015 13:00	1.0	13.9	1,600.8	0.8	4.80	1	1	0
02/05/2015 14:00	1.1	13.9	1,654.4	0.9	5.00	1	1	0
02/05/2015 15:00	1.0	13.9	1,613.1	0.8	4.80	1	1	0
02/05/2015 16:00	1.2	13.4	1,836.8	0.9	5.50	1	1	1
02/05/2015 17:00	1.2	13.3	1,861.2	0.9	5.60	1	1	1
02/05/2015 18:00	1.4	12.8	1,967.4	1.0	7.90	1	1	1
02/05/2015 19:00	1.4	13.0	1,946.1	1.0	7.80	1	1	1
02/05/2015 20:00	1.4	12.9	1,962.9	1.0	7.90	1	1	1
02/05/2015 21:00	1.4	13.0	1,932.1	1.0	7.70	1	1	1
02/05/2015 22:00	0.9	13.9	1,456.7	0.8	4.40	1	1	0
02/05/2015 23:00	0.8	13.9	1,282.9	0.7	2.60	1	1	0
Average/Sum#:	1.0	13.6	1,573.6	0.8	111.70 #	24 #	24 #	10 #
Minimum:	0.7	12.8	1,282.9	0.6	2.60	1	1	0
Maximum:	1.4	13.9	1,967.4	1.0	7.90	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/06/2015 00:00	0.8	13.9	1,296.7	0.7	2.60	1	1	0
02/06/2015 01:00	0.8	13.9	1,288.4	0.7	2.60	1	1	0
02/06/2015 02:00	0.8	13.9	1,281.5	0.7	2.60	1	1	0
02/06/2015 03:00	0.8	13.9	1,286.3	0.7	2.60	1	1	0
02/06/2015 04:00	0.8	14.0	1,329.8	0.7	4.00	1	1	0
02/06/2015 05:00	1.2	13.4	1,772.2	0.9	5.30	1	1	1
02/06/2015 06:00	1.3	13.1	1,912.7	1.0	7.70	1	1	1
02/06/2015 07:00	1.3	13.0	1,884.8	1.0	7.50	1	1	1
02/06/2015 08:00	1.1	13.4	1,837.2	0.9	5.50	1	1	1
02/06/2015 09:00	1.1	13.6	1,651.1	0.9	5.00	1	1	1
02/06/2015 10:00	1.1	13.4	1,826.6	0.9	5.50	1	1	1
02/06/2015 11:00	1.0	13.4	1,836.7	0.8	5.50	1	1	1
02/06/2015 12:00	0.9	13.8	1,610.0	0.7	4.80	1	1	1
02/06/2015 13:00	1.0	13.4	1,845.4	0.8	5.50	1	1	1
02/06/2015 14:00	1.0	13.4	1,836.5	0.8	5.50	1	1	1
02/06/2015 15:00	1.0	13.4	1,838.6	0.8	5.50	1	1	1
02/06/2015 16:00	1.1	13.3	1,863.5	0.9	5.60	1	1	1
02/06/2015 17:00	1.3	12.7	1,977.9	0.9	5.90	1	1	1
02/06/2015 18:00	1.4	12.4	2,021.5	1.0	8.10	1	1	1
02/06/2015 19:00	1.3	12.6	1,979.7	0.9	5.90	1	1	1
02/06/2015 20:00	1.4	12.5	2,004.0	1.0	8.00	1	1	1
02/06/2015 21:00	1.2	13.1	1,882.7	0.9	5.60	1	1	1
02/06/2015 22:00	0.7	14.0	1,372.7	0.6	2.70	1	1	0
02/06/2015 23:00	0.9	13.9	1,577.9	0.8	4.70	1	1	0
Average/Sum#:	1.1	13.4	1,708.9	0.8	124.20 #	24 #	24 #	17 #
Minimum:	0.7	12.4	1,281.5	0.6	2.60	1	1	0
Maximum:	1.4	14.0	2,021.5	1.0	8.10	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/07/2015 00:00	0.6	14.0	1,308.7	0.5	2.60	1	1	0
02/07/2015 01:00	0.8	13.9	1,443.0	0.7	2.90	1	1	0
02/07/2015 02:00	0.8	14.0	1,394.9	0.7	4.20	1	1	0
02/07/2015 03:00	0.7	14.0	1,338.6	0.6	2.70	1	1	0
02/07/2015 04:00	0.8	14.0	1,337.7	0.7	4.00	1	1	0
02/07/2015 05:00	0.7	14.0	1,326.8	0.6	2.70	1	1	0
02/07/2015 06:00	0.7	14.0	1,329.5	0.6	2.70	1	1	0
02/07/2015 07:00	0.7	14.0	1,311.8	0.6	2.60	1	1	0
02/07/2015 08:00	0.7	13.9	1,285.2	0.6	2.60	1	1	0
02/07/2015 09:00	0.7	13.9	1,303.4	0.6	2.60	1	1	0
02/07/2015 10:00	0.7	13.9	1,349.9	0.6	2.70	1	1	0
02/07/2015 11:00	0.7	13.9	1,330.3	0.6	2.70	1	1	0
02/07/2015 12:00	0.7	13.9	1,293.3	0.6	2.60	1	1	0
02/07/2015 13:00	0.7	14.0	1,299.3	0.6	2.60	1	1	0
02/07/2015 14:00	0.7	14.0	1,341.1	0.6	2.70	1	1	0
02/07/2015 15:00	0.7	14.0	1,318.4	0.6	2.60	1	1	0
02/07/2015 16:00	0.9	13.6	1,648.4	0.7	4.90	1	1	1
02/07/2015 17:00	1.1	13.2	1,874.7	0.8	5.60	1	1	1
02/07/2015 18:00	1.4	12.5	2,009.9	1.0	8.00	1	1	1
02/07/2015 19:00	1.3	12.9	1,933.7	1.0	7.70	1	1	1
02/07/2015 20:00	1.4	12.6	2,004.3	1.0	8.00	1	1	1
02/07/2015 21:00	1.0	13.5	1,719.0	0.8	5.20	1	1	1
02/07/2015 22:00	0.8	13.9	1,382.0	0.7	2.80	1	1	0
02/07/2015 23:00	0.7	13.9	1,285.3	0.6	2.60	1	1	0
Average/Sum#:	0.8	13.7	1,465.4	0.7	90.30 #	24 #	24 #	6 #
Minimum:	0.6	12.5	1,285.2	0.5	2.60	1	1	0
Maximum:	1.4	14.0	2,009.9	1.0	8.00	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/08/2015 00:00	0.7	13.9	1,308.2	0.6	2.60	1	1	0
02/08/2015 01:00	0.7	13.9	1,341.7	0.6	2.70	1	1	0
02/08/2015 02:00	0.7	13.9	1,337.2	0.6	2.70	1	1	0
02/08/2015 03:00	0.7	13.9	1,290.1	0.6	2.60	1	1	0
02/08/2015 04:00	0.7	13.9	1,289.0	0.6	2.60	1	1	0
02/08/2015 05:00	0.7	13.9	1,285.2	0.6	2.60	1	1	0
02/08/2015 06:00	0.7	13.9	1,326.9	0.6	2.70	1	1	0
02/08/2015 07:00	0.7	13.9	1,314.1	0.6	2.60	1	1	0
02/08/2015 08:00	0.7	13.9	1,282.8	0.6	2.60	1	1	0
02/08/2015 09:00	0.7	13.9	1,284.3	0.6	2.60	1	1	0
02/08/2015 10:00	0.7	13.9	1,283.5	0.6	2.60	1	1	0
02/08/2015 11:00	0.7	13.9	1,286.8	0.6	2.60	1	1	0
02/08/2015 12:00	0.7	13.9	1,313.0	0.6	2.60	1	1	0
02/08/2015 13:00	0.7	13.9	1,322.2	0.6	2.60	1	1	0
02/08/2015 14:00	0.7	14.0	1,296.3	0.6	2.60	1	1	0
02/08/2015 15:00	0.7	14.0	1,297.8	0.6	2.60	1	1	0
02/08/2015 16:00	1.2	13.3	1,823.8	0.9	5.50	1	1	1
02/08/2015 17:00	1.2	13.1	1,907.1	0.9	5.70	1	1	1
02/08/2015 18:00	1.5	12.5	2,022.9	1.1	8.10	1	1	1
02/08/2015 19:00	1.5	12.7	1,980.0	1.1	7.90	1	1	1
02/08/2015 20:00	1.5	12.6	2,004.3	1.1	8.00	1	1	1
02/08/2015 21:00	1.3	13.1	1,763.9	1.0	7.10	1	1	1
02/08/2015 22:00	0.7	14.0	1,332.1	0.6	2.70	1	1	0
02/08/2015 23:00	0.9	13.9	1,521.3	0.8	4.60	1	1	0
Average/Sum#:	0.9	13.7	1,467.3	0.7	91.50 #	24 #	24 #	6 #
Minimum:	0.7	12.5	1,282.8	0.6	2.60	1	1	0
Maximum:	1.5	14.0	2,022.9	1.1	8.10	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/09/2015 00:00	0.7	14.0	1,306.9	0.6	2.60	1	1	0
02/09/2015 01:00	0.7	14.0	1,315.0	0.6	2.60	1	1	0
02/09/2015 02:00	0.8	14.0	1,285.2	0.7	3.90	1	1	0
02/09/2015 03:00	0.8	13.9	1,285.3	0.7	2.60	1	1	0
02/09/2015 04:00	0.8	13.9	1,285.8	0.7	2.60	1	1	0
02/09/2015 05:00	0.8	14.0	1,319.3	0.7	4.00	1	1	0
02/09/2015 06:00	1.1	13.5	1,722.3	0.9	5.20	1	1	1
02/09/2015 07:00	1.2	13.4	1,841.0	0.9	5.50	1	1	1
02/09/2015 08:00	1.1	13.5	1,839.6	0.9	5.50	1	1	1
02/09/2015 09:00	0.9	13.8	1,452.6	0.7	4.40	1	1	1
02/09/2015 10:00	0.7	13.9	1,289.8	0.6	2.60	1	1	0
02/09/2015 11:00	0.7	13.9	1,288.3	0.6	2.60	1	1	0
02/09/2015 12:00	0.8	13.9	1,286.1	0.7	2.60	1	1	0
02/09/2015 13:00	0.8	14.0	1,287.9	0.7	3.90	1	1	0
02/09/2015 14:00	0.8	14.0	1,290.0	0.7	3.90	1	1	0
02/09/2015 15:00	0.8	14.0	1,286.4	0.7	3.90	1	1	0
02/09/2015 16:00	0.8	14.0	1,287.4	0.7	3.90	1	1	0
02/09/2015 17:00	1.1	13.6	1,764.7	0.9	5.30	1	1	1
02/09/2015 18:00	1.1	13.5	1,847.8	0.9	5.50	1	1	1
02/09/2015 19:00	1.2	13.4	1,847.3	0.9	5.50	1	1	1
02/09/2015 20:00	1.2	13.4	1,869.2	0.9	5.60	1	1	1
02/09/2015 21:00	1.1	13.7	1,633.4	0.9	4.90	1	1	1
02/09/2015 22:00	0.9	13.9	1,326.8	0.8	4.00	1	1	0
02/09/2015 23:00	0.9	13.9	1,318.5	0.8	4.00	1	1	0
Average/Sum#:	0.9	13.8	1,469.9	0.8	97.10 #	24 #	24 #	9 #
Minimum:	0.7	13.4	1,285.2	0.6	2.60	1	1	0
Maximum:	1.2	14.0	1,869.2	0.9	5.60	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/10/2015 00:00	0.8	13.9	1,292.8	0.7	2.60	1	1	0
02/10/2015 01:00	0.8	13.9	1,296.3	0.7	2.60	1	1	0
02/10/2015 02:00	0.8	13.9	1,291.7	0.7	2.60	1	1	0
02/10/2015 03:00	0.8	13.9	1,293.6	0.7	2.60	1	1	0
02/10/2015 04:00	0.8	13.9	1,297.4	0.7	2.60	1	1	0
02/10/2015 05:00	0.8	13.9	1,330.0	0.7	2.70	1	1	0
02/10/2015 06:00	1.2	13.4	1,891.8	0.9	5.70	1	1	1
02/10/2015 07:00	1.4	13.1	1,932.9	1.1	7.70	1	1	1
02/10/2015 08:00	1.0	13.8	1,525.3	0.8	4.60	1	1	1
02/10/2015 09:00	0.8	14.0	1,294.9	0.7	3.90	1	1	0
02/10/2015 10:00	0.8	13.9	1,294.6	0.7	2.60	1	1	0
02/10/2015 11:00	0.8	13.9	1,296.9	0.7	2.60	1	1	0
02/10/2015 12:00	0.8	14.0	1,297.3	0.7	3.90	1	1	0
02/10/2015 13:00	0.8	14.0	1,294.1	0.7	3.90	1	1	0
02/10/2015 14:00	0.8	14.0	1,294.3	0.7	3.90	1	1	0
02/10/2015 15:00	0.8	14.0	1,294.9	0.7	3.90	1	1	0
02/10/2015 16:00	1.2	13.3	1,851.3	0.9	5.60	1	1	1
02/10/2015 17:00	1.4	12.9	1,987.4	1.0	7.90	1	1	1
02/10/2015 18:00	1.5	12.6	2,027.7	1.1	8.10	1	1	1
02/10/2015 19:00	1.5	12.6	2,029.0	1.1	8.10	1	1	1
02/10/2015 20:00	1.5	12.7	2,015.0	1.1	8.10	1	1	1
02/10/2015 21:00	1.4	12.9	1,963.3	1.0	7.90	1	1	1
02/10/2015 22:00	1.5	12.7	2,015.1	1.1	8.10	1	1	1
02/10/2015 23:00	1.4	12.9	1,998.4	1.0	8.00	1	1	1
Average/Sum#:	1.1	13.5	1,587.8	0.8	120.20 #	24 #	24 #	11 #
Minimum:	0.8	12.6	1,291.7	0.7	2.60	1	1	0
Maximum:	1.5	14.0	2,029.0	1.1	8.10	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/11/2015 00:00	1.5	12.9	2,002.2	1.1	8.00	1	1	1
02/11/2015 01:00	1.2	13.3	1,890.2	0.9	5.70	1	1	1
02/11/2015 02:00	1.2	13.4	1,837.4	0.9	5.50	1	1	1
02/11/2015 03:00	1.2	13.4	1,838.6	0.9	5.50	1	1	1
02/11/2015 04:00	1.2	13.4	1,840.4	0.9	5.50	1	1	1
02/11/2015 05:00	1.2	13.4	1,865.2	0.9	5.60	1	1	1
02/11/2015 06:00	1.3	13.2	1,910.6	1.0	7.60	1	1	1
02/11/2015 07:00	1.1	13.4	1,846.2	0.9	5.50	1	1	1
02/11/2015 08:00	1.2	13.4	1,834.3	0.9	5.50	1	1	1
02/11/2015 09:00	1.2	13.4	1,837.9	0.9	5.50	1	1	1
02/11/2015 10:00	1.0	13.7	1,588.8	0.8	4.80	1	1	1
02/11/2015 11:00	0.9	13.9	1,449.6	0.8	4.30	1	1	0
02/11/2015 12:00	1.0	13.9	1,495.6	0.8	4.50	1	1	0
02/11/2015 13:00	0.8	14.0	1,292.2	0.7	3.90	1	1	0
02/11/2015 14:00	0.8	14.0	1,294.4	0.7	3.90	1	1	0
02/11/2015 15:00	0.9	13.7	1,552.7	0.7	4.70	1	1	1
02/11/2015 16:00	1.2	13.3	1,886.1	0.9	5.70	1	1	1
02/11/2015 17:00	1.3	13.1	1,933.6	1.0	7.70	1	1	1
02/11/2015 18:00	1.5	12.7	2,024.5	1.1	8.10	1	1	1
02/11/2015 19:00	1.5	12.8	1,990.0	1.1	8.00	1	1	1
02/11/2015 20:00	1.4	12.8	1,997.0	1.0	8.00	1	1	1
02/11/2015 21:00	1.4	13.0	1,960.1	1.0	7.80	1	1	1
02/11/2015 22:00	1.4	13.0	1,970.0	1.0	7.90	1	1	1
02/11/2015 23:00	1.1	13.4	1,858.5	0.9	5.60	1	1	1
Average/Sum#:	1.2	13.4	1,791.5	0.9	144.80 #	24 #	24 #	20 #
Minimum:	0.8	12.7	1,292.2	0.7	3.90	1	1	0
Maximum:	1.5	14.0	2,024.5	1.1	8.10	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/12/2015 00:00	0.9	13.8	1,413.0	0.7	4.20	1	1	1
02/12/2015 01:00	0.9	13.9	1,367.9	0.8	4.10	1	1	0
02/12/2015 02:00	0.8	13.9	1,301.9	0.7	2.60	1	1	0
02/12/2015 03:00	0.9	13.9	1,479.6	0.8	4.40	1	1	0
02/12/2015 04:00	1.0	13.7	1,596.7	0.8	4.80	1	1	1
02/12/2015 05:00	1.3	13.1	1,928.2	1.0	7.70	1	1	1
02/12/2015 06:00	1.3	13.2	1,912.4	1.0	7.60	1	1	1
02/12/2015 07:00	1.4	13.0	1,915.9	1.0	7.70	1	1	1
02/12/2015 08:00	1.0	13.7	1,559.6	0.8	4.70	1	1	1
02/12/2015 09:00	0.8	13.9	1,290.2	0.7	2.60	1	1	0
02/12/2015 10:00	0.8	13.9	1,290.3	0.7	2.60	1	1	0
02/12/2015 11:00	0.8	13.9	1,291.1	0.7	2.60	1	1	0
02/12/2015 12:00	0.8	13.9	1,294.8	0.7	2.60	1	1	0
02/12/2015 13:00	1.1	13.8	1,673.8	0.9	5.00	1	1	1
02/12/2015 14:00	1.5	12.7	1,991.9	1.1	8.00	1	1	1
02/12/2015 15:00	1.2	13.1	1,885.8	0.9	5.70	1	1	1
02/12/2015 16:00	1.3	13.0	1,921.0	1.0	7.70	1	1	1
02/12/2015 17:00	1.5	12.8	1,970.2	1.1	7.90	1	1	1
02/12/2015 18:00	1.5	12.5	2,036.2	1.1	8.10	1	1	1
02/12/2015 19:00	1.5	12.5	2,047.8	1.1	8.20	1	1	1
02/12/2015 20:00	1.5	12.6	2,032.6	1.1	8.10	1	1	1
02/12/2015 21:00	1.4	13.0	1,960.1	1.0	7.80	1	1	1
02/12/2015 22:00	1.4	12.8	1,996.9	1.0	8.00	1	1	1
02/12/2015 23:00	1.0	13.8	1,631.1	0.8	4.90	1	1	1
Average/Sum#:	1.2	13.4	1,699.5	0.9	137.60 #	24 #	24 #	17 #
Minimum:	0.8	12.5	1,290.2	0.7	2.60	1	1	0
Maximum:	1.5	13.9	2,047.8	1.1	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/13/2015 00:00	1.1	13.9	1,729.9	0.9	5.20	1	1	0
02/13/2015 01:00	0.9	13.9	1,483.7	0.8	4.50	1	1	0
02/13/2015 02:00	0.9	13.9	1,475.9	0.8	4.40	1	1	0
02/13/2015 03:00	1.1	13.9	1,747.9	0.9	5.20	1	1	0
02/13/2015 04:00	1.0	13.9	1,555.2	0.8	4.70	1	1	0
02/13/2015 05:00	0.9	13.8	1,575.5	0.7	4.70	1	1	1
02/13/2015 06:00	1.3	13.3	1,906.9	1.0	7.60	1	1	1
02/13/2015 07:00	1.3	13.3	1,879.7	1.0	7.50	1	1	1
02/13/2015 08:00	0.9	13.8	1,462.7	0.7	4.40	1	1	1
02/13/2015 09:00	0.8	13.9	1,294.8	0.7	2.60	1	1	0
02/13/2015 10:00	0.8	13.9	1,295.0	0.7	2.60	1	1	0
02/13/2015 11:00	0.8	13.9	1,301.9	0.7	2.60	1	1	0
02/13/2015 12:00	0.9	13.9	1,400.6	0.8	4.20	1	1	0
02/13/2015 13:00	1.0	13.8	1,653.1	0.8	5.00	1	1	1
02/13/2015 14:00	1.2	13.3	1,878.2	0.9	5.60	1	1	1
02/13/2015 15:00	1.0	13.4	1,851.4	0.8	5.60	1	1	1
02/13/2015 16:00	1.2	13.3	1,875.7	0.9	5.60	1	1	1
02/13/2015 17:00	1.3	13.0	1,933.9	1.0	7.70	1	1	1
02/13/2015 18:00	1.5	12.7	2,006.9	1.1	8.00	1	1	1
02/13/2015 19:00	1.5	12.5	2,042.2	1.1	8.20	1	1	1
02/13/2015 20:00	1.5	12.6	2,024.0	1.1	8.10	1	1	1
02/13/2015 21:00	1.5	12.8	1,999.2	1.1	8.00	1	1	1
02/13/2015 22:00	1.5	12.7	2,018.2	1.1	8.10	1	1	1
02/13/2015 23:00	1.3	13.2	1,902.4	1.0	7.60	1	1	1
Average/Sum#:	1.1	13.4	1,720.6	0.9	137.70 #	24 #	24 #	15 #
Minimum:	0.8	12.5	1,294.8	0.7	2.60	1	1	0
Maximum:	1.5	13.9	2,042.2	1.1	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/14/2015 00:00	1.4	12.9	1,983.2	1.0	7.90	1	1	1
02/14/2015 01:00	1.4	13.0	1,957.7	1.0	7.80	1	1	1
02/14/2015 02:00	1.4	12.9	1,973.7	1.0	7.90	1	1	1
02/14/2015 03:00	1.4	12.9	1,973.8	1.0	7.90	1	1	1
02/14/2015 04:00	1.4	13.0	1,963.6	1.0	7.90	1	1	1
02/14/2015 05:00	1.1	13.4	1,843.0	0.9	5.50	1	1	1
02/14/2015 06:00	0.9	13.8	1,493.9	0.7	4.50	1	1	1
02/14/2015 07:00	0.7	13.9	1,308.4	0.6	2.60	1	1	0
02/14/2015 08:00	0.8	13.9	1,297.8	0.7	2.60	1	1	0
02/14/2015 09:00	0.7	13.9	1,309.0	0.6	2.60	1	1	0
02/14/2015 10:00	0.8	13.9	1,302.9	0.7	2.60	1	1	0
02/14/2015 11:00	0.8	14.0	1,298.7	0.7	3.90	1	1	0
02/14/2015 12:00	0.8	14.0	1,299.1	0.7	3.90	1	1	0
02/14/2015 13:00	0.8	14.0	1,298.0	0.7	3.90	1	1	0
02/14/2015 14:00	0.8	14.0	1,295.9	0.7	3.90	1	1	0
02/14/2015 15:00	0.8	14.0	1,293.8	0.7	3.90	1	1	0
02/14/2015 16:00	1.0	13.5	1,559.5	0.8	4.70	1	1	1
02/14/2015 17:00	1.3	13.1	1,892.2	1.0	7.60	1	1	1
02/14/2015 18:00	1.2	13.1	1,893.2	0.9	5.70	1	1	1
02/14/2015 19:00	1.5	12.5	2,038.9	1.1	8.20	1	1	1
02/14/2015 20:00	1.3	13.0	1,936.5	1.0	7.70	1	1	1
02/14/2015 21:00	1.3	13.1	1,923.0	1.0	7.70	1	1	1
02/14/2015 22:00	1.4	12.8	1,975.3	1.0	7.90	1	1	1
02/14/2015 23:00	0.9	13.9	1,427.9	0.8	4.30	1	1	1
Average/Sum#:	1.1	13.4	1,647.5	0.8	133.10 #	24 #	24 #	15 #
Minimum:	0.7	12.5	1,293.8	0.6	2.60	1	1	0
Maximum:	1.5	14.0	2,038.9	1.1	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/15/2015 00:00	0.9	14.0	1,391.6	0.8	4.20	1	1	0
02/15/2015 01:00	0.9	13.9	1,456.7	0.8	4.40	1	1	0
02/15/2015 02:00	5.2	16.4	392.0	6.8	1.67	1	0	0
02/15/2015 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2015 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2015 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2015 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2015 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2015 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2015 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2015 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2015 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2015 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2015 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2015 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2015 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2015 16:00	15.6	18.1	386.6	32.9	14.04	1	0	0
02/15/2015 17:00	20.7	14.9	1,052.3	20.4	78.90	1	0	0
02/15/2015 18:00	0.7	14.0	1,444.1	0.6	2.90	1	1	0
02/15/2015 19:00	1.4	13.0	1,933.7	1.0	7.70	1	1	1
02/15/2015 20:00	1.4	12.7	1,987.8	1.0	8.00	1	1	1
02/15/2015 21:00	1.4	12.9	1,972.7	1.0	7.90	1	1	1
02/15/2015 22:00	1.5	12.9	1,971.8	1.1	7.90	1	1	1
02/15/2015 23:00	1.5	12.9	1,971.0	1.1	7.90	1	1	1
Average/Sum#:	4.7	14.2	1,450.9	6.1	145.51 #	11 #	8 #	5 #
Minimum:	0.7	12.7	386.6	0.6	1.67	0	0	0
Maximum:	20.7	18.1	1,987.8	32.9	78.90	1	1	1
%SI	54.2	54.2	54.2	54.2	54.17	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/16/2015 00:00	1.4	12.9	1,981.1	1.0	7.90	1	1	1
02/16/2015 01:00	1.3	13.2	1,910.4	1.0	7.60	1	1	1
02/16/2015 02:00	1.2	13.4	1,849.6	0.9	5.50	1	1	1
02/16/2015 03:00	1.2	13.4	1,851.4	0.9	5.60	1	1	1
02/16/2015 04:00	1.2	13.4	1,852.5	0.9	5.60	1	1	1
02/16/2015 05:00	1.3	13.3	1,882.9	1.0	7.50	1	1	1
02/16/2015 06:00	1.3	13.3	1,901.1	1.0	7.60	1	1	1
02/16/2015 07:00	1.2	13.4	1,834.3	0.9	5.50	1	1	1
02/16/2015 08:00	1.2	13.5	1,836.6	1.0	7.30	1	1	1
02/16/2015 09:00	1.2	13.5	1,846.7	1.0	7.40	1	1	1
02/16/2015 10:00	1.1	13.5	1,858.7	0.9	5.60	1	1	1
02/16/2015 11:00	1.1	13.4	1,857.5	0.9	5.60	1	1	1
02/16/2015 12:00	1.1	13.4	1,854.0	0.9	5.60	1	1	1
02/16/2015 13:00	1.0	13.6	1,558.2	0.8	4.70	1	1	1
02/16/2015 14:00	0.8	14.0	1,285.9	0.7	3.90	1	1	0
02/16/2015 15:00	1.0	13.7	1,544.6	0.8	4.60	1	1	1
02/16/2015 16:00	1.3	13.1	1,892.1	1.0	7.60	1	1	1
02/16/2015 17:00	1.4	12.9	1,943.1	1.0	7.80	1	1	1
02/16/2015 18:00	1.5	12.5	2,031.3	1.1	8.10	1	1	1
02/16/2015 19:00	1.5	12.6	2,021.1	1.1	8.10	1	1	1
02/16/2015 20:00	1.1	13.4	1,854.7	0.9	5.60	1	1	1
02/16/2015 21:00	1.2	13.3	1,884.0	0.9	5.70	1	1	1
02/16/2015 22:00	1.3	13.1	1,915.3	1.0	7.70	1	1	1
02/16/2015 23:00	1.1	13.5	1,854.1	0.9	5.60	1	1	1
Average/Sum#:	1.2	13.3	1,837.6	0.9	153.70 #	24 #	24 #	23 #
Minimum:	0.8	12.5	1,285.9	0.7	3.90	1	1	0
Maximum:	1.5	14.0	2,031.3	1.1	8.10	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/17/2015 00:00	1.1	13.4	1,852.3	0.9	5.60	1	1	1
02/17/2015 01:00	1.1	13.4	1,850.3	0.9	5.60	1	1	1
02/17/2015 02:00	1.1	13.4	1,851.7	0.9	5.60	1	1	1
02/17/2015 03:00	1.1	13.5	1,856.3	0.9	5.60	1	1	1
02/17/2015 04:00	1.1	13.5	1,860.3	0.9	5.60	1	1	1
02/17/2015 05:00	1.2	13.4	1,855.6	0.9	5.60	1	1	1
02/17/2015 06:00	1.2	13.4	1,874.9	0.9	5.60	1	1	1
02/17/2015 07:00	1.3	13.0	1,915.9	1.0	7.70	1	1	1
02/17/2015 08:00	1.1	13.4	1,842.0	0.9	5.50	1	1	1
02/17/2015 09:00	1.0	13.7	1,548.6	0.8	4.60	1	1	1
02/17/2015 10:00	0.9	13.9	1,410.7	0.8	4.20	1	1	0
02/17/2015 11:00	1.0	13.9	1,580.7	0.8	4.70	1	1	0
02/17/2015 12:00	0.9	13.9	1,557.7	0.8	4.70	1	1	0
02/17/2015 13:00	0.7	13.9	1,312.3	0.6	2.60	1	1	0
02/17/2015 14:00	0.7	13.9	1,288.7	0.6	2.60	1	1	0
02/17/2015 15:00	0.8	14.0	1,300.3	0.7	3.90	1	1	0
02/17/2015 16:00	1.0	13.6	1,605.7	0.8	4.80	1	1	1
02/17/2015 17:00	1.2	13.1	1,901.2	0.9	5.70	1	1	1
02/17/2015 18:00	1.5	12.6	2,014.9	1.1	8.10	1	1	1
02/17/2015 19:00	1.5	12.6	2,010.2	1.1	8.00	1	1	1
02/17/2015 20:00	1.4	12.9	1,964.7	1.0	7.90	1	1	1
02/17/2015 21:00	1.2	13.2	1,898.9	0.9	5.70	1	1	1
02/17/2015 22:00	1.3	13.1	1,830.3	1.0	7.30	1	1	1
02/17/2015 23:00	0.8	13.9	1,308.1	0.7	2.60	1	1	0
Average/Sum#:	1.1	13.4	1,720.5	0.9	129.80 #	24 #	24 #	17 #
Minimum:	0.7	12.6	1,288.7	0.6	2.60	1	1	0
Maximum:	1.5	14.0	2,014.9	1.1	8.10	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/18/2015 00:00	0.9	13.9	1,491.0	0.8	4.50	1	1	0
02/18/2015 01:00	1.0	13.9	1,518.4	0.8	4.60	1	1	0
02/18/2015 02:00	0.8	13.9	1,338.1	0.7	2.70	1	1	0
02/18/2015 03:00	0.8	13.9	1,307.4	0.7	2.60	1	1	0
02/18/2015 04:00	1.1	13.7	1,694.9	0.9	5.10	1	1	1
02/18/2015 05:00	1.2	13.3	1,882.0	0.9	5.60	1	1	1
02/18/2015 06:00	1.2	13.3	1,874.6	0.9	5.60	1	1	1
02/18/2015 07:00	1.3	13.1	1,947.5	1.0	7.80	1	1	1
02/18/2015 08:00	1.3	13.1	1,975.2	1.0	7.90	1	1	1
02/18/2015 09:00	1.4	13.0	1,989.3	1.0	8.00	1	1	1
02/18/2015 10:00	1.4	13.0	1,964.5	1.0	7.90	1	1	1
02/18/2015 11:00	1.1	13.4	1,844.4	0.9	5.50	1	1	1
02/18/2015 12:00	1.1	13.4	1,850.8	0.9	5.60	1	1	1
02/18/2015 13:00	1.1	13.4	1,852.8	0.9	5.60	1	1	1
02/18/2015 14:00	1.0	13.7	1,565.6	0.8	4.70	1	1	1
02/18/2015 15:00	1.0	13.9	1,658.5	0.8	5.00	1	1	0
02/18/2015 16:00	1.2	13.3	1,846.1	0.9	5.50	1	1	1
02/18/2015 17:00	1.4	12.8	1,996.7	1.0	8.00	1	1	1
02/18/2015 18:00	1.5	12.6	2,026.5	1.1	8.10	1	1	1
02/18/2015 19:00	1.4	12.8	1,993.3	1.0	8.00	1	1	1
02/18/2015 20:00	1.4	12.8	1,986.2	1.0	7.90	1	1	1
02/18/2015 21:00	1.4	12.9	1,974.4	1.0	7.90	1	1	1
02/18/2015 22:00	1.3	13.1	1,938.6	1.0	7.80	1	1	1
02/18/2015 23:00	1.2	13.3	1,865.1	0.9	5.60	1	1	1
Average/Sum#:	1.2	13.3	1,807.6	0.9	147.50 #	24 #	24 #	19 #
Minimum:	0.8	12.6	1,307.4	0.7	2.60	1	1	0
Maximum:	1.5	13.9	2,026.5	1.1	8.10	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/19/2015 00:00	1.4	13.0	1,961.5	1.0	7.80	1	1	1
02/19/2015 01:00	1.1	13.4	1,835.8	0.9	5.50	1	1	1
02/19/2015 02:00	0.8	13.8	1,428.3	0.7	2.90	1	1	1
02/19/2015 03:00	0.8	13.9	1,311.3	0.7	2.60	1	1	0
02/19/2015 04:00	0.8	13.8	1,435.3	0.7	2.90	1	1	1
02/19/2015 05:00	1.2	13.2	1,923.7	0.9	5.80	1	1	1
02/19/2015 06:00	1.3	13.1	1,940.7	1.0	7.80	1	1	1
02/19/2015 07:00	1.4	12.8	1,979.3	1.0	7.90	1	1	1
02/19/2015 08:00	1.4	12.9	1,985.2	1.0	7.90	1	1	1
02/19/2015 09:00	1.3	13.1	1,945.1	1.0	7.80	1	1	1
02/19/2015 10:00	1.4	12.7	2,021.8	1.0	8.10	1	1	1
02/19/2015 11:00	1.4	12.9	1,988.6	1.0	8.00	1	1	1
02/19/2015 12:00	1.3	13.0	1,942.3	1.0	7.80	1	1	1
02/19/2015 13:00	1.4	13.0	1,950.5	1.0	7.80	1	1	1
02/19/2015 14:00	1.0	13.4	1,852.5	0.8	5.60	1	1	1
02/19/2015 15:00	1.0	13.4	1,855.5	0.8	5.60	1	1	1
02/19/2015 16:00	1.1	13.3	1,870.0	0.9	5.60	1	1	1
02/19/2015 17:00	1.0	13.4	1,851.9	0.8	5.60	1	1	1
02/19/2015 18:00	1.3	13.0	1,939.2	1.0	7.80	1	1	1
02/19/2015 19:00	1.1	13.3	1,850.5	0.9	5.60	1	1	1
02/19/2015 20:00	1.0	13.4	1,843.1	0.8	5.50	1	1	1
02/19/2015 21:00	1.0	13.4	1,850.6	0.8	5.60	1	1	1
02/19/2015 22:00	1.1	13.3	1,881.9	0.9	5.60	1	1	1
02/19/2015 23:00	1.3	13.1	1,816.6	1.0	7.30	1	1	1
Average/Sum#:	1.2	13.2	1,844.2	0.9	150.40 #	24 #	24 #	23 #
Minimum:	0.8	12.7	1,311.3	0.7	2.60	1	1	0
Maximum:	1.4	13.9	2,021.8	1.0	8.10	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/20/2015 00:00	0.7	13.9	1,345.3	0.6	2.70	1	1	0
02/20/2015 01:00	3.6	15.9	571.2	4.2	2.09	1	0	0
02/20/2015 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2015 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2015 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2015 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2015 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2015 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2015 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2015 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2015 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2015 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2015 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2015 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2015 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2015 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2015 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2015 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2015 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2015 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2015 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2015 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2015 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2015 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	2.2	14.9	958.3	2.4	4.79 #	2 #	1 #	0 #
Minimum:	0.7	13.9	571.2	0.6	2.09	0	0	0
Maximum:	3.6	15.9	1,345.3	4.2	2.70	1	1	0
%SI	91.7	91.7	91.7	91.7	91.67	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/21/2015 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2015 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2015 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2015 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2015 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2015 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2015 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2015 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2015 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2015 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2015 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2015 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2015 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2015 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2015 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2015 15:00	26.2	17.4	509.5	44.2	55.61	1	0	0
02/21/2015 16:00	13.0	14.8	1,042.1	12.6	47.90	1	0	0
02/21/2015 17:00	0.7	13.8	1,506.1	0.6	3.00	1	1	1
02/21/2015 18:00	1.3	12.8	1,973.2	0.9	5.90	1	1	1
02/21/2015 19:00	1.5	12.6	2,022.8	1.1	8.10	1	1	1
02/21/2015 20:00	1.5	12.7	2,019.2	1.1	8.10	1	1	1
02/21/2015 21:00	1.4	12.9	1,984.1	1.0	7.90	1	1	1
02/21/2015 22:00	1.5	12.8	2,031.9	1.1	8.10	1	1	1
02/21/2015 23:00	1.3	13.1	1,943.6	1.0	7.80	1	1	1
Average/Sum#:	5.4	13.7	1,670.3	7.1	152.41 #	9 #	7 #	7 #
Minimum:	0.7	12.6	509.5	0.6	3.00	0	0	0
Maximum:	26.2	17.4	2,031.9	44.2	55.61	1	1	1
%SI	62.5	62.5	62.5	62.5	62.50	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/22/2015 00:00	0.9	14.0	1,401.2	0.8	4.20	1	1	0
02/22/2015 01:00	1.0	13.9	1,549.0	0.8	4.60	1	1	0
02/22/2015 02:00	0.8	14.0	1,293.0	0.7	3.90	1	1	0
02/22/2015 03:00	0.8	14.0	1,342.6	0.7	4.00	1	1	0
02/22/2015 04:00	1.1	14.0	1,584.9	0.9	4.80	1	1	0
02/22/2015 05:00	1.0	14.0	1,500.5	0.9	4.50	1	1	0
02/22/2015 06:00	6.3	16.5	403.5	8.4	2.25	1	0	0
02/22/2015 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2015 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2015 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2015 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2015 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2015 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2015 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2015 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2015 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2015 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2015 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2015 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2015 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2015 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2015 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2015 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2015 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.7	14.3	1,296.4	1.9	28.25 #	7 #	6 #	0 #
Minimum:	0.8	13.9	403.5	0.7	2.25	0	0	0
Maximum:	6.3	16.5	1,584.9	8.4	4.80	1	1	0
%SI	70.8	70.8	70.8	70.8	70.83	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/23/2015 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/24/2015 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/24/2015 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/24/2015 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/24/2015 03:00	26.4	17.8	457.8	50.2	49.13	1	0	0
02/24/2015 04:00	27.2	15.8	718.2	31.5	83.30	1	0	0
02/24/2015 05:00	11.7	13.7	1,613.7	9.6	56.50	1	0	1
02/24/2015 06:00	1.4	12.9	2,017.2	1.0	8.10	1	1	1
02/24/2015 07:00	1.4	13.0	2,012.0	1.0	8.00	1	1	1
02/24/2015 08:00	1.3	13.2	1,960.4	1.0	7.80	1	1	1
02/24/2015 09:00	1.1	13.7	1,558.6	0.9	4.70	1	1	1
02/24/2015 10:00	0.9	14.0	1,325.8	0.8	4.00	1	1	0
02/24/2015 11:00	1.0	14.0	1,293.5	0.9	3.90	1	1	0
02/24/2015 12:00	1.0	14.0	1,292.0	0.9	3.90	1	1	0
02/24/2015 13:00	1.0	14.0	1,289.1	0.9	3.90	1	1	0
02/24/2015 14:00	1.0	14.0	1,310.1	0.9	3.90	1	1	0
02/24/2015 15:00	1.0	14.0	1,364.1	0.9	4.10	1	1	0
02/24/2015 16:00	1.0	13.8	1,477.7	0.8	4.40	1	1	1
02/24/2015 17:00	1.4	12.9	1,969.0	1.0	7.90	1	1	1
02/24/2015 18:00	1.4	12.7	2,015.2	1.0	8.10	1	1	1
02/24/2015 19:00	1.4	12.8	2,012.3	1.0	8.00	1	1	1
02/24/2015 20:00	1.4	12.8	2,018.9	1.0	8.10	1	1	1
02/24/2015 21:00	1.4	12.9	2,024.7	1.0	8.10	1	1	1
02/24/2015 22:00	1.3	13.3	1,820.3	1.0	7.30	1	1	1
02/24/2015 23:00	0.9	14.0	1,489.8	0.8	4.50	1	1	0
Average/Sum#:	4.1	13.8	1,573.4	5.1	297.63 #	21 #	18 #	12 #
Minimum:	0.9	12.7	457.8	0.8	3.90	0	0	0
Maximum:	27.2	17.8	2,024.7	50.2	83.30	1	1	1
%SI	12.5	12.5	12.5	12.5	12.50	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/25/2015 00:00	0.9	13.9	1,301.2	0.8	3.90	1	1	0
02/25/2015 01:00	1.1	14.0	1,754.7	0.9	5.30	1	1	0
02/25/2015 02:00	1.1	13.9	1,735.6	0.9	5.20	1	1	0
02/25/2015 03:00	0.9	13.9	1,442.5	0.8	4.30	1	1	0
02/25/2015 04:00	0.9	13.9	1,287.6	0.8	3.90	1	1	0
02/25/2015 05:00	1.1	13.6	1,632.5	0.9	4.90	1	1	1
02/25/2015 06:00	1.4	13.1	1,991.4	1.1	8.00	1	1	1
02/25/2015 07:00	1.4	13.1	1,971.7	1.1	7.90	1	1	1
02/25/2015 08:00	1.2	13.6	1,734.4	1.0	6.90	1	1	1
02/25/2015 09:00	0.9	13.9	1,307.2	0.8	3.90	1	1	0
02/25/2015 10:00	0.9	14.0	1,291.5	0.8	3.90	1	1	0
02/25/2015 11:00	0.9	14.0	1,292.1	0.8	3.90	1	1	0
02/25/2015 12:00	0.8	14.0	1,293.3	0.7	3.90	1	1	0
02/25/2015 13:00	0.9	14.0	1,410.7	0.8	4.20	1	1	0
02/25/2015 14:00	0.9	14.0	1,299.6	0.8	3.90	1	1	0
02/25/2015 15:00	0.9	14.0	1,292.8	0.8	3.90	1	1	0
02/25/2015 16:00	0.9	13.8	1,466.8	0.7	4.40	1	1	1
02/25/2015 17:00	1.4	12.9	1,956.1	1.0	7.80	1	1	1
02/25/2015 18:00	1.4	12.8	1,980.6	1.0	7.90	1	1	1
02/25/2015 19:00	1.4	13.1	1,916.9	1.1	7.70	1	1	1
02/25/2015 20:00	1.4	13.2	1,925.6	1.1	7.70	1	1	1
02/25/2015 21:00	1.4	13.0	1,975.8	1.0	7.90	1	1	1
02/25/2015 22:00	1.3	13.3	1,790.1	1.0	7.20	1	1	1
02/25/2015 23:00	0.9	14.0	1,440.6	0.8	4.30	1	1	0
Average/Sum#:	1.1	13.6	1,603.8	0.9	132.80 #	24 #	24 #	11 #
Minimum:	0.8	12.8	1,287.6	0.7	3.90	1	1	0
Maximum:	1.4	14.0	1,991.4	1.1	8.00	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/26/2015 00:00	0.8	14.0	1,288.7	0.7	3.90	1	1	0
02/26/2015 01:00	0.8	14.0	1,303.7	0.7	3.90	1	1	0
02/26/2015 02:00	1.2	13.8	1,754.7	1.0	7.00	1	1	0
02/26/2015 03:00	1.2	13.8	1,816.7	1.0	7.30	1	1	0
02/26/2015 04:00	1.1	13.7	1,760.9	0.9	5.30	1	1	1
02/26/2015 05:00	1.4	13.2	1,945.5	1.1	7.80	1	1	1
02/26/2015 06:00	1.4	13.2	1,958.0	1.1	7.80	1	1	1
02/26/2015 07:00	1.4	13.0	1,969.6	1.0	7.90	1	1	1
02/26/2015 08:00	1.2	13.5	1,626.7	1.0	6.50	1	1	1
02/26/2015 09:00	0.9	14.0	1,374.8	0.8	4.10	1	1	0
02/26/2015 10:00	1.0	14.0	1,677.5	0.9	5.00	1	1	0
02/26/2015 11:00	1.1	13.9	1,699.9	0.9	5.10	1	1	0
02/26/2015 12:00	0.8	14.1	1,314.0	0.7	3.90	1	1	0
02/26/2015 13:00	0.8	14.0	1,289.8	0.7	3.90	1	1	0
02/26/2015 14:00	0.8	14.0	1,290.9	0.7	3.90	1	1	0
02/26/2015 15:00	0.9	14.0	1,477.3	0.8	4.40	1	1	0
02/26/2015 16:00	1.2	13.2	1,789.9	0.9	5.40	1	1	1
02/26/2015 17:00	1.5	12.9	1,956.0	1.1	7.80	1	1	1
02/26/2015 18:00	1.5	12.5	2,032.6	1.1	8.10	1	1	1
02/26/2015 19:00	1.5	12.5	2,029.8	1.1	8.10	1	1	1
02/26/2015 20:00	1.5	12.7	1,997.6	1.1	8.00	1	1	1
02/26/2015 21:00	1.5	12.8	1,981.9	1.1	7.90	1	1	1
02/26/2015 22:00	1.0	13.6	1,576.2	0.8	4.70	1	1	1
02/26/2015 23:00	0.7	14.0	1,286.8	0.6	2.60	1	1	0
Average/Sum#:	1.1	13.5	1,675.0	0.9	140.30 #	24 #	24 #	12 #
Minimum:	0.7	12.5	1,286.8	0.6	2.60	1	1	0
Maximum:	1.5	14.1	2,032.6	1.1	8.10	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/27/2015 00:00	1.1	13.8	1,715.6	0.9	5.10	1	1	0
02/27/2015 01:00	1.2	13.8	1,787.0	1.0	7.10	1	1	0
02/27/2015 02:00	1.2	13.8	1,767.6	1.0	7.10	1	1	0
02/27/2015 03:00	0.9	13.9	1,499.4	0.8	4.50	1	1	0
02/27/2015 04:00	0.7	14.0	1,287.7	0.6	2.60	1	1	0
02/27/2015 05:00	0.9	13.8	1,472.7	0.7	4.40	1	1	1
02/27/2015 06:00	1.4	13.0	1,991.1	1.0	8.00	1	1	1
02/27/2015 07:00	1.3	13.0	1,800.5	1.0	7.20	1	1	1
02/27/2015 08:00	0.7	14.0	1,304.2	0.6	2.60	1	1	0
02/27/2015 09:00	0.7	14.0	1,285.3	0.6	2.60	1	1	0
02/27/2015 10:00	0.8	14.0	1,291.0	0.7	3.90	1	1	0
02/27/2015 11:00	0.9	13.9	1,487.1	0.8	4.50	1	1	0
02/27/2015 12:00	0.7	14.0	1,288.7	0.6	2.60	1	1	0
02/27/2015 13:00	0.7	14.0	1,289.8	0.6	2.60	1	1	0
02/27/2015 14:00	0.8	14.0	1,285.2	0.7	3.90	1	1	0
02/27/2015 15:00	0.8	14.1	1,352.5	0.7	4.10	1	1	0
02/27/2015 16:00	0.9	14.0	1,448.8	0.8	4.30	1	1	0
02/27/2015 17:00	1.1	13.4	1,658.6	0.9	5.00	1	1	1
02/27/2015 18:00	1.5	12.6	2,050.2	1.1	8.20	1	1	1
02/27/2015 19:00	1.5	12.6	2,048.8	1.1	8.20	1	1	1
02/27/2015 20:00	1.5	12.7	2,050.2	1.1	8.20	1	1	1
02/27/2015 21:00	1.5	12.7	2,040.1	1.1	8.20	1	1	1
02/27/2015 22:00	1.5	12.8	2,022.8	1.1	8.10	1	1	1
02/27/2015 23:00	1.1	13.6	1,587.2	0.9	4.80	1	1	1
Average/Sum#:	1.1	13.6	1,617.2	0.9	127.80 #	24 #	24 #	10 #
Minimum:	0.7	12.6	1,285.2	0.6	2.60	1	1	0
Maximum:	1.5	14.1	2,050.2	1.1	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/28/2015 00:00	0.8	14.0	1,285.3	0.7	3.90	1	1	0
02/28/2015 01:00	4.2	15.9	572.0	5.0	2.27	1	0	0
02/28/2015 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2015 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2015 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2015 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2015 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2015 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2015 08:00	10.4	16.9	566.9	15.3	22.61	1	0	0
02/28/2015 09:00	8.6	14.5	1,155.7	7.9	33.50	1	0	0
02/28/2015 10:00	0.9	13.9	1,610.8	0.8	4.80	1	1	0
02/28/2015 11:00	1.2	13.8	1,819.7	1.0	7.30	1	1	0
02/28/2015 12:00	0.9	13.9	1,591.4	0.8	4.80	1	1	0
02/28/2015 13:00	0.8	14.0	1,519.6	0.7	4.60	1	1	0
02/28/2015 14:00	1.3	13.8	1,785.2	1.1	7.10	1	1	0
02/28/2015 15:00	0.9	14.0	1,577.6	0.8	4.70	1	1	0
02/28/2015 16:00	1.0	13.7	1,584.1	0.8	4.80	1	1	1
02/28/2015 17:00	1.4	12.8	2,008.3	1.0	8.00	1	1	1
02/28/2015 18:00	1.5	12.7	2,030.8	1.1	8.10	1	1	1
02/28/2015 19:00	1.5	12.8	2,031.6	1.1	8.10	1	1	1
02/28/2015 20:00	1.5	12.8	2,038.1	1.1	8.20	1	1	1
02/28/2015 21:00	1.5	12.8	2,035.5	1.1	8.10	1	1	1
02/28/2015 22:00	1.5	12.8	2,036.7	1.1	8.10	1	1	1
02/28/2015 23:00	1.4	12.9	2,011.2	1.0	8.00	1	1	1
Average/Sum#:	2.3	13.8	1,625.6	2.4	156.98 #	18 #	15 #	8 #
Minimum:	0.8	12.7	566.9	0.7	2.27	0	0	0
Maximum:	10.4	16.9	2,038.1	15.3	33.50	1	1	1
%SI	25.0	25.0	25.0	25.0	25.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/01/2015 00:00	1.4	13.0	1,991.7	1.0	8.00	1	1	1
03/01/2015 01:00	1.3	13.5	1,858.2	1.0	7.40	1	1	1
03/01/2015 02:00	1.0	14.0	1,587.3	0.9	4.80	1	1	0
03/01/2015 03:00	1.0	14.0	1,665.9	0.9	5.00	1	1	0
03/01/2015 04:00	0.8	14.0	1,379.1	0.7	4.10	1	1	0
03/01/2015 05:00	1.2	13.9	1,745.9	1.0	7.00	1	1	0
03/01/2015 06:00	1.2	13.9	1,794.8	1.0	7.20	1	1	0
03/01/2015 07:00	1.3	13.8	1,835.0	1.1	7.30	1	1	0
03/01/2015 08:00	1.3	13.4	1,881.7	1.0	7.50	1	1	1
03/01/2015 09:00	1.5	12.8	2,040.1	1.1	8.20	1	1	1
03/01/2015 10:00	1.5	12.8	2,044.9	1.1	8.20	1	1	1
03/01/2015 11:00	1.5	12.7	2,050.5	1.1	8.20	1	1	1
03/01/2015 12:00	1.5	12.7	2,053.3	1.1	8.20	1	1	1
03/01/2015 13:00	1.4	13.0	1,986.5	1.0	7.90	1	1	1
03/01/2015 14:00	1.4	12.8	2,025.9	1.0	8.10	1	1	1
03/01/2015 15:00	1.5	12.6	2,053.6	1.1	8.20	1	1	1
03/01/2015 16:00	1.5	12.7	2,026.6	1.1	8.10	1	1	1
03/01/2015 17:00	1.5	12.6	2,053.2	1.1	8.20	1	1	1
03/01/2015 18:00	1.5	12.6	2,053.4	1.1	8.20	1	1	1
03/01/2015 19:00	1.5	12.7	2,052.5	1.1	8.20	1	1	1
03/01/2015 20:00	1.5	12.7	2,053.0	1.1	8.20	1	1	1
03/01/2015 21:00	1.5	12.7	2,052.7	1.1	8.20	1	1	1
03/01/2015 22:00	1.4	12.8	2,035.8	1.0	8.10	1	1	1
03/01/2015 23:00	1.4	13.0	1,993.3	1.0	8.00	1	1	1
Average/Sum#:	1.4	13.1	1,929.8	1.0	180.50 #	24 #	24 #	18 #
Minimum:	0.8	12.6	1,379.1	0.7	4.10	1	1	0
Maximum:	1.5	14.0	2,053.6	1.1	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/02/2015 00:00	1.4	12.9	2,009.0	1.0	8.00	1	1	1
03/02/2015 01:00	1.5	12.8	2,026.3	1.1	8.10	1	1	1
03/02/2015 02:00	1.4	13.0	1,996.9	1.0	8.00	1	1	1
03/02/2015 03:00	1.3	13.3	1,941.6	1.0	7.80	1	1	1
03/02/2015 04:00	1.1	13.6	1,816.0	0.9	5.40	1	1	1
03/02/2015 05:00	1.3	13.1	1,977.4	1.0	7.90	1	1	1
03/02/2015 06:00	1.4	13.0	2,000.8	1.0	8.00	1	1	1
03/02/2015 07:00	1.4	12.8	2,029.4	1.0	8.10	1	1	1
03/02/2015 08:00	1.4	12.9	2,008.5	1.0	8.00	1	1	1
03/02/2015 09:00	1.4	12.9	2,013.8	1.0	8.10	1	1	1
03/02/2015 10:00	1.4	13.0	2,006.3	1.0	8.00	1	1	1
03/02/2015 11:00	1.4	13.0	1,978.5	1.0	7.90	1	1	1
03/02/2015 12:00	1.4	12.9	2,004.4	1.0	8.00	1	1	1
03/02/2015 13:00	1.4	12.9	1,992.8	1.0	8.00	1	1	1
03/02/2015 14:00	1.2	13.6	1,699.2	1.0	6.80	1	1	1
03/02/2015 15:00	1.0	13.9	1,616.8	0.8	4.90	1	1	0
03/02/2015 16:00	1.2	13.5	1,823.6	1.0	7.30	1	1	1
03/02/2015 17:00	1.4	13.3	1,927.3	1.1	7.70	1	1	1
03/02/2015 18:00	1.4	13.3	1,932.6	1.1	7.70	1	1	1
03/02/2015 19:00	1.4	13.3	1,936.3	1.1	7.70	1	1	1
03/02/2015 20:00	1.4	13.3	1,942.8	1.1	7.80	1	1	1
03/02/2015 21:00	1.4	13.3	1,943.3	1.1	7.80	1	1	1
03/02/2015 22:00	1.3	13.5	1,801.7	1.0	7.20	1	1	1
03/02/2015 23:00	0.9	13.9	1,545.1	0.8	4.60	1	1	0
Average/Sum#:	1.3	13.2	1,915.4	1.0	178.80 #	24 #	24 #	22 #
Minimum:	0.9	12.8	1,545.1	0.8	4.60	1	1	0
Maximum:	1.5	13.9	2,029.4	1.1	8.10	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/03/2015 00:00	0.8	13.9	1,288.7	0.7	2.60	1	1	0
03/03/2015 01:00	0.8	13.9	1,289.4	0.7	2.60	1	1	0
03/03/2015 02:00	0.8	13.9	1,292.2	0.7	2.60	1	1	0
03/03/2015 03:00	0.8	13.9	1,294.3	0.7	2.60	1	1	0
03/03/2015 04:00	1.0	13.7	1,562.2	0.8	4.70	1	1	1
03/03/2015 05:00	1.3	13.1	1,989.1	1.0	8.00	1	1	1
03/03/2015 06:00	1.4	12.9	2,026.0	1.0	8.10	1	1	1
03/03/2015 07:00	1.4	13.0	1,981.8	1.0	7.90	1	1	1
03/03/2015 08:00	1.0	13.7	1,594.7	0.8	4.80	1	1	1
03/03/2015 09:00	0.8	14.0	1,290.8	0.7	3.90	1	1	0
03/03/2015 10:00	0.8	14.0	1,293.1	0.7	3.90	1	1	0
03/03/2015 11:00	0.8	14.0	1,293.5	0.7	3.90	1	1	0
03/03/2015 12:00	0.8	14.0	1,296.6	0.7	3.90	1	1	0
03/03/2015 13:00	0.8	14.0	1,298.0	0.7	3.90	1	1	0
03/03/2015 14:00	0.8	14.0	1,292.8	0.7	3.90	1	1	0
03/03/2015 15:00	0.8	14.0	1,292.4	0.7	3.90	1	1	0
03/03/2015 16:00	0.9	13.9	1,406.7	0.8	4.20	1	1	1
03/03/2015 17:00	1.4	13.2	1,938.6	1.1	7.80	1	1	1
03/03/2015 18:00	1.5	12.9	2,010.7	1.1	8.00	1	1	1
03/03/2015 19:00	1.5	12.7	2,055.8	1.1	8.20	1	1	1
03/03/2015 20:00	1.5	12.7	2,049.7	1.1	8.20	1	1	1
03/03/2015 21:00	1.5	12.7	2,049.8	1.1	8.20	1	1	1
03/03/2015 22:00	1.4	12.9	2,011.7	1.0	8.00	1	1	1
03/03/2015 23:00	1.2	13.6	1,718.2	1.0	6.90	1	1	1
Average/Sum#:	1.1	13.5	1,609.0	0.9	130.70 #	24 #	24 #	13 #
Minimum:	0.8	12.7	1,288.7	0.7	2.60	1	1	0
Maximum:	1.5	14.0	2,055.8	1.1	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/04/2015 00:00	1.1	13.9	1,813.5	0.9	5.40	1	1	0
03/04/2015 01:00	1.1	13.9	1,786.5	0.9	5.40	1	1	0
03/04/2015 02:00	1.0	14.1	1,736.5	0.9	5.20	1	1	0
03/04/2015 03:00	1.1	13.9	1,769.1	0.9	5.30	1	1	0
03/04/2015 04:00	1.2	13.5	1,819.7	1.0	7.30	1	1	1
03/04/2015 05:00	1.4	13.0	2,003.0	1.0	8.00	1	1	1
03/04/2015 06:00	1.4	13.0	2,006.0	1.0	8.00	1	1	1
03/04/2015 07:00	1.4	12.9	2,001.0	1.0	8.00	1	1	1
03/04/2015 08:00	1.3	13.1	1,977.6	1.0	7.90	1	1	1
03/04/2015 09:00	1.0	13.8	1,456.5	0.8	4.40	1	1	1
03/04/2015 10:00	0.8	14.0	1,292.8	0.7	3.90	1	1	0
03/04/2015 11:00	0.9	14.0	1,291.4	0.8	3.90	1	1	0
03/04/2015 12:00	0.9	14.0	1,290.1	0.8	3.90	1	1	0
03/04/2015 13:00	0.9	14.0	1,288.9	0.8	3.90	1	1	0
03/04/2015 14:00	0.9	14.0	1,289.0	0.8	3.90	1	1	0
03/04/2015 15:00	0.9	14.0	1,288.3	0.8	3.90	1	1	0
03/04/2015 16:00	1.1	13.7	1,545.9	0.9	4.60	1	1	1
03/04/2015 17:00	1.5	12.8	2,008.9	1.1	8.00	1	1	1
03/04/2015 18:00	1.5	12.7	2,031.5	1.1	8.10	1	1	1
03/04/2015 19:00	1.5	12.7	2,027.5	1.1	8.10	1	1	1
03/04/2015 20:00	1.5	12.8	2,026.1	1.1	8.10	1	1	1
03/04/2015 21:00	1.4	12.9	2,009.7	1.0	8.00	1	1	1
03/04/2015 22:00	1.4	13.0	2,013.6	1.0	8.10	1	1	1
03/04/2015 23:00	1.3	13.2	1,982.8	1.0	7.90	1	1	1
Average/Sum#:	1.2	13.5	1,739.8	0.9	149.20 #	24 #	24 #	14 #
Minimum:	0.8	12.7	1,288.3	0.7	3.90	1	1	0
Maximum:	1.5	14.1	2,031.5	1.1	8.10	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/05/2015 00:00	1.2	13.5	1,807.0	1.0	7.20	1	1	1
03/05/2015 01:00	1.0	13.9	1,591.2	0.8	4.80	1	1	0
03/05/2015 02:00	1.0	13.9	1,546.0	0.8	4.60	1	1	0
03/05/2015 03:00	1.0	13.9	1,632.9	0.8	4.90	1	1	0
03/05/2015 04:00	1.1	13.8	1,760.9	0.9	5.30	1	1	1
03/05/2015 05:00	1.3	13.1	1,991.2	1.0	8.00	1	1	1
03/05/2015 06:00	1.4	13.0	2,018.4	1.0	8.10	1	1	1
03/05/2015 07:00	1.4	13.1	2,015.3	1.1	8.10	1	1	1
03/05/2015 08:00	1.2	13.3	1,941.5	0.9	5.80	1	1	1
03/05/2015 09:00	0.8	13.8	1,455.1	0.7	2.76	1	1	1
03/05/2015 10:00	0.7	13.9	1,292.3	0.6	2.60	1	1	0
03/05/2015 11:00	0.8	14.0	1,292.4	0.7	3.90	1	1	0
03/05/2015 12:00	0.8	14.0	1,292.5	0.7	3.90	1	1	0
03/05/2015 13:00	0.9	14.0	1,293.4	0.8	3.90	1	1	0
03/05/2015 14:00	0.9	14.0	1,294.8	0.8	3.90	1	1	0
03/05/2015 15:00	0.8	14.0	1,295.6	0.7	3.90	1	1	0
03/05/2015 16:00	1.0	13.7	1,549.7	0.8	4.60	1	1	1
03/05/2015 17:00	1.5	12.6	2,023.1	1.1	8.10	1	1	1
03/05/2015 18:00	1.5	12.6	2,035.5	1.1	8.10	1	1	1
03/05/2015 19:00	1.5	12.6	2,031.7	1.1	8.10	1	1	1
03/05/2015 20:00	1.5	12.7	2,029.0	1.1	8.10	1	1	1
03/05/2015 21:00	1.5	12.7	2,018.7	1.1	8.10	1	1	1
03/05/2015 22:00	1.5	12.8	2,010.9	1.1	8.00	1	1	1
03/05/2015 23:00	1.2	13.4	1,745.1	0.9	5.20	1	1	1
Average/Sum#:	1.1	13.4	1,706.8	0.9	139.96 #	24 #	24 #	15 #
Minimum:	0.7	12.6	1,292.3	0.6	2.60	1	1	0
Maximum:	1.5	14.0	2,035.5	1.1	8.10	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/06/2015 00:00	0.8	13.9	1,294.5	0.7	2.60	1	1	0
03/06/2015 01:00	0.8	13.9	1,292.1	0.7	2.60	1	1	0
03/06/2015 02:00	0.8	13.9	1,290.3	0.7	2.60	1	1	0
03/06/2015 03:00	0.8	13.9	1,292.0	0.7	2.60	1	1	0
03/06/2015 04:00	0.8	13.9	1,293.1	0.7	2.60	1	1	0
03/06/2015 05:00	1.0	13.6	1,570.5	0.8	4.70	1	1	1
03/06/2015 06:00	1.3	13.1	1,994.1	1.0	8.00	1	1	1
03/06/2015 07:00	1.3	13.2	1,954.1	1.0	7.80	1	1	1
03/06/2015 08:00	1.2	13.3	1,941.3	0.9	5.80	1	1	1
03/06/2015 09:00	1.2	13.3	1,949.5	0.9	5.80	1	1	1
03/06/2015 10:00	1.1	13.6	1,612.8	0.9	4.80	1	1	1
03/06/2015 11:00	0.8	14.0	1,291.4	0.7	3.90	1	1	0
03/06/2015 12:00	0.8	14.0	1,292.6	0.7	3.90	1	1	0
03/06/2015 13:00	0.8	14.0	1,295.6	0.7	3.90	1	1	0
03/06/2015 14:00	0.8	14.0	1,298.0	0.7	3.90	1	1	0
03/06/2015 15:00	0.8	14.0	1,297.6	0.7	3.90	1	1	0
03/06/2015 16:00	1.0	13.7	1,535.8	0.8	4.60	1	1	1
03/06/2015 17:00	1.5	12.6	1,996.7	1.1	8.00	1	1	1
03/06/2015 18:00	1.5	12.4	2,042.2	1.0	8.20	1	1	1
03/06/2015 19:00	1.5	12.4	2,042.1	1.0	8.20	1	1	1
03/06/2015 20:00	1.5	12.5	2,038.0	1.1	8.20	1	1	1
03/06/2015 21:00	1.4	12.8	2,003.6	1.0	8.00	1	1	1
03/06/2015 22:00	1.4	12.8	2,009.9	1.0	8.00	1	1	1
03/06/2015 23:00	1.4	12.9	1,995.0	1.0	8.00	1	1	1
Average/Sum#:	1.1	13.4	1,651.0	0.9	130.60 #	24 #	24 #	14 #
Minimum:	0.8	12.4	1,290.3	0.7	2.60	1	1	0
Maximum:	1.5	14.0	2,042.2	1.1	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/07/2015 00:00	1.3	13.2	1,881.1	1.0	7.50	1	1	1
03/07/2015 01:00	1.2	13.8	1,727.7	1.0	6.90	1	1	0
03/07/2015 02:00	6.2	16.1	468.2	7.6	2.36	1	0	0
03/07/2015 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2015 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2015 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2015 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2015 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2015 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2015 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2015 10:00	15.1	16.8	573.4	21.7	32.13	1	0	0
03/07/2015 11:00	12.5	15.0	999.4	12.5	46.00	1	0	0
03/07/2015 12:00	1.2	13.9	1,751.8	1.0	7.00	1	1	0
03/07/2015 13:00	1.4	13.9	1,754.1	1.2	7.00	1	1	0
03/07/2015 14:00	1.3	13.9	1,686.5	1.1	6.70	1	1	0
03/07/2015 15:00	0.9	14.0	1,453.4	0.8	4.40	1	1	0
03/07/2015 16:00	1.2	13.5	1,700.8	1.0	6.80	1	1	1
03/07/2015 17:00	1.5	12.4	2,038.3	1.0	8.20	1	1	1
03/07/2015 18:00	1.5	12.5	2,011.2	1.1	8.00	1	1	1
03/07/2015 19:00	1.5	12.4	2,039.0	1.0	8.20	1	1	1
03/07/2015 20:00	1.5	12.5	2,037.5	1.1	8.20	1	1	1
03/07/2015 21:00	1.5	12.8	1,993.6	1.1	8.00	1	1	1
03/07/2015 22:00	1.4	12.9	1,993.2	1.0	8.00	1	1	1
03/07/2015 23:00	1.3	13.2	1,789.3	1.0	7.20	1	1	1
Average/Sum#:	3.1	13.7	1,641.1	3.3	182.59 #	17 #	14 #	9 #
Minimum:	0.9	12.4	468.2	0.8	2.36	0	0	0
Maximum:	15.1	16.8	2,039.0	21.7	46.00	1	1	1
%SI	29.2	29.2	29.2	29.2	29.17	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/08/2015 00:00	0.8	14.0	1,286.2	0.7	3.90	1	1	0
03/08/2015 01:00	0.8	14.0	1,286.3	0.7	3.90	1	1	0
03/08/2015 02:00	0.8	14.0	1,286.7	0.7	3.90	1	1	0
03/08/2015 03:00	0.8	14.0	1,287.3	0.7	3.90	1	1	0
03/08/2015 04:00	0.9	14.0	1,288.2	0.8	3.90	1	1	0
03/08/2015 05:00	0.9	14.0	1,288.0	0.8	3.90	1	1	0
03/08/2015 06:00	0.8	13.9	1,290.3	0.7	2.60	1	1	0
03/08/2015 07:00	0.9	13.9	1,290.6	0.8	3.90	1	1	0
03/08/2015 08:00	4.0	15.8	578.5	4.6	2.16	1	0	0
03/08/2015 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2015 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2015 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2015 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2015 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2015 14:00	0.0	21.0	0.2	0.0	0.00	1	0	0
03/08/2015 15:00	11.6	16.0	676.0	14.0	34.50	1	0	0
03/08/2015 16:00	6.1	14.0	1,295.4	5.2	24.60	1	0	0
03/08/2015 17:00	0.7	14.0	1,294.9	0.6	2.60	1	1	0
03/08/2015 18:00	1.2	13.4	1,691.0	0.9	5.10	1	1	1
03/08/2015 19:00	1.5	12.7	1,965.3	1.1	7.90	1	1	1
03/08/2015 20:00	1.4	13.0	1,853.8	1.0	7.40	1	1	1
03/08/2015 21:00	0.8	14.0	1,310.9	0.7	3.90	1	1	0
03/08/2015 22:00	0.8	14.0	1,288.3	0.7	3.90	1	1	0
03/08/2015 23:00	0.8	14.0	1,288.2	0.7	3.90	1	1	0
Average/Sum#:	1.9	14.4	1,239.3	1.9	125.86 #	19 #	15 #	3 #
Minimum:	0.0	12.7	0.2	0.0	0.00	0	0	0
Maximum:	11.6	21.0	1,965.3	14.0	34.50	1	1	1
%SI	20.8	20.8	20.8	20.8	20.83	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/09/2015 00:00	0.8	14.0	1,287.1	0.7	3.90	1	1	0
03/09/2015 01:00	0.8	14.0	1,285.9	0.7	3.90	1	1	0
03/09/2015 02:00	0.8	14.0	1,286.2	0.7	3.90	1	1	0
03/09/2015 03:00	0.8	14.0	1,285.0	0.7	3.90	1	1	0
03/09/2015 04:00	0.9	13.9	1,400.9	0.8	4.20	1	1	1
03/09/2015 05:00	1.4	12.9	1,995.2	1.0	8.00	1	1	1
03/09/2015 06:00	1.5	12.7	2,053.3	1.1	8.20	1	1	1
03/09/2015 07:00	1.3	13.0	1,970.0	1.0	7.90	1	1	1
03/09/2015 08:00	1.3	13.2	1,953.3	1.0	7.80	1	1	1
03/09/2015 09:00	0.8	13.9	1,331.1	0.7	2.70	1	1	1
03/09/2015 10:00	0.8	14.0	1,285.7	0.7	3.90	1	1	0
03/09/2015 11:00	0.8	14.0	1,285.7	0.7	3.90	1	1	0
03/09/2015 12:00	0.8	14.0	1,286.7	0.7	3.90	1	1	0
03/09/2015 13:00	0.8	14.0	1,293.4	0.7	3.90	1	1	0
03/09/2015 14:00	1.0	13.6	1,619.5	0.8	4.90	1	1	1
03/09/2015 15:00	0.8	14.0	1,285.8	0.7	3.90	1	1	0
03/09/2015 16:00	0.8	14.0	1,285.4	0.7	3.90	1	1	0
03/09/2015 17:00	1.1	13.2	1,727.0	0.8	5.20	1	1	1
03/09/2015 18:00	1.4	12.4	2,041.8	1.0	8.20	1	1	1
03/09/2015 19:00	1.4	12.5	2,041.9	1.0	8.20	1	1	1
03/09/2015 20:00	1.4	12.6	2,017.9	1.0	8.10	1	1	1
03/09/2015 21:00	1.3	12.9	1,958.2	1.0	7.80	1	1	1
03/09/2015 22:00	1.3	12.8	1,989.9	0.9	6.00	1	1	1
03/09/2015 23:00	1.3	13.0	1,946.8	1.0	7.80	1	1	1
Average/Sum#:	1.1	13.4	1,621.4	0.8	134.00 #	24 #	24 #	14 #
Minimum:	0.8	12.4	1,285.0	0.7	2.70	1	1	0
Maximum:	1.5	14.0	2,053.3	1.1	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/10/2015 00:00	1.3	13.1	1,926.2	1.0	7.70	1	1	1
03/10/2015 01:00	1.4	12.9	1,967.5	1.0	7.90	1	1	1
03/10/2015 02:00	1.4	13.2	1,914.9	1.1	7.70	1	1	1
03/10/2015 03:00	1.4	13.1	1,922.9	1.1	7.70	1	1	1
03/10/2015 04:00	1.4	13.1	1,954.1	1.1	7.80	1	1	1
03/10/2015 05:00	1.4	12.9	2,013.8	1.0	8.10	1	1	1
03/10/2015 06:00	1.4	12.8	2,046.4	1.0	8.20	1	1	1
03/10/2015 07:00	1.4	12.8	2,004.7	1.0	8.00	1	1	1
03/10/2015 08:00	1.2	13.4	1,800.6	0.9	5.40	1	1	1
03/10/2015 09:00	0.8	13.9	1,414.1	0.7	2.80	1	1	0
03/10/2015 10:00	0.7	13.9	1,288.2	0.6	2.60	1	1	0
03/10/2015 11:00	0.8	14.0	1,288.1	0.7	3.90	1	1	0
03/10/2015 12:00	0.8	14.0	1,288.5	0.7	3.90	1	1	0
03/10/2015 13:00	0.8	14.0	1,288.9	0.7	3.90	1	1	0
03/10/2015 14:00	0.8	14.0	1,289.3	0.7	3.90	1	1	0
03/10/2015 15:00	0.8	14.0	1,288.7	0.7	3.90	1	1	0
03/10/2015 16:00	0.9	13.9	1,398.9	0.8	4.20	1	1	1
03/10/2015 17:00	1.4	12.5	2,023.3	1.0	8.10	1	1	1
03/10/2015 18:00	1.5	12.5	2,033.7	1.1	8.10	1	1	1
03/10/2015 19:00	1.5	12.5	2,038.7	1.1	8.20	1	1	1
03/10/2015 20:00	1.5	12.5	2,035.7	1.1	8.10	1	1	1
03/10/2015 21:00	1.5	12.7	1,989.8	1.1	8.00	1	1	1
03/10/2015 22:00	1.1	13.4	1,671.8	0.9	5.00	1	1	1
03/10/2015 23:00	0.7	13.9	1,287.5	0.6	2.60	1	1	0
Average/Sum#:	1.2	13.3	1,715.7	0.9	145.70 #	24 #	24 #	16 #
Minimum:	0.7	12.5	1,287.5	0.6	2.60	1	1	0
Maximum:	1.5	14.0	2,046.4	1.1	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/11/2015 00:00	0.7	13.9	1,287.4	0.6	2.60	1	1	0
03/11/2015 01:00	0.7	13.9	1,288.6	0.6	2.60	1	1	0
03/11/2015 02:00	0.7	13.9	1,288.6	0.6	2.60	1	1	0
03/11/2015 03:00	0.8	14.0	1,288.3	0.7	3.90	1	1	0
03/11/2015 04:00	0.9	13.8	1,404.7	0.7	4.20	1	1	1
03/11/2015 05:00	1.3	13.2	1,936.8	1.0	7.70	1	1	1
03/11/2015 06:00	1.4	13.0	1,979.6	1.0	7.90	1	1	1
03/11/2015 07:00	1.3	12.7	2,047.5	0.9	6.10	1	1	1
03/11/2015 08:00	1.4	12.7	2,049.3	1.0	8.20	1	1	1
03/11/2015 09:00	1.4	12.7	2,044.5	1.0	8.20	1	1	1
03/11/2015 10:00	1.4	12.6	2,042.8	1.0	8.20	1	1	1
03/11/2015 11:00	1.3	12.6	2,044.1	0.9	6.10	1	1	1
03/11/2015 12:00	1.3	12.6	2,038.5	0.9	6.10	1	1	1
03/11/2015 13:00	1.3	12.6	2,044.8	0.9	6.10	1	1	1
03/11/2015 14:00	1.3	12.6	2,041.6	0.9	6.10	1	1	1
03/11/2015 15:00	1.3	12.6	2,043.3	0.9	6.10	1	1	1
03/11/2015 16:00	1.3	12.6	2,042.8	0.9	6.10	1	1	1
03/11/2015 17:00	1.2	13.0	1,961.1	0.9	5.90	1	1	1
03/11/2015 18:00	1.3	12.6	2,042.0	0.9	6.10	1	1	1
03/11/2015 19:00	1.3	12.7	2,050.1	0.9	6.20	1	1	1
03/11/2015 20:00	1.2	12.9	2,004.1	0.9	6.00	1	1	1
03/11/2015 21:00	1.0	13.5	1,619.4	0.8	4.90	1	1	1
03/11/2015 22:00	0.7	13.9	1,292.9	0.6	2.60	1	1	0
03/11/2015 23:00	0.7	13.9	1,297.1	0.6	2.60	1	1	0
Average/Sum#:	1.1	13.1	1,799.2	0.8	133.10 #	24 #	24 #	18 #
Minimum:	0.7	12.6	1,287.4	0.6	2.60	1	1	0
Maximum:	1.4	14.0	2,050.1	1.0	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/12/2015 00:00	0.7	13.9	1,300.4	0.6	2.60	1	1	0
03/12/2015 01:00	0.7	13.9	1,305.1	0.6	2.60	1	1	0
03/12/2015 02:00	0.7	13.9	1,307.5	0.6	2.60	1	1	0
03/12/2015 03:00	0.7	13.9	1,307.7	0.6	2.60	1	1	0
03/12/2015 04:00	0.8	13.8	1,425.3	0.7	2.90	1	1	1
03/12/2015 05:00	1.3	13.2	1,945.8	1.0	7.80	1	1	1
03/12/2015 06:00	1.4	12.7	2,033.2	1.0	8.10	1	1	1
03/12/2015 07:00	1.4	12.7	2,032.8	1.0	8.10	1	1	1
03/12/2015 08:00	1.3	12.9	1,980.2	1.0	7.90	1	1	1
03/12/2015 09:00	1.3	13.1	1,945.5	1.0	7.80	1	1	1
03/12/2015 10:00	1.3	13.2	1,923.9	1.0	7.70	1	1	1
03/12/2015 11:00	0.8	13.9	1,352.3	0.7	2.70	1	1	0
03/12/2015 12:00	0.8	14.0	1,293.5	0.7	3.90	1	1	0
03/12/2015 13:00	0.8	14.0	1,293.0	0.7	3.90	1	1	0
03/12/2015 14:00	0.8	14.0	1,292.6	0.7	3.90	1	1	0
03/12/2015 15:00	0.8	14.0	1,291.0	0.7	3.90	1	1	0
03/12/2015 16:00	1.0	13.7	1,538.0	0.8	4.60	1	1	1
03/12/2015 17:00	1.3	12.6	2,023.8	0.9	6.10	1	1	1
03/12/2015 18:00	1.4	12.6	2,041.0	1.0	8.20	1	1	1
03/12/2015 19:00	1.4	12.6	2,043.0	1.0	8.20	1	1	1
03/12/2015 20:00	1.4	12.6	2,041.8	1.0	8.20	1	1	1
03/12/2015 21:00	1.4	12.6	2,036.5	1.0	8.10	1	1	1
03/12/2015 22:00	1.2	13.2	1,782.1	0.9	5.30	1	1	1
03/12/2015 23:00	0.8	14.0	1,381.1	0.7	4.10	1	1	0
Average/Sum#:	1.1	13.4	1,663.2	0.8	131.80 #	24 #	24 #	14 #
Minimum:	0.7	12.6	1,291.0	0.6	2.60	1	1	0
Maximum:	1.4	14.0	2,043.0	1.0	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/13/2015 00:00	0.8	14.0	1,382.0	0.7	4.10	1	1	0
03/13/2015 01:00	0.8	13.9	1,415.4	0.7	2.80	1	1	0
03/13/2015 02:00	0.9	13.9	1,538.8	0.8	4.60	1	1	0
03/13/2015 03:00	0.8	13.9	1,411.2	0.7	2.80	1	1	0
03/13/2015 04:00	1.0	13.7	1,555.4	0.8	4.70	1	1	1
03/13/2015 05:00	1.3	13.0	1,976.0	1.0	7.90	1	1	1
03/13/2015 06:00	1.3	12.9	2,001.0	1.0	8.00	1	1	1
03/13/2015 07:00	1.3	13.3	1,913.7	1.0	7.70	1	1	1
03/13/2015 08:00	1.3	13.2	1,916.6	1.0	7.70	1	1	1
03/13/2015 09:00	1.3	13.2	1,918.8	1.0	7.70	1	1	1
03/13/2015 10:00	1.1	13.6	1,625.9	0.9	4.90	1	1	1
03/13/2015 11:00	0.8	14.0	1,292.1	0.7	3.90	1	1	0
03/13/2015 12:00	0.9	13.9	1,396.7	0.8	4.20	1	1	1
03/13/2015 13:00	1.3	12.8	1,972.5	0.9	5.90	1	1	1
03/13/2015 14:00	1.3	12.8	1,979.2	0.9	5.90	1	1	1
03/13/2015 15:00	1.4	12.5	2,028.3	1.0	8.10	1	1	1
03/13/2015 16:00	1.4	12.4	2,040.0	1.0	8.20	1	1	1
03/13/2015 17:00	1.4	12.4	2,043.3	1.0	8.20	1	1	1
03/13/2015 18:00	1.4	12.5	2,042.4	1.0	8.20	1	1	1
03/13/2015 19:00	1.4	12.5	2,032.0	1.0	8.10	1	1	1
03/13/2015 20:00	1.4	12.5	2,035.5	1.0	8.10	1	1	1
03/13/2015 21:00	1.4	12.6	2,008.1	1.0	8.00	1	1	1
03/13/2015 22:00	1.4	12.6	2,019.7	1.0	8.10	1	1	1
03/13/2015 23:00	1.4	12.5	2,028.4	1.0	8.10	1	1	1
Average/Sum#:	1.2	13.1	1,815.5	0.9	155.90 #	24 #	24 #	19 #
Minimum:	0.8	12.4	1,292.1	0.7	2.80	1	1	0
Maximum:	1.4	14.0	2,043.3	1.0	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/14/2015 00:00	1.3	12.8	1,980.0	0.9	5.90	1	1	1
03/14/2015 01:00	1.4	12.8	1,981.4	1.0	7.90	1	1	1
03/14/2015 02:00	1.3	12.9	1,966.4	1.0	7.90	1	1	1
03/14/2015 03:00	1.3	13.1	1,924.9	1.0	7.70	1	1	1
03/14/2015 04:00	1.3	13.1	1,919.6	1.0	7.70	1	1	1
03/14/2015 05:00	1.3	13.1	1,924.7	1.0	7.70	1	1	1
03/14/2015 06:00	1.4	12.6	2,028.5	1.0	8.10	1	1	1
03/14/2015 07:00	1.3	12.7	1,998.1	0.9	6.00	1	1	1
03/14/2015 08:00	1.3	12.9	1,954.2	1.0	7.80	1	1	1
03/14/2015 09:00	1.3	13.0	1,950.0	1.0	7.80	1	1	1
03/14/2015 10:00	1.3	12.9	1,952.3	1.0	7.80	1	1	1
03/14/2015 11:00	1.3	12.9	1,971.4	1.0	7.90	1	1	1
03/14/2015 12:00	1.4	12.5	2,049.8	1.0	8.20	1	1	1
03/14/2015 13:00	1.4	12.4	2,052.3	1.0	8.20	1	1	1
03/14/2015 14:00	1.4	12.4	2,048.6	1.0	8.20	1	1	1
03/14/2015 15:00	1.4	12.5	2,013.9	1.0	8.10	1	1	1
03/14/2015 16:00	1.4	12.3	2,049.9	1.0	8.20	1	1	1
03/14/2015 17:00	1.4	12.4	2,049.7	1.0	8.20	1	1	1
03/14/2015 18:00	1.4	12.4	2,046.9	1.0	8.20	1	1	1
03/14/2015 19:00	1.4	12.4	2,045.6	1.0	8.20	1	1	1
03/14/2015 20:00	1.4	12.4	2,044.4	1.0	8.20	1	1	1
03/14/2015 21:00	1.4	12.4	2,044.5	1.0	8.20	1	1	1
03/14/2015 22:00	1.4	12.5	2,042.1	1.0	8.20	1	1	1
03/14/2015 23:00	1.3	12.6	2,006.8	0.9	6.00	1	1	1
Average/Sum#:	1.4	12.7	2,001.9	1.0	186.30 #	24 #	24 #	24 #
Minimum:	1.3	12.3	1,919.6	0.9	5.90	1	1	1
Maximum:	1.4	13.1	2,052.3	1.0	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/15/2015 00:00	1.3	12.9	1,950.1	1.0	7.80	1	1	1
03/15/2015 01:00	1.3	12.7	1,990.5	0.9	6.00	1	1	1
03/15/2015 02:00	1.2	13.2	1,813.2	0.9	5.40	1	1	1
03/15/2015 03:00	1.0	13.8	1,769.1	0.8	5.30	1	1	0
03/15/2015 04:00	1.1	13.7	1,782.6	0.9	5.30	1	1	0
03/15/2015 05:00	1.0	13.8	1,753.2	0.8	5.30	1	1	0
03/15/2015 06:00	1.1	13.7	1,784.0	0.9	5.40	1	1	0
03/15/2015 07:00	1.1	13.7	1,556.0	0.9	4.70	1	1	0
03/15/2015 08:00	0.7	13.9	1,296.8	0.6	2.60	1	1	0
03/15/2015 09:00	0.8	14.0	1,297.7	0.7	3.90	1	1	0
03/15/2015 10:00	0.9	14.0	1,299.0	0.8	3.90	1	1	0
03/15/2015 11:00	1.0	13.9	1,570.7	0.8	4.70	1	1	0
03/15/2015 12:00	1.1	13.9	1,761.6	0.9	5.30	1	1	0
03/15/2015 13:00	1.3	13.0	1,920.1	1.0	7.70	1	1	1
03/15/2015 14:00	1.4	12.6	2,046.5	1.0	8.20	1	1	1
03/15/2015 15:00	1.4	12.6	2,031.2	1.0	8.10	1	1	1
03/15/2015 16:00	1.4	12.6	2,036.6	1.0	8.10	1	1	1
03/15/2015 17:00	1.4	12.6	2,034.2	1.0	8.10	1	1	1
03/15/2015 18:00	1.4	12.6	2,033.7	1.0	8.10	1	1	1
03/15/2015 19:00	1.4	12.6	2,035.7	1.0	8.10	1	1	1
03/15/2015 20:00	1.3	12.6	2,034.5	0.9	6.10	1	1	1
03/15/2015 21:00	1.4	12.6	2,027.0	1.0	8.10	1	1	1
03/15/2015 22:00	1.2	13.1	1,846.4	0.9	5.50	1	1	1
03/15/2015 23:00	0.7	13.9	1,294.0	0.6	2.60	1	1	0
Average/Sum#:	1.2	13.3	1,790.2	0.9	144.30 #	24 #	24 #	13 #
Minimum:	0.7	12.6	1,294.0	0.6	2.60	1	1	0
Maximum:	1.4	14.0	2,046.5	1.0	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/16/2015 00:00	0.7	14.0	1,291.5	0.6	2.60	1	1	0
03/16/2015 01:00	0.8	13.9	1,288.4	0.7	2.60	1	1	0
03/16/2015 02:00	0.8	13.9	1,291.1	0.7	2.60	1	1	0
03/16/2015 03:00	0.8	14.0	1,294.6	0.7	3.90	1	1	0
03/16/2015 04:00	1.0	13.6	1,552.3	0.8	4.70	1	1	1
03/16/2015 05:00	1.3	12.8	1,993.5	0.9	6.00	1	1	1
03/16/2015 06:00	1.4	12.6	2,034.4	1.0	8.10	1	1	1
03/16/2015 07:00	1.3	12.7	1,997.9	0.9	6.00	1	1	1
03/16/2015 08:00	1.3	12.6	2,033.2	0.9	6.10	1	1	1
03/16/2015 09:00	1.3	12.7	2,030.7	0.9	6.10	1	1	1
03/16/2015 10:00	1.3	12.7	2,016.3	0.9	6.00	1	1	1
03/16/2015 11:00	1.4	12.6	2,033.2	1.0	8.10	1	1	1
03/16/2015 12:00	1.3	12.6	2,031.5	0.9	6.10	1	1	1
03/16/2015 13:00	1.3	12.6	2,033.0	0.9	6.10	1	1	1
03/16/2015 14:00	1.4	12.6	2,032.2	1.0	8.10	1	1	1
03/16/2015 15:00	1.3	12.6	2,022.6	0.9	6.10	1	1	1
03/16/2015 16:00	1.3	12.8	1,978.8	0.9	5.90	1	1	1
03/16/2015 17:00	1.3	12.9	1,950.4	1.0	7.80	1	1	1
03/16/2015 18:00	1.3	12.7	2,010.4	0.9	6.00	1	1	1
03/16/2015 19:00	1.3	12.6	2,047.3	0.9	6.10	1	1	1
03/16/2015 20:00	1.3	12.8	2,011.6	0.9	6.00	1	1	1
03/16/2015 21:00	1.3	13.0	1,977.0	1.0	7.90	1	1	1
03/16/2015 22:00	0.9	13.8	1,459.4	0.7	4.40	1	1	1
03/16/2015 23:00	0.7	13.9	1,290.7	0.6	2.60	1	1	0
Average/Sum#:	1.2	13.0	1,820.9	0.9	135.90 #	24 #	24 #	19 #
Minimum:	0.7	12.6	1,288.4	0.6	2.60	1	1	0
Maximum:	1.4	14.0	2,047.3	1.0	8.10	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/17/2015 00:00	0.7	13.9	1,289.0	0.6	2.60	1	1	0
03/17/2015 01:00	0.8	13.9	1,289.8	0.7	2.60	1	1	0
03/17/2015 02:00	0.8	13.9	1,289.7	0.7	2.60	1	1	0
03/17/2015 03:00	0.8	13.9	1,290.5	0.7	2.60	1	1	0
03/17/2015 04:00	0.8	13.9	1,290.1	0.7	2.60	1	1	0
03/17/2015 05:00	0.8	13.9	1,290.3	0.7	2.60	1	1	0
03/17/2015 06:00	0.8	13.9	1,290.3	0.7	2.60	1	1	0
03/17/2015 07:00	0.8	13.9	1,289.1	0.7	2.60	1	1	0
03/17/2015 08:00	0.8	13.9	1,290.7	0.7	2.60	1	1	0
03/17/2015 09:00	0.8	13.9	1,292.8	0.7	2.60	1	1	0
03/17/2015 10:00	0.0	0.0	1,295.3	0.0	0.00	1	1	0
03/17/2015 11:00	0.7	15.0	1,294.8	0.7	2.85	1	0	0
03/17/2015 12:00	0.5	16.6	1,296.9	0.7	3.90	1	0	0
03/17/2015 13:00	0.4	17.4	1,298.4	0.7	2.60	1	1	0
03/17/2015 14:00	0.4	17.5	1,299.0	0.7	3.90	1	1	0
03/17/2015 15:00	0.4	17.6	1,297.7	0.7	3.90	1	1	0
03/17/2015 16:00	0.3	18.0	1,295.9	0.6	2.60	1	1	0
03/17/2015 17:00	0.3	18.2	1,296.3	0.7	2.60	1	1	0
03/17/2015 18:00	0.3	18.2	1,295.9	0.7	2.60	1	1	0
03/17/2015 19:00	0.3	18.3	1,294.0	0.7	3.90	1	1	0
03/17/2015 20:00	0.3	18.3	1,292.2	0.7	3.90	1	1	0
03/17/2015 21:00	0.3	18.3	1,292.2	0.7	3.90	1	1	0
03/17/2015 22:00	0.7	15.3	1,290.6	0.7	3.90	1	1	0
03/17/2015 23:00	0.8	14.3	1,286.6	0.7	3.90	1	1	0
Average/Sum#:	0.6	15.7	1,292.8	0.7	70.45 #	24 #	22 #	0 #
Minimum:	0.3	13.9	1,286.6	0.6	2.60	1	0	0
Maximum:	0.8	18.3	1,299.0	0.7	3.90	1	1	0
%SI	4.2	4.2	0.0	4.2	4.17	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/18/2015 00:00	0.8	14.2	1,285.9	0.7	3.90	1	1	0
03/18/2015 01:00	0.8	14.2	1,290.6	0.7	3.90	1	1	0
03/18/2015 02:00	0.8	14.2	1,301.4	0.7	3.90	1	1	0
03/18/2015 03:00	0.8	14.2	1,303.6	0.7	3.90	1	1	0
03/18/2015 04:00	0.8	14.2	1,304.1	0.7	3.90	1	1	0
03/18/2015 05:00	0.8	14.2	1,302.8	0.7	3.90	1	1	0
03/18/2015 06:00	0.8	14.2	1,302.1	0.7	3.90	1	1	0
03/18/2015 07:00	0.8	14.2	1,300.7	0.7	3.90	1	1	0
03/18/2015 08:00	0.8	14.2	1,300.5	0.7	3.90	1	1	0
03/18/2015 09:00	0.8	14.2	1,300.4	0.7	3.90	1	1	0
03/18/2015 10:00	0.8	14.2	1,301.2	0.7	3.90	1	1	0
03/18/2015 11:00	0.8	14.2	1,299.5	0.7	3.90	1	1	0
03/18/2015 12:00	0.8	14.2	1,296.2	0.7	3.90	1	1	0
03/18/2015 13:00	0.8	14.2	1,296.0	0.7	3.90	1	1	0
03/18/2015 14:00	0.9	14.2	1,312.2	0.8	3.90	1	1	0
03/18/2015 15:00	1.1	14.1	1,652.2	1.0	6.60	1	1	0
03/18/2015 16:00	1.1	14.1	1,677.7	1.0	6.70	1	1	0
03/18/2015 17:00	0.8	14.2	1,282.0	0.7	3.80	1	1	0
03/18/2015 18:00	0.9	14.2	1,283.9	0.8	3.90	1	1	0
03/18/2015 19:00	0.9	14.2	1,282.4	0.8	3.80	1	1	0
03/18/2015 20:00	0.9	14.2	1,286.6	0.8	3.90	1	1	0
03/18/2015 21:00	0.9	14.2	1,286.6	0.8	3.90	1	1	0
03/18/2015 22:00	0.9	14.1	1,283.2	0.8	3.80	1	1	0
03/18/2015 23:00	0.9	14.1	1,282.7	0.8	3.80	1	1	0
Average/Sum#:	0.9	14.2	1,325.6	0.8	98.70 #	24 #	24 #	0 #
Minimum:	0.8	14.1	1,282.0	0.7	3.80	1	1	0
Maximum:	1.1	14.2	1,677.7	1.0	6.70	1	1	0
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/19/2015 00:00	0.9	14.1	1,282.9	0.8	3.80	1	1	0
03/19/2015 01:00	0.8	14.1	1,281.1	0.7	3.80	1	1	0
03/19/2015 02:00	0.8	14.1	1,281.4	0.7	3.80	1	1	0
03/19/2015 03:00	0.8	14.1	1,283.3	0.7	3.80	1	1	0
03/19/2015 04:00	0.9	14.1	1,285.5	0.8	3.90	1	1	0
03/19/2015 05:00	0.8	14.0	1,292.6	0.7	3.90	1	1	0
03/19/2015 06:00	0.9	13.9	1,409.9	0.8	4.20	1	1	1
03/19/2015 07:00	1.2	12.9	1,995.0	0.9	6.00	1	1	1
03/19/2015 08:00	0.0	0.0	1,953.0	0.0	0.00	1	1	1
03/19/2015 09:00	0.0	0.0	1,942.5	0.0	0.00	1	1	1
03/19/2015 10:00	0.0	0.0	1,947.4	0.0	0.00	1	1	1
03/19/2015 11:00	0.0	0.0	1,976.3	0.0	0.00	1	1	1
03/19/2015 12:00	1.4	12.6	2,039.6	1.0	8.20	1	1	1
03/19/2015 13:00	1.3	12.9	1,981.1	1.0	7.90	1	1	1
03/19/2015 14:00	0.8	14.0	1,564.1	0.7	4.70	1	1	1
03/19/2015 15:00	0.8	14.0	1,320.8	0.7	4.00	1	1	0
03/19/2015 16:00	0.9	13.9	1,390.8	0.8	4.20	1	1	1
03/19/2015 17:00	1.3	13.0	1,930.3	1.0	7.70	1	1	1
03/19/2015 18:00	1.3	12.8	1,972.5	0.9	5.90	1	1	1
03/19/2015 19:00	1.4	12.5	2,038.9	1.0	8.20	1	1	1
03/19/2015 20:00	1.3	13.0	1,929.7	1.0	7.70	1	1	1
03/19/2015 21:00	1.1	13.3	1,743.0	0.9	5.20	1	1	1
03/19/2015 22:00	0.8	13.9	1,465.4	0.7	2.90	1	1	0
03/19/2015 23:00	0.7	13.9	1,307.0	0.6	2.60	1	1	0
Average/Sum#:	1.0	13.6	1,650.6	0.8	102.40 #	24 #	24 #	15 #
Minimum:	0.7	12.5	1,281.1	0.6	2.60	1	1	0
Maximum:	1.4	14.1	2,039.6	1.0	8.20	1	1	1
%SI	16.7	16.7	0.0	16.7	16.67	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/20/2015 00:00	0.9	13.9	1,451.1	0.8	4.40	1	1	0
03/20/2015 01:00	0.8	13.9	1,299.2	0.7	2.60	1	1	0
03/20/2015 02:00	1.1	13.8	1,675.1	0.9	5.00	1	1	0
03/20/2015 03:00	0.7	13.9	1,330.0	0.6	2.70	1	1	0
03/20/2015 04:00	1.0	13.4	1,687.7	0.8	5.10	1	1	1
03/20/2015 05:00	1.3	12.9	2,009.9	1.0	8.00	1	1	1
03/20/2015 06:00	1.4	12.7	2,034.0	1.0	8.10	1	1	1
03/20/2015 07:00	1.3	13.0	1,974.4	1.0	7.90	1	1	1
03/20/2015 08:00	1.3	13.0	1,929.4	1.0	7.70	1	1	1
03/20/2015 09:00	1.2	13.7	1,831.5	1.0	7.30	1	1	0
03/20/2015 10:00	1.2	13.7	1,828.5	1.0	7.30	1	1	0
03/20/2015 11:00	1.2	13.5	1,834.0	1.0	7.30	1	1	1
03/20/2015 12:00	1.3	12.9	1,988.6	1.0	8.00	1	1	1
03/20/2015 13:00	1.4	12.8	2,010.0	1.0	8.00	1	1	1
03/20/2015 14:00	1.3	12.9	1,978.9	1.0	7.90	1	1	1
03/20/2015 15:00	1.3	12.9	1,975.9	1.0	7.90	1	1	1
03/20/2015 16:00	1.3	13.0	1,945.4	1.0	7.80	1	1	1
03/20/2015 17:00	1.3	13.0	1,944.2	1.0	7.80	1	1	1
03/20/2015 18:00	1.3	13.0	1,950.5	1.0	7.80	1	1	1
03/20/2015 19:00	1.3	13.0	1,944.3	1.0	7.80	1	1	1
03/20/2015 20:00	1.3	13.0	1,945.8	1.0	7.80	1	1	1
03/20/2015 21:00	1.3	13.1	1,953.4	1.0	7.80	1	1	1
03/20/2015 22:00	1.1	13.5	1,733.9	0.9	5.20	1	1	1
03/20/2015 23:00	0.7	13.9	1,290.6	0.6	2.60	1	1	0
Average/Sum#:	1.2	13.3	1,814.4	0.9	159.80 #	24 #	24 #	17 #
Minimum:	0.7	12.7	1,290.6	0.6	2.60	1	1	0
Maximum:	1.4	13.9	2,034.0	1.0	8.10	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/21/2015 00:00	0.7	13.9	1,286.0	0.6	2.60	1	1	0
03/21/2015 01:00	0.9	13.9	1,530.0	0.8	4.60	1	1	0
03/21/2015 02:00	0.7	13.9	1,338.3	0.6	2.70	1	1	0
03/21/2015 03:00	1.0	13.8	1,566.9	0.8	4.70	1	1	0
03/21/2015 04:00	0.9	13.9	1,584.6	0.8	4.80	1	1	0
03/21/2015 05:00	0.9	13.7	1,499.0	0.7	4.50	1	1	1
03/21/2015 06:00	1.3	13.0	1,992.7	1.0	8.00	1	1	1
03/21/2015 07:00	1.2	13.3	1,801.1	0.9	5.40	1	1	1
03/21/2015 08:00	0.7	13.9	1,345.0	0.6	2.70	1	1	0
03/21/2015 09:00	0.8	13.9	1,307.2	0.7	2.60	1	1	0
03/21/2015 10:00	0.8	13.9	1,311.1	0.7	2.60	1	1	0
03/21/2015 11:00	0.8	13.9	1,312.9	0.7	2.60	1	1	0
03/21/2015 12:00	0.8	14.0	1,340.6	0.7	4.00	1	1	0
03/21/2015 13:00	0.8	14.0	1,310.0	0.7	3.90	1	1	0
03/21/2015 14:00	0.9	14.0	1,403.2	0.8	4.20	1	1	0
03/21/2015 15:00	0.9	13.9	1,489.2	0.8	4.50	1	1	0
03/21/2015 16:00	1.0	13.9	1,641.6	0.8	4.90	1	1	0
03/21/2015 17:00	1.2	13.2	1,806.3	0.9	5.40	1	1	1
03/21/2015 18:00	1.3	12.7	1,989.9	0.9	6.00	1	1	1
03/21/2015 19:00	1.4	12.7	1,996.9	1.0	8.00	1	1	1
03/21/2015 20:00	1.4	12.6	2,016.1	1.0	8.10	1	1	1
03/21/2015 21:00	1.3	12.8	1,996.3	0.9	6.00	1	1	1
03/21/2015 22:00	1.1	13.4	1,787.5	0.9	5.40	1	1	1
03/21/2015 23:00	1.0	13.8	1,758.3	0.8	5.30	1	1	0
Average/Sum#:	1.0	13.6	1,600.4	0.8	113.50 #	24 #	24 #	9 #
Minimum:	0.7	12.6	1,286.0	0.6	2.60	1	1	0
Maximum:	1.4	14.0	2,016.1	1.0	8.10	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/22/2015 00:00	1.1	13.7	1,798.3	0.9	5.40	1	1	0
03/22/2015 01:00	0.8	13.9	1,610.8	0.7	3.20	1	1	0
03/22/2015 02:00	0.9	13.8	1,654.1	0.7	5.00	1	1	0
03/22/2015 03:00	1.0	13.9	1,765.1	0.8	5.30	1	1	0
03/22/2015 04:00	0.9	13.9	1,523.6	0.8	4.60	1	1	0
03/22/2015 05:00	0.9	13.8	1,592.0	0.7	4.80	1	1	0
03/22/2015 06:00	1.0	13.8	1,634.2	0.8	4.90	1	1	0
03/22/2015 07:00	0.9	13.7	1,672.3	0.7	5.00	1	1	1
03/22/2015 08:00	1.4	12.6	2,040.5	1.0	8.20	1	1	1
03/22/2015 09:00	1.5	12.6	2,017.3	1.1	8.10	1	1	1
03/22/2015 10:00	1.4	12.9	1,952.7	1.0	7.80	1	1	1
03/22/2015 11:00	1.4	12.9	1,960.7	1.0	7.80	1	1	1
03/22/2015 12:00	1.3	12.9	1,973.2	1.0	7.90	1	1	1
03/22/2015 13:00	1.1	13.5	1,697.4	0.9	5.10	1	1	1
03/22/2015 14:00	1.0	13.9	1,609.8	0.8	4.80	1	1	0
03/22/2015 15:00	0.9	13.9	1,614.0	0.8	4.80	1	1	0
03/22/2015 16:00	0.9	13.9	1,567.0	0.8	4.70	1	1	0
03/22/2015 17:00	1.1	13.4	1,713.6	0.9	5.10	1	1	1
03/22/2015 18:00	1.3	12.8	1,992.7	0.9	6.00	1	1	1
03/22/2015 19:00	1.3	12.9	1,977.8	1.0	7.90	1	1	1
03/22/2015 20:00	1.3	13.0	1,960.9	1.0	7.80	1	1	1
03/22/2015 21:00	0.9	13.7	1,470.8	0.7	4.40	1	1	1
03/22/2015 22:00	0.7	13.9	1,304.5	0.6	2.60	1	1	0
03/22/2015 23:00	1.5	14.4	1,119.6	1.4	4.87	1	0	0
Average/Sum#:	1.1	13.5	1,717.6	0.9	136.07 #	24 #	23 #	12 #
Minimum:	0.7	12.6	1,119.6	0.6	2.60	1	0	0
Maximum:	1.5	14.4	2,040.5	1.4	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/23/2015 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/24/2015 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/25/2015 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/26/2015 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2015 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2015 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2015 03:00	26.0	17.5	470.3	45.1	42.96	1	0	0
03/26/2015 04:00	11.2	16.7	594.4	15.7	34.50	1	0	0
03/26/2015 05:00	4.1	16.0	758.2	4.9	13.60	1	0	0
03/26/2015 06:00	0.3	13.9	1,375.5	0.3	1.40	1	1	0
03/26/2015 07:00	0.5	13.9	1,375.7	0.4	2.80	1	1	0
03/26/2015 08:00	0.5	13.9	1,381.9	0.4	2.80	1	1	0
03/26/2015 09:00	0.5	14.0	1,381.1	0.4	2.80	1	1	0
03/26/2015 10:00	0.5	14.0	1,383.7	0.4	2.80	1	1	0
03/26/2015 11:00	0.5	14.0	1,382.6	0.4	2.80	1	1	0
03/26/2015 12:00	0.5	14.0	1,385.0	0.4	2.80	1	1	0
03/26/2015 13:00	0.8	13.8	1,658.7	0.7	3.30	1	1	0
03/26/2015 14:00	0.5	13.9	1,396.3	0.4	2.80	1	1	0
03/26/2015 15:00	0.6	14.0	1,403.5	0.5	2.80	1	1	0
03/26/2015 16:00	0.8	13.8	1,679.7	0.7	3.40	1	1	0
03/26/2015 17:00	0.9	13.7	1,772.2	0.7	5.30	1	1	0
03/26/2015 18:00	0.9	13.7	1,778.2	0.7	5.30	1	1	0
03/26/2015 19:00	0.9	13.7	1,781.5	0.7	5.30	1	1	0
03/26/2015 20:00	0.9	13.7	1,785.4	0.7	5.40	1	1	0
03/26/2015 21:00	0.5	13.9	1,361.7	0.4	2.70	1	1	0
03/26/2015 22:00	3.5	16.6	334.2	4.8	1.02	1	0	0
03/26/2015 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	2.7	14.4	1,322.0	3.9	146.58 #	20 #	16 #	0 #
Minimum:	0.3	13.7	334.2	0.3	1.02	0	0	0
Maximum:	26.0	17.5	1,785.4	45.1	42.96	1	1	0
%SI	16.7	16.7	16.7	16.7	16.67	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/27/2015 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2015 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2015 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2015 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2015 04:00	0.2	19.5	170.5	0.8	0.04	1	0	0
03/27/2015 05:00	20.4	15.8	806.7	23.6	70.20	1	0	0
03/27/2015 06:00	0.4	13.9	1,385.0	0.3	1.40	1	1	0
03/27/2015 07:00	0.5	13.9	1,379.3	0.4	2.80	1	1	0
03/27/2015 08:00	0.5	14.0	1,376.2	0.4	2.80	1	1	0
03/27/2015 09:00	0.5	14.0	1,376.0	0.4	2.80	1	1	0
03/27/2015 10:00	0.5	14.0	1,377.8	0.4	2.80	1	1	0
03/27/2015 11:00	0.5	14.0	1,383.3	0.4	2.80	1	1	0
03/27/2015 12:00	0.5	14.0	1,383.1	0.4	2.80	1	1	0
03/27/2015 13:00	0.5	14.0	1,380.2	0.4	2.80	1	1	0
03/27/2015 14:00	0.5	14.0	1,379.3	0.4	2.80	1	1	0
03/27/2015 15:00	0.5	14.0	1,378.5	0.4	2.80	1	1	0
03/27/2015 16:00	0.6	14.0	1,381.3	0.5	2.80	1	1	0
03/27/2015 17:00	0.8	13.9	1,566.7	0.7	3.10	1	1	0
03/27/2015 18:00	0.6	14.0	1,393.8	0.5	2.80	1	1	0
03/27/2015 19:00	0.6	14.0	1,373.3	0.5	2.70	1	1	0
03/27/2015 20:00	1.6	14.6	1,113.2	1.5	4.49	1	0	0
03/27/2015 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2015 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2015 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.7	14.4	1,270.8	1.9	112.73 #	17 #	14 #	0 #
Minimum:	0.2	13.9	170.5	0.3	0.04	0	0	0
Maximum:	20.4	19.5	1,566.7	23.6	70.20	1	1	0
%SI	29.2	29.2	29.2	29.2	29.17	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/28/2015 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/29/2015 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/30/2015 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2015 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2015 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2015 03:00	27.7	17.5	476.6	48.1	46.42	1	0	0
03/30/2015 04:00	18.0	15.7	715.5	20.4	53.70	1	0	0
03/30/2015 05:00	8.5	14.7	1,086.2	8.1	32.60	1	0	0
03/30/2015 06:00	0.4	14.0	1,380.6	0.3	1.40	1	1	0
03/30/2015 07:00	0.5	14.0	1,386.9	0.4	2.80	1	1	0
03/30/2015 08:00	0.5	14.0	1,384.8	0.4	2.80	1	1	0
03/30/2015 09:00	0.5	14.0	1,386.0	0.4	2.80	1	1	0
03/30/2015 10:00	0.5	14.0	1,378.1	0.4	2.80	1	1	0
03/30/2015 11:00	0.5	14.0	1,376.0	0.4	2.80	1	1	0
03/30/2015 12:00	0.6	13.9	1,510.8	0.5	3.00	1	1	0
03/30/2015 13:00	0.5	14.0	1,531.3	0.4	3.10	1	1	0
03/30/2015 14:00	0.5	13.9	1,513.1	0.4	3.00	1	1	0
03/30/2015 15:00	0.5	14.0	1,351.2	0.4	2.70	1	1	0
03/30/2015 16:00	0.4	14.0	1,334.9	0.3	1.30	1	1	0
03/30/2015 17:00	0.5	13.9	1,473.4	0.4	2.90	1	1	0
03/30/2015 18:00	0.7	13.8	1,692.8	0.6	3.40	1	1	0
03/30/2015 19:00	0.7	13.9	1,609.6	0.6	3.20	1	1	0
03/30/2015 20:00	2.1	14.9	974.0	2.1	3.51	1	0	0
03/30/2015 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2015 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2015 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	3.5	14.3	1,309.0	4.7	174.23 #	18 #	14 #	0 #
Minimum:	0.4	13.8	476.6	0.3	1.30	0	0	0
Maximum:	27.7	17.5	1,692.8	48.1	53.70	1	1	0
%SI	25.0	25.0	25.0	25.0	25.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/31/2015 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2015 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2015 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2015 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2015 04:00	27.6	17.2	519.8	44.0	53.05	1	0	0
03/31/2015 05:00	4.7	14.2	1,246.4	4.1	18.70	1	0	0
03/31/2015 06:00	0.4	13.9	1,379.2	0.3	1.40	1	1	0
03/31/2015 07:00	0.5	13.9	1,382.0	0.4	2.80	1	1	0
03/31/2015 08:00	0.5	13.9	1,384.5	0.4	2.80	1	1	0
03/31/2015 09:00	0.5	14.0	1,381.1	0.4	2.80	1	1	0
03/31/2015 10:00	0.5	14.0	1,377.2	0.4	2.80	1	1	0
03/31/2015 11:00	0.5	14.0	1,372.5	0.4	2.70	1	1	0
03/31/2015 12:00	0.5	14.0	1,377.5	0.4	2.80	1	1	0
03/31/2015 13:00	0.5	14.0	1,375.2	0.4	2.80	1	1	0
03/31/2015 14:00	0.6	14.0	1,383.2	0.5	2.80	1	1	0
03/31/2015 15:00	0.5	14.0	1,379.8	0.4	2.80	1	1	0
03/31/2015 16:00	0.6	14.0	1,522.7	0.5	3.00	1	1	0
03/31/2015 17:00	0.6	14.0	1,508.6	0.5	3.00	1	1	0
03/31/2015 18:00	0.6	14.0	1,595.8	0.5	3.20	1	1	0
03/31/2015 19:00	0.7	14.0	1,771.1	0.6	3.50	1	1	0
03/31/2015 20:00	0.7	13.9	1,619.3	0.6	3.20	1	1	0
03/31/2015 21:00	2.2	14.8	1,048.4	2.1	3.78	1	0	0
03/31/2015 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2015 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	2.4	14.2	1,368.0	3.2	117.93 #	18 #	15 #	0 #
Minimum:	0.4	13.9	519.8	0.3	1.40	0	0	0
Maximum:	27.6	17.2	1,771.1	44.0	53.05	1	1	0
%SI	25.0	25.0	25.0	25.0	25.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/01/2015 00:00	1.5	11.9	2,249.1	1.0	9.00	1	1	1
01/01/2015 01:00	1.5	11.7	2,288.5	1.0	9.20	1	1	1
01/01/2015 02:00	1.5	11.7	2,277.8	1.0	9.10	1	1	1
01/01/2015 03:00	1.5	11.7	2,269.6	1.0	9.10	1	1	1
01/01/2015 04:00	1.5	12.0	2,227.2	1.0	8.90	1	1	1
01/01/2015 05:00	1.5	12.1	2,212.8	1.0	8.90	1	1	1
01/01/2015 06:00	1.5	11.7	2,296.2	1.0	9.20	1	1	1
01/01/2015 07:00	1.5	11.8	2,269.9	1.0	9.10	1	1	1
01/01/2015 08:00	1.2	13.1	1,942.5	0.9	5.80	1	1	1
01/01/2015 09:00	1.1	13.4	1,836.7	0.9	5.50	1	1	1
01/01/2015 10:00	0.8	13.8	1,449.7	0.7	2.90	1	1	1
01/01/2015 11:00	0.6	13.9	1,269.6	0.5	2.50	1	1	0
01/01/2015 12:00	0.6	13.9	1,272.4	0.5	2.50	1	1	0
01/01/2015 13:00	0.6	13.9	1,268.6	0.5	2.50	1	1	0
01/01/2015 14:00	0.6	13.9	1,266.0	0.5	2.50	1	1	0
01/01/2015 15:00	0.9	13.6	1,599.7	0.7	4.80	1	1	1
01/01/2015 16:00	1.1	13.3	1,913.4	0.9	5.70	1	1	1
01/01/2015 17:00	1.3	13.1	1,981.6	1.0	7.90	1	1	1
01/01/2015 18:00	1.4	12.6	2,091.4	1.0	8.40	1	1	1
01/01/2015 19:00	1.5	11.7	2,285.5	1.0	9.10	1	1	1
01/01/2015 20:00	1.5	11.7	2,290.4	1.0	9.20	1	1	1
01/01/2015 21:00	1.5	11.8	2,271.5	1.0	9.10	1	1	1
01/01/2015 22:00	1.5	11.9	2,267.4	1.0	9.10	1	1	1
01/01/2015 23:00	1.3	13.0	2,024.7	1.0	8.10	1	1	1
Average/Sum#:	1.2	12.6	1,963.4	0.9	168.10 #	24 #	24 #	20 #
Minimum:	0.6	11.7	1,266.0	0.5	2.50	1	1	0
Maximum:	1.5	13.9	2,296.2	1.0	9.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/02/2015 00:00	1.3	13.1	2,002.3	1.0	8.00	1	1	1
01/02/2015 01:00	1.4	12.7	2,069.6	1.0	8.30	1	1	1
01/02/2015 02:00	1.1	13.3	1,873.1	0.9	5.60	1	1	1
01/02/2015 03:00	1.3	13.0	2,037.6	1.0	8.20	1	1	1
01/02/2015 04:00	1.2	13.2	1,987.7	0.9	6.00	1	1	1
01/02/2015 05:00	1.3	13.0	2,017.2	1.0	8.10	1	1	1
01/02/2015 06:00	1.2	13.2	1,971.1	0.9	5.90	1	1	1
01/02/2015 07:00	1.1	13.3	1,967.7	0.9	5.90	1	1	1
01/02/2015 08:00	1.1	13.3	1,909.2	0.9	5.70	1	1	1
01/02/2015 09:00	1.1	13.3	1,841.9	0.9	5.50	1	1	1
01/02/2015 10:00	0.8	13.7	1,458.5	0.7	2.90	1	1	1
01/02/2015 11:00	0.7	13.8	1,307.8	0.6	2.60	1	1	0
01/02/2015 12:00	0.7	13.8	1,304.8	0.6	2.60	1	1	0
01/02/2015 13:00	0.7	13.9	1,310.1	0.6	2.60	1	1	0
01/02/2015 14:00	0.7	13.9	1,304.5	0.6	2.60	1	1	0
01/02/2015 15:00	0.9	13.7	1,641.6	0.7	4.90	1	1	1
01/02/2015 16:00	1.1	13.3	1,900.3	0.9	5.70	1	1	1
01/02/2015 17:00	1.5	12.2	2,188.5	1.0	8.80	1	1	1
01/02/2015 18:00	1.5	11.6	2,299.0	1.0	9.20	1	1	1
01/02/2015 19:00	1.5	11.6	2,294.4	1.0	9.20	1	1	1
01/02/2015 20:00	1.5	11.6	2,295.6	1.0	9.20	1	1	1
01/02/2015 21:00	1.5	11.6	2,296.1	1.0	9.20	1	1	1
01/02/2015 22:00	1.5	11.7	2,296.8	1.0	9.20	1	1	1
01/02/2015 23:00	1.5	12.1	2,219.1	1.0	8.90	1	1	1
Average/Sum#:	1.2	12.9	1,908.1	0.9	154.80 #	24 #	24 #	20 #
Minimum:	0.7	11.6	1,304.5	0.6	2.60	1	1	0
Maximum:	1.5	13.9	2,299.0	1.0	9.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/03/2015 00:00	1.4	12.4	2,158.1	1.0	8.60	1	1	1
01/03/2015 01:00	1.5	12.0	2,246.0	1.0	9.00	1	1	1
01/03/2015 02:00	1.4	12.4	2,149.4	1.0	8.60	1	1	1
01/03/2015 03:00	1.4	12.0	2,246.3	0.9	6.70	1	1	1
01/03/2015 04:00	1.3	12.7	2,092.2	0.9	6.30	1	1	1
01/03/2015 05:00	1.2	12.9	2,042.2	0.9	6.10	1	1	1
01/03/2015 06:00	1.4	12.4	2,164.0	1.0	8.70	1	1	1
01/03/2015 07:00	1.2	12.3	2,110.4	0.8	6.30	1	1	1
01/03/2015 08:00	1.0	13.3	1,896.5	0.8	5.70	1	1	1
01/03/2015 09:00	1.0	13.3	1,843.8	0.8	5.50	1	1	1
01/03/2015 10:00	1.0	13.3	1,845.3	0.8	5.50	1	1	1
01/03/2015 11:00	1.0	13.3	1,850.6	0.8	5.60	1	1	1
01/03/2015 12:00	0.7	13.8	1,356.1	0.6	2.70	1	1	0
01/03/2015 13:00	0.6	13.8	1,304.3	0.5	2.60	1	1	0
01/03/2015 14:00	0.6	13.9	1,301.7	0.5	2.60	1	1	0
01/03/2015 15:00	0.9	13.6	1,654.7	0.7	5.00	1	1	1
01/03/2015 16:00	1.2	13.0	1,983.0	0.9	5.90	1	1	1
01/03/2015 17:00	1.4	12.3	2,178.3	1.0	8.70	1	1	1
01/03/2015 18:00	1.5	11.7	2,298.7	1.0	9.20	1	1	1
01/03/2015 19:00	1.4	11.7	2,283.4	0.9	6.90	1	1	1
01/03/2015 20:00	1.5	11.7	2,284.4	1.0	9.10	1	1	1
01/03/2015 21:00	1.5	11.7	2,293.5	1.0	9.20	1	1	1
01/03/2015 22:00	1.4	12.0	2,235.7	0.9	6.70	1	1	1
01/03/2015 23:00	1.4	12.1	2,216.2	0.9	6.60	1	1	1
Average/Sum#:	1.2	12.7	2,001.5	0.9	157.80 #	24 #	24 #	21 #
Minimum:	0.6	11.7	1,301.7	0.5	2.60	1	1	0
Maximum:	1.5	13.9	2,298.7	1.0	9.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/04/2015 00:00	1.4	12.2	2,218.4	0.9	6.70	1	1	1
01/04/2015 01:00	1.2	13.1	1,998.5	0.9	6.00	1	1	1
01/04/2015 02:00	1.1	13.2	1,983.0	0.8	5.90	1	1	1
01/04/2015 03:00	1.1	13.2	1,981.0	0.8	5.90	1	1	1
01/04/2015 04:00	1.1	13.2	1,962.4	0.8	5.90	1	1	1
01/04/2015 05:00	1.0	13.2	1,967.9	0.8	5.90	1	1	1
01/04/2015 06:00	1.3	12.6	2,119.3	0.9	6.40	1	1	1
01/04/2015 07:00	1.4	11.9	2,245.7	0.9	6.70	1	1	1
01/04/2015 08:00	1.1	13.2	1,946.0	0.8	5.80	1	1	1
01/04/2015 09:00	1.0	13.3	1,908.8	0.8	5.70	1	1	1
01/04/2015 10:00	1.0	13.3	1,893.1	0.8	5.70	1	1	1
01/04/2015 11:00	0.9	13.3	1,858.2	0.7	5.60	1	1	1
01/04/2015 12:00	0.9	13.3	1,849.9	0.7	5.50	1	1	1
01/04/2015 13:00	1.0	13.3	1,875.9	0.8	5.60	1	1	1
01/04/2015 14:00	1.3	13.1	1,989.3	1.0	8.00	1	1	1
01/04/2015 15:00	1.2	13.0	2,004.9	0.9	6.00	1	1	1
01/04/2015 16:00	1.2	12.9	2,010.1	0.9	6.00	1	1	1
01/04/2015 17:00	1.4	11.9	2,239.2	0.9	6.70	1	1	1
01/04/2015 18:00	1.4	11.6	2,308.2	0.9	6.90	1	1	1
01/04/2015 19:00	1.5	11.6	2,314.7	1.0	9.30	1	1	1
01/04/2015 20:00	1.5	11.6	2,314.8	1.0	9.30	1	1	1
01/04/2015 21:00	1.4	11.8	2,257.8	0.9	6.80	1	1	1
01/04/2015 22:00	1.4	11.9	2,239.4	0.9	6.70	1	1	1
01/04/2015 23:00	1.0	13.2	1,897.5	0.8	5.70	1	1	1
Average/Sum#:	1.2	12.7	2,057.7	0.9	154.70 #	24 #	24 #	24 #
Minimum:	0.9	11.6	1,849.9	0.7	5.50	1	1	1
Maximum:	1.5	13.3	2,314.8	1.0	9.30	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/05/2015 00:00	0.9	13.3	1,853.4	0.7	5.60	1	1	1
01/05/2015 01:00	1.0	13.3	1,941.2	0.8	5.80	1	1	1
01/05/2015 02:00	1.0	13.3	1,860.9	0.8	5.60	1	1	1
01/05/2015 03:00	1.1	13.2	1,969.6	0.8	5.90	1	1	1
01/05/2015 04:00	1.0	13.3	1,903.3	0.8	5.70	1	1	1
01/05/2015 05:00	1.0	13.3	1,922.6	0.8	5.80	1	1	1
01/05/2015 06:00	1.2	13.0	2,033.0	0.9	6.10	1	1	1
01/05/2015 07:00	1.4	11.9	2,283.7	0.9	6.90	1	1	1
01/05/2015 08:00	1.4	11.9	2,263.0	0.9	6.80	1	1	1
01/05/2015 09:00	1.0	13.2	1,918.7	0.8	5.80	1	1	1
01/05/2015 10:00	0.9	13.3	1,850.8	0.7	5.60	1	1	1
01/05/2015 11:00	0.9	13.3	1,849.2	0.7	5.50	1	1	1
01/05/2015 12:00	0.9	13.3	1,852.4	0.7	5.60	1	1	1
01/05/2015 13:00	0.9	13.4	1,867.2	0.7	5.60	1	1	1
01/05/2015 14:00	1.2	12.9	1,987.1	0.9	6.00	1	1	1
01/05/2015 15:00	1.2	13.0	1,966.7	0.9	5.90	1	1	1
01/05/2015 16:00	1.2	12.9	1,987.0	0.9	6.00	1	1	1
01/05/2015 17:00	1.4	11.8	2,233.2	0.9	6.70	1	1	1
01/05/2015 18:00	1.5	11.5	2,312.9	0.9	6.90	1	1	1
01/05/2015 19:00	1.5	11.4	2,317.9	0.9	7.00	1	1	1
01/05/2015 20:00	1.5	11.5	2,316.3	0.9	6.90	1	1	1
01/05/2015 21:00	1.4	12.1	2,184.4	0.9	6.60	1	1	1
01/05/2015 22:00	1.2	12.9	2,021.9	0.9	6.10	1	1	1
01/05/2015 23:00	0.9	13.4	1,709.9	0.7	5.10	1	1	1
Average/Sum#:	1.2	12.8	2,016.9	0.8	145.50 #	24 #	24 #	24 #
Minimum:	0.9	11.4	1,709.9	0.7	5.10	1	1	1
Maximum:	1.5	13.4	2,317.9	0.9	7.00	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/06/2015 00:00	0.7	13.8	1,436.9	0.6	2.90	1	1	0
01/06/2015 01:00	0.8	13.8	1,653.6	0.7	3.30	1	1	0
01/06/2015 02:00	0.8	13.6	1,715.2	0.6	3.40	1	1	1
01/06/2015 03:00	0.9	13.3	1,859.9	0.7	5.60	1	1	1
01/06/2015 04:00	1.0	13.3	1,859.3	0.8	5.60	1	1	1
01/06/2015 05:00	1.0	13.3	1,919.1	0.8	5.80	1	1	1
01/06/2015 06:00	1.2	12.8	2,049.0	0.9	6.10	1	1	1
01/06/2015 07:00	1.4	11.7	2,286.5	0.9	6.90	1	1	1
01/06/2015 08:00	1.2	12.5	2,085.4	0.8	6.30	1	1	1
01/06/2015 09:00	0.9	13.3	1,848.1	0.7	5.50	1	1	1
01/06/2015 10:00	0.8	13.6	1,549.8	0.6	3.10	1	1	1
01/06/2015 11:00	0.6	13.8	1,301.1	0.5	2.60	1	1	0
01/06/2015 12:00	0.6	13.9	1,301.4	0.5	2.60	1	1	0
01/06/2015 13:00	0.7	13.9	1,445.5	0.6	2.90	1	1	0
01/06/2015 14:00	0.6	13.9	1,304.6	0.5	2.60	1	1	0
01/06/2015 15:00	0.9	13.6	1,635.8	0.7	4.90	1	1	1
01/06/2015 16:00	1.0	13.1	1,931.0	0.8	5.80	1	1	1
01/06/2015 17:00	1.2	12.7	2,026.1	0.9	6.10	1	1	1
01/06/2015 18:00	1.3	12.5	2,061.5	0.9	6.20	1	1	1
01/06/2015 19:00	1.4	12.5	2,089.3	1.0	8.40	1	1	1
01/06/2015 20:00	1.3	12.2	2,136.3	0.9	6.40	1	1	1
01/06/2015 21:00	1.3	12.3	2,131.0	0.9	6.40	1	1	1
01/06/2015 22:00	1.3	12.5	2,072.2	0.9	6.20	1	1	1
01/06/2015 23:00	0.9	13.3	1,874.4	0.7	5.60	1	1	1
Average/Sum#:	1.0	13.1	1,815.5	0.7	121.20 #	24 #	24 #	18 #
Minimum:	0.6	11.7	1,301.1	0.5	2.60	1	1	0
Maximum:	1.4	13.9	2,286.5	1.0	8.40	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/07/2015 00:00	1.0	13.2	1,915.2	0.8	5.70	1	1	1
01/07/2015 01:00	0.9	13.3	1,868.2	0.7	5.60	1	1	1
01/07/2015 02:00	0.9	13.3	1,891.9	0.7	5.70	1	1	1
01/07/2015 03:00	0.9	13.3	1,859.0	0.7	5.60	1	1	1
01/07/2015 04:00	1.1	13.1	1,953.2	0.8	5.90	1	1	1
01/07/2015 05:00	1.0	13.2	1,903.0	0.8	5.70	1	1	1
01/07/2015 06:00	1.2	12.8	2,072.7	0.9	6.20	1	1	1
01/07/2015 07:00	1.5	12.0	2,242.6	1.0	9.00	1	1	1
01/07/2015 08:00	1.1	12.8	2,015.4	0.8	6.00	1	1	1
01/07/2015 09:00	1.0	13.3	1,891.2	0.8	5.70	1	1	1
01/07/2015 10:00	0.9	13.4	1,852.0	0.7	5.60	1	1	1
01/07/2015 11:00	0.9	13.4	1,837.5	0.7	5.50	1	1	1
01/07/2015 12:00	0.6	13.9	1,307.2	0.5	2.60	1	1	0
01/07/2015 13:00	0.7	13.8	1,493.8	0.6	3.00	1	1	0
01/07/2015 14:00	0.8	13.9	1,559.2	0.7	3.10	1	1	1
01/07/2015 15:00	1.2	12.8	1,992.1	0.9	6.00	1	1	1
01/07/2015 16:00	1.2	12.9	1,973.7	0.9	5.90	1	1	1
01/07/2015 17:00	1.4	11.9	2,181.5	0.9	6.50	1	1	1
01/07/2015 18:00	1.3	12.6	2,054.2	0.9	6.20	1	1	1
01/07/2015 19:00	1.2	12.8	2,015.1	0.9	6.00	1	1	1
01/07/2015 20:00	1.3	12.7	2,017.2	0.9	6.10	1	1	1
01/07/2015 21:00	1.3	12.7	2,024.6	0.9	6.10	1	1	1
01/07/2015 22:00	1.1	13.1	1,926.2	0.8	5.80	1	1	1
01/07/2015 23:00	0.9	13.4	1,853.9	0.7	5.60	1	1	1
Average/Sum#:	1.1	13.1	1,904.2	0.8	135.10 #	24 #	24 #	22 #
Minimum:	0.6	11.9	1,307.2	0.5	2.60	1	1	0
Maximum:	1.5	13.9	2,242.6	1.0	9.00	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/08/2015 00:00	0.9	13.4	1,847.6	0.7	5.50	1	1	1
01/08/2015 01:00	0.9	13.4	1,849.2	0.7	5.50	1	1	1
01/08/2015 02:00	0.9	13.4	1,847.0	0.7	5.50	1	1	1
01/08/2015 03:00	0.9	13.4	1,849.8	0.7	5.50	1	1	1
01/08/2015 04:00	0.9	13.3	1,846.5	0.7	5.50	1	1	1
01/08/2015 05:00	0.9	13.3	1,851.9	0.7	5.60	1	1	1
01/08/2015 06:00	1.2	12.7	2,075.8	0.9	6.20	1	1	1
01/08/2015 07:00	1.5	11.6	2,294.9	1.0	9.20	1	1	1
01/08/2015 08:00	1.5	11.7	2,266.0	1.0	9.10	1	1	1
01/08/2015 09:00	1.4	12.1	2,179.1	0.9	6.50	1	1	1
01/08/2015 10:00	1.2	12.6	2,060.4	0.9	6.20	1	1	1
01/08/2015 11:00	1.2	12.9	1,982.2	0.9	5.90	1	1	1
01/08/2015 12:00	1.2	12.8	2,014.7	0.9	6.00	1	1	1
01/08/2015 13:00	1.3	12.4	2,089.5	0.9	6.30	1	1	1
01/08/2015 14:00	1.3	12.5	2,081.3	0.9	6.20	1	1	1
01/08/2015 15:00	1.5	11.5	2,269.6	0.9	6.80	1	1	1
01/08/2015 16:00	1.2	12.6	2,021.7	0.9	6.10	1	1	1
01/08/2015 17:00	1.3	12.5	2,052.3	0.9	6.20	1	1	1
01/08/2015 18:00	1.3	12.5	2,057.4	0.9	6.20	1	1	1
01/08/2015 19:00	1.2	12.8	2,002.1	0.9	6.00	1	1	1
01/08/2015 20:00	1.2	12.7	2,016.5	0.9	6.00	1	1	1
01/08/2015 21:00	1.3	12.3	2,103.7	0.9	6.30	1	1	1
01/08/2015 22:00	1.3	12.7	2,016.7	0.9	6.10	1	1	1
01/08/2015 23:00	1.0	13.1	1,908.7	0.8	5.70	1	1	1
Average/Sum#:	1.2	12.7	2,024.4	0.9	150.10 #	24 #	24 #	24 #
Minimum:	0.9	11.5	1,846.5	0.7	5.50	1	1	1
Maximum:	1.5	13.4	2,294.9	1.0	9.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/09/2015 00:00	1.1	13.1	1,941.5	0.8	5.80	1	1	1
01/09/2015 01:00	1.0	13.3	1,889.2	0.8	5.70	1	1	1
01/09/2015 02:00	0.9	13.3	1,852.4	0.7	5.60	1	1	1
01/09/2015 03:00	1.1	13.2	1,916.3	0.8	5.70	1	1	1
01/09/2015 04:00	0.9	13.4	1,858.6	0.7	5.60	1	1	1
01/09/2015 05:00	1.0	13.3	1,900.8	0.8	5.70	1	1	1
01/09/2015 06:00	1.0	13.1	1,945.7	0.8	5.80	1	1	1
01/09/2015 07:00	1.3	12.4	2,144.4	0.9	6.40	1	1	1
01/09/2015 08:00	1.5	11.6	2,282.1	1.0	9.10	1	1	1
01/09/2015 09:00	1.2	12.6	2,050.6	0.9	6.20	1	1	1
01/09/2015 10:00	1.4	11.9	2,217.9	0.9	6.70	1	1	1
01/09/2015 11:00	1.4	11.7	2,236.5	0.9	6.70	1	1	1
01/09/2015 12:00	1.0	13.3	1,889.8	0.8	5.70	1	1	1
01/09/2015 13:00	0.8	13.5	1,693.1	0.6	3.40	1	1	1
01/09/2015 14:00	0.6	13.9	1,388.3	0.5	2.80	1	1	0
01/09/2015 15:00	0.6	13.9	1,374.8	0.5	2.70	1	1	0
01/09/2015 16:00	0.9	13.4	1,692.6	0.7	5.10	1	1	1
01/09/2015 17:00	0.9	13.3	1,881.0	0.7	5.60	1	1	1
01/09/2015 18:00	1.0	13.3	1,794.7	0.8	5.40	1	1	1
01/09/2015 19:00	1.0	13.4	1,802.3	0.8	5.40	1	1	1
01/09/2015 20:00	1.0	13.4	1,872.3	0.8	5.60	1	1	1
01/09/2015 21:00	1.0	13.4	1,879.5	0.8	5.60	1	1	1
01/09/2015 22:00	1.1	13.2	1,918.2	0.8	5.80	1	1	1
01/09/2015 23:00	1.2	13.0	1,968.5	0.9	5.90	1	1	1
Average/Sum#:	1.0	13.1	1,891.3	0.8	134.00 #	24 #	24 #	22 #
Minimum:	0.6	11.6	1,374.8	0.5	2.70	1	1	0
Maximum:	1.5	13.9	2,282.1	1.0	9.10	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/10/2015 00:00	1.0	13.4	1,871.5	0.8	5.60	1	1	1
01/10/2015 01:00	0.9	13.5	1,845.4	0.7	5.50	1	1	1
01/10/2015 02:00	0.9	13.6	1,705.9	0.7	5.10	1	1	1
01/10/2015 03:00	0.6	13.9	1,360.4	0.5	2.70	1	1	0
01/10/2015 04:00	0.8	13.6	1,625.7	0.6	3.30	1	1	1
01/10/2015 05:00	1.0	13.3	1,899.5	0.8	5.70	1	1	1
01/10/2015 06:00	1.2	13.1	1,942.2	0.9	5.80	1	1	1
01/10/2015 07:00	1.2	13.1	1,956.5	0.9	5.90	1	1	1
01/10/2015 08:00	1.0	13.3	1,876.0	0.8	5.60	1	1	1
01/10/2015 09:00	0.9	13.3	1,856.3	0.7	5.60	1	1	1
01/10/2015 10:00	1.1	13.1	1,964.4	0.8	5.90	1	1	1
01/10/2015 11:00	1.4	11.9	2,216.0	0.9	6.60	1	1	1
01/10/2015 12:00	1.4	12.0	2,169.9	0.9	6.50	1	1	1
01/10/2015 13:00	1.1	13.1	1,939.5	0.8	5.80	1	1	1
01/10/2015 14:00	1.2	12.8	1,999.8	0.9	6.00	1	1	1
01/10/2015 15:00	0.9	13.4	1,863.8	0.7	5.60	1	1	1
01/10/2015 16:00	1.0	13.2	1,899.6	0.8	5.70	1	1	1
01/10/2015 17:00	1.3	12.6	2,055.6	0.9	6.20	1	1	1
01/10/2015 18:00	1.2	12.9	1,985.0	0.9	6.00	1	1	1
01/10/2015 19:00	1.3	12.6	2,057.1	0.9	6.20	1	1	1
01/10/2015 20:00	1.5	11.6	2,267.6	1.0	9.10	1	1	1
01/10/2015 21:00	1.3	12.3	2,106.3	0.9	6.30	1	1	1
01/10/2015 22:00	1.2	12.7	2,026.5	0.9	6.10	1	1	1
01/10/2015 23:00	1.0	13.2	1,906.6	0.8	5.70	1	1	1
Average/Sum#:	1.1	13.0	1,933.2	0.8	138.50 #	24 #	24 #	23 #
Minimum:	0.6	11.6	1,360.4	0.5	2.70	1	1	0
Maximum:	1.5	13.9	2,267.6	1.0	9.10	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/11/2015 00:00	1.0	13.2	1,911.0	0.8	5.70	1	1	1
01/11/2015 01:00	1.0	13.2	1,915.6	0.8	5.70	1	1	1
01/11/2015 02:00	1.1	13.2	1,925.5	0.8	5.80	1	1	1
01/11/2015 03:00	0.9	13.4	1,855.6	0.7	5.60	1	1	1
01/11/2015 04:00	0.9	13.4	1,852.0	0.7	5.60	1	1	1
01/11/2015 05:00	1.0	13.3	1,889.3	0.8	5.70	1	1	1
01/11/2015 06:00	1.0	13.3	1,884.5	0.8	5.70	1	1	1
01/11/2015 07:00	1.0	13.2	1,927.2	0.8	5.80	1	1	1
01/11/2015 08:00	1.3	12.5	2,100.2	0.9	6.30	1	1	1
01/11/2015 09:00	1.4	11.7	2,268.5	0.9	6.80	1	1	1
01/11/2015 10:00	1.5	11.7	2,254.0	1.0	9.00	1	1	1
01/11/2015 11:00	1.4	12.1	2,168.1	0.9	6.50	1	1	1
01/11/2015 12:00	1.2	12.9	1,985.3	0.9	6.00	1	1	1
01/11/2015 13:00	1.2	12.9	1,980.1	0.9	5.90	1	1	1
01/11/2015 14:00	1.0	13.2	1,914.8	0.8	5.70	1	1	1
01/11/2015 15:00	1.2	12.9	2,005.7	0.9	6.00	1	1	1
01/11/2015 16:00	1.0	13.3	1,903.9	0.8	5.70	1	1	1
01/11/2015 17:00	1.3	12.3	2,127.9	0.9	6.40	1	1	1
01/11/2015 18:00	1.3	12.3	2,130.6	0.9	6.40	1	1	1
01/11/2015 19:00	1.4	11.8	2,223.7	0.9	6.70	1	1	1
01/11/2015 20:00	1.4	12.3	2,117.4	1.0	8.50	1	1	1
01/11/2015 21:00	1.4	12.1	2,149.3	0.9	6.40	1	1	1
01/11/2015 22:00	1.1	13.0	1,946.8	0.8	5.80	1	1	1
01/11/2015 23:00	0.9	13.4	1,850.7	0.7	5.60	1	1	1
Average/Sum#:	1.2	12.8	2,012.0	0.8	149.30 #	24 #	24 #	24 #
Minimum:	0.9	11.7	1,850.7	0.7	5.60	1	1	1
Maximum:	1.5	13.4	2,268.5	1.0	9.00	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/12/2015 00:00	1.1	13.1	1,953.1	0.8	5.90	1	1	1
01/12/2015 01:00	1.0	13.3	1,886.0	0.8	5.70	1	1	1
01/12/2015 02:00	0.9	13.3	1,888.2	0.7	5.70	1	1	1
01/12/2015 03:00	1.1	13.2	1,940.7	0.8	5.80	1	1	1
01/12/2015 04:00	1.0	13.2	1,920.1	0.8	5.80	1	1	1
01/12/2015 05:00	1.0	13.2	1,912.7	0.8	5.70	1	1	1
01/12/2015 06:00	1.2	13.0	2,000.2	0.9	6.00	1	1	1
01/12/2015 07:00	1.2	13.0	1,981.3	0.9	5.90	1	1	1
01/12/2015 08:00	1.2	13.1	1,982.8	0.9	5.90	1	1	1
01/12/2015 09:00	1.3	12.5	2,097.7	0.9	6.30	1	1	1
01/12/2015 10:00	1.2	12.8	2,020.9	0.9	6.10	1	1	1
01/12/2015 11:00	0.9	13.3	1,862.6	0.7	5.60	1	1	1
01/12/2015 12:00	0.9	13.4	1,857.0	0.7	5.60	1	1	1
01/12/2015 13:00	0.9	13.4	1,859.2	0.7	5.60	1	1	1
01/12/2015 14:00	0.9	13.4	1,864.3	0.7	5.60	1	1	1
01/12/2015 15:00	0.9	13.4	1,867.7	0.7	5.60	1	1	1
01/12/2015 16:00	1.0	13.3	1,900.6	0.8	5.70	1	1	1
01/12/2015 17:00	1.2	12.9	1,982.6	0.9	5.90	1	1	1
01/12/2015 18:00	1.5	11.8	2,237.2	1.0	8.90	1	1	1
01/12/2015 19:00	1.5	11.5	2,283.9	0.9	6.90	1	1	1
01/12/2015 20:00	1.4	11.5	2,289.6	0.9	6.90	1	1	1
01/12/2015 21:00	1.4	11.9	2,204.2	0.9	6.60	1	1	1
01/12/2015 22:00	1.3	12.4	2,108.4	0.9	6.30	1	1	1
01/12/2015 23:00	1.1	13.1	1,927.1	0.8	5.80	1	1	1
Average/Sum#:	1.1	12.9	1,992.8	0.8	145.80 #	24 #	24 #	24 #
Minimum:	0.9	11.5	1,857.0	0.7	5.60	1	1	1
Maximum:	1.5	13.4	2,289.6	1.0	8.90	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/13/2015 00:00	1.3	12.8	2,016.7	0.9	6.10	1	1	1
01/13/2015 01:00	1.3	12.8	2,008.9	0.9	6.00	1	1	1
01/13/2015 02:00	1.3	12.9	2,001.1	1.0	8.00	1	1	1
01/13/2015 03:00	1.2	13.0	1,971.8	0.9	5.90	1	1	1
01/13/2015 04:00	1.2	13.2	1,929.0	0.9	5.80	1	1	1
01/13/2015 05:00	1.0	13.4	1,860.4	0.8	5.60	1	1	1
01/13/2015 06:00	1.1	13.2	1,916.4	0.8	5.70	1	1	1
01/13/2015 07:00	1.3	12.9	2,011.1	1.0	8.00	1	1	1
01/13/2015 08:00	1.2	13.2	1,934.7	0.9	5.80	1	1	1
01/13/2015 09:00	1.0	13.4	1,878.3	0.8	5.60	1	1	1
01/13/2015 10:00	1.3	12.9	2,002.5	1.0	8.00	1	1	1
01/13/2015 11:00	1.2	12.8	2,012.3	0.9	6.00	1	1	1
01/13/2015 12:00	1.1	13.1	1,936.1	0.8	5.80	1	1	1
01/13/2015 13:00	1.2	13.0	1,959.1	0.9	5.90	1	1	1
01/13/2015 14:00	1.1	13.1	1,929.7	0.8	5.80	1	1	1
01/13/2015 15:00	1.0	13.3	1,905.9	0.8	5.70	1	1	1
01/13/2015 16:00	1.1	13.3	1,907.8	0.9	5.70	1	1	1
01/13/2015 17:00	1.4	12.3	2,138.0	1.0	8.60	1	1	1
01/13/2015 18:00	1.4	11.6	2,281.6	0.9	6.80	1	1	1
01/13/2015 19:00	1.4	11.6	2,281.2	0.9	6.80	1	1	1
01/13/2015 20:00	1.4	11.6	2,277.2	0.9	6.80	1	1	1
01/13/2015 21:00	1.4	12.0	2,191.4	0.9	6.60	1	1	1
01/13/2015 22:00	1.3	12.3	2,109.5	0.9	6.30	1	1	1
01/13/2015 23:00	0.9	13.6	1,633.9	0.7	4.90	1	1	1
Average/Sum#:	1.2	12.8	2,003.9	0.9	152.20 #	24 #	24 #	24 #
Minimum:	0.9	11.6	1,633.9	0.7	4.90	1	1	1
Maximum:	1.4	13.6	2,281.6	1.0	8.60	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/14/2015 00:00	0.6	13.9	1,341.9	0.5	2.70	1	1	0
01/14/2015 01:00	0.8	13.8	1,577.7	0.7	3.20	1	1	0
01/14/2015 02:00	0.9	13.6	1,700.8	0.7	5.10	1	1	1
01/14/2015 03:00	1.1	13.2	1,925.6	0.8	5.80	1	1	1
01/14/2015 04:00	1.2	13.2	1,965.7	0.9	5.90	1	1	1
01/14/2015 05:00	1.0	13.3	1,872.9	0.8	5.60	1	1	1
01/14/2015 06:00	1.1	13.0	1,972.6	0.8	5.90	1	1	1
01/14/2015 07:00	1.5	12.0	2,240.7	1.0	9.00	1	1	1
01/14/2015 08:00	1.3	12.5	2,105.1	0.9	6.30	1	1	1
01/14/2015 09:00	1.2	13.1	1,965.4	0.9	5.90	1	1	1
01/14/2015 10:00	1.0	13.2	1,885.7	0.8	5.70	1	1	1
01/14/2015 11:00	0.9	13.3	1,852.0	0.7	5.60	1	1	1
01/14/2015 12:00	1.0	13.3	1,853.9	0.8	5.60	1	1	1
01/14/2015 13:00	1.0	13.3	1,861.5	0.8	5.60	1	1	1
01/14/2015 14:00	1.0	13.4	1,867.5	0.8	5.60	1	1	1
01/14/2015 15:00	1.1	13.4	1,878.6	0.9	5.60	1	1	1
01/14/2015 16:00	1.2	13.3	1,923.3	0.9	5.80	1	1	1
01/14/2015 17:00	1.6	12.5	2,109.9	1.1	8.40	1	1	1
01/14/2015 18:00	2.2	11.6	2,287.7	1.4	11.40	1	1	1
01/14/2015 19:00	2.1	11.7	2,287.9	1.3	11.40	1	1	1
01/14/2015 20:00	1.5	11.7	2,286.7	1.0	9.10	1	1	1
01/14/2015 21:00	1.6	11.8	2,273.1	1.0	9.10	1	1	1
01/14/2015 22:00	1.4	12.6	2,076.8	1.0	8.30	1	1	1
01/14/2015 23:00	1.2	13.4	1,878.2	0.9	5.60	1	1	1
Average/Sum#:	1.2	12.9	1,958.0	0.9	158.20 #	24 #	24 #	22 #
Minimum:	0.6	11.6	1,341.9	0.5	2.70	1	1	0
Maximum:	2.2	13.9	2,287.9	1.4	11.40	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/15/2015 00:00	1.2	13.3	1,903.4	0.9	5.70	1	1	1
01/15/2015 01:00	1.2	13.4	1,848.5	0.9	5.50	1	1	1
01/15/2015 02:00	1.2	13.4	1,846.5	0.9	5.50	1	1	1
01/15/2015 03:00	1.2	13.4	1,851.6	0.9	5.60	1	1	1
01/15/2015 04:00	1.2	13.4	1,859.6	0.9	5.60	1	1	1
01/15/2015 05:00	1.2	13.4	1,856.0	0.9	5.60	1	1	1
01/15/2015 06:00	1.3	13.1	1,984.5	1.0	7.90	1	1	1
01/15/2015 07:00	1.5	12.3	2,207.9	1.0	8.80	1	1	1
01/15/2015 08:00	1.3	13.0	1,979.3	1.0	7.90	1	1	1
01/15/2015 09:00	1.0	13.6	1,572.7	0.8	4.70	1	1	1
01/15/2015 10:00	0.8	13.9	1,302.2	0.7	2.60	1	1	0
01/15/2015 11:00	0.8	13.9	1,304.2	0.7	2.60	1	1	0
01/15/2015 12:00	0.9	13.9	1,304.0	0.8	3.90	1	1	0
01/15/2015 13:00	0.8	13.9	1,299.9	0.7	2.60	1	1	0
01/15/2015 14:00	0.9	13.9	1,299.7	0.8	3.90	1	1	0
01/15/2015 15:00	0.9	13.9	1,332.8	0.8	4.00	1	1	0
01/15/2015 16:00	1.2	13.4	1,880.8	0.9	5.60	1	1	1
01/15/2015 17:00	1.6	12.1	2,218.1	1.1	8.90	1	1	1
01/15/2015 18:00	1.2	13.2	1,881.3	0.9	5.60	1	1	1
01/15/2015 19:00	1.4	12.7	2,065.5	1.0	8.30	1	1	1
01/15/2015 20:00	1.5	12.6	2,066.1	1.1	8.30	1	1	1
01/15/2015 21:00	1.5	12.6	2,090.5	1.1	8.40	1	1	1
01/15/2015 22:00	1.5	12.3	2,133.8	1.0	8.50	1	1	1
01/15/2015 23:00	1.2	13.2	1,881.8	0.9	5.60	1	1	1
Average/Sum#:	1.2	13.2	1,790.4	0.9	141.60 #	24 #	24 #	18 #
Minimum:	0.8	12.1	1,299.7	0.7	2.60	1	1	0
Maximum:	1.6	13.9	2,218.1	1.1	8.90	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/16/2015 00:00	1.2	13.3	1,845.7	0.9	5.50	1	1	1
01/16/2015 01:00	1.2	13.3	1,848.6	0.9	5.50	1	1	1
01/16/2015 02:00	1.2	13.3	1,853.9	0.9	5.60	1	1	1
01/16/2015 03:00	1.0	13.6	1,622.1	0.8	4.90	1	1	1
01/16/2015 04:00	0.8	13.9	1,320.0	0.7	2.60	1	1	0
01/16/2015 05:00	1.1	13.4	1,834.2	0.9	5.50	1	1	1
01/16/2015 06:00	1.3	13.1	1,954.4	1.0	7.80	1	1	1
01/16/2015 07:00	1.6	12.1	2,204.3	1.1	8.80	1	1	1
01/16/2015 08:00	1.3	13.2	1,929.8	1.0	7.70	1	1	1
01/16/2015 09:00	1.2	13.5	1,853.0	1.0	7.40	1	1	1
01/16/2015 10:00	1.2	13.5	1,870.6	1.0	7.50	1	1	1
01/16/2015 11:00	1.2	13.4	1,888.8	0.9	5.70	1	1	1
01/16/2015 12:00	0.9	13.7	1,475.3	0.7	4.40	1	1	1
01/16/2015 13:00	0.7	13.9	1,284.5	0.6	2.60	1	1	0
01/16/2015 14:00	0.7	13.9	1,281.9	0.6	2.60	1	1	0
01/16/2015 15:00	0.7	13.9	1,282.9	0.6	2.60	1	1	0
01/16/2015 16:00	1.2	13.3	1,750.4	0.9	5.30	1	1	1
01/16/2015 17:00	1.4	12.9	1,903.4	1.0	7.60	1	1	1
01/16/2015 18:00	0.7	13.9	1,333.6	0.6	2.70	1	1	0
01/16/2015 19:00	0.7	13.9	1,294.3	0.6	2.60	1	1	0
01/16/2015 20:00	0.7	13.9	1,299.4	0.6	2.60	1	1	0
01/16/2015 21:00	0.7	13.9	1,317.3	0.6	2.60	1	1	0
01/16/2015 22:00	0.9	13.9	1,521.6	0.8	4.60	1	1	0
01/16/2015 23:00	0.8	13.9	1,306.3	0.7	2.60	1	1	0
Average/Sum#:	1.0	13.5	1,628.2	0.8	117.30 #	24 #	24 #	14 #
Minimum:	0.7	12.1	1,281.9	0.6	2.60	1	1	0
Maximum:	1.6	13.9	2,204.3	1.1	8.80	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/17/2015 00:00	0.8	13.9	1,326.5	0.7	2.70	1	1	0
01/17/2015 01:00	0.9	13.9	1,539.9	0.8	4.60	1	1	0
01/17/2015 02:00	0.9	13.9	1,429.4	0.8	4.30	1	1	0
01/17/2015 03:00	1.0	13.9	1,598.8	0.8	4.80	1	1	0
01/17/2015 04:00	0.8	13.9	1,318.4	0.7	2.60	1	1	0
01/17/2015 05:00	0.8	13.9	1,356.8	0.7	2.70	1	1	0
01/17/2015 06:00	1.1	13.8	1,821.6	0.9	5.50	1	1	1
01/17/2015 07:00	1.1	13.7	1,845.6	0.9	5.50	1	1	0
01/17/2015 08:00	1.0	13.8	1,816.3	0.8	5.40	1	1	1
01/17/2015 09:00	0.9	13.9	1,794.9	0.8	5.40	1	1	1
01/17/2015 10:00	1.0	13.6	1,819.4	0.8	5.50	1	1	1
01/17/2015 11:00	1.1	13.6	1,851.1	0.9	5.60	1	1	1
01/17/2015 12:00	1.1	13.6	1,856.8	0.9	5.60	1	1	1
01/17/2015 13:00	0.9	13.7	1,574.4	0.7	4.70	1	1	1
01/17/2015 14:00	0.8	13.9	1,302.1	0.7	2.60	1	1	0
01/17/2015 15:00	0.8	13.9	1,302.3	0.7	2.60	1	1	0
01/17/2015 16:00	0.9	13.7	1,631.7	0.7	4.90	1	1	1
01/17/2015 17:00	1.2	13.1	1,944.3	0.9	5.80	1	1	1
01/17/2015 18:00	1.6	12.0	2,197.9	1.1	8.80	1	1	1
01/17/2015 19:00	1.5	12.2	2,138.8	1.0	8.60	1	1	1
01/17/2015 20:00	1.4	12.9	2,006.3	1.0	8.00	1	1	1
01/17/2015 21:00	1.4	12.7	2,042.8	1.0	8.20	1	1	1
01/17/2015 22:00	1.4	12.8	2,036.5	1.0	8.10	1	1	1
01/17/2015 23:00	1.4	12.7	2,050.7	1.0	8.20	1	1	1
Average/Sum#:	1.1	13.5	1,733.5	0.8	130.70 #	24 #	24 #	15 #
Minimum:	0.8	12.0	1,302.1	0.7	2.60	1	1	0
Maximum:	1.6	13.9	2,197.9	1.1	8.80	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/18/2015 00:00	1.3	13.0	1,973.6	1.0	7.90	1	1	1
01/18/2015 01:00	1.1	13.4	1,781.2	0.9	5.30	1	1	1
01/18/2015 02:00	2.6	15.0	891.9	2.6	3.74	1	0	0
01/18/2015 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/18/2015 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/18/2015 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/18/2015 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/18/2015 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/18/2015 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/18/2015 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/18/2015 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/18/2015 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/18/2015 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/18/2015 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/18/2015 14:00	22.3	17.7	462.1	41.1	30.01	1	0	0
01/18/2015 15:00	16.6	15.7	787.3	18.8	54.30	1	0	0
01/18/2015 16:00	0.5	13.9	1,439.7	0.4	2.90	1	0	1
01/18/2015 17:00	1.1	13.3	1,908.4	0.9	5.70	1	1	1
01/18/2015 18:00	1.3	12.9	2,006.6	1.0	8.00	1	1	1
01/18/2015 19:00	1.3	13.0	2,002.9	1.0	8.00	1	1	1
01/18/2015 20:00	1.3	13.1	1,973.4	1.0	7.90	1	1	1
01/18/2015 21:00	1.1	13.4	1,910.9	0.9	5.70	1	1	1
01/18/2015 22:00	0.8	13.9	1,474.8	0.7	2.90	1	1	0
01/18/2015 23:00	0.7	13.9	1,303.8	0.6	2.60	1	1	0
Average/Sum#:	4.0	14.0	1,532.0	5.5	144.95 #	13 #	9 #	8 #
Minimum:	0.5	12.9	462.1	0.4	2.60	0	0	0
Maximum:	22.3	17.7	2,006.6	41.1	54.30	1	1	1
%SI	45.8	45.8	45.8	45.8	45.83	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/19/2015 00:00	0.8	13.9	1,510.2	0.7	3.00	1	1	0
01/19/2015 01:00	0.7	13.9	1,353.2	0.6	2.70	1	1	0
01/19/2015 02:00	0.7	13.9	1,305.2	0.6	2.60	1	1	0
01/19/2015 03:00	0.9	13.8	1,577.9	0.7	4.70	1	1	0
01/19/2015 04:00	1.1	13.3	1,894.6	0.9	5.70	1	1	1
01/19/2015 05:00	1.3	13.1	1,977.8	1.0	7.90	1	1	1
01/19/2015 06:00	1.4	13.1	1,986.1	1.1	7.90	1	1	1
01/19/2015 07:00	1.5	12.7	2,082.5	1.1	8.30	1	1	1
01/19/2015 08:00	1.2	13.3	1,928.6	0.9	5.80	1	1	1
01/19/2015 09:00	1.1	13.4	1,895.4	0.9	5.70	1	1	1
01/19/2015 10:00	1.2	13.3	1,928.8	0.9	5.80	1	1	1
01/19/2015 11:00	1.1	13.4	1,857.5	0.9	5.60	1	1	1
01/19/2015 12:00	1.1	13.4	1,868.9	0.9	5.60	1	1	1
01/19/2015 13:00	1.1	13.4	1,866.3	0.9	5.60	1	1	1
01/19/2015 14:00	1.1	13.4	1,870.6	0.9	5.60	1	1	1
01/19/2015 15:00	1.2	13.3	1,913.8	0.9	5.70	1	1	1
01/19/2015 16:00	1.4	13.1	1,961.9	1.1	7.80	1	1	1
01/19/2015 17:00	1.4	12.8	2,029.6	1.0	8.10	1	1	1
01/19/2015 18:00	1.5	12.4	2,104.2	1.0	8.40	1	1	1
01/19/2015 19:00	1.5	12.5	2,085.0	1.1	8.30	1	1	1
01/19/2015 20:00	1.5	12.7	2,048.2	1.1	8.20	1	1	1
01/19/2015 21:00	1.4	12.8	2,029.3	1.0	8.10	1	1	1
01/19/2015 22:00	1.2	13.2	1,922.5	0.9	5.80	1	1	1
01/19/2015 23:00	1.1	13.3	1,857.9	0.9	5.60	1	1	1
Average/Sum#:	1.2	13.2	1,869.0	0.9	148.50 #	24 #	24 #	20 #
Minimum:	0.7	12.4	1,305.2	0.6	2.60	1	1	0
Maximum:	1.5	13.9	2,104.2	1.1	8.40	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/20/2015 00:00	1.3	13.2	1,947.2	1.0	7.80	1	1	1
01/20/2015 01:00	1.1	13.3	1,850.9	0.9	5.60	1	1	1
01/20/2015 02:00	1.2	13.3	1,852.8	0.9	5.60	1	1	1
01/20/2015 03:00	1.2	13.3	1,854.0	0.9	5.60	1	1	1
01/20/2015 04:00	1.2	13.3	1,855.6	0.9	5.60	1	1	1
01/20/2015 05:00	1.2	13.3	1,854.3	0.9	5.60	1	1	1
01/20/2015 06:00	1.3	13.1	1,982.8	1.0	7.90	1	1	1
01/20/2015 07:00	1.4	13.0	2,013.5	1.0	8.10	1	1	1
01/20/2015 08:00	1.4	13.0	2,022.0	1.0	8.10	1	1	1
01/20/2015 09:00	1.4	13.0	2,018.2	1.0	8.10	1	1	1
01/20/2015 10:00	1.4	13.0	2,003.5	1.0	8.00	1	1	1
01/20/2015 11:00	1.4	12.9	2,018.4	1.0	8.10	1	1	1
01/20/2015 12:00	1.4	12.8	2,025.1	1.0	8.10	1	1	1
01/20/2015 13:00	1.4	12.9	2,003.4	1.0	8.00	1	1	1
01/20/2015 14:00	1.4	12.9	2,013.9	1.0	8.10	1	1	1
01/20/2015 15:00	1.4	12.8	2,032.1	1.0	8.10	1	1	1
01/20/2015 16:00	1.2	13.3	1,880.4	0.9	5.60	1	1	1
01/20/2015 17:00	1.2	13.2	1,909.7	0.9	5.70	1	1	1
01/20/2015 18:00	1.4	12.8	2,028.4	1.0	8.10	1	1	1
01/20/2015 19:00	1.4	12.8	2,040.7	1.0	8.20	1	1	1
01/20/2015 20:00	1.4	12.9	2,003.2	1.0	8.00	1	1	1
01/20/2015 21:00	1.4	12.9	2,023.2	1.0	8.10	1	1	1
01/20/2015 22:00	1.4	13.1	1,980.3	1.1	7.90	1	1	1
01/20/2015 23:00	1.1	13.5	1,852.4	0.9	5.60	1	1	1
Average/Sum#:	1.3	13.1	1,961.1	1.0	173.60 #	24 #	24 #	24 #
Minimum:	1.1	12.8	1,850.9	0.9	5.60	1	1	1
Maximum:	1.4	13.5	2,040.7	1.1	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/21/2015 00:00	1.1	13.6	1,873.4	0.9	5.60	1	1	1
01/21/2015 01:00	1.2	13.6	1,858.6	1.0	7.40	1	1	1
01/21/2015 02:00	1.2	13.5	1,891.8	1.0	7.60	1	1	1
01/21/2015 03:00	1.2	13.6	1,850.1	1.0	7.40	1	1	1
01/21/2015 04:00	1.2	13.5	1,863.1	1.0	7.50	1	1	1
01/21/2015 05:00	1.2	13.4	1,857.4	0.9	5.60	1	1	1
01/21/2015 06:00	1.3	13.3	1,940.4	1.0	7.80	1	1	1
01/21/2015 07:00	1.4	13.1	1,997.6	1.1	8.00	1	1	1
01/21/2015 08:00	1.4	12.9	2,042.0	1.0	8.20	1	1	1
01/21/2015 09:00	1.4	12.9	2,011.3	1.0	8.00	1	1	1
01/21/2015 10:00	1.3	13.2	1,940.3	1.0	7.80	1	1	1
01/21/2015 11:00	1.3	13.2	1,935.7	1.0	7.70	1	1	1
01/21/2015 12:00	1.3	13.3	1,916.2	1.0	7.70	1	1	1
01/21/2015 13:00	1.1	13.4	1,872.3	0.9	5.60	1	1	1
01/21/2015 14:00	1.1	13.5	1,861.8	0.9	5.60	1	1	1
01/21/2015 15:00	1.3	13.2	1,928.0	1.0	7.70	1	1	1
01/21/2015 16:00	1.4	13.0	1,961.3	1.0	7.80	1	1	1
01/21/2015 17:00	1.4	12.9	1,993.4	1.0	8.00	1	1	1
01/21/2015 18:00	1.5	12.7	2,035.7	1.1	8.10	1	1	1
01/21/2015 19:00	1.4	12.8	2,030.6	1.0	8.10	1	1	1
01/21/2015 20:00	1.4	13.0	2,003.0	1.0	8.00	1	1	1
01/21/2015 21:00	1.4	13.0	1,994.4	1.0	8.00	1	1	1
01/21/2015 22:00	1.2	13.2	1,917.5	0.9	5.80	1	1	1
01/21/2015 23:00	1.0	13.7	1,560.2	0.8	4.70	1	1	1
Average/Sum#:	1.3	13.2	1,922.3	1.0	173.70 #	24 #	24 #	24 #
Minimum:	1.0	12.7	1,560.2	0.8	4.70	1	1	1
Maximum:	1.5	13.7	2,042.0	1.1	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/22/2015 00:00	0.9	13.9	1,405.6	0.8	4.20	1	1	0
01/22/2015 01:00	0.8	13.9	1,300.1	0.7	2.60	1	1	0
01/22/2015 02:00	0.8	13.9	1,312.8	0.7	2.60	1	1	0
01/22/2015 03:00	1.0	13.8	1,568.1	0.8	4.70	1	1	1
01/22/2015 04:00	1.2	13.3	1,873.8	0.9	5.60	1	1	1
01/22/2015 05:00	1.2	13.3	1,859.5	0.9	5.60	1	1	1
01/22/2015 06:00	1.2	13.2	1,920.1	0.9	5.80	1	1	1
01/22/2015 07:00	1.4	12.9	2,005.8	1.0	8.00	1	1	1
01/22/2015 08:00	1.3	13.1	1,977.5	1.0	7.90	1	1	1
01/22/2015 09:00	1.4	13.0	2,010.7	1.0	8.00	1	1	1
01/22/2015 10:00	1.1	13.3	1,862.6	0.9	5.60	1	1	1
01/22/2015 11:00	1.1	13.3	1,854.4	0.9	5.60	1	1	1
01/22/2015 12:00	1.1	13.3	1,849.5	0.9	5.50	1	1	1
01/22/2015 13:00	0.9	13.7	1,506.2	0.7	4.50	1	1	1
01/22/2015 14:00	1.0	13.9	1,646.5	0.8	4.90	1	1	0
01/22/2015 15:00	1.0	13.6	1,733.1	0.8	5.20	1	1	1
01/22/2015 16:00	1.1	13.4	1,854.7	0.9	5.60	1	1	1
01/22/2015 17:00	1.3	13.1	1,966.0	1.0	7.90	1	1	1
01/22/2015 18:00	1.4	12.8	2,038.4	1.0	8.20	1	1	1
01/22/2015 19:00	1.4	12.9	2,028.0	1.0	8.10	1	1	1
01/22/2015 20:00	1.4	13.1	1,991.3	1.1	8.00	1	1	1
01/22/2015 21:00	1.2	13.2	1,951.3	0.9	5.90	1	1	1
01/22/2015 22:00	1.2	13.3	1,925.8	0.9	5.80	1	1	1
01/22/2015 23:00	1.2	13.4	1,877.1	0.9	5.60	1	1	1
Average/Sum#:	1.2	13.4	1,805.0	0.9	141.40 #	24 #	24 #	20 #
Minimum:	0.8	12.8	1,300.1	0.7	2.60	1	1	0
Maximum:	1.4	13.9	2,038.4	1.1	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/23/2015 00:00	1.3	13.2	1,932.9	1.0	7.70	1	1	1
01/23/2015 01:00	1.2	13.4	1,894.6	0.9	5.70	1	1	1
01/23/2015 02:00	1.4	13.1	1,990.2	1.1	8.00	1	1	1
01/23/2015 03:00	1.4	13.1	1,970.3	1.1	7.90	1	1	1
01/23/2015 04:00	1.3	13.3	1,905.7	1.0	7.60	1	1	1
01/23/2015 05:00	1.2	13.3	1,895.9	0.9	5.70	1	1	1
01/23/2015 06:00	1.3	13.2	1,954.9	1.0	7.80	1	1	1
01/23/2015 07:00	1.4	12.9	2,022.8	1.0	8.10	1	1	1
01/23/2015 08:00	1.4	13.0	2,004.0	1.0	8.00	1	1	1
01/23/2015 09:00	1.2	13.4	1,914.9	0.9	5.70	1	1	1
01/23/2015 10:00	1.2	13.3	1,893.1	0.9	5.70	1	1	1
01/23/2015 11:00	1.1	13.4	1,859.7	0.9	5.60	1	1	1
01/23/2015 12:00	1.1	13.5	1,866.6	0.9	5.60	1	1	1
01/23/2015 13:00	1.1	13.4	1,865.8	0.9	5.60	1	1	1
01/23/2015 14:00	1.1	13.4	1,862.6	0.9	5.60	1	1	1
01/23/2015 15:00	1.1	13.3	1,877.6	0.9	5.60	1	1	1
01/23/2015 16:00	1.3	13.2	1,917.1	1.0	7.70	1	1	1
01/23/2015 17:00	1.3	13.2	1,930.0	1.0	7.70	1	1	1
01/23/2015 18:00	1.5	12.7	2,040.9	1.1	8.20	1	1	1
01/23/2015 19:00	1.5	12.6	2,058.2	1.1	8.20	1	1	1
01/23/2015 20:00	1.5	12.6	2,047.5	1.1	8.20	1	1	1
01/23/2015 21:00	1.5	12.8	2,012.3	1.1	8.00	1	1	1
01/23/2015 22:00	1.4	12.8	2,015.9	1.0	8.10	1	1	1
01/23/2015 23:00	1.2	13.3	1,915.5	0.9	5.70	1	1	1
Average/Sum#:	1.3	13.1	1,943.7	1.0	167.70 #	24 #	24 #	24 #
Minimum:	1.1	12.6	1,859.7	0.9	5.60	1	1	1
Maximum:	1.5	13.5	2,058.2	1.1	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/24/2015 00:00	1.1	13.5	1,862.6	0.9	5.60	1	1	1
01/24/2015 01:00	1.2	13.4	1,881.3	0.9	5.60	1	1	1
01/24/2015 02:00	1.1	13.5	1,858.6	0.9	5.60	1	1	1
01/24/2015 03:00	1.2	13.5	1,867.4	1.0	7.50	1	1	1
01/24/2015 04:00	1.3	13.2	1,942.6	1.0	7.80	1	1	1
01/24/2015 05:00	1.4	13.0	1,988.1	1.0	8.00	1	1	1
01/24/2015 06:00	1.4	13.0	1,985.2	1.0	7.90	1	1	1
01/24/2015 07:00	1.4	12.9	2,010.4	1.0	8.00	1	1	1
01/24/2015 08:00	1.3	13.2	1,935.9	1.0	7.70	1	1	1
01/24/2015 09:00	1.2	13.3	1,899.6	0.9	5.70	1	1	1
01/24/2015 10:00	1.2	13.4	1,847.6	0.9	5.50	1	1	1
01/24/2015 11:00	1.1	13.4	1,864.6	0.9	5.60	1	1	1
01/24/2015 12:00	1.2	13.4	1,860.5	0.9	5.60	1	1	1
01/24/2015 13:00	1.2	13.4	1,834.8	0.9	5.50	1	1	1
01/24/2015 14:00	0.8	14.0	1,300.9	0.7	3.90	1	1	0
01/24/2015 15:00	0.8	14.0	1,297.6	0.7	3.90	1	1	0
01/24/2015 16:00	0.9	14.0	1,443.9	0.8	4.30	1	1	0
01/24/2015 17:00	1.3	13.1	1,829.0	1.0	7.30	1	1	1
01/24/2015 18:00	1.5	12.5	2,070.2	1.1	8.30	1	1	1
01/24/2015 19:00	1.5	12.7	2,046.6	1.1	8.20	1	1	1
01/24/2015 20:00	1.4	13.0	1,985.7	1.0	7.90	1	1	1
01/24/2015 21:00	1.4	12.9	2,002.8	1.0	8.00	1	1	1
01/24/2015 22:00	1.4	12.9	2,018.4	1.0	8.10	1	1	1
01/24/2015 23:00	1.4	13.1	1,976.8	1.1	7.90	1	1	1
Average/Sum#:	1.2	13.3	1,858.8	0.9	159.40 #	24 #	24 #	21 #
Minimum:	0.8	12.5	1,297.6	0.7	3.90	1	1	0
Maximum:	1.5	14.0	2,070.2	1.1	8.30	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/25/2015 00:00	0.9	13.9	1,469.4	0.8	4.40	1	1	0
01/25/2015 01:00	5.0	15.8	589.7	5.8	2.73	1	0	0
01/25/2015 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2015 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2015 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2015 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2015 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2015 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2015 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2015 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2015 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2015 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2015 12:00	25.6	17.7	466.5	47.2	34.10	1	0	0
01/25/2015 13:00	17.7	15.9	709.9	20.9	54.70	1	0	0
01/25/2015 14:00	5.0	14.1	1,438.1	4.3	23.00	1	0	0
01/25/2015 15:00	1.0	13.9	1,776.5	0.8	5.30	1	1	0
01/25/2015 16:00	0.9	13.9	1,660.8	0.8	5.00	1	1	0
01/25/2015 17:00	1.3	13.2	1,820.2	1.0	7.30	1	1	1
01/25/2015 18:00	1.6	12.2	2,162.4	1.1	8.60	1	1	1
01/25/2015 19:00	1.2	13.3	1,823.5	0.9	5.50	1	1	1
01/25/2015 20:00	1.0	13.9	1,809.1	0.8	5.40	1	1	0
01/25/2015 21:00	1.0	13.9	1,710.2	0.8	5.10	1	1	0
01/25/2015 22:00	1.8	14.5	1,351.6	1.7	5.91	1	0	0
01/25/2015 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	4.9	14.3	1,445.2	6.7	167.04 #	13 #	8 #	3 #
Minimum:	0.9	12.2	466.5	0.8	2.73	0	0	0
Maximum:	25.6	17.7	2,162.4	47.2	54.70	1	1	1
%SI	45.8	45.8	45.8	45.8	45.83	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/26/2015 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2015 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2015 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2015 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2015 04:00	14.1	17.1	553.9	21.9	28.29	1	0	0
01/26/2015 05:00	8.0	14.4	1,288.0	7.3	34.80	1	0	0
01/26/2015 06:00	1.0	13.8	1,715.5	0.8	5.10	1	1	0
01/26/2015 07:00	1.1	13.9	1,814.9	0.9	5.40	1	1	0
01/26/2015 08:00	1.0	13.9	1,813.7	0.8	5.40	1	1	0
01/26/2015 09:00	1.0	13.8	1,815.7	0.8	5.40	1	1	0
01/26/2015 10:00	1.2	13.8	1,819.4	1.0	7.30	1	1	0
01/26/2015 11:00	1.2	13.8	1,772.5	1.0	7.10	1	1	0
01/26/2015 12:00	1.3	13.8	1,818.6	1.1	7.30	1	1	0
01/26/2015 13:00	1.3	13.8	1,798.5	1.1	7.20	1	1	0
01/26/2015 14:00	1.3	13.8	1,803.2	1.1	7.20	1	1	0
01/26/2015 15:00	1.3	13.8	1,799.5	1.1	7.20	1	1	0
01/26/2015 16:00	1.3	13.8	1,797.6	1.1	7.20	1	1	0
01/26/2015 17:00	0.9	13.9	1,615.7	0.8	4.80	1	1	0
01/26/2015 18:00	1.0	13.9	1,670.9	0.8	5.00	1	1	0
01/26/2015 19:00	1.3	13.8	1,815.6	1.1	7.30	1	1	0
01/26/2015 20:00	1.3	13.8	1,815.3	1.1	7.30	1	1	0
01/26/2015 21:00	1.0	13.9	1,593.4	0.8	4.80	1	1	0
01/26/2015 22:00	0.8	13.9	1,451.2	0.7	2.90	1	1	0
01/26/2015 23:00	0.7	13.9	1,353.0	0.6	2.70	1	1	0
Average/Sum#:	2.1	14.0	1,646.3	2.3	169.69 #	20 #	18 #	0 #
Minimum:	0.7	13.8	553.9	0.6	2.70	0	0	0
Maximum:	14.1	17.1	1,819.4	21.9	34.80	1	1	0
%SI	16.7	16.7	16.7	16.7	16.67	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/27/2015 00:00	0.8	13.9	1,357.9	0.7	2.70	1	1	0
01/27/2015 01:00	0.8	13.9	1,356.6	0.7	2.70	1	1	0
01/27/2015 02:00	1.0	13.9	1,557.3	0.8	4.70	1	1	0
01/27/2015 03:00	1.0	13.9	1,710.1	0.8	5.10	1	1	0
01/27/2015 04:00	1.3	13.7	1,821.4	1.1	7.30	1	1	0
01/27/2015 05:00	1.3	13.7	1,836.0	1.1	7.30	1	1	0
01/27/2015 06:00	1.3	13.7	1,841.9	1.1	7.40	1	1	0
01/27/2015 07:00	1.3	13.7	1,843.9	1.1	7.40	1	1	0
01/27/2015 08:00	1.3	13.7	1,841.8	1.1	7.40	1	1	0
01/27/2015 09:00	1.3	13.7	1,831.9	1.1	7.30	1	1	0
01/27/2015 10:00	0.8	13.9	1,386.8	0.7	2.80	1	1	0
01/27/2015 11:00	0.8	13.9	1,276.1	0.7	2.60	1	1	0
01/27/2015 12:00	0.8	13.9	1,302.4	0.7	2.60	1	1	0
01/27/2015 13:00	1.0	13.9	1,559.6	0.8	4.70	1	1	0
01/27/2015 14:00	0.8	13.9	1,295.6	0.7	2.60	1	1	0
01/27/2015 15:00	1.0	13.9	1,571.0	0.8	4.70	1	1	0
01/27/2015 16:00	0.8	13.9	1,322.9	0.7	2.60	1	1	0
01/27/2015 17:00	1.0	13.6	1,656.7	0.8	5.00	1	1	1
01/27/2015 18:00	1.4	13.0	1,990.1	1.0	8.00	1	1	1
01/27/2015 19:00	1.5	13.0	1,980.6	1.1	7.90	1	1	1
01/27/2015 20:00	1.4	13.1	1,962.0	1.1	7.80	1	1	1
01/27/2015 21:00	1.4	13.1	1,971.7	1.1	7.90	1	1	1
01/27/2015 22:00	1.4	13.0	1,963.0	1.0	7.90	1	1	1
01/27/2015 23:00	1.0	13.7	1,563.3	0.8	4.70	1	1	1
Average/Sum#:	1.1	13.7	1,658.4	0.9	131.10 #	24 #	24 #	7 #
Minimum:	0.8	13.0	1,276.1	0.7	2.60	1	1	0
Maximum:	1.5	13.9	1,990.1	1.1	8.00	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/28/2015 00:00	0.8	13.9	1,278.9	0.7	2.60	1	1	0
01/28/2015 01:00	0.8	13.9	1,278.5	0.7	2.60	1	1	0
01/28/2015 02:00	0.8	13.9	1,272.6	0.7	2.50	1	1	0
01/28/2015 03:00	0.8	13.9	1,271.8	0.7	2.50	1	1	0
01/28/2015 04:00	0.8	13.9	1,281.0	0.7	2.60	1	1	0
01/28/2015 05:00	1.0	13.6	1,610.8	0.8	4.80	1	1	1
01/28/2015 06:00	1.2	13.5	1,879.1	1.0	7.50	1	1	1
01/28/2015 07:00	1.4	12.7	2,022.9	1.0	8.10	1	1	1
01/28/2015 08:00	1.2	13.3	1,875.2	0.9	5.60	1	1	1
01/28/2015 09:00	1.1	13.6	1,850.2	0.9	5.60	1	1	1
01/28/2015 10:00	1.2	13.6	1,851.3	1.0	7.40	1	1	1
01/28/2015 11:00	1.1	13.6	1,734.5	0.9	5.20	1	1	1
01/28/2015 12:00	0.9	14.0	1,269.0	0.8	3.80	1	1	0
01/28/2015 13:00	1.1	13.9	1,609.9	0.9	4.80	1	1	0
01/28/2015 14:00	1.3	13.4	1,834.3	1.0	7.30	1	1	1
01/28/2015 15:00	1.5	12.4	2,058.7	1.0	8.20	1	1	1
01/28/2015 16:00	1.5	12.8	1,991.8	1.1	8.00	1	1	1
01/28/2015 17:00	1.3	13.0	1,944.7	1.0	7.80	1	1	1
01/28/2015 18:00	1.4	12.8	2,005.7	1.0	8.00	1	1	1
01/28/2015 19:00	1.4	12.8	2,006.1	1.0	8.00	1	1	1
01/28/2015 20:00	1.3	13.1	1,939.0	1.0	7.80	1	1	1
01/28/2015 21:00	1.3	13.1	1,954.1	1.0	7.80	1	1	1
01/28/2015 22:00	1.3	13.1	1,924.9	1.0	7.70	1	1	1
01/28/2015 23:00	1.2	13.4	1,847.1	0.9	5.50	1	1	1
Average/Sum#:	1.2	13.4	1,733.0	0.9	141.70 #	24 #	24 #	17 #
Minimum:	0.8	12.4	1,269.0	0.7	2.50	1	1	0
Maximum:	1.5	14.0	2,058.7	1.1	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/29/2015 00:00	1.2	13.4	1,844.4	0.9	5.50	1	1	1
01/29/2015 01:00	1.2	13.4	1,849.0	0.9	5.50	1	1	1
01/29/2015 02:00	1.2	13.4	1,850.8	0.9	5.60	1	1	1
01/29/2015 03:00	1.2	13.4	1,848.3	0.9	5.50	1	1	1
01/29/2015 04:00	1.2	13.4	1,858.4	0.9	5.60	1	1	1
01/29/2015 05:00	1.2	13.4	1,853.3	0.9	5.60	1	1	1
01/29/2015 06:00	1.3	13.2	1,936.3	1.0	7.70	1	1	1
01/29/2015 07:00	1.4	12.9	2,016.8	1.0	8.10	1	1	1
01/29/2015 08:00	1.4	13.2	1,966.3	1.1	7.90	1	1	1
01/29/2015 09:00	1.4	13.1	1,956.0	1.1	7.80	1	1	1
01/29/2015 10:00	1.1	13.4	1,868.3	0.9	5.60	1	1	1
01/29/2015 11:00	1.1	13.5	1,853.5	0.9	5.60	1	1	1
01/29/2015 12:00	1.2	13.5	1,858.4	1.0	7.40	1	1	1
01/29/2015 13:00	1.3	13.4	1,855.8	1.0	7.40	1	1	1
01/29/2015 14:00	1.2	13.4	1,867.5	0.9	5.60	1	1	1
01/29/2015 15:00	1.5	12.5	2,027.1	1.1	8.10	1	1	1
01/29/2015 16:00	1.3	13.1	1,915.4	1.0	7.70	1	1	1
01/29/2015 17:00	1.2	13.3	1,896.1	0.9	5.70	1	1	1
01/29/2015 18:00	1.5	12.8	2,006.5	1.1	8.00	1	1	1
01/29/2015 19:00	1.4	12.7	2,025.2	1.0	8.10	1	1	1
01/29/2015 20:00	1.5	12.7	2,044.2	1.1	8.20	1	1	1
01/29/2015 21:00	1.4	13.0	1,978.6	1.0	7.90	1	1	1
01/29/2015 22:00	1.3	13.3	1,907.6	1.0	7.60	1	1	1
01/29/2015 23:00	1.2	13.5	1,858.7	1.0	7.40	1	1	1
Average/Sum#:	1.3	13.2	1,914.3	1.0	165.10 #	24 #	24 #	24 #
Minimum:	1.1	12.5	1,844.4	0.9	5.50	1	1	1
Maximum:	1.5	13.5	2,044.2	1.1	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/30/2015 00:00	1.2	13.5	1,859.5	1.0	7.40	1	1	1
01/30/2015 01:00	1.2	13.5	1,860.3	1.0	7.40	1	1	1
01/30/2015 02:00	1.2	13.4	1,856.6	0.9	5.60	1	1	1
01/30/2015 03:00	1.2	13.4	1,854.7	0.9	5.60	1	1	1
01/30/2015 04:00	1.2	13.5	1,861.1	1.0	7.40	1	1	1
01/30/2015 05:00	1.2	13.5	1,865.0	1.0	7.50	1	1	1
01/30/2015 06:00	1.2	13.4	1,902.1	0.9	5.70	1	1	1
01/30/2015 07:00	1.3	13.0	1,977.9	1.0	7.90	1	1	1
01/30/2015 08:00	1.4	13.0	1,968.4	1.0	7.90	1	1	1
01/30/2015 09:00	1.3	13.2	1,924.3	1.0	7.70	1	1	1
01/30/2015 10:00	1.2	13.3	1,890.8	0.9	5.70	1	1	1
01/30/2015 11:00	1.2	13.4	1,860.8	0.9	5.60	1	1	1
01/30/2015 12:00	1.0	13.8	1,629.3	0.8	4.90	1	1	1
01/30/2015 13:00	1.3	13.1	1,902.5	1.0	7.60	1	1	1
01/30/2015 14:00	1.3	13.1	1,910.9	1.0	7.60	1	1	1
01/30/2015 15:00	1.3	13.2	1,902.4	1.0	7.60	1	1	1
01/30/2015 16:00	1.4	12.9	1,974.9	1.0	7.90	1	1	1
01/30/2015 17:00	1.2	13.3	1,882.5	0.9	5.60	1	1	1
01/30/2015 18:00	1.2	13.4	1,870.8	0.9	5.60	1	1	1
01/30/2015 19:00	1.1	13.4	1,862.9	0.9	5.60	1	1	1
01/30/2015 20:00	1.2	13.4	1,865.4	0.9	5.60	1	1	1
01/30/2015 21:00	1.2	13.5	1,865.4	1.0	7.50	1	1	1
01/30/2015 22:00	1.1	13.6	1,696.3	0.9	5.10	1	1	1
01/30/2015 23:00	0.9	14.0	1,273.1	0.8	3.80	1	1	0
Average/Sum#:	1.2	13.4	1,846.6	0.9	155.80 #	24 #	24 #	23 #
Minimum:	0.9	12.9	1,273.1	0.8	3.80	1	1	0
Maximum:	1.4	14.0	1,977.9	1.0	7.90	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/31/2015 00:00	5.7	15.9	546.3	6.7	3.01	1	0	0
01/31/2015 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/31/2015 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/31/2015 03:00	5.5	16.9	574.2	8.1	12.04	1	0	0
01/31/2015 04:00	13.3	14.7	1,067.9	12.7	50.20	1	0	0
01/31/2015 05:00	1.1	13.6	1,780.3	0.9	5.30	1	1	1
01/31/2015 06:00	1.3	13.5	1,873.1	1.0	7.50	1	1	1
01/31/2015 07:00	1.3	13.5	1,872.8	1.0	7.50	1	1	1
01/31/2015 08:00	1.3	13.6	1,872.0	1.1	7.50	1	1	1
01/31/2015 09:00	1.3	13.5	1,871.6	1.0	7.50	1	1	1
01/31/2015 10:00	1.3	13.5	1,869.9	1.0	7.50	1	1	1
01/31/2015 11:00	1.0	14.0	1,366.3	0.9	4.10	1	1	1
01/31/2015 12:00	0.9	14.0	1,299.3	0.8	3.90	1	1	0
01/31/2015 13:00	0.9	14.0	1,328.4	0.8	4.00	1	1	0
01/31/2015 14:00	1.0	14.0	1,522.4	0.9	4.60	1	1	0
01/31/2015 15:00	1.2	13.7	1,702.6	1.0	6.80	1	1	1
01/31/2015 16:00	1.2	13.6	1,731.2	1.0	6.90	1	1	1
01/31/2015 17:00	1.1	13.8	1,594.1	0.9	4.80	1	1	1
01/31/2015 18:00	1.5	12.7	2,018.3	1.1	8.10	1	1	1
01/31/2015 19:00	1.5	12.6	2,034.1	1.1	8.10	1	1	1
01/31/2015 20:00	1.5	12.6	2,035.0	1.1	8.10	1	1	1
01/31/2015 21:00	1.4	12.6	2,044.7	1.0	8.20	1	1	1
01/31/2015 22:00	1.5	12.7	2,038.4	1.1	8.20	1	1	1
01/31/2015 23:00	1.3	13.1	1,945.8	1.0	7.80	1	1	1
Average/Sum#:	2.2	13.7	1,635.9	2.1	191.65 #	22 #	19 #	16 #
Minimum:	0.9	12.6	546.3	0.8	3.01	0	0	0
Maximum:	13.3	16.9	2,044.7	12.7	50.20	1	1	1
%SI	8.3	8.3	8.3	8.3	8.33	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/01/2015 00:00	1.4	12.9	1,991.9	1.0	8.00	1	1	1
02/01/2015 01:00	1.1	13.8	1,620.8	0.9	4.90	1	1	1
02/01/2015 02:00	5.7	15.9	592.1	6.7	3.40	1	0	0
02/01/2015 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2015 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2015 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2015 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2015 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2015 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2015 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2015 10:00	26.5	17.5	477.6	46.0	50.03	1	0	0
02/01/2015 11:00	15.8	15.3	840.0	16.6	51.20	1	0	0
02/01/2015 12:00	0.6	13.9	1,385.6	0.5	2.80	1	1	0
02/01/2015 13:00	0.7	14.0	1,390.7	0.6	2.80	1	1	0
02/01/2015 14:00	1.1	13.9	1,728.2	0.9	5.20	1	1	0
02/01/2015 15:00	0.8	14.0	1,506.9	0.7	4.50	1	1	0
02/01/2015 16:00	1.1	13.6	1,787.5	0.9	5.40	1	1	1
02/01/2015 17:00	1.2	13.3	1,909.9	0.9	5.70	1	1	1
02/01/2015 18:00	1.5	12.9	1,984.3	1.1	7.90	1	1	1
02/01/2015 19:00	1.5	12.8	2,010.5	1.1	8.00	1	1	1
02/01/2015 20:00	1.5	12.7	2,016.9	1.1	8.10	1	1	1
02/01/2015 21:00	1.5	12.8	1,998.4	1.1	8.00	1	1	1
02/01/2015 22:00	1.3	13.2	1,914.4	1.0	7.70	1	1	1
02/01/2015 23:00	1.2	13.4	1,831.9	0.9	5.50	1	1	1
Average/Sum#:	3.8	13.9	1,587.5	4.8	189.13 #	17 #	14 #	10 #
Minimum:	0.6	12.7	477.6	0.5	2.80	0	0	0
Maximum:	26.5	17.5	2,016.9	46.0	51.20	1	1	1
%SI	29.2	29.2	29.2	29.2	29.17	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/02/2015 00:00	1.2	13.4	1,848.1	0.9	5.50	1	1	1
02/02/2015 01:00	1.4	12.9	1,987.1	1.0	7.90	1	1	1
02/02/2015 02:00	1.4	13.1	1,936.2	1.1	7.70	1	1	1
02/02/2015 03:00	1.2	13.4	1,851.9	0.9	5.60	1	1	1
02/02/2015 04:00	1.2	13.4	1,841.2	0.9	5.50	1	1	1
02/02/2015 05:00	1.2	13.4	1,865.0	0.9	5.60	1	1	1
02/02/2015 06:00	1.3	13.0	1,963.0	1.0	7.90	1	1	1
02/02/2015 07:00	1.4	12.9	1,967.8	1.0	7.90	1	1	1
02/02/2015 08:00	1.2	13.4	1,844.1	0.9	5.50	1	1	1
02/02/2015 09:00	1.2	13.4	1,837.4	0.9	5.50	1	1	1
02/02/2015 10:00	1.2	13.4	1,841.9	0.9	5.50	1	1	1
02/02/2015 11:00	1.2	13.4	1,860.6	0.9	5.60	1	1	1
02/02/2015 12:00	1.3	13.2	1,906.3	1.0	7.60	1	1	1
02/02/2015 13:00	1.2	13.3	1,883.5	0.9	5.70	1	1	1
02/02/2015 14:00	1.2	13.4	1,858.9	0.9	5.60	1	1	1
02/02/2015 15:00	1.1	13.4	1,857.8	0.9	5.60	1	1	1
02/02/2015 16:00	1.2	13.2	1,913.3	0.9	5.70	1	1	1
02/02/2015 17:00	1.3	13.1	1,939.2	1.0	7.80	1	1	1
02/02/2015 18:00	1.5	12.8	1,996.8	1.1	8.00	1	1	1
02/02/2015 19:00	1.4	12.8	1,991.8	1.0	8.00	1	1	1
02/02/2015 20:00	1.5	12.8	1,998.1	1.1	8.00	1	1	1
02/02/2015 21:00	1.4	13.0	1,954.2	1.0	7.80	1	1	1
02/02/2015 22:00	1.3	13.2	1,902.4	1.0	7.60	1	1	1
02/02/2015 23:00	1.1	13.4	1,822.9	0.9	5.50	1	1	1
Average/Sum#:	1.3	13.2	1,902.9	1.0	158.60 #	24 #	24 #	24 #
Minimum:	1.1	12.8	1,822.9	0.9	5.50	1	1	1
Maximum:	1.5	13.4	1,998.1	1.1	8.00	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/03/2015 00:00	0.8	13.9	1,328.5	0.7	2.70	1	1	0
02/03/2015 01:00	0.8	13.9	1,288.5	0.7	2.60	1	1	0
02/03/2015 02:00	0.8	13.9	1,290.1	0.7	2.60	1	1	0
02/03/2015 03:00	0.8	13.9	1,368.4	0.7	2.70	1	1	0
02/03/2015 04:00	1.1	13.7	1,701.6	0.9	5.10	1	1	1
02/03/2015 05:00	1.1	13.4	1,831.8	0.9	5.50	1	1	1
02/03/2015 06:00	1.2	13.3	1,862.4	0.9	5.60	1	1	1
02/03/2015 07:00	1.1	13.4	1,830.3	0.9	5.50	1	1	1
02/03/2015 08:00	1.1	13.4	1,834.1	0.9	5.50	1	1	1
02/03/2015 09:00	1.1	13.4	1,838.5	0.9	5.50	1	1	1
02/03/2015 10:00	1.0	13.6	1,676.2	0.8	5.00	1	1	1
02/03/2015 11:00	0.7	13.9	1,260.8	0.6	2.50	1	1	0
02/03/2015 12:00	0.8	13.9	1,298.9	0.7	2.60	1	1	0
02/03/2015 13:00	0.9	13.9	1,358.6	0.8	4.10	1	1	0
02/03/2015 14:00	1.1	13.8	1,705.7	0.9	5.10	1	1	0
02/03/2015 15:00	1.0	13.9	1,582.4	0.8	4.70	1	1	0
02/03/2015 16:00	1.0	13.6	1,649.0	0.8	4.90	1	1	1
02/03/2015 17:00	1.2	13.2	1,915.3	0.9	5.70	1	1	1
02/03/2015 18:00	1.5	12.6	2,039.5	1.1	8.20	1	1	1
02/03/2015 19:00	1.4	12.8	2,000.2	1.0	8.00	1	1	1
02/03/2015 20:00	1.4	12.9	1,978.9	1.0	7.90	1	1	1
02/03/2015 21:00	1.3	13.1	1,923.7	1.0	7.70	1	1	1
02/03/2015 22:00	1.3	13.2	1,808.6	1.0	7.20	1	1	1
02/03/2015 23:00	0.7	13.9	1,316.8	0.6	2.60	1	1	0
Average/Sum#:	1.1	13.5	1,653.7	0.8	119.50 #	24 #	24 #	14 #
Minimum:	0.7	12.6	1,260.8	0.6	2.50	1	1	0
Maximum:	1.5	13.9	2,039.5	1.1	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/04/2015 00:00	1.1	13.8	1,689.4	0.9	5.10	1	1	0
02/04/2015 01:00	0.9	13.9	1,491.3	0.8	4.50	1	1	0
02/04/2015 02:00	0.7	13.9	1,285.8	0.6	2.60	1	1	0
02/04/2015 03:00	0.8	13.9	1,288.3	0.7	2.60	1	1	0
02/04/2015 04:00	0.8	13.9	1,386.9	0.7	2.80	1	1	0
02/04/2015 05:00	1.0	13.7	1,606.1	0.8	4.80	1	1	1
02/04/2015 06:00	1.2	13.3	1,894.2	0.9	5.70	1	1	1
02/04/2015 07:00	1.3	13.3	1,876.9	1.0	7.50	1	1	1
02/04/2015 08:00	0.8	13.9	1,323.4	0.7	2.60	1	1	0
02/04/2015 09:00	0.7	13.9	1,290.3	0.6	2.60	1	1	0
02/04/2015 10:00	0.8	13.9	1,292.0	0.7	2.60	1	1	0
02/04/2015 11:00	0.8	13.9	1,292.0	0.7	2.60	1	1	0
02/04/2015 12:00	0.8	13.9	1,291.5	0.7	2.60	1	1	0
02/04/2015 13:00	0.8	13.9	1,292.0	0.7	2.60	1	1	0
02/04/2015 14:00	0.8	13.9	1,292.7	0.7	2.60	1	1	0
02/04/2015 15:00	0.8	13.9	1,351.9	0.7	2.70	1	1	1
02/04/2015 16:00	1.2	13.3	1,856.6	0.9	5.60	1	1	1
02/04/2015 17:00	1.3	13.1	1,924.6	1.0	7.70	1	1	1
02/04/2015 18:00	1.5	12.7	2,013.7	1.1	8.10	1	1	1
02/04/2015 19:00	1.5	12.7	1,993.9	1.1	8.00	1	1	1
02/04/2015 20:00	1.4	12.9	1,971.6	1.0	7.90	1	1	1
02/04/2015 21:00	1.4	12.8	1,992.6	1.0	8.00	1	1	1
02/04/2015 22:00	1.4	12.9	1,960.3	1.0	7.80	1	1	1
02/04/2015 23:00	1.0	13.6	1,554.0	0.8	4.70	1	1	1
Average/Sum#:	1.0	13.5	1,592.2	0.8	114.30 #	24 #	24 #	12 #
Minimum:	0.7	12.7	1,285.8	0.6	2.60	1	1	0
Maximum:	1.5	13.9	2,013.7	1.1	8.10	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/05/2015 00:00	0.8	13.9	1,285.5	0.7	2.60	1	1	0
02/05/2015 01:00	0.8	13.9	1,287.4	0.7	2.60	1	1	0
02/05/2015 02:00	0.7	13.9	1,289.2	0.6	2.60	1	1	0
02/05/2015 03:00	0.8	13.9	1,289.4	0.7	2.60	1	1	0
02/05/2015 04:00	0.9	13.9	1,418.9	0.8	4.30	1	1	0
02/05/2015 05:00	1.0	13.7	1,590.0	0.8	4.80	1	1	1
02/05/2015 06:00	1.2	13.3	1,886.6	0.9	5.70	1	1	1
02/05/2015 07:00	1.3	13.1	1,922.0	1.0	7.70	1	1	1
02/05/2015 08:00	0.9	13.8	1,427.9	0.7	4.30	1	1	1
02/05/2015 09:00	0.8	13.9	1,284.9	0.7	2.60	1	1	0
02/05/2015 10:00	0.8	13.9	1,297.7	0.7	2.60	1	1	0
02/05/2015 11:00	0.8	13.9	1,321.2	0.7	2.60	1	1	0
02/05/2015 12:00	0.8	13.9	1,350.2	0.7	2.70	1	1	0
02/05/2015 13:00	1.0	13.9	1,600.8	0.8	4.80	1	1	0
02/05/2015 14:00	1.1	13.9	1,654.4	0.9	5.00	1	1	0
02/05/2015 15:00	1.0	13.9	1,613.1	0.8	4.80	1	1	0
02/05/2015 16:00	1.2	13.4	1,836.8	0.9	5.50	1	1	1
02/05/2015 17:00	1.2	13.3	1,861.2	0.9	5.60	1	1	1
02/05/2015 18:00	1.4	12.8	1,967.4	1.0	7.90	1	1	1
02/05/2015 19:00	1.4	13.0	1,946.1	1.0	7.80	1	1	1
02/05/2015 20:00	1.4	12.9	1,962.9	1.0	7.90	1	1	1
02/05/2015 21:00	1.4	13.0	1,932.1	1.0	7.70	1	1	1
02/05/2015 22:00	0.9	13.9	1,456.7	0.8	4.40	1	1	0
02/05/2015 23:00	0.8	13.9	1,282.9	0.7	2.60	1	1	0
Average/Sum#:	1.0	13.6	1,573.6	0.8	111.70 #	24 #	24 #	10 #
Minimum:	0.7	12.8	1,282.9	0.6	2.60	1	1	0
Maximum:	1.4	13.9	1,967.4	1.0	7.90	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/06/2015 00:00	0.8	13.9	1,296.7	0.7	2.60	1	1	0
02/06/2015 01:00	0.8	13.9	1,288.4	0.7	2.60	1	1	0
02/06/2015 02:00	0.8	13.9	1,281.5	0.7	2.60	1	1	0
02/06/2015 03:00	0.8	13.9	1,286.3	0.7	2.60	1	1	0
02/06/2015 04:00	0.8	14.0	1,329.8	0.7	4.00	1	1	0
02/06/2015 05:00	1.2	13.4	1,772.2	0.9	5.30	1	1	1
02/06/2015 06:00	1.3	13.1	1,912.7	1.0	7.70	1	1	1
02/06/2015 07:00	1.3	13.0	1,884.8	1.0	7.50	1	1	1
02/06/2015 08:00	1.1	13.4	1,837.2	0.9	5.50	1	1	1
02/06/2015 09:00	1.1	13.6	1,651.1	0.9	5.00	1	1	1
02/06/2015 10:00	1.1	13.4	1,826.6	0.9	5.50	1	1	1
02/06/2015 11:00	1.0	13.4	1,836.7	0.8	5.50	1	1	1
02/06/2015 12:00	0.9	13.8	1,610.0	0.7	4.80	1	1	1
02/06/2015 13:00	1.0	13.4	1,845.4	0.8	5.50	1	1	1
02/06/2015 14:00	1.0	13.4	1,836.5	0.8	5.50	1	1	1
02/06/2015 15:00	1.0	13.4	1,838.6	0.8	5.50	1	1	1
02/06/2015 16:00	1.1	13.3	1,863.5	0.9	5.60	1	1	1
02/06/2015 17:00	1.3	12.7	1,977.9	0.9	5.90	1	1	1
02/06/2015 18:00	1.4	12.4	2,021.5	1.0	8.10	1	1	1
02/06/2015 19:00	1.3	12.6	1,979.7	0.9	5.90	1	1	1
02/06/2015 20:00	1.4	12.5	2,004.0	1.0	8.00	1	1	1
02/06/2015 21:00	1.2	13.1	1,882.7	0.9	5.60	1	1	1
02/06/2015 22:00	0.7	14.0	1,372.7	0.6	2.70	1	1	0
02/06/2015 23:00	0.9	13.9	1,577.9	0.8	4.70	1	1	0
Average/Sum#:	1.1	13.4	1,708.9	0.8	124.20 #	24 #	24 #	17 #
Minimum:	0.7	12.4	1,281.5	0.6	2.60	1	1	0
Maximum:	1.4	14.0	2,021.5	1.0	8.10	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/07/2015 00:00	0.6	14.0	1,308.7	0.5	2.60	1	1	0
02/07/2015 01:00	0.8	13.9	1,443.0	0.7	2.90	1	1	0
02/07/2015 02:00	0.8	14.0	1,394.9	0.7	4.20	1	1	0
02/07/2015 03:00	0.7	14.0	1,338.6	0.6	2.70	1	1	0
02/07/2015 04:00	0.8	14.0	1,337.7	0.7	4.00	1	1	0
02/07/2015 05:00	0.7	14.0	1,326.8	0.6	2.70	1	1	0
02/07/2015 06:00	0.7	14.0	1,329.5	0.6	2.70	1	1	0
02/07/2015 07:00	0.7	14.0	1,311.8	0.6	2.60	1	1	0
02/07/2015 08:00	0.7	13.9	1,285.2	0.6	2.60	1	1	0
02/07/2015 09:00	0.7	13.9	1,303.4	0.6	2.60	1	1	0
02/07/2015 10:00	0.7	13.9	1,349.9	0.6	2.70	1	1	0
02/07/2015 11:00	0.7	13.9	1,330.3	0.6	2.70	1	1	0
02/07/2015 12:00	0.7	13.9	1,293.3	0.6	2.60	1	1	0
02/07/2015 13:00	0.7	14.0	1,299.3	0.6	2.60	1	1	0
02/07/2015 14:00	0.7	14.0	1,341.1	0.6	2.70	1	1	0
02/07/2015 15:00	0.7	14.0	1,318.4	0.6	2.60	1	1	0
02/07/2015 16:00	0.9	13.6	1,648.4	0.7	4.90	1	1	1
02/07/2015 17:00	1.1	13.2	1,874.7	0.8	5.60	1	1	1
02/07/2015 18:00	1.4	12.5	2,009.9	1.0	8.00	1	1	1
02/07/2015 19:00	1.3	12.9	1,933.7	1.0	7.70	1	1	1
02/07/2015 20:00	1.4	12.6	2,004.3	1.0	8.00	1	1	1
02/07/2015 21:00	1.0	13.5	1,719.0	0.8	5.20	1	1	1
02/07/2015 22:00	0.8	13.9	1,382.0	0.7	2.80	1	1	0
02/07/2015 23:00	0.7	13.9	1,285.3	0.6	2.60	1	1	0
Average/Sum#:	0.8	13.7	1,465.4	0.7	90.30 #	24 #	24 #	6 #
Minimum:	0.6	12.5	1,285.2	0.5	2.60	1	1	0
Maximum:	1.4	14.0	2,009.9	1.0	8.00	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/08/2015 00:00	0.7	13.9	1,308.2	0.6	2.60	1	1	0
02/08/2015 01:00	0.7	13.9	1,341.7	0.6	2.70	1	1	0
02/08/2015 02:00	0.7	13.9	1,337.2	0.6	2.70	1	1	0
02/08/2015 03:00	0.7	13.9	1,290.1	0.6	2.60	1	1	0
02/08/2015 04:00	0.7	13.9	1,289.0	0.6	2.60	1	1	0
02/08/2015 05:00	0.7	13.9	1,285.2	0.6	2.60	1	1	0
02/08/2015 06:00	0.7	13.9	1,326.9	0.6	2.70	1	1	0
02/08/2015 07:00	0.7	13.9	1,314.1	0.6	2.60	1	1	0
02/08/2015 08:00	0.7	13.9	1,282.8	0.6	2.60	1	1	0
02/08/2015 09:00	0.7	13.9	1,284.3	0.6	2.60	1	1	0
02/08/2015 10:00	0.7	13.9	1,283.5	0.6	2.60	1	1	0
02/08/2015 11:00	0.7	13.9	1,286.8	0.6	2.60	1	1	0
02/08/2015 12:00	0.7	13.9	1,313.0	0.6	2.60	1	1	0
02/08/2015 13:00	0.7	13.9	1,322.2	0.6	2.60	1	1	0
02/08/2015 14:00	0.7	14.0	1,296.3	0.6	2.60	1	1	0
02/08/2015 15:00	0.7	14.0	1,297.8	0.6	2.60	1	1	0
02/08/2015 16:00	1.2	13.3	1,823.8	0.9	5.50	1	1	1
02/08/2015 17:00	1.2	13.1	1,907.1	0.9	5.70	1	1	1
02/08/2015 18:00	1.5	12.5	2,022.9	1.1	8.10	1	1	1
02/08/2015 19:00	1.5	12.7	1,980.0	1.1	7.90	1	1	1
02/08/2015 20:00	1.5	12.6	2,004.3	1.1	8.00	1	1	1
02/08/2015 21:00	1.3	13.1	1,763.9	1.0	7.10	1	1	1
02/08/2015 22:00	0.7	14.0	1,332.1	0.6	2.70	1	1	0
02/08/2015 23:00	0.9	13.9	1,521.3	0.8	4.60	1	1	0
Average/Sum#:	0.9	13.7	1,467.3	0.7	91.50 #	24 #	24 #	6 #
Minimum:	0.7	12.5	1,282.8	0.6	2.60	1	1	0
Maximum:	1.5	14.0	2,022.9	1.1	8.10	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/09/2015 00:00	0.7	14.0	1,306.9	0.6	2.60	1	1	0
02/09/2015 01:00	0.7	14.0	1,315.0	0.6	2.60	1	1	0
02/09/2015 02:00	0.8	14.0	1,285.2	0.7	3.90	1	1	0
02/09/2015 03:00	0.8	13.9	1,285.3	0.7	2.60	1	1	0
02/09/2015 04:00	0.8	13.9	1,285.8	0.7	2.60	1	1	0
02/09/2015 05:00	0.8	14.0	1,319.3	0.7	4.00	1	1	0
02/09/2015 06:00	1.1	13.5	1,722.3	0.9	5.20	1	1	1
02/09/2015 07:00	1.2	13.4	1,841.0	0.9	5.50	1	1	1
02/09/2015 08:00	1.1	13.5	1,839.6	0.9	5.50	1	1	1
02/09/2015 09:00	0.9	13.8	1,452.6	0.7	4.40	1	1	1
02/09/2015 10:00	0.7	13.9	1,289.8	0.6	2.60	1	1	0
02/09/2015 11:00	0.7	13.9	1,288.3	0.6	2.60	1	1	0
02/09/2015 12:00	0.8	13.9	1,286.1	0.7	2.60	1	1	0
02/09/2015 13:00	0.8	14.0	1,287.9	0.7	3.90	1	1	0
02/09/2015 14:00	0.8	14.0	1,290.0	0.7	3.90	1	1	0
02/09/2015 15:00	0.8	14.0	1,286.4	0.7	3.90	1	1	0
02/09/2015 16:00	0.8	14.0	1,287.4	0.7	3.90	1	1	0
02/09/2015 17:00	1.1	13.6	1,764.7	0.9	5.30	1	1	1
02/09/2015 18:00	1.1	13.5	1,847.8	0.9	5.50	1	1	1
02/09/2015 19:00	1.2	13.4	1,847.3	0.9	5.50	1	1	1
02/09/2015 20:00	1.2	13.4	1,869.2	0.9	5.60	1	1	1
02/09/2015 21:00	1.1	13.7	1,633.4	0.9	4.90	1	1	1
02/09/2015 22:00	0.9	13.9	1,326.8	0.8	4.00	1	1	0
02/09/2015 23:00	0.9	13.9	1,318.5	0.8	4.00	1	1	0
Average/Sum#:	0.9	13.8	1,469.9	0.8	97.10 #	24 #	24 #	9 #
Minimum:	0.7	13.4	1,285.2	0.6	2.60	1	1	0
Maximum:	1.2	14.0	1,869.2	0.9	5.60	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/10/2015 00:00	0.8	13.9	1,292.8	0.7	2.60	1	1	0
02/10/2015 01:00	0.8	13.9	1,296.3	0.7	2.60	1	1	0
02/10/2015 02:00	0.8	13.9	1,291.7	0.7	2.60	1	1	0
02/10/2015 03:00	0.8	13.9	1,293.6	0.7	2.60	1	1	0
02/10/2015 04:00	0.8	13.9	1,297.4	0.7	2.60	1	1	0
02/10/2015 05:00	0.8	13.9	1,330.0	0.7	2.70	1	1	0
02/10/2015 06:00	1.2	13.4	1,891.8	0.9	5.70	1	1	1
02/10/2015 07:00	1.4	13.1	1,932.9	1.1	7.70	1	1	1
02/10/2015 08:00	1.0	13.8	1,525.3	0.8	4.60	1	1	1
02/10/2015 09:00	0.8	14.0	1,294.9	0.7	3.90	1	1	0
02/10/2015 10:00	0.8	13.9	1,294.6	0.7	2.60	1	1	0
02/10/2015 11:00	0.8	13.9	1,296.9	0.7	2.60	1	1	0
02/10/2015 12:00	0.8	14.0	1,297.3	0.7	3.90	1	1	0
02/10/2015 13:00	0.8	14.0	1,294.1	0.7	3.90	1	1	0
02/10/2015 14:00	0.8	14.0	1,294.3	0.7	3.90	1	1	0
02/10/2015 15:00	0.8	14.0	1,294.9	0.7	3.90	1	1	0
02/10/2015 16:00	1.2	13.3	1,851.3	0.9	5.60	1	1	1
02/10/2015 17:00	1.4	12.9	1,987.4	1.0	7.90	1	1	1
02/10/2015 18:00	1.5	12.6	2,027.7	1.1	8.10	1	1	1
02/10/2015 19:00	1.5	12.6	2,029.0	1.1	8.10	1	1	1
02/10/2015 20:00	1.5	12.7	2,015.0	1.1	8.10	1	1	1
02/10/2015 21:00	1.4	12.9	1,963.3	1.0	7.90	1	1	1
02/10/2015 22:00	1.5	12.7	2,015.1	1.1	8.10	1	1	1
02/10/2015 23:00	1.4	12.9	1,998.4	1.0	8.00	1	1	1
Average/Sum#:	1.1	13.5	1,587.8	0.8	120.20 #	24 #	24 #	11 #
Minimum:	0.8	12.6	1,291.7	0.7	2.60	1	1	0
Maximum:	1.5	14.0	2,029.0	1.1	8.10	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/11/2015 00:00	1.5	12.9	2,002.2	1.1	8.00	1	1	1
02/11/2015 01:00	1.2	13.3	1,890.2	0.9	5.70	1	1	1
02/11/2015 02:00	1.2	13.4	1,837.4	0.9	5.50	1	1	1
02/11/2015 03:00	1.2	13.4	1,838.6	0.9	5.50	1	1	1
02/11/2015 04:00	1.2	13.4	1,840.4	0.9	5.50	1	1	1
02/11/2015 05:00	1.2	13.4	1,865.2	0.9	5.60	1	1	1
02/11/2015 06:00	1.3	13.2	1,910.6	1.0	7.60	1	1	1
02/11/2015 07:00	1.1	13.4	1,846.2	0.9	5.50	1	1	1
02/11/2015 08:00	1.2	13.4	1,834.3	0.9	5.50	1	1	1
02/11/2015 09:00	1.2	13.4	1,837.9	0.9	5.50	1	1	1
02/11/2015 10:00	1.0	13.7	1,588.8	0.8	4.80	1	1	1
02/11/2015 11:00	0.9	13.9	1,449.6	0.8	4.30	1	1	0
02/11/2015 12:00	1.0	13.9	1,495.6	0.8	4.50	1	1	0
02/11/2015 13:00	0.8	14.0	1,292.2	0.7	3.90	1	1	0
02/11/2015 14:00	0.8	14.0	1,294.4	0.7	3.90	1	1	0
02/11/2015 15:00	0.9	13.7	1,552.7	0.7	4.70	1	1	1
02/11/2015 16:00	1.2	13.3	1,886.1	0.9	5.70	1	1	1
02/11/2015 17:00	1.3	13.1	1,933.6	1.0	7.70	1	1	1
02/11/2015 18:00	1.5	12.7	2,024.5	1.1	8.10	1	1	1
02/11/2015 19:00	1.5	12.8	1,990.0	1.1	8.00	1	1	1
02/11/2015 20:00	1.4	12.8	1,997.0	1.0	8.00	1	1	1
02/11/2015 21:00	1.4	13.0	1,960.1	1.0	7.80	1	1	1
02/11/2015 22:00	1.4	13.0	1,970.0	1.0	7.90	1	1	1
02/11/2015 23:00	1.1	13.4	1,858.5	0.9	5.60	1	1	1
Average/Sum#:	1.2	13.4	1,791.5	0.9	144.80 #	24 #	24 #	20 #
Minimum:	0.8	12.7	1,292.2	0.7	3.90	1	1	0
Maximum:	1.5	14.0	2,024.5	1.1	8.10	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/12/2015 00:00	0.9	13.8	1,413.0	0.7	4.20	1	1	1
02/12/2015 01:00	0.9	13.9	1,367.9	0.8	4.10	1	1	0
02/12/2015 02:00	0.8	13.9	1,301.9	0.7	2.60	1	1	0
02/12/2015 03:00	0.9	13.9	1,479.6	0.8	4.40	1	1	0
02/12/2015 04:00	1.0	13.7	1,596.7	0.8	4.80	1	1	1
02/12/2015 05:00	1.3	13.1	1,928.2	1.0	7.70	1	1	1
02/12/2015 06:00	1.3	13.2	1,912.4	1.0	7.60	1	1	1
02/12/2015 07:00	1.4	13.0	1,915.9	1.0	7.70	1	1	1
02/12/2015 08:00	1.0	13.7	1,559.6	0.8	4.70	1	1	1
02/12/2015 09:00	0.8	13.9	1,290.2	0.7	2.60	1	1	0
02/12/2015 10:00	0.8	13.9	1,290.3	0.7	2.60	1	1	0
02/12/2015 11:00	0.8	13.9	1,291.1	0.7	2.60	1	1	0
02/12/2015 12:00	0.8	13.9	1,294.8	0.7	2.60	1	1	0
02/12/2015 13:00	1.1	13.8	1,673.8	0.9	5.00	1	1	1
02/12/2015 14:00	1.5	12.7	1,991.9	1.1	8.00	1	1	1
02/12/2015 15:00	1.2	13.1	1,885.8	0.9	5.70	1	1	1
02/12/2015 16:00	1.3	13.0	1,921.0	1.0	7.70	1	1	1
02/12/2015 17:00	1.5	12.8	1,970.2	1.1	7.90	1	1	1
02/12/2015 18:00	1.5	12.5	2,036.2	1.1	8.10	1	1	1
02/12/2015 19:00	1.5	12.5	2,047.8	1.1	8.20	1	1	1
02/12/2015 20:00	1.5	12.6	2,032.6	1.1	8.10	1	1	1
02/12/2015 21:00	1.4	13.0	1,960.1	1.0	7.80	1	1	1
02/12/2015 22:00	1.4	12.8	1,996.9	1.0	8.00	1	1	1
02/12/2015 23:00	1.0	13.8	1,631.1	0.8	4.90	1	1	1
Average/Sum#:	1.2	13.4	1,699.5	0.9	137.60 #	24 #	24 #	17 #
Minimum:	0.8	12.5	1,290.2	0.7	2.60	1	1	0
Maximum:	1.5	13.9	2,047.8	1.1	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/13/2015 00:00	1.1	13.9	1,729.9	0.9	5.20	1	1	0
02/13/2015 01:00	0.9	13.9	1,483.7	0.8	4.50	1	1	0
02/13/2015 02:00	0.9	13.9	1,475.9	0.8	4.40	1	1	0
02/13/2015 03:00	1.1	13.9	1,747.9	0.9	5.20	1	1	0
02/13/2015 04:00	1.0	13.9	1,555.2	0.8	4.70	1	1	0
02/13/2015 05:00	0.9	13.8	1,575.5	0.7	4.70	1	1	1
02/13/2015 06:00	1.3	13.3	1,906.9	1.0	7.60	1	1	1
02/13/2015 07:00	1.3	13.3	1,879.7	1.0	7.50	1	1	1
02/13/2015 08:00	0.9	13.8	1,462.7	0.7	4.40	1	1	1
02/13/2015 09:00	0.8	13.9	1,294.8	0.7	2.60	1	1	0
02/13/2015 10:00	0.8	13.9	1,295.0	0.7	2.60	1	1	0
02/13/2015 11:00	0.8	13.9	1,301.9	0.7	2.60	1	1	0
02/13/2015 12:00	0.9	13.9	1,400.6	0.8	4.20	1	1	0
02/13/2015 13:00	1.0	13.8	1,653.1	0.8	5.00	1	1	1
02/13/2015 14:00	1.2	13.3	1,878.2	0.9	5.60	1	1	1
02/13/2015 15:00	1.0	13.4	1,851.4	0.8	5.60	1	1	1
02/13/2015 16:00	1.2	13.3	1,875.7	0.9	5.60	1	1	1
02/13/2015 17:00	1.3	13.0	1,933.9	1.0	7.70	1	1	1
02/13/2015 18:00	1.5	12.7	2,006.9	1.1	8.00	1	1	1
02/13/2015 19:00	1.5	12.5	2,042.2	1.1	8.20	1	1	1
02/13/2015 20:00	1.5	12.6	2,024.0	1.1	8.10	1	1	1
02/13/2015 21:00	1.5	12.8	1,999.2	1.1	8.00	1	1	1
02/13/2015 22:00	1.5	12.7	2,018.2	1.1	8.10	1	1	1
02/13/2015 23:00	1.3	13.2	1,902.4	1.0	7.60	1	1	1
Average/Sum#:	1.1	13.4	1,720.6	0.9	137.70 #	24 #	24 #	15 #
Minimum:	0.8	12.5	1,294.8	0.7	2.60	1	1	0
Maximum:	1.5	13.9	2,042.2	1.1	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/14/2015 00:00	1.4	12.9	1,983.2	1.0	7.90	1	1	1
02/14/2015 01:00	1.4	13.0	1,957.7	1.0	7.80	1	1	1
02/14/2015 02:00	1.4	12.9	1,973.7	1.0	7.90	1	1	1
02/14/2015 03:00	1.4	12.9	1,973.8	1.0	7.90	1	1	1
02/14/2015 04:00	1.4	13.0	1,963.6	1.0	7.90	1	1	1
02/14/2015 05:00	1.1	13.4	1,843.0	0.9	5.50	1	1	1
02/14/2015 06:00	0.9	13.8	1,493.9	0.7	4.50	1	1	1
02/14/2015 07:00	0.7	13.9	1,308.4	0.6	2.60	1	1	0
02/14/2015 08:00	0.8	13.9	1,297.8	0.7	2.60	1	1	0
02/14/2015 09:00	0.7	13.9	1,309.0	0.6	2.60	1	1	0
02/14/2015 10:00	0.8	13.9	1,302.9	0.7	2.60	1	1	0
02/14/2015 11:00	0.8	14.0	1,298.7	0.7	3.90	1	1	0
02/14/2015 12:00	0.8	14.0	1,299.1	0.7	3.90	1	1	0
02/14/2015 13:00	0.8	14.0	1,298.0	0.7	3.90	1	1	0
02/14/2015 14:00	0.8	14.0	1,295.9	0.7	3.90	1	1	0
02/14/2015 15:00	0.8	14.0	1,293.8	0.7	3.90	1	1	0
02/14/2015 16:00	1.0	13.5	1,559.5	0.8	4.70	1	1	1
02/14/2015 17:00	1.3	13.1	1,892.2	1.0	7.60	1	1	1
02/14/2015 18:00	1.2	13.1	1,893.2	0.9	5.70	1	1	1
02/14/2015 19:00	1.5	12.5	2,038.9	1.1	8.20	1	1	1
02/14/2015 20:00	1.3	13.0	1,936.5	1.0	7.70	1	1	1
02/14/2015 21:00	1.3	13.1	1,923.0	1.0	7.70	1	1	1
02/14/2015 22:00	1.4	12.8	1,975.3	1.0	7.90	1	1	1
02/14/2015 23:00	0.9	13.9	1,427.9	0.8	4.30	1	1	1
Average/Sum#:	1.1	13.4	1,647.5	0.8	133.10 #	24 #	24 #	15 #
Minimum:	0.7	12.5	1,293.8	0.6	2.60	1	1	0
Maximum:	1.5	14.0	2,038.9	1.1	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/15/2015 00:00	0.9	14.0	1,391.6	0.8	4.20	1	1	0
02/15/2015 01:00	0.9	13.9	1,456.7	0.8	4.40	1	1	0
02/15/2015 02:00	5.2	16.4	392.0	6.8	1.67	1	0	0
02/15/2015 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2015 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2015 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2015 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2015 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2015 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2015 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2015 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2015 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2015 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2015 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2015 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2015 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2015 16:00	15.6	18.1	386.6	32.9	14.04	1	0	0
02/15/2015 17:00	20.7	14.9	1,052.3	20.4	78.90	1	0	0
02/15/2015 18:00	0.7	14.0	1,444.1	0.6	2.90	1	1	0
02/15/2015 19:00	1.4	13.0	1,933.7	1.0	7.70	1	1	1
02/15/2015 20:00	1.4	12.7	1,987.8	1.0	8.00	1	1	1
02/15/2015 21:00	1.4	12.9	1,972.7	1.0	7.90	1	1	1
02/15/2015 22:00	1.5	12.9	1,971.8	1.1	7.90	1	1	1
02/15/2015 23:00	1.5	12.9	1,971.0	1.1	7.90	1	1	1
Average/Sum#:	4.7	14.2	1,450.9	6.1	145.51 #	11 #	8 #	5 #
Minimum:	0.7	12.7	386.6	0.6	1.67	0	0	0
Maximum:	20.7	18.1	1,987.8	32.9	78.90	1	1	1
%SI	54.2	54.2	54.2	54.2	54.17	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/16/2015 00:00	1.4	12.9	1,981.1	1.0	7.90	1	1	1
02/16/2015 01:00	1.3	13.2	1,910.4	1.0	7.60	1	1	1
02/16/2015 02:00	1.2	13.4	1,849.6	0.9	5.50	1	1	1
02/16/2015 03:00	1.2	13.4	1,851.4	0.9	5.60	1	1	1
02/16/2015 04:00	1.2	13.4	1,852.5	0.9	5.60	1	1	1
02/16/2015 05:00	1.3	13.3	1,882.9	1.0	7.50	1	1	1
02/16/2015 06:00	1.3	13.3	1,901.1	1.0	7.60	1	1	1
02/16/2015 07:00	1.2	13.4	1,834.3	0.9	5.50	1	1	1
02/16/2015 08:00	1.2	13.5	1,836.6	1.0	7.30	1	1	1
02/16/2015 09:00	1.2	13.5	1,846.7	1.0	7.40	1	1	1
02/16/2015 10:00	1.1	13.5	1,858.7	0.9	5.60	1	1	1
02/16/2015 11:00	1.1	13.4	1,857.5	0.9	5.60	1	1	1
02/16/2015 12:00	1.1	13.4	1,854.0	0.9	5.60	1	1	1
02/16/2015 13:00	1.0	13.6	1,558.2	0.8	4.70	1	1	1
02/16/2015 14:00	0.8	14.0	1,285.9	0.7	3.90	1	1	0
02/16/2015 15:00	1.0	13.7	1,544.6	0.8	4.60	1	1	1
02/16/2015 16:00	1.3	13.1	1,892.1	1.0	7.60	1	1	1
02/16/2015 17:00	1.4	12.9	1,943.1	1.0	7.80	1	1	1
02/16/2015 18:00	1.5	12.5	2,031.3	1.1	8.10	1	1	1
02/16/2015 19:00	1.5	12.6	2,021.1	1.1	8.10	1	1	1
02/16/2015 20:00	1.1	13.4	1,854.7	0.9	5.60	1	1	1
02/16/2015 21:00	1.2	13.3	1,884.0	0.9	5.70	1	1	1
02/16/2015 22:00	1.3	13.1	1,915.3	1.0	7.70	1	1	1
02/16/2015 23:00	1.1	13.5	1,854.1	0.9	5.60	1	1	1
Average/Sum#:	1.2	13.3	1,837.6	0.9	153.70 #	24 #	24 #	23 #
Minimum:	0.8	12.5	1,285.9	0.7	3.90	1	1	0
Maximum:	1.5	14.0	2,031.3	1.1	8.10	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/17/2015 00:00	1.1	13.4	1,852.3	0.9	5.60	1	1	1
02/17/2015 01:00	1.1	13.4	1,850.3	0.9	5.60	1	1	1
02/17/2015 02:00	1.1	13.4	1,851.7	0.9	5.60	1	1	1
02/17/2015 03:00	1.1	13.5	1,856.3	0.9	5.60	1	1	1
02/17/2015 04:00	1.1	13.5	1,860.3	0.9	5.60	1	1	1
02/17/2015 05:00	1.2	13.4	1,855.6	0.9	5.60	1	1	1
02/17/2015 06:00	1.2	13.4	1,874.9	0.9	5.60	1	1	1
02/17/2015 07:00	1.3	13.0	1,915.9	1.0	7.70	1	1	1
02/17/2015 08:00	1.1	13.4	1,842.0	0.9	5.50	1	1	1
02/17/2015 09:00	1.0	13.7	1,548.6	0.8	4.60	1	1	1
02/17/2015 10:00	0.9	13.9	1,410.7	0.8	4.20	1	1	0
02/17/2015 11:00	1.0	13.9	1,580.7	0.8	4.70	1	1	0
02/17/2015 12:00	0.9	13.9	1,557.7	0.8	4.70	1	1	0
02/17/2015 13:00	0.7	13.9	1,312.3	0.6	2.60	1	1	0
02/17/2015 14:00	0.7	13.9	1,288.7	0.6	2.60	1	1	0
02/17/2015 15:00	0.8	14.0	1,300.3	0.7	3.90	1	1	0
02/17/2015 16:00	1.0	13.6	1,605.7	0.8	4.80	1	1	1
02/17/2015 17:00	1.2	13.1	1,901.2	0.9	5.70	1	1	1
02/17/2015 18:00	1.5	12.6	2,014.9	1.1	8.10	1	1	1
02/17/2015 19:00	1.5	12.6	2,010.2	1.1	8.00	1	1	1
02/17/2015 20:00	1.4	12.9	1,964.7	1.0	7.90	1	1	1
02/17/2015 21:00	1.2	13.2	1,898.9	0.9	5.70	1	1	1
02/17/2015 22:00	1.3	13.1	1,830.3	1.0	7.30	1	1	1
02/17/2015 23:00	0.8	13.9	1,308.1	0.7	2.60	1	1	0
Average/Sum#:	1.1	13.4	1,720.5	0.9	129.80 #	24 #	24 #	17 #
Minimum:	0.7	12.6	1,288.7	0.6	2.60	1	1	0
Maximum:	1.5	14.0	2,014.9	1.1	8.10	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/18/2015 00:00	0.9	13.9	1,491.0	0.8	4.50	1	1	0
02/18/2015 01:00	1.0	13.9	1,518.4	0.8	4.60	1	1	0
02/18/2015 02:00	0.8	13.9	1,338.1	0.7	2.70	1	1	0
02/18/2015 03:00	0.8	13.9	1,307.4	0.7	2.60	1	1	0
02/18/2015 04:00	1.1	13.7	1,694.9	0.9	5.10	1	1	1
02/18/2015 05:00	1.2	13.3	1,882.0	0.9	5.60	1	1	1
02/18/2015 06:00	1.2	13.3	1,874.6	0.9	5.60	1	1	1
02/18/2015 07:00	1.3	13.1	1,947.5	1.0	7.80	1	1	1
02/18/2015 08:00	1.3	13.1	1,975.2	1.0	7.90	1	1	1
02/18/2015 09:00	1.4	13.0	1,989.3	1.0	8.00	1	1	1
02/18/2015 10:00	1.4	13.0	1,964.5	1.0	7.90	1	1	1
02/18/2015 11:00	1.1	13.4	1,844.4	0.9	5.50	1	1	1
02/18/2015 12:00	1.1	13.4	1,850.8	0.9	5.60	1	1	1
02/18/2015 13:00	1.1	13.4	1,852.8	0.9	5.60	1	1	1
02/18/2015 14:00	1.0	13.7	1,565.6	0.8	4.70	1	1	1
02/18/2015 15:00	1.0	13.9	1,658.5	0.8	5.00	1	1	0
02/18/2015 16:00	1.2	13.3	1,846.1	0.9	5.50	1	1	1
02/18/2015 17:00	1.4	12.8	1,996.7	1.0	8.00	1	1	1
02/18/2015 18:00	1.5	12.6	2,026.5	1.1	8.10	1	1	1
02/18/2015 19:00	1.4	12.8	1,993.3	1.0	8.00	1	1	1
02/18/2015 20:00	1.4	12.8	1,986.2	1.0	7.90	1	1	1
02/18/2015 21:00	1.4	12.9	1,974.4	1.0	7.90	1	1	1
02/18/2015 22:00	1.3	13.1	1,938.6	1.0	7.80	1	1	1
02/18/2015 23:00	1.2	13.3	1,865.1	0.9	5.60	1	1	1
Average/Sum#:	1.2	13.3	1,807.6	0.9	147.50 #	24 #	24 #	19 #
Minimum:	0.8	12.6	1,307.4	0.7	2.60	1	1	0
Maximum:	1.5	13.9	2,026.5	1.1	8.10	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/19/2015 00:00	1.4	13.0	1,961.5	1.0	7.80	1	1	1
02/19/2015 01:00	1.1	13.4	1,835.8	0.9	5.50	1	1	1
02/19/2015 02:00	0.8	13.8	1,428.3	0.7	2.90	1	1	1
02/19/2015 03:00	0.8	13.9	1,311.3	0.7	2.60	1	1	0
02/19/2015 04:00	0.8	13.8	1,435.3	0.7	2.90	1	1	1
02/19/2015 05:00	1.2	13.2	1,923.7	0.9	5.80	1	1	1
02/19/2015 06:00	1.3	13.1	1,940.7	1.0	7.80	1	1	1
02/19/2015 07:00	1.4	12.8	1,979.3	1.0	7.90	1	1	1
02/19/2015 08:00	1.4	12.9	1,985.2	1.0	7.90	1	1	1
02/19/2015 09:00	1.3	13.1	1,945.1	1.0	7.80	1	1	1
02/19/2015 10:00	1.4	12.7	2,021.8	1.0	8.10	1	1	1
02/19/2015 11:00	1.4	12.9	1,988.6	1.0	8.00	1	1	1
02/19/2015 12:00	1.3	13.0	1,942.3	1.0	7.80	1	1	1
02/19/2015 13:00	1.4	13.0	1,950.5	1.0	7.80	1	1	1
02/19/2015 14:00	1.0	13.4	1,852.5	0.8	5.60	1	1	1
02/19/2015 15:00	1.0	13.4	1,855.5	0.8	5.60	1	1	1
02/19/2015 16:00	1.1	13.3	1,870.0	0.9	5.60	1	1	1
02/19/2015 17:00	1.0	13.4	1,851.9	0.8	5.60	1	1	1
02/19/2015 18:00	1.3	13.0	1,939.2	1.0	7.80	1	1	1
02/19/2015 19:00	1.1	13.3	1,850.5	0.9	5.60	1	1	1
02/19/2015 20:00	1.0	13.4	1,843.1	0.8	5.50	1	1	1
02/19/2015 21:00	1.0	13.4	1,850.6	0.8	5.60	1	1	1
02/19/2015 22:00	1.1	13.3	1,881.9	0.9	5.60	1	1	1
02/19/2015 23:00	1.3	13.1	1,816.6	1.0	7.30	1	1	1
Average/Sum#:	1.2	13.2	1,844.2	0.9	150.40 #	24 #	24 #	23 #
Minimum:	0.8	12.7	1,311.3	0.7	2.60	1	1	0
Maximum:	1.4	13.9	2,021.8	1.0	8.10	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/20/2015 00:00	0.7	13.9	1,345.3	0.6	2.70	1	1	0
02/20/2015 01:00	3.6	15.9	571.2	4.2	2.09	1	0	0
02/20/2015 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2015 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2015 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2015 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2015 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2015 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2015 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2015 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2015 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2015 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2015 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2015 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2015 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2015 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2015 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2015 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2015 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2015 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2015 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2015 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2015 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/20/2015 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	2.2	14.9	958.3	2.4	4.79 #	2 #	1 #	0 #
Minimum:	0.7	13.9	571.2	0.6	2.09	0	0	0
Maximum:	3.6	15.9	1,345.3	4.2	2.70	1	1	0
%SI	91.7	91.7	91.7	91.7	91.67	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/21/2015 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2015 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2015 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2015 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2015 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2015 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2015 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2015 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2015 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2015 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2015 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2015 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2015 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2015 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2015 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/21/2015 15:00	26.2	17.4	509.5	44.2	55.61	1	0	0
02/21/2015 16:00	13.0	14.8	1,042.1	12.6	47.90	1	0	0
02/21/2015 17:00	0.7	13.8	1,506.1	0.6	3.00	1	1	1
02/21/2015 18:00	1.3	12.8	1,973.2	0.9	5.90	1	1	1
02/21/2015 19:00	1.5	12.6	2,022.8	1.1	8.10	1	1	1
02/21/2015 20:00	1.5	12.7	2,019.2	1.1	8.10	1	1	1
02/21/2015 21:00	1.4	12.9	1,984.1	1.0	7.90	1	1	1
02/21/2015 22:00	1.5	12.8	2,031.9	1.1	8.10	1	1	1
02/21/2015 23:00	1.3	13.1	1,943.6	1.0	7.80	1	1	1
Average/Sum#:	5.4	13.7	1,670.3	7.1	152.41 #	9 #	7 #	7 #
Minimum:	0.7	12.6	509.5	0.6	3.00	0	0	0
Maximum:	26.2	17.4	2,031.9	44.2	55.61	1	1	1
%SI	62.5	62.5	62.5	62.5	62.50	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/22/2015 00:00	0.9	14.0	1,401.2	0.8	4.20	1	1	0
02/22/2015 01:00	1.0	13.9	1,549.0	0.8	4.60	1	1	0
02/22/2015 02:00	0.8	14.0	1,293.0	0.7	3.90	1	1	0
02/22/2015 03:00	0.8	14.0	1,342.6	0.7	4.00	1	1	0
02/22/2015 04:00	1.1	14.0	1,584.9	0.9	4.80	1	1	0
02/22/2015 05:00	1.0	14.0	1,500.5	0.9	4.50	1	1	0
02/22/2015 06:00	6.3	16.5	403.5	8.4	2.25	1	0	0
02/22/2015 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2015 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2015 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2015 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2015 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2015 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2015 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2015 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2015 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2015 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2015 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2015 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2015 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2015 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2015 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2015 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2015 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.7	14.3	1,296.4	1.9	28.25 #	7 #	6 #	0 #
Minimum:	0.8	13.9	403.5	0.7	2.25	0	0	0
Maximum:	6.3	16.5	1,584.9	8.4	4.80	1	1	0
%SI	70.8	70.8	70.8	70.8	70.83	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/23/2015 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2015 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/24/2015 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/24/2015 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/24/2015 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/24/2015 03:00	26.4	17.8	457.8	50.2	49.13	1	0	0
02/24/2015 04:00	27.2	15.8	718.2	31.5	83.30	1	0	0
02/24/2015 05:00	11.7	13.7	1,613.7	9.6	56.50	1	0	1
02/24/2015 06:00	1.4	12.9	2,017.2	1.0	8.10	1	1	1
02/24/2015 07:00	1.4	13.0	2,012.0	1.0	8.00	1	1	1
02/24/2015 08:00	1.3	13.2	1,960.4	1.0	7.80	1	1	1
02/24/2015 09:00	1.1	13.7	1,558.6	0.9	4.70	1	1	1
02/24/2015 10:00	0.9	14.0	1,325.8	0.8	4.00	1	1	0
02/24/2015 11:00	1.0	14.0	1,293.5	0.9	3.90	1	1	0
02/24/2015 12:00	1.0	14.0	1,292.0	0.9	3.90	1	1	0
02/24/2015 13:00	1.0	14.0	1,289.1	0.9	3.90	1	1	0
02/24/2015 14:00	1.0	14.0	1,310.1	0.9	3.90	1	1	0
02/24/2015 15:00	1.0	14.0	1,364.1	0.9	4.10	1	1	0
02/24/2015 16:00	1.0	13.8	1,477.7	0.8	4.40	1	1	1
02/24/2015 17:00	1.4	12.9	1,969.0	1.0	7.90	1	1	1
02/24/2015 18:00	1.4	12.7	2,015.2	1.0	8.10	1	1	1
02/24/2015 19:00	1.4	12.8	2,012.3	1.0	8.00	1	1	1
02/24/2015 20:00	1.4	12.8	2,018.9	1.0	8.10	1	1	1
02/24/2015 21:00	1.4	12.9	2,024.7	1.0	8.10	1	1	1
02/24/2015 22:00	1.3	13.3	1,820.3	1.0	7.30	1	1	1
02/24/2015 23:00	0.9	14.0	1,489.8	0.8	4.50	1	1	0
Average/Sum#:	4.1	13.8	1,573.4	5.1	297.63 #	21 #	18 #	12 #
Minimum:	0.9	12.7	457.8	0.8	3.90	0	0	0
Maximum:	27.2	17.8	2,024.7	50.2	83.30	1	1	1
%SI	12.5	12.5	12.5	12.5	12.50	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/25/2015 00:00	0.9	13.9	1,301.2	0.8	3.90	1	1	0
02/25/2015 01:00	1.1	14.0	1,754.7	0.9	5.30	1	1	0
02/25/2015 02:00	1.1	13.9	1,735.6	0.9	5.20	1	1	0
02/25/2015 03:00	0.9	13.9	1,442.5	0.8	4.30	1	1	0
02/25/2015 04:00	0.9	13.9	1,287.6	0.8	3.90	1	1	0
02/25/2015 05:00	1.1	13.6	1,632.5	0.9	4.90	1	1	1
02/25/2015 06:00	1.4	13.1	1,991.4	1.1	8.00	1	1	1
02/25/2015 07:00	1.4	13.1	1,971.7	1.1	7.90	1	1	1
02/25/2015 08:00	1.2	13.6	1,734.4	1.0	6.90	1	1	1
02/25/2015 09:00	0.9	13.9	1,307.2	0.8	3.90	1	1	0
02/25/2015 10:00	0.9	14.0	1,291.5	0.8	3.90	1	1	0
02/25/2015 11:00	0.9	14.0	1,292.1	0.8	3.90	1	1	0
02/25/2015 12:00	0.8	14.0	1,293.3	0.7	3.90	1	1	0
02/25/2015 13:00	0.9	14.0	1,410.7	0.8	4.20	1	1	0
02/25/2015 14:00	0.9	14.0	1,299.6	0.8	3.90	1	1	0
02/25/2015 15:00	0.9	14.0	1,292.8	0.8	3.90	1	1	0
02/25/2015 16:00	0.9	13.8	1,466.8	0.7	4.40	1	1	1
02/25/2015 17:00	1.4	12.9	1,956.1	1.0	7.80	1	1	1
02/25/2015 18:00	1.4	12.8	1,980.6	1.0	7.90	1	1	1
02/25/2015 19:00	1.4	13.1	1,916.9	1.1	7.70	1	1	1
02/25/2015 20:00	1.4	13.2	1,925.6	1.1	7.70	1	1	1
02/25/2015 21:00	1.4	13.0	1,975.8	1.0	7.90	1	1	1
02/25/2015 22:00	1.3	13.3	1,790.1	1.0	7.20	1	1	1
02/25/2015 23:00	0.9	14.0	1,440.6	0.8	4.30	1	1	0
Average/Sum#:	1.1	13.6	1,603.8	0.9	132.80 #	24 #	24 #	11 #
Minimum:	0.8	12.8	1,287.6	0.7	3.90	1	1	0
Maximum:	1.4	14.0	1,991.4	1.1	8.00	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/26/2015 00:00	0.8	14.0	1,288.7	0.7	3.90	1	1	0
02/26/2015 01:00	0.8	14.0	1,303.7	0.7	3.90	1	1	0
02/26/2015 02:00	1.2	13.8	1,754.7	1.0	7.00	1	1	0
02/26/2015 03:00	1.2	13.8	1,816.7	1.0	7.30	1	1	0
02/26/2015 04:00	1.1	13.7	1,760.9	0.9	5.30	1	1	1
02/26/2015 05:00	1.4	13.2	1,945.5	1.1	7.80	1	1	1
02/26/2015 06:00	1.4	13.2	1,958.0	1.1	7.80	1	1	1
02/26/2015 07:00	1.4	13.0	1,969.6	1.0	7.90	1	1	1
02/26/2015 08:00	1.2	13.5	1,626.7	1.0	6.50	1	1	1
02/26/2015 09:00	0.9	14.0	1,374.8	0.8	4.10	1	1	0
02/26/2015 10:00	1.0	14.0	1,677.5	0.9	5.00	1	1	0
02/26/2015 11:00	1.1	13.9	1,699.9	0.9	5.10	1	1	0
02/26/2015 12:00	0.8	14.1	1,314.0	0.7	3.90	1	1	0
02/26/2015 13:00	0.8	14.0	1,289.8	0.7	3.90	1	1	0
02/26/2015 14:00	0.8	14.0	1,290.9	0.7	3.90	1	1	0
02/26/2015 15:00	0.9	14.0	1,477.3	0.8	4.40	1	1	0
02/26/2015 16:00	1.2	13.2	1,789.9	0.9	5.40	1	1	1
02/26/2015 17:00	1.5	12.9	1,956.0	1.1	7.80	1	1	1
02/26/2015 18:00	1.5	12.5	2,032.6	1.1	8.10	1	1	1
02/26/2015 19:00	1.5	12.5	2,029.8	1.1	8.10	1	1	1
02/26/2015 20:00	1.5	12.7	1,997.6	1.1	8.00	1	1	1
02/26/2015 21:00	1.5	12.8	1,981.9	1.1	7.90	1	1	1
02/26/2015 22:00	1.0	13.6	1,576.2	0.8	4.70	1	1	1
02/26/2015 23:00	0.7	14.0	1,286.8	0.6	2.60	1	1	0
Average/Sum#:	1.1	13.5	1,675.0	0.9	140.30 #	24 #	24 #	12 #
Minimum:	0.7	12.5	1,286.8	0.6	2.60	1	1	0
Maximum:	1.5	14.1	2,032.6	1.1	8.10	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/27/2015 00:00	1.1	13.8	1,715.6	0.9	5.10	1	1	0
02/27/2015 01:00	1.2	13.8	1,787.0	1.0	7.10	1	1	0
02/27/2015 02:00	1.2	13.8	1,767.6	1.0	7.10	1	1	0
02/27/2015 03:00	0.9	13.9	1,499.4	0.8	4.50	1	1	0
02/27/2015 04:00	0.7	14.0	1,287.7	0.6	2.60	1	1	0
02/27/2015 05:00	0.9	13.8	1,472.7	0.7	4.40	1	1	1
02/27/2015 06:00	1.4	13.0	1,991.1	1.0	8.00	1	1	1
02/27/2015 07:00	1.3	13.0	1,800.5	1.0	7.20	1	1	1
02/27/2015 08:00	0.7	14.0	1,304.2	0.6	2.60	1	1	0
02/27/2015 09:00	0.7	14.0	1,285.3	0.6	2.60	1	1	0
02/27/2015 10:00	0.8	14.0	1,291.0	0.7	3.90	1	1	0
02/27/2015 11:00	0.9	13.9	1,487.1	0.8	4.50	1	1	0
02/27/2015 12:00	0.7	14.0	1,288.7	0.6	2.60	1	1	0
02/27/2015 13:00	0.7	14.0	1,289.8	0.6	2.60	1	1	0
02/27/2015 14:00	0.8	14.0	1,285.2	0.7	3.90	1	1	0
02/27/2015 15:00	0.8	14.1	1,352.5	0.7	4.10	1	1	0
02/27/2015 16:00	0.9	14.0	1,448.8	0.8	4.30	1	1	0
02/27/2015 17:00	1.1	13.4	1,658.6	0.9	5.00	1	1	1
02/27/2015 18:00	1.5	12.6	2,050.2	1.1	8.20	1	1	1
02/27/2015 19:00	1.5	12.6	2,048.8	1.1	8.20	1	1	1
02/27/2015 20:00	1.5	12.7	2,050.2	1.1	8.20	1	1	1
02/27/2015 21:00	1.5	12.7	2,040.1	1.1	8.20	1	1	1
02/27/2015 22:00	1.5	12.8	2,022.8	1.1	8.10	1	1	1
02/27/2015 23:00	1.1	13.6	1,587.2	0.9	4.80	1	1	1
Average/Sum#:	1.1	13.6	1,617.2	0.9	127.80 #	24 #	24 #	10 #
Minimum:	0.7	12.6	1,285.2	0.6	2.60	1	1	0
Maximum:	1.5	14.1	2,050.2	1.1	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/28/2015 00:00	0.8	14.0	1,285.3	0.7	3.90	1	1	0
02/28/2015 01:00	4.2	15.9	572.0	5.0	2.27	1	0	0
02/28/2015 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2015 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2015 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2015 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2015 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2015 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/28/2015 08:00	10.4	16.9	566.9	15.3	22.61	1	0	0
02/28/2015 09:00	8.6	14.5	1,155.7	7.9	33.50	1	0	0
02/28/2015 10:00	0.9	13.9	1,610.8	0.8	4.80	1	1	0
02/28/2015 11:00	1.2	13.8	1,819.7	1.0	7.30	1	1	0
02/28/2015 12:00	0.9	13.9	1,591.4	0.8	4.80	1	1	0
02/28/2015 13:00	0.8	14.0	1,519.6	0.7	4.60	1	1	0
02/28/2015 14:00	1.3	13.8	1,785.2	1.1	7.10	1	1	0
02/28/2015 15:00	0.9	14.0	1,577.6	0.8	4.70	1	1	0
02/28/2015 16:00	1.0	13.7	1,584.1	0.8	4.80	1	1	1
02/28/2015 17:00	1.4	12.8	2,008.3	1.0	8.00	1	1	1
02/28/2015 18:00	1.5	12.7	2,030.8	1.1	8.10	1	1	1
02/28/2015 19:00	1.5	12.8	2,031.6	1.1	8.10	1	1	1
02/28/2015 20:00	1.5	12.8	2,038.1	1.1	8.20	1	1	1
02/28/2015 21:00	1.5	12.8	2,035.5	1.1	8.10	1	1	1
02/28/2015 22:00	1.5	12.8	2,036.7	1.1	8.10	1	1	1
02/28/2015 23:00	1.4	12.9	2,011.2	1.0	8.00	1	1	1
Average/Sum#:	2.3	13.8	1,625.6	2.4	156.98 #	18 #	15 #	8 #
Minimum:	0.8	12.7	566.9	0.7	2.27	0	0	0
Maximum:	10.4	16.9	2,038.1	15.3	33.50	1	1	1
%SI	25.0	25.0	25.0	25.0	25.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/01/2015 00:00	1.4	13.0	1,991.7	1.0	8.00	1	1	1
03/01/2015 01:00	1.3	13.5	1,858.2	1.0	7.40	1	1	1
03/01/2015 02:00	1.0	14.0	1,587.3	0.9	4.80	1	1	0
03/01/2015 03:00	1.0	14.0	1,665.9	0.9	5.00	1	1	0
03/01/2015 04:00	0.8	14.0	1,379.1	0.7	4.10	1	1	0
03/01/2015 05:00	1.2	13.9	1,745.9	1.0	7.00	1	1	0
03/01/2015 06:00	1.2	13.9	1,794.8	1.0	7.20	1	1	0
03/01/2015 07:00	1.3	13.8	1,835.0	1.1	7.30	1	1	0
03/01/2015 08:00	1.3	13.4	1,881.7	1.0	7.50	1	1	1
03/01/2015 09:00	1.5	12.8	2,040.1	1.1	8.20	1	1	1
03/01/2015 10:00	1.5	12.8	2,044.9	1.1	8.20	1	1	1
03/01/2015 11:00	1.5	12.7	2,050.5	1.1	8.20	1	1	1
03/01/2015 12:00	1.5	12.7	2,053.3	1.1	8.20	1	1	1
03/01/2015 13:00	1.4	13.0	1,986.5	1.0	7.90	1	1	1
03/01/2015 14:00	1.4	12.8	2,025.9	1.0	8.10	1	1	1
03/01/2015 15:00	1.5	12.6	2,053.6	1.1	8.20	1	1	1
03/01/2015 16:00	1.5	12.7	2,026.6	1.1	8.10	1	1	1
03/01/2015 17:00	1.5	12.6	2,053.2	1.1	8.20	1	1	1
03/01/2015 18:00	1.5	12.6	2,053.4	1.1	8.20	1	1	1
03/01/2015 19:00	1.5	12.7	2,052.5	1.1	8.20	1	1	1
03/01/2015 20:00	1.5	12.7	2,053.0	1.1	8.20	1	1	1
03/01/2015 21:00	1.5	12.7	2,052.7	1.1	8.20	1	1	1
03/01/2015 22:00	1.4	12.8	2,035.8	1.0	8.10	1	1	1
03/01/2015 23:00	1.4	13.0	1,993.3	1.0	8.00	1	1	1
Average/Sum#:	1.4	13.1	1,929.8	1.0	180.50 #	24 #	24 #	18 #
Minimum:	0.8	12.6	1,379.1	0.7	4.10	1	1	0
Maximum:	1.5	14.0	2,053.6	1.1	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/02/2015 00:00	1.4	12.9	2,009.0	1.0	8.00	1	1	1
03/02/2015 01:00	1.5	12.8	2,026.3	1.1	8.10	1	1	1
03/02/2015 02:00	1.4	13.0	1,996.9	1.0	8.00	1	1	1
03/02/2015 03:00	1.3	13.3	1,941.6	1.0	7.80	1	1	1
03/02/2015 04:00	1.1	13.6	1,816.0	0.9	5.40	1	1	1
03/02/2015 05:00	1.3	13.1	1,977.4	1.0	7.90	1	1	1
03/02/2015 06:00	1.4	13.0	2,000.8	1.0	8.00	1	1	1
03/02/2015 07:00	1.4	12.8	2,029.4	1.0	8.10	1	1	1
03/02/2015 08:00	1.4	12.9	2,008.5	1.0	8.00	1	1	1
03/02/2015 09:00	1.4	12.9	2,013.8	1.0	8.10	1	1	1
03/02/2015 10:00	1.4	13.0	2,006.3	1.0	8.00	1	1	1
03/02/2015 11:00	1.4	13.0	1,978.5	1.0	7.90	1	1	1
03/02/2015 12:00	1.4	12.9	2,004.4	1.0	8.00	1	1	1
03/02/2015 13:00	1.4	12.9	1,992.8	1.0	8.00	1	1	1
03/02/2015 14:00	1.2	13.6	1,699.2	1.0	6.80	1	1	1
03/02/2015 15:00	1.0	13.9	1,616.8	0.8	4.90	1	1	0
03/02/2015 16:00	1.2	13.5	1,823.6	1.0	7.30	1	1	1
03/02/2015 17:00	1.4	13.3	1,927.3	1.1	7.70	1	1	1
03/02/2015 18:00	1.4	13.3	1,932.6	1.1	7.70	1	1	1
03/02/2015 19:00	1.4	13.3	1,936.3	1.1	7.70	1	1	1
03/02/2015 20:00	1.4	13.3	1,942.8	1.1	7.80	1	1	1
03/02/2015 21:00	1.4	13.3	1,943.3	1.1	7.80	1	1	1
03/02/2015 22:00	1.3	13.5	1,801.7	1.0	7.20	1	1	1
03/02/2015 23:00	0.9	13.9	1,545.1	0.8	4.60	1	1	0
Average/Sum#:	1.3	13.2	1,915.4	1.0	178.80 #	24 #	24 #	22 #
Minimum:	0.9	12.8	1,545.1	0.8	4.60	1	1	0
Maximum:	1.5	13.9	2,029.4	1.1	8.10	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/03/2015 00:00	0.8	13.9	1,288.7	0.7	2.60	1	1	0
03/03/2015 01:00	0.8	13.9	1,289.4	0.7	2.60	1	1	0
03/03/2015 02:00	0.8	13.9	1,292.2	0.7	2.60	1	1	0
03/03/2015 03:00	0.8	13.9	1,294.3	0.7	2.60	1	1	0
03/03/2015 04:00	1.0	13.7	1,562.2	0.8	4.70	1	1	1
03/03/2015 05:00	1.3	13.1	1,989.1	1.0	8.00	1	1	1
03/03/2015 06:00	1.4	12.9	2,026.0	1.0	8.10	1	1	1
03/03/2015 07:00	1.4	13.0	1,981.8	1.0	7.90	1	1	1
03/03/2015 08:00	1.0	13.7	1,594.7	0.8	4.80	1	1	1
03/03/2015 09:00	0.8	14.0	1,290.8	0.7	3.90	1	1	0
03/03/2015 10:00	0.8	14.0	1,293.1	0.7	3.90	1	1	0
03/03/2015 11:00	0.8	14.0	1,293.5	0.7	3.90	1	1	0
03/03/2015 12:00	0.8	14.0	1,296.6	0.7	3.90	1	1	0
03/03/2015 13:00	0.8	14.0	1,298.0	0.7	3.90	1	1	0
03/03/2015 14:00	0.8	14.0	1,292.8	0.7	3.90	1	1	0
03/03/2015 15:00	0.8	14.0	1,292.4	0.7	3.90	1	1	0
03/03/2015 16:00	0.9	13.9	1,406.7	0.8	4.20	1	1	1
03/03/2015 17:00	1.4	13.2	1,938.6	1.1	7.80	1	1	1
03/03/2015 18:00	1.5	12.9	2,010.7	1.1	8.00	1	1	1
03/03/2015 19:00	1.5	12.7	2,055.8	1.1	8.20	1	1	1
03/03/2015 20:00	1.5	12.7	2,049.7	1.1	8.20	1	1	1
03/03/2015 21:00	1.5	12.7	2,049.8	1.1	8.20	1	1	1
03/03/2015 22:00	1.4	12.9	2,011.7	1.0	8.00	1	1	1
03/03/2015 23:00	1.2	13.6	1,718.2	1.0	6.90	1	1	1
Average/Sum#:	1.1	13.5	1,609.0	0.9	130.70 #	24 #	24 #	13 #
Minimum:	0.8	12.7	1,288.7	0.7	2.60	1	1	0
Maximum:	1.5	14.0	2,055.8	1.1	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/04/2015 00:00	1.1	13.9	1,813.5	0.9	5.40	1	1	0
03/04/2015 01:00	1.1	13.9	1,786.5	0.9	5.40	1	1	0
03/04/2015 02:00	1.0	14.1	1,736.5	0.9	5.20	1	1	0
03/04/2015 03:00	1.1	13.9	1,769.1	0.9	5.30	1	1	0
03/04/2015 04:00	1.2	13.5	1,819.7	1.0	7.30	1	1	1
03/04/2015 05:00	1.4	13.0	2,003.0	1.0	8.00	1	1	1
03/04/2015 06:00	1.4	13.0	2,006.0	1.0	8.00	1	1	1
03/04/2015 07:00	1.4	12.9	2,001.0	1.0	8.00	1	1	1
03/04/2015 08:00	1.3	13.1	1,977.6	1.0	7.90	1	1	1
03/04/2015 09:00	1.0	13.8	1,456.5	0.8	4.40	1	1	1
03/04/2015 10:00	0.8	14.0	1,292.8	0.7	3.90	1	1	0
03/04/2015 11:00	0.9	14.0	1,291.4	0.8	3.90	1	1	0
03/04/2015 12:00	0.9	14.0	1,290.1	0.8	3.90	1	1	0
03/04/2015 13:00	0.9	14.0	1,288.9	0.8	3.90	1	1	0
03/04/2015 14:00	0.9	14.0	1,289.0	0.8	3.90	1	1	0
03/04/2015 15:00	0.9	14.0	1,288.3	0.8	3.90	1	1	0
03/04/2015 16:00	1.1	13.7	1,545.9	0.9	4.60	1	1	1
03/04/2015 17:00	1.5	12.8	2,008.9	1.1	8.00	1	1	1
03/04/2015 18:00	1.5	12.7	2,031.5	1.1	8.10	1	1	1
03/04/2015 19:00	1.5	12.7	2,027.5	1.1	8.10	1	1	1
03/04/2015 20:00	1.5	12.8	2,026.1	1.1	8.10	1	1	1
03/04/2015 21:00	1.4	12.9	2,009.7	1.0	8.00	1	1	1
03/04/2015 22:00	1.4	13.0	2,013.6	1.0	8.10	1	1	1
03/04/2015 23:00	1.3	13.2	1,982.8	1.0	7.90	1	1	1
Average/Sum#:	1.2	13.5	1,739.8	0.9	149.20 #	24 #	24 #	14 #
Minimum:	0.8	12.7	1,288.3	0.7	3.90	1	1	0
Maximum:	1.5	14.1	2,031.5	1.1	8.10	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/05/2015 00:00	1.2	13.5	1,807.0	1.0	7.20	1	1	1
03/05/2015 01:00	1.0	13.9	1,591.2	0.8	4.80	1	1	0
03/05/2015 02:00	1.0	13.9	1,546.0	0.8	4.60	1	1	0
03/05/2015 03:00	1.0	13.9	1,632.9	0.8	4.90	1	1	0
03/05/2015 04:00	1.1	13.8	1,760.9	0.9	5.30	1	1	1
03/05/2015 05:00	1.3	13.1	1,991.2	1.0	8.00	1	1	1
03/05/2015 06:00	1.4	13.0	2,018.4	1.0	8.10	1	1	1
03/05/2015 07:00	1.4	13.1	2,015.3	1.1	8.10	1	1	1
03/05/2015 08:00	1.2	13.3	1,941.5	0.9	5.80	1	1	1
03/05/2015 09:00	0.8	13.8	1,455.1	0.7	2.76	1	1	1
03/05/2015 10:00	0.7	13.9	1,292.3	0.6	2.60	1	1	0
03/05/2015 11:00	0.8	14.0	1,292.4	0.7	3.90	1	1	0
03/05/2015 12:00	0.8	14.0	1,292.5	0.7	3.90	1	1	0
03/05/2015 13:00	0.9	14.0	1,293.4	0.8	3.90	1	1	0
03/05/2015 14:00	0.9	14.0	1,294.8	0.8	3.90	1	1	0
03/05/2015 15:00	0.8	14.0	1,295.6	0.7	3.90	1	1	0
03/05/2015 16:00	1.0	13.7	1,549.7	0.8	4.60	1	1	1
03/05/2015 17:00	1.5	12.6	2,023.1	1.1	8.10	1	1	1
03/05/2015 18:00	1.5	12.6	2,035.5	1.1	8.10	1	1	1
03/05/2015 19:00	1.5	12.6	2,031.7	1.1	8.10	1	1	1
03/05/2015 20:00	1.5	12.7	2,029.0	1.1	8.10	1	1	1
03/05/2015 21:00	1.5	12.7	2,018.7	1.1	8.10	1	1	1
03/05/2015 22:00	1.5	12.8	2,010.9	1.1	8.00	1	1	1
03/05/2015 23:00	1.2	13.4	1,745.1	0.9	5.20	1	1	1
Average/Sum#:	1.1	13.4	1,706.8	0.9	139.96 #	24 #	24 #	15 #
Minimum:	0.7	12.6	1,292.3	0.6	2.60	1	1	0
Maximum:	1.5	14.0	2,035.5	1.1	8.10	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/06/2015 00:00	0.8	13.9	1,294.5	0.7	2.60	1	1	0
03/06/2015 01:00	0.8	13.9	1,292.1	0.7	2.60	1	1	0
03/06/2015 02:00	0.8	13.9	1,290.3	0.7	2.60	1	1	0
03/06/2015 03:00	0.8	13.9	1,292.0	0.7	2.60	1	1	0
03/06/2015 04:00	0.8	13.9	1,293.1	0.7	2.60	1	1	0
03/06/2015 05:00	1.0	13.6	1,570.5	0.8	4.70	1	1	1
03/06/2015 06:00	1.3	13.1	1,994.1	1.0	8.00	1	1	1
03/06/2015 07:00	1.3	13.2	1,954.1	1.0	7.80	1	1	1
03/06/2015 08:00	1.2	13.3	1,941.3	0.9	5.80	1	1	1
03/06/2015 09:00	1.2	13.3	1,949.5	0.9	5.80	1	1	1
03/06/2015 10:00	1.1	13.6	1,612.8	0.9	4.80	1	1	1
03/06/2015 11:00	0.8	14.0	1,291.4	0.7	3.90	1	1	0
03/06/2015 12:00	0.8	14.0	1,292.6	0.7	3.90	1	1	0
03/06/2015 13:00	0.8	14.0	1,295.6	0.7	3.90	1	1	0
03/06/2015 14:00	0.8	14.0	1,298.0	0.7	3.90	1	1	0
03/06/2015 15:00	0.8	14.0	1,297.6	0.7	3.90	1	1	0
03/06/2015 16:00	1.0	13.7	1,535.8	0.8	4.60	1	1	1
03/06/2015 17:00	1.5	12.6	1,996.7	1.1	8.00	1	1	1
03/06/2015 18:00	1.5	12.4	2,042.2	1.0	8.20	1	1	1
03/06/2015 19:00	1.5	12.4	2,042.1	1.0	8.20	1	1	1
03/06/2015 20:00	1.5	12.5	2,038.0	1.1	8.20	1	1	1
03/06/2015 21:00	1.4	12.8	2,003.6	1.0	8.00	1	1	1
03/06/2015 22:00	1.4	12.8	2,009.9	1.0	8.00	1	1	1
03/06/2015 23:00	1.4	12.9	1,995.0	1.0	8.00	1	1	1
Average/Sum#:	1.1	13.4	1,651.0	0.9	130.60 #	24 #	24 #	14 #
Minimum:	0.8	12.4	1,290.3	0.7	2.60	1	1	0
Maximum:	1.5	14.0	2,042.2	1.1	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/07/2015 00:00	1.3	13.2	1,881.1	1.0	7.50	1	1	1
03/07/2015 01:00	1.2	13.8	1,727.7	1.0	6.90	1	1	0
03/07/2015 02:00	6.2	16.1	468.2	7.6	2.36	1	0	0
03/07/2015 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2015 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2015 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2015 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2015 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2015 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2015 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2015 10:00	15.1	16.8	573.4	21.7	32.13	1	0	0
03/07/2015 11:00	12.5	15.0	999.4	12.5	46.00	1	0	0
03/07/2015 12:00	1.2	13.9	1,751.8	1.0	7.00	1	1	0
03/07/2015 13:00	1.4	13.9	1,754.1	1.2	7.00	1	1	0
03/07/2015 14:00	1.3	13.9	1,686.5	1.1	6.70	1	1	0
03/07/2015 15:00	0.9	14.0	1,453.4	0.8	4.40	1	1	0
03/07/2015 16:00	1.2	13.5	1,700.8	1.0	6.80	1	1	1
03/07/2015 17:00	1.5	12.4	2,038.3	1.0	8.20	1	1	1
03/07/2015 18:00	1.5	12.5	2,011.2	1.1	8.00	1	1	1
03/07/2015 19:00	1.5	12.4	2,039.0	1.0	8.20	1	1	1
03/07/2015 20:00	1.5	12.5	2,037.5	1.1	8.20	1	1	1
03/07/2015 21:00	1.5	12.8	1,993.6	1.1	8.00	1	1	1
03/07/2015 22:00	1.4	12.9	1,993.2	1.0	8.00	1	1	1
03/07/2015 23:00	1.3	13.2	1,789.3	1.0	7.20	1	1	1
Average/Sum#:	3.1	13.7	1,641.1	3.3	182.59 #	17 #	14 #	9 #
Minimum:	0.9	12.4	468.2	0.8	2.36	0	0	0
Maximum:	15.1	16.8	2,039.0	21.7	46.00	1	1	1
%SI	29.2	29.2	29.2	29.2	29.17	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/08/2015 00:00	0.8	14.0	1,286.2	0.7	3.90	1	1	0
03/08/2015 01:00	0.8	14.0	1,286.3	0.7	3.90	1	1	0
03/08/2015 02:00	0.8	14.0	1,286.7	0.7	3.90	1	1	0
03/08/2015 03:00	0.8	14.0	1,287.3	0.7	3.90	1	1	0
03/08/2015 04:00	0.9	14.0	1,288.2	0.8	3.90	1	1	0
03/08/2015 05:00	0.9	14.0	1,288.0	0.8	3.90	1	1	0
03/08/2015 06:00	0.8	13.9	1,290.3	0.7	2.60	1	1	0
03/08/2015 07:00	0.9	13.9	1,290.6	0.8	3.90	1	1	0
03/08/2015 08:00	4.0	15.8	578.5	4.6	2.16	1	0	0
03/08/2015 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2015 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2015 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2015 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2015 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2015 14:00	0.0	21.0	0.2	0.0	0.00	1	0	0
03/08/2015 15:00	11.6	16.0	676.0	14.0	34.50	1	0	0
03/08/2015 16:00	6.1	14.0	1,295.4	5.2	24.60	1	0	0
03/08/2015 17:00	0.7	14.0	1,294.9	0.6	2.60	1	1	0
03/08/2015 18:00	1.2	13.4	1,691.0	0.9	5.10	1	1	1
03/08/2015 19:00	1.5	12.7	1,965.3	1.1	7.90	1	1	1
03/08/2015 20:00	1.4	13.0	1,853.8	1.0	7.40	1	1	1
03/08/2015 21:00	0.8	14.0	1,310.9	0.7	3.90	1	1	0
03/08/2015 22:00	0.8	14.0	1,288.3	0.7	3.90	1	1	0
03/08/2015 23:00	0.8	14.0	1,288.2	0.7	3.90	1	1	0
Average/Sum#:	1.9	14.4	1,239.3	1.9	125.86 #	19 #	15 #	3 #
Minimum:	0.0	12.7	0.2	0.0	0.00	0	0	0
Maximum:	11.6	21.0	1,965.3	14.0	34.50	1	1	1
%SI	20.8	20.8	20.8	20.8	20.83	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/09/2015 00:00	0.8	14.0	1,287.1	0.7	3.90	1	1	0
03/09/2015 01:00	0.8	14.0	1,285.9	0.7	3.90	1	1	0
03/09/2015 02:00	0.8	14.0	1,286.2	0.7	3.90	1	1	0
03/09/2015 03:00	0.8	14.0	1,285.0	0.7	3.90	1	1	0
03/09/2015 04:00	0.9	13.9	1,400.9	0.8	4.20	1	1	1
03/09/2015 05:00	1.4	12.9	1,995.2	1.0	8.00	1	1	1
03/09/2015 06:00	1.5	12.7	2,053.3	1.1	8.20	1	1	1
03/09/2015 07:00	1.3	13.0	1,970.0	1.0	7.90	1	1	1
03/09/2015 08:00	1.3	13.2	1,953.3	1.0	7.80	1	1	1
03/09/2015 09:00	0.8	13.9	1,331.1	0.7	2.70	1	1	1
03/09/2015 10:00	0.8	14.0	1,285.7	0.7	3.90	1	1	0
03/09/2015 11:00	0.8	14.0	1,285.7	0.7	3.90	1	1	0
03/09/2015 12:00	0.8	14.0	1,286.7	0.7	3.90	1	1	0
03/09/2015 13:00	0.8	14.0	1,293.4	0.7	3.90	1	1	0
03/09/2015 14:00	1.0	13.6	1,619.5	0.8	4.90	1	1	1
03/09/2015 15:00	0.8	14.0	1,285.8	0.7	3.90	1	1	0
03/09/2015 16:00	0.8	14.0	1,285.4	0.7	3.90	1	1	0
03/09/2015 17:00	1.1	13.2	1,727.0	0.8	5.20	1	1	1
03/09/2015 18:00	1.4	12.4	2,041.8	1.0	8.20	1	1	1
03/09/2015 19:00	1.4	12.5	2,041.9	1.0	8.20	1	1	1
03/09/2015 20:00	1.4	12.6	2,017.9	1.0	8.10	1	1	1
03/09/2015 21:00	1.3	12.9	1,958.2	1.0	7.80	1	1	1
03/09/2015 22:00	1.3	12.8	1,989.9	0.9	6.00	1	1	1
03/09/2015 23:00	1.3	13.0	1,946.8	1.0	7.80	1	1	1
Average/Sum#:	1.1	13.4	1,621.4	0.8	134.00 #	24 #	24 #	14 #
Minimum:	0.8	12.4	1,285.0	0.7	2.70	1	1	0
Maximum:	1.5	14.0	2,053.3	1.1	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/10/2015 00:00	1.3	13.1	1,926.2	1.0	7.70	1	1	1
03/10/2015 01:00	1.4	12.9	1,967.5	1.0	7.90	1	1	1
03/10/2015 02:00	1.4	13.2	1,914.9	1.1	7.70	1	1	1
03/10/2015 03:00	1.4	13.1	1,922.9	1.1	7.70	1	1	1
03/10/2015 04:00	1.4	13.1	1,954.1	1.1	7.80	1	1	1
03/10/2015 05:00	1.4	12.9	2,013.8	1.0	8.10	1	1	1
03/10/2015 06:00	1.4	12.8	2,046.4	1.0	8.20	1	1	1
03/10/2015 07:00	1.4	12.8	2,004.7	1.0	8.00	1	1	1
03/10/2015 08:00	1.2	13.4	1,800.6	0.9	5.40	1	1	1
03/10/2015 09:00	0.8	13.9	1,414.1	0.7	2.80	1	1	0
03/10/2015 10:00	0.7	13.9	1,288.2	0.6	2.60	1	1	0
03/10/2015 11:00	0.8	14.0	1,288.1	0.7	3.90	1	1	0
03/10/2015 12:00	0.8	14.0	1,288.5	0.7	3.90	1	1	0
03/10/2015 13:00	0.8	14.0	1,288.9	0.7	3.90	1	1	0
03/10/2015 14:00	0.8	14.0	1,289.3	0.7	3.90	1	1	0
03/10/2015 15:00	0.8	14.0	1,288.7	0.7	3.90	1	1	0
03/10/2015 16:00	0.9	13.9	1,398.9	0.8	4.20	1	1	1
03/10/2015 17:00	1.4	12.5	2,023.3	1.0	8.10	1	1	1
03/10/2015 18:00	1.5	12.5	2,033.7	1.1	8.10	1	1	1
03/10/2015 19:00	1.5	12.5	2,038.7	1.1	8.20	1	1	1
03/10/2015 20:00	1.5	12.5	2,035.7	1.1	8.10	1	1	1
03/10/2015 21:00	1.5	12.7	1,989.8	1.1	8.00	1	1	1
03/10/2015 22:00	1.1	13.4	1,671.8	0.9	5.00	1	1	1
03/10/2015 23:00	0.7	13.9	1,287.5	0.6	2.60	1	1	0
Average/Sum#:	1.2	13.3	1,715.7	0.9	145.70 #	24 #	24 #	16 #
Minimum:	0.7	12.5	1,287.5	0.6	2.60	1	1	0
Maximum:	1.5	14.0	2,046.4	1.1	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/11/2015 00:00	0.7	13.9	1,287.4	0.6	2.60	1	1	0
03/11/2015 01:00	0.7	13.9	1,288.6	0.6	2.60	1	1	0
03/11/2015 02:00	0.7	13.9	1,288.6	0.6	2.60	1	1	0
03/11/2015 03:00	0.8	14.0	1,288.3	0.7	3.90	1	1	0
03/11/2015 04:00	0.9	13.8	1,404.7	0.7	4.20	1	1	1
03/11/2015 05:00	1.3	13.2	1,936.8	1.0	7.70	1	1	1
03/11/2015 06:00	1.4	13.0	1,979.6	1.0	7.90	1	1	1
03/11/2015 07:00	1.3	12.7	2,047.5	0.9	6.10	1	1	1
03/11/2015 08:00	1.4	12.7	2,049.3	1.0	8.20	1	1	1
03/11/2015 09:00	1.4	12.7	2,044.5	1.0	8.20	1	1	1
03/11/2015 10:00	1.4	12.6	2,042.8	1.0	8.20	1	1	1
03/11/2015 11:00	1.3	12.6	2,044.1	0.9	6.10	1	1	1
03/11/2015 12:00	1.3	12.6	2,038.5	0.9	6.10	1	1	1
03/11/2015 13:00	1.3	12.6	2,044.8	0.9	6.10	1	1	1
03/11/2015 14:00	1.3	12.6	2,041.6	0.9	6.10	1	1	1
03/11/2015 15:00	1.3	12.6	2,043.3	0.9	6.10	1	1	1
03/11/2015 16:00	1.3	12.6	2,042.8	0.9	6.10	1	1	1
03/11/2015 17:00	1.2	13.0	1,961.1	0.9	5.90	1	1	1
03/11/2015 18:00	1.3	12.6	2,042.0	0.9	6.10	1	1	1
03/11/2015 19:00	1.3	12.7	2,050.1	0.9	6.20	1	1	1
03/11/2015 20:00	1.2	12.9	2,004.1	0.9	6.00	1	1	1
03/11/2015 21:00	1.0	13.5	1,619.4	0.8	4.90	1	1	1
03/11/2015 22:00	0.7	13.9	1,292.9	0.6	2.60	1	1	0
03/11/2015 23:00	0.7	13.9	1,297.1	0.6	2.60	1	1	0
Average/Sum#:	1.1	13.1	1,799.2	0.8	133.10 #	24 #	24 #	18 #
Minimum:	0.7	12.6	1,287.4	0.6	2.60	1	1	0
Maximum:	1.4	14.0	2,050.1	1.0	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/12/2015 00:00	0.7	13.9	1,300.4	0.6	2.60	1	1	0
03/12/2015 01:00	0.7	13.9	1,305.1	0.6	2.60	1	1	0
03/12/2015 02:00	0.7	13.9	1,307.5	0.6	2.60	1	1	0
03/12/2015 03:00	0.7	13.9	1,307.7	0.6	2.60	1	1	0
03/12/2015 04:00	0.8	13.8	1,425.3	0.7	2.90	1	1	1
03/12/2015 05:00	1.3	13.2	1,945.8	1.0	7.80	1	1	1
03/12/2015 06:00	1.4	12.7	2,033.2	1.0	8.10	1	1	1
03/12/2015 07:00	1.4	12.7	2,032.8	1.0	8.10	1	1	1
03/12/2015 08:00	1.3	12.9	1,980.2	1.0	7.90	1	1	1
03/12/2015 09:00	1.3	13.1	1,945.5	1.0	7.80	1	1	1
03/12/2015 10:00	1.3	13.2	1,923.9	1.0	7.70	1	1	1
03/12/2015 11:00	0.8	13.9	1,352.3	0.7	2.70	1	1	0
03/12/2015 12:00	0.8	14.0	1,293.5	0.7	3.90	1	1	0
03/12/2015 13:00	0.8	14.0	1,293.0	0.7	3.90	1	1	0
03/12/2015 14:00	0.8	14.0	1,292.6	0.7	3.90	1	1	0
03/12/2015 15:00	0.8	14.0	1,291.0	0.7	3.90	1	1	0
03/12/2015 16:00	1.0	13.7	1,538.0	0.8	4.60	1	1	1
03/12/2015 17:00	1.3	12.6	2,023.8	0.9	6.10	1	1	1
03/12/2015 18:00	1.4	12.6	2,041.0	1.0	8.20	1	1	1
03/12/2015 19:00	1.4	12.6	2,043.0	1.0	8.20	1	1	1
03/12/2015 20:00	1.4	12.6	2,041.8	1.0	8.20	1	1	1
03/12/2015 21:00	1.4	12.6	2,036.5	1.0	8.10	1	1	1
03/12/2015 22:00	1.2	13.2	1,782.1	0.9	5.30	1	1	1
03/12/2015 23:00	0.8	14.0	1,381.1	0.7	4.10	1	1	0
Average/Sum#:	1.1	13.4	1,663.2	0.8	131.80 #	24 #	24 #	14 #
Minimum:	0.7	12.6	1,291.0	0.6	2.60	1	1	0
Maximum:	1.4	14.0	2,043.0	1.0	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/13/2015 00:00	0.8	14.0	1,382.0	0.7	4.10	1	1	0
03/13/2015 01:00	0.8	13.9	1,415.4	0.7	2.80	1	1	0
03/13/2015 02:00	0.9	13.9	1,538.8	0.8	4.60	1	1	0
03/13/2015 03:00	0.8	13.9	1,411.2	0.7	2.80	1	1	0
03/13/2015 04:00	1.0	13.7	1,555.4	0.8	4.70	1	1	1
03/13/2015 05:00	1.3	13.0	1,976.0	1.0	7.90	1	1	1
03/13/2015 06:00	1.3	12.9	2,001.0	1.0	8.00	1	1	1
03/13/2015 07:00	1.3	13.3	1,913.7	1.0	7.70	1	1	1
03/13/2015 08:00	1.3	13.2	1,916.6	1.0	7.70	1	1	1
03/13/2015 09:00	1.3	13.2	1,918.8	1.0	7.70	1	1	1
03/13/2015 10:00	1.1	13.6	1,625.9	0.9	4.90	1	1	1
03/13/2015 11:00	0.8	14.0	1,292.1	0.7	3.90	1	1	0
03/13/2015 12:00	0.9	13.9	1,396.7	0.8	4.20	1	1	1
03/13/2015 13:00	1.3	12.8	1,972.5	0.9	5.90	1	1	1
03/13/2015 14:00	1.3	12.8	1,979.2	0.9	5.90	1	1	1
03/13/2015 15:00	1.4	12.5	2,028.3	1.0	8.10	1	1	1
03/13/2015 16:00	1.4	12.4	2,040.0	1.0	8.20	1	1	1
03/13/2015 17:00	1.4	12.4	2,043.3	1.0	8.20	1	1	1
03/13/2015 18:00	1.4	12.5	2,042.4	1.0	8.20	1	1	1
03/13/2015 19:00	1.4	12.5	2,032.0	1.0	8.10	1	1	1
03/13/2015 20:00	1.4	12.5	2,035.5	1.0	8.10	1	1	1
03/13/2015 21:00	1.4	12.6	2,008.1	1.0	8.00	1	1	1
03/13/2015 22:00	1.4	12.6	2,019.7	1.0	8.10	1	1	1
03/13/2015 23:00	1.4	12.5	2,028.4	1.0	8.10	1	1	1
Average/Sum#:	1.2	13.1	1,815.5	0.9	155.90 #	24 #	24 #	19 #
Minimum:	0.8	12.4	1,292.1	0.7	2.80	1	1	0
Maximum:	1.4	14.0	2,043.3	1.0	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/14/2015 00:00	1.3	12.8	1,980.0	0.9	5.90	1	1	1
03/14/2015 01:00	1.4	12.8	1,981.4	1.0	7.90	1	1	1
03/14/2015 02:00	1.3	12.9	1,966.4	1.0	7.90	1	1	1
03/14/2015 03:00	1.3	13.1	1,924.9	1.0	7.70	1	1	1
03/14/2015 04:00	1.3	13.1	1,919.6	1.0	7.70	1	1	1
03/14/2015 05:00	1.3	13.1	1,924.7	1.0	7.70	1	1	1
03/14/2015 06:00	1.4	12.6	2,028.5	1.0	8.10	1	1	1
03/14/2015 07:00	1.3	12.7	1,998.1	0.9	6.00	1	1	1
03/14/2015 08:00	1.3	12.9	1,954.2	1.0	7.80	1	1	1
03/14/2015 09:00	1.3	13.0	1,950.0	1.0	7.80	1	1	1
03/14/2015 10:00	1.3	12.9	1,952.3	1.0	7.80	1	1	1
03/14/2015 11:00	1.3	12.9	1,971.4	1.0	7.90	1	1	1
03/14/2015 12:00	1.4	12.5	2,049.8	1.0	8.20	1	1	1
03/14/2015 13:00	1.4	12.4	2,052.3	1.0	8.20	1	1	1
03/14/2015 14:00	1.4	12.4	2,048.6	1.0	8.20	1	1	1
03/14/2015 15:00	1.4	12.5	2,013.9	1.0	8.10	1	1	1
03/14/2015 16:00	1.4	12.3	2,049.9	1.0	8.20	1	1	1
03/14/2015 17:00	1.4	12.4	2,049.7	1.0	8.20	1	1	1
03/14/2015 18:00	1.4	12.4	2,046.9	1.0	8.20	1	1	1
03/14/2015 19:00	1.4	12.4	2,045.6	1.0	8.20	1	1	1
03/14/2015 20:00	1.4	12.4	2,044.4	1.0	8.20	1	1	1
03/14/2015 21:00	1.4	12.4	2,044.5	1.0	8.20	1	1	1
03/14/2015 22:00	1.4	12.5	2,042.1	1.0	8.20	1	1	1
03/14/2015 23:00	1.3	12.6	2,006.8	0.9	6.00	1	1	1
Average/Sum#:	1.4	12.7	2,001.9	1.0	186.30 #	24 #	24 #	24 #
Minimum:	1.3	12.3	1,919.6	0.9	5.90	1	1	1
Maximum:	1.4	13.1	2,052.3	1.0	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/15/2015 00:00	1.3	12.9	1,950.1	1.0	7.80	1	1	1
03/15/2015 01:00	1.3	12.7	1,990.5	0.9	6.00	1	1	1
03/15/2015 02:00	1.2	13.2	1,813.2	0.9	5.40	1	1	1
03/15/2015 03:00	1.0	13.8	1,769.1	0.8	5.30	1	1	0
03/15/2015 04:00	1.1	13.7	1,782.6	0.9	5.30	1	1	0
03/15/2015 05:00	1.0	13.8	1,753.2	0.8	5.30	1	1	0
03/15/2015 06:00	1.1	13.7	1,784.0	0.9	5.40	1	1	0
03/15/2015 07:00	1.1	13.7	1,556.0	0.9	4.70	1	1	0
03/15/2015 08:00	0.7	13.9	1,296.8	0.6	2.60	1	1	0
03/15/2015 09:00	0.8	14.0	1,297.7	0.7	3.90	1	1	0
03/15/2015 10:00	0.9	14.0	1,299.0	0.8	3.90	1	1	0
03/15/2015 11:00	1.0	13.9	1,570.7	0.8	4.70	1	1	0
03/15/2015 12:00	1.1	13.9	1,761.6	0.9	5.30	1	1	0
03/15/2015 13:00	1.3	13.0	1,920.1	1.0	7.70	1	1	1
03/15/2015 14:00	1.4	12.6	2,046.5	1.0	8.20	1	1	1
03/15/2015 15:00	1.4	12.6	2,031.2	1.0	8.10	1	1	1
03/15/2015 16:00	1.4	12.6	2,036.6	1.0	8.10	1	1	1
03/15/2015 17:00	1.4	12.6	2,034.2	1.0	8.10	1	1	1
03/15/2015 18:00	1.4	12.6	2,033.7	1.0	8.10	1	1	1
03/15/2015 19:00	1.4	12.6	2,035.7	1.0	8.10	1	1	1
03/15/2015 20:00	1.3	12.6	2,034.5	0.9	6.10	1	1	1
03/15/2015 21:00	1.4	12.6	2,027.0	1.0	8.10	1	1	1
03/15/2015 22:00	1.2	13.1	1,846.4	0.9	5.50	1	1	1
03/15/2015 23:00	0.7	13.9	1,294.0	0.6	2.60	1	1	0
Average/Sum#:	1.2	13.3	1,790.2	0.9	144.30 #	24 #	24 #	13 #
Minimum:	0.7	12.6	1,294.0	0.6	2.60	1	1	0
Maximum:	1.4	14.0	2,046.5	1.0	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/16/2015 00:00	0.7	14.0	1,291.5	0.6	2.60	1	1	0
03/16/2015 01:00	0.8	13.9	1,288.4	0.7	2.60	1	1	0
03/16/2015 02:00	0.8	13.9	1,291.1	0.7	2.60	1	1	0
03/16/2015 03:00	0.8	14.0	1,294.6	0.7	3.90	1	1	0
03/16/2015 04:00	1.0	13.6	1,552.3	0.8	4.70	1	1	1
03/16/2015 05:00	1.3	12.8	1,993.5	0.9	6.00	1	1	1
03/16/2015 06:00	1.4	12.6	2,034.4	1.0	8.10	1	1	1
03/16/2015 07:00	1.3	12.7	1,997.9	0.9	6.00	1	1	1
03/16/2015 08:00	1.3	12.6	2,033.2	0.9	6.10	1	1	1
03/16/2015 09:00	1.3	12.7	2,030.7	0.9	6.10	1	1	1
03/16/2015 10:00	1.3	12.7	2,016.3	0.9	6.00	1	1	1
03/16/2015 11:00	1.4	12.6	2,033.2	1.0	8.10	1	1	1
03/16/2015 12:00	1.3	12.6	2,031.5	0.9	6.10	1	1	1
03/16/2015 13:00	1.3	12.6	2,033.0	0.9	6.10	1	1	1
03/16/2015 14:00	1.4	12.6	2,032.2	1.0	8.10	1	1	1
03/16/2015 15:00	1.3	12.6	2,022.6	0.9	6.10	1	1	1
03/16/2015 16:00	1.3	12.8	1,978.8	0.9	5.90	1	1	1
03/16/2015 17:00	1.3	12.9	1,950.4	1.0	7.80	1	1	1
03/16/2015 18:00	1.3	12.7	2,010.4	0.9	6.00	1	1	1
03/16/2015 19:00	1.3	12.6	2,047.3	0.9	6.10	1	1	1
03/16/2015 20:00	1.3	12.8	2,011.6	0.9	6.00	1	1	1
03/16/2015 21:00	1.3	13.0	1,977.0	1.0	7.90	1	1	1
03/16/2015 22:00	0.9	13.8	1,459.4	0.7	4.40	1	1	1
03/16/2015 23:00	0.7	13.9	1,290.7	0.6	2.60	1	1	0
Average/Sum#:	1.2	13.0	1,820.9	0.9	135.90 #	24 #	24 #	19 #
Minimum:	0.7	12.6	1,288.4	0.6	2.60	1	1	0
Maximum:	1.4	14.0	2,047.3	1.0	8.10	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/17/2015 00:00	0.7	13.9	1,289.0	0.6	2.60	1	1	0
03/17/2015 01:00	0.8	13.9	1,289.8	0.7	2.60	1	1	0
03/17/2015 02:00	0.8	13.9	1,289.7	0.7	2.60	1	1	0
03/17/2015 03:00	0.8	13.9	1,290.5	0.7	2.60	1	1	0
03/17/2015 04:00	0.8	13.9	1,290.1	0.7	2.60	1	1	0
03/17/2015 05:00	0.8	13.9	1,290.3	0.7	2.60	1	1	0
03/17/2015 06:00	0.8	13.9	1,290.3	0.7	2.60	1	1	0
03/17/2015 07:00	0.8	13.9	1,289.1	0.7	2.60	1	1	0
03/17/2015 08:00	0.8	13.9	1,290.7	0.7	2.60	1	1	0
03/17/2015 09:00	0.8	13.9	1,292.8	0.7	2.60	1	1	0
03/17/2015 10:00	0.0	0.0	1,295.3	0.0	0.00	1	1	0
03/17/2015 11:00	0.7	15.0	1,294.8	0.7	2.85	1	0	0
03/17/2015 12:00	0.5	16.6	1,296.9	0.7	3.90	1	0	0
03/17/2015 13:00	0.4	17.4	1,298.4	0.7	2.60	1	1	0
03/17/2015 14:00	0.4	17.5	1,299.0	0.7	3.90	1	1	0
03/17/2015 15:00	0.4	17.6	1,297.7	0.7	3.90	1	1	0
03/17/2015 16:00	0.3	18.0	1,295.9	0.6	2.60	1	1	0
03/17/2015 17:00	0.3	18.2	1,296.3	0.7	2.60	1	1	0
03/17/2015 18:00	0.3	18.2	1,295.9	0.7	2.60	1	1	0
03/17/2015 19:00	0.3	18.3	1,294.0	0.7	3.90	1	1	0
03/17/2015 20:00	0.3	18.3	1,292.2	0.7	3.90	1	1	0
03/17/2015 21:00	0.3	18.3	1,292.2	0.7	3.90	1	1	0
03/17/2015 22:00	0.7	15.3	1,290.6	0.7	3.90	1	1	0
03/17/2015 23:00	0.8	14.3	1,286.6	0.7	3.90	1	1	0
Average/Sum#:	0.6	15.7	1,292.8	0.7	70.45 #	24 #	22 #	0 #
Minimum:	0.3	13.9	1,286.6	0.6	2.60	1	0	0
Maximum:	0.8	18.3	1,299.0	0.7	3.90	1	1	0
%SI	4.2	4.2	0.0	4.2	4.17	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/18/2015 00:00	0.8	14.2	1,285.9	0.7	3.90	1	1	0
03/18/2015 01:00	0.8	14.2	1,290.6	0.7	3.90	1	1	0
03/18/2015 02:00	0.8	14.2	1,301.4	0.7	3.90	1	1	0
03/18/2015 03:00	0.8	14.2	1,303.6	0.7	3.90	1	1	0
03/18/2015 04:00	0.8	14.2	1,304.1	0.7	3.90	1	1	0
03/18/2015 05:00	0.8	14.2	1,302.8	0.7	3.90	1	1	0
03/18/2015 06:00	0.8	14.2	1,302.1	0.7	3.90	1	1	0
03/18/2015 07:00	0.8	14.2	1,300.7	0.7	3.90	1	1	0
03/18/2015 08:00	0.8	14.2	1,300.5	0.7	3.90	1	1	0
03/18/2015 09:00	0.8	14.2	1,300.4	0.7	3.90	1	1	0
03/18/2015 10:00	0.8	14.2	1,301.2	0.7	3.90	1	1	0
03/18/2015 11:00	0.8	14.2	1,299.5	0.7	3.90	1	1	0
03/18/2015 12:00	0.8	14.2	1,296.2	0.7	3.90	1	1	0
03/18/2015 13:00	0.8	14.2	1,296.0	0.7	3.90	1	1	0
03/18/2015 14:00	0.9	14.2	1,312.2	0.8	3.90	1	1	0
03/18/2015 15:00	1.1	14.1	1,652.2	1.0	6.60	1	1	0
03/18/2015 16:00	1.1	14.1	1,677.7	1.0	6.70	1	1	0
03/18/2015 17:00	0.8	14.2	1,282.0	0.7	3.80	1	1	0
03/18/2015 18:00	0.9	14.2	1,283.9	0.8	3.90	1	1	0
03/18/2015 19:00	0.9	14.2	1,282.4	0.8	3.80	1	1	0
03/18/2015 20:00	0.9	14.2	1,286.6	0.8	3.90	1	1	0
03/18/2015 21:00	0.9	14.2	1,286.6	0.8	3.90	1	1	0
03/18/2015 22:00	0.9	14.1	1,283.2	0.8	3.80	1	1	0
03/18/2015 23:00	0.9	14.1	1,282.7	0.8	3.80	1	1	0
Average/Sum#:	0.9	14.2	1,325.6	0.8	98.70 #	24 #	24 #	0 #
Minimum:	0.8	14.1	1,282.0	0.7	3.80	1	1	0
Maximum:	1.1	14.2	1,677.7	1.0	6.70	1	1	0
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/19/2015 00:00	0.9	14.1	1,282.9	0.8	3.80	1	1	0
03/19/2015 01:00	0.8	14.1	1,281.1	0.7	3.80	1	1	0
03/19/2015 02:00	0.8	14.1	1,281.4	0.7	3.80	1	1	0
03/19/2015 03:00	0.8	14.1	1,283.3	0.7	3.80	1	1	0
03/19/2015 04:00	0.9	14.1	1,285.5	0.8	3.90	1	1	0
03/19/2015 05:00	0.8	14.0	1,292.6	0.7	3.90	1	1	0
03/19/2015 06:00	0.9	13.9	1,409.9	0.8	4.20	1	1	1
03/19/2015 07:00	1.2	12.9	1,995.0	0.9	6.00	1	1	1
03/19/2015 08:00	0.0	0.0	1,953.0	0.0	0.00	1	1	1
03/19/2015 09:00	0.0	0.0	1,942.5	0.0	0.00	1	1	1
03/19/2015 10:00	0.0	0.0	1,947.4	0.0	0.00	1	1	1
03/19/2015 11:00	0.0	0.0	1,976.3	0.0	0.00	1	1	1
03/19/2015 12:00	1.4	12.6	2,039.6	1.0	8.20	1	1	1
03/19/2015 13:00	1.3	12.9	1,981.1	1.0	7.90	1	1	1
03/19/2015 14:00	0.8	14.0	1,564.1	0.7	4.70	1	1	1
03/19/2015 15:00	0.8	14.0	1,320.8	0.7	4.00	1	1	0
03/19/2015 16:00	0.9	13.9	1,390.8	0.8	4.20	1	1	1
03/19/2015 17:00	1.3	13.0	1,930.3	1.0	7.70	1	1	1
03/19/2015 18:00	1.3	12.8	1,972.5	0.9	5.90	1	1	1
03/19/2015 19:00	1.4	12.5	2,038.9	1.0	8.20	1	1	1
03/19/2015 20:00	1.3	13.0	1,929.7	1.0	7.70	1	1	1
03/19/2015 21:00	1.1	13.3	1,743.0	0.9	5.20	1	1	1
03/19/2015 22:00	0.8	13.9	1,465.4	0.7	2.90	1	1	0
03/19/2015 23:00	0.7	13.9	1,307.0	0.6	2.60	1	1	0
Average/Sum#:	1.0	13.6	1,650.6	0.8	102.40 #	24 #	24 #	15 #
Minimum:	0.7	12.5	1,281.1	0.6	2.60	1	1	0
Maximum:	1.4	14.1	2,039.6	1.0	8.20	1	1	1
%SI	16.7	16.7	0.0	16.7	16.67	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/20/2015 00:00	0.9	13.9	1,451.1	0.8	4.40	1	1	0
03/20/2015 01:00	0.8	13.9	1,299.2	0.7	2.60	1	1	0
03/20/2015 02:00	1.1	13.8	1,675.1	0.9	5.00	1	1	0
03/20/2015 03:00	0.7	13.9	1,330.0	0.6	2.70	1	1	0
03/20/2015 04:00	1.0	13.4	1,687.7	0.8	5.10	1	1	1
03/20/2015 05:00	1.3	12.9	2,009.9	1.0	8.00	1	1	1
03/20/2015 06:00	1.4	12.7	2,034.0	1.0	8.10	1	1	1
03/20/2015 07:00	1.3	13.0	1,974.4	1.0	7.90	1	1	1
03/20/2015 08:00	1.3	13.0	1,929.4	1.0	7.70	1	1	1
03/20/2015 09:00	1.2	13.7	1,831.5	1.0	7.30	1	1	0
03/20/2015 10:00	1.2	13.7	1,828.5	1.0	7.30	1	1	0
03/20/2015 11:00	1.2	13.5	1,834.0	1.0	7.30	1	1	1
03/20/2015 12:00	1.3	12.9	1,988.6	1.0	8.00	1	1	1
03/20/2015 13:00	1.4	12.8	2,010.0	1.0	8.00	1	1	1
03/20/2015 14:00	1.3	12.9	1,978.9	1.0	7.90	1	1	1
03/20/2015 15:00	1.3	12.9	1,975.9	1.0	7.90	1	1	1
03/20/2015 16:00	1.3	13.0	1,945.4	1.0	7.80	1	1	1
03/20/2015 17:00	1.3	13.0	1,944.2	1.0	7.80	1	1	1
03/20/2015 18:00	1.3	13.0	1,950.5	1.0	7.80	1	1	1
03/20/2015 19:00	1.3	13.0	1,944.3	1.0	7.80	1	1	1
03/20/2015 20:00	1.3	13.0	1,945.8	1.0	7.80	1	1	1
03/20/2015 21:00	1.3	13.1	1,953.4	1.0	7.80	1	1	1
03/20/2015 22:00	1.1	13.5	1,733.9	0.9	5.20	1	1	1
03/20/2015 23:00	0.7	13.9	1,290.6	0.6	2.60	1	1	0
Average/Sum#:	1.2	13.3	1,814.4	0.9	159.80 #	24 #	24 #	17 #
Minimum:	0.7	12.7	1,290.6	0.6	2.60	1	1	0
Maximum:	1.4	13.9	2,034.0	1.0	8.10	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/21/2015 00:00	0.7	13.9	1,286.0	0.6	2.60	1	1	0
03/21/2015 01:00	0.9	13.9	1,530.0	0.8	4.60	1	1	0
03/21/2015 02:00	0.7	13.9	1,338.3	0.6	2.70	1	1	0
03/21/2015 03:00	1.0	13.8	1,566.9	0.8	4.70	1	1	0
03/21/2015 04:00	0.9	13.9	1,584.6	0.8	4.80	1	1	0
03/21/2015 05:00	0.9	13.7	1,499.0	0.7	4.50	1	1	1
03/21/2015 06:00	1.3	13.0	1,992.7	1.0	8.00	1	1	1
03/21/2015 07:00	1.2	13.3	1,801.1	0.9	5.40	1	1	1
03/21/2015 08:00	0.7	13.9	1,345.0	0.6	2.70	1	1	0
03/21/2015 09:00	0.8	13.9	1,307.2	0.7	2.60	1	1	0
03/21/2015 10:00	0.8	13.9	1,311.1	0.7	2.60	1	1	0
03/21/2015 11:00	0.8	13.9	1,312.9	0.7	2.60	1	1	0
03/21/2015 12:00	0.8	14.0	1,340.6	0.7	4.00	1	1	0
03/21/2015 13:00	0.8	14.0	1,310.0	0.7	3.90	1	1	0
03/21/2015 14:00	0.9	14.0	1,403.2	0.8	4.20	1	1	0
03/21/2015 15:00	0.9	13.9	1,489.2	0.8	4.50	1	1	0
03/21/2015 16:00	1.0	13.9	1,641.6	0.8	4.90	1	1	0
03/21/2015 17:00	1.2	13.2	1,806.3	0.9	5.40	1	1	1
03/21/2015 18:00	1.3	12.7	1,989.9	0.9	6.00	1	1	1
03/21/2015 19:00	1.4	12.7	1,996.9	1.0	8.00	1	1	1
03/21/2015 20:00	1.4	12.6	2,016.1	1.0	8.10	1	1	1
03/21/2015 21:00	1.3	12.8	1,996.3	0.9	6.00	1	1	1
03/21/2015 22:00	1.1	13.4	1,787.5	0.9	5.40	1	1	1
03/21/2015 23:00	1.0	13.8	1,758.3	0.8	5.30	1	1	0
Average/Sum#:	1.0	13.6	1,600.4	0.8	113.50 #	24 #	24 #	9 #
Minimum:	0.7	12.6	1,286.0	0.6	2.60	1	1	0
Maximum:	1.4	14.0	2,016.1	1.0	8.10	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/22/2015 00:00	1.1	13.7	1,798.3	0.9	5.40	1	1	0
03/22/2015 01:00	0.8	13.9	1,610.8	0.7	3.20	1	1	0
03/22/2015 02:00	0.9	13.8	1,654.1	0.7	5.00	1	1	0
03/22/2015 03:00	1.0	13.9	1,765.1	0.8	5.30	1	1	0
03/22/2015 04:00	0.9	13.9	1,523.6	0.8	4.60	1	1	0
03/22/2015 05:00	0.9	13.8	1,592.0	0.7	4.80	1	1	0
03/22/2015 06:00	1.0	13.8	1,634.2	0.8	4.90	1	1	0
03/22/2015 07:00	0.9	13.7	1,672.3	0.7	5.00	1	1	1
03/22/2015 08:00	1.4	12.6	2,040.5	1.0	8.20	1	1	1
03/22/2015 09:00	1.5	12.6	2,017.3	1.1	8.10	1	1	1
03/22/2015 10:00	1.4	12.9	1,952.7	1.0	7.80	1	1	1
03/22/2015 11:00	1.4	12.9	1,960.7	1.0	7.80	1	1	1
03/22/2015 12:00	1.3	12.9	1,973.2	1.0	7.90	1	1	1
03/22/2015 13:00	1.1	13.5	1,697.4	0.9	5.10	1	1	1
03/22/2015 14:00	1.0	13.9	1,609.8	0.8	4.80	1	1	0
03/22/2015 15:00	0.9	13.9	1,614.0	0.8	4.80	1	1	0
03/22/2015 16:00	0.9	13.9	1,567.0	0.8	4.70	1	1	0
03/22/2015 17:00	1.1	13.4	1,713.6	0.9	5.10	1	1	1
03/22/2015 18:00	1.3	12.8	1,992.7	0.9	6.00	1	1	1
03/22/2015 19:00	1.3	12.9	1,977.8	1.0	7.90	1	1	1
03/22/2015 20:00	1.3	13.0	1,960.9	1.0	7.80	1	1	1
03/22/2015 21:00	0.9	13.7	1,470.8	0.7	4.40	1	1	1
03/22/2015 22:00	0.7	13.9	1,304.5	0.6	2.60	1	1	0
03/22/2015 23:00	1.5	14.4	1,119.6	1.4	4.87	1	0	0
Average/Sum#:	1.1	13.5	1,717.6	0.9	136.07 #	24 #	23 #	12 #
Minimum:	0.7	12.6	1,119.6	0.6	2.60	1	0	0
Maximum:	1.5	14.4	2,040.5	1.4	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/23/2015 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2015 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/24/2015 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2015 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/25/2015 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2015 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/26/2015 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2015 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2015 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2015 03:00	26.0	17.5	470.3	45.1	42.96	1	0	0
03/26/2015 04:00	11.2	16.7	594.4	15.7	34.50	1	0	0
03/26/2015 05:00	4.1	16.0	758.2	4.9	13.60	1	0	0
03/26/2015 06:00	0.3	13.9	1,375.5	0.3	1.40	1	1	0
03/26/2015 07:00	0.5	13.9	1,375.7	0.4	2.80	1	1	0
03/26/2015 08:00	0.5	13.9	1,381.9	0.4	2.80	1	1	0
03/26/2015 09:00	0.5	14.0	1,381.1	0.4	2.80	1	1	0
03/26/2015 10:00	0.5	14.0	1,383.7	0.4	2.80	1	1	0
03/26/2015 11:00	0.5	14.0	1,382.6	0.4	2.80	1	1	0
03/26/2015 12:00	0.5	14.0	1,385.0	0.4	2.80	1	1	0
03/26/2015 13:00	0.8	13.8	1,658.7	0.7	3.30	1	1	0
03/26/2015 14:00	0.5	13.9	1,396.3	0.4	2.80	1	1	0
03/26/2015 15:00	0.6	14.0	1,403.5	0.5	2.80	1	1	0
03/26/2015 16:00	0.8	13.8	1,679.7	0.7	3.40	1	1	0
03/26/2015 17:00	0.9	13.7	1,772.2	0.7	5.30	1	1	0
03/26/2015 18:00	0.9	13.7	1,778.2	0.7	5.30	1	1	0
03/26/2015 19:00	0.9	13.7	1,781.5	0.7	5.30	1	1	0
03/26/2015 20:00	0.9	13.7	1,785.4	0.7	5.40	1	1	0
03/26/2015 21:00	0.5	13.9	1,361.7	0.4	2.70	1	1	0
03/26/2015 22:00	3.5	16.6	334.2	4.8	1.02	1	0	0
03/26/2015 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	2.7	14.4	1,322.0	3.9	146.58 #	20 #	16 #	0 #
Minimum:	0.3	13.7	334.2	0.3	1.02	0	0	0
Maximum:	26.0	17.5	1,785.4	45.1	42.96	1	1	0
%SI	16.7	16.7	16.7	16.7	16.67	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/27/2015 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2015 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2015 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2015 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2015 04:00	0.2	19.5	170.5	0.8	0.04	1	0	0
03/27/2015 05:00	20.4	15.8	806.7	23.6	70.20	1	0	0
03/27/2015 06:00	0.4	13.9	1,385.0	0.3	1.40	1	1	0
03/27/2015 07:00	0.5	13.9	1,379.3	0.4	2.80	1	1	0
03/27/2015 08:00	0.5	14.0	1,376.2	0.4	2.80	1	1	0
03/27/2015 09:00	0.5	14.0	1,376.0	0.4	2.80	1	1	0
03/27/2015 10:00	0.5	14.0	1,377.8	0.4	2.80	1	1	0
03/27/2015 11:00	0.5	14.0	1,383.3	0.4	2.80	1	1	0
03/27/2015 12:00	0.5	14.0	1,383.1	0.4	2.80	1	1	0
03/27/2015 13:00	0.5	14.0	1,380.2	0.4	2.80	1	1	0
03/27/2015 14:00	0.5	14.0	1,379.3	0.4	2.80	1	1	0
03/27/2015 15:00	0.5	14.0	1,378.5	0.4	2.80	1	1	0
03/27/2015 16:00	0.6	14.0	1,381.3	0.5	2.80	1	1	0
03/27/2015 17:00	0.8	13.9	1,566.7	0.7	3.10	1	1	0
03/27/2015 18:00	0.6	14.0	1,393.8	0.5	2.80	1	1	0
03/27/2015 19:00	0.6	14.0	1,373.3	0.5	2.70	1	1	0
03/27/2015 20:00	1.6	14.6	1,113.2	1.5	4.49	1	0	0
03/27/2015 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2015 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2015 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.7	14.4	1,270.8	1.9	112.73 #	17 #	14 #	0 #
Minimum:	0.2	13.9	170.5	0.3	0.04	0	0	0
Maximum:	20.4	19.5	1,566.7	23.6	70.20	1	1	0
%SI	29.2	29.2	29.2	29.2	29.17	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/28/2015 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/28/2015 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/29/2015 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/29/2015 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/30/2015 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2015 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2015 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2015 03:00	27.7	17.5	476.6	48.1	46.42	1	0	0
03/30/2015 04:00	18.0	15.7	715.5	20.4	53.70	1	0	0
03/30/2015 05:00	8.5	14.7	1,086.2	8.1	32.60	1	0	0
03/30/2015 06:00	0.4	14.0	1,380.6	0.3	1.40	1	1	0
03/30/2015 07:00	0.5	14.0	1,386.9	0.4	2.80	1	1	0
03/30/2015 08:00	0.5	14.0	1,384.8	0.4	2.80	1	1	0
03/30/2015 09:00	0.5	14.0	1,386.0	0.4	2.80	1	1	0
03/30/2015 10:00	0.5	14.0	1,378.1	0.4	2.80	1	1	0
03/30/2015 11:00	0.5	14.0	1,376.0	0.4	2.80	1	1	0
03/30/2015 12:00	0.6	13.9	1,510.8	0.5	3.00	1	1	0
03/30/2015 13:00	0.5	14.0	1,531.3	0.4	3.10	1	1	0
03/30/2015 14:00	0.5	13.9	1,513.1	0.4	3.00	1	1	0
03/30/2015 15:00	0.5	14.0	1,351.2	0.4	2.70	1	1	0
03/30/2015 16:00	0.4	14.0	1,334.9	0.3	1.30	1	1	0
03/30/2015 17:00	0.5	13.9	1,473.4	0.4	2.90	1	1	0
03/30/2015 18:00	0.7	13.8	1,692.8	0.6	3.40	1	1	0
03/30/2015 19:00	0.7	13.9	1,609.6	0.6	3.20	1	1	0
03/30/2015 20:00	2.1	14.9	974.0	2.1	3.51	1	0	0
03/30/2015 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2015 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/30/2015 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	3.5	14.3	1,309.0	4.7	174.23 #	18 #	14 #	0 #
Minimum:	0.4	13.8	476.6	0.3	1.30	0	0	0
Maximum:	27.7	17.5	1,692.8	48.1	53.70	1	1	0
%SI	25.0	25.0	25.0	25.0	25.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/31/2015 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2015 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2015 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2015 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2015 04:00	27.6	17.2	519.8	44.0	53.05	1	0	0
03/31/2015 05:00	4.7	14.2	1,246.4	4.1	18.70	1	0	0
03/31/2015 06:00	0.4	13.9	1,379.2	0.3	1.40	1	1	0
03/31/2015 07:00	0.5	13.9	1,382.0	0.4	2.80	1	1	0
03/31/2015 08:00	0.5	13.9	1,384.5	0.4	2.80	1	1	0
03/31/2015 09:00	0.5	14.0	1,381.1	0.4	2.80	1	1	0
03/31/2015 10:00	0.5	14.0	1,377.2	0.4	2.80	1	1	0
03/31/2015 11:00	0.5	14.0	1,372.5	0.4	2.70	1	1	0
03/31/2015 12:00	0.5	14.0	1,377.5	0.4	2.80	1	1	0
03/31/2015 13:00	0.5	14.0	1,375.2	0.4	2.80	1	1	0
03/31/2015 14:00	0.6	14.0	1,383.2	0.5	2.80	1	1	0
03/31/2015 15:00	0.5	14.0	1,379.8	0.4	2.80	1	1	0
03/31/2015 16:00	0.6	14.0	1,522.7	0.5	3.00	1	1	0
03/31/2015 17:00	0.6	14.0	1,508.6	0.5	3.00	1	1	0
03/31/2015 18:00	0.6	14.0	1,595.8	0.5	3.20	1	1	0
03/31/2015 19:00	0.7	14.0	1,771.1	0.6	3.50	1	1	0
03/31/2015 20:00	0.7	13.9	1,619.3	0.6	3.20	1	1	0
03/31/2015 21:00	2.2	14.8	1,048.4	2.1	3.78	1	0	0
03/31/2015 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2015 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	2.4	14.2	1,368.0	3.2	117.93 #	18 #	15 #	0 #
Minimum:	0.4	13.9	519.8	0.3	1.40	0	0	0
Maximum:	27.6	17.2	1,771.1	44.0	53.05	1	1	0
%SI	25.0	25.0	25.0	25.0	25.00	0	0	0

ATTACHMENT 7
Hourly Emissions CO

FCD:	AQ-16
Title V:	#6

Excess Emission Report

CT1 - CO Lb 1-Day Block Average

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 12:40 **Location:** Maxwell, CA

Tag Name: CT1_CO_Lb_1D
Total Operating Time: 1,870.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 290.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,870.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - CO Lb 1-Day Block Average

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 12:40 **Location:** Maxwell, CA

Tag Name: CT2_CO_Lb_1D
Total Operating Time: 1,811.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 349.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,811.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/01/2015 00:00	0.5	11.9	2,249.1	0.4	1.7	1	1	1
01/01/2015 01:00	0.4	11.7	2,288.5	0.3	1.3	1	1	1
01/01/2015 02:00	0.4	11.7	2,277.8	0.3	1.3	1	1	1
01/01/2015 03:00	0.4	11.7	2,269.6	0.3	1.3	1	1	1
01/01/2015 04:00	0.5	12.0	2,227.2	0.3	1.7	1	1	1
01/01/2015 05:00	0.5	12.1	2,212.8	0.3	1.7	1	1	1
01/01/2015 06:00	0.4	11.7	2,296.2	0.3	1.3	1	1	1
01/01/2015 07:00	0.4	11.8	2,269.9	0.3	1.3	1	1	1
01/01/2015 08:00	0.2	13.1	1,942.5	0.3	0.7	1	1	1
01/01/2015 09:00	0.1	13.4	1,836.7	0.2	0.3	1	1	1
01/01/2015 10:00	0.0	13.8	1,449.7	0.1	0.0	1	1	1
01/01/2015 11:00	0.0	13.9	1,269.6	0.0	0.0	1	1	0
01/01/2015 12:00	0.0	13.9	1,272.4	0.0	0.0	1	1	0
01/01/2015 13:00	0.0	13.9	1,268.6	0.0	0.0	1	1	0
01/01/2015 14:00	0.0	13.9	1,266.0	0.0	0.0	1	1	0
01/01/2015 15:00	0.1	13.6	1,599.7	0.0	0.3	1	1	1
01/01/2015 16:00	0.3	13.3	1,913.4	0.1	1.0	1	1	1
01/01/2015 17:00	0.3	13.1	1,981.6	0.2	1.0	1	1	1
01/01/2015 18:00	0.6	12.6	2,091.4	0.3	2.0	1	1	1
01/01/2015 19:00	0.5	11.7	2,285.5	0.3	1.6	1	1	1
01/01/2015 20:00	0.5	11.7	2,290.4	0.3	1.6	1	1	1
01/01/2015 21:00	0.5	11.8	2,271.5	0.3	1.6	1	1	1
01/01/2015 22:00	0.5	11.9	2,267.4	0.3	1.7	1	1	1
01/01/2015 23:00	0.4	13.0	2,024.7	0.3	1.4	1	1	1
Average/Sum#:	0.3	12.6	1,963.4	0.2	24.8 #	24 #	24 #	20 #
Minimum:	0.0	11.7	1,266.0	0.0	0.0	1	1	0
Maximum:	0.6	13.9	2,296.2	0.4	2.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/02/2015 00:00	0.3	13.1	2,002.3	0.3	1.0	1	1	1
01/02/2015 01:00	0.5	12.7	2,069.6	0.3	1.7	1	1	1
01/02/2015 02:00	0.3	13.3	1,873.1	0.3	1.0	1	1	1
01/02/2015 03:00	0.5	13.0	2,037.6	0.3	1.7	1	1	1
01/02/2015 04:00	0.3	13.2	1,987.7	0.3	1.0	1	1	1
01/02/2015 05:00	0.4	13.0	2,017.2	0.3	1.3	1	1	1
01/02/2015 06:00	0.3	13.2	1,971.1	0.2	1.0	1	1	1
01/02/2015 07:00	0.3	13.3	1,967.7	0.2	1.0	1	1	1
01/02/2015 08:00	0.3	13.3	1,909.2	0.2	1.0	1	1	1
01/02/2015 09:00	0.3	13.3	1,841.9	0.2	1.0	1	1	1
01/02/2015 10:00	0.1	13.7	1,458.5	0.2	0.3	1	1	1
01/02/2015 11:00	0.0	13.8	1,307.8	0.1	0.0	1	1	0
01/02/2015 12:00	0.0	13.8	1,304.8	0.0	0.0	1	1	0
01/02/2015 13:00	0.0	13.9	1,310.1	0.0	0.0	1	1	0
01/02/2015 14:00	0.0	13.9	1,304.5	0.0	0.0	1	1	0
01/02/2015 15:00	0.1	13.7	1,641.6	0.0	0.3	1	1	1
01/02/2015 16:00	0.3	13.3	1,900.3	0.1	1.0	1	1	1
01/02/2015 17:00	0.7	12.2	2,188.5	0.3	2.3	1	1	1
01/02/2015 18:00	0.5	11.6	2,299.0	0.3	1.6	1	1	1
01/02/2015 19:00	0.5	11.6	2,294.4	0.4	1.6	1	1	1
01/02/2015 20:00	0.5	11.6	2,295.6	0.3	1.6	1	1	1
01/02/2015 21:00	0.5	11.6	2,296.1	0.3	1.6	1	1	1
01/02/2015 22:00	0.5	11.7	2,296.8	0.3	1.6	1	1	1
01/02/2015 23:00	0.5	12.1	2,219.1	0.3	1.7	1	1	1
Average/Sum#:	0.3	12.9	1,908.1	0.2	25.3 #	24 #	24 #	20 #
Minimum:	0.0	11.6	1,304.5	0.0	0.0	1	1	0
Maximum:	0.7	13.9	2,299.0	0.4	2.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/03/2015 00:00	0.6	12.4	2,158.1	0.3	2.0	1	1	1
01/03/2015 01:00	0.6	12.0	2,246.0	0.4	2.0	1	1	1
01/03/2015 02:00	0.5	12.4	2,149.4	0.4	1.7	1	1	1
01/03/2015 03:00	0.6	12.0	2,246.3	0.4	2.0	1	1	1
01/03/2015 04:00	0.4	12.7	2,092.2	0.3	1.3	1	1	1
01/03/2015 05:00	0.4	12.9	2,042.2	0.3	1.3	1	1	1
01/03/2015 06:00	0.6	12.4	2,164.0	0.3	2.0	1	1	1
01/03/2015 07:00	0.5	12.3	2,110.4	0.3	1.6	1	1	1
01/03/2015 08:00	0.2	13.3	1,896.5	0.3	0.7	1	1	1
01/03/2015 09:00	0.3	13.3	1,843.8	0.2	1.0	1	1	1
01/03/2015 10:00	0.3	13.3	1,845.3	0.2	1.0	1	1	1
01/03/2015 11:00	0.3	13.3	1,850.6	0.2	1.0	1	1	1
01/03/2015 12:00	0.0	13.8	1,356.1	0.1	0.0	1	1	0
01/03/2015 13:00	0.0	13.8	1,304.3	0.1	0.0	1	1	0
01/03/2015 14:00	0.0	13.9	1,301.7	0.0	0.0	1	1	0
01/03/2015 15:00	0.1	13.6	1,654.7	0.0	0.3	1	1	1
01/03/2015 16:00	0.5	13.0	1,983.0	0.2	1.7	1	1	1
01/03/2015 17:00	0.7	12.3	2,178.3	0.3	2.3	1	1	1
01/03/2015 18:00	0.5	11.7	2,298.7	0.4	1.6	1	1	1
01/03/2015 19:00	0.5	11.7	2,283.4	0.4	1.6	1	1	1
01/03/2015 20:00	0.5	11.7	2,284.4	0.3	1.6	1	1	1
01/03/2015 21:00	0.5	11.7	2,293.5	0.3	1.6	1	1	1
01/03/2015 22:00	0.5	12.0	2,235.7	0.3	1.7	1	1	1
01/03/2015 23:00	0.5	12.1	2,216.2	0.3	1.7	1	1	1
Average/Sum#:	0.4	12.7	2,001.5	0.3	31.7 #	24 #	24 #	21 #
Minimum:	0.0	11.7	1,301.7	0.0	0.0	1	1	0
Maximum:	0.7	13.9	2,298.7	0.4	2.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/04/2015 00:00	0.6	12.2	2,218.4	0.3	2.0	1	1	1
01/04/2015 01:00	0.3	13.1	1,998.5	0.3	1.0	1	1	1
01/04/2015 02:00	0.2	13.2	1,983.0	0.3	0.7	1	1	1
01/04/2015 03:00	0.3	13.2	1,981.0	0.2	1.0	1	1	1
01/04/2015 04:00	0.3	13.2	1,962.4	0.2	1.0	1	1	1
01/04/2015 05:00	0.3	13.2	1,967.9	0.2	1.0	1	1	1
01/04/2015 06:00	0.6	12.6	2,119.3	0.3	2.0	1	1	1
01/04/2015 07:00	0.6	11.9	2,245.7	0.3	2.0	1	1	1
01/04/2015 08:00	0.3	13.2	1,946.0	0.3	1.0	1	1	1
01/04/2015 09:00	0.3	13.3	1,908.8	0.3	1.0	1	1	1
01/04/2015 10:00	0.3	13.3	1,893.1	0.2	1.0	1	1	1
01/04/2015 11:00	0.3	13.3	1,858.2	0.2	1.0	1	1	1
01/04/2015 12:00	0.3	13.3	1,849.9	0.2	1.0	1	1	1
01/04/2015 13:00	0.3	13.3	1,875.9	0.2	1.0	1	1	1
01/04/2015 14:00	0.4	13.1	1,989.3	0.2	1.3	1	1	1
01/04/2015 15:00	0.4	13.0	2,004.9	0.3	1.3	1	1	1
01/04/2015 16:00	0.5	12.9	2,010.1	0.3	1.7	1	1	1
01/04/2015 17:00	0.6	11.9	2,239.2	0.4	2.0	1	1	1
01/04/2015 18:00	0.5	11.6	2,308.2	0.4	1.6	1	1	1
01/04/2015 19:00	0.5	11.6	2,314.7	0.3	1.6	1	1	1
01/04/2015 20:00	0.4	11.6	2,314.8	0.3	1.3	1	1	1
01/04/2015 21:00	0.5	11.8	2,257.8	0.3	1.6	1	1	1
01/04/2015 22:00	0.4	11.9	2,239.4	0.3	1.3	1	1	1
01/04/2015 23:00	0.2	13.2	1,897.5	0.3	0.7	1	1	1
Average/Sum#:	0.4	12.7	2,057.7	0.3	31.1 #	24 #	24 #	24 #
Minimum:	0.2	11.6	1,849.9	0.2	0.7	1	1	1
Maximum:	0.6	13.3	2,314.8	0.4	2.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/05/2015 00:00	0.2	13.3	1,853.4	0.2	0.6	1	1	1
01/05/2015 01:00	0.2	13.3	1,941.2	0.2	0.7	1	1	1
01/05/2015 02:00	0.2	13.3	1,860.9	0.2	0.6	1	1	1
01/05/2015 03:00	0.3	13.2	1,969.6	0.2	1.0	1	1	1
01/05/2015 04:00	0.3	13.3	1,903.3	0.2	1.0	1	1	1
01/05/2015 05:00	0.3	13.3	1,922.6	0.2	1.0	1	1	1
01/05/2015 06:00	0.4	13.0	2,033.0	0.2	1.4	1	1	1
01/05/2015 07:00	0.7	11.9	2,283.7	0.3	2.3	1	1	1
01/05/2015 08:00	0.5	11.9	2,263.0	0.4	1.7	1	1	1
01/05/2015 09:00	0.2	13.2	1,918.7	0.3	0.7	1	1	1
01/05/2015 10:00	0.2	13.3	1,850.8	0.2	0.6	1	1	1
01/05/2015 11:00	0.1	13.3	1,849.2	0.2	0.3	1	1	1
01/05/2015 12:00	0.1	13.3	1,852.4	0.1	0.3	1	1	1
01/05/2015 13:00	0.2	13.4	1,867.2	0.1	0.7	1	1	1
01/05/2015 14:00	0.4	12.9	1,987.1	0.2	1.3	1	1	1
01/05/2015 15:00	0.3	13.0	1,966.7	0.2	1.0	1	1	1
01/05/2015 16:00	0.3	12.9	1,987.0	0.2	1.0	1	1	1
01/05/2015 17:00	0.5	11.8	2,233.2	0.2	1.6	1	1	1
01/05/2015 18:00	0.3	11.5	2,312.9	0.2	1.0	1	1	1
01/05/2015 19:00	0.3	11.4	2,317.9	0.2	1.0	1	1	1
01/05/2015 20:00	0.3	11.5	2,316.3	0.2	1.0	1	1	1
01/05/2015 21:00	0.5	12.1	2,184.4	0.2	1.6	1	1	1
01/05/2015 22:00	0.3	12.9	2,021.9	0.2	1.0	1	1	1
01/05/2015 23:00	0.1	13.4	1,709.9	0.2	0.3	1	1	1
Average/Sum#:	0.3	12.8	2,016.9	0.2	23.7 #	24 #	24 #	24 #
Minimum:	0.1	11.4	1,709.9	0.1	0.3	1	1	1
Maximum:	0.7	13.4	2,317.9	0.4	2.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/06/2015 00:00	0.0	13.8	1,436.9	0.1	0.0	1	1	0
01/06/2015 01:00	0.0	13.8	1,653.6	0.0	0.0	1	1	0
01/06/2015 02:00	0.0	13.6	1,715.2	0.0	0.0	1	1	1
01/06/2015 03:00	0.2	13.3	1,859.9	0.1	0.6	1	1	1
01/06/2015 04:00	0.2	13.3	1,859.3	0.1	0.6	1	1	1
01/06/2015 05:00	0.2	13.3	1,919.1	0.2	0.7	1	1	1
01/06/2015 06:00	0.5	12.8	2,049.0	0.3	1.7	1	1	1
01/06/2015 07:00	0.5	11.7	2,286.5	0.3	1.6	1	1	1
01/06/2015 08:00	0.5	12.5	2,085.4	0.4	1.6	1	1	1
01/06/2015 09:00	0.1	13.3	1,848.1	0.3	0.3	1	1	1
01/06/2015 10:00	0.0	13.6	1,549.8	0.2	0.0	1	1	1
01/06/2015 11:00	0.0	13.8	1,301.1	0.0	0.0	1	1	0
01/06/2015 12:00	0.0	13.9	1,301.4	0.0	0.0	1	1	0
01/06/2015 13:00	0.0	13.9	1,445.5	0.0	0.0	1	1	0
01/06/2015 14:00	0.0	13.9	1,304.6	0.0	0.0	1	1	0
01/06/2015 15:00	0.0	13.6	1,635.8	0.0	0.0	1	1	1
01/06/2015 16:00	0.3	13.1	1,931.0	0.1	1.0	1	1	1
01/06/2015 17:00	0.5	12.7	2,026.1	0.2	1.6	1	1	1
01/06/2015 18:00	0.5	12.5	2,061.5	0.3	1.6	1	1	1
01/06/2015 19:00	0.6	12.5	2,089.3	0.4	2.0	1	1	1
01/06/2015 20:00	0.5	12.2	2,136.3	0.4	1.6	1	1	1
01/06/2015 21:00	0.6	12.3	2,131.0	0.4	2.0	1	1	1
01/06/2015 22:00	0.4	12.5	2,072.2	0.3	1.3	1	1	1
01/06/2015 23:00	0.1	13.3	1,874.4	0.3	0.3	1	1	1
Average/Sum#:	0.2	13.1	1,815.5	0.2	18.5 #	24 #	24 #	18 #
Minimum:	0.0	11.7	1,301.1	0.0	0.0	1	1	0
Maximum:	0.6	13.9	2,286.5	0.4	2.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/07/2015 00:00	0.2	13.2	1,915.2	0.2	0.7	1	1	1
01/07/2015 01:00	0.2	13.3	1,868.2	0.2	0.6	1	1	1
01/07/2015 02:00	0.2	13.3	1,891.9	0.2	0.7	1	1	1
01/07/2015 03:00	0.2	13.3	1,859.0	0.2	0.6	1	1	1
01/07/2015 04:00	0.3	13.1	1,953.2	0.2	1.0	1	1	1
01/07/2015 05:00	0.2	13.2	1,903.0	0.2	0.7	1	1	1
01/07/2015 06:00	0.5	12.8	2,072.7	0.3	1.7	1	1	1
01/07/2015 07:00	0.6	12.0	2,242.6	0.3	2.0	1	1	1
01/07/2015 08:00	0.3	12.8	2,015.4	0.3	1.0	1	1	1
01/07/2015 09:00	0.1	13.3	1,891.2	0.2	0.3	1	1	1
01/07/2015 10:00	0.1	13.4	1,852.0	0.1	0.3	1	1	1
01/07/2015 11:00	0.1	13.4	1,837.5	0.1	0.3	1	1	1
01/07/2015 12:00	0.0	13.9	1,307.2	0.1	0.0	1	1	0
01/07/2015 13:00	0.0	13.8	1,493.8	0.0	0.0	1	1	0
01/07/2015 14:00	0.0	13.9	1,559.2	0.0	0.0	1	1	1
01/07/2015 15:00	0.5	12.8	1,992.1	0.1	1.6	1	1	1
01/07/2015 16:00	0.4	12.9	1,973.7	0.2	1.3	1	1	1
01/07/2015 17:00	0.5	11.9	2,181.5	0.3	1.6	1	1	1
01/07/2015 18:00	0.5	12.6	2,054.2	0.3	1.6	1	1	1
01/07/2015 19:00	0.5	12.8	2,015.1	0.4	1.6	1	1	1
01/07/2015 20:00	0.5	12.7	2,017.2	0.4	1.6	1	1	1
01/07/2015 21:00	0.5	12.7	2,024.6	0.4	1.6	1	1	1
01/07/2015 22:00	0.3	13.1	1,926.2	0.3	1.0	1	1	1
01/07/2015 23:00	0.2	13.4	1,853.9	0.3	0.7	1	1	1
Average/Sum#:	0.3	13.1	1,904.2	0.2	22.5 #	24 #	24 #	22 #
Minimum:	0.0	11.9	1,307.2	0.0	0.0	1	1	0
Maximum:	0.6	13.9	2,242.6	0.4	2.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/08/2015 00:00	0.2	13.4	1,847.6	0.2	0.7	1	1	1
01/08/2015 01:00	0.2	13.4	1,849.2	0.2	0.7	1	1	1
01/08/2015 02:00	0.2	13.4	1,847.0	0.2	0.7	1	1	1
01/08/2015 03:00	0.2	13.4	1,849.8	0.2	0.7	1	1	1
01/08/2015 04:00	0.2	13.3	1,846.5	0.2	0.6	1	1	1
01/08/2015 05:00	0.2	13.3	1,851.9	0.2	0.6	1	1	1
01/08/2015 06:00	0.5	12.7	2,075.8	0.3	1.7	1	1	1
01/08/2015 07:00	0.5	11.6	2,294.9	0.3	1.6	1	1	1
01/08/2015 08:00	0.5	11.7	2,266.0	0.3	1.6	1	1	1
01/08/2015 09:00	0.6	12.1	2,179.1	0.3	2.0	1	1	1
01/08/2015 10:00	0.6	12.6	2,060.4	0.4	2.0	1	1	1
01/08/2015 11:00	0.4	12.9	1,982.2	0.4	1.3	1	1	1
01/08/2015 12:00	0.4	12.8	2,014.7	0.3	1.3	1	1	1
01/08/2015 13:00	0.5	12.4	2,089.5	0.3	1.6	1	1	1
01/08/2015 14:00	0.5	12.5	2,081.3	0.3	1.6	1	1	1
01/08/2015 15:00	0.3	11.5	2,269.6	0.3	1.0	1	1	1
01/08/2015 16:00	0.4	12.6	2,021.7	0.3	1.3	1	1	1
01/08/2015 17:00	0.5	12.5	2,052.3	0.3	1.6	1	1	1
01/08/2015 18:00	0.5	12.5	2,057.4	0.4	1.6	1	1	1
01/08/2015 19:00	0.5	12.8	2,002.1	0.4	1.6	1	1	1
01/08/2015 20:00	0.5	12.7	2,016.5	0.4	1.6	1	1	1
01/08/2015 21:00	0.5	12.3	2,103.7	0.4	1.6	1	1	1
01/08/2015 22:00	0.5	12.7	2,016.7	0.4	1.6	1	1	1
01/08/2015 23:00	0.3	13.1	1,908.7	0.3	1.0	1	1	1
Average/Sum#:	0.4	12.7	2,024.4	0.3	31.6 #	24 #	24 #	24 #
Minimum:	0.2	11.5	1,846.5	0.2	0.6	1	1	1
Maximum:	0.6	13.4	2,294.9	0.4	2.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/09/2015 00:00	0.3	13.1	1,941.5	0.3	1.0	1	1	1
01/09/2015 01:00	0.2	13.3	1,889.2	0.2	0.7	1	1	1
01/09/2015 02:00	0.2	13.3	1,852.4	0.2	0.6	1	1	1
01/09/2015 03:00	0.3	13.2	1,916.3	0.2	1.0	1	1	1
01/09/2015 04:00	0.2	13.4	1,858.6	0.2	0.7	1	1	1
01/09/2015 05:00	0.2	13.3	1,900.8	0.2	0.7	1	1	1
01/09/2015 06:00	0.3	13.1	1,945.7	0.2	1.0	1	1	1
01/09/2015 07:00	0.7	12.4	2,144.4	0.3	2.3	1	1	1
01/09/2015 08:00	0.5	11.6	2,282.1	0.3	1.6	1	1	1
01/09/2015 09:00	0.4	12.6	2,050.6	0.4	1.3	1	1	1
01/09/2015 10:00	0.5	11.9	2,217.9	0.3	1.6	1	1	1
01/09/2015 11:00	0.5	11.7	2,236.5	0.3	1.6	1	1	1
01/09/2015 12:00	0.2	13.3	1,889.8	0.3	0.7	1	1	1
01/09/2015 13:00	0.1	13.5	1,693.1	0.2	0.3	1	1	1
01/09/2015 14:00	0.0	13.9	1,388.3	0.1	0.0	1	1	0
01/09/2015 15:00	0.0	13.9	1,374.8	0.0	0.0	1	1	0
01/09/2015 16:00	0.2	13.4	1,692.6	0.1	0.6	1	1	1
01/09/2015 17:00	0.2	13.3	1,881.0	0.1	0.7	1	1	1
01/09/2015 18:00	0.2	13.3	1,794.7	0.2	0.6	1	1	1
01/09/2015 19:00	0.1	13.4	1,802.3	0.2	0.3	1	1	1
01/09/2015 20:00	0.2	13.4	1,872.3	0.2	0.7	1	1	1
01/09/2015 21:00	0.2	13.4	1,879.5	0.2	0.7	1	1	1
01/09/2015 22:00	0.3	13.2	1,918.2	0.2	1.0	1	1	1
01/09/2015 23:00	0.4	13.0	1,968.5	0.2	1.3	1	1	1
Average/Sum#:	0.3	13.1	1,891.3	0.2	21.0 #	24 #	24 #	22 #
Minimum:	0.0	11.6	1,374.8	0.0	0.0	1	1	0
Maximum:	0.7	13.9	2,282.1	0.4	2.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/10/2015 00:00	0.2	13.4	1,871.5	0.2	0.7	1	1	1
01/10/2015 01:00	0.2	13.5	1,845.4	0.2	0.7	1	1	1
01/10/2015 02:00	0.0	13.6	1,705.9	0.1	0.0	1	1	1
01/10/2015 03:00	0.0	13.9	1,360.4	0.1	0.0	1	1	0
01/10/2015 04:00	0.1	13.6	1,625.7	0.0	0.3	1	1	1
01/10/2015 05:00	0.3	13.3	1,899.5	0.1	1.0	1	1	1
01/10/2015 06:00	0.3	13.1	1,942.2	0.2	1.0	1	1	1
01/10/2015 07:00	0.3	13.1	1,956.5	0.2	1.0	1	1	1
01/10/2015 08:00	0.3	13.3	1,876.0	0.2	1.0	1	1	1
01/10/2015 09:00	0.3	13.3	1,856.3	0.2	1.0	1	1	1
01/10/2015 10:00	0.4	13.1	1,964.4	0.2	1.3	1	1	1
01/10/2015 11:00	0.7	11.9	2,216.0	0.3	2.3	1	1	1
01/10/2015 12:00	0.6	12.0	2,169.9	0.4	1.9	1	1	1
01/10/2015 13:00	0.4	13.1	1,939.5	0.4	1.3	1	1	1
01/10/2015 14:00	0.6	12.8	1,999.8	0.4	2.0	1	1	1
01/10/2015 15:00	0.3	13.4	1,863.8	0.3	1.0	1	1	1
01/10/2015 16:00	0.3	13.2	1,899.6	0.3	1.0	1	1	1
01/10/2015 17:00	0.6	12.6	2,055.6	0.3	2.0	1	1	1
01/10/2015 18:00	0.5	12.9	1,985.0	0.3	1.6	1	1	1
01/10/2015 19:00	0.6	12.6	2,057.1	0.4	2.0	1	1	1
01/10/2015 20:00	0.5	11.6	2,267.6	0.4	1.6	1	1	1
01/10/2015 21:00	0.6	12.3	2,106.3	0.4	1.9	1	1	1
01/10/2015 22:00	0.5	12.7	2,026.5	0.4	1.6	1	1	1
01/10/2015 23:00	0.3	13.2	1,906.6	0.3	1.0	1	1	1
Average/Sum#:	0.4	13.0	1,933.2	0.3	29.2 #	24 #	24 #	23 #
Minimum:	0.0	11.6	1,360.4	0.0	0.0	1	1	0
Maximum:	0.7	13.9	2,267.6	0.4	2.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/11/2015 00:00	0.3	13.2	1,911.0	0.3	1.0	1	1	1
01/11/2015 01:00	0.3	13.2	1,915.6	0.2	1.0	1	1	1
01/11/2015 02:00	0.3	13.2	1,925.5	0.2	1.0	1	1	1
01/11/2015 03:00	0.3	13.4	1,855.6	0.2	1.0	1	1	1
01/11/2015 04:00	0.3	13.4	1,852.0	0.2	1.0	1	1	1
01/11/2015 05:00	0.3	13.3	1,889.3	0.2	1.0	1	1	1
01/11/2015 06:00	0.3	13.3	1,884.5	0.2	1.0	1	1	1
01/11/2015 07:00	0.3	13.2	1,927.2	0.2	1.0	1	1	1
01/11/2015 08:00	0.6	12.5	2,100.2	0.3	2.0	1	1	1
01/11/2015 09:00	0.6	11.7	2,268.5	0.3	2.0	1	1	1
01/11/2015 10:00	0.5	11.7	2,254.0	0.4	1.6	1	1	1
01/11/2015 11:00	0.5	12.1	2,168.1	0.3	1.6	1	1	1
01/11/2015 12:00	0.4	12.9	1,985.3	0.3	1.3	1	1	1
01/11/2015 13:00	0.4	12.9	1,980.1	0.3	1.3	1	1	1
01/11/2015 14:00	0.3	13.2	1,914.8	0.3	1.0	1	1	1
01/11/2015 15:00	0.6	12.9	2,005.7	0.3	2.0	1	1	1
01/11/2015 16:00	0.3	13.3	1,903.9	0.3	1.0	1	1	1
01/11/2015 17:00	0.6	12.3	2,127.9	0.3	2.0	1	1	1
01/11/2015 18:00	0.5	12.3	2,130.6	0.3	1.6	1	1	1
01/11/2015 19:00	0.5	11.8	2,223.7	0.3	1.6	1	1	1
01/11/2015 20:00	0.5	12.3	2,117.4	0.3	1.6	1	1	1
01/11/2015 21:00	0.6	12.1	2,149.3	0.3	1.9	1	1	1
01/11/2015 22:00	0.4	13.0	1,946.8	0.3	1.3	1	1	1
01/11/2015 23:00	0.3	13.4	1,850.7	0.3	1.0	1	1	1
Average/Sum#:	0.4	12.8	2,012.0	0.3	32.8 #	24 #	24 #	24 #
Minimum:	0.3	11.7	1,850.7	0.2	1.0	1	1	1
Maximum:	0.6	13.4	2,268.5	0.4	2.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/12/2015 00:00	0.4	13.1	1,953.1	0.3	1.3	1	1	1
01/12/2015 01:00	0.3	13.3	1,886.0	0.2	1.0	1	1	1
01/12/2015 02:00	0.3	13.3	1,888.2	0.2	1.0	1	1	1
01/12/2015 03:00	0.3	13.2	1,940.7	0.2	1.0	1	1	1
01/12/2015 04:00	0.3	13.2	1,920.1	0.2	1.0	1	1	1
01/12/2015 05:00	0.3	13.2	1,912.7	0.2	1.0	1	1	1
01/12/2015 06:00	0.4	13.0	2,000.2	0.2	1.3	1	1	1
01/12/2015 07:00	0.4	13.0	1,981.3	0.3	1.3	1	1	1
01/12/2015 08:00	0.3	13.1	1,982.8	0.3	1.0	1	1	1
01/12/2015 09:00	0.7	12.5	2,097.7	0.3	2.3	1	1	1
01/12/2015 10:00	0.5	12.8	2,020.9	0.4	1.6	1	1	1
01/12/2015 11:00	0.2	13.3	1,862.6	0.4	0.6	1	1	1
01/12/2015 12:00	0.2	13.4	1,857.0	0.3	0.7	1	1	1
01/12/2015 13:00	0.3	13.4	1,859.2	0.2	1.0	1	1	1
01/12/2015 14:00	0.3	13.4	1,864.3	0.2	1.0	1	1	1
01/12/2015 15:00	0.3	13.4	1,867.7	0.2	1.0	1	1	1
01/12/2015 16:00	0.3	13.3	1,900.6	0.2	1.0	1	1	1
01/12/2015 17:00	0.5	12.9	1,982.6	0.3	1.6	1	1	1
01/12/2015 18:00	0.5	11.8	2,237.2	0.3	1.6	1	1	1
01/12/2015 19:00	0.5	11.5	2,283.9	0.3	1.6	1	1	1
01/12/2015 20:00	0.4	11.5	2,289.6	0.3	1.3	1	1	1
01/12/2015 21:00	0.5	11.9	2,204.2	0.3	1.6	1	1	1
01/12/2015 22:00	0.5	12.4	2,108.4	0.3	1.6	1	1	1
01/12/2015 23:00	0.3	13.1	1,927.1	0.3	1.0	1	1	1
Average/Sum#:	0.4	12.9	1,992.8	0.3	29.4 #	24 #	24 #	24 #
Minimum:	0.2	11.5	1,857.0	0.2	0.6	1	1	1
Maximum:	0.7	13.4	2,289.6	0.4	2.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/13/2015 00:00	0.5	12.8	2,016.7	0.3	1.6	1	1	1
01/13/2015 01:00	0.5	12.8	2,008.9	0.3	1.6	1	1	1
01/13/2015 02:00	0.5	12.9	2,001.1	0.4	1.7	1	1	1
01/13/2015 03:00	0.4	13.0	1,971.8	0.4	1.3	1	1	1
01/13/2015 04:00	0.3	13.2	1,929.0	0.3	1.0	1	1	1
01/13/2015 05:00	0.2	13.4	1,860.4	0.2	0.7	1	1	1
01/13/2015 06:00	0.3	13.2	1,916.4	0.2	1.0	1	1	1
01/13/2015 07:00	0.6	12.9	2,011.1	0.3	2.0	1	1	1
01/13/2015 08:00	0.3	13.2	1,934.7	0.3	1.0	1	1	1
01/13/2015 09:00	0.3	13.4	1,878.3	0.3	1.0	1	1	1
01/13/2015 10:00	0.6	12.9	2,002.5	0.3	2.0	1	1	1
01/13/2015 11:00	0.5	12.8	2,012.3	0.3	1.6	1	1	1
01/13/2015 12:00	0.4	13.1	1,936.1	0.4	1.3	1	1	1
01/13/2015 13:00	0.4	13.0	1,959.1	0.3	1.3	1	1	1
01/13/2015 14:00	0.4	13.1	1,929.7	0.3	1.3	1	1	1
01/13/2015 15:00	0.3	13.3	1,905.9	0.3	1.0	1	1	1
01/13/2015 16:00	0.3	13.3	1,907.8	0.2	1.0	1	1	1
01/13/2015 17:00	0.6	12.3	2,138.0	0.3	2.0	1	1	1
01/13/2015 18:00	0.5	11.6	2,281.6	0.3	1.6	1	1	1
01/13/2015 19:00	0.5	11.6	2,281.2	0.3	1.6	1	1	1
01/13/2015 20:00	0.4	11.6	2,277.2	0.3	1.3	1	1	1
01/13/2015 21:00	0.5	12.0	2,191.4	0.3	1.6	1	1	1
01/13/2015 22:00	0.5	12.3	2,109.5	0.3	1.6	1	1	1
01/13/2015 23:00	0.0	13.6	1,633.9	0.2	0.0	1	1	1
Average/Sum#:	0.4	12.8	2,003.9	0.3	32.1 #	24 #	24 #	24 #
Minimum:	0.0	11.6	1,633.9	0.2	0.0	1	1	1
Maximum:	0.6	13.6	2,281.6	0.4	2.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/14/2015 00:00	0.0	13.9	1,341.9	0.1	0.0	1	1	0
01/14/2015 01:00	0.0	13.8	1,577.7	0.0	0.0	1	1	0
01/14/2015 02:00	0.1	13.6	1,700.8	0.0	0.3	1	1	1
01/14/2015 03:00	0.4	13.2	1,925.6	0.1	1.3	1	1	1
01/14/2015 04:00	0.4	13.2	1,965.7	0.2	1.3	1	1	1
01/14/2015 05:00	0.4	13.3	1,872.9	0.3	1.3	1	1	1
01/14/2015 06:00	0.5	13.0	1,972.6	0.3	1.6	1	1	1
01/14/2015 07:00	0.8	12.0	2,240.7	0.4	2.7	1	1	1
01/14/2015 08:00	0.6	12.5	2,105.1	0.4	2.0	1	1	1
01/14/2015 09:00	0.3	13.1	1,965.4	0.4	1.0	1	1	1
01/14/2015 10:00	0.3	13.2	1,885.7	0.3	1.0	1	1	1
01/14/2015 11:00	0.3	13.3	1,852.0	0.2	1.0	1	1	1
01/14/2015 12:00	0.3	13.3	1,853.9	0.2	1.0	1	1	1
01/14/2015 13:00	0.3	13.3	1,861.5	0.2	1.0	1	1	1
01/14/2015 14:00	0.4	13.4	1,867.5	0.2	1.3	1	1	1
01/14/2015 15:00	0.4	13.4	1,878.6	0.3	1.3	1	1	1
01/14/2015 16:00	0.4	13.3	1,923.3	0.3	1.3	1	1	1
01/14/2015 17:00	0.7	12.5	2,109.9	0.4	2.3	1	1	1
01/14/2015 18:00	0.6	11.6	2,287.7	0.4	1.9	1	1	1
01/14/2015 19:00	0.5	11.7	2,287.9	0.4	1.6	1	1	1
01/14/2015 20:00	0.5	11.7	2,286.7	0.3	1.6	1	1	1
01/14/2015 21:00	0.5	11.8	2,273.1	0.3	1.6	1	1	1
01/14/2015 22:00	0.5	12.6	2,076.8	0.3	1.7	1	1	1
01/14/2015 23:00	0.3	13.4	1,878.2	0.3	1.0	1	1	1
Average/Sum#:	0.4	12.9	1,958.0	0.3	31.1 #	24 #	24 #	22 #
Minimum:	0.0	11.6	1,341.9	0.0	0.0	1	1	0
Maximum:	0.8	13.9	2,287.9	0.4	2.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/15/2015 00:00	0.3	13.3	1,903.4	0.3	1.0	1	1	1
01/15/2015 01:00	0.3	13.4	1,848.5	0.2	1.0	1	1	1
01/15/2015 02:00	0.3	13.4	1,846.5	0.2	1.0	1	1	1
01/15/2015 03:00	0.3	13.4	1,851.6	0.2	1.0	1	1	1
01/15/2015 04:00	0.3	13.4	1,859.6	0.2	1.0	1	1	1
01/15/2015 05:00	0.3	13.4	1,856.0	0.2	1.0	1	1	1
01/15/2015 06:00	0.5	13.1	1,984.5	0.3	1.7	1	1	1
01/15/2015 07:00	0.8	12.3	2,207.9	0.4	2.7	1	1	1
01/15/2015 08:00	0.4	13.0	1,979.3	0.4	1.3	1	1	1
01/15/2015 09:00	0.1	13.6	1,572.7	0.3	0.3	1	1	1
01/15/2015 10:00	0.0	13.9	1,302.2	0.1	0.0	1	1	0
01/15/2015 11:00	0.0	13.9	1,304.2	0.0	0.0	1	1	0
01/15/2015 12:00	0.0	13.9	1,304.0	0.0	0.0	1	1	0
01/15/2015 13:00	0.0	13.9	1,299.9	0.0	0.0	1	1	0
01/15/2015 14:00	0.0	13.9	1,299.7	0.0	0.0	1	1	0
01/15/2015 15:00	0.0	13.9	1,332.8	0.0	0.0	1	1	0
01/15/2015 16:00	0.3	13.4	1,880.8	0.1	1.0	1	1	1
01/15/2015 17:00	0.7	12.1	2,218.1	0.2	2.3	1	1	1
01/15/2015 18:00	0.1	13.2	1,881.3	0.3	0.3	1	1	1
01/15/2015 19:00	0.4	12.7	2,065.5	0.3	1.3	1	1	1
01/15/2015 20:00	0.6	12.6	2,066.1	0.3	2.0	1	1	1
01/15/2015 21:00	0.6	12.6	2,090.5	0.4	2.0	1	1	1
01/15/2015 22:00	0.6	12.3	2,133.8	0.4	2.0	1	1	1
01/15/2015 23:00	0.2	13.2	1,881.8	0.3	0.6	1	1	1
Average/Sum#:	0.3	13.2	1,790.4	0.2	23.5 #	24 #	24 #	18 #
Minimum:	0.0	12.1	1,299.7	0.0	0.0	1	1	0
Maximum:	0.8	13.9	2,218.1	0.4	2.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/16/2015 00:00	0.2	13.3	1,845.7	0.3	0.6	1	1	1
01/16/2015 01:00	0.3	13.3	1,848.6	0.2	1.0	1	1	1
01/16/2015 02:00	0.3	13.3	1,853.9	0.2	1.0	1	1	1
01/16/2015 03:00	0.1	13.6	1,622.1	0.2	0.3	1	1	1
01/16/2015 04:00	0.0	13.9	1,320.0	0.1	0.0	1	1	0
01/16/2015 05:00	0.3	13.4	1,834.2	0.1	1.0	1	1	1
01/16/2015 06:00	0.5	13.1	1,954.4	0.2	1.7	1	1	1
01/16/2015 07:00	0.7	12.1	2,204.3	0.4	2.3	1	1	1
01/16/2015 08:00	0.4	13.2	1,929.8	0.4	1.3	1	1	1
01/16/2015 09:00	0.2	13.5	1,853.0	0.3	0.7	1	1	1
01/16/2015 10:00	0.2	13.5	1,870.6	0.2	0.7	1	1	1
01/16/2015 11:00	0.2	13.4	1,888.8	0.2	0.7	1	1	1
01/16/2015 12:00	0.1	13.7	1,475.3	0.2	0.3	1	1	1
01/16/2015 13:00	0.0	13.9	1,284.5	0.1	0.0	1	1	0
01/16/2015 14:00	0.0	13.9	1,281.9	0.0	0.0	1	1	0
01/16/2015 15:00	0.0	13.9	1,282.9	0.0	0.0	1	1	0
01/16/2015 16:00	0.4	13.3	1,750.4	0.1	1.2	1	0	1
01/16/2015 17:00	0.7	12.9	1,903.4	0.3	2.2	1	0	1
01/16/2015 18:00	0.0	13.9	1,333.6	0.3	0.0	1	0	0
01/16/2015 19:00	0.0	13.9	1,294.3	0.2	0.0	1	1	0
01/16/2015 20:00	0.0	13.9	1,299.4	0.0	0.0	1	1	0
01/16/2015 21:00	0.0	13.9	1,317.3	0.0	0.0	1	1	0
01/16/2015 22:00	0.0	13.9	1,521.6	0.0	0.0	1	1	0
01/16/2015 23:00	0.0	13.9	1,306.3	0.0	0.0	1	1	0
Average/Sum#:	0.2	13.5	1,628.2	0.2	15.0 #	24 #	21 #	14 #
Minimum:	0.0	12.1	1,281.9	0.0	0.0	1	0	0
Maximum:	0.7	13.9	2,204.3	0.4	2.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/17/2015 00:00	0.0	13.9	1,326.5	0.0	0.0	1	1	0
01/17/2015 01:00	0.0	13.9	1,539.9	0.0	0.0	1	1	0
01/17/2015 02:00	0.0	13.9	1,429.4	0.0	0.0	1	1	0
01/17/2015 03:00	0.0	13.9	1,598.8	0.0	0.0	1	1	0
01/17/2015 04:00	0.0	13.9	1,318.4	0.0	0.0	1	1	0
01/17/2015 05:00	0.0	13.9	1,356.8	0.0	0.0	1	1	0
01/17/2015 06:00	0.0	13.8	1,821.6	0.0	0.0	1	1	1
01/17/2015 07:00	0.0	13.7	1,845.6	0.0	0.0	1	1	0
01/17/2015 08:00	0.0	13.8	1,816.3	0.0	0.0	1	1	1
01/17/2015 09:00	0.0	13.9	1,794.9	0.0	0.0	1	1	1
01/17/2015 10:00	0.1	13.6	1,819.4	0.0	0.3	1	1	1
01/17/2015 11:00	0.2	13.6	1,851.1	0.1	0.7	1	1	1
01/17/2015 12:00	0.2	13.6	1,856.8	0.2	0.7	1	1	1
01/17/2015 13:00	0.0	13.7	1,574.4	0.1	0.0	1	1	1
01/17/2015 14:00	0.0	13.9	1,302.1	0.1	0.0	1	1	0
01/17/2015 15:00	0.0	13.9	1,302.3	0.0	0.0	1	1	0
01/17/2015 16:00	0.1	13.7	1,631.7	0.0	0.3	1	1	1
01/17/2015 17:00	0.4	13.1	1,944.3	0.1	1.3	1	1	1
01/17/2015 18:00	0.7	12.0	2,197.9	0.3	2.3	1	1	1
01/17/2015 19:00	0.5	12.2	2,138.8	0.4	1.6	1	1	1
01/17/2015 20:00	0.4	12.9	2,006.3	0.4	1.3	1	1	1
01/17/2015 21:00	0.6	12.7	2,042.8	0.3	2.0	1	1	1
01/17/2015 22:00	0.5	12.8	2,036.5	0.4	1.7	1	1	1
01/17/2015 23:00	0.6	12.7	2,050.7	0.4	2.0	1	1	1
Average/Sum#:	0.2	13.5	1,733.5	0.1	14.2 #	24 #	24 #	15 #
Minimum:	0.0	12.0	1,302.1	0.0	0.0	1	1	0
Maximum:	0.7	13.9	2,197.9	0.4	2.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/18/2015 00:00	0.3	13.0	1,973.6	0.3	1.0	1	1	1
01/18/2015 01:00	0.2	13.4	1,781.2	0.3	0.6	1	1	1
01/18/2015 02:00	8.9	15.0	891.9	0.0	7.5	1	0	0
01/18/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/18/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/18/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/18/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/18/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/18/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/18/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/18/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/18/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/18/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
01/18/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
01/18/2015 14:00	26.0	17.7	462.1	0.0	21.3	1	1	0
01/18/2015 15:00	27.9	15.7	787.3	0.0	55.8	1	1	0
01/18/2015 16:00	0.0	13.9	1,439.7	0.0	0.0	1	1	1
01/18/2015 17:00	0.2	13.3	1,908.4	0.0	0.7	1	1	1
01/18/2015 18:00	0.4	12.9	2,006.6	0.0	1.3	1	1	1
01/18/2015 19:00	0.4	13.0	2,002.9	0.3	1.3	1	1	1
01/18/2015 20:00	0.4	13.1	1,973.4	0.3	1.3	1	1	1
01/18/2015 21:00	0.2	13.4	1,910.9	0.3	0.7	1	1	1
01/18/2015 22:00	0.0	13.9	1,474.8	0.2	0.0	1	1	0
01/18/2015 23:00	0.0	13.9	1,303.8	0.1	0.0	1	1	0
Average/Sum#:	5.0	14.0	1,532.0	0.3	91.5 #	13 #	14 #	8 #
Minimum:	0.0	12.9	462.1	0.1	0.0	0	0	0
Maximum:	27.9	17.7	2,006.6	0.3	55.8	1	1	1
%SI	45.8	45.8	45.8	70.8	45.8	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/19/2015 00:00	0.0	13.9	1,510.2	0.0	0.0	1	1	0
01/19/2015 01:00	0.0	13.9	1,353.2	0.0	0.0	1	1	0
01/19/2015 02:00	0.0	13.9	1,305.2	0.0	0.0	1	1	0
01/19/2015 03:00	0.0	13.8	1,577.9	0.0	0.0	1	1	0
01/19/2015 04:00	0.3	13.3	1,894.6	0.1	1.0	1	1	1
01/19/2015 05:00	0.3	13.1	1,977.8	0.1	1.0	1	1	1
01/19/2015 06:00	0.3	13.1	1,986.1	0.2	1.0	1	1	1
01/19/2015 07:00	0.7	12.7	2,082.5	0.3	2.3	1	1	1
01/19/2015 08:00	0.2	13.3	1,928.6	0.3	0.7	1	1	1
01/19/2015 09:00	0.2	13.4	1,895.4	0.3	0.7	1	1	1
01/19/2015 10:00	0.3	13.3	1,928.8	0.2	1.0	1	1	1
01/19/2015 11:00	0.2	13.4	1,857.5	0.2	0.7	1	1	1
01/19/2015 12:00	0.2	13.4	1,868.9	0.2	0.7	1	1	1
01/19/2015 13:00	0.2	13.4	1,866.3	0.2	0.7	1	1	1
01/19/2015 14:00	0.2	13.4	1,870.6	0.2	0.7	1	1	1
01/19/2015 15:00	0.3	13.3	1,913.8	0.2	1.0	1	1	1
01/19/2015 16:00	0.3	13.1	1,961.9	0.2	1.0	1	1	1
01/19/2015 17:00	0.5	12.8	2,029.6	0.3	1.7	1	1	1
01/19/2015 18:00	0.7	12.4	2,104.2	0.4	2.3	1	1	1
01/19/2015 19:00	0.7	12.5	2,085.0	0.5	2.3	1	1	1
01/19/2015 20:00	0.6	12.7	2,048.2	0.5	2.0	1	1	1
01/19/2015 21:00	0.5	12.8	2,029.3	0.4	1.7	1	1	1
01/19/2015 22:00	0.3	13.2	1,922.5	0.3	1.0	1	1	1
01/19/2015 23:00	0.2	13.3	1,857.9	0.3	0.6	1	1	1
Average/Sum#:	0.3	13.2	1,869.0	0.2	24.1 #	24 #	24 #	20 #
Minimum:	0.0	12.4	1,305.2	0.0	0.0	1	1	0
Maximum:	0.7	13.9	2,104.2	0.5	2.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/20/2015 00:00	0.3	13.2	1,947.2	0.2	1.0	1	1	1
01/20/2015 01:00	0.2	13.3	1,850.9	0.2	0.6	1	1	1
01/20/2015 02:00	0.2	13.3	1,852.8	0.2	0.6	1	1	1
01/20/2015 03:00	0.2	13.3	1,854.0	0.2	0.6	1	1	1
01/20/2015 04:00	0.2	13.3	1,855.6	0.2	0.6	1	1	1
01/20/2015 05:00	0.2	13.3	1,854.3	0.2	0.6	1	1	1
01/20/2015 06:00	0.4	13.1	1,982.8	0.2	1.3	1	1	1
01/20/2015 07:00	0.4	13.0	2,013.5	0.3	1.3	1	1	1
01/20/2015 08:00	0.5	13.0	2,022.0	0.3	1.7	1	1	1
01/20/2015 09:00	0.5	13.0	2,018.2	0.4	1.7	1	1	1
01/20/2015 10:00	0.4	13.0	2,003.5	0.4	1.3	1	1	1
01/20/2015 11:00	0.5	12.9	2,018.4	0.4	1.7	1	1	1
01/20/2015 12:00	0.6	12.8	2,025.1	0.4	2.0	1	1	1
01/20/2015 13:00	0.5	12.9	2,003.4	0.4	1.7	1	1	1
01/20/2015 14:00	0.5	12.9	2,013.9	0.4	1.7	1	1	1
01/20/2015 15:00	0.6	12.8	2,032.1	0.4	2.0	1	1	1
01/20/2015 16:00	0.2	13.3	1,880.4	0.3	0.7	1	1	1
01/20/2015 17:00	0.3	13.2	1,909.7	0.3	1.0	1	1	1
01/20/2015 18:00	0.6	12.8	2,028.4	0.3	2.0	1	1	1
01/20/2015 19:00	0.6	12.8	2,040.7	0.3	2.0	1	1	1
01/20/2015 20:00	0.5	12.9	2,003.2	0.4	1.7	1	1	1
01/20/2015 21:00	0.5	12.9	2,023.2	0.4	1.7	1	1	1
01/20/2015 22:00	0.4	13.1	1,980.3	0.4	1.3	1	1	1
01/20/2015 23:00	0.2	13.5	1,852.4	0.3	0.7	1	1	1
Average/Sum#:	0.4	13.1	1,961.1	0.3	31.5 #	24 #	24 #	24 #
Minimum:	0.2	12.8	1,850.9	0.2	0.6	1	1	1
Maximum:	0.6	13.5	2,040.7	0.4	2.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/21/2015 00:00	0.1	13.6	1,873.4	0.2	0.3	1	1	1
01/21/2015 01:00	0.1	13.6	1,858.6	0.1	0.3	1	1	1
01/21/2015 02:00	0.2	13.5	1,891.8	0.1	0.7	1	1	1
01/21/2015 03:00	0.1	13.6	1,850.1	0.1	0.3	1	1	1
01/21/2015 04:00	0.2	13.5	1,863.1	0.2	0.7	1	1	1
01/21/2015 05:00	0.3	13.4	1,857.4	0.2	1.0	1	1	1
01/21/2015 06:00	0.3	13.3	1,940.4	0.2	1.0	1	1	1
01/21/2015 07:00	0.4	13.1	1,997.6	0.2	1.4	1	1	1
01/21/2015 08:00	0.6	12.9	2,042.0	0.3	2.0	1	1	1
01/21/2015 09:00	0.5	12.9	2,011.3	0.4	1.7	1	1	1
01/21/2015 10:00	0.3	13.2	1,940.3	0.3	1.0	1	1	1
01/21/2015 11:00	0.3	13.2	1,935.7	0.3	1.0	1	1	1
01/21/2015 12:00	0.3	13.3	1,916.2	0.2	1.0	1	1	1
01/21/2015 13:00	0.2	13.4	1,872.3	0.2	0.7	1	1	1
01/21/2015 14:00	0.2	13.5	1,861.8	0.2	0.7	1	1	1
01/21/2015 15:00	0.3	13.2	1,928.0	0.2	1.0	1	1	1
01/21/2015 16:00	0.4	13.0	1,961.3	0.2	1.3	1	1	1
01/21/2015 17:00	0.4	12.9	1,993.4	0.3	1.3	1	1	1
01/21/2015 18:00	0.6	12.7	2,035.7	0.3	2.0	1	1	1
01/21/2015 19:00	0.6	12.8	2,030.6	0.4	2.0	1	1	1
01/21/2015 20:00	0.4	13.0	2,003.0	0.4	1.3	1	1	1
01/21/2015 21:00	0.4	13.0	1,994.4	0.3	1.3	1	1	1
01/21/2015 22:00	0.3	13.2	1,917.5	0.3	1.0	1	1	1
01/21/2015 23:00	0.0	13.7	1,560.2	0.2	0.0	1	1	1
Average/Sum#:	0.3	13.2	1,922.3	0.2	25.0 #	24 #	24 #	24 #
Minimum:	0.0	12.7	1,560.2	0.1	0.0	1	1	1
Maximum:	0.6	13.7	2,042.0	0.4	2.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/22/2015 00:00	0.0	13.9	1,405.6	0.1	0.0	1	1	0
01/22/2015 01:00	0.0	13.9	1,300.1	0.0	0.0	1	1	0
01/22/2015 02:00	0.0	13.9	1,312.8	0.0	0.0	1	1	0
01/22/2015 03:00	0.1	13.8	1,568.1	0.0	0.3	1	1	1
01/22/2015 04:00	0.3	13.3	1,873.8	0.1	1.0	1	1	1
01/22/2015 05:00	0.3	13.3	1,859.5	0.2	1.0	1	1	1
01/22/2015 06:00	0.3	13.2	1,920.1	0.2	1.0	1	1	1
01/22/2015 07:00	0.5	12.9	2,005.8	0.3	1.7	1	1	1
01/22/2015 08:00	0.4	13.1	1,977.5	0.3	1.3	1	1	1
01/22/2015 09:00	0.5	13.0	2,010.7	0.4	1.7	1	1	1
01/22/2015 10:00	0.2	13.3	1,862.6	0.3	0.6	1	1	1
01/22/2015 11:00	0.3	13.3	1,854.4	0.3	1.0	1	1	1
01/22/2015 12:00	0.3	13.3	1,849.5	0.2	1.0	1	1	1
01/22/2015 13:00	0.0	13.7	1,506.2	0.1	0.0	1	1	1
01/22/2015 14:00	0.0	13.9	1,646.5	0.1	0.0	1	1	0
01/22/2015 15:00	0.1	13.6	1,733.1	0.0	0.3	1	1	1
01/22/2015 16:00	0.3	13.4	1,854.7	0.1	1.0	1	1	1
01/22/2015 17:00	0.4	13.1	1,966.0	0.2	1.3	1	1	1
01/22/2015 18:00	0.6	12.8	2,038.4	0.3	2.0	1	1	1
01/22/2015 19:00	0.5	12.9	2,028.0	0.4	1.7	1	1	1
01/22/2015 20:00	0.4	13.1	1,991.3	0.4	1.3	1	1	1
01/22/2015 21:00	0.3	13.2	1,951.3	0.3	1.0	1	1	1
01/22/2015 22:00	0.3	13.3	1,925.8	0.2	1.0	1	1	1
01/22/2015 23:00	0.1	13.4	1,877.1	0.2	0.3	1	1	1
Average/Sum#:	0.3	13.4	1,805.0	0.2	20.5 #	24 #	24 #	20 #
Minimum:	0.0	12.8	1,300.1	0.0	0.0	1	1	0
Maximum:	0.6	13.9	2,038.4	0.4	2.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/23/2015 00:00	0.3	13.2	1,932.9	0.2	1.0	1	1	1
01/23/2015 01:00	0.1	13.4	1,894.6	0.1	0.3	1	1	1
01/23/2015 02:00	0.3	13.1	1,990.2	0.2	1.0	1	1	1
01/23/2015 03:00	0.3	13.1	1,970.3	0.2	1.0	1	1	1
01/23/2015 04:00	0.2	13.3	1,905.7	0.2	0.7	1	1	1
01/23/2015 05:00	0.2	13.3	1,895.9	0.2	0.7	1	1	1
01/23/2015 06:00	0.3	13.2	1,954.9	0.2	1.0	1	1	1
01/23/2015 07:00	0.5	12.9	2,022.8	0.3	1.7	1	1	1
01/23/2015 08:00	0.4	13.0	2,004.0	0.3	1.3	1	1	1
01/23/2015 09:00	0.2	13.4	1,914.9	0.3	0.7	1	1	1
01/23/2015 10:00	0.2	13.3	1,893.1	0.2	0.7	1	1	1
01/23/2015 11:00	0.2	13.4	1,859.7	0.2	0.7	1	1	1
01/23/2015 12:00	0.2	13.5	1,866.6	0.2	0.7	1	1	1
01/23/2015 13:00	0.2	13.4	1,865.8	0.2	0.7	1	1	1
01/23/2015 14:00	0.2	13.4	1,862.6	0.2	0.7	1	1	1
01/23/2015 15:00	0.2	13.3	1,877.6	0.2	0.7	1	1	1
01/23/2015 16:00	0.3	13.2	1,917.1	0.2	1.0	1	1	1
01/23/2015 17:00	0.3	13.2	1,930.0	0.2	1.0	1	1	1
01/23/2015 18:00	0.6	12.7	2,040.9	0.3	2.0	1	1	1
01/23/2015 19:00	0.6	12.6	2,058.2	0.3	2.0	1	1	1
01/23/2015 20:00	0.6	12.6	2,047.5	0.4	2.0	1	1	1
01/23/2015 21:00	0.5	12.8	2,012.3	0.4	1.6	1	1	1
01/23/2015 22:00	0.4	12.8	2,015.9	0.4	1.3	1	1	1
01/23/2015 23:00	0.3	13.3	1,915.5	0.3	1.0	1	1	1
Average/Sum#:	0.3	13.1	1,943.7	0.2	25.5 #	24 #	24 #	24 #
Minimum:	0.1	12.6	1,859.7	0.1	0.3	1	1	1
Maximum:	0.6	13.5	2,058.2	0.4	2.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/24/2015 00:00	0.2	13.5	1,862.6	0.2	0.7	1	1	1
01/24/2015 01:00	0.2	13.4	1,881.3	0.2	0.7	1	1	1
01/24/2015 02:00	0.2	13.5	1,858.6	0.2	0.7	1	1	1
01/24/2015 03:00	0.2	13.5	1,867.4	0.2	0.7	1	1	1
01/24/2015 04:00	0.4	13.2	1,942.6	0.2	1.3	1	1	1
01/24/2015 05:00	0.4	13.0	1,988.1	0.3	1.3	1	1	1
01/24/2015 06:00	0.4	13.0	1,985.2	0.3	1.3	1	1	1
01/24/2015 07:00	0.5	12.9	2,010.4	0.3	1.7	1	1	1
01/24/2015 08:00	0.3	13.2	1,935.9	0.3	1.0	1	1	1
01/24/2015 09:00	0.3	13.3	1,899.6	0.3	1.0	1	1	1
01/24/2015 10:00	0.3	13.4	1,847.6	0.2	1.0	1	1	1
01/24/2015 11:00	0.2	13.4	1,864.6	0.2	0.7	1	1	1
01/24/2015 12:00	0.2	13.4	1,860.5	0.2	0.7	1	1	1
01/24/2015 13:00	0.2	13.4	1,834.8	0.2	0.6	1	1	1
01/24/2015 14:00	0.0	14.0	1,300.9	0.1	0.0	1	1	0
01/24/2015 15:00	0.0	14.0	1,297.6	0.1	0.0	1	1	0
01/24/2015 16:00	0.0	14.0	1,443.9	0.0	0.0	1	1	0
01/24/2015 17:00	0.4	13.1	1,829.0	0.1	1.2	1	1	1
01/24/2015 18:00	0.7	12.5	2,070.2	0.3	2.3	1	1	1
01/24/2015 19:00	0.7	12.7	2,046.6	0.4	2.3	1	1	1
01/24/2015 20:00	0.4	13.0	1,985.7	0.4	1.3	1	1	1
01/24/2015 21:00	0.5	12.9	2,002.8	0.4	1.7	1	1	1
01/24/2015 22:00	0.5	12.9	2,018.4	0.4	1.7	1	1	1
01/24/2015 23:00	0.5	13.1	1,976.8	0.4	1.7	1	1	1
Average/Sum#:	0.3	13.3	1,858.8	0.2	25.6 #	24 #	24 #	21 #
Minimum:	0.0	12.5	1,297.6	0.0	0.0	1	1	0
Maximum:	0.7	14.0	2,070.2	0.4	2.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/25/2015 00:00	0.0	13.9	1,469.4	0.3	0.0	1	1	0
01/25/2015 01:00	14.3	15.8	589.7	0.0	4.8	1	0	0
01/25/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 12:00	67.9	17.7	466.5	0.0	54.9	1	0	0
01/25/2015 13:00	34.1	15.9	709.9	0.0	63.9	1	0	0
01/25/2015 14:00	4.3	14.1	1,438.1	0.0	12.0	1	0	0
01/25/2015 15:00	0.0	13.9	1,776.5	0.0	0.0	1	0	0
01/25/2015 16:00	0.0	13.9	1,660.8	0.0	0.0	1	0	0
01/25/2015 17:00	0.4	13.2	1,820.2	0.1	1.2	1	0	1
01/25/2015 18:00	1.0	12.2	2,162.4	0.3	3.3	1	0	1
01/25/2015 19:00	0.3	13.3	1,823.5	0.4	1.0	1	0	1
01/25/2015 20:00	0.0	13.9	1,809.1	0.3	0.0	1	0	0
01/25/2015 21:00	0.0	13.9	1,710.2	0.1	0.0	1	0	0
01/25/2015 22:00	4.9	14.5	1,351.6	0.0	10.0	1	0	0
01/25/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	9.8	14.3	1,445.2	0.3	151.1 #	13 #	1 #	3 #
Minimum:	0.0	12.2	466.5	0.1	0.0	0	0	0
Maximum:	67.9	17.7	2,162.4	0.4	63.9	1	1	1
%SI	45.8	45.8	45.8	75.0	45.8	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/26/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 04:00	23.5	17.1	553.9	0.0	28.5	1	0	0
01/26/2015 05:00	14.3	14.4	1,288.0	0.0	37.4	1	0	0
01/26/2015 06:00	0.0	13.8	1,715.5	0.0	0.0	1	0	0
01/26/2015 07:00	0.0	13.9	1,814.9	0.0	0.0	1	0	0
01/26/2015 08:00	0.0	13.9	1,813.7	0.0	0.0	1	0	0
01/26/2015 09:00	0.0	13.8	1,815.7	0.0	0.0	1	0	0
01/26/2015 10:00	0.0	13.8	1,819.4	0.0	0.0	1	0	0
01/26/2015 11:00	0.0	13.8	1,772.5	0.0	0.0	1	0	0
01/26/2015 12:00	0.0	13.8	1,818.6	0.0	0.0	1	0	0
01/26/2015 13:00	0.0	13.8	1,798.5	0.0	0.0	1	0	0
01/26/2015 14:00	0.0	13.8	1,803.2	0.0	0.0	1	0	0
01/26/2015 15:00	0.0	13.8	1,799.5	0.0	0.0	1	0	0
01/26/2015 16:00	0.0	13.8	1,797.6	0.0	0.0	1	0	0
01/26/2015 17:00	0.0	13.9	1,615.7	0.0	0.0	1	0	0
01/26/2015 18:00	0.0	13.9	1,670.9	0.0	0.0	1	0	0
01/26/2015 19:00	0.0	13.8	1,815.6	0.0	0.0	1	0	0
01/26/2015 20:00	0.0	13.8	1,815.3	0.0	0.0	1	0	0
01/26/2015 21:00	0.0	13.9	1,593.4	0.0	0.0	1	0	0
01/26/2015 22:00	0.0	13.9	1,451.2	0.0	0.0	1	0	0
01/26/2015 23:00	0.0	13.9	1,353.0	0.0	0.0	1	0	0
Average/Sum#:	1.9	14.0	1,646.3	0.0	65.9 #	20 #	0 #	0 #
Minimum:	0.0	13.8	553.9	0.0	0.0	0	0	0
Maximum:	23.5	17.1	1,819.4	0.0	37.4	1	0	0
%SI	16.7	16.7	16.7	33.3	16.7	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/27/2015 00:00	0.0	13.9	1,357.9	0.0	0.0	1	0	0
01/27/2015 01:00	0.1	13.9	1,356.6	0.0	0.3	1	0	0
01/27/2015 02:00	0.0	13.9	1,557.3	0.0	0.0	1	0	0
01/27/2015 03:00	0.0	13.9	1,710.1	0.0	0.0	1	0	0
01/27/2015 04:00	0.0	13.7	1,821.4	0.0	0.0	1	0	0
01/27/2015 05:00	0.0	13.7	1,836.0	0.0	0.0	1	0	0
01/27/2015 06:00	0.0	13.7	1,841.9	0.0	0.0	1	0	0
01/27/2015 07:00	0.1	13.7	1,843.9	0.0	0.3	1	0	0
01/27/2015 08:00	0.0	13.7	1,841.8	0.0	0.0	1	0	0
01/27/2015 09:00	0.0	13.7	1,831.9	0.0	0.0	1	0	0
01/27/2015 10:00	0.1	13.9	1,386.8	0.0	0.3	1	0	0
01/27/2015 11:00	0.1	13.9	1,276.1	0.1	0.2	1	1	0
01/27/2015 12:00	0.0	13.9	1,302.4	0.1	0.0	1	1	0
01/27/2015 13:00	0.0	13.9	1,559.6	0.0	0.0	1	1	0
01/27/2015 14:00	0.0	13.9	1,295.6	0.0	0.0	1	1	0
01/27/2015 15:00	0.0	13.9	1,571.0	0.0	0.0	1	1	0
01/27/2015 16:00	0.0	13.9	1,322.9	0.0	0.0	1	1	0
01/27/2015 17:00	0.2	13.6	1,656.7	0.1	0.6	1	1	1
01/27/2015 18:00	0.6	13.0	1,990.1	0.2	2.0	1	1	1
01/27/2015 19:00	0.5	13.0	1,980.6	0.3	1.7	1	1	1
01/27/2015 20:00	0.4	13.1	1,962.0	0.4	1.3	1	1	1
01/27/2015 21:00	0.5	13.1	1,971.7	0.4	1.7	1	1	1
01/27/2015 22:00	0.5	13.0	1,963.0	0.4	1.6	1	1	1
01/27/2015 23:00	0.1	13.7	1,563.3	0.3	0.3	1	1	1
Average/Sum#:	0.1	13.7	1,658.4	0.1	10.3 #	24 #	13 #	7 #
Minimum:	0.0	13.0	1,276.1	0.0	0.0	1	0	0
Maximum:	0.6	13.9	1,990.1	0.4	2.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/28/2015 00:00	0.0	13.9	1,278.9	0.2	0.0	1	1	0
01/28/2015 01:00	0.0	13.9	1,278.5	0.0	0.0	1	1	0
01/28/2015 02:00	0.0	13.9	1,272.6	0.0	0.0	1	1	0
01/28/2015 03:00	0.0	13.9	1,271.8	0.0	0.0	1	1	0
01/28/2015 04:00	0.0	13.9	1,281.0	0.0	0.0	1	1	0
01/28/2015 05:00	0.2	13.6	1,610.8	0.1	0.6	1	1	1
01/28/2015 06:00	0.3	13.5	1,879.1	0.1	1.0	1	1	1
01/28/2015 07:00	0.7	12.7	2,022.9	0.3	2.3	1	1	1
01/28/2015 08:00	0.2	13.3	1,875.2	0.3	0.7	1	1	1
01/28/2015 09:00	0.2	13.6	1,850.2	0.3	0.7	1	1	1
01/28/2015 10:00	0.2	13.6	1,851.3	0.2	0.7	1	1	1
01/28/2015 11:00	0.1	13.6	1,734.5	0.2	0.3	1	1	1
01/28/2015 12:00	0.0	14.0	1,269.0	0.1	0.0	1	1	0
01/28/2015 13:00	0.0	13.9	1,609.9	0.0	0.0	1	1	0
01/28/2015 14:00	0.3	13.4	1,834.3	0.1	1.0	1	1	1
01/28/2015 15:00	0.7	12.4	2,058.7	0.2	2.2	1	1	1
01/28/2015 16:00	0.6	12.8	1,991.8	0.4	1.9	1	1	1
01/28/2015 17:00	0.4	13.0	1,944.7	0.4	1.3	1	1	1
01/28/2015 18:00	0.6	12.8	2,005.7	0.4	2.0	1	1	1
01/28/2015 19:00	0.6	12.8	2,006.1	0.4	2.0	1	1	1
01/28/2015 20:00	0.3	13.1	1,939.0	0.3	1.0	1	1	1
01/28/2015 21:00	0.4	13.1	1,954.1	0.3	1.3	1	1	1
01/28/2015 22:00	0.4	13.1	1,924.9	0.3	1.3	1	1	1
01/28/2015 23:00	0.2	13.4	1,847.1	0.3	0.7	1	1	1
Average/Sum#:	0.3	13.4	1,733.0	0.2	21.0 #	24 #	24 #	17 #
Minimum:	0.0	12.4	1,269.0	0.0	0.0	1	1	0
Maximum:	0.7	14.0	2,058.7	0.4	2.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/29/2015 00:00	0.2	13.4	1,844.4	0.2	0.6	1	1	1
01/29/2015 01:00	0.3	13.4	1,849.0	0.2	1.0	1	1	1
01/29/2015 02:00	0.2	13.4	1,850.8	0.2	0.7	1	1	1
01/29/2015 03:00	0.2	13.4	1,848.3	0.2	0.7	1	1	1
01/29/2015 04:00	0.2	13.4	1,858.4	0.2	0.7	1	1	1
01/29/2015 05:00	0.2	13.4	1,853.3	0.2	0.7	1	1	1
01/29/2015 06:00	0.3	13.2	1,936.3	0.2	1.0	1	1	1
01/29/2015 07:00	0.6	12.9	2,016.8	0.3	2.0	1	1	1
01/29/2015 08:00	0.3	13.2	1,966.3	0.3	1.0	1	1	1
01/29/2015 09:00	0.3	13.1	1,956.0	0.3	1.0	1	1	1
01/29/2015 10:00	0.3	13.4	1,868.3	0.2	1.0	1	1	1
01/29/2015 11:00	0.1	13.5	1,853.5	0.2	0.3	1	1	1
01/29/2015 12:00	0.1	13.5	1,858.4	0.1	0.3	1	1	1
01/29/2015 13:00	0.1	13.4	1,855.8	0.1	0.3	1	1	1
01/29/2015 14:00	0.1	13.4	1,867.5	0.1	0.3	1	1	1
01/29/2015 15:00	0.7	12.5	2,027.1	0.2	2.2	1	1	1
01/29/2015 16:00	0.4	13.1	1,915.4	0.3	1.3	1	1	1
01/29/2015 17:00	0.3	13.3	1,896.1	0.3	1.0	1	1	1
01/29/2015 18:00	0.6	12.8	2,006.5	0.3	2.0	1	1	1
01/29/2015 19:00	0.6	12.7	2,025.2	0.3	2.0	1	1	1
01/29/2015 20:00	0.6	12.7	2,044.2	0.4	2.0	1	1	1
01/29/2015 21:00	0.4	13.0	1,978.6	0.4	1.3	1	1	1
01/29/2015 22:00	0.3	13.3	1,907.6	0.3	1.0	1	1	1
01/29/2015 23:00	0.2	13.5	1,858.7	0.2	0.7	1	1	1
Average/Sum#:	0.3	13.2	1,914.3	0.2	25.1 #	24 #	24 #	24 #
Minimum:	0.1	12.5	1,844.4	0.1	0.3	1	1	1
Maximum:	0.7	13.5	2,044.2	0.4	2.2	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/30/2015 00:00	0.2	13.5	1,859.5	0.2	0.7	1	1	1
01/30/2015 01:00	0.2	13.5	1,860.3	0.2	0.7	1	1	1
01/30/2015 02:00	0.2	13.4	1,856.6	0.2	0.7	1	1	1
01/30/2015 03:00	0.2	13.4	1,854.7	0.2	0.7	1	1	1
01/30/2015 04:00	0.2	13.5	1,861.1	0.2	0.7	1	1	1
01/30/2015 05:00	0.2	13.5	1,865.0	0.2	0.7	1	1	1
01/30/2015 06:00	0.2	13.4	1,902.1	0.2	0.7	1	1	1
01/30/2015 07:00	0.5	13.0	1,977.9	0.3	1.7	1	1	1
01/30/2015 08:00	0.4	13.0	1,968.4	0.3	1.3	1	1	1
01/30/2015 09:00	0.3	13.2	1,924.3	0.3	1.0	1	1	1
01/30/2015 10:00	0.2	13.3	1,890.8	0.2	0.7	1	1	1
01/30/2015 11:00	0.2	13.4	1,860.8	0.2	0.7	1	1	1
01/30/2015 12:00	0.0	13.8	1,629.3	0.1	0.0	1	1	1
01/30/2015 13:00	0.4	13.1	1,902.5	0.2	1.3	1	1	1
01/30/2015 14:00	0.5	13.1	1,910.9	0.2	1.6	1	1	1
01/30/2015 15:00	0.4	13.2	1,902.4	0.3	1.3	1	1	1
01/30/2015 16:00	0.6	12.9	1,974.9	0.4	2.0	1	1	1
01/30/2015 17:00	0.3	13.3	1,882.5	0.3	1.0	1	1	1
01/30/2015 18:00	0.3	13.4	1,870.8	0.3	1.0	1	1	1
01/30/2015 19:00	0.3	13.4	1,862.9	0.2	1.0	1	1	1
01/30/2015 20:00	0.3	13.4	1,865.4	0.2	1.0	1	1	1
01/30/2015 21:00	0.3	13.5	1,865.4	0.2	1.0	1	1	1
01/30/2015 22:00	0.2	13.6	1,696.3	0.2	0.6	1	1	1
01/30/2015 23:00	0.0	14.0	1,273.1	0.1	0.0	1	1	0
Average/Sum#:	0.3	13.4	1,846.6	0.2	22.1 #	24 #	24 #	23 #
Minimum:	0.0	12.9	1,273.1	0.1	0.0	1	1	0
Maximum:	0.6	14.0	1,977.9	0.4	2.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/31/2015 00:00	16.0	15.9	546.3	0.0	5.1	1	1	0
01/31/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
01/31/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	1	0
01/31/2015 03:00	25.5	16.9	574.2	0.0	33.8	1	1	0
01/31/2015 04:00	19.4	14.7	1,067.9	0.0	44.1	1	1	0
01/31/2015 05:00	0.2	13.6	1,780.3	0.0	0.6	1	1	1
01/31/2015 06:00	0.3	13.5	1,873.1	0.0	1.0	1	1	1
01/31/2015 07:00	0.3	13.5	1,872.8	0.2	1.0	1	1	1
01/31/2015 08:00	0.3	13.6	1,872.0	0.2	1.0	1	1	1
01/31/2015 09:00	0.3	13.5	1,871.6	0.2	1.0	1	1	1
01/31/2015 10:00	0.3	13.5	1,869.9	0.2	1.0	1	1	1
01/31/2015 11:00	0.0	14.0	1,366.3	0.1	0.0	1	1	1
01/31/2015 12:00	0.0	14.0	1,299.3	0.1	0.0	1	1	0
01/31/2015 13:00	0.0	14.0	1,328.4	0.0	0.0	1	1	0
01/31/2015 14:00	0.0	14.0	1,522.4	0.0	0.0	1	1	0
01/31/2015 15:00	0.1	13.7	1,702.6	0.0	0.3	1	1	1
01/31/2015 16:00	0.1	13.6	1,731.2	0.1	0.3	1	1	1
01/31/2015 17:00	0.0	13.8	1,594.1	0.1	0.0	1	1	1
01/31/2015 18:00	0.7	12.7	2,018.3	0.2	2.3	1	1	1
01/31/2015 19:00	0.6	12.6	2,034.1	0.3	1.9	1	1	1
01/31/2015 20:00	0.6	12.6	2,035.0	0.4	1.9	1	1	1
01/31/2015 21:00	0.6	12.6	2,044.7	0.4	2.0	1	1	1
01/31/2015 22:00	0.6	12.7	2,038.4	0.4	2.0	1	1	1
01/31/2015 23:00	0.4	13.1	1,945.8	0.4	1.3	1	1	1
Average/Sum#:	3.0	13.7	1,635.9	0.2	100.6 #	22 #	24 #	16 #
Minimum:	0.0	12.6	546.3	0.0	0.0	0	1	0
Maximum:	25.5	16.9	2,044.7	0.4	44.1	1	1	1
%SI	8.3	8.3	8.3	29.2	8.3	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/01/2015 00:00	0.6	12.9	1,991.9	0.4	2.0	1	1	1
02/01/2015 01:00	0.0	13.8	1,620.8	0.2	0.0	1	1	1
02/01/2015 02:00	14.4	15.9	592.1	0.0	5.2	1	0	0
02/01/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2015 10:00	27.0	17.5	477.6	0.0	31.1	1	0	0
02/01/2015 11:00	30.1	15.3	840.0	0.0	59.6	1	0	0
02/01/2015 12:00	0.0	13.9	1,385.6	0.0	0.0	1	0	0
02/01/2015 13:00	0.0	14.0	1,390.7	0.0	0.0	1	0	0
02/01/2015 14:00	0.0	13.9	1,728.2	0.0	0.0	1	0	0
02/01/2015 15:00	0.0	14.0	1,506.9	0.0	0.0	1	0	0
02/01/2015 16:00	0.2	13.6	1,787.5	0.1	0.6	1	1	1
02/01/2015 17:00	0.4	13.3	1,909.9	0.2	1.3	1	1	1
02/01/2015 18:00	0.6	12.9	1,984.3	0.3	2.0	1	1	1
02/01/2015 19:00	0.7	12.8	2,010.5	0.4	2.3	1	1	1
02/01/2015 20:00	0.7	12.7	2,016.9	0.5	2.3	1	1	1
02/01/2015 21:00	0.6	12.8	1,998.4	0.5	2.0	1	1	1
02/01/2015 22:00	0.3	13.2	1,914.4	0.4	1.0	1	1	1
02/01/2015 23:00	0.2	13.4	1,831.9	0.3	0.6	1	1	1
Average/Sum#:	4.5	13.9	1,587.5	0.3	110.0 #	17 #	10 #	10 #
Minimum:	0.0	12.7	477.6	0.0	0.0	0	0	0
Maximum:	30.1	17.5	2,016.9	0.5	59.6	1	1	1
%SI	29.2	29.2	29.2	50.0	29.2	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/02/2015 00:00	0.3	13.4	1,848.1	0.2	1.0	1	1	1
02/02/2015 01:00	0.6	12.9	1,987.1	0.3	2.0	1	1	1
02/02/2015 02:00	0.4	13.1	1,936.2	0.3	1.3	1	1	1
02/02/2015 03:00	0.3	13.4	1,851.9	0.3	1.0	1	1	1
02/02/2015 04:00	0.3	13.4	1,841.2	0.2	1.0	1	1	1
02/02/2015 05:00	0.3	13.4	1,865.0	0.2	1.0	1	1	1
02/02/2015 06:00	0.5	13.0	1,963.0	0.3	1.6	1	1	1
02/02/2015 07:00	0.6	12.9	1,967.8	0.3	1.9	1	1	1
02/02/2015 08:00	0.3	13.4	1,844.1	0.3	1.0	1	1	1
02/02/2015 09:00	0.3	13.4	1,837.4	0.3	1.0	1	1	1
02/02/2015 10:00	0.3	13.4	1,841.9	0.2	1.0	1	1	1
02/02/2015 11:00	0.3	13.4	1,860.6	0.2	1.0	1	1	1
02/02/2015 12:00	0.3	13.2	1,906.3	0.2	1.0	1	1	1
02/02/2015 13:00	0.3	13.3	1,883.5	0.2	1.0	1	1	1
02/02/2015 14:00	0.3	13.4	1,858.9	0.2	1.0	1	1	1
02/02/2015 15:00	0.2	13.4	1,857.8	0.2	0.7	1	1	1
02/02/2015 16:00	0.4	13.2	1,913.3	0.2	1.3	1	1	1
02/02/2015 17:00	0.4	13.1	1,939.2	0.3	1.3	1	1	1
02/02/2015 18:00	0.6	12.8	1,996.8	0.3	2.0	1	1	1
02/02/2015 19:00	0.5	12.8	1,991.8	0.4	1.6	1	1	1
02/02/2015 20:00	0.6	12.8	1,998.1	0.4	2.0	1	1	1
02/02/2015 21:00	0.4	13.0	1,954.2	0.4	1.3	1	1	1
02/02/2015 22:00	0.3	13.2	1,902.4	0.3	1.0	1	1	1
02/02/2015 23:00	0.2	13.4	1,822.9	0.2	0.6	1	1	1
Average/Sum#:	0.4	13.2	1,902.9	0.3	29.6 #	24 #	24 #	24 #
Minimum:	0.2	12.8	1,822.9	0.2	0.6	1	1	1
Maximum:	0.6	13.4	1,998.1	0.4	2.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/03/2015 00:00	0.0	13.9	1,328.5	0.1	0.0	1	1	0
02/03/2015 01:00	0.0	13.9	1,288.5	0.1	0.0	1	1	0
02/03/2015 02:00	0.0	13.9	1,290.1	0.0	0.0	1	1	0
02/03/2015 03:00	0.0	13.9	1,368.4	0.0	0.0	1	1	0
02/03/2015 04:00	0.1	13.7	1,701.6	0.0	0.3	1	1	1
02/03/2015 05:00	0.3	13.4	1,831.8	0.1	1.0	1	1	1
02/03/2015 06:00	0.3	13.3	1,862.4	0.2	1.0	1	1	1
02/03/2015 07:00	0.3	13.4	1,830.3	0.2	1.0	1	1	1
02/03/2015 08:00	0.3	13.4	1,834.1	0.2	1.0	1	1	1
02/03/2015 09:00	0.3	13.4	1,838.5	0.2	1.0	1	1	1
02/03/2015 10:00	0.2	13.6	1,676.2	0.2	0.6	1	1	1
02/03/2015 11:00	0.0	13.9	1,260.8	0.1	0.0	1	1	0
02/03/2015 12:00	0.0	13.9	1,298.9	0.1	0.0	1	1	0
02/03/2015 13:00	0.0	13.9	1,358.6	0.0	0.0	1	1	0
02/03/2015 14:00	0.0	13.8	1,705.7	0.0	0.0	1	1	0
02/03/2015 15:00	0.0	13.9	1,582.4	0.0	0.0	1	1	0
02/03/2015 16:00	0.1	13.6	1,649.0	0.0	0.3	1	1	1
02/03/2015 17:00	0.5	13.2	1,915.3	0.2	1.6	1	1	1
02/03/2015 18:00	0.8	12.6	2,039.5	0.4	2.6	1	1	1
02/03/2015 19:00	0.6	12.8	2,000.2	0.5	2.0	1	1	1
02/03/2015 20:00	0.6	12.9	1,978.9	0.5	2.0	1	1	1
02/03/2015 21:00	0.4	13.1	1,923.7	0.4	1.3	1	1	1
02/03/2015 22:00	0.4	13.2	1,808.6	0.3	1.2	1	1	1
02/03/2015 23:00	0.0	13.9	1,316.8	0.2	0.0	1	1	0
Average/Sum#:	0.2	13.5	1,653.7	0.2	16.9 #	24 #	24 #	14 #
Minimum:	0.0	12.6	1,260.8	0.0	0.0	1	1	0
Maximum:	0.8	13.9	2,039.5	0.5	2.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/04/2015 00:00	0.0	13.8	1,689.4	0.1	0.0	1	1	0
02/04/2015 01:00	0.0	13.9	1,491.3	0.0	0.0	1	1	0
02/04/2015 02:00	0.0	13.9	1,285.8	0.0	0.0	1	1	0
02/04/2015 03:00	0.0	13.9	1,288.3	0.0	0.0	1	1	0
02/04/2015 04:00	0.0	13.9	1,386.9	0.0	0.0	1	1	0
02/04/2015 05:00	0.2	13.7	1,606.1	0.1	0.6	1	1	1
02/04/2015 06:00	0.4	13.3	1,894.2	0.2	1.3	1	1	1
02/04/2015 07:00	0.4	13.3	1,876.9	0.3	1.3	1	1	1
02/04/2015 08:00	0.0	13.9	1,323.4	0.2	0.0	1	1	0
02/04/2015 09:00	0.0	13.9	1,290.3	0.1	0.0	1	1	0
02/04/2015 10:00	0.0	13.9	1,292.0	0.0	0.0	1	1	0
02/04/2015 11:00	0.0	13.9	1,292.0	0.0	0.0	1	1	0
02/04/2015 12:00	0.0	13.9	1,291.5	0.0	0.0	1	1	0
02/04/2015 13:00	0.0	13.9	1,292.0	0.0	0.0	1	1	0
02/04/2015 14:00	0.0	13.9	1,292.7	0.0	0.0	1	1	0
02/04/2015 15:00	0.0	13.9	1,351.9	0.0	0.0	1	1	1
02/04/2015 16:00	0.5	13.3	1,856.6	0.1	1.6	1	1	1
02/04/2015 17:00	0.6	13.1	1,924.6	0.3	2.0	1	1	1
02/04/2015 18:00	0.8	12.7	2,013.7	0.5	2.6	1	1	1
02/04/2015 19:00	0.8	12.7	1,993.9	0.6	2.6	1	1	1
02/04/2015 20:00	0.7	12.9	1,971.6	0.6	2.3	1	1	1
02/04/2015 21:00	0.7	12.8	1,992.6	0.5	2.3	1	1	1
02/04/2015 22:00	0.6	12.9	1,960.3	0.5	1.9	1	1	1
02/04/2015 23:00	0.1	13.6	1,554.0	0.3	0.3	1	1	1
Average/Sum#:	0.2	13.5	1,592.2	0.2	18.8 #	24 #	24 #	12 #
Minimum:	0.0	12.7	1,285.8	0.0	0.0	1	1	0
Maximum:	0.8	13.9	2,013.7	0.6	2.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/05/2015 00:00	0.0	13.9	1,285.5	0.2	0.0	1	1	0
02/05/2015 01:00	0.0	13.9	1,287.4	0.0	0.0	1	1	0
02/05/2015 02:00	0.0	13.9	1,289.2	0.0	0.0	1	1	0
02/05/2015 03:00	0.0	13.9	1,289.4	0.0	0.0	1	1	0
02/05/2015 04:00	0.0	13.9	1,418.9	0.0	0.0	1	1	0
02/05/2015 05:00	0.2	13.7	1,590.0	0.1	0.6	1	1	1
02/05/2015 06:00	0.5	13.3	1,886.6	0.2	1.6	1	1	1
02/05/2015 07:00	0.5	13.1	1,922.0	0.3	1.6	1	1	1
02/05/2015 08:00	0.0	13.8	1,427.9	0.3	0.0	1	1	1
02/05/2015 09:00	0.0	13.9	1,284.9	0.1	0.0	1	1	0
02/05/2015 10:00	0.0	13.9	1,297.7	0.0	0.0	1	1	0
02/05/2015 11:00	0.0	13.9	1,321.2	0.0	0.0	1	1	0
02/05/2015 12:00	0.0	13.9	1,350.2	0.0	0.0	1	1	0
02/05/2015 13:00	0.0	13.9	1,600.8	0.0	0.0	1	1	0
02/05/2015 14:00	0.0	13.9	1,654.4	0.0	0.0	1	1	0
02/05/2015 15:00	0.0	13.9	1,613.1	0.0	0.0	1	1	0
02/05/2015 16:00	0.3	13.4	1,836.8	0.1	1.0	1	1	1
02/05/2015 17:00	0.3	13.3	1,861.2	0.1	1.0	1	1	1
02/05/2015 18:00	0.7	12.8	1,967.4	0.3	2.2	1	1	1
02/05/2015 19:00	0.6	13.0	1,946.1	0.4	2.0	1	1	1
02/05/2015 20:00	0.7	12.9	1,962.9	0.5	2.3	1	1	1
02/05/2015 21:00	0.6	13.0	1,932.1	0.4	1.9	1	1	1
02/05/2015 22:00	0.0	13.9	1,456.7	0.3	0.0	1	1	0
02/05/2015 23:00	0.0	13.9	1,282.9	0.1	0.0	1	1	0
Average/Sum#:	0.2	13.6	1,573.6	0.1	14.2 #	24 #	24 #	10 #
Minimum:	0.0	12.8	1,282.9	0.0	0.0	1	1	0
Maximum:	0.7	13.9	1,967.4	0.5	2.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/06/2015 00:00	0.0	13.9	1,296.7	0.0	0.0	1	1	0
02/06/2015 01:00	0.0	13.9	1,288.4	0.0	0.0	1	1	0
02/06/2015 02:00	0.0	13.9	1,281.5	0.0	0.0	1	1	0
02/06/2015 03:00	0.0	13.9	1,286.3	0.0	0.0	1	1	0
02/06/2015 04:00	0.0	14.0	1,329.8	0.0	0.0	1	1	0
02/06/2015 05:00	0.3	13.4	1,772.2	0.1	0.9	1	1	1
02/06/2015 06:00	0.6	13.1	1,912.7	0.2	1.9	1	1	1
02/06/2015 07:00	0.6	13.0	1,884.8	0.4	1.9	1	1	1
02/06/2015 08:00	0.2	13.4	1,837.2	0.4	0.6	1	1	1
02/06/2015 09:00	0.0	13.6	1,651.1	0.2	0.0	1	1	1
02/06/2015 10:00	0.2	13.4	1,826.6	0.1	0.6	1	1	1
02/06/2015 11:00	0.3	13.4	1,836.7	0.1	1.0	1	1	1
02/06/2015 12:00	0.0	13.8	1,610.0	0.1	0.0	1	1	1
02/06/2015 13:00	0.3	13.4	1,845.4	0.1	1.0	1	1	1
02/06/2015 14:00	0.3	13.4	1,836.5	0.1	1.0	1	1	1
02/06/2015 15:00	0.3	13.4	1,838.6	0.2	1.0	1	1	1
02/06/2015 16:00	0.3	13.3	1,863.5	0.2	1.0	1	1	1
02/06/2015 17:00	0.7	12.7	1,977.9	0.3	2.2	1	1	1
02/06/2015 18:00	0.7	12.4	2,021.5	0.4	2.2	1	1	1
02/06/2015 19:00	0.7	12.6	1,979.7	0.5	2.2	1	1	1
02/06/2015 20:00	0.7	12.5	2,004.0	0.5	2.2	1	1	1
02/06/2015 21:00	0.4	13.1	1,882.7	0.4	1.3	1	1	1
02/06/2015 22:00	0.0	14.0	1,372.7	0.3	0.0	1	1	0
02/06/2015 23:00	0.0	13.9	1,577.9	0.1	0.0	1	1	0
Average/Sum#:	0.3	13.4	1,708.9	0.2	21.0 #	24 #	24 #	17 #
Minimum:	0.0	12.4	1,281.5	0.0	0.0	1	1	0
Maximum:	0.7	14.0	2,021.5	0.5	2.2	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/07/2015 00:00	0.0	14.0	1,308.7	0.0	0.0	1	1	0
02/07/2015 01:00	0.0	13.9	1,443.0	0.0	0.0	1	1	0
02/07/2015 02:00	0.0	14.0	1,394.9	0.0	0.0	1	1	0
02/07/2015 03:00	0.0	14.0	1,338.6	0.0	0.0	1	1	0
02/07/2015 04:00	0.0	14.0	1,337.7	0.0	0.0	1	1	0
02/07/2015 05:00	0.0	14.0	1,326.8	0.0	0.0	1	1	0
02/07/2015 06:00	0.0	14.0	1,329.5	0.0	0.0	1	1	0
02/07/2015 07:00	0.0	14.0	1,311.8	0.0	0.0	1	1	0
02/07/2015 08:00	0.0	13.9	1,285.2	0.0	0.0	1	1	0
02/07/2015 09:00	0.0	13.9	1,303.4	0.0	0.0	1	1	0
02/07/2015 10:00	0.0	13.9	1,349.9	0.0	0.0	1	1	0
02/07/2015 11:00	0.0	13.9	1,330.3	0.0	0.0	1	1	0
02/07/2015 12:00	0.0	13.9	1,293.3	0.0	0.0	1	1	0
02/07/2015 13:00	0.0	14.0	1,299.3	0.0	0.0	1	1	0
02/07/2015 14:00	0.0	14.0	1,341.1	0.0	0.0	1	1	0
02/07/2015 15:00	0.0	14.0	1,318.4	0.0	0.0	1	1	0
02/07/2015 16:00	0.2	13.6	1,648.4	0.1	0.6	1	1	1
02/07/2015 17:00	0.4	13.2	1,874.7	0.2	1.3	1	1	1
02/07/2015 18:00	0.8	12.5	2,009.9	0.4	2.5	1	1	1
02/07/2015 19:00	0.4	12.9	1,933.7	0.4	1.3	1	1	1
02/07/2015 20:00	0.7	12.6	2,004.3	0.5	2.2	1	1	1
02/07/2015 21:00	0.1	13.5	1,719.0	0.3	0.3	1	1	1
02/07/2015 22:00	0.0	13.9	1,382.0	0.2	0.0	1	1	0
02/07/2015 23:00	0.0	13.9	1,285.3	0.0	0.0	1	1	0
Average/Sum#:	0.1	13.7	1,465.4	0.1	8.2 #	24 #	24 #	6 #
Minimum:	0.0	12.5	1,285.2	0.0	0.0	1	1	0
Maximum:	0.8	14.0	2,009.9	0.5	2.5	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/08/2015 00:00	0.0	13.9	1,308.2	0.0	0.0	1	1	0
02/08/2015 01:00	0.0	13.9	1,341.7	0.0	0.0	1	1	0
02/08/2015 02:00	0.0	13.9	1,337.2	0.0	0.0	1	1	0
02/08/2015 03:00	0.0	13.9	1,290.1	0.0	0.0	1	1	0
02/08/2015 04:00	0.0	13.9	1,289.0	0.0	0.0	1	1	0
02/08/2015 05:00	0.0	13.9	1,285.2	0.0	0.0	1	1	0
02/08/2015 06:00	0.0	13.9	1,326.9	0.0	0.0	1	1	0
02/08/2015 07:00	0.0	13.9	1,314.1	0.0	0.0	1	1	0
02/08/2015 08:00	0.0	13.9	1,282.8	0.0	0.0	1	1	0
02/08/2015 09:00	0.0	13.9	1,284.3	0.0	0.0	1	1	0
02/08/2015 10:00	0.0	13.9	1,283.5	0.0	0.0	1	1	0
02/08/2015 11:00	0.0	13.9	1,286.8	0.0	0.0	1	1	0
02/08/2015 12:00	0.0	13.9	1,313.0	0.0	0.0	1	1	0
02/08/2015 13:00	0.0	13.9	1,322.2	0.0	0.0	1	1	0
02/08/2015 14:00	0.0	14.0	1,296.3	0.0	0.0	1	1	0
02/08/2015 15:00	0.0	14.0	1,297.8	0.0	0.0	1	1	0
02/08/2015 16:00	0.4	13.3	1,823.8	0.1	1.3	1	1	1
02/08/2015 17:00	0.5	13.1	1,907.1	0.2	1.6	1	1	1
02/08/2015 18:00	0.8	12.5	2,022.9	0.4	2.5	1	1	1
02/08/2015 19:00	0.6	12.7	1,980.0	0.5	1.9	1	1	1
02/08/2015 20:00	0.7	12.6	2,004.3	0.5	2.2	1	1	1
02/08/2015 21:00	0.4	13.1	1,763.9	0.4	1.2	1	1	1
02/08/2015 22:00	0.0	14.0	1,332.1	0.3	0.0	1	1	0
02/08/2015 23:00	0.0	13.9	1,521.3	0.1	0.0	1	1	0
Average/Sum#:	0.1	13.7	1,467.3	0.1	10.7 #	24 #	24 #	6 #
Minimum:	0.0	12.5	1,282.8	0.0	0.0	1	1	0
Maximum:	0.8	14.0	2,022.9	0.5	2.5	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/09/2015 00:00	0.0	14.0	1,306.9	0.0	0.0	1	1	0
02/09/2015 01:00	0.0	14.0	1,315.0	0.0	0.0	1	1	0
02/09/2015 02:00	0.0	14.0	1,285.2	0.0	0.0	1	1	0
02/09/2015 03:00	0.0	13.9	1,285.3	0.0	0.0	1	1	0
02/09/2015 04:00	0.0	13.9	1,285.8	0.0	0.0	1	1	0
02/09/2015 05:00	0.0	14.0	1,319.3	0.0	0.0	1	1	0
02/09/2015 06:00	0.2	13.5	1,722.3	0.1	0.6	1	1	1
02/09/2015 07:00	0.3	13.4	1,841.0	0.1	1.0	1	1	1
02/09/2015 08:00	0.2	13.5	1,839.6	0.2	0.7	1	1	1
02/09/2015 09:00	0.0	13.8	1,452.6	0.1	0.0	1	1	1
02/09/2015 10:00	0.0	13.9	1,289.8	0.1	0.0	1	1	0
02/09/2015 11:00	0.0	13.9	1,288.3	0.0	0.0	1	1	0
02/09/2015 12:00	0.0	13.9	1,286.1	0.0	0.0	1	1	0
02/09/2015 13:00	0.0	14.0	1,287.9	0.0	0.0	1	1	0
02/09/2015 14:00	0.0	14.0	1,290.0	0.0	0.0	1	1	0
02/09/2015 15:00	0.0	14.0	1,286.4	0.0	0.0	1	1	0
02/09/2015 16:00	0.0	14.0	1,287.4	0.0	0.0	1	1	0
02/09/2015 17:00	0.2	13.6	1,764.7	0.1	0.6	1	1	1
02/09/2015 18:00	0.4	13.5	1,847.8	0.2	1.3	1	1	1
02/09/2015 19:00	0.3	13.4	1,847.3	0.2	1.0	1	1	1
02/09/2015 20:00	0.3	13.4	1,869.2	0.2	1.0	1	1	1
02/09/2015 21:00	0.1	13.7	1,633.4	0.2	0.3	1	1	1
02/09/2015 22:00	0.0	13.9	1,326.8	0.1	0.0	1	1	0
02/09/2015 23:00	0.0	13.9	1,318.5	0.0	0.0	1	1	0
Average/Sum#:	0.1	13.8	1,469.9	0.1	6.5 #	24 #	24 #	9 #
Minimum:	0.0	13.4	1,285.2	0.0	0.0	1	1	0
Maximum:	0.4	14.0	1,869.2	0.2	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/10/2015 00:00	0.0	13.9	1,292.8	0.0	0.0	1	1	0
02/10/2015 01:00	0.0	13.9	1,296.3	0.0	0.0	1	1	0
02/10/2015 02:00	0.0	13.9	1,291.7	0.0	0.0	1	1	0
02/10/2015 03:00	0.0	13.9	1,293.6	0.0	0.0	1	1	0
02/10/2015 04:00	0.0	13.9	1,297.4	0.0	0.0	1	1	0
02/10/2015 05:00	0.0	13.9	1,330.0	0.0	0.0	1	1	0
02/10/2015 06:00	0.4	13.4	1,891.8	0.1	1.3	1	1	1
02/10/2015 07:00	0.6	13.1	1,932.9	0.3	2.0	1	1	1
02/10/2015 08:00	0.1	13.8	1,525.3	0.3	0.3	1	1	1
02/10/2015 09:00	0.0	14.0	1,294.9	0.2	0.0	1	1	0
02/10/2015 10:00	0.0	13.9	1,294.6	0.0	0.0	1	1	0
02/10/2015 11:00	0.0	13.9	1,296.9	0.0	0.0	1	1	0
02/10/2015 12:00	0.0	14.0	1,297.3	0.0	0.0	1	1	0
02/10/2015 13:00	0.0	14.0	1,294.1	0.0	0.0	1	1	0
02/10/2015 14:00	0.0	14.0	1,294.3	0.0	0.0	1	1	0
02/10/2015 15:00	0.0	14.0	1,294.9	0.0	0.0	1	1	0
02/10/2015 16:00	0.4	13.3	1,851.3	0.1	1.3	1	1	1
02/10/2015 17:00	0.7	12.9	1,987.4	0.3	2.3	1	1	1
02/10/2015 18:00	0.7	12.6	2,027.7	0.4	2.3	1	1	1
02/10/2015 19:00	0.7	12.6	2,029.0	0.5	2.3	1	1	1
02/10/2015 20:00	0.7	12.7	2,015.0	0.5	2.3	1	1	1
02/10/2015 21:00	0.5	12.9	1,963.3	0.5	1.6	1	1	1
02/10/2015 22:00	0.6	12.7	2,015.1	0.4	1.9	1	1	1
02/10/2015 23:00	0.6	12.9	1,998.4	0.4	2.0	1	1	1
Average/Sum#:	0.3	13.5	1,587.8	0.2	19.6 #	24 #	24 #	11 #
Minimum:	0.0	12.6	1,291.7	0.0	0.0	1	1	0
Maximum:	0.7	14.0	2,029.0	0.5	2.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/11/2015 00:00	0.6	12.9	2,002.2	0.4	2.0	1	1	1
02/11/2015 01:00	0.3	13.3	1,890.2	0.3	1.0	1	1	1
02/11/2015 02:00	0.2	13.4	1,837.4	0.3	0.6	1	1	1
02/11/2015 03:00	0.3	13.4	1,838.6	0.2	1.0	1	1	1
02/11/2015 04:00	0.3	13.4	1,840.4	0.2	1.0	1	1	1
02/11/2015 05:00	0.3	13.4	1,865.2	0.2	1.0	1	1	1
02/11/2015 06:00	0.4	13.2	1,910.6	0.2	1.3	1	1	1
02/11/2015 07:00	0.2	13.4	1,846.2	0.2	0.7	1	1	1
02/11/2015 08:00	0.2	13.4	1,834.3	0.2	0.6	1	1	1
02/11/2015 09:00	0.2	13.4	1,837.9	0.2	0.6	1	1	1
02/11/2015 10:00	0.1	13.7	1,588.8	0.2	0.3	1	1	1
02/11/2015 11:00	0.0	13.9	1,449.6	0.1	0.0	1	1	0
02/11/2015 12:00	0.0	13.9	1,495.6	0.0	0.0	1	1	0
02/11/2015 13:00	0.0	14.0	1,292.2	0.0	0.0	1	1	0
02/11/2015 14:00	0.0	14.0	1,294.4	0.0	0.0	1	1	0
02/11/2015 15:00	0.1	13.7	1,552.7	0.0	0.3	1	1	1
02/11/2015 16:00	0.4	13.3	1,886.1	0.1	1.3	1	1	1
02/11/2015 17:00	0.5	13.1	1,933.6	0.3	1.6	1	1	1
02/11/2015 18:00	0.8	12.7	2,024.5	0.4	2.6	1	1	1
02/11/2015 19:00	0.7	12.8	1,990.0	0.5	2.3	1	1	1
02/11/2015 20:00	0.7	12.8	1,997.0	0.5	2.3	1	1	1
02/11/2015 21:00	0.5	13.0	1,960.1	0.5	1.6	1	1	1
02/11/2015 22:00	0.6	13.0	1,970.0	0.4	2.0	1	1	1
02/11/2015 23:00	0.3	13.4	1,858.5	0.3	1.0	1	1	1
Average/Sum#:	0.3	13.4	1,791.5	0.2	25.1 #	24 #	24 #	20 #
Minimum:	0.0	12.7	1,292.2	0.0	0.0	1	1	0
Maximum:	0.8	14.0	2,024.5	0.5	2.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/12/2015 00:00	0.0	13.8	1,413.0	0.2	0.0	1	1	1
02/12/2015 01:00	0.0	13.9	1,367.9	0.1	0.0	1	1	0
02/12/2015 02:00	0.0	13.9	1,301.9	0.0	0.0	1	1	0
02/12/2015 03:00	0.0	13.9	1,479.6	0.0	0.0	1	1	0
02/12/2015 04:00	0.2	13.7	1,596.7	0.1	0.6	1	1	1
02/12/2015 05:00	0.5	13.1	1,928.2	0.2	1.6	1	1	1
02/12/2015 06:00	0.4	13.2	1,912.4	0.3	1.3	1	1	1
02/12/2015 07:00	0.5	13.0	1,915.9	0.4	1.6	1	1	1
02/12/2015 08:00	0.1	13.7	1,559.6	0.3	0.3	1	1	1
02/12/2015 09:00	0.0	13.9	1,290.2	0.2	0.0	1	1	0
02/12/2015 10:00	0.0	13.9	1,290.3	0.0	0.0	1	1	0
02/12/2015 11:00	0.0	13.9	1,291.1	0.0	0.0	1	1	0
02/12/2015 12:00	0.0	13.9	1,294.8	0.0	0.0	1	1	0
02/12/2015 13:00	0.0	13.8	1,673.8	0.0	0.0	1	1	1
02/12/2015 14:00	0.7	12.7	1,991.9	0.2	2.2	1	1	1
02/12/2015 15:00	0.4	13.1	1,885.8	0.3	1.3	1	1	1
02/12/2015 16:00	0.5	13.0	1,921.0	0.4	1.6	1	1	1
02/12/2015 17:00	0.6	12.8	1,970.2	0.4	1.9	1	1	1
02/12/2015 18:00	0.7	12.5	2,036.2	0.4	2.2	1	1	1
02/12/2015 19:00	0.7	12.5	2,047.8	0.5	2.3	1	1	1
02/12/2015 20:00	0.7	12.6	2,032.6	0.5	2.3	1	1	1
02/12/2015 21:00	0.5	13.0	1,960.1	0.5	1.6	1	1	1
02/12/2015 22:00	0.6	12.8	1,996.9	0.4	2.0	1	1	1
02/12/2015 23:00	0.0	13.8	1,631.1	0.3	0.0	1	1	1
Average/Sum#:	0.3	13.4	1,699.5	0.2	22.8 #	24 #	24 #	17 #
Minimum:	0.0	12.5	1,290.2	0.0	0.0	1	1	0
Maximum:	0.7	13.9	2,047.8	0.5	2.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/13/2015 00:00	0.0	13.9	1,729.9	0.1	0.0	1	1	0
02/13/2015 01:00	0.0	13.9	1,483.7	0.0	0.0	1	1	0
02/13/2015 02:00	0.0	13.9	1,475.9	0.0	0.0	1	1	0
02/13/2015 03:00	0.0	13.9	1,747.9	0.0	0.0	1	1	0
02/13/2015 04:00	0.0	13.9	1,555.2	0.0	0.0	1	1	0
02/13/2015 05:00	0.1	13.8	1,575.5	0.0	0.3	1	1	1
02/13/2015 06:00	0.3	13.3	1,906.9	0.1	1.0	1	1	1
02/13/2015 07:00	0.4	13.3	1,879.7	0.2	1.3	1	1	1
02/13/2015 08:00	0.0	13.8	1,462.7	0.2	0.0	1	1	1
02/13/2015 09:00	0.0	13.9	1,294.8	0.1	0.0	1	1	0
02/13/2015 10:00	0.0	13.9	1,295.0	0.0	0.0	1	1	0
02/13/2015 11:00	0.0	13.9	1,301.9	0.0	0.0	1	1	0
02/13/2015 12:00	0.0	13.9	1,400.6	0.0	0.0	1	1	0
02/13/2015 13:00	0.0	13.8	1,653.1	0.0	0.0	1	1	1
02/13/2015 14:00	0.4	13.3	1,878.2	0.1	1.3	1	1	1
02/13/2015 15:00	0.4	13.4	1,851.4	0.2	1.3	1	1	1
02/13/2015 16:00	0.4	13.3	1,875.7	0.3	1.3	1	1	1
02/13/2015 17:00	0.5	13.0	1,933.9	0.3	1.6	1	1	1
02/13/2015 18:00	0.7	12.7	2,006.9	0.4	2.3	1	1	1
02/13/2015 19:00	0.7	12.5	2,042.2	0.5	2.2	1	1	1
02/13/2015 20:00	0.7	12.6	2,024.0	0.5	2.3	1	1	1
02/13/2015 21:00	0.6	12.8	1,999.2	0.5	2.0	1	1	1
02/13/2015 22:00	0.7	12.7	2,018.2	0.5	2.3	1	1	1
02/13/2015 23:00	0.3	13.2	1,902.4	0.4	1.0	1	1	1
Average/Sum#:	0.3	13.4	1,720.6	0.2	20.2 #	24 #	24 #	15 #
Minimum:	0.0	12.5	1,294.8	0.0	0.0	1	1	0
Maximum:	0.7	13.9	2,042.2	0.5	2.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/14/2015 00:00	0.6	12.9	1,983.2	0.4	2.0	1	1	1
02/14/2015 01:00	0.5	13.0	1,957.7	0.3	1.6	1	1	1
02/14/2015 02:00	0.8	12.9	1,973.7	0.5	2.6	1	1	1
02/14/2015 03:00	0.6	12.9	1,973.8	0.5	2.0	1	1	1
02/14/2015 04:00	0.5	13.0	1,963.6	0.5	1.6	1	1	1
02/14/2015 05:00	0.3	13.4	1,843.0	0.3	1.0	1	1	1
02/14/2015 06:00	0.0	13.8	1,493.9	0.2	0.0	1	1	1
02/14/2015 07:00	0.0	13.9	1,308.4	0.1	0.0	1	1	0
02/14/2015 08:00	0.0	13.9	1,297.8	0.0	0.0	1	1	0
02/14/2015 09:00	0.0	13.9	1,309.0	0.0	0.0	1	1	0
02/14/2015 10:00	0.0	13.9	1,302.9	0.0	0.0	1	1	0
02/14/2015 11:00	0.0	14.0	1,298.7	0.0	0.0	1	1	0
02/14/2015 12:00	0.0	14.0	1,299.1	0.0	0.0	1	1	0
02/14/2015 13:00	0.0	14.0	1,298.0	0.0	0.0	1	1	0
02/14/2015 14:00	0.0	14.0	1,295.9	0.0	0.0	1	1	0
02/14/2015 15:00	0.0	14.0	1,293.8	0.0	0.0	1	1	0
02/14/2015 16:00	0.3	13.5	1,559.5	0.1	0.8	1	1	1
02/14/2015 17:00	0.5	13.1	1,892.2	0.2	1.6	1	1	1
02/14/2015 18:00	0.5	13.1	1,893.2	0.3	1.6	1	1	1
02/14/2015 19:00	0.8	12.5	2,038.9	0.5	2.6	1	1	1
02/14/2015 20:00	0.5	13.0	1,936.5	0.5	1.6	1	1	1
02/14/2015 21:00	0.5	13.1	1,923.0	0.5	1.6	1	1	1
02/14/2015 22:00	0.6	12.8	1,975.3	0.4	1.9	1	1	1
02/14/2015 23:00	0.0	13.9	1,427.9	0.3	0.0	1	1	1
Average/Sum#:	0.3	13.4	1,647.5	0.2	22.5 #	24 #	24 #	15 #
Minimum:	0.0	12.5	1,293.8	0.0	0.0	1	1	0
Maximum:	0.8	14.0	2,038.9	0.5	2.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/15/2015 00:00	0.0	14.0	1,391.6	0.1	0.0	1	1	0
02/15/2015 01:00	0.0	13.9	1,456.7	0.0	0.0	1	1	0
02/15/2015 02:00	20.1	16.4	392.0	0.0	3.9	1	0	0
02/15/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/15/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/15/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/15/2015 15:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/15/2015 16:00	23.6	18.1	386.6	0.0	12.9	1	1	0
02/15/2015 17:00	14.1	14.9	1,052.3	0.0	32.7	1	1	0
02/15/2015 18:00	0.0	14.0	1,444.1	0.0	0.0	1	1	0
02/15/2015 19:00	0.5	13.0	1,933.7	0.0	1.6	1	1	1
02/15/2015 20:00	0.6	12.7	1,987.8	0.3	1.9	1	1	1
02/15/2015 21:00	0.5	12.9	1,972.7	0.4	1.6	1	1	1
02/15/2015 22:00	0.5	12.9	1,971.8	0.4	1.6	1	1	1
02/15/2015 23:00	0.5	12.9	1,971.0	0.4	1.6	1	1	1
Average/Sum#:	5.5	14.2	1,450.9	0.3	57.8 #	11 #	14 #	5 #
Minimum:	0.0	12.7	386.6	0.0	0.0	0	0	0
Maximum:	23.6	18.1	1,987.8	0.4	32.7	1	1	1
%SI	54.2	54.2	54.2	75.0	54.2	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/16/2015 00:00	0.5	12.9	1,981.1	0.4	1.6	1	1	1
02/16/2015 01:00	0.3	13.2	1,910.4	0.3	1.0	1	1	1
02/16/2015 02:00	0.2	13.4	1,849.6	0.3	0.7	1	1	1
02/16/2015 03:00	0.2	13.4	1,851.4	0.2	0.7	1	1	1
02/16/2015 04:00	0.2	13.4	1,852.5	0.2	0.7	1	1	1
02/16/2015 05:00	0.3	13.3	1,882.9	0.2	1.0	1	1	1
02/16/2015 06:00	0.3	13.3	1,901.1	0.2	1.0	1	1	1
02/16/2015 07:00	0.2	13.4	1,834.3	0.2	0.6	1	1	1
02/16/2015 08:00	0.2	13.5	1,836.6	0.2	0.7	1	1	1
02/16/2015 09:00	0.2	13.5	1,846.7	0.2	0.7	1	1	1
02/16/2015 10:00	0.2	13.5	1,858.7	0.2	0.7	1	1	1
02/16/2015 11:00	0.2	13.4	1,857.5	0.2	0.7	1	1	1
02/16/2015 12:00	0.2	13.4	1,854.0	0.2	0.7	1	1	1
02/16/2015 13:00	0.1	13.6	1,558.2	0.2	0.3	1	1	1
02/16/2015 14:00	0.0	14.0	1,285.9	0.1	0.0	1	1	0
02/16/2015 15:00	0.1	13.7	1,544.6	0.1	0.3	1	1	1
02/16/2015 16:00	0.4	13.1	1,892.1	0.1	1.3	1	1	1
02/16/2015 17:00	0.5	12.9	1,943.1	0.3	1.6	1	1	1
02/16/2015 18:00	0.6	12.5	2,031.3	0.4	1.9	1	1	1
02/16/2015 19:00	0.6	12.6	2,021.1	0.4	1.9	1	1	1
02/16/2015 20:00	0.2	13.4	1,854.7	0.3	0.7	1	1	1
02/16/2015 21:00	0.3	13.3	1,884.0	0.3	1.0	1	1	1
02/16/2015 22:00	0.4	13.1	1,915.3	0.2	1.3	1	1	1
02/16/2015 23:00	0.2	13.5	1,854.1	0.2	0.7	1	1	1
Average/Sum#:	0.3	13.3	1,837.6	0.2	21.8 #	24 #	24 #	23 #
Minimum:	0.0	12.5	1,285.9	0.1	0.0	1	1	0
Maximum:	0.6	14.0	2,031.3	0.4	1.9	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/17/2015 00:00	0.3	13.4	1,852.3	0.2	1.0	1	1	1
02/17/2015 01:00	0.3	13.4	1,850.3	0.2	1.0	1	1	1
02/17/2015 02:00	0.2	13.4	1,851.7	0.2	0.7	1	1	1
02/17/2015 03:00	0.3	13.5	1,856.3	0.2	1.0	1	1	1
02/17/2015 04:00	0.3	13.5	1,860.3	0.2	1.0	1	1	1
02/17/2015 05:00	0.3	13.4	1,855.6	0.2	1.0	1	1	1
02/17/2015 06:00	0.3	13.4	1,874.9	0.2	1.0	1	1	1
02/17/2015 07:00	0.5	13.0	1,915.9	0.3	1.6	1	1	1
02/17/2015 08:00	0.3	13.4	1,842.0	0.3	1.0	1	1	1
02/17/2015 09:00	0.1	13.7	1,548.6	0.2	0.3	1	1	1
02/17/2015 10:00	0.0	13.9	1,410.7	0.1	0.0	1	1	0
02/17/2015 11:00	0.0	13.9	1,580.7	0.0	0.0	1	1	0
02/17/2015 12:00	0.0	13.9	1,557.7	0.0	0.0	1	1	0
02/17/2015 13:00	0.0	13.9	1,312.3	0.0	0.0	1	1	0
02/17/2015 14:00	0.0	13.9	1,288.7	0.0	0.0	1	1	0
02/17/2015 15:00	0.0	14.0	1,300.3	0.0	0.0	1	1	0
02/17/2015 16:00	0.1	13.6	1,605.7	0.0	0.3	1	1	1
02/17/2015 17:00	0.4	13.1	1,901.2	0.1	1.3	1	1	1
02/17/2015 18:00	0.7	12.6	2,014.9	0.3	2.2	1	1	1
02/17/2015 19:00	0.7	12.6	2,010.2	0.4	2.2	1	1	1
02/17/2015 20:00	0.5	12.9	1,964.7	0.5	1.6	1	1	1
02/17/2015 21:00	0.3	13.2	1,898.9	0.4	1.0	1	1	1
02/17/2015 22:00	0.5	13.1	1,830.3	0.3	1.5	1	1	1
02/17/2015 23:00	0.0	13.9	1,308.1	0.2	0.0	1	1	0
Average/Sum#:	0.3	13.4	1,720.5	0.2	19.7 #	24 #	24 #	17 #
Minimum:	0.0	12.6	1,288.7	0.0	0.0	1	1	0
Maximum:	0.7	14.0	2,014.9	0.5	2.2	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/18/2015 00:00	0.0	13.9	1,491.0	0.1	0.0	1	1	0
02/18/2015 01:00	0.0	13.9	1,518.4	0.0	0.0	1	1	0
02/18/2015 02:00	0.0	13.9	1,338.1	0.0	0.0	1	1	0
02/18/2015 03:00	0.1	13.9	1,307.4	0.0	0.2	1	1	0
02/18/2015 04:00	0.1	13.7	1,694.9	0.1	0.3	1	1	1
02/18/2015 05:00	0.3	13.3	1,882.0	0.1	1.0	1	1	1
02/18/2015 06:00	0.3	13.3	1,874.6	0.2	1.0	1	1	1
02/18/2015 07:00	0.4	13.1	1,947.5	0.2	1.3	1	1	1
02/18/2015 08:00	0.5	13.1	1,975.2	0.3	1.7	1	1	1
02/18/2015 09:00	0.5	13.0	1,989.3	0.4	1.7	1	1	1
02/18/2015 10:00	0.5	13.0	1,964.5	0.4	1.6	1	1	1
02/18/2015 11:00	0.3	13.4	1,844.4	0.3	1.0	1	1	1
02/18/2015 12:00	0.3	13.4	1,850.8	0.3	1.0	1	1	1
02/18/2015 13:00	0.3	13.4	1,852.8	0.2	1.0	1	1	1
02/18/2015 14:00	0.0	13.7	1,565.6	0.1	0.0	1	1	1
02/18/2015 15:00	0.0	13.9	1,658.5	0.1	0.0	1	1	0
02/18/2015 16:00	0.3	13.3	1,846.1	0.1	1.0	1	1	1
02/18/2015 17:00	0.6	12.8	1,996.7	0.2	2.0	1	1	1
02/18/2015 18:00	0.7	12.6	2,026.5	0.4	2.3	1	1	1
02/18/2015 19:00	0.6	12.8	1,993.3	0.4	2.0	1	1	1
02/18/2015 20:00	0.6	12.8	1,986.2	0.4	1.9	1	1	1
02/18/2015 21:00	0.5	12.9	1,974.4	0.4	1.6	1	1	1
02/18/2015 22:00	0.4	13.1	1,938.6	0.4	1.3	1	1	1
02/18/2015 23:00	0.3	13.3	1,865.1	0.3	1.0	1	1	1
Average/Sum#:	0.3	13.3	1,807.6	0.2	24.9 #	24 #	24 #	19 #
Minimum:	0.0	12.6	1,307.4	0.0	0.0	1	1	0
Maximum:	0.7	13.9	2,026.5	0.4	2.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/19/2015 00:00	0.5	13.0	1,961.5	0.3	1.6	1	1	1
02/19/2015 01:00	0.3	13.4	1,835.8	0.3	1.0	1	1	1
02/19/2015 02:00	0.1	13.8	1,428.3	0.2	0.3	1	1	1
02/19/2015 03:00	0.0	13.9	1,311.3	0.1	0.0	1	1	0
02/19/2015 04:00	0.1	13.8	1,435.3	0.1	0.3	1	1	1
02/19/2015 05:00	0.5	13.2	1,923.7	0.2	1.6	1	1	1
02/19/2015 06:00	0.5	13.1	1,940.7	0.3	1.6	1	1	1
02/19/2015 07:00	0.6	12.8	1,979.3	0.4	1.9	1	1	1
02/19/2015 08:00	0.5	12.9	1,985.2	0.4	1.6	1	1	1
02/19/2015 09:00	0.4	13.1	1,945.1	0.4	1.3	1	1	1
02/19/2015 10:00	0.7	12.7	2,021.8	0.4	2.3	1	1	1
02/19/2015 11:00	0.5	12.9	1,988.6	0.4	1.6	1	1	1
02/19/2015 12:00	0.4	13.0	1,942.3	0.4	1.3	1	1	1
02/19/2015 13:00	0.5	13.0	1,950.5	0.4	1.6	1	1	1
02/19/2015 14:00	0.3	13.4	1,852.5	0.3	1.0	1	1	1
02/19/2015 15:00	0.3	13.4	1,855.5	0.3	1.0	1	1	1
02/19/2015 16:00	0.3	13.3	1,870.0	0.2	1.0	1	1	1
02/19/2015 17:00	0.2	13.4	1,851.9	0.2	0.7	1	1	1
02/19/2015 18:00	0.5	13.0	1,939.2	0.3	1.6	1	1	1
02/19/2015 19:00	0.3	13.3	1,850.5	0.3	1.0	1	1	1
02/19/2015 20:00	0.3	13.4	1,843.1	0.3	1.0	1	1	1
02/19/2015 21:00	0.3	13.4	1,850.6	0.2	1.0	1	1	1
02/19/2015 22:00	0.3	13.3	1,881.9	0.2	1.0	1	1	1
02/19/2015 23:00	0.4	13.1	1,816.6	0.2	1.2	1	1	1
Average/Sum#:	0.4	13.2	1,844.2	0.3	28.5 #	24 #	24 #	23 #
Minimum:	0.0	12.7	1,311.3	0.1	0.0	1	1	0
Maximum:	0.7	13.9	2,021.8	0.4	2.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/20/2015 00:00	0.0	13.9	1,345.3	0.2	0.0	1	1	0
02/20/2015 01:00	16.5	15.9	571.2	0.0	5.7	1	0	0
02/20/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/20/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/20/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/20/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/20/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/20/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/20/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	8.3	14.9	958.3	0.2	5.7 #	2 #	7 #	0 #
Minimum:	0.0	13.9	571.2	0.2	0.0	0	0	0
Maximum:	16.5	15.9	1,345.3	0.2	5.7	1	1	0
%SI	91.7	91.7	91.7	95.8	91.7	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/21/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/21/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/21/2015 15:00	131.6	17.4	509.5	0.0	169.5	1	1	0
02/21/2015 16:00	13.5	14.8	1,042.1	0.0	30.5	1	1	0
02/21/2015 17:00	0.0	13.8	1,506.1	0.0	0.0	1	1	1
02/21/2015 18:00	0.5	12.8	1,973.2	0.0	1.6	1	1	1
02/21/2015 19:00	0.6	12.6	2,022.8	0.3	1.9	1	1	1
02/21/2015 20:00	0.6	12.7	2,019.2	0.4	2.0	1	1	1
02/21/2015 21:00	0.4	12.9	1,984.1	0.4	1.3	1	1	1
02/21/2015 22:00	0.6	12.8	2,031.9	0.4	2.0	1	1	1
02/21/2015 23:00	0.4	13.1	1,943.6	0.3	1.3	1	1	1
Average/Sum#:	16.5	13.7	1,670.3	0.4	210.1 #	9 #	11 #	7 #
Minimum:	0.0	12.6	509.5	0.3	0.0	0	0	0
Maximum:	131.6	17.4	2,031.9	0.4	169.5	1	1	1
%SI	62.5	62.5	62.5	79.2	62.5	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/22/2015 00:00	0.0	14.0	1,401.2	0.2	0.0	1	1	0
02/22/2015 01:00	0.0	13.9	1,549.0	0.1	0.0	1	1	0
02/22/2015 02:00	0.0	14.0	1,293.0	0.0	0.0	1	1	0
02/22/2015 03:00	0.0	14.0	1,342.6	0.0	0.0	1	1	0
02/22/2015 04:00	0.0	14.0	1,584.9	0.0	0.0	1	1	0
02/22/2015 05:00	0.0	14.0	1,500.5	0.0	0.0	1	1	0
02/22/2015 06:00	19.3	16.5	403.5	0.0	4.2	1	0	0
02/22/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2015 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2015 16:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/22/2015 17:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/22/2015 18:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/22/2015 19:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/22/2015 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/22/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/22/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	2.8	14.3	1,296.4	0.1	4.2 #	7 #	12 #	0 #
Minimum:	0.0	13.9	403.5	0.0	0.0	0	0	0
Maximum:	19.3	16.5	1,584.9	0.2	4.2	1	1	0
%SI	70.8	70.8	70.8	75.0	70.8	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/23/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/23/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/23/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/23/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/23/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/23/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/23/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/23/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/23/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/23/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/23/2015 15:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/23/2015 16:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/23/2015 17:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/23/2015 18:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/23/2015 19:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/23/2015 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/23/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/23/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/23/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	19 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/24/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/24/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/24/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/24/2015 03:00	84.5	17.8	457.8	0.0	95.6	1	1	0
02/24/2015 04:00	25.0	15.8	718.2	0.0	46.5	1	1	0
02/24/2015 05:00	2.3	13.7	1,613.7	0.0	6.8	1	1	1
02/24/2015 06:00	0.5	12.9	2,017.2	0.0	1.7	1	1	1
02/24/2015 07:00	0.5	13.0	2,012.0	0.0	1.7	1	1	1
02/24/2015 08:00	0.3	13.2	1,960.4	0.3	1.0	1	1	1
02/24/2015 09:00	0.0	13.7	1,558.6	0.2	0.0	1	1	1
02/24/2015 10:00	0.0	14.0	1,325.8	0.1	0.0	1	1	0
02/24/2015 11:00	0.0	14.0	1,293.5	0.0	0.0	1	1	0
02/24/2015 12:00	0.0	14.0	1,292.0	0.0	0.0	1	1	0
02/24/2015 13:00	0.0	14.0	1,289.1	0.0	0.0	1	1	0
02/24/2015 14:00	0.0	14.0	1,310.1	0.0	0.0	1	1	0
02/24/2015 15:00	0.0	14.0	1,364.1	0.0	0.0	1	1	0
02/24/2015 16:00	0.0	13.8	1,477.7	0.0	0.0	1	1	1
02/24/2015 17:00	0.6	12.9	1,969.0	0.1	2.0	1	1	1
02/24/2015 18:00	0.6	12.7	2,015.2	0.3	1.9	1	1	1
02/24/2015 19:00	0.6	12.8	2,012.3	0.4	2.0	1	1	1
02/24/2015 20:00	0.6	12.8	2,018.9	0.4	2.0	1	1	1
02/24/2015 21:00	0.6	12.9	2,024.7	0.4	2.0	1	1	1
02/24/2015 22:00	0.3	13.3	1,820.3	0.3	0.9	1	1	1
02/24/2015 23:00	0.0	14.0	1,489.8	0.2	0.0	1	1	0
Average/Sum#:	5.5	13.8	1,573.4	0.2	164.1 #	21 #	24 #	12 #
Minimum:	0.0	12.7	457.8	0.0	0.0	0	1	0
Maximum:	84.5	17.8	2,024.7	0.4	95.6	1	1	1
%SI	12.5	12.5	12.5	33.3	12.5	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/25/2015 00:00	0.0	13.9	1,301.2	0.1	0.0	1	1	0
02/25/2015 01:00	0.0	14.0	1,754.7	0.0	0.0	1	1	0
02/25/2015 02:00	0.0	13.9	1,735.6	0.0	0.0	1	1	0
02/25/2015 03:00	0.0	13.9	1,442.5	0.0	0.0	1	1	0
02/25/2015 04:00	0.0	13.9	1,287.6	0.0	0.0	1	1	0
02/25/2015 05:00	0.2	13.6	1,632.5	0.1	0.6	1	1	1
02/25/2015 06:00	0.5	13.1	1,991.4	0.2	1.7	1	1	1
02/25/2015 07:00	0.5	13.1	1,971.7	0.3	1.7	1	1	1
02/25/2015 08:00	0.1	13.6	1,734.4	0.3	0.3	1	1	1
02/25/2015 09:00	0.0	13.9	1,307.2	0.2	0.0	1	1	0
02/25/2015 10:00	0.0	14.0	1,291.5	0.0	0.0	1	1	0
02/25/2015 11:00	0.0	14.0	1,292.1	0.0	0.0	1	1	0
02/25/2015 12:00	0.0	14.0	1,293.3	0.0	0.0	1	1	0
02/25/2015 13:00	0.0	14.0	1,410.7	0.0	0.0	1	1	0
02/25/2015 14:00	0.0	14.0	1,299.6	0.0	0.0	1	1	0
02/25/2015 15:00	0.0	14.0	1,292.8	0.0	0.0	1	1	0
02/25/2015 16:00	0.0	13.8	1,466.8	0.0	0.0	1	1	1
02/25/2015 17:00	0.6	12.9	1,956.1	0.1	1.9	1	1	1
02/25/2015 18:00	0.6	12.8	1,980.6	0.3	1.9	1	1	1
02/25/2015 19:00	0.4	13.1	1,916.9	0.4	1.3	1	1	1
02/25/2015 20:00	0.4	13.2	1,925.6	0.3	1.3	1	1	1
02/25/2015 21:00	0.5	13.0	1,975.8	0.3	1.7	1	1	1
02/25/2015 22:00	0.4	13.3	1,790.1	0.3	1.2	1	1	1
02/25/2015 23:00	0.0	14.0	1,440.6	0.2	0.0	1	1	0
Average/Sum#:	0.2	13.6	1,603.8	0.1	13.6 #	24 #	24 #	11 #
Minimum:	0.0	12.8	1,287.6	0.0	0.0	1	1	0
Maximum:	0.6	14.0	1,991.4	0.4	1.9	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/26/2015 00:00	0.0	14.0	1,288.7	0.1	0.0	1	1	0
02/26/2015 01:00	0.0	14.0	1,303.7	0.0	0.0	1	1	0
02/26/2015 02:00	0.0	13.8	1,754.7	0.0	0.0	1	1	0
02/26/2015 03:00	0.0	13.8	1,816.7	0.0	0.0	1	1	0
02/26/2015 04:00	0.1	13.7	1,760.9	0.0	0.3	1	1	1
02/26/2015 05:00	0.4	13.2	1,945.5	0.1	1.3	1	1	1
02/26/2015 06:00	0.4	13.2	1,958.0	0.2	1.3	1	1	1
02/26/2015 07:00	0.5	13.0	1,969.6	0.3	1.6	1	1	1
02/26/2015 08:00	0.1	13.5	1,626.7	0.3	0.3	1	1	1
02/26/2015 09:00	0.0	14.0	1,374.8	0.2	0.0	1	1	0
02/26/2015 10:00	0.0	14.0	1,677.5	0.0	0.0	1	1	0
02/26/2015 11:00	0.0	13.9	1,699.9	0.0	0.0	1	1	0
02/26/2015 12:00	0.0	14.1	1,314.0	0.0	0.0	1	1	0
02/26/2015 13:00	0.0	14.0	1,289.8	0.0	0.0	1	1	0
02/26/2015 14:00	0.0	14.0	1,290.9	0.0	0.0	1	1	0
02/26/2015 15:00	0.0	14.0	1,477.3	0.0	0.0	1	1	0
02/26/2015 16:00	0.5	13.2	1,789.9	0.1	1.5	1	1	1
02/26/2015 17:00	0.6	12.9	1,956.0	0.3	1.9	1	1	1
02/26/2015 18:00	0.7	12.5	2,032.6	0.4	2.2	1	1	1
02/26/2015 19:00	0.6	12.5	2,029.8	0.4	1.9	1	1	1
02/26/2015 20:00	0.6	12.7	1,997.6	0.4	1.9	1	1	1
02/26/2015 21:00	0.6	12.8	1,981.9	0.4	1.9	1	1	1
02/26/2015 22:00	0.1	13.6	1,576.2	0.3	0.3	1	1	1
02/26/2015 23:00	0.0	14.0	1,286.8	0.2	0.0	1	1	0
Average/Sum#:	0.2	13.5	1,675.0	0.2	16.4 #	24 #	24 #	12 #
Minimum:	0.0	12.5	1,286.8	0.0	0.0	1	1	0
Maximum:	0.7	14.1	2,032.6	0.4	2.2	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/27/2015 00:00	0.0	13.8	1,715.6	0.0	0.0	1	1	0
02/27/2015 01:00	0.0	13.8	1,787.0	0.0	0.0	1	1	0
02/27/2015 02:00	0.0	13.8	1,767.6	0.0	0.0	1	1	0
02/27/2015 03:00	0.0	13.9	1,499.4	0.0	0.0	1	1	0
02/27/2015 04:00	0.0	14.0	1,287.7	0.0	0.0	1	1	0
02/27/2015 05:00	0.1	13.8	1,472.7	0.0	0.3	1	1	1
02/27/2015 06:00	0.6	13.0	1,991.1	0.2	2.0	1	1	1
02/27/2015 07:00	0.6	13.0	1,800.5	0.3	1.8	1	1	1
02/27/2015 08:00	0.0	14.0	1,304.2	0.3	0.0	1	1	0
02/27/2015 09:00	0.0	14.0	1,285.3	0.1	0.0	1	1	0
02/27/2015 10:00	0.0	14.0	1,291.0	0.0	0.0	1	1	0
02/27/2015 11:00	0.0	13.9	1,487.1	0.0	0.0	1	1	0
02/27/2015 12:00	0.0	14.0	1,288.7	0.0	0.0	1	1	0
02/27/2015 13:00	0.0	14.0	1,289.8	0.0	0.0	1	1	0
02/27/2015 14:00	0.0	14.0	1,285.2	0.0	0.0	1	1	0
02/27/2015 15:00	0.0	14.1	1,352.5	0.0	0.0	1	1	0
02/27/2015 16:00	0.0	14.0	1,448.8	0.0	0.0	1	1	0
02/27/2015 17:00	0.4	13.4	1,658.6	0.1	1.2	1	1	1
02/27/2015 18:00	0.8	12.6	2,050.2	0.3	2.6	1	1	1
02/27/2015 19:00	0.7	12.6	2,048.8	0.5	2.3	1	1	1
02/27/2015 20:00	0.7	12.7	2,050.2	0.5	2.3	1	1	1
02/27/2015 21:00	0.7	12.7	2,040.1	0.5	2.3	1	1	1
02/27/2015 22:00	0.7	12.8	2,022.8	0.5	2.3	1	1	1
02/27/2015 23:00	0.1	13.6	1,587.2	0.4	0.3	1	1	1
Average/Sum#:	0.2	13.6	1,617.2	0.2	17.4 #	24 #	24 #	10 #
Minimum:	0.0	12.6	1,285.2	0.0	0.0	1	1	0
Maximum:	0.8	14.1	2,050.2	0.5	2.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/28/2015 00:00	0.0	14.0	1,285.3	0.2	0.0	1	1	0
02/28/2015 01:00	13.7	15.9	572.0	0.0	4.6	1	0	0
02/28/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2015 08:00	22.9	16.9	566.9	0.0	30.0	1	0	0
02/28/2015 09:00	13.0	14.5	1,155.7	0.0	31.0	1	0	0
02/28/2015 10:00	0.0	13.9	1,610.8	0.0	0.0	1	0	0
02/28/2015 11:00	0.0	13.8	1,819.7	0.0	0.0	1	0	0
02/28/2015 12:00	0.0	13.9	1,591.4	0.0	0.0	1	0	0
02/28/2015 13:00	0.0	14.0	1,519.6	0.0	0.0	1	0	0
02/28/2015 14:00	0.0	13.8	1,785.2	0.0	0.0	1	0	0
02/28/2015 15:00	0.0	14.0	1,577.6	0.0	0.0	1	0	0
02/28/2015 16:00	0.1	13.7	1,584.1	0.0	0.3	1	1	1
02/28/2015 17:00	0.8	12.8	2,008.3	0.2	2.6	1	1	1
02/28/2015 18:00	0.8	12.7	2,030.8	0.4	2.6	1	1	1
02/28/2015 19:00	0.7	12.8	2,031.6	0.6	2.3	1	1	1
02/28/2015 20:00	0.7	12.8	2,038.1	0.5	2.3	1	1	1
02/28/2015 21:00	0.7	12.8	2,035.5	0.5	2.3	1	1	1
02/28/2015 22:00	0.7	12.8	2,036.7	0.5	2.3	1	1	1
02/28/2015 23:00	0.6	12.9	2,011.2	0.5	2.0	1	1	1
Average/Sum#:	3.0	13.8	1,625.6	0.3	82.3 #	18 #	9 #	8 #
Minimum:	0.0	12.7	566.9	0.0	0.0	0	0	0
Maximum:	22.9	16.9	2,038.1	0.6	31.0	1	1	1
%SI	25.0	25.0	25.0	45.8	25.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/01/2015 00:00	0.5	13.0	1,991.7	0.4	1.7	1	1	1
03/01/2015 01:00	0.2	13.5	1,858.2	0.3	0.7	1	1	1
03/01/2015 02:00	0.0	14.0	1,587.3	0.2	0.0	1	1	0
03/01/2015 03:00	0.0	14.0	1,665.9	0.1	0.0	1	1	0
03/01/2015 04:00	0.0	14.0	1,379.1	0.0	0.0	1	1	0
03/01/2015 05:00	0.0	13.9	1,745.9	0.0	0.0	1	1	0
03/01/2015 06:00	0.0	13.9	1,794.8	0.0	0.0	1	1	0
03/01/2015 07:00	0.0	13.8	1,835.0	0.0	0.0	1	1	0
03/01/2015 08:00	0.3	13.4	1,881.7	0.1	1.0	1	1	1
03/01/2015 09:00	0.7	12.8	2,040.1	0.2	2.3	1	1	1
03/01/2015 10:00	0.7	12.8	2,044.9	0.4	2.3	1	1	1
03/01/2015 11:00	0.7	12.7	2,050.5	0.5	2.3	1	1	1
03/01/2015 12:00	0.7	12.7	2,053.3	0.5	2.3	1	1	1
03/01/2015 13:00	0.5	13.0	1,986.5	0.5	1.7	1	1	1
03/01/2015 14:00	0.6	12.8	2,025.9	0.4	2.0	1	1	1
03/01/2015 15:00	0.7	12.6	2,053.6	0.4	2.3	1	1	1
03/01/2015 16:00	0.6	12.7	2,026.6	0.4	2.0	1	1	1
03/01/2015 17:00	0.7	12.6	2,053.2	0.5	2.3	1	1	1
03/01/2015 18:00	0.7	12.6	2,053.4	0.5	2.3	1	1	1
03/01/2015 19:00	0.7	12.7	2,052.5	0.5	2.3	1	1	1
03/01/2015 20:00	0.7	12.7	2,053.0	0.5	2.3	1	1	1
03/01/2015 21:00	0.7	12.7	2,052.7	0.5	2.3	1	1	1
03/01/2015 22:00	0.6	12.8	2,035.8	0.5	2.0	1	1	1
03/01/2015 23:00	0.6	13.0	1,993.3	0.4	2.0	1	1	1
Average/Sum#:	0.5	13.1	1,929.8	0.3	36.1 #	24 #	24 #	18 #
Minimum:	0.0	12.6	1,379.1	0.0	0.0	1	1	0
Maximum:	0.7	14.0	2,053.6	0.5	2.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/02/2015 00:00	0.6	12.9	2,009.0	0.4	2.0	1	1	1
03/02/2015 01:00	0.7	12.8	2,026.3	0.4	2.3	1	1	1
03/02/2015 02:00	0.6	13.0	1,996.9	0.4	2.0	1	1	1
03/02/2015 03:00	0.3	13.3	1,941.6	0.4	1.0	1	1	1
03/02/2015 04:00	0.2	13.6	1,816.0	0.3	0.7	1	1	1
03/02/2015 05:00	0.6	13.1	1,977.4	0.3	2.0	1	1	1
03/02/2015 06:00	0.7	13.0	2,000.8	0.4	2.3	1	1	1
03/02/2015 07:00	0.8	12.8	2,029.4	0.5	2.6	1	1	1
03/02/2015 08:00	0.7	12.9	2,008.5	0.5	2.3	1	1	1
03/02/2015 09:00	0.7	12.9	2,013.8	0.5	2.3	1	1	1
03/02/2015 10:00	0.6	13.0	2,006.3	0.5	2.0	1	1	1
03/02/2015 11:00	0.5	13.0	1,978.5	0.4	1.7	1	1	1
03/02/2015 12:00	0.6	12.9	2,004.4	0.4	2.0	1	1	1
03/02/2015 13:00	0.6	12.9	1,992.8	0.4	2.0	1	1	1
03/02/2015 14:00	0.1	13.6	1,699.2	0.3	0.3	1	1	1
03/02/2015 15:00	0.0	13.9	1,616.8	0.2	0.0	1	1	0
03/02/2015 16:00	0.3	13.5	1,823.6	0.1	1.0	1	1	1
03/02/2015 17:00	0.3	13.3	1,927.3	0.1	1.0	1	1	1
03/02/2015 18:00	0.3	13.3	1,932.6	0.2	1.0	1	1	1
03/02/2015 19:00	0.3	13.3	1,936.3	0.2	1.0	1	1	1
03/02/2015 20:00	0.3	13.3	1,942.8	0.2	1.0	1	1	1
03/02/2015 21:00	0.3	13.3	1,943.3	0.2	1.0	1	1	1
03/02/2015 22:00	0.2	13.5	1,801.7	0.2	0.6	1	1	1
03/02/2015 23:00	0.0	13.9	1,545.1	0.1	0.0	1	1	0
Average/Sum#:	0.4	13.2	1,915.4	0.3	34.1 #	24 #	24 #	22 #
Minimum:	0.0	12.8	1,545.1	0.1	0.0	1	1	0
Maximum:	0.8	13.9	2,029.4	0.5	2.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/03/2015 00:00	0.0	13.9	1,288.7	0.1	0.0	1	1	0
03/03/2015 01:00	0.0	13.9	1,289.4	0.0	0.0	1	1	0
03/03/2015 02:00	0.0	13.9	1,292.2	0.0	0.0	1	1	0
03/03/2015 03:00	0.0	13.9	1,294.3	0.0	0.0	1	1	0
03/03/2015 04:00	0.2	13.7	1,562.2	0.1	0.6	1	1	1
03/03/2015 05:00	0.6	13.1	1,989.1	0.2	2.0	1	1	1
03/03/2015 06:00	0.7	12.9	2,026.0	0.4	2.3	1	1	1
03/03/2015 07:00	0.6	13.0	1,981.8	0.5	2.0	1	1	1
03/03/2015 08:00	0.1	13.7	1,594.7	0.3	0.3	1	1	1
03/03/2015 09:00	0.0	14.0	1,290.8	0.2	0.0	1	1	0
03/03/2015 10:00	0.0	14.0	1,293.1	0.0	0.0	1	1	0
03/03/2015 11:00	0.0	14.0	1,293.5	0.0	0.0	1	1	0
03/03/2015 12:00	0.0	14.0	1,296.6	0.0	0.0	1	1	0
03/03/2015 13:00	0.0	14.0	1,298.0	0.0	0.0	1	1	0
03/03/2015 14:00	0.0	14.0	1,292.8	0.0	0.0	1	1	0
03/03/2015 15:00	0.0	14.0	1,292.4	0.0	0.0	1	1	0
03/03/2015 16:00	0.0	13.9	1,406.7	0.0	0.0	1	1	1
03/03/2015 17:00	0.4	13.2	1,938.6	0.1	1.3	1	1	1
03/03/2015 18:00	0.6	12.9	2,010.7	0.2	2.0	1	1	1
03/03/2015 19:00	0.7	12.7	2,055.8	0.4	2.3	1	1	1
03/03/2015 20:00	0.7	12.7	2,049.7	0.5	2.3	1	1	1
03/03/2015 21:00	0.7	12.7	2,049.8	0.5	2.3	1	1	1
03/03/2015 22:00	0.6	12.9	2,011.7	0.5	2.0	1	1	1
03/03/2015 23:00	0.1	13.6	1,718.2	0.3	0.3	1	1	1
Average/Sum#:	0.3	13.5	1,609.0	0.2	19.7 #	24 #	24 #	13 #
Minimum:	0.0	12.7	1,288.7	0.0	0.0	1	1	0
Maximum:	0.7	14.0	2,055.8	0.5	2.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/04/2015 00:00	0.0	13.9	1,813.5	0.2	0.0	1	1	0
03/04/2015 01:00	0.0	13.9	1,786.5	0.0	0.0	1	1	0
03/04/2015 02:00	0.0	14.1	1,736.5	0.0	0.0	1	1	0
03/04/2015 03:00	0.0	13.9	1,769.1	0.0	0.0	1	1	0
03/04/2015 04:00	0.3	13.5	1,819.7	0.1	1.0	1	1	1
03/04/2015 05:00	0.6	13.0	2,003.0	0.2	2.0	1	1	1
03/04/2015 06:00	0.5	13.0	2,006.0	0.3	1.7	1	1	1
03/04/2015 07:00	0.6	12.9	2,001.0	0.4	2.0	1	1	1
03/04/2015 08:00	0.4	13.1	1,977.6	0.4	1.3	1	1	1
03/04/2015 09:00	0.0	13.8	1,456.5	0.2	0.0	1	1	1
03/04/2015 10:00	0.0	14.0	1,292.8	0.1	0.0	1	1	0
03/04/2015 11:00	0.0	14.0	1,291.4	0.0	0.0	1	1	0
03/04/2015 12:00	0.0	14.0	1,290.1	0.0	0.0	1	1	0
03/04/2015 13:00	0.0	14.0	1,288.9	0.0	0.0	1	1	0
03/04/2015 14:00	0.0	14.0	1,289.0	0.0	0.0	1	1	0
03/04/2015 15:00	0.0	14.0	1,288.3	0.0	0.0	1	1	0
03/04/2015 16:00	0.2	13.7	1,545.9	0.1	0.6	1	1	1
03/04/2015 17:00	0.8	12.8	2,008.9	0.3	2.6	1	1	1
03/04/2015 18:00	0.7	12.7	2,031.5	0.4	2.3	1	1	1
03/04/2015 19:00	0.7	12.7	2,027.5	0.5	2.3	1	1	1
03/04/2015 20:00	0.7	12.8	2,026.1	0.5	2.3	1	1	1
03/04/2015 21:00	0.6	12.9	2,009.7	0.5	2.0	1	1	1
03/04/2015 22:00	0.6	13.0	2,013.6	0.4	2.0	1	1	1
03/04/2015 23:00	0.4	13.2	1,982.8	0.4	1.4	1	1	1
Average/Sum#:	0.3	13.5	1,739.8	0.2	23.5 #	24 #	24 #	14 #
Minimum:	0.0	12.7	1,288.3	0.0	0.0	1	1	0
Maximum:	0.8	14.1	2,031.5	0.5	2.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/05/2015 00:00	0.2	13.5	1,807.0	0.3	0.6	1	1	1
03/05/2015 01:00	0.0	13.9	1,591.2	0.2	0.0	1	1	0
03/05/2015 02:00	0.0	13.9	1,546.0	0.1	0.0	1	1	0
03/05/2015 03:00	0.0	13.9	1,632.9	0.0	0.0	1	1	0
03/05/2015 04:00	0.1	13.8	1,760.9	0.0	0.3	1	1	1
03/05/2015 05:00	0.6	13.1	1,991.2	0.2	2.0	1	1	1
03/05/2015 06:00	0.7	13.0	2,018.4	0.4	2.4	1	1	1
03/05/2015 07:00	0.6	13.1	2,015.3	0.5	2.0	1	1	1
03/05/2015 08:00	0.4	13.3	1,941.5	0.4	1.3	1	1	1
03/05/2015 09:00	0.0	13.8	1,455.1	0.3	0.0	1	1	1
03/05/2015 10:00	0.0	13.9	1,292.3	0.1	0.0	1	1	0
03/05/2015 11:00	0.0	14.0	1,292.4	0.0	0.0	1	1	0
03/05/2015 12:00	0.0	14.0	1,292.5	0.0	0.0	1	1	0
03/05/2015 13:00	0.0	14.0	1,293.4	0.0	0.0	1	1	0
03/05/2015 14:00	0.0	14.0	1,294.8	0.0	0.0	1	1	0
03/05/2015 15:00	0.0	14.0	1,295.6	0.0	0.0	1	1	0
03/05/2015 16:00	0.1	13.7	1,549.7	0.0	0.3	1	1	1
03/05/2015 17:00	0.8	12.6	2,023.1	0.2	2.6	1	1	1
03/05/2015 18:00	0.7	12.6	2,035.5	0.4	2.3	1	1	1
03/05/2015 19:00	0.7	12.6	2,031.7	0.5	2.3	1	1	1
03/05/2015 20:00	0.7	12.7	2,029.0	0.5	2.3	1	1	1
03/05/2015 21:00	0.7	12.7	2,018.7	0.5	2.3	1	1	1
03/05/2015 22:00	0.6	12.8	2,010.9	0.5	2.0	1	1	1
03/05/2015 23:00	0.2	13.4	1,745.1	0.4	0.6	1	1	1
Average/Sum#:	0.3	13.4	1,706.8	0.2	23.3 #	24 #	24 #	15 #
Minimum:	0.0	12.6	1,292.3	0.0	0.0	1	1	0
Maximum:	0.8	14.0	2,035.5	0.5	2.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/06/2015 00:00	0.0	13.9	1,294.5	0.2	0.0	1	1	0
03/06/2015 01:00	0.0	13.9	1,292.1	0.1	0.0	1	1	0
03/06/2015 02:00	0.0	13.9	1,290.3	0.0	0.0	1	1	0
03/06/2015 03:00	0.0	13.9	1,292.0	0.0	0.0	1	1	0
03/06/2015 04:00	0.1	13.9	1,293.1	0.0	0.2	1	1	0
03/06/2015 05:00	0.3	13.6	1,570.5	0.1	0.9	1	1	1
03/06/2015 06:00	0.6	13.1	1,994.1	0.3	2.0	1	1	1
03/06/2015 07:00	0.5	13.2	1,954.1	0.4	1.7	1	1	1
03/06/2015 08:00	0.3	13.3	1,941.3	0.4	1.0	1	1	1
03/06/2015 09:00	0.4	13.3	1,949.5	0.3	1.4	1	1	1
03/06/2015 10:00	0.1	13.6	1,612.8	0.2	0.3	1	1	1
03/06/2015 11:00	0.0	14.0	1,291.4	0.1	0.0	1	1	0
03/06/2015 12:00	0.0	14.0	1,292.6	0.0	0.0	1	1	0
03/06/2015 13:00	0.0	14.0	1,295.6	0.0	0.0	1	1	0
03/06/2015 14:00	0.0	14.0	1,298.0	0.0	0.0	1	1	0
03/06/2015 15:00	0.0	14.0	1,297.6	0.0	0.0	1	1	0
03/06/2015 16:00	0.2	13.7	1,535.8	0.1	0.6	1	1	1
03/06/2015 17:00	0.8	12.6	1,996.7	0.3	2.5	1	1	1
03/06/2015 18:00	0.7	12.4	2,042.2	0.4	2.2	1	1	1
03/06/2015 19:00	0.7	12.4	2,042.1	0.5	2.2	1	1	1
03/06/2015 20:00	0.7	12.5	2,038.0	0.5	2.2	1	1	1
03/06/2015 21:00	0.6	12.8	2,003.6	0.5	2.0	1	1	1
03/06/2015 22:00	0.6	12.8	2,009.9	0.4	2.0	1	1	1
03/06/2015 23:00	0.5	12.9	1,995.0	0.4	1.6	1	1	1
Average/Sum#:	0.3	13.4	1,651.0	0.2	22.8 #	24 #	24 #	14 #
Minimum:	0.0	12.4	1,290.3	0.0	0.0	1	1	0
Maximum:	0.8	14.0	2,042.2	0.5	2.5	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/07/2015 00:00	0.4	13.2	1,881.1	0.4	1.3	1	1	1
03/07/2015 01:00	0.0	13.8	1,727.7	0.2	0.0	1	1	0
03/07/2015 02:00	18.8	16.1	468.2	0.0	4.4	1	0	0
03/07/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2015 10:00	27.8	16.8	573.4	0.0	35.9	1	0	0
03/07/2015 11:00	26.2	15.0	999.4	0.0	58.6	1	0	0
03/07/2015 12:00	0.0	13.9	1,751.8	0.0	0.0	1	0	0
03/07/2015 13:00	0.0	13.9	1,754.1	0.0	0.0	1	0	0
03/07/2015 14:00	0.0	13.9	1,686.5	0.0	0.0	1	0	0
03/07/2015 15:00	0.0	14.0	1,453.4	0.0	0.0	1	0	0
03/07/2015 16:00	0.3	13.5	1,700.8	0.1	0.9	1	1	1
03/07/2015 17:00	0.8	12.4	2,038.3	0.3	2.5	1	1	1
03/07/2015 18:00	0.7	12.5	2,011.2	0.4	2.2	1	1	1
03/07/2015 19:00	0.7	12.4	2,039.0	0.5	2.2	1	1	1
03/07/2015 20:00	0.6	12.5	2,037.5	0.5	1.9	1	1	1
03/07/2015 21:00	0.5	12.8	1,993.6	0.4	1.6	1	1	1
03/07/2015 22:00	0.6	12.9	1,993.2	0.4	2.0	1	1	1
03/07/2015 23:00	0.3	13.2	1,789.3	0.3	0.9	1	1	1
Average/Sum#:	4.6	13.7	1,641.1	0.3	114.4 #	17 #	10 #	9 #
Minimum:	0.0	12.4	468.2	0.0	0.0	0	0	0
Maximum:	27.8	16.8	2,039.0	0.5	58.6	1	1	1
%SI	29.2	29.2	29.2	50.0	29.2	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/08/2015 00:00	0.0	14.0	1,286.2	0.2	0.0	1	1	0
03/08/2015 01:00	0.0	14.0	1,286.3	0.1	0.0	1	1	0
03/08/2015 02:00	0.0	14.0	1,286.7	0.0	0.0	1	1	0
03/08/2015 03:00	0.0	14.0	1,287.3	0.0	0.0	1	1	0
03/08/2015 04:00	0.0	14.0	1,288.2	0.0	0.0	1	1	0
03/08/2015 05:00	0.0	14.0	1,288.0	0.0	0.0	1	1	0
03/08/2015 06:00	0.1	13.9	1,290.3	0.0	0.2	1	1	0
03/08/2015 07:00	0.1	13.9	1,290.6	0.1	0.2	1	1	0
03/08/2015 08:00	15.4	15.8	578.5	0.0	5.1	1	0	0
03/08/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
03/08/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
03/08/2015 14:00	0.0	21.0	0.2	0.0	0.0	1	1	0
03/08/2015 15:00	36.7	16.0	676.0	0.0	66.9	1	1	0
03/08/2015 16:00	0.7	14.0	1,295.4	0.0	1.7	1	1	0
03/08/2015 17:00	0.0	14.0	1,294.9	0.0	0.0	1	1	0
03/08/2015 18:00	0.4	13.4	1,691.0	0.0	1.2	1	1	1
03/08/2015 19:00	0.8	12.7	1,965.3	0.3	2.5	1	1	1
03/08/2015 20:00	0.6	13.0	1,853.8	0.4	1.9	1	1	1
03/08/2015 21:00	0.0	14.0	1,310.9	0.3	0.0	1	1	0
03/08/2015 22:00	0.0	14.0	1,288.3	0.1	0.0	1	1	0
03/08/2015 23:00	0.0	14.0	1,288.2	0.0	0.0	1	1	0
Average/Sum#:	2.9	14.4	1,239.3	0.1	79.7 #	19 #	20 #	3 #
Minimum:	0.0	12.7	0.2	0.0	0.0	0	0	0
Maximum:	36.7	21.0	1,965.3	0.4	66.9	1	1	1
%SI	20.8	20.8	20.8	45.8	20.8	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/09/2015 00:00	0.0	14.0	1,287.1	0.0	0.0	1	1	0
03/09/2015 01:00	0.0	14.0	1,285.9	0.0	0.0	1	1	0
03/09/2015 02:00	0.0	14.0	1,286.2	0.0	0.0	1	1	0
03/09/2015 03:00	0.0	14.0	1,285.0	0.0	0.0	1	1	0
03/09/2015 04:00	0.1	13.9	1,400.9	0.0	0.3	1	1	1
03/09/2015 05:00	0.8	12.9	1,995.2	0.2	2.6	1	1	1
03/09/2015 06:00	0.9	12.7	2,053.3	0.4	3.0	1	1	1
03/09/2015 07:00	0.6	13.0	1,970.0	0.5	2.0	1	1	1
03/09/2015 08:00	0.4	13.2	1,953.3	0.4	1.3	1	1	1
03/09/2015 09:00	0.0	13.9	1,331.1	0.2	0.0	1	1	1
03/09/2015 10:00	0.0	14.0	1,285.7	0.1	0.0	1	1	0
03/09/2015 11:00	0.0	14.0	1,285.7	0.0	0.0	1	1	0
03/09/2015 12:00	0.0	14.0	1,286.7	0.0	0.0	1	1	0
03/09/2015 13:00	0.0	14.0	1,293.4	0.0	0.0	1	1	0
03/09/2015 14:00	0.2	13.6	1,619.5	0.1	0.6	1	1	1
03/09/2015 15:00	0.0	14.0	1,285.8	0.1	0.0	1	1	0
03/09/2015 16:00	0.0	14.0	1,285.4	0.1	0.0	1	1	0
03/09/2015 17:00	0.5	13.2	1,727.0	0.1	1.5	1	1	1
03/09/2015 18:00	0.8	12.4	2,041.8	0.3	2.5	1	1	1
03/09/2015 19:00	0.8	12.5	2,041.9	0.5	2.6	1	1	1
03/09/2015 20:00	0.7	12.6	2,017.9	0.6	2.2	1	1	1
03/09/2015 21:00	0.5	12.9	1,958.2	0.5	1.6	1	1	1
03/09/2015 22:00	0.7	12.8	1,989.9	0.5	2.3	1	1	1
03/09/2015 23:00	0.5	13.0	1,946.8	0.4	1.6	1	1	1
Average/Sum#:	0.3	13.4	1,621.4	0.2	24.1 #	24 #	24 #	14 #
Minimum:	0.0	12.4	1,285.0	0.0	0.0	1	1	0
Maximum:	0.9	14.0	2,053.3	0.6	3.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/10/2015 00:00	0.4	13.1	1,926.2	0.4	1.3	1	1	1
03/10/2015 01:00	0.6	12.9	1,967.5	0.4	1.9	1	1	1
03/10/2015 02:00	0.4	13.2	1,914.9	0.3	1.3	1	1	1
03/10/2015 03:00	0.4	13.1	1,922.9	0.3	1.3	1	1	1
03/10/2015 04:00	0.5	13.1	1,954.1	0.3	1.7	1	1	1
03/10/2015 05:00	0.7	12.9	2,013.8	0.4	2.3	1	1	1
03/10/2015 06:00	0.8	12.8	2,046.4	0.5	2.7	1	1	1
03/10/2015 07:00	0.7	12.8	2,004.7	0.5	2.3	1	1	1
03/10/2015 08:00	0.3	13.4	1,800.6	0.4	1.0	1	1	1
03/10/2015 09:00	0.0	13.9	1,414.1	0.2	0.0	1	1	0
03/10/2015 10:00	0.0	13.9	1,288.2	0.1	0.0	1	1	0
03/10/2015 11:00	0.0	14.0	1,288.1	0.0	0.0	1	1	0
03/10/2015 12:00	0.0	14.0	1,288.5	0.0	0.0	1	1	0
03/10/2015 13:00	0.0	14.0	1,288.9	0.0	0.0	1	1	0
03/10/2015 14:00	0.0	14.0	1,289.3	0.0	0.0	1	1	0
03/10/2015 15:00	0.0	14.0	1,288.7	0.0	0.0	1	1	0
03/10/2015 16:00	0.1	13.9	1,398.9	0.0	0.3	1	1	1
03/10/2015 17:00	1.0	12.5	2,023.3	0.3	3.2	1	1	1
03/10/2015 18:00	0.9	12.5	2,033.7	0.5	2.9	1	1	1
03/10/2015 19:00	0.8	12.5	2,038.7	0.6	2.6	1	1	1
03/10/2015 20:00	0.8	12.5	2,035.7	0.6	2.6	1	1	1
03/10/2015 21:00	0.7	12.7	1,989.8	0.6	2.2	1	1	1
03/10/2015 22:00	0.3	13.4	1,671.8	0.4	0.9	1	1	1
03/10/2015 23:00	0.0	13.9	1,287.5	0.2	0.0	1	1	0
Average/Sum#:	0.4	13.3	1,715.7	0.3	30.5 #	24 #	24 #	16 #
Minimum:	0.0	12.5	1,287.5	0.0	0.0	1	1	0
Maximum:	1.0	14.0	2,046.4	0.6	3.2	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/11/2015 00:00	0.0	13.9	1,287.4	0.1	0.0	1	1	0
03/11/2015 01:00	0.1	13.9	1,288.6	0.0	0.2	1	1	0
03/11/2015 02:00	0.1	13.9	1,288.6	0.1	0.2	1	1	0
03/11/2015 03:00	0.0	14.0	1,288.3	0.1	0.0	1	1	0
03/11/2015 04:00	0.1	13.8	1,404.7	0.1	0.3	1	1	1
03/11/2015 05:00	0.6	13.2	1,936.8	0.2	2.0	1	1	1
03/11/2015 06:00	0.6	13.0	1,979.6	0.3	2.0	1	1	1
03/11/2015 07:00	0.8	12.7	2,047.5	0.5	2.6	1	1	1
03/11/2015 08:00	0.8	12.7	2,049.3	0.5	2.6	1	1	1
03/11/2015 09:00	0.7	12.7	2,044.5	0.6	2.3	1	1	1
03/11/2015 10:00	0.7	12.6	2,042.8	0.5	2.3	1	1	1
03/11/2015 11:00	0.7	12.6	2,044.1	0.5	2.3	1	1	1
03/11/2015 12:00	0.7	12.6	2,038.5	0.5	2.3	1	1	1
03/11/2015 13:00	0.7	12.6	2,044.8	0.5	2.3	1	1	1
03/11/2015 14:00	0.7	12.6	2,041.6	0.5	2.3	1	1	1
03/11/2015 15:00	0.7	12.6	2,043.3	0.5	2.3	1	1	1
03/11/2015 16:00	0.7	12.6	2,042.8	0.5	2.3	1	1	1
03/11/2015 17:00	0.4	13.0	1,961.1	0.4	1.3	1	1	1
03/11/2015 18:00	0.7	12.6	2,042.0	0.4	2.3	1	1	1
03/11/2015 19:00	0.7	12.7	2,050.1	0.4	2.3	1	1	1
03/11/2015 20:00	0.5	12.9	2,004.1	0.5	1.7	1	1	1
03/11/2015 21:00	0.1	13.5	1,619.4	0.3	0.3	1	1	1
03/11/2015 22:00	0.0	13.9	1,292.9	0.2	0.0	1	1	0
03/11/2015 23:00	0.0	13.9	1,297.1	0.0	0.0	1	1	0
Average/Sum#:	0.5	13.1	1,799.2	0.3	36.2 #	24 #	24 #	18 #
Minimum:	0.0	12.6	1,287.4	0.0	0.0	1	1	0
Maximum:	0.8	14.0	2,050.1	0.6	2.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/12/2015 00:00	0.0	13.9	1,300.4	0.0	0.0	1	1	0
03/12/2015 01:00	0.0	13.9	1,305.1	0.0	0.0	1	1	0
03/12/2015 02:00	0.1	13.9	1,307.5	0.0	0.2	1	1	0
03/12/2015 03:00	0.1	13.9	1,307.7	0.1	0.2	1	1	0
03/12/2015 04:00	0.1	13.8	1,425.3	0.1	0.3	1	1	1
03/12/2015 05:00	0.5	13.2	1,945.8	0.2	1.7	1	1	1
03/12/2015 06:00	0.9	12.7	2,033.2	0.4	2.9	1	1	1
03/12/2015 07:00	0.8	12.7	2,032.8	0.5	2.6	1	1	1
03/12/2015 08:00	0.6	12.9	1,980.2	0.5	2.0	1	1	1
03/12/2015 09:00	0.4	13.1	1,945.5	0.4	1.3	1	1	1
03/12/2015 10:00	0.4	13.2	1,923.9	0.3	1.3	1	1	1
03/12/2015 11:00	0.0	13.9	1,352.3	0.2	0.0	1	1	0
03/12/2015 12:00	0.0	14.0	1,293.5	0.1	0.0	1	1	0
03/12/2015 13:00	0.0	14.0	1,293.0	0.0	0.0	1	1	0
03/12/2015 14:00	0.0	14.0	1,292.6	0.0	0.0	1	1	0
03/12/2015 15:00	0.0	14.0	1,291.0	0.0	0.0	1	1	0
03/12/2015 16:00	0.1	13.7	1,538.0	0.0	0.3	1	1	1
03/12/2015 17:00	0.9	12.6	2,023.8	0.2	2.9	1	1	1
03/12/2015 18:00	0.8	12.6	2,041.0	0.4	2.6	1	1	1
03/12/2015 19:00	0.8	12.6	2,043.0	0.6	2.6	1	1	1
03/12/2015 20:00	0.8	12.6	2,041.8	0.6	2.6	1	1	1
03/12/2015 21:00	0.8	12.6	2,036.5	0.6	2.6	1	1	1
03/12/2015 22:00	0.4	13.2	1,782.1	0.5	1.2	1	1	1
03/12/2015 23:00	0.0	14.0	1,381.1	0.3	0.0	1	1	0
Average/Sum#:	0.4	13.4	1,663.2	0.3	27.3 #	24 #	24 #	14 #
Minimum:	0.0	12.6	1,291.0	0.0	0.0	1	1	0
Maximum:	0.9	14.0	2,043.0	0.6	2.9	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/13/2015 00:00	0.0	14.0	1,382.0	0.1	0.0	1	1	0
03/13/2015 01:00	0.0	13.9	1,415.4	0.0	0.0	1	1	0
03/13/2015 02:00	0.0	13.9	1,538.8	0.0	0.0	1	1	0
03/13/2015 03:00	0.0	13.9	1,411.2	0.0	0.0	1	1	0
03/13/2015 04:00	0.2	13.7	1,555.4	0.1	0.6	1	1	1
03/13/2015 05:00	0.5	13.0	1,976.0	0.2	1.7	1	1	1
03/13/2015 06:00	0.6	12.9	2,001.0	0.3	2.0	1	1	1
03/13/2015 07:00	0.2	13.3	1,913.7	0.3	0.7	1	1	1
03/13/2015 08:00	0.2	13.2	1,916.6	0.3	0.7	1	1	1
03/13/2015 09:00	0.3	13.2	1,918.8	0.2	1.0	1	1	1
03/13/2015 10:00	0.1	13.6	1,625.9	0.2	0.3	1	1	1
03/13/2015 11:00	0.0	14.0	1,292.1	0.1	0.0	1	1	0
03/13/2015 12:00	0.0	13.9	1,396.7	0.0	0.0	1	1	1
03/13/2015 13:00	0.7	12.8	1,972.5	0.2	2.3	1	1	1
03/13/2015 14:00	0.6	12.8	1,979.2	0.3	1.9	1	1	1
03/13/2015 15:00	0.7	12.5	2,028.3	0.5	2.2	1	1	1
03/13/2015 16:00	0.7	12.4	2,040.0	0.5	2.2	1	1	1
03/13/2015 17:00	0.7	12.4	2,043.3	0.5	2.2	1	1	1
03/13/2015 18:00	0.7	12.5	2,042.4	0.5	2.2	1	1	1
03/13/2015 19:00	0.7	12.5	2,032.0	0.5	2.2	1	1	1
03/13/2015 20:00	0.7	12.5	2,035.5	0.5	2.2	1	1	1
03/13/2015 21:00	0.6	12.6	2,008.1	0.5	1.9	1	1	1
03/13/2015 22:00	0.7	12.6	2,019.7	0.5	2.2	1	1	1
03/13/2015 23:00	0.7	12.5	2,028.4	0.5	2.2	1	1	1
Average/Sum#:	0.4	13.1	1,815.5	0.3	30.7 #	24 #	24 #	19 #
Minimum:	0.0	12.4	1,292.1	0.0	0.0	1	1	0
Maximum:	0.7	14.0	2,043.3	0.5	2.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/14/2015 00:00	0.6	12.8	1,980.0	0.5	1.9	1	1	1
03/14/2015 01:00	0.6	12.8	1,981.4	0.4	1.9	1	1	1
03/14/2015 02:00	0.6	12.9	1,966.4	0.4	1.9	1	1	1
03/14/2015 03:00	0.4	13.1	1,924.9	0.4	1.3	1	1	1
03/14/2015 04:00	0.3	13.1	1,919.6	0.3	1.0	1	1	1
03/14/2015 05:00	0.3	13.1	1,924.7	0.2	1.0	1	1	1
03/14/2015 06:00	0.8	12.6	2,028.5	0.3	2.6	1	1	1
03/14/2015 07:00	0.7	12.7	1,998.1	0.4	2.3	1	1	1
03/14/2015 08:00	0.5	12.9	1,954.2	0.5	1.6	1	1	1
03/14/2015 09:00	0.5	13.0	1,950.0	0.4	1.6	1	1	1
03/14/2015 10:00	0.5	12.9	1,952.3	0.4	1.6	1	1	1
03/14/2015 11:00	0.5	12.9	1,971.4	0.4	1.6	1	1	1
03/14/2015 12:00	0.8	12.5	2,049.8	0.5	2.6	1	1	1
03/14/2015 13:00	0.8	12.4	2,052.3	0.5	2.6	1	1	1
03/14/2015 14:00	0.7	12.4	2,048.6	0.6	2.2	1	1	1
03/14/2015 15:00	0.7	12.5	2,013.9	0.5	2.2	1	1	1
03/14/2015 16:00	0.7	12.3	2,049.9	0.5	2.2	1	1	1
03/14/2015 17:00	0.7	12.4	2,049.7	0.5	2.2	1	1	1
03/14/2015 18:00	0.7	12.4	2,046.9	0.5	2.2	1	1	1
03/14/2015 19:00	0.7	12.4	2,045.6	0.5	2.2	1	1	1
03/14/2015 20:00	0.7	12.4	2,044.4	0.5	2.2	1	1	1
03/14/2015 21:00	0.7	12.4	2,044.5	0.5	2.2	1	1	1
03/14/2015 22:00	0.7	12.5	2,042.1	0.5	2.2	1	1	1
03/14/2015 23:00	0.7	12.6	2,006.8	0.5	2.2	1	1	1
Average/Sum#:	0.6	12.7	2,001.9	0.4	47.5 #	24 #	24 #	24 #
Minimum:	0.3	12.3	1,919.6	0.2	1.0	1	1	1
Maximum:	0.8	13.1	2,052.3	0.6	2.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/15/2015 00:00	0.5	12.9	1,950.1	0.5	1.6	1	1	1
03/15/2015 01:00	0.6	12.7	1,990.5	0.4	1.9	1	1	1
03/15/2015 02:00	0.3	13.2	1,813.2	0.3	0.9	1	1	1
03/15/2015 03:00	0.0	13.8	1,769.1	0.2	0.0	1	1	0
03/15/2015 04:00	0.0	13.7	1,782.6	0.1	0.0	1	1	0
03/15/2015 05:00	0.0	13.8	1,753.2	0.0	0.0	1	1	0
03/15/2015 06:00	0.0	13.7	1,784.0	0.0	0.0	1	1	0
03/15/2015 07:00	0.0	13.7	1,556.0	0.0	0.0	1	1	0
03/15/2015 08:00	0.0	13.9	1,296.8	0.0	0.0	1	1	0
03/15/2015 09:00	0.0	14.0	1,297.7	0.0	0.0	1	1	0
03/15/2015 10:00	0.0	14.0	1,299.0	0.0	0.0	1	1	0
03/15/2015 11:00	0.0	13.9	1,570.7	0.0	0.0	1	1	0
03/15/2015 12:00	0.0	13.9	1,761.6	0.0	0.0	1	1	0
03/15/2015 13:00	0.6	13.0	1,920.1	0.1	1.9	1	1	1
03/15/2015 14:00	0.8	12.6	2,046.5	0.3	2.6	1	1	1
03/15/2015 15:00	0.7	12.6	2,031.2	0.5	2.3	1	1	1
03/15/2015 16:00	0.7	12.6	2,036.6	0.5	2.3	1	1	1
03/15/2015 17:00	0.7	12.6	2,034.2	0.5	2.3	1	1	1
03/15/2015 18:00	0.7	12.6	2,033.7	0.5	2.3	1	1	1
03/15/2015 19:00	0.7	12.6	2,035.7	0.5	2.3	1	1	1
03/15/2015 20:00	0.7	12.6	2,034.5	0.5	2.3	1	1	1
03/15/2015 21:00	0.7	12.6	2,027.0	0.5	2.3	1	1	1
03/15/2015 22:00	0.4	13.1	1,846.4	0.4	1.3	1	1	1
03/15/2015 23:00	0.0	13.9	1,294.0	0.3	0.0	1	1	0
Average/Sum#:	0.3	13.3	1,790.2	0.3	26.3 #	24 #	24 #	13 #
Minimum:	0.0	12.6	1,294.0	0.0	0.0	1	1	0
Maximum:	0.8	14.0	2,046.5	0.5	2.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/16/2015 00:00	0.0	14.0	1,291.5	0.1	0.0	1	1	0
03/16/2015 01:00	0.0	13.9	1,288.4	0.0	0.0	1	1	0
03/16/2015 02:00	0.0	13.9	1,291.1	0.0	0.0	1	1	0
03/16/2015 03:00	0.0	14.0	1,294.6	0.0	0.0	1	1	0
03/16/2015 04:00	0.2	13.6	1,552.3	0.1	0.6	1	1	1
03/16/2015 05:00	0.6	12.8	1,993.5	0.2	2.0	1	1	1
03/16/2015 06:00	0.8	12.6	2,034.4	0.4	2.6	1	1	1
03/16/2015 07:00	0.7	12.7	1,997.9	0.5	2.3	1	1	1
03/16/2015 08:00	0.7	12.6	2,033.2	0.5	2.3	1	1	1
03/16/2015 09:00	0.7	12.7	2,030.7	0.5	2.3	1	1	1
03/16/2015 10:00	0.7	12.7	2,016.3	0.5	2.3	1	1	1
03/16/2015 11:00	0.7	12.6	2,033.2	0.5	2.3	1	1	1
03/16/2015 12:00	0.7	12.6	2,031.5	0.5	2.3	1	1	1
03/16/2015 13:00	0.7	12.6	2,033.0	0.5	2.3	1	1	1
03/16/2015 14:00	0.7	12.6	2,032.2	0.5	2.3	1	1	1
03/16/2015 15:00	0.7	12.6	2,022.6	0.5	2.3	1	1	1
03/16/2015 16:00	0.6	12.8	1,978.8	0.5	1.9	1	1	1
03/16/2015 17:00	0.5	12.9	1,950.4	0.4	1.6	1	1	1
03/16/2015 18:00	0.7	12.7	2,010.4	0.4	2.3	1	1	1
03/16/2015 19:00	0.7	12.6	2,047.3	0.5	2.3	1	1	1
03/16/2015 20:00	0.5	12.8	2,011.6	0.5	1.6	1	1	1
03/16/2015 21:00	0.4	13.0	1,977.0	0.4	1.3	1	1	1
03/16/2015 22:00	0.0	13.8	1,459.4	0.2	0.0	1	1	1
03/16/2015 23:00	0.0	13.9	1,290.7	0.1	0.0	1	1	0
Average/Sum#:	0.5	13.0	1,820.9	0.3	36.9 #	24 #	24 #	19 #
Minimum:	0.0	12.6	1,288.4	0.0	0.0	1	1	0
Maximum:	0.8	14.0	2,047.3	0.5	2.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/17/2015 00:00	0.0	13.9	1,289.0	0.0	0.0	1	1	0
03/17/2015 01:00	0.0	13.9	1,289.8	0.0	0.0	1	1	0
03/17/2015 02:00	0.0	13.9	1,289.7	0.0	0.0	1	1	0
03/17/2015 03:00	0.0	13.9	1,290.5	0.0	0.0	1	1	0
03/17/2015 04:00	0.1	13.9	1,290.1	0.0	0.2	1	1	0
03/17/2015 05:00	0.1	13.9	1,290.3	0.1	0.2	1	1	0
03/17/2015 06:00	0.1	13.9	1,290.3	0.1	0.2	1	1	0
03/17/2015 07:00	0.1	13.9	1,289.1	0.1	0.2	1	1	0
03/17/2015 08:00	0.1	13.9	1,290.7	0.1	0.2	1	1	0
03/17/2015 09:00	0.1	13.9	1,292.8	0.1	0.2	1	1	0
03/17/2015 10:00	0.0	0.0	1,295.3	0.0	0.0	1	1	0
03/17/2015 11:00	0.0	15.0	1,294.8	0.0	0.0	1	1	0
03/17/2015 12:00	0.0	16.6	1,296.9	0.0	0.0	1	1	0
03/17/2015 13:00	0.0	17.4	1,298.4	0.0	0.0	1	1	0
03/17/2015 14:00	0.0	17.5	1,299.0	0.0	0.0	1	1	0
03/17/2015 15:00	0.0	17.6	1,297.7	0.0	0.0	1	1	0
03/17/2015 16:00	0.0	18.0	1,295.9	0.0	0.0	1	1	0
03/17/2015 17:00	0.0	18.2	1,296.3	0.0	0.0	1	1	0
03/17/2015 18:00	0.0	18.2	1,295.9	0.0	0.0	1	1	0
03/17/2015 19:00	0.0	18.3	1,294.0	0.0	0.0	1	1	0
03/17/2015 20:00	0.0	18.3	1,292.2	0.0	0.0	1	1	0
03/17/2015 21:00	0.0	18.3	1,292.2	0.0	0.0	1	1	0
03/17/2015 22:00	0.0	15.3	1,290.6	0.0	0.0	1	1	0
03/17/2015 23:00	0.0	14.3	1,286.6	0.0	0.0	1	1	0
Average/Sum#:	0.0	15.7	1,292.8	0.0	1.2 #	24 #	24 #	0 #
Minimum:	0.0	13.9	1,286.6	0.0	0.0	1	1	0
Maximum:	0.1	18.3	1,299.0	0.1	0.2	1	1	0
%SI	4.2	4.2	0.0	20.8	4.2	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/18/2015 00:00	0.0	14.2	1,285.9	0.0	0.0	1	1	0
03/18/2015 01:00	0.0	14.2	1,290.6	0.0	0.0	1	1	0
03/18/2015 02:00	0.0	14.2	1,301.4	0.0	0.0	1	1	0
03/18/2015 03:00	0.0	14.2	1,303.6	0.0	0.0	1	1	0
03/18/2015 04:00	0.0	14.2	1,304.1	0.0	0.0	1	1	0
03/18/2015 05:00	0.0	14.2	1,302.8	0.0	0.0	1	1	0
03/18/2015 06:00	0.0	14.2	1,302.1	0.0	0.0	1	1	0
03/18/2015 07:00	0.0	14.2	1,300.7	0.0	0.0	1	1	0
03/18/2015 08:00	0.0	14.2	1,300.5	0.0	0.0	1	1	0
03/18/2015 09:00	0.0	14.2	1,300.4	0.0	0.0	1	0	0
03/18/2015 10:00	0.0	14.2	1,301.2	0.0	0.0	1	0	0
03/18/2015 11:00	0.0	14.2	1,299.5	0.0	0.0	1	0	0
03/18/2015 12:00	0.0	14.2	1,296.2	0.0	0.0	1	1	0
03/18/2015 13:00	0.0	14.2	1,296.0	0.0	0.0	1	1	0
03/18/2015 14:00	0.0	14.2	1,312.2	0.0	0.0	1	1	0
03/18/2015 15:00	0.0	14.1	1,652.2	0.0	0.0	1	1	0
03/18/2015 16:00	0.0	14.1	1,677.7	0.0	0.0	1	1	0
03/18/2015 17:00	0.0	14.2	1,282.0	0.0	0.0	1	1	0
03/18/2015 18:00	0.0	14.2	1,283.9	0.0	0.0	1	1	0
03/18/2015 19:00	0.0	14.2	1,282.4	0.0	0.0	1	1	0
03/18/2015 20:00	0.0	14.2	1,286.6	0.0	0.0	1	1	0
03/18/2015 21:00	0.0	14.2	1,286.6	0.0	0.0	1	1	0
03/18/2015 22:00	0.0	14.1	1,283.2	0.0	0.0	1	1	0
03/18/2015 23:00	0.0	14.1	1,282.7	0.0	0.0	1	1	0
Average/Sum#:	0.0	14.2	1,325.6	0.0	0.0 #	24 #	21 #	0 #
Minimum:	0.0	14.1	1,282.0	0.0	0.0	1	0	0
Maximum:	0.0	14.2	1,677.7	0.0	0.0	1	1	0
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/19/2015 00:00	0.0	14.1	1,282.9	0.0	0.0	1	1	0
03/19/2015 01:00	0.0	14.1	1,281.1	0.0	0.0	1	1	0
03/19/2015 02:00	0.0	14.1	1,281.4	0.0	0.0	1	1	0
03/19/2015 03:00	0.0	14.1	1,283.3	0.0	0.0	1	1	0
03/19/2015 04:00	0.0	14.1	1,285.5	0.0	0.0	1	1	0
03/19/2015 05:00	0.2	14.0	1,292.6	0.1	0.5	1	1	0
03/19/2015 06:00	0.2	13.9	1,409.9	0.1	0.5	1	1	1
03/19/2015 07:00	1.0	12.9	1,995.0	0.4	3.3	1	1	1
03/19/2015 08:00	0.0	0.0	1,953.0	0.0	0.0	1	1	1
03/19/2015 09:00	0.0	0.0	1,942.5	0.0	0.0	1	1	1
03/19/2015 10:00	0.0	0.0	1,947.4	0.0	0.0	1	1	1
03/19/2015 11:00	0.0	0.0	1,976.3	0.0	0.0	1	1	1
03/19/2015 12:00	0.9	12.6	2,039.6	0.0	2.9	1	1	1
03/19/2015 13:00	0.7	12.9	1,981.1	0.0	2.3	1	1	1
03/19/2015 14:00	0.2	14.0	1,564.1	0.4	0.6	1	1	1
03/19/2015 15:00	0.1	14.0	1,320.8	0.3	0.3	1	1	0
03/19/2015 16:00	0.2	13.9	1,390.8	0.2	0.5	1	1	1
03/19/2015 17:00	0.8	13.0	1,930.3	0.3	2.6	1	1	1
03/19/2015 18:00	0.8	12.8	1,972.5	0.5	2.6	1	1	1
03/19/2015 19:00	1.0	12.5	2,038.9	0.6	3.2	1	1	1
03/19/2015 20:00	0.6	13.0	1,929.7	0.6	1.9	1	1	1
03/19/2015 21:00	0.5	13.3	1,743.0	0.5	1.5	1	1	1
03/19/2015 22:00	0.1	13.9	1,465.4	0.3	0.3	1	1	0
03/19/2015 23:00	0.2	13.9	1,307.0	0.2	0.5	1	1	0
Average/Sum#:	0.4	13.6	1,650.6	0.3	23.5 #	24 #	24 #	15 #
Minimum:	0.0	12.5	1,281.1	0.0	0.0	1	1	0
Maximum:	1.0	14.1	2,039.6	0.6	3.3	1	1	1
%SI	16.7	16.7	0.0	25.0	16.7	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/20/2015 00:00	0.2	13.9	1,451.1	0.2	0.5	1	1	0
03/20/2015 01:00	0.2	13.9	1,299.2	0.2	0.5	1	1	0
03/20/2015 02:00	0.2	13.8	1,675.1	0.2	0.6	1	1	0
03/20/2015 03:00	0.3	13.9	1,330.0	0.2	0.8	1	1	0
03/20/2015 04:00	0.6	13.4	1,687.7	0.3	1.8	1	1	1
03/20/2015 05:00	0.9	12.9	2,009.9	0.5	3.0	1	1	1
03/20/2015 06:00	1.1	12.7	2,034.0	0.7	3.6	1	1	1
03/20/2015 07:00	1.0	13.0	1,974.4	0.7	3.3	1	1	1
03/20/2015 08:00	0.8	13.0	1,929.4	0.7	2.6	1	1	1
03/20/2015 09:00	0.1	13.7	1,831.5	0.5	0.3	1	1	0
03/20/2015 10:00	0.3	13.7	1,828.5	0.3	1.0	1	1	0
03/20/2015 11:00	0.4	13.5	1,834.0	0.2	1.3	1	1	1
03/20/2015 12:00	0.9	12.9	1,988.6	0.4	3.0	1	1	1
03/20/2015 13:00	0.9	12.8	2,010.0	0.6	2.9	1	1	1
03/20/2015 14:00	0.9	12.9	1,978.9	0.7	2.9	1	1	1
03/20/2015 15:00	0.9	12.9	1,975.9	0.7	2.9	1	1	1
03/20/2015 16:00	0.7	13.0	1,945.4	0.6	2.3	1	1	1
03/20/2015 17:00	0.7	13.0	1,944.2	0.6	2.3	1	1	1
03/20/2015 18:00	0.8	13.0	1,950.5	0.5	2.6	1	1	1
03/20/2015 19:00	0.7	13.0	1,944.3	0.5	2.3	1	1	1
03/20/2015 20:00	0.7	13.0	1,945.8	0.5	2.3	1	1	1
03/20/2015 21:00	0.7	13.1	1,953.4	0.5	2.3	1	1	1
03/20/2015 22:00	0.4	13.5	1,733.9	0.4	1.2	1	1	1
03/20/2015 23:00	0.2	13.9	1,290.6	0.3	0.5	1	1	0
Average/Sum#:	0.6	13.3	1,814.4	0.5	46.8 #	24 #	24 #	17 #
Minimum:	0.1	12.7	1,290.6	0.2	0.3	1	1	0
Maximum:	1.1	13.9	2,034.0	0.7	3.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/21/2015 00:00	0.2	13.9	1,286.0	0.2	0.5	1	1	0
03/21/2015 01:00	0.2	13.9	1,530.0	0.2	0.6	1	1	0
03/21/2015 02:00	0.3	13.9	1,338.3	0.2	0.8	1	1	0
03/21/2015 03:00	0.2	13.8	1,566.9	0.2	0.6	1	1	0
03/21/2015 04:00	0.2	13.9	1,584.6	0.2	0.6	1	1	0
03/21/2015 05:00	0.5	13.7	1,499.0	0.3	1.4	1	1	1
03/21/2015 06:00	0.9	13.0	1,992.7	0.4	3.0	1	1	1
03/21/2015 07:00	0.6	13.3	1,801.1	0.5	1.9	1	1	1
03/21/2015 08:00	0.3	13.9	1,345.0	0.5	0.8	1	1	0
03/21/2015 09:00	0.3	13.9	1,307.2	0.4	0.7	1	1	0
03/21/2015 10:00	0.2	13.9	1,311.1	0.3	0.5	1	1	0
03/21/2015 11:00	0.2	13.9	1,312.9	0.2	0.5	1	1	0
03/21/2015 12:00	0.2	14.0	1,340.6	0.2	0.5	1	1	0
03/21/2015 13:00	0.2	14.0	1,310.0	0.2	0.5	1	1	0
03/21/2015 14:00	0.2	14.0	1,403.2	0.2	0.5	1	1	0
03/21/2015 15:00	0.2	13.9	1,489.2	0.2	0.6	1	1	0
03/21/2015 16:00	0.1	13.9	1,641.6	0.2	0.3	1	1	0
03/21/2015 17:00	0.7	13.2	1,806.3	0.3	2.2	1	1	1
03/21/2015 18:00	1.0	12.7	1,989.9	0.4	3.2	1	1	1
03/21/2015 19:00	0.9	12.7	1,996.9	0.6	2.9	1	1	1
03/21/2015 20:00	1.0	12.6	2,016.1	0.7	3.2	1	1	1
03/21/2015 21:00	0.9	12.8	1,996.3	0.7	2.9	1	1	1
03/21/2015 22:00	0.4	13.4	1,787.5	0.6	1.3	1	1	1
03/21/2015 23:00	0.1	13.8	1,758.3	0.4	0.3	1	1	0
Average/Sum#:	0.4	13.6	1,600.4	0.3	30.3 #	24 #	24 #	9 #
Minimum:	0.1	12.6	1,286.0	0.2	0.3	1	1	0
Maximum:	1.0	14.0	2,016.1	0.7	3.2	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/22/2015 00:00	0.1	13.7	1,798.3	0.2	0.3	1	1	0
03/22/2015 01:00	0.1	13.9	1,610.8	0.1	0.3	1	1	0
03/22/2015 02:00	0.1	13.8	1,654.1	0.1	0.3	1	1	0
03/22/2015 03:00	0.1	13.9	1,765.1	0.1	0.3	1	1	0
03/22/2015 04:00	0.2	13.9	1,523.6	0.1	0.6	1	1	0
03/22/2015 05:00	0.2	13.8	1,592.0	0.2	0.6	1	1	0
03/22/2015 06:00	0.2	13.8	1,634.2	0.2	0.6	1	1	0
03/22/2015 07:00	0.4	13.7	1,672.3	0.2	1.2	1	1	1
03/22/2015 08:00	1.1	12.6	2,040.5	0.4	3.6	1	1	1
03/22/2015 09:00	1.0	12.6	2,017.3	0.6	3.2	1	1	1
03/22/2015 10:00	0.8	12.9	1,952.7	0.7	2.6	1	1	1
03/22/2015 11:00	0.9	12.9	1,960.7	0.7	2.9	1	1	1
03/22/2015 12:00	0.8	12.9	1,973.2	0.6	2.6	1	1	1
03/22/2015 13:00	0.4	13.5	1,697.4	0.5	1.2	1	1	1
03/22/2015 14:00	0.1	13.9	1,609.8	0.3	0.3	1	1	0
03/22/2015 15:00	0.1	13.9	1,614.0	0.2	0.3	1	1	0
03/22/2015 16:00	0.1	13.9	1,567.0	0.1	0.3	1	1	0
03/22/2015 17:00	0.6	13.4	1,713.6	0.2	1.8	1	1	1
03/22/2015 18:00	0.9	12.8	1,992.7	0.4	2.9	1	1	1
03/22/2015 19:00	0.8	12.9	1,977.8	0.6	2.6	1	1	1
03/22/2015 20:00	0.7	13.0	1,960.9	0.6	2.3	1	1	1
03/22/2015 21:00	0.3	13.7	1,470.8	0.4	0.8	1	1	1
03/22/2015 22:00	0.3	13.9	1,304.5	0.3	0.7	1	1	0
03/22/2015 23:00	3.9	14.4	1,119.6	0.0	7.7	1	0	0
Average/Sum#:	0.6	13.5	1,717.6	0.3	40.0 #	24 #	23 #	12 #
Minimum:	0.1	12.6	1,119.6	0.1	0.3	1	0	0
Maximum:	3.9	14.4	2,040.5	0.7	7.7	1	1	1
%SI	0.0	0.0	0.0	4.2	0.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/23/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/24/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/25/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/26/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 03:00	85.0	17.5	470.3	0.0	85.4	1	0	0
03/26/2015 04:00	52.1	16.7	594.4	0.0	97.4	1	0	0
03/26/2015 05:00	36.9	16.0	758.2	0.0	75.4	1	0	0
03/26/2015 06:00	0.1	13.9	1,375.5	0.0	0.3	1	0	0
03/26/2015 07:00	0.1	13.9	1,375.7	0.0	0.3	1	0	0
03/26/2015 08:00	0.1	13.9	1,381.9	0.1	0.3	1	0	0
03/26/2015 09:00	0.1	14.0	1,381.1	0.1	0.3	1	0	0
03/26/2015 10:00	0.1	14.0	1,383.7	0.1	0.3	1	0	0
03/26/2015 11:00	0.1	14.0	1,382.6	0.1	0.3	1	0	0
03/26/2015 12:00	0.1	14.0	1,385.0	0.1	0.3	1	0	0
03/26/2015 13:00	0.1	13.8	1,658.7	0.1	0.3	1	0	0
03/26/2015 14:00	0.1	13.9	1,396.3	0.1	0.3	1	0	0
03/26/2015 15:00	0.1	14.0	1,403.5	0.1	0.3	1	0	0
03/26/2015 16:00	0.1	13.8	1,679.7	0.1	0.3	1	0	0
03/26/2015 17:00	0.1	13.7	1,772.2	0.1	0.3	1	0	0
03/26/2015 18:00	0.1	13.7	1,778.2	0.1	0.3	1	0	0
03/26/2015 19:00	0.1	13.7	1,781.5	0.1	0.3	1	0	0
03/26/2015 20:00	0.1	13.7	1,785.4	0.1	0.3	1	0	0
03/26/2015 21:00	0.1	13.9	1,361.7	0.1	0.3	1	0	0
03/26/2015 22:00	19.0	16.6	334.2	0.0	3.3	1	0	0
03/26/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	9.7	14.4	1,322.0	0.1	266.3 #	20 #	0 #	0 #
Minimum:	0.1	13.7	334.2	0.1	0.3	0	0	0
Maximum:	85.0	17.5	1,785.4	0.1	97.4	1	0	0
%SI	16.7	16.7	16.7	41.7	16.7	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/27/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 04:00	33.0	19.5	170.5	0.0	6.9	1	0	0
03/27/2015 05:00	14.9	15.8	806.7	0.0	31.1	1	0	0
03/27/2015 06:00	0.2	13.9	1,385.0	0.0	0.5	1	0	0
03/27/2015 07:00	0.2	13.9	1,379.3	0.0	0.5	1	0	0
03/27/2015 08:00	0.1	14.0	1,376.2	0.2	0.3	1	0	0
03/27/2015 09:00	0.1	14.0	1,376.0	0.1	0.3	1	0	0
03/27/2015 10:00	0.1	14.0	1,377.8	0.1	0.3	1	0	0
03/27/2015 11:00	0.1	14.0	1,383.3	0.1	0.3	1	0	0
03/27/2015 12:00	0.1	14.0	1,383.1	0.1	0.3	1	0	0
03/27/2015 13:00	0.1	14.0	1,380.2	0.1	0.3	1	0	0
03/27/2015 14:00	0.1	14.0	1,379.3	0.1	0.3	1	0	0
03/27/2015 15:00	0.1	14.0	1,378.5	0.1	0.3	1	0	0
03/27/2015 16:00	0.1	14.0	1,381.3	0.1	0.3	1	0	0
03/27/2015 17:00	0.1	13.9	1,566.7	0.1	0.3	1	0	0
03/27/2015 18:00	0.1	14.0	1,393.8	0.1	0.3	1	0	0
03/27/2015 19:00	0.1	14.0	1,373.3	0.1	0.3	1	0	0
03/27/2015 20:00	4.3	14.6	1,113.2	0.0	6.7	1	0	0
03/27/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	3.2	14.4	1,270.8	0.1	49.3 #	17 #	0 #	0 #
Minimum:	0.1	13.9	170.5	0.1	0.3	0	0	0
Maximum:	33.0	19.5	1,566.7	0.2	31.1	1	0	0
%SI	29.2	29.2	29.2	50.0	29.2	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/28/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/29/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/30/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 03:00	77.5	17.5	476.6	0.0	78.9	1	0	0
03/30/2015 04:00	31.7	15.7	715.5	0.0	57.6	1	0	0
03/30/2015 05:00	12.3	14.7	1,086.2	0.0	28.5	1	0	0
03/30/2015 06:00	0.0	14.0	1,380.6	0.0	0.0	1	0	0
03/30/2015 07:00	0.0	14.0	1,386.9	0.0	0.0	1	0	0
03/30/2015 08:00	0.0	14.0	1,384.8	0.0	0.0	1	0	0
03/30/2015 09:00	0.0	14.0	1,386.0	0.0	0.0	1	0	0
03/30/2015 10:00	0.0	14.0	1,378.1	0.0	0.0	1	0	0
03/30/2015 11:00	0.0	14.0	1,376.0	0.0	0.0	1	0	0
03/30/2015 12:00	0.0	13.9	1,510.8	0.0	0.0	1	0	0
03/30/2015 13:00	0.0	14.0	1,531.3	0.0	0.0	1	0	0
03/30/2015 14:00	0.0	13.9	1,513.1	0.0	0.0	1	0	0
03/30/2015 15:00	0.0	14.0	1,351.2	0.0	0.0	1	0	0
03/30/2015 16:00	0.0	14.0	1,334.9	0.0	0.0	1	0	0
03/30/2015 17:00	0.0	13.9	1,473.4	0.0	0.0	1	0	0
03/30/2015 18:00	0.0	13.8	1,692.8	0.0	0.0	1	0	0
03/30/2015 19:00	0.0	13.9	1,609.6	0.0	0.0	1	0	0
03/30/2015 20:00	5.9	14.9	974.0	0.0	5.7	1	0	0
03/30/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	7.1	14.3	1,309.0	0.0	170.7 #	18 #	0 #	0 #
Minimum:	0.0	13.8	476.6	0.0	0.0	0	0	0
Maximum:	77.5	17.5	1,692.8	0.0	78.9	1	0	0
%SI	25.0	25.0	25.0	50.0	25.0	0	0	0

Daily Summary Report

CT1 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/31/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 04:00	25.0	17.2	519.8	0.0	29.2	1	0	0
03/31/2015 05:00	6.4	14.2	1,246.4	0.0	15.7	1	0	0
03/31/2015 06:00	0.0	13.9	1,379.2	0.0	0.0	1	0	0
03/31/2015 07:00	0.0	13.9	1,382.0	0.0	0.0	1	0	0
03/31/2015 08:00	0.0	13.9	1,384.5	0.0	0.0	1	0	0
03/31/2015 09:00	0.0	14.0	1,381.1	0.0	0.0	1	0	0
03/31/2015 10:00	0.0	14.0	1,377.2	0.0	0.0	1	0	0
03/31/2015 11:00	0.0	14.0	1,372.5	0.0	0.0	1	0	0
03/31/2015 12:00	0.0	14.0	1,377.5	0.0	0.0	1	0	0
03/31/2015 13:00	0.0	14.0	1,375.2	0.0	0.0	1	0	0
03/31/2015 14:00	0.0	14.0	1,383.2	0.0	0.0	1	0	0
03/31/2015 15:00	0.0	14.0	1,379.8	0.0	0.0	1	0	0
03/31/2015 16:00	0.0	14.0	1,522.7	0.0	0.0	1	0	0
03/31/2015 17:00	0.0	14.0	1,508.6	0.0	0.0	1	0	0
03/31/2015 18:00	0.0	14.0	1,595.8	0.0	0.0	1	0	0
03/31/2015 19:00	0.0	14.0	1,771.1	0.0	0.0	1	0	0
03/31/2015 20:00	0.0	13.9	1,619.3	0.0	0.0	1	0	0
03/31/2015 21:00	5.7	14.8	1,048.4	0.0	5.8	1	0	0
03/31/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	2.1	14.2	1,368.0	0.0	50.7 #	18 #	0 #	0 #
Minimum:	0.0	13.9	519.8	0.0	0.0	0	0	0
Maximum:	25.0	17.2	1,771.1	0.0	29.2	1	0	0
%SI	25.0	25.0	25.0	45.8	25.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/01/2015 00:00	0.4	12.0	2,299.0	0.4	1.4	1	1	1
01/01/2015 01:00	0.3	11.8	2,341.5	0.3	1.0	1	1	1
01/01/2015 02:00	0.4	11.8	2,341.2	0.3	1.4	1	1	1
01/01/2015 03:00	0.3	11.8	2,341.1	0.2	1.0	1	1	1
01/01/2015 04:00	0.4	12.0	2,297.3	0.3	1.4	1	1	1
01/01/2015 05:00	0.4	12.1	2,280.3	0.3	1.4	1	1	1
01/01/2015 06:00	0.4	11.8	2,365.0	0.3	1.4	1	1	1
01/01/2015 07:00	0.4	11.9	2,342.0	0.3	1.4	1	1	1
01/01/2015 08:00	0.4	13.1	1,992.7	0.3	1.3	1	1	1
01/01/2015 09:00	0.3	13.4	1,878.9	0.3	1.0	1	1	1
01/01/2015 10:00	0.2	13.7	1,458.9	0.2	0.5	1	1	1
01/01/2015 11:00	0.2	13.9	1,274.6	0.2	0.5	1	1	0
01/01/2015 12:00	0.2	13.9	1,277.7	0.2	0.5	1	1	0
01/01/2015 13:00	0.2	13.9	1,274.3	0.2	0.5	1	1	0
01/01/2015 14:00	0.2	13.9	1,272.3	0.2	0.5	1	1	0
01/01/2015 15:00	0.4	13.6	1,619.1	0.2	1.2	1	1	1
01/01/2015 16:00	0.5	13.2	1,951.4	0.3	1.7	1	1	1
01/01/2015 17:00	0.5	13.1	2,025.2	0.4	1.7	1	1	1
01/01/2015 18:00	0.5	12.6	2,152.7	0.4	1.7	1	1	1
01/01/2015 19:00	0.4	11.7	2,355.1	0.4	1.4	1	1	1
01/01/2015 20:00	0.3	11.7	2,362.2	0.3	1.0	1	1	1
01/01/2015 21:00	0.4	11.8	2,343.4	0.3	1.4	1	1	1
01/01/2015 22:00	0.4	11.8	2,338.5	0.3	1.4	1	1	1
01/01/2015 23:00	0.4	12.9	2,078.7	0.3	1.4	1	1	1
Average/Sum#:	0.4	12.6	2,011.0	0.3	28.1 #	24 #	24 #	20 #
Minimum:	0.2	11.7	1,272.3	0.2	0.5	1	1	0
Maximum:	0.5	13.9	2,365.0	0.4	1.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/02/2015 00:00	0.5	13.1	2,036.3	0.3	1.7	1	1	1
01/02/2015 01:00	0.5	12.7	2,128.7	0.4	1.7	1	1	1
01/02/2015 02:00	0.4	13.2	1,915.1	0.4	1.3	1	1	1
01/02/2015 03:00	0.5	13.0	2,084.5	0.4	1.7	1	1	1
01/02/2015 04:00	0.5	13.2	2,031.8	0.4	1.7	1	1	1
01/02/2015 05:00	0.5	13.0	2,067.6	0.4	1.7	1	1	1
01/02/2015 06:00	0.5	13.2	2,012.4	0.4	1.7	1	1	1
01/02/2015 07:00	0.5	13.2	2,005.4	0.4	1.7	1	1	1
01/02/2015 08:00	0.5	13.2	1,949.1	0.4	1.7	1	1	1
01/02/2015 09:00	0.4	13.2	1,885.3	0.4	1.3	1	1	1
01/02/2015 10:00	0.3	13.7	1,466.9	0.3	0.8	1	1	1
01/02/2015 11:00	0.2	13.8	1,312.5	0.2	0.5	1	1	0
01/02/2015 12:00	0.2	13.8	1,309.5	0.2	0.5	1	1	0
01/02/2015 13:00	0.2	13.8	1,314.1	0.2	0.5	1	1	0
01/02/2015 14:00	0.2	13.8	1,309.5	0.2	0.5	1	1	0
01/02/2015 15:00	0.4	13.6	1,646.5	0.2	1.2	1	1	1
01/02/2015 16:00	0.5	13.2	1,924.6	0.3	1.7	1	1	1
01/02/2015 17:00	0.5	12.1	2,238.4	0.3	1.7	1	1	1
01/02/2015 18:00	0.4	11.6	2,355.2	0.3	1.3	1	1	1
01/02/2015 19:00	0.3	11.6	2,358.6	0.3	1.0	1	1	1
01/02/2015 20:00	0.3	11.6	2,359.5	0.2	1.0	1	1	1
01/02/2015 21:00	0.3	11.6	2,360.9	0.2	1.0	1	1	1
01/02/2015 22:00	0.3	11.7	2,357.4	0.2	1.0	1	1	1
01/02/2015 23:00	0.4	12.0	2,282.8	0.2	1.4	1	1	1
Average/Sum#:	0.4	12.9	1,946.4	0.3	30.3 #	24 #	24 #	20 #
Minimum:	0.2	11.6	1,309.5	0.2	0.5	1	1	0
Maximum:	0.5	13.8	2,360.9	0.4	1.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/03/2015 00:00	0.5	12.3	2,219.8	0.3	1.7	1	1	1
01/03/2015 01:00	0.4	12.0	2,309.1	0.3	1.4	1	1	1
01/03/2015 02:00	0.5	12.3	2,211.0	0.3	1.7	1	1	1
01/03/2015 03:00	0.4	12.0	2,308.0	0.3	1.4	1	1	1
01/03/2015 04:00	0.4	12.6	2,149.4	0.3	1.4	1	1	1
01/03/2015 05:00	0.5	12.9	2,090.8	0.3	1.7	1	1	1
01/03/2015 06:00	0.5	12.2	2,219.7	0.3	1.7	1	1	1
01/03/2015 07:00	0.5	12.5	2,166.1	0.4	1.7	1	1	1
01/03/2015 08:00	0.4	13.2	1,936.2	0.3	1.3	1	1	1
01/03/2015 09:00	0.4	13.2	1,887.9	0.3	1.3	1	1	1
01/03/2015 10:00	0.4	13.2	1,886.6	0.3	1.3	1	1	1
01/03/2015 11:00	0.4	13.2	1,877.8	0.3	1.3	1	1	1
01/03/2015 12:00	0.2	13.8	1,360.0	0.3	0.5	1	1	0
01/03/2015 13:00	0.2	13.8	1,308.2	0.2	0.5	1	1	0
01/03/2015 14:00	0.2	13.8	1,306.2	0.2	0.5	1	1	0
01/03/2015 15:00	0.3	13.5	1,671.5	0.2	0.9	1	1	1
01/03/2015 16:00	0.5	12.9	2,027.1	0.3	1.7	1	1	1
01/03/2015 17:00	0.5	12.2	2,226.6	0.3	1.7	1	1	1
01/03/2015 18:00	0.4	11.7	2,350.9	0.3	1.3	1	1	1
01/03/2015 19:00	0.4	11.7	2,344.8	0.3	1.3	1	1	1
01/03/2015 20:00	0.4	11.7	2,345.4	0.3	1.3	1	1	1
01/03/2015 21:00	0.4	11.7	2,356.8	0.3	1.4	1	1	1
01/03/2015 22:00	0.4	11.9	2,301.5	0.3	1.4	1	1	1
01/03/2015 23:00	0.4	12.0	2,279.9	0.3	1.4	1	1	1
Average/Sum#:	0.4	12.6	2,047.6	0.3	31.8 #	24 #	24 #	21 #
Minimum:	0.2	11.7	1,306.2	0.2	0.5	1	1	0
Maximum:	0.5	13.8	2,356.8	0.4	1.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/04/2015 00:00	0.4	12.1	2,280.6	0.3	1.4	1	1	1
01/04/2015 01:00	0.4	13.0	2,039.4	0.3	1.4	1	1	1
01/04/2015 02:00	0.4	13.1	2,024.6	0.3	1.4	1	1	1
01/04/2015 03:00	0.4	13.1	2,025.0	0.3	1.4	1	1	1
01/04/2015 04:00	0.4	13.2	2,004.2	0.3	1.4	1	1	1
01/04/2015 05:00	0.4	13.2	2,013.4	0.3	1.4	1	1	1
01/04/2015 06:00	0.5	12.3	2,174.1	0.3	1.7	1	1	1
01/04/2015 07:00	0.4	11.9	2,306.5	0.3	1.4	1	1	1
01/04/2015 08:00	0.4	13.1	1,991.2	0.3	1.3	1	1	1
01/04/2015 09:00	0.4	13.2	1,936.9	0.3	1.3	1	1	1
01/04/2015 10:00	0.4	13.2	1,923.0	0.3	1.3	1	1	1
01/04/2015 11:00	0.4	13.2	1,896.1	0.3	1.3	1	1	1
01/04/2015 12:00	0.4	13.2	1,891.0	0.3	1.3	1	1	1
01/04/2015 13:00	0.4	13.2	1,915.3	0.3	1.3	1	1	1
01/04/2015 14:00	0.4	13.0	2,022.0	0.3	1.4	1	1	1
01/04/2015 15:00	0.4	12.9	2,038.2	0.3	1.3	1	1	1
01/04/2015 16:00	0.5	12.9	2,047.1	0.3	1.7	1	1	1
01/04/2015 17:00	0.4	11.9	2,276.6	0.3	1.3	1	1	1
01/04/2015 18:00	0.3	11.6	2,343.9	0.3	1.0	1	1	1
01/04/2015 19:00	0.3	11.6	2,353.0	0.2	1.0	1	1	1
01/04/2015 20:00	0.3	11.6	2,352.1	0.2	1.0	1	1	1
01/04/2015 21:00	0.3	11.8	2,304.6	0.2	1.0	1	1	1
01/04/2015 22:00	0.3	11.9	2,285.6	0.2	1.0	1	1	1
01/04/2015 23:00	0.3	13.2	1,934.8	0.2	1.0	1	1	1
Average/Sum#:	0.4	12.6	2,099.1	0.3	31.0 #	24 #	24 #	24 #
Minimum:	0.3	11.6	1,891.0	0.2	1.0	1	1	1
Maximum:	0.5	13.2	2,353.0	0.3	1.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/05/2015 00:00	0.4	13.2	1,892.1	0.2	1.3	1	1	1
01/05/2015 01:00	0.4	13.2	1,980.3	0.3	1.4	1	1	1
01/05/2015 02:00	0.4	13.2	1,888.4	0.3	1.3	1	1	1
01/05/2015 03:00	0.4	13.2	2,003.5	0.3	1.4	1	1	1
01/05/2015 04:00	0.4	13.2	1,932.5	0.3	1.3	1	1	1
01/05/2015 05:00	0.4	13.2	1,955.5	0.3	1.3	1	1	1
01/05/2015 06:00	0.5	12.8	2,078.4	0.3	1.7	1	1	1
01/05/2015 07:00	0.4	11.8	2,336.1	0.3	1.4	1	1	1
01/05/2015 08:00	0.4	11.9	2,316.2	0.3	1.4	1	1	1
01/05/2015 09:00	0.3	13.1	1,957.3	0.3	1.0	1	1	1
01/05/2015 10:00	0.3	13.2	1,886.2	0.2	1.0	1	1	1
01/05/2015 11:00	0.4	13.3	1,885.9	0.2	1.3	1	1	1
01/05/2015 12:00	0.4	13.3	1,889.8	0.3	1.3	1	1	1
01/05/2015 13:00	0.4	13.3	1,895.4	0.3	1.3	1	1	1
01/05/2015 14:00	0.4	12.9	2,012.6	0.3	1.3	1	1	1
01/05/2015 15:00	0.4	13.0	1,994.1	0.3	1.3	1	1	1
01/05/2015 16:00	0.4	12.9	2,030.4	0.3	1.3	1	1	1
01/05/2015 17:00	0.4	12.0	2,275.6	0.3	1.4	1	1	1
01/05/2015 18:00	0.3	11.6	2,351.9	0.3	1.0	1	1	1
01/05/2015 19:00	0.3	11.6	2,358.0	0.2	1.0	1	1	1
01/05/2015 20:00	0.3	11.6	2,360.0	0.2	1.0	1	1	1
01/05/2015 21:00	0.4	12.1	2,231.4	0.2	1.3	1	1	1
01/05/2015 22:00	0.4	12.8	2,061.6	0.3	1.3	1	1	1
01/05/2015 23:00	0.4	13.4	1,724.6	0.3	1.2	1	1	1
Average/Sum#:	0.4	12.7	2,054.1	0.3	30.5 #	24 #	24 #	24 #
Minimum:	0.3	11.6	1,724.6	0.2	1.0	1	1	1
Maximum:	0.5	13.4	2,360.0	0.3	1.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/06/2015 00:00	0.2	13.8	1,441.6	0.3	0.5	1	1	0
01/06/2015 01:00	0.2	13.8	1,656.6	0.2	0.6	1	1	0
01/06/2015 02:00	0.3	13.5	1,730.7	0.2	0.9	1	1	1
01/06/2015 03:00	0.4	13.2	1,888.6	0.2	1.3	1	1	1
01/06/2015 04:00	0.4	13.2	1,887.7	0.3	1.3	1	1	1
01/06/2015 05:00	0.4	13.2	1,947.4	0.3	1.3	1	1	1
01/06/2015 06:00	0.5	12.5	2,095.1	0.3	1.6	1	1	1
01/06/2015 07:00	0.4	11.8	2,329.4	0.3	1.4	1	1	1
01/06/2015 08:00	0.4	12.5	2,139.9	0.3	1.3	1	1	1
01/06/2015 09:00	0.4	13.2	1,887.0	0.3	1.3	1	1	1
01/06/2015 10:00	0.3	13.6	1,562.1	0.3	0.8	1	1	1
01/06/2015 11:00	0.2	13.8	1,305.0	0.2	0.5	1	1	0
01/06/2015 12:00	0.2	13.8	1,305.6	0.2	0.5	1	1	0
01/06/2015 13:00	0.2	13.9	1,449.1	0.2	0.5	1	1	0
01/06/2015 14:00	0.2	13.9	1,311.3	0.2	0.5	1	1	0
01/06/2015 15:00	0.2	13.8	1,614.6	0.2	0.6	1	1	1
01/06/2015 16:00	0.4	13.2	1,908.0	0.2	1.3	1	1	1
01/06/2015 17:00	0.4	12.7	2,040.1	0.3	1.3	1	1	1
01/06/2015 18:00	0.4	12.4	2,084.2	0.3	1.3	1	1	1
01/06/2015 19:00	0.4	12.4	2,108.3	0.3	1.3	1	1	1
01/06/2015 20:00	0.4	12.2	2,160.6	0.3	1.3	1	1	1
01/06/2015 21:00	0.4	12.3	2,171.2	0.3	1.3	1	1	1
01/06/2015 22:00	0.4	12.5	2,108.7	0.3	1.3	1	1	1
01/06/2015 23:00	0.3	13.3	1,901.6	0.3	1.0	1	1	1
Average/Sum#:	0.3	13.1	1,834.8	0.3	25.0 #	24 #	24 #	18 #
Minimum:	0.2	11.8	1,305.0	0.2	0.5	1	1	0
Maximum:	0.5	13.9	2,329.4	0.3	1.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/07/2015 00:00	0.4	13.1	1,945.2	0.3	1.3	1	1	1
01/07/2015 01:00	0.4	13.2	1,906.3	0.3	1.3	1	1	1
01/07/2015 02:00	0.4	13.2	1,923.1	0.3	1.3	1	1	1
01/07/2015 03:00	0.4	13.3	1,889.3	0.3	1.3	1	1	1
01/07/2015 04:00	0.4	13.0	1,993.2	0.3	1.3	1	1	1
01/07/2015 05:00	0.4	13.2	1,935.2	0.3	1.3	1	1	1
01/07/2015 06:00	0.5	12.5	2,112.6	0.3	1.7	1	1	1
01/07/2015 07:00	0.4	11.9	2,288.8	0.3	1.3	1	1	1
01/07/2015 08:00	0.4	12.8	2,067.6	0.3	1.3	1	1	1
01/07/2015 09:00	0.4	13.2	1,928.9	0.3	1.3	1	1	1
01/07/2015 10:00	0.4	13.3	1,885.4	0.3	1.3	1	1	1
01/07/2015 11:00	0.4	13.4	1,858.2	0.3	1.3	1	1	1
01/07/2015 12:00	0.2	13.9	1,312.0	0.3	0.5	1	1	0
01/07/2015 13:00	0.2	13.9	1,497.3	0.2	0.6	1	1	0
01/07/2015 14:00	0.2	13.9	1,560.7	0.2	0.6	1	1	1
01/07/2015 15:00	0.5	12.8	2,015.4	0.3	1.6	1	1	1
01/07/2015 16:00	0.4	12.8	1,994.3	0.3	1.3	1	1	1
01/07/2015 17:00	0.4	12.0	2,192.5	0.3	1.3	1	1	1
01/07/2015 18:00	0.4	12.5	2,078.5	0.3	1.3	1	1	1
01/07/2015 19:00	0.5	12.7	2,037.9	0.3	1.6	1	1	1
01/07/2015 20:00	0.5	12.7	2,040.6	0.4	1.6	1	1	1
01/07/2015 21:00	0.5	12.7	2,047.6	0.4	1.6	1	1	1
01/07/2015 22:00	0.4	13.0	1,944.4	0.4	1.3	1	1	1
01/07/2015 23:00	0.4	13.3	1,887.1	0.3	1.3	1	1	1
Average/Sum#:	0.4	13.0	1,930.9	0.3	30.6 #	24 #	24 #	22 #
Minimum:	0.2	11.9	1,312.0	0.2	0.5	1	1	0
Maximum:	0.5	13.9	2,288.8	0.4	1.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/08/2015 00:00	0.4	13.3	1,886.3	0.3	1.3	1	1	1
01/08/2015 01:00	0.4	13.3	1,885.6	0.3	1.3	1	1	1
01/08/2015 02:00	0.4	13.3	1,887.0	0.3	1.3	1	1	1
01/08/2015 03:00	0.4	13.3	1,888.3	0.3	1.3	1	1	1
01/08/2015 04:00	0.4	13.2	1,886.1	0.3	1.3	1	1	1
01/08/2015 05:00	0.4	13.2	1,879.9	0.3	1.3	1	1	1
01/08/2015 06:00	0.5	12.3	2,109.2	0.3	1.6	1	1	1
01/08/2015 07:00	0.4	11.7	2,318.2	0.3	1.3	1	1	1
01/08/2015 08:00	0.3	11.8	2,301.3	0.3	1.0	1	1	1
01/08/2015 09:00	0.4	12.1	2,233.7	0.3	1.3	1	1	1
01/08/2015 10:00	0.5	12.5	2,116.6	0.3	1.7	1	1	1
01/08/2015 11:00	0.4	12.8	2,026.6	0.3	1.3	1	1	1
01/08/2015 12:00	0.5	12.7	2,054.9	0.4	1.7	1	1	1
01/08/2015 13:00	0.4	12.3	2,126.2	0.3	1.3	1	1	1
01/08/2015 14:00	0.4	12.4	2,109.7	0.3	1.3	1	1	1
01/08/2015 15:00	0.3	11.6	2,276.6	0.3	1.0	1	1	1
01/08/2015 16:00	0.4	12.5	2,058.6	0.3	1.3	1	1	1
01/08/2015 17:00	0.4	12.5	2,089.0	0.3	1.3	1	1	1
01/08/2015 18:00	0.4	12.4	2,095.0	0.3	1.3	1	1	1
01/08/2015 19:00	0.5	12.7	2,042.7	0.3	1.6	1	1	1
01/08/2015 20:00	0.4	12.6	2,055.3	0.3	1.3	1	1	1
01/08/2015 21:00	0.4	12.3	2,140.2	0.3	1.3	1	1	1
01/08/2015 22:00	0.4	12.6	2,053.0	0.3	1.3	1	1	1
01/08/2015 23:00	0.4	13.0	1,941.6	0.3	1.3	1	1	1
Average/Sum#:	0.4	12.6	2,060.9	0.3	32.0 #	24 #	24 #	24 #
Minimum:	0.3	11.6	1,879.9	0.3	1.0	1	1	1
Maximum:	0.5	13.3	2,318.2	0.4	1.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/09/2015 00:00	0.4	13.0	1,979.6	0.3	1.3	1	1	1
01/09/2015 01:00	0.4	13.2	1,923.9	0.3	1.3	1	1	1
01/09/2015 02:00	0.4	13.3	1,888.0	0.3	1.3	1	1	1
01/09/2015 03:00	0.4	13.1	1,952.8	0.3	1.3	1	1	1
01/09/2015 04:00	0.4	13.3	1,897.0	0.3	1.3	1	1	1
01/09/2015 05:00	0.4	13.2	1,937.4	0.3	1.3	1	1	1
01/09/2015 06:00	0.5	12.9	1,984.6	0.3	1.6	1	1	1
01/09/2015 07:00	0.4	12.3	2,183.7	0.3	1.3	1	1	1
01/09/2015 08:00	0.3	11.7	2,304.7	0.3	1.0	1	1	1
01/09/2015 09:00	0.4	12.6	2,093.9	0.3	1.3	1	1	1
01/09/2015 10:00	0.4	12.0	2,248.5	0.3	1.3	1	1	1
01/09/2015 11:00	0.3	11.8	2,262.0	0.3	1.0	1	1	1
01/09/2015 12:00	0.4	13.2	1,915.8	0.3	1.3	1	1	1
01/09/2015 13:00	0.3	13.4	1,705.3	0.2	0.9	1	1	1
01/09/2015 14:00	0.2	13.9	1,392.2	0.2	0.5	1	1	0
01/09/2015 15:00	0.2	13.9	1,377.4	0.2	0.5	1	1	0
01/09/2015 16:00	0.4	13.4	1,697.9	0.2	1.2	1	1	1
01/09/2015 17:00	0.4	13.2	1,909.8	0.3	1.3	1	1	1
01/09/2015 18:00	0.4	13.3	1,812.1	0.3	1.3	1	1	1
01/09/2015 19:00	0.4	13.4	1,817.2	0.3	1.3	1	1	1
01/09/2015 20:00	0.4	13.3	1,899.5	0.3	1.3	1	1	1
01/09/2015 21:00	0.4	13.4	1,904.5	0.3	1.3	1	1	1
01/09/2015 22:00	0.4	13.2	1,945.2	0.3	1.3	1	1	1
01/09/2015 23:00	0.5	13.0	2,005.0	0.3	1.7	1	1	1
Average/Sum#:	0.4	13.0	1,918.3	0.3	29.2 #	24 #	24 #	22 #
Minimum:	0.2	11.7	1,377.4	0.2	0.5	1	1	0
Maximum:	0.5	13.9	2,304.7	0.3	1.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/10/2015 00:00	0.4	13.4	1,903.7	0.3	1.3	1	1	1
01/10/2015 01:00	0.4	13.5	1,875.5	0.3	1.3	1	1	1
01/10/2015 02:00	0.3	13.6	1,715.7	0.3	0.9	1	1	1
01/10/2015 03:00	0.2	13.8	1,361.5	0.2	0.5	1	1	0
01/10/2015 04:00	0.3	13.5	1,637.1	0.2	0.9	1	1	1
01/10/2015 05:00	0.5	13.2	1,928.2	0.3	1.7	1	1	1
01/10/2015 06:00	0.5	13.0	1,978.8	0.3	1.7	1	1	1
01/10/2015 07:00	0.5	13.0	1,995.1	0.4	1.7	1	1	1
01/10/2015 08:00	0.4	13.2	1,910.8	0.4	1.3	1	1	1
01/10/2015 09:00	0.4	13.2	1,886.2	0.3	1.3	1	1	1
01/10/2015 10:00	0.5	13.0	1,998.8	0.3	1.7	1	1	1
01/10/2015 11:00	0.4	11.9	2,260.3	0.3	1.3	1	1	1
01/10/2015 12:00	0.3	11.9	2,214.9	0.3	1.0	1	1	1
01/10/2015 13:00	0.4	13.0	1,969.1	0.3	1.3	1	1	1
01/10/2015 14:00	0.5	12.7	2,032.5	0.3	1.6	1	1	1
01/10/2015 15:00	0.4	13.3	1,885.8	0.3	1.3	1	1	1
01/10/2015 16:00	0.4	13.2	1,925.6	0.3	1.3	1	1	1
01/10/2015 17:00	0.5	12.5	2,092.3	0.3	1.6	1	1	1
01/10/2015 18:00	0.5	12.8	2,020.8	0.4	1.6	1	1	1
01/10/2015 19:00	0.5	12.6	2,094.7	0.4	1.7	1	1	1
01/10/2015 20:00	0.3	11.6	2,306.2	0.3	1.0	1	1	1
01/10/2015 21:00	0.4	12.2	2,150.3	0.3	1.3	1	1	1
01/10/2015 22:00	0.4	12.6	2,067.2	0.3	1.3	1	1	1
01/10/2015 23:00	0.4	13.1	1,935.0	0.3	1.3	1	1	1
Average/Sum#:	0.4	12.9	1,964.4	0.3	31.9 #	24 #	24 #	23 #
Minimum:	0.2	11.6	1,361.5	0.2	0.5	1	1	0
Maximum:	0.5	13.8	2,306.2	0.4	1.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/11/2015 00:00	0.4	13.1	1,944.1	0.3	1.3	1	1	1
01/11/2015 01:00	0.4	13.1	1,952.4	0.3	1.3	1	1	1
01/11/2015 02:00	0.4	13.1	1,963.8	0.3	1.3	1	1	1
01/11/2015 03:00	0.4	13.3	1,892.7	0.3	1.3	1	1	1
01/11/2015 04:00	0.4	13.3	1,889.4	0.3	1.3	1	1	1
01/11/2015 05:00	0.4	13.2	1,919.4	0.3	1.3	1	1	1
01/11/2015 06:00	0.4	13.2	1,920.2	0.3	1.3	1	1	1
01/11/2015 07:00	0.4	13.1	1,962.7	0.3	1.3	1	1	1
01/11/2015 08:00	0.5	12.5	2,140.3	0.3	1.7	1	1	1
01/11/2015 09:00	0.3	11.7	2,316.9	0.3	1.0	1	1	1
01/11/2015 10:00	0.3	11.7	2,303.2	0.3	1.0	1	1	1
01/11/2015 11:00	0.3	12.0	2,215.1	0.2	1.0	1	1	1
01/11/2015 12:00	0.4	12.8	2,017.8	0.2	1.3	1	1	1
01/11/2015 13:00	0.4	12.9	2,010.9	0.3	1.3	1	1	1
01/11/2015 14:00	0.4	13.1	1,937.3	0.3	1.3	1	1	1
01/11/2015 15:00	0.4	12.8	2,024.9	0.3	1.3	1	1	1
01/11/2015 16:00	0.4	13.2	1,918.6	0.3	1.3	1	1	1
01/11/2015 17:00	0.4	12.3	2,146.3	0.3	1.3	1	1	1
01/11/2015 18:00	0.4	12.2	2,155.7	0.3	1.3	1	1	1
01/11/2015 19:00	0.3	11.8	2,257.5	0.3	1.0	1	1	1
01/11/2015 20:00	0.4	12.2	2,162.7	0.3	1.3	1	1	1
01/11/2015 21:00	0.4	12.1	2,192.8	0.3	1.3	1	1	1
01/11/2015 22:00	0.4	13.0	1,978.7	0.3	1.3	1	1	1
01/11/2015 23:00	0.4	13.3	1,876.5	0.3	1.3	1	1	1
Average/Sum#:	0.4	12.7	2,045.8	0.3	30.4 #	24 #	24 #	24 #
Minimum:	0.3	11.7	1,876.5	0.2	1.0	1	1	1
Maximum:	0.5	13.3	2,316.9	0.3	1.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/12/2015 00:00	0.5	13.0	1,987.1	0.3	1.7	1	1	1
01/12/2015 01:00	0.4	13.2	1,924.1	0.3	1.3	1	1	1
01/12/2015 02:00	0.4	13.2	1,920.8	0.3	1.3	1	1	1
01/12/2015 03:00	0.4	13.1	1,972.9	0.3	1.3	1	1	1
01/12/2015 04:00	0.4	13.2	1,954.8	0.3	1.3	1	1	1
01/12/2015 05:00	0.4	13.1	1,942.6	0.3	1.3	1	1	1
01/12/2015 06:00	0.5	12.9	2,030.5	0.3	1.7	1	1	1
01/12/2015 07:00	0.4	13.0	2,011.7	0.3	1.3	1	1	1
01/12/2015 08:00	0.4	13.0	2,013.3	0.3	1.3	1	1	1
01/12/2015 09:00	0.5	12.5	2,141.9	0.3	1.7	1	1	1
01/12/2015 10:00	0.4	12.7	2,061.7	0.3	1.3	1	1	1
01/12/2015 11:00	0.4	13.3	1,894.3	0.3	1.3	1	1	1
01/12/2015 12:00	0.4	13.3	1,882.6	0.3	1.3	1	1	1
01/12/2015 13:00	0.4	13.3	1,880.5	0.3	1.3	1	1	1
01/12/2015 14:00	0.4	13.3	1,884.6	0.3	1.3	1	1	1
01/12/2015 15:00	0.4	13.3	1,884.5	0.3	1.3	1	1	1
01/12/2015 16:00	0.4	13.2	1,915.7	0.3	1.3	1	1	1
01/12/2015 17:00	0.4	12.9	2,002.9	0.3	1.3	1	1	1
01/12/2015 18:00	0.3	11.7	2,261.3	0.3	1.0	1	1	1
01/12/2015 19:00	0.3	11.6	2,303.2	0.2	1.0	1	1	1
01/12/2015 20:00	0.2	11.5	2,310.9	0.2	0.6	1	1	1
01/12/2015 21:00	0.3	11.9	2,235.6	0.2	1.0	1	1	1
01/12/2015 22:00	0.4	12.3	2,141.7	0.2	1.3	1	1	1
01/12/2015 23:00	0.4	13.1	1,967.0	0.3	1.3	1	1	1
Average/Sum#:	0.4	12.8	2,021.9	0.3	30.8 #	24 #	24 #	24 #
Minimum:	0.2	11.5	1,880.5	0.2	0.6	1	1	1
Maximum:	0.5	13.3	2,310.9	0.3	1.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/13/2015 00:00	0.4	12.7	2,062.5	0.3	1.3	1	1	1
01/13/2015 01:00	0.4	12.8	2,050.6	0.3	1.3	1	1	1
01/13/2015 02:00	0.4	12.8	2,035.6	0.3	1.3	1	1	1
01/13/2015 03:00	0.4	13.0	2,004.6	0.3	1.3	1	1	1
01/13/2015 04:00	0.4	13.1	1,960.9	0.3	1.3	1	1	1
01/13/2015 05:00	0.4	13.3	1,891.0	0.3	1.3	1	1	1
01/13/2015 06:00	0.4	13.1	1,943.8	0.3	1.3	1	1	1
01/13/2015 07:00	0.5	12.9	2,042.6	0.3	1.7	1	1	1
01/13/2015 08:00	0.4	13.1	1,965.8	0.3	1.3	1	1	1
01/13/2015 09:00	0.4	13.3	1,913.2	0.3	1.3	1	1	1
01/13/2015 10:00	0.4	12.8	2,039.6	0.3	1.3	1	1	1
01/13/2015 11:00	0.4	12.7	2,043.1	0.3	1.3	1	1	1
01/13/2015 12:00	0.4	13.1	1,953.7	0.3	1.3	1	1	1
01/13/2015 13:00	0.4	13.0	1,976.1	0.3	1.3	1	1	1
01/13/2015 14:00	0.4	13.1	1,947.8	0.3	1.3	1	1	1
01/13/2015 15:00	0.4	13.2	1,922.1	0.3	1.3	1	1	1
01/13/2015 16:00	0.4	13.2	1,924.3	0.3	1.3	1	1	1
01/13/2015 17:00	0.4	12.3	2,160.4	0.3	1.3	1	1	1
01/13/2015 18:00	0.3	11.6	2,299.7	0.3	1.0	1	1	1
01/13/2015 19:00	0.3	11.6	2,301.3	0.2	1.0	1	1	1
01/13/2015 20:00	0.2	11.6	2,301.7	0.2	0.7	1	1	1
01/13/2015 21:00	0.3	12.0	2,229.7	0.2	1.0	1	1	1
01/13/2015 22:00	0.3	12.3	2,158.0	0.2	1.0	1	1	1
01/13/2015 23:00	0.2	13.6	1,639.2	0.2	0.6	1	1	1
Average/Sum#:	0.4	12.8	2,032.0	0.3	29.1 #	24 #	24 #	24 #
Minimum:	0.2	11.6	1,639.2	0.2	0.6	1	1	1
Maximum:	0.5	13.6	2,301.7	0.3	1.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/14/2015 00:00	0.2	13.9	1,344.2	0.2	0.5	1	1	0
01/14/2015 01:00	0.2	13.8	1,579.2	0.2	0.6	1	1	0
01/14/2015 02:00	0.3	13.6	1,715.6	0.2	0.9	1	1	1
01/14/2015 03:00	0.5	13.1	1,964.5	0.3	1.7	1	1	1
01/14/2015 04:00	0.5	13.2	1,997.0	0.3	1.7	1	1	1
01/14/2015 05:00	0.4	13.2	1,911.6	0.4	1.3	1	1	1
01/14/2015 06:00	0.5	12.9	2,019.8	0.4	1.7	1	1	1
01/14/2015 07:00	0.4	11.9	2,306.2	0.3	1.4	1	1	1
01/14/2015 08:00	0.4	12.4	2,168.5	0.3	1.3	1	1	1
01/14/2015 09:00	0.4	13.1	2,001.5	0.3	1.4	1	1	1
01/14/2015 10:00	0.4	13.2	1,918.9	0.3	1.3	1	1	1
01/14/2015 11:00	0.4	13.2	1,886.6	0.3	1.3	1	1	1
01/14/2015 12:00	0.4	13.3	1,885.0	0.3	1.3	1	1	1
01/14/2015 13:00	0.4	13.3	1,887.1	0.3	1.3	1	1	1
01/14/2015 14:00	0.4	13.3	1,889.6	0.3	1.3	1	1	1
01/14/2015 15:00	0.4	13.3	1,896.7	0.3	1.3	1	1	1
01/14/2015 16:00	0.4	13.1	1,953.8	0.3	1.3	1	1	1
01/14/2015 17:00	0.5	12.4	2,157.4	0.3	1.7	1	1	1
01/14/2015 18:00	0.3	11.5	2,335.8	0.3	1.0	1	1	1
01/14/2015 19:00	0.3	11.6	2,338.2	0.2	1.0	1	1	1
01/14/2015 20:00	0.3	11.6	2,338.1	0.2	1.0	1	1	1
01/14/2015 21:00	0.3	11.6	2,328.6	0.2	1.0	1	1	1
01/14/2015 22:00	0.4	12.5	2,122.0	0.2	1.3	1	1	1
01/14/2015 23:00	0.4	13.2	1,916.9	0.3	1.3	1	1	1
Average/Sum#:	0.4	12.8	1,994.3	0.3	29.9 #	24 #	24 #	22 #
Minimum:	0.2	11.5	1,344.2	0.2	0.5	1	1	0
Maximum:	0.5	13.9	2,338.2	0.4	1.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/15/2015 00:00	0.4	13.2	1,941.1	0.3	1.3	1	1	1
01/15/2015 01:00	0.4	13.2	1,884.6	0.3	1.3	1	1	1
01/15/2015 02:00	0.4	13.2	1,883.9	0.3	1.3	1	1	1
01/15/2015 03:00	0.4	13.2	1,882.8	0.3	1.3	1	1	1
01/15/2015 04:00	0.4	13.2	1,885.5	0.3	1.3	1	1	1
01/15/2015 05:00	0.4	13.2	1,881.9	0.3	1.3	1	1	1
01/15/2015 06:00	0.5	12.9	2,012.6	0.3	1.7	1	1	1
01/15/2015 07:00	0.4	12.1	2,257.7	0.3	1.4	1	1	1
01/15/2015 08:00	0.4	12.9	2,023.5	0.3	1.3	1	1	1
01/15/2015 09:00	0.3	13.5	1,581.9	0.3	0.8	1	1	1
01/15/2015 10:00	0.2	13.8	1,305.2	0.2	0.5	1	1	0
01/15/2015 11:00	0.2	13.8	1,305.8	0.2	0.5	1	1	0
01/15/2015 12:00	0.2	13.8	1,306.8	0.2	0.5	1	1	0
01/15/2015 13:00	0.2	13.8	1,302.6	0.2	0.5	1	1	0
01/15/2015 14:00	0.2	13.8	1,302.3	0.2	0.5	1	1	0
01/15/2015 15:00	0.2	13.8	1,334.7	0.2	0.5	1	1	0
01/15/2015 16:00	0.4	13.3	1,888.2	0.2	1.3	1	1	1
01/15/2015 17:00	0.5	11.9	2,293.0	0.3	1.7	1	1	1
01/15/2015 18:00	0.3	11.5	2,381.3	0.3	1.0	1	1	1
01/15/2015 19:00	0.4	12.0	2,261.8	0.3	1.3	1	1	1
01/15/2015 20:00	0.5	12.6	2,115.1	0.3	1.7	1	1	1
01/15/2015 21:00	0.5	12.5	2,145.4	0.4	1.7	1	1	1
01/15/2015 22:00	0.4	12.3	2,197.9	0.4	1.4	1	1	1
01/15/2015 23:00	0.4	13.1	1,921.2	0.3	1.3	1	1	1
Average/Sum#:	0.4	13.0	1,845.7	0.3	27.4 #	24 #	24 #	18 #
Minimum:	0.2	11.5	1,302.3	0.2	0.5	1	1	0
Maximum:	0.5	13.8	2,381.3	0.4	1.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/16/2015 00:00	0.4	13.2	1,884.9	0.3	1.3	1	1	1
01/16/2015 01:00	0.4	13.2	1,884.0	0.3	1.3	1	1	1
01/16/2015 02:00	0.4	13.2	1,882.7	0.3	1.3	1	1	1
01/16/2015 03:00	0.3	13.5	1,628.9	0.3	0.9	1	1	1
01/16/2015 04:00	0.2	13.8	1,322.8	0.2	0.5	1	1	0
01/16/2015 05:00	0.4	13.3	1,868.8	0.2	1.3	1	1	1
01/16/2015 06:00	0.5	12.9	1,989.7	0.3	1.6	1	1	1
01/16/2015 07:00	0.5	11.9	2,287.1	0.3	1.7	1	1	1
01/16/2015 08:00	0.4	13.1	1,967.7	0.3	1.3	1	1	1
01/16/2015 09:00	0.4	13.4	1,872.6	0.3	1.3	1	1	1
01/16/2015 10:00	0.4	13.4	1,890.3	0.3	1.3	1	1	1
01/16/2015 11:00	0.3	13.6	1,724.9	0.3	0.9	1	1	1
01/16/2015 12:00	0.2	14.0	1,427.2	0.2	0.5	1	1	0
01/16/2015 13:00	0.2	13.9	1,358.1	0.2	0.5	1	1	0
01/16/2015 14:00	0.2	13.9	1,364.7	0.2	0.5	1	1	0
01/16/2015 15:00	0.2	13.9	1,367.1	0.2	0.5	1	1	0
01/16/2015 16:00	10.0	15.0	901.1	0.0	7.5	1	0	0
01/16/2015 17:00	36.3	16.5	620.5	0.0	48.7	1	0	0
01/16/2015 18:00	3.3	13.9	1,281.1	0.0	8.0	1	0	0
01/16/2015 19:00	0.2	13.8	1,302.1	0.0	0.5	1	1	0
01/16/2015 20:00	0.2	13.8	1,299.3	0.0	0.5	1	1	0
01/16/2015 21:00	0.2	13.8	1,323.3	0.2	0.5	1	1	0
01/16/2015 22:00	0.2	13.8	1,526.1	0.2	0.6	1	1	0
01/16/2015 23:00	0.2	13.8	1,310.4	0.2	0.5	1	1	0
Average/Sum#:	2.3	13.7	1,553.6	0.3	83.5 #	24 #	21 #	11 #
Minimum:	0.2	11.9	620.5	0.2	0.5	1	0	0
Maximum:	36.3	16.5	2,287.1	0.3	48.7	1	1	1
%SI	0.0	0.0	0.0	20.8	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/17/2015 00:00	0.2	13.8	1,330.0	0.2	0.5	1	1	0
01/17/2015 01:00	0.2	13.8	1,545.2	0.2	0.6	1	1	0
01/17/2015 02:00	0.2	13.8	1,432.3	0.2	0.5	1	1	0
01/17/2015 03:00	0.2	13.8	1,603.7	0.2	0.6	1	1	0
01/17/2015 04:00	0.2	13.8	1,321.5	0.2	0.5	1	1	0
01/17/2015 05:00	0.2	13.8	1,359.0	0.2	0.5	1	1	0
01/17/2015 06:00	0.5	13.0	1,965.1	0.3	1.6	1	1	1
01/17/2015 07:00	0.5	12.8	2,053.8	0.3	1.7	1	1	1
01/17/2015 08:00	0.5	13.1	1,982.6	0.4	1.7	1	1	1
01/17/2015 09:00	0.4	13.4	1,918.0	0.4	1.4	1	1	1
01/17/2015 10:00	0.4	13.4	1,888.5	0.3	1.3	1	1	1
01/17/2015 11:00	0.4	13.4	1,879.0	0.3	1.3	1	1	1
01/17/2015 12:00	0.4	13.4	1,879.9	0.3	1.3	1	1	1
01/17/2015 13:00	0.3	13.6	1,581.8	0.3	0.9	1	1	1
01/17/2015 14:00	0.2	13.8	1,305.8	0.2	0.5	1	1	0
01/17/2015 15:00	0.2	13.8	1,306.1	0.2	0.5	1	1	0
01/17/2015 16:00	0.3	13.5	1,650.4	0.2	0.9	1	1	1
01/17/2015 17:00	0.4	13.0	1,990.4	0.2	1.3	1	1	1
01/17/2015 18:00	0.5	12.0	2,259.6	0.3	1.7	1	1	1
01/17/2015 19:00	0.4	12.2	2,201.3	0.3	1.3	1	1	1
01/17/2015 20:00	0.4	12.8	2,056.7	0.3	1.3	1	1	1
01/17/2015 21:00	0.5	12.7	2,099.3	0.3	1.7	1	1	1
01/17/2015 22:00	0.5	12.7	2,091.7	0.4	1.7	1	1	1
01/17/2015 23:00	0.5	12.6	2,106.3	0.4	1.7	1	1	1
Average/Sum#:	0.4	13.3	1,783.7	0.3	27.0 #	24 #	24 #	16 #
Minimum:	0.2	12.0	1,305.8	0.2	0.5	1	1	0
Maximum:	0.5	13.8	2,259.6	0.4	1.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/18/2015 00:00	0.4	13.0	2,017.0	0.4	1.3	1	1	1
01/18/2015 01:00	0.4	13.3	1,801.5	0.3	1.3	1	1	1
01/18/2015 02:00	7.8	14.8	952.4	0.0	7.6	1	0	0
01/18/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/18/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/18/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/18/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/18/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/18/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/18/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/18/2015 10:00	19.4	17.7	457.8	0.0	15.4	1	0	0
01/18/2015 11:00	25.9	15.2	929.5	0.0	55.8	1	0	0
01/18/2015 12:00	0.2	13.8	1,334.9	0.0	0.5	1	1	0
01/18/2015 13:00	0.2	13.8	1,327.0	0.0	0.5	1	1	0
01/18/2015 14:00	0.2	13.8	1,542.7	0.2	0.6	1	1	0
01/18/2015 15:00	0.2	13.8	1,487.1	0.2	0.6	1	1	0
01/18/2015 16:00	0.2	13.8	1,437.5	0.2	0.5	1	1	1
01/18/2015 17:00	0.4	13.2	1,953.5	0.2	1.3	1	1	1
01/18/2015 18:00	0.4	13.0	2,015.2	0.3	1.3	1	1	1
01/18/2015 19:00	0.4	13.0	2,020.3	0.3	1.4	1	1	1
01/18/2015 20:00	0.4	13.1	1,999.4	0.3	1.4	1	1	1
01/18/2015 21:00	0.4	13.3	1,945.9	0.3	1.4	1	1	1
01/18/2015 22:00	0.2	13.8	1,478.9	0.3	0.6	1	1	0
01/18/2015 23:00	0.2	13.8	1,306.8	0.2	0.5	1	1	0
Average/Sum#:	3.4	13.9	1,529.8	0.3	92.0 #	17 #	14 #	8 #
Minimum:	0.2	13.0	457.8	0.2	0.5	0	0	0
Maximum:	25.9	17.7	2,020.3	0.4	55.8	1	1	1
%SI	29.2	29.2	29.2	50.0	29.2	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/19/2015 00:00	0.2	13.8	1,511.5	0.2	0.6	1	1	0
01/19/2015 01:00	0.2	13.8	1,356.5	0.2	0.5	1	1	0
01/19/2015 02:00	0.2	13.8	1,308.7	0.2	0.5	1	1	0
01/19/2015 03:00	0.4	13.8	1,580.3	0.2	1.2	1	1	0
01/19/2015 04:00	0.4	13.2	1,910.6	0.3	1.3	1	1	1
01/19/2015 05:00	0.4	13.0	2,011.5	0.3	1.3	1	1	1
01/19/2015 06:00	0.4	13.0	2,016.0	0.3	1.3	1	1	1
01/19/2015 07:00	0.4	13.0	2,021.1	0.3	1.4	1	1	1
01/19/2015 08:00	0.4	13.1	1,955.5	0.3	1.3	1	1	1
01/19/2015 09:00	0.4	13.2	1,906.7	0.3	1.3	1	1	1
01/19/2015 10:00	0.4	13.2	1,928.6	0.3	1.3	1	1	1
01/19/2015 11:00	0.4	13.2	1,897.0	0.3	1.3	1	1	1
01/19/2015 12:00	0.4	13.3	1,901.8	0.3	1.3	1	1	1
01/19/2015 13:00	0.4	13.3	1,894.8	0.3	1.3	1	1	1
01/19/2015 14:00	0.4	13.3	1,896.4	0.3	1.3	1	1	1
01/19/2015 15:00	0.4	13.2	1,918.5	0.3	1.3	1	1	1
01/19/2015 16:00	0.4	13.1	1,949.6	0.3	1.3	1	1	1
01/19/2015 17:00	0.4	13.1	1,951.6	0.3	1.3	1	1	1
01/19/2015 18:00	0.4	13.1	1,977.3	0.3	1.3	1	1	1
01/19/2015 19:00	0.4	12.9	2,008.8	0.3	1.3	1	1	1
01/19/2015 20:00	0.4	12.9	2,025.6	0.3	1.3	1	1	1
01/19/2015 21:00	0.4	12.9	2,038.7	0.3	1.3	1	1	1
01/19/2015 22:00	0.4	13.1	1,955.1	0.3	1.3	1	1	1
01/19/2015 23:00	0.4	13.2	1,897.8	0.3	1.3	1	1	1
Average/Sum#:	0.4	13.2	1,867.5	0.3	28.9 #	24 #	24 #	20 #
Minimum:	0.2	12.9	1,308.7	0.2	0.5	1	1	0
Maximum:	0.4	13.8	2,038.7	0.3	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/20/2015 00:00	0.4	13.1	1,978.5	0.3	1.3	1	1	1
01/20/2015 01:00	0.4	13.2	1,878.2	0.3	1.3	1	1	1
01/20/2015 02:00	0.4	13.2	1,882.2	0.3	1.3	1	1	1
01/20/2015 03:00	0.4	13.2	1,881.8	0.3	1.3	1	1	1
01/20/2015 04:00	0.4	13.2	1,883.4	0.3	1.3	1	1	1
01/20/2015 05:00	0.4	13.2	1,881.3	0.3	1.3	1	1	1
01/20/2015 06:00	0.5	12.9	2,029.5	0.3	1.7	1	1	1
01/20/2015 07:00	0.5	12.9	2,068.5	0.4	1.7	1	1	1
01/20/2015 08:00	0.5	12.8	2,079.8	0.4	1.7	1	1	1
01/20/2015 09:00	0.5	12.8	2,077.0	0.4	1.7	1	1	1
01/20/2015 10:00	0.5	12.9	2,048.4	0.4	1.7	1	1	1
01/20/2015 11:00	0.5	12.8	2,061.0	0.4	1.7	1	1	1
01/20/2015 12:00	0.5	12.7	2,066.4	0.4	1.7	1	1	1
01/20/2015 13:00	0.5	12.8	2,039.8	0.4	1.7	1	1	1
01/20/2015 14:00	0.4	12.8	2,039.0	0.4	1.3	1	1	1
01/20/2015 15:00	0.5	12.7	2,052.8	0.4	1.7	1	1	1
01/20/2015 16:00	0.4	13.2	1,911.3	0.3	1.3	1	1	1
01/20/2015 17:00	0.4	13.1	1,938.6	0.3	1.3	1	1	1
01/20/2015 18:00	0.5	12.7	2,071.3	0.3	1.7	1	1	1
01/20/2015 19:00	0.5	12.6	2,085.6	0.4	1.7	1	1	1
01/20/2015 20:00	0.5	12.8	2,043.3	0.4	1.7	1	1	1
01/20/2015 21:00	0.5	12.8	2,065.2	0.4	1.7	1	1	1
01/20/2015 22:00	0.5	13.0	2,019.1	0.4	1.7	1	1	1
01/20/2015 23:00	0.4	13.3	1,881.6	0.4	1.3	1	1	1
Average/Sum#:	0.5	12.9	1,998.5	0.4	36.8 #	24 #	24 #	24 #
Minimum:	0.4	12.6	1,878.2	0.3	1.3	1	1	1
Maximum:	0.5	13.3	2,085.6	0.4	1.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/21/2015 00:00	0.3	13.4	1,894.9	0.3	1.0	1	1	1
01/21/2015 01:00	0.3	13.5	1,884.1	0.2	1.0	1	1	1
01/21/2015 02:00	0.3	13.4	1,919.0	0.2	1.0	1	1	1
01/21/2015 03:00	0.3	13.4	1,876.6	0.2	1.0	1	1	1
01/21/2015 04:00	0.4	13.4	1,890.7	0.2	1.3	1	1	1
01/21/2015 05:00	0.4	13.2	1,887.1	0.3	1.3	1	1	1
01/21/2015 06:00	0.4	13.1	1,969.1	0.3	1.3	1	1	1
01/21/2015 07:00	0.5	13.0	2,031.5	0.3	1.7	1	1	1
01/21/2015 08:00	0.5	12.8	2,076.7	0.4	1.7	1	1	1
01/21/2015 09:00	0.5	12.8	2,051.3	0.4	1.7	1	1	1
01/21/2015 10:00	0.4	13.1	1,973.1	0.4	1.3	1	1	1
01/21/2015 11:00	0.4	13.1	1,972.6	0.3	1.3	1	1	1
01/21/2015 12:00	0.4	13.1	1,949.1	0.3	1.3	1	1	1
01/21/2015 13:00	0.4	13.3	1,890.3	0.3	1.3	1	1	1
01/21/2015 14:00	0.4	13.3	1,887.2	0.3	1.3	1	1	1
01/21/2015 15:00	0.4	13.1	1,954.9	0.3	1.3	1	1	1
01/21/2015 16:00	0.4	12.8	2,016.9	0.3	1.3	1	1	1
01/21/2015 17:00	0.5	12.8	2,042.6	0.3	1.7	1	1	1
01/21/2015 18:00	0.5	12.6	2,079.0	0.4	1.7	1	1	1
01/21/2015 19:00	0.5	12.7	2,073.2	0.4	1.7	1	1	1
01/21/2015 20:00	0.5	12.8	2,045.1	0.4	1.7	1	1	1
01/21/2015 21:00	0.5	12.9	2,033.8	0.4	1.7	1	1	1
01/21/2015 22:00	0.4	13.1	1,958.0	0.4	1.3	1	1	1
01/21/2015 23:00	0.3	13.6	1,572.1	0.3	0.9	1	1	1
Average/Sum#:	0.4	13.1	1,955.4	0.3	32.8 #	24 #	24 #	24 #
Minimum:	0.3	12.6	1,572.1	0.2	0.9	1	1	1
Maximum:	0.5	13.6	2,079.0	0.4	1.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/22/2015 00:00	0.2	13.8	1,407.9	0.2	0.5	1	1	0
01/22/2015 01:00	0.2	13.8	1,303.9	0.2	0.5	1	1	0
01/22/2015 02:00	0.2	13.8	1,315.9	0.2	0.5	1	1	0
01/22/2015 03:00	0.3	13.7	1,575.4	0.2	0.9	1	1	1
01/22/2015 04:00	0.5	13.2	1,904.1	0.3	1.6	1	1	1
01/22/2015 05:00	0.4	13.2	1,888.8	0.3	1.3	1	1	1
01/22/2015 06:00	0.5	13.1	1,956.7	0.4	1.7	1	1	1
01/22/2015 07:00	0.5	12.9	2,060.8	0.4	1.7	1	1	1
01/22/2015 08:00	0.5	13.0	2,030.0	0.4	1.7	1	1	1
01/22/2015 09:00	0.5	12.9	2,055.6	0.4	1.7	1	1	1
01/22/2015 10:00	0.4	13.2	1,896.3	0.4	1.3	1	1	1
01/22/2015 11:00	0.4	13.2	1,887.9	0.3	1.3	1	1	1
01/22/2015 12:00	0.4	13.2	1,891.5	0.3	1.3	1	1	1
01/22/2015 13:00	0.3	13.7	1,512.7	0.3	0.8	1	1	1
01/22/2015 14:00	0.2	13.8	1,649.9	0.2	0.6	1	1	0
01/22/2015 15:00	0.3	13.5	1,751.6	0.2	0.9	1	1	1
01/22/2015 16:00	0.4	13.2	1,895.4	0.2	1.3	1	1	1
01/22/2015 17:00	0.5	13.0	2,006.9	0.3	1.7	1	1	1
01/22/2015 18:00	0.5	12.8	2,081.1	0.4	1.7	1	1	1
01/22/2015 19:00	0.5	12.8	2,071.7	0.4	1.7	1	1	1
01/22/2015 20:00	0.5	13.0	2,034.4	0.4	1.7	1	1	1
01/22/2015 21:00	0.4	13.1	1,992.6	0.4	1.3	1	1	1
01/22/2015 22:00	0.4	13.2	1,966.2	0.3	1.3	1	1	1
01/22/2015 23:00	0.4	13.3	1,912.5	0.3	1.3	1	1	1
Average/Sum#:	0.4	13.3	1,835.4	0.3	30.3 #	24 #	24 #	20 #
Minimum:	0.2	12.8	1,303.9	0.2	0.5	1	1	0
Maximum:	0.5	13.8	2,081.1	0.4	1.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/23/2015 00:00	0.4	13.2	1,970.8	0.3	1.4	1	1	1
01/23/2015 01:00	0.3	13.4	1,928.1	0.3	1.0	1	1	1
01/23/2015 02:00	0.4	13.0	2,024.1	0.3	1.4	1	1	1
01/23/2015 03:00	0.4	13.0	2,002.3	0.3	1.3	1	1	1
01/23/2015 04:00	0.4	13.2	1,944.4	0.3	1.3	1	1	1
01/23/2015 05:00	0.4	13.2	1,934.5	0.3	1.3	1	1	1
01/23/2015 06:00	0.4	13.0	1,992.7	0.3	1.3	1	1	1
01/23/2015 07:00	0.5	12.9	2,060.6	0.3	1.7	1	1	1
01/23/2015 08:00	0.5	12.9	2,046.5	0.4	1.7	1	1	1
01/23/2015 09:00	0.4	13.2	1,954.6	0.4	1.3	1	1	1
01/23/2015 10:00	0.3	13.2	1,926.9	0.3	1.0	1	1	1
01/23/2015 11:00	0.3	13.3	1,885.6	0.2	1.0	1	1	1
01/23/2015 12:00	0.3	13.4	1,886.1	0.2	1.0	1	1	1
01/23/2015 13:00	0.3	13.3	1,883.8	0.2	1.0	1	1	1
01/23/2015 14:00	0.3	13.3	1,880.4	0.2	1.0	1	1	1
01/23/2015 15:00	0.3	13.2	1,896.7	0.2	1.0	1	1	1
01/23/2015 16:00	0.4	13.0	1,938.1	0.2	1.3	1	1	1
01/23/2015 17:00	0.4	13.0	1,950.0	0.3	1.3	1	1	1
01/23/2015 18:00	0.4	12.6	2,067.0	0.3	1.3	1	1	1
01/23/2015 19:00	0.4	12.5	2,091.4	0.3	1.3	1	1	1
01/23/2015 20:00	0.4	12.6	2,084.6	0.3	1.3	1	1	1
01/23/2015 21:00	0.4	12.7	2,047.6	0.3	1.3	1	1	1
01/23/2015 22:00	0.4	12.8	2,043.3	0.3	1.3	1	1	1
01/23/2015 23:00	0.3	13.1	1,936.4	0.3	1.0	1	1	1
Average/Sum#:	0.4	13.0	1,974.0	0.3	29.8 #	24 #	24 #	24 #
Minimum:	0.3	12.5	1,880.4	0.2	1.0	1	1	1
Maximum:	0.5	13.4	2,091.4	0.4	1.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/24/2015 00:00	0.3	13.4	1,885.1	0.2	1.0	1	1	1
01/24/2015 01:00	0.3	13.3	1,917.3	0.2	1.0	1	1	1
01/24/2015 02:00	0.4	13.4	1,885.8	0.2	1.3	1	1	1
01/24/2015 03:00	0.4	13.3	1,889.2	0.3	1.3	1	1	1
01/24/2015 04:00	0.4	13.0	1,979.2	0.3	1.3	1	1	1
01/24/2015 05:00	0.4	12.9	2,028.5	0.3	1.3	1	1	1
01/24/2015 06:00	0.5	12.8	2,024.7	0.3	1.7	1	1	1
01/24/2015 07:00	0.5	12.8	2,054.8	0.4	1.7	1	1	1
01/24/2015 08:00	0.4	13.1	1,973.9	0.4	1.3	1	1	1
01/24/2015 09:00	0.4	13.2	1,935.3	0.3	1.3	1	1	1
01/24/2015 10:00	0.4	13.3	1,879.4	0.3	1.3	1	1	1
01/24/2015 11:00	0.4	13.3	1,885.2	0.3	1.3	1	1	1
01/24/2015 12:00	0.3	13.3	1,876.1	0.3	1.0	1	1	1
01/24/2015 13:00	0.3	13.3	1,849.0	0.2	1.0	1	1	1
01/24/2015 14:00	0.1	13.9	1,308.9	0.2	0.2	1	1	0
01/24/2015 15:00	0.1	13.9	1,306.5	0.1	0.2	1	1	0
01/24/2015 16:00	0.1	13.9	1,447.2	0.1	0.3	1	1	0
01/24/2015 17:00	0.4	13.0	1,829.7	0.2	1.2	1	1	1
01/24/2015 18:00	0.4	12.3	2,098.9	0.2	1.3	1	1	1
01/24/2015 19:00	0.5	12.5	2,075.7	0.3	1.6	1	1	1
01/24/2015 20:00	0.5	12.8	2,027.5	0.4	1.7	1	1	1
01/24/2015 21:00	0.5	12.8	2,048.9	0.4	1.7	1	1	1
01/24/2015 22:00	0.5	12.8	2,063.1	0.4	1.7	1	1	1
01/24/2015 23:00	0.5	12.9	2,013.4	0.4	1.7	1	1	1
Average/Sum#:	0.4	13.1	1,886.8	0.3	29.4 #	24 #	24 #	21 #
Minimum:	0.1	12.3	1,306.5	0.1	0.2	1	1	0
Maximum:	0.5	13.9	2,098.9	0.4	1.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/25/2015 00:00	0.2	13.8	1,473.3	0.3	0.5	1	1	0
01/25/2015 01:00	13.9	15.7	647.0	0.0	5.7	1	0	0
01/25/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	7.1	14.8	1,060.2	0.3	6.2 #	2 #	1 #	0 #
Minimum:	0.2	13.8	647.0	0.3	0.5	0	0	0
Maximum:	13.9	15.7	1,473.3	0.3	5.7	1	1	0
%SI	91.7	91.7	91.7	95.8	91.7	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/26/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/27/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2015 02:00	76.2	17.4	507.7	0.0	127.0	1	0	0
01/27/2015 03:00	29.1	15.6	735.7	0.0	53.3	1	0	0
01/27/2015 04:00	30.9	16.6	443.8	0.0	9.3	1	0	0
01/27/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2015 07:00	11.2	18.0	416.6	0.0	7.0	1	0	0
01/27/2015 08:00	12.2	17.0	527.3	0.0	20.1	1	0	0
01/27/2015 09:00	20.2	17.3	523.9	0.0	14.4	1	0	0
01/27/2015 10:00	8.7	0.0	1,230.9	0.0	6.8	1	0	0
01/27/2015 11:00	0.2	0.0	1,300.1	0.0	0.2	1	1	0
01/27/2015 12:00	0.2	0.0	1,305.9	0.0	0.2	1	1	0
01/27/2015 13:00	0.1	13.8	1,555.0	0.0	0.3	1	1	0
01/27/2015 14:00	0.1	13.8	1,299.8	0.0	0.2	1	1	0
01/27/2015 15:00	0.2	13.7	1,570.7	0.1	0.6	1	1	1
01/27/2015 16:00	0.1	13.8	1,326.6	0.1	0.2	1	1	0
01/27/2015 17:00	0.3	13.5	1,653.6	0.2	0.9	1	1	1
01/27/2015 18:00	0.4	12.8	2,023.3	0.2	1.3	1	1	1
01/27/2015 19:00	0.4	12.9	2,013.8	0.3	1.3	1	1	1
01/27/2015 20:00	0.4	13.0	1,992.7	0.3	1.3	1	1	1
01/27/2015 21:00	0.4	13.0	1,992.8	0.3	1.3	1	1	1
01/27/2015 22:00	0.3	13.0	1,959.8	0.3	1.0	1	1	1
01/27/2015 23:00	0.2	13.6	1,557.6	0.2	0.6	1	1	1
Average/Sum#:	9.6	14.6	1,296.9	0.2	240.1 #	20 #	13 #	8 #
Minimum:	0.1	12.8	416.6	0.1	0.2	0	0	0
Maximum:	76.2	18.0	2,023.3	0.3	127.0	1	1	1
%SI	16.7	29.2	16.7	62.5	29.2	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/28/2015 00:00	0.1	13.9	1,281.1	0.2	0.2	1	1	0
01/28/2015 01:00	0.1	13.8	1,281.3	0.1	0.2	1	1	0
01/28/2015 02:00	0.1	13.8	1,275.8	0.1	0.2	1	1	0
01/28/2015 03:00	0.1	13.9	1,274.9	0.1	0.2	1	1	0
01/28/2015 04:00	0.1	13.8	1,283.6	0.1	0.2	1	1	0
01/28/2015 05:00	0.2	13.6	1,610.7	0.1	0.6	1	1	1
01/28/2015 06:00	0.3	13.3	1,879.4	0.2	1.0	1	1	1
01/28/2015 07:00	0.3	12.9	2,014.6	0.2	1.0	1	1	1
01/28/2015 08:00	0.3	13.3	1,892.4	0.2	1.0	1	1	1
01/28/2015 09:00	0.2	13.5	1,859.7	0.2	0.7	1	1	1
01/28/2015 10:00	0.2	13.5	1,857.1	0.2	0.7	1	1	1
01/28/2015 11:00	0.2	13.6	1,732.8	0.2	0.6	1	1	1
01/28/2015 12:00	0.1	13.9	1,272.7	0.2	0.2	1	1	0
01/28/2015 13:00	0.1	13.8	1,608.5	0.1	0.3	1	1	0
01/28/2015 14:00	0.2	13.3	1,843.2	0.1	0.6	1	1	1
01/28/2015 15:00	0.3	12.3	2,082.7	0.2	1.0	1	1	1
01/28/2015 16:00	0.3	12.7	2,017.7	0.2	1.0	1	1	1
01/28/2015 17:00	0.3	12.9	1,954.0	0.2	1.0	1	1	1
01/28/2015 18:00	0.3	12.7	2,020.5	0.2	1.0	1	1	1
01/28/2015 19:00	0.3	12.7	2,024.9	0.2	1.0	1	1	1
01/28/2015 20:00	0.3	13.0	1,954.0	0.2	1.0	1	1	1
01/28/2015 21:00	0.3	13.0	1,969.0	0.2	1.0	1	1	1
01/28/2015 22:00	0.3	13.1	1,941.3	0.2	1.0	1	1	1
01/28/2015 23:00	0.3	13.3	1,859.4	0.2	1.0	1	1	1
Average/Sum#:	0.2	13.3	1,741.3	0.2	16.7 #	24 #	24 #	17 #
Minimum:	0.1	12.3	1,272.7	0.1	0.2	1	1	0
Maximum:	0.3	13.9	2,082.7	0.2	1.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/29/2015 00:00	0.3	13.3	1,857.5	0.2	1.0	1	1	1
01/29/2015 01:00	0.3	13.2	1,861.6	0.2	1.0	1	1	1
01/29/2015 02:00	0.3	13.3	1,865.9	0.2	1.0	1	1	1
01/29/2015 03:00	0.3	13.2	1,860.1	0.2	1.0	1	1	1
01/29/2015 04:00	0.3	13.2	1,867.9	0.2	1.0	1	1	1
01/29/2015 05:00	0.3	13.2	1,860.0	0.2	1.0	1	1	1
01/29/2015 06:00	0.4	13.0	1,947.7	0.2	1.3	1	1	1
01/29/2015 07:00	0.4	12.9	2,038.0	0.3	1.3	1	1	1
01/29/2015 08:00	0.3	13.0	1,995.7	0.3	1.0	1	1	1
01/29/2015 09:00	0.3	13.0	1,987.3	0.2	1.0	1	1	1
01/29/2015 10:00	0.3	13.3	1,879.3	0.2	1.0	1	1	1
01/29/2015 11:00	0.2	13.5	1,855.3	0.2	0.7	1	1	1
01/29/2015 12:00	0.2	13.4	1,858.6	0.2	0.7	1	1	1
01/29/2015 13:00	0.2	13.4	1,855.4	0.2	0.7	1	1	1
01/29/2015 14:00	0.2	13.4	1,868.3	0.2	0.7	1	1	1
01/29/2015 15:00	0.3	12.5	2,046.6	0.2	1.0	1	1	1
01/29/2015 16:00	0.3	13.0	1,940.0	0.2	1.0	1	1	1
01/29/2015 17:00	0.3	13.2	1,901.0	0.2	1.0	1	1	1
01/29/2015 18:00	0.3	12.7	2,013.7	0.2	1.0	1	1	1
01/29/2015 19:00	0.3	12.6	2,035.8	0.2	1.0	1	1	1
01/29/2015 20:00	0.3	12.6	2,054.2	0.2	1.0	1	1	1
01/29/2015 21:00	0.3	12.9	1,989.1	0.2	1.0	1	1	1
01/29/2015 22:00	0.3	13.2	1,909.8	0.2	1.0	1	1	1
01/29/2015 23:00	0.3	13.3	1,858.9	0.2	1.0	1	1	1
Average/Sum#:	0.3	13.1	1,925.3	0.2	23.4 #	24 #	24 #	24 #
Minimum:	0.2	12.5	1,855.3	0.2	0.7	1	1	1
Maximum:	0.4	13.5	2,054.2	0.3	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/30/2015 00:00	0.3	13.3	1,864.5	0.2	1.0	1	1	1
01/30/2015 01:00	0.3	13.3	1,863.3	0.2	1.0	1	1	1
01/30/2015 02:00	0.3	13.3	1,862.1	0.2	1.0	1	1	1
01/30/2015 03:00	0.3	13.3	1,861.1	0.2	1.0	1	1	1
01/30/2015 04:00	0.3	13.3	1,864.1	0.2	1.0	1	1	1
01/30/2015 05:00	0.3	13.3	1,867.7	0.2	1.0	1	1	1
01/30/2015 06:00	0.3	13.2	1,910.6	0.2	1.0	1	1	1
01/30/2015 07:00	0.4	12.9	2,001.3	0.2	1.3	1	1	1
01/30/2015 08:00	0.3	12.9	1,999.4	0.2	1.0	1	1	1
01/30/2015 09:00	0.3	13.1	1,939.8	0.2	1.0	1	1	1
01/30/2015 10:00	0.2	13.3	1,876.1	0.2	0.7	1	1	1
01/30/2015 11:00	0.2	13.4	1,852.2	0.2	0.7	1	1	1
01/30/2015 12:00	0.1	13.7	1,626.0	0.2	0.3	1	1	1
01/30/2015 13:00	0.3	13.1	1,910.8	0.2	1.0	1	1	1
01/30/2015 14:00	0.3	13.0	1,922.4	0.2	1.0	1	1	1
01/30/2015 15:00	0.3	13.0	1,913.5	0.2	1.0	1	1	1
01/30/2015 16:00	0.3	12.7	1,993.1	0.2	1.0	1	1	1
01/30/2015 17:00	0.3	13.2	1,890.1	0.2	1.0	1	1	1
01/30/2015 18:00	0.3	13.3	1,870.1	0.2	1.0	1	1	1
01/30/2015 19:00	0.3	13.4	1,863.0	0.2	1.0	1	1	1
01/30/2015 20:00	0.3	13.4	1,867.6	0.2	1.0	1	1	1
01/30/2015 21:00	0.3	13.4	1,867.1	0.2	1.0	1	1	1
01/30/2015 22:00	0.2	13.6	1,694.5	0.2	0.6	1	1	1
01/30/2015 23:00	0.0	13.9	1,277.0	0.1	0.0	1	1	0
Average/Sum#:	0.3	13.3	1,852.4	0.2	21.6 #	24 #	24 #	23 #
Minimum:	0.0	12.7	1,277.0	0.1	0.0	1	1	0
Maximum:	0.4	13.9	2,001.3	0.2	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/31/2015 00:00	0.1	13.8	1,684.7	0.1	0.3	1	1	0
01/31/2015 01:00	0.1	13.9	1,790.4	0.1	0.3	1	1	0
01/31/2015 02:00	0.1	13.9	1,791.2	0.1	0.3	1	1	0
01/31/2015 03:00	0.1	13.9	1,708.9	0.1	0.3	1	1	0
01/31/2015 04:00	0.1	13.9	1,329.1	0.1	0.3	1	1	0
01/31/2015 05:00	0.2	13.6	1,766.0	0.1	0.6	1	1	1
01/31/2015 06:00	0.3	13.4	1,869.9	0.2	1.0	1	1	1
01/31/2015 07:00	0.3	13.4	1,872.8	0.2	1.0	1	1	1
01/31/2015 08:00	0.3	13.4	1,870.8	0.2	1.0	1	1	1
01/31/2015 09:00	0.3	13.4	1,867.2	0.2	1.0	1	1	1
01/31/2015 10:00	0.3	13.4	1,868.2	0.2	1.0	1	1	1
01/31/2015 11:00	0.0	13.9	1,366.2	0.1	0.0	1	1	0
01/31/2015 12:00	0.0	13.9	1,299.9	0.1	0.0	1	1	0
01/31/2015 13:00	0.0	13.9	1,330.0	0.0	0.0	1	1	0
01/31/2015 14:00	0.1	13.9	1,520.8	0.0	0.3	1	1	0
01/31/2015 15:00	0.1	13.9	1,672.6	0.1	0.3	1	1	1
01/31/2015 16:00	0.2	13.7	1,701.5	0.1	0.6	1	1	1
01/31/2015 17:00	0.1	13.7	1,593.3	0.1	0.3	1	1	1
01/31/2015 18:00	0.3	12.6	2,023.9	0.2	1.0	1	1	1
01/31/2015 19:00	0.3	12.5	2,040.8	0.2	1.0	1	1	1
01/31/2015 20:00	0.3	12.5	2,046.5	0.2	1.0	1	1	1
01/31/2015 21:00	0.3	12.5	2,055.4	0.2	1.0	1	1	1
01/31/2015 22:00	0.3	12.6	2,051.5	0.2	1.0	1	1	1
01/31/2015 23:00	0.3	13.1	1,965.6	0.2	1.0	1	1	1
Average/Sum#:	0.2	13.4	1,753.6	0.1	14.6 #	24 #	24 #	15 #
Minimum:	0.0	12.5	1,299.9	0.0	0.0	1	1	0
Maximum:	0.3	13.9	2,055.4	0.2	1.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/01/2015 00:00	0.4	12.8	2,023.1	0.2	1.3	1	1	1
02/01/2015 01:00	0.1	13.7	1,626.2	0.2	0.3	1	1	1
02/01/2015 02:00	11.8	15.7	598.6	0.0	3.9	1	0	0
02/01/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2015 14:00	15.0	17.5	486.5	0.0	18.4	1	0	0
02/01/2015 15:00	13.1	14.5	1,147.9	0.0	31.0	1	0	0
02/01/2015 16:00	0.2	13.4	1,781.9	0.0	0.6	1	1	1
02/01/2015 17:00	0.3	13.2	1,910.7	0.0	1.0	1	1	1
02/01/2015 18:00	0.3	12.8	2,004.9	0.2	1.0	1	1	1
02/01/2015 19:00	0.4	12.6	2,037.3	0.2	1.3	1	1	1
02/01/2015 20:00	0.3	12.6	2,045.1	0.2	1.0	1	1	1
02/01/2015 21:00	0.3	12.7	2,027.2	0.2	1.0	1	1	1
02/01/2015 22:00	0.3	13.1	1,939.9	0.2	1.0	1	1	1
02/01/2015 23:00	0.2	13.2	1,852.3	0.2	0.6	1	1	1
Average/Sum#:	3.3	13.7	1,652.4	0.2	62.4 #	13 #	10 #	10 #
Minimum:	0.1	12.6	486.5	0.2	0.3	0	0	0
Maximum:	15.0	17.5	2,045.1	0.2	31.0	1	1	1
%SI	45.8	45.8	45.8	66.7	45.8	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/02/2015 00:00	0.3	13.2	1,867.1	0.2	1.0	1	1	1
02/02/2015 01:00	0.4	12.8	2,011.0	0.2	1.3	1	1	1
02/02/2015 02:00	0.3	13.0	1,965.7	0.2	1.0	1	1	1
02/02/2015 03:00	0.2	13.2	1,869.5	0.2	0.6	1	1	1
02/02/2015 04:00	0.3	13.2	1,860.0	0.2	1.0	1	1	1
02/02/2015 05:00	0.3	13.2	1,886.8	0.2	1.0	1	1	1
02/02/2015 06:00	0.3	13.2	1,924.5	0.2	1.0	1	1	1
02/02/2015 07:00	0.3	13.0	1,981.7	0.2	1.0	1	1	1
02/02/2015 08:00	0.2	13.2	1,865.5	0.2	0.6	1	1	1
02/02/2015 09:00	0.3	13.2	1,858.2	0.2	1.0	1	1	1
02/02/2015 10:00	0.2	13.3	1,855.9	0.2	0.6	1	1	1
02/02/2015 11:00	0.2	13.3	1,868.8	0.2	0.6	1	1	1
02/02/2015 12:00	0.3	13.1	1,922.0	0.2	1.0	1	1	1
02/02/2015 13:00	0.2	13.3	1,866.9	0.2	0.6	1	1	1
02/02/2015 14:00	0.2	13.3	1,848.2	0.2	0.6	1	1	1
02/02/2015 15:00	0.2	13.3	1,848.8	0.2	0.6	1	1	1
02/02/2015 16:00	0.3	13.1	1,913.6	0.2	1.0	1	1	1
02/02/2015 17:00	0.3	13.0	1,945.8	0.2	1.0	1	1	1
02/02/2015 18:00	0.4	12.7	2,025.3	0.2	1.3	1	1	1
02/02/2015 19:00	0.3	12.7	2,021.5	0.2	1.0	1	1	1
02/02/2015 20:00	0.4	12.7	2,027.5	0.3	1.3	1	1	1
02/02/2015 21:00	0.3	12.9	1,980.5	0.2	1.0	1	1	1
02/02/2015 22:00	0.3	13.0	1,925.8	0.2	1.0	1	1	1
02/02/2015 23:00	0.2	13.2	1,842.7	0.2	0.6	1	1	1
Average/Sum#:	0.3	13.1	1,916.0	0.2	21.7 #	24 #	24 #	24 #
Minimum:	0.2	12.7	1,842.7	0.2	0.6	1	1	1
Maximum:	0.4	13.3	2,027.5	0.3	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/03/2015 00:00	0.1	13.8	1,331.7	0.2	0.2	1	1	0
02/03/2015 01:00	0.1	13.8	1,289.7	0.1	0.2	1	1	0
02/03/2015 02:00	0.1	13.8	1,291.0	0.1	0.2	1	1	0
02/03/2015 03:00	0.1	13.8	1,368.6	0.1	0.3	1	1	0
02/03/2015 04:00	0.2	13.5	1,706.1	0.1	0.6	1	1	1
02/03/2015 05:00	0.3	13.2	1,854.4	0.2	1.0	1	1	1
02/03/2015 06:00	0.3	13.2	1,880.7	0.2	1.0	1	1	1
02/03/2015 07:00	0.3	13.2	1,846.9	0.2	1.0	1	1	1
02/03/2015 08:00	0.3	13.2	1,849.7	0.2	1.0	1	1	1
02/03/2015 09:00	0.3	13.2	1,852.7	0.2	1.0	1	1	1
02/03/2015 10:00	0.2	13.4	1,678.9	0.2	0.6	1	1	1
02/03/2015 11:00	0.0	13.8	1,264.1	0.1	0.0	1	1	0
02/03/2015 12:00	0.0	13.8	1,301.0	0.1	0.0	1	1	0
02/03/2015 13:00	0.1	13.8	1,359.7	0.0	0.3	1	1	0
02/03/2015 14:00	0.1	13.8	1,698.6	0.1	0.3	1	1	0
02/03/2015 15:00	0.1	13.8	1,576.5	0.1	0.3	1	1	0
02/03/2015 16:00	0.2	13.5	1,641.0	0.1	0.6	1	1	1
02/03/2015 17:00	0.3	13.2	1,890.8	0.2	1.0	1	1	1
02/03/2015 18:00	0.4	12.5	2,047.3	0.2	1.3	1	1	1
02/03/2015 19:00	0.3	12.7	2,009.1	0.2	1.0	1	1	1
02/03/2015 20:00	0.3	12.8	1,996.4	0.2	1.0	1	1	1
02/03/2015 21:00	0.3	13.0	1,943.6	0.2	1.0	1	1	1
02/03/2015 22:00	0.3	13.0	1,820.2	0.2	0.9	1	1	1
02/03/2015 23:00	0.0	13.8	1,316.7	0.1	0.0	1	1	0
Average/Sum#:	0.2	13.4	1,659.0	0.2	14.8 #	24 #	24 #	14 #
Minimum:	0.0	12.5	1,264.1	0.0	0.0	1	1	0
Maximum:	0.4	13.8	2,047.3	0.2	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/04/2015 00:00	0.1	13.8	1,692.4	0.1	0.3	1	1	0
02/04/2015 01:00	0.1	13.8	1,488.5	0.1	0.3	1	1	0
02/04/2015 02:00	0.1	13.8	1,286.8	0.1	0.2	1	1	0
02/04/2015 03:00	0.1	13.8	1,290.3	0.1	0.2	1	1	0
02/04/2015 04:00	0.1	13.8	1,386.6	0.1	0.3	1	1	0
02/04/2015 05:00	0.2	13.5	1,611.9	0.1	0.6	1	1	1
02/04/2015 06:00	0.3	13.1	1,915.4	0.2	1.0	1	1	1
02/04/2015 07:00	0.3	13.2	1,896.3	0.2	1.0	1	1	1
02/04/2015 08:00	0.1	13.8	1,324.6	0.2	0.2	1	1	0
02/04/2015 09:00	0.1	13.8	1,291.7	0.1	0.2	1	1	0
02/04/2015 10:00	0.1	13.8	1,293.6	0.1	0.2	1	1	0
02/04/2015 11:00	0.1	13.8	1,294.7	0.1	0.2	1	1	0
02/04/2015 12:00	0.1	13.8	1,294.4	0.1	0.2	1	1	0
02/04/2015 13:00	0.1	13.8	1,294.7	0.1	0.2	1	1	0
02/04/2015 14:00	0.1	13.8	1,295.7	0.1	0.2	1	1	0
02/04/2015 15:00	0.1	13.8	1,354.0	0.1	0.3	1	1	0
02/04/2015 16:00	0.4	13.2	1,867.2	0.2	1.3	1	1	1
02/04/2015 17:00	0.4	13.0	1,940.3	0.2	1.3	1	1	1
02/04/2015 18:00	0.4	12.5	2,037.2	0.3	1.3	1	1	1
02/04/2015 19:00	0.4	12.6	2,020.9	0.3	1.3	1	1	1
02/04/2015 20:00	0.4	12.7	2,000.1	0.3	1.3	1	1	1
02/04/2015 21:00	0.4	12.7	2,018.0	0.3	1.3	1	1	1
02/04/2015 22:00	0.4	12.8	1,979.2	0.3	1.3	1	1	1
02/04/2015 23:00	0.2	13.5	1,556.6	0.3	0.6	1	1	1
Average/Sum#:	0.2	13.4	1,601.3	0.2	15.3 #	24 #	24 #	11 #
Minimum:	0.1	12.5	1,286.8	0.1	0.2	1	1	0
Maximum:	0.4	13.8	2,037.2	0.3	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/05/2015 00:00	0.1	13.8	1,286.3	0.2	0.2	1	1	0
02/05/2015 01:00	0.1	13.8	1,288.3	0.1	0.2	1	1	0
02/05/2015 02:00	0.1	13.8	1,292.2	0.1	0.2	1	1	0
02/05/2015 03:00	0.1	13.8	1,292.2	0.1	0.2	1	1	0
02/05/2015 04:00	0.1	13.8	1,419.6	0.1	0.3	1	1	0
02/05/2015 05:00	0.2	13.6	1,594.8	0.1	0.6	1	1	1
02/05/2015 06:00	0.4	13.1	1,907.2	0.2	1.3	1	1	1
02/05/2015 07:00	0.4	13.0	1,954.5	0.3	1.3	1	1	1
02/05/2015 08:00	0.1	13.7	1,424.7	0.2	0.3	1	1	1
02/05/2015 09:00	0.1	13.8	1,288.0	0.2	0.2	1	1	0
02/05/2015 10:00	0.1	13.8	1,301.5	0.1	0.2	1	1	0
02/05/2015 11:00	0.1	13.8	1,325.4	0.1	0.2	1	1	0
02/05/2015 12:00	0.1	13.8	1,352.8	0.1	0.3	1	1	0
02/05/2015 13:00	0.1	13.8	1,599.2	0.1	0.3	1	1	0
02/05/2015 14:00	0.1	13.8	1,658.1	0.1	0.3	1	1	0
02/05/2015 15:00	0.1	13.9	1,610.4	0.1	0.3	1	1	0
02/05/2015 16:00	0.3	13.3	1,844.4	0.1	1.0	1	1	1
02/05/2015 17:00	0.3	13.2	1,877.5	0.2	1.0	1	1	1
02/05/2015 18:00	0.5	12.8	1,994.4	0.3	1.6	1	1	1
02/05/2015 19:00	0.4	12.9	1,974.3	0.3	1.3	1	1	1
02/05/2015 20:00	0.4	12.8	1,991.3	0.3	1.3	1	1	1
02/05/2015 21:00	0.4	12.9	1,956.9	0.3	1.3	1	1	1
02/05/2015 22:00	0.1	13.8	1,456.7	0.2	0.3	1	1	0
02/05/2015 23:00	0.1	13.8	1,287.3	0.2	0.2	1	1	0
Average/Sum#:	0.2	13.5	1,582.4	0.2	14.4 #	24 #	24 #	10 #
Minimum:	0.1	12.8	1,286.3	0.1	0.2	1	1	0
Maximum:	0.5	13.9	1,994.4	0.3	1.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/06/2015 00:00	0.1	13.8	1,301.6	0.1	0.2	1	1	0
02/06/2015 01:00	0.1	13.8	1,290.9	0.1	0.2	1	1	0
02/06/2015 02:00	0.1	13.8	1,283.6	0.1	0.2	1	1	0
02/06/2015 03:00	0.1	13.8	1,287.9	0.1	0.2	1	1	0
02/06/2015 04:00	0.2	13.9	1,333.5	0.1	0.5	1	1	0
02/06/2015 05:00	0.4	13.3	1,787.5	0.2	1.2	1	1	1
02/06/2015 06:00	0.5	12.8	1,932.7	0.3	1.6	1	1	1
02/06/2015 07:00	0.4	13.1	1,905.9	0.3	1.3	1	1	1
02/06/2015 08:00	0.3	13.3	1,847.7	0.3	1.0	1	1	1
02/06/2015 09:00	0.1	13.7	1,649.9	0.2	0.3	1	1	1
02/06/2015 10:00	0.3	13.3	1,829.2	0.2	1.0	1	1	1
02/06/2015 11:00	0.3	13.3	1,850.2	0.2	1.0	1	1	1
02/06/2015 12:00	0.2	13.7	1,604.6	0.2	0.6	1	1	1
02/06/2015 13:00	0.3	13.2	1,855.2	0.2	1.0	1	1	1
02/06/2015 14:00	0.3	13.2	1,848.4	0.2	1.0	1	1	1
02/06/2015 15:00	0.3	13.3	1,851.3	0.2	1.0	1	1	1
02/06/2015 16:00	0.3	13.2	1,881.7	0.2	1.0	1	1	1
02/06/2015 17:00	0.4	12.6	2,008.5	0.2	1.3	1	1	1
02/06/2015 18:00	0.3	12.3	2,049.4	0.2	0.9	1	1	1
02/06/2015 19:00	0.3	12.5	2,008.1	0.2	0.9	1	1	1
02/06/2015 20:00	0.3	12.4	2,033.9	0.2	0.9	1	1	1
02/06/2015 21:00	0.3	13.0	1,904.6	0.2	1.0	1	1	1
02/06/2015 22:00	0.1	13.8	1,371.6	0.2	0.3	1	1	0
02/06/2015 23:00	0.1	13.8	1,585.6	0.1	0.3	1	1	0
Average/Sum#:	0.3	13.3	1,721.0	0.2	18.9 #	24 #	24 #	17 #
Minimum:	0.1	12.3	1,283.6	0.1	0.2	1	1	0
Maximum:	0.5	13.9	2,049.4	0.3	1.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/07/2015 00:00	0.1	13.8	1,310.3	0.1	0.2	1	1	0
02/07/2015 01:00	0.1	13.8	1,444.0	0.1	0.3	1	1	0
02/07/2015 02:00	0.1	13.9	1,394.7	0.1	0.3	1	1	0
02/07/2015 03:00	0.1	13.9	1,341.8	0.1	0.3	1	1	0
02/07/2015 04:00	0.1	13.9	1,344.2	0.1	0.3	1	1	0
02/07/2015 05:00	0.1	13.9	1,328.8	0.1	0.3	1	1	0
02/07/2015 06:00	0.1	13.9	1,330.4	0.1	0.3	1	1	0
02/07/2015 07:00	0.1	13.8	1,314.2	0.1	0.2	1	1	0
02/07/2015 08:00	0.1	13.8	1,285.5	0.1	0.2	1	1	0
02/07/2015 09:00	0.1	13.8	1,304.4	0.1	0.2	1	1	0
02/07/2015 10:00	0.1	13.8	1,353.4	0.1	0.3	1	1	0
02/07/2015 11:00	0.1	13.8	1,333.4	0.1	0.2	1	1	0
02/07/2015 12:00	0.1	13.8	1,293.5	0.1	0.2	1	1	0
02/07/2015 13:00	0.1	13.8	1,299.9	0.1	0.2	1	1	0
02/07/2015 14:00	0.1	13.8	1,342.0	0.1	0.2	1	1	0
02/07/2015 15:00	0.1	13.8	1,319.2	0.1	0.2	1	1	0
02/07/2015 16:00	0.2	13.5	1,642.3	0.1	0.6	1	1	1
02/07/2015 17:00	0.3	13.1	1,883.7	0.2	1.0	1	1	1
02/07/2015 18:00	0.4	12.4	2,040.2	0.2	1.3	1	1	1
02/07/2015 19:00	0.3	12.8	1,951.8	0.2	1.0	1	1	1
02/07/2015 20:00	0.4	12.5	2,019.7	0.3	1.3	1	1	1
02/07/2015 21:00	0.2	13.4	1,725.2	0.2	0.6	1	1	1
02/07/2015 22:00	0.1	13.8	1,382.4	0.2	0.3	1	1	0
02/07/2015 23:00	0.1	13.8	1,285.1	0.1	0.2	1	1	0
Average/Sum#:	0.2	13.6	1,469.6	0.1	10.2 #	24 #	24 #	6 #
Minimum:	0.1	12.4	1,285.1	0.1	0.2	1	1	0
Maximum:	0.4	13.9	2,040.2	0.3	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/08/2015 00:00	0.1	13.8	1,308.0	0.1	0.2	1	1	0
02/08/2015 01:00	0.1	13.8	1,341.8	0.1	0.2	1	1	0
02/08/2015 02:00	0.1	13.8	1,335.8	0.1	0.2	1	1	0
02/08/2015 03:00	0.1	13.8	1,289.7	0.1	0.2	1	1	0
02/08/2015 04:00	0.1	13.8	1,288.7	0.1	0.2	1	1	0
02/08/2015 05:00	0.1	13.8	1,285.6	0.1	0.2	1	1	0
02/08/2015 06:00	0.1	13.8	1,326.6	0.1	0.2	1	1	0
02/08/2015 07:00	0.1	13.8	1,312.4	0.1	0.2	1	1	0
02/08/2015 08:00	0.1	13.8	1,283.3	0.1	0.2	1	1	0
02/08/2015 09:00	0.1	13.8	1,285.3	0.1	0.2	1	1	0
02/08/2015 10:00	0.1	13.8	1,285.8	0.1	0.2	1	1	0
02/08/2015 11:00	0.1	13.8	1,288.9	0.1	0.2	1	1	0
02/08/2015 12:00	0.1	13.8	1,314.7	0.1	0.2	1	1	0
02/08/2015 13:00	0.1	13.8	1,322.9	0.1	0.2	1	1	0
02/08/2015 14:00	0.1	13.8	1,297.0	0.1	0.2	1	1	0
02/08/2015 15:00	0.1	13.8	1,297.8	0.1	0.2	1	1	0
02/08/2015 16:00	0.3	13.2	1,826.9	0.1	0.9	1	1	1
02/08/2015 17:00	0.3	13.0	1,922.9	0.2	1.0	1	1	1
02/08/2015 18:00	0.4	12.3	2,049.0	0.2	1.3	1	1	1
02/08/2015 19:00	0.3	12.6	2,005.3	0.2	1.0	1	1	1
02/08/2015 20:00	0.3	12.5	2,029.4	0.2	1.0	1	1	1
02/08/2015 21:00	0.2	13.0	1,779.0	0.2	0.6	1	1	1
02/08/2015 22:00	0.0	13.9	1,332.4	0.1	0.0	1	1	0
02/08/2015 23:00	0.1	13.8	1,525.9	0.1	0.3	1	1	0
Average/Sum#:	0.1	13.5	1,472.3	0.1	9.3 #	24 #	24 #	6 #
Minimum:	0.0	12.3	1,283.3	0.1	0.0	1	1	0
Maximum:	0.4	13.9	2,049.0	0.2	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/09/2015 00:00	0.1	13.8	1,308.4	0.1	0.2	1	1	0
02/09/2015 01:00	0.1	13.9	1,317.1	0.1	0.2	1	1	0
02/09/2015 02:00	0.1	13.8	1,285.9	0.1	0.2	1	1	0
02/09/2015 03:00	0.1	13.8	1,286.0	0.1	0.2	1	1	0
02/09/2015 04:00	0.1	13.8	1,286.3	0.1	0.2	1	1	0
02/09/2015 05:00	0.1	13.9	1,320.7	0.1	0.2	1	1	0
02/09/2015 06:00	0.3	13.1	1,733.5	0.1	0.9	1	1	1
02/09/2015 07:00	0.3	13.2	1,857.6	0.2	1.0	1	1	1
02/09/2015 08:00	0.3	13.3	1,854.4	0.2	1.0	1	1	1
02/09/2015 09:00	0.1	13.6	1,456.6	0.2	0.3	1	1	1
02/09/2015 10:00	0.0	13.8	1,289.5	0.1	0.0	1	1	0
02/09/2015 11:00	0.1	13.8	1,288.4	0.1	0.2	1	1	0
02/09/2015 12:00	0.1	13.8	1,287.0	0.1	0.2	1	1	0
02/09/2015 13:00	0.1	13.8	1,288.7	0.1	0.2	1	1	0
02/09/2015 14:00	0.1	13.8	1,291.2	0.1	0.2	1	1	0
02/09/2015 15:00	0.1	13.8	1,289.4	0.1	0.2	1	1	0
02/09/2015 16:00	0.1	13.8	1,288.8	0.1	0.2	1	1	0
02/09/2015 17:00	0.2	13.4	1,757.4	0.1	0.6	1	1	1
02/09/2015 18:00	0.3	13.2	1,845.0	0.2	0.9	1	1	1
02/09/2015 19:00	0.3	13.2	1,863.7	0.2	1.0	1	1	1
02/09/2015 20:00	0.3	13.3	1,886.6	0.2	1.0	1	1	1
02/09/2015 21:00	0.1	13.6	1,635.6	0.2	0.3	1	1	1
02/09/2015 22:00	0.1	13.8	1,326.3	0.1	0.2	1	1	0
02/09/2015 23:00	0.1	13.8	1,319.4	0.1	0.2	1	1	0
Average/Sum#:	0.2	13.6	1,473.5	0.1	9.8 #	24 #	24 #	9 #
Minimum:	0.0	13.1	1,285.9	0.1	0.0	1	1	0
Maximum:	0.3	13.9	1,886.6	0.2	1.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/10/2015 00:00	0.1	13.8	1,294.3	0.1	0.2	1	1	0
02/10/2015 01:00	0.1	13.8	1,298.3	0.1	0.2	1	1	0
02/10/2015 02:00	0.1	13.8	1,291.9	0.1	0.2	1	1	0
02/10/2015 03:00	0.1	13.8	1,295.5	0.1	0.2	1	1	0
02/10/2015 04:00	0.1	13.8	1,299.2	0.1	0.2	1	1	0
02/10/2015 05:00	0.1	13.8	1,331.7	0.1	0.2	1	1	0
02/10/2015 06:00	0.3	13.2	1,899.2	0.1	1.0	1	1	1
02/10/2015 07:00	0.3	13.1	1,939.1	0.2	1.0	1	1	1
02/10/2015 08:00	0.1	13.6	1,523.9	0.2	0.3	1	1	1
02/10/2015 09:00	0.0	13.8	1,296.8	0.1	0.0	1	1	0
02/10/2015 10:00	0.1	13.8	1,294.6	0.1	0.2	1	1	0
02/10/2015 11:00	0.1	13.8	1,296.8	0.1	0.2	1	1	0
02/10/2015 12:00	0.1	13.8	1,297.1	0.1	0.2	1	1	0
02/10/2015 13:00	0.1	13.8	1,294.3	0.1	0.2	1	1	0
02/10/2015 14:00	0.1	13.8	1,295.4	0.1	0.2	1	1	0
02/10/2015 15:00	0.1	13.8	1,296.7	0.1	0.2	1	1	0
02/10/2015 16:00	0.3	13.2	1,847.6	0.1	1.0	1	1	1
02/10/2015 17:00	0.4	12.7	1,999.1	0.2	1.3	1	1	1
02/10/2015 18:00	0.4	12.5	2,045.6	0.3	1.3	1	1	1
02/10/2015 19:00	0.3	12.5	2,050.8	0.3	1.0	1	1	1
02/10/2015 20:00	0.3	12.6	2,036.2	0.2	1.0	1	1	1
02/10/2015 21:00	0.3	12.8	1,983.4	0.2	1.0	1	1	1
02/10/2015 22:00	0.3	12.6	2,033.5	0.2	1.0	1	1	1
02/10/2015 23:00	0.3	12.8	2,026.5	0.2	1.0	1	1	1
Average/Sum#:	0.2	13.4	1,594.5	0.1	13.3 #	24 #	24 #	11 #
Minimum:	0.0	12.5	1,291.9	0.1	0.0	1	1	0
Maximum:	0.4	13.8	2,050.8	0.3	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/11/2015 00:00	0.3	12.7	2,029.4	0.2	1.0	1	1	1
02/11/2015 01:00	0.2	13.2	1,908.5	0.2	0.7	1	1	1
02/11/2015 02:00	0.2	13.2	1,847.6	0.2	0.6	1	1	1
02/11/2015 03:00	0.2	13.2	1,849.2	0.2	0.6	1	1	1
02/11/2015 04:00	0.2	13.2	1,848.2	0.2	0.6	1	1	1
02/11/2015 05:00	0.3	13.2	1,875.1	0.2	1.0	1	1	1
02/11/2015 06:00	0.3	13.0	1,928.7	0.2	1.0	1	1	1
02/11/2015 07:00	0.2	13.2	1,863.2	0.2	0.6	1	1	1
02/11/2015 08:00	0.2	13.3	1,851.6	0.2	0.6	1	1	1
02/11/2015 09:00	0.2	13.2	1,855.1	0.2	0.6	1	1	1
02/11/2015 10:00	0.1	13.5	1,592.2	0.2	0.3	1	1	1
02/11/2015 11:00	0.0	13.8	1,445.6	0.1	0.0	1	1	0
02/11/2015 12:00	0.0	13.8	1,491.3	0.0	0.0	1	1	0
02/11/2015 13:00	0.0	13.8	1,292.8	0.0	0.0	1	1	0
02/11/2015 14:00	0.0	13.8	1,296.3	0.0	0.0	1	1	0
02/11/2015 15:00	0.2	13.6	1,549.5	0.1	0.6	1	1	1
02/11/2015 16:00	0.3	13.2	1,886.2	0.1	1.0	1	1	1
02/11/2015 17:00	0.3	13.0	1,945.4	0.2	1.0	1	1	1
02/11/2015 18:00	0.4	12.5	2,046.0	0.2	1.3	1	1	1
02/11/2015 19:00	0.3	12.7	2,014.5	0.2	1.0	1	1	1
02/11/2015 20:00	0.3	12.7	2,019.9	0.2	1.0	1	1	1
02/11/2015 21:00	0.3	12.9	1,979.9	0.2	1.0	1	1	1
02/11/2015 22:00	0.3	12.8	1,989.0	0.2	1.0	1	1	1
02/11/2015 23:00	0.2	13.2	1,860.5	0.2	0.6	1	1	1
Average/Sum#:	0.2	13.2	1,802.7	0.2	16.1 #	24 #	24 #	20 #
Minimum:	0.0	12.5	1,292.8	0.0	0.0	1	1	0
Maximum:	0.4	13.8	2,046.0	0.2	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/12/2015 00:00	0.1	13.7	1,408.9	0.2	0.3	1	1	1
02/12/2015 01:00	0.0	13.8	1,367.0	0.1	0.0	1	1	0
02/12/2015 02:00	0.1	13.8	1,302.4	0.1	0.2	1	1	0
02/12/2015 03:00	0.1	13.8	1,477.7	0.1	0.3	1	1	0
02/12/2015 04:00	0.2	13.5	1,600.3	0.1	0.6	1	1	1
02/12/2015 05:00	0.3	13.2	1,911.6	0.2	1.0	1	1	1
02/12/2015 06:00	0.3	13.0	1,920.6	0.2	1.0	1	1	1
02/12/2015 07:00	0.3	13.0	1,935.8	0.2	1.0	1	1	1
02/12/2015 08:00	0.1	13.6	1,559.1	0.2	0.3	1	1	1
02/12/2015 09:00	0.0	13.8	1,289.9	0.1	0.0	1	1	0
02/12/2015 10:00	0.0	13.8	1,290.9	0.0	0.0	1	1	0
02/12/2015 11:00	0.0	13.8	1,292.3	0.0	0.0	1	1	0
02/12/2015 12:00	0.0	13.8	1,296.2	0.0	0.0	1	1	0
02/12/2015 13:00	0.1	13.7	1,671.8	0.0	0.3	1	1	1
02/12/2015 14:00	0.4	12.6	2,000.3	0.1	1.3	1	1	1
02/12/2015 15:00	0.2	13.0	1,891.8	0.2	0.6	1	1	1
02/12/2015 16:00	0.3	12.9	1,923.5	0.2	1.0	1	1	1
02/12/2015 17:00	0.3	12.7	1,980.2	0.2	1.0	1	1	1
02/12/2015 18:00	0.3	12.4	2,039.8	0.2	1.0	1	1	1
02/12/2015 19:00	0.3	12.4	2,049.6	0.2	1.0	1	1	1
02/12/2015 20:00	0.3	12.5	2,039.3	0.2	1.0	1	1	1
02/12/2015 21:00	0.3	12.9	1,965.9	0.2	1.0	1	1	1
02/12/2015 22:00	0.3	12.7	1,999.9	0.2	1.0	1	1	1
02/12/2015 23:00	0.1	13.7	1,618.0	0.2	0.3	1	1	1
Average/Sum#:	0.2	13.3	1,701.4	0.1	14.2 #	24 #	24 #	17 #
Minimum:	0.0	12.4	1,289.9	0.0	0.0	1	1	0
Maximum:	0.4	13.8	2,049.6	0.2	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/13/2015 00:00	0.0	13.8	1,719.9	0.1	0.0	1	1	0
02/13/2015 01:00	0.0	13.8	1,478.9	0.0	0.0	1	1	0
02/13/2015 02:00	0.1	13.8	1,472.0	0.0	0.3	1	1	0
02/13/2015 03:00	0.1	13.8	1,749.7	0.1	0.3	1	1	0
02/13/2015 04:00	0.1	13.8	1,553.6	0.1	0.3	1	1	0
02/13/2015 05:00	0.1	13.7	1,568.2	0.1	0.3	1	1	1
02/13/2015 06:00	0.3	13.1	1,915.3	0.1	1.0	1	1	1
02/13/2015 07:00	0.3	13.2	1,893.8	0.2	1.0	1	1	1
02/13/2015 08:00	0.1	13.7	1,453.2	0.2	0.3	1	1	1
02/13/2015 09:00	0.0	13.8	1,294.6	0.1	0.0	1	1	0
02/13/2015 10:00	0.0	13.8	1,294.7	0.0	0.0	1	1	0
02/13/2015 11:00	0.0	13.8	1,301.8	0.0	0.0	1	1	0
02/13/2015 12:00	0.1	13.8	1,399.5	0.0	0.3	1	1	0
02/13/2015 13:00	0.1	13.7	1,647.7	0.1	0.3	1	1	1
02/13/2015 14:00	0.3	13.1	1,882.1	0.1	1.0	1	1	1
02/13/2015 15:00	0.2	13.3	1,850.8	0.2	0.6	1	1	1
02/13/2015 16:00	0.2	13.2	1,879.0	0.2	0.6	1	1	1
02/13/2015 17:00	0.3	12.9	1,935.7	0.2	1.0	1	1	1
02/13/2015 18:00	0.3	12.6	2,011.9	0.2	1.0	1	1	1
02/13/2015 19:00	0.3	12.4	2,042.3	0.2	1.0	1	1	1
02/13/2015 20:00	0.3	12.5	2,028.1	0.2	1.0	1	1	1
02/13/2015 21:00	0.3	12.6	2,006.5	0.2	1.0	1	1	1
02/13/2015 22:00	0.3	12.6	2,023.2	0.2	1.0	1	1	1
02/13/2015 23:00	0.2	13.1	1,902.7	0.2	0.6	1	1	1
Average/Sum#:	0.2	13.3	1,721.1	0.1	12.9 #	24 #	24 #	15 #
Minimum:	0.0	12.4	1,294.6	0.0	0.0	1	1	0
Maximum:	0.3	13.8	2,042.3	0.2	1.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/14/2015 00:00	0.3	12.8	1,991.1	0.2	1.0	1	1	1
02/14/2015 01:00	0.3	12.9	1,974.7	0.2	1.0	1	1	1
02/14/2015 02:00	0.5	12.8	1,998.4	0.3	1.6	1	1	1
02/14/2015 03:00	0.3	12.8	1,997.6	0.3	1.0	1	1	1
02/14/2015 04:00	0.3	12.8	1,984.5	0.3	1.0	1	1	1
02/14/2015 05:00	0.2	13.2	1,858.4	0.2	0.6	1	1	1
02/14/2015 06:00	0.0	13.8	1,490.9	0.1	0.0	1	1	1
02/14/2015 07:00	0.1	13.8	1,307.7	0.1	0.2	1	1	0
02/14/2015 08:00	0.1	13.8	1,297.7	0.1	0.2	1	1	0
02/14/2015 09:00	0.1	13.8	1,310.3	0.1	0.2	1	1	0
02/14/2015 10:00	0.1	13.8	1,304.6	0.1	0.2	1	1	0
02/14/2015 11:00	0.0	13.8	1,301.5	0.1	0.0	1	1	0
02/14/2015 12:00	0.0	13.8	1,302.2	0.0	0.0	1	1	0
02/14/2015 13:00	0.0	13.9	1,301.4	0.0	0.0	1	1	0
02/14/2015 14:00	0.0	13.9	1,299.0	0.0	0.0	1	1	0
02/14/2015 15:00	0.0	13.9	1,297.0	0.0	0.0	1	1	0
02/14/2015 16:00	0.2	13.4	1,565.2	0.1	0.6	1	1	1
02/14/2015 17:00	0.3	13.0	1,902.0	0.1	1.0	1	1	1
02/14/2015 18:00	0.3	13.0	1,897.5	0.2	1.0	1	1	1
02/14/2015 19:00	0.3	12.3	2,050.6	0.2	0.9	1	1	1
02/14/2015 20:00	0.3	12.8	1,945.3	0.2	1.0	1	1	1
02/14/2015 21:00	0.3	12.9	1,930.7	0.2	1.0	1	1	1
02/14/2015 22:00	0.3	12.6	1,986.7	0.2	0.9	1	1	1
02/14/2015 23:00	0.0	13.8	1,427.5	0.1	0.0	1	1	1
Average/Sum#:	0.2	13.3	1,655.1	0.1	13.4 #	24 #	24 #	15 #
Minimum:	0.0	12.3	1,297.0	0.0	0.0	1	1	0
Maximum:	0.5	13.9	2,050.6	0.3	1.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/15/2015 00:00	0.0	13.9	1,389.4	0.1	0.0	1	1	0
02/15/2015 01:00	0.1	13.8	1,461.0	0.0	0.3	1	1	0
02/15/2015 02:00	14.3	15.8	565.1	0.0	4.6	1	0	0
02/15/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2015 10:00	19.3	17.2	522.1	0.0	22.3	1	0	0
02/15/2015 11:00	19.7	14.8	973.4	0.0	41.5	1	0	0
02/15/2015 12:00	0.0	13.9	1,323.3	0.0	0.0	1	1	0
02/15/2015 13:00	0.0	13.9	1,316.9	0.0	0.0	1	1	0
02/15/2015 14:00	0.0	13.8	1,585.1	0.0	0.0	1	1	0
02/15/2015 15:00	0.1	13.7	1,741.0	0.0	0.3	1	1	0
02/15/2015 16:00	0.1	13.7	1,741.6	0.1	0.3	1	1	0
02/15/2015 17:00	0.0	13.9	1,400.5	0.1	0.0	1	1	0
02/15/2015 18:00	0.0	13.9	1,437.5	0.0	0.0	1	1	0
02/15/2015 19:00	0.3	12.9	1,927.0	0.1	1.0	1	1	1
02/15/2015 20:00	0.2	12.7	1,990.1	0.1	0.6	1	1	1
02/15/2015 21:00	0.2	12.8	1,979.5	0.1	0.6	1	1	1
02/15/2015 22:00	0.2	12.8	1,977.7	0.1	0.6	1	1	1
02/15/2015 23:00	0.2	12.8	1,976.4	0.1	0.6	1	1	1
Average/Sum#:	3.2	13.9	1,488.7	0.1	72.7 #	17 #	14 #	5 #
Minimum:	0.0	12.7	522.1	0.0	0.0	0	0	0
Maximum:	19.7	17.2	1,990.1	0.1	41.5	1	1	1
%SI	29.2	29.2	29.2	50.0	29.2	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/16/2015 00:00	0.2	12.9	1,987.0	0.1	0.7	1	1	1
02/16/2015 01:00	0.2	13.1	1,909.0	0.1	0.6	1	1	1
02/16/2015 02:00	0.2	13.3	1,844.2	0.2	0.6	1	1	1
02/16/2015 03:00	0.2	13.3	1,845.2	0.2	0.6	1	1	1
02/16/2015 04:00	0.2	13.3	1,854.6	0.2	0.6	1	1	1
02/16/2015 05:00	0.2	13.2	1,892.1	0.2	0.6	1	1	1
02/16/2015 06:00	0.2	13.1	1,918.6	0.2	0.6	1	1	1
02/16/2015 07:00	0.2	13.2	1,852.9	0.2	0.6	1	1	1
02/16/2015 08:00	0.2	13.3	1,854.2	0.2	0.6	1	1	1
02/16/2015 09:00	0.2	13.3	1,853.1	0.2	0.6	1	1	1
02/16/2015 10:00	0.2	13.3	1,854.5	0.2	0.6	1	1	1
02/16/2015 11:00	0.2	13.3	1,851.0	0.2	0.6	1	1	1
02/16/2015 12:00	0.2	13.3	1,850.7	0.2	0.6	1	1	1
02/16/2015 13:00	0.1	13.5	1,561.8	0.2	0.3	1	1	1
02/16/2015 14:00	0.0	13.9	1,289.8	0.1	0.0	1	1	0
02/16/2015 15:00	0.1	13.6	1,543.5	0.1	0.3	1	1	1
02/16/2015 16:00	0.2	13.1	1,896.5	0.1	0.6	1	1	1
02/16/2015 17:00	0.3	12.8	1,948.3	0.2	1.0	1	1	1
02/16/2015 18:00	0.3	12.4	2,036.9	0.2	0.9	1	1	1
02/16/2015 19:00	0.3	12.4	2,031.3	0.2	0.9	1	1	1
02/16/2015 20:00	0.2	13.2	1,853.8	0.2	0.6	1	1	1
02/16/2015 21:00	0.2	13.2	1,875.3	0.2	0.6	1	1	1
02/16/2015 22:00	0.2	13.0	1,918.3	0.2	0.6	1	1	1
02/16/2015 23:00	0.2	13.3	1,847.8	0.2	0.6	1	1	1
Average/Sum#:	0.2	13.2	1,840.4	0.2	14.3 #	24 #	24 #	23 #
Minimum:	0.0	12.4	1,289.8	0.1	0.0	1	1	0
Maximum:	0.3	13.9	2,036.9	0.2	1.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/17/2015 00:00	0.2	13.2	1,853.0	0.2	0.6	1	1	1
02/17/2015 01:00	0.3	13.2	1,856.2	0.2	1.0	1	1	1
02/17/2015 02:00	0.2	13.3	1,854.4	0.2	0.6	1	1	1
02/17/2015 03:00	0.2	13.3	1,855.4	0.2	0.6	1	1	1
02/17/2015 04:00	0.2	13.3	1,854.3	0.2	0.6	1	1	1
02/17/2015 05:00	0.3	13.2	1,862.6	0.2	1.0	1	1	1
02/17/2015 06:00	0.3	13.2	1,880.1	0.2	1.0	1	1	1
02/17/2015 07:00	0.3	13.1	1,932.6	0.2	1.0	1	1	1
02/17/2015 08:00	0.3	13.2	1,853.8	0.2	1.0	1	1	1
02/17/2015 09:00	0.1	13.5	1,548.7	0.2	0.3	1	1	1
02/17/2015 10:00	0.0	13.8	1,409.6	0.1	0.0	1	1	0
02/17/2015 11:00	0.1	13.8	1,573.6	0.1	0.3	1	1	0
02/17/2015 12:00	0.1	13.8	1,554.8	0.1	0.3	1	1	0
02/17/2015 13:00	0.1	13.8	1,315.3	0.1	0.2	1	1	0
02/17/2015 14:00	0.1	13.8	1,292.2	0.1	0.2	1	1	0
02/17/2015 15:00	0.1	13.8	1,303.9	0.1	0.2	1	1	0
02/17/2015 16:00	0.2	13.5	1,604.3	0.1	0.6	1	1	1
02/17/2015 17:00	0.3	13.1	1,895.0	0.2	1.0	1	1	1
02/17/2015 18:00	0.4	12.5	2,031.3	0.2	1.3	1	1	1
02/17/2015 19:00	0.4	12.5	2,024.9	0.3	1.3	1	1	1
02/17/2015 20:00	0.3	12.8	1,980.7	0.3	1.0	1	1	1
02/17/2015 21:00	0.3	13.1	1,904.2	0.2	1.0	1	1	1
02/17/2015 22:00	0.3	12.9	1,842.2	0.2	0.9	1	1	1
02/17/2015 23:00	0.1	13.8	1,308.6	0.2	0.2	1	1	0
Average/Sum#:	0.2	13.3	1,724.7	0.2	16.2 #	24 #	24 #	17 #
Minimum:	0.0	12.5	1,292.2	0.1	0.0	1	1	0
Maximum:	0.4	13.8	2,031.3	0.3	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/18/2015 00:00	0.1	13.8	1,488.8	0.1	0.3	1	1	0
02/18/2015 01:00	0.1	13.8	1,516.0	0.1	0.3	1	1	0
02/18/2015 02:00	0.1	13.8	1,338.1	0.1	0.2	1	1	0
02/18/2015 03:00	0.1	13.8	1,307.5	0.1	0.2	1	1	0
02/18/2015 04:00	0.2	13.6	1,693.0	0.1	0.6	1	1	1
02/18/2015 05:00	0.3	13.2	1,895.4	0.2	1.0	1	1	1
02/18/2015 06:00	0.3	13.2	1,893.1	0.2	1.0	1	1	1
02/18/2015 07:00	0.3	13.1	1,961.9	0.2	1.0	1	1	1
02/18/2015 08:00	0.4	13.0	1,997.9	0.2	1.3	1	1	1
02/18/2015 09:00	0.3	13.0	2,002.6	0.2	1.0	1	1	1
02/18/2015 10:00	0.3	12.9	1,988.1	0.2	1.0	1	1	1
02/18/2015 11:00	0.3	13.2	1,858.2	0.2	1.0	1	1	1
02/18/2015 12:00	0.3	13.2	1,859.4	0.2	1.0	1	1	1
02/18/2015 13:00	0.3	13.2	1,856.6	0.2	1.0	1	1	1
02/18/2015 14:00	0.1	13.6	1,558.1	0.2	0.3	1	1	1
02/18/2015 15:00	0.0	13.8	1,654.5	0.1	0.0	1	1	0
02/18/2015 16:00	0.2	13.2	1,841.0	0.1	0.6	1	1	1
02/18/2015 17:00	0.4	12.7	2,001.0	0.2	1.3	1	1	1
02/18/2015 18:00	0.4	12.5	2,044.4	0.3	1.3	1	1	1
02/18/2015 19:00	0.3	12.6	2,015.7	0.3	1.0	1	1	1
02/18/2015 20:00	0.4	12.7	2,008.7	0.3	1.3	1	1	1
02/18/2015 21:00	0.3	12.8	1,991.2	0.2	1.0	1	1	1
02/18/2015 22:00	0.3	13.0	1,954.2	0.2	1.0	1	1	1
02/18/2015 23:00	0.3	13.2	1,878.0	0.2	1.0	1	1	1
Average/Sum#:	0.3	13.2	1,816.8	0.2	19.7 #	24 #	24 #	19 #
Minimum:	0.0	12.5	1,307.5	0.1	0.0	1	1	0
Maximum:	0.4	13.8	2,044.4	0.3	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/19/2015 00:00	0.4	12.8	1,981.9	0.2	1.3	1	1	1
02/19/2015 01:00	0.3	13.2	1,855.2	0.2	1.0	1	1	1
02/19/2015 02:00	0.1	13.7	1,430.1	0.2	0.3	1	1	1
02/19/2015 03:00	0.1	13.8	1,312.7	0.1	0.2	1	1	0
02/19/2015 04:00	0.1	13.7	1,437.7	0.1	0.3	1	1	1
02/19/2015 05:00	0.4	13.0	1,943.1	0.2	1.3	1	1	1
02/19/2015 06:00	0.4	12.9	1,945.6	0.2	1.3	1	1	1
02/19/2015 07:00	0.4	12.9	2,005.5	0.3	1.3	1	1	1
02/19/2015 08:00	0.3	12.8	2,012.3	0.3	1.0	1	1	1
02/19/2015 09:00	0.3	13.0	1,960.7	0.2	1.0	1	1	1
02/19/2015 10:00	0.4	12.6	2,043.3	0.2	1.3	1	1	1
02/19/2015 11:00	0.3	12.8	2,008.6	0.2	1.0	1	1	1
02/19/2015 12:00	0.3	12.9	1,959.2	0.2	1.0	1	1	1
02/19/2015 13:00	0.3	12.8	1,968.1	0.2	1.0	1	1	1
02/19/2015 14:00	0.3	13.2	1,850.0	0.2	1.0	1	1	1
02/19/2015 15:00	0.3	13.3	1,848.3	0.2	1.0	1	1	1
02/19/2015 16:00	0.3	13.2	1,875.7	0.2	1.0	1	1	1
02/19/2015 17:00	0.3	13.2	1,864.2	0.2	1.0	1	1	1
02/19/2015 18:00	0.3	12.9	1,964.8	0.2	1.0	1	1	1
02/19/2015 19:00	0.3	13.2	1,867.6	0.2	1.0	1	1	1
02/19/2015 20:00	0.3	13.2	1,850.3	0.2	1.0	1	1	1
02/19/2015 21:00	0.3	13.2	1,860.1	0.2	1.0	1	1	1
02/19/2015 22:00	0.3	13.1	1,896.7	0.2	1.0	1	1	1
02/19/2015 23:00	0.3	13.0	1,827.1	0.2	0.9	1	1	1
Average/Sum#:	0.3	13.1	1,857.0	0.2	23.2 #	24 #	24 #	23 #
Minimum:	0.1	12.6	1,312.7	0.1	0.2	1	1	0
Maximum:	0.4	13.8	2,043.3	0.3	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/20/2015 00:00	0.1	13.8	1,342.1	0.2	0.2	1	1	0
02/20/2015 01:00	14.5	15.7	621.7	0.0	5.7	1	0	0
02/20/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 04:00	7.9	18.7	313.2	0.0	3.0	1	0	0
02/20/2015 05:00	14.6	14.5	1,139.3	0.0	34.3	1	0	0
02/20/2015 06:00	0.1	13.8	1,586.4	0.0	0.3	1	1	0
02/20/2015 07:00	0.1	13.8	1,793.8	0.0	0.3	1	1	0
02/20/2015 08:00	0.1	13.8	1,797.4	0.1	0.3	1	1	0
02/20/2015 09:00	0.1	13.8	1,806.3	0.1	0.3	1	1	0
02/20/2015 10:00	0.1	13.7	1,798.7	0.1	0.3	1	1	0
02/20/2015 11:00	0.1	13.7	1,717.1	0.1	0.3	1	1	0
02/20/2015 12:00	16.8	16.3	441.8	0.0	4.3	1	0	0
02/20/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/20/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	5.0	14.7	1,305.3	0.1	49.3 #	11 #	7 #	0 #
Minimum:	0.1	13.7	313.2	0.1	0.2	0	0	0
Maximum:	16.8	18.7	1,806.3	0.2	34.3	1	1	0
%SI	54.2	54.2	54.2	79.2	54.2	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/21/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/21/2015 10:00	55.3	17.4	488.4	0.0	74.4	1	0	0
02/21/2015 11:00	37.6	15.5	736.1	0.0	67.7	1	0	0
02/21/2015 12:00	7.8	14.2	1,247.6	0.0	19.2	1	0	0
02/21/2015 13:00	0.0	13.9	1,280.1	0.0	0.0	1	1	0
02/21/2015 14:00	0.0	13.9	1,274.8	0.0	0.0	1	1	0
02/21/2015 15:00	0.1	13.9	1,366.4	0.0	0.3	1	1	0
02/21/2015 16:00	0.1	13.9	1,365.1	0.1	0.3	1	1	0
02/21/2015 17:00	0.1	13.7	1,508.4	0.1	0.3	1	1	1
02/21/2015 18:00	0.4	12.7	2,003.0	0.2	1.3	1	1	1
02/21/2015 19:00	0.3	12.5	2,049.5	0.2	1.0	1	1	1
02/21/2015 20:00	0.3	12.5	2,044.6	0.2	1.0	1	1	1
02/21/2015 21:00	0.3	12.8	2,006.0	0.2	1.0	1	1	1
02/21/2015 22:00	0.3	12.6	2,045.5	0.2	1.0	1	1	1
02/21/2015 23:00	0.3	12.9	1,954.3	0.2	1.0	1	1	1
Average/Sum#:	7.4	13.7	1,526.4	0.2	168.5 #	14 #	11 #	7 #
Minimum:	0.0	12.5	488.4	0.0	0.0	0	0	0
Maximum:	55.3	17.4	2,049.5	0.2	74.4	1	1	1
%SI	41.7	41.7	41.7	62.5	41.7	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/22/2015 00:00	0.0	13.9	1,398.5	0.1	0.0	1	1	0
02/22/2015 01:00	0.0	13.8	1,549.6	0.1	0.0	1	1	0
02/22/2015 02:00	0.0	13.9	1,292.2	0.0	0.0	1	1	0
02/22/2015 03:00	0.0	13.9	1,342.6	0.0	0.0	1	1	0
02/22/2015 04:00	0.0	13.9	1,584.8	0.0	0.0	1	1	0
02/22/2015 05:00	0.0	13.9	1,505.7	0.0	0.0	1	1	0
02/22/2015 06:00	0.0	0.0	644.7	0.0	0.0	1	0	0
02/22/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2015 14:00	20.0	17.0	541.2	0.0	25.0	1	0	0
02/22/2015 15:00	24.5	15.0	943.2	0.0	51.7	1	0	0
02/22/2015 16:00	0.0	13.8	1,775.3	0.0	0.0	1	1	0
02/22/2015 17:00	0.0	13.8	1,737.5	0.0	0.0	1	1	0
02/22/2015 18:00	0.1	13.8	1,805.9	0.0	0.3	1	1	0
02/22/2015 19:00	0.1	13.8	1,811.0	0.1	0.3	1	1	0
02/22/2015 20:00	0.1	13.8	1,815.0	0.1	0.3	1	1	0
02/22/2015 21:00	0.1	13.8	1,817.9	0.1	0.3	1	1	0
02/22/2015 22:00	5.1	14.7	1,221.4	0.0	6.9	1	0	0
02/22/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	3.3	14.2	1,424.2	0.1	84.8 #	16 #	12 #	0 #
Minimum:	0.0	13.8	541.2	0.0	0.0	0	0	0
Maximum:	24.5	17.0	1,817.9	0.1	51.7	1	1	0
%SI	37.5	37.5	33.3	58.3	37.5	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/23/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2015 03:00	21.4	16.9	565.9	0.0	28.0	1	0	0
02/23/2015 04:00	10.2	14.3	1,287.3	0.0	26.3	1	0	0
02/23/2015 05:00	0.2	13.5	1,873.1	0.0	0.7	1	1	1
02/23/2015 06:00	0.4	12.9	2,032.0	0.0	1.3	1	1	1
02/23/2015 07:00	0.4	12.7	1,955.5	0.3	1.3	1	1	1
02/23/2015 08:00	0.1	13.9	1,798.5	0.2	0.3	1	1	0
02/23/2015 09:00	0.1	13.8	1,793.2	0.2	0.3	1	1	0
02/23/2015 10:00	0.1	13.8	1,809.1	0.1	0.3	1	1	0
02/23/2015 11:00	0.1	13.9	1,646.7	0.1	0.3	1	1	0
02/23/2015 12:00	0.1	13.8	1,813.3	0.1	0.3	1	1	0
02/23/2015 13:00	0.1	13.8	1,808.6	0.1	0.3	1	1	0
02/23/2015 14:00	0.1	13.8	1,630.5	0.1	0.3	1	1	0
02/23/2015 15:00	0.1	13.8	1,793.7	0.1	0.3	1	1	0
02/23/2015 16:00	0.1	13.8	1,669.3	0.1	0.3	1	1	0
02/23/2015 17:00	0.3	13.2	1,884.6	0.1	1.0	1	1	1
02/23/2015 18:00	0.4	12.1	2,159.4	0.2	1.3	1	1	1
02/23/2015 19:00	0.2	13.5	1,835.1	0.2	0.7	1	1	1
02/23/2015 20:00	0.4	12.1	2,183.2	0.3	1.3	1	1	1
02/23/2015 21:00	0.4	12.2	2,107.3	0.3	1.3	1	1	1
02/23/2015 22:00	0.1	13.8	1,809.2	0.2	0.3	1	1	0
02/23/2015 23:00	0.1	13.9	1,747.0	0.2	0.3	1	1	0
Average/Sum#:	1.7	13.6	1,771.5	0.2	66.5 #	21 #	19 #	8 #
Minimum:	0.1	12.1	565.9	0.1	0.3	0	0	0
Maximum:	21.4	16.9	2,183.2	0.3	28.0	1	1	1
%SI	12.5	12.5	12.5	29.2	12.5	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/24/2015 00:00	0.1	13.9	1,755.5	0.1	0.3	1	1	0
02/24/2015 01:00	0.1	13.9	1,798.6	0.1	0.3	1	1	0
02/24/2015 02:00	0.1	13.9	1,810.8	0.1	0.3	1	1	0
02/24/2015 03:00	0.1	13.9	1,792.1	0.1	0.3	1	1	0
02/24/2015 04:00	0.1	13.9	1,635.4	0.1	0.3	1	1	0
02/24/2015 05:00	0.2	13.5	1,696.6	0.1	0.6	1	1	1
02/24/2015 06:00	0.4	12.8	2,044.4	0.2	1.3	1	1	1
02/24/2015 07:00	0.3	12.8	2,039.5	0.2	1.0	1	1	1
02/24/2015 08:00	0.2	13.1	1,968.4	0.2	0.7	1	1	1
02/24/2015 09:00	0.1	13.6	1,556.8	0.2	0.3	1	1	1
02/24/2015 10:00	0.0	13.9	1,325.9	0.1	0.0	1	1	0
02/24/2015 11:00	0.0	13.9	1,293.5	0.0	0.0	1	1	0
02/24/2015 12:00	0.0	13.9	1,292.5	0.0	0.0	1	1	0
02/24/2015 13:00	0.0	13.9	1,291.8	0.0	0.0	1	1	0
02/24/2015 14:00	0.0	13.9	1,313.9	0.0	0.0	1	1	0
02/24/2015 15:00	0.0	13.9	1,368.1	0.0	0.0	1	1	0
02/24/2015 16:00	0.1	13.8	1,479.7	0.0	0.3	1	1	1
02/24/2015 17:00	0.3	12.8	2,000.5	0.1	1.0	1	1	1
02/24/2015 18:00	0.3	12.6	2,046.8	0.2	1.0	1	1	1
02/24/2015 19:00	0.3	12.6	2,040.6	0.2	1.0	1	1	1
02/24/2015 20:00	0.3	12.7	2,039.2	0.2	1.0	1	1	1
02/24/2015 21:00	0.3	12.7	2,032.0	0.2	1.0	1	1	1
02/24/2015 22:00	0.2	13.1	1,821.5	0.2	0.6	1	1	1
02/24/2015 23:00	0.0	13.8	1,488.2	0.1	0.0	1	1	0
Average/Sum#:	0.1	13.5	1,705.5	0.1	11.3 #	24 #	24 #	12 #
Minimum:	0.0	12.6	1,291.8	0.0	0.0	1	1	0
Maximum:	0.4	13.9	2,046.8	0.2	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/25/2015 00:00	0.1	13.8	1,302.5	0.1	0.2	1	1	0
02/25/2015 01:00	0.1	13.9	1,748.3	0.1	0.3	1	1	0
02/25/2015 02:00	0.1	13.9	1,733.9	0.1	0.3	1	1	0
02/25/2015 03:00	0.1	13.8	1,447.1	0.1	0.3	1	1	0
02/25/2015 04:00	0.1	13.8	1,291.0	0.1	0.2	1	1	0
02/25/2015 05:00	0.2	13.6	1,636.3	0.1	0.6	1	1	1
02/25/2015 06:00	0.4	12.9	2,012.3	0.2	1.3	1	1	1
02/25/2015 07:00	0.3	13.1	1,992.6	0.2	1.0	1	1	1
02/25/2015 08:00	0.2	13.5	1,736.1	0.2	0.6	1	1	1
02/25/2015 09:00	0.0	13.8	1,309.6	0.1	0.0	1	1	0
02/25/2015 10:00	0.0	13.8	1,293.2	0.1	0.0	1	1	0
02/25/2015 11:00	0.0	13.8	1,293.7	0.0	0.0	1	1	0
02/25/2015 12:00	0.0	13.8	1,295.5	0.0	0.0	1	1	0
02/25/2015 13:00	0.1	13.9	1,411.7	0.0	0.3	1	1	0
02/25/2015 14:00	0.0	13.9	1,303.4	0.0	0.0	1	1	0
02/25/2015 15:00	0.0	13.9	1,296.8	0.0	0.0	1	1	0
02/25/2015 16:00	0.1	13.8	1,468.0	0.0	0.3	1	1	1
02/25/2015 17:00	0.4	12.8	1,981.7	0.1	1.3	1	1	1
02/25/2015 18:00	0.3	12.6	2,005.5	0.2	1.0	1	1	1
02/25/2015 19:00	0.3	13.0	1,942.1	0.2	1.0	1	1	1
02/25/2015 20:00	0.3	13.1	1,943.9	0.2	1.0	1	1	1
02/25/2015 21:00	0.3	12.9	1,978.6	0.2	1.0	1	1	1
02/25/2015 22:00	0.3	13.1	1,782.6	0.2	0.9	1	1	1
02/25/2015 23:00	0.0	13.8	1,439.7	0.1	0.0	1	1	0
Average/Sum#:	0.2	13.5	1,610.3	0.1	11.6 #	24 #	24 #	11 #
Minimum:	0.0	12.6	1,291.0	0.0	0.0	1	1	0
Maximum:	0.4	13.9	2,012.3	0.2	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/26/2015 00:00	0.0	13.8	1,289.3	0.1	0.0	1	1	0
02/26/2015 01:00	0.1	13.8	1,304.5	0.0	0.2	1	1	0
02/26/2015 02:00	0.1	13.8	1,754.2	0.1	0.3	1	1	0
02/26/2015 03:00	0.1	13.8	1,783.3	0.1	0.3	1	1	0
02/26/2015 04:00	0.2	13.6	1,749.3	0.1	0.6	1	1	1
02/26/2015 05:00	0.3	13.2	1,937.2	0.2	1.0	1	1	1
02/26/2015 06:00	0.3	13.1	1,957.6	0.2	1.0	1	1	1
02/26/2015 07:00	0.3	13.0	1,976.3	0.2	1.0	1	1	1
02/26/2015 08:00	0.1	13.5	1,626.0	0.2	0.3	1	1	1
02/26/2015 09:00	0.0	13.8	1,374.3	0.1	0.0	1	1	0
02/26/2015 10:00	0.0	13.9	1,676.3	0.0	0.0	1	1	0
02/26/2015 11:00	0.0	13.8	1,705.7	0.0	0.0	1	1	0
02/26/2015 12:00	0.0	13.9	1,312.0	0.0	0.0	1	1	0
02/26/2015 13:00	0.0	13.9	1,290.3	0.0	0.0	1	1	0
02/26/2015 14:00	0.0	13.9	1,292.3	0.0	0.0	1	1	0
02/26/2015 15:00	0.1	13.9	1,479.2	0.0	0.3	1	1	0
02/26/2015 16:00	0.3	13.1	1,792.5	0.1	0.9	1	1	1
02/26/2015 17:00	0.3	12.7	1,984.0	0.2	1.0	1	1	1
02/26/2015 18:00	0.3	12.3	2,059.1	0.2	0.9	1	1	1
02/26/2015 19:00	0.3	12.3	2,057.7	0.2	0.9	1	1	1
02/26/2015 20:00	0.3	12.5	2,022.2	0.2	1.0	1	1	1
02/26/2015 21:00	0.3	12.6	2,006.3	0.2	1.0	1	1	1
02/26/2015 22:00	0.1	13.5	1,581.4	0.2	0.3	1	1	1
02/26/2015 23:00	0.0	13.9	1,286.3	0.1	0.0	1	1	0
Average/Sum#:	0.1	13.4	1,679.1	0.1	11.0 #	24 #	24 #	12 #
Minimum:	0.0	12.3	1,286.3	0.0	0.0	1	1	0
Maximum:	0.3	13.9	2,059.1	0.2	1.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/27/2015 00:00	0.1	13.7	1,722.3	0.1	0.3	1	1	0
02/27/2015 01:00	0.1	13.7	1,799.3	0.1	0.3	1	1	0
02/27/2015 02:00	0.1	13.7	1,774.8	0.1	0.3	1	1	0
02/27/2015 03:00	0.1	13.8	1,497.1	0.1	0.3	1	1	0
02/27/2015 04:00	0.1	13.8	1,287.9	0.1	0.2	1	1	0
02/27/2015 05:00	0.1	13.7	1,468.7	0.1	0.3	1	1	1
02/27/2015 06:00	0.4	12.7	1,994.9	0.2	1.3	1	1	1
02/27/2015 07:00	0.3	13.1	1,807.8	0.2	0.9	1	1	1
02/27/2015 08:00	0.0	13.8	1,306.0	0.2	0.0	1	1	0
02/27/2015 09:00	0.0	13.8	1,286.1	0.1	0.0	1	1	0
02/27/2015 10:00	0.0	13.9	1,289.9	0.0	0.0	1	1	0
02/27/2015 11:00	0.1	13.8	1,492.8	0.0	0.3	1	1	0
02/27/2015 12:00	0.0	13.9	1,288.7	0.0	0.0	1	1	0
02/27/2015 13:00	0.1	13.9	1,290.6	0.1	0.2	1	1	0
02/27/2015 14:00	0.1	13.9	1,288.0	0.1	0.2	1	1	0
02/27/2015 15:00	0.1	13.9	1,355.3	0.1	0.3	1	1	0
02/27/2015 16:00	0.1	13.9	1,450.5	0.1	0.3	1	1	0
02/27/2015 17:00	0.3	13.3	1,663.0	0.1	0.9	1	1	1
02/27/2015 18:00	0.4	12.5	2,050.9	0.2	1.3	1	1	1
02/27/2015 19:00	0.4	12.5	2,051.9	0.3	1.3	1	1	1
02/27/2015 20:00	0.3	12.5	2,052.8	0.3	1.0	1	1	1
02/27/2015 21:00	0.4	12.6	2,052.0	0.3	1.3	1	1	1
02/27/2015 22:00	0.4	12.6	2,048.2	0.3	1.3	1	1	1
02/27/2015 23:00	0.1	13.5	1,597.7	0.2	0.3	1	1	1
Average/Sum#:	0.2	13.4	1,621.6	0.1	12.6 #	24 #	24 #	10 #
Minimum:	0.0	12.5	1,286.1	0.0	0.0	1	1	0
Maximum:	0.4	13.9	2,052.8	0.3	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/28/2015 00:00	0.0	13.9	1,287.4	0.1	0.0	1	1	0
02/28/2015 01:00	12.4	15.8	577.7	0.0	4.1	1	0	0
02/28/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/28/2015 14:00	29.3	18.6	334.3	0.0	12.9	1	0	0
02/28/2015 15:00	19.0	15.6	807.3	0.0	38.2	1	0	0
02/28/2015 16:00	0.1	13.6	1,594.0	0.0	0.3	1	1	1
02/28/2015 17:00	0.3	12.6	2,030.9	0.0	1.0	1	1	1
02/28/2015 18:00	0.3	12.6	2,048.1	0.2	1.0	1	1	1
02/28/2015 19:00	0.3	12.6	2,044.8	0.2	1.0	1	1	1
02/28/2015 20:00	0.3	12.6	2,046.4	0.2	1.0	1	1	1
02/28/2015 21:00	0.3	12.6	2,050.5	0.2	1.0	1	1	1
02/28/2015 22:00	0.3	12.6	2,051.1	0.2	1.0	1	1	1
02/28/2015 23:00	0.3	12.7	2,026.7	0.2	1.0	1	1	1
Average/Sum#:	5.2	13.8	1,574.9	0.2	62.5 #	12 #	9 #	8 #
Minimum:	0.0	12.6	334.3	0.1	0.0	0	0	0
Maximum:	29.3	18.6	2,051.1	0.2	38.2	1	1	1
%SI	50.0	50.0	50.0	70.8	50.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/01/2015 00:00	0.3	12.9	2,004.0	0.2	1.0	1	1	1
03/01/2015 01:00	0.2	13.4	1,843.8	0.2	0.6	1	1	1
03/01/2015 02:00	0.0	13.9	1,586.7	0.1	0.0	1	1	0
03/01/2015 03:00	0.0	13.9	1,655.5	0.1	0.0	1	1	0
03/01/2015 04:00	0.0	13.9	1,383.3	0.0	0.0	1	1	0
03/01/2015 05:00	0.0	13.8	1,731.2	0.0	0.0	1	1	0
03/01/2015 06:00	0.0	13.8	1,774.3	0.0	0.0	1	1	0
03/01/2015 07:00	0.0	13.8	1,816.5	0.0	0.0	1	1	0
03/01/2015 08:00	0.2	13.3	1,879.0	0.1	0.7	1	1	1
03/01/2015 09:00	0.3	12.7	2,054.4	0.1	1.0	1	1	1
03/01/2015 10:00	0.3	12.6	2,055.1	0.2	1.0	1	1	1
03/01/2015 11:00	0.3	12.6	2,055.3	0.2	1.0	1	1	1
03/01/2015 12:00	0.3	12.5	2,055.1	0.2	1.0	1	1	1
03/01/2015 13:00	0.2	12.8	1,988.7	0.2	0.6	1	1	1
03/01/2015 14:00	0.2	12.6	2,029.0	0.1	0.6	1	1	1
03/01/2015 15:00	0.2	12.4	2,059.7	0.1	0.6	1	1	1
03/01/2015 16:00	0.2	12.6	2,028.8	0.1	0.6	1	1	1
03/01/2015 17:00	0.3	12.5	2,053.1	0.1	1.0	1	1	1
03/01/2015 18:00	0.2	12.5	2,053.2	0.1	0.6	1	1	1
03/01/2015 19:00	0.3	12.5	2,055.7	0.2	1.0	1	1	1
03/01/2015 20:00	0.3	12.6	2,058.1	0.2	1.0	1	1	1
03/01/2015 21:00	0.3	12.6	2,059.6	0.2	1.0	1	1	1
03/01/2015 22:00	0.3	12.7	2,041.2	0.2	1.0	1	1	1
03/01/2015 23:00	0.3	12.9	2,016.9	0.2	1.0	1	1	1
Average/Sum#:	0.2	13.0	1,930.8	0.1	15.3 #	24 #	24 #	18 #
Minimum:	0.0	12.4	1,383.3	0.0	0.0	1	1	0
Maximum:	0.3	13.9	2,059.7	0.2	1.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/02/2015 00:00	0.3	12.8	2,035.4	0.2	1.0	1	1	1
03/02/2015 01:00	0.3	12.7	2,052.9	0.2	1.0	1	1	1
03/02/2015 02:00	0.3	12.9	2,020.3	0.2	1.0	1	1	1
03/02/2015 03:00	0.2	13.2	1,952.1	0.2	0.7	1	1	1
03/02/2015 04:00	0.2	13.5	1,815.4	0.2	0.6	1	1	1
03/02/2015 05:00	0.3	13.0	1,999.0	0.2	1.0	1	1	1
03/02/2015 06:00	0.4	12.7	2,012.4	0.2	1.3	1	1	1
03/02/2015 07:00	0.4	12.7	2,057.0	0.3	1.3	1	1	1
03/02/2015 08:00	0.4	12.8	2,038.1	0.3	1.3	1	1	1
03/02/2015 09:00	0.3	12.7	2,037.4	0.3	1.0	1	1	1
03/02/2015 10:00	0.3	12.9	2,003.9	0.2	1.0	1	1	1
03/02/2015 11:00	0.2	13.0	1,970.4	0.2	0.7	1	1	1
03/02/2015 12:00	0.3	12.8	2,005.4	0.2	1.0	1	1	1
03/02/2015 13:00	0.3	12.8	1,994.8	0.2	1.0	1	1	1
03/02/2015 14:00	0.1	13.4	1,698.5	0.2	0.3	1	1	1
03/02/2015 15:00	0.0	13.8	1,618.3	0.1	0.0	1	1	0
03/02/2015 16:00	0.2	13.3	1,819.6	0.1	0.6	1	1	1
03/02/2015 17:00	0.3	13.1	1,929.4	0.1	1.0	1	1	1
03/02/2015 18:00	0.2	13.1	1,933.6	0.2	0.7	1	1	1
03/02/2015 19:00	0.2	13.1	1,940.2	0.2	0.7	1	1	1
03/02/2015 20:00	0.2	13.1	1,949.2	0.2	0.7	1	1	1
03/02/2015 21:00	0.2	13.1	1,952.8	0.2	0.7	1	1	1
03/02/2015 22:00	0.2	13.3	1,806.5	0.2	0.6	1	1	1
03/02/2015 23:00	0.0	13.8	1,540.9	0.1	0.0	1	1	0
Average/Sum#:	0.2	13.1	1,924.3	0.2	19.2 #	24 #	24 #	22 #
Minimum:	0.0	12.7	1,540.9	0.1	0.0	1	1	0
Maximum:	0.4	13.8	2,057.0	0.3	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/03/2015 00:00	0.0	13.8	1,292.6	0.1	0.0	1	1	0
03/03/2015 01:00	0.0	13.8	1,293.6	0.0	0.0	1	1	0
03/03/2015 02:00	0.0	13.8	1,295.9	0.0	0.0	1	1	0
03/03/2015 03:00	0.1	13.8	1,298.3	0.0	0.2	1	1	0
03/03/2015 04:00	0.2	13.6	1,566.9	0.1	0.6	1	1	1
03/03/2015 05:00	0.4	12.9	2,009.7	0.2	1.3	1	1	1
03/03/2015 06:00	0.3	12.7	2,045.3	0.2	1.0	1	1	1
03/03/2015 07:00	0.3	12.9	2,004.0	0.2	1.0	1	1	1
03/03/2015 08:00	0.1	13.5	1,597.5	0.2	0.3	1	1	1
03/03/2015 09:00	0.0	13.8	1,293.5	0.1	0.0	1	1	0
03/03/2015 10:00	0.0	13.8	1,293.8	0.0	0.0	1	1	0
03/03/2015 11:00	0.0	13.8	1,294.3	0.0	0.0	1	1	0
03/03/2015 12:00	0.0	13.9	1,297.1	0.0	0.0	1	1	0
03/03/2015 13:00	0.0	13.9	1,299.1	0.0	0.0	1	1	0
03/03/2015 14:00	0.0	13.9	1,295.3	0.0	0.0	1	1	0
03/03/2015 15:00	0.0	13.9	1,295.3	0.0	0.0	1	1	0
03/03/2015 16:00	0.1	13.9	1,409.6	0.0	0.3	1	1	1
03/03/2015 17:00	0.3	13.0	1,952.6	0.1	1.0	1	1	1
03/03/2015 18:00	0.3	12.8	2,013.8	0.2	1.0	1	1	1
03/03/2015 19:00	0.3	12.6	2,054.1	0.2	1.0	1	1	1
03/03/2015 20:00	0.3	12.6	2,047.0	0.2	1.0	1	1	1
03/03/2015 21:00	0.3	12.6	2,050.8	0.2	1.0	1	1	1
03/03/2015 22:00	0.3	12.8	2,013.4	0.2	1.0	1	1	1
03/03/2015 23:00	0.1	13.5	1,716.3	0.2	0.3	1	1	1
Average/Sum#:	0.1	13.4	1,613.7	0.1	11.0 #	24 #	24 #	13 #
Minimum:	0.0	12.6	1,292.6	0.0	0.0	1	1	0
Maximum:	0.4	13.9	2,054.1	0.2	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/04/2015 00:00	0.0	13.9	1,816.2	0.1	0.0	1	1	0
03/04/2015 01:00	0.0	13.8	1,779.5	0.0	0.0	1	1	0
03/04/2015 02:00	0.0	13.9	1,721.1	0.0	0.0	1	1	0
03/04/2015 03:00	0.0	13.9	1,761.4	0.0	0.0	1	1	0
03/04/2015 04:00	0.2	13.4	1,812.0	0.1	0.6	1	1	1
03/04/2015 05:00	0.3	12.9	2,021.2	0.1	1.0	1	1	1
03/04/2015 06:00	0.3	12.8	2,026.0	0.2	1.0	1	1	1
03/04/2015 07:00	0.3	12.9	2,012.1	0.2	1.0	1	1	1
03/04/2015 08:00	0.3	13.1	1,975.4	0.2	1.0	1	1	1
03/04/2015 09:00	0.1	13.7	1,439.2	0.2	0.3	1	1	1
03/04/2015 10:00	0.1	13.9	1,293.9	0.1	0.2	1	1	0
03/04/2015 11:00	0.1	13.9	1,293.2	0.1	0.2	1	1	0
03/04/2015 12:00	0.1	13.9	1,293.1	0.1	0.2	1	1	0
03/04/2015 13:00	0.1	13.9	1,293.8	0.1	0.2	1	1	0
03/04/2015 14:00	0.1	13.9	1,293.7	0.1	0.2	1	1	0
03/04/2015 15:00	0.1	13.9	1,293.4	0.1	0.2	1	1	0
03/04/2015 16:00	0.2	13.5	1,560.9	0.1	0.6	1	1	1
03/04/2015 17:00	0.4	12.6	2,030.7	0.2	1.3	1	1	1
03/04/2015 18:00	0.3	12.5	2,054.2	0.2	1.0	1	1	1
03/04/2015 19:00	0.3	12.6	2,050.7	0.2	1.0	1	1	1
03/04/2015 20:00	0.3	12.6	2,051.8	0.2	1.0	1	1	1
03/04/2015 21:00	0.3	12.7	2,041.3	0.2	1.0	1	1	1
03/04/2015 22:00	0.4	12.8	2,018.8	0.2	1.3	1	1	1
03/04/2015 23:00	0.3	13.1	1,978.2	0.2	1.0	1	1	1
Average/Sum#:	0.2	13.3	1,746.3	0.1	14.3 #	24 #	24 #	14 #
Minimum:	0.0	12.5	1,293.1	0.0	0.0	1	1	0
Maximum:	0.4	13.9	2,054.2	0.2	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/05/2015 00:00	0.3	13.4	1,813.7	0.2	1.0	1	1	1
03/05/2015 01:00	0.1	13.9	1,588.9	0.2	0.3	1	1	0
03/05/2015 02:00	0.1	13.9	1,546.1	0.1	0.3	1	1	0
03/05/2015 03:00	0.1	13.9	1,631.3	0.1	0.3	1	1	0
03/05/2015 04:00	0.2	13.7	1,761.5	0.1	0.6	1	1	1
03/05/2015 05:00	0.4	13.0	2,006.2	0.2	1.3	1	1	1
03/05/2015 06:00	0.4	12.8	2,037.9	0.3	1.3	1	1	1
03/05/2015 07:00	0.4	12.9	2,031.6	0.3	1.3	1	1	1
03/05/2015 08:00	0.3	13.2	1,952.9	0.3	1.0	1	1	1
03/05/2015 09:00	0.1	13.7	1,456.0	0.2	0.3	1	1	1
03/05/2015 10:00	0.1	13.8	1,294.8	0.1	0.2	1	1	0
03/05/2015 11:00	0.1	13.8	1,295.8	0.1	0.2	1	1	0
03/05/2015 12:00	0.1	13.8	1,296.1	0.1	0.2	1	1	0
03/05/2015 13:00	0.1	13.9	1,298.3	0.1	0.2	1	1	0
03/05/2015 14:00	0.1	13.9	1,299.4	0.1	0.2	1	1	0
03/05/2015 15:00	0.1	13.9	1,301.1	0.1	0.2	1	1	0
03/05/2015 16:00	0.2	13.7	1,549.2	0.1	0.6	1	1	1
03/05/2015 17:00	0.4	12.6	2,047.0	0.2	1.3	1	1	1
03/05/2015 18:00	0.4	12.5	2,052.3	0.3	1.3	1	1	1
03/05/2015 19:00	0.4	12.5	2,051.5	0.3	1.3	1	1	1
03/05/2015 20:00	0.4	12.6	2,050.6	0.3	1.3	1	1	1
03/05/2015 21:00	0.4	12.6	2,044.4	0.3	1.3	1	1	1
03/05/2015 22:00	0.4	12.7	2,035.2	0.3	1.3	1	1	1
03/05/2015 23:00	0.3	13.3	1,759.2	0.3	0.9	1	1	1
Average/Sum#:	0.2	13.3	1,716.7	0.2	18.2 #	24 #	24 #	15 #
Minimum:	0.1	12.5	1,294.8	0.1	0.2	1	1	0
Maximum:	0.4	13.9	2,052.3	0.3	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/06/2015 00:00	0.1	13.8	1,296.1	0.2	0.2	1	1	0
03/06/2015 01:00	0.1	13.8	1,295.0	0.1	0.2	1	1	0
03/06/2015 02:00	0.1	13.8	1,293.3	0.1	0.2	1	1	0
03/06/2015 03:00	0.1	13.8	1,294.5	0.1	0.2	1	1	0
03/06/2015 04:00	0.1	13.8	1,296.0	0.1	0.2	1	1	0
03/06/2015 05:00	0.2	13.6	1,571.1	0.1	0.6	1	1	1
03/06/2015 06:00	0.5	12.8	2,009.7	0.2	1.6	1	1	1
03/06/2015 07:00	0.3	13.2	1,966.9	0.3	1.0	1	1	1
03/06/2015 08:00	0.3	13.2	1,952.9	0.3	1.0	1	1	1
03/06/2015 09:00	0.4	13.2	1,949.3	0.2	1.3	1	1	1
03/06/2015 10:00	0.2	13.5	1,606.4	0.2	0.6	1	1	1
03/06/2015 11:00	0.1	13.8	1,294.5	0.2	0.2	1	1	0
03/06/2015 12:00	0.1	13.9	1,296.2	0.1	0.2	1	1	0
03/06/2015 13:00	0.1	13.9	1,299.2	0.1	0.2	1	1	0
03/06/2015 14:00	0.1	13.9	1,301.7	0.1	0.2	1	1	0
03/06/2015 15:00	0.1	13.9	1,301.3	0.1	0.2	1	1	0
03/06/2015 16:00	0.2	13.6	1,538.8	0.1	0.6	1	1	1
03/06/2015 17:00	0.4	12.5	2,022.2	0.2	1.3	1	1	1
03/06/2015 18:00	0.3	12.3	2,068.5	0.2	1.0	1	1	1
03/06/2015 19:00	0.3	12.3	2,067.7	0.2	1.0	1	1	1
03/06/2015 20:00	0.3	12.4	2,060.7	0.2	1.0	1	1	1
03/06/2015 21:00	0.3	12.7	2,013.4	0.2	1.0	1	1	1
03/06/2015 22:00	0.4	12.8	2,011.8	0.2	1.3	1	1	1
03/06/2015 23:00	0.4	12.8	1,992.8	0.3	1.3	1	1	1
Average/Sum#:	0.2	13.3	1,658.3	0.2	16.6 #	24 #	24 #	14 #
Minimum:	0.1	12.3	1,293.3	0.1	0.2	1	1	0
Maximum:	0.5	13.9	2,068.5	0.3	1.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/07/2015 00:00	0.3	13.1	1,868.9	0.3	0.9	1	1	1
03/07/2015 01:00	0.1	13.8	1,722.8	0.2	0.3	1	1	0
03/07/2015 02:00	14.5	16.0	496.7	0.0	3.9	1	0	0
03/07/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2015 14:00	21.4	16.9	546.5	0.0	27.0	1	0	0
03/07/2015 15:00	27.0	15.0	916.4	0.0	55.4	1	0	0
03/07/2015 16:00	0.2	13.5	1,706.8	0.0	0.6	1	1	1
03/07/2015 17:00	0.3	12.3	2,060.4	0.0	0.9	1	1	1
03/07/2015 18:00	0.3	12.5	2,032.7	0.2	1.0	1	1	1
03/07/2015 19:00	0.3	12.3	2,063.6	0.2	1.0	1	1	1
03/07/2015 20:00	0.3	12.3	2,063.9	0.2	1.0	1	1	1
03/07/2015 21:00	0.3	12.6	2,018.8	0.2	1.0	1	1	1
03/07/2015 22:00	0.4	12.8	2,008.8	0.2	1.3	1	1	1
03/07/2015 23:00	0.3	13.2	1,779.4	0.2	0.9	1	1	1
Average/Sum#:	5.1	13.6	1,637.4	0.2	95.2 #	13 #	10 #	9 #
Minimum:	0.1	12.3	496.7	0.2	0.3	0	0	0
Maximum:	27.0	16.9	2,063.9	0.3	55.4	1	1	1
%SI	45.8	45.8	45.8	66.7	45.8	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/08/2015 00:00	0.1	13.9	1,286.7	0.2	0.2	1	1	0
03/08/2015 01:00	0.1	13.8	1,287.2	0.1	0.2	1	1	0
03/08/2015 02:00	0.1	13.8	1,287.7	0.1	0.2	1	1	0
03/08/2015 03:00	0.1	13.8	1,288.8	0.1	0.2	1	1	0
03/08/2015 04:00	0.1	13.8	1,289.9	0.1	0.2	1	1	0
03/08/2015 05:00	0.2	13.8	1,289.3	0.1	0.5	1	1	0
03/08/2015 06:00	0.2	13.8	1,290.9	0.2	0.5	1	1	0
03/08/2015 07:00	0.1	13.8	1,292.0	0.2	0.2	1	1	0
03/08/2015 08:00	14.1	15.8	579.0	0.0	4.6	1	0	0
03/08/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2015 10:00	20.4	16.9	551.7	0.0	26.0	1	0	0
03/08/2015 11:00	17.4	14.6	1,112.4	0.0	40.6	1	0	0
03/08/2015 12:00	0.1	13.9	1,391.7	0.0	0.3	1	1	0
03/08/2015 13:00	0.1	13.9	1,394.5	0.0	0.3	1	1	0
03/08/2015 14:00	0.1	13.9	1,511.7	0.1	0.3	1	1	0
03/08/2015 15:00	0.1	13.9	1,399.8	0.1	0.3	1	1	0
03/08/2015 16:00	0.1	13.9	1,317.5	0.1	0.2	1	1	0
03/08/2015 17:00	0.1	13.9	1,296.8	0.1	0.2	1	1	0
03/08/2015 18:00	0.2	13.8	1,636.5	0.1	0.6	1	1	1
03/08/2015 19:00	0.1	13.7	1,759.7	0.1	0.3	1	1	0
03/08/2015 20:00	0.1	13.7	1,736.2	0.1	0.3	1	1	0
03/08/2015 21:00	0.2	13.9	1,416.7	0.1	0.5	1	1	1
03/08/2015 22:00	0.1	13.9	1,291.5	0.1	0.2	1	1	0
03/08/2015 23:00	0.2	13.9	1,290.2	0.2	0.5	1	1	0
Average/Sum#:	2.4	14.1	1,304.3	0.1	77.4 #	23 #	20 #	2 #
Minimum:	0.1	13.7	551.7	0.1	0.2	0	0	0
Maximum:	20.4	16.9	1,759.7	0.2	40.6	1	1	1
%SI	4.2	4.2	4.2	25.0	4.2	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/09/2015 00:00	0.2	13.8	1,287.7	0.2	0.5	1	1	0
03/09/2015 01:00	0.2	13.8	1,287.2	0.2	0.5	1	1	0
03/09/2015 02:00	0.2	13.8	1,286.7	0.2	0.5	1	1	0
03/09/2015 03:00	0.2	13.8	1,286.1	0.2	0.5	1	1	0
03/09/2015 04:00	0.2	13.7	1,402.8	0.2	0.5	1	1	1
03/09/2015 05:00	0.5	12.8	2,004.9	0.3	1.6	1	1	1
03/09/2015 06:00	0.4	12.6	2,050.5	0.3	1.3	1	1	1
03/09/2015 07:00	0.4	13.0	1,962.1	0.3	1.3	1	1	1
03/09/2015 08:00	0.4	13.1	1,938.3	0.3	1.3	1	1	1
03/09/2015 09:00	0.1	13.8	1,331.7	0.2	0.2	1	1	1
03/09/2015 10:00	0.1	13.8	1,289.2	0.2	0.2	1	1	0
03/09/2015 11:00	0.1	13.9	1,289.5	0.1	0.2	1	1	0
03/09/2015 12:00	0.1	13.9	1,290.4	0.1	0.2	1	1	0
03/09/2015 13:00	0.1	13.9	1,296.0	0.1	0.2	1	1	0
03/09/2015 14:00	0.2	13.5	1,626.5	0.1	0.6	1	1	1
03/09/2015 15:00	0.1	13.9	1,289.6	0.1	0.2	1	1	0
03/09/2015 16:00	0.1	13.9	1,288.8	0.1	0.2	1	1	0
03/09/2015 17:00	0.4	13.1	1,728.5	0.2	1.2	1	1	1
03/09/2015 18:00	0.4	12.3	2,056.2	0.2	1.3	1	1	1
03/09/2015 19:00	0.4	12.4	2,056.9	0.3	1.3	1	1	1
03/09/2015 20:00	0.4	12.5	2,035.0	0.3	1.3	1	1	1
03/09/2015 21:00	0.4	12.8	1,986.2	0.3	1.3	1	1	1
03/09/2015 22:00	0.4	12.7	2,014.0	0.3	1.3	1	1	1
03/09/2015 23:00	0.4	12.9	1,964.8	0.3	1.3	1	1	1
Average/Sum#:	0.3	13.3	1,627.1	0.2	19.0 #	24 #	24 #	14 #
Minimum:	0.1	12.3	1,286.1	0.1	0.2	1	1	0
Maximum:	0.5	13.9	2,056.9	0.3	1.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/10/2015 00:00	0.4	13.0	1,955.6	0.3	1.3	1	1	1
03/10/2015 01:00	0.4	12.8	1,993.5	0.3	1.3	1	1	1
03/10/2015 02:00	0.4	13.0	1,943.9	0.3	1.3	1	1	1
03/10/2015 03:00	0.4	13.0	1,944.1	0.3	1.3	1	1	1
03/10/2015 04:00	0.4	12.9	1,955.7	0.3	1.3	1	1	1
03/10/2015 05:00	0.4	12.8	2,002.7	0.3	1.3	1	1	1
03/10/2015 06:00	0.4	12.6	2,043.9	0.3	1.3	1	1	1
03/10/2015 07:00	0.4	12.8	1,999.1	0.3	1.3	1	1	1
03/10/2015 08:00	0.3	13.3	1,790.9	0.3	0.9	1	1	1
03/10/2015 09:00	0.1	13.8	1,414.1	0.2	0.3	1	1	0
03/10/2015 10:00	0.1	13.8	1,290.9	0.1	0.2	1	1	0
03/10/2015 11:00	0.1	13.8	1,291.1	0.1	0.2	1	1	0
03/10/2015 12:00	0.1	13.8	1,291.4	0.1	0.2	1	1	0
03/10/2015 13:00	0.1	13.8	1,291.8	0.1	0.2	1	1	0
03/10/2015 14:00	0.1	13.8	1,291.9	0.1	0.2	1	1	0
03/10/2015 15:00	0.1	13.8	1,291.5	0.1	0.2	1	1	0
03/10/2015 16:00	0.2	13.8	1,402.9	0.1	0.5	1	1	1
03/10/2015 17:00	0.4	12.4	2,047.7	0.2	1.3	1	1	1
03/10/2015 18:00	0.4	12.3	2,054.6	0.3	1.3	1	1	1
03/10/2015 19:00	0.4	12.3	2,058.7	0.3	1.3	1	1	1
03/10/2015 20:00	0.4	12.4	2,057.3	0.3	1.3	1	1	1
03/10/2015 21:00	0.4	12.6	2,010.7	0.3	1.3	1	1	1
03/10/2015 22:00	0.2	13.3	1,679.4	0.3	0.6	1	1	1
03/10/2015 23:00	0.1	13.8	1,288.1	0.2	0.2	1	1	0
Average/Sum#:	0.3	13.2	1,724.6	0.2	20.6 #	24 #	24 #	16 #
Minimum:	0.1	12.3	1,288.1	0.1	0.2	1	1	0
Maximum:	0.4	13.8	2,058.7	0.3	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/11/2015 00:00	0.1	13.8	1,287.7	0.1	0.2	1	1	0
03/11/2015 01:00	0.1	13.8	1,289.0	0.1	0.2	1	1	0
03/11/2015 02:00	0.2	13.8	1,288.7	0.1	0.5	1	1	0
03/11/2015 03:00	0.2	13.8	1,288.6	0.2	0.5	1	1	0
03/11/2015 04:00	0.2	13.8	1,404.9	0.2	0.5	1	1	1
03/11/2015 05:00	0.4	13.0	1,951.4	0.2	1.3	1	1	1
03/11/2015 06:00	0.4	12.8	1,984.7	0.3	1.3	1	1	1
03/11/2015 07:00	0.4	12.6	2,047.0	0.3	1.3	1	1	1
03/11/2015 08:00	0.4	12.6	2,046.7	0.3	1.3	1	1	1
03/11/2015 09:00	0.4	12.6	2,047.6	0.3	1.3	1	1	1
03/11/2015 10:00	0.4	12.5	2,056.5	0.3	1.3	1	1	1
03/11/2015 11:00	0.4	12.5	2,059.0	0.3	1.3	1	1	1
03/11/2015 12:00	0.4	12.5	2,059.1	0.3	1.3	1	1	1
03/11/2015 13:00	0.4	12.5	2,061.3	0.3	1.3	1	1	1
03/11/2015 14:00	0.4	12.5	2,058.1	0.3	1.3	1	1	1
03/11/2015 15:00	0.4	12.5	2,052.4	0.3	1.3	1	1	1
03/11/2015 16:00	0.4	12.5	2,052.0	0.3	1.3	1	1	1
03/11/2015 17:00	0.3	12.9	1,974.6	0.3	1.0	1	1	1
03/11/2015 18:00	0.4	12.5	2,051.9	0.3	1.3	1	1	1
03/11/2015 19:00	0.4	12.6	2,050.7	0.3	1.3	1	1	1
03/11/2015 20:00	0.4	12.8	2,001.1	0.3	1.3	1	1	1
03/11/2015 21:00	0.2	13.5	1,597.0	0.3	0.6	1	1	1
03/11/2015 22:00	0.1	13.8	1,292.7	0.2	0.2	1	1	0
03/11/2015 23:00	0.1	13.8	1,295.9	0.1	0.2	1	1	0
Average/Sum#:	0.3	13.0	1,804.1	0.3	23.4 #	24 #	24 #	18 #
Minimum:	0.1	12.5	1,287.7	0.1	0.2	1	1	0
Maximum:	0.4	13.8	2,061.3	0.3	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/12/2015 00:00	0.1	13.8	1,298.8	0.1	0.2	1	1	0
03/12/2015 01:00	0.1	13.8	1,304.9	0.1	0.2	1	1	0
03/12/2015 02:00	0.1	13.8	1,308.5	0.1	0.2	1	1	0
03/12/2015 03:00	0.1	13.8	1,307.0	0.1	0.2	1	1	0
03/12/2015 04:00	0.1	13.8	1,427.1	0.1	0.3	1	1	1
03/12/2015 05:00	0.4	13.1	1,947.2	0.2	1.3	1	1	1
03/12/2015 06:00	0.4	12.6	2,051.5	0.2	1.3	1	1	1
03/12/2015 07:00	0.4	12.5	2,051.3	0.3	1.3	1	1	1
03/12/2015 08:00	0.3	12.8	1,993.9	0.3	1.0	1	1	1
03/12/2015 09:00	0.3	13.0	1,956.0	0.2	1.0	1	1	1
03/12/2015 10:00	0.3	13.0	1,945.2	0.2	1.0	1	1	1
03/12/2015 11:00	0.1	13.8	1,350.5	0.2	0.3	1	1	0
03/12/2015 12:00	0.1	13.8	1,293.5	0.1	0.2	1	1	0
03/12/2015 13:00	0.1	13.8	1,293.3	0.1	0.2	1	1	0
03/12/2015 14:00	0.1	13.8	1,293.1	0.1	0.2	1	1	0
03/12/2015 15:00	0.1	13.8	1,292.6	0.1	0.2	1	1	0
03/12/2015 16:00	0.2	13.6	1,537.1	0.1	0.6	1	1	1
03/12/2015 17:00	0.4	12.5	2,047.5	0.2	1.3	1	1	1
03/12/2015 18:00	0.4	12.5	2,058.7	0.3	1.3	1	1	1
03/12/2015 19:00	0.4	12.5	2,061.0	0.3	1.3	1	1	1
03/12/2015 20:00	0.4	12.5	2,062.8	0.3	1.3	1	1	1
03/12/2015 21:00	0.4	12.5	2,057.0	0.3	1.3	1	1	1
03/12/2015 22:00	0.3	13.1	1,796.4	0.3	0.9	1	1	1
03/12/2015 23:00	0.1	13.9	1,382.0	0.2	0.3	1	1	0
Average/Sum#:	0.2	13.3	1,671.5	0.2	17.4 #	24 #	24 #	14 #
Minimum:	0.1	12.5	1,292.6	0.1	0.2	1	1	0
Maximum:	0.4	13.9	2,062.8	0.3	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/13/2015 00:00	0.1	13.9	1,379.4	0.1	0.3	1	1	0
03/13/2015 01:00	0.1	13.8	1,416.3	0.1	0.3	1	1	0
03/13/2015 02:00	0.1	13.8	1,536.5	0.1	0.3	1	1	0
03/13/2015 03:00	0.1	13.8	1,410.3	0.1	0.3	1	1	0
03/13/2015 04:00	0.2	13.6	1,557.0	0.1	0.6	1	1	1
03/13/2015 05:00	0.4	12.9	1,999.6	0.2	1.3	1	1	1
03/13/2015 06:00	0.4	12.8	2,023.4	0.3	1.3	1	1	1
03/13/2015 07:00	0.3	13.2	1,939.4	0.3	1.0	1	1	1
03/13/2015 08:00	0.3	13.1	1,939.1	0.2	1.0	1	1	1
03/13/2015 09:00	0.3	13.0	1,944.9	0.2	1.0	1	1	1
03/13/2015 10:00	0.2	13.4	1,636.5	0.2	0.6	1	1	1
03/13/2015 11:00	0.1	13.8	1,295.2	0.2	0.2	1	1	0
03/13/2015 12:00	0.1	13.8	1,399.5	0.1	0.3	1	1	1
03/13/2015 13:00	0.4	12.7	1,988.7	0.2	1.3	1	1	1
03/13/2015 14:00	0.4	12.6	1,999.1	0.2	1.3	1	1	1
03/13/2015 15:00	0.4	12.4	2,043.3	0.3	1.3	1	1	1
03/13/2015 16:00	0.4	12.3	2,052.8	0.3	1.3	1	1	1
03/13/2015 17:00	0.4	12.3	2,058.5	0.3	1.3	1	1	1
03/13/2015 18:00	0.4	12.4	2,054.5	0.3	1.3	1	1	1
03/13/2015 19:00	0.4	12.4	2,046.6	0.3	1.3	1	1	1
03/13/2015 20:00	0.4	12.4	2,050.4	0.3	1.3	1	1	1
03/13/2015 21:00	0.4	12.5	2,027.6	0.3	1.3	1	1	1
03/13/2015 22:00	0.4	12.5	2,036.0	0.3	1.3	1	1	1
03/13/2015 23:00	0.4	12.4	2,045.6	0.3	1.3	1	1	1
Average/Sum#:	0.3	13.0	1,828.3	0.2	22.8 #	24 #	24 #	19 #
Minimum:	0.1	12.3	1,295.2	0.1	0.2	1	1	0
Maximum:	0.4	13.9	2,058.5	0.3	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/14/2015 00:00	0.4	12.7	2,001.8	0.3	1.3	1	1	1
03/14/2015 01:00	0.4	12.7	2,004.2	0.3	1.3	1	1	1
03/14/2015 02:00	0.4	12.8	1,991.2	0.3	1.3	1	1	1
03/14/2015 03:00	0.3	13.0	1,953.1	0.3	1.0	1	1	1
03/14/2015 04:00	0.3	13.0	1,947.3	0.2	1.0	1	1	1
03/14/2015 05:00	0.3	13.0	1,951.7	0.2	1.0	1	1	1
03/14/2015 06:00	0.4	12.5	2,050.3	0.2	1.3	1	1	1
03/14/2015 07:00	0.4	12.6	2,019.3	0.3	1.3	1	1	1
03/14/2015 08:00	0.3	12.8	1,979.1	0.3	1.0	1	1	1
03/14/2015 09:00	0.3	12.8	1,975.1	0.2	1.0	1	1	1
03/14/2015 10:00	0.3	12.8	1,975.1	0.2	1.0	1	1	1
03/14/2015 11:00	0.3	12.8	1,974.3	0.2	1.0	1	1	1
03/14/2015 12:00	0.4	12.4	2,041.1	0.2	1.3	1	1	1
03/14/2015 13:00	0.3	12.3	2,056.8	0.2	0.9	1	1	1
03/14/2015 14:00	0.3	12.3	2,058.8	0.2	0.9	1	1	1
03/14/2015 15:00	0.3	12.4	2,027.2	0.2	0.9	1	1	1
03/14/2015 16:00	0.3	12.2	2,062.9	0.2	0.9	1	1	1
03/14/2015 17:00	0.3	12.3	2,061.7	0.2	0.9	1	1	1
03/14/2015 18:00	0.3	12.3	2,059.9	0.2	0.9	1	1	1
03/14/2015 19:00	0.3	12.3	2,057.2	0.2	0.9	1	1	1
03/14/2015 20:00	0.3	12.3	2,056.8	0.2	0.9	1	1	1
03/14/2015 21:00	0.4	12.4	2,056.3	0.2	1.3	1	1	1
03/14/2015 22:00	0.4	12.4	2,053.2	0.3	1.3	1	1	1
03/14/2015 23:00	0.4	12.5	2,020.9	0.3	1.3	1	1	1
Average/Sum#:	0.3	12.6	2,018.1	0.2	25.9 #	24 #	24 #	24 #
Minimum:	0.3	12.2	1,947.3	0.2	0.9	1	1	1
Maximum:	0.4	13.0	2,062.9	0.3	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/15/2015 00:00	0.3	12.8	1,969.7	0.3	1.0	1	1	1
03/15/2015 01:00	0.4	12.6	2,006.5	0.3	1.3	1	1	1
03/15/2015 02:00	0.2	13.1	1,822.3	0.2	0.6	1	1	1
03/15/2015 03:00	0.1	13.7	1,781.9	0.2	0.3	1	1	0
03/15/2015 04:00	0.1	13.6	1,799.8	0.1	0.3	1	1	0
03/15/2015 05:00	0.1	13.7	1,763.4	0.1	0.3	1	1	0
03/15/2015 06:00	0.1	13.6	1,804.8	0.1	0.3	1	1	0
03/15/2015 07:00	0.1	13.7	1,565.4	0.1	0.3	1	1	0
03/15/2015 08:00	0.1	13.8	1,296.7	0.1	0.2	1	1	0
03/15/2015 09:00	0.1	13.9	1,299.1	0.1	0.2	1	1	0
03/15/2015 10:00	0.1	13.9	1,300.9	0.1	0.2	1	1	0
03/15/2015 11:00	0.1	13.8	1,576.9	0.1	0.3	1	1	0
03/15/2015 12:00	0.1	13.8	1,763.2	0.1	0.3	1	1	0
03/15/2015 13:00	0.4	13.0	1,919.9	0.2	1.3	1	1	1
03/15/2015 14:00	0.4	12.5	2,064.1	0.2	1.3	1	1	1
03/15/2015 15:00	0.4	12.5	2,052.6	0.3	1.3	1	1	1
03/15/2015 16:00	0.4	12.5	2,059.2	0.3	1.3	1	1	1
03/15/2015 17:00	0.4	12.5	2,057.7	0.3	1.3	1	1	1
03/15/2015 18:00	0.4	12.5	2,053.6	0.3	1.3	1	1	1
03/15/2015 19:00	0.4	12.5	2,055.1	0.3	1.3	1	1	1
03/15/2015 20:00	0.4	12.5	2,054.6	0.3	1.3	1	1	1
03/15/2015 21:00	0.4	12.5	2,047.5	0.3	1.3	1	1	1
03/15/2015 22:00	0.3	13.0	1,852.7	0.3	0.9	1	1	1
03/15/2015 23:00	0.1	13.8	1,294.3	0.2	0.2	1	1	0
Average/Sum#:	0.2	13.2	1,802.6	0.2	18.4 #	24 #	24 #	13 #
Minimum:	0.1	12.5	1,294.3	0.1	0.2	1	1	0
Maximum:	0.4	13.9	2,064.1	0.3	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/16/2015 00:00	0.1	13.8	1,292.2	0.1	0.2	1	1	0
03/16/2015 01:00	0.1	13.8	1,289.9	0.1	0.2	1	1	0
03/16/2015 02:00	0.1	13.8	1,291.4	0.1	0.2	1	1	0
03/16/2015 03:00	0.1	13.8	1,294.5	0.1	0.2	1	1	0
03/16/2015 04:00	0.2	13.5	1,558.4	0.1	0.6	1	1	1
03/16/2015 05:00	0.4	12.7	2,016.3	0.2	1.3	1	1	1
03/16/2015 06:00	0.4	12.5	2,057.1	0.3	1.3	1	1	1
03/16/2015 07:00	0.4	12.8	2,008.7	0.3	1.3	1	1	1
03/16/2015 08:00	0.4	12.6	2,050.1	0.3	1.3	1	1	1
03/16/2015 09:00	0.4	12.5	2,054.9	0.3	1.3	1	1	1
03/16/2015 10:00	0.4	12.6	2,041.6	0.3	1.3	1	1	1
03/16/2015 11:00	0.4	12.5	2,056.0	0.3	1.3	1	1	1
03/16/2015 12:00	0.4	12.5	2,052.5	0.3	1.3	1	1	1
03/16/2015 13:00	0.4	12.5	2,053.6	0.3	1.3	1	1	1
03/16/2015 14:00	0.3	12.5	2,052.9	0.3	1.0	1	1	1
03/16/2015 15:00	0.4	12.5	2,044.9	0.3	1.3	1	1	1
03/16/2015 16:00	0.3	12.7	2,005.4	0.2	1.0	1	1	1
03/16/2015 17:00	0.3	12.8	1,976.3	0.2	1.0	1	1	1
03/16/2015 18:00	0.4	12.6	2,032.7	0.2	1.3	1	1	1
03/16/2015 19:00	0.4	12.5	2,049.6	0.3	1.3	1	1	1
03/16/2015 20:00	0.3	12.7	2,010.1	0.3	1.0	1	1	1
03/16/2015 21:00	0.3	12.8	1,978.1	0.2	1.0	1	1	1
03/16/2015 22:00	0.1	13.7	1,457.7	0.2	0.3	1	1	1
03/16/2015 23:00	0.1	13.8	1,292.7	0.1	0.2	1	1	0
Average/Sum#:	0.3	12.9	1,834.1	0.2	22.5 #	24 #	24 #	19 #
Minimum:	0.1	12.5	1,289.9	0.1	0.2	1	1	0
Maximum:	0.4	13.8	2,057.1	0.3	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/17/2015 00:00	0.1	13.8	1,291.3	0.1	0.2	1	1	0
03/17/2015 01:00	0.1	13.8	1,291.9	0.1	0.2	1	1	0
03/17/2015 02:00	0.1	13.8	1,292.1	0.1	0.2	1	1	0
03/17/2015 03:00	0.1	13.8	1,292.8	0.1	0.2	1	1	0
03/17/2015 04:00	0.1	13.8	1,292.4	0.1	0.2	1	1	0
03/17/2015 05:00	0.1	13.8	1,292.3	0.1	0.2	1	1	0
03/17/2015 06:00	0.1	13.8	1,292.5	0.1	0.2	1	1	0
03/17/2015 07:00	0.1	13.8	1,291.2	0.1	0.2	1	1	0
03/17/2015 08:00	0.1	13.8	1,293.0	0.1	0.2	1	1	0
03/17/2015 09:00	0.1	13.8	1,295.6	0.1	0.2	1	1	0
03/17/2015 10:00	0.1	13.8	1,299.0	0.1	0.2	1	1	0
03/17/2015 11:00	0.1	13.8	1,298.7	0.1	0.2	1	1	0
03/17/2015 12:00	0.1	13.8	1,300.8	0.1	0.2	1	1	0
03/17/2015 13:00	0.1	13.8	1,302.4	0.1	0.2	1	1	0
03/17/2015 14:00	0.1	13.8	1,303.0	0.1	0.2	1	1	0
03/17/2015 15:00	0.1	13.9	1,302.2	0.1	0.2	1	1	0
03/17/2015 16:00	0.1	13.9	1,299.8	0.1	0.2	1	1	0
03/17/2015 17:00	0.1	13.9	1,299.6	0.1	0.2	1	1	0
03/17/2015 18:00	0.1	13.9	1,298.0	0.1	0.2	1	1	0
03/17/2015 19:00	0.1	13.9	1,296.5	0.1	0.2	1	1	0
03/17/2015 20:00	0.1	13.8	1,294.6	0.1	0.2	1	1	0
03/17/2015 21:00	0.1	13.9	1,294.8	0.1	0.2	1	1	0
03/17/2015 22:00	0.1	13.9	1,292.8	0.1	0.2	1	1	0
03/17/2015 23:00	0.1	13.8	1,288.5	0.1	0.2	1	1	0
Average/Sum#:	0.1	13.8	1,295.7	0.1	4.8 #	24 #	24 #	0 #
Minimum:	0.1	13.8	1,288.5	0.1	0.2	1	1	0
Maximum:	0.1	13.9	1,303.0	0.1	0.2	1	1	0
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/18/2015 00:00	0.1	13.8	1,287.9	0.1	0.2	1	1	0
03/18/2015 01:00	0.1	13.9	1,291.9	0.1	0.2	1	1	0
03/18/2015 02:00	0.1	13.9	1,302.5	0.1	0.2	1	1	0
03/18/2015 03:00	0.1	13.9	1,304.6	0.1	0.2	1	1	0
03/18/2015 04:00	0.1	13.9	1,304.5	0.1	0.2	1	1	0
03/18/2015 05:00	0.1	13.9	1,303.3	0.1	0.2	1	1	0
03/18/2015 06:00	0.0	13.9	1,302.9	0.0	0.0	1	1	0
03/18/2015 07:00	0.0	13.9	1,301.9	0.0	0.0	1	1	0
03/18/2015 08:00	0.0	13.9	1,302.4	0.0	0.0	1	1	0
03/18/2015 09:00	0.0	13.9	1,300.7	0.0	0.0	1	0	0
03/18/2015 10:00	0.0	0.0	1,302.2	0.0	0.0	1	0	0
03/18/2015 11:00	0.0	13.9	1,300.9	0.0	0.0	1	0	0
03/18/2015 12:00	0.0	13.9	1,298.9	0.0	0.0	1	1	0
03/18/2015 13:00	0.0	13.9	1,298.4	0.0	0.0	1	1	0
03/18/2015 14:00	0.0	13.9	1,315.0	0.0	0.0	1	1	0
03/18/2015 15:00	0.0	13.8	1,665.4	0.0	0.0	1	1	0
03/18/2015 16:00	0.0	13.8	1,686.1	0.0	0.0	1	1	0
03/18/2015 17:00	0.0	13.9	1,285.3	0.0	0.0	1	1	0
03/18/2015 18:00	0.0	13.9	1,286.7	0.0	0.0	1	1	0
03/18/2015 19:00	0.0	13.9	1,285.8	0.0	0.0	1	1	0
03/18/2015 20:00	0.0	13.9	1,287.9	0.0	0.0	1	1	0
03/18/2015 21:00	0.0	13.9	1,289.5	0.0	0.0	1	1	0
03/18/2015 22:00	0.0	13.9	1,286.0	0.0	0.0	1	1	0
03/18/2015 23:00	0.0	13.9	1,285.0	0.0	0.0	1	1	0
Average/Sum#:	0.1	13.9	1,328.2	0.1	1.2 #	24 #	21 #	0 #
Minimum:	0.1	13.8	1,285.0	0.1	0.2	1	0	0
Maximum:	0.1	13.9	1,686.1	0.1	0.2	1	1	0
%SI	75.0	4.2	0.0	75.0	75.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/19/2015 00:00	0.0	13.9	1,285.3	0.0	0.0	1	1	0
03/19/2015 01:00	0.0	13.9	1,283.8	0.0	0.0	1	1	0
03/19/2015 02:00	0.0	13.9	1,283.8	0.0	0.0	1	1	0
03/19/2015 03:00	0.0	13.9	1,285.7	0.0	0.0	1	1	0
03/19/2015 04:00	0.2	13.9	1,287.4	0.0	0.5	1	1	0
03/19/2015 05:00	0.2	13.9	1,293.5	0.0	0.5	1	1	0
03/19/2015 06:00	0.2	13.9	1,409.6	0.2	0.5	1	1	1
03/19/2015 07:00	0.5	12.9	1,990.1	0.3	1.6	1	1	1
03/19/2015 08:00	0.4	13.1	1,939.4	0.3	1.3	1	1	1
03/19/2015 09:00	0.4	13.0	1,946.7	0.3	1.3	1	1	1
03/19/2015 10:00	0.4	13.0	1,953.1	0.3	1.3	1	1	1
03/19/2015 11:00	0.4	12.9	1,977.3	0.3	1.3	1	1	1
03/19/2015 12:00	0.4	12.5	2,037.8	0.3	1.3	1	1	1
03/19/2015 13:00	0.4	12.8	1,983.0	0.3	1.3	1	1	1
03/19/2015 14:00	0.2	13.5	1,573.8	0.3	0.6	1	1	1
03/19/2015 15:00	0.1	13.9	1,324.9	0.2	0.2	1	1	0
03/19/2015 16:00	0.1	13.9	1,396.2	0.1	0.3	1	1	1
03/19/2015 17:00	0.4	12.9	1,959.3	0.2	1.3	1	1	1
03/19/2015 18:00	0.4	12.7	2,001.6	0.2	1.3	1	1	1
03/19/2015 19:00	0.4	12.4	2,062.5	0.3	1.3	1	1	1
03/19/2015 20:00	0.3	12.9	1,966.9	0.3	1.0	1	1	1
03/19/2015 21:00	0.3	13.2	1,753.1	0.2	0.9	1	1	1
03/19/2015 22:00	0.1	13.8	1,465.7	0.2	0.3	1	1	0
03/19/2015 23:00	0.1	13.8	1,309.9	0.1	0.2	1	1	0
Average/Sum#:	0.3	13.4	1,657.1	0.2	18.3 #	24 #	24 #	15 #
Minimum:	0.1	12.4	1,283.8	0.1	0.2	1	1	0
Maximum:	0.5	13.9	2,062.5	0.3	1.6	1	1	1
%SI	16.7	0.0	0.0	25.0	16.7	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/20/2015 00:00	0.2	13.9	1,451.5	0.1	0.5	1	1	0
03/20/2015 01:00	0.2	13.8	1,301.1	0.2	0.5	1	1	0
03/20/2015 02:00	0.2	13.7	1,678.7	0.2	0.6	1	1	0
03/20/2015 03:00	0.2	13.8	1,320.9	0.2	0.5	1	1	0
03/20/2015 04:00	0.3	13.4	1,676.5	0.2	0.9	1	1	1
03/20/2015 05:00	0.5	12.8	2,003.1	0.3	1.6	1	1	1
03/20/2015 06:00	0.5	12.6	2,044.9	0.3	1.6	1	1	1
03/20/2015 07:00	0.0	0.0	1,971.4	0.0	0.0	1	1	1
03/20/2015 08:00	0.0	0.0	1,931.4	0.0	0.0	1	1	1
03/20/2015 09:00	0.0	0.0	1,805.5	0.0	0.0	1	1	0
03/20/2015 10:00	0.0	0.0	1,807.5	0.0	0.0	1	1	0
03/20/2015 11:00	0.2	13.4	1,817.4	0.0	0.6	1	1	1
03/20/2015 12:00	0.4	12.8	1,993.7	0.0	1.3	1	1	1
03/20/2015 13:00	0.4	12.6	2,013.6	0.3	1.3	1	1	1
03/20/2015 14:00	0.4	12.7	1,986.2	0.3	1.3	1	1	1
03/20/2015 15:00	0.4	12.7	1,980.5	0.3	1.3	1	1	1
03/20/2015 16:00	0.3	12.9	1,950.5	0.3	1.0	1	1	1
03/20/2015 17:00	0.3	12.9	1,947.3	0.2	1.0	1	1	1
03/20/2015 18:00	0.3	12.9	1,954.3	0.2	1.0	1	1	1
03/20/2015 19:00	0.3	12.9	1,948.7	0.2	1.0	1	1	1
03/20/2015 20:00	0.3	12.9	1,947.5	0.2	1.0	1	1	1
03/20/2015 21:00	0.3	13.0	1,948.7	0.2	1.0	1	1	1
03/20/2015 22:00	0.2	13.4	1,723.6	0.2	0.6	1	1	1
03/20/2015 23:00	0.1	13.8	1,292.0	0.2	0.2	1	1	0
Average/Sum#:	0.3	13.1	1,812.4	0.2	18.8 #	24 #	24 #	17 #
Minimum:	0.1	12.6	1,292.0	0.1	0.2	1	1	0
Maximum:	0.5	13.9	2,044.9	0.3	1.6	1	1	1
%SI	16.7	16.7	0.0	25.0	16.7	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/21/2015 00:00	0.1	13.8	1,287.4	0.1	0.2	1	1	0
03/21/2015 01:00	0.1	13.8	1,533.2	0.1	0.3	1	1	0
03/21/2015 02:00	0.1	13.8	1,338.6	0.1	0.2	1	1	0
03/21/2015 03:00	0.1	13.8	1,556.3	0.1	0.3	1	1	0
03/21/2015 04:00	0.1	13.8	1,583.8	0.1	0.3	1	1	0
03/21/2015 05:00	0.2	13.7	1,491.5	0.1	0.5	1	1	1
03/21/2015 06:00	0.3	13.0	1,989.6	0.2	1.0	1	1	1
03/21/2015 07:00	0.3	13.3	1,777.4	0.2	0.9	1	1	1
03/21/2015 08:00	0.1	13.8	1,346.1	0.2	0.3	1	1	0
03/21/2015 09:00	0.1	13.8	1,307.8	0.1	0.2	1	1	0
03/21/2015 10:00	0.1	13.8	1,312.2	0.1	0.2	1	1	0
03/21/2015 11:00	0.1	13.8	1,315.0	0.1	0.2	1	1	0
03/21/2015 12:00	0.1	13.9	1,344.0	0.1	0.3	1	1	0
03/21/2015 13:00	0.1	13.9	1,312.9	0.1	0.2	1	1	0
03/21/2015 14:00	0.1	13.9	1,404.3	0.1	0.3	1	1	0
03/21/2015 15:00	0.1	13.9	1,491.2	0.1	0.3	1	1	0
03/21/2015 16:00	0.1	13.8	1,641.6	0.1	0.3	1	1	0
03/21/2015 17:00	0.3	13.1	1,810.5	0.1	0.9	1	1	1
03/21/2015 18:00	0.4	12.6	2,013.6	0.2	1.3	1	1	1
03/21/2015 19:00	0.4	12.6	2,015.0	0.3	1.3	1	1	1
03/21/2015 20:00	0.4	12.6	2,034.4	0.3	1.3	1	1	1
03/21/2015 21:00	0.4	12.7	2,009.1	0.3	1.3	1	1	1
03/21/2015 22:00	0.2	13.4	1,787.0	0.3	0.6	1	1	1
03/21/2015 23:00	0.1	13.7	1,755.4	0.2	0.3	1	1	0
Average/Sum#:	0.2	13.5	1,602.4	0.2	13.0 #	24 #	24 #	9 #
Minimum:	0.1	12.6	1,287.4	0.1	0.2	1	1	0
Maximum:	0.4	13.9	2,034.4	0.3	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/22/2015 00:00	0.1	13.6	1,806.6	0.1	0.3	1	1	0
03/22/2015 01:00	0.1	13.8	1,607.1	0.1	0.3	1	1	0
03/22/2015 02:00	0.1	13.7	1,654.4	0.1	0.3	1	1	0
03/22/2015 03:00	0.1	13.8	1,760.9	0.1	0.3	1	1	0
03/22/2015 04:00	0.1	13.8	1,523.2	0.1	0.3	1	1	0
03/22/2015 05:00	0.1	13.8	1,596.0	0.1	0.3	1	1	0
03/22/2015 06:00	0.1	13.8	1,643.3	0.1	0.3	1	1	0
03/22/2015 07:00	0.2	13.5	1,662.4	0.1	0.6	1	1	1
03/22/2015 08:00	0.4	12.5	2,044.8	0.2	1.3	1	1	1
03/22/2015 09:00	0.3	12.5	2,015.3	0.2	1.0	1	1	1
03/22/2015 10:00	0.3	12.8	1,953.9	0.2	1.0	1	1	1
03/22/2015 11:00	0.3	12.7	1,961.5	0.2	0.9	1	1	1
03/22/2015 12:00	0.3	12.8	1,976.8	0.2	1.0	1	1	1
03/22/2015 13:00	0.2	13.4	1,698.3	0.2	0.6	1	1	1
03/22/2015 14:00	0.1	13.8	1,609.1	0.2	0.3	1	1	0
03/22/2015 15:00	0.1	13.8	1,607.9	0.1	0.3	1	1	0
03/22/2015 16:00	0.1	13.9	1,565.1	0.1	0.3	1	1	0
03/22/2015 17:00	0.3	13.3	1,718.5	0.1	0.9	1	1	1
03/22/2015 18:00	0.4	12.7	2,017.0	0.2	1.3	1	1	1
03/22/2015 19:00	0.4	12.8	2,002.4	0.3	1.3	1	1	1
03/22/2015 20:00	0.3	12.9	1,976.6	0.3	1.0	1	1	1
03/22/2015 21:00	0.1	13.6	1,462.2	0.2	0.3	1	1	1
03/22/2015 22:00	0.1	13.8	1,301.0	0.1	0.2	1	1	0
03/22/2015 23:00	15.8	16.3	439.6	0.0	4.0	1	0	0
Average/Sum#:	0.9	13.5	1,691.8	0.2	18.4 #	24 #	23 #	12 #
Minimum:	0.1	12.5	439.6	0.1	0.2	1	0	0
Maximum:	15.8	16.3	2,044.8	0.3	4.0	1	1	1
%SI	0.0	0.0	0.0	4.2	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/23/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/24/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/25/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/26/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/27/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/28/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/28/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/29/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/29/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/30/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/30/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report

CT2 - CO

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:39 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/31/2015 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2015 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

ATTACHMENT 8
Hourly Emissions CO

FCD: AQ-18
Title V: #6

AQ-18

Pursuant to the CEC conditions of certification, AQ-18 requires that a calculation be developed to determine the ammonia slip emissions, using source test data, based on NOx concentration and Ammonia Injection Rate. AQ-18 reads as follows:

AQ-18 Ammonia slip shall be limited to 5.0 ppmvd @ 15% O_2 over one hour. Formaldehyde emissions will be limited to 0.917 lbs per million standard cubic feet (MMscf) of natural gas. Maximum hourly steady state emission limits for each CTG are:

Pounds NH_3 with Duct Firing Pounds: 19.2

NH_3 without Duct Firing: 14.2

Verification: The project owner shall submit to the CPM and APCO CTG emissions data demonstrating compliance with this condition as part of the Quarterly Operation Reports (AQ-22). The project owner shall provide approval of the CPM and APCO a calculation method to determine the ammonia slip emissions, using source test data, based on the NO_x concentration and the ammonia injection rate; and this calculation shall be revised for approval as necessary after each source test performed under AQ-9.

<u>Calculation</u>

The Calculation used is the standard calculation for determining slip. The constant was updated using 2013 Source Test Data. The correction calculations is attached.

(((NH3Inj_LbPerHr_1H/MoleWtNH3_constant)/(ExhaustFlow_LbPerHr_1H/MoleWtExhaustGas const*1000000)-(NOxInlet_Ppmvdc_1H-NOx_Ppmvdc_1J))*NH3 Correction Constant

Correction Constant

CT1 - .0198

CT2 - .0146

Ammonia Correction Constant Calculations Yellow cells are user input values. **Page 1** **Page 2**

Site ID: PG&E Colusa GS

Unit ID:		1	1	1	2	2	2	1	1	1	2	2	2	1	1	1	2	2	2	1	1	1	2	2	2
Load Condition:		Min Load	Min Load	Min Load	Min Load	Min Load	Min Load	Mid Load	Mid Load	Mid Load	Mid Load	Mid Load	Mid Load	Base wo DB	Base wo DB	Base wo DB	Base wo DB	Base wo DB	Base wo DB	Max w DB	Max w DB	Max w DB	Max w DB	Max w DB	Max w DB
Test Date:		11/17/2014	11/17/2014	11/17/2014	11/19/2014	11/19/2014	11/19/2014	11/17/2014	11/17/2014	11/17/2014	11/19/2014	11/19/2014	11/19/2014	11/17/2014	11/17/2014	11/17/2014	11/19/2014	11/19/2014	11/19/2014	11/18/2014	11/18/2014	11/18/2014	11/20/2014	11/20/2014	11/20/2014
Test Duration, minutes:		40	38	38	32	32	32	32	32	32	32	32	32	32	32	32	32	32	32	32	32	32	32	32	32
NH3 Conc, ppm volume dry:		1.72	1.6	1.52	1.03	0.93	0.69	1.87	1.83	1.24	1.23	0.79	0.81	1.82	2.1	2.08	1.62	1.43	1.37	2.06	2.08	1.98	1.59	1.66	1.67
Stack flow rate, dscfm:		546175	552657	552821	542383	543551	544851	662307	659831	658961	657154	656026	620534	771344	771562	772539	778152	758400	756272	740876	749017	749017	756674	756197	756795
NH3 MW:		17.01	17.01	17.01	17.01	17.01	17.01	17.01	17.01	17.01	17.01	17.01	17.01	17.01	17.01	17.01	17.01	17.01	17.01	17.01	17.01	17.01	17.01	17.01	17.01
Agency STP ft^3/lb-mol (see Tab):		385.3	385.3	385.3	385.3	385.3	385.3	385.3	385.3	385.3	385.3	385.3	385.3	385.3	385.3	385.3	385.3	385.3	385.3	385.3	385.3	385.3	385.3	385.3	385.3
NH3 Conc, ppm at 15% O2:		1.48	1.37	1.3	0.86	0.77	0.58	1.58	1.56	1.06	1.23	0.66	0.68	1.5	1.74	1.71	1.32	1.17	1.12	1.34	1.35	1.28	0.99	1.03	1.07
Calculated NH3 slip, lbs/hr:		*2.49*	*2.34*	*2.23*	*1.48*	*1.34*	*1.00*	*3.28*	*3.20*	*2.16*	*2.14*	*1.37*	*1.33*	*3.72*	*4.29*	*4.26*	*3.34*	*2.87*	*2.74*	*4.04*	*4.13*	*3.93*	*3.19*	*3.33*	*3.35*
Fuel Flow, scf/hr:		1217623	1214269	1214753	1226217	1228874	1231926	1476341	1471065	1466240	1485932	1483184	1484414	1768588	1769132	1771307	1784222	1782080	1779676	2173754	2170644	2175573	2240880	2239649	2241298
Btu/scf: (avg all tests)		1020	1020	1020	1020	1020	1020	1020	1020	1020	1020	1020	1020	1020	1020	1020	1020	1020	1020	1020	1020	1020	1020	1020	1020
Calculated MMBTU/Hr:		1241.98	1238.55	1239.05	1250.74	1253.45	1256.56	1505.87	1500.49	1495.56	1515.65	1512.85	1514.10	1803.96	1804.51	1806.73	1819.91	1817.72	1815.27	2217.23	2214.06	2219.08	2285.70	2284.44	2286.12
Calculated MMSCF/Hr:		1.19	1.19	1.19	1.20	1.20	1.21	1.45	1.44	1.44	1.46	1.45	1.46	1.73	1.73	1.74	1.75	1.75	1.74	2.13	2.13	2.13	2.20	2.20	2.20
NH3 Injection Rate, lbs/hr:		98.0	97.9	98.1	86.9	86.7	86.7	110.7	110.5	110.4	97.2	97.2	97.3	128.3	128.5	128.2	116.0	113.2	113.2	178.2	175.1	178.4	163.9	163.2	165.7
Stack Temp, deg F:		196	196	196	196	196	196	196	196	196	196	196	196	196	196	196	196	196	196	170	170	170	170	170	170
Approx Exhaust Density, lb/ft3: (see Tab):		0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062
Exhaust flow rate dry, lbs/hr:		2031771.0	2055884.0	2056494.1	2017664.8	2022009.7	2026845.7	2463782.0	2454571.3	2451334.9	2444612.9	2440416.7	2308386.5	2869399.7	2870210.6	2873845.1	2894725.4	2821248.0	2813331.8	2756058.7	2786343.2	2786343.2	2814827.3	2813052.8	2815277.4
Inlet Nox, ppm at 15% O2:		11.3	11.2	11.3	11.4	11.4	11.4	11.4	11.2	11.0	11.2	11.1	11.1	11.1	11.0	10.8	10.9	10.8	10.8	11.8	11.8	11.9	11.9	11.9	11.8
Outlet Nox, ppm at 15% O2:		0.6	0.6	0.7	0.8	0.8	0.8	0.8	0.8	0.8	1.1	1.1	1.0	0.9	0.9	0.9	1.1	1.1	1.1	1.0	1.0	1.0	1.0	1.1	1.0
calc 1	a = (NH3 Inj/NH3 MW)	5.76	5.75	5.77	5.11	5.10	5.10	6.51	6.50	6.49	5.72	5.71	5.72	7.54	7.56	7.53	6.82	6.66	6.65	10.48	10.29	10.49	9.63	9.59	9.74
calc 2	b = (Exhaust Flow Rate/29)	70061.07	70892.55	70913.59	69574.65	69724.47	69891.23	84958.00	84640.39	84528.79	84297.00	84152.30	79599.53	98944.82	98972.78	99098.11	99818.12	97284.41	97011.44	95036.51	96080.80	96080.80	97063.01	97001.82	97078.53
calc 3	c = (Nox Inlet - Nox Outlet)\	10.65	10.61	10.67	10.62	10.64	10.61	10.56	10.37	10.20	10.08	10.01	10.05	10.20	10.08	9.88	9.84	9.73	9.71	10.86	10.77	10.89	10.85	10.79	10.76
Calculated NH3 slip, ppm @ 15% O2:	(((a/b)*1000000)-c)	71.61	70.56	70.64	62.84	62.46	62.31	66.02	66.41	66.58	57.72	57.87	61.80	66.03	66.25	66.14	58.46	58.68	58.88	99.38	96.34	98.28	88.40	88.11	89.59
Correction Constant, d:	NH3 Conc/Calculated NH3	0.0207	0.0194	0.0184	0.0137	0.0123	0.0093	0.0239	0.0235	0.0159	0.0213	0.0114	0.0110	0.0227	0.0263	0.0259	0.0226	0.0199	0.0190	0.0135	0.0140	0.0130	0.0112	0.0117	0.0119

Avg Correction Constant:

Unit 1-Min	**0.0195**
Unit 1-Mid	**0.0211**
Unit 1-Base	**0.0249**
Unit 1-Max	**0.0135**
Unit 2-Min	**0.0118**
Unit 2-Mid	**0.0146**
Unit 2-Base	**0.0205**
Unit 2-Max	**0.0116**

Correction Constants (all loads-tested)

Unit 1	**0.0198**
Unit 2	**0.0146**

The equations for all values in **RED** must be revised each year depending upon the number of loads tested and number of tests per load.

1/29/2015 14:08

Reference: all input data derived from "Colusa Generating Station-2012 Source Test Report, December 10, 2012", Avogadro.
Supplemental data derived from CEMS data for the specified test dates and times for each unit tested.

Excess Emission Report

CT1 - NH3 LbPerHr 1-Hour Block Average

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 12:42 **Location:** Maxwell, CA

Tag Name: CT1_NH3slip_LbPerHr_1H
Total Operating Time: 1,870.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 290.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,870.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - NH3 Ppmvdc 1-Hour Block Average

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 12:44 **Location:** Maxwell, CA

Tag Name: CT1_NH3Slip_Ppmvdc_1H
Total Operating Time: 1,870.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 290.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,870.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NH3 LbPerHr 1-Hour Block Average

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 12:42 **Location:** Maxwell, CA

Tag Name: CT2_NH3slip_LbPerHr_1H
Total Operating Time: 1,811.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 349.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,811.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NH3 Ppmvdc 1-Hour Block Average

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 12:43 **Location:** Maxwell, CA

Tag Name: CT2_NH3Slip_Ppmvdc_1H
Total Operating Time: 1,811.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 349.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,811.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/01/2015 00:00	11.8	13.4	9.3	179.4	3,422,191.5	2,249.1	1.5	1.3
01/01/2015 01:00	11.9	13.4	9.4	189.3	3,406,443.2	2,288.5	1.6	1.4
01/01/2015 02:00	11.9	13.4	9.4	185.4	3,390,516.2	2,277.8	1.6	1.4
01/01/2015 03:00	11.9	13.4	9.4	187.0	3,378,310.4	2,269.6	1.6	1.4
01/01/2015 04:00	11.8	13.4	9.3	172.5	3,426,946.1	2,227.2	1.5	1.3
01/01/2015 05:00	11.6	13.4	9.1	167.8	3,443,479.9	2,212.8	1.4	1.1
01/01/2015 06:00	11.9	13.4	9.4	191.4	3,417,904.6	2,296.2	1.7	1.6
01/01/2015 07:00	11.8	13.4	9.3	204.1	3,415,886.2	2,269.9	1.8	1.6
01/01/2015 08:00	10.9	13.7	8.9	131.2	3,410,393.4	1,942.5	1.1	0.8
01/01/2015 09:00	10.5	13.8	8.7	120.2	3,353,629.0	1,836.7	1.0	0.7
01/01/2015 10:00	10.5	13.9	8.9	106.0	2,796,133.1	1,449.7	1.1	0.6
01/01/2015 11:00	10.4	13.9	8.8	96.3	2,483,744.6	1,269.6	1.1	0.5
01/01/2015 12:00	10.6	13.9	8.9	96.8	2,489,222.3	1,272.4	1.1	0.5
01/01/2015 13:00	10.5	13.9	8.9	96.4	2,481,788.2	1,268.6	1.1	0.5
01/01/2015 14:00	10.4	14.0	8.9	96.2	2,476,701.8	1,266.0	1.1	0.5
01/01/2015 15:00	10.5	13.8	8.7	112.2	3,000,915.3	1,599.7	1.1	0.6
01/01/2015 16:00	10.6	13.7	8.7	124.2	3,447,706.1	1,913.4	1.0	0.8
01/01/2015 17:00	11.2	13.5	8.9	131.2	3,479,040.2	1,981.6	1.1	0.8
01/01/2015 18:00	11.4	13.4	9.0	145.8	3,450,619.5	2,091.4	1.2	1.0
01/01/2015 19:00	11.9	13.3	9.2	188.7	3,401,977.6	2,285.5	1.6	1.4
01/01/2015 20:00	11.9	13.3	9.2	189.0	3,409,271.3	2,290.4	1.6	1.4
01/01/2015 21:00	11.8	13.3	9.2	184.3	3,418,293.9	2,271.5	1.6	1.4
01/01/2015 22:00	11.8	13.3	9.2	180.3	3,450,036.5	2,267.4	1.5	1.4
01/01/2015 23:00	10.9	13.5	8.7	137.2	3,509,713.4	2,024.7	1.1	0.8
Average/Sum#:	11.3	13.6	9.1	150.5	3,223,369.3	1,963.4	1.3	1.0
Minimum:	10.4	13.3	8.7	96.2	2,476,701.8	1,266.0	1.0	0.5
Maximum:	11.9	14.0	9.4	204.1	3,509,713.4	2,296.2	1.8	1.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/02/2015 00:00	11.2	13.5	8.9	133.9	3,515,382.6	2,002.3	1.1	0.8
01/02/2015 01:00	11.1	13.5	8.9	142.2	3,456,293.5	2,069.6	1.2	1.0
01/02/2015 02:00	10.6	13.7	8.7	123.1	3,375,090.5	1,873.1	1.0	0.7
01/02/2015 03:00	11.0	13.5	8.8	136.9	3,532,074.8	2,037.6	1.1	0.8
01/02/2015 04:00	10.4	13.6	8.4	129.2	3,535,071.2	1,987.7	1.0	0.8
01/02/2015 05:00	10.9	13.5	8.7	133.2	3,496,712.5	2,017.2	1.1	0.8
01/02/2015 06:00	10.4	13.6	8.4	129.1	3,505,548.6	1,971.1	1.1	0.8
01/02/2015 07:00	10.2	13.6	8.2	129.8	3,545,547.8	1,967.7	1.0	0.8
01/02/2015 08:00	10.3	13.7	8.4	124.3	3,440,138.2	1,909.2	1.0	0.8
01/02/2015 09:00	10.6	13.7	8.7	121.6	3,318,872.1	1,841.9	1.0	0.7
01/02/2015 10:00	10.6	13.8	8.8	106.2	2,774,035.4	1,458.5	1.1	0.6
01/02/2015 11:00	10.7	13.9	9.0	97.3	2,522,441.1	1,307.8	1.1	0.5
01/02/2015 12:00	10.7	13.9	9.0	97.4	2,516,654.8	1,304.8	1.1	0.5
01/02/2015 13:00	10.7	13.9	9.0	97.2	2,562,975.6	1,310.1	1.1	0.5
01/02/2015 14:00	10.7	13.9	9.0	97.2	2,552,020.2	1,304.5	1.1	0.5
01/02/2015 15:00	10.6	13.8	8.8	112.8	3,122,287.6	1,641.6	1.0	0.7
01/02/2015 16:00	10.5	13.7	8.6	123.0	3,424,101.5	1,900.3	1.0	0.8
01/02/2015 17:00	11.7	13.3	9.1	160.6	3,444,810.6	2,188.5	1.4	1.1
01/02/2015 18:00	12.0	13.2	9.2	186.8	3,385,276.0	2,299.0	1.6	1.4
01/02/2015 19:00	12.0	13.2	9.2	186.4	3,378,502.5	2,294.4	1.6	1.4
01/02/2015 20:00	11.9	13.2	9.1	185.7	3,380,269.5	2,295.6	1.6	1.4
01/02/2015 21:00	12.0	13.2	9.2	186.0	3,381,005.7	2,296.1	1.6	1.4
01/02/2015 22:00	12.0	13.2	9.2	182.8	3,418,797.7	2,296.8	1.6	1.4
01/02/2015 23:00	11.7	13.3	9.1	163.9	3,453,283.7	2,219.1	1.4	1.1
Average/Sum#:	11.0	13.6	8.9	136.9	3,251,549.7	1,908.1	1.2	0.9
Minimum:	10.2	13.2	8.2	97.2	2,516,654.8	1,304.5	1.0	0.5
Maximum:	12.0	13.9	9.2	186.8	3,545,547.8	2,299.0	1.6	1.4
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/03/2015 00:00	11.5	13.4	9.0	152.4	3,476,888.0	2,158.1	1.3	1.1
01/03/2015 01:00	11.8	13.3	9.2	169.1	3,455,873.2	2,246.0	1.4	1.1
01/03/2015 02:00	11.6	13.4	9.1	155.3	3,462,871.5	2,149.4	1.3	1.1
01/03/2015 03:00	11.7	13.3	9.1	173.2	3,456,334.8	2,246.3	1.5	1.3
01/03/2015 04:00	11.4	13.4	9.0	146.6	3,494,036.2	2,092.2	1.2	1.0
01/03/2015 05:00	11.1	13.5	8.9	136.3	3,495,798.1	2,042.2	1.1	0.8
01/03/2015 06:00	11.6	13.4	9.1	156.1	3,486,393.4	2,164.0	1.3	1.1
01/03/2015 07:00	11.0	13.5	8.8	156.0	3,360,503.7	2,110.4	1.4	1.1
01/03/2015 08:00	10.4	13.7	8.5	125.7	3,417,254.4	1,896.5	1.0	0.8
01/03/2015 09:00	10.7	13.7	8.8	122.8	3,322,295.6	1,843.8	1.0	0.7
01/03/2015 10:00	10.7	13.7	8.8	123.0	3,324,998.4	1,845.3	1.0	0.7
01/03/2015 11:00	10.6	13.7	8.7	122.7	3,334,548.4	1,850.6	1.0	0.7
01/03/2015 12:00	10.6	13.9	8.9	101.5	2,615,600.6	1,356.1	1.1	0.5
01/03/2015 13:00	10.8	13.9	9.1	98.3	2,515,690.5	1,304.3	1.1	0.5
01/03/2015 14:00	10.9	13.9	9.2	98.5	2,546,542.5	1,301.7	1.1	0.5
01/03/2015 15:00	10.8	13.8	9.0	115.7	3,104,091.1	1,654.7	1.1	0.7
01/03/2015 16:00	11.0	13.6	8.9	131.6	3,437,428.5	1,983.0	1.1	0.8
01/03/2015 17:00	11.6	13.4	9.1	156.8	3,468,624.6	2,178.3	1.3	1.1
01/03/2015 18:00	11.9	13.2	9.1	187.7	3,421,625.9	2,298.7	1.6	1.4
01/03/2015 19:00	11.8	13.2	9.0	185.1	3,398,851.8	2,283.4	1.6	1.4
01/03/2015 20:00	11.9	13.2	9.1	183.7	3,400,340.3	2,284.4	1.6	1.4
01/03/2015 21:00	11.9	13.2	9.1	184.2	3,413,885.7	2,293.5	1.6	1.4
01/03/2015 22:00	11.8	13.3	9.2	171.9	3,440,024.8	2,235.7	1.5	1.3
01/03/2015 23:00	11.7	13.3	9.1	167.9	3,448,770.8	2,216.2	1.4	1.1
Average/Sum#:	11.3	13.5	9.0	146.8	3,304,136.4	2,001.5	1.3	1.0
Minimum:	10.4	13.2	8.5	98.3	2,515,690.5	1,301.7	1.0	0.5
Maximum:	11.9	13.9	9.2	187.7	3,495,798.1	2,298.7	1.6	1.4
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/04/2015 00:00	11.7	13.3	9.1	165.9	3,491,874.8	2,218.4	1.4	1.1
01/04/2015 01:00	10.9	13.5	8.7	132.0	3,508,711.1	1,998.5	1.1	0.8
01/04/2015 02:00	10.6	13.6	8.6	129.5	3,526,712.4	1,983.0	1.0	0.8
01/04/2015 03:00	10.6	13.5	8.5	129.5	3,523,155.5	1,981.0	1.0	0.8
01/04/2015 04:00	10.6	13.6	8.6	128.5	3,490,075.9	1,962.4	1.0	0.8
01/04/2015 05:00	10.2	13.6	8.2	128.1	3,499,857.5	1,967.9	1.0	0.8
01/04/2015 06:00	11.4	13.4	9.0	147.1	3,496,651.9	2,119.3	1.2	1.1
01/04/2015 07:00	11.7	13.3	9.1	176.2	3,417,018.2	2,245.7	1.5	1.3
01/04/2015 08:00	10.6	13.6	8.6	130.0	3,460,908.9	1,946.0	1.1	0.8
01/04/2015 09:00	10.3	13.7	8.4	124.4	3,439,417.5	1,908.8	1.0	0.8
01/04/2015 10:00	10.3	13.7	8.4	123.8	3,411,128.0	1,893.1	1.0	0.8
01/04/2015 11:00	10.3	13.7	8.4	122.3	3,348,242.6	1,858.2	1.0	0.7
01/04/2015 12:00	10.4	13.7	8.5	121.9	3,333,287.1	1,849.9	1.0	0.7
01/04/2015 13:00	10.4	13.7	8.5	123.1	3,380,135.8	1,875.9	1.0	0.8
01/04/2015 14:00	11.4	13.5	9.1	131.7	3,492,558.9	1,989.3	1.1	0.8
01/04/2015 15:00	11.2	13.5	8.9	134.3	3,475,391.1	2,004.9	1.1	0.8
01/04/2015 16:00	11.1	13.5	8.9	135.0	3,440,849.9	2,010.1	1.1	0.8
01/04/2015 17:00	11.9	13.3	9.2	176.5	3,407,127.9	2,239.2	1.5	1.3
01/04/2015 18:00	12.1	13.2	9.3	194.3	3,398,823.0	2,308.2	1.7	1.6
01/04/2015 19:00	12.1	13.2	9.3	195.8	3,408,394.2	2,314.7	1.7	1.6
01/04/2015 20:00	12.0	13.2	9.2	193.7	3,408,541.5	2,314.8	1.7	1.6
01/04/2015 21:00	11.9	13.3	9.2	175.5	3,397,677.3	2,257.8	1.5	1.4
01/04/2015 22:00	11.8	13.3	9.2	174.5	3,407,432.2	2,239.4	1.5	1.3
01/04/2015 23:00	10.6	13.7	8.7	125.6	3,374,652.9	1,897.5	1.1	0.8
Average/Sum#:	11.1	13.5	8.8	146.6	3,439,109.4	2,057.7	1.2	1.0
Minimum:	10.2	13.2	8.2	121.9	3,333,287.1	1,849.9	1.0	0.7
Maximum:	12.1	13.7	9.3	195.8	3,526,712.4	2,314.8	1.7	1.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/05/2015 00:00	10.5	13.7	8.6	121.9	3,339,593.6	1,853.4	1.0	0.7
01/05/2015 01:00	10.4	13.6	8.4	126.5	3,497,798.2	1,941.2	1.0	0.8
01/05/2015 02:00	10.5	13.7	8.6	122.1	3,353,107.7	1,860.9	1.0	0.7
01/05/2015 03:00	10.8	13.6	8.7	128.5	3,502,880.9	1,969.6	1.0	0.8
01/05/2015 04:00	10.4	13.7	8.5	124.3	3,429,507.1	1,903.3	1.0	0.8
01/05/2015 05:00	10.3	13.7	8.4	124.7	3,464,283.3	1,922.6	1.0	0.8
01/05/2015 06:00	10.9	13.5	8.7	134.6	3,524,101.0	2,033.0	1.1	0.8
01/05/2015 07:00	11.9	13.2	9.1	192.4	3,474,838.3	2,283.7	1.6	1.4
01/05/2015 08:00	11.7	13.3	9.1	169.9	3,443,341.5	2,263.0	1.4	1.1
01/05/2015 09:00	10.5	13.6	8.5	126.8	3,412,356.6	1,918.7	1.1	0.8
01/05/2015 10:00	10.3	13.7	8.4	121.5	3,334,908.7	1,850.8	1.0	0.7
01/05/2015 11:00	10.3	13.7	8.4	121.4	3,332,025.8	1,849.2	1.0	0.7
01/05/2015 12:00	10.2	13.7	8.4	121.1	3,337,791.7	1,852.4	1.0	0.7
01/05/2015 13:00	10.1	13.8	8.4	121.1	3,409,318.9	1,867.2	1.0	0.7
01/05/2015 14:00	11.3	13.5	9.0	131.2	3,401,479.0	1,987.1	1.1	0.8
01/05/2015 15:00	11.0	13.5	8.8	129.5	3,409,173.3	1,966.7	1.1	0.8
01/05/2015 16:00	11.0	13.5	8.8	131.7	3,401,307.8	1,987.0	1.1	0.8
01/05/2015 17:00	11.6	13.3	9.0	167.5	3,360,657.7	2,233.2	1.5	1.3
01/05/2015 18:00	11.8	13.3	9.2	184.6	3,369,512.4	2,312.9	1.6	1.4
01/05/2015 19:00	11.8	13.3	9.2	187.9	3,341,251.3	2,317.9	1.7	1.6
01/05/2015 20:00	11.8	13.3	9.2	183.9	3,374,465.6	2,316.3	1.6	1.4
01/05/2015 21:00	11.5	13.4	9.0	156.5	3,399,284.8	2,184.4	1.3	1.1
01/05/2015 22:00	10.8	13.6	8.7	135.6	3,461,049.0	2,021.9	1.1	0.8
01/05/2015 23:00	10.3	13.7	8.4	117.1	3,122,105.0	1,709.9	1.1	0.7
Average/Sum#:	10.9	13.5	8.7	140.9	3,395,672.5	2,016.9	1.2	0.9
Minimum:	10.1	13.2	8.4	117.1	3,122,105.0	1,709.9	1.0	0.7
Maximum:	11.9	13.8	9.2	192.4	3,524,101.0	2,317.9	1.7	1.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/06/2015 00:00	10.6	13.9	8.9	104.0	2,771,444.9	1,436.9	1.1	0.6
01/06/2015 01:00	10.6	13.8	8.8	116.4	3,189,408.7	1,653.6	1.0	0.7
01/06/2015 02:00	10.4	13.8	8.6	118.9	3,217,584.5	1,715.2	1.0	0.7
01/06/2015 03:00	10.3	13.7	8.4	121.5	3,351,305.8	1,859.9	1.0	0.7
01/06/2015 04:00	10.3	13.7	8.4	121.7	3,350,224.7	1,859.3	1.0	0.7
01/06/2015 05:00	10.4	13.7	8.5	124.6	3,457,976.8	1,919.1	1.0	0.8
01/06/2015 06:00	10.8	13.5	8.6	136.5	3,464,136.5	2,049.0	1.1	0.8
01/06/2015 07:00	11.7	13.3	9.1	193.8	3,403,466.1	2,286.5	1.7	1.6
01/06/2015 08:00	11.1	13.5	8.9	143.8	3,399,759.1	2,085.4	1.2	1.0
01/06/2015 09:00	10.2	13.7	8.4	121.5	3,330,043.7	1,848.1	1.0	0.7
01/06/2015 10:00	10.3	13.8	8.6	111.0	2,907,306.7	1,549.8	1.1	0.6
01/06/2015 11:00	10.8	13.9	9.1	98.1	2,509,518.4	1,301.1	1.1	0.5
01/06/2015 12:00	10.8	13.9	9.1	98.2	2,545,955.6	1,301.4	1.1	0.5
01/06/2015 13:00	10.7	13.9	9.0	104.5	2,827,861.4	1,445.5	1.0	0.6
01/06/2015 14:00	10.7	13.9	9.0	98.1	2,552,215.8	1,304.6	1.1	0.5
01/06/2015 15:00	11.0	13.7	9.0	114.3	3,068,636.2	1,635.8	1.0	0.7
01/06/2015 16:00	10.7	13.6	8.6	125.6	3,390,203.2	1,931.0	1.1	0.8
01/06/2015 17:00	11.1	13.5	8.9	136.0	3,383,647.2	2,026.1	1.2	1.0
01/06/2015 18:00	11.5	13.5	9.2	141.1	3,360,795.7	2,061.5	1.2	1.0
01/06/2015 19:00	11.6	13.5	9.2	144.2	3,406,117.1	2,089.3	1.2	1.0
01/06/2015 20:00	11.6	13.4	9.1	153.7	3,362,645.2	2,136.3	1.3	1.1
01/06/2015 21:00	11.3	13.4	8.9	147.5	3,393,306.2	2,131.0	1.3	1.1
01/06/2015 22:00	11.3	13.5	9.0	143.3	3,378,239.5	2,072.2	1.2	1.0
01/06/2015 23:00	10.0	13.8	8.3	121.8	3,377,433.0	1,874.4	1.0	0.7
Average/Sum#:	10.8	13.7	8.8	126.7	3,183,301.3	1,815.5	1.1	0.8
Minimum:	10.0	13.3	8.3	98.1	2,509,518.4	1,301.1	1.0	0.5
Maximum:	11.7	13.9	9.2	193.8	3,464,136.5	2,286.5	1.7	1.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/07/2015 00:00	10.5	13.7	8.6	125.0	3,406,131.9	1,915.2	1.0	0.8
01/07/2015 01:00	10.2	13.7	8.4	122.3	3,366,261.4	1,868.2	1.0	0.7
01/07/2015 02:00	10.3	13.7	8.4	123.3	3,408,965.8	1,891.9	1.0	0.8
01/07/2015 03:00	10.2	13.8	8.5	121.1	3,349,684.1	1,859.0	1.0	0.7
01/07/2015 04:00	11.0	13.6	8.9	128.7	3,429,179.1	1,953.2	1.1	0.8
01/07/2015 05:00	10.5	13.7	8.6	125.1	3,384,434.5	1,903.0	1.0	0.8
01/07/2015 06:00	11.1	13.5	8.9	138.9	3,504,204.8	2,072.7	1.1	0.8
01/07/2015 07:00	11.6	13.3	9.0	169.3	3,450,641.7	2,242.6	1.4	1.1
01/07/2015 08:00	10.9	13.5	8.7	138.8	3,407,330.7	2,015.4	1.2	1.0
01/07/2015 09:00	10.3	13.7	8.4	123.8	3,407,704.5	1,891.2	1.0	0.8
01/07/2015 10:00	9.9	13.8	8.2	120.5	3,381,565.3	1,852.0	1.0	0.7
01/07/2015 11:00	10.0	13.8	8.3	120.6	3,355,089.7	1,837.5	1.0	0.7
01/07/2015 12:00	10.7	13.9	9.0	98.7	2,557,302.2	1,307.2	1.1	0.5
01/07/2015 13:00	10.6	13.9	8.9	107.2	2,881,191.8	1,493.8	1.0	0.6
01/07/2015 14:00	10.6	13.9	8.9	110.4	3,050,295.0	1,559.2	1.0	0.6
01/07/2015 15:00	11.5	13.5	9.2	132.8	3,367,938.7	1,992.1	1.1	0.8
01/07/2015 16:00	11.2	13.6	9.1	131.0	3,378,541.1	1,973.7	1.1	0.8
01/07/2015 17:00	11.7	13.4	9.2	162.7	3,319,332.5	2,181.5	1.4	1.1
01/07/2015 18:00	11.4	13.5	9.1	140.7	3,389,242.9	2,054.2	1.2	1.0
01/07/2015 19:00	11.3	13.5	9.0	133.8	3,406,823.6	2,015.1	1.1	0.8
01/07/2015 20:00	11.4	13.5	9.1	134.7	3,368,784.0	2,017.2	1.1	0.8
01/07/2015 21:00	11.4	13.5	9.1	135.4	3,381,142.2	2,024.6	1.1	0.8
01/07/2015 22:00	10.5	13.7	8.6	126.7	3,381,776.0	1,926.2	1.1	0.8
01/07/2015 23:00	10.0	13.8	8.3	120.7	3,385,034.5	1,853.9	1.0	0.7
Average/Sum#:	10.8	13.6	8.8	128.8	3,321,608.3	1,904.2	1.1	0.8
Minimum:	9.9	13.3	8.2	98.7	2,557,302.2	1,307.2	1.0	0.5
Maximum:	11.7	13.9	9.2	169.3	3,504,204.8	2,242.6	1.4	1.1
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/08/2015 00:00	10.0	13.8	8.3	120.6	3,373,531.3	1,847.6	1.0	0.7
01/08/2015 01:00	10.1	13.8	8.4	120.8	3,376,452.8	1,849.2	1.0	0.7
01/08/2015 02:00	10.0	13.8	8.3	120.7	3,372,435.8	1,847.0	1.0	0.7
01/08/2015 03:00	9.9	13.8	8.2	120.6	3,377,548.3	1,849.8	1.0	0.7
01/08/2015 04:00	10.2	13.7	8.4	121.2	3,327,160.7	1,846.5	1.0	0.7
01/08/2015 05:00	10.2	13.8	8.5	121.2	3,336,890.8	1,851.9	1.0	0.7
01/08/2015 06:00	11.1	13.5	8.9	140.6	3,466,647.7	2,075.8	1.2	1.0
01/08/2015 07:00	11.6	13.3	9.0	181.0	3,379,238.7	2,294.9	1.6	1.4
01/08/2015 08:00	11.6	13.3	9.0	173.8	3,372,951.8	2,266.0	1.5	1.4
01/08/2015 09:00	11.4	13.4	9.0	157.5	3,391,037.1	2,179.1	1.4	1.1
01/08/2015 10:00	11.2	13.4	8.8	139.9	3,399,472.3	2,060.4	1.2	1.0
01/08/2015 11:00	11.0	13.5	8.8	132.6	3,393,091.3	1,982.2	1.1	0.8
01/08/2015 12:00	11.2	13.5	8.9	134.5	3,406,147.3	2,014.7	1.1	0.8
01/08/2015 13:00	11.4	13.4	9.0	145.8	3,366,367.4	2,089.5	1.2	1.0
01/08/2015 14:00	11.4	13.5	9.1	144.9	3,393,075.0	2,081.3	1.2	1.0
01/08/2015 15:00	12.0	13.3	9.3	185.4	3,306,431.5	2,269.6	1.7	1.6
01/08/2015 16:00	11.4	13.5	9.1	137.7	3,335,620.8	2,021.7	1.2	1.0
01/08/2015 17:00	11.4	13.5	9.1	139.9	3,345,797.2	2,052.3	1.2	1.0
01/08/2015 18:00	11.4	13.5	9.1	142.5	3,354,111.6	2,057.4	1.2	1.0
01/08/2015 19:00	11.3	13.5	9.0	134.4	3,384,845.1	2,002.1	1.1	0.8
01/08/2015 20:00	11.4	13.5	9.1	136.0	3,367,615.0	2,016.5	1.2	1.0
01/08/2015 21:00	11.6	13.5	9.2	150.7	3,349,835.0	2,103.7	1.3	1.1
01/08/2015 22:00	11.4	13.5	9.1	136.5	3,367,949.0	2,016.7	1.2	1.0
01/08/2015 23:00	10.4	13.7	8.5	125.9	3,351,051.7	1,908.7	1.1	0.8
Average/Sum#:	11.0	13.5	8.8	140.2	3,370,637.7	2,024.4	1.2	1.0
Minimum:	9.9	13.3	8.2	120.6	3,306,431.5	1,846.5	1.0	0.7
Maximum:	12.0	13.8	9.3	185.4	3,466,647.7	2,294.9	1.7	1.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/09/2015 00:00	10.7	13.6	8.6	127.7	3,408,637.7	1,941.5	1.1	0.8
01/09/2015 01:00	10.3	13.7	8.4	123.7	3,404,100.7	1,889.2	1.0	0.8
01/09/2015 02:00	10.0	13.8	8.3	121.1	3,337,791.7	1,852.4	1.0	0.7
01/09/2015 03:00	10.5	13.7	8.6	126.0	3,408,088.2	1,916.3	1.1	0.8
01/09/2015 04:00	10.1	13.8	8.4	121.6	3,393,616.2	1,858.6	1.0	0.7
01/09/2015 05:00	10.2	13.7	8.4	124.0	3,425,002.5	1,900.8	1.0	0.8
01/09/2015 06:00	10.6	13.6	8.6	128.0	3,416,011.6	1,945.7	1.1	0.8
01/09/2015 07:00	11.4	13.4	9.0	156.3	3,454,816.1	2,144.4	1.3	1.1
01/09/2015 08:00	11.7	13.3	9.1	177.6	3,360,390.7	2,282.1	1.6	1.4
01/09/2015 09:00	11.1	13.5	8.9	139.7	3,383,303.2	2,050.6	1.2	1.0
01/09/2015 10:00	11.4	13.4	9.0	164.3	3,374,718.2	2,217.9	1.4	1.1
01/09/2015 11:00	11.5	13.3	8.9	171.1	3,329,040.9	2,236.5	1.5	1.3
01/09/2015 12:00	10.1	13.7	8.3	124.0	3,405,181.8	1,889.8	1.0	0.8
01/09/2015 13:00	9.9	13.8	8.2	114.9	3,133,206.0	1,693.1	1.0	0.7
01/09/2015 14:00	10.3	13.9	8.7	100.4	2,715,959.8	1,388.3	1.0	0.6
01/09/2015 15:00	10.4	13.9	8.8	100.4	2,689,549.5	1,374.8	1.1	0.5
01/09/2015 16:00	10.7	13.7	8.8	116.5	3,090,516.9	1,692.6	1.1	0.7
01/09/2015 17:00	10.1	13.7	8.3	122.5	3,389,325.4	1,881.0	1.0	0.8
01/09/2015 18:00	10.3	13.7	8.4	122.3	3,233,823.6	1,794.7	1.1	0.7
01/09/2015 19:00	10.5	13.7	8.6	123.0	3,290,818.1	1,802.3	1.1	0.7
01/09/2015 20:00	9.9	13.7	8.1	120.8	3,418,631.0	1,872.3	1.0	0.7
01/09/2015 21:00	10.2	13.7	8.4	120.7	3,431,777.5	1,879.5	1.0	0.8
01/09/2015 22:00	10.4	13.6	8.4	124.7	3,411,467.3	1,918.2	1.0	0.8
01/09/2015 23:00	10.8	13.5	8.6	129.4	3,412,293.5	1,968.5	1.1	0.8
Average/Sum#:	10.5	13.6	8.6	129.2	3,304,919.5	1,891.3	1.1	0.8
Minimum:	9.9	13.3	8.1	100.4	2,689,549.5	1,374.8	1.0	0.5
Maximum:	11.7	13.9	9.1	177.6	3,454,816.1	2,282.1	1.6	1.4
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/10/2015 00:00	10.0	13.7	8.2	120.4	3,417,170.3	1,871.5	1.0	0.7
01/10/2015 01:00	9.6	13.8	8.0	117.7	3,415,048.3	1,845.4	1.0	0.7
01/10/2015 02:00	10.2	13.8	8.5	117.1	3,200,138.4	1,705.9	1.0	0.7
01/10/2015 03:00	10.4	13.9	8.8	100.8	2,661,378.5	1,360.4	1.1	0.5
01/10/2015 04:00	10.6	13.8	8.8	112.8	3,049,689.3	1,625.7	1.0	0.7
01/10/2015 05:00	10.2	13.7	8.4	123.8	3,422,660.0	1,899.5	1.0	0.8
01/10/2015 06:00	10.9	13.5	8.7	127.5	3,409,866.7	1,942.2	1.1	0.8
01/10/2015 07:00	11.0	13.5	8.8	128.1	3,434,972.8	1,956.5	1.1	0.8
01/10/2015 08:00	10.1	13.7	8.3	122.9	3,380,316.0	1,876.0	1.0	0.8
01/10/2015 09:00	9.9	13.8	8.2	121.0	3,344,819.1	1,856.3	1.0	0.7
01/10/2015 10:00	10.7	13.5	8.5	128.5	3,448,842.6	1,964.4	1.1	0.8
01/10/2015 11:00	11.5	13.3	8.9	168.8	3,371,827.1	2,216.0	1.5	1.3
01/10/2015 12:00	11.5	13.3	8.9	162.4	3,338,779.7	2,169.9	1.4	1.1
01/10/2015 13:00	10.6	13.6	8.6	127.6	3,405,126.4	1,939.5	1.1	0.8
01/10/2015 14:00	11.1	13.5	8.9	133.4	3,380,956.6	1,999.8	1.1	0.8
01/10/2015 15:00	9.8	13.8	8.1	120.9	3,403,110.9	1,863.8	1.0	0.7
01/10/2015 16:00	10.4	13.7	8.5	123.9	3,378,387.7	1,899.6	1.0	0.8
01/10/2015 17:00	11.2	13.5	8.9	140.0	3,391,552.7	2,055.6	1.2	1.0
01/10/2015 18:00	11.0	13.5	8.8	132.2	3,397,884.3	1,985.0	1.1	0.8
01/10/2015 19:00	11.2	13.5	8.9	140.2	3,394,027.6	2,057.1	1.2	1.0
01/10/2015 20:00	11.8	13.2	9.0	184.2	3,339,039.5	2,267.6	1.6	1.4
01/10/2015 21:00	11.3	13.4	8.9	147.5	3,353,975.1	2,106.3	1.3	1.1
01/10/2015 22:00	11.1	13.5	8.9	139.1	3,384,315.3	2,026.5	1.2	1.0
01/10/2015 23:00	10.1	13.7	8.3	124.1	3,390,837.1	1,906.6	1.0	0.8
Average/Sum#:	10.7	13.6	8.6	131.9	3,338,113.4	1,933.2	1.1	0.9
Minimum:	9.6	13.2	8.0	100.8	2,661,378.5	1,360.4	1.0	0.5
Maximum:	11.8	13.9	9.0	184.2	3,448,842.6	2,267.6	1.6	1.4
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/11/2015 00:00	10.2	13.7	8.4	124.9	3,398,662.3	1,911.0	1.0	0.8
01/11/2015 01:00	10.4	13.6	8.4	125.1	3,406,843.3	1,915.6	1.0	0.8
01/11/2015 02:00	10.4	13.6	8.4	126.4	3,424,450.2	1,925.5	1.1	0.8
01/11/2015 03:00	9.9	13.8	8.2	120.9	3,388,138.5	1,855.6	1.0	0.7
01/11/2015 04:00	9.9	13.8	8.2	120.6	3,381,565.3	1,852.0	1.0	0.7
01/11/2015 05:00	10.2	13.7	8.4	123.0	3,404,280.9	1,889.3	1.0	0.8
01/11/2015 06:00	10.2	13.7	8.4	123.2	3,395,631.9	1,884.5	1.0	0.8
01/11/2015 07:00	11.0	13.5	8.8	128.1	3,427,473.6	1,927.2	1.1	0.8
01/11/2015 08:00	11.3	13.4	8.9	147.3	3,423,887.0	2,100.2	1.2	1.1
01/11/2015 09:00	11.7	13.2	9.0	181.0	3,376,673.1	2,268.5	1.6	1.4
01/11/2015 10:00	11.7	13.2	9.0	179.2	3,355,089.7	2,254.0	1.6	1.4
01/11/2015 11:00	11.6	13.3	9.0	162.2	3,373,919.3	2,168.1	1.4	1.1
01/11/2015 12:00	10.7	13.6	8.6	134.1	3,398,397.8	1,985.3	1.1	0.8
01/11/2015 13:00	11.2	13.5	8.9	131.1	3,389,496.5	1,980.1	1.1	0.8
01/11/2015 14:00	10.5	13.7	8.6	125.3	3,405,420.5	1,914.8	1.0	0.8
01/11/2015 15:00	11.4	13.5	9.1	133.4	3,433,318.1	2,005.7	1.1	0.8
01/11/2015 16:00	10.2	13.7	8.4	123.1	3,430,588.3	1,903.9	1.0	0.8
01/11/2015 17:00	11.4	13.4	9.0	151.6	3,388,369.9	2,127.9	1.3	1.1
01/11/2015 18:00	11.5	13.4	9.0	153.4	3,392,669.3	2,130.6	1.3	1.1
01/11/2015 19:00	11.7	13.3	9.1	173.4	3,346,361.5	2,223.7	1.5	1.3
01/11/2015 20:00	11.5	13.4	9.0	150.9	3,371,650.2	2,117.4	1.3	1.1
01/11/2015 21:00	11.5	13.3	8.9	158.1	3,344,663.4	2,149.3	1.4	1.1
01/11/2015 22:00	10.5	13.6	8.5	128.9	3,374,677.7	1,946.8	1.1	0.8
01/11/2015 23:00	9.8	13.8	8.1	119.1	3,379,191.6	1,850.7	1.0	0.7
Average/Sum#:	10.9	13.5	8.7	139.3	3,392,142.5	2,012.0	1.2	0.9
Minimum:	9.8	13.2	8.1	119.1	3,344,663.4	1,850.7	1.0	0.7
Maximum:	11.7	13.8	9.1	181.0	3,433,318.1	2,268.5	1.6	1.4
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/12/2015 00:00	10.7	13.6	8.6	128.2	3,429,003.5	1,953.1	1.1	0.8
01/12/2015 01:00	10.0	13.7	8.2	123.2	3,398,334.7	1,886.0	1.0	0.8
01/12/2015 02:00	9.9	13.7	8.1	122.5	3,402,298.8	1,888.2	1.0	0.8
01/12/2015 03:00	10.6	13.6	8.6	127.0	3,451,483.0	1,940.7	1.0	0.8
01/12/2015 04:00	10.3	13.7	8.4	125.5	3,414,846.4	1,920.1	1.0	0.8
01/12/2015 05:00	10.4	13.6	8.4	124.7	3,401,685.7	1,912.7	1.0	0.8
01/12/2015 06:00	11.0	13.5	8.8	131.5	3,467,243.9	2,000.2	1.1	0.8
01/12/2015 07:00	11.1	13.5	8.9	131.9	3,434,481.7	1,981.3	1.1	0.8
01/12/2015 08:00	11.0	13.5	8.8	130.0	3,481,147.0	1,982.8	1.1	0.8
01/12/2015 09:00	11.3	13.4	8.9	143.4	3,419,811.3	2,097.7	1.2	1.0
01/12/2015 10:00	10.9	13.5	8.7	136.8	3,416,629.3	2,020.9	1.1	0.8
01/12/2015 11:00	9.9	13.7	8.1	121.3	3,356,170.9	1,862.6	1.0	0.7
01/12/2015 12:00	9.8	13.8	8.1	120.0	3,390,694.8	1,857.0	1.0	0.7
01/12/2015 13:00	9.6	13.8	8.0	119.6	3,394,711.8	1,859.2	1.0	0.7
01/12/2015 14:00	9.6	13.8	8.0	119.4	3,404,023.8	1,864.3	1.0	0.7
01/12/2015 15:00	9.6	13.8	8.0	119.3	3,410,231.9	1,867.7	1.0	0.7
01/12/2015 16:00	10.2	13.7	8.4	122.4	3,424,642.1	1,900.6	1.0	0.8
01/12/2015 17:00	10.8	13.6	8.7	132.2	3,393,776.0	1,982.6	1.1	0.8
01/12/2015 18:00	12.0	13.3	9.3	178.5	3,366,677.2	2,237.2	1.6	1.3
01/12/2015 19:00	12.1	13.2	9.3	191.8	3,327,264.2	2,283.9	1.7	1.6
01/12/2015 20:00	12.0	13.2	9.2	189.6	3,335,568.2	2,289.6	1.7	1.6
01/12/2015 21:00	11.7	13.3	9.1	168.9	3,353,872.5	2,204.2	1.5	1.3
01/12/2015 22:00	11.5	13.4	9.0	151.0	3,396,816.9	2,108.4	1.3	1.1
01/12/2015 23:00	10.7	13.6	8.6	127.3	3,383,356.1	1,927.1	1.1	0.8
Average/Sum#:	10.7	13.6	8.6	136.9	3,402,282.2	1,992.8	1.2	0.9
Minimum:	9.6	13.2	8.0	119.3	3,327,264.2	1,857.0	1.0	0.7
Maximum:	12.1	13.8	9.3	191.8	3,481,147.0	2,289.6	1.7	1.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/13/2015 00:00	11.3	13.5	9.0	136.2	3,409,528.6	2,016.7	1.1	0.8
01/13/2015 01:00	11.3	13.5	9.0	134.8	3,396,341.5	2,008.9	1.1	0.8
01/13/2015 02:00	11.4	13.5	9.1	134.9	3,425,443.9	2,001.1	1.1	0.8
01/13/2015 03:00	11.1	13.5	8.9	130.7	3,418,013.9	1,971.8	1.1	0.8
01/13/2015 04:00	10.7	13.6	8.6	127.4	3,430,674.9	1,929.0	1.1	0.8
01/13/2015 05:00	10.1	13.8	8.4	121.6	3,396,902.8	1,860.4	1.0	0.7
01/13/2015 06:00	10.6	13.7	8.7	125.6	3,408,266.1	1,916.4	1.0	0.8
01/13/2015 07:00	11.3	13.5	9.0	135.7	3,442,561.7	2,011.1	1.1	0.8
01/13/2015 08:00	10.8	13.6	8.7	128.7	3,440,812.2	1,934.7	1.1	0.8
01/13/2015 09:00	10.3	13.7	8.4	124.1	3,429,586.4	1,878.3	1.0	0.8
01/13/2015 10:00	11.5	13.5	9.2	138.1	3,427,840.4	2,002.5	1.1	0.8
01/13/2015 11:00	11.4	13.5	9.1	141.4	3,402,089.7	2,012.3	1.2	1.0
01/13/2015 12:00	10.8	13.6	8.7	128.7	3,399,157.1	1,936.1	1.1	0.8
01/13/2015 13:00	11.1	13.6	9.0	131.4	3,395,999.1	1,959.1	1.1	0.8
01/13/2015 14:00	10.8	13.6	8.7	129.0	3,387,920.8	1,929.7	1.1	0.8
01/13/2015 15:00	10.4	13.7	8.5	125.2	3,434,192.0	1,905.9	1.0	0.8
01/13/2015 16:00	10.5	13.7	8.6	125.7	3,437,615.6	1,907.8	1.0	0.8
01/13/2015 17:00	11.7	13.4	9.2	159.8	3,404,452.7	2,138.0	1.4	1.1
01/13/2015 18:00	12.1	13.2	9.3	194.7	3,359,654.5	2,281.6	1.7	1.6
01/13/2015 19:00	12.2	13.2	9.3	194.3	3,359,065.5	2,281.2	1.7	1.6
01/13/2015 20:00	12.1	13.3	9.4	192.0	3,353,175.5	2,277.2	1.7	1.6
01/13/2015 21:00	11.8	13.4	9.3	169.2	3,371,861.3	2,191.4	1.5	1.3
01/13/2015 22:00	11.6	13.4	9.1	156.7	3,359,070.6	2,109.5	1.4	1.1
01/13/2015 23:00	10.4	13.8	8.6	115.7	3,065,071.9	1,633.9	1.1	0.7
Average/Sum#:	11.1	13.5	8.9	141.7	3,389,804.1	2,003.9	1.2	0.9
Minimum:	10.1	13.2	8.4	115.7	3,065,071.9	1,633.9	1.0	0.7
Maximum:	12.2	13.8	9.4	194.7	3,442,561.7	2,281.6	1.7	1.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/14/2015 00:00	10.7	13.9	9.0	99.3	2,625,186.5	1,341.9	1.1	0.5
01/14/2015 01:00	10.8	13.8	9.0	114.5	3,043,015.3	1,577.7	1.1	0.6
01/14/2015 02:00	10.6	13.8	8.8	118.4	3,190,571.2	1,700.8	1.0	0.7
01/14/2015 03:00	10.6	13.6	8.6	126.8	3,424,628.0	1,925.6	1.1	0.8
01/14/2015 04:00	10.7	13.6	8.6	129.6	3,495,944.8	1,965.7	1.1	0.8
01/14/2015 05:00	10.3	13.7	8.4	123.4	3,374,730.2	1,872.9	1.0	0.7
01/14/2015 06:00	10.7	13.6	8.6	130.4	3,419,400.7	1,972.6	1.1	0.8
01/14/2015 07:00	11.6	13.3	9.0	170.0	3,447,718.2	2,240.7	1.4	1.1
01/14/2015 08:00	11.2	13.4	8.8	147.8	3,431,875.3	2,105.1	1.2	1.1
01/14/2015 09:00	10.7	13.5	8.5	129.1	3,450,598.3	1,965.4	1.1	0.8
01/14/2015 10:00	10.1	13.6	8.2	123.6	3,353,667.0	1,885.7	1.1	0.8
01/14/2015 11:00	10.1	13.7	8.3	121.4	3,337,071.0	1,852.0	1.0	0.7
01/14/2015 12:00	10.2	13.8	8.5	121.6	3,340,494.6	1,853.9	1.0	0.7
01/14/2015 13:00	10.0	13.8	8.3	121.1	3,354,188.8	1,861.5	1.0	0.7
01/14/2015 14:00	9.9	13.8	8.2	121.8	3,409,866.7	1,867.5	1.0	0.7
01/14/2015 15:00	10.1	13.8	8.4	122.5	3,430,134.2	1,878.6	1.0	0.8
01/14/2015 16:00	10.4	13.6	8.4	129.0	3,465,544.6	1,923.3	1.1	0.8
01/14/2015 17:00	11.3	13.4	8.9	143.3	3,439,700.6	2,109.9	1.2	1.1
01/14/2015 18:00	11.9	13.2	9.1	161.7	3,368,636.7	2,287.7	1.4	1.1
01/14/2015 19:00	11.9	13.2	9.1	184.2	3,405,550.1	2,287.9	1.6	1.4
01/14/2015 20:00	12.0	13.2	9.2	193.0	3,403,763.8	2,286.7	1.7	1.6
01/14/2015 21:00	11.9	13.3	9.2	187.0	3,420,701.7	2,273.1	1.6	1.4
01/14/2015 22:00	11.2	13.5	8.9	147.4	3,426,530.8	2,076.8	1.2	1.0
01/14/2015 23:00	10.1	13.7	8.3	120.9	3,429,403.8	1,878.2	1.0	0.8
Average/Sum#:	10.8	13.6	8.7	137.0	3,353,705.1	1,958.0	1.2	0.9
Minimum:	9.9	13.2	8.2	99.3	2,625,186.5	1,341.9	1.0	0.5
Maximum:	12.0	13.9	9.2	193.0	3,495,944.8	2,287.9	1.7	1.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/15/2015 00:00	10.4	13.6	8.4	123.2	3,429,687.3	1,903.4	1.0	0.8
01/15/2015 01:00	10.3	13.7	8.4	118.9	3,375,174.6	1,848.5	1.0	0.7
01/15/2015 02:00	10.4	13.7	8.5	118.9	3,371,522.8	1,846.5	1.0	0.7
01/15/2015 03:00	10.4	13.7	8.5	119.2	3,380,834.9	1,851.6	1.0	0.7
01/15/2015 04:00	10.3	13.7	8.4	119.3	3,395,442.1	1,859.6	1.0	0.7
01/15/2015 05:00	10.4	13.7	8.5	119.3	3,388,868.9	1,856.0	1.0	0.7
01/15/2015 06:00	10.8	13.6	8.7	132.9	3,484,131.7	1,984.5	1.1	0.8
01/15/2015 07:00	11.7	13.4	9.2	166.1	3,515,758.3	2,207.9	1.4	1.1
01/15/2015 08:00	10.9	13.6	8.8	135.1	3,431,014.8	1,979.3	1.1	0.8
01/15/2015 09:00	10.4	13.8	8.6	109.9	2,950,265.4	1,572.7	1.1	0.6
01/15/2015 10:00	10.7	13.9	9.0	96.1	2,547,520.6	1,302.2	1.1	0.5
01/15/2015 11:00	10.8	13.9	9.1	96.3	2,551,433.3	1,304.2	1.1	0.5
01/15/2015 12:00	10.8	13.9	9.1	96.4	2,551,042.0	1,304.0	1.1	0.5
01/15/2015 13:00	10.8	13.9	9.1	96.3	2,543,021.1	1,299.9	1.1	0.5
01/15/2015 14:00	10.8	13.9	9.1	96.5	2,542,629.8	1,299.7	1.1	0.5
01/15/2015 15:00	10.7	13.9	9.0	96.9	2,607,384.0	1,332.8	1.0	0.5
01/15/2015 16:00	10.9	13.6	8.8	128.7	3,434,151.2	1,880.8	1.1	0.8
01/15/2015 17:00	11.7	13.3	9.1	170.3	3,451,727.5	2,218.1	1.4	1.1
01/15/2015 18:00	11.1	13.6	9.0	143.3	3,345,841.7	1,881.3	1.2	0.9
01/15/2015 19:00	10.8	13.7	8.9	145.2	3,449,446.4	2,065.5	1.2	1.0
01/15/2015 20:00	10.8	13.7	8.9	140.8	3,408,876.8	2,066.1	1.2	1.0
01/15/2015 21:00	10.8	13.7	8.9	144.4	3,449,134.5	2,090.5	1.2	1.0
01/15/2015 22:00	10.8	13.6	8.7	154.1	3,397,764.8	2,133.8	1.3	1.1
01/15/2015 23:00	10.0	13.9	8.4	121.7	3,346,730.9	1,881.8	1.0	0.8
Average/Sum#:	10.7	13.7	8.8	124.6	3,181,225.2	1,790.4	1.1	0.8
Minimum:	10.0	13.3	8.4	96.1	2,542,629.8	1,299.7	1.0	0.5
Maximum:	11.7	13.9	9.2	170.3	3,515,758.3	2,218.1	1.4	1.1
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/16/2015 00:00	9.9	13.9	8.3	118.1	3,325,719.2	1,845.7	1.0	0.7
01/16/2015 01:00	9.8	13.9	8.3	118.0	3,330,944.6	1,848.6	1.0	0.7
01/16/2015 02:00	9.8	13.9	8.3	117.8	3,340,494.6	1,853.9	1.0	0.7
01/16/2015 03:00	10.1	13.9	8.5	113.2	3,042,936.0	1,622.1	1.1	0.6
01/16/2015 04:00	10.4	13.9	8.8	96.1	2,582,343.1	1,320.0	1.1	0.5
01/16/2015 05:00	10.1	13.8	8.4	119.0	3,349,064.3	1,834.2	1.0	0.7
01/16/2015 06:00	10.2	13.8	8.5	126.5	3,431,285.9	1,954.4	1.1	0.8
01/16/2015 07:00	10.8	13.6	8.7	165.0	3,430,252.5	2,204.3	1.4	1.1
01/16/2015 08:00	10.0	13.8	8.3	124.9	3,432,097.6	1,929.8	1.0	0.8
01/16/2015 09:00	9.6	13.9	8.1	115.5	3,429,112.7	1,853.0	1.0	0.7
01/16/2015 10:00	9.6	13.9	8.1	116.3	3,461,682.8	1,870.6	1.0	0.7
01/16/2015 11:00	9.9	13.8	8.2	123.3	3,448,758.4	1,888.8	1.0	0.8
01/16/2015 12:00	10.3	13.8	8.6	106.4	2,805,988.6	1,475.3	1.1	0.6
01/16/2015 13:00	10.3	13.9	8.7	95.4	2,512,893.7	1,284.5	1.1	0.5
01/16/2015 14:00	10.3	13.9	8.7	95.3	2,507,807.3	1,281.9	1.1	0.5
01/16/2015 15:00	10.4	13.9	8.8	95.3	2,509,763.6	1,282.9	1.1	0.5
01/16/2015 16:00	10.9	13.7	8.9	133.3	3,154,000.6	1,750.4	1.2	0.9
01/16/2015 17:00	10.6	13.7	8.7	142.5	3,258,203.0	1,903.4	1.3	1.0
01/16/2015 18:00	10.2	13.9	8.6	96.4	2,608,949.1	1,333.6	1.0	0.5
01/16/2015 19:00	10.4	13.9	8.8	95.2	2,532,065.7	1,294.3	1.1	0.5
01/16/2015 20:00	10.4	13.9	8.8	95.2	2,542,042.9	1,299.4	1.1	0.5
01/16/2015 21:00	10.3	13.9	8.7	95.9	2,577,061.1	1,317.3	1.1	0.5
01/16/2015 22:00	10.4	13.8	8.6	106.9	2,976,737.3	1,521.6	1.0	0.6
01/16/2015 23:00	10.4	13.9	8.8	95.5	2,555,541.5	1,306.3	1.1	0.5
Average/Sum#:	10.2	13.8	8.6	112.8	3,006,072.8	1,628.2	1.1	0.7
Minimum:	9.6	13.6	8.1	95.2	2,507,807.3	1,281.9	1.0	0.5
Maximum:	10.9	13.9	8.9	165.0	3,461,682.8	2,204.3	1.4	1.1
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/17/2015 00:00	10.4	13.9	8.8	96.1	2,595,059.2	1,326.5	1.0	0.5
01/17/2015 01:00	10.3	13.9	8.7	109.0	3,012,538.0	1,539.9	1.0	0.6
01/17/2015 02:00	10.3	13.9	8.7	100.8	2,796,364.6	1,429.4	1.0	0.6
01/17/2015 03:00	10.4	13.8	8.6	112.4	3,127,765.3	1,598.8	1.0	0.6
01/17/2015 04:00	10.3	13.9	8.7	95.9	2,579,213.0	1,318.4	1.1	0.5
01/17/2015 05:00	10.4	13.9	8.8	96.9	2,654,335.7	1,356.8	1.0	0.5
01/17/2015 06:00	10.3	13.8	8.6	123.7	3,513,441.5	1,821.6	1.0	0.7
01/17/2015 07:00	10.4	13.7	8.5	124.1	3,510,291.2	1,845.6	1.0	0.7
01/17/2015 08:00	9.8	13.8	8.1	121.8	3,503,219.0	1,816.3	1.0	0.7
01/17/2015 09:00	9.2	13.9	7.8	118.7	3,511,399.8	1,794.9	1.0	0.7
01/17/2015 10:00	9.3	13.9	7.8	116.9	3,413,055.8	1,819.4	1.0	0.7
01/17/2015 11:00	9.5	13.8	7.9	114.8	3,472,522.6	1,851.1	0.9	0.6
01/17/2015 12:00	9.5	13.8	7.9	114.8	3,483,215.3	1,856.8	0.9	0.6
01/17/2015 13:00	9.8	13.8	8.1	104.9	2,994,474.7	1,574.4	1.0	0.6
01/17/2015 14:00	10.4	13.9	8.8	92.8	2,547,325.0	1,302.1	1.0	0.5
01/17/2015 15:00	10.4	13.9	8.8	92.8	2,547,716.3	1,302.3	1.0	0.5
01/17/2015 16:00	10.0	13.8	8.3	108.4	3,103,458.0	1,631.7	1.0	0.7
01/17/2015 17:00	10.6	13.6	8.6	124.9	3,413,553.6	1,944.3	1.0	0.8
01/17/2015 18:00	11.3	13.3	8.8	156.0	3,381,862.8	2,197.9	1.3	1.1
01/17/2015 19:00	11.2	13.4	8.8	150.0	3,366,580.3	2,138.8	1.3	1.1
01/17/2015 20:00	10.9	13.5	8.7	130.3	3,434,345.2	2,006.3	1.1	0.8
01/17/2015 21:00	11.0	13.4	8.7	133.8	3,411,536.7	2,042.8	1.1	0.8
01/17/2015 22:00	10.9	13.4	8.6	133.3	3,443,003.4	2,036.5	1.1	0.8
01/17/2015 23:00	11.0	13.4	8.7	134.9	3,424,730.0	2,050.7	1.1	0.8
Average/Sum#:	10.3	13.7	8.5	117.0	3,176,708.6	1,733.5	1.0	0.7
Minimum:	9.2	13.3	7.8	92.8	2,547,325.0	1,302.1	0.9	0.5
Maximum:	11.3	13.9	8.8	156.0	3,513,441.5	2,197.9	1.3	1.1
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/18/2015 00:00	10.5	13.5	8.4	126.8	3,421,134.1	1,973.6	1.1	0.8
01/18/2015 01:00	10.1	13.7	8.3	118.5	3,252,291.6	1,781.2	1.0	0.7
01/18/2015 02:00	21.1	15.2	21.8	166.9	2,070,151.9	891.9	2.2	0.7
01/18/2015 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/18/2015 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/18/2015 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/18/2015 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/18/2015 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/18/2015 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/18/2015 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/18/2015 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/18/2015 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/18/2015 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/18/2015 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/18/2015 14:00	38.0	17.4	64.1	0.6	1,977,534.4	462.1	0.0	0.0
01/18/2015 15:00	62.3	15.6	69.4	281.4	2,073,361.2	787.3	3.4	1.0
01/18/2015 16:00	10.3	13.9	8.7	132.4	2,816,514.7	1,439.7	1.4	0.7
01/18/2015 17:00	10.2	13.6	8.2	121.9	3,438,696.7	1,908.4	1.0	0.8
01/18/2015 18:00	10.8	13.4	8.5	129.6	3,434,858.7	2,006.6	1.1	0.8
01/18/2015 19:00	10.8	13.5	8.6	131.8	3,471,924.2	2,002.9	1.1	0.8
01/18/2015 20:00	10.5	13.5	8.4	127.2	3,464,643.7	1,973.4	1.0	0.8
01/18/2015 21:00	9.5	13.7	7.8	119.8	3,489,110.7	1,910.9	1.0	0.8
01/18/2015 22:00	9.9	13.8	8.2	104.3	2,885,181.5	1,474.8	1.0	0.6
01/18/2015 23:00	10.2	13.9	8.6	95.1	2,550,650.7	1,303.8	1.1	0.5
Average/Sum#:	17.2	14.2	18.4	127.4	2,949,696.5	1,532.0	1.3	0.7
Minimum:	9.5	13.4	7.8	0.6	1,977,534.4	462.1	0.0	0.0
Maximum:	62.3	17.4	69.4	281.4	3,489,110.7	2,006.6	3.4	1.0
%SI	45.8	45.8	45.8	45.8	45.8	45.8	45.8	45.8

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/19/2015 00:00	10.3	13.8	8.6	105.5	2,954,435.3	1,510.2	1.0	0.6
01/19/2015 01:00	10.2	13.9	8.6	97.2	2,647,293.0	1,353.2	1.0	0.5
01/19/2015 02:00	10.4	13.9	8.8	95.4	2,553,389.6	1,305.2	1.1	0.5
01/19/2015 03:00	10.3	13.8	8.6	108.0	3,043,401.0	1,577.9	1.0	0.6
01/19/2015 04:00	10.3	13.6	8.3	122.2	3,413,830.8	1,894.6	1.0	0.8
01/19/2015 05:00	10.8	13.5	8.6	127.2	3,472,368.6	1,977.8	1.0	0.8
01/19/2015 06:00	10.8	13.5	8.6	127.6	3,486,940.7	1,986.1	1.0	0.8
01/19/2015 07:00	11.1	13.4	8.7	137.3	3,477,836.9	2,082.5	1.1	0.8
01/19/2015 08:00	10.2	13.7	8.4	123.7	3,475,094.6	1,928.6	1.0	0.8
01/19/2015 09:00	9.8	13.8	8.1	119.9	3,460,809.3	1,895.4	1.0	0.8
01/19/2015 10:00	10.0	13.7	8.2	122.4	3,475,454.9	1,928.8	1.0	0.8
01/19/2015 11:00	9.9	13.7	8.1	118.5	3,391,607.7	1,857.5	1.0	0.7
01/19/2015 12:00	9.9	13.8	8.2	119.1	3,412,423.0	1,868.9	1.0	0.7
01/19/2015 13:00	9.9	13.8	8.2	118.1	3,407,675.6	1,866.3	1.0	0.7
01/19/2015 14:00	9.9	13.8	8.2	118.0	3,415,527.0	1,870.6	1.0	0.7
01/19/2015 15:00	10.4	13.7	8.5	123.6	3,448,426.8	1,913.8	1.0	0.8
01/19/2015 16:00	11.1	13.6	9.0	129.1	3,444,453.5	1,961.9	1.1	0.8
01/19/2015 17:00	11.1	13.5	8.9	136.6	3,431,337.9	2,029.6	1.1	0.8
01/19/2015 18:00	11.5	13.4	9.0	146.6	3,390,050.3	2,104.2	1.2	1.1
01/19/2015 19:00	11.5	13.5	9.2	147.3	3,399,107.0	2,085.0	1.3	1.0
01/19/2015 20:00	11.3	13.5	9.0	138.3	3,420,554.9	2,048.2	1.2	1.0
01/19/2015 21:00	11.1	13.5	8.9	133.7	3,430,830.7	2,029.3	1.1	0.8
01/19/2015 22:00	10.2	13.6	8.2	123.8	3,419,114.8	1,922.5	1.0	0.8
01/19/2015 23:00	9.9	13.7	8.1	118.7	3,347,702.1	1,857.9	1.0	0.7
Average/Sum#:	10.5	13.7	8.5	123.2	3,325,819.4	1,869.0	1.1	0.8
Minimum:	9.8	13.4	8.1	95.4	2,553,389.6	1,305.2	1.0	0.5
Maximum:	11.5	13.9	9.2	147.3	3,486,940.7	2,104.2	1.3	1.1
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/20/2015 00:00	10.3	13.6	8.3	124.1	3,463,043.1	1,947.2	1.0	0.8
01/20/2015 01:00	10.0	13.7	8.2	118.2	3,335,088.9	1,850.9	1.0	0.7
01/20/2015 02:00	10.1	13.7	8.3	118.6	3,338,512.5	1,852.8	1.0	0.7
01/20/2015 03:00	10.2	13.7	8.4	118.6	3,340,674.7	1,854.0	1.0	0.7
01/20/2015 04:00	10.1	13.7	8.3	118.7	3,343,557.7	1,855.6	1.0	0.7
01/20/2015 05:00	10.1	13.7	8.3	118.6	3,341,215.3	1,854.3	1.0	0.7
01/20/2015 06:00	10.8	13.6	8.7	129.1	3,481,147.0	1,982.8	1.1	0.8
01/20/2015 07:00	11.0	13.5	8.8	132.5	3,490,298.7	2,013.5	1.1	0.8
01/20/2015 08:00	10.9	13.5	8.7	133.0	3,505,033.0	2,022.0	1.1	0.8
01/20/2015 09:00	10.9	13.5	8.7	132.3	3,498,445.9	2,018.2	1.1	0.8
01/20/2015 10:00	10.7	13.5	8.5	129.7	3,472,964.2	2,003.5	1.1	0.8
01/20/2015 11:00	10.9	13.5	8.7	132.2	3,455,057.7	2,018.4	1.1	0.8
01/20/2015 12:00	11.1	13.5	8.9	134.1	3,423,730.0	2,025.1	1.1	0.8
01/20/2015 13:00	10.7	13.5	8.5	130.2	3,429,381.0	2,003.4	1.1	0.8
01/20/2015 14:00	10.9	13.5	8.7	130.6	3,447,354.7	2,013.9	1.1	0.8
01/20/2015 15:00	11.0	13.5	8.8	132.2	3,435,564.6	2,032.1	1.1	0.8
01/20/2015 16:00	10.0	13.7	8.2	120.4	3,388,244.2	1,880.4	1.0	0.8
01/20/2015 17:00	10.3	13.7	8.4	122.4	3,396,350.3	1,909.7	1.0	0.8
01/20/2015 18:00	11.0	13.5	8.8	133.5	3,429,309.2	2,028.4	1.1	0.8
01/20/2015 19:00	11.1	13.5	8.9	135.0	3,450,104.1	2,040.7	1.1	0.8
01/20/2015 20:00	10.9	13.5	8.7	132.1	3,429,038.7	2,003.2	1.1	0.8
01/20/2015 21:00	11.0	13.5	8.8	132.3	3,463,274.3	2,023.2	1.1	0.8
01/20/2015 22:00	10.6	13.6	8.6	128.2	3,476,757.8	1,980.3	1.1	0.8
01/20/2015 23:00	9.8	13.8	8.1	116.9	3,428,002.3	1,852.4	1.0	0.7
Average/Sum#:	10.6	13.6	8.6	127.2	3,427,589.6	1,961.1	1.1	0.8
Minimum:	9.8	13.5	8.1	116.9	3,335,088.9	1,850.9	1.0	0.7
Maximum:	11.1	13.8	8.9	135.0	3,505,033.0	2,040.7	1.1	0.8
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/21/2015 00:00	9.9	13.8	8.2	118.8	3,514,355.7	1,873.4	1.0	0.7
01/21/2015 01:00	9.9	13.9	8.3	116.3	3,486,592.0	1,858.6	0.9	0.6
01/21/2015 02:00	10.4	13.8	8.6	122.9	3,500,914.9	1,891.8	1.0	0.8
01/21/2015 03:00	10.1	13.8	8.4	117.1	3,470,646.6	1,850.1	1.0	0.7
01/21/2015 04:00	10.1	13.8	8.4	118.4	3,447,803.5	1,863.1	1.0	0.7
01/21/2015 05:00	10.2	13.8	8.5	119.4	3,391,425.1	1,857.4	1.0	0.7
01/21/2015 06:00	10.7	13.6	8.6	127.9	3,496,356.7	1,940.4	1.0	0.8
01/21/2015 07:00	11.1	13.6	9.0	135.7	3,507,131.0	1,997.6	1.1	0.8
01/21/2015 08:00	11.3	13.5	9.0	137.8	3,495,455.7	2,042.0	1.1	0.8
01/21/2015 09:00	11.1	13.5	8.9	134.8	3,442,904.1	2,011.3	1.1	0.8
01/21/2015 10:00	10.6	13.6	8.6	127.0	3,450,771.6	1,940.3	1.0	0.8
01/21/2015 11:00	10.9	13.6	8.8	129.9	3,442,590.6	1,935.7	1.1	0.8
01/21/2015 12:00	10.7	13.7	8.8	127.9	3,452,751.3	1,916.2	1.1	0.8
01/21/2015 13:00	10.2	13.8	8.5	123.0	3,418,631.0	1,872.3	1.0	0.7
01/21/2015 14:00	9.8	13.8	8.1	117.7	3,445,397.7	1,861.8	1.0	0.7
01/21/2015 15:00	10.7	13.6	8.6	125.1	3,428,896.4	1,928.0	1.0	0.8
01/21/2015 16:00	11.0	13.5	8.8	129.1	3,399,812.7	1,961.3	1.1	0.8
01/21/2015 17:00	10.9	13.5	8.7	130.2	3,412,263.2	1,993.4	1.1	0.8
01/21/2015 18:00	11.0	13.5	8.8	134.2	3,399,679.5	2,035.7	1.1	0.8
01/21/2015 19:00	11.0	13.5	8.8	133.8	3,433,028.6	2,030.6	1.1	0.8
01/21/2015 20:00	11.0	13.5	8.8	131.4	3,472,097.5	2,003.0	1.1	0.8
01/21/2015 21:00	10.9	13.5	8.7	130.1	3,457,189.9	1,994.4	1.1	0.8
01/21/2015 22:00	10.3	13.6	8.3	123.6	3,410,222.4	1,917.5	1.0	0.8
01/21/2015 23:00	10.2	13.8	8.5	107.4	2,967,466.6	1,560.2	1.0	0.6
Average/Sum#:	10.6	13.7	8.6	125.8	3,431,016.0	1,922.3	1.0	0.8
Minimum:	9.8	13.5	8.1	107.4	2,967,466.6	1,560.2	0.9	0.6
Maximum:	11.3	13.9	9.0	137.8	3,514,355.7	2,042.0	1.1	0.8
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/22/2015 00:00	10.5	13.9	8.9	100.9	2,749,804.2	1,405.6	1.0	0.6
01/22/2015 01:00	10.4	13.9	8.8	95.5	2,543,412.3	1,300.1	1.1	0.5
01/22/2015 02:00	10.5	13.9	8.9	95.9	2,568,257.6	1,312.8	1.1	0.5
01/22/2015 03:00	10.4	13.8	8.6	108.8	3,024,499.1	1,568.1	1.0	0.6
01/22/2015 04:00	10.2	13.7	8.4	120.1	3,376,351.9	1,873.8	1.0	0.7
01/22/2015 05:00	10.2	13.7	8.4	119.3	3,350,585.1	1,859.5	1.0	0.7
01/22/2015 06:00	10.4	13.6	8.4	124.3	3,414,846.4	1,920.1	1.0	0.8
01/22/2015 07:00	10.7	13.5	8.5	132.5	3,433,489.3	2,005.8	1.1	0.8
01/22/2015 08:00	10.6	13.6	8.6	128.7	3,471,841.9	1,977.5	1.1	0.8
01/22/2015 09:00	10.8	13.5	8.6	131.9	3,485,445.1	2,010.7	1.1	0.8
01/22/2015 10:00	10.1	13.7	8.3	119.7	3,356,170.9	1,862.6	1.0	0.7
01/22/2015 11:00	10.1	13.7	8.3	118.9	3,341,395.5	1,854.4	1.0	0.7
01/22/2015 12:00	9.9	13.7	8.1	118.7	3,332,566.3	1,849.5	1.0	0.7
01/22/2015 13:00	10.2	13.8	8.5	106.2	2,864,759.7	1,506.2	1.1	0.6
01/22/2015 14:00	10.5	13.8	8.7	114.7	3,221,081.8	1,646.5	1.0	0.7
01/22/2015 15:00	10.2	13.7	8.4	116.6	3,251,163.6	1,733.1	1.0	0.7
01/22/2015 16:00	9.8	13.7	8.0	118.6	3,386,495.2	1,854.7	1.0	0.7
01/22/2015 17:00	10.5	13.6	8.5	126.4	3,451,651.7	1,966.0	1.0	0.8
01/22/2015 18:00	11.0	13.4	8.7	133.1	3,446,215.6	2,038.4	1.1	0.8
01/22/2015 19:00	10.9	13.4	8.6	132.6	3,471,490.8	2,028.0	1.1	0.8
01/22/2015 20:00	10.6	13.5	8.5	128.8	3,496,070.2	1,991.3	1.1	0.8
01/22/2015 21:00	10.1	13.6	8.2	124.3	3,470,334.8	1,951.3	1.0	0.8
01/22/2015 22:00	10.3	13.6	8.3	124.2	3,470,049.3	1,925.8	1.0	0.8
01/22/2015 23:00	10.1	13.7	8.3	120.2	3,427,395.3	1,877.1	1.0	0.8
Average/Sum#:	10.4	13.7	8.5	119.2	3,266,890.6	1,805.0	1.0	0.7
Minimum:	9.8	13.4	8.0	95.5	2,543,412.3	1,300.1	1.0	0.5
Maximum:	11.0	13.9	8.9	133.1	3,496,070.2	2,038.4	1.1	0.8
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/23/2015 00:00	10.9	13.6	8.8	129.9	3,437,610.9	1,932.9	1.1	0.8
01/23/2015 01:00	10.4	13.7	8.5	122.5	3,459,348.6	1,894.6	1.0	0.8
01/23/2015 02:00	11.2	13.5	8.9	131.9	3,494,139.0	1,990.2	1.1	0.8
01/23/2015 03:00	11.1	13.5	8.9	132.2	3,459,201.1	1,970.3	1.1	0.8
01/23/2015 04:00	10.7	13.6	8.6	127.2	3,433,831.6	1,905.7	1.1	0.8
01/23/2015 05:00	10.5	13.7	8.6	125.1	3,416,173.3	1,895.9	1.0	0.8
01/23/2015 06:00	10.7	13.6	8.6	128.1	3,476,737.3	1,954.9	1.0	0.8
01/23/2015 07:00	11.1	13.5	8.9	136.6	3,462,589.6	2,022.8	1.1	0.8
01/23/2015 08:00	11.0	13.5	8.8	134.4	3,473,831.0	2,004.0	1.1	0.8
01/23/2015 09:00	10.1	13.7	8.3	122.6	3,496,414.3	1,914.9	1.0	0.8
01/23/2015 10:00	10.2	13.7	8.4	122.1	3,411,128.0	1,893.1	1.0	0.8
01/23/2015 11:00	9.8	13.8	8.1	117.5	3,395,624.7	1,859.7	1.0	0.7
01/23/2015 12:00	9.7	13.8	8.1	117.1	3,454,280.5	1,866.6	1.0	0.7
01/23/2015 13:00	9.7	13.8	8.1	116.8	3,406,762.7	1,865.8	1.0	0.7
01/23/2015 14:00	9.7	13.8	8.1	116.6	3,400,919.8	1,862.6	1.0	0.7
01/23/2015 15:00	10.1	13.7	8.3	120.1	3,383,199.0	1,877.6	1.0	0.8
01/23/2015 16:00	10.7	13.6	8.6	126.5	3,409,511.0	1,917.1	1.1	0.8
01/23/2015 17:00	10.6	13.6	8.6	126.6	3,432,453.3	1,930.0	1.1	0.8
01/23/2015 18:00	11.6	13.5	9.2	140.7	3,408,363.7	2,040.9	1.2	1.0
01/23/2015 19:00	11.8	13.5	9.4	147.8	3,395,842.5	2,058.2	1.3	1.0
01/23/2015 20:00	11.7	13.5	9.3	143.9	3,378,188.5	2,047.5	1.2	1.0
01/23/2015 21:00	11.6	13.5	9.2	140.3	3,402,089.7	2,012.3	1.2	1.0
01/23/2015 22:00	11.4	13.5	9.1	138.4	3,408,176.1	2,015.9	1.2	1.0
01/23/2015 23:00	10.5	13.7	8.6	125.4	3,451,490.0	1,915.5	1.0	0.8
Average/Sum#:	10.7	13.6	8.7	128.8	3,431,162.8	1,943.7	1.1	0.8
Minimum:	9.7	13.5	8.1	116.6	3,378,188.5	1,859.7	1.0	0.7
Maximum:	11.8	13.8	9.4	147.8	3,496,414.3	2,058.2	1.3	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/24/2015 00:00	9.8	13.8	8.1	118.0	3,446,878.2	1,862.6	1.0	0.7
01/24/2015 01:00	10.5	13.7	8.6	124.5	3,435,064.1	1,881.3	1.0	0.8
01/24/2015 02:00	9.8	13.8	8.1	117.8	3,439,475.9	1,858.6	1.0	0.7
01/24/2015 03:00	9.9	13.8	8.2	118.1	3,455,760.9	1,867.4	1.0	0.7
01/24/2015 04:00	10.8	13.6	8.7	128.8	3,454,862.1	1,942.6	1.1	0.8
01/24/2015 05:00	11.2	13.5	8.9	135.1	3,446,269.1	1,988.1	1.1	0.8
01/24/2015 06:00	10.9	13.6	8.8	131.4	3,441,242.1	1,985.2	1.1	0.8
01/24/2015 07:00	11.1	13.5	8.9	135.7	3,441,363.5	2,010.4	1.1	0.8
01/24/2015 08:00	10.6	13.6	8.6	128.3	3,442,946.3	1,935.9	1.1	0.8
01/24/2015 09:00	10.2	13.6	8.2	123.9	3,422,840.2	1,899.6	1.0	0.8
01/24/2015 10:00	9.9	13.8	8.2	117.7	3,373,531.3	1,847.6	1.0	0.7
01/24/2015 11:00	9.8	13.8	8.1	117.4	3,404,571.6	1,864.6	1.0	0.7
01/24/2015 12:00	10.3	13.7	8.4	120.6	3,397,085.4	1,860.5	1.0	0.7
01/24/2015 13:00	10.6	13.7	8.7	122.2	3,350,159.8	1,834.8	1.0	0.7
01/24/2015 14:00	10.5	14.0	9.0	96.9	2,581,861.1	1,300.9	1.1	0.5
01/24/2015 15:00	10.5	14.0	9.0	95.4	2,575,311.7	1,297.6	1.0	0.5
01/24/2015 16:00	10.5	13.9	8.9	104.4	2,865,669.4	1,443.9	1.0	0.6
01/24/2015 17:00	11.4	13.6	9.2	127.4	3,211,124.6	1,829.0	1.1	0.7
01/24/2015 18:00	11.5	13.4	9.0	142.7	3,374,979.0	2,070.2	1.2	1.0
01/24/2015 19:00	11.2	13.4	8.8	135.7	3,417,882.9	2,046.6	1.1	0.8
01/24/2015 20:00	11.0	13.5	8.8	130.3	3,442,108.9	1,985.7	1.1	0.8
01/24/2015 21:00	11.0	13.5	8.8	131.6	3,428,353.9	2,002.8	1.1	0.8
01/24/2015 22:00	11.1	13.4	8.7	133.8	3,455,057.7	2,018.4	1.1	0.8
01/24/2015 23:00	10.7	13.5	8.5	130.2	3,470,613.0	1,976.8	1.1	0.8
Average/Sum#:	10.6	13.7	8.6	123.7	3,323,958.9	1,858.8	1.1	0.7
Minimum:	9.8	13.4	8.1	95.4	2,575,311.7	1,297.6	1.0	0.5
Maximum:	11.5	14.0	9.2	142.7	3,470,613.0	2,070.2	1.2	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/25/2015 00:00	10.4	13.9	8.8	105.5	2,874,617.4	1,469.4	1.0	0.6
01/25/2015 01:00	33.0	16.1	40.6	234.2	1,583,430.5	589.7	4.1	0.9
01/25/2015 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2015 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2015 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2015 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2015 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2015 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2015 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2015 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2015 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2015 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2015 12:00	38.4	17.4	64.7	0.0	1,996,364.0	466.5	0.0	0.0
01/25/2015 13:00	57.5	15.8	66.5	230.1	1,944,308.7	709.9	3.0	0.9
01/25/2015 14:00	21.3	14.0	18.2	173.1	2,896,131.2	1,438.1	1.7	1.0
01/25/2015 15:00	9.8	13.8	8.1	120.3	3,475,403.5	1,776.5	1.0	0.7
01/25/2015 16:00	9.8	13.8	8.1	112.8	3,249,057.2	1,660.8	1.0	0.7
01/25/2015 17:00	10.2	13.7	8.4	123.0	3,237,177.0	1,820.2	1.1	0.7
01/25/2015 18:00	11.3	13.4	8.9	164.3	3,403,727.9	2,162.4	1.4	1.1
01/25/2015 19:00	10.1	13.7	8.3	123.0	3,285,717.6	1,823.5	1.1	0.7
01/25/2015 20:00	9.2	13.8	7.6	119.6	3,539,179.5	1,809.1	1.0	0.7
01/25/2015 21:00	9.5	13.8	7.9	115.1	3,345,699.4	1,710.2	1.0	0.7
01/25/2015 22:00	16.3	14.6	15.3	150.9	2,892,053.1	1,351.6	1.4	0.7
01/25/2015 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	19.0	14.4	20.9	136.3	2,901,759.0	1,445.2	1.4	0.7
Minimum:	9.2	13.4	7.6	0.0	1,583,430.5	466.5	0.0	0.0
Maximum:	57.5	17.4	66.5	234.2	3,539,179.5	2,162.4	4.1	1.1
%SI	45.8	45.8	45.8	45.8	45.8	45.8	45.8	45.8

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/26/2015 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2015 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2015 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2015 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2015 04:00	45.6	16.9	67.3	149.7	1,996,116.2	553.9	0.0	0.0
01/26/2015 05:00	32.3	14.4	29.3	209.1	2,713,567.1	1,288.0	2.1	1.0
01/26/2015 06:00	10.5	13.8	8.7	117.9	3,308,799.3	1,715.5	1.0	0.7
01/26/2015 07:00	9.6	13.9	8.1	121.9	3,550,526.2	1,814.9	1.0	0.7
01/26/2015 08:00	9.4	13.8	7.8	121.1	3,548,178.6	1,813.7	1.0	0.7
01/26/2015 09:00	9.3	13.8	7.7	120.8	3,502,061.8	1,815.7	1.0	0.7
01/26/2015 10:00	10.1	13.7	8.3	123.7	3,509,198.2	1,819.4	1.0	0.7
01/26/2015 11:00	10.3	13.7	8.4	122.3	3,418,739.0	1,772.5	1.0	0.7
01/26/2015 12:00	10.5	13.7	8.6	124.2	3,507,655.2	1,818.6	1.0	0.7
01/26/2015 13:00	10.5	13.8	8.7	123.8	3,468,887.0	1,798.5	1.0	0.7
01/26/2015 14:00	10.6	13.8	8.8	124.8	3,477,952.2	1,803.2	1.0	0.7
01/26/2015 15:00	10.7	13.8	8.9	124.8	3,470,815.7	1,799.5	1.0	0.7
01/26/2015 16:00	10.7	13.8	8.9	124.8	3,467,151.1	1,797.6	1.0	0.7
01/26/2015 17:00	9.8	13.9	8.3	111.9	3,160,827.1	1,615.7	1.0	0.6
01/26/2015 18:00	10.2	13.9	8.6	116.2	3,268,816.0	1,670.9	1.0	0.7
01/26/2015 19:00	10.6	13.7	8.7	124.2	3,501,868.9	1,815.6	1.0	0.7
01/26/2015 20:00	10.6	13.7	8.7	124.1	3,501,290.3	1,815.3	1.0	0.7
01/26/2015 21:00	10.0	13.8	8.3	110.5	3,117,201.2	1,593.4	1.0	0.6
01/26/2015 22:00	10.0	13.9	8.4	101.3	2,839,012.4	1,451.2	1.0	0.6
01/26/2015 23:00	9.8	13.9	8.3	94.9	2,646,901.7	1,353.0	1.0	0.5
Average/Sum#:	13.1	14.0	12.4	124.6	3,248,778.3	1,646.3	1.0	0.7
Minimum:	9.3	13.7	7.7	94.9	1,996,116.2	553.9	0.0	0.0
Maximum:	45.6	16.9	67.3	209.1	3,550,526.2	1,819.4	2.1	1.0
%SI	16.7	16.7	16.7	16.7	16.7	16.7	16.7	16.7

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/27/2015 00:00	9.9	13.9	8.3	95.0	2,656,487.7	1,357.9	1.0	0.5
01/27/2015 01:00	9.9	13.9	8.3	94.9	2,653,944.5	1,356.6	1.0	0.5
01/27/2015 02:00	10.1	13.9	8.5	107.5	3,046,578.0	1,557.3	1.0	0.6
01/27/2015 03:00	9.5	13.9	8.0	118.0	3,345,503.8	1,710.1	1.0	0.7
01/27/2015 04:00	10.4	13.7	8.5	125.5	3,464,263.3	1,821.4	1.0	0.7
01/27/2015 05:00	10.5	13.7	8.6	126.6	3,492,032.2	1,836.0	1.0	0.7
01/27/2015 06:00	10.3	13.7	8.4	127.4	3,503,253.9	1,841.9	1.0	0.7
01/27/2015 07:00	10.5	13.7	8.6	126.6	3,507,057.8	1,843.9	1.0	0.7
01/27/2015 08:00	10.5	13.7	8.6	126.7	3,503,063.7	1,841.8	1.0	0.7
01/27/2015 09:00	10.3	13.7	8.4	125.8	3,484,234.1	1,831.9	1.0	0.7
01/27/2015 10:00	10.3	13.9	8.7	102.5	2,713,025.3	1,386.8	1.1	0.6
01/27/2015 11:00	10.4	13.9	8.8	95.4	2,496,460.7	1,276.1	1.1	0.5
01/27/2015 12:00	10.3	13.9	8.7	95.8	2,547,911.9	1,302.4	1.1	0.5
01/27/2015 13:00	10.3	13.8	8.6	108.4	3,051,077.5	1,559.6	1.0	0.6
01/27/2015 14:00	10.3	13.9	8.7	95.9	2,534,608.9	1,295.6	1.1	0.5
01/27/2015 15:00	10.4	13.8	8.6	109.5	3,073,379.6	1,571.0	1.0	0.6
01/27/2015 16:00	10.2	13.9	8.6	97.2	2,588,016.5	1,322.9	1.1	0.5
01/27/2015 17:00	10.2	13.8	8.5	111.8	3,107,843.0	1,656.7	1.0	0.7
01/27/2015 18:00	11.0	13.5	8.8	129.4	3,449,736.0	1,990.1	1.1	0.8
01/27/2015 19:00	10.9	13.5	8.7	128.5	3,433,268.3	1,980.6	1.1	0.8
01/27/2015 20:00	10.7	13.5	8.5	126.4	3,444,629.0	1,962.0	1.0	0.8
01/27/2015 21:00	10.5	13.6	8.5	127.1	3,461,659.0	1,971.7	1.0	0.8
01/27/2015 22:00	10.4	13.6	8.4	127.2	3,402,759.6	1,963.0	1.1	0.8
01/27/2015 23:00	10.0	13.8	8.3	109.0	2,973,362.7	1,563.3	1.0	0.6
Average/Sum#:	10.3	13.8	8.5	114.1	3,122,256.5	1,658.4	1.0	0.7
Minimum:	9.5	13.5	8.0	94.9	2,496,460.7	1,276.1	1.0	0.5
Maximum:	11.0	13.9	8.8	129.4	3,507,057.8	1,990.1	1.1	0.8
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/28/2015 00:00	10.3	13.9	8.7	95.3	2,501,938.3	1,278.9	1.1	0.5
01/28/2015 01:00	10.4	13.9	8.8	95.5	2,501,155.8	1,278.5	1.1	0.5
01/28/2015 02:00	10.4	13.9	8.8	95.3	2,489,613.5	1,272.6	1.1	0.5
01/28/2015 03:00	10.4	13.9	8.8	95.5	2,488,048.5	1,271.8	1.1	0.5
01/28/2015 04:00	10.4	13.9	8.8	95.5	2,506,046.6	1,281.0	1.1	0.5
01/28/2015 05:00	10.4	13.8	8.6	110.1	3,021,738.1	1,610.8	1.0	0.6
01/28/2015 06:00	10.1	13.7	8.3	118.8	3,477,412.6	1,879.1	1.0	0.8
01/28/2015 07:00	11.2	13.5	8.9	144.2	3,378,303.2	2,022.9	1.2	1.0
01/28/2015 08:00	10.1	13.7	8.3	120.8	3,378,874.5	1,875.2	1.0	0.8
01/28/2015 09:00	9.6	13.8	8.0	115.0	3,470,834.2	1,850.2	0.9	0.6
01/28/2015 10:00	9.6	13.8	8.0	114.8	3,472,897.8	1,851.3	0.9	0.6
01/28/2015 11:00	9.7	13.8	8.1	111.3	3,253,789.9	1,734.5	1.0	0.7
01/28/2015 12:00	10.7	13.9	9.0	93.4	2,518,550.1	1,269.0	1.0	0.5
01/28/2015 13:00	10.8	13.9	9.1	118.3	3,149,480.5	1,609.9	1.1	0.6
01/28/2015 14:00	11.5	13.7	9.4	132.1	3,349,246.9	1,834.3	1.2	0.9
01/28/2015 15:00	11.8	13.5	9.4	150.6	3,316,745.9	2,058.7	1.4	1.0
01/28/2015 16:00	11.6	13.5	9.2	142.6	3,367,431.5	1,991.8	1.3	1.0
01/28/2015 17:00	10.9	13.6	8.8	134.4	3,371,037.5	1,944.7	1.2	1.0
01/28/2015 18:00	11.4	13.5	9.1	141.7	3,390,931.5	2,005.7	1.3	1.0
01/28/2015 19:00	11.4	13.5	9.1	140.1	3,391,607.7	2,006.1	1.2	1.0
01/28/2015 20:00	10.7	13.6	8.6	131.7	3,404,248.6	1,939.0	1.2	1.0
01/28/2015 21:00	10.6	13.6	8.6	129.8	3,430,759.2	1,954.1	1.1	0.8
01/28/2015 22:00	10.3	13.6	8.3	126.5	3,379,493.6	1,924.9	1.1	0.8
01/28/2015 23:00	9.7	13.8	8.1	117.1	3,372,618.4	1,847.1	1.0	0.7
Average/Sum#:	10.6	13.7	8.7	119.6	3,140,950.2	1,733.0	1.1	0.7
Minimum:	9.6	13.5	8.0	93.4	2,488,048.5	1,269.0	0.9	0.5
Maximum:	11.8	13.9	9.4	150.6	3,477,412.6	2,058.7	1.4	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/29/2015 00:00	9.7	13.8	8.1	117.0	3,367,688.4	1,844.4	1.0	0.7
01/29/2015 01:00	9.7	13.8	8.1	117.2	3,376,087.6	1,849.0	1.0	0.7
01/29/2015 02:00	9.8	13.8	8.1	117.8	3,379,374.2	1,850.8	1.0	0.7
01/29/2015 03:00	9.9	13.8	8.2	117.7	3,374,809.5	1,848.3	1.0	0.7
01/29/2015 04:00	9.9	13.7	8.1	118.1	3,393,251.0	1,858.4	1.0	0.7
01/29/2015 05:00	9.9	13.8	8.2	117.9	3,383,938.9	1,853.3	1.0	0.7
01/29/2015 06:00	10.5	13.6	8.5	127.7	3,443,657.7	1,936.3	1.1	0.8
01/29/2015 07:00	11.1	13.5	8.9	144.4	3,452,318.9	2,016.8	1.3	1.0
01/29/2015 08:00	11.0	13.5	8.8	133.0	3,497,011.9	1,966.3	1.1	0.8
01/29/2015 09:00	11.0	13.5	8.8	134.2	3,434,095.0	1,956.0	1.2	1.0
01/29/2015 10:00	9.9	13.8	8.2	122.6	3,411,327.4	1,868.3	1.1	0.7
01/29/2015 11:00	9.5	13.8	7.9	115.1	3,430,038.0	1,853.5	1.0	0.7
01/29/2015 12:00	9.9	13.7	8.1	116.0	3,439,105.8	1,858.4	1.0	0.7
01/29/2015 13:00	10.4	13.7	8.5	125.0	3,388,503.7	1,855.8	1.1	0.7
01/29/2015 14:00	10.5	13.7	8.6	124.7	3,409,866.7	1,867.5	1.1	0.7
01/29/2015 15:00	11.6	13.5	9.2	145.1	3,304,714.5	2,027.1	1.3	1.0
01/29/2015 16:00	11.1	13.6	9.0	134.4	3,362,814.7	1,915.4	1.2	1.0
01/29/2015 17:00	10.2	13.7	8.4	125.9	3,416,533.7	1,896.1	1.1	0.8
01/29/2015 18:00	11.4	13.5	9.1	139.9	3,392,284.0	2,006.5	1.2	1.0
01/29/2015 19:00	11.4	13.5	9.1	141.3	3,382,144.2	2,025.2	1.3	1.0
01/29/2015 20:00	11.4	13.5	9.1	144.5	3,413,874.8	2,044.2	1.3	1.0
01/29/2015 21:00	10.9	13.6	8.8	134.6	3,429,801.4	1,978.6	1.2	1.0
01/29/2015 22:00	10.2	13.7	8.4	122.4	3,437,255.2	1,907.6	1.1	0.8
01/29/2015 23:00	9.8	13.8	8.1	117.3	3,439,660.9	1,858.7	1.0	0.7
Average/Sum#:	10.4	13.7	8.5	127.2	3,406,673.3	1,914.3	1.1	0.8
Minimum:	9.5	13.5	7.9	115.1	3,304,714.5	1,844.4	1.0	0.7
Maximum:	11.6	13.8	9.2	145.1	3,497,011.9	2,044.2	1.3	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/30/2015 00:00	9.8	13.8	8.1	117.4	3,441,141.4	1,859.5	1.0	0.7
01/30/2015 01:00	9.7	13.8	8.1	117.1	3,442,621.9	1,860.3	1.0	0.7
01/30/2015 02:00	9.8	13.8	8.1	117.6	3,389,964.4	1,856.6	1.0	0.7
01/30/2015 03:00	9.9	13.8	8.2	117.8	3,386,495.2	1,854.7	1.0	0.7
01/30/2015 04:00	9.9	13.8	8.2	117.6	3,444,102.3	1,861.1	1.0	0.7
01/30/2015 05:00	9.7	13.8	8.1	117.4	3,451,319.6	1,865.0	1.0	0.7
01/30/2015 06:00	10.2	13.7	8.4	125.1	3,473,042.8	1,902.1	1.1	0.8
01/30/2015 07:00	11.2	13.5	8.9	143.1	3,428,588.0	1,977.9	1.3	1.0
01/30/2015 08:00	11.1	13.6	9.0	135.6	3,412,120.2	1,968.4	1.2	1.0
01/30/2015 09:00	10.6	13.6	8.6	129.8	3,422,316.0	1,924.3	1.1	0.8
01/30/2015 10:00	10.4	13.7	8.5	126.5	3,406,983.7	1,890.8	1.1	0.8
01/30/2015 11:00	9.8	13.7	8.0	117.8	3,397,633.2	1,860.8	1.0	0.7
01/30/2015 12:00	10.6	13.9	8.9	116.7	3,142,539.6	1,629.3	1.1	0.7
01/30/2015 13:00	10.9	13.6	8.8	128.6	3,340,166.5	1,902.5	1.1	0.8
01/30/2015 14:00	11.2	13.6	9.1	133.0	3,354,914.2	1,910.9	1.2	1.0
01/30/2015 15:00	11.1	13.6	9.0	132.9	3,383,367.5	1,902.4	1.2	1.0
01/30/2015 16:00	11.7	13.5	9.3	143.2	3,380,595.3	1,974.9	1.3	1.0
01/30/2015 17:00	10.6	13.7	8.7	129.4	3,392,028.2	1,882.5	1.1	0.8
01/30/2015 18:00	10.2	13.7	8.4	121.6	3,415,892.2	1,870.8	1.1	0.7
01/30/2015 19:00	10.2	13.7	8.4	122.9	3,401,467.6	1,862.9	1.1	0.7
01/30/2015 20:00	9.9	13.8	8.2	117.8	3,406,032.3	1,865.4	1.0	0.7
01/30/2015 21:00	9.7	13.8	8.1	117.3	3,452,059.8	1,865.4	1.0	0.7
01/30/2015 22:00	9.9	13.9	8.3	112.9	3,182,129.6	1,696.3	1.1	0.7
01/30/2015 23:00	10.9	14.0	9.3	96.2	2,526,687.2	1,273.1	1.1	0.5
Average/Sum#:	10.4	13.7	8.5	123.1	3,353,092.0	1,846.6	1.1	0.8
Minimum:	9.7	13.5	8.0	96.2	2,526,687.2	1,273.1	1.0	0.5
Maximum:	11.7	14.0	9.3	143.2	3,473,042.8	1,977.9	1.3	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/31/2015 00:00	34.7	16.3	44.5	247.6	1,496,233.1	546.3	4.8	1.0
01/31/2015 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/31/2015 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/31/2015 03:00	50.2	16.6	68.9	245.0	1,965,808.7	574.2	3.0	0.7
01/31/2015 04:00	44.7	14.7	42.5	234.8	2,358,723.1	1,067.9	2.8	1.2
01/31/2015 05:00	10.6	13.8	8.8	118.9	3,339,707.2	1,780.3	1.0	0.7
01/31/2015 06:00	9.9	13.9	8.3	118.9	3,466,309.2	1,873.1	1.0	0.7
01/31/2015 07:00	9.9	13.9	8.3	119.1	3,465,754.0	1,872.8	1.0	0.7
01/31/2015 08:00	9.8	13.9	8.3	119.0	3,511,729.4	1,872.0	1.0	0.7
01/31/2015 09:00	9.8	13.8	8.1	117.8	3,463,533.3	1,871.6	1.0	0.7
01/31/2015 10:00	9.7	13.8	8.1	117.5	3,460,387.4	1,869.9	1.0	0.7
01/31/2015 11:00	10.4	14.0	8.9	99.3	2,711,658.7	1,366.3	1.1	0.5
01/31/2015 12:00	10.7	14.0	9.1	95.9	2,578,685.7	1,299.3	1.1	0.5
01/31/2015 13:00	10.7	14.0	9.1	96.4	2,636,439.6	1,328.4	1.1	0.5
01/31/2015 14:00	10.4	14.0	8.9	105.4	3,021,466.2	1,522.4	1.0	0.6
01/31/2015 15:00	11.1	13.8	9.2	127.8	3,238,308.3	1,702.6	1.2	0.9
01/31/2015 16:00	10.6	13.8	8.8	125.8	3,247,599.3	1,731.2	1.2	0.9
01/31/2015 17:00	10.7	13.9	9.0	117.5	3,074,647.1	1,594.1	1.1	0.6
01/31/2015 18:00	11.9	13.5	9.5	150.6	3,370,621.0	2,018.3	1.3	1.0
01/31/2015 19:00	11.9	13.5	9.5	155.0	3,356,079.7	2,034.1	1.4	1.0
01/31/2015 20:00	11.8	13.6	9.5	158.1	3,357,564.6	2,035.0	1.4	1.0
01/31/2015 21:00	11.9	13.5	9.5	157.0	3,373,568.7	2,044.7	1.4	1.0
01/31/2015 22:00	11.5	13.5	9.2	150.8	3,404,188.6	2,038.4	1.3	1.0
01/31/2015 23:00	10.6	13.6	8.6	136.4	3,416,187.1	1,945.8	1.2	1.0
Average/Sum#:	15.2	14.1	14.8	141.6	3,059,781.8	1,635.9	1.5	0.8
Minimum:	9.7	13.5	8.1	95.9	1,496,233.1	546.3	1.0	0.5
Maximum:	50.2	16.6	68.9	247.6	3,511,729.4	2,044.7	4.8	1.2
%SI	8.3	8.3	8.3	8.3	8.3	8.3	8.3	8.3

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/01/2015 00:00	11.1	13.5	8.9	142.5	3,409,695.5	1,991.9	1.3	1.0
02/01/2015 01:00	10.5	13.8	8.7	120.0	3,126,145.1	1,620.8	1.1	0.6
02/01/2015 02:00	31.1	16.2	39.0	224.6	1,621,672.4	592.1	4.0	0.9
02/01/2015 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2015 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2015 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2015 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2015 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2015 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2015 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2015 10:00	43.2	17.3	70.8	42.8	1,923,638.5	477.6	0.0	0.0
02/01/2015 11:00	61.3	15.3	64.6	287.8	2,054,136.6	840.0	3.8	1.3
02/01/2015 12:00	10.0	13.9	8.4	116.4	2,710,677.8	1,385.6	1.3	0.7
02/01/2015 13:00	9.8	13.9	8.3	95.8	2,760,084.8	1,390.7	1.0	0.6
02/01/2015 14:00	10.0	13.9	8.4	122.6	3,380,913.2	1,728.2	1.1	0.7
02/01/2015 15:00	9.7	13.9	8.2	103.1	2,990,703.8	1,506.9	1.0	0.6
02/01/2015 16:00	9.8	13.8	8.1	117.5	3,353,213.8	1,787.5	1.0	0.7
02/01/2015 17:00	10.2	13.7	8.4	125.7	3,441,399.5	1,909.9	1.1	0.8
02/01/2015 18:00	10.9	13.5	8.7	135.6	3,396,686.0	1,984.3	1.2	1.0
02/01/2015 19:00	11.0	13.5	8.8	138.5	3,399,046.6	2,010.5	1.2	1.0
02/01/2015 20:00	11.0	13.5	8.8	139.4	3,368,283.0	2,016.9	1.2	1.0
02/01/2015 21:00	11.0	13.5	8.8	138.7	3,378,589.7	1,998.4	1.2	1.0
02/01/2015 22:00	10.3	13.6	8.3	130.0	3,404,709.1	1,914.4	1.1	0.8
02/01/2015 23:00	9.7	13.8	8.1	117.5	3,344,864.7	1,831.9	1.0	0.7
Average/Sum#:	16.5	14.2	17.3	135.2	3,003,791.8	1,587.5	1.4	0.8
Minimum:	9.7	13.5	8.1	42.8	1,621,672.4	477.6	0.0	0.0
Maximum:	61.3	17.3	70.8	287.8	3,441,399.5	2,016.9	4.0	1.3
%SI	29.2	29.2	29.2	29.2	29.2	29.2	29.2	29.2

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/02/2015 00:00	9.8	13.8	8.1	119.5	3,374,444.3	1,848.1	1.1	0.7
02/02/2015 01:00	11.1	13.5	8.9	139.1	3,401,479.0	1,987.1	1.2	1.0
02/02/2015 02:00	10.8	13.5	8.6	132.8	3,399,332.7	1,936.2	1.2	1.0
02/02/2015 03:00	9.9	13.7	8.1	121.7	3,381,382.7	1,851.9	1.1	0.7
02/02/2015 04:00	9.9	13.7	8.1	118.7	3,361,845.6	1,841.2	1.1	0.7
02/02/2015 05:00	10.0	13.7	8.2	121.2	3,405,302.0	1,865.0	1.1	0.7
02/02/2015 06:00	10.5	13.6	8.5	134.7	3,402,759.6	1,963.0	1.2	1.0
02/02/2015 07:00	10.7	13.5	8.5	136.0	3,368,441.6	1,967.8	1.2	1.0
02/02/2015 08:00	9.9	13.7	8.1	120.1	3,367,140.7	1,844.1	1.1	0.7
02/02/2015 09:00	9.7	13.8	8.1	118.2	3,354,907.2	1,837.4	1.0	0.7
02/02/2015 10:00	9.6	13.8	8.0	117.6	3,363,123.7	1,841.9	1.0	0.7
02/02/2015 11:00	9.7	13.8	8.1	119.6	3,397,268.0	1,860.6	1.0	0.7
02/02/2015 12:00	10.5	13.6	8.5	129.2	3,390,303.5	1,906.3	1.1	0.8
02/02/2015 13:00	10.1	13.7	8.3	124.5	3,393,830.0	1,883.5	1.1	0.8
02/02/2015 14:00	9.6	13.8	8.0	119.8	3,394,164.0	1,858.9	1.1	0.7
02/02/2015 15:00	9.4	13.8	7.8	116.8	3,392,155.5	1,857.8	1.0	0.7
02/02/2015 16:00	10.2	13.6	8.2	124.9	3,402,752.8	1,913.3	1.1	0.8
02/02/2015 17:00	10.3	13.6	8.3	125.3	3,404,599.7	1,939.2	1.1	0.8
02/02/2015 18:00	10.8	13.5	8.6	132.9	3,375,884.7	1,996.8	1.2	1.0
02/02/2015 19:00	10.8	13.5	8.6	131.7	3,367,431.5	1,991.8	1.2	1.0
02/02/2015 20:00	10.9	13.5	8.7	132.5	3,378,082.5	1,998.1	1.2	1.0
02/02/2015 21:00	10.5	13.5	8.4	127.8	3,387,505.2	1,954.2	1.1	0.8
02/02/2015 22:00	10.1	13.6	8.2	123.3	3,383,367.5	1,902.4	1.1	0.8
02/02/2015 23:00	9.7	13.8	8.1	117.5	3,328,431.6	1,822.9	1.0	0.7
Average/Sum#:	10.2	13.7	8.3	125.2	3,382,330.7	1,902.9	1.1	0.8
Minimum:	9.4	13.5	7.8	116.8	3,328,431.6	1,822.9	1.0	0.7
Maximum:	11.1	13.8	8.9	139.1	3,405,302.0	1,998.1	1.2	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/03/2015 00:00	10.0	13.9	8.4	96.1	2,598,971.8	1,328.5	1.1	0.5
02/03/2015 01:00	10.1	13.9	8.5	95.0	2,520,719.0	1,288.5	1.1	0.5
02/03/2015 02:00	10.2	13.9	8.6	95.2	2,523,849.1	1,290.1	1.1	0.5
02/03/2015 03:00	10.2	13.9	8.6	98.7	2,677,029.0	1,368.4	1.1	0.5
02/03/2015 04:00	10.1	13.8	8.4	116.5	3,236,406.3	1,701.6	1.1	0.7
02/03/2015 05:00	9.8	13.7	8.0	117.9	3,344,682.1	1,831.8	1.1	0.7
02/03/2015 06:00	9.8	13.7	8.0	120.1	3,355,810.5	1,862.4	1.1	0.7
02/03/2015 07:00	9.6	13.8	8.0	117.9	3,341,943.3	1,830.3	1.1	0.7
02/03/2015 08:00	9.6	13.8	8.0	117.3	3,348,881.7	1,834.1	1.0	0.7
02/03/2015 09:00	9.6	13.8	8.0	117.7	3,356,915.6	1,838.5	1.0	0.7
02/03/2015 10:00	9.6	13.8	8.0	112.7	3,144,423.5	1,676.2	1.1	0.7
02/03/2015 11:00	10.0	13.9	8.4	95.8	2,466,528.9	1,260.8	1.2	0.6
02/03/2015 12:00	10.3	13.9	8.7	95.7	2,541,064.8	1,298.9	1.1	0.5
02/03/2015 13:00	10.2	13.9	8.6	98.5	2,657,857.1	1,358.6	1.1	0.5
02/03/2015 14:00	10.6	13.8	8.8	118.7	3,289,897.4	1,705.7	1.1	0.7
02/03/2015 15:00	9.9	13.9	8.3	110.7	3,095,681.6	1,582.4	1.1	0.6
02/03/2015 16:00	10.2	13.8	8.5	112.5	3,093,398.4	1,649.0	1.1	0.7
02/03/2015 17:00	10.2	13.6	8.2	123.6	3,406,309.8	1,915.3	1.1	0.8
02/03/2015 18:00	11.1	13.4	8.7	137.6	3,364,989.2	2,039.5	1.2	1.0
02/03/2015 19:00	11.0	13.5	8.8	132.9	3,381,632.9	2,000.2	1.2	1.0
02/03/2015 20:00	11.0	13.5	8.8	131.7	3,387,442.4	1,978.9	1.2	1.0
02/03/2015 21:00	10.6	13.5	8.5	127.0	3,377,386.8	1,923.7	1.1	0.8
02/03/2015 22:00	10.6	13.6	8.6	125.0	3,216,546.7	1,808.6	1.2	0.9
02/03/2015 23:00	10.1	13.9	8.5	96.5	2,576,082.9	1,316.8	1.1	0.5
Average/Sum#:	10.2	13.8	8.4	113.0	3,054,352.1	1,653.7	1.1	0.7
Minimum:	9.6	13.4	8.0	95.0	2,466,528.9	1,260.8	1.0	0.5
Maximum:	11.1	13.9	8.8	137.6	3,406,309.8	2,039.5	1.2	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/04/2015 00:00	10.3	13.8	8.6	118.2	3,258,458.5	1,689.4	1.1	0.7
02/04/2015 01:00	9.9	13.9	8.3	105.9	2,917,460.8	1,491.3	1.1	0.6
02/04/2015 02:00	10.1	13.9	8.5	95.0	2,515,437.0	1,285.8	1.1	0.5
02/04/2015 03:00	10.2	13.9	8.6	95.2	2,520,327.8	1,288.3	1.1	0.5
02/04/2015 04:00	10.2	13.9	8.6	99.7	2,713,221.0	1,386.9	1.1	0.6
02/04/2015 05:00	10.1	13.8	8.4	110.6	3,054,767.4	1,606.1	1.1	0.6
02/04/2015 06:00	10.3	13.6	8.3	122.5	3,413,110.1	1,894.2	1.1	0.8
02/04/2015 07:00	10.1	13.7	8.3	122.7	3,381,937.7	1,876.9	1.1	0.8
02/04/2015 08:00	10.1	13.9	8.5	98.3	2,588,994.6	1,323.4	1.1	0.5
02/04/2015 09:00	10.1	13.9	8.5	95.0	2,524,240.4	1,290.3	1.1	0.5
02/04/2015 10:00	10.1	13.9	8.5	95.1	2,527,566.1	1,292.0	1.1	0.5
02/04/2015 11:00	10.1	13.9	8.5	95.0	2,527,566.1	1,292.0	1.1	0.5
02/04/2015 12:00	10.1	13.9	8.5	95.0	2,526,588.0	1,291.5	1.1	0.5
02/04/2015 13:00	10.2	13.9	8.6	95.2	2,527,566.1	1,292.0	1.1	0.5
02/04/2015 14:00	10.1	13.9	8.5	94.9	2,528,935.6	1,292.7	1.1	0.5
02/04/2015 15:00	10.1	13.9	8.5	97.4	2,644,749.7	1,351.9	1.1	0.5
02/04/2015 16:00	10.1	13.7	8.3	122.1	3,345,359.6	1,856.6	1.1	0.7
02/04/2015 17:00	10.4	13.6	8.4	126.5	3,378,966.9	1,924.6	1.1	0.8
02/04/2015 18:00	11.1	13.4	8.7	137.1	3,362,938.9	2,013.7	1.2	1.0
02/04/2015 19:00	11.1	13.4	8.7	135.5	3,329,872.3	1,993.9	1.2	1.0
02/04/2015 20:00	11.0	13.5	8.8	133.4	3,374,946.4	1,971.6	1.2	1.0
02/04/2015 21:00	11.0	13.4	8.7	133.4	3,368,784.0	1,992.6	1.2	1.0
02/04/2015 22:00	10.7	13.5	8.5	130.8	3,355,603.3	1,960.3	1.2	1.0
02/04/2015 23:00	9.8	13.8	8.1	108.8	2,915,185.6	1,554.0	1.1	0.6
Average/Sum#:	10.3	13.8	8.5	111.0	2,941,774.3	1,592.2	1.1	0.7
Minimum:	9.8	13.4	8.1	94.9	2,515,437.0	1,285.8	1.1	0.5
Maximum:	11.1	13.9	8.8	137.1	3,413,110.1	2,013.7	1.2	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/05/2015 00:00	10.2	13.9	8.6	95.2	2,514,850.1	1,285.5	1.1	0.5
02/05/2015 01:00	10.1	13.9	8.5	95.1	2,518,567.1	1,287.4	1.1	0.5
02/05/2015 02:00	10.0	13.9	8.4	94.8	2,522,088.5	1,289.2	1.1	0.5
02/05/2015 03:00	10.2	13.9	8.6	95.1	2,522,479.7	1,289.4	1.1	0.5
02/05/2015 04:00	10.2	13.9	8.6	100.9	2,775,823.2	1,418.9	1.1	0.6
02/05/2015 05:00	10.0	13.8	8.3	110.8	3,024,145.5	1,590.0	1.1	0.6
02/05/2015 06:00	10.2	13.7	8.4	123.3	3,399,415.8	1,886.6	1.1	0.8
02/05/2015 07:00	10.4	13.6	8.4	130.7	3,374,402.1	1,922.0	1.2	1.0
02/05/2015 08:00	10.1	13.8	8.4	104.4	2,754,086.0	1,427.9	1.1	0.6
02/05/2015 09:00	10.2	13.9	8.6	95.3	2,513,676.3	1,284.9	1.1	0.5
02/05/2015 10:00	10.2	13.9	8.6	95.4	2,538,717.2	1,297.7	1.1	0.5
02/05/2015 11:00	10.1	13.9	8.5	96.2	2,584,690.7	1,321.2	1.1	0.5
02/05/2015 12:00	10.1	13.9	8.5	97.6	2,641,424.0	1,350.2	1.1	0.5
02/05/2015 13:00	10.0	13.9	8.4	112.0	3,131,677.9	1,600.8	1.1	0.6
02/05/2015 14:00	10.1	13.9	8.5	115.8	3,236,536.7	1,654.4	1.1	0.7
02/05/2015 15:00	9.7	13.9	8.2	112.0	3,155,740.7	1,613.1	1.1	0.6
02/05/2015 16:00	10.1	13.7	8.3	121.8	3,353,811.6	1,836.8	1.1	0.7
02/05/2015 17:00	10.0	13.7	8.2	122.1	3,353,648.2	1,861.2	1.1	0.7
02/05/2015 18:00	11.0	13.5	8.8	132.9	3,326,179.7	1,967.4	1.2	1.0
02/05/2015 19:00	10.8	13.5	8.6	132.0	3,373,464.3	1,946.1	1.2	1.0
02/05/2015 20:00	10.8	13.5	8.6	132.5	3,360,053.9	1,962.9	1.2	1.0
02/05/2015 21:00	10.5	13.6	8.5	129.4	3,349,196.0	1,932.1	1.2	1.0
02/05/2015 22:00	10.0	13.9	8.4	105.0	2,849,772.1	1,456.7	1.1	0.6
02/05/2015 23:00	10.1	13.9	8.5	94.9	2,509,763.6	1,282.9	1.1	0.5
Average/Sum#:	10.2	13.8	8.5	110.2	2,945,175.5	1,573.6	1.1	0.7
Minimum:	9.7	13.5	8.2	94.8	2,509,763.6	1,282.9	1.1	0.5
Maximum:	11.0	13.9	8.8	132.9	3,399,415.8	1,967.4	1.2	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/06/2015 00:00	10.0	13.9	8.4	95.0	2,536,760.9	1,296.7	1.1	0.5
02/06/2015 01:00	10.1	13.9	8.5	95.0	2,520,523.4	1,288.4	1.1	0.5
02/06/2015 02:00	10.1	13.9	8.5	94.9	2,507,024.8	1,281.5	1.1	0.5
02/06/2015 03:00	10.1	13.9	8.5	95.1	2,516,415.1	1,286.3	1.1	0.5
02/06/2015 04:00	9.9	13.9	8.3	95.0	2,639,218.2	1,329.8	1.1	0.5
02/06/2015 05:00	10.7	13.7	8.8	121.0	3,235,858.5	1,772.2	1.1	0.7
02/06/2015 06:00	10.4	13.6	8.4	125.7	3,358,074.4	1,912.7	1.1	0.8
02/06/2015 07:00	9.8	13.7	8.0	125.7	3,267,203.9	1,884.8	1.2	0.9
02/06/2015 08:00	9.5	13.7	7.8	116.8	3,354,542.0	1,837.2	1.0	0.7
02/06/2015 09:00	10.0	13.8	8.3	113.7	3,097,337.8	1,651.1	1.1	0.7
02/06/2015 10:00	9.5	13.7	7.8	117.6	3,335,187.4	1,826.6	1.1	0.7
02/06/2015 11:00	9.1	13.8	7.6	115.9	3,353,629.0	1,836.7	1.0	0.7
02/06/2015 12:00	9.5	13.9	8.0	110.0	3,105,314.4	1,610.0	1.1	0.6
02/06/2015 13:00	9.5	13.7	7.8	117.3	3,369,514.3	1,845.4	1.0	0.7
02/06/2015 14:00	9.3	13.8	7.7	116.5	3,353,263.8	1,836.5	1.0	0.7
02/06/2015 15:00	9.1	13.8	7.6	116.1	3,357,098.2	1,838.6	1.0	0.7
02/06/2015 16:00	9.6	13.7	7.9	118.9	3,357,792.6	1,863.5	1.1	0.7
02/06/2015 17:00	10.7	13.5	8.5	131.6	3,303,151.8	1,977.9	1.2	1.0
02/06/2015 18:00	10.8	13.4	8.5	136.6	3,256,813.4	2,021.5	1.3	1.0
02/06/2015 19:00	10.7	13.4	8.4	132.2	3,266,324.6	1,979.7	1.2	1.0
02/06/2015 20:00	10.6	13.4	8.3	134.3	3,267,055.3	2,004.0	1.2	1.0
02/06/2015 21:00	9.9	13.6	8.0	122.5	3,305,404.2	1,882.7	1.1	0.8
02/06/2015 22:00	9.4	13.9	7.9	94.4	2,724,360.7	1,372.7	1.0	0.5
02/06/2015 23:00	9.8	13.8	8.1	106.9	3,086,878.2	1,577.9	1.0	0.6
Average/Sum#:	9.9	13.7	8.2	114.5	3,103,114.5	1,708.9	1.1	0.7
Minimum:	9.1	13.4	7.6	94.4	2,507,024.8	1,281.5	1.0	0.5
Maximum:	10.8	13.9	8.8	136.6	3,369,514.3	2,021.5	1.3	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:40 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/07/2015 00:00	9.4	13.9	7.9	93.8	2,597,341.6	1,308.7	1.1	0.5
02/07/2015 01:00	9.9	13.9	8.3	101.4	2,822,970.6	1,443.0	1.1	0.6
02/07/2015 02:00	9.7	13.9	8.2	99.2	2,768,420.4	1,394.9	1.1	0.6
02/07/2015 03:00	9.9	13.9	8.3	94.8	2,656,683.3	1,338.6	1.1	0.5
02/07/2015 04:00	9.9	13.9	8.3	95.0	2,654,897.1	1,337.7	1.1	0.5
02/07/2015 05:00	9.8	13.9	8.3	94.6	2,633,264.2	1,326.8	1.1	0.5
02/07/2015 06:00	9.9	13.9	8.3	94.9	2,638,622.8	1,329.5	1.1	0.5
02/07/2015 07:00	9.8	13.9	8.3	93.4	2,603,494.1	1,311.8	1.1	0.5
02/07/2015 08:00	9.9	13.9	8.3	94.5	2,514,263.2	1,285.2	1.1	0.5
02/07/2015 09:00	9.8	13.9	8.3	94.4	2,549,868.2	1,303.4	1.1	0.5
02/07/2015 10:00	9.6	13.9	8.1	94.2	2,640,837.1	1,349.9	1.1	0.5
02/07/2015 11:00	9.6	13.9	8.1	94.3	2,602,493.2	1,330.3	1.1	0.5
02/07/2015 12:00	9.7	13.9	8.2	94.1	2,530,109.4	1,293.3	1.1	0.5
02/07/2015 13:00	9.7	13.9	8.2	94.2	2,578,685.7	1,299.3	1.1	0.5
02/07/2015 14:00	9.6	13.9	8.1	94.3	2,661,645.0	1,341.1	1.0	0.5
02/07/2015 15:00	9.6	13.9	8.1	94.1	2,616,592.9	1,318.4	1.1	0.5
02/07/2015 16:00	9.5	13.8	7.9	109.0	3,092,272.8	1,648.4	1.0	0.7
02/07/2015 17:00	9.8	13.6	7.9	119.1	3,334,103.8	1,874.7	1.1	0.7
02/07/2015 18:00	11.1	13.4	8.7	134.8	3,276,673.9	2,009.9	1.2	1.0
02/07/2015 19:00	10.7	13.5	8.5	126.6	3,310,069.9	1,933.7	1.1	0.8
02/07/2015 20:00	11.0	13.4	8.7	133.1	3,306,912.4	2,004.3	1.2	1.0
02/07/2015 21:00	9.4	13.8	7.8	113.2	3,181,135.8	1,719.0	1.1	0.7
02/07/2015 22:00	9.7	13.9	8.2	99.3	2,703,635.0	1,382.0	1.1	0.6
02/07/2015 23:00	9.9	13.9	8.3	94.5	2,514,458.8	1,285.3	1.1	0.5
Average/Sum#:	9.9	13.8	8.2	102.1	2,782,893.8	1,465.4	1.1	0.6
Minimum:	9.4	13.4	7.8	93.4	2,514,263.2	1,285.2	1.0	0.5
Maximum:	11.1	13.9	8.7	134.8	3,334,103.8	2,009.9	1.2	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/08/2015 00:00	9.9	13.9	8.3	94.6	2,559,258.5	1,308.2	1.1	0.5
02/08/2015 01:00	9.6	13.9	8.1	94.3	2,624,795.3	1,341.7	1.1	0.5
02/08/2015 02:00	9.6	13.9	8.1	94.2	2,615,991.8	1,337.2	1.1	0.5
02/08/2015 03:00	9.9	13.9	8.3	94.6	2,523,849.1	1,290.1	1.1	0.5
02/08/2015 04:00	9.9	13.9	8.3	94.6	2,521,697.2	1,289.0	1.1	0.5
02/08/2015 05:00	9.8	13.9	8.3	94.4	2,514,263.2	1,285.2	1.1	0.5
02/08/2015 06:00	9.7	13.9	8.2	94.3	2,595,841.7	1,326.9	1.1	0.5
02/08/2015 07:00	9.8	13.9	8.3	95.8	2,570,800.8	1,314.1	1.1	0.5
02/08/2015 08:00	9.9	13.9	8.3	94.5	2,509,568.0	1,282.8	1.1	0.5
02/08/2015 09:00	9.8	13.9	8.3	94.3	2,512,502.5	1,284.3	1.1	0.5
02/08/2015 10:00	9.7	13.9	8.2	94.0	2,510,937.4	1,283.5	1.1	0.5
02/08/2015 11:00	9.5	13.9	8.0	93.7	2,517,393.3	1,286.8	1.1	0.5
02/08/2015 12:00	9.5	13.9	8.0	93.7	2,568,648.9	1,313.0	1.1	0.5
02/08/2015 13:00	9.4	13.9	7.9	93.7	2,586,647.0	1,322.2	1.1	0.5
02/08/2015 14:00	9.6	13.9	8.1	93.7	2,572,731.6	1,296.3	1.1	0.5
02/08/2015 15:00	9.7	13.9	8.2	94.2	2,575,708.6	1,297.8	1.1	0.5
02/08/2015 16:00	10.5	13.6	8.5	119.5	3,286,258.1	1,823.8	1.1	0.7
02/08/2015 17:00	10.3	13.6	8.3	124.0	3,348,242.6	1,907.1	1.1	0.8
02/08/2015 18:00	11.1	13.4	8.7	136.6	3,297,867.4	2,022.9	1.2	1.0
02/08/2015 19:00	11.1	13.5	8.9	133.1	3,306,658.9	1,980.0	1.2	1.0
02/08/2015 20:00	11.0	13.5	8.8	134.8	3,306,912.4	2,004.3	1.2	1.0
02/08/2015 21:00	10.6	13.6	8.6	123.9	3,096,830.3	1,763.9	1.2	0.9
02/08/2015 22:00	9.8	13.9	8.3	94.6	2,643,782.9	1,332.1	1.1	0.5
02/08/2015 23:00	10.2	13.8	8.5	109.0	2,976,150.5	1,521.3	1.1	0.6
Average/Sum#:	10.0	13.8	8.3	103.5	2,755,972.4	1,467.3	1.1	0.6
Minimum:	9.4	13.4	7.9	93.7	2,509,568.0	1,282.8	1.1	0.5
Maximum:	11.1	13.9	8.9	136.6	3,348,242.6	2,022.9	1.2	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/09/2015 00:00	9.9	13.9	8.3	94.3	2,593,769.2	1,306.9	1.1	0.5
02/09/2015 01:00	9.9	13.9	8.3	94.4	2,609,845.0	1,315.0	1.1	0.5
02/09/2015 02:00	10.2	13.9	8.6	94.7	2,550,701.8	1,285.2	1.1	0.5
02/09/2015 03:00	10.2	13.9	8.6	94.6	2,514,458.8	1,285.3	1.1	0.5
02/09/2015 04:00	10.2	13.9	8.6	94.7	2,515,437.0	1,285.8	1.1	0.5
02/09/2015 05:00	10.0	13.9	8.4	94.6	2,618,379.1	1,319.3	1.1	0.5
02/09/2015 06:00	10.6	13.7	8.7	117.6	3,187,242.7	1,722.3	1.1	0.7
02/09/2015 07:00	9.7	13.8	8.1	118.1	3,361,480.4	1,841.0	1.0	0.7
02/09/2015 08:00	9.5	13.8	7.9	117.0	3,404,315.0	1,839.6	1.0	0.7
02/09/2015 09:00	9.9	13.8	8.2	104.4	2,801,726.6	1,452.6	1.1	0.6
02/09/2015 10:00	9.9	13.9	8.3	94.7	2,523,262.2	1,289.8	1.1	0.5
02/09/2015 11:00	10.0	13.9	8.4	94.8	2,520,327.8	1,288.3	1.1	0.5
02/09/2015 12:00	10.2	13.9	8.6	95.3	2,516,023.9	1,286.1	1.1	0.5
02/09/2015 13:00	10.4	13.9	8.8	95.6	2,556,060.4	1,287.9	1.1	0.5
02/09/2015 14:00	10.5	13.9	8.9	95.8	2,560,228.2	1,290.0	1.1	0.5
02/09/2015 15:00	10.5	13.9	8.9	95.8	2,553,083.4	1,286.4	1.1	0.5
02/09/2015 16:00	10.4	13.9	8.8	95.5	2,555,068.0	1,287.4	1.1	0.5
02/09/2015 17:00	10.1	13.8	8.4	120.4	3,310,442.8	1,764.7	1.1	0.7
02/09/2015 18:00	9.7	13.8	8.1	117.4	3,419,489.7	1,847.8	1.0	0.7
02/09/2015 19:00	10.0	13.8	8.3	120.6	3,372,983.6	1,847.3	1.1	0.7
02/09/2015 20:00	10.1	13.7	8.3	122.3	3,412,970.7	1,869.2	1.1	0.7
02/09/2015 21:00	9.9	13.9	8.3	109.4	3,106,691.4	1,633.4	1.0	0.7
02/09/2015 22:00	10.4	13.9	8.8	94.2	2,595,646.1	1,326.8	1.1	0.5
02/09/2015 23:00	10.5	13.9	8.9	95.9	2,579,408.6	1,318.5	1.1	0.5
Average/Sum#:	10.1	13.9	8.5	103.0	2,822,460.1	1,469.9	1.1	0.6
Minimum:	9.5	13.7	7.9	94.2	2,514,458.8	1,285.2	1.0	0.5
Maximum:	10.6	13.9	8.9	122.3	3,419,489.7	1,869.2	1.1	0.7
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/10/2015 00:00	10.5	13.9	8.9	95.9	2,529,131.2	1,292.8	1.1	0.5
02/10/2015 01:00	10.5	13.9	8.9	95.8	2,535,978.3	1,296.3	1.1	0.5
02/10/2015 02:00	10.6	13.9	8.9	96.0	2,526,979.3	1,291.7	1.1	0.5
02/10/2015 03:00	10.6	13.9	8.9	96.0	2,530,696.3	1,293.6	1.1	0.5
02/10/2015 04:00	10.5	13.9	8.9	96.0	2,538,130.3	1,297.4	1.1	0.5
02/10/2015 05:00	10.6	13.9	8.9	97.1	2,601,906.3	1,330.0	1.1	0.5
02/10/2015 06:00	10.7	13.6	8.6	128.3	3,454,236.1	1,891.8	1.1	0.8
02/10/2015 07:00	10.4	13.7	8.5	134.4	3,393,539.0	1,932.9	1.2	1.0
02/10/2015 08:00	10.2	13.9	8.6	108.3	2,941,947.9	1,525.3	1.1	0.6
02/10/2015 09:00	10.5	13.9	8.9	95.8	2,569,953.1	1,294.9	1.1	0.5
02/10/2015 10:00	10.5	13.9	8.9	95.9	2,532,652.6	1,294.6	1.1	0.5
02/10/2015 11:00	10.5	13.9	8.9	95.8	2,537,152.1	1,296.9	1.1	0.5
02/10/2015 12:00	10.5	13.9	8.9	96.0	2,574,716.3	1,297.3	1.1	0.5
02/10/2015 13:00	10.5	14.0	9.0	96.0	2,568,365.4	1,294.1	1.1	0.5
02/10/2015 14:00	10.6	14.0	9.1	96.1	2,568,762.3	1,294.3	1.1	0.5
02/10/2015 15:00	10.5	14.0	9.0	95.9	2,569,953.1	1,294.9	1.1	0.5
02/10/2015 16:00	11.0	13.6	8.9	126.0	3,335,809.7	1,851.3	1.1	0.7
02/10/2015 17:00	11.5	13.5	9.2	139.3	3,401,992.5	1,987.4	1.2	1.0
02/10/2015 18:00	11.5	13.5	9.2	145.7	3,345,520.3	2,027.7	1.3	1.0
02/10/2015 19:00	11.5	13.5	9.2	146.3	3,347,665.2	2,029.0	1.3	1.0
02/10/2015 20:00	11.6	13.5	9.2	147.0	3,365,109.9	2,015.0	1.3	1.0
02/10/2015 21:00	11.6	13.5	9.2	142.5	3,360,738.6	1,963.3	1.3	1.0
02/10/2015 22:00	11.5	13.5	9.2	143.9	3,365,276.9	2,015.1	1.3	1.0
02/10/2015 23:00	11.3	13.5	9.0	138.7	3,420,822.1	1,998.4	1.2	1.0
Average/Sum#:	10.8	13.8	9.0	114.5	2,913,209.8	1,587.8	1.2	0.7
Minimum:	10.2	13.5	8.5	95.8	2,526,979.3	1,291.7	1.1	0.5
Maximum:	11.6	14.0	9.2	147.0	3,454,236.1	2,029.0	1.3	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/11/2015 00:00	11.3	13.5	9.0	139.1	3,427,326.9	2,002.2	1.2	1.0
02/11/2015 01:00	10.3	13.7	8.4	125.6	3,405,902.6	1,890.2	1.1	0.8
02/11/2015 02:00	10.0	13.8	8.3	118.6	3,354,907.2	1,837.4	1.0	0.7
02/11/2015 03:00	10.1	13.8	8.4	118.7	3,357,098.2	1,838.6	1.0	0.7
02/11/2015 04:00	10.0	13.8	8.3	118.6	3,360,384.8	1,840.4	1.0	0.7
02/11/2015 05:00	10.1	13.8	8.4	122.3	3,405,667.1	1,865.2	1.1	0.7
02/11/2015 06:00	10.6	13.6	8.6	127.7	3,397,950.9	1,910.6	1.1	0.8
02/11/2015 07:00	9.9	13.8	8.2	124.4	3,370,975.1	1,846.2	1.1	0.7
02/11/2015 08:00	9.9	13.8	8.2	118.1	3,349,246.9	1,834.3	1.0	0.7
02/11/2015 09:00	9.9	13.8	8.2	118.0	3,355,820.1	1,837.9	1.0	0.7
02/11/2015 10:00	10.0	13.8	8.3	110.9	3,021,863.1	1,588.8	1.1	0.6
02/11/2015 11:00	10.4	13.9	8.8	102.2	2,835,882.3	1,449.6	1.1	0.6
02/11/2015 12:00	10.3	13.9	8.7	105.4	2,925,873.0	1,495.6	1.1	0.6
02/11/2015 13:00	10.4	13.9	8.8	95.2	2,564,594.5	1,292.2	1.1	0.5
02/11/2015 14:00	10.3	13.9	8.7	94.9	2,568,960.8	1,294.4	1.1	0.5
02/11/2015 15:00	10.3	13.8	8.6	110.7	2,953,201.7	1,552.7	1.1	0.6
02/11/2015 16:00	10.2	13.7	8.4	121.5	3,398,514.9	1,886.1	1.1	0.8
02/11/2015 17:00	10.6	13.6	8.6	128.2	3,394,767.9	1,933.6	1.1	0.8
02/11/2015 18:00	11.2	13.4	8.8	138.9	3,380,975.2	2,024.5	1.2	1.0
02/11/2015 19:00	11.1	13.5	8.9	134.8	3,364,388.3	1,990.0	1.2	1.0
02/11/2015 20:00	11.1	13.5	8.9	134.7	3,376,222.8	1,997.0	1.2	1.0
02/11/2015 21:00	10.7	13.5	8.5	129.9	3,397,732.6	1,960.1	1.1	0.8
02/11/2015 22:00	10.8	13.5	8.6	131.6	3,414,893.7	1,970.0	1.2	1.0
02/11/2015 23:00	9.7	13.8	8.1	119.6	3,393,433.6	1,858.5	1.0	0.7
Average/Sum#:	10.4	13.7	8.5	120.4	3,240,691.0	1,791.5	1.1	0.8
Minimum:	9.7	13.4	8.1	94.9	2,564,594.5	1,292.2	1.0	0.5
Maximum:	11.3	13.9	9.0	139.1	3,427,326.9	2,024.5	1.2	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/12/2015 00:00	10.2	13.8	8.5	103.5	2,725,347.4	1,413.0	1.1	0.6
02/12/2015 01:00	10.3	13.9	8.7	99.0	2,676,050.9	1,367.9	1.1	0.5
02/12/2015 02:00	10.3	13.9	8.7	95.5	2,546,933.7	1,301.9	1.1	0.5
02/12/2015 03:00	10.3	13.9	8.7	104.0	2,894,571.9	1,479.6	1.1	0.6
02/12/2015 04:00	10.3	13.8	8.6	111.5	3,036,888.8	1,596.7	1.1	0.6
02/12/2015 05:00	10.7	13.6	8.6	129.0	3,385,287.3	1,928.2	1.1	0.8
02/12/2015 06:00	10.6	13.6	8.6	129.7	3,401,152.2	1,912.4	1.1	0.8
02/12/2015 07:00	10.4	13.7	8.5	135.7	3,321,114.1	1,915.9	1.2	1.0
02/12/2015 08:00	10.3	13.9	8.7	112.7	2,966,325.4	1,559.6	1.1	0.6
02/12/2015 09:00	10.3	13.9	8.7	95.5	2,524,044.8	1,290.2	1.1	0.5
02/12/2015 10:00	10.2	13.9	8.6	95.2	2,524,240.4	1,290.3	1.1	0.5
02/12/2015 11:00	10.3	13.9	8.7	95.5	2,525,805.5	1,291.1	1.1	0.5
02/12/2015 12:00	10.3	13.9	8.7	95.5	2,533,043.8	1,294.8	1.1	0.5
02/12/2015 13:00	10.9	13.8	9.1	121.4	3,228,369.8	1,673.8	1.1	0.7
02/12/2015 14:00	11.5	13.5	9.2	135.9	3,326,532.2	1,991.9	1.2	1.0
02/12/2015 15:00	10.3	13.6	8.3	126.4	3,310,846.8	1,885.8	1.1	0.8
02/12/2015 16:00	10.6	13.6	8.6	126.7	3,329,954.7	1,921.0	1.1	0.8
02/12/2015 17:00	11.4	13.5	9.1	134.8	3,330,913.5	1,970.2	1.2	1.0
02/12/2015 18:00	11.4	13.4	9.0	140.0	3,319,549.9	2,036.2	1.3	1.0
02/12/2015 19:00	11.3	13.4	8.9	141.5	3,338,461.0	2,047.8	1.3	1.0
02/12/2015 20:00	11.2	13.5	8.9	138.7	3,353,604.8	2,032.6	1.2	1.0
02/12/2015 21:00	10.6	13.6	8.6	128.7	3,397,732.6	1,960.1	1.1	0.8
02/12/2015 22:00	11.0	13.5	8.8	132.7	3,376,053.8	1,996.9	1.2	1.0
02/12/2015 23:00	9.8	13.8	8.1	113.5	3,146,011.4	1,631.1	1.1	0.7
Average/Sum#:	10.6	13.7	8.7	118.4	3,063,284.9	1,699.5	1.1	0.7
Minimum:	9.8	13.4	8.1	95.2	2,524,044.8	1,290.2	1.1	0.5
Maximum:	11.5	13.9	9.2	141.5	3,401,152.2	2,047.8	1.3	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/13/2015 00:00	10.3	13.8	8.6	118.6	3,384,238.9	1,729.9	1.0	0.7
02/13/2015 01:00	10.1	13.9	8.5	105.7	2,902,592.8	1,483.7	1.1	0.6
02/13/2015 02:00	10.3	13.9	8.7	104.4	2,887,333.5	1,475.9	1.1	0.6
02/13/2015 03:00	10.4	13.8	8.6	121.6	3,419,452.7	1,747.9	1.0	0.7
02/13/2015 04:00	10.3	13.9	8.7	112.1	3,042,469.7	1,555.2	1.1	0.6
02/13/2015 05:00	10.3	13.8	8.6	111.3	3,038,772.0	1,575.5	1.1	0.6
02/13/2015 06:00	10.5	13.6	8.5	123.0	3,435,993.9	1,906.9	1.1	0.8
02/13/2015 07:00	9.7	13.8	8.1	121.4	3,386,982.9	1,879.7	1.1	0.8
02/13/2015 08:00	10.3	13.8	8.6	108.5	2,821,207.1	1,462.7	1.1	0.6
02/13/2015 09:00	10.1	13.9	8.5	95.0	2,533,043.8	1,294.8	1.1	0.5
02/13/2015 10:00	10.2	13.9	8.6	95.1	2,533,435.1	1,295.0	1.1	0.5
02/13/2015 11:00	10.2	13.9	8.6	95.2	2,546,933.7	1,301.9	1.1	0.5
02/13/2015 12:00	10.1	13.9	8.5	99.7	2,740,022.6	1,400.6	1.1	0.6
02/13/2015 13:00	10.2	13.8	8.5	114.2	3,188,444.3	1,653.1	1.1	0.7
02/13/2015 14:00	10.2	13.6	8.2	120.5	3,384,280.1	1,878.2	1.1	0.8
02/13/2015 15:00	9.0	13.7	7.4	114.7	3,380,469.7	1,851.4	1.0	0.7
02/13/2015 16:00	9.8	13.6	7.9	118.3	3,379,775.4	1,875.7	1.0	0.8
02/13/2015 17:00	10.2	13.6	8.2	126.2	3,352,316.2	1,933.9	1.1	0.8
02/13/2015 18:00	11.1	13.5	8.9	135.0	3,351,582.7	2,006.9	1.2	1.0
02/13/2015 19:00	11.1	13.4	8.7	137.6	3,329,331.5	2,042.2	1.2	1.0
02/13/2015 20:00	11.3	13.5	9.0	138.2	3,339,415.6	2,024.0	1.2	1.0
02/13/2015 21:00	11.4	13.5	9.1	136.2	3,379,942.3	1,999.2	1.2	1.0
02/13/2015 22:00	11.3	13.5	9.0	135.9	3,370,454.0	2,018.2	1.2	1.0
02/13/2015 23:00	10.3	13.6	8.3	124.1	3,383,367.5	1,902.4	1.1	0.8
Average/Sum#:	10.4	13.7	8.5	117.2	3,146,327.4	1,720.6	1.1	0.7
Minimum:	9.0	13.4	7.4	95.0	2,533,043.8	1,294.8	1.0	0.5
Maximum:	11.4	13.9	9.1	138.2	3,435,993.9	2,042.2	1.2	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/14/2015 00:00	11.0	13.5	8.8	132.1	3,394,803.0	1,983.2	1.2	1.0
02/14/2015 01:00	10.6	13.5	8.5	128.1	3,393,572.3	1,957.7	1.1	0.8
02/14/2015 02:00	10.9	13.5	8.7	130.1	3,378,541.1	1,973.7	1.1	0.8
02/14/2015 03:00	10.9	13.5	8.7	130.6	3,378,712.3	1,973.8	1.2	1.0
02/14/2015 04:00	10.6	13.5	8.5	128.8	3,403,799.6	1,963.6	1.1	0.8
02/14/2015 05:00	9.6	13.8	8.0	117.5	3,365,132.2	1,843.0	1.0	0.7
02/14/2015 06:00	10.1	13.8	8.4	106.4	2,881,384.6	1,493.9	1.1	0.6
02/14/2015 07:00	10.2	13.9	8.6	101.0	2,559,649.8	1,308.4	1.2	0.7
02/14/2015 08:00	10.2	13.9	8.6	95.5	2,538,912.8	1,297.8	1.1	0.5
02/14/2015 09:00	10.0	13.9	8.4	95.2	2,560,823.6	1,309.0	1.1	0.5
02/14/2015 10:00	10.2	13.9	8.6	95.3	2,548,890.0	1,302.9	1.1	0.5
02/14/2015 11:00	10.1	13.9	8.5	95.1	2,577,494.9	1,298.7	1.1	0.5
02/14/2015 12:00	10.2	13.9	8.6	95.2	2,578,288.7	1,299.1	1.1	0.5
02/14/2015 13:00	10.2	14.0	8.7	95.3	2,576,105.6	1,298.0	1.1	0.5
02/14/2015 14:00	10.3	14.0	8.8	95.3	2,571,937.8	1,295.9	1.1	0.5
02/14/2015 15:00	10.3	14.0	8.8	95.3	2,567,770.0	1,293.8	1.1	0.5
02/14/2015 16:00	10.9	13.8	9.1	113.5	2,885,969.4	1,559.5	1.2	0.8
02/14/2015 17:00	10.8	13.6	8.7	125.9	3,322,083.1	1,892.2	1.1	0.8
02/14/2015 18:00	10.3	13.6	8.3	124.7	3,323,838.8	1,893.2	1.1	0.8
02/14/2015 19:00	11.6	13.4	9.1	146.5	3,323,951.6	2,038.9	1.3	1.0
02/14/2015 20:00	10.8	13.5	8.6	130.3	3,356,823.2	1,936.5	1.2	1.0
02/14/2015 21:00	10.7	13.6	8.6	126.6	3,376,157.8	1,923.0	1.1	0.8
02/14/2015 22:00	11.1	13.5	8.9	135.4	3,339,535.8	1,975.3	1.2	1.0
02/14/2015 23:00	10.3	13.9	8.7	105.2	2,793,430.1	1,427.9	1.1	0.6
Average/Sum#:	10.5	13.7	8.6	114.4	2,999,900.3	1,647.5	1.1	0.7
Minimum:	9.6	13.4	8.0	95.1	2,538,912.8	1,293.8	1.0	0.5
Maximum:	11.6	14.0	9.1	146.5	3,403,799.6	2,038.9	1.3	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/15/2015 00:00	10.2	13.9	8.6	99.4	2,761,871.0	1,391.6	1.1	0.6
02/15/2015 01:00	10.2	13.9	8.6	105.6	2,849,772.1	1,456.7	1.1	0.6
02/15/2015 02:00	38.1	16.8	54.8	280.1	1,192,920.8	392.0	7.0	1.1
02/15/2015 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2015 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2015 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2015 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2015 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2015 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2015 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2015 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2015 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2015 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2015 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2015 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2015 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2015 16:00	32.8	17.7	60.5	0.1	1,890,783.8	386.6	0.0	0.0
02/15/2015 17:00	39.5	14.8	38.2	162.0	2,401,742.1	1,052.3	1.9	0.7
02/15/2015 18:00	10.3	14.0	8.8	105.3	2,866,066.3	1,444.1	1.1	0.6
02/15/2015 19:00	11.8	13.5	9.4	137.6	3,351,969.5	1,933.7	1.2	1.0
02/15/2015 20:00	11.6	13.5	9.2	140.9	3,319,685.1	1,987.8	1.3	1.0
02/15/2015 21:00	11.3	13.5	9.0	137.6	3,376,829.4	1,972.7	1.2	1.0
02/15/2015 22:00	11.3	13.5	9.0	137.0	3,375,288.8	1,971.8	1.2	1.0
02/15/2015 23:00	11.4	13.5	9.1	137.8	3,373,919.3	1,971.0	1.2	1.0
Average/Sum#:	18.0	14.4	20.5	131.2	2,796,440.7	1,450.9	1.7	0.8
Minimum:	10.2	13.5	8.6	0.1	1,192,920.8	386.6	0.0	0.0
Maximum:	39.5	17.7	60.5	280.1	3,376,829.4	1,987.8	7.0	1.1
%SI	54.2	54.2	54.2	54.2	54.2	54.2	54.2	54.2

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/16/2015 00:00	11.2	13.5	8.9	135.4	3,391,208.3	1,981.1	1.2	1.0
02/16/2015 01:00	10.3	13.7	8.4	125.6	3,397,595.3	1,910.4	1.1	0.8
02/16/2015 02:00	9.8	13.8	8.1	117.6	3,377,183.1	1,849.6	1.0	0.7
02/16/2015 03:00	9.7	13.8	8.1	117.5	3,380,469.7	1,851.4	1.0	0.7
02/16/2015 04:00	9.8	13.8	8.1	117.6	3,382,478.2	1,852.5	1.0	0.7
02/16/2015 05:00	10.2	13.7	8.4	123.7	3,392,748.9	1,882.9	1.1	0.8
02/16/2015 06:00	10.2	13.7	8.4	125.3	3,425,543.0	1,901.1	1.1	0.8
02/16/2015 07:00	9.8	13.8	8.1	118.7	3,349,246.9	1,834.3	1.1	0.7
02/16/2015 08:00	9.7	13.8	8.1	117.8	3,398,763.3	1,836.6	1.0	0.7
02/16/2015 09:00	9.5	13.8	7.9	116.9	3,417,454.1	1,846.7	1.0	0.7
02/16/2015 10:00	9.5	13.8	7.9	116.9	3,439,660.9	1,858.7	1.0	0.7
02/16/2015 11:00	9.5	13.8	7.9	116.9	3,391,607.7	1,857.5	1.0	0.7
02/16/2015 12:00	9.6	13.8	8.0	117.0	3,385,217.1	1,854.0	1.0	0.7
02/16/2015 13:00	10.4	13.8	8.6	114.5	2,923,064.5	1,558.2	1.2	0.8
02/16/2015 14:00	10.4	14.0	8.9	95.3	2,552,091.0	1,285.9	1.1	0.5
02/16/2015 15:00	10.5	13.8	8.7	110.1	2,937,795.7	1,544.6	1.1	0.6
02/16/2015 16:00	11.0	13.6	8.9	126.5	3,321,907.5	1,892.1	1.1	0.8
02/16/2015 17:00	11.1	13.6	9.0	135.2	3,326,160.7	1,943.1	1.2	1.0
02/16/2015 18:00	11.5	13.5	9.2	147.4	3,311,561.6	2,031.3	1.3	1.0
02/16/2015 19:00	11.5	13.5	9.2	144.9	3,334,630.9	2,021.1	1.3	1.0
02/16/2015 20:00	9.6	13.7	7.9	120.0	3,386,495.2	1,854.7	1.1	0.7
02/16/2015 21:00	10.1	13.7	8.3	124.6	3,394,731.0	1,884.0	1.1	0.8
02/16/2015 22:00	10.4	13.6	8.4	127.1	3,362,639.1	1,915.3	1.1	0.8
02/16/2015 23:00	9.5	13.8	7.9	116.9	3,431,148.3	1,854.1	1.0	0.7
Average/Sum#:	10.2	13.7	8.4	122.1	3,308,808.4	1,837.6	1.1	0.8
Minimum:	9.5	13.5	7.9	95.3	2,552,091.0	1,285.9	1.0	0.5
Maximum:	11.5	14.0	9.2	147.4	3,439,660.9	2,031.3	1.3	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/17/2015 00:00	9.7	13.8	8.1	117.5	3,382,113.0	1,852.3	1.0	0.7
02/17/2015 01:00	9.7	13.8	8.1	117.7	3,378,461.3	1,850.3	1.0	0.7
02/17/2015 02:00	9.7	13.8	8.1	117.3	3,381,017.5	1,851.7	1.0	0.7
02/17/2015 03:00	9.6	13.8	8.0	117.1	3,435,219.6	1,856.3	1.0	0.7
02/17/2015 04:00	9.5	13.8	7.9	117.2	3,442,621.9	1,860.3	1.0	0.7
02/17/2015 05:00	9.8	13.8	8.1	118.3	3,388,138.5	1,855.6	1.0	0.7
02/17/2015 06:00	9.8	13.7	8.0	120.7	3,423,378.4	1,874.9	1.1	0.7
02/17/2015 07:00	9.8	13.7	8.0	126.1	3,321,114.1	1,915.9	1.1	0.8
02/17/2015 08:00	9.5	13.8	7.9	117.4	3,363,306.3	1,842.0	1.0	0.7
02/17/2015 09:00	9.8	13.8	8.1	107.2	2,945,403.6	1,548.6	1.1	0.6
02/17/2015 10:00	10.2	13.9	8.6	100.7	2,759,781.4	1,410.7	1.1	0.6
02/17/2015 11:00	10.0	13.9	8.4	109.7	3,092,355.9	1,580.7	1.0	0.6
02/17/2015 12:00	9.9	13.9	8.3	108.2	3,047,360.5	1,557.7	1.1	0.6
02/17/2015 13:00	9.8	13.9	8.3	95.9	2,567,279.5	1,312.3	1.1	0.5
02/17/2015 14:00	9.9	13.9	8.3	94.5	2,521,110.3	1,288.7	1.1	0.5
02/17/2015 15:00	10.0	13.9	8.4	94.8	2,580,670.3	1,300.3	1.1	0.5
02/17/2015 16:00	10.4	13.7	8.5	111.6	3,012,170.9	1,605.7	1.1	0.6
02/17/2015 17:00	10.0	13.6	8.1	122.6	3,337,884.2	1,901.2	1.1	0.8
02/17/2015 18:00	10.9	13.4	8.6	134.9	3,324,401.4	2,014.9	1.2	1.0
02/17/2015 19:00	10.8	13.5	8.6	134.0	3,316,646.9	2,010.2	1.2	1.0
02/17/2015 20:00	10.7	13.5	8.5	129.6	3,363,135.1	1,964.7	1.2	1.0
02/17/2015 21:00	9.9	13.6	8.0	121.8	3,377,142.8	1,898.9	1.1	0.8
02/17/2015 22:00	10.4	13.5	8.3	125.1	3,213,407.0	1,830.3	1.2	0.9
02/17/2015 23:00	9.9	13.9	8.3	95.2	2,559,062.9	1,308.1	1.1	0.5
Average/Sum#:	10.0	13.7	8.2	114.8	3,147,216.0	1,720.5	1.1	0.7
Minimum:	9.5	13.4	7.9	94.5	2,521,110.3	1,288.7	1.0	0.5
Maximum:	10.9	13.9	8.6	134.9	3,442,621.9	2,014.9	1.2	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/18/2015 00:00	10.1	13.8	8.4	104.7	2,916,873.9	1,491.0	1.1	0.6
02/18/2015 01:00	10.1	13.8	8.4	105.7	2,970,477.1	1,518.4	1.1	0.6
02/18/2015 02:00	9.9	13.9	8.3	96.3	2,617,752.5	1,338.1	1.1	0.5
02/18/2015 03:00	10.0	13.9	8.4	94.8	2,557,693.5	1,307.4	1.1	0.5
02/18/2015 04:00	10.2	13.7	8.4	115.2	3,223,663.0	1,694.9	1.1	0.7
02/18/2015 05:00	9.9	13.7	8.1	120.6	3,391,127.2	1,882.0	1.1	0.8
02/18/2015 06:00	9.9	13.7	8.1	120.7	3,377,793.4	1,874.6	1.1	0.7
02/18/2015 07:00	10.3	13.6	8.3	129.8	3,419,171.8	1,947.5	1.1	0.8
02/18/2015 08:00	10.2	13.6	8.2	128.0	3,467,803.9	1,975.2	1.1	0.8
02/18/2015 09:00	10.6	13.5	8.5	129.3	3,448,349.3	1,989.3	1.1	0.8
02/18/2015 10:00	10.4	13.5	8.3	127.5	3,405,359.7	1,964.5	1.1	0.8
02/18/2015 11:00	9.4	13.7	7.7	117.1	3,367,688.4	1,844.4	1.0	0.7
02/18/2015 12:00	9.4	13.8	7.8	116.9	3,379,374.2	1,850.8	1.0	0.7
02/18/2015 13:00	9.3	13.8	7.7	116.2	3,383,026.0	1,852.8	1.0	0.7
02/18/2015 14:00	9.8	13.8	8.1	108.1	2,977,737.2	1,565.6	1.1	0.6
02/18/2015 15:00	9.9	13.8	8.2	113.9	3,244,557.6	1,658.5	1.0	0.7
02/18/2015 16:00	10.4	13.6	8.4	124.6	3,326,439.9	1,846.1	1.1	0.7
02/18/2015 17:00	10.7	13.5	8.5	130.0	3,375,715.6	1,996.7	1.2	1.0
02/18/2015 18:00	10.7	13.4	8.4	134.1	3,343,540.4	2,026.5	1.2	1.0
02/18/2015 19:00	10.7	13.5	8.5	131.0	3,369,967.4	1,993.3	1.2	1.0
02/18/2015 20:00	10.7	13.5	8.5	130.3	3,357,963.8	1,986.2	1.2	1.0
02/18/2015 21:00	10.5	13.5	8.4	129.2	3,379,739.4	1,974.4	1.1	0.8
02/18/2015 22:00	10.2	13.6	8.2	124.9	3,403,546.3	1,938.6	1.1	0.8
02/18/2015 23:00	9.6	13.7	7.9	118.7	3,360,675.6	1,865.1	1.1	0.7
Average/Sum#:	10.1	13.7	8.2	119.5	3,252,751.5	1,807.6	1.1	0.8
Minimum:	9.3	13.4	7.7	94.8	2,557,693.5	1,307.4	1.0	0.5
Maximum:	10.7	13.9	8.5	134.1	3,467,803.9	2,026.5	1.2	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/19/2015 00:00	10.3	13.5	8.2	127.1	3,400,159.4	1,961.5	1.1	0.8
02/19/2015 01:00	9.4	13.7	7.7	116.7	3,351,985.7	1,835.8	1.0	0.7
02/19/2015 02:00	9.7	13.9	8.2	101.6	2,754,857.5	1,428.3	1.1	0.6
02/19/2015 03:00	9.9	13.9	8.3	95.1	2,565,323.1	1,311.3	1.1	0.5
02/19/2015 04:00	10.0	13.8	8.3	101.7	2,768,358.9	1,435.3	1.1	0.6
02/19/2015 05:00	10.2	13.6	8.2	123.9	3,421,248.9	1,923.7	1.1	0.8
02/19/2015 06:00	10.1	13.6	8.2	125.1	3,407,233.2	1,940.7	1.1	0.8
02/19/2015 07:00	10.3	13.5	8.2	131.5	3,346,298.4	1,979.3	1.2	1.0
02/19/2015 08:00	10.5	13.5	8.4	129.4	3,398,226.6	1,985.2	1.1	0.8
02/19/2015 09:00	9.9	13.6	8.0	124.3	3,414,958.2	1,945.1	1.1	0.8
02/19/2015 10:00	10.5	13.5	8.4	132.0	3,376,466.1	2,021.8	1.2	1.0
02/19/2015 11:00	10.4	13.5	8.3	129.2	3,404,046.7	1,988.6	1.1	0.8
02/19/2015 12:00	10.3	13.5	8.2	125.7	3,366,877.2	1,942.3	1.1	0.8
02/19/2015 13:00	10.6	13.5	8.5	126.6	3,381,091.5	1,950.5	1.1	0.8
02/19/2015 14:00	8.9	13.8	7.4	115.0	3,382,478.2	1,852.5	1.0	0.7
02/19/2015 15:00	8.8	13.8	7.3	114.3	3,387,955.9	1,855.5	1.0	0.7
02/19/2015 16:00	9.4	13.7	7.7	117.3	3,369,504.7	1,870.0	1.0	0.7
02/19/2015 17:00	9.2	13.8	7.6	116.4	3,381,382.7	1,851.9	1.0	0.7
02/19/2015 18:00	10.5	13.5	8.4	126.1	3,361,503.5	1,939.2	1.1	0.8
02/19/2015 19:00	9.4	13.7	7.7	117.3	3,334,368.2	1,850.5	1.1	0.7
02/19/2015 20:00	9.2	13.8	7.6	116.0	3,365,314.8	1,843.1	1.0	0.7
02/19/2015 21:00	9.3	13.8	7.7	116.3	3,379,009.0	1,850.6	1.0	0.7
02/19/2015 22:00	9.7	13.7	7.9	119.4	3,390,947.0	1,881.9	1.1	0.8
02/19/2015 23:00	10.3	13.6	8.3	123.4	3,189,354.3	1,816.6	1.2	0.9
Average/Sum#:	9.9	13.7	8.0	119.6	3,287,456.2	1,844.2	1.1	0.8
Minimum:	8.8	13.5	7.3	95.1	2,565,323.1	1,311.3	1.0	0.5
Maximum:	10.6	13.9	8.5	132.0	3,421,248.9	2,021.8	1.2	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/20/2015 00:00	9.5	13.9	8.0	94.8	2,631,838.0	1,345.3	1.1	0.5
02/20/2015 01:00	28.7	16.3	36.8	223.9	1,564,430.4	571.2	4.2	0.9
02/20/2015 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2015 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2015 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2015 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2015 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2015 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2015 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2015 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2015 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2015 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2015 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2015 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2015 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2015 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2015 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2015 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2015 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2015 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2015 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2015 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2015 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2015 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	19.1	15.1	22.4	159.4	2,098,134.2	958.3	2.7	0.7
Minimum:	9.5	13.9	8.0	94.8	1,564,430.4	571.2	1.1	0.5
Maximum:	28.7	16.3	36.8	223.9	2,631,838.0	1,345.3	4.2	0.9
%SI	91.7	91.7	91.7	91.7	91.7	91.7	91.7	91.7

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/21/2015 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2015 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2015 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2015 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2015 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2015 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2015 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2015 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2015 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2015 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2015 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2015 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2015 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2015 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2015 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2015 15:00	36.4	17.1	56.5	15.1	1,993,490.6	509.5	0.0	0.0
02/21/2015 16:00	44.9	14.7	42.7	236.0	2,339,470.7	1,042.1	2.8	1.1
02/21/2015 17:00	10.1	13.8	8.4	108.1	2,904,915.6	1,506.1	1.1	0.6
02/21/2015 18:00	10.9	13.5	8.7	130.0	3,335,985.4	1,973.2	1.2	1.0
02/21/2015 19:00	10.8	13.5	8.6	134.5	3,337,435.7	2,022.8	1.2	1.0
02/21/2015 20:00	10.7	13.5	8.5	133.9	3,372,124.0	2,019.2	1.2	1.0
02/21/2015 21:00	10.7	13.5	8.5	130.0	3,396,343.7	1,984.1	1.1	0.8
02/21/2015 22:00	11.0	13.5	8.8	138.0	3,435,226.4	2,031.9	1.2	1.0
02/21/2015 23:00	10.8	13.6	8.7	134.3	3,412,324.7	1,943.6	1.2	1.0
Average/Sum#:	17.4	14.1	17.7	128.9	3,058,590.8	1,670.3	1.2	0.8
Minimum:	10.1	13.5	8.4	15.1	1,993,490.6	509.5	0.0	0.0
Maximum:	44.9	17.1	56.5	236.0	3,435,226.4	2,031.9	2.8	1.1
%SI	62.5	62.5	62.5	62.5	62.5	62.5	62.5	62.5

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/22/2015 00:00	10.4	14.0	8.9	102.1	2,780,923.8	1,401.2	1.1	0.6
02/22/2015 01:00	10.5	13.9	8.9	115.7	3,030,340.5	1,549.0	1.1	0.6
02/22/2015 02:00	10.4	14.0	8.9	95.7	2,566,182.2	1,293.0	1.1	0.5
02/22/2015 03:00	10.5	14.0	9.0	97.7	2,664,622.0	1,342.6	1.1	0.5
02/22/2015 04:00	10.6	13.9	8.9	111.7	3,145,508.3	1,584.9	1.0	0.6
02/22/2015 05:00	10.4	13.9	8.8	107.0	2,978,001.9	1,500.5	1.1	0.6
02/22/2015 06:00	37.2	16.9	54.9	258.6	1,255,824.4	403.5	6.0	0.9
02/22/2015 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2015 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2015 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2015 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2015 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2015 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2015 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2015 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2015 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2015 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2015 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2015 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2015 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2015 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2015 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2015 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2015 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	14.3	14.4	15.5	126.9	2,631,629.0	1,296.4	1.8	0.6
Minimum:	10.4	13.9	8.8	95.7	1,255,824.4	403.5	1.0	0.5
Maximum:	37.2	16.9	54.9	258.6	3,145,508.3	1,584.9	6.0	0.9
%SI	70.8	70.8	70.8	70.8	70.8	70.8	70.8	70.8

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/23/2015 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2015 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2015 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2015 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2015 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2015 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2015 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2015 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2015 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2015 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2015 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2015 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2015 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2015 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2015 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2015 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2015 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2015 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2015 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2015 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2015 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2015 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2015 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2015 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/24/2015 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2015 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2015 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2015 03:00	39.9	17.6	71.3	0.0	2,022,330.6	457.8	0.0	0.0
02/24/2015 04:00	67.6	15.9	79.8	225.6	1,928,471.8	718.2	3.0	0.9
02/24/2015 05:00	27.8	13.9	23.4	187.0	3,069,222.4	1,613.7	1.8	1.1
02/24/2015 06:00	11.5	13.6	9.3	149.6	3,453,003.6	2,017.2	1.3	1.0
02/24/2015 07:00	11.4	13.6	9.2	145.7	3,487,698.6	2,012.0	1.2	1.0
02/24/2015 08:00	10.7	13.7	8.8	138.3	3,486,518.9	1,960.4	1.2	1.0
02/24/2015 09:00	10.7	13.9	9.0	117.0	2,964,423.4	1,558.6	1.2	0.8
02/24/2015 10:00	10.7	14.0	9.1	97.1	2,631,279.5	1,325.8	1.1	0.5
02/24/2015 11:00	10.9	14.0	9.3	96.1	2,567,174.6	1,293.5	1.1	0.5
02/24/2015 12:00	10.8	14.0	9.2	96.0	2,564,197.5	1,292.0	1.1	0.5
02/24/2015 13:00	10.8	14.0	9.2	95.9	2,558,442.0	1,289.1	1.1	0.5
02/24/2015 14:00	10.8	14.0	9.2	96.5	2,600,120.1	1,310.1	1.1	0.5
02/24/2015 15:00	10.5	14.0	9.0	99.2	2,707,292.5	1,364.1	1.1	0.5
02/24/2015 16:00	10.8	13.9	9.1	113.9	2,850,138.6	1,477.7	1.2	0.7
02/24/2015 17:00	11.5	13.6	9.3	142.6	3,370,495.8	1,969.0	1.3	1.0
02/24/2015 18:00	11.4	13.5	9.1	149.9	3,365,443.9	2,015.2	1.3	1.0
02/24/2015 19:00	11.3	13.5	9.0	145.4	3,402,089.7	2,012.3	1.3	1.0
02/24/2015 20:00	11.3	13.5	9.0	145.1	3,413,248.0	2,018.9	1.3	1.0
02/24/2015 21:00	11.2	13.5	8.9	142.4	3,465,841.9	2,024.7	1.2	1.0
02/24/2015 22:00	10.7	13.7	8.8	128.6	3,279,951.6	1,820.3	1.2	0.9
02/24/2015 23:00	10.2	13.9	8.6	108.2	2,956,765.9	1,489.8	1.1	0.6
Average/Sum#:	15.8	14.1	16.1	124.8	2,959,245.3	1,573.4	1.2	0.8
Minimum:	10.2	13.5	8.6	0.0	1,928,471.8	457.8	0.0	0.0
Maximum:	67.6	17.6	79.8	225.6	3,487,698.6	2,024.7	3.0	1.1
%SI	12.5	12.5	12.5	12.5	12.5	12.5	12.5	12.5

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/25/2015 00:00	10.7	13.9	9.0	96.3	2,545,564.3	1,301.2	1.1	0.5
02/25/2015 01:00	10.1	13.9	8.5	121.9	3,482,505.7	1,754.7	1.0	0.7
02/25/2015 02:00	10.1	13.8	8.4	121.6	3,395,389.9	1,735.6	1.1	0.7
02/25/2015 03:00	10.3	13.9	8.7	103.2	2,821,992.4	1,442.5	1.1	0.6
02/25/2015 04:00	10.6	13.9	8.9	96.0	2,518,958.3	1,287.6	1.1	0.5
02/25/2015 05:00	10.8	13.7	8.9	119.9	3,062,445.6	1,632.5	1.2	0.8
02/25/2015 06:00	10.8	13.5	8.6	135.7	3,496,245.8	1,991.4	1.2	1.0
02/25/2015 07:00	10.2	13.6	8.2	134.6	3,461,659.0	1,971.7	1.2	1.0
02/25/2015 08:00	10.0	13.8	8.3	118.5	3,253,602.3	1,734.4	1.1	0.7
02/25/2015 09:00	10.4	13.9	8.8	97.0	2,557,302.2	1,307.2	1.1	0.5
02/25/2015 10:00	10.6	13.9	8.9	96.2	2,563,205.2	1,291.5	1.1	0.5
02/25/2015 11:00	10.6	13.9	8.9	96.0	2,564,396.0	1,292.1	1.1	0.5
02/25/2015 12:00	10.4	13.9	8.8	95.7	2,566,777.6	1,293.3	1.1	0.5
02/25/2015 13:00	10.3	13.9	8.7	100.6	2,799,778.2	1,410.7	1.1	0.6
02/25/2015 14:00	10.4	14.0	8.9	96.6	2,579,281.1	1,299.6	1.1	0.5
02/25/2015 15:00	10.5	14.0	9.0	95.9	2,565,785.3	1,292.8	1.1	0.5
02/25/2015 16:00	10.8	13.9	9.1	111.9	2,829,115.1	1,466.8	1.2	0.7
02/25/2015 17:00	11.5	13.5	9.2	135.2	3,348,413.8	1,956.1	1.2	1.0
02/25/2015 18:00	11.6	13.5	9.2	144.7	3,348,496.2	1,980.6	1.3	1.0
02/25/2015 19:00	11.5	13.6	9.3	137.6	3,365,448.2	1,916.9	1.2	1.0
02/25/2015 20:00	11.0	13.6	8.9	132.4	3,424,628.0	1,925.6	1.2	1.0
02/25/2015 21:00	11.0	13.5	8.8	132.8	3,424,947.7	1,975.8	1.2	1.0
02/25/2015 22:00	10.7	13.6	8.6	124.6	3,225,535.0	1,790.1	1.2	0.9
02/25/2015 23:00	10.2	13.9	8.6	103.0	2,859,120.0	1,440.6	1.1	0.6
Average/Sum#:	10.6	13.8	8.8	114.5	3,002,524.7	1,603.8	1.1	0.7
Minimum:	10.0	13.5	8.2	95.7	2,518,958.3	1,287.6	1.0	0.5
Maximum:	11.6	14.0	9.3	144.7	3,496,245.8	1,991.4	1.3	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/26/2015 00:00	10.4	13.9	8.8	95.7	2,557,648.1	1,288.7	1.1	0.5
02/26/2015 01:00	10.4	13.9	8.8	95.9	2,587,418.2	1,303.7	1.1	0.5
02/26/2015 02:00	10.7	13.8	8.9	125.0	3,384,407.0	1,754.7	1.1	0.7
02/26/2015 03:00	10.3	13.8	8.6	124.5	3,503,990.5	1,816.7	1.0	0.7
02/26/2015 04:00	10.2	13.8	8.5	119.5	3,349,193.6	1,760.9	1.1	0.7
02/26/2015 05:00	10.8	13.6	8.7	129.2	3,460,019.7	1,945.5	1.1	0.8
02/26/2015 06:00	11.1	13.6	9.0	134.1	3,482,250.6	1,958.0	1.1	0.8
02/26/2015 07:00	10.9	13.6	8.8	132.1	3,414,200.3	1,969.6	1.2	1.0
02/26/2015 08:00	10.5	13.8	8.7	114.7	3,010,327.9	1,626.7	1.1	0.7
02/26/2015 09:00	10.6	13.9	8.9	96.7	2,728,528.5	1,374.8	1.0	0.5
02/26/2015 10:00	10.1	13.9	8.5	115.4	3,329,289.0	1,677.5	1.0	0.7
02/26/2015 11:00	10.6	13.9	8.9	116.6	3,325,549.3	1,699.9	1.0	0.7
02/26/2015 12:00	10.3	14.0	8.8	93.9	2,646,211.2	1,314.0	1.0	0.5
02/26/2015 13:00	10.7	14.0	9.1	93.4	2,559,831.3	1,289.8	1.1	0.5
02/26/2015 14:00	10.7	14.0	9.1	93.5	2,562,014.4	1,290.9	1.1	0.5
02/26/2015 15:00	10.4	13.9	8.8	101.4	2,931,957.5	1,477.3	1.0	0.6
02/26/2015 16:00	11.6	13.6	9.4	126.6	3,183,289.2	1,789.9	1.2	0.9
02/26/2015 17:00	11.8	13.5	9.4	137.2	3,348,242.6	1,956.0	1.2	1.0
02/26/2015 18:00	12.0	13.5	9.6	148.4	3,313,681.0	2,032.6	1.3	1.0
02/26/2015 19:00	11.8	13.5	9.4	146.9	3,309,116.2	2,029.8	1.3	1.0
02/26/2015 20:00	11.6	13.5	9.2	140.8	3,336,051.4	1,997.6	1.3	1.0
02/26/2015 21:00	11.4	13.5	9.1	135.6	3,350,694.1	1,981.9	1.2	1.0
02/26/2015 22:00	10.8	13.8	9.0	115.1	2,956,831.1	1,576.2	1.2	0.8
02/26/2015 23:00	10.6	14.0	9.1	95.9	2,553,877.2	1,286.8	1.1	0.5
Average/Sum#:	10.8	13.8	9.0	117.8	3,091,025.8	1,675.0	1.1	0.7
Minimum:	10.1	13.5	8.5	93.4	2,553,877.2	1,286.8	1.0	0.5
Maximum:	12.0	14.0	9.6	148.4	3,503,990.5	2,032.6	1.3	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/27/2015 00:00	11.1	13.8	9.2	121.3	3,308,992.2	1,715.6	1.1	0.7
02/27/2015 01:00	10.8	13.8	9.0	123.9	3,446,706.2	1,787.0	1.1	0.7
02/27/2015 02:00	10.7	13.8	8.9	122.4	3,409,288.1	1,767.6	1.1	0.7
02/27/2015 03:00	10.5	13.9	8.9	107.5	2,933,307.0	1,499.4	1.1	0.6
02/27/2015 04:00	10.5	13.9	8.9	95.8	2,555,663.4	1,287.7	1.1	0.5
02/27/2015 05:00	10.8	13.8	9.0	106.8	2,840,494.8	1,472.7	1.1	0.6
02/27/2015 06:00	11.4	13.5	9.1	132.3	3,451,469.5	1,991.1	1.1	0.8
02/27/2015 07:00	10.9	13.7	8.9	135.2	3,121,074.2	1,800.5	1.3	0.9
02/27/2015 08:00	10.4	13.9	8.8	98.5	2,588,410.6	1,304.2	1.1	0.5
02/27/2015 09:00	10.4	13.9	8.8	95.7	2,550,900.2	1,285.3	1.1	0.5
02/27/2015 10:00	10.5	14.0	9.0	95.9	2,562,212.9	1,291.0	1.1	0.5
02/27/2015 11:00	10.8	13.9	9.1	112.9	2,909,244.3	1,487.1	1.1	0.6
02/27/2015 12:00	10.4	14.0	8.9	95.7	2,557,648.1	1,288.7	1.1	0.5
02/27/2015 13:00	10.4	14.0	8.9	95.6	2,559,831.3	1,289.8	1.1	0.5
02/27/2015 14:00	10.5	14.0	9.0	95.7	2,550,701.8	1,285.2	1.1	0.5
02/27/2015 15:00	10.3	14.0	8.8	96.3	2,723,744.8	1,352.5	1.0	0.5
02/27/2015 16:00	10.7	13.9	9.0	107.8	2,875,394.3	1,448.8	1.1	0.6
02/27/2015 17:00	11.1	13.7	9.1	119.3	3,028,436.4	1,658.6	1.2	0.8
02/27/2015 18:00	11.6	13.5	9.2	141.5	3,382,643.2	2,050.2	1.3	1.0
02/27/2015 19:00	11.5	13.5	9.2	141.5	3,380,333.3	2,048.8	1.3	1.0
02/27/2015 20:00	11.4	13.5	9.1	142.4	3,423,895.0	2,050.2	1.2	1.0
02/27/2015 21:00	11.3	13.5	9.0	138.9	3,407,027.7	2,040.1	1.2	1.0
02/27/2015 22:00	11.4	13.5	9.1	138.8	3,419,841.5	2,022.8	1.2	1.0
02/27/2015 23:00	10.9	13.8	9.1	115.6	2,977,466.3	1,587.2	1.1	0.6
Average/Sum#:	10.8	13.8	9.0	115.7	2,998,530.3	1,617.2	1.1	0.7
Minimum:	10.3	13.5	8.8	95.6	2,550,701.8	1,285.2	1.0	0.5
Maximum:	11.6	14.0	9.2	142.4	3,451,469.5	2,050.2	1.3	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/28/2015 00:00	10.6	14.0	9.1	96.2	2,550,900.2	1,285.3	1.1	0.5
02/28/2015 01:00	32.4	16.2	40.7	244.3	1,566,621.5	572.0	4.6	1.0
02/28/2015 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2015 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2015 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2015 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2015 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2015 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2015 08:00	49.4	16.7	69.4	195.5	1,940,816.7	566.9	0.0	0.0
02/28/2015 09:00	34.9	14.4	31.7	207.0	2,472,880.9	1,155.7	2.4	1.0
02/28/2015 10:00	10.6	13.8	8.8	112.9	3,151,241.1	1,610.8	1.1	0.6
02/28/2015 11:00	10.9	13.8	9.1	124.8	3,509,776.8	1,819.7	1.0	0.7
02/28/2015 12:00	10.6	13.9	8.9	112.2	3,113,288.5	1,591.4	1.1	0.6
02/28/2015 13:00	10.5	13.9	8.9	109.3	3,015,909.1	1,519.6	1.1	0.6
02/28/2015 14:00	11.1	13.8	9.2	125.3	3,443,234.4	1,785.2	1.1	0.7
02/28/2015 15:00	10.1	14.0	8.6	110.8	3,131,020.2	1,577.6	1.0	0.6
02/28/2015 16:00	11.1	13.8	9.2	116.0	3,012,923.8	1,584.1	1.1	0.6
02/28/2015 17:00	11.6	13.5	9.2	136.2	3,395,327.1	2,008.3	1.2	1.0
02/28/2015 18:00	11.4	13.5	9.1	138.0	3,391,496.4	2,030.8	1.2	1.0
02/28/2015 19:00	11.3	13.5	9.0	135.8	3,434,719.2	2,031.6	1.2	1.0
02/28/2015 20:00	11.3	13.5	9.0	136.0	3,445,708.4	2,038.1	1.2	1.0
02/28/2015 21:00	11.5	13.5	9.2	138.6	3,441,312.8	2,035.5	1.2	1.0
02/28/2015 22:00	11.6	13.5	9.2	139.0	3,443,341.5	2,036.7	1.2	1.0
02/28/2015 23:00	11.5	13.5	9.2	138.8	3,442,732.9	2,011.2	1.2	1.0
Average/Sum#:	15.7	14.0	15.4	139.8	3,050,180.6	1,625.6	1.3	0.8
Minimum:	10.1	13.5	8.6	96.2	1,566,621.5	566.9	0.0	0.0
Maximum:	49.4	16.7	69.4	244.3	3,509,776.8	2,038.1	4.6	1.0
%SI	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/01/2015 00:00	11.3	13.5	9.0	133.9	3,452,509.6	1,991.7	1.2	1.0
03/01/2015 01:00	11.0	13.7	9.0	128.6	3,438,735.7	1,858.2	1.1	0.7
03/01/2015 02:00	10.7	13.9	9.0	112.1	3,150,271.5	1,587.3	1.0	0.6
03/01/2015 03:00	10.4	14.0	8.9	115.8	3,306,266.8	1,665.9	1.0	0.7
03/01/2015 04:00	10.9	13.9	9.2	100.0	2,737,062.6	1,379.1	1.1	0.6
03/01/2015 05:00	11.2	13.8	9.3	125.6	3,415,540.0	1,745.9	1.1	0.7
03/01/2015 06:00	10.9	13.9	9.2	125.3	3,511,204.1	1,794.8	1.0	0.7
03/01/2015 07:00	11.0	13.8	9.1	126.0	3,539,287.0	1,835.0	1.0	0.7
03/01/2015 08:00	11.4	13.7	9.3	131.5	3,435,794.5	1,881.7	1.1	0.8
03/01/2015 09:00	11.8	13.5	9.4	140.6	3,449,089.7	2,040.1	1.2	1.0
03/01/2015 10:00	11.8	13.5	9.4	143.4	3,457,204.8	2,044.9	1.2	1.0
03/01/2015 11:00	11.8	13.5	9.4	143.8	3,424,396.0	2,050.5	1.3	1.0
03/01/2015 12:00	11.8	13.5	9.4	145.6	3,429,072.1	2,053.3	1.3	1.0
03/01/2015 13:00	11.7	13.6	9.5	138.3	3,443,495.6	1,986.5	1.2	1.0
03/01/2015 14:00	11.9	13.5	9.5	143.6	3,425,082.5	2,025.9	1.2	1.0
03/01/2015 15:00	12.0	13.5	9.6	148.1	3,388,252.9	2,053.6	1.3	1.0
03/01/2015 16:00	11.7	13.5	9.3	141.8	3,384,482.3	2,026.6	1.3	1.0
03/01/2015 17:00	11.8	13.5	9.4	145.7	3,387,592.9	2,053.2	1.3	1.0
03/01/2015 18:00	11.8	13.5	9.4	144.2	3,387,922.9	2,053.4	1.3	1.0
03/01/2015 19:00	11.8	13.5	9.4	145.6	3,427,736.0	2,052.5	1.3	1.0
03/01/2015 20:00	11.6	13.5	9.2	142.2	3,428,571.0	2,053.0	1.2	1.0
03/01/2015 21:00	11.7	13.5	9.3	144.1	3,428,070.0	2,052.7	1.3	1.0
03/01/2015 22:00	11.5	13.5	9.2	138.2	3,441,820.0	2,035.8	1.2	1.0
03/01/2015 23:00	11.3	13.5	9.0	134.1	3,455,283.1	1,993.3	1.2	1.0
Average/Sum#:	11.5	13.6	9.3	134.9	3,389,364.3	1,929.8	1.2	0.9
Minimum:	10.4	13.5	8.9	100.0	2,737,062.6	1,379.1	1.0	0.6
Maximum:	12.0	14.0	9.6	148.1	3,539,287.0	2,053.6	1.3	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/02/2015 00:00	11.5	13.5	9.2	136.9	3,438,967.0	2,009.0	1.2	1.0
03/02/2015 01:00	11.4	13.5	9.1	137.6	3,425,758.8	2,026.3	1.2	1.0
03/02/2015 02:00	11.2	13.5	8.9	133.1	3,461,523.5	1,996.9	1.1	0.8
03/02/2015 03:00	11.0	13.6	8.9	128.6	3,498,518.9	1,941.6	1.1	0.8
03/02/2015 04:00	10.2	13.8	8.5	121.9	3,406,677.6	1,816.0	1.1	0.7
03/02/2015 05:00	10.9	13.5	8.7	129.7	3,471,666.4	1,977.4	1.1	0.8
03/02/2015 06:00	11.1	13.5	8.9	132.9	3,468,283.9	2,000.8	1.1	0.8
03/02/2015 07:00	11.2	13.5	8.9	136.8	3,430,999.8	2,029.4	1.2	1.0
03/02/2015 08:00	11.1	13.5	8.9	134.2	3,438,111.1	2,008.5	1.2	1.0
03/02/2015 09:00	11.2	13.5	8.9	133.8	3,447,183.5	2,013.8	1.2	1.0
03/02/2015 10:00	11.1	13.5	8.9	131.7	3,477,817.9	2,006.3	1.1	0.8
03/02/2015 11:00	11.2	13.5	8.9	130.3	3,429,628.0	1,978.5	1.1	0.8
03/02/2015 12:00	11.3	13.5	9.0	133.0	3,431,092.8	2,004.4	1.2	1.0
03/02/2015 13:00	11.3	13.5	9.0	133.2	3,411,236.1	1,992.8	1.2	1.0
03/02/2015 14:00	11.0	13.8	9.1	118.3	3,187,569.7	1,699.2	1.1	0.7
03/02/2015 15:00	10.7	13.9	9.0	115.1	3,162,979.1	1,616.8	1.1	0.6
03/02/2015 16:00	10.9	13.7	8.9	121.0	3,374,705.8	1,823.6	1.1	0.7
03/02/2015 17:00	11.5	13.6	9.3	127.8	3,472,752.1	1,927.3	1.1	0.8
03/02/2015 18:00	11.4	13.6	9.2	128.7	3,482,302.1	1,932.6	1.1	0.8
03/02/2015 19:00	11.4	13.6	9.2	128.9	3,488,969.0	1,936.3	1.1	0.8
03/02/2015 20:00	11.2	13.6	9.1	127.7	3,500,681.2	1,942.8	1.1	0.8
03/02/2015 21:00	11.4	13.6	9.2	128.6	3,501,582.1	1,943.3	1.1	0.8
03/02/2015 22:00	11.0	13.7	9.0	123.9	3,334,178.3	1,801.7	1.1	0.7
03/02/2015 23:00	10.4	13.9	8.8	109.6	3,022,710.9	1,545.1	1.1	0.6
Average/Sum#:	11.1	13.6	9.0	128.5	3,406,912.3	1,915.4	1.1	0.8
Minimum:	10.2	13.5	8.5	109.6	3,022,710.9	1,545.1	1.1	0.6
Maximum:	11.5	13.9	9.3	137.6	3,501,582.1	2,029.4	1.2	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/03/2015 00:00	10.6	13.9	8.9	95.5	2,521,110.3	1,288.7	1.1	0.5
03/03/2015 01:00	10.6	13.9	8.9	95.5	2,522,479.7	1,289.4	1.1	0.5
03/03/2015 02:00	10.6	13.9	8.9	95.5	2,527,957.4	1,292.2	1.1	0.5
03/03/2015 03:00	10.6	13.9	8.9	95.5	2,532,065.7	1,294.3	1.1	0.5
03/03/2015 04:00	10.9	13.8	9.1	111.3	2,971,270.5	1,562.2	1.1	0.6
03/03/2015 05:00	10.9	13.5	8.7	130.8	3,492,207.7	1,989.1	1.1	0.8
03/03/2015 06:00	11.3	13.5	9.0	137.6	3,468,067.3	2,026.0	1.2	1.0
03/03/2015 07:00	11.0	13.6	8.9	133.4	3,435,348.4	1,981.8	1.2	1.0
03/03/2015 08:00	10.4	13.8	8.6	112.5	3,033,084.8	1,594.7	1.1	0.6
03/03/2015 09:00	10.6	13.9	8.9	96.1	2,561,815.9	1,290.8	1.1	0.5
03/03/2015 10:00	10.6	13.9	8.9	96.2	2,566,380.7	1,293.1	1.1	0.5
03/03/2015 11:00	10.6	13.9	8.9	96.1	2,567,174.6	1,293.5	1.1	0.5
03/03/2015 12:00	10.7	14.0	9.1	96.3	2,573,327.0	1,296.6	1.1	0.5
03/03/2015 13:00	10.9	14.0	9.3	96.6	2,576,105.6	1,298.0	1.1	0.5
03/03/2015 14:00	10.9	14.0	9.3	96.7	2,565,785.3	1,292.8	1.1	0.5
03/03/2015 15:00	10.8	14.0	9.2	96.5	2,564,991.4	1,292.4	1.1	0.5
03/03/2015 16:00	10.9	13.9	9.2	104.3	2,751,956.1	1,406.7	1.1	0.6
03/03/2015 17:00	11.7	13.6	9.5	130.6	3,447,748.2	1,938.6	1.1	0.8
03/03/2015 18:00	11.5	13.5	9.2	135.5	3,441,877.0	2,010.7	1.2	1.0
03/03/2015 19:00	11.6	13.5	9.2	140.9	3,433,247.1	2,055.8	1.2	1.0
03/03/2015 20:00	11.8	13.5	9.4	142.0	3,423,060.0	2,049.7	1.2	1.0
03/03/2015 21:00	11.7	13.5	9.3	140.2	3,423,227.0	2,049.8	1.2	1.0
03/03/2015 22:00	11.7	13.5	9.3	137.9	3,443,588.8	2,011.7	1.2	1.0
03/03/2015 23:00	11.0	13.8	9.1	122.4	3,223,212.3	1,718.2	1.1	0.7
Average/Sum#:	11.0	13.8	9.1	114.0	2,961,128.7	1,609.0	1.1	0.7
Minimum:	10.4	13.5	8.6	95.5	2,521,110.3	1,288.7	1.1	0.5
Maximum:	11.8	14.0	9.5	142.0	3,492,207.7	2,055.8	1.2	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/04/2015 00:00	10.1	13.8	8.4	123.8	3,547,787.3	1,813.5	1.0	0.7
03/04/2015 01:00	10.5	13.9	8.9	122.9	3,494,966.7	1,786.5	1.0	0.7
03/04/2015 02:00	9.8	14.0	8.4	118.3	3,497,066.8	1,736.5	1.0	0.7
03/04/2015 03:00	10.3	13.9	8.7	122.1	3,460,926.7	1,769.1	1.0	0.7
03/04/2015 04:00	10.9	13.8	9.1	123.1	3,367,488.6	1,819.7	1.1	0.7
03/04/2015 05:00	11.3	13.5	9.0	134.5	3,472,097.5	2,003.0	1.2	1.0
03/04/2015 06:00	11.3	13.5	9.0	135.8	3,477,297.9	2,006.0	1.2	1.0
03/04/2015 07:00	11.2	13.6	9.1	137.9	3,425,272.7	2,001.0	1.2	1.0
03/04/2015 08:00	10.9	13.6	8.8	128.8	3,472,017.5	1,977.6	1.1	0.8
03/04/2015 09:00	10.8	13.9	9.1	107.5	2,809,248.8	1,456.5	1.1	0.6
03/04/2015 10:00	11.0	14.0	9.4	96.8	2,565,785.3	1,292.8	1.1	0.5
03/04/2015 11:00	11.1	14.0	9.5	96.9	2,563,006.7	1,291.4	1.1	0.5
03/04/2015 12:00	11.1	14.0	9.5	97.0	2,560,426.7	1,290.1	1.1	0.5
03/04/2015 13:00	11.2	14.0	9.6	97.1	2,558,045.1	1,288.9	1.1	0.5
03/04/2015 14:00	11.1	14.0	9.5	96.8	2,558,243.5	1,289.0	1.1	0.5
03/04/2015 15:00	11.1	14.0	9.5	97.0	2,556,854.3	1,288.3	1.1	0.5
03/04/2015 16:00	11.5	13.8	9.6	117.3	2,940,268.3	1,545.9	1.2	0.8
03/04/2015 17:00	12.0	13.5	9.6	145.6	3,396,341.5	2,008.9	1.3	1.0
03/04/2015 18:00	12.0	13.5	9.6	149.7	3,392,665.4	2,031.5	1.3	1.0
03/04/2015 19:00	11.8	13.5	9.4	145.2	3,385,985.3	2,027.5	1.3	1.0
03/04/2015 20:00	11.6	13.5	9.2	142.5	3,425,420.7	2,026.1	1.2	1.0
03/04/2015 21:00	11.7	13.5	9.3	142.2	3,440,165.2	2,009.7	1.2	1.0
03/04/2015 22:00	11.4	13.5	9.1	137.7	3,490,472.1	2,013.6	1.2	1.0
03/04/2015 23:00	10.7	13.6	8.6	128.1	3,526,356.7	1,982.8	1.1	0.8
Average/Sum#:	11.1	13.7	9.2	122.7	3,182,675.3	1,739.8	1.1	0.8
Minimum:	9.8	13.5	8.4	96.8	2,556,854.3	1,288.3	1.0	0.5
Maximum:	12.0	14.0	9.6	149.7	3,547,787.3	2,031.5	1.3	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/05/2015 00:00	10.3	13.7	8.4	119.8	3,343,986.3	1,807.0	1.1	0.7
03/05/2015 01:00	10.8	13.9	9.1	111.2	3,112,897.3	1,591.2	1.0	0.6
03/05/2015 02:00	10.9	13.9	9.2	108.5	3,024,471.6	1,546.0	1.0	0.6
03/05/2015 03:00	10.5	13.9	8.9	113.0	3,194,475.8	1,632.9	1.0	0.7
03/05/2015 04:00	10.2	13.8	8.5	119.4	3,396,365.3	1,760.9	1.0	0.7
03/05/2015 05:00	11.0	13.5	8.8	130.1	3,495,894.7	1,991.2	1.1	0.8
03/05/2015 06:00	11.2	13.5	8.9	134.7	3,498,792.6	2,018.4	1.1	0.8
03/05/2015 07:00	11.0	13.5	8.8	135.0	3,538,206.4	2,015.3	1.1	0.8
03/05/2015 08:00	10.2	13.7	8.4	124.0	3,498,338.7	1,941.5	1.0	0.8
03/05/2015 09:00	10.6	13.8	8.8	116.9	2,806,548.5	1,455.1	1.2	0.7
03/05/2015 10:00	10.8	13.9	9.1	98.4	2,528,153.0	1,292.3	1.1	0.5
03/05/2015 11:00	10.8	13.9	9.1	96.5	2,564,991.4	1,292.4	1.1	0.5
03/05/2015 12:00	10.9	13.9	9.2	96.6	2,565,189.9	1,292.5	1.1	0.5
03/05/2015 13:00	11.0	14.0	9.4	96.9	2,566,976.1	1,293.4	1.1	0.5
03/05/2015 14:00	11.0	14.0	9.4	96.7	2,569,754.6	1,294.8	1.1	0.5
03/05/2015 15:00	10.8	14.0	9.2	96.7	2,571,342.4	1,295.6	1.1	0.5
03/05/2015 16:00	11.3	13.8	9.4	113.9	2,947,495.8	1,549.7	1.1	0.6
03/05/2015 17:00	11.9	13.5	9.5	140.8	3,337,930.7	2,023.1	1.3	1.0
03/05/2015 18:00	11.8	13.5	9.4	144.4	3,358,389.6	2,035.5	1.3	1.0
03/05/2015 19:00	11.8	13.5	9.4	142.1	3,352,119.9	2,031.7	1.3	1.0
03/05/2015 20:00	11.5	13.5	9.2	140.4	3,388,490.3	2,029.0	1.2	1.0
03/05/2015 21:00	11.4	13.5	9.1	138.3	3,371,289.0	2,018.7	1.2	1.0
03/05/2015 22:00	11.3	13.5	9.0	136.1	3,399,722.8	2,010.9	1.2	1.0
03/05/2015 23:00	11.0	13.7	9.0	124.4	3,186,376.7	1,745.1	1.2	0.9
Average/Sum#:	11.0	13.7	9.1	119.8	3,109,091.6	1,706.8	1.1	0.7
Minimum:	10.2	13.5	8.4	96.5	2,528,153.0	1,292.3	1.0	0.5
Maximum:	11.9	14.0	9.5	144.4	3,538,206.4	2,035.5	1.3	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/06/2015 00:00	10.7	13.9	9.0	96.7	2,532,456.9	1,294.5	1.1	0.5
03/06/2015 01:00	10.7	13.9	9.0	96.2	2,527,761.8	1,292.1	1.1	0.5
03/06/2015 02:00	10.7	13.9	9.0	96.1	2,524,240.4	1,290.3	1.1	0.5
03/06/2015 03:00	10.7	13.9	9.0	96.3	2,527,566.1	1,292.0	1.1	0.5
03/06/2015 04:00	10.7	13.9	9.0	96.2	2,529,718.1	1,293.1	1.1	0.5
03/06/2015 05:00	11.1	13.7	9.1	114.2	2,946,138.3	1,570.5	1.1	0.6
03/06/2015 06:00	11.1	13.5	8.9	131.9	3,500,986.1	1,994.1	1.1	0.8
03/06/2015 07:00	10.1	13.7	8.3	127.7	3,475,314.5	1,954.1	1.1	0.8
03/06/2015 08:00	10.0	13.7	8.2	123.4	3,497,978.4	1,941.3	1.0	0.8
03/06/2015 09:00	10.4	13.6	8.4	124.2	3,512,753.7	1,949.5	1.0	0.8
03/06/2015 10:00	10.9	13.8	9.1	117.3	3,025,489.9	1,612.8	1.1	0.6
03/06/2015 11:00	10.7	13.9	9.0	96.2	2,563,006.7	1,291.4	1.1	0.5
03/06/2015 12:00	10.8	14.0	9.2	96.4	2,565,388.3	1,292.6	1.1	0.5
03/06/2015 13:00	10.8	14.0	9.2	96.5	2,571,342.4	1,295.6	1.1	0.5
03/06/2015 14:00	10.7	14.0	9.1	96.3	2,576,105.6	1,298.0	1.1	0.5
03/06/2015 15:00	10.6	14.0	9.1	96.1	2,575,311.7	1,297.6	1.1	0.5
03/06/2015 16:00	11.1	13.8	9.2	113.2	2,921,058.3	1,535.8	1.1	0.6
03/06/2015 17:00	11.6	13.5	9.2	135.4	3,294,373.1	1,996.7	1.2	1.0
03/06/2015 18:00	11.7	13.5	9.3	142.8	3,290,162.9	2,042.2	1.3	1.0
03/06/2015 19:00	11.9	13.5	9.5	146.7	3,290,001.8	2,042.1	1.3	1.0
03/06/2015 20:00	11.9	13.5	9.5	147.0	3,322,484.4	2,038.0	1.3	1.0
03/06/2015 21:00	11.4	13.5	9.1	135.5	3,387,381.1	2,003.6	1.2	1.0
03/06/2015 22:00	11.3	13.5	9.0	135.7	3,398,032.2	2,009.9	1.2	1.0
03/06/2015 23:00	11.6	13.5	9.2	135.4	3,415,002.1	1,995.0	1.2	1.0
Average/Sum#:	11.0	13.7	9.0	116.4	2,990,419.0	1,651.0	1.1	0.7
Minimum:	10.0	13.5	8.2	96.1	2,524,240.4	1,290.3	1.0	0.5
Maximum:	11.9	14.0	9.5	147.0	3,512,753.7	2,042.2	1.3	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/07/2015 00:00	11.1	13.6	9.0	130.0	3,345,486.0	1,881.1	1.2	0.9
03/07/2015 01:00	10.8	13.8	9.0	121.0	3,332,330.3	1,727.7	1.1	0.7
03/07/2015 02:00	37.3	16.5	50.0	263.4	1,335,759.4	468.2	5.8	1.0
03/07/2015 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2015 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2015 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2015 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2015 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2015 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2015 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2015 10:00	49.2	16.6	67.5	167.2	1,915,190.1	573.4	0.0	0.0
03/07/2015 11:00	50.8	15.0	50.8	262.3	2,319,665.6	999.4	3.1	1.2
03/07/2015 12:00	11.3	13.8	9.4	126.2	3,427,082.3	1,751.8	1.1	0.7
03/07/2015 13:00	11.4	13.8	9.5	122.3	3,431,581.9	1,754.1	1.0	0.7
03/07/2015 14:00	10.7	13.9	9.0	116.6	3,299,334.6	1,686.5	1.0	0.7
03/07/2015 15:00	10.2	14.0	8.7	101.1	2,884,523.8	1,453.4	1.0	0.6
03/07/2015 16:00	11.2	13.8	9.3	119.8	3,147,455.4	1,700.8	1.1	0.7
03/07/2015 17:00	12.1	13.5	9.6	146.9	3,283,879.7	2,038.3	1.3	1.0
03/07/2015 18:00	12.0	13.5	9.6	148.3	3,278,793.2	2,011.2	1.4	1.0
03/07/2015 19:00	12.0	13.5	9.6	150.4	3,285,007.4	2,039.0	1.4	1.0
03/07/2015 20:00	12.1	13.5	9.6	150.0	3,321,669.3	2,037.5	1.4	1.0
03/07/2015 21:00	11.7	13.5	9.3	140.5	3,370,474.6	1,993.6	1.2	1.0
03/07/2015 22:00	11.2	13.5	8.9	134.1	3,411,920.9	1,993.2	1.2	1.0
03/07/2015 23:00	11.0	13.6	8.9	123.1	3,182,222.1	1,789.3	1.2	0.9
Average/Sum#:	17.4	14.1	17.5	148.4	3,033,669.2	1,641.1	1.5	0.8
Minimum:	10.2	13.5	8.7	101.1	1,335,759.4	468.2	0.0	0.0
Maximum:	50.8	16.6	67.5	263.4	3,431,581.9	2,039.0	5.8	1.2
%SI	29.2	29.2	29.2	29.2	29.2	29.2	29.2	29.2

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/08/2015 00:00	10.7	13.9	9.0	96.1	2,552,686.4	1,286.2	1.1	0.5
03/08/2015 01:00	10.7	13.9	9.0	95.7	2,552,884.9	1,286.3	1.1	0.5
03/08/2015 02:00	10.6	13.9	8.9	95.5	2,553,678.8	1,286.7	1.1	0.5
03/08/2015 03:00	10.8	13.9	9.1	95.8	2,554,869.6	1,287.3	1.1	0.5
03/08/2015 04:00	10.8	13.9	9.1	95.8	2,556,655.8	1,288.2	1.1	0.5
03/08/2015 05:00	10.8	13.9	9.1	95.9	2,556,258.8	1,288.0	1.1	0.5
03/08/2015 06:00	10.8	13.9	9.1	95.8	2,524,240.4	1,290.3	1.1	0.5
03/08/2015 07:00	10.8	13.9	9.1	94.0	2,524,827.3	1,290.6	1.1	0.5
03/08/2015 08:00	32.1	16.1	39.5	241.6	1,553,356.9	578.5	4.6	1.0
03/08/2015 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2015 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2015 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2015 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2015 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2015 14:00	0.0	21.0	0.0	97.2	0.0	0.2	0.0	0.0
03/08/2015 15:00	61.6	15.8	71.3	252.8	1,889,246.7	676.0	3.4	0.9
03/08/2015 16:00	18.7	14.0	16.0	150.3	2,570,945.4	1,295.4	1.8	0.9
03/08/2015 17:00	10.3	14.0	8.8	95.0	2,569,953.1	1,294.9	1.1	0.5
03/08/2015 18:00	11.3	13.7	9.3	118.2	3,087,595.5	1,691.0	1.1	0.7
03/08/2015 19:00	11.7	13.5	9.3	139.0	3,282,109.4	1,965.3	1.3	1.0
03/08/2015 20:00	11.5	13.6	9.3	138.0	3,213,467.0	1,853.8	1.3	0.9
03/08/2015 21:00	10.4	14.0	8.9	96.5	2,601,707.9	1,310.9	1.1	0.5
03/08/2015 22:00	10.6	13.9	8.9	95.8	2,556,854.3	1,288.3	1.1	0.5
03/08/2015 23:00	10.6	13.9	8.9	95.7	2,556,655.8	1,288.2	1.1	0.5
Average/Sum#:	14.5	14.5	13.8	120.2	2,434,631.3	1,239.3	1.4	0.6
Minimum:	0.0	13.5	0.0	94.0	0.0	0.2	0.0	0.0
Maximum:	61.6	21.0	71.3	252.8	3,282,109.4	1,965.3	4.6	1.0
%SI	20.8	20.8	20.8	20.8	20.8	20.8	20.8	20.8

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/09/2015 00:00	10.6	13.9	8.9	95.7	2,554,472.6	1,287.1	1.1	0.5
03/09/2015 01:00	10.7	13.9	9.0	96.0	2,552,091.0	1,285.9	1.1	0.5
03/09/2015 02:00	10.7	13.9	9.0	96.0	2,552,686.4	1,286.2	1.1	0.5
03/09/2015 03:00	10.7	13.9	9.0	95.9	2,550,304.8	1,285.0	1.1	0.5
03/09/2015 04:00	10.9	13.8	9.1	102.8	2,740,609.5	1,400.9	1.1	0.6
03/09/2015 05:00	11.7	13.5	9.3	132.4	3,415,344.4	1,995.2	1.1	0.8
03/09/2015 06:00	11.6	13.5	9.2	140.5	3,429,072.1	2,053.3	1.2	1.0
03/09/2015 07:00	10.9	13.6	8.8	133.8	3,414,893.7	1,970.0	1.2	1.0
03/09/2015 08:00	10.9	13.5	8.7	126.1	3,473,891.8	1,953.3	1.1	0.8
03/09/2015 09:00	10.3	13.9	8.7	98.6	2,604,058.3	1,331.1	1.1	0.5
03/09/2015 10:00	10.7	14.0	9.1	96.1	2,551,694.1	1,285.7	1.1	0.5
03/09/2015 11:00	10.5	14.0	9.0	95.6	2,551,694.1	1,285.7	1.1	0.5
03/09/2015 12:00	10.6	14.0	9.1	95.9	2,553,678.8	1,286.7	1.1	0.5
03/09/2015 13:00	10.6	14.0	9.1	95.9	2,566,976.1	1,293.4	1.1	0.5
03/09/2015 14:00	10.3	13.7	8.4	111.7	3,038,058.6	1,619.5	1.1	0.6
03/09/2015 15:00	10.3	14.0	8.8	95.5	2,551,892.6	1,285.8	1.1	0.5
03/09/2015 16:00	10.3	14.0	8.8	95.3	2,551,098.7	1,285.4	1.1	0.5
03/09/2015 17:00	10.6	13.6	8.6	118.8	3,071,423.3	1,727.0	1.2	0.9
03/09/2015 18:00	11.1	13.4	8.7	137.3	3,289,518.5	2,041.8	1.3	1.0
03/09/2015 19:00	11.0	13.4	8.7	136.7	3,328,842.4	2,041.9	1.2	1.0
03/09/2015 20:00	10.9	13.4	8.6	134.1	3,329,351.2	2,017.9	1.2	1.0
03/09/2015 21:00	10.8	13.5	8.6	128.3	3,352,008.5	1,958.2	1.1	0.8
03/09/2015 22:00	10.8	13.5	8.6	131.2	3,364,219.2	1,989.9	1.2	1.0
03/09/2015 23:00	10.8	13.5	8.6	126.9	3,374,677.7	1,946.8	1.1	0.8
Average/Sum#:	10.8	13.7	8.9	113.2	2,948,439.9	1,621.4	1.1	0.7
Minimum:	10.3	13.4	8.4	95.3	2,550,304.8	1,285.0	1.1	0.5
Maximum:	11.7	14.0	9.3	140.5	3,473,891.8	2,053.3	1.3	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/10/2015 00:00	10.8	13.5	8.6	124.9	3,381,776.0	1,926.2	1.1	0.8
03/10/2015 01:00	11.1	13.5	8.9	130.2	3,367,928.1	1,967.5	1.1	0.8
03/10/2015 02:00	11.0	13.5	8.8	124.9	3,405,598.4	1,914.9	1.1	0.8
03/10/2015 03:00	11.0	13.5	8.8	124.8	3,375,982.2	1,922.9	1.1	0.8
03/10/2015 04:00	11.0	13.5	8.8	125.9	3,430,759.2	1,954.1	1.1	0.8
03/10/2015 05:00	10.9	13.5	8.7	130.8	3,447,183.5	2,013.8	1.1	0.8
03/10/2015 06:00	11.0	13.5	8.8	133.7	3,459,740.8	2,046.4	1.2	1.0
03/10/2015 07:00	10.8	13.5	8.6	134.1	3,389,240.8	2,004.7	1.2	1.0
03/10/2015 08:00	10.6	13.6	8.6	120.9	3,287,714.1	1,800.6	1.1	0.7
03/10/2015 09:00	9.8	13.9	8.3	101.3	2,766,432.9	1,414.1	1.1	0.6
03/10/2015 10:00	10.2	13.9	8.6	95.0	2,520,132.1	1,288.2	1.1	0.5
03/10/2015 11:00	10.4	13.9	8.8	95.5	2,556,457.3	1,288.1	1.1	0.5
03/10/2015 12:00	10.5	13.9	8.9	95.6	2,557,251.2	1,288.5	1.1	0.5
03/10/2015 13:00	10.4	13.9	8.8	95.5	2,558,045.1	1,288.9	1.1	0.5
03/10/2015 14:00	10.4	13.9	8.8	95.5	2,558,838.9	1,289.3	1.1	0.5
03/10/2015 15:00	10.4	13.9	8.8	95.4	2,557,648.1	1,288.7	1.1	0.5
03/10/2015 16:00	10.5	13.8	8.7	101.3	2,736,696.8	1,398.9	1.1	0.6
03/10/2015 17:00	11.6	13.4	9.1	137.4	3,298,519.5	2,023.3	1.2	1.0
03/10/2015 18:00	11.5	13.4	9.0	140.8	3,315,474.2	2,033.7	1.3	1.0
03/10/2015 19:00	11.4	13.4	9.0	140.0	3,323,625.6	2,038.7	1.3	1.0
03/10/2015 20:00	11.5	13.4	9.0	138.7	3,318,734.8	2,035.7	1.3	1.0
03/10/2015 21:00	11.2	13.5	8.9	133.7	3,323,025.2	1,989.8	1.2	1.0
03/10/2015 22:00	10.4	13.7	8.5	118.4	3,052,538.2	1,671.8	1.2	0.8
03/10/2015 23:00	10.1	13.9	8.5	95.0	2,518,762.7	1,287.5	1.1	0.5
Average/Sum#:	10.8	13.6	8.8	117.9	3,062,837.7	1,715.7	1.1	0.8
Minimum:	9.8	13.4	8.3	95.0	2,518,762.7	1,287.5	1.1	0.5
Maximum:	11.6	13.9	9.1	140.8	3,459,740.8	2,046.4	1.3	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/11/2015 00:00	10.1	13.9	8.5	94.8	2,518,567.1	1,287.4	1.1	0.5
03/11/2015 01:00	10.1	13.9	8.5	95.0	2,520,914.7	1,288.6	1.1	0.5
03/11/2015 02:00	10.1	13.9	8.5	94.9	2,520,914.7	1,288.6	1.1	0.5
03/11/2015 03:00	10.4	13.9	8.8	95.4	2,556,854.3	1,288.3	1.1	0.5
03/11/2015 04:00	10.6	13.8	8.8	101.3	2,709,338.6	1,404.7	1.1	0.6
03/11/2015 05:00	11.2	13.5	8.9	125.6	3,444,546.9	1,936.8	1.1	0.8
03/11/2015 06:00	11.1	13.5	8.9	128.6	3,431,534.8	1,979.6	1.1	0.8
03/11/2015 07:00	11.1	13.4	8.7	134.8	3,419,385.9	2,047.5	1.2	1.0
03/11/2015 08:00	11.0	13.4	8.7	134.0	3,422,391.9	2,049.3	1.2	1.0
03/11/2015 09:00	11.0	13.4	8.7	134.1	3,414,375.8	2,044.5	1.2	1.0
03/11/2015 10:00	11.1	13.4	8.7	135.3	3,370,433.9	2,042.8	1.2	1.0
03/11/2015 11:00	11.0	13.4	8.7	135.1	3,372,578.8	2,044.1	1.2	1.0
03/11/2015 12:00	10.9	13.4	8.6	134.7	3,363,339.3	2,038.5	1.2	1.0
03/11/2015 13:00	10.9	13.4	8.6	135.1	3,373,733.7	2,044.8	1.2	1.0
03/11/2015 14:00	10.9	13.4	8.6	134.7	3,368,454.0	2,041.6	1.2	1.0
03/11/2015 15:00	10.9	13.4	8.6	134.1	3,371,258.8	2,043.3	1.2	1.0
03/11/2015 16:00	10.9	13.4	8.6	134.4	3,370,433.9	2,042.8	1.2	1.0
03/11/2015 17:00	10.8	13.5	8.6	126.1	3,399,466.0	1,961.1	1.1	0.8
03/11/2015 18:00	10.9	13.4	8.6	133.8	3,369,114.0	2,042.0	1.2	1.0
03/11/2015 19:00	10.9	13.4	8.6	133.7	3,423,728.0	2,050.1	1.2	1.0
03/11/2015 20:00	10.6	13.5	8.5	129.0	3,430,579.3	2,004.1	1.1	0.8
03/11/2015 21:00	10.3	13.7	8.4	112.3	2,996,818.7	1,619.4	1.1	0.6
03/11/2015 22:00	10.3	13.9	8.7	95.4	2,529,326.8	1,292.9	1.1	0.5
03/11/2015 23:00	10.3	13.9	8.7	95.2	2,537,543.4	1,297.1	1.1	0.5
Average/Sum#:	10.7	13.6	8.6	121.1	3,134,818.1	1,799.2	1.2	0.8
Minimum:	10.1	13.4	8.4	94.8	2,518,567.1	1,287.4	1.1	0.5
Maximum:	11.2	13.9	8.9	135.3	3,444,546.9	2,050.1	1.2	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/12/2015 00:00	10.3	13.9	8.7	95.3	2,543,999.2	1,300.4	1.1	0.5
03/12/2015 01:00	10.2	13.9	8.6	95.3	2,553,193.9	1,305.1	1.1	0.5
03/12/2015 02:00	10.2	13.9	8.6	95.4	2,557,889.1	1,307.5	1.1	0.5
03/12/2015 03:00	10.3	13.9	8.7	95.4	2,558,280.4	1,307.7	1.1	0.5
03/12/2015 04:00	10.4	13.8	8.6	101.0	2,749,071.2	1,425.3	1.1	0.6
03/12/2015 05:00	11.0	13.5	8.8	125.8	3,460,553.2	1,945.8	1.1	0.8
03/12/2015 06:00	11.2	13.4	8.8	134.6	3,395,504.5	2,033.2	1.2	1.0
03/12/2015 07:00	11.2	13.4	8.8	134.5	3,394,836.4	2,032.8	1.2	1.0
03/12/2015 08:00	11.0	13.5	8.8	130.4	3,389,667.7	1,980.2	1.1	0.8
03/12/2015 09:00	10.8	13.5	8.6	125.8	3,415,660.4	1,945.5	1.1	0.8
03/12/2015 10:00	10.8	13.5	8.6	124.8	3,421,604.6	1,923.9	1.1	0.8
03/12/2015 11:00	10.1	13.9	8.5	98.9	2,645,532.3	1,352.3	1.1	0.5
03/12/2015 12:00	10.6	13.9	8.9	96.1	2,567,174.6	1,293.5	1.1	0.5
03/12/2015 13:00	10.6	13.9	8.9	96.1	2,566,182.2	1,293.0	1.1	0.5
03/12/2015 14:00	10.6	13.9	8.9	95.9	2,565,388.3	1,292.6	1.1	0.5
03/12/2015 15:00	10.5	13.9	8.9	95.9	2,562,212.9	1,291.0	1.1	0.5
03/12/2015 16:00	11.0	13.8	9.1	111.5	2,925,242.6	1,538.0	1.1	0.6
03/12/2015 17:00	11.3	13.4	8.9	135.4	3,339,085.6	2,023.8	1.2	1.0
03/12/2015 18:00	11.1	13.4	8.7	136.2	3,367,464.1	2,041.0	1.2	1.0
03/12/2015 19:00	11.1	13.4	8.7	136.3	3,370,763.9	2,043.0	1.2	1.0
03/12/2015 20:00	11.1	13.4	8.7	136.4	3,368,784.0	2,041.8	1.2	1.0
03/12/2015 21:00	11.1	13.4	8.7	135.8	3,360,039.5	2,036.5	1.2	1.0
03/12/2015 22:00	10.7	13.6	8.6	123.4	3,169,417.1	1,782.1	1.2	0.9
03/12/2015 23:00	10.4	13.9	8.8	99.0	2,741,031.9	1,381.1	1.1	0.6
Average/Sum#:	10.7	13.7	8.7	114.8	2,999,524.2	1,663.2	1.1	0.7
Minimum:	10.1	13.4	8.5	95.3	2,543,999.2	1,291.0	1.1	0.5
Maximum:	11.3	13.9	9.1	136.4	3,460,553.2	2,043.0	1.2	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/13/2015 00:00	10.5	13.9	8.9	99.1	2,742,818.1	1,382.0	1.1	0.6
03/13/2015 01:00	10.4	13.9	8.8	100.1	2,768,976.1	1,415.4	1.1	0.6
03/13/2015 02:00	10.3	13.9	8.7	107.2	3,010,386.1	1,538.8	1.0	0.6
03/13/2015 03:00	10.2	13.9	8.6	100.8	2,760,759.6	1,411.2	1.1	0.6
03/13/2015 04:00	10.7	13.7	8.8	108.7	2,958,337.1	1,555.4	1.1	0.6
03/13/2015 05:00	10.9	13.5	8.7	128.1	3,425,294.4	1,976.0	1.1	0.8
03/13/2015 06:00	10.8	13.5	8.6	130.9	3,425,272.7	2,001.0	1.1	0.8
03/13/2015 07:00	10.8	13.5	8.6	122.1	3,448,246.6	1,913.7	1.0	0.8
03/13/2015 08:00	10.7	13.5	8.5	122.7	3,408,621.8	1,916.6	1.1	0.8
03/13/2015 09:00	10.7	13.5	8.5	123.4	3,412,534.4	1,918.8	1.1	0.8
03/13/2015 10:00	10.3	13.7	8.4	111.9	3,050,064.5	1,625.9	1.1	0.7
03/13/2015 11:00	10.5	13.9	8.9	95.6	2,564,396.0	1,292.1	1.1	0.5
03/13/2015 12:00	10.7	13.9	9.0	102.8	2,732,392.9	1,396.7	1.1	0.6
03/13/2015 13:00	11.1	13.5	8.9	129.9	3,334,802.0	1,972.5	1.2	1.0
03/13/2015 14:00	10.9	13.5	8.7	130.6	3,346,129.3	1,979.2	1.2	1.0
03/13/2015 15:00	11.1	13.4	8.7	135.2	3,306,670.8	2,028.3	1.2	1.0
03/13/2015 16:00	11.0	13.4	8.7	136.6	3,286,618.5	2,040.0	1.3	1.0
03/13/2015 17:00	10.9	13.4	8.6	136.6	3,291,935.1	2,043.3	1.3	1.0
03/13/2015 18:00	10.9	13.4	8.6	136.2	3,329,657.6	2,042.4	1.2	1.0
03/13/2015 19:00	10.9	13.4	8.6	135.0	3,312,702.8	2,032.0	1.2	1.0
03/13/2015 20:00	10.9	13.4	8.6	135.3	3,318,408.7	2,035.5	1.2	1.0
03/13/2015 21:00	10.9	13.4	8.6	132.9	3,313,182.1	2,008.1	1.2	1.0
03/13/2015 22:00	10.9	13.4	8.6	133.6	3,332,321.0	2,019.7	1.2	1.0
03/13/2015 23:00	10.8	13.4	8.5	134.2	3,306,833.8	2,028.4	1.2	1.0
Average/Sum#:	10.7	13.6	8.7	122.1	3,174,473.4	1,815.5	1.1	0.8
Minimum:	10.2	13.4	8.4	95.6	2,564,396.0	1,292.1	1.0	0.5
Maximum:	11.1	13.9	9.0	136.6	3,448,246.6	2,043.3	1.3	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/14/2015 00:00	10.8	13.4	8.5	130.2	3,347,481.8	1,980.0	1.2	1.0
03/14/2015 01:00	10.8	13.5	8.6	130.1	3,349,848.7	1,981.4	1.2	1.0
03/14/2015 02:00	10.8	13.5	8.6	129.0	3,366,045.1	1,966.4	1.1	0.8
03/14/2015 03:00	10.7	13.5	8.5	124.8	3,379,493.6	1,924.9	1.1	0.8
03/14/2015 04:00	10.8	13.5	8.6	124.4	3,370,188.5	1,919.6	1.1	0.8
03/14/2015 05:00	10.8	13.5	8.6	124.6	3,379,142.5	1,924.7	1.1	0.8
03/14/2015 06:00	10.9	13.4	8.6	134.4	3,346,840.2	2,028.5	1.2	1.0
03/14/2015 07:00	10.8	13.4	8.5	135.5	3,336,886.4	1,998.1	1.2	1.0
03/14/2015 08:00	10.7	13.5	8.5	128.0	3,345,161.4	1,954.2	1.1	0.8
03/14/2015 09:00	10.8	13.5	8.6	127.0	3,380,224.7	1,950.0	1.1	0.8
03/14/2015 10:00	10.8	13.5	8.6	127.6	3,341,909.0	1,952.3	1.1	0.8
03/14/2015 11:00	10.7	13.5	8.5	127.7	3,374,604.0	1,971.4	1.1	0.8
03/14/2015 12:00	10.8	13.4	8.5	134.9	3,341,721.6	2,049.8	1.2	1.0
03/14/2015 13:00	10.9	13.4	8.6	136.9	3,306,434.9	2,052.3	1.2	1.0
03/14/2015 14:00	10.9	13.4	8.6	137.2	3,300,473.9	2,048.6	1.3	1.0
03/14/2015 15:00	10.8	13.4	8.5	133.7	3,283,195.0	2,013.9	1.2	1.0
03/14/2015 16:00	10.9	13.4	8.6	137.4	3,264,166.3	2,049.9	1.3	1.0
03/14/2015 17:00	10.9	13.4	8.6	137.3	3,302,246.1	2,049.7	1.3	1.0
03/14/2015 18:00	10.9	13.4	8.6	136.9	3,297,735.0	2,046.9	1.3	1.0
03/14/2015 19:00	10.9	13.4	8.6	136.5	3,295,640.6	2,045.6	1.2	1.0
03/14/2015 20:00	10.9	13.4	8.6	136.2	3,293,707.3	2,044.4	1.2	1.0
03/14/2015 21:00	10.9	13.4	8.6	136.1	3,293,868.4	2,044.5	1.2	1.0
03/14/2015 22:00	10.8	13.4	8.5	135.6	3,329,168.5	2,042.1	1.2	1.0
03/14/2015 23:00	10.8	13.4	8.5	132.4	3,311,037.2	2,006.8	1.2	1.0
Average/Sum#:	10.8	13.4	8.6	132.3	3,330,717.5	2,001.9	1.2	0.9
Minimum:	10.7	13.4	8.5	124.4	3,264,166.3	1,919.6	1.1	0.8
Maximum:	10.9	13.5	8.6	137.4	3,380,224.7	2,052.3	1.3	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/15/2015 00:00	10.7	13.5	8.5	126.9	3,338,143.1	1,950.1	1.1	0.8
03/15/2015 01:00	10.7	13.4	8.4	130.0	3,324,194.2	1,990.5	1.2	1.0
03/15/2015 02:00	10.1	13.6	8.2	125.6	3,224,727.7	1,813.2	1.2	0.9
03/15/2015 03:00	9.9	13.8	8.2	119.8	3,412,181.2	1,769.1	1.0	0.7
03/15/2015 04:00	10.4	13.7	8.5	122.1	3,390,466.5	1,782.6	1.1	0.7
03/15/2015 05:00	10.1	13.8	8.4	119.6	3,381,513.8	1,753.2	1.0	0.7
03/15/2015 06:00	10.4	13.7	8.5	122.3	3,393,129.3	1,784.0	1.1	0.7
03/15/2015 07:00	9.9	13.8	8.2	113.5	2,959,478.3	1,556.0	1.2	0.8
03/15/2015 08:00	10.0	13.9	8.4	95.4	2,536,956.5	1,296.8	1.1	0.5
03/15/2015 09:00	10.5	14.0	9.0	96.0	2,575,510.2	1,297.7	1.1	0.5
03/15/2015 10:00	10.7	14.0	9.1	96.2	2,578,090.3	1,299.0	1.1	0.5
03/15/2015 11:00	10.5	13.9	8.9	110.3	3,072,792.7	1,570.7	1.1	0.6
03/15/2015 12:00	10.1	13.8	8.4	120.3	3,446,254.3	1,761.6	1.0	0.7
03/15/2015 13:00	10.6	13.6	8.6	129.5	3,328,394.6	1,920.1	1.2	1.0
03/15/2015 14:00	11.0	13.5	8.8	136.3	3,376,538.6	2,046.5	1.2	1.0
03/15/2015 15:00	11.0	13.5	8.8	135.2	3,351,295.0	2,031.2	1.2	1.0
03/15/2015 16:00	11.0	13.5	8.8	135.8	3,360,204.5	2,036.6	1.2	1.0
03/15/2015 17:00	10.9	13.5	8.7	135.5	3,356,244.7	2,034.2	1.2	1.0
03/15/2015 18:00	10.9	13.5	8.7	135.1	3,355,419.7	2,033.7	1.2	1.0
03/15/2015 19:00	10.9	13.5	8.7	135.2	3,358,719.5	2,035.7	1.2	1.0
03/15/2015 20:00	10.9	13.4	8.6	135.0	3,356,739.6	2,034.5	1.2	1.0
03/15/2015 21:00	10.9	13.4	8.6	134.4	3,344,365.3	2,027.0	1.2	1.0
03/15/2015 22:00	10.6	13.5	8.5	126.2	3,241,673.3	1,846.4	1.2	0.9
03/15/2015 23:00	10.1	13.9	8.5	95.6	2,531,478.8	1,294.0	1.1	0.5
Average/Sum#:	10.5	13.7	8.6	122.2	3,191,438.0	1,790.2	1.1	0.8
Minimum:	9.9	13.4	8.2	95.4	2,531,478.8	1,294.0	1.0	0.5
Maximum:	11.0	14.0	9.1	136.3	3,446,254.3	2,046.5	1.2	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/16/2015 00:00	10.4	13.9	8.8	95.4	2,563,205.2	1,291.5	1.1	0.5
03/16/2015 01:00	10.4	13.9	8.8	95.5	2,520,523.4	1,288.4	1.1	0.5
03/16/2015 02:00	10.4	13.9	8.8	95.6	2,525,805.5	1,291.1	1.1	0.5
03/16/2015 03:00	10.5	13.9	8.9	95.7	2,569,357.7	1,294.6	1.1	0.5
03/16/2015 04:00	10.9	13.7	8.9	109.4	2,911,996.5	1,552.3	1.1	0.6
03/16/2015 05:00	11.1	13.4	8.7	131.2	3,370,305.6	1,993.5	1.2	1.0
03/16/2015 06:00	11.0	13.4	8.7	135.2	3,356,574.7	2,034.4	1.2	1.0
03/16/2015 07:00	10.8	13.5	8.6	134.9	3,336,552.4	1,997.9	1.2	1.0
03/16/2015 08:00	10.9	13.4	8.6	135.1	3,354,594.8	2,033.2	1.2	1.0
03/16/2015 09:00	10.9	13.4	8.6	134.8	3,391,329.4	2,030.7	1.2	1.0
03/16/2015 10:00	11.0	13.4	8.7	133.6	3,367,281.0	2,016.3	1.2	1.0
03/16/2015 11:00	11.0	13.4	8.7	135.0	3,354,594.8	2,033.2	1.2	1.0
03/16/2015 12:00	11.0	13.4	8.7	135.1	3,351,789.9	2,031.5	1.2	1.0
03/16/2015 13:00	10.9	13.4	8.6	135.4	3,354,264.8	2,033.0	1.2	1.0
03/16/2015 14:00	10.9	13.4	8.6	135.4	3,352,944.9	2,032.2	1.2	1.0
03/16/2015 15:00	10.9	13.4	8.6	134.4	3,337,105.7	2,022.6	1.2	1.0
03/16/2015 16:00	10.8	13.5	8.6	130.4	3,345,453.1	1,978.8	1.2	1.0
03/16/2015 17:00	10.9	13.5	8.7	127.9	3,338,656.6	1,950.4	1.1	0.8
03/16/2015 18:00	10.9	13.5	8.7	133.4	3,357,427.8	2,010.4	1.2	1.0
03/16/2015 19:00	10.9	13.4	8.6	135.0	3,377,858.5	2,047.3	1.2	1.0
03/16/2015 20:00	10.8	13.5	8.6	130.9	3,400,906.3	2,011.6	1.1	0.8
03/16/2015 21:00	10.8	13.5	8.6	127.2	3,427,027.9	1,977.0	1.1	0.8
03/16/2015 22:00	10.0	13.8	8.3	104.6	2,814,842.2	1,459.4	1.1	0.6
03/16/2015 23:00	10.0	13.9	8.4	94.7	2,525,022.9	1,290.7	1.1	0.5
Average/Sum#:	10.8	13.6	8.7	123.2	3,150,225.9	1,820.9	1.2	0.8
Minimum:	10.0	13.4	8.3	94.7	2,520,523.4	1,288.4	1.1	0.5
Maximum:	11.1	13.9	8.9	135.4	3,427,027.9	2,047.3	1.2	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/17/2015 00:00	10.2	13.9	8.6	95.0	2,521,697.2	1,289.0	1.1	0.5
03/17/2015 01:00	10.3	13.9	8.7	95.4	2,523,262.2	1,289.8	1.1	0.5
03/17/2015 02:00	10.3	13.9	8.7	95.4	2,523,066.6	1,289.7	1.1	0.5
03/17/2015 03:00	10.3	13.9	8.7	95.4	2,524,631.7	1,290.5	1.1	0.5
03/17/2015 04:00	10.4	13.9	8.8	95.5	2,523,849.1	1,290.1	1.1	0.5
03/17/2015 05:00	10.3	13.9	8.7	95.4	2,524,240.4	1,290.3	1.1	0.5
03/17/2015 06:00	10.3	13.9	8.7	95.4	2,524,240.4	1,290.3	1.1	0.5
03/17/2015 07:00	10.3	13.9	8.7	93.4	2,521,892.8	1,289.1	1.1	0.5
03/17/2015 08:00	10.3	13.9	8.7	95.3	2,525,022.9	1,290.7	1.1	0.5
03/17/2015 09:00	10.3	13.9	8.7	95.3	2,529,131.2	1,292.8	1.1	0.5
03/17/2015 10:00	0.0	0.0	0.0	95.3	848,715.5	1,295.3	3.8	1.9
03/17/2015 11:00	10.4	13.9	8.8	95.5	3,005,306.3	1,294.8	0.9	0.4
03/17/2015 12:00	10.3	13.9	8.7	95.5	4,130,247.6	1,296.9	0.6	0.3
03/17/2015 13:00	10.4	13.9	8.8	95.5	5,080,173.2	1,298.4	0.5	0.3
03/17/2015 14:00	10.4	13.9	8.8	95.6	5,232,006.7	1,299.0	0.5	0.3
03/17/2015 15:00	10.3	14.0	8.8	95.6	5,385,157.6	1,297.7	0.4	0.3
03/17/2015 16:00	10.4	14.0	8.9	95.6	6,119,438.1	1,295.9	0.4	0.3
03/17/2015 17:00	10.3	13.9	8.7	95.5	6,574,758.6	1,296.3	0.3	0.1
03/17/2015 18:00	10.3	13.9	8.7	95.6	6,572,729.8	1,295.9	0.3	0.1
03/17/2015 19:00	10.4	13.9	8.8	95.6	6,815,519.8	1,294.0	0.3	0.1
03/17/2015 20:00	10.4	13.9	8.8	95.6	6,806,039.2	1,292.2	0.3	0.1
03/17/2015 21:00	10.5	13.9	8.9	95.8	6,806,039.2	1,292.2	0.3	0.1
03/17/2015 22:00	10.6	13.9	8.9	96.0	3,156,034.1	1,290.6	0.9	0.4
03/17/2015 23:00	10.6	13.9	8.9	95.9	2,669,547.6	1,286.6	1.1	0.5
Average/Sum#:	10.4	13.9	8.8	95.4	4,069,305.8	1,292.8	0.8	0.4
Minimum:	10.2	13.9	8.6	93.4	2,521,697.2	1,286.6	0.3	0.1
Maximum:	10.6	14.0	8.9	96.0	6,815,519.8	1,299.0	1.1	0.5
%SI	4.2	4.2	4.2	0.0	4.2	0.0	4.2	4.2

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/18/2015 00:00	10.6	13.9	8.9	96.0	2,628,272.9	1,285.9	1.1	0.5
03/18/2015 01:00	10.6	13.9	8.9	96.2	2,637,879.3	1,290.6	1.1	0.5
03/18/2015 02:00	10.7	13.9	9.0	96.3	2,659,953.6	1,301.4	1.1	0.5
03/18/2015 03:00	10.6	13.9	8.9	96.1	2,664,450.2	1,303.6	1.1	0.5
03/18/2015 04:00	10.6	13.9	8.9	96.1	2,665,472.1	1,304.1	1.1	0.5
03/18/2015 05:00	10.6	13.9	8.9	96.1	2,662,815.1	1,302.8	1.1	0.5
03/18/2015 06:00	10.6	13.9	8.9	96.1	2,661,384.3	1,302.1	1.1	0.5
03/18/2015 07:00	10.6	13.9	8.9	97.7	2,658,522.8	1,300.7	1.1	0.5
03/18/2015 08:00	10.6	13.9	8.9	96.4	2,658,114.0	1,300.5	1.1	0.5
03/18/2015 09:00	10.6	14.0	9.1	96.2	2,657,909.7	1,300.4	1.1	0.5
03/18/2015 10:00	10.6	14.0	9.1	96.2	2,659,544.8	1,301.2	1.1	0.5
03/18/2015 11:00	10.6	14.0	9.1	96.1	2,656,070.1	1,299.5	1.1	0.5
03/18/2015 12:00	10.7	14.0	9.1	96.3	2,649,325.2	1,296.2	1.1	0.5
03/18/2015 13:00	10.7	14.0	9.1	96.4	2,648,916.4	1,296.0	1.1	0.5
03/18/2015 14:00	10.7	14.0	9.1	96.9	2,682,027.9	1,312.2	1.1	0.5
03/18/2015 15:00	11.2	13.9	9.4	121.6	3,327,298.5	1,652.2	1.1	0.7
03/18/2015 16:00	10.5	13.9	8.9	119.2	3,378,651.9	1,677.7	1.0	0.7
03/18/2015 17:00	10.7	14.0	9.1	97.0	2,620,301.6	1,282.0	1.1	0.5
03/18/2015 18:00	10.9	14.0	9.3	96.6	2,624,185.0	1,283.9	1.1	0.5
03/18/2015 19:00	11.0	14.0	9.4	96.9	2,621,119.1	1,282.4	1.1	0.5
03/18/2015 20:00	10.9	14.0	9.3	96.6	2,629,703.6	1,286.6	1.1	0.5
03/18/2015 21:00	10.8	14.0	9.2	96.6	2,629,703.6	1,286.6	1.1	0.5
03/18/2015 22:00	10.8	14.0	9.2	96.4	2,584,184.4	1,283.2	1.1	0.5
03/18/2015 23:00	10.8	13.9	9.1	96.5	2,583,177.4	1,282.7	1.1	0.5
Average/Sum#:	10.7	14.0	9.1	98.4	2,702,041.0	1,325.6	1.1	0.5
Minimum:	10.5	13.9	8.9	96.0	2,583,177.4	1,282.0	1.0	0.5
Maximum:	11.2	14.0	9.4	121.6	3,378,651.9	1,677.7	1.1	0.7
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/19/2015 00:00	10.8	14.0	9.2	96.4	2,583,580.2	1,282.9	1.1	0.5
03/19/2015 01:00	10.8	13.9	9.1	96.3	2,579,955.3	1,281.1	1.1	0.5
03/19/2015 02:00	10.8	13.9	9.1	96.2	2,580,559.4	1,281.4	1.1	0.5
03/19/2015 03:00	10.8	13.9	9.1	96.3	2,584,385.8	1,283.3	1.1	0.5
03/19/2015 04:00	10.8	14.0	9.2	96.5	2,588,816.2	1,285.5	1.1	0.5
03/19/2015 05:00	10.8	14.0	9.2	98.7	2,565,388.3	1,292.6	1.1	0.5
03/19/2015 06:00	11.0	13.9	9.3	105.5	2,758,216.3	1,409.9	1.1	0.6
03/19/2015 07:00	10.8	13.5	8.6	131.8	3,415,002.1	1,995.0	1.2	1.0
03/19/2015 08:00	10.9	13.5	8.7	125.8	1,279,658.3	1,953.0	3.1	2.3
03/19/2015 09:00	10.9	13.5	8.7	124.9	1,272,778.4	1,942.5	3.1	2.3
03/19/2015 10:00	11.0	13.5	8.8	125.6	1,275,989.0	1,947.4	3.2	2.3
03/19/2015 11:00	11.0	13.5	8.8	128.2	1,294,925.1	1,976.3	3.2	2.4
03/19/2015 12:00	11.1	13.5	8.9	135.0	3,365,154.2	2,039.6	1.2	1.0
03/19/2015 13:00	0.0	0.0	0.0	129.7	3,391,208.3	1,981.1	1.3	1.0
03/19/2015 14:00	10.2	13.8	8.5	110.4	3,104,227.1	1,564.1	1.0	0.6
03/19/2015 15:00	10.3	14.0	8.8	96.9	2,621,356.1	1,320.8	1.1	0.5
03/19/2015 16:00	10.5	13.9	8.9	100.5	2,720,850.6	1,390.8	1.1	0.6
03/19/2015 17:00	10.8	13.5	8.6	125.8	3,346,075.8	1,930.3	1.1	0.8
03/19/2015 18:00	10.9	13.5	8.7	129.6	3,334,802.0	1,972.5	1.2	1.0
03/19/2015 19:00	11.0	13.4	8.7	136.2	3,323,951.6	2,038.9	1.2	1.0
03/19/2015 20:00	10.9	13.5	8.7	126.3	3,345,035.7	1,929.7	1.1	0.8
03/19/2015 21:00	10.4	13.7	8.5	121.5	3,140,666.7	1,743.0	1.2	0.9
03/19/2015 22:00	9.9	13.9	8.3	103.8	2,866,792.1	1,465.4	1.1	0.6
03/19/2015 23:00	10.3	13.9	8.7	95.2	2,556,911.0	1,307.0	1.1	0.5
Average/Sum#:	10.7	13.7	8.8	113.9	2,938,646.7	1,650.6	1.1	0.7
Minimum:	9.9	13.4	8.3	95.2	2,556,911.0	1,281.1	1.0	0.5
Maximum:	11.1	14.0	9.3	136.2	3,415,002.1	2,039.6	1.2	1.0
%SI	4.2	4.2	4.2	0.0	16.7	0.0	20.8	20.8

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/20/2015 00:00	10.4	13.9	8.8	101.7	2,838,816.7	1,451.1	1.1	0.6
03/20/2015 01:00	10.5	13.9	8.9	95.6	2,541,651.7	1,299.2	1.1	0.5
03/20/2015 02:00	10.8	13.8	9.0	116.1	3,230,877.2	1,675.1	1.1	0.7
03/20/2015 03:00	10.1	13.9	8.5	96.5	2,601,906.3	1,330.0	1.1	0.5
03/20/2015 04:00	10.7	13.7	8.8	115.4	3,081,570.0	1,687.7	1.1	0.7
03/20/2015 05:00	10.9	13.5	8.7	130.2	3,440,507.6	2,009.9	1.1	0.8
03/20/2015 06:00	11.1	13.5	8.9	133.8	3,396,840.5	2,034.0	1.2	1.0
03/20/2015 07:00	11.0	13.5	8.8	134.5	3,422,520.9	1,974.4	1.2	1.0
03/20/2015 08:00	10.8	13.6	8.7	130.4	3,344,515.7	1,929.4	1.2	1.0
03/20/2015 09:00	10.5	13.7	8.6	123.4	3,483,473.3	1,831.5	1.0	0.7
03/20/2015 10:00	10.5	13.7	8.6	123.1	3,477,767.3	1,828.5	1.0	0.7
03/20/2015 11:00	10.5	13.6	8.5	124.2	3,393,951.8	1,834.0	1.1	0.7
03/20/2015 12:00	10.9	13.5	8.7	129.3	3,404,046.7	1,988.6	1.1	0.8
03/20/2015 13:00	11.1	13.4	8.7	131.8	3,398,201.2	2,010.0	1.2	1.0
03/20/2015 14:00	10.9	13.5	8.7	128.8	3,387,442.4	1,978.9	1.1	0.8
03/20/2015 15:00	10.8	13.5	8.6	128.5	3,382,307.1	1,975.9	1.1	0.8
03/20/2015 16:00	10.8	13.5	8.6	125.2	3,372,250.9	1,945.4	1.1	0.8
03/20/2015 17:00	10.8	13.5	8.6	125.1	3,370,170.7	1,944.2	1.1	0.8
03/20/2015 18:00	10.8	13.5	8.6	125.6	3,381,091.5	1,950.5	1.1	0.8
03/20/2015 19:00	10.8	13.5	8.6	124.9	3,370,344.1	1,944.3	1.1	0.8
03/20/2015 20:00	10.7	13.5	8.5	124.8	3,372,944.3	1,945.8	1.1	0.8
03/20/2015 21:00	11.0	13.5	8.8	125.7	3,429,530.2	1,953.4	1.1	0.8
03/20/2015 22:00	10.3	13.7	8.4	118.7	3,208,709.4	1,733.9	1.1	0.7
03/20/2015 23:00	10.1	13.9	8.5	95.6	2,524,827.3	1,290.6	1.1	0.5
Average/Sum#:	10.7	13.6	8.7	121.2	3,244,011.0	1,814.4	1.1	0.8
Minimum:	10.1	13.4	8.4	95.6	2,524,827.3	1,290.6	1.0	0.5
Maximum:	11.1	13.9	9.0	134.5	3,483,473.3	2,034.0	1.2	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/21/2015 00:00	10.4	13.9	8.8	95.4	2,515,828.2	1,286.0	1.1	0.5
03/21/2015 01:00	10.4	13.8	8.6	109.2	2,993,170.4	1,530.0	1.1	0.6
03/21/2015 02:00	10.3	13.9	8.7	97.7	2,618,143.8	1,338.3	1.1	0.5
03/21/2015 03:00	10.6	13.8	8.8	110.2	3,022,184.6	1,566.9	1.1	0.6
03/21/2015 04:00	10.1	13.9	8.5	111.2	3,099,985.5	1,584.6	1.1	0.6
03/21/2015 05:00	10.5	13.8	8.7	105.8	2,851,065.5	1,499.0	1.1	0.6
03/21/2015 06:00	10.8	13.5	8.6	128.5	3,454,243.0	1,992.7	1.1	0.8
03/21/2015 07:00	10.6	13.6	8.6	123.9	3,245,355.6	1,801.1	1.1	0.7
03/21/2015 08:00	10.1	13.9	8.5	98.3	2,631,251.1	1,345.0	1.1	0.5
03/21/2015 09:00	10.3	13.9	8.7	95.1	2,557,302.2	1,307.2	1.1	0.5
03/21/2015 10:00	10.4	13.9	8.8	95.1	2,564,931.9	1,311.1	1.1	0.5
03/21/2015 11:00	10.5	13.9	8.9	95.4	2,568,453.2	1,312.9	1.1	0.5
03/21/2015 12:00	10.5	14.0	9.0	96.5	2,660,652.7	1,340.6	1.1	0.5
03/21/2015 13:00	10.5	14.0	9.0	95.5	2,599,921.7	1,310.0	1.1	0.5
03/21/2015 14:00	10.3	14.0	8.8	99.1	2,784,893.2	1,403.2	1.0	0.6
03/21/2015 15:00	10.3	13.9	8.7	105.6	2,913,352.6	1,489.2	1.1	0.6
03/21/2015 16:00	10.4	13.9	8.8	114.5	3,211,495.8	1,641.6	1.0	0.7
03/21/2015 17:00	10.7	13.6	8.6	124.6	3,212,456.2	1,806.3	1.2	0.9
03/21/2015 18:00	10.9	13.4	8.6	131.9	3,323,192.2	1,989.9	1.2	1.0
03/21/2015 19:00	10.9	13.4	8.6	132.2	3,334,882.4	1,996.9	1.2	1.0
03/21/2015 20:00	10.9	13.4	8.6	133.7	3,326,381.3	2,016.1	1.2	1.0
03/21/2015 21:00	11.0	13.4	8.7	131.8	3,375,039.4	1,996.3	1.2	1.0
03/21/2015 22:00	10.4	13.7	8.5	122.4	3,263,794.8	1,787.5	1.1	0.7
03/21/2015 23:00	10.1	13.8	8.4	120.0	3,391,350.6	1,758.3	1.0	0.7
Average/Sum#:	10.5	13.8	8.7	111.4	2,979,972.0	1,600.4	1.1	0.7
Minimum:	10.1	13.4	8.4	95.1	2,515,828.2	1,286.0	1.0	0.5
Maximum:	11.0	14.0	9.0	133.7	3,454,243.0	2,016.1	1.2	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/22/2015 00:00	10.4	13.7	8.5	122.9	3,420,327.6	1,798.3	1.1	0.7
03/22/2015 01:00	9.5	13.9	8.0	110.3	3,151,241.1	1,610.8	1.0	0.6
03/22/2015 02:00	10.2	13.8	8.5	113.0	3,190,373.1	1,654.1	1.0	0.7
03/22/2015 03:00	10.0	13.9	8.4	119.0	3,453,101.4	1,765.1	1.0	0.7
03/22/2015 04:00	10.1	13.8	8.4	107.3	2,980,650.0	1,523.6	1.1	0.6
03/22/2015 05:00	10.5	13.8	8.7	111.5	3,070,596.6	1,592.0	1.1	0.6
03/22/2015 06:00	10.4	13.8	8.6	114.6	3,151,990.6	1,634.2	1.1	0.7
03/22/2015 07:00	10.9	13.6	8.8	114.4	3,180,678.3	1,672.3	1.1	0.7
03/22/2015 08:00	11.3	13.4	8.9	135.6	3,366,639.1	2,040.5	1.2	1.0
03/22/2015 09:00	11.3	13.4	8.9	134.3	3,328,361.2	2,017.3	1.2	1.0
03/22/2015 10:00	11.4	13.5	9.1	129.2	3,342,593.7	1,952.7	1.1	0.8
03/22/2015 11:00	11.4	13.5	9.1	129.8	3,356,288.0	1,960.7	1.1	0.8
03/22/2015 12:00	10.9	13.5	8.7	128.1	3,377,685.2	1,973.2	1.1	0.8
03/22/2015 13:00	10.3	13.7	8.4	116.2	3,141,163.4	1,697.4	1.1	0.7
03/22/2015 14:00	10.5	13.8	8.7	113.2	3,149,284.8	1,609.8	1.1	0.6
03/22/2015 15:00	10.0	13.8	8.3	112.0	3,157,501.4	1,614.0	1.0	0.6
03/22/2015 16:00	10.0	13.9	8.4	108.9	3,065,554.3	1,567.0	1.0	0.6
03/22/2015 17:00	10.8	13.7	8.9	118.1	3,128,860.8	1,713.6	1.1	0.7
03/22/2015 18:00	11.0	13.4	8.7	131.4	3,368,953.0	1,992.7	1.2	1.0
03/22/2015 19:00	10.9	13.5	8.7	129.5	3,385,559.4	1,977.8	1.1	0.8
03/22/2015 20:00	10.8	13.5	8.6	127.9	3,399,119.3	1,960.9	1.1	0.8
03/22/2015 21:00	10.2	13.8	8.5	104.8	2,797,429.7	1,470.8	1.1	0.6
03/22/2015 22:00	10.3	13.9	8.7	94.8	2,552,020.2	1,304.5	1.1	0.5
03/22/2015 23:00	15.8	14.5	14.6	133.6	2,358,780.8	1,119.6	1.7	0.8
Average/Sum#:	10.8	13.7	8.9	119.2	3,161,448.0	1,717.6	1.1	0.7
Minimum:	9.5	13.4	8.0	94.8	2,358,780.8	1,119.6	1.0	0.5
Maximum:	15.8	14.5	14.6	135.6	3,453,101.4	2,040.5	1.7	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/23/2015 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/24/2015 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/25/2015 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/26/2015 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2015 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2015 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2015 03:00	43.2	17.3	70.8	0.0	1,894,236.1	470.3	0.0	0.0
03/26/2015 04:00	34.4	16.7	48.3	218.8	1,938,061.6	594.4	3.2	0.7
03/26/2015 05:00	43.2	16.0	52.0	284.5	2,118,974.6	758.2	3.6	1.1
03/26/2015 06:00	9.8	13.9	8.3	114.9	2,690,918.9	1,375.5	1.3	0.7
03/26/2015 07:00	9.6	13.9	8.1	94.3	2,691,310.2	1,375.7	1.0	0.6
03/26/2015 08:00	9.6	13.9	8.1	97.5	2,703,439.4	1,381.9	1.1	0.6
03/26/2015 09:00	9.5	13.9	8.0	94.0	2,741,031.9	1,381.1	1.0	0.6
03/26/2015 10:00	9.6	13.9	8.1	94.4	2,746,192.1	1,383.7	1.0	0.6
03/26/2015 11:00	9.7	13.9	8.2	94.4	2,744,008.9	1,382.6	1.0	0.6
03/26/2015 12:00	9.8	14.0	8.4	94.8	2,748,772.1	1,385.0	1.0	0.6
03/26/2015 13:00	10.3	13.8	8.6	112.3	3,199,245.4	1,658.7	1.0	0.7
03/26/2015 14:00	9.8	13.9	8.3	98.9	2,731,610.4	1,396.3	1.1	0.6
03/26/2015 15:00	9.9	14.0	8.5	96.7	2,785,488.6	1,403.5	1.0	0.6
03/26/2015 16:00	10.5	13.8	8.7	114.4	3,239,749.5	1,679.7	1.0	0.7
03/26/2015 17:00	10.4	13.7	8.5	120.8	3,370,686.0	1,772.2	1.1	0.7
03/26/2015 18:00	10.4	13.7	8.5	121.2	3,382,097.8	1,778.2	1.1	0.7
03/26/2015 19:00	10.4	13.7	8.5	121.3	3,388,374.4	1,781.5	1.1	0.7
03/26/2015 20:00	10.3	13.7	8.4	121.3	3,395,792.1	1,785.4	1.1	0.7
03/26/2015 21:00	10.1	13.9	8.5	102.6	2,663,921.7	1,361.7	1.1	0.5
03/26/2015 22:00	37.5	17.1	58.2	276.4	1,064,329.4	334.2	7.7	1.0
03/26/2015 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	15.9	14.4	18.2	123.7	2,711,912.1	1,322.0	1.6	0.7
Minimum:	9.5	13.7	8.0	0.0	1,064,329.4	334.2	0.0	0.0
Maximum:	43.2	17.3	70.8	284.5	3,395,792.1	1,785.4	7.7	1.1
%SI	16.7	16.7	16.7	16.7	16.7	16.7	16.7	16.7

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/27/2015 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2015 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2015 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2015 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2015 04:00	12.5	18.6	32.1	0.1	1,667,763.3	170.5	0.0	0.0
03/27/2015 05:00	51.7	15.8	59.8	170.6	2,166,107.2	806.7	1.9	0.6
03/27/2015 06:00	9.8	13.9	8.3	106.2	2,709,504.0	1,385.0	1.2	0.7
03/27/2015 07:00	9.5	13.9	8.0	94.1	2,698,352.9	1,379.3	1.0	0.6
03/27/2015 08:00	9.5	13.9	8.0	93.8	2,731,307.0	1,376.2	1.0	0.6
03/27/2015 09:00	9.6	13.9	8.1	96.0	2,730,910.1	1,376.0	1.0	0.6
03/27/2015 10:00	9.6	13.9	8.1	94.3	2,734,482.5	1,377.8	1.0	0.6
03/27/2015 11:00	9.6	13.9	8.1	94.0	2,745,398.2	1,383.3	1.0	0.6
03/27/2015 12:00	9.8	14.0	8.4	94.7	2,745,001.3	1,383.1	1.0	0.6
03/27/2015 13:00	9.8	14.0	8.4	94.6	2,739,245.7	1,380.2	1.0	0.6
03/27/2015 14:00	9.7	14.0	8.3	94.4	2,737,459.5	1,379.3	1.0	0.6
03/27/2015 15:00	9.7	14.0	8.3	94.6	2,735,871.8	1,378.5	1.0	0.6
03/27/2015 16:00	9.9	14.0	8.5	94.9	2,741,428.8	1,381.3	1.0	0.6
03/27/2015 17:00	10.4	13.9	8.8	107.0	3,064,967.4	1,566.7	1.0	0.6
03/27/2015 18:00	9.9	14.0	8.5	97.1	2,766,237.3	1,393.8	1.0	0.6
03/27/2015 19:00	10.2	14.0	8.7	95.4	2,725,551.5	1,373.3	1.0	0.5
03/27/2015 20:00	17.5	14.7	16.7	145.4	2,419,751.1	1,113.2	1.7	0.8
03/27/2015 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2015 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2015 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	12.9	14.4	13.2	98.1	2,638,784.7	1,270.8	1.0	0.6
Minimum:	9.5	13.9	8.0	0.1	1,667,763.3	170.5	0.0	0.0
Maximum:	51.7	18.6	59.8	170.6	3,064,967.4	1,566.7	1.9	0.8
%SI	29.2	29.2	29.2	29.2	29.2	29.2	29.2	29.2

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/28/2015 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/29/2015 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/30/2015 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2015 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2015 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2015 03:00	44.7	17.2	71.3	0.0	1,919,610.8	476.6	0.0	0.0
03/30/2015 04:00	62.1	15.7	70.5	227.3	1,884,275.3	715.5	3.1	0.9
03/30/2015 05:00	42.0	14.6	39.3	231.9	2,399,143.2	1,086.2	2.6	1.1
03/30/2015 06:00	9.8	13.9	8.3	96.4	2,740,039.6	1,380.6	1.0	0.6
03/30/2015 07:00	9.8	13.9	8.3	94.8	2,752,543.0	1,386.9	1.0	0.6
03/30/2015 08:00	9.9	13.9	8.3	98.1	2,748,375.2	1,384.8	1.0	0.6
03/30/2015 09:00	9.8	14.0	8.4	94.8	2,750,756.8	1,386.0	1.0	0.6
03/30/2015 10:00	9.7	14.0	8.3	94.3	2,735,077.9	1,378.1	1.0	0.6
03/30/2015 11:00	9.8	14.0	8.4	94.4	2,730,910.1	1,376.0	1.0	0.6
03/30/2015 12:00	10.1	13.9	8.5	102.6	2,955,609.1	1,510.8	1.0	0.6
03/30/2015 13:00	9.4	13.9	7.9	103.5	3,039,129.8	1,531.3	1.0	0.6
03/30/2015 14:00	9.4	13.9	7.9	103.8	2,960,108.6	1,513.1	1.0	0.6
03/30/2015 15:00	9.7	14.0	8.3	94.6	2,681,690.2	1,351.2	1.0	0.5
03/30/2015 16:00	9.6	14.0	8.2	93.7	2,649,340.0	1,334.9	1.0	0.5
03/30/2015 17:00	9.9	13.9	8.3	101.3	2,882,442.7	1,473.4	1.0	0.6
03/30/2015 18:00	10.1	13.8	8.4	115.0	3,265,016.3	1,692.8	1.0	0.7
03/30/2015 19:00	9.9	13.8	8.2	110.8	3,148,893.6	1,609.6	1.0	0.6
03/30/2015 20:00	21.6	15.1	22.0	170.3	2,223,032.2	974.0	2.2	0.8
03/30/2015 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2015 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2015 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	17.1	14.3	17.7	112.6	2,692,555.2	1,309.0	1.2	0.6
Minimum:	9.4	13.8	7.9	0.0	1,884,275.3	476.6	0.0	0.0
Maximum:	62.1	17.2	71.3	231.9	3,265,016.3	1,692.8	3.1	1.1
%SI	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/31/2015 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2015 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2015 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2015 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2015 04:00	45.1	17.0	68.2	56.3	1,923,856.2	519.8	0.0	0.0
03/31/2015 05:00	26.3	14.2	23.2	182.3	2,547,538.1	1,246.4	2.0	1.0
03/31/2015 06:00	9.8	13.9	8.3	94.9	2,698,157.3	1,379.2	1.0	0.6
03/31/2015 07:00	9.8	13.9	8.3	94.7	2,703,635.0	1,382.0	1.0	0.6
03/31/2015 08:00	9.7	13.9	8.2	94.7	2,708,525.8	1,384.5	1.0	0.6
03/31/2015 09:00	9.8	13.9	8.3	95.4	2,741,031.9	1,381.1	1.0	0.6
03/31/2015 10:00	9.9	13.9	8.3	94.7	2,733,291.7	1,377.2	1.0	0.6
03/31/2015 11:00	9.8	13.9	8.3	94.2	2,723,963.7	1,372.5	1.0	0.5
03/31/2015 12:00	10.0	14.0	8.6	94.8	2,733,887.1	1,377.5	1.0	0.6
03/31/2015 13:00	10.3	14.0	8.8	95.5	2,729,322.3	1,375.2	1.0	0.6
03/31/2015 14:00	10.5	14.0	9.0	96.3	2,745,199.7	1,383.2	1.0	0.6
03/31/2015 15:00	10.4	14.0	8.9	96.0	2,738,451.8	1,379.8	1.0	0.6
03/31/2015 16:00	10.2	13.9	8.6	104.1	3,022,061.6	1,522.7	1.0	0.6
03/31/2015 17:00	10.0	14.0	8.6	103.4	2,994,077.7	1,508.6	1.0	0.6
03/31/2015 18:00	9.8	13.9	8.3	108.6	3,167,141.2	1,595.8	1.0	0.6
03/31/2015 19:00	9.6	14.0	8.2	118.9	3,515,054.4	1,771.1	1.0	0.7
03/31/2015 20:00	10.1	13.8	8.4	111.5	3,167,869.9	1,619.3	1.0	0.6
03/31/2015 21:00	21.5	15.0	21.5	168.6	2,353,614.0	1,048.4	2.0	0.8
03/31/2015 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2015 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	13.5	14.2	13.3	105.8	2,774,815.5	1,368.0	1.1	0.6
Minimum:	9.6	13.8	8.2	56.3	1,923,856.2	519.8	0.0	0.0
Maximum:	45.1	17.0	68.2	182.3	3,515,054.4	1,771.1	2.0	1.0
%SI	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/01/2015 00:00	12.5	13.2	9.6	179.8	3,537,423.2	2,299.0	1.5	1.4
01/01/2015 01:00	12.6	13.2	9.7	182.8	3,523,634.3	2,341.5	1.5	1.4
01/01/2015 02:00	12.7	13.2	9.7	186.9	3,523,182.8	2,341.2	1.6	1.4
01/01/2015 03:00	12.7	13.2	9.7	184.0	3,523,032.3	2,341.1	1.5	1.4
01/01/2015 04:00	12.5	13.2	9.6	175.4	3,534,807.5	2,297.3	1.5	1.4
01/01/2015 05:00	12.4	13.2	9.5	165.8	3,548,520.9	2,280.3	1.4	1.1
01/01/2015 06:00	12.7	13.1	9.6	180.2	3,558,998.5	2,365.0	1.5	1.4
01/01/2015 07:00	12.7	13.2	9.7	179.3	3,563,546.6	2,342.0	1.5	1.4
01/01/2015 08:00	11.7	13.6	9.5	132.1	3,498,528.2	1,992.7	1.1	0.8
01/01/2015 09:00	11.5	13.7	9.4	121.7	3,430,682.0	1,878.9	1.0	0.8
01/01/2015 10:00	11.3	13.8	9.4	98.6	2,774,796.2	1,458.9	1.0	0.6
01/01/2015 11:00	11.4	13.8	9.5	86.7	2,493,526.2	1,274.6	1.0	0.5
01/01/2015 12:00	11.5	13.8	9.6	86.9	2,499,590.8	1,277.7	1.0	0.5
01/01/2015 13:00	11.4	13.8	9.5	86.7	2,492,939.3	1,274.3	1.0	0.5
01/01/2015 14:00	11.4	13.8	9.5	86.6	2,489,026.6	1,272.3	1.0	0.5
01/01/2015 15:00	11.2	13.7	9.2	107.6	3,037,308.2	1,619.1	1.0	0.6
01/01/2015 16:00	11.2	13.6	9.1	122.6	3,470,512.7	1,951.4	1.0	0.8
01/01/2015 17:00	11.4	13.4	9.0	128.6	3,555,587.5	2,025.2	1.0	0.8
01/01/2015 18:00	11.7	13.3	9.1	146.4	3,551,758.9	2,152.7	1.2	1.1
01/01/2015 19:00	12.4	13.0	9.3	186.1	3,505,577.6	2,355.1	1.6	1.4
01/01/2015 20:00	12.5	13.0	9.3	186.9	3,516,146.0	2,362.2	1.6	1.4
01/01/2015 21:00	12.4	13.1	9.4	179.2	3,526,493.5	2,343.4	1.5	1.4
01/01/2015 22:00	12.5	13.1	9.5	184.9	3,519,119.7	2,338.5	1.6	1.4
01/01/2015 23:00	11.6	13.4	9.1	136.3	3,558,278.1	2,078.7	1.1	0.8
Average/Sum#:	12.0	13.4	9.4	146.3	3,301,375.7	2,011.0	1.3	1.0
Minimum:	11.2	13.0	9.0	86.6	2,489,026.6	1,272.3	1.0	0.5
Maximum:	12.7	13.8	9.7	186.9	3,563,546.6	2,365.0	1.6	1.4
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/02/2015 00:00	11.4	13.5	9.1	129.5	3,575,075.5	2,036.3	1.0	0.8
01/02/2015 01:00	11.7	13.3	9.1	139.5	3,554,992.3	2,128.7	1.1	0.9
01/02/2015 02:00	11.3	13.6	9.1	123.1	3,405,954.1	1,915.1	1.0	0.8
01/02/2015 03:00	11.7	13.4	9.2	141.1	3,613,373.6	2,084.5	1.1	0.8
01/02/2015 04:00	11.4	13.5	9.1	129.5	3,613,501.9	2,031.8	1.0	0.8
01/02/2015 05:00	11.5	13.4	9.0	134.8	3,584,078.3	2,067.6	1.1	0.8
01/02/2015 06:00	11.3	13.5	9.0	128.7	3,578,999.5	2,012.4	1.0	0.8
01/02/2015 07:00	11.2	13.6	9.1	131.1	3,566,550.2	2,005.4	1.1	0.8
01/02/2015 08:00	11.2	13.6	9.1	123.4	3,466,422.2	1,949.1	1.0	0.8
01/02/2015 09:00	11.3	13.6	9.1	118.3	3,352,955.6	1,885.3	1.0	0.8
01/02/2015 10:00	11.2	13.7	9.2	98.7	2,790,012.0	1,466.9	1.0	0.6
01/02/2015 11:00	11.6	13.8	9.6	87.4	2,531,506.3	1,312.5	1.0	0.5
01/02/2015 12:00	11.6	13.8	9.6	87.2	2,525,720.0	1,309.5	1.0	0.5
01/02/2015 13:00	11.5	13.8	9.6	87.1	2,534,592.4	1,314.1	1.0	0.5
01/02/2015 14:00	11.5	13.8	9.6	87.1	2,525,720.0	1,309.5	1.0	0.5
01/02/2015 15:00	11.1	13.7	9.1	106.3	3,088,708.6	1,646.5	1.0	0.7
01/02/2015 16:00	11.0	13.6	8.9	118.6	3,422,849.6	1,924.6	1.0	0.8
01/02/2015 17:00	11.9	13.2	9.1	159.0	3,483,317.7	2,238.4	1.3	1.1
01/02/2015 18:00	12.3	13.0	9.2	184.6	3,468,030.4	2,355.2	1.6	1.4
01/02/2015 19:00	12.4	13.0	9.3	177.0	3,473,036.9	2,358.6	1.5	1.4
01/02/2015 20:00	12.4	13.0	9.3	183.7	3,474,362.2	2,359.5	1.6	1.4
01/02/2015 21:00	12.4	13.0	9.3	181.7	3,476,423.7	2,360.9	1.6	1.4
01/02/2015 22:00	12.4	13.0	9.3	180.9	3,509,001.1	2,357.4	1.5	1.4
01/02/2015 23:00	12.3	13.1	9.3	161.1	3,512,496.6	2,282.8	1.3	1.1
Average/Sum#:	11.7	13.4	9.2	133.3	3,296,986.7	1,946.4	1.2	0.9
Minimum:	11.0	13.0	8.9	87.1	2,525,720.0	1,309.5	1.0	0.5
Maximum:	12.4	13.8	9.6	184.6	3,613,501.9	2,360.9	1.6	1.4
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/03/2015 00:00	12.1	13.2	9.3	154.5	3,534,707.3	2,219.8	1.3	1.1
01/03/2015 01:00	12.3	13.1	9.3	172.1	3,552,963.9	2,309.1	1.4	1.2
01/03/2015 02:00	12.1	13.2	9.3	152.5	3,520,694.5	2,211.0	1.3	1.1
01/03/2015 03:00	12.4	13.1	9.4	171.3	3,551,271.3	2,308.0	1.4	1.2
01/03/2015 04:00	11.9	13.3	9.2	143.1	3,546,314.2	2,149.4	1.2	1.1
01/03/2015 05:00	11.6	13.4	9.1	134.5	3,578,990.6	2,090.8	1.1	0.8
01/03/2015 06:00	12.0	13.2	9.2	154.7	3,493,921.0	2,219.7	1.3	1.1
01/03/2015 07:00	11.9	13.3	9.2	145.1	3,531,321.6	2,166.1	1.2	1.1
01/03/2015 08:00	11.2	13.6	9.1	119.6	3,443,479.9	1,936.2	1.0	0.8
01/03/2015 09:00	11.3	13.6	9.1	120.2	3,357,579.6	1,887.9	1.0	0.8
01/03/2015 10:00	11.2	13.6	9.1	114.9	3,355,267.6	1,886.6	1.0	0.8
01/03/2015 11:00	11.0	13.6	8.9	113.6	3,339,617.0	1,877.8	1.0	0.8
01/03/2015 12:00	11.2	13.8	9.3	90.1	2,623,122.8	1,360.0	1.0	0.5
01/03/2015 13:00	11.5	13.8	9.6	87.0	2,523,212.6	1,308.2	1.0	0.5
01/03/2015 14:00	11.6	13.8	9.6	87.1	2,519,355.1	1,306.2	1.0	0.5
01/03/2015 15:00	11.3	13.7	9.3	105.6	3,093,233.6	1,671.5	1.0	0.7
01/03/2015 16:00	11.2	13.4	8.8	124.3	3,469,950.2	2,027.1	1.0	0.8
01/03/2015 17:00	11.8	13.2	9.0	150.5	3,504,782.0	2,226.6	1.3	1.1
01/03/2015 18:00	12.2	13.0	9.1	178.2	3,499,325.9	2,350.9	1.5	1.4
01/03/2015 19:00	12.2	13.0	9.1	172.9	3,490,246.0	2,344.8	1.5	1.4
01/03/2015 20:00	12.2	13.0	9.1	177.1	3,491,139.1	2,345.4	1.5	1.4
01/03/2015 21:00	12.3	13.0	9.2	176.8	3,508,108.0	2,356.8	1.5	1.4
01/03/2015 22:00	12.1	13.1	9.2	163.2	3,501,922.5	2,301.5	1.4	1.2
01/03/2015 23:00	12.0	13.1	9.1	162.7	3,508,034.4	2,279.9	1.4	1.1
Average/Sum#:	11.8	13.3	9.2	140.5	3,355,773.4	2,047.6	1.2	1.0
Minimum:	11.0	13.0	8.8	87.0	2,519,355.1	1,306.2	1.0	0.5
Maximum:	12.4	13.8	9.6	178.2	3,578,990.6	2,356.8	1.5	1.4
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/04/2015 00:00	12.2	13.2	9.3	162.8	3,548,987.8	2,280.6	1.3	1.1
01/04/2015 01:00	11.3	13.5	9.0	130.7	3,535,195.0	2,039.4	1.1	0.8
01/04/2015 02:00	11.1	13.5	8.9	122.2	3,554,534.1	2,024.6	1.0	0.8
01/04/2015 03:00	11.1	13.5	8.9	122.2	3,555,236.4	2,025.0	1.0	0.8
01/04/2015 04:00	11.1	13.5	8.9	121.5	3,564,416.0	2,004.2	1.0	0.8
01/04/2015 05:00	11.0	13.5	8.8	121.1	3,580,778.0	2,013.4	1.0	0.8
01/04/2015 06:00	11.5	13.3	8.9	147.7	3,461,936.7	2,174.1	1.2	1.1
01/04/2015 07:00	12.1	13.1	9.2	165.3	3,509,530.4	2,306.5	1.4	1.2
01/04/2015 08:00	11.1	13.5	8.9	118.9	3,495,894.7	1,991.2	1.0	0.8
01/04/2015 09:00	10.9	13.6	8.8	115.8	3,444,724.8	1,936.9	1.0	0.8
01/04/2015 10:00	10.9	13.6	8.8	118.1	3,420,004.0	1,923.0	1.0	0.8
01/04/2015 11:00	10.8	13.6	8.7	114.1	3,372,163.1	1,896.1	1.0	0.8
01/04/2015 12:00	10.7	13.6	8.6	109.2	3,363,092.9	1,891.0	0.9	0.6
01/04/2015 13:00	10.7	13.6	8.6	114.3	3,406,309.8	1,915.3	1.0	0.8
01/04/2015 14:00	11.0	13.4	8.7	117.8	3,505,033.0	2,022.0	1.0	0.8
01/04/2015 15:00	11.0	13.4	8.7	122.9	3,488,951.0	2,038.2	1.0	0.8
01/04/2015 16:00	11.0	13.4	8.7	123.7	3,504,185.8	2,047.1	1.0	0.8
01/04/2015 17:00	11.9	13.1	9.0	161.7	3,464,035.1	2,276.6	1.4	1.1
01/04/2015 18:00	12.1	13.0	9.0	172.9	3,451,391.2	2,343.9	1.5	1.4
01/04/2015 19:00	12.1	13.0	9.0	175.7	3,464,790.9	2,353.0	1.5	1.4
01/04/2015 20:00	12.1	13.0	9.0	172.2	3,463,465.7	2,352.1	1.5	1.4
01/04/2015 21:00	11.9	13.1	9.0	161.8	3,468,104.9	2,304.6	1.4	1.2
01/04/2015 22:00	11.8	13.1	8.9	159.3	3,477,729.3	2,285.6	1.3	1.1
01/04/2015 23:00	10.8	13.6	8.7	113.4	3,440,990.0	1,934.8	0.9	0.6
Average/Sum#:	11.3	13.4	8.9	136.1	3,480,895.0	2,099.1	1.1	0.9
Minimum:	10.7	13.0	8.6	109.2	3,363,092.9	1,891.0	0.9	0.6
Maximum:	12.2	13.6	9.3	175.7	3,580,778.0	2,353.0	1.5	1.4
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/05/2015 00:00	10.9	13.6	8.8	113.6	3,365,049.2	1,892.1	1.0	0.8
01/05/2015 01:00	11.0	13.6	8.9	122.1	3,521,910.5	1,980.3	1.0	0.8
01/05/2015 02:00	11.0	13.6	8.9	112.8	3,358,468.8	1,888.4	1.0	0.8
01/05/2015 03:00	11.0	13.5	8.8	120.4	3,563,171.1	2,003.5	1.0	0.8
01/05/2015 04:00	10.9	13.6	8.8	116.1	3,436,899.5	1,932.5	1.0	0.8
01/05/2015 05:00	11.0	13.6	8.9	117.1	3,477,804.4	1,955.5	1.0	0.8
01/05/2015 06:00	11.2	13.5	8.9	128.8	3,513,841.5	2,078.4	1.1	0.8
01/05/2015 07:00	12.1	13.1	9.2	170.8	3,515,508.0	2,336.1	1.4	1.2
01/05/2015 08:00	11.9	13.1	9.0	155.8	3,524,289.7	2,316.2	1.3	1.2
01/05/2015 09:00	10.9	13.5	8.7	115.7	3,436,377.4	1,957.3	1.0	0.8
01/05/2015 10:00	10.7	13.6	8.6	108.1	3,354,556.2	1,886.2	0.9	0.6
01/05/2015 11:00	10.6	13.6	8.6	110.0	3,398,154.5	1,885.9	0.9	0.6
01/05/2015 12:00	10.4	13.6	8.4	106.3	3,405,181.8	1,889.8	0.9	0.6
01/05/2015 13:00	10.3	13.7	8.4	106.4	3,415,272.3	1,895.4	0.9	0.6
01/05/2015 14:00	10.9	13.4	8.6	117.1	3,445,129.4	2,012.6	1.0	0.8
01/05/2015 15:00	10.7	13.4	8.4	114.4	3,456,669.8	1,994.1	0.9	0.6
01/05/2015 16:00	10.7	13.4	8.4	117.4	3,475,599.1	2,030.4	1.0	0.8
01/05/2015 17:00	11.4	13.2	8.7	148.6	3,501,418.1	2,275.6	1.2	1.1
01/05/2015 18:00	11.6	13.1	8.8	160.5	3,463,171.2	2,351.9	1.4	1.2
01/05/2015 19:00	11.7	13.1	8.9	163.3	3,472,153.4	2,358.0	1.4	1.2
01/05/2015 20:00	11.7	13.1	8.9	167.6	3,475,098.4	2,360.0	1.4	1.2
01/05/2015 21:00	11.4	13.2	8.7	138.7	3,472,424.5	2,231.4	1.2	1.1
01/05/2015 22:00	10.9	13.4	8.6	123.1	3,485,438.7	2,061.6	1.0	0.8
01/05/2015 23:00	10.9	13.6	8.8	105.5	3,148,945.7	1,724.6	0.9	0.5
Average/Sum#:	11.1	13.4	8.7	127.5	3,445,105.6	2,054.1	1.1	0.9
Minimum:	10.3	13.1	8.4	105.5	3,148,945.7	1,724.6	0.9	0.5
Maximum:	12.1	13.7	9.2	170.8	3,563,171.1	2,360.0	1.4	1.2
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/06/2015 00:00	11.2	13.8	9.3	92.3	2,780,510.1	1,441.6	0.9	0.4
01/06/2015 01:00	11.0	13.8	9.1	104.8	3,195,195.0	1,656.6	0.9	0.5
01/06/2015 02:00	10.9	13.7	8.9	108.2	3,202,787.5	1,730.7	1.0	0.7
01/06/2015 03:00	10.9	13.6	8.8	111.0	3,358,824.5	1,888.6	0.9	0.6
01/06/2015 04:00	11.0	13.6	8.9	116.2	3,357,223.9	1,887.7	1.0	0.8
01/06/2015 05:00	11.0	13.6	8.9	117.3	3,463,398.8	1,947.4	1.0	0.8
01/06/2015 06:00	11.3	13.4	8.9	134.8	3,415,572.7	2,095.1	1.1	0.8
01/06/2015 07:00	12.0	13.1	9.1	166.0	3,505,425.5	2,329.4	1.4	1.2
01/06/2015 08:00	11.4	13.3	8.9	137.4	3,488,608.6	2,139.9	1.1	0.9
01/06/2015 09:00	10.8	13.6	8.7	109.4	3,355,979.0	1,887.0	0.9	0.6
01/06/2015 10:00	10.8	13.7	8.9	98.4	2,930,380.6	1,562.1	0.9	0.5
01/06/2015 11:00	11.4	13.8	9.5	86.9	2,517,040.6	1,305.0	1.0	0.5
01/06/2015 12:00	11.4	13.8	9.5	86.8	2,518,197.9	1,305.6	1.0	0.5
01/06/2015 13:00	10.7	13.8	8.9	91.4	2,834,904.1	1,449.1	0.9	0.4
01/06/2015 14:00	11.2	13.8	9.3	86.6	2,565,323.1	1,311.3	0.9	0.4
01/06/2015 15:00	10.7	13.7	8.8	100.1	3,114,186.8	1,614.6	0.9	0.5
01/06/2015 16:00	10.6	13.5	8.5	109.9	3,393,326.9	1,908.0	0.9	0.6
01/06/2015 17:00	11.0	13.4	8.7	127.7	3,407,027.7	2,040.1	1.1	0.8
01/06/2015 18:00	11.4	13.3	8.9	131.5	3,357,828.6	2,084.2	1.1	0.8
01/06/2015 19:00	11.5	13.3	8.9	136.8	3,396,655.8	2,108.3	1.2	1.1
01/06/2015 20:00	11.5	13.2	8.8	138.4	3,400,894.6	2,160.6	1.2	1.1
01/06/2015 21:00	11.3	13.3	8.8	137.7	3,457,318.9	2,171.2	1.2	1.1
01/06/2015 22:00	11.2	13.3	8.7	131.8	3,437,744.3	2,108.7	1.1	0.8
01/06/2015 23:00	10.5	13.7	8.6	108.4	3,426,444.0	1,901.6	0.9	0.6
Average/Sum#:	11.1	13.5	8.9	115.4	3,203,366.6	1,834.8	1.0	0.7
Minimum:	10.5	13.1	8.5	86.6	2,517,040.6	1,305.0	0.9	0.4
Maximum:	12.0	13.8	9.5	166.0	3,505,425.5	2,329.4	1.4	1.2
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/07/2015 00:00	10.7	13.6	8.6	114.5	3,415,133.7	1,945.2	1.0	0.8
01/07/2015 01:00	10.7	13.6	8.6	111.7	3,390,303.5	1,906.3	0.9	0.6
01/07/2015 02:00	10.8	13.6	8.7	113.3	3,420,181.9	1,923.1	0.9	0.6
01/07/2015 03:00	10.7	13.7	8.8	111.2	3,404,280.9	1,889.3	0.9	0.6
01/07/2015 04:00	11.0	13.5	8.8	119.0	3,455,109.7	1,993.2	1.0	0.8
01/07/2015 05:00	10.7	13.6	8.6	114.5	3,441,701.4	1,935.2	0.9	0.6
01/07/2015 06:00	11.3	13.4	8.9	141.7	3,444,102.3	2,112.6	1.2	1.1
01/07/2015 07:00	11.9	13.1	9.0	156.5	3,482,598.4	2,288.8	1.3	1.1
01/07/2015 08:00	11.2	13.4	8.8	126.4	3,495,582.5	2,067.6	1.0	0.8
01/07/2015 09:00	10.7	13.6	8.6	111.9	3,430,497.0	1,928.9	0.9	0.6
01/07/2015 10:00	10.4	13.7	8.5	106.4	3,397,253.6	1,885.4	0.9	0.6
01/07/2015 11:00	10.3	13.7	8.4	106.0	3,392,885.9	1,858.2	0.9	0.6
01/07/2015 12:00	11.2	13.8	9.3	87.3	2,566,692.6	1,312.0	1.0	0.5
01/07/2015 13:00	10.6	13.8	8.8	93.4	2,929,198.8	1,497.3	0.9	0.4
01/07/2015 14:00	10.5	13.8	8.7	96.1	3,053,229.5	1,560.7	0.9	0.5
01/07/2015 15:00	11.3	13.3	8.8	120.3	3,407,330.7	2,015.4	1.0	0.8
01/07/2015 16:00	11.2	13.4	8.8	120.2	3,371,658.1	1,994.3	1.0	0.8
01/07/2015 17:00	11.8	13.2	9.0	151.4	3,373,553.9	2,192.5	1.3	1.1
01/07/2015 18:00	11.3	13.3	8.8	127.1	3,388,510.2	2,078.5	1.1	0.8
01/07/2015 19:00	11.2	13.3	8.7	121.3	3,403,353.6	2,037.9	1.0	0.8
01/07/2015 20:00	11.3	13.3	8.8	124.2	3,407,862.7	2,040.6	1.0	0.8
01/07/2015 21:00	11.4	13.3	8.9	126.1	3,419,552.9	2,047.6	1.1	0.8
01/07/2015 22:00	10.8	13.5	8.6	115.5	3,370,517.4	1,944.4	1.0	0.8
01/07/2015 23:00	10.5	13.7	8.6	107.8	3,400,316.8	1,887.1	0.9	0.6
Average/Sum#:	11.0	13.5	8.8	117.7	3,344,225.3	1,930.9	1.0	0.7
Minimum:	10.3	13.1	8.4	87.3	2,566,692.6	1,312.0	0.9	0.4
Maximum:	11.9	13.8	9.3	156.5	3,495,582.5	2,288.8	1.3	1.1
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/08/2015 00:00	10.6	13.7	8.7	110.0	3,398,875.3	1,886.3	0.9	0.6
01/08/2015 01:00	10.7	13.7	8.8	111.0	3,397,614.0	1,885.6	0.9	0.6
01/08/2015 02:00	10.7	13.6	8.6	110.1	3,400,136.6	1,887.0	0.9	0.6
01/08/2015 03:00	10.5	13.6	8.5	107.7	3,402,479.0	1,888.3	0.9	0.6
01/08/2015 04:00	10.8	13.6	8.7	111.1	3,354,378.4	1,886.1	0.9	0.6
01/08/2015 05:00	10.8	13.6	8.7	110.3	3,343,351.8	1,879.9	0.9	0.6
01/08/2015 06:00	11.3	13.4	8.9	136.6	3,358,592.9	2,109.2	1.2	1.1
01/08/2015 07:00	12.0	13.1	9.1	169.1	3,450,651.7	2,318.2	1.4	1.2
01/08/2015 08:00	12.0	13.1	9.1	164.4	3,463,138.8	2,301.3	1.4	1.2
01/08/2015 09:00	11.8	13.2	9.0	148.9	3,476,003.7	2,233.7	1.3	1.1
01/08/2015 10:00	11.2	13.3	8.7	126.0	3,450,623.4	2,116.6	1.1	0.8
01/08/2015 11:00	10.9	13.4	8.6	119.3	3,426,266.0	2,026.6	1.0	0.8
01/08/2015 12:00	11.0	13.3	8.5	120.7	3,431,744.1	2,054.9	1.0	0.8
01/08/2015 13:00	11.4	13.2	8.7	137.0	3,385,662.9	2,126.2	1.2	1.1
01/08/2015 14:00	11.4	13.3	8.9	134.7	3,398,911.3	2,109.7	1.1	0.8
01/08/2015 15:00	12.0	13.0	9.0	166.7	3,352,292.0	2,276.6	1.5	1.4
01/08/2015 16:00	11.3	13.3	8.8	123.3	3,356,067.9	2,058.6	1.1	0.8
01/08/2015 17:00	11.3	13.3	8.8	129.7	3,405,628.0	2,089.0	1.1	0.8
01/08/2015 18:00	11.3	13.3	8.8	127.2	3,375,228.3	2,095.0	1.1	0.8
01/08/2015 19:00	11.1	13.3	8.6	122.9	3,411,369.7	2,042.7	1.0	0.8
01/08/2015 20:00	11.2	13.3	8.7	124.1	3,391,057.8	2,055.3	1.1	0.8
01/08/2015 21:00	11.5	13.2	8.8	139.0	3,407,955.9	2,140.2	1.2	1.1
01/08/2015 22:00	11.3	13.3	8.8	124.4	3,387,263.0	2,053.0	1.1	0.8
01/08/2015 23:00	10.7	13.5	8.5	114.5	3,365,663.8	1,941.6	1.0	0.8
Average/Sum#:	11.2	13.4	8.8	128.7	3,399,623.2	2,060.9	1.1	0.9
Minimum:	10.5	13.0	8.5	107.7	3,343,351.8	1,879.9	0.9	0.6
Maximum:	12.0	13.7	9.1	169.1	3,476,003.7	2,318.2	1.5	1.4
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/09/2015 00:00	10.7	13.5	8.5	114.9	3,431,534.8	1,979.6	1.0	0.8
01/09/2015 01:00	10.5	13.6	8.5	110.3	3,421,604.6	1,923.9	0.9	0.6
01/09/2015 02:00	10.4	13.7	8.5	107.1	3,401,938.5	1,888.0	0.9	0.6
01/09/2015 03:00	10.7	13.5	8.5	114.6	3,428,476.8	1,952.8	1.0	0.8
01/09/2015 04:00	10.6	13.6	8.6	109.4	3,418,155.3	1,897.0	0.9	0.6
01/09/2015 05:00	10.7	13.6	8.6	114.0	3,445,614.0	1,937.4	0.9	0.6
01/09/2015 06:00	10.8	13.5	8.6	125.1	3,397,199.5	1,984.6	1.1	0.8
01/09/2015 07:00	11.4	13.2	8.7	138.9	3,477,223.3	2,183.7	1.2	1.1
01/09/2015 08:00	11.9	13.1	9.0	163.9	3,430,556.9	2,304.7	1.4	1.2
01/09/2015 09:00	11.2	13.3	8.7	125.7	3,454,744.2	2,093.9	1.0	0.8
01/09/2015 10:00	11.6	13.1	8.8	152.2	3,459,719.9	2,248.5	1.3	1.1
01/09/2015 11:00	11.7	13.1	8.9	156.9	3,403,997.8	2,262.0	1.4	1.1
01/09/2015 12:00	10.4	13.6	8.4	109.4	3,407,199.0	1,915.8	0.9	0.6
01/09/2015 13:00	10.3	13.7	8.4	101.3	3,113,705.9	1,705.3	0.9	0.5
01/09/2015 14:00	10.5	13.8	8.7	87.9	2,723,589.5	1,392.2	0.9	0.4
01/09/2015 15:00	10.7	13.8	8.9	88.1	2,694,635.9	1,377.4	0.9	0.4
01/09/2015 16:00	10.8	13.6	8.7	101.9	3,100,194.2	1,697.9	0.9	0.5
01/09/2015 17:00	10.5	13.6	8.5	109.8	3,396,528.2	1,909.8	0.9	0.6
01/09/2015 18:00	10.5	13.6	8.5	108.8	3,265,176.2	1,812.1	0.9	0.5
01/09/2015 19:00	10.5	13.6	8.5	107.7	3,318,024.0	1,817.2	0.9	0.5
01/09/2015 20:00	10.3	13.7	8.4	109.2	3,422,660.0	1,899.5	0.9	0.6
01/09/2015 21:00	10.4	13.6	8.4	108.2	3,477,425.0	1,904.5	0.9	0.6
01/09/2015 22:00	10.6	13.5	8.5	112.0	3,459,486.1	1,945.2	0.9	0.6
01/09/2015 23:00	10.7	13.4	8.4	116.8	3,475,564.4	2,005.0	1.0	0.8
Average/Sum#:	10.8	13.5	8.6	116.4	3,334,373.1	1,918.3	1.0	0.7
Minimum:	10.3	13.1	8.4	87.9	2,694,635.9	1,377.4	0.9	0.4
Maximum:	11.9	13.8	9.0	163.9	3,477,425.0	2,304.7	1.4	1.2
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/10/2015 00:00	10.3	13.6	8.3	109.1	3,475,964.3	1,903.7	0.9	0.6
01/10/2015 01:00	10.2	13.7	8.4	105.7	3,470,750.6	1,875.5	0.9	0.6
01/10/2015 02:00	10.5	13.7	8.6	106.9	3,218,522.5	1,715.7	0.9	0.5
01/10/2015 03:00	11.2	13.8	9.3	89.5	2,626,015.9	1,361.5	1.0	0.5
01/10/2015 04:00	11.0	13.7	9.0	104.1	3,029,573.9	1,637.1	1.0	0.7
01/10/2015 05:00	10.6	13.6	8.6	115.4	3,429,252.1	1,928.2	1.0	0.8
01/10/2015 06:00	10.8	13.5	8.6	124.3	3,430,148.1	1,978.8	1.0	0.8
01/10/2015 07:00	10.9	13.4	8.6	117.5	3,458,403.3	1,995.1	1.0	0.8
01/10/2015 08:00	10.6	13.6	8.6	110.9	3,398,306.6	1,910.8	0.9	0.6
01/10/2015 09:00	10.5	13.6	8.5	110.0	3,354,556.2	1,886.2	0.9	0.6
01/10/2015 10:00	10.8	13.4	8.5	117.6	3,464,817.0	1,998.8	1.0	0.8
01/10/2015 11:00	11.5	13.1	8.7	159.7	3,439,233.3	2,260.3	1.4	1.1
01/10/2015 12:00	11.5	13.1	8.7	147.6	3,370,153.4	2,214.9	1.3	1.1
01/10/2015 13:00	10.6	13.5	8.5	114.4	3,413,333.6	1,969.1	1.0	0.8
01/10/2015 14:00	10.9	13.3	8.5	120.4	3,394,335.4	2,032.5	1.0	0.8
01/10/2015 15:00	10.2	13.7	8.4	106.8	3,397,974.3	1,885.8	0.9	0.6
01/10/2015 16:00	10.5	13.5	8.4	110.1	3,424,628.0	1,925.6	0.9	0.6
01/10/2015 17:00	11.1	13.3	8.6	129.0	3,411,007.9	2,092.3	1.1	0.8
01/10/2015 18:00	10.9	13.4	8.6	118.8	3,416,460.2	2,020.8	1.0	0.8
01/10/2015 19:00	11.1	13.3	8.6	128.0	3,456,064.2	2,094.7	1.1	0.8
01/10/2015 20:00	11.8	13.0	8.8	167.7	3,395,878.0	2,306.2	1.5	1.4
01/10/2015 21:00	11.3	13.2	8.7	136.3	3,384,681.9	2,150.3	1.2	1.1
01/10/2015 22:00	11.0	13.3	8.5	124.5	3,410,691.7	2,067.2	1.1	0.8
01/10/2015 23:00	10.5	13.6	8.5	112.6	3,397,225.9	1,935.0	0.9	0.6
Average/Sum#:	10.8	13.5	8.6	120.3	3,361,165.8	1,964.4	1.0	0.8
Minimum:	10.2	13.0	8.3	89.5	2,626,015.9	1,361.5	0.9	0.5
Maximum:	11.8	13.8	9.3	167.7	3,475,964.3	2,306.2	1.5	1.4
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/11/2015 00:00	10.5	13.5	8.4	112.5	3,413,202.5	1,944.1	0.9	0.6
01/11/2015 01:00	10.6	13.5	8.5	115.2	3,427,774.6	1,952.4	1.0	0.8
01/11/2015 02:00	10.6	13.5	8.5	116.7	3,447,789.2	1,963.8	1.0	0.8
01/11/2015 03:00	10.5	13.6	8.5	109.5	3,410,407.3	1,892.7	0.9	0.6
01/11/2015 04:00	10.5	13.6	8.5	109.2	3,404,461.1	1,889.4	0.9	0.6
01/11/2015 05:00	10.6	13.6	8.6	111.3	3,413,601.5	1,919.4	0.9	0.6
01/11/2015 06:00	10.6	13.6	8.6	113.5	3,415,024.3	1,920.2	0.9	0.6
01/11/2015 07:00	10.9	13.5	8.7	116.0	3,445,858.0	1,962.7	1.0	0.8
01/11/2015 08:00	11.3	13.3	8.8	140.1	3,489,260.7	2,140.3	1.2	1.1
01/11/2015 09:00	11.9	13.0	8.9	168.8	3,448,716.7	2,316.9	1.5	1.4
01/11/2015 10:00	11.8	13.0	8.8	164.0	3,428,324.2	2,303.2	1.4	1.2
01/11/2015 11:00	11.6	13.2	8.9	150.6	3,408,328.0	2,215.1	1.3	1.1
01/11/2015 12:00	10.9	13.4	8.6	121.5	3,411,388.3	2,017.8	1.0	0.8
01/11/2015 13:00	11.0	13.4	8.7	122.2	3,442,219.4	2,010.9	1.0	0.8
01/11/2015 14:00	10.6	13.5	8.5	112.1	3,401,263.9	1,937.3	0.9	0.6
01/11/2015 15:00	11.1	13.4	8.7	122.3	3,423,391.9	2,024.9	1.0	0.8
01/11/2015 16:00	10.5	13.6	8.5	111.6	3,412,178.7	1,918.6	0.9	0.6
01/11/2015 17:00	11.4	13.2	8.7	140.2	3,417,669.3	2,146.3	1.2	1.1
01/11/2015 18:00	11.4	13.2	8.7	141.3	3,393,181.8	2,155.7	1.2	1.1
01/11/2015 19:00	11.7	13.1	8.9	160.8	3,397,225.9	2,257.5	1.4	1.1
01/11/2015 20:00	11.4	13.2	8.7	138.4	3,404,200.1	2,162.7	1.2	1.1
01/11/2015 21:00	11.5	13.2	8.8	144.5	3,412,356.6	2,192.8	1.2	1.1
01/11/2015 22:00	10.7	13.5	8.5	115.3	3,429,974.7	1,978.7	1.0	0.8
01/11/2015 23:00	10.3	13.6	8.3	107.6	3,381,216.9	1,876.5	0.9	0.6
Average/Sum#:	11.0	13.4	8.6	127.7	3,419,959.0	2,045.8	1.1	0.9
Minimum:	10.3	13.0	8.3	107.6	3,381,216.9	1,876.5	0.9	0.6
Maximum:	11.9	13.6	8.9	168.8	3,489,260.7	2,316.9	1.5	1.4
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/12/2015 00:00	10.8	13.5	8.6	115.5	3,444,535.7	1,987.1	1.0	0.8
01/12/2015 01:00	10.5	13.6	8.5	111.4	3,421,960.3	1,924.1	0.9	0.6
01/12/2015 02:00	10.6	13.6	8.6	115.9	3,416,091.4	1,920.8	1.0	0.8
01/12/2015 03:00	10.8	13.5	8.6	115.7	3,463,765.9	1,972.9	1.0	0.8
01/12/2015 04:00	10.6	13.5	8.5	114.4	3,476,559.5	1,954.8	0.9	0.6
01/12/2015 05:00	10.8	13.5	8.6	114.7	3,410,569.0	1,942.6	1.0	0.8
01/12/2015 06:00	10.9	13.4	8.6	123.4	3,475,770.3	2,030.5	1.0	0.8
01/12/2015 07:00	10.9	13.4	8.6	118.9	3,487,178.5	2,011.7	1.0	0.8
01/12/2015 08:00	10.9	13.4	8.6	118.7	3,489,952.0	2,013.3	1.0	0.8
01/12/2015 09:00	11.2	13.2	8.6	133.4	3,491,869.2	2,141.9	1.1	0.9
01/12/2015 10:00	10.9	13.4	8.6	123.3	3,443,100.3	2,061.7	1.0	0.8
01/12/2015 11:00	10.4	13.6	8.4	109.8	3,413,290.3	1,894.3	0.9	0.6
01/12/2015 12:00	10.3	13.6	8.3	106.0	3,392,208.3	1,882.6	0.9	0.6
01/12/2015 13:00	10.1	13.7	8.3	105.3	3,388,424.4	1,880.5	0.9	0.6
01/12/2015 14:00	10.1	13.7	8.3	105.2	3,395,812.1	1,884.6	0.9	0.6
01/12/2015 15:00	10.0	13.7	8.2	105.7	3,395,631.9	1,884.5	0.9	0.6
01/12/2015 16:00	10.5	13.6	8.5	114.3	3,407,021.2	1,915.7	1.0	0.8
01/12/2015 17:00	10.9	13.4	8.6	123.9	3,428,525.1	2,002.9	1.0	0.8
01/12/2015 18:00	12.0	13.1	9.1	167.9	3,365,955.8	2,261.3	1.5	1.4
01/12/2015 19:00	12.1	13.0	9.0	172.7	3,391,460.5	2,303.2	1.5	1.4
01/12/2015 20:00	12.1	13.0	9.0	176.2	3,366,598.7	2,310.9	1.6	1.4
01/12/2015 21:00	11.8	13.1	8.9	154.8	3,401,650.2	2,235.6	1.3	1.1
01/12/2015 22:00	11.5	13.2	8.8	136.4	3,410,344.4	2,141.7	1.2	1.1
01/12/2015 23:00	10.8	13.5	8.6	115.2	3,453,407.4	1,967.0	0.9	0.6
Average/Sum#:	10.9	13.4	8.6	124.9	3,426,320.1	2,021.9	1.1	0.8
Minimum:	10.0	13.0	8.2	105.2	3,365,955.8	1,880.5	0.9	0.6
Maximum:	12.1	13.7	9.1	176.2	3,491,869.2	2,310.9	1.6	1.4
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/13/2015 00:00	11.2	13.3	8.7	126.6	3,444,436.3	2,062.5	1.1	0.8
01/13/2015 01:00	11.2	13.4	8.8	124.2	3,466,841.5	2,050.6	1.0	0.8
01/13/2015 02:00	11.2	13.4	8.8	124.2	3,441,481.8	2,035.6	1.0	0.8
01/13/2015 03:00	11.1	13.4	8.7	123.7	3,474,871.0	2,004.6	1.0	0.8
01/13/2015 04:00	10.9	13.5	8.7	118.3	3,442,697.8	1,960.9	1.0	0.8
01/13/2015 05:00	10.6	13.7	8.7	110.8	3,407,344.1	1,891.0	0.9	0.6
01/13/2015 06:00	10.8	13.6	8.7	120.6	3,412,675.8	1,943.8	1.0	0.8
01/13/2015 07:00	11.2	13.4	8.8	124.8	3,496,482.8	2,042.6	1.0	0.8
01/13/2015 08:00	10.9	13.5	8.7	118.8	3,451,300.6	1,965.8	1.0	0.8
01/13/2015 09:00	10.7	13.6	8.6	116.5	3,447,345.7	1,913.2	1.0	0.8
01/13/2015 10:00	11.3	13.4	8.9	126.9	3,448,244.4	2,039.6	1.1	0.8
01/13/2015 11:00	11.4	13.4	9.0	130.7	3,412,037.8	2,043.1	1.1	0.8
01/13/2015 12:00	11.0	13.5	8.8	117.6	3,430,056.9	1,953.7	1.0	0.8
01/13/2015 13:00	11.2	13.5	8.9	124.5	3,425,467.8	1,976.1	1.0	0.8
01/13/2015 14:00	11.0	13.5	8.8	119.3	3,419,698.5	1,947.8	1.0	0.8
01/13/2015 15:00	10.8	13.6	8.7	118.7	3,418,403.4	1,922.1	1.0	0.8
01/13/2015 16:00	10.8	13.6	8.7	115.9	3,422,316.0	1,924.3	1.0	0.8
01/13/2015 17:00	11.7	13.2	9.0	150.6	3,440,121.4	2,160.4	1.3	1.1
01/13/2015 18:00	12.3	13.0	9.2	176.1	3,386,306.7	2,299.7	1.5	1.4
01/13/2015 19:00	12.3	13.0	9.2	174.5	3,388,662.7	2,301.3	1.5	1.4
01/13/2015 20:00	12.3	13.0	9.2	176.9	3,389,251.7	2,301.7	1.6	1.4
01/13/2015 21:00	12.0	13.1	9.1	155.8	3,430,792.8	2,229.7	1.3	1.1
01/13/2015 22:00	11.7	13.2	9.0	145.9	3,436,299.8	2,158.0	1.2	1.1
01/13/2015 23:00	10.9	13.7	8.9	104.6	3,075,014.3	1,639.2	1.0	0.7
Average/Sum#:	11.3	13.4	8.9	131.1	3,417,006.3	2,032.0	1.1	0.9
Minimum:	10.6	13.0	8.6	104.6	3,075,014.3	1,639.2	0.9	0.6
Maximum:	12.3	13.7	9.2	176.9	3,496,482.8	2,301.7	1.6	1.4
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/14/2015 00:00	11.3	13.8	9.4	87.6	2,629,686.1	1,344.2	0.9	0.4
01/14/2015 01:00	10.9	13.8	9.1	105.2	3,045,908.4	1,579.2	1.0	0.6
01/14/2015 02:00	11.0	13.7	9.0	107.4	3,218,334.9	1,715.6	0.9	0.5
01/14/2015 03:00	11.2	13.5	8.9	122.0	3,449,018.2	1,964.5	1.0	0.8
01/14/2015 04:00	11.2	13.5	8.9	126.0	3,551,611.0	1,997.0	1.0	0.8
01/14/2015 05:00	11.1	13.6	9.0	120.1	3,399,729.4	1,911.6	1.0	0.8
01/14/2015 06:00	11.2	13.5	8.9	143.0	3,457,454.2	2,019.8	1.2	1.0
01/14/2015 07:00	11.9	13.1	9.0	163.0	3,509,073.9	2,306.2	1.4	1.2
01/14/2015 08:00	11.5	13.2	8.8	140.3	3,493,643.3	2,168.5	1.2	1.1
01/14/2015 09:00	10.8	13.4	8.5	117.9	3,513,978.1	2,001.5	1.0	0.8
01/14/2015 10:00	10.6	13.6	8.6	110.3	3,412,712.3	1,918.9	0.9	0.6
01/14/2015 11:00	10.6	13.6	8.6	110.8	3,355,267.6	1,886.6	0.9	0.6
01/14/2015 12:00	10.6	13.6	8.6	111.2	3,396,532.8	1,885.0	0.9	0.6
01/14/2015 13:00	10.6	13.6	8.6	110.1	3,400,316.8	1,887.1	0.9	0.6
01/14/2015 14:00	10.4	13.6	8.4	110.6	3,404,821.5	1,889.6	0.9	0.6
01/14/2015 15:00	10.5	13.6	8.5	110.2	3,417,614.8	1,896.7	0.9	0.6
01/14/2015 16:00	10.7	13.5	8.5	118.3	3,430,232.5	1,953.8	1.0	0.8
01/14/2015 17:00	11.2	13.2	8.6	137.8	3,475,760.2	2,157.4	1.2	1.1
01/14/2015 18:00	12.0	13.0	9.0	176.6	3,402,873.9	2,335.8	1.5	1.4
01/14/2015 19:00	12.1	13.0	9.0	174.9	3,442,998.0	2,338.2	1.5	1.4
01/14/2015 20:00	12.1	13.0	9.0	177.9	3,442,850.7	2,338.1	1.5	1.4
01/14/2015 21:00	12.1	13.0	9.0	174.7	3,428,862.0	2,328.6	1.5	1.4
01/14/2015 22:00	11.4	13.3	8.9	137.7	3,459,426.8	2,122.0	1.2	1.1
01/14/2015 23:00	10.8	13.6	8.7	114.6	3,409,155.3	1,916.9	1.0	0.8
Average/Sum#:	11.2	13.4	8.8	129.5	3,381,160.9	1,994.3	1.1	0.9
Minimum:	10.4	13.0	8.4	87.6	2,629,686.1	1,344.2	0.9	0.4
Maximum:	12.1	13.8	9.4	177.9	3,551,611.0	2,338.2	1.5	1.4
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/15/2015 00:00	10.9	13.5	8.7	116.9	3,452,194.4	1,941.1	1.0	0.8
01/15/2015 01:00	10.9	13.6	8.8	113.8	3,351,710.6	1,884.6	1.0	0.8
01/15/2015 02:00	11.0	13.6	8.9	115.8	3,350,465.7	1,883.9	1.0	0.8
01/15/2015 03:00	11.0	13.6	8.9	114.8	3,348,509.4	1,882.8	1.0	0.8
01/15/2015 04:00	11.1	13.6	9.0	117.5	3,353,311.3	1,885.5	1.0	0.8
01/15/2015 05:00	11.1	13.6	9.0	119.2	3,346,908.8	1,881.9	1.0	0.8
01/15/2015 06:00	11.3	13.5	9.0	131.2	3,445,129.4	2,012.6	1.1	0.8
01/15/2015 07:00	12.0	13.2	9.2	160.0	3,513,351.6	2,257.7	1.3	1.1
01/15/2015 08:00	11.3	13.4	8.9	128.6	3,463,787.8	2,023.5	1.1	0.8
01/15/2015 09:00	11.1	13.7	9.1	102.4	2,927,422.2	1,581.9	1.0	0.6
01/15/2015 10:00	11.5	13.8	9.6	87.0	2,517,426.3	1,305.2	1.0	0.5
01/15/2015 11:00	11.6	13.8	9.6	87.2	2,518,583.6	1,305.8	1.0	0.5
01/15/2015 12:00	11.6	13.8	9.6	87.2	2,520,512.4	1,306.8	1.0	0.5
01/15/2015 13:00	11.6	13.8	9.6	87.1	2,512,411.6	1,302.6	1.0	0.5
01/15/2015 14:00	11.6	13.8	9.6	87.2	2,511,832.9	1,302.3	1.0	0.5
01/15/2015 15:00	11.3	13.8	9.4	87.4	2,574,325.0	1,334.7	1.0	0.5
01/15/2015 16:00	10.8	13.6	8.7	114.8	3,402,298.8	1,888.2	1.0	0.8
01/15/2015 17:00	11.7	13.2	9.0	161.1	3,488,989.0	2,293.0	1.4	1.1
01/15/2015 18:00	12.0	13.1	9.1	188.8	3,469,159.9	2,381.3	1.6	1.4
01/15/2015 19:00	11.7	13.2	9.0	149.8	3,480,184.4	2,261.8	1.3	1.1
01/15/2015 20:00	11.2	13.3	8.7	128.8	3,489,722.3	2,115.1	1.1	0.8
01/15/2015 21:00	11.3	13.3	8.8	133.4	3,497,575.1	2,145.4	1.1	0.9
01/15/2015 22:00	11.4	13.3	8.9	141.9	3,499,834.7	2,197.9	1.2	1.1
01/15/2015 23:00	10.8	13.6	8.7	112.7	3,372,997.6	1,921.2	0.9	0.6
Average/Sum#:	11.3	13.5	9.1	119.8	3,183,693.5	1,845.7	1.1	0.8
Minimum:	10.8	13.1	8.7	87.0	2,511,832.9	1,302.3	0.9	0.5
Maximum:	12.0	13.8	9.6	188.8	3,513,351.6	2,381.3	1.6	1.4
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/16/2015 00:00	10.8	13.6	8.7	111.3	3,352,244.2	1,884.9	0.9	0.6
01/16/2015 01:00	10.8	13.6	8.7	110.8	3,350,643.6	1,884.0	0.9	0.6
01/16/2015 02:00	10.7	13.6	8.6	110.7	3,348,331.5	1,882.7	0.9	0.6
01/16/2015 03:00	10.7	13.7	8.8	103.4	3,014,399.2	1,628.9	1.0	0.7
01/16/2015 04:00	11.1	13.8	9.2	86.8	2,551,372.6	1,322.8	1.0	0.5
01/16/2015 05:00	10.7	13.6	8.6	109.6	3,367,342.5	1,868.8	0.9	0.6
01/16/2015 06:00	10.8	13.5	8.6	126.9	3,405,929.6	1,989.7	1.1	0.8
01/16/2015 07:00	11.5	13.2	8.8	153.0	3,480,011.7	2,287.1	1.3	1.1
01/16/2015 08:00	10.7	13.5	8.5	115.4	3,454,636.4	1,967.7	1.0	0.8
01/16/2015 09:00	10.5	13.6	8.5	107.4	3,419,178.8	1,872.6	0.9	0.6
01/16/2015 10:00	10.5	13.7	8.6	112.3	3,451,497.2	1,890.3	0.9	0.6
01/16/2015 11:00	10.3	13.7	8.4	102.8	3,235,781.0	1,724.9	0.9	0.5
01/16/2015 12:00	10.2	13.9	8.6	87.7	2,832,525.3	1,427.2	0.9	0.4
01/16/2015 13:00	10.4	13.9	8.8	85.3	2,656,878.9	1,358.1	0.9	0.4
01/16/2015 14:00	10.5	13.9	8.9	85.4	2,669,790.7	1,364.7	0.9	0.4
01/16/2015 15:00	10.4	13.9	8.8	85.3	2,674,485.8	1,367.1	0.9	0.4
01/16/2015 16:00	23.3	15.2	24.1	163.6	2,091,505.6	901.1	2.2	0.7
01/16/2015 17:00	47.0	16.3	60.3	239.1	1,931,199.6	620.5	3.0	0.7
01/16/2015 18:00	26.7	13.8	22.2	141.3	2,506,242.3	1,281.1	1.6	0.8
01/16/2015 19:00	11.4	13.8	9.5	87.0	2,511,447.2	1,302.1	1.0	0.5
01/16/2015 20:00	11.5	13.8	9.6	87.0	2,506,046.6	1,299.3	1.0	0.5
01/16/2015 21:00	11.3	13.8	9.4	87.3	2,552,337.0	1,323.3	1.0	0.5
01/16/2015 22:00	10.8	13.7	8.9	96.2	2,943,490.9	1,526.1	0.9	0.5
01/16/2015 23:00	11.2	13.8	9.3	86.7	2,527,455.9	1,310.4	1.0	0.5
Average/Sum#:	13.5	13.9	12.2	111.8	2,909,782.3	1,553.6	1.1	0.6
Minimum:	10.2	13.2	8.4	85.3	1,931,199.6	620.5	0.9	0.4
Maximum:	47.0	16.3	60.3	239.1	3,480,011.7	2,287.1	3.0	1.1
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/17/2015 00:00	11.4	13.8	9.5	87.4	2,565,259.8	1,330.0	1.0	0.5
01/17/2015 01:00	10.6	13.8	8.8	97.4	2,980,330.4	1,545.2	0.9	0.5
01/17/2015 02:00	10.8	13.8	9.0	90.8	2,762,572.6	1,432.3	0.9	0.4
01/17/2015 03:00	10.7	13.8	8.9	101.9	3,093,163.2	1,603.7	0.9	0.5
01/17/2015 04:00	11.4	13.8	9.5	87.6	2,548,865.2	1,321.5	1.0	0.5
01/17/2015 05:00	11.5	13.8	9.6	88.7	2,621,194.0	1,359.0	0.9	0.4
01/17/2015 06:00	10.8	13.5	8.6	134.9	3,406,399.8	1,965.1	1.1	0.8
01/17/2015 07:00	11.1	13.4	8.7	122.9	3,472,251.6	2,053.8	1.0	0.8
01/17/2015 08:00	10.7	13.5	8.5	118.5	3,480,795.9	1,982.6	1.0	0.8
01/17/2015 09:00	10.3	13.7	8.4	108.8	3,502,074.6	1,918.0	0.9	0.6
01/17/2015 10:00	10.3	13.7	8.4	106.0	3,448,210.6	1,888.5	0.9	0.6
01/17/2015 11:00	10.2	13.7	8.4	106.3	3,430,864.6	1,879.0	0.9	0.6
01/17/2015 12:00	10.1	13.7	8.3	104.4	3,432,507.9	1,879.9	0.9	0.6
01/17/2015 13:00	10.4	13.7	8.5	95.4	2,967,336.3	1,581.8	0.9	0.5
01/17/2015 14:00	11.1	13.8	9.2	84.2	2,518,583.6	1,305.8	0.9	0.4
01/17/2015 15:00	11.1	13.8	9.2	84.2	2,519,162.2	1,306.1	0.9	0.4
01/17/2015 16:00	10.4	13.7	8.5	97.4	3,054,186.5	1,650.4	0.9	0.5
01/17/2015 17:00	10.5	13.5	8.4	114.3	3,450,256.1	1,990.4	0.9	0.6
01/17/2015 18:00	11.2	13.2	8.6	144.7	3,476,799.3	2,259.6	1.2	1.1
01/17/2015 19:00	11.1	13.2	8.5	136.5	3,464,958.5	2,201.3	1.1	0.9
01/17/2015 20:00	10.8	13.4	8.5	119.6	3,477,154.5	2,056.7	1.0	0.8
01/17/2015 21:00	10.8	13.3	8.4	121.2	3,505,893.4	2,099.3	1.0	0.8
01/17/2015 22:00	10.8	13.3	8.4	123.5	3,493,201.2	2,091.7	1.0	0.8
01/17/2015 23:00	10.9	13.3	8.5	124.1	3,475,203.1	2,106.3	1.0	0.8
Average/Sum#:	10.8	13.6	8.7	108.4	3,172,801.0	1,783.7	1.0	0.6
Minimum:	10.1	13.2	8.3	84.2	2,518,583.6	1,305.8	0.9	0.4
Maximum:	11.5	13.8	9.6	144.7	3,505,893.4	2,259.6	1.2	1.1
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/18/2015 00:00	10.6	13.4	8.3	115.3	3,496,365.8	2,017.0	0.9	0.6
01/18/2015 01:00	10.5	13.6	8.5	109.0	3,246,076.4	1,801.5	1.0	0.7
01/18/2015 02:00	20.7	14.9	20.4	142.3	2,138,098.0	952.4	1.9	0.7
01/18/2015 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/18/2015 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/18/2015 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/18/2015 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/18/2015 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/18/2015 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/18/2015 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/18/2015 10:00	38.1	17.3	62.4	19.5	1,959,132.8	457.8	0.0	0.0
01/18/2015 11:00	51.6	15.1	52.5	229.5	2,233,122.7	929.5	2.7	0.9
01/18/2015 12:00	11.1	13.8	9.2	90.1	2,574,710.7	1,334.9	1.0	0.5
01/18/2015 13:00	10.8	13.8	9.0	85.9	2,559,473.5	1,327.0	0.9	0.4
01/18/2015 14:00	10.6	13.8	8.8	95.9	2,975,508.4	1,542.7	0.9	0.5
01/18/2015 15:00	10.5	13.8	8.7	95.7	2,868,269.0	1,487.1	0.9	0.4
01/18/2015 16:00	10.6	13.8	8.8	90.7	2,772,602.2	1,437.5	0.9	0.4
01/18/2015 17:00	10.6	13.5	8.5	112.3	3,474,247.4	1,953.5	0.9	0.6
01/18/2015 18:00	10.7	13.4	8.4	114.5	3,493,245.6	2,015.2	0.9	0.6
01/18/2015 19:00	10.7	13.4	8.4	115.6	3,502,086.2	2,020.3	0.9	0.6
01/18/2015 20:00	10.6	13.5	8.5	114.8	3,510,291.2	1,999.4	0.9	0.6
01/18/2015 21:00	10.3	13.6	8.3	110.1	3,506,267.0	1,945.9	0.9	0.6
01/18/2015 22:00	10.4	13.8	8.6	95.2	2,852,453.1	1,478.9	0.9	0.4
01/18/2015 23:00	11.0	13.8	9.1	86.1	2,520,512.4	1,306.8	1.0	0.5
Average/Sum#:	15.3	14.0	15.1	107.2	2,922,497.8	1,529.8	1.0	0.5
Minimum:	10.3	13.4	8.3	19.5	1,959,132.8	457.8	0.0	0.0
Maximum:	51.6	17.3	62.4	229.5	3,510,291.2	2,020.3	2.7	0.9
%SI	29.2	29.2	29.2	29.2	29.2	29.2	29.2	29.2

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/19/2015 00:00	10.6	13.7	8.7	94.7	2,915,330.9	1,511.5	0.9	0.5
01/19/2015 01:00	10.8	13.8	9.0	87.8	2,616,372.1	1,356.5	0.9	0.4
01/19/2015 02:00	11.0	13.8	9.1	86.3	2,524,177.0	1,308.7	1.0	0.5
01/19/2015 03:00	10.7	13.7	8.8	97.0	3,048,030.1	1,580.3	0.9	0.5
01/19/2015 04:00	10.6	13.6	8.6	112.1	3,397,950.9	1,910.6	0.9	0.6
01/19/2015 05:00	10.9	13.4	8.6	118.2	3,486,831.8	2,011.5	1.0	0.8
01/19/2015 06:00	10.9	13.4	8.6	123.3	3,494,632.4	2,016.0	1.0	0.8
01/19/2015 07:00	11.0	13.4	8.7	119.6	3,503,472.9	2,021.1	1.0	0.8
01/19/2015 08:00	10.8	13.5	8.6	115.5	3,433,217.2	1,955.5	1.0	0.8
01/19/2015 09:00	10.6	13.6	8.6	110.3	3,391,014.9	1,906.7	0.9	0.6
01/19/2015 10:00	10.5	13.6	8.5	110.7	3,429,963.5	1,928.6	0.9	0.6
01/19/2015 11:00	10.5	13.6	8.5	108.0	3,373,763.7	1,897.0	0.9	0.6
01/19/2015 12:00	10.4	13.6	8.4	109.0	3,426,804.3	1,901.8	0.9	0.6
01/19/2015 13:00	10.4	13.7	8.5	108.3	3,414,191.2	1,894.8	0.9	0.6
01/19/2015 14:00	10.3	13.7	8.4	109.5	3,417,074.2	1,896.4	0.9	0.6
01/19/2015 15:00	10.6	13.6	8.6	112.0	3,412,000.9	1,918.5	0.9	0.6
01/19/2015 16:00	11.0	13.4	8.7	118.5	3,422,858.7	1,949.6	1.0	0.8
01/19/2015 17:00	10.8	13.4	8.5	115.9	3,426,370.0	1,951.6	1.0	0.8
01/19/2015 18:00	11.0	13.4	8.7	116.0	3,471,490.8	1,977.3	0.9	0.6
01/19/2015 19:00	11.2	13.4	8.8	123.6	3,438,624.6	2,008.8	1.0	0.8
01/19/2015 20:00	11.2	13.4	8.8	123.1	3,467,382.5	2,025.6	1.0	0.8
01/19/2015 21:00	11.0	13.4	8.7	122.4	3,489,806.9	2,038.7	1.0	0.8
01/19/2015 22:00	10.7	13.5	8.5	116.2	3,432,514.9	1,955.1	1.0	0.8
01/19/2015 23:00	10.7	13.6	8.6	110.9	3,375,186.5	1,897.8	0.9	0.6
Average/Sum#:	10.8	13.6	8.6	111.2	3,325,377.6	1,867.5	0.9	0.7
Minimum:	10.3	13.4	8.4	86.3	2,524,177.0	1,308.7	0.9	0.4
Maximum:	11.2	13.8	9.1	123.6	3,503,472.9	2,038.7	1.0	0.8
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/20/2015 00:00	10.9	13.5	8.7	118.9	3,473,597.6	1,978.5	1.0	0.8
01/20/2015 01:00	10.9	13.6	8.8	115.0	3,340,328.4	1,878.2	1.0	0.8
01/20/2015 02:00	11.0	13.6	8.9	115.3	3,347,442.3	1,882.2	1.0	0.8
01/20/2015 03:00	11.1	13.6	9.0	114.7	3,346,730.9	1,881.8	1.0	0.8
01/20/2015 04:00	11.0	13.6	8.9	114.7	3,349,576.5	1,883.4	1.0	0.8
01/20/2015 05:00	11.0	13.6	8.9	114.9	3,345,841.7	1,881.3	1.0	0.8
01/20/2015 06:00	11.3	13.4	8.9	127.2	3,474,058.5	2,029.5	1.0	0.8
01/20/2015 07:00	11.4	13.3	8.9	132.2	3,540,817.9	2,068.5	1.1	0.8
01/20/2015 08:00	11.5	13.3	8.9	129.9	3,516,208.4	2,079.8	1.1	0.8
01/20/2015 09:00	11.4	13.3	8.9	129.3	3,511,474.6	2,077.0	1.1	0.8
01/20/2015 10:00	11.1	13.4	8.7	123.4	3,506,411.1	2,048.4	1.0	0.8
01/20/2015 11:00	11.2	13.3	8.7	126.2	3,484,424.3	2,061.0	1.0	0.8
01/20/2015 12:00	11.2	13.3	8.7	126.9	3,450,949.4	2,066.4	1.1	0.8
01/20/2015 13:00	10.9	13.4	8.6	121.7	3,448,582.5	2,039.8	1.0	0.8
01/20/2015 14:00	11.0	13.4	8.7	121.0	3,447,230.0	2,039.0	1.0	0.8
01/20/2015 15:00	11.0	13.3	8.5	121.0	3,428,237.0	2,052.8	1.0	0.8
01/20/2015 16:00	10.5	13.6	8.5	111.6	3,399,195.9	1,911.3	0.9	0.6
01/20/2015 17:00	10.6	13.5	8.5	112.7	3,403,546.3	1,938.6	0.9	0.6
01/20/2015 18:00	11.1	13.3	8.6	125.6	3,459,132.6	2,071.3	1.0	0.8
01/20/2015 19:00	11.1	13.3	8.6	125.6	3,441,050.0	2,085.6	1.1	0.8
01/20/2015 20:00	11.1	13.4	8.7	125.1	3,454,499.8	2,043.3	1.0	0.8
01/20/2015 21:00	11.2	13.3	8.7	125.3	3,491,525.0	2,065.2	1.0	0.8
01/20/2015 22:00	11.0	13.4	8.7	124.5	3,500,006.0	2,019.1	1.0	0.8
01/20/2015 23:00	10.5	13.7	8.6	108.3	3,390,406.5	1,881.6	0.9	0.6
Average/Sum#:	11.0	13.4	8.7	121.3	3,439,636.4	1,998.5	1.0	0.8
Minimum:	10.5	13.3	8.5	108.3	3,340,328.4	1,878.2	0.9	0.6
Maximum:	11.5	13.7	9.0	132.2	3,540,817.9	2,085.6	1.1	0.8
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/21/2015 00:00	10.6	13.7	8.7	112.7	3,459,896.4	1,894.9	0.9	0.6
01/21/2015 01:00	10.6	13.8	8.8	112.1	3,486,665.5	1,884.1	0.9	0.6
01/21/2015 02:00	10.9	13.7	8.9	118.0	3,503,900.5	1,919.0	1.0	0.8
01/21/2015 03:00	10.8	13.7	8.9	113.3	3,426,482.4	1,876.6	0.9	0.6
01/21/2015 04:00	10.9	13.7	8.9	117.1	3,452,227.6	1,890.7	1.0	0.8
01/21/2015 05:00	11.1	13.6	9.0	114.9	3,356,156.8	1,887.1	1.0	0.8
01/21/2015 06:00	11.2	13.6	9.1	146.3	3,457,094.3	1,969.1	1.2	1.0
01/21/2015 07:00	11.5	13.4	9.0	126.5	3,521,500.8	2,031.5	1.0	0.8
01/21/2015 08:00	11.6	13.4	9.1	132.2	3,510,967.4	2,076.7	1.1	0.8
01/21/2015 09:00	11.4	13.3	8.9	126.3	3,468,025.0	2,051.3	1.0	0.8
01/21/2015 10:00	11.0	13.5	8.8	121.3	3,464,117.0	1,973.1	1.0	0.8
01/21/2015 11:00	11.1	13.5	8.9	123.7	3,463,239.2	1,972.6	1.0	0.8
01/21/2015 12:00	11.0	13.6	8.9	120.8	3,421,980.9	1,949.1	1.0	0.8
01/21/2015 13:00	10.5	13.7	8.6	109.9	3,406,082.8	1,890.3	0.9	0.6
01/21/2015 14:00	10.3	13.7	8.4	107.4	3,400,497.0	1,887.2	0.9	0.6
01/21/2015 15:00	10.8	13.5	8.6	117.2	3,432,163.8	1,954.9	1.0	0.8
01/21/2015 16:00	11.0	13.4	8.7	120.2	3,409,866.7	2,016.9	1.0	0.8
01/21/2015 17:00	10.9	13.4	8.6	119.5	3,453,316.4	2,042.6	1.0	0.8
01/21/2015 18:00	11.1	13.3	8.6	126.6	3,430,160.6	2,079.0	1.1	0.8
01/21/2015 19:00	11.1	13.3	8.6	124.7	3,462,305.6	2,073.2	1.0	0.8
01/21/2015 20:00	11.0	13.4	8.7	122.5	3,457,543.0	2,045.1	1.0	0.8
01/21/2015 21:00	11.0	13.4	8.7	122.2	3,481,419.1	2,033.8	1.0	0.8
01/21/2015 22:00	10.8	13.5	8.6	117.3	3,437,606.3	1,958.0	1.0	0.8
01/21/2015 23:00	10.8	13.7	8.9	99.6	2,949,139.8	1,572.1	1.0	0.6
Average/Sum#:	11.0	13.5	8.8	119.7	3,429,681.5	1,955.4	1.0	0.8
Minimum:	10.3	13.3	8.4	99.6	2,949,139.8	1,572.1	0.9	0.6
Maximum:	11.6	13.8	9.1	146.3	3,521,500.8	2,079.0	1.2	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/22/2015 00:00	11.0	13.8	9.1	90.7	2,715,510.7	1,407.9	0.9	0.4
01/22/2015 01:00	11.3	13.8	9.4	86.6	2,514,918.9	1,303.9	1.0	0.5
01/22/2015 02:00	11.4	13.8	9.5	86.9	2,538,064.2	1,315.9	1.0	0.5
01/22/2015 03:00	11.3	13.7	9.3	109.5	2,996,376.6	1,575.4	1.0	0.6
01/22/2015 04:00	11.0	13.6	8.9	113.4	3,386,390.9	1,904.1	0.9	0.6
01/22/2015 05:00	10.9	13.6	8.8	113.5	3,359,180.2	1,888.8	1.0	0.8
01/22/2015 06:00	11.0	13.5	8.8	122.3	3,435,324.0	1,956.7	1.0	0.8
01/22/2015 07:00	11.2	13.4	8.8	127.4	3,527,637.2	2,060.8	1.0	0.8
01/22/2015 08:00	11.0	13.5	8.8	121.2	3,518,900.6	2,030.0	1.0	0.8
01/22/2015 09:00	11.1	13.4	8.7	125.7	3,518,736.0	2,055.6	1.0	0.8
01/22/2015 10:00	10.8	13.6	8.7	112.1	3,372,518.8	1,896.3	0.9	0.6
01/22/2015 11:00	10.8	13.6	8.7	111.4	3,357,579.6	1,887.9	0.9	0.6
01/22/2015 12:00	10.7	13.6	8.6	111.7	3,363,982.1	1,891.5	0.9	0.6
01/22/2015 13:00	10.7	13.7	8.8	95.9	2,877,122.6	1,512.7	0.9	0.5
01/22/2015 14:00	10.6	13.8	8.8	105.8	3,182,272.2	1,649.9	0.9	0.5
01/22/2015 15:00	10.5	13.7	8.6	105.0	3,241,464.5	1,751.6	0.9	0.5
01/22/2015 16:00	10.4	13.6	8.4	109.9	3,370,918.2	1,895.4	0.9	0.6
01/22/2015 17:00	10.8	13.4	8.5	119.2	3,478,858.0	2,006.9	1.0	0.8
01/22/2015 18:00	11.0	13.3	8.5	124.1	3,518,406.3	2,081.1	1.0	0.8
01/22/2015 19:00	11.0	13.3	8.5	124.8	3,502,514.2	2,071.7	1.0	0.8
01/22/2015 20:00	10.9	13.4	8.6	122.8	3,526,527.8	2,034.4	1.0	0.8
01/22/2015 21:00	10.7	13.5	8.5	114.9	3,498,352.6	1,992.6	0.9	0.6
01/22/2015 22:00	10.7	13.5	8.5	117.7	3,496,834.1	1,966.2	1.0	0.8
01/22/2015 23:00	10.7	13.6	8.6	113.4	3,446,084.4	1,912.5	0.9	0.6
Average/Sum#:	10.9	13.6	8.8	111.9	3,281,019.8	1,835.4	1.0	0.7
Minimum:	10.4	13.3	8.4	86.6	2,514,918.9	1,303.9	0.9	0.4
Maximum:	11.4	13.8	9.5	127.4	3,527,637.2	2,081.1	1.0	0.8
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/23/2015 00:00	11.0	13.5	8.8	122.5	3,505,015.0	1,970.8	1.0	0.8
01/23/2015 01:00	10.9	13.6	8.8	119.4	3,520,516.2	1,928.1	1.0	0.8
01/23/2015 02:00	11.3	13.4	8.9	124.4	3,508,673.3	2,024.1	1.0	0.8
01/23/2015 03:00	11.2	13.4	8.8	121.5	3,470,884.1	2,002.3	1.0	0.8
01/23/2015 04:00	11.0	13.6	8.9	122.6	3,458,063.3	1,944.4	1.0	0.8
01/23/2015 05:00	11.0	13.6	8.9	118.1	3,440,456.5	1,934.5	1.0	0.8
01/23/2015 06:00	11.1	13.6	9.0	139.7	3,454,243.0	1,992.7	1.2	1.0
01/23/2015 07:00	11.4	13.4	9.0	127.3	3,527,294.9	2,060.6	1.0	0.8
01/23/2015 08:00	11.3	13.4	8.9	126.6	3,503,158.8	2,046.5	1.0	0.8
01/23/2015 09:00	10.8	13.6	8.7	121.8	3,476,203.8	1,954.6	1.0	0.8
01/23/2015 10:00	10.7	13.6	8.6	114.7	3,426,940.1	1,926.9	1.0	0.8
01/23/2015 11:00	10.4	13.7	8.5	108.0	3,397,614.0	1,885.6	0.9	0.6
01/23/2015 12:00	10.4	13.7	8.5	108.6	3,443,828.4	1,886.1	0.9	0.6
01/23/2015 13:00	10.5	13.6	8.5	108.0	3,394,370.6	1,883.8	0.9	0.6
01/23/2015 14:00	10.4	13.6	8.4	107.1	3,388,244.2	1,880.4	0.9	0.6
01/23/2015 15:00	10.6	13.6	8.6	115.0	3,373,230.2	1,896.7	1.0	0.8
01/23/2015 16:00	10.9	13.5	8.7	117.9	3,359,596.7	1,938.1	1.0	0.8
01/23/2015 17:00	10.8	13.5	8.6	118.9	3,380,224.7	1,950.0	1.0	0.8
01/23/2015 18:00	11.5	13.4	9.0	132.9	3,410,361.7	2,067.0	1.1	0.8
01/23/2015 19:00	11.8	13.3	9.2	137.6	3,409,540.7	2,091.4	1.2	1.0
01/23/2015 20:00	11.7	13.3	9.1	135.6	3,439,400.1	2,084.6	1.1	0.8
01/23/2015 21:00	11.6	13.4	9.1	132.6	3,419,552.9	2,047.6	1.1	0.8
01/23/2015 22:00	11.5	13.4	9.0	129.2	3,454,499.8	2,043.3	1.1	0.8
01/23/2015 23:00	10.9	13.6	8.8	116.9	3,399,683.8	1,936.4	1.0	0.8
Average/Sum#:	11.0	13.5	8.8	122.0	3,440,066.5	1,974.0	1.0	0.8
Minimum:	10.4	13.3	8.4	107.1	3,359,596.7	1,880.4	0.9	0.6
Maximum:	11.8	13.7	9.2	139.7	3,527,294.9	2,091.4	1.2	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/24/2015 00:00	10.5	13.7	8.6	110.0	3,442,002.5	1,885.1	0.9	0.6
01/24/2015 01:00	10.8	13.6	8.7	116.2	3,454,733.4	1,917.3	1.0	0.8
01/24/2015 02:00	10.4	13.7	8.5	109.1	3,443,280.7	1,885.8	0.9	0.6
01/24/2015 03:00	10.5	13.7	8.6	113.2	3,404,100.7	1,889.2	0.9	0.6
01/24/2015 04:00	11.1	13.5	8.9	122.6	3,430,841.4	1,979.2	1.0	0.8
01/24/2015 05:00	11.3	13.4	8.9	126.3	3,472,346.7	2,028.5	1.0	0.8
01/24/2015 06:00	11.0	13.5	8.8	124.3	3,423,053.8	2,024.7	1.0	0.8
01/24/2015 07:00	11.3	13.4	8.9	125.6	3,473,942.3	2,054.8	1.0	0.8
01/24/2015 08:00	11.0	13.5	8.8	120.5	3,465,521.5	1,973.9	1.0	0.8
01/24/2015 09:00	10.8	13.5	8.6	115.3	3,441,879.2	1,935.3	1.0	0.8
01/24/2015 10:00	10.5	13.6	8.5	108.1	3,386,442.4	1,879.4	0.9	0.6
01/24/2015 11:00	10.4	13.6	8.4	107.2	3,396,893.2	1,885.2	0.9	0.6
01/24/2015 12:00	10.4	13.6	8.4	106.7	3,380,496.2	1,876.1	0.9	0.6
01/24/2015 13:00	10.5	13.6	8.5	112.6	3,331,665.4	1,849.0	1.0	0.7
01/24/2015 14:00	11.2	13.9	9.4	87.7	2,560,628.0	1,308.9	1.0	0.5
01/24/2015 15:00	11.3	13.9	9.5	86.3	2,555,932.8	1,306.5	0.9	0.4
01/24/2015 16:00	10.8	13.8	9.0	92.5	2,831,187.1	1,447.2	0.9	0.4
01/24/2015 17:00	10.7	13.7	8.8	120.4	3,171,690.9	1,829.7	1.1	0.7
01/24/2015 18:00	10.8	13.6	8.7	135.0	3,342,191.7	2,098.9	1.2	1.0
01/24/2015 19:00	10.6	13.6	8.6	128.1	3,383,945.5	2,075.7	1.1	0.8
01/24/2015 20:00	10.6	13.6	8.6	121.2	3,427,787.6	2,027.5	1.0	0.8
01/24/2015 21:00	10.6	13.6	8.6	122.5	3,463,967.4	2,048.9	1.0	0.8
01/24/2015 22:00	10.7	13.6	8.6	126.7	3,487,974.6	2,063.1	1.0	0.8
01/24/2015 23:00	10.6	13.7	8.7	123.4	3,446,498.8	2,013.4	1.0	0.8
Average/Sum#:	10.8	13.6	8.7	115.1	3,317,458.5	1,886.8	1.0	0.7
Minimum:	10.4	13.4	8.4	86.3	2,555,932.8	1,306.5	0.9	0.4
Maximum:	11.3	13.9	9.5	135.0	3,487,974.6	2,098.9	1.2	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/25/2015 00:00	11.1	13.8	9.2	95.5	2,841,652.0	1,473.3	0.9	0.4
01/25/2015 01:00	29.9	15.9	35.3	187.5	1,703,880.0	647.0	3.1	0.8
01/25/2015 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2015 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2015 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2015 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2015 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2015 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2015 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2015 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2015 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2015 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2015 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2015 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2015 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2015 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2015 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2015 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2015 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2015 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2015 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2015 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2015 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2015 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	20.5	14.9	22.3	141.5	2,272,766.0	1,060.2	2.0	0.6
Minimum:	11.1	13.8	9.2	95.5	1,703,880.0	647.0	0.9	0.4
Maximum:	29.9	15.9	35.3	187.5	2,841,652.0	1,473.3	3.1	0.8
%SI	91.7	91.7	91.7	91.7	91.7	91.7	91.7	91.7

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/26/2015 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2015 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2015 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2015 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2015 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2015 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2015 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2015 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2015 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2015 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2015 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2015 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2015 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2015 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2015 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2015 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2015 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2015 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2015 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2015 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2015 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2015 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2015 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2015 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/27/2015 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2015 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2015 02:00	43.4	17.1	67.4	10.7	1,986,447.9	507.7	-0.1	0.0
01/27/2015 03:00	58.5	15.6	65.1	242.2	1,900,916.1	735.7	3.3	1.0
01/27/2015 04:00	37.7	16.8	54.3	236.0	1,413,373.4	443.8	4.7	0.8
01/27/2015 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2015 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2015 07:00	33.8	17.5	58.7	139.8	1,967,249.0	416.6	1.4	0.2
01/27/2015 08:00	48.4	16.9	71.4	255.4	1,851,532.0	527.3	3.4	0.7
01/27/2015 09:00	38.7	16.9	57.1	242.8	1,992,892.9	523.9	2.9	0.6
01/27/2015 10:00	34.5	14.1	29.9	168.2	806,518.9	1,230.9	6.3	3.0
01/27/2015 11:00	10.9	13.8	9.1	86.4	851,860.6	1,300.1	3.1	1.6
01/27/2015 12:00	10.7	13.8	8.9	86.1	855,660.9	1,305.9	3.1	1.6
01/27/2015 13:00	10.1	13.8	8.4	106.1	2,999,232.3	1,555.0	1.0	0.6
01/27/2015 14:00	10.6	13.8	8.8	86.1	2,507,011.0	1,299.8	1.0	0.5
01/27/2015 15:00	10.2	13.7	8.4	105.6	2,987,437.3	1,570.7	1.0	0.6
01/27/2015 16:00	10.4	13.8	8.6	87.1	2,558,702.0	1,326.6	1.0	0.5
01/27/2015 17:00	10.1	13.7	8.3	104.5	3,060,108.3	1,653.6	1.0	0.7
01/27/2015 18:00	10.3	13.3	8.0	128.8	3,420,686.9	2,023.3	1.1	0.8
01/27/2015 19:00	10.3	13.3	8.0	128.5	3,447,183.5	2,013.8	1.1	0.8
01/27/2015 20:00	10.3	13.4	8.1	127.6	3,454,243.0	1,992.7	1.1	0.8
01/27/2015 21:00	10.3	13.4	8.1	123.5	3,454,416.3	1,992.8	1.0	0.8
01/27/2015 22:00	10.3	13.5	8.2	121.5	3,397,212.5	1,959.8	1.0	0.8
01/27/2015 23:00	10.4	13.7	8.5	102.4	2,921,938.9	1,557.6	1.0	0.6
Average/Sum#:	21.5	14.6	25.7	134.5	2,665,916.7	1,296.9	1.6	0.6
Minimum:	10.1	13.3	8.0	10.7	1,413,373.4	416.6	-0.1	0.0
Maximum:	58.5	17.5	71.4	255.4	3,454,416.3	2,023.3	4.7	1.0
%SI	16.7	16.7	16.7	16.7	29.2	16.7	29.2	29.2

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/28/2015 00:00	11.6	13.8	9.6	88.5	2,506,242.3	1,281.1	1.0	0.5
01/28/2015 01:00	11.8	13.8	9.8	89.1	2,471,328.8	1,281.3	1.0	0.5
01/28/2015 02:00	11.8	13.8	9.8	87.2	2,460,720.6	1,275.8	1.0	0.5
01/28/2015 03:00	11.8	13.8	9.8	87.4	2,494,113.1	1,274.9	1.0	0.5
01/28/2015 04:00	11.9	13.8	9.9	90.7	2,475,765.0	1,283.6	1.0	0.5
01/28/2015 05:00	11.0	13.7	9.0	108.3	3,021,550.5	1,610.7	1.0	0.6
01/28/2015 06:00	10.6	13.6	8.6	119.2	3,386,442.4	1,879.4	1.0	0.8
01/28/2015 07:00	10.8	13.4	8.5	130.0	3,448,553.0	2,014.6	1.1	0.8
01/28/2015 08:00	10.3	13.6	8.3	117.7	3,409,866.7	1,892.4	1.0	0.8
01/28/2015 09:00	10.1	13.7	8.3	111.5	3,441,511.5	1,859.7	0.9	0.6
01/28/2015 10:00	10.0	13.7	8.2	111.5	3,436,700.0	1,857.1	0.9	0.6
01/28/2015 11:00	10.0	13.7	8.2	105.8	3,250,600.8	1,732.8	0.9	0.5
01/28/2015 12:00	11.2	13.8	9.3	84.8	2,489,809.2	1,272.7	1.0	0.5
01/28/2015 13:00	10.6	13.8	8.8	109.6	3,102,421.3	1,608.5	0.8	0.5
01/28/2015 14:00	11.0	13.6	8.9	120.2	3,321,214.5	1,843.2	0.8	0.6
01/28/2015 15:00	11.3	13.3	8.8	146.4	3,316,395.5	2,082.7	1.0	0.8
01/28/2015 16:00	11.1	13.4	8.7	136.0	3,369,619.0	2,017.7	0.9	0.6
01/28/2015 17:00	10.8	13.5	8.6	128.3	3,344,819.1	1,954.0	0.8	0.6
01/28/2015 18:00	11.1	13.4	8.7	137.6	3,374,295.1	2,020.5	0.9	0.6
01/28/2015 19:00	11.1	13.4	8.7	135.1	3,381,643.2	2,024.9	0.9	0.6
01/28/2015 20:00	10.6	13.5	8.5	124.6	3,387,158.5	1,954.0	0.8	0.6
01/28/2015 21:00	10.5	13.5	8.4	121.8	3,413,160.3	1,969.0	0.8	0.6
01/28/2015 22:00	10.4	13.5	8.3	119.4	3,408,286.6	1,941.3	0.8	0.6
01/28/2015 23:00	10.3	13.6	8.3	113.5	3,350,404.9	1,859.4	0.7	0.6
Average/Sum#:	10.9	13.6	8.8	113.5	3,127,609.2	1,741.3	0.9	0.6
Minimum:	10.0	13.3	8.2	84.8	2,460,720.6	1,272.7	0.7	0.5
Maximum:	11.9	13.8	9.9	146.4	3,448,553.0	2,082.7	1.1	0.8
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/29/2015 00:00	10.3	13.6	8.3	112.8	3,346,981.3	1,857.5	0.7	0.6
01/29/2015 01:00	10.3	13.6	8.3	114.0	3,310,805.8	1,861.6	0.8	0.6
01/29/2015 02:00	10.5	13.6	8.5	117.0	3,362,117.0	1,865.9	0.8	0.6
01/29/2015 03:00	10.6	13.6	8.6	119.7	3,308,138.0	1,860.1	0.8	0.6
01/29/2015 04:00	10.6	13.6	8.6	116.8	3,322,010.1	1,867.9	0.8	0.6
01/29/2015 05:00	10.7	13.6	8.6	117.5	3,307,960.2	1,860.0	0.8	0.6
01/29/2015 06:00	10.9	13.5	8.7	145.1	3,376,237.8	1,947.7	1.0	0.8
01/29/2015 07:00	11.3	13.3	8.8	138.6	3,488,608.6	2,038.0	0.9	0.6
01/29/2015 08:00	11.1	13.4	8.7	129.8	3,459,443.3	1,995.7	0.8	0.6
01/29/2015 09:00	10.9	13.4	8.6	128.3	3,444,882.4	1,987.3	0.8	0.6
01/29/2015 10:00	10.4	13.6	8.4	115.9	3,386,262.2	1,879.3	0.7	0.6
01/29/2015 11:00	10.1	13.7	8.3	113.3	3,433,369.0	1,855.3	0.7	0.6
01/29/2015 12:00	10.3	13.7	8.4	115.3	3,393,616.2	1,858.6	0.7	0.6
01/29/2015 13:00	10.3	13.7	8.4	115.5	3,387,773.3	1,855.4	0.7	0.6
01/29/2015 14:00	10.4	13.6	8.4	117.4	3,411,327.4	1,868.3	0.8	0.6
01/29/2015 15:00	11.3	13.3	8.8	140.4	3,336,504.7	2,046.6	0.9	0.6
01/29/2015 16:00	10.8	13.4	8.5	126.7	3,362,890.3	1,940.0	0.8	0.6
01/29/2015 17:00	10.3	13.6	8.3	114.1	3,380,877.6	1,901.0	0.7	0.6
01/29/2015 18:00	11.2	13.4	8.8	135.3	3,362,938.9	2,013.7	0.9	0.6
01/29/2015 19:00	11.2	13.4	8.8	140.1	3,358,884.5	2,035.8	0.9	0.6
01/29/2015 20:00	11.2	13.3	8.7	137.3	3,389,242.9	2,054.2	0.9	0.6
01/29/2015 21:00	10.9	13.4	8.6	127.7	3,404,902.6	1,989.1	0.8	0.6
01/29/2015 22:00	10.6	13.5	8.5	117.9	3,396,528.2	1,909.8	0.8	0.6
01/29/2015 23:00	10.4	13.6	8.4	113.4	3,349,503.9	1,858.9	0.7	0.6
Average/Sum#:	10.7	13.5	8.5	123.7	3,378,408.6	1,925.3	0.8	0.6
Minimum:	10.1	13.3	8.3	112.8	3,307,960.2	1,855.3	0.7	0.6
Maximum:	11.3	13.7	8.8	145.1	3,488,608.6	2,054.2	1.0	0.8
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/30/2015 00:00	10.4	13.6	8.4	114.7	3,359,594.4	1,864.5	0.7	0.6
01/30/2015 01:00	10.5	13.7	8.6	115.9	3,357,432.2	1,863.3	0.8	0.6
01/30/2015 02:00	10.6	13.6	8.6	117.5	3,355,269.9	1,862.1	0.8	0.6
01/30/2015 03:00	10.6	13.6	8.6	115.8	3,353,468.1	1,861.1	0.8	0.6
01/30/2015 04:00	10.6	13.7	8.7	117.4	3,358,873.7	1,864.1	0.8	0.6
01/30/2015 05:00	10.5	13.7	8.6	115.9	3,365,360.4	1,867.7	0.7	0.6
01/30/2015 06:00	10.6	13.6	8.6	128.9	3,397,950.9	1,910.6	0.8	0.6
01/30/2015 07:00	11.1	13.4	8.7	129.6	3,425,786.3	2,001.3	0.8	0.6
01/30/2015 08:00	11.1	13.4	8.7	129.9	3,422,533.9	1,999.4	0.8	0.6
01/30/2015 09:00	10.8	13.5	8.6	124.6	3,405,653.1	1,939.8	0.8	0.6
01/30/2015 10:00	10.3	13.6	8.3	114.2	3,380,496.2	1,876.1	0.7	0.6
01/30/2015 11:00	10.3	13.7	8.4	113.5	3,381,930.5	1,852.2	0.7	0.6
01/30/2015 12:00	10.6	13.8	8.8	109.0	3,092,616.7	1,626.0	0.8	0.5
01/30/2015 13:00	10.9	13.5	8.7	123.6	3,354,738.6	1,910.8	0.8	0.6
01/30/2015 14:00	11.0	13.5	8.8	125.5	3,332,381.6	1,922.4	0.8	0.6
01/30/2015 15:00	11.0	13.5	8.8	127.0	3,316,953.9	1,913.5	0.8	0.6
01/30/2015 16:00	11.4	13.4	9.0	136.1	3,328,536.3	1,993.1	0.9	0.6
01/30/2015 17:00	10.7	13.6	8.6	124.9	3,361,492.2	1,890.1	0.8	0.6
01/30/2015 18:00	10.5	13.7	8.6	118.1	3,369,684.9	1,870.1	0.8	0.6
01/30/2015 19:00	10.5	13.7	8.6	117.8	3,401,650.2	1,863.0	0.8	0.6
01/30/2015 20:00	10.5	13.7	8.6	116.9	3,410,049.3	1,867.6	0.7	0.6
01/30/2015 21:00	10.5	13.7	8.6	119.8	3,409,136.4	1,867.1	0.8	0.6
01/30/2015 22:00	10.7	13.8	8.9	111.3	3,178,752.9	1,694.5	0.8	0.5
01/30/2015 23:00	11.9	13.9	10.0	91.2	2,498,221.3	1,277.0	0.8	0.4
Average/Sum#:	10.7	13.6	8.7	119.1	3,317,440.2	1,852.4	0.8	0.6
Minimum:	10.3	13.4	8.3	91.2	2,498,221.3	1,277.0	0.7	0.4
Maximum:	11.9	13.9	10.0	136.1	3,425,786.3	2,001.3	0.9	0.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/31/2015 00:00	11.3	13.8	9.4	124.4	3,249,393.3	1,684.7	0.8	0.5
01/31/2015 01:00	10.9	13.8	9.1	123.9	3,502,596.3	1,790.4	0.8	0.5
01/31/2015 02:00	10.9	13.8	9.1	122.9	3,504,161.4	1,791.2	0.8	0.5
01/31/2015 03:00	10.9	13.8	9.1	114.3	3,343,156.2	1,708.9	0.7	0.5
01/31/2015 04:00	11.5	13.9	9.7	90.7	2,600,145.6	1,329.1	0.7	0.4
01/31/2015 05:00	11.1	13.7	9.1	120.8	3,312,881.5	1,766.0	0.8	0.5
01/31/2015 06:00	10.9	13.7	8.9	125.4	3,414,248.9	1,869.9	0.8	0.6
01/31/2015 07:00	10.9	13.7	8.9	123.7	3,419,544.0	1,872.8	0.8	0.6
01/31/2015 08:00	10.8	13.7	8.9	121.4	3,415,892.2	1,870.8	0.8	0.6
01/31/2015 09:00	10.7	13.7	8.8	123.7	3,409,318.9	1,867.2	0.8	0.6
01/31/2015 10:00	10.6	13.7	8.7	119.7	3,411,144.8	1,868.2	0.8	0.6
01/31/2015 11:00	11.4	13.9	9.6	95.2	2,672,725.1	1,366.2	0.8	0.4
01/31/2015 12:00	12.5	13.9	10.5	105.9	2,543,021.1	1,299.9	0.9	0.4
01/31/2015 13:00	12.1	13.9	10.2	100.2	2,601,906.3	1,330.0	0.8	0.4
01/31/2015 14:00	10.6	13.9	8.9	97.1	2,975,172.3	1,520.8	0.7	0.5
01/31/2015 15:00	10.8	13.8	9.0	110.2	3,272,141.7	1,672.6	0.7	0.5
01/31/2015 16:00	10.6	13.7	8.7	108.3	3,236,216.1	1,701.5	0.7	0.5
01/31/2015 17:00	10.9	13.8	9.1	109.8	3,030,422.0	1,593.3	0.8	0.5
01/31/2015 18:00	11.8	13.4	9.3	144.8	3,339,250.6	2,023.9	1.0	0.8
01/31/2015 19:00	12.0	13.4	9.4	150.0	3,327,049.1	2,040.8	1.0	0.8
01/31/2015 20:00	12.0	13.4	9.4	152.3	3,336,341.7	2,046.5	1.0	0.8
01/31/2015 21:00	12.0	13.3	9.3	153.3	3,350,851.0	2,055.4	1.0	0.8
01/31/2015 22:00	11.8	13.4	9.3	146.0	3,384,788.1	2,051.5	1.0	0.8
01/31/2015 23:00	11.1	13.5	8.9	127.6	3,450,949.4	1,965.6	0.8	0.6
Average/Sum#:	11.3	13.7	9.2	121.3	3,212,638.2	1,753.6	0.8	0.6
Minimum:	10.6	13.3	8.7	90.7	2,543,021.1	1,299.9	0.7	0.4
Maximum:	12.5	13.9	10.5	153.3	3,504,161.4	2,055.4	1.0	0.8
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/01/2015 00:00	11.4	13.4	9.0	136.9	3,420,348.7	2,023.1	0.9	0.6
02/01/2015 01:00	11.0	13.7	9.0	110.9	3,092,997.1	1,626.2	0.8	0.5
02/01/2015 02:00	33.8	16.0	40.7	212.7	1,576,418.1	598.6	2.9	0.7
02/01/2015 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2015 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2015 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2015 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2015 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2015 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2015 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2015 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2015 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2015 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2015 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2015 14:00	44.1	17.2	70.3	50.2	1,959,485.2	486.5	0.3	0.0
02/01/2015 15:00	41.5	14.4	37.7	194.4	2,456,191.0	1,147.9	1.6	0.7
02/01/2015 16:00	10.6	13.7	8.7	111.3	3,253,569.7	1,781.9	0.7	0.5
02/01/2015 17:00	10.5	13.6	8.5	121.7	3,398,128.8	1,910.7	0.8	0.6
02/01/2015 18:00	10.8	13.4	8.5	134.5	3,389,578.9	2,004.9	0.9	0.6
02/01/2015 19:00	10.9	13.3	8.5	134.9	3,361,359.4	2,037.3	0.9	0.6
02/01/2015 20:00	10.9	13.3	8.5	134.1	3,374,228.7	2,045.1	0.9	0.6
02/01/2015 21:00	10.9	13.3	8.5	132.4	3,385,484.3	2,027.2	0.9	0.6
02/01/2015 22:00	10.7	13.5	8.5	125.5	3,405,828.7	1,939.9	0.8	0.6
02/01/2015 23:00	10.6	13.6	8.6	118.5	3,294,266.0	1,852.3	0.8	0.6
Average/Sum#:	17.5	14.0	18.1	132.2	3,028,298.8	1,652.4	1.0	0.6
Minimum:	10.5	13.3	8.5	50.2	1,576,418.1	486.5	0.3	0.0
Maximum:	44.1	17.2	70.3	212.7	3,420,348.7	2,045.1	2.9	0.7
%SI	45.8	45.8	45.8	45.8	45.8	45.8	45.8	45.8

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/02/2015 00:00	10.6	13.6	8.6	122.5	3,320,587.4	1,867.1	0.8	0.6
02/02/2015 01:00	11.0	13.4	8.7	134.0	3,399,891.9	2,011.0	0.9	0.6
02/02/2015 02:00	10.9	13.5	8.7	131.5	3,407,439.9	1,965.7	0.9	0.6
02/02/2015 03:00	10.7	13.6	8.6	122.0	3,324,855.7	1,869.5	0.8	0.6
02/02/2015 04:00	10.9	13.6	8.8	121.6	3,307,960.2	1,860.0	0.8	0.6
02/02/2015 05:00	10.9	13.6	8.8	126.0	3,355,623.3	1,886.8	0.8	0.6
02/02/2015 06:00	10.7	13.6	8.6	137.2	3,422,671.7	1,924.5	0.9	0.6
02/02/2015 07:00	10.9	13.4	8.6	130.9	3,435,175.1	1,981.7	0.8	0.6
02/02/2015 08:00	10.6	13.6	8.6	119.3	3,317,741.8	1,865.5	0.8	0.6
02/02/2015 09:00	10.5	13.6	8.5	115.3	3,304,758.9	1,858.2	0.8	0.6
02/02/2015 10:00	10.4	13.6	8.4	116.3	3,344,098.3	1,855.9	0.8	0.6
02/02/2015 11:00	10.4	13.6	8.4	116.5	3,367,342.5	1,868.8	0.8	0.6
02/02/2015 12:00	10.6	13.5	8.5	121.5	3,374,402.1	1,922.0	0.8	0.6
02/02/2015 13:00	10.2	13.6	8.2	113.1	3,363,918.9	1,866.9	0.7	0.6
02/02/2015 14:00	10.0	13.7	8.2	114.0	3,330,223.9	1,848.2	0.7	0.6
02/02/2015 15:00	10.0	13.7	8.2	112.4	3,331,305.0	1,848.8	0.7	0.6
02/02/2015 16:00	10.4	13.5	8.3	123.0	3,359,654.5	1,913.6	0.8	0.6
02/02/2015 17:00	10.4	13.4	8.2	119.6	3,372,944.3	1,945.8	0.8	0.6
02/02/2015 18:00	10.7	13.3	8.3	125.7	3,382,311.2	2,025.3	0.8	0.6
02/02/2015 19:00	10.7	13.3	8.3	125.3	3,375,965.1	2,021.5	0.8	0.6
02/02/2015 20:00	10.7	13.3	8.3	125.0	3,385,985.3	2,027.5	0.8	0.6
02/02/2015 21:00	10.6	13.4	8.3	124.7	3,390,181.2	1,980.5	0.8	0.6
02/02/2015 22:00	10.4	13.5	8.3	115.6	3,338,275.3	1,925.8	0.8	0.6
02/02/2015 23:00	10.4	13.6	8.4	113.9	3,277,192.6	1,842.7	0.8	0.6
Average/Sum#:	10.6	13.5	8.5	122.0	3,357,937.8	1,916.0	0.8	0.6
Minimum:	10.0	13.3	8.2	112.4	3,277,192.6	1,842.7	0.7	0.6
Maximum:	11.0	13.7	8.8	137.2	3,435,175.1	2,027.5	0.9	0.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/03/2015 00:00	10.7	13.8	8.9	87.7	2,568,538.7	1,331.7	0.7	0.4
02/03/2015 01:00	11.1	13.8	9.2	86.4	2,487,530.5	1,289.7	0.7	0.4
02/03/2015 02:00	11.1	13.8	9.2	86.5	2,490,037.9	1,291.0	0.7	0.4
02/03/2015 03:00	11.0	13.8	9.1	91.0	2,639,710.2	1,368.6	0.7	0.4
02/03/2015 04:00	10.5	13.7	8.6	106.3	3,157,263.4	1,706.1	0.7	0.5
02/03/2015 05:00	10.5	13.6	8.5	115.3	3,298,000.8	1,854.4	0.8	0.6
02/03/2015 06:00	10.5	13.6	8.5	120.6	3,344,774.6	1,880.7	0.8	0.6
02/03/2015 07:00	10.5	13.6	8.5	112.6	3,284,662.2	1,846.9	0.7	0.6
02/03/2015 08:00	10.4	13.6	8.4	113.4	3,289,641.9	1,849.7	0.8	0.6
02/03/2015 09:00	10.4	13.6	8.4	112.6	3,294,977.3	1,852.7	0.7	0.6
02/03/2015 10:00	10.3	13.7	8.4	106.1	3,065,502.1	1,678.9	0.8	0.5
02/03/2015 11:00	10.7	13.8	8.9	85.1	2,438,154.0	1,264.1	0.8	0.4
02/03/2015 12:00	11.0	13.8	9.1	86.5	2,509,325.5	1,301.0	0.7	0.4
02/03/2015 13:00	11.2	13.8	9.3	90.6	2,622,544.1	1,359.7	0.7	0.4
02/03/2015 14:00	10.2	13.7	8.4	106.0	3,276,203.2	1,698.6	0.7	0.5
02/03/2015 15:00	10.0	13.8	8.3	99.3	3,040,700.8	1,576.5	0.7	0.5
02/03/2015 16:00	10.3	13.7	8.4	102.6	3,036,791.1	1,641.0	0.7	0.5
02/03/2015 17:00	10.1	13.6	8.2	111.1	3,362,737.2	1,890.8	0.7	0.6
02/03/2015 18:00	10.9	13.3	8.5	132.5	3,337,645.9	2,047.3	0.9	0.6
02/03/2015 19:00	10.8	13.4	8.5	126.9	3,355,256.7	2,009.1	0.8	0.6
02/03/2015 20:00	10.7	13.4	8.4	125.4	3,375,208.4	1,996.4	0.8	0.6
02/03/2015 21:00	10.4	13.5	8.3	120.2	3,369,130.7	1,943.6	0.8	0.6
02/03/2015 22:00	10.5	13.5	8.4	117.1	3,155,223.1	1,820.2	0.8	0.5
02/03/2015 23:00	10.9	13.8	9.1	87.6	2,539,607.2	1,316.7	0.7	0.4
Average/Sum#:	10.6	13.7	8.6	105.4	3,014,132.0	1,659.0	0.7	0.5
Minimum:	10.0	13.3	8.2	85.1	2,438,154.0	1,264.1	0.7	0.4
Maximum:	11.2	13.8	9.3	132.5	3,375,208.4	2,047.3	0.9	0.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/04/2015 00:00	10.3	13.7	8.4	107.6	3,264,244.8	1,692.4	0.7	0.5
02/04/2015 01:00	10.3	13.8	8.6	95.5	2,870,969.3	1,488.5	0.7	0.4
02/04/2015 02:00	11.0	13.8	9.1	86.4	2,481,937.0	1,286.8	0.7	0.4
02/04/2015 03:00	11.4	13.8	9.5	86.9	2,488,687.7	1,290.3	0.7	0.4
02/04/2015 04:00	11.3	13.8	9.4	93.1	2,674,428.0	1,386.6	0.7	0.4
02/04/2015 05:00	10.5	13.7	8.6	104.3	2,982,939.4	1,611.9	0.8	0.5
02/04/2015 06:00	10.6	13.5	8.5	131.3	3,362,814.7	1,915.4	0.9	0.6
02/04/2015 07:00	10.5	13.5	8.4	119.3	3,372,518.8	1,896.3	0.8	0.6
02/04/2015 08:00	11.5	13.8	9.6	90.5	2,554,844.4	1,324.6	0.8	0.4
02/04/2015 09:00	11.9	13.8	9.9	90.8	2,491,388.0	1,291.7	0.8	0.4
02/04/2015 10:00	11.8	13.8	9.8	90.2	2,495,052.7	1,293.6	0.8	0.4
02/04/2015 11:00	11.8	13.8	9.8	91.1	2,497,174.3	1,294.7	0.8	0.4
02/04/2015 12:00	11.8	13.8	9.8	90.8	2,496,595.7	1,294.4	0.8	0.4
02/04/2015 13:00	11.7	13.8	9.7	91.0	2,497,174.3	1,294.7	0.8	0.4
02/04/2015 14:00	11.7	13.8	9.7	90.9	2,499,103.1	1,295.7	0.8	0.4
02/04/2015 15:00	11.4	13.8	9.5	93.1	2,611,550.2	1,354.0	0.8	0.4
02/04/2015 16:00	10.2	13.6	8.2	118.6	3,320,765.2	1,867.2	0.8	0.6
02/04/2015 17:00	10.5	13.5	8.4	122.7	3,363,410.3	1,940.3	0.8	0.6
02/04/2015 18:00	10.9	13.3	8.5	132.9	3,321,180.2	2,037.2	0.9	0.6
02/04/2015 19:00	10.8	13.3	8.4	129.6	3,334,300.9	2,020.9	0.9	0.6
02/04/2015 20:00	10.7	13.3	8.3	125.3	3,340,226.5	2,000.1	0.8	0.6
02/04/2015 21:00	10.7	13.3	8.3	127.8	3,370,120.0	2,018.0	0.8	0.6
02/04/2015 22:00	10.6	13.4	8.3	126.1	3,346,129.3	1,979.2	0.8	0.6
02/04/2015 23:00	10.6	13.7	8.7	103.0	2,880,602.7	1,556.6	0.8	0.5
Average/Sum#:	11.0	13.6	9.0	105.8	2,913,256.6	1,601.3	0.8	0.5
Minimum:	10.2	13.3	8.2	86.4	2,481,937.0	1,286.8	0.7	0.4
Maximum:	11.9	13.8	9.9	132.9	3,372,518.8	2,037.2	0.9	0.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/05/2015 00:00	11.7	13.8	9.7	88.6	2,480,972.7	1,286.3	0.8	0.4
02/05/2015 01:00	11.8	13.8	9.8	90.2	2,484,830.2	1,288.3	0.8	0.4
02/05/2015 02:00	11.7	13.8	9.7	90.1	2,492,352.4	1,292.2	0.8	0.4
02/05/2015 03:00	11.8	13.8	9.8	91.5	2,492,352.4	1,292.2	0.8	0.4
02/05/2015 04:00	11.1	13.8	9.2	98.6	2,738,077.3	1,419.6	0.8	0.4
02/05/2015 05:00	10.7	13.7	8.8	106.1	2,991,723.3	1,594.8	0.8	0.5
02/05/2015 06:00	10.6	13.5	8.5	124.7	3,348,418.2	1,907.2	0.8	0.6
02/05/2015 07:00	10.8	13.5	8.6	126.4	3,388,025.3	1,954.5	0.8	0.6
02/05/2015 08:00	11.2	13.8	9.3	98.1	2,709,748.5	1,424.7	0.8	0.4
02/05/2015 09:00	11.9	13.8	9.9	91.8	2,484,251.6	1,288.0	0.8	0.4
02/05/2015 10:00	11.7	13.8	9.7	92.0	2,510,289.9	1,301.5	0.8	0.4
02/05/2015 11:00	11.4	13.8	9.5	90.9	2,556,387.4	1,325.4	0.8	0.4
02/05/2015 12:00	11.3	13.8	9.4	92.2	2,609,235.6	1,352.8	0.8	0.4
02/05/2015 13:00	10.1	13.8	8.4	100.8	3,084,483.8	1,599.2	0.7	0.5
02/05/2015 14:00	10.1	13.8	8.4	103.0	3,198,088.1	1,658.1	0.7	0.5
02/05/2015 15:00	10.0	13.8	8.3	100.7	3,150,458.6	1,610.4	0.7	0.5
02/05/2015 16:00	10.2	13.6	8.2	111.8	3,323,376.8	1,844.4	0.7	0.6
02/05/2015 17:00	10.3	13.6	8.3	115.3	3,339,083.5	1,877.5	0.8	0.6
02/05/2015 18:00	10.7	13.4	8.4	127.7	3,371,827.1	1,994.4	0.8	0.6
02/05/2015 19:00	10.6	13.4	8.3	126.5	3,379,568.2	1,974.3	0.8	0.6
02/05/2015 20:00	10.7	13.4	8.4	127.4	3,366,586.1	1,991.3	0.8	0.6
02/05/2015 21:00	10.6	13.5	8.5	123.0	3,349,783.2	1,956.9	0.8	0.6
02/05/2015 22:00	10.4	13.8	8.6	95.0	2,809,634.5	1,456.7	0.7	0.4
02/05/2015 23:00	11.0	13.8	9.1	86.3	2,482,901.4	1,287.3	0.7	0.4
Average/Sum#:	10.9	13.7	9.0	104.1	2,922,602.3	1,582.4	0.8	0.5
Minimum:	10.0	13.4	8.2	86.3	2,480,972.7	1,286.3	0.7	0.4
Maximum:	11.9	13.8	9.9	127.7	3,388,025.3	1,994.4	0.8	0.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/06/2015 00:00	10.9	13.8	9.1	86.2	2,510,482.8	1,301.6	0.7	0.4
02/06/2015 01:00	11.0	13.8	9.1	86.2	2,489,845.0	1,290.9	0.7	0.4
02/06/2015 02:00	11.0	13.8	9.1	86.3	2,475,765.0	1,283.6	0.8	0.4
02/06/2015 03:00	11.0	13.8	9.1	86.2	2,484,058.7	1,287.9	0.7	0.4
02/06/2015 04:00	10.5	13.8	8.7	85.7	2,608,753.5	1,333.5	0.7	0.4
02/06/2015 05:00	10.5	13.6	8.5	113.6	3,220,850.1	1,787.5	0.8	0.5
02/06/2015 06:00	10.4	13.6	8.4	136.7	3,267,514.2	1,932.7	0.9	0.6
02/06/2015 07:00	10.3	13.6	8.3	117.2	3,346,135.8	1,905.9	0.8	0.6
02/06/2015 08:00	9.9	13.7	8.1	110.0	3,329,322.9	1,847.7	0.7	0.6
02/06/2015 09:00	10.0	13.8	8.3	104.0	3,138,074.0	1,649.9	0.7	0.5
02/06/2015 10:00	10.0	13.7	8.2	107.0	3,295,988.3	1,829.2	0.7	0.5
02/06/2015 11:00	9.9	13.7	8.1	105.6	3,333,827.6	1,850.2	0.7	0.6
02/06/2015 12:00	9.9	13.7	8.1	99.4	3,051,914.4	1,604.6	0.7	0.5
02/06/2015 13:00	9.9	13.6	8.0	106.7	3,299,423.5	1,855.2	0.7	0.6
02/06/2015 14:00	9.9	13.6	8.0	106.6	3,287,329.9	1,848.4	0.7	0.6
02/06/2015 15:00	9.9	13.7	8.1	106.8	3,335,809.7	1,851.3	0.7	0.6
02/06/2015 16:00	10.1	13.6	8.2	110.9	3,346,553.1	1,881.7	0.7	0.6
02/06/2015 17:00	10.5	13.3	8.2	118.9	3,313,842.0	2,008.5	0.8	0.6
02/06/2015 18:00	10.6	13.3	8.2	125.0	3,263,370.2	2,049.4	0.9	0.6
02/06/2015 19:00	10.5	13.3	8.2	118.8	3,273,739.4	2,008.1	0.8	0.6
02/06/2015 20:00	10.6	13.3	8.2	123.6	3,276,790.9	2,033.9	0.8	0.6
02/06/2015 21:00	10.1	13.5	8.1	110.8	3,301,526.2	1,904.6	0.7	0.6
02/06/2015 22:00	10.0	13.8	8.3	85.7	2,645,496.5	1,371.6	0.7	0.4
02/06/2015 23:00	9.9	13.7	8.1	95.8	3,058,252.5	1,585.6	0.7	0.5
Average/Sum#:	10.3	13.6	8.4	105.6	3,081,444.4	1,721.0	0.7	0.5
Minimum:	9.9	13.3	8.0	85.7	2,475,765.0	1,283.6	0.7	0.4
Maximum:	11.0	13.8	9.1	136.7	3,346,553.1	2,049.4	0.9	0.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/07/2015 00:00	10.2	13.8	8.5	85.4	2,527,263.1	1,310.3	0.7	0.4
02/07/2015 01:00	10.3	13.8	8.6	95.0	2,785,139.2	1,444.0	0.7	0.4
02/07/2015 02:00	10.3	13.8	8.6	90.8	2,728,480.3	1,394.7	0.7	0.4
02/07/2015 03:00	10.6	13.8	8.8	86.0	2,624,990.9	1,341.8	0.7	0.4
02/07/2015 04:00	10.6	13.8	8.8	86.6	2,629,686.1	1,344.2	0.7	0.4
02/07/2015 05:00	10.8	13.8	9.0	88.5	2,599,558.7	1,328.8	0.7	0.4
02/07/2015 06:00	11.0	13.8	9.1	86.9	2,602,688.9	1,330.4	0.7	0.4
02/07/2015 07:00	11.1	13.8	9.2	87.1	2,534,785.2	1,314.2	0.7	0.4
02/07/2015 08:00	11.6	13.8	9.6	87.5	2,479,429.6	1,285.5	0.8	0.4
02/07/2015 09:00	11.3	13.7	9.3	87.0	2,515,883.3	1,304.4	0.7	0.4
02/07/2015 10:00	10.3	13.8	8.6	85.6	2,610,392.9	1,353.4	0.7	0.4
02/07/2015 11:00	10.7	13.8	8.9	85.9	2,571,817.6	1,333.4	0.7	0.4
02/07/2015 12:00	11.3	13.8	9.4	86.9	2,494,859.8	1,293.5	0.7	0.4
02/07/2015 13:00	11.3	13.8	9.4	87.5	2,507,203.9	1,299.9	0.7	0.4
02/07/2015 14:00	10.5	13.8	8.7	86.0	2,588,405.0	1,342.0	0.7	0.4
02/07/2015 15:00	10.9	13.8	9.1	86.8	2,544,429.1	1,319.2	0.7	0.4
02/07/2015 16:00	10.1	13.7	8.3	98.8	3,039,196.8	1,642.3	0.7	0.5
02/07/2015 17:00	10.0	13.5	8.0	110.0	3,307,159.9	1,883.7	0.7	0.6
02/07/2015 18:00	10.8	13.3	8.4	124.9	3,286,940.7	2,040.2	0.8	0.6
02/07/2015 19:00	10.5	13.4	8.3	118.9	3,299,805.6	1,951.8	0.8	0.6
02/07/2015 20:00	10.7	13.3	8.3	124.4	3,292,650.5	2,019.7	0.8	0.6
02/07/2015 21:00	9.9	13.6	8.0	103.5	3,150,041.3	1,725.2	0.7	0.5
02/07/2015 22:00	10.8	13.7	8.9	90.4	2,666,327.1	1,382.4	0.7	0.4
02/07/2015 23:00	11.6	13.7	9.5	87.2	2,478,658.1	1,285.1	0.8	0.4
Average/Sum#:	10.7	13.7	8.8	94.1	2,744,408.1	1,469.6	0.7	0.4
Minimum:	9.9	13.3	8.0	85.4	2,478,658.1	1,285.1	0.7	0.4
Maximum:	11.6	13.8	9.6	124.9	3,307,159.9	2,040.2	0.8	0.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/08/2015 00:00	11.2	13.7	9.2	87.0	2,522,826.9	1,308.0	0.7	0.4
02/08/2015 01:00	10.6	13.8	8.8	86.0	2,588,019.2	1,341.8	0.7	0.4
02/08/2015 02:00	10.7	13.8	8.9	86.2	2,576,446.6	1,335.8	0.7	0.4
02/08/2015 03:00	11.6	13.7	9.5	87.6	2,487,530.5	1,289.7	0.8	0.4
02/08/2015 04:00	11.6	13.7	9.5	87.5	2,485,601.7	1,288.7	0.8	0.4
02/08/2015 05:00	11.6	13.7	9.5	87.2	2,479,622.5	1,285.6	0.8	0.4
02/08/2015 06:00	11.1	13.7	9.1	86.7	2,558,702.0	1,326.6	0.7	0.4
02/08/2015 07:00	11.0	13.8	9.1	86.3	2,531,313.5	1,312.4	0.7	0.4
02/08/2015 08:00	11.5	13.7	9.4	87.0	2,475,186.4	1,283.3	0.8	0.4
02/08/2015 09:00	11.4	13.7	9.3	86.9	2,479,043.9	1,285.3	0.8	0.4
02/08/2015 10:00	11.4	13.7	9.3	86.9	2,480,008.3	1,285.8	0.8	0.4
02/08/2015 11:00	11.2	13.7	9.2	86.7	2,485,987.4	1,288.9	0.8	0.4
02/08/2015 12:00	10.7	13.8	8.9	86.0	2,535,749.6	1,314.7	0.7	0.4
02/08/2015 13:00	10.5	13.8	8.7	85.6	2,551,565.5	1,322.9	0.7	0.4
02/08/2015 14:00	11.0	13.8	9.1	86.4	2,501,610.5	1,297.0	0.7	0.4
02/08/2015 15:00	11.2	13.8	9.3	87.1	2,503,153.5	1,297.8	0.7	0.4
02/08/2015 16:00	10.3	13.6	8.3	112.2	3,249,092.7	1,826.9	0.8	0.5
02/08/2015 17:00	10.4	13.5	8.3	118.2	3,333,248.3	1,922.9	0.8	0.6
02/08/2015 18:00	10.9	13.3	8.5	131.0	3,262,733.2	2,049.0	0.9	0.6
02/08/2015 19:00	10.8	13.3	8.4	125.2	3,308,562.3	2,005.3	0.8	0.6
02/08/2015 20:00	10.9	13.3	8.5	129.8	3,308,464.1	2,029.4	0.9	0.6
02/08/2015 21:00	10.8	13.5	8.6	116.1	3,083,805.0	1,779.0	0.8	0.5
02/08/2015 22:00	10.8	13.8	9.0	87.1	2,606,601.5	1,332.4	0.7	0.4
02/08/2015 23:00	10.7	13.7	8.8	103.6	2,943,105.2	1,525.9	0.8	0.5
Average/Sum#:	11.0	13.7	9.0	96.3	2,722,415.8	1,472.3	0.8	0.4
Minimum:	10.3	13.3	8.3	85.6	2,475,186.4	1,283.3	0.7	0.4
Maximum:	11.6	13.8	9.5	131.0	3,333,248.3	2,049.0	0.9	0.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/09/2015 00:00	11.4	13.8	9.5	88.4	2,523,598.4	1,308.4	0.7	0.4
02/09/2015 01:00	11.2	13.8	9.3	89.3	2,576,669.8	1,317.1	0.7	0.4
02/09/2015 02:00	11.9	13.8	9.9	90.8	2,480,201.1	1,285.9	0.8	0.4
02/09/2015 03:00	12.0	13.8	10.0	90.7	2,480,394.0	1,286.0	0.8	0.4
02/09/2015 04:00	12.0	13.8	10.0	91.6	2,480,972.7	1,286.3	0.8	0.4
02/09/2015 05:00	11.4	13.8	9.5	89.8	2,583,712.5	1,320.7	0.7	0.4
02/09/2015 06:00	11.0	13.6	8.9	130.2	3,043,457.9	1,733.5	0.9	0.5
02/09/2015 07:00	10.4	13.6	8.4	112.7	3,303,691.9	1,857.6	0.7	0.6
02/09/2015 08:00	10.4	13.6	8.4	114.4	3,341,395.5	1,854.4	0.7	0.6
02/09/2015 09:00	10.7	13.7	8.8	97.5	2,732,470.6	1,456.6	0.8	0.4
02/09/2015 10:00	11.2	13.8	9.3	86.6	2,487,144.7	1,289.5	0.7	0.4
02/09/2015 11:00	11.2	13.8	9.3	86.6	2,485,023.1	1,288.4	0.7	0.4
02/09/2015 12:00	11.3	13.8	9.4	87.0	2,482,322.8	1,287.0	0.8	0.4
02/09/2015 13:00	11.5	13.8	9.6	88.8	2,485,601.7	1,288.7	0.8	0.4
02/09/2015 14:00	11.6	13.8	9.6	89.2	2,490,423.6	1,291.2	0.8	0.4
02/09/2015 15:00	11.6	13.8	9.6	88.9	2,486,951.8	1,289.4	0.8	0.4
02/09/2015 16:00	11.4	13.8	9.5	87.7	2,485,794.6	1,288.8	0.8	0.4
02/09/2015 17:00	10.5	13.7	8.6	109.9	3,208,835.2	1,757.4	0.7	0.5
02/09/2015 18:00	10.4	13.6	8.4	113.4	3,281,283.1	1,845.0	0.8	0.6
02/09/2015 19:00	10.6	13.6	8.6	117.0	3,314,540.6	1,863.7	0.8	0.6
02/09/2015 20:00	10.5	13.6	8.5	118.8	3,399,415.8	1,886.6	0.8	0.6
02/09/2015 21:00	10.6	13.7	8.7	104.2	3,068,261.0	1,635.6	0.7	0.5
02/09/2015 22:00	11.5	13.8	9.6	92.9	2,558,123.3	1,326.3	0.8	0.4
02/09/2015 23:00	12.1	13.8	10.1	94.8	2,544,814.8	1,319.4	0.8	0.4
Average/Sum#:	11.2	13.7	9.2	98.4	2,763,545.9	1,473.5	0.8	0.5
Minimum:	10.4	13.6	8.4	86.6	2,480,201.1	1,285.9	0.7	0.4
Maximum:	12.1	13.8	10.1	130.2	3,399,415.8	1,886.6	0.9	0.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/10/2015 00:00	12.4	13.8	10.3	94.9	2,496,402.8	1,294.3	0.8	0.4
02/10/2015 01:00	12.4	13.8	10.3	96.3	2,504,117.9	1,298.3	0.8	0.4
02/10/2015 02:00	12.6	13.8	10.5	97.3	2,491,773.7	1,291.9	0.8	0.4
02/10/2015 03:00	12.4	13.8	10.3	94.6	2,498,717.3	1,295.5	0.8	0.4
02/10/2015 04:00	12.5	13.8	10.4	96.7	2,505,853.7	1,299.2	0.8	0.4
02/10/2015 05:00	12.2	13.8	10.1	98.7	2,568,538.7	1,331.7	0.8	0.4
02/10/2015 06:00	11.3	13.5	9.0	139.5	3,377,676.4	1,899.2	0.9	0.6
02/10/2015 07:00	11.2	13.5	8.9	125.8	3,404,424.1	1,939.1	0.8	0.6
02/10/2015 08:00	11.3	13.7	9.3	105.2	2,858,720.3	1,523.9	0.8	0.5
02/10/2015 09:00	12.5	13.8	10.4	96.3	2,501,224.7	1,296.8	0.8	0.4
02/10/2015 10:00	12.4	13.8	10.3	96.0	2,496,981.4	1,294.6	0.8	0.4
02/10/2015 11:00	12.4	13.8	10.3	96.1	2,501,224.7	1,296.8	0.8	0.4
02/10/2015 12:00	12.4	13.8	10.3	97.3	2,501,803.3	1,297.1	0.8	0.4
02/10/2015 13:00	12.4	13.8	10.3	96.7	2,496,402.8	1,294.3	0.8	0.4
02/10/2015 14:00	12.4	13.8	10.3	98.3	2,498,524.4	1,295.4	0.8	0.4
02/10/2015 15:00	12.3	13.8	10.2	94.6	2,501,031.8	1,296.7	0.8	0.4
02/10/2015 16:00	10.9	13.5	8.7	118.4	3,285,907.1	1,847.6	0.8	0.6
02/10/2015 17:00	11.2	13.4	8.8	130.4	3,338,556.4	1,999.1	0.9	0.6
02/10/2015 18:00	11.3	13.3	8.8	135.6	3,334,874.4	2,045.6	0.9	0.6
02/10/2015 19:00	11.3	13.3	8.8	136.5	3,343,351.8	2,050.8	0.9	0.6
02/10/2015 20:00	11.4	13.4	9.0	138.4	3,359,544.5	2,036.2	0.9	0.6
02/10/2015 21:00	11.2	13.4	8.8	130.9	3,353,230.0	1,983.4	0.9	0.6
02/10/2015 22:00	11.4	13.4	9.0	137.9	3,355,089.7	2,033.5	0.9	0.6
02/10/2015 23:00	11.2	13.4	8.8	133.0	3,426,096.9	2,026.5	0.9	0.6
Average/Sum#:	11.9	13.6	9.7	111.9	2,875,002.9	1,594.5	0.8	0.5
Minimum:	10.9	13.3	8.7	94.6	2,491,773.7	1,291.9	0.8	0.4
Maximum:	12.6	13.8	10.5	139.5	3,426,096.9	2,050.8	0.9	0.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/11/2015 00:00	11.3	13.4	8.9	132.0	3,389,158.3	2,029.4	0.9	0.6
02/11/2015 01:00	10.9	13.6	8.8	123.1	3,394,216.2	1,908.5	0.8	0.6
02/11/2015 02:00	10.8	13.6	8.7	115.8	3,285,907.1	1,847.6	0.8	0.6
02/11/2015 03:00	10.9	13.6	8.8	118.8	3,288,752.7	1,849.2	0.8	0.6
02/11/2015 04:00	11.0	13.6	8.9	121.2	3,286,974.2	1,848.2	0.8	0.6
02/11/2015 05:00	11.0	13.6	8.9	119.3	3,334,815.1	1,875.1	0.8	0.6
02/11/2015 06:00	11.0	13.5	8.8	139.7	3,343,302.3	1,928.7	0.9	0.6
02/11/2015 07:00	10.8	13.6	8.7	116.9	3,313,651.3	1,863.2	0.8	0.6
02/11/2015 08:00	10.8	13.6	8.7	115.7	3,336,350.2	1,851.6	0.8	0.6
02/11/2015 09:00	10.7	13.6	8.6	113.7	3,299,245.7	1,855.1	0.7	0.6
02/11/2015 10:00	10.7	13.7	8.8	104.0	2,946,483.1	1,592.2	0.8	0.5
02/11/2015 11:00	10.9	13.8	9.1	94.4	2,788,225.2	1,445.6	0.7	0.4
02/11/2015 12:00	10.7	13.8	8.9	95.7	2,876,369.8	1,491.3	0.7	0.4
02/11/2015 13:00	11.4	13.8	9.5	86.7	2,493,509.6	1,292.8	0.7	0.4
02/11/2015 14:00	11.4	13.8	9.5	87.2	2,500,260.3	1,296.3	0.7	0.4
02/11/2015 15:00	10.8	13.7	8.9	104.6	2,906,743.9	1,549.5	0.8	0.5
02/11/2015 16:00	10.5	13.6	8.5	116.9	3,354,556.2	1,886.2	0.8	0.6
02/11/2015 17:00	10.7	13.5	8.5	122.6	3,372,250.9	1,945.4	0.8	0.6
02/11/2015 18:00	11.0	13.3	8.5	132.4	3,335,526.5	2,046.0	0.9	0.6
02/11/2015 19:00	11.0	13.4	8.7	127.5	3,364,274.9	2,014.5	0.8	0.6
02/11/2015 20:00	11.0	13.4	8.7	129.3	3,373,293.1	2,019.9	0.8	0.6
02/11/2015 21:00	10.7	13.4	8.4	123.5	3,389,154.2	1,979.9	0.8	0.6
02/11/2015 22:00	10.7	13.4	8.4	122.8	3,362,697.7	1,989.0	0.8	0.6
02/11/2015 23:00	10.3	13.6	8.3	112.5	3,308,849.4	1,860.5	0.7	0.6
Average/Sum#:	10.9	13.6	8.8	115.7	3,193,523.7	1,802.7	0.8	0.6
Minimum:	10.3	13.3	8.3	86.7	2,493,509.6	1,292.8	0.7	0.4
Maximum:	11.4	13.8	9.5	139.7	3,394,216.2	2,046.0	0.9	0.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/12/2015 00:00	11.5	13.8	9.6	97.5	2,679,697.2	1,408.9	0.8	0.4
02/12/2015 01:00	11.5	13.8	9.6	92.6	2,636,624.1	1,367.0	0.8	0.4
02/12/2015 02:00	11.3	13.8	9.4	87.0	2,512,025.8	1,302.4	0.7	0.4
02/12/2015 03:00	10.7	13.8	8.9	93.6	2,850,138.6	1,477.7	0.7	0.4
02/12/2015 04:00	10.9	13.7	8.9	106.0	2,961,472.8	1,600.3	0.8	0.5
02/12/2015 05:00	10.7	13.5	8.5	119.1	3,399,729.4	1,911.6	0.8	0.6
02/12/2015 06:00	10.8	13.5	8.6	135.0	3,329,261.4	1,920.6	0.9	0.6
02/12/2015 07:00	10.9	13.5	8.7	123.7	3,355,609.8	1,935.8	0.8	0.6
02/12/2015 08:00	10.9	13.7	8.9	103.6	2,924,752.8	1,559.1	0.8	0.5
02/12/2015 09:00	11.3	13.8	9.4	87.0	2,487,916.2	1,289.9	0.7	0.4
02/12/2015 10:00	11.3	13.8	9.4	86.8	2,489,845.0	1,290.9	0.7	0.4
02/12/2015 11:00	11.4	13.8	9.5	86.9	2,492,545.3	1,292.3	0.7	0.4
02/12/2015 12:00	11.9	13.8	9.9	94.3	2,500,067.4	1,296.2	0.8	0.4
02/12/2015 13:00	10.7	13.7	8.8	109.0	3,179,727.3	1,671.8	0.7	0.5
02/12/2015 14:00	11.1	13.3	8.6	137.7	3,300,312.8	2,000.3	0.9	0.6
02/12/2015 15:00	10.4	13.5	8.3	118.2	3,279,338.0	1,891.8	0.8	0.6
02/12/2015 16:00	10.5	13.5	8.4	120.9	3,292,609.8	1,923.5	0.8	0.6
02/12/2015 17:00	11.0	13.4	8.7	126.9	3,306,992.9	1,980.2	0.8	0.6
02/12/2015 18:00	11.1	13.3	8.6	132.1	3,286,296.3	2,039.8	0.9	0.6
02/12/2015 19:00	11.0	13.3	8.5	132.5	3,302,085.0	2,049.6	0.9	0.6
02/12/2015 20:00	11.0	13.3	8.5	129.9	3,324,603.7	2,039.3	0.9	0.6
02/12/2015 21:00	10.5	13.4	8.3	120.9	3,365,189.2	1,965.9	0.8	0.6
02/12/2015 22:00	10.7	13.3	8.3	122.7	3,339,892.5	1,999.9	0.8	0.6
02/12/2015 23:00	10.2	13.7	8.4	102.1	3,077,400.9	1,618.0	0.7	0.5
Average/Sum#:	11.0	13.6	8.9	111.1	3,028,088.9	1,701.4	0.8	0.5
Minimum:	10.2	13.3	8.3	86.8	2,487,916.2	1,289.9	0.7	0.4
Maximum:	11.9	13.8	9.9	137.7	3,399,729.4	2,049.6	0.9	0.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/13/2015 00:00	10.2	13.7	8.4	107.7	3,317,285.9	1,719.9	0.7	0.5
02/13/2015 01:00	10.8	13.8	9.0	95.9	2,852,453.1	1,478.9	0.7	0.4
02/13/2015 02:00	11.0	13.8	9.1	95.7	2,839,144.6	1,472.0	0.7	0.4
02/13/2015 03:00	10.4	13.7	8.5	108.7	3,374,763.2	1,749.7	0.7	0.5
02/13/2015 04:00	10.7	13.8	8.9	102.0	2,996,532.0	1,553.6	0.7	0.5
02/13/2015 05:00	11.0	13.7	9.0	106.5	2,982,682.4	1,568.2	0.8	0.5
02/13/2015 06:00	10.6	13.6	8.6	141.5	3,362,639.1	1,915.3	0.9	0.6
02/13/2015 07:00	10.6	13.6	8.6	112.4	3,368,072.6	1,893.8	0.7	0.6
02/13/2015 08:00	11.3	13.8	9.4	99.0	2,763,954.9	1,453.2	0.8	0.4
02/13/2015 09:00	12.0	13.8	10.0	91.6	2,496,981.4	1,294.6	0.8	0.4
02/13/2015 10:00	12.0	13.8	10.0	91.3	2,497,174.3	1,294.7	0.8	0.4
02/13/2015 11:00	12.0	13.8	10.0	93.8	2,510,868.5	1,301.8	0.8	0.4
02/13/2015 12:00	11.3	13.8	9.4	94.9	2,699,309.0	1,399.5	0.8	0.4
02/13/2015 13:00	10.1	13.7	8.3	102.8	3,133,889.7	1,647.7	0.7	0.5
02/13/2015 14:00	10.4	13.5	8.3	113.2	3,304,350.8	1,882.1	0.7	0.6
02/13/2015 15:00	9.9	13.7	8.1	107.3	3,334,908.7	1,850.8	0.7	0.6
02/13/2015 16:00	10.2	13.6	8.2	112.7	3,341,751.2	1,879.0	0.7	0.6
02/13/2015 17:00	10.4	13.5	8.3	118.1	3,313,493.5	1,935.7	0.8	0.6
02/13/2015 18:00	10.9	13.3	8.5	128.6	3,319,451.7	2,011.9	0.9	0.6
02/13/2015 19:00	11.0	13.3	8.5	131.2	3,290,324.0	2,042.3	0.9	0.6
02/13/2015 20:00	11.0	13.3	8.5	130.8	3,306,344.8	2,028.1	0.9	0.6
02/13/2015 21:00	11.0	13.3	8.5	126.7	3,310,542.2	2,006.5	0.8	0.6
02/13/2015 22:00	11.0	13.3	8.5	127.5	3,338,095.7	2,023.2	0.8	0.6
02/13/2015 23:00	10.5	13.5	8.4	117.6	3,340,517.7	1,902.7	0.8	0.6
Average/Sum#:	10.8	13.6	8.8	110.7	3,099,813.8	1,721.1	0.8	0.5
Minimum:	9.9	13.3	8.1	91.3	2,496,981.4	1,294.6	0.7	0.4
Maximum:	12.0	13.8	10.0	141.5	3,374,763.2	2,042.3	0.9	0.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/14/2015 00:00	11.0	13.4	8.7	126.3	3,366,248.0	1,991.1	0.8	0.6
02/14/2015 01:00	10.7	13.4	8.4	120.6	3,380,252.9	1,974.7	0.8	0.6
02/14/2015 02:00	10.8	13.3	8.4	120.0	3,378,589.7	1,998.4	0.8	0.6
02/14/2015 03:00	10.8	13.4	8.5	125.1	3,377,237.2	1,997.6	0.8	0.6
02/14/2015 04:00	10.7	13.4	8.4	123.0	3,355,089.7	1,984.5	0.8	0.6
02/14/2015 05:00	10.4	13.6	8.4	111.4	3,305,114.6	1,858.4	0.7	0.6
02/14/2015 06:00	10.7	13.7	8.8	106.6	2,875,598.3	1,490.9	0.8	0.4
02/14/2015 07:00	11.4	13.8	9.5	87.6	2,522,248.3	1,307.7	0.7	0.4
02/14/2015 08:00	11.6	13.8	9.6	90.2	2,502,960.6	1,297.7	0.8	0.4
02/14/2015 09:00	11.8	13.7	9.7	89.8	2,527,263.1	1,310.3	0.8	0.4
02/14/2015 10:00	11.9	13.8	9.9	93.0	2,516,269.1	1,304.6	0.8	0.4
02/14/2015 11:00	12.0	13.8	10.0	93.6	2,510,289.9	1,301.5	0.8	0.4
02/14/2015 12:00	11.9	13.8	9.9	93.2	2,511,640.0	1,302.2	0.8	0.4
02/14/2015 13:00	12.0	13.8	10.0	95.3	2,545,955.6	1,301.4	0.8	0.4
02/14/2015 14:00	12.1	13.8	10.1	95.2	2,541,260.4	1,299.0	0.8	0.4
02/14/2015 15:00	12.0	13.8	10.0	94.1	2,537,347.8	1,297.0	0.8	0.4
02/14/2015 16:00	11.5	13.6	9.3	110.2	2,857,897.4	1,565.2	0.8	0.5
02/14/2015 17:00	10.8	13.5	8.6	122.0	3,297,019.2	1,902.0	0.8	0.6
02/14/2015 18:00	10.5	13.5	8.4	120.5	3,289,218.7	1,897.5	0.8	0.6
02/14/2015 19:00	11.4	13.3	8.9	139.2	3,265,281.0	2,050.6	0.9	0.6
02/14/2015 20:00	10.8	13.4	8.5	126.2	3,288,816.4	1,945.3	0.8	0.6
02/14/2015 21:00	10.7	13.5	8.5	123.2	3,304,934.6	1,930.7	0.8	0.6
02/14/2015 22:00	11.0	13.4	8.7	128.0	3,277,874.0	1,986.7	0.9	0.6
02/14/2015 23:00	11.4	13.8	9.5	99.7	2,753,314.5	1,427.5	0.8	0.4
Average/Sum#:	11.2	13.6	9.1	109.8	2,961,988.4	1,655.1	0.8	0.5
Minimum:	10.4	13.3	8.4	87.6	2,502,960.6	1,297.0	0.7	0.4
Maximum:	12.1	13.8	10.1	139.2	3,380,252.9	2,050.6	0.9	0.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/15/2015 00:00	11.0	13.8	9.1	90.8	2,718,111.8	1,389.4	0.7	0.4
02/15/2015 01:00	10.7	13.8	8.9	93.7	2,817,928.2	1,461.0	0.7	0.4
02/15/2015 02:00	32.2	16.1	39.6	204.4	1,517,375.9	565.1	2.9	0.6
02/15/2015 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2015 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2015 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2015 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2015 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2015 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2015 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2015 10:00	47.1	16.8	67.8	70.5	1,932,368.8	522.1	0.5	0.1
02/15/2015 11:00	54.4	14.8	52.6	240.8	2,185,242.1	973.4	2.2	0.8
02/15/2015 12:00	10.8	13.8	9.0	88.7	2,588,799.0	1,323.3	0.7	0.4
02/15/2015 13:00	10.7	13.8	8.9	85.6	2,576,278.5	1,316.9	0.7	0.4
02/15/2015 14:00	10.4	13.7	8.5	103.7	3,057,288.2	1,585.1	0.7	0.5
02/15/2015 15:00	10.5	13.6	8.5	109.2	3,311,344.2	1,741.0	0.7	0.5
02/15/2015 16:00	10.6	13.6	8.6	110.2	3,312,485.4	1,741.6	0.7	0.5
02/15/2015 17:00	10.5	13.9	8.9	91.0	2,739,826.9	1,400.5	0.7	0.4
02/15/2015 18:00	11.3	13.8	9.4	98.4	2,812,210.8	1,437.5	0.8	0.4
02/15/2015 19:00	11.4	13.4	9.0	124.2	3,298,601.0	1,927.0	0.8	0.6
02/15/2015 20:00	11.4	13.4	9.0	128.5	3,323,526.2	1,990.1	0.8	0.6
02/15/2015 21:00	11.1	13.4	8.7	124.5	3,346,636.5	1,979.5	0.8	0.6
02/15/2015 22:00	11.1	13.4	8.7	124.8	3,343,593.3	1,977.7	0.8	0.6
02/15/2015 23:00	11.2	13.4	8.8	125.7	3,341,395.5	1,976.4	0.8	0.6
Average/Sum#:	16.8	14.0	16.7	118.5	2,836,647.8	1,488.7	0.9	0.5
Minimum:	10.4	13.4	8.5	70.5	1,517,375.9	522.1	0.5	0.1
Maximum:	54.4	16.8	67.8	240.8	3,346,636.5	1,990.1	2.9	0.8
%SI	29.2	29.2	29.2	29.2	29.2	29.2	29.2	29.2

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/16/2015 00:00	11.0	13.4	8.7	122.0	3,401,307.8	1,987.0	0.8	0.6
02/16/2015 01:00	10.6	13.5	8.5	116.4	3,351,578.4	1,909.0	0.8	0.6
02/16/2015 02:00	10.5	13.6	8.5	111.3	3,323,016.4	1,844.2	0.7	0.6
02/16/2015 03:00	10.4	13.6	8.4	107.6	3,324,818.3	1,845.2	0.7	0.6
02/16/2015 04:00	10.5	13.6	8.5	110.6	3,341,755.9	1,854.6	0.7	0.6
02/16/2015 05:00	10.6	13.5	8.5	113.6	3,365,049.2	1,892.1	0.7	0.6
02/16/2015 06:00	10.5	13.6	8.5	116.3	3,368,432.8	1,918.6	0.8	0.6
02/16/2015 07:00	10.4	13.6	8.4	109.4	3,295,333.0	1,852.9	0.7	0.6
02/16/2015 08:00	10.4	13.6	8.4	109.3	3,341,035.1	1,854.2	0.7	0.6
02/16/2015 09:00	10.3	13.7	8.4	108.8	3,339,053.1	1,853.1	0.7	0.6
02/16/2015 10:00	10.2	13.7	8.4	108.3	3,341,575.7	1,854.5	0.7	0.6
02/16/2015 11:00	10.1	13.7	8.3	106.8	3,335,269.1	1,851.0	0.7	0.6
02/16/2015 12:00	10.1	13.7	8.3	109.0	3,334,728.6	1,850.7	0.7	0.6
02/16/2015 13:00	10.8	13.7	8.9	103.1	2,890,225.7	1,561.8	0.8	0.5
02/16/2015 14:00	11.8	13.8	9.8	93.3	2,523,262.2	1,289.8	0.8	0.4
02/16/2015 15:00	11.2	13.7	9.2	105.1	2,895,488.4	1,543.5	0.8	0.5
02/16/2015 16:00	10.7	13.5	8.5	119.0	3,329,632.5	1,896.5	0.8	0.6
02/16/2015 17:00	11.0	13.4	8.7	124.5	3,293,888.3	1,948.3	0.8	0.6
02/16/2015 18:00	11.4	13.3	8.9	137.2	3,281,624.2	2,036.9	0.9	0.6
02/16/2015 19:00	11.3	13.3	8.8	133.8	3,272,602.1	2,031.3	0.9	0.6
02/16/2015 20:00	10.1	13.7	8.3	110.4	3,296,933.7	1,853.8	0.7	0.6
02/16/2015 21:00	10.2	13.6	8.2	110.1	3,335,170.8	1,875.3	0.7	0.6
02/16/2015 22:00	10.6	13.5	8.5	119.7	3,325,274.4	1,918.3	0.8	0.6
02/16/2015 23:00	10.2	13.7	8.4	108.7	3,329,503.1	1,847.8	0.7	0.6
Average/Sum#:	10.6	13.6	8.6	113.1	3,259,856.6	1,840.4	0.8	0.6
Minimum:	10.1	13.3	8.2	93.3	2,523,262.2	1,289.8	0.7	0.4
Maximum:	11.8	13.8	9.8	137.2	3,401,307.8	2,036.9	0.9	0.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/17/2015 00:00	10.5	13.6	8.5	110.8	3,295,510.9	1,853.0	0.7	0.6
02/17/2015 01:00	10.5	13.6	8.5	111.2	3,301,202.0	1,856.2	0.7	0.6
02/17/2015 02:00	10.4	13.7	8.5	110.6	3,341,395.5	1,854.4	0.7	0.6
02/17/2015 03:00	10.4	13.7	8.5	110.8	3,343,197.4	1,855.4	0.7	0.6
02/17/2015 04:00	10.4	13.7	8.5	113.3	3,341,215.3	1,854.3	0.7	0.6
02/17/2015 05:00	10.6	13.6	8.6	114.4	3,312,584.2	1,862.6	0.8	0.6
02/17/2015 06:00	10.7	13.6	8.6	118.0	3,343,707.5	1,880.1	0.8	0.6
02/17/2015 07:00	10.6	13.5	8.5	116.8	3,393,012.3	1,932.6	0.7	0.6
02/17/2015 08:00	10.3	13.6	8.3	109.6	3,296,933.7	1,853.8	0.7	0.6
02/17/2015 09:00	10.6	13.7	8.7	99.6	2,865,983.2	1,548.7	0.8	0.5
02/17/2015 10:00	11.0	13.8	9.1	91.4	2,718,789.6	1,409.6	0.7	0.4
02/17/2015 11:00	10.3	13.8	8.6	98.3	3,035,107.3	1,573.6	0.7	0.5
02/17/2015 12:00	10.2	13.8	8.5	97.0	2,998,846.5	1,554.8	0.7	0.5
02/17/2015 13:00	10.7	13.8	8.9	87.4	2,536,906.9	1,315.3	0.7	0.4
02/17/2015 14:00	10.8	13.8	9.0	85.9	2,492,352.4	1,292.2	0.7	0.4
02/17/2015 15:00	10.7	13.8	8.9	85.9	2,514,918.9	1,303.9	0.7	0.4
02/17/2015 16:00	10.4	13.6	8.4	98.7	2,968,875.1	1,604.3	0.7	0.5
02/17/2015 17:00	10.0	13.5	8.0	111.3	3,326,999.0	1,895.0	0.7	0.6
02/17/2015 18:00	10.9	13.3	8.5	123.8	3,311,561.6	2,031.3	0.8	0.6
02/17/2015 19:00	10.8	13.3	8.4	125.7	3,301,127.9	2,024.9	0.8	0.6
02/17/2015 20:00	10.6	13.4	8.3	120.3	3,348,665.3	1,980.7	0.8	0.6
02/17/2015 21:00	10.2	13.5	8.1	111.2	3,343,151.2	1,904.2	0.7	0.6
02/17/2015 22:00	10.5	13.4	8.3	115.5	3,153,442.0	1,842.2	0.8	0.6
02/17/2015 23:00	11.3	13.7	9.3	87.7	2,523,984.2	1,308.6	0.7	0.4
Average/Sum#:	10.6	13.6	8.6	106.5	3,100,394.6	1,724.7	0.7	0.5
Minimum:	10.0	13.3	8.0	85.9	2,492,352.4	1,292.2	0.7	0.4
Maximum:	11.3	13.8	9.3	125.7	3,393,012.3	2,031.3	0.8	0.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/18/2015 00:00	10.7	13.7	8.8	95.7	2,871,547.9	1,488.8	0.7	0.4
02/18/2015 01:00	10.5	13.7	8.6	95.3	2,924,010.4	1,516.0	0.7	0.5
02/18/2015 02:00	11.2	13.7	9.2	88.2	2,580,882.8	1,338.1	0.7	0.4
02/18/2015 03:00	11.4	13.7	9.3	87.0	2,521,862.5	1,307.5	0.7	0.4
02/18/2015 04:00	10.5	13.6	8.5	107.1	3,175,939.0	1,693.0	0.7	0.5
02/18/2015 05:00	10.6	13.6	8.6	115.5	3,370,918.2	1,895.4	0.7	0.6
02/18/2015 06:00	10.7	13.5	8.5	129.9	3,366,827.7	1,893.1	0.8	0.6
02/18/2015 07:00	10.7	13.5	8.5	120.8	3,444,453.5	1,961.9	0.8	0.6
02/18/2015 08:00	10.7	13.4	8.4	123.9	3,463,256.9	1,997.9	0.8	0.6
02/18/2015 09:00	10.8	13.4	8.5	125.0	3,471,404.1	2,002.6	0.8	0.6
02/18/2015 10:00	10.6	13.4	8.3	118.6	3,403,190.8	1,988.1	0.8	0.6
02/18/2015 11:00	10.2	13.6	8.2	107.8	3,304,758.9	1,858.2	0.7	0.6
02/18/2015 12:00	10.1	13.6	8.2	107.6	3,306,893.1	1,859.4	0.7	0.6
02/18/2015 13:00	9.9	13.6	8.0	106.7	3,301,913.4	1,856.6	0.7	0.6
02/18/2015 14:00	10.3	13.7	8.4	100.4	2,922,876.9	1,558.1	0.7	0.5
02/18/2015 15:00	10.0	13.7	8.2	101.2	3,191,144.6	1,654.5	0.7	0.5
02/18/2015 16:00	10.3	13.5	8.2	110.8	3,274,169.2	1,841.0	0.7	0.6
02/18/2015 17:00	10.6	13.3	8.2	118.9	3,341,729.5	2,001.0	0.8	0.6
02/18/2015 18:00	10.6	13.3	8.2	123.1	3,332,918.1	2,044.4	0.8	0.6
02/18/2015 19:00	10.5	13.3	8.2	119.1	3,325,721.4	2,015.7	0.8	0.6
02/18/2015 20:00	10.5	13.3	8.2	119.6	3,354,588.7	2,008.7	0.8	0.6
02/18/2015 21:00	10.4	13.4	8.2	118.5	3,366,417.1	1,991.2	0.8	0.6
02/18/2015 22:00	10.3	13.4	8.1	116.6	3,387,505.2	1,954.2	0.8	0.6
02/18/2015 23:00	10.2	13.6	8.2	109.5	3,339,972.7	1,878.0	0.7	0.6
Average/Sum#:	10.5	13.5	8.4	111.1	3,222,704.3	1,816.8	0.7	0.6
Minimum:	9.9	13.3	8.0	87.0	2,521,862.5	1,307.5	0.7	0.4
Maximum:	11.4	13.7	9.3	129.9	3,471,404.1	2,044.4	0.8	0.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/19/2015 00:00	10.3	13.4	8.1	115.5	3,350,694.1	1,981.9	0.8	0.6
02/19/2015 01:00	10.1	13.6	8.2	106.2	3,299,423.5	1,855.2	0.7	0.6
02/19/2015 02:00	10.9	13.7	8.9	95.0	2,720,019.2	1,430.1	0.8	0.4
02/19/2015 03:00	11.5	13.7	9.4	87.8	2,531,892.1	1,312.7	0.7	0.4
02/19/2015 04:00	11.3	13.7	9.3	100.2	2,734,474.2	1,437.7	0.8	0.4
02/19/2015 05:00	10.6	13.4	8.3	115.4	3,368,263.9	1,943.1	0.7	0.6
02/19/2015 06:00	10.5	13.5	8.4	119.0	3,330,440.1	1,945.6	0.8	0.6
02/19/2015 07:00	10.6	13.4	8.3	120.4	3,432,975.8	2,005.5	0.8	0.6
02/19/2015 08:00	10.6	13.3	8.2	119.2	3,402,089.7	2,012.3	0.8	0.6
02/19/2015 09:00	10.3	13.4	8.1	115.3	3,398,772.6	1,960.7	0.7	0.6
02/19/2015 10:00	10.6	13.3	8.2	119.0	3,371,258.8	2,043.3	0.8	0.6
02/19/2015 11:00	10.5	13.3	8.2	117.7	3,395,834.3	2,008.6	0.8	0.6
02/19/2015 12:00	10.3	13.4	8.1	114.5	3,353,720.3	1,959.2	0.7	0.6
02/19/2015 13:00	10.5	13.3	8.2	114.6	3,327,363.1	1,968.1	0.8	0.6
02/19/2015 14:00	9.6	13.6	7.8	104.8	3,290,175.5	1,850.0	0.7	0.6
02/19/2015 15:00	9.6	13.6	7.8	104.0	3,330,404.1	1,848.3	0.7	0.6
02/19/2015 16:00	9.8	13.6	7.9	108.5	3,335,882.2	1,875.7	0.7	0.6
02/19/2015 17:00	9.8	13.6	7.9	106.2	3,315,429.8	1,864.2	0.7	0.6
02/19/2015 18:00	10.2	13.4	8.0	114.2	3,363,306.3	1,964.8	0.7	0.6
02/19/2015 19:00	9.9	13.6	8.0	106.4	3,321,476.6	1,867.6	0.7	0.6
02/19/2015 20:00	9.9	13.6	8.0	105.5	3,290,709.0	1,850.3	0.7	0.6
02/19/2015 21:00	9.9	13.6	8.0	106.0	3,308,138.0	1,860.1	0.7	0.6
02/19/2015 22:00	10.1	13.5	8.1	110.6	3,329,983.6	1,896.7	0.7	0.6
02/19/2015 23:00	10.3	13.4	8.1	113.3	3,167,183.9	1,827.1	0.8	0.5
Average/Sum#:	10.3	13.5	8.2	110.0	3,252,912.9	1,857.0	0.7	0.6
Minimum:	9.6	13.3	7.8	87.8	2,531,892.1	1,312.7	0.7	0.4
Maximum:	11.5	13.7	9.4	120.4	3,432,975.8	2,043.3	0.8	0.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/20/2015 00:00	10.1	13.8	8.4	86.1	2,588,597.8	1,342.1	0.7	0.4
02/20/2015 01:00	27.2	15.9	32.1	185.5	1,637,252.2	621.7	2.4	0.6
02/20/2015 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2015 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2015 04:00	24.0	18.0	48.8	246.5	1,949,562.4	313.2	2.4	0.3
02/20/2015 05:00	35.2	14.4	32.0	185.0	2,437,789.4	1,139.3	1.5	0.7
02/20/2015 06:00	10.6	13.7	8.7	97.3	3,059,795.6	1,586.4	0.7	0.5
02/20/2015 07:00	10.1	13.8	8.4	109.1	3,459,821.8	1,793.8	0.7	0.5
02/20/2015 08:00	10.1	13.8	8.4	109.4	3,466,765.3	1,797.4	0.7	0.5
02/20/2015 09:00	10.2	13.7	8.4	110.1	3,483,931.4	1,806.3	0.7	0.5
02/20/2015 10:00	10.4	13.7	8.5	111.3	3,421,088.4	1,798.7	0.7	0.5
02/20/2015 11:00	10.8	13.7	8.9	112.9	3,265,887.0	1,717.1	0.7	0.5
02/20/2015 12:00	36.3	16.6	49.8	232.6	1,315,242.8	441.8	3.8	0.7
02/20/2015 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2015 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2015 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2015 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2015 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2015 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2015 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2015 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2015 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2015 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/20/2015 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	17.7	14.6	20.2	144.2	2,735,066.7	1,305.3	1.4	0.5
Minimum:	10.1	13.7	8.4	86.1	1,315,242.8	313.2	0.7	0.3
Maximum:	36.3	18.0	49.8	246.5	3,483,931.4	1,806.3	3.8	0.7
%SI	54.2	54.2	54.2	54.2	54.2	54.2	54.2	54.2

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/21/2015 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2015 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2015 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2015 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2015 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2015 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2015 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2015 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2015 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2015 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/21/2015 10:00	44.0	17.2	70.2	19.2	1,910,933.9	488.4	0.0	0.0
02/21/2015 11:00	63.6	15.5	69.5	257.0	1,866,728.3	736.1	2.7	0.7
02/21/2015 12:00	26.2	14.1	22.7	155.2	2,549,990.8	1,247.6	1.3	0.6
02/21/2015 13:00	12.0	13.8	10.0	87.9	2,504,285.9	1,280.1	0.7	0.4
02/21/2015 14:00	11.4	13.8	9.5	87.0	2,493,917.4	1,274.8	0.7	0.4
02/21/2015 15:00	10.4	13.8	8.6	86.1	2,673,116.4	1,366.4	0.7	0.4
02/21/2015 16:00	10.2	13.8	8.5	85.4	2,670,573.2	1,365.1	0.7	0.4
02/21/2015 17:00	10.4	13.7	8.5	95.8	2,868,944.1	1,508.4	0.7	0.5
02/21/2015 18:00	10.7	13.3	8.3	118.3	3,345,069.6	2,003.0	0.8	0.6
02/21/2015 19:00	10.8	13.3	8.4	126.7	3,341,232.5	2,049.5	0.8	0.6
02/21/2015 20:00	10.8	13.3	8.4	126.1	3,333,244.2	2,044.6	0.8	0.6
02/21/2015 21:00	10.7	13.3	8.3	122.6	3,391,438.7	2,006.0	0.8	0.6
02/21/2015 22:00	11.1	13.3	8.6	132.0	3,374,888.6	2,045.5	0.9	0.6
02/21/2015 23:00	11.1	13.5	8.9	127.2	3,345,332.6	1,954.3	0.8	0.6
Average/Sum#:	18.1	14.0	18.5	116.2	2,833,549.7	1,526.4	0.9	0.5
Minimum:	10.2	13.3	8.3	19.2	1,866,728.3	488.4	0.0	0.0
Maximum:	63.6	17.2	70.2	257.0	3,391,438.7	2,049.5	2.7	0.7
%SI	41.7	41.7	41.7	41.7	41.7	41.7	41.7	41.7

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/22/2015 00:00	11.2	13.8	9.3	93.1	2,735,914.3	1,398.5	0.7	0.4
02/22/2015 01:00	11.2	13.8	9.3	110.9	2,988,816.9	1,549.6	0.8	0.5
02/22/2015 02:00	11.7	13.8	9.7	87.5	2,527,957.4	1,292.2	0.7	0.4
02/22/2015 03:00	11.9	13.8	9.9	97.1	2,626,556.0	1,342.6	0.8	0.4
02/22/2015 04:00	11.1	13.8	9.2	104.9	3,100,376.8	1,584.8	0.7	0.5
02/22/2015 05:00	11.2	13.8	9.3	102.4	2,945,631.8	1,505.7	0.7	0.5
02/22/2015 06:00	33.0	15.9	38.9	88.9	422,424.8	644.7	4.7	1.2
02/22/2015 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2015 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2015 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2015 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2015 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2015 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2015 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2015 14:00	52.3	16.8	75.3	67.7	1,900,339.7	541.2	0.6	0.1
02/22/2015 15:00	57.6	15.0	57.6	244.9	2,189,222.2	943.2	2.2	0.8
02/22/2015 16:00	11.3	13.7	9.3	118.3	3,424,139.6	1,775.3	0.7	0.5
02/22/2015 17:00	10.9	13.7	8.9	117.5	3,351,232.2	1,737.5	0.8	0.5
02/22/2015 18:00	11.1	13.7	9.1	120.1	3,483,159.9	1,805.9	0.7	0.5
02/22/2015 19:00	11.1	13.7	9.1	120.5	3,492,996.6	1,811.0	0.7	0.5
02/22/2015 20:00	11.1	13.7	9.1	121.1	3,500,711.6	1,815.0	0.7	0.5
02/22/2015 21:00	11.2	13.7	9.2	121.6	3,506,305.1	1,817.9	0.7	0.5
02/22/2015 22:00	20.8	14.8	20.1	155.6	2,697,766.0	1,221.4	1.2	0.6
02/22/2015 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	18.7	14.2	19.0	117.0	2,964,741.7	1,424.2	0.8	0.5
Minimum:	10.9	13.7	8.9	67.7	1,900,339.7	541.2	0.6	0.1
Maximum:	57.6	16.8	75.3	244.9	3,506,305.1	1,817.9	2.2	0.8
%SI	33.3	33.3	33.3	33.3	37.5	33.3	37.5	37.5

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/23/2015 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2015 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2015 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2015 03:00	52.6	16.7	73.9	176.5	1,937,393.1	565.9	1.6	0.3
02/23/2015 04:00	34.4	14.2	30.3	177.2	2,671,000.0	1,287.3	1.4	0.6
02/23/2015 05:00	11.7	13.6	9.5	144.9	3,466,309.2	1,873.1	0.9	0.6
02/23/2015 06:00	11.9	13.4	9.4	155.9	3,478,337.9	2,032.0	1.0	0.8
02/23/2015 07:00	11.9	13.4	9.4	157.2	3,265,743.1	1,955.5	1.1	0.8
02/23/2015 08:00	11.0	13.8	9.1	121.6	3,518,442.5	1,798.5	0.7	0.5
02/23/2015 09:00	11.1	13.8	9.2	123.3	3,458,664.5	1,793.2	0.8	0.5
02/23/2015 10:00	11.0	13.7	9.0	120.6	3,489,331.9	1,809.1	0.7	0.5
02/23/2015 11:00	11.1	13.8	9.2	116.6	3,221,473.0	1,646.7	0.8	0.5
02/23/2015 12:00	11.1	13.7	9.1	122.1	3,497,432.7	1,813.3	0.8	0.5
02/23/2015 13:00	11.1	13.7	9.1	122.9	3,488,367.5	1,808.6	0.8	0.5
02/23/2015 14:00	11.1	13.8	9.2	117.7	3,144,854.2	1,630.5	0.8	0.5
02/23/2015 15:00	11.1	13.7	9.1	120.5	3,459,628.9	1,793.7	0.8	0.5
02/23/2015 16:00	11.0	13.8	9.1	114.8	3,219,690.3	1,669.3	0.8	0.5
02/23/2015 17:00	11.4	13.5	9.1	138.9	3,351,710.6	1,884.6	0.9	0.6
02/23/2015 18:00	12.2	13.2	9.3	173.1	3,360,380.7	2,159.4	1.2	1.1
02/23/2015 19:00	11.2	13.6	9.1	127.2	3,395,987.4	1,835.1	0.8	0.6
02/23/2015 20:00	12.2	13.3	9.5	178.1	3,397,417.4	2,183.2	1.2	1.1
02/23/2015 21:00	12.1	13.3	9.4	175.4	3,316,997.7	2,107.3	1.2	1.1
02/23/2015 22:00	11.1	13.8	9.2	122.7	3,489,524.8	1,809.2	0.8	0.5
02/23/2015 23:00	11.0	13.8	9.1	117.1	3,417,692.0	1,747.0	0.7	0.5
Average/Sum#:	14.4	13.8	13.3	139.3	3,287,922.8	1,771.5	0.9	0.6
Minimum:	11.0	13.2	9.0	114.8	1,937,393.1	565.9	0.7	0.3
Maximum:	52.6	16.7	73.9	178.1	3,518,442.5	2,183.2	1.6	1.1
%SI	12.5	12.5	12.5	12.5	12.5	12.5	12.5	12.5

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/24/2015 00:00	10.8	13.8	9.0	114.3	3,434,320.7	1,755.5	0.7	0.5
02/24/2015 01:00	10.8	13.8	9.0	120.2	3,518,638.1	1,798.6	0.7	0.5
02/24/2015 02:00	11.0	13.8	9.1	122.6	3,542,505.2	1,810.8	0.7	0.5
02/24/2015 03:00	11.0	13.8	9.1	117.3	3,505,922.1	1,792.1	0.7	0.5
02/24/2015 04:00	11.1	13.8	9.2	104.2	3,199,366.6	1,635.4	0.7	0.5
02/24/2015 05:00	11.5	13.6	9.3	118.5	3,139,683.0	1,696.6	0.8	0.5
02/24/2015 06:00	11.9	13.4	9.4	147.0	3,456,359.5	2,044.4	0.9	0.6
02/24/2015 07:00	11.9	13.4	9.4	142.7	3,448,075.3	2,039.5	0.9	0.6
02/24/2015 08:00	11.5	13.5	9.2	133.8	3,455,865.3	1,968.4	0.8	0.6
02/24/2015 09:00	11.5	13.7	9.4	107.5	2,920,438.2	1,556.8	0.8	0.5
02/24/2015 10:00	12.3	13.8	10.2	98.6	2,593,885.4	1,325.9	0.8	0.4
02/24/2015 11:00	13.1	13.8	10.9	102.7	2,530,500.6	1,293.5	0.9	0.4
02/24/2015 12:00	13.2	13.8	11.0	105.6	2,528,544.3	1,292.5	0.9	0.4
02/24/2015 13:00	13.1	13.8	10.9	101.1	2,527,174.9	1,291.8	0.9	0.4
02/24/2015 14:00	12.8	13.8	10.6	102.4	2,570,409.6	1,313.9	0.9	0.4
02/24/2015 15:00	11.6	13.8	9.6	93.1	2,676,442.1	1,368.1	0.7	0.4
02/24/2015 16:00	11.6	13.8	9.6	106.2	2,853,996.1	1,479.7	0.8	0.4
02/24/2015 17:00	11.7	13.4	9.2	136.5	3,382,140.1	2,000.5	0.9	0.6
02/24/2015 18:00	11.6	13.4	9.1	140.9	3,377,033.5	2,046.8	0.9	0.6
02/24/2015 19:00	11.4	13.3	8.9	137.0	3,366,804.1	2,040.6	0.9	0.6
02/24/2015 20:00	11.4	13.4	9.0	137.3	3,405,524.6	2,039.2	0.9	0.6
02/24/2015 21:00	11.3	13.4	8.9	134.1	3,393,500.4	2,032.0	0.9	0.6
02/24/2015 22:00	11.1	13.5	8.9	121.2	3,197,957.1	1,821.5	0.8	0.5
02/24/2015 23:00	11.1	13.8	9.2	102.7	2,870,390.7	1,488.2	0.8	0.4
Average/Sum#:	11.7	13.6	9.5	118.6	3,120,644.9	1,705.5	0.8	0.5
Minimum:	10.8	13.3	8.9	93.1	2,527,174.9	1,291.8	0.7	0.4
Maximum:	13.2	13.8	11.0	147.0	3,542,505.2	2,046.8	0.9	0.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/25/2015 00:00	11.6	13.8	9.6	88.0	2,512,218.7	1,302.5	0.7	0.4
02/25/2015 01:00	10.7	13.8	8.9	113.4	3,420,235.2	1,748.3	0.7	0.5
02/25/2015 02:00	10.7	13.8	8.9	113.2	3,392,064.2	1,733.9	0.7	0.5
02/25/2015 03:00	11.4	13.8	9.5	97.3	2,791,118.3	1,447.1	0.7	0.4
02/25/2015 04:00	12.6	13.8	10.5	95.3	2,490,037.9	1,291.0	0.8	0.4
02/25/2015 05:00	11.7	13.7	9.6	119.4	3,069,574.1	1,636.3	0.8	0.5
02/25/2015 06:00	11.3	13.5	9.0	154.6	3,444,615.9	2,012.3	1.0	0.8
02/25/2015 07:00	11.3	13.5	9.0	133.4	3,498,352.6	1,992.6	0.8	0.6
02/25/2015 08:00	11.0	13.7	9.0	118.9	3,212,780.6	1,736.1	0.8	0.5
02/25/2015 09:00	12.2	13.8	10.1	92.8	2,525,912.9	1,309.6	0.8	0.4
02/25/2015 10:00	12.6	13.8	10.5	97.6	2,494,281.1	1,293.2	0.8	0.4
02/25/2015 11:00	12.6	13.8	10.5	96.7	2,495,245.5	1,293.7	0.8	0.4
02/25/2015 12:00	12.4	13.8	10.3	96.8	2,498,717.3	1,295.5	0.8	0.4
02/25/2015 13:00	11.4	13.8	9.5	97.1	2,761,737.7	1,411.7	0.8	0.4
02/25/2015 14:00	12.0	13.8	10.0	93.9	2,549,868.2	1,303.4	0.8	0.4
02/25/2015 15:00	12.2	13.8	10.1	96.6	2,536,956.5	1,296.8	0.8	0.4
02/25/2015 16:00	11.7	13.7	9.6	108.0	2,831,429.6	1,468.0	0.8	0.4
02/25/2015 17:00	11.2	13.4	8.8	127.7	3,350,355.9	1,981.7	0.8	0.6
02/25/2015 18:00	11.3	13.4	8.9	135.2	3,308,892.3	2,005.5	0.9	0.6
02/25/2015 19:00	11.2	13.4	8.8	129.5	3,366,530.5	1,942.1	0.8	0.6
02/25/2015 20:00	10.8	13.5	8.6	123.6	3,412,851.4	1,943.9	0.8	0.6
02/25/2015 21:00	10.7	13.4	8.4	122.2	3,386,928.9	1,978.6	0.8	0.6
02/25/2015 22:00	10.8	13.5	8.6	117.1	3,129,661.4	1,782.6	0.8	0.5
02/25/2015 23:00	11.1	13.8	9.2	96.1	2,776,845.5	1,439.7	0.7	0.4
Average/Sum#:	11.5	13.7	9.4	111.0	2,969,050.5	1,610.3	0.8	0.5
Minimum:	10.7	13.4	8.4	88.0	2,490,037.9	1,291.0	0.7	0.4
Maximum:	12.6	13.8	10.5	154.6	3,498,352.6	2,012.3	1.0	0.8
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/26/2015 00:00	12.1	13.8	10.1	91.8	2,486,759.0	1,289.3	0.8	0.4
02/26/2015 01:00	12.1	13.8	10.1	93.2	2,516,076.2	1,304.5	0.8	0.4
02/26/2015 02:00	10.6	13.7	8.7	114.5	3,383,442.6	1,754.2	0.7	0.5
02/26/2015 03:00	10.5	13.7	8.6	112.3	3,439,569.7	1,783.3	0.7	0.5
02/26/2015 04:00	10.7	13.7	8.8	110.7	3,281,553.5	1,749.3	0.7	0.5
02/26/2015 05:00	10.9	13.6	8.8	123.4	3,445,258.3	1,937.2	0.8	0.6
02/26/2015 06:00	10.9	13.5	8.7	127.5	3,436,904.1	1,957.6	0.8	0.6
02/26/2015 07:00	11.0	13.5	8.8	126.8	3,425,814.4	1,976.3	0.8	0.6
02/26/2015 08:00	10.9	13.6	8.8	104.8	3,009,032.5	1,626.0	0.8	0.5
02/26/2015 09:00	11.0	13.8	9.1	89.0	2,650,704.1	1,374.3	0.7	0.4
02/26/2015 10:00	10.2	13.8	8.5	106.7	3,279,380.1	1,676.3	0.7	0.5
02/26/2015 11:00	10.4	13.8	8.6	104.9	3,289,897.4	1,705.7	0.7	0.5
02/26/2015 12:00	11.5	13.8	9.6	91.8	2,566,692.6	1,312.0	0.8	0.4
02/26/2015 13:00	12.3	13.8	10.2	97.1	2,524,240.4	1,290.3	0.8	0.4
02/26/2015 14:00	12.2	13.8	10.1	95.9	2,528,153.0	1,292.3	0.8	0.4
02/26/2015 15:00	10.3	13.8	8.6	91.6	2,893,789.4	1,479.2	0.7	0.4
02/26/2015 16:00	11.0	13.5	8.8	115.2	3,147,042.6	1,792.5	0.8	0.5
02/26/2015 17:00	11.3	13.4	8.9	129.7	3,313,339.0	1,984.0	0.9	0.6
02/26/2015 18:00	11.4	13.3	8.9	140.6	3,278,816.0	2,059.1	1.0	0.8
02/26/2015 19:00	11.3	13.3	8.8	137.1	3,276,586.7	2,057.7	0.9	0.6
02/26/2015 20:00	11.3	13.3	8.8	134.4	3,296,726.2	2,022.2	0.9	0.6
02/26/2015 21:00	11.1	13.4	8.7	129.9	3,310,212.2	2,006.3	0.9	0.6
02/26/2015 22:00	10.8	13.7	8.9	106.9	2,926,496.9	1,581.4	0.8	0.5
02/26/2015 23:00	11.3	13.8	9.4	86.9	2,516,415.1	1,286.3	0.7	0.4
Average/Sum#:	11.1	13.6	9.1	110.9	3,050,954.3	1,679.1	0.8	0.5
Minimum:	10.2	13.3	8.5	86.9	2,486,759.0	1,286.3	0.7	0.4
Maximum:	12.3	13.8	10.2	140.6	3,445,258.3	2,059.1	1.0	0.8
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/27/2015 00:00	10.6	13.7	8.7	110.4	3,275,777.2	1,722.3	0.7	0.5
02/27/2015 01:00	10.4	13.7	8.5	110.3	3,422,229.6	1,799.3	0.7	0.5
02/27/2015 02:00	10.3	13.7	8.4	109.4	3,375,631.1	1,774.8	0.7	0.5
02/27/2015 03:00	10.6	13.8	8.8	96.4	2,887,556.7	1,497.1	0.7	0.4
02/27/2015 04:00	11.3	13.8	9.4	86.8	2,484,058.7	1,287.9	0.7	0.4
02/27/2015 05:00	11.1	13.7	9.1	99.6	2,793,435.5	1,468.7	0.8	0.4
02/27/2015 06:00	11.1	13.4	8.7	127.8	3,331,542.3	1,994.9	0.8	0.6
02/27/2015 07:00	10.9	13.5	8.7	120.0	3,173,904.4	1,807.8	0.8	0.5
02/27/2015 08:00	11.1	13.8	9.2	87.7	2,518,969.4	1,306.0	0.7	0.4
02/27/2015 09:00	11.3	13.8	9.4	86.9	2,480,586.9	1,286.1	0.8	0.4
02/27/2015 10:00	11.4	13.8	9.5	88.0	2,523,457.9	1,289.9	0.7	0.4
02/27/2015 11:00	10.8	13.8	9.0	105.8	2,879,263.0	1,492.8	0.8	0.4
02/27/2015 12:00	11.9	13.8	9.9	92.1	2,521,110.3	1,288.7	0.8	0.4
02/27/2015 13:00	11.8	13.8	9.8	93.1	2,524,827.3	1,290.6	0.8	0.4
02/27/2015 14:00	11.8	13.8	9.8	92.9	2,519,740.9	1,288.0	0.8	0.4
02/27/2015 15:00	10.8	13.9	9.1	89.4	2,651,401.2	1,355.3	0.7	0.4
02/27/2015 16:00	11.1	13.8	9.2	101.2	2,837,643.0	1,450.5	0.8	0.4
02/27/2015 17:00	11.0	13.6	8.9	112.3	2,996,516.8	1,663.0	0.8	0.5
02/27/2015 18:00	11.2	13.3	8.7	135.0	3,343,514.8	2,050.9	0.9	0.6
02/27/2015 19:00	11.2	13.3	8.7	133.7	3,345,145.1	2,051.9	0.9	0.6
02/27/2015 20:00	11.2	13.3	8.7	133.4	3,346,612.4	2,052.8	0.9	0.6
02/27/2015 21:00	11.2	13.3	8.7	134.8	3,385,613.1	2,052.0	0.9	0.6
02/27/2015 22:00	11.3	13.4	8.9	132.8	3,379,343.4	2,048.2	0.9	0.6
02/27/2015 23:00	11.0	13.7	9.0	108.1	2,956,661.3	1,597.7	0.8	0.5
Average/Sum#:	11.1	13.6	9.0	107.8	2,956,439.3	1,621.6	0.8	0.5
Minimum:	10.3	13.3	8.4	86.8	2,480,586.9	1,286.1	0.7	0.4
Maximum:	11.9	13.9	9.9	135.0	3,422,229.6	2,052.8	0.9	0.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/28/2015 00:00	11.6	13.8	9.6	87.5	2,518,567.1	1,287.4	0.7	0.4
02/28/2015 01:00	32.7	16.1	40.2	207.2	1,551,208.8	577.7	2.9	0.6
02/28/2015 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2015 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2015 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2015 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2015 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2015 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2015 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2015 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2015 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2015 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2015 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2015 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/28/2015 14:00	27.3	17.9	53.7	0.1	1,990,428.6	334.3	-0.3	0.0
02/28/2015 15:00	62.0	15.5	67.7	179.0	2,085,917.6	807.3	1.7	0.6
02/28/2015 16:00	11.3	13.7	9.3	108.6	2,990,222.6	1,594.0	0.8	0.5
02/28/2015 17:00	11.1	13.4	8.7	131.1	3,350,800.0	2,030.9	0.9	0.6
02/28/2015 18:00	11.2	13.4	8.8	136.9	3,379,178.4	2,048.1	0.9	0.6
02/28/2015 19:00	11.1	13.3	8.6	130.3	3,373,733.7	2,044.8	0.9	0.6
02/28/2015 20:00	11.1	13.3	8.6	132.3	3,376,373.6	2,046.4	0.9	0.6
02/28/2015 21:00	11.3	13.4	8.9	136.3	3,383,138.2	2,050.5	0.9	0.6
02/28/2015 22:00	11.4	13.4	9.0	137.0	3,384,128.1	2,051.1	0.9	0.6
02/28/2015 23:00	11.4	13.4	9.0	136.9	3,384,649.3	2,026.7	0.9	0.6
Average/Sum#:	18.6	14.2	20.2	126.9	2,897,362.2	1,574.9	1.0	0.5
Minimum:	11.1	13.3	8.6	0.1	1,551,208.8	334.3	-0.3	0.0
Maximum:	62.0	17.9	67.7	207.2	3,384,649.3	2,051.1	2.9	0.6
%SI	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/01/2015 00:00	11.3	13.4	8.9	131.4	3,430,408.1	2,004.0	0.8	0.6
03/01/2015 01:00	11.1	13.6	9.0	123.4	3,366,592.9	1,843.8	0.8	0.6
03/01/2015 02:00	11.1	13.8	9.2	103.8	3,104,093.8	1,586.7	0.7	0.5
03/01/2015 03:00	10.9	13.9	9.2	107.3	3,238,688.7	1,655.5	0.7	0.5
03/01/2015 04:00	11.3	13.8	9.4	90.4	2,706,178.2	1,383.3	0.7	0.4
03/01/2015 05:00	11.2	13.8	9.3	120.0	3,339,081.0	1,731.2	0.8	0.5
03/01/2015 06:00	10.8	13.8	9.0	113.4	3,422,210.8	1,774.3	0.7	0.5
03/01/2015 07:00	10.9	13.8	9.1	116.6	3,503,604.8	1,816.5	0.7	0.5
03/01/2015 08:00	11.0	13.6	8.9	119.0	3,385,721.6	1,879.0	0.8	0.6
03/01/2015 09:00	11.3	13.4	8.9	134.2	3,430,909.1	2,054.4	0.9	0.6
03/01/2015 10:00	11.3	13.4	8.9	134.1	3,390,727.8	2,055.1	0.9	0.6
03/01/2015 11:00	11.3	13.4	8.9	136.8	3,391,057.8	2,055.3	0.9	0.6
03/01/2015 12:00	11.3	13.4	8.9	136.8	3,350,362.0	2,055.1	0.9	0.6
03/01/2015 13:00	11.2	13.4	8.8	129.5	3,362,190.5	1,988.7	0.8	0.6
03/01/2015 14:00	11.3	13.4	8.9	134.7	3,347,665.2	2,029.0	0.9	0.6
03/01/2015 15:00	11.4	13.3	8.9	137.3	3,318,356.9	2,059.7	0.9	0.6
03/01/2015 16:00	11.3	13.3	8.8	133.1	3,347,335.2	2,028.8	0.9	0.6
03/01/2015 17:00	11.3	13.3	8.8	137.0	3,347,101.4	2,053.1	0.9	0.6
03/01/2015 18:00	11.3	13.4	8.9	137.9	3,347,264.5	2,053.2	0.9	0.6
03/01/2015 19:00	11.3	13.4	8.9	136.1	3,351,340.1	2,055.7	0.9	0.6
03/01/2015 20:00	11.3	13.4	8.9	134.8	3,395,677.5	2,058.1	0.9	0.6
03/01/2015 21:00	11.3	13.4	8.9	137.2	3,398,152.4	2,059.6	0.9	0.6
03/01/2015 22:00	11.3	13.4	8.9	130.9	3,408,864.7	2,041.2	0.8	0.6
03/01/2015 23:00	11.2	13.4	8.8	131.2	3,452,490.0	2,016.9	0.8	0.6
Average/Sum#:	11.2	13.5	9.0	127.0	3,339,003.1	1,930.8	0.8	0.6
Minimum:	10.8	13.3	8.8	90.4	2,706,178.2	1,383.3	0.7	0.4
Maximum:	11.4	13.9	9.4	137.9	3,503,604.8	2,059.7	0.9	0.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/02/2015 00:00	11.3	13.4	8.9	133.7	3,441,143.7	2,035.4	0.9	0.6
03/02/2015 01:00	11.4	13.4	9.0	137.2	3,428,404.0	2,052.9	0.9	0.6
03/02/2015 02:00	11.3	13.4	8.9	131.5	3,458,310.1	2,020.3	0.8	0.6
03/02/2015 03:00	11.0	13.5	8.8	127.8	3,471,757.6	1,952.1	0.8	0.6
03/02/2015 04:00	10.7	13.6	8.6	115.4	3,359,531.1	1,815.4	0.7	0.5
03/02/2015 05:00	11.0	13.5	8.8	129.3	3,465,163.7	1,999.0	0.8	0.6
03/02/2015 06:00	10.9	13.4	8.6	136.4	3,360,767.8	2,012.4	0.9	0.6
03/02/2015 07:00	11.1	13.3	8.6	131.9	3,435,251.2	2,057.0	0.8	0.6
03/02/2015 08:00	11.1	13.3	8.6	128.9	3,445,708.4	2,038.1	0.8	0.6
03/02/2015 09:00	11.0	13.3	8.5	127.1	3,402,518.6	2,037.4	0.8	0.6
03/02/2015 10:00	10.8	13.4	8.5	124.0	3,430,236.9	2,003.9	0.8	0.6
03/02/2015 11:00	10.7	13.4	8.4	123.0	3,415,587.1	1,970.4	0.8	0.6
03/02/2015 12:00	10.9	13.4	8.6	126.6	3,390,424.3	2,005.4	0.8	0.6
03/02/2015 13:00	10.9	13.4	8.6	124.9	3,372,503.4	1,994.8	0.8	0.6
03/02/2015 14:00	10.6	13.6	8.6	110.0	3,101,289.8	1,698.5	0.8	0.5
03/02/2015 15:00	10.6	13.7	8.7	107.7	3,121,323.2	1,618.3	0.7	0.5
03/02/2015 16:00	10.8	13.5	8.6	112.9	3,278,690.3	1,819.6	0.7	0.5
03/02/2015 17:00	11.0	13.4	8.7	122.4	3,387,394.1	1,929.4	0.8	0.6
03/02/2015 18:00	11.0	13.5	8.8	123.1	3,394,767.9	1,933.6	0.8	0.6
03/02/2015 19:00	11.0	13.4	8.7	124.1	3,406,355.4	1,940.2	0.8	0.6
03/02/2015 20:00	11.1	13.4	8.7	125.1	3,422,156.4	1,949.2	0.8	0.6
03/02/2015 21:00	11.1	13.4	8.7	123.4	3,428,476.8	1,952.8	0.8	0.6
03/02/2015 22:00	10.9	13.5	8.7	118.0	3,255,085.7	1,806.5	0.8	0.5
03/02/2015 23:00	11.0	13.8	9.1	104.3	2,972,036.7	1,540.9	0.8	0.5
Average/Sum#:	11.0	13.5	8.7	123.7	3,360,203.5	1,924.3	0.8	0.6
Minimum:	10.6	13.3	8.4	104.3	2,972,036.7	1,540.9	0.7	0.5
Maximum:	11.4	13.8	9.1	137.2	3,471,757.6	2,057.0	0.9	0.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/03/2015 00:00	12.3	13.8	10.2	92.5	2,493,123.9	1,292.6	0.8	0.4
03/03/2015 01:00	12.4	13.8	10.3	94.3	2,495,052.7	1,293.6	0.8	0.4
03/03/2015 02:00	12.4	13.8	10.3	95.7	2,499,488.8	1,295.9	0.8	0.4
03/03/2015 03:00	12.4	13.8	10.3	94.6	2,504,117.9	1,298.3	0.8	0.4
03/03/2015 04:00	11.8	13.7	9.7	112.4	2,939,385.0	1,566.9	0.8	0.5
03/03/2015 05:00	11.4	13.4	9.0	133.9	3,440,165.2	2,009.7	0.9	0.6
03/03/2015 06:00	11.5	13.3	8.9	137.1	3,415,711.8	2,045.3	0.9	0.6
03/03/2015 07:00	11.3	13.4	8.9	134.6	3,430,408.1	2,004.0	0.9	0.6
03/03/2015 08:00	11.0	13.7	9.0	108.3	2,956,291.2	1,597.5	0.8	0.5
03/03/2015 09:00	11.6	13.8	9.6	87.6	2,494,859.8	1,293.5	0.8	0.4
03/03/2015 10:00	11.6	13.8	9.6	88.6	2,495,438.4	1,293.8	0.8	0.4
03/03/2015 11:00	11.7	13.8	9.7	89.9	2,496,402.8	1,294.3	0.8	0.4
03/03/2015 12:00	11.7	13.8	9.7	90.5	2,537,543.4	1,297.1	0.8	0.4
03/03/2015 13:00	11.8	13.8	9.8	92.3	2,541,456.0	1,299.1	0.8	0.4
03/03/2015 14:00	11.8	13.8	9.8	92.2	2,534,022.0	1,295.3	0.8	0.4
03/03/2015 15:00	11.8	13.8	9.8	91.1	2,534,022.0	1,295.3	0.8	0.4
03/03/2015 16:00	11.9	13.8	9.9	103.8	2,757,629.4	1,409.6	0.8	0.4
03/03/2015 17:00	11.3	13.5	9.0	126.0	3,384,731.7	1,952.6	0.8	0.6
03/03/2015 18:00	11.3	13.4	8.9	131.4	3,404,625.7	2,013.8	0.8	0.6
03/03/2015 19:00	11.4	13.4	9.0	137.0	3,389,077.9	2,054.1	0.9	0.6
03/03/2015 20:00	11.4	13.4	9.0	134.6	3,377,363.5	2,047.0	0.9	0.6
03/03/2015 21:00	11.4	13.4	9.0	137.1	3,383,633.2	2,050.8	0.9	0.6
03/03/2015 22:00	11.3	13.4	8.9	131.9	3,403,949.5	2,013.4	0.9	0.6
03/03/2015 23:00	11.0	13.7	9.0	115.6	3,176,139.3	1,716.3	0.8	0.5
Average/Sum#:	11.6	13.6	9.5	110.5	2,920,193.3	1,613.7	0.8	0.5
Minimum:	11.0	13.3	8.9	87.6	2,493,123.9	1,292.6	0.8	0.4
Maximum:	12.4	13.8	10.3	137.1	3,440,165.2	2,054.1	0.9	0.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/04/2015 00:00	10.8	13.8	9.0	118.7	3,553,069.4	1,816.2	0.7	0.5
03/04/2015 01:00	10.7	13.8	8.9	112.0	3,432,240.4	1,779.5	0.7	0.5
03/04/2015 02:00	10.5	13.9	8.9	107.3	3,367,023.3	1,721.1	0.7	0.5
03/04/2015 03:00	10.7	13.8	8.9	113.2	3,445,863.0	1,761.4	0.7	0.5
03/04/2015 04:00	11.2	13.6	9.1	120.8	3,308,529.3	1,812.0	0.8	0.5
03/04/2015 05:00	11.5	13.4	9.0	133.4	3,459,850.7	2,021.2	0.8	0.6
03/04/2015 06:00	11.6	13.4	9.1	146.8	3,425,251.6	2,026.0	0.9	0.6
03/04/2015 07:00	11.4	13.4	9.0	131.3	3,444,273.5	2,012.1	0.8	0.6
03/04/2015 08:00	11.2	13.5	8.9	148.4	3,468,155.0	1,975.4	0.9	0.6
03/04/2015 09:00	12.0	13.7	9.8	103.2	2,737,327.2	1,439.2	0.8	0.4
03/04/2015 10:00	13.0	13.8	10.8	100.1	2,531,283.2	1,293.9	0.8	0.4
03/04/2015 11:00	13.0	13.8	10.8	98.9	2,529,913.7	1,293.2	0.8	0.4
03/04/2015 12:00	13.0	13.8	10.8	100.3	2,529,718.1	1,293.1	0.8	0.4
03/04/2015 13:00	13.1	13.8	10.9	100.9	2,531,087.5	1,293.8	0.8	0.4
03/04/2015 14:00	13.0	13.8	10.8	100.8	2,530,891.9	1,293.7	0.9	0.4
03/04/2015 15:00	13.0	13.8	10.8	100.6	2,530,305.0	1,293.4	0.8	0.4
03/04/2015 16:00	12.3	13.7	10.1	117.4	2,888,560.2	1,560.9	0.9	0.5
03/04/2015 17:00	11.7	13.4	9.2	140.3	3,350,470.0	2,030.7	0.9	0.6
03/04/2015 18:00	11.7	13.4	9.2	141.7	3,348,894.7	2,054.2	0.9	0.6
03/04/2015 19:00	11.6	13.4	9.1	139.4	3,383,468.2	2,050.7	0.9	0.6
03/04/2015 20:00	11.5	13.4	9.0	137.5	3,385,283.1	2,051.8	0.9	0.6
03/04/2015 21:00	11.5	13.4	9.0	134.2	3,409,031.7	2,041.3	0.9	0.6
03/04/2015 22:00	11.3	13.4	8.9	131.3	3,413,078.9	2,018.8	0.8	0.6
03/04/2015 23:00	11.1	13.5	8.9	128.3	3,473,070.9	1,978.2	0.8	0.6
Average/Sum#:	11.8	13.6	9.5	121.1	3,144,860.0	1,746.3	0.8	0.5
Minimum:	10.5	13.4	8.9	98.9	2,529,718.1	1,293.1	0.7	0.4
Maximum:	13.1	13.9	10.9	148.4	3,553,069.4	2,054.2	0.9	0.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/05/2015 00:00	10.9	13.7	8.9	119.7	3,311,633.3	1,813.7	0.8	0.5
03/05/2015 01:00	10.9	13.8	9.1	102.0	3,108,397.7	1,588.9	0.7	0.5
03/05/2015 02:00	11.0	13.8	9.1	100.1	3,024,667.2	1,546.1	0.7	0.5
03/05/2015 03:00	10.9	13.8	9.1	104.7	3,191,345.7	1,631.3	0.7	0.5
03/05/2015 04:00	10.7	13.7	8.8	112.4	3,350,334.8	1,761.5	0.7	0.5
03/05/2015 05:00	11.2	13.5	8.9	128.6	3,477,644.6	2,006.2	0.8	0.6
03/05/2015 06:00	11.4	13.4	9.0	140.6	3,445,370.3	2,037.9	0.9	0.6
03/05/2015 07:00	11.5	13.4	9.0	137.3	3,477,653.2	2,031.6	0.9	0.6
03/05/2015 08:00	10.9	13.6	8.8	122.3	3,473,180.4	1,952.9	0.8	0.6
03/05/2015 09:00	11.9	13.7	9.8	114.0	2,769,280.4	1,456.0	0.9	0.4
03/05/2015 10:00	12.9	13.8	10.7	95.2	2,497,367.2	1,294.8	0.8	0.4
03/05/2015 11:00	12.9	13.8	10.7	97.2	2,499,295.9	1,295.8	0.8	0.4
03/05/2015 12:00	12.9	13.8	10.7	99.2	2,499,874.6	1,296.1	0.8	0.4
03/05/2015 13:00	12.9	13.8	10.7	100.5	2,539,891.0	1,298.3	0.8	0.4
03/05/2015 14:00	12.8	13.8	10.6	99.1	2,542,042.9	1,299.4	0.8	0.4
03/05/2015 15:00	12.7	13.8	10.6	98.6	2,545,368.7	1,301.1	0.8	0.4
03/05/2015 16:00	11.9	13.7	9.8	107.8	2,946,544.8	1,549.2	0.8	0.5
03/05/2015 17:00	11.4	13.3	8.9	132.7	3,377,363.5	2,047.0	0.9	0.6
03/05/2015 18:00	11.4	13.3	8.9	136.3	3,345,797.2	2,052.3	0.9	0.6
03/05/2015 19:00	11.4	13.3	8.9	136.9	3,344,493.0	2,051.5	0.9	0.6
03/05/2015 20:00	11.3	13.3	8.8	135.2	3,383,303.2	2,050.6	0.9	0.6
03/05/2015 21:00	11.2	13.3	8.7	132.7	3,373,073.7	2,044.4	0.9	0.6
03/05/2015 22:00	11.2	13.4	8.8	131.0	3,398,844.5	2,035.2	0.8	0.6
03/05/2015 23:00	10.8	13.6	8.7	115.3	3,169,857.1	1,759.2	0.8	0.5
Average/Sum#:	11.6	13.6	9.4	116.6	3,087,192.7	1,716.7	0.8	0.5
Minimum:	10.7	13.3	8.7	95.2	2,497,367.2	1,294.8	0.7	0.4
Maximum:	12.9	13.8	10.7	140.6	3,477,653.2	2,052.3	0.9	0.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/06/2015 00:00	11.5	13.8	9.6	87.7	2,499,874.6	1,296.1	0.7	0.4
03/06/2015 01:00	11.7	13.8	9.7	87.3	2,497,752.9	1,295.0	0.7	0.4
03/06/2015 02:00	11.9	13.8	9.9	92.0	2,494,474.0	1,293.3	0.8	0.4
03/06/2015 03:00	12.6	13.8	10.5	93.4	2,496,788.5	1,294.5	0.8	0.4
03/06/2015 04:00	12.6	13.8	10.5	94.2	2,499,681.7	1,296.0	0.8	0.4
03/06/2015 05:00	12.0	13.7	9.8	116.1	2,947,263.9	1,571.1	0.9	0.5
03/06/2015 06:00	11.3	13.5	9.0	140.5	3,397,694.1	2,009.7	0.9	0.6
03/06/2015 07:00	11.1	13.5	8.9	128.7	3,498,079.0	1,966.9	0.8	0.6
03/06/2015 08:00	10.9	13.6	8.8	124.1	3,473,180.4	1,952.9	0.8	0.6
03/06/2015 09:00	10.8	13.5	8.6	120.1	3,466,777.9	1,949.3	0.8	0.6
03/06/2015 10:00	11.0	13.7	9.0	107.8	2,972,761.3	1,606.4	0.8	0.5
03/06/2015 11:00	11.8	13.8	9.8	89.1	2,496,788.5	1,294.5	0.8	0.4
03/06/2015 12:00	11.8	13.8	9.8	89.7	2,535,782.7	1,296.2	0.8	0.4
03/06/2015 13:00	11.8	13.8	9.8	91.1	2,541,651.7	1,299.2	0.8	0.4
03/06/2015 14:00	11.7	13.8	9.7	89.9	2,546,542.5	1,301.7	0.8	0.4
03/06/2015 15:00	11.5	13.8	9.6	88.6	2,545,759.9	1,301.3	0.7	0.4
03/06/2015 16:00	11.2	13.7	9.2	107.2	2,886,671.6	1,538.8	0.8	0.5
03/06/2015 17:00	11.2	13.3	8.7	128.5	3,296,726.2	2,022.2	0.9	0.6
03/06/2015 18:00	11.4	13.3	8.9	139.7	3,293,784.1	2,068.5	0.9	0.6
03/06/2015 19:00	11.4	13.3	8.9	140.3	3,292,510.2	2,067.7	0.9	0.6
03/06/2015 20:00	11.5	13.3	8.9	139.8	3,319,968.0	2,060.7	0.9	0.6
03/06/2015 21:00	10.9	13.4	8.6	124.5	3,362,437.9	2,013.4	0.8	0.6
03/06/2015 22:00	10.9	13.4	8.6	125.9	3,401,244.4	2,011.8	0.8	0.6
03/06/2015 23:00	11.1	13.4	8.7	127.3	3,369,122.1	1,992.8	0.8	0.6
Average/Sum#:	11.5	13.6	9.3	111.4	2,963,888.3	1,658.3	0.8	0.5
Minimum:	10.8	13.3	8.6	87.3	2,494,474.0	1,293.3	0.7	0.4
Maximum:	12.6	13.8	10.5	140.5	3,498,079.0	2,068.5	0.9	0.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/07/2015 00:00	10.9	13.5	8.7	122.8	3,281,175.9	1,868.9	0.8	0.6
03/07/2015 01:00	10.6	13.7	8.7	106.6	3,322,879.3	1,722.8	0.7	0.5
03/07/2015 02:00	34.2	16.4	44.8	214.6	1,388,149.2	496.7	3.3	0.6
03/07/2015 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2015 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2015 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2015 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2015 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2015 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2015 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2015 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2015 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2015 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2015 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2015 14:00	51.6	16.7	72.5	88.2	1,870,976.1	546.5	0.7	0.2
03/07/2015 15:00	58.3	15.0	58.3	254.3	2,127,017.8	916.4	2.4	0.8
03/07/2015 16:00	11.2	13.7	9.2	110.7	3,158,558.8	1,706.8	0.8	0.5
03/07/2015 17:00	11.8	13.3	9.2	146.8	3,280,886.0	2,060.4	1.0	0.8
03/07/2015 18:00	11.8	13.3	9.2	146.5	3,313,844.0	2,032.7	1.0	0.8
03/07/2015 19:00	11.7	13.3	9.1	147.1	3,285,981.6	2,063.6	1.0	0.8
03/07/2015 20:00	11.6	13.3	9.0	142.6	3,286,459.3	2,063.9	1.0	0.8
03/07/2015 21:00	11.4	13.4	9.0	134.2	3,330,836.1	2,018.8	0.9	0.6
03/07/2015 22:00	11.0	13.4	8.7	128.2	3,396,172.5	2,008.8	0.8	0.6
03/07/2015 23:00	10.8	13.5	8.6	113.8	3,164,615.3	1,779.4	0.8	0.5
Average/Sum#:	19.8	14.0	20.4	142.8	2,939,042.5	1,637.4	1.2	0.6
Minimum:	10.6	13.3	8.6	88.2	1,388,149.2	496.7	0.7	0.2
Maximum:	58.3	16.7	72.5	254.3	3,396,172.5	2,063.9	3.3	0.8
%SI	45.8	45.8	45.8	45.8	45.8	45.8	45.8	45.8

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/08/2015 00:00	11.7	13.8	9.7	89.3	2,517,197.6	1,286.7	0.8	0.4
03/08/2015 01:00	11.8	13.8	9.8	88.3	2,482,708.5	1,287.2	0.8	0.4
03/08/2015 02:00	11.7	13.8	9.7	88.6	2,483,672.9	1,287.7	0.8	0.4
03/08/2015 03:00	11.7	13.8	9.7	87.4	2,485,794.6	1,288.8	0.8	0.4
03/08/2015 04:00	11.6	13.8	9.6	87.4	2,487,916.2	1,289.9	0.8	0.4
03/08/2015 05:00	11.6	13.8	9.6	87.4	2,486,759.0	1,289.3	0.8	0.4
03/08/2015 06:00	11.7	13.8	9.7	88.2	2,489,845.0	1,290.9	0.8	0.4
03/08/2015 07:00	11.9	13.8	9.9	91.7	2,491,966.6	1,292.0	0.8	0.4
03/08/2015 08:00	32.1	16.1	39.5	205.2	1,554,699.4	579.0	2.8	0.6
03/08/2015 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2015 10:00	48.1	16.7	67.6	264.4	1,888,778.6	551.7	2.6	0.6
03/08/2015 11:00	36.1	14.5	33.3	194.9	2,418,012.2	1,112.4	1.6	0.7
03/08/2015 12:00	10.4	13.8	8.6	87.5	2,722,611.3	1,391.7	0.7	0.4
03/08/2015 13:00	10.3	13.9	8.7	86.6	2,728,089.0	1,394.5	0.7	0.4
03/08/2015 14:00	10.4	13.8	8.6	105.8	2,957,369.8	1,511.7	0.8	0.5
03/08/2015 15:00	10.7	13.9	9.0	92.0	2,738,457.5	1,399.8	0.7	0.4
03/08/2015 16:00	10.9	13.9	9.2	86.3	2,577,452.3	1,317.5	0.7	0.4
03/08/2015 17:00	11.1	13.8	9.2	86.4	2,536,956.5	1,296.8	0.7	0.4
03/08/2015 18:00	10.9	13.7	8.9	107.3	3,156,426.8	1,636.5	0.7	0.5
03/08/2015 19:00	10.8	13.7	8.9	108.9	3,346,911.2	1,759.7	0.7	0.5
03/08/2015 20:00	10.5	13.7	8.6	107.7	3,302,214.7	1,736.2	0.7	0.5
03/08/2015 21:00	10.8	13.8	9.0	92.6	2,771,519.3	1,416.7	0.7	0.4
03/08/2015 22:00	11.8	13.8	9.8	92.9	2,526,588.0	1,291.5	0.8	0.4
03/08/2015 23:00	12.3	13.8	10.2	93.5	2,524,044.8	1,290.2	0.8	0.4
Average/Sum#:	14.8	14.1	14.2	109.6	2,594,608.3	1,304.3	1.0	0.4
Minimum:	10.3	13.7	8.6	86.3	1,554,699.4	551.7	0.7	0.4
Maximum:	48.1	16.7	67.6	264.4	3,346,911.2	1,759.7	2.8	0.7
%SI	4.2	4.2	4.2	4.2	4.2	4.2	4.2	4.2

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/09/2015 00:00	11.5	13.8	9.6	87.1	2,483,672.9	1,287.7	0.7	0.4
03/09/2015 01:00	11.5	13.8	9.6	87.2	2,482,708.5	1,287.2	0.8	0.4
03/09/2015 02:00	11.5	13.8	9.6	87.1	2,481,744.2	1,286.7	0.8	0.4
03/09/2015 03:00	11.5	13.8	9.6	88.7	2,480,586.9	1,286.1	0.8	0.4
03/09/2015 04:00	11.6	13.8	9.6	98.8	2,668,095.2	1,402.8	0.8	0.4
03/09/2015 05:00	11.1	13.3	8.6	122.7	3,389,578.9	2,004.9	0.8	0.6
03/09/2015 06:00	11.2	13.3	8.7	134.0	3,383,138.2	2,050.5	0.9	0.6
03/09/2015 07:00	10.7	13.4	8.4	120.1	3,401,199.5	1,962.1	0.8	0.6
03/09/2015 08:00	10.5	13.5	8.4	114.9	3,403,019.6	1,938.3	0.7	0.6
03/09/2015 09:00	11.2	13.8	9.3	92.3	2,568,538.7	1,331.7	0.8	0.4
03/09/2015 10:00	12.5	13.8	10.4	96.2	2,486,566.1	1,289.2	0.8	0.4
03/09/2015 11:00	12.4	13.8	10.3	96.2	2,522,675.3	1,289.5	0.8	0.4
03/09/2015 12:00	12.3	13.8	10.2	96.0	2,524,436.0	1,290.4	0.8	0.4
03/09/2015 13:00	12.1	13.8	10.1	95.8	2,535,391.4	1,296.0	0.8	0.4
03/09/2015 14:00	10.2	13.6	8.2	100.2	3,009,957.8	1,626.5	0.7	0.5
03/09/2015 15:00	11.2	13.9	9.4	86.8	2,522,871.0	1,289.6	0.7	0.4
03/09/2015 16:00	11.1	13.9	9.4	86.5	2,521,305.9	1,288.8	0.7	0.4
03/09/2015 17:00	10.5	13.5	8.4	105.7	3,034,679.5	1,728.5	0.8	0.5
03/09/2015 18:00	10.6	13.3	8.2	121.6	3,274,198.2	2,056.2	0.8	0.6
03/09/2015 19:00	10.6	13.3	8.2	121.6	3,313,845.9	2,056.9	0.8	0.6
03/09/2015 20:00	10.6	13.3	8.2	119.3	3,317,593.6	2,035.0	0.8	0.6
03/09/2015 21:00	10.5	13.4	8.3	114.5	3,357,963.8	1,986.2	0.7	0.6
03/09/2015 22:00	10.5	13.3	8.2	117.0	3,363,439.9	2,014.0	0.8	0.6
03/09/2015 23:00	10.4	13.4	8.2	114.2	3,363,306.3	1,964.8	0.7	0.6
Average/Sum#:	11.2	13.6	9.0	104.4	2,912,104.7	1,627.1	0.8	0.5
Minimum:	10.2	13.3	8.2	86.5	2,480,586.9	1,286.1	0.7	0.4
Maximum:	12.5	13.9	10.4	134.0	3,403,019.6	2,056.9	0.9	0.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/10/2015 00:00	10.4	13.4	8.2	113.8	3,389,932.1	1,955.6	0.7	0.6
03/10/2015 01:00	10.7	13.4	8.4	120.5	3,370,305.6	1,993.5	0.8	0.6
03/10/2015 02:00	10.6	13.4	8.3	116.1	3,369,650.7	1,943.9	0.8	0.6
03/10/2015 03:00	10.7	13.4	8.4	118.3	3,369,997.4	1,944.1	0.8	0.6
03/10/2015 04:00	10.8	13.4	8.5	119.3	3,347,729.1	1,955.7	0.8	0.6
03/10/2015 05:00	10.7	13.4	8.4	121.8	3,385,859.5	2,002.7	0.8	0.6
03/10/2015 06:00	10.9	13.3	8.5	131.6	3,372,248.8	2,043.9	0.9	0.6
03/10/2015 07:00	10.7	13.4	8.4	119.8	3,379,773.2	1,999.1	0.8	0.6
03/10/2015 08:00	10.3	13.5	8.2	109.0	3,226,976.5	1,790.9	0.7	0.5
03/10/2015 09:00	10.4	13.8	8.6	91.5	2,727,469.0	1,414.1	0.7	0.4
03/10/2015 10:00	11.1	13.8	9.2	86.2	2,489,845.0	1,290.9	0.7	0.4
03/10/2015 11:00	11.1	13.8	9.2	86.3	2,490,230.7	1,291.1	0.7	0.4
03/10/2015 12:00	11.1	13.8	9.2	86.3	2,490,809.4	1,291.4	0.7	0.4
03/10/2015 13:00	11.1	13.8	9.2	86.4	2,491,580.9	1,291.8	0.7	0.4
03/10/2015 14:00	11.7	13.8	9.7	89.7	2,491,773.7	1,291.9	0.8	0.4
03/10/2015 15:00	11.7	13.8	9.7	89.7	2,491,002.2	1,291.5	0.8	0.4
03/10/2015 16:00	11.3	13.8	9.4	94.2	2,705,866.9	1,402.9	0.7	0.4
03/10/2015 17:00	11.0	13.3	8.5	126.4	3,299,023.9	2,047.7	0.8	0.6
03/10/2015 18:00	11.1	13.3	8.6	132.6	3,271,650.4	2,054.6	0.9	0.6
03/10/2015 19:00	11.0	13.3	8.5	130.5	3,278,179.0	2,058.7	0.9	0.6
03/10/2015 20:00	10.9	13.3	8.5	131.2	3,314,490.3	2,057.3	0.9	0.6
03/10/2015 21:00	10.9	13.3	8.5	124.9	3,317,471.8	2,010.7	0.8	0.6
03/10/2015 22:00	10.3	13.6	8.3	107.8	3,026,067.5	1,679.4	0.8	0.5
03/10/2015 23:00	10.9	13.8	9.1	86.2	2,484,444.4	1,288.1	0.7	0.4
Average/Sum#:	10.9	13.5	8.7	109.2	3,024,265.8	1,724.6	0.8	0.5
Minimum:	10.3	13.3	8.2	86.2	2,484,444.4	1,288.1	0.7	0.4
Maximum:	11.7	13.8	9.7	132.6	3,389,932.1	2,058.7	0.9	0.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/11/2015 00:00	10.9	13.8	9.1	85.9	2,483,672.9	1,287.7	0.7	0.4
03/11/2015 01:00	10.9	13.8	9.1	86.1	2,486,180.3	1,289.0	0.7	0.4
03/11/2015 02:00	10.9	13.8	9.1	86.0	2,485,601.7	1,288.7	0.7	0.4
03/11/2015 03:00	11.2	13.8	9.3	86.4	2,485,408.8	1,288.6	0.7	0.4
03/11/2015 04:00	11.6	13.8	9.6	96.8	2,709,724.4	1,404.9	0.8	0.4
03/11/2015 05:00	10.8	13.4	8.5	117.0	3,382,651.6	1,951.4	0.8	0.6
03/11/2015 06:00	10.7	13.4	8.4	121.0	3,355,427.9	1,984.7	0.8	0.6
03/11/2015 07:00	10.7	13.3	8.3	120.9	3,377,363.5	2,047.0	0.8	0.6
03/11/2015 08:00	10.6	13.3	8.2	119.6	3,376,868.5	2,046.7	0.8	0.6
03/11/2015 09:00	10.6	13.3	8.2	121.8	3,378,353.5	2,047.6	0.8	0.6
03/11/2015 10:00	10.7	13.3	8.3	123.4	3,352,644.3	2,056.5	0.8	0.6
03/11/2015 11:00	10.6	13.3	8.2	122.0	3,356,720.0	2,059.0	0.8	0.6
03/11/2015 12:00	10.6	13.3	8.2	120.1	3,356,883.0	2,059.1	0.8	0.6
03/11/2015 13:00	10.5	13.3	8.2	120.5	3,360,469.6	2,061.3	0.8	0.6
03/11/2015 14:00	10.6	13.3	8.2	120.4	3,355,252.8	2,058.1	0.8	0.6
03/11/2015 15:00	10.6	13.3	8.2	119.6	3,345,960.2	2,052.4	0.8	0.6
03/11/2015 16:00	10.6	13.3	8.2	119.8	3,345,308.1	2,052.0	0.8	0.6
03/11/2015 17:00	10.4	13.4	8.2	112.6	3,380,081.7	1,974.6	0.7	0.6
03/11/2015 18:00	10.5	13.3	8.2	119.3	3,345,145.1	2,051.9	0.8	0.6
03/11/2015 19:00	10.6	13.3	8.2	119.7	3,383,468.2	2,050.7	0.8	0.6
03/11/2015 20:00	10.4	13.4	8.2	115.7	3,383,154.5	2,001.1	0.7	0.6
03/11/2015 21:00	10.3	13.6	8.3	99.9	2,955,365.9	1,597.0	0.7	0.5
03/11/2015 22:00	11.6	13.7	9.5	87.2	2,493,316.8	1,292.7	0.7	0.4
03/11/2015 23:00	11.9	13.7	9.8	87.9	2,499,488.8	1,295.9	0.8	0.4
Average/Sum#:	10.8	13.5	8.6	109.6	3,101,438.0	1,804.1	0.8	0.5
Minimum:	10.3	13.3	8.2	85.9	2,483,672.9	1,287.7	0.7	0.4
Maximum:	11.9	13.8	9.8	123.4	3,383,468.2	2,061.3	0.8	0.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/12/2015 00:00	11.9	13.7	9.8	89.1	2,505,082.2	1,298.8	0.8	0.4
03/12/2015 01:00	11.9	13.7	9.8	90.1	2,516,847.7	1,304.9	0.8	0.4
03/12/2015 02:00	11.8	13.7	9.7	90.1	2,523,791.3	1,308.5	0.8	0.4
03/12/2015 03:00	11.8	13.7	9.7	89.2	2,520,898.1	1,307.0	0.8	0.4
03/12/2015 04:00	11.5	13.7	9.4	98.3	2,752,543.0	1,427.1	0.8	0.4
03/12/2015 05:00	10.6	13.5	8.5	113.5	3,418,645.1	1,947.2	0.7	0.6
03/12/2015 06:00	10.8	13.3	8.4	126.6	3,384,788.1	2,051.5	0.8	0.6
03/12/2015 07:00	10.9	13.3	8.5	125.0	3,344,167.0	2,051.3	0.8	0.6
03/12/2015 08:00	10.7	13.4	8.4	119.4	3,370,981.8	1,993.9	0.8	0.6
03/12/2015 09:00	10.2	13.4	8.0	111.0	3,390,625.4	1,956.0	0.7	0.6
03/12/2015 10:00	10.4	13.4	8.2	113.5	3,371,904.2	1,945.2	0.7	0.6
03/12/2015 11:00	10.7	13.7	8.8	89.8	2,604,799.5	1,350.5	0.7	0.4
03/12/2015 12:00	11.3	13.8	9.4	86.9	2,494,859.8	1,293.5	0.7	0.4
03/12/2015 13:00	11.3	13.8	9.4	86.7	2,494,474.0	1,293.3	0.7	0.4
03/12/2015 14:00	11.9	13.8	9.9	92.8	2,494,088.3	1,293.1	0.8	0.4
03/12/2015 15:00	11.9	13.8	9.9	91.2	2,493,123.9	1,292.6	0.8	0.4
03/12/2015 16:00	11.2	13.7	9.2	102.0	2,883,482.5	1,537.1	0.8	0.5
03/12/2015 17:00	10.6	13.3	8.2	120.1	3,337,971.9	2,047.5	0.8	0.6
03/12/2015 18:00	10.7	13.3	8.3	121.9	3,356,230.9	2,058.7	0.8	0.6
03/12/2015 19:00	10.7	13.3	8.3	121.3	3,359,980.5	2,061.0	0.8	0.6
03/12/2015 20:00	10.7	13.3	8.3	124.3	3,362,915.0	2,062.8	0.8	0.6
03/12/2015 21:00	10.7	13.3	8.3	120.9	3,353,459.5	2,057.0	0.8	0.6
03/12/2015 22:00	10.5	13.5	8.4	112.0	3,153,889.7	1,796.4	0.8	0.5
03/12/2015 23:00	10.7	13.8	8.9	89.2	2,703,635.0	1,382.0	0.7	0.4
Average/Sum#:	11.1	13.6	8.9	105.2	2,966,382.7	1,671.5	0.8	0.5
Minimum:	10.2	13.3	8.0	86.7	2,493,123.9	1,292.6	0.7	0.4
Maximum:	11.9	13.8	9.9	126.6	3,418,645.1	2,062.8	0.8	0.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/13/2015 00:00	10.8	13.8	9.0	88.9	2,698,548.6	1,379.4	0.7	0.4
03/13/2015 01:00	10.6	13.8	8.8	89.8	2,731,712.3	1,416.3	0.7	0.4
03/13/2015 02:00	10.4	13.8	8.6	95.7	2,963,550.1	1,536.5	0.7	0.5
03/13/2015 03:00	10.7	13.8	8.9	91.0	2,720,139.7	1,410.3	0.7	0.4
03/13/2015 04:00	10.9	13.7	8.9	98.2	2,920,813.4	1,557.0	0.7	0.5
03/13/2015 05:00	10.7	13.4	8.4	117.0	3,422,876.2	1,999.6	0.7	0.6
03/13/2015 06:00	10.7	13.3	8.3	125.9	3,420,855.9	2,023.4	0.8	0.6
03/13/2015 07:00	10.6	13.4	8.3	114.2	3,449,171.0	1,939.4	0.7	0.6
03/13/2015 08:00	10.4	13.4	8.2	112.2	3,404,424.1	1,939.1	0.7	0.6
03/13/2015 09:00	10.5	13.4	8.3	112.5	3,371,384.2	1,944.9	0.7	0.6
03/13/2015 10:00	10.4	13.6	8.4	102.5	2,988,084.0	1,636.5	0.7	0.5
03/13/2015 11:00	11.8	13.8	9.8	91.2	2,498,138.7	1,295.2	0.8	0.4
03/13/2015 12:00	11.7	13.8	9.7	98.3	2,699,309.0	1,399.5	0.8	0.4
03/13/2015 13:00	10.6	13.3	8.2	117.0	3,321,188.1	1,988.7	0.8	0.6
03/13/2015 14:00	10.5	13.3	8.2	117.7	3,298,332.9	1,999.1	0.8	0.6
03/13/2015 15:00	10.6	13.2	8.1	122.5	3,291,935.1	2,043.3	0.8	0.6
03/13/2015 16:00	10.6	13.2	8.1	124.3	3,268,784.2	2,052.8	0.8	0.6
03/13/2015 17:00	10.6	13.2	8.1	123.6	3,277,860.6	2,058.5	0.8	0.6
03/13/2015 18:00	10.7	13.2	8.2	123.8	3,309,979.3	2,054.5	0.8	0.6
03/13/2015 19:00	10.6	13.2	8.1	121.0	3,297,251.7	2,046.6	0.8	0.6
03/13/2015 20:00	10.6	13.2	8.1	121.2	3,303,373.8	2,050.4	0.8	0.6
03/13/2015 21:00	10.5	13.3	8.2	119.1	3,305,529.6	2,027.6	0.8	0.6
03/13/2015 22:00	10.6	13.3	8.2	120.1	3,319,223.9	2,036.0	0.8	0.6
03/13/2015 23:00	10.6	13.2	8.1	124.3	3,295,640.6	2,045.6	0.8	0.6
Average/Sum#:	10.7	13.4	8.5	111.3	3,149,087.8	1,828.3	0.8	0.5
Minimum:	10.4	13.2	8.1	88.9	2,498,138.7	1,295.2	0.7	0.4
Maximum:	11.8	13.8	9.8	125.9	3,449,171.0	2,058.5	0.8	0.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/14/2015 00:00	10.5	13.3	8.2	117.2	3,343,065.5	2,001.8	0.8	0.6
03/14/2015 01:00	10.5	13.3	8.2	119.7	3,347,073.6	2,004.2	0.8	0.6
03/14/2015 02:00	10.5	13.3	8.2	117.1	3,366,417.1	1,991.2	0.8	0.6
03/14/2015 03:00	10.5	13.4	8.3	115.0	3,385,598.4	1,953.1	0.7	0.6
03/14/2015 04:00	10.4	13.4	8.2	113.1	3,375,544.4	1,947.3	0.7	0.6
03/14/2015 05:00	10.4	13.4	8.2	113.5	3,383,171.6	1,951.7	0.7	0.6
03/14/2015 06:00	10.6	13.3	8.2	123.7	3,342,536.7	2,050.3	0.8	0.6
03/14/2015 07:00	10.6	13.3	8.2	120.7	3,331,661.0	2,019.3	0.8	0.6
03/14/2015 08:00	10.5	13.3	8.2	116.5	3,345,960.2	1,979.1	0.8	0.6
03/14/2015 09:00	10.4	13.3	8.1	114.8	3,339,197.7	1,975.1	0.8	0.6
03/14/2015 10:00	10.5	13.3	8.2	115.9	3,339,197.7	1,975.1	0.8	0.6
03/14/2015 11:00	10.4	13.3	8.1	115.9	3,337,845.1	1,974.3	0.8	0.6
03/14/2015 12:00	10.5	13.2	8.0	121.6	3,288,390.7	2,041.1	0.8	0.6
03/14/2015 13:00	10.6	13.2	8.1	123.5	3,275,153.6	2,056.8	0.8	0.6
03/14/2015 14:00	10.6	13.2	8.1	124.4	3,278,338.3	2,058.8	0.8	0.6
03/14/2015 15:00	10.5	13.2	8.0	119.6	3,265,996.6	2,027.2	0.8	0.6
03/14/2015 16:00	10.6	13.2	8.1	125.8	3,247,109.8	2,062.9	0.9	0.6
03/14/2015 17:00	10.6	13.2	8.1	125.4	3,282,956.1	2,061.7	0.8	0.6
03/14/2015 18:00	10.6	13.2	8.1	123.9	3,280,089.9	2,059.9	0.8	0.6
03/14/2015 19:00	10.6	13.2	8.1	123.8	3,275,790.5	2,057.2	0.8	0.6
03/14/2015 20:00	10.6	13.2	8.1	123.8	3,275,153.6	2,056.8	0.8	0.6
03/14/2015 21:00	10.6	13.2	8.1	122.9	3,312,879.2	2,056.3	0.8	0.6
03/14/2015 22:00	10.6	13.2	8.1	122.1	3,307,884.9	2,053.2	0.8	0.6
03/14/2015 23:00	10.6	13.3	8.2	119.2	3,294,606.8	2,020.9	0.8	0.6
Average/Sum#:	10.5	13.3	8.1	120.0	3,317,567.5	2,018.1	0.8	0.6
Minimum:	10.4	13.2	8.0	113.1	3,247,109.8	1,947.3	0.7	0.6
Maximum:	10.6	13.4	8.3	125.8	3,385,598.4	2,062.9	0.9	0.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/15/2015 00:00	10.4	13.3	8.1	114.7	3,330,068.2	1,969.7	0.8	0.6
03/15/2015 01:00	10.5	13.3	8.2	117.5	3,310,542.2	2,006.5	0.8	0.6
03/15/2015 02:00	10.0	13.5	8.0	112.9	3,199,361.6	1,822.3	0.8	0.5
03/15/2015 03:00	9.8	13.6	7.9	107.2	3,389,135.2	1,781.9	0.7	0.5
03/15/2015 04:00	10.0	13.6	8.1	108.6	3,376,287.7	1,799.8	0.7	0.5
03/15/2015 05:00	9.9	13.6	8.0	106.8	3,353,948.6	1,763.4	0.7	0.5
03/15/2015 06:00	9.9	13.6	8.0	108.2	3,385,667.3	1,804.8	0.7	0.5
03/15/2015 07:00	10.1	13.7	8.3	98.7	2,977,356.8	1,565.4	0.7	0.5
03/15/2015 08:00	10.9	13.7	8.9	86.1	2,501,031.8	1,296.7	0.7	0.4
03/15/2015 09:00	11.4	13.8	9.5	89.2	2,541,456.0	1,299.1	0.8	0.4
03/15/2015 10:00	11.7	13.8	9.7	97.2	2,544,977.4	1,300.9	0.8	0.4
03/15/2015 11:00	10.7	13.7	8.8	100.6	3,041,472.3	1,576.9	0.7	0.5
03/15/2015 12:00	9.9	13.7	8.1	107.2	3,400,801.5	1,763.2	0.7	0.5
03/15/2015 13:00	10.4	13.4	8.2	114.9	3,328,047.9	1,919.9	0.8	0.6
03/15/2015 14:00	10.8	13.3	8.4	125.4	3,365,034.4	2,064.1	0.8	0.6
03/15/2015 15:00	10.8	13.3	8.4	124.6	3,346,286.3	2,052.6	0.8	0.6
03/15/2015 16:00	10.8	13.3	8.4	125.2	3,357,046.1	2,059.2	0.8	0.6
03/15/2015 17:00	10.8	13.3	8.4	123.6	3,354,600.7	2,057.7	0.8	0.6
03/15/2015 18:00	10.8	13.3	8.4	124.4	3,347,916.6	2,053.6	0.8	0.6
03/15/2015 19:00	10.7	13.3	8.3	124.0	3,350,362.0	2,055.1	0.8	0.6
03/15/2015 20:00	10.7	13.3	8.3	122.5	3,349,546.8	2,054.6	0.8	0.6
03/15/2015 21:00	10.7	13.3	8.3	121.2	3,337,971.9	2,047.5	0.8	0.6
03/15/2015 22:00	10.4	13.4	8.2	112.8	3,211,560.2	1,852.7	0.8	0.6
03/15/2015 23:00	11.2	13.8	9.3	88.4	2,496,402.8	1,294.3	0.8	0.4
Average/Sum#:	10.6	13.5	8.4	110.9	3,174,870.1	1,802.6	0.8	0.5
Minimum:	9.8	13.3	7.9	86.1	2,496,402.8	1,294.3	0.7	0.4
Maximum:	11.7	13.8	9.7	125.4	3,400,801.5	2,064.1	0.8	0.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/16/2015 00:00	12.0	13.8	10.0	92.8	2,492,352.4	1,292.2	0.8	0.4
03/16/2015 01:00	12.0	13.8	10.0	91.5	2,487,916.2	1,289.9	0.8	0.4
03/16/2015 02:00	12.0	13.8	10.0	92.9	2,490,809.4	1,291.4	0.8	0.4
03/16/2015 03:00	12.0	13.8	10.0	93.8	2,496,788.5	1,294.5	0.8	0.4
03/16/2015 04:00	11.4	13.7	9.3	104.7	2,883,933.7	1,558.4	0.8	0.5
03/16/2015 05:00	10.6	13.3	8.2	117.9	3,367,281.0	2,016.3	0.8	0.6
03/16/2015 06:00	10.7	13.3	8.3	124.2	3,353,622.5	2,057.1	0.8	0.6
03/16/2015 07:00	10.5	13.4	8.3	120.2	3,396,003.4	2,008.7	0.8	0.6
03/16/2015 08:00	10.6	13.3	8.2	121.2	3,382,478.2	2,050.1	0.8	0.6
03/16/2015 09:00	10.7	13.3	8.3	124.3	3,350,035.9	2,054.9	0.8	0.6
03/16/2015 10:00	10.7	13.3	8.3	122.0	3,368,454.0	2,041.6	0.8	0.6
03/16/2015 11:00	10.7	13.3	8.3	123.6	3,351,829.2	2,056.0	0.8	0.6
03/16/2015 12:00	10.7	13.3	8.3	122.6	3,346,123.3	2,052.5	0.8	0.6
03/16/2015 13:00	10.7	13.3	8.3	122.2	3,347,916.6	2,053.6	0.8	0.6
03/16/2015 14:00	10.7	13.3	8.3	121.6	3,346,775.4	2,052.9	0.8	0.6
03/16/2015 15:00	10.6	13.3	8.2	122.4	3,333,733.2	2,044.9	0.8	0.6
03/16/2015 16:00	10.5	13.3	8.2	117.2	3,349,077.6	2,005.4	0.8	0.6
03/16/2015 17:00	10.5	13.3	8.2	114.4	3,341,226.4	1,976.3	0.8	0.6
03/16/2015 18:00	10.6	13.3	8.2	121.2	3,353,769.8	2,032.7	0.8	0.6
03/16/2015 19:00	10.6	13.3	8.2	121.4	3,341,395.5	2,049.6	0.8	0.6
03/16/2015 20:00	10.5	13.3	8.2	117.0	3,356,926.8	2,010.1	0.8	0.6
03/16/2015 21:00	10.5	13.4	8.3	114.0	3,344,269.6	1,978.1	0.7	0.6
03/16/2015 22:00	10.5	13.7	8.6	94.5	2,772,513.8	1,457.7	0.7	0.4
03/16/2015 23:00	10.9	13.7	8.9	86.0	2,493,316.8	1,292.7	0.7	0.4
Average/Sum#:	10.9	13.4	8.6	112.7	3,131,189.6	1,834.1	0.8	0.5
Minimum:	10.5	13.3	8.2	86.0	2,487,916.2	1,289.9	0.7	0.4
Maximum:	12.0	13.8	10.0	124.3	3,396,003.4	2,057.1	0.8	0.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/17/2015 00:00	11.0	13.8	9.1	86.2	2,490,616.5	1,291.3	0.7	0.4
03/17/2015 01:00	11.0	13.8	9.1	86.2	2,491,773.7	1,291.9	0.7	0.4
03/17/2015 02:00	11.1	13.8	9.2	86.3	2,492,159.5	1,292.1	0.7	0.4
03/17/2015 03:00	11.1	13.8	9.2	86.3	2,493,509.6	1,292.8	0.7	0.4
03/17/2015 04:00	11.1	13.8	9.2	86.3	2,492,738.1	1,292.4	0.7	0.4
03/17/2015 05:00	11.1	13.8	9.2	86.3	2,492,545.3	1,292.3	0.7	0.4
03/17/2015 06:00	11.1	13.8	9.2	86.1	2,492,931.0	1,292.5	0.7	0.4
03/17/2015 07:00	11.1	13.8	9.2	86.4	2,490,423.6	1,291.2	0.7	0.4
03/17/2015 08:00	11.1	13.8	9.2	86.3	2,493,895.4	1,293.0	0.7	0.4
03/17/2015 09:00	11.1	13.8	9.2	86.6	2,498,910.2	1,295.6	0.7	0.4
03/17/2015 10:00	11.1	13.8	9.2	86.4	2,505,468.0	1,299.0	0.7	0.4
03/17/2015 11:00	11.1	13.8	9.2	86.5	2,504,889.4	1,298.7	0.7	0.4
03/17/2015 12:00	11.1	13.8	9.2	86.4	2,508,939.8	1,300.8	0.7	0.4
03/17/2015 13:00	11.0	13.8	9.1	86.5	2,512,025.8	1,302.4	0.7	0.4
03/17/2015 14:00	11.6	13.8	9.6	93.8	2,513,183.1	1,303.0	0.8	0.4
03/17/2015 15:00	11.8	13.8	9.8	94.3	2,547,520.6	1,302.2	0.8	0.4
03/17/2015 16:00	11.9	13.8	9.9	94.9	2,542,825.4	1,299.8	0.8	0.4
03/17/2015 17:00	11.8	13.8	9.8	91.9	2,542,434.2	1,299.6	0.8	0.4
03/17/2015 18:00	11.9	13.8	9.9	94.1	2,539,304.1	1,298.0	0.8	0.4
03/17/2015 19:00	12.0	13.8	10.0	94.0	2,536,369.6	1,296.5	0.8	0.4
03/17/2015 20:00	12.0	13.8	10.0	93.9	2,496,981.4	1,294.6	0.8	0.4
03/17/2015 21:00	12.1	13.8	10.1	94.8	2,533,043.8	1,294.8	0.8	0.4
03/17/2015 22:00	12.3	13.8	10.2	95.9	2,529,131.2	1,292.8	0.8	0.4
03/17/2015 23:00	12.2	13.8	10.1	92.3	2,485,215.9	1,288.5	0.8	0.4
Average/Sum#:	11.4	13.8	9.5	89.5	2,509,451.5	1,295.7	0.7	0.4
Minimum:	11.0	13.8	9.1	86.1	2,485,215.9	1,288.5	0.7	0.4
Maximum:	12.3	13.8	10.2	95.9	2,547,520.6	1,303.0	0.8	0.4
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/18/2015 00:00	12.3	13.8	10.2	94.8	2,484,058.7	1,287.9	0.8	0.4
03/18/2015 01:00	12.4	13.8	10.3	98.8	2,527,370.5	1,291.9	0.8	0.4
03/18/2015 02:00	12.3	13.8	10.2	99.4	2,548,107.5	1,302.5	0.8	0.4
03/18/2015 03:00	12.2	13.8	10.1	97.0	2,552,215.8	1,304.6	0.8	0.4
03/18/2015 04:00	12.2	13.8	10.1	98.5	2,552,020.2	1,304.5	0.8	0.4
03/18/2015 05:00	12.3	13.8	10.2	97.3	2,549,672.6	1,303.3	0.8	0.4
03/18/2015 06:00	12.3	13.8	10.2	105.5	2,548,890.0	1,302.9	0.9	0.4
03/18/2015 07:00	12.3	13.8	10.2	95.0	2,546,933.7	1,301.9	0.8	0.4
03/18/2015 08:00	12.3	13.8	10.2	94.1	2,547,911.9	1,302.4	0.8	0.4
03/18/2015 09:00	4.4	18.3	10.0	110.1	2,544,586.1	1,300.7	0.9	0.4
03/18/2015 10:00	6.6	17.0	10.0	109.9	853,236.6	1,302.2	3.1	1.6
03/18/2015 11:00	6.3	17.2	10.0	101.1	2,544,977.4	1,300.9	0.9	0.4
03/18/2015 12:00	6.2	17.3	10.2	101.8	2,541,064.8	1,298.9	0.9	0.4
03/18/2015 13:00	10.5	14.9	10.3	99.6	2,540,086.6	1,298.4	0.8	0.4
03/18/2015 14:00	12.2	13.9	10.3	99.3	2,572,561.5	1,315.0	0.8	0.4
03/18/2015 15:00	10.9	13.8	9.1	110.7	3,212,168.1	1,665.4	0.7	0.5
03/18/2015 16:00	10.4	13.8	8.6	106.5	3,252,093.6	1,686.1	0.7	0.5
03/18/2015 17:00	11.6	13.8	9.6	93.9	2,514,458.8	1,285.3	0.8	0.4
03/18/2015 18:00	12.6	13.9	10.6	101.4	2,517,197.6	1,286.7	0.9	0.4
03/18/2015 19:00	12.0	13.9	10.1	93.7	2,515,437.0	1,285.8	0.8	0.4
03/18/2015 20:00	11.9	13.9	10.0	93.8	2,519,545.2	1,287.9	0.8	0.4
03/18/2015 21:00	11.9	13.9	10.0	93.8	2,522,675.3	1,289.5	0.8	0.4
03/18/2015 22:00	11.8	13.8	9.8	92.1	2,515,828.2	1,286.0	0.8	0.4
03/18/2015 23:00	11.9	13.8	9.9	91.9	2,513,871.9	1,285.0	0.8	0.4
Average/Sum#:	10.9	14.5	10.0	99.2	2,594,944.9	1,328.2	0.8	0.4
Minimum:	4.4	13.8	8.6	91.9	2,484,058.7	1,285.0	0.7	0.4
Maximum:	12.6	18.3	10.6	110.7	3,252,093.6	1,686.1	0.9	0.5
%SI	0.0	0.0	0.0	0.0	4.2	0.0	4.2	4.2

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/19/2015 00:00	11.9	13.8	9.9	92.6	2,514,458.8	1,285.3	0.8	0.4
03/19/2015 01:00	11.8	13.8	9.8	90.9	2,511,524.3	1,283.8	0.8	0.4
03/19/2015 02:00	11.8	13.8	9.8	91.1	2,511,524.3	1,283.8	0.8	0.4
03/19/2015 03:00	11.9	13.8	9.9	92.5	2,515,241.3	1,285.7	0.8	0.4
03/19/2015 04:00	11.9	13.8	9.9	92.9	2,518,567.1	1,287.4	0.8	0.4
03/19/2015 05:00	12.0	13.8	10.0	96.1	2,530,500.6	1,293.5	0.8	0.4
03/19/2015 06:00	12.2	13.8	10.1	123.4	2,757,629.4	1,409.6	1.0	0.6
03/19/2015 07:00	10.9	13.4	8.6	119.6	3,406,614.3	1,990.1	0.8	0.6
03/19/2015 08:00	10.6	13.5	8.5	116.6	3,404,950.8	1,939.4	0.7	0.6
03/19/2015 09:00	10.6	13.4	8.3	116.2	3,374,504.4	1,946.7	0.8	0.6
03/19/2015 10:00	10.6	13.4	8.3	116.5	3,385,598.4	1,953.1	0.8	0.6
03/19/2015 11:00	10.7	13.4	8.4	118.9	3,384,703.5	1,977.3	0.8	0.6
03/19/2015 12:00	10.8	13.3	8.4	123.6	3,322,158.3	2,037.8	0.8	0.6
03/19/2015 13:00	10.7	13.3	8.3	119.3	3,352,553.8	1,983.0	0.8	0.6
03/19/2015 14:00	10.5	13.6	8.5	101.0	2,912,432.6	1,573.8	0.8	0.5
03/19/2015 15:00	11.0	13.9	9.3	88.3	2,591,929.1	1,324.9	0.7	0.4
03/19/2015 16:00	11.1	13.8	9.2	93.5	2,731,414.7	1,396.2	0.7	0.4
03/19/2015 17:00	10.5	13.4	8.3	113.1	3,353,891.5	1,959.3	0.7	0.6
03/19/2015 18:00	10.6	13.3	8.2	117.8	3,342,731.5	2,001.6	0.8	0.6
03/19/2015 19:00	10.8	13.3	8.4	124.9	3,322,868.0	2,062.5	0.8	0.6
03/19/2015 20:00	10.6	13.4	8.3	116.4	3,366,901.0	1,966.9	0.8	0.6
03/19/2015 21:00	10.3	13.5	8.2	109.3	3,117,841.4	1,753.1	0.8	0.5
03/19/2015 22:00	10.3	13.8	8.6	92.8	2,826,993.4	1,465.7	0.7	0.4
03/19/2015 23:00	11.0	13.8	9.1	86.3	2,526,491.5	1,309.9	0.7	0.4
Average/Sum#:	11.0	13.6	8.9	106.4	2,982,667.7	1,657.1	0.8	0.5
Minimum:	10.3	13.3	8.2	86.3	2,511,524.3	1,283.8	0.7	0.4
Maximum:	12.2	13.9	10.1	124.9	3,406,614.3	2,062.5	1.0	0.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/20/2015 00:00	10.4	13.8	8.6	90.6	2,839,599.3	1,451.5	0.7	0.4
03/20/2015 01:00	11.5	13.8	9.6	91.7	2,509,518.4	1,301.1	0.8	0.4
03/20/2015 02:00	10.6	13.7	8.7	106.4	3,192,851.0	1,678.7	0.7	0.5
03/20/2015 03:00	10.9	13.8	9.1	87.3	2,547,708.0	1,320.9	0.7	0.4
03/20/2015 04:00	10.8	13.6	8.7	107.6	3,061,120.0	1,676.5	0.8	0.5
03/20/2015 05:00	10.6	13.4	8.3	120.7	3,386,535.8	2,003.1	0.8	0.6
03/20/2015 06:00	10.8	13.3	8.4	146.2	3,373,898.7	2,044.9	1.0	0.8
03/20/2015 07:00	10.5	13.4	8.3	229.1	1,291,714.5	1,971.4	4.3	3.4
03/20/2015 08:00	10.5	13.4	8.3	142.0	1,265,505.4	1,931.4	2.7	1.9
03/20/2015 09:00	9.8	13.6	7.9	136.0	1,183,012.3	1,805.5	2.7	1.8
03/20/2015 10:00	9.8	13.6	7.9	131.0	1,184,322.8	1,807.5	2.6	1.8
03/20/2015 11:00	0.0	0.0	0.0	133.7	3,318,389.2	1,817.4	1.0	0.7
03/20/2015 12:00	10.4	13.3	8.1	134.8	3,370,643.7	1,993.7	0.9	0.6
03/20/2015 13:00	10.5	13.3	8.2	117.8	3,322,256.6	2,013.6	0.8	0.6
03/20/2015 14:00	10.5	13.3	8.2	115.1	3,317,013.1	1,986.2	0.8	0.6
03/20/2015 15:00	10.4	13.3	8.1	115.8	3,307,493.9	1,980.5	0.8	0.6
03/20/2015 16:00	10.3	13.3	8.0	111.9	3,338,827.8	1,950.5	0.7	0.6
03/20/2015 17:00	10.3	13.3	8.0	112.0	3,333,350.1	1,947.3	0.7	0.6
03/20/2015 18:00	10.3	13.3	8.0	112.4	3,345,332.6	1,954.3	0.7	0.6
03/20/2015 19:00	10.3	13.3	8.0	111.5	3,335,746.6	1,948.7	0.7	0.6
03/20/2015 20:00	10.3	13.3	8.0	112.2	3,333,692.5	1,947.5	0.7	0.6
03/20/2015 21:00	10.3	13.4	8.1	113.9	3,377,971.3	1,948.7	0.7	0.6
03/20/2015 22:00	10.1	13.6	8.2	107.2	3,147,119.8	1,723.6	0.7	0.5
03/20/2015 23:00	11.1	13.7	9.1	86.8	2,491,966.6	1,292.0	0.7	0.4
Average/Sum#:	10.5	13.5	8.3	119.7	3,162,551.8	1,812.4	0.8	0.6
Minimum:	9.8	13.3	7.9	86.8	2,491,966.6	1,292.0	0.7	0.4
Maximum:	11.5	13.8	9.6	229.1	3,386,535.8	2,044.9	1.0	0.8
%SI	4.2	4.2	4.2	0.0	16.7	0.0	20.8	20.8

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/21/2015 00:00	12.0	13.8	10.0	91.5	2,483,094.3	1,287.4	0.8	0.4
03/21/2015 01:00	10.7	13.7	8.8	101.5	2,957,185.2	1,533.2	0.7	0.5
03/21/2015 02:00	11.0	13.8	9.1	88.3	2,581,847.2	1,338.6	0.7	0.4
03/21/2015 03:00	10.5	13.7	8.6	100.7	3,001,739.7	1,556.3	0.7	0.5
03/21/2015 04:00	10.4	13.8	8.6	100.0	3,054,780.8	1,583.8	0.7	0.5
03/21/2015 05:00	11.0	13.7	9.0	100.8	2,836,800.7	1,491.5	0.8	0.4
03/21/2015 06:00	10.9	13.4	8.6	121.1	3,448,869.3	1,989.6	0.8	0.6
03/21/2015 07:00	10.5	13.6	8.5	110.6	3,202,651.2	1,777.4	0.8	0.5
03/21/2015 08:00	11.1	13.7	9.1	90.3	2,596,312.9	1,346.1	0.7	0.4
03/21/2015 09:00	11.8	13.7	9.7	92.5	2,522,441.1	1,307.8	0.8	0.4
03/21/2015 10:00	11.8	13.8	9.8	95.0	2,530,927.7	1,312.2	0.8	0.4
03/21/2015 11:00	11.9	13.8	9.9	96.8	2,536,328.3	1,315.0	0.8	0.4
03/21/2015 12:00	11.0	13.8	9.1	89.7	2,629,294.8	1,344.0	0.7	0.4
03/21/2015 13:00	11.3	13.8	9.4	91.8	2,568,453.2	1,312.9	0.8	0.4
03/21/2015 14:00	10.9	13.8	9.1	93.4	2,747,260.9	1,404.3	0.7	0.4
03/21/2015 15:00	10.4	13.8	8.6	95.9	2,917,265.2	1,491.2	0.7	0.4
03/21/2015 16:00	10.2	13.7	8.4	102.6	3,166,263.5	1,641.6	0.7	0.5
03/21/2015 17:00	10.3	13.5	8.2	110.8	3,178,644.7	1,810.5	0.8	0.5
03/21/2015 18:00	10.6	13.3	8.2	118.0	3,322,256.6	2,013.6	0.8	0.6
03/21/2015 19:00	10.6	13.3	8.2	119.1	3,324,566.4	2,015.0	0.8	0.6
03/21/2015 20:00	10.6	13.3	8.2	120.3	3,356,574.7	2,034.4	0.8	0.6
03/21/2015 21:00	10.6	13.3	8.2	118.3	3,355,256.7	2,009.1	0.8	0.6
03/21/2015 22:00	10.1	13.6	8.2	109.1	3,262,881.8	1,787.0	0.7	0.5
03/21/2015 23:00	10.0	13.7	8.2	105.3	3,338,732.7	1,755.4	0.7	0.5
Average/Sum#:	10.8	13.6	8.8	102.6	2,955,017.9	1,602.4	0.8	0.5
Minimum:	10.0	13.3	8.2	88.3	2,483,094.3	1,287.4	0.7	0.4
Maximum:	12.0	13.8	10.0	121.1	3,448,869.3	2,034.4	0.8	0.6
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/22/2015 00:00	10.0	13.6	8.1	108.0	3,389,044.0	1,806.6	0.7	0.5
03/22/2015 01:00	9.9	13.8	8.2	99.4	3,099,721.0	1,607.1	0.7	0.5
03/22/2015 02:00	10.1	13.7	8.3	98.7	3,146,632.9	1,654.4	0.7	0.5
03/22/2015 03:00	10.0	13.7	8.2	106.1	3,396,365.3	1,760.9	0.7	0.5
03/22/2015 04:00	10.4	13.7	8.5	96.2	2,937,897.5	1,523.2	0.7	0.5
03/22/2015 05:00	10.7	13.7	8.8	100.4	3,078,311.7	1,596.0	0.7	0.5
03/22/2015 06:00	10.5	13.7	8.6	105.0	3,169,542.4	1,643.3	0.7	0.5
03/22/2015 07:00	10.5	13.6	8.5	101.5	3,076,393.4	1,662.4	0.7	0.5
03/22/2015 08:00	11.0	13.2	8.4	125.0	3,333,570.2	2,044.8	0.8	0.6
03/22/2015 09:00	11.1	13.3	8.6	126.4	3,285,477.3	2,015.3	0.8	0.6
03/22/2015 10:00	11.0	13.3	8.5	121.4	3,303,355.9	1,953.9	0.8	0.6
03/22/2015 11:00	11.1	13.3	8.6	123.8	3,275,763.3	1,961.5	0.8	0.6
03/22/2015 12:00	10.6	13.3	8.2	115.4	3,342,071.8	1,976.8	0.8	0.6
03/22/2015 13:00	10.1	13.5	8.1	104.8	3,100,924.6	1,698.3	0.7	0.5
03/22/2015 14:00	10.3	13.7	8.4	101.5	3,103,578.6	1,609.1	0.7	0.5
03/22/2015 15:00	10.0	13.7	8.2	99.1	3,101,264.0	1,607.9	0.7	0.5
03/22/2015 16:00	10.0	13.8	8.3	96.6	3,061,837.3	1,565.1	0.7	0.5
03/22/2015 17:00	10.7	13.6	8.6	104.1	3,096,520.8	1,718.5	0.7	0.5
03/22/2015 18:00	10.7	13.3	8.3	118.4	3,368,450.0	2,017.0	0.8	0.6
03/22/2015 19:00	10.6	13.3	8.2	117.0	3,385,352.3	2,002.4	0.8	0.6
03/22/2015 20:00	10.5	13.4	8.3	114.1	3,383,505.3	1,976.6	0.7	0.6
03/22/2015 21:00	10.5	13.7	8.6	94.5	2,742,975.8	1,462.2	0.7	0.4
03/22/2015 22:00	11.1	13.8	9.2	86.4	2,509,325.5	1,301.0	0.7	0.4
03/22/2015 23:00	33.2	16.6	45.6	224.3	1,308,693.4	439.6	3.8	0.7
Average/Sum#:	11.4	13.7	10.0	112.0	3,083,190.6	1,691.8	0.9	0.5
Minimum:	9.9	13.2	8.1	86.4	1,308,693.4	439.6	0.7	0.4
Maximum:	33.2	16.6	45.6	224.3	3,396,365.3	2,044.8	3.8	0.7
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/23/2015 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2015 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/24/2015 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2015 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/25/2015 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2015 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/26/2015 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2015 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2015 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2015 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2015 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2015 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2015 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2015 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2015 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2015 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2015 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2015 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2015 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2015 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2015 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2015 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2015 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2015 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2015 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2015 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2015 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2015 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2015 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2015 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/27/2015 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2015 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2015 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2015 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2015 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2015 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2015 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2015 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2015 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2015 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2015 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2015 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2015 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2015 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2015 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2015 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2015 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2015 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2015 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2015 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2015 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2015 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2015 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2015 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/28/2015 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/28/2015 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/29/2015 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/29/2015 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/30/2015 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2015 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2015 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2015 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2015 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2015 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2015 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2015 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2015 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2015 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2015 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2015 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2015 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2015 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2015 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2015 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2015 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2015 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2015 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2015 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2015 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2015 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2015 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/30/2015 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:41 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/31/2015 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2015 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2015 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2015 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2015 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2015 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2015 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2015 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2015 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2015 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2015 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2015 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2015 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2015 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2015 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2015 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2015 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2015 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2015 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2015 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2015 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2015 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2015 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2015 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

ATTACHMENT 9

Quarterly/Annual Emissions
(Fuel Use, Hours of Operation and NH3 Injection)

FCD:	AQ-23, 26
Title V:	#6, 13

Emissions Limits Per AQ-26

Quarterly and Annual Combustion Emissions from CGS Facility					
Pollutant	1st Quarter Emissions (tons)	2nd Quarter Emissions (tons)	3rd Quarter Emissions (tons)	4th Quarter Emissions (tons)	Annual Emissions (tons)
NO_x	45.56	43.58	51.30	44.27	184.7
CO	54.29	52.49	107.15	53.95	267.9
VOC's	12.30	11.63	11.84	11.76	47.5
PM10	25.54	25.78	26.02	26.02	103.4
SO_2	4.07	3.85	3.89	3.89	15.7

Notes

1. Emissions are based on CT1 and CT2.
2. VOC Mass Emissions are based on Average Souce Test Results for lbs/MMBtu. CT1 EF = .0009 Prior to 10/30/2013 and .0007 After 10/30/2013. CT2 EF = .0007 Prior to 11/01/2014 and .0003 after 11/01/2014.
3. PM10 is based on 2010 lb/MMBtu Source Test Results. CT1 EF = .0025; CT2 EF = .003

Quarterly Emissions

Cumulative Emissions Report

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/29/2015 12:54 **Location:** Maxwell, CA

Month	PlantWide NOx, Tons 1 Day(s)	PlantWide CO, Tons 1 Day(s)	PlantWide VOC, Tons 1 Day(s)	PlantWide PM10, Tons 1 Day(s)	PlantWide SO2, Tons 1 Day(s)
January	5.0	1.1	0.7	3.6	0.8
February	4.1	0.9	0.5	2.7	0.6
March	3.6	0.9	0.5	2.5	0.6
Quarter 1	12.7	2.9	1.7	8.8	2.0
YTD	12.7	2.9	1.7	8.8	2.0

Monthly Summary by Day (Pounds)

Monthly Summary By Day Report

CT1 and CT2 - Pounds

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:50 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)
01/01/2015	24.8	168.10	28.7	28.1	184.20	29.1
01/02/2015	25.3	154.80	27.5	30.3	186.60	28.0
01/03/2015	31.7	157.80	28.8	31.8	193.80	29.4
01/04/2015	31.1	154.70	29.5	31.0	201.60	30.2
01/05/2015	23.7	145.50	29.1	30.5	197.00	29.3
01/06/2015	18.5	121.20	26.3	25.0	170.20	26.5
01/07/2015	22.5	135.10	27.1	30.6	181.20	27.7
01/08/2015	31.6	150.10	29.0	32.0	197.70	29.6
01/09/2015	21.0	134.00	27.0	29.2	177.60	27.5
01/10/2015	29.2	138.50	27.7	31.9	186.40	28.3
01/11/2015	32.8	149.30	29.0	30.4	196.70	29.7
01/12/2015	29.4	145.80	28.7	30.8	193.90	29.1
01/13/2015	32.1	152.20	29.0	29.1	195.20	29.3
01/14/2015	31.1	158.20	28.2	29.9	187.90	28.6
01/15/2015	23.5	141.60	25.6	27.4	175.70	26.6
01/16/2015	15.0	117.30	23.6	83.5	178.95	21.9
01/17/2015	14.2	130.70	25.0	27.0	163.20	25.8
01/18/2015	91.5	144.95	11.5	92.0	181.64	15.3
01/19/2015	24.1	148.50	26.8	28.9	173.40	26.7
01/20/2015	31.5	173.60	28.0	36.8	191.80	28.2
01/21/2015	25.0	173.70	27.6	32.8	185.70	27.8
01/22/2015	20.5	141.40	25.9	30.3	171.90	26.0
01/23/2015	25.5	167.70	27.7	29.8	187.40	28.5
01/24/2015	25.6	159.40	26.7	29.4	179.70	27.0
01/25/2015	151.1	167.04	10.7	6.2	10.93	1.0
01/26/2015	65.9	169.69	19.9	0.0	0.00	0.0
01/27/2015	10.3	131.10	23.8	240.1	244.24	14.9
01/28/2015	21.0	141.70	25.2	16.7	167.00	25.2
01/29/2015	25.1	165.10	27.3	23.4	182.70	27.4
01/30/2015	22.1	155.80	26.3	21.6	176.20	26.4
01/31/2015	100.6	191.65	21.0	14.6	168.60	25.1
Monthly Avg/Sum*:	1,077.3 *	4,686.23 *	798.2 *	1,161.1 *	5,389.06 *	776.1 *
Daily Min:	10.3	117.30	10.7	6.2	10.93	1.0
Daily Max:	151.1	191.65	29.5	240.1	244.24	30.2
Jan 2015 - Jan 2015	1,077.3	4,686.23	798.2	1,161.1	5,389.06	776.1
QTD:	1,077.3 *	4,686.23 *	798.2 *	1,161.1 *	5,389.06 *	776.1 *
YTD 2015:	1,077.3 *	4,686.23 *	798.2 *	1,161.1 *	5,389.06 *	776.1 *

Monthly Summary By Day Report

CT1 and CT2 - Pounds

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:50 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)
02/01/2015	110.0	189.13	15.7	62.4	197.92	12.5
02/02/2015	29.6	158.60	27.3	21.7	184.00	27.5
02/03/2015	16.9	119.50	23.8	14.8	156.50	23.8
02/04/2015	18.8	114.30	23.1	15.3	150.40	23.1
02/05/2015	14.2	111.70	23.2	14.4	151.90	23.2
02/06/2015	21.0	124.20	24.6	18.9	161.70	24.8
02/07/2015	8.2	90.30	21.2	10.2	138.40	21.2
02/08/2015	10.7	91.50	21.4	9.3	141.20	21.5
02/09/2015	6.5	97.10	21.5	9.8	139.70	21.5
02/10/2015	19.6	120.20	23.1	13.3	151.30	23.1
02/11/2015	25.1	144.80	25.8	16.1	171.30	25.9
02/12/2015	22.8	137.60	24.5	14.2	163.50	24.6
02/13/2015	20.2	137.70	24.5	12.9	163.20	24.5
02/14/2015	22.5	133.10	24.0	13.4	157.30	24.0
02/15/2015	57.8	145.51	9.3	72.7	204.33	14.9
02/16/2015	21.8	153.70	26.1	14.3	176.60	26.3
02/17/2015	19.7	129.80	24.5	16.2	164.00	24.6
02/18/2015	24.9	147.50	26.0	19.7	171.00	26.0
02/19/2015	28.5	150.40	26.8	23.2	178.30	26.8
02/20/2015	5.7	4.79	0.9	49.3	73.25	8.1
02/21/2015	210.1	152.41	8.9	168.5	228.83	12.6
02/22/2015	4.2	28.25	5.2	84.8	222.87	13.0
02/23/2015	0.0	0.00	0.0	66.5	228.75	22.3
02/24/2015	164.1	297.63	19.8	11.3	164.00	24.6
02/25/2015	13.6	132.80	23.5	11.6	154.50	23.4
02/26/2015	16.4	140.30	24.4	11.0	160.90	24.3
02/27/2015	17.4	127.80	23.5	12.6	155.90	23.5
02/28/2015	82.3	156.98	17.2	62.5	189.60	10.8
Monthly Avg/Sum*:	1,012.6 *	3,537.60 *	559.8 *	870.9 *	4,701.15 *	602.4 *
Daily Min:	4.2	4.79	0.9	9.3	73.25	8.1
Daily Max:	210.1	297.63	27.3	168.5	228.83	27.5
Jan 2015 - Feb 2015	2,089.9	8,223.83	1,358.0	2,032.0	10,090.21	1,378.5
QTD:	2,089.9 *	8,223.83 *	1,358.0 *	2,032.0 *	10,090.21 *	1,378.5 *
YTD 2015:	2,089.9 *	8,223.83 *	1,358.0 *	2,032.0 *	10,090.21 *	1,378.5 *

Monthly Summary By Day Report

CT1 and CT2 - Pounds

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:50 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)
03/01/2015	36.1	180.50	27.4	15.3	185.10	27.4
03/02/2015	34.1	178.80	27.8	19.2	184.70	27.8
03/03/2015	19.7	130.70	23.3	11.0	155.20	23.3
03/04/2015	23.5	149.20	25.2	14.3	165.70	25.2
03/05/2015	23.3	139.96	24.6	18.2	162.41	24.7
03/06/2015	22.8	130.60	24.0	16.6	157.40	24.0
03/07/2015	114.4	182.59	16.4	95.2	208.71	12.2
03/08/2015	79.7	125.86	14.2	77.4	150.79	17.9
03/09/2015	24.1	134.00	23.6	19.0	156.20	23.6
03/10/2015	30.5	145.70	24.8	20.6	163.00	24.9
03/11/2015	36.2	133.10	25.8	23.4	173.20	25.8
03/12/2015	27.3	131.80	24.1	17.4	159.10	24.1
03/13/2015	30.7	155.90	25.9	22.8	175.50	26.0
03/14/2015	47.5	186.30	28.8	25.9	193.60	28.8
03/15/2015	26.3	144.30	25.9	18.4	171.50	25.9
03/16/2015	36.9	135.90	26.2	22.5	174.70	26.2
03/17/2015	1.2	70.45	19.0	4.8	124.80	19.2
03/18/2015	0.0	98.70	19.6	1.2	119.08	19.0
03/19/2015	23.5	102.40	24.0	18.3	157.60	24.1
03/20/2015	46.8	159.80	26.4	18.8	140.20	26.4
03/21/2015	30.3	113.50	23.2	13.0	153.80	23.2
03/22/2015	40.0	136.07	24.9	18.4	157.52	24.4
03/23/2015	0.0	0.00	0.0	0.0	0.00	0.0
03/24/2015	0.0	0.00	0.0	0.0	0.00	0.0
03/25/2015	0.0	0.00	0.0	0.0	0.00	0.0
03/26/2015	266.3	146.58	15.5	0.0	0.00	0.0
03/27/2015	49.3	112.73	12.2	0.0	0.00	0.0
03/28/2015	0.0	0.00	0.0	0.0	0.00	0.0
03/29/2015	0.0	0.00	0.0	0.0	0.00	0.0
03/30/2015	170.7	174.23	13.6	0.0	0.00	0.0
03/31/2015	50.7	117.93	14.1	0.0	0.00	0.0
Monthly Avg/Sum*:	1,291.9 *	3,617.60 *	580.5 *	511.7 *	3,589.81 *	524.1 *
Daily Min:	0.0	70.45	12.2	1.2	119.08	12.2
Daily Max:	266.3	186.30	28.8	95.2	208.71	28.8
Jan 2015 - Mar 2015	3,381.8	11,841.43	1,938.5	2,543.7	13,680.02	1,902.6
QTD:	3,381.8 *	11,841.43 *	1,938.5 *	2,543.7 *	13,680.02 *	1,902.6 *
YTD 2015:	3,381.8 *	11,841.43 *	1,938.5 *	2,543.7 *	13,680.02 *	1,902.6 *

Monthly Summary By Day Report

VOC PM10

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:50 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 VOC, Lb 1 Day(s)	Unit CT1 PM10, Lb 1 Day(s)	Unit CT2 VOC, Lb 1 Day(s)	Unit CT2 PM10, Lb 1 Day(s)
01/01/2015	33.1	118.0	14.5	144.7
01/02/2015	31.8	114.4	14.0	140.0
01/03/2015	33.7	119.9	14.9	147.4
01/04/2015	34.7	123.4	15.3	151.1
01/05/2015	33.8	121.3	15.0	148.1
01/06/2015	30.5	108.9	13.2	132.0
01/07/2015	31.8	114.1	14.1	139.0
01/08/2015	34.0	121.3	14.8	148.6
01/09/2015	31.9	113.4	14.0	138.1
01/10/2015	32.5	116.0	14.3	141.5
01/11/2015	33.7	120.8	14.9	147.5
01/12/2015	33.4	119.8	14.8	145.5
01/13/2015	33.7	120.1	14.7	146.3
01/14/2015	32.9	117.5	14.6	143.8
01/15/2015	29.9	107.2	13.6	132.8
01/16/2015	27.2	97.6	11.2	109.9
01/17/2015	29.0	103.9	13.0	128.5
01/18/2015	13.3	47.9	7.4	75.8
01/19/2015	31.4	112.1	13.8	134.4
01/20/2015	32.8	117.6	14.4	143.6
01/21/2015	32.2	115.4	14.3	140.9
01/22/2015	30.3	108.2	13.4	132.1
01/23/2015	32.4	116.5	14.4	142.3
01/24/2015	31.2	111.6	13.7	135.8
01/25/2015	12.4	44.4	0.5	4.9
01/26/2015	23.2	81.5	0.0	0.0
01/27/2015	28.1	99.6	7.7	74.8
01/28/2015	29.1	103.9	12.9	125.3
01/29/2015	32.1	114.5	14.4	138.7
01/30/2015	30.8	111.0	14.0	133.4
01/31/2015	24.6	88.6	12.7	126.4
Monthly Avg/Sum*:	931.5 *	3,330.4 *	394.5 *	3,893.2 *
Daily Min:	12.4	44.4	0.0	0.0
Daily Max:	34.7	123.4	15.3	151.1
Jan 2015 - Jan 2015	931.5	3,330.4	394.5	3,893.2
QTD:	931.5 *	3,330.4 *	394.5 *	3,893.2 *
YTD 2015:	931.5 *	3,330.4 *	394.5 *	3,893.2 *

Monthly Summary By Day Report

VOC PM10

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:50 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 VOC, Lb 1 Day(s)	Unit CT1 PM10, Lb 1 Day(s)	Unit CT2 VOC, Lb 1 Day(s)	Unit CT2 PM10, Lb 1 Day(s)
02/01/2015	18.5	66.0	6.2	62.5
02/02/2015	32.1	114.2	14.4	137.9
02/03/2015	27.9	99.3	12.2	119.4
02/04/2015	26.6	95.2	11.7	115.6
02/05/2015	26.4	94.2	11.6	114.3
02/06/2015	28.7	102.3	12.7	123.9
02/07/2015	24.4	87.8	10.6	105.9
02/08/2015	24.4	88.0	10.7	106.1
02/09/2015	24.5	88.0	10.9	106.7
02/10/2015	26.6	94.7	11.7	115.0
02/11/2015	30.1	107.4	13.4	129.7
02/12/2015	28.3	101.9	12.4	122.5
02/13/2015	28.7	103.2	12.5	123.8
02/14/2015	27.6	98.5	12.1	119.3
02/15/2015	10.9	38.3	7.3	74.1
02/16/2015	30.8	110.2	14.0	132.8
02/17/2015	28.8	103.2	13.0	124.2
02/18/2015	30.5	108.3	13.4	130.9
02/19/2015	31.2	110.7	13.7	133.6
02/20/2015	1.0	3.7	3.8	40.0
02/21/2015	10.5	37.3	6.4	63.5
02/22/2015	6.2	22.0	6.3	64.4
02/23/2015	0.0	0.0	10.9	111.0
02/24/2015	22.9	81.8	12.0	122.8
02/25/2015	26.8	96.1	11.5	115.6
02/26/2015	28.2	100.5	12.0	120.9
02/27/2015	26.9	96.9	11.4	117.2
02/28/2015	19.9	71.6	5.3	54.6
Monthly Avg/Sum*:	649.4 *	2,321.3 *	304.1 *	3,008.2 *
Daily Min:	0.0	0.0	3.8	40.0
Daily Max:	32.1	114.2	14.4	137.9
Jan 2015 - Feb 2015	1,580.9	5,651.7	698.6	6,901.4
QTD:	1,580.9 *	5,651.7 *	698.6 *	6,901.4 *
YTD 2015:	1,580.9 *	5,651.7 *	698.6 *	6,901.4 *

Monthly Summary By Day Report

VOC PM10

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:50 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 VOC, Lb 1 Day(s)	Unit CT1 PM10, Lb 1 Day(s)	Unit CT2 VOC, Lb 1 Day(s)	Unit CT2 PM10, Lb 1 Day(s)
03/01/2015	32.1	115.7	13.7	139.3
03/02/2015	32.4	114.8	13.8	138.6
03/03/2015	26.9	96.1	11.7	116.2
03/04/2015	29.2	104.1	12.4	125.9
03/05/2015	28.5	102.1	12.3	123.5
03/06/2015	27.7	98.7	12.1	119.4
03/07/2015	19.1	68.4	6.1	62.1
03/08/2015	16.2	57.4	8.8	88.6
03/09/2015	27.2	97.0	11.8	117.6
03/10/2015	28.7	102.8	12.4	124.3
03/11/2015	29.9	107.5	12.9	130.3
03/12/2015	27.7	100.1	12.0	120.5
03/13/2015	30.3	108.8	13.1	131.6
03/14/2015	33.3	120.0	14.4	145.6
03/15/2015	29.7	107.4	12.8	130.0
03/16/2015	30.4	109.1	13.1	132.2
03/17/2015	21.4	75.9	9.6	93.6
03/18/2015	22.2	79.7	9.5	92.9
03/19/2015	27.9	99.1	12.0	119.5
03/20/2015	30.8	108.8	13.0	130.4
03/21/2015	26.7	96.1	11.4	115.2
03/22/2015	28.8	102.5	12.1	120.8
03/23/2015	0.0	0.0	0.0	0.0
03/24/2015	0.0	0.0	0.0	0.0
03/25/2015	0.0	0.0	0.0	0.0
03/26/2015	18.3	65.0	0.0	0.0
03/27/2015	15.2	52.7	0.0	0.0
03/28/2015	0.0	0.0	0.0	0.0
03/29/2015	0.0	0.0	0.0	0.0
03/30/2015	16.2	57.1	0.0	0.0
03/31/2015	17.1	59.5	0.0	0.0
Monthly Avg/Sum*:	673.9 *	2,406.4 *	261.0 *	2,618.1 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	33.3	120.0	14.4	145.6
Jan 2015 - Mar 2015	2,254.8	8,058.1	959.6	9,519.5
QTD:	2,254.8 *	8,058.1 *	959.6 *	9,519.5 *
YTD 2015:	2,254.8 *	8,058.1 *	959.6 *	9,519.5 *

Annual Fuel Use, NH3 Injection and Operating Hours

Cumulative Emissions Report

CT1

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:48 **Location:** Maxwell, CA

Month	Unit CT1 GasFlowCT, 100scf 1 Day(s)	Unit CT1 GasFlowDB, 100scf 1 Day(s)	Unit CT1 GasFlow, Total, 100scf 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
January	11,784,635	1,010,967	12,795,601.3	716	0.8
February	8,555,186	451,275	9,006,457.7	565	0.7
March	8,822,732	481,116	9,303,845.4	589	0.7
Quarter 1	29,162,553	1,943,358	31,105,904.4	1,870	0.7
YTD	29,162,553	1,943,358	31,105,904.4	1,870	0.7

Cumulative Emissions Report

CT2

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:49 **Location:** Maxwell, CA

Month	Unit CT2 GasFlowCT, 100scf 1 Day(s)	Unit CT2 GasFlowDB, 100scf 1 Day(s)	Unit CT2 GasFlow, Total, 100scf 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)
January	11,293,791	1,165,348	12,459,134.6	687	84,334.2
February	9,213,278	496,884	9,710,159.3	608	67,978.5
March	7,920,826	492,059	8,412,882.1	516	57,728.2
Quarter 1	28,427,895	2,154,291	30,582,176.0	1,811	210,040.9
YTD	28,427,895	2,154,291	30,582,176.0	1,811	210,040.9

Cumulative Emissions Report

CT1

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:48 **Location:** Maxwell, CA

Month	Unit CT1 GasFlowCT, 100scf 1 Day(s)	Unit CT1 GasFlowDB, 100scf 1 Day(s)	Unit CT1 GasFlow, Total, 100scf 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
January	11,784,635	1,010,967	12,795,601.3	716	0.8
February	8,555,186	451,275	9,006,457.7	565	0.7
March	8,822,732	481,116	9,303,845.4	589	0.7
Quarter 1	29,162,553	1,943,358	31,105,904.4	1,870	0.7
YTD	29,162,553	1,943,358	31,105,904.4	1,870	0.7

Cumulative Emissions Report

CT2

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:49 **Location:** Maxwell, CA

Month	Unit CT2 GasFlowCT, 100scf 1 Day(s)	Unit CT2 GasFlowDB, 100scf 1 Day(s)	Unit CT2 GasFlow, Total, 100scf 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)
January	11,293,791	1,165,348	12,459,134.6	687	84,334.2
February	9,213,278	496,884	9,710,159.3	608	67,978.5
March	7,920,826	492,059	8,412,882.1	516	57,728.2
Quarter 1	28,427,895	2,154,291	30,582,176.0	1,811	210,040.9
YTD	28,427,895	2,154,291	30,582,176.0	1,811	210,040.9

ATTACHMENT 10
Maximum Emissions

FCD: AQ-25

AQ-25 Emission Limits

Maximum Emissions Both Turbines (lbs)		
Pollutant	1-Hour Emissions	24-Hour Emissions
NO_x	666.60	2,994.60
CO	967.00	7,659.00
VOC	55.40	630.60
PM10	27.00	648.00
SO_2	14.80	355.20

Excess Emission Report

CT1 and CT2 CO Lb/Day

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 13:07 **Location:** Maxwell, CA

Tag Name: ALL_CO_Lb_1D
Total Operating Time: 85.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 5.00 Day(s) Report Time: 90.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**85.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 CO Lb/Hr

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 13:08 **Location:** Maxwell, CA

Tag Name: ALL_CO_Lb_1H
Total Operating Time: 1,933.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 227.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,933.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 NOx Lb/Day

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 13:08 **Location:** Maxwell, CA

Tag Name: ALL_NOx_Lb_1D
Total Operating Time: 85.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 5.00 Day(s) Report Time: 90.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**85.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 NOx Lb/Hr

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 13:08 **Location:** Maxwell, CA

Tag Name: ALL_NOx_Lb_1H
Total Operating Time: 1,933.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 227.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,933.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 PM10 Lb/Day

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 13:09 **Location:** Maxwell, CA

Tag Name: ALL_PM10_Lb_1D
Total Operating Time: 85.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 5.00 Day(s) Report Time: 90.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**85.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 PM10 Lb/Hr

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 13:09 **Location:** Maxwell, CA

Tag Name: ALL_PM10_Lb_1H
Total Operating Time: 1,933.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 227.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,933.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 SO2 Lb/Day

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 13:10 **Location:** Maxwell, CA

Tag Name: ALL_SO2_Lb_1D
Total Operating Time: 85.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 5.00 Day(s) Report Time: 90.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**85.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 SO2 Lb/Hr

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 13:10 **Location:** Maxwell, CA

Tag Name: ALL_SO2_Lb_1H
Total Operating Time: 1,933.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 227.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,933.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 VOC Lb/Day

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 13:10 **Location:** Maxwell, CA

Tag Name: ALL_VOC_Lb_1D
Total Operating Time: 85.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 5.00 Day(s) Report Time: 90.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**85.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 VOC Lb/Hr

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 13:11 **Location:** Maxwell, CA

Tag Name: ALL_VOC_Lb_1H
Total Operating Time: 1,933.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 227.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,933.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Monthly Summary By Day Report

AQ-25

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/29/2015 12:54 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	PlantWide NOx, Lb 1 Day(s)	PlantWide CO, Lb 1 Day(s)	PlantWide VOC, Lb 1 Day(s)	PlantWide PM10, Lb 1 Day(s)	PlantWide SO2, Lb 1 Day(s)
01/01/2015	352.3	52.9	47.6	262.7	57.8
01/02/2015	341.4	55.6	45.8	254.4	55.5
01/03/2015	351.6	63.5	48.6	267.3	58.2
01/04/2015	356.3	62.1	50.0	274.5	59.7
01/05/2015	342.5	54.2	48.8	269.4	58.4
01/06/2015	291.4	43.5	43.7	240.9	52.8
01/07/2015	316.3	53.1	45.9	253.1	54.8
01/08/2015	347.8	63.6	48.8	269.9	58.6
01/09/2015	311.6	50.2	45.9	251.5	54.5
01/10/2015	324.9	61.1	46.8	257.5	56.0
01/11/2015	346.0	63.2	48.6	268.3	58.7
01/12/2015	339.7	60.2	48.2	265.3	57.8
01/13/2015	347.4	61.2	48.4	266.4	58.3
01/14/2015	346.1	61.0	47.5	261.3	56.8
01/15/2015	317.3	50.9	43.5	240.0	52.2
01/16/2015	296.3	98.5	38.4	207.5	45.5
01/17/2015	293.9	41.2	42.0	232.4	50.8
01/18/2015	326.6	183.5	20.7	123.7	26.8
01/19/2015	321.9	53.0	45.2	246.5	53.5
01/20/2015	365.4	68.3	47.2	261.2	56.2
01/21/2015	359.4	57.8	46.5	256.3	55.4
01/22/2015	313.3	50.8	43.7	240.3	51.9
01/23/2015	355.1	55.3	46.8	258.8	56.2
01/24/2015	339.1	55.0	44.9	247.4	53.7
01/25/2015	177.9	157.3	12.9	49.3	11.7
01/26/2015	169.7	65.9	23.2	81.5	19.9
01/27/2015	375.3	250.4	35.8	174.4	38.7
01/28/2015	308.7	37.7	42.0	229.2	50.4
01/29/2015	347.8	48.5	46.5	253.2	54.7
01/30/2015	332.0	43.7	44.8	244.4	52.7
01/31/2015	360.3	115.2	37.3	215.0	46.1
Monthly Avg/Sum*:	10,075.3 *	2,238.4 *	1,326.0 *	7,223.6 *	1,574.3 *
Daily Min:	169.7	37.7	12.9	49.3	11.7
Daily Max:	375.3	250.4	50.0	274.5	59.7
Jan 2015 - Jan 2015	10,075.3	2,238.4	1,326.0	7,223.6	1,574.3
QTD:	10,075.3 *	2,238.4 *	1,326.0 *	7,223.6 *	1,574.3 *
YTD 2015:	10,075.3 *	2,238.4 *	1,326.0 *	7,223.6 *	1,574.3 *

Monthly Summary By Day Report

AQ-25

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/29/2015 12:54 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	PlantWide NOx, Lb 1 Day(s)	PlantWide CO, Lb 1 Day(s)	PlantWide VOC, Lb 1 Day(s)	PlantWide PM10, Lb 1 Day(s)	PlantWide SO2, Lb 1 Day(s)
02/01/2015	387.0	172.4	24.7	128.5	28.2
02/02/2015	342.6	51.3	46.5	252.1	54.8
02/03/2015	276.0	31.7	40.1	218.7	47.6
02/04/2015	264.7	34.1	38.3	210.8	46.2
02/05/2015	263.6	28.6	38.0	208.5	46.4
02/06/2015	285.9	39.9	41.4	226.2	49.4
02/07/2015	228.7	18.4	35.0	193.7	42.4
02/08/2015	232.7	20.0	35.1	194.1	42.9
02/09/2015	236.8	16.3	35.4	194.7	43.0
02/10/2015	271.5	32.9	38.3	209.7	46.2
02/11/2015	316.1	41.2	43.5	237.1	51.7
02/12/2015	301.1	37.0	40.7	224.4	49.1
02/13/2015	300.9	33.1	41.2	227.0	49.0
02/14/2015	290.4	35.9	39.7	217.8	48.0
02/15/2015	349.8	130.5	18.2	112.4	24.2
02/16/2015	330.3	36.1	44.8	243.0	52.4
02/17/2015	293.8	35.9	41.8	227.4	49.1
02/18/2015	318.5	44.6	43.9	239.2	52.0
02/19/2015	328.7	51.7	44.9	244.3	53.6
02/20/2015	78.1	55.0	4.8	43.7	9.0
02/21/2015	381.2	378.6	16.9	100.8	21.5
02/22/2015	251.2	89.0	12.5	86.4	18.2
02/23/2015	228.8	66.5	10.9	111.0	22.3
02/24/2015	461.6	175.4	34.9	204.6	44.4
02/25/2015	287.3	25.2	38.3	211.7	46.9
02/26/2015	301.2	27.4	40.2	221.4	48.7
02/27/2015	283.7	30.0	38.3	214.1	47.0
02/28/2015	346.6	144.8	25.2	126.2	28.0
Monthly Avg/Sum*:	8,238.8 *	1,883.5 *	953.5 *	5,329.5 *	1,162.2 *
Daily Min:	78.1	16.3	4.8	43.7	9.0
Daily Max:	461.6	378.6	46.5	252.1	54.8
Jan 2015 - Feb 2015	18,314.1	4,121.9	2,279.5	12,553.1	2,736.5
QTD:	18,314.1 *	4,121.9 *	2,279.5 *	12,553.1 *	2,736.5 *
YTD 2015:	18,314.1 *	4,121.9 *	2,279.5 *	12,553.1 *	2,736.5 *

Monthly Summary By Day Report

AQ-25

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/29/2015 12:54 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	PlantWide NOx, Lb 1 Day(s)	PlantWide CO, Lb 1 Day(s)	PlantWide VOC, Lb 1 Day(s)	PlantWide PM10, Lb 1 Day(s)	PlantWide SO2, Lb 1 Day(s)
03/01/2015	365.6	51.4	45.8	255.0	54.8
03/02/2015	363.5	53.3	46.2	253.4	55.6
03/03/2015	285.9	30.7	38.6	212.3	46.6
03/04/2015	314.9	37.8	41.6	230.0	50.4
03/05/2015	302.4	41.5	40.8	225.6	49.3
03/06/2015	288.0	39.4	39.8	218.1	48.0
03/07/2015	391.3	209.6	25.2	130.5	28.6
03/08/2015	276.7	157.1	25.0	146.0	32.1
03/09/2015	290.2	43.1	39.0	214.6	47.2
03/10/2015	308.7	51.1	41.1	227.1	49.7
03/11/2015	306.3	59.6	42.8	237.8	51.6
03/12/2015	290.9	44.7	39.7	220.6	48.2
03/13/2015	331.4	53.5	43.4	240.4	51.9
03/14/2015	379.9	73.4	47.7	265.6	57.6
03/15/2015	315.8	44.7	42.5	237.4	51.8
03/16/2015	310.6	59.4	43.5	241.3	52.4
03/17/2015	195.3	6.0	31.0	169.5	38.2
03/18/2015	217.8	1.2	31.7	172.6	38.6
03/19/2015	260.0	41.8	39.9	218.6	48.1
03/20/2015	300.0	65.6	43.8	239.2	52.8
03/21/2015	267.3	43.3	38.1	211.3	46.4
03/22/2015	293.6	58.4	40.9	223.3	49.3
03/23/2015	0.0	0.0	0.0	0.0	0.0
03/24/2015	0.0	0.0	0.0	0.0	0.0
03/25/2015	0.0	0.0	0.0	0.0	0.0
03/26/2015	146.6	266.3	18.3	65.0	15.5
03/27/2015	112.7	49.3	15.2	52.7	12.2
03/28/2015	0.0	0.0	0.0	0.0	0.0
03/29/2015	0.0	0.0	0.0	0.0	0.0
03/30/2015	174.2	170.7	16.2	57.1	13.6
03/31/2015	117.9	50.7	17.1	59.5	14.1
Monthly Avg/Sum*:	7,207.5 *	1,803.6 *	934.9 *	5,024.5 *	1,104.6 *
Daily Min:	0.0	0.0	0.0	0.0	0.0
Daily Max:	391.3	266.3	47.7	265.6	57.6
Jan 2015 - Mar 2015	25,521.6	5,925.5	3,214.4	17,577.6	3,841.1
QTD:	25,521.6 *	5,925.5 *	3,214.4 *	17,577.6 *	3,841.1 *
YTD 2015:	25,521.6 *	5,925.5 *	3,214.4 *	17,577.6 *	3,841.1 *

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/01/2015 00:00	18.2	3.1	2.3	12.5	2.7
01/01/2015 01:00	18.6	2.3	2.3	12.7	2.8
01/01/2015 02:00	18.5	2.7	2.3	12.7	2.8
01/01/2015 03:00	18.5	2.3	2.3	12.7	2.8
01/01/2015 04:00	18.1	3.1	2.3	12.5	2.7
01/01/2015 05:00	18.0	3.1	2.2	12.3	2.7
01/01/2015 06:00	16.3	2.7	2.3	12.8	2.8
01/01/2015 07:00	18.5	2.7	2.3	12.7	2.8
01/01/2015 08:00	13.8	2.0	2.0	10.9	2.4
01/01/2015 09:00	13.0	1.3	1.9	10.2	2.2
01/01/2015 10:00	7.3	0.5	1.4	8.0	1.8
01/01/2015 11:00	6.3	0.5	1.3	7.0	1.6
01/01/2015 12:00	6.3	0.5	1.3	7.0	1.6
01/01/2015 13:00	6.3	0.5	1.3	7.0	1.6
01/01/2015 14:00	6.3	0.5	1.3	7.0	1.6
01/01/2015 15:00	11.3	1.5	1.6	8.9	2.0
01/01/2015 16:00	13.5	2.7	1.9	10.7	2.3
01/01/2015 17:00	16.0	2.7	2.0	11.1	2.4
01/01/2015 18:00	17.0	3.7	2.1	11.7	2.6
01/01/2015 19:00	18.5	3.0	2.3	12.8	2.8
01/01/2015 20:00	18.6	2.6	2.3	12.8	2.8
01/01/2015 21:00	18.5	3.0	2.3	12.7	2.8
01/01/2015 22:00	18.5	3.1	2.3	12.7	2.8
01/01/2015 23:00	16.4	2.8	2.0	11.3	2.4
Average/Sum#:	352.3 #	52.9 #	47.6 #	262.7 #	57.8 #
Minimum:	6.3	0.5	1.3	7.0	1.6
Maximum:	18.6	3.7	2.3	12.8	2.8
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/02/2015 00:00	16.1	2.7	2.0	11.1	2.4
01/02/2015 01:00	16.8	3.4	2.0	11.6	2.5
01/02/2015 02:00	13.3	2.3	1.9	10.4	2.2
01/02/2015 03:00	16.5	3.4	2.0	11.4	2.5
01/02/2015 04:00	14.1	2.7	2.0	11.1	2.4
01/02/2015 05:00	16.4	3.0	2.0	11.2	2.4
01/02/2015 06:00	13.9	2.7	2.0	10.9	2.4
01/02/2015 07:00	13.9	2.7	2.0	10.9	2.4
01/02/2015 08:00	13.5	2.7	1.9	10.6	2.3
01/02/2015 09:00	13.0	2.3	1.9	10.3	2.2
01/02/2015 10:00	8.8	1.1	1.4	8.0	1.8
01/02/2015 11:00	7.9	0.5	1.3	7.2	1.6
01/02/2015 12:00	7.8	0.5	1.3	7.2	1.6
01/02/2015 13:00	7.9	0.5	1.3	7.2	1.6
01/02/2015 14:00	7.8	0.5	1.3	7.2	1.6
01/02/2015 15:00	11.5	1.5	1.6	9.0	2.0
01/02/2015 16:00	13.4	2.7	1.9	10.6	2.3
01/02/2015 17:00	17.8	4.0	2.2	12.2	2.6
01/02/2015 18:00	18.6	2.9	2.3	12.8	2.8
01/02/2015 19:00	18.6	2.6	2.3	12.8	2.8
01/02/2015 20:00	18.6	2.6	2.3	12.8	2.8
01/02/2015 21:00	18.6	2.6	2.3	12.8	2.8
01/02/2015 22:00	18.6	2.6	2.3	12.8	2.8
01/02/2015 23:00	18.0	3.1	2.3	12.3	2.7
Average/Sum#:	341.4 #	55.6 #	45.8 #	254.4 #	55.5 #
Minimum:	7.8	0.5	1.3	7.2	1.6
Maximum:	18.6	4.0	2.3	12.8	2.8
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/03/2015 00:00	17.5	3.7	2.2	12.1	2.6
01/03/2015 01:00	18.2	3.4	2.3	12.5	2.7
01/03/2015 02:00	17.4	3.4	2.2	12.0	2.6
01/03/2015 03:00	15.9	3.4	2.3	12.5	2.7
01/03/2015 04:00	14.9	2.7	2.1	11.6	2.6
01/03/2015 05:00	14.5	3.0	2.0	11.4	2.5
01/03/2015 06:00	17.6	3.7	2.2	12.1	2.6
01/03/2015 07:00	15.0	3.3	2.1	11.8	2.6
01/03/2015 08:00	13.4	2.0	1.9	10.5	2.3
01/03/2015 09:00	13.1	2.3	1.9	10.3	2.2
01/03/2015 10:00	13.0	2.3	1.9	10.3	2.2
01/03/2015 11:00	13.1	2.3	1.9	10.2	2.2
01/03/2015 12:00	6.8	0.5	1.3	7.5	1.6
01/03/2015 13:00	6.5	0.5	1.3	7.2	1.6
01/03/2015 14:00	7.8	0.5	1.3	7.2	1.6
01/03/2015 15:00	11.7	1.2	1.7	9.1	2.0
01/03/2015 16:00	14.0	3.4	2.0	11.1	2.4
01/03/2015 17:00	17.6	4.0	2.2	12.1	2.6
01/03/2015 18:00	18.6	2.9	2.3	12.8	2.8
01/03/2015 19:00	16.3	2.9	2.3	12.7	2.8
01/03/2015 20:00	18.5	2.9	2.3	12.7	2.8
01/03/2015 21:00	18.6	3.0	2.3	12.8	2.8
01/03/2015 22:00	15.9	3.1	2.3	12.5	2.7
01/03/2015 23:00	15.7	3.1	2.3	12.3	2.7
Average/Sum#:	351.6 #	63.5 #	48.6 #	267.3 #	58.2 #
Minimum:	6.5	0.5	1.3	7.2	1.6
Maximum:	18.6	4.0	2.3	12.8	2.8
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/04/2015 00:00	15.8	3.4	2.3	12.3	2.7
01/04/2015 01:00	14.2	2.4	2.0	11.1	2.4
01/04/2015 02:00	14.0	2.1	2.0	11.1	2.4
01/04/2015 03:00	14.0	2.4	2.0	11.1	2.4
01/04/2015 04:00	13.9	2.4	2.0	10.9	2.4
01/04/2015 05:00	14.0	2.4	2.0	10.9	2.4
01/04/2015 06:00	15.1	3.7	2.2	11.8	2.6
01/04/2015 07:00	15.9	3.4	2.3	12.5	2.7
01/04/2015 08:00	13.8	2.3	2.0	10.9	2.4
01/04/2015 09:00	13.4	2.3	1.9	10.6	2.3
01/04/2015 10:00	13.4	2.3	1.9	10.5	2.3
01/04/2015 11:00	13.2	2.3	1.9	10.3	2.2
01/04/2015 12:00	13.1	2.3	1.9	10.3	2.2
01/04/2015 13:00	13.3	2.3	1.9	10.4	2.2
01/04/2015 14:00	16.1	2.7	2.0	11.1	2.4
01/04/2015 15:00	14.2	2.6	2.0	11.1	2.4
01/04/2015 16:00	14.2	3.4	2.0	11.1	2.4
01/04/2015 17:00	15.8	3.3	2.3	12.4	2.7
01/04/2015 18:00	16.3	2.6	2.3	12.8	2.8
01/04/2015 19:00	18.7	2.6	2.3	12.9	2.8
01/04/2015 20:00	18.7	2.3	2.3	12.9	2.8
01/04/2015 21:00	16.0	2.6	2.3	12.5	2.8
01/04/2015 22:00	15.8	2.3	2.3	12.5	2.7
01/04/2015 23:00	13.4	1.7	1.9	10.5	2.3
Average/Sum#:	356.3 #	62.1 #	50.0 #	274.5 #	59.7 #
Minimum:	13.1	1.7	1.9	10.3	2.2
Maximum:	18.7	3.7	2.3	12.9	2.8
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/05/2015 00:00	13.2	1.9	1.9	10.3	2.2
01/05/2015 01:00	13.7	2.1	2.0	10.8	2.4
01/05/2015 02:00	13.2	1.9	1.9	10.4	2.2
01/05/2015 03:00	13.9	2.4	2.0	10.9	2.4
01/05/2015 04:00	13.4	2.3	1.9	10.6	2.3
01/05/2015 05:00	13.6	2.3	1.9	10.7	2.4
01/05/2015 06:00	14.4	3.1	2.0	11.3	2.4
01/05/2015 07:00	16.2	3.7	2.3	12.7	2.8
01/05/2015 08:00	16.1	3.1	2.3	12.6	2.8
01/05/2015 09:00	13.6	1.7	1.9	10.7	2.4
01/05/2015 10:00	13.1	1.6	1.9	10.3	2.2
01/05/2015 11:00	13.0	1.6	1.9	10.3	2.2
01/05/2015 12:00	13.2	1.6	1.9	10.3	2.2
01/05/2015 13:00	13.2	2.0	1.9	10.4	2.2
01/05/2015 14:00	14.1	2.6	2.0	11.0	2.4
01/05/2015 15:00	13.9	2.3	2.0	10.9	2.4
01/05/2015 16:00	14.1	2.3	2.0	11.1	2.4
01/05/2015 17:00	15.8	3.0	2.3	12.4	2.7
01/05/2015 18:00	16.3	2.0	2.3	12.9	2.8
01/05/2015 19:00	16.4	2.0	2.3	12.9	2.8
01/05/2015 20:00	16.3	2.0	2.3	12.9	2.8
01/05/2015 21:00	15.5	2.9	2.2	12.2	2.6
01/05/2015 22:00	14.3	2.3	2.0	11.3	2.4
01/05/2015 23:00	12.0	1.5	1.7	9.5	2.0
Average/Sum#:	342.5 #	54.2 #	48.8 #	269.4 #	58.4 #
Minimum:	12.0	1.5	1.7	9.5	2.0
Maximum:	16.4	3.7	2.3	12.9	2.8
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/06/2015 00:00	8.7	0.5	1.4	7.9	1.8
01/06/2015 01:00	9.9	0.6	1.7	9.1	2.0
01/06/2015 02:00	10.3	0.9	1.7	9.5	2.0
01/06/2015 03:00	13.2	1.9	1.9	10.3	2.2
01/06/2015 04:00	13.2	1.9	1.9	10.3	2.2
01/06/2015 05:00	13.6	2.0	1.9	10.6	2.4
01/06/2015 06:00	14.5	3.3	2.0	11.4	2.5
01/06/2015 07:00	16.2	3.0	2.3	12.7	2.8
01/06/2015 08:00	14.9	2.9	2.1	11.6	2.6
01/06/2015 09:00	13.0	1.6	1.9	10.3	2.2
01/06/2015 10:00	9.3	0.8	1.6	8.6	1.8
01/06/2015 11:00	6.5	0.5	1.3	7.2	1.6
01/06/2015 12:00	7.8	0.5	1.3	7.2	1.6
01/06/2015 13:00	7.2	0.5	1.4	7.9	1.8
01/06/2015 14:00	6.5	0.5	1.3	7.2	1.6
01/06/2015 15:00	9.7	0.6	1.6	8.9	2.0
01/06/2015 16:00	13.4	2.3	2.0	10.5	2.3
01/06/2015 17:00	14.3	2.9	2.0	11.2	2.4
01/06/2015 18:00	14.5	2.9	2.0	11.5	2.5
01/06/2015 19:00	16.8	3.3	2.1	11.5	2.6
01/06/2015 20:00	15.0	2.9	2.1	11.8	2.6
01/06/2015 21:00	15.1	3.3	2.2	11.8	2.6
01/06/2015 22:00	14.6	2.6	2.1	11.5	2.5
01/06/2015 23:00	13.2	1.3	1.9	10.4	2.2
Average/Sum#:	291.4 #	43.5 #	43.7 #	240.9 #	52.8 #
Minimum:	6.5	0.5	1.3	7.2	1.6
Maximum:	16.8	3.3	2.3	12.7	2.8
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/07/2015 00:00	13.5	2.0	1.9	10.6	2.3
01/07/2015 01:00	13.2	1.9	1.9	10.4	2.2
01/07/2015 02:00	13.4	2.0	1.9	10.5	2.3
01/07/2015 03:00	13.2	1.9	1.9	10.3	2.2
01/07/2015 04:00	13.9	2.3	2.0	10.9	2.4
01/07/2015 05:00	13.4	2.0	1.9	10.6	2.3
01/07/2015 06:00	14.7	3.4	2.1	11.5	2.5
01/07/2015 07:00	18.2	3.3	2.3	12.5	2.7
01/07/2015 08:00	14.3	2.3	2.0	11.2	2.4
01/07/2015 09:00	13.4	1.6	1.9	10.5	2.3
01/07/2015 10:00	13.1	1.6	1.9	10.3	2.2
01/07/2015 11:00	12.9	1.6	1.9	10.2	2.2
01/07/2015 12:00	6.5	0.5	1.3	7.2	1.6
01/07/2015 13:00	7.5	0.6	1.4	8.2	1.8
01/07/2015 14:00	7.8	0.6	1.6	8.6	1.8
01/07/2015 15:00	14.1	3.2	2.0	11.0	2.4
01/07/2015 16:00	13.9	2.6	2.0	10.9	2.4
01/07/2015 17:00	15.3	2.9	2.2	12.1	2.6
01/07/2015 18:00	14.5	2.9	2.0	11.3	2.4
01/07/2015 19:00	14.2	3.2	2.0	11.1	2.4
01/07/2015 20:00	14.3	3.2	2.0	11.1	2.4
01/07/2015 21:00	14.3	3.2	2.0	11.2	2.4
01/07/2015 22:00	13.6	2.3	1.9	10.6	2.4
01/07/2015 23:00	13.1	2.0	1.9	10.3	2.2
Average/Sum#:	316.3 #	53.1 #	45.9 #	253.1 #	54.8 #
Minimum:	6.5	0.5	1.3	7.2	1.6
Maximum:	18.2	3.4	2.3	12.5	2.7
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/08/2015 00:00	13.0	2.0	1.9	10.3	2.2
01/08/2015 01:00	13.0	2.0	1.9	10.3	2.2
01/08/2015 02:00	13.0	2.0	1.9	10.3	2.2
01/08/2015 03:00	13.1	2.0	1.9	10.3	2.2
01/08/2015 04:00	13.0	1.9	1.9	10.3	2.2
01/08/2015 05:00	13.1	1.9	1.9	10.2	2.2
01/08/2015 06:00	14.6	3.3	2.1	11.5	2.5
01/08/2015 07:00	18.5	2.9	2.3	12.7	2.8
01/08/2015 08:00	18.3	2.6	2.3	12.6	2.8
01/08/2015 09:00	15.4	3.3	2.2	12.1	2.6
01/08/2015 10:00	14.7	3.7	2.0	11.5	2.5
01/08/2015 11:00	14.0	2.6	2.0	11.1	2.4
01/08/2015 12:00	14.2	3.0	2.0	11.2	2.4
01/08/2015 13:00	14.8	2.9	2.1	11.6	2.6
01/08/2015 14:00	14.6	2.9	2.1	11.5	2.5
01/08/2015 15:00	15.9	2.0	2.3	12.5	2.8
01/08/2015 16:00	14.3	2.6	2.0	11.3	2.4
01/08/2015 17:00	14.6	2.9	2.0	11.4	2.5
01/08/2015 18:00	14.6	2.9	2.0	11.4	2.5
01/08/2015 19:00	14.2	3.2	2.0	11.1	2.4
01/08/2015 20:00	14.2	2.9	2.0	11.2	2.4
01/08/2015 21:00	14.9	2.9	2.1	11.7	2.6
01/08/2015 22:00	14.3	2.9	2.0	11.2	2.4
01/08/2015 23:00	13.5	2.3	1.9	10.6	2.3
Average/Sum#:	347.8 #	63.6 #	48.8 #	269.9 #	58.6 #
Minimum:	13.0	1.9	1.9	10.2	2.2
Maximum:	18.5	3.7	2.3	12.7	2.8
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/09/2015 00:00	13.7	2.3	2.0	10.8	2.4
01/09/2015 01:00	13.4	2.0	1.9	10.5	2.3
01/09/2015 02:00	13.2	1.9	1.9	10.3	2.2
01/09/2015 03:00	13.5	2.3	1.9	10.7	2.3
01/09/2015 04:00	13.2	2.0	1.9	10.3	2.2
01/09/2015 05:00	13.4	2.0	1.9	10.6	2.3
01/09/2015 06:00	11.8	2.6	2.0	10.9	2.4
01/09/2015 07:00	15.1	3.6	2.2	12.0	2.6
01/09/2015 08:00	18.3	2.6	2.3	12.6	2.8
01/09/2015 09:00	14.6	2.6	2.0	11.4	2.5
01/09/2015 10:00	15.7	2.9	2.3	12.2	2.6
01/09/2015 11:00	15.7	2.6	2.3	12.4	2.7
01/09/2015 12:00	13.4	2.0	1.9	10.4	2.2
01/09/2015 13:00	8.5	1.2	1.7	9.3	2.0
01/09/2015 14:00	7.0	0.5	1.4	7.7	1.6
01/09/2015 15:00	6.8	0.5	1.4	7.5	1.6
01/09/2015 16:00	11.9	1.8	1.7	9.3	2.0
01/09/2015 17:00	13.2	2.0	1.9	10.4	2.2
01/09/2015 18:00	12.6	1.9	1.8	9.9	2.2
01/09/2015 19:00	12.7	1.6	1.8	10.0	2.2
01/09/2015 20:00	13.2	2.0	1.9	10.4	2.2
01/09/2015 21:00	13.2	2.0	1.9	10.4	2.2
01/09/2015 22:00	13.6	2.3	1.9	10.6	2.4
01/09/2015 23:00	13.9	3.0	2.0	10.9	2.4
Average/Sum#:	311.6 #	50.2 #	45.9 #	251.5 #	54.5 #
Minimum:	6.8	0.5	1.4	7.5	1.6
Maximum:	18.3	3.6	2.3	12.6	2.8
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/10/2015 00:00	13.2	2.0	1.9	10.4	2.2
01/10/2015 01:00	13.0	2.0	1.9	10.2	2.2
01/10/2015 02:00	12.0	0.9	1.7	9.4	2.0
01/10/2015 03:00	8.1	0.5	1.4	7.5	1.6
01/10/2015 04:00	9.8	1.2	1.6	9.0	2.0
01/10/2015 05:00	13.4	2.7	1.9	10.5	2.3
01/10/2015 06:00	11.7	2.7	2.0	10.8	2.4
01/10/2015 07:00	13.9	2.7	2.0	10.9	2.4
01/10/2015 08:00	13.2	2.3	1.9	10.4	2.2
01/10/2015 09:00	13.1	2.3	1.9	10.3	2.2
01/10/2015 10:00	13.9	3.0	2.0	10.9	2.4
01/10/2015 11:00	15.6	3.6	2.3	12.3	2.7
01/10/2015 12:00	15.4	2.9	2.2	12.0	2.6
01/10/2015 13:00	13.7	2.6	2.0	10.7	2.4
01/10/2015 14:00	14.1	3.6	2.0	11.1	2.4
01/10/2015 15:00	13.1	2.3	1.9	10.4	2.2
01/10/2015 16:00	13.4	2.3	1.9	10.5	2.3
01/10/2015 17:00	14.6	3.6	2.0	11.4	2.5
01/10/2015 18:00	14.1	3.2	2.0	11.1	2.4
01/10/2015 19:00	14.6	3.7	2.0	11.4	2.5
01/10/2015 20:00	18.3	2.6	2.3	12.6	2.8
01/10/2015 21:00	14.9	3.2	2.1	11.8	2.6
01/10/2015 22:00	14.4	2.9	2.0	11.3	2.4
01/10/2015 23:00	13.4	2.3	1.9	10.6	2.3
Average/Sum#:	324.9 #	61.1 #	46.8 #	257.5 #	56.0 #
Minimum:	8.1	0.5	1.4	7.5	1.6
Maximum:	18.3	3.7	2.3	12.6	2.8
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/11/2015 00:00	13.5	2.3	1.9	10.6	2.3
01/11/2015 01:00	13.5	2.3	1.9	10.7	2.3
01/11/2015 02:00	13.7	2.3	1.9	10.7	2.4
01/11/2015 03:00	13.2	2.3	1.9	10.3	2.2
01/11/2015 04:00	13.2	2.3	1.9	10.3	2.2
01/11/2015 05:00	13.4	2.3	1.9	10.5	2.3
01/11/2015 06:00	13.4	2.3	1.9	10.5	2.3
01/11/2015 07:00	13.7	2.3	1.9	10.7	2.4
01/11/2015 08:00	14.9	3.7	2.1	11.7	2.6
01/11/2015 09:00	16.1	3.0	2.3	12.7	2.8
01/11/2015 10:00	18.2	2.6	2.3	12.5	2.8
01/11/2015 11:00	15.4	2.6	2.2	12.0	2.6
01/11/2015 12:00	14.1	2.6	2.0	11.1	2.4
01/11/2015 13:00	13.9	2.6	2.0	11.0	2.4
01/11/2015 14:00	13.4	2.3	1.9	10.6	2.3
01/11/2015 15:00	14.1	3.3	2.0	11.1	2.4
01/11/2015 16:00	13.4	2.3	1.9	10.6	2.3
01/11/2015 17:00	15.0	3.3	2.1	11.7	2.6
01/11/2015 18:00	15.0	2.9	2.1	11.8	2.6
01/11/2015 19:00	15.7	2.6	2.3	12.4	2.7
01/11/2015 20:00	17.2	2.9	2.1	11.8	2.6
01/11/2015 21:00	15.2	3.2	2.2	12.0	2.6
01/11/2015 22:00	13.7	2.6	2.0	10.8	2.4
01/11/2015 23:00	13.1	2.3	1.9	10.2	2.2
Average/Sum#:	346.0 #	63.2 #	48.6 #	268.3 #	58.7 #
Minimum:	13.1	2.3	1.9	10.2	2.2
Maximum:	18.2	3.7	2.3	12.7	2.8
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/12/2015 00:00	13.8	3.0	2.0	10.9	2.4
01/12/2015 01:00	13.4	2.3	1.9	10.5	2.3
01/12/2015 02:00	13.4	2.3	1.9	10.5	2.3
01/12/2015 03:00	13.7	2.3	2.0	10.8	2.4
01/12/2015 04:00	13.6	2.3	1.9	10.7	2.4
01/12/2015 05:00	13.5	2.3	1.9	10.6	2.3
01/12/2015 06:00	14.1	3.0	2.0	11.1	2.4
01/12/2015 07:00	13.9	2.6	2.0	11.0	2.4
01/12/2015 08:00	14.0	2.3	2.0	11.0	2.4
01/12/2015 09:00	14.9	4.0	2.1	11.6	2.6
01/12/2015 10:00	14.3	2.9	2.0	11.3	2.4
01/12/2015 11:00	13.2	1.9	1.9	10.4	2.2
01/12/2015 12:00	13.1	2.0	1.9	10.2	2.2
01/12/2015 13:00	13.1	2.3	1.9	10.2	2.2
01/12/2015 14:00	13.1	2.3	1.9	10.4	2.2
01/12/2015 15:00	13.1	2.3	1.9	10.4	2.2
01/12/2015 16:00	13.4	2.3	1.9	10.5	2.2
01/12/2015 17:00	13.9	2.9	2.0	11.0	2.4
01/12/2015 18:00	17.9	2.6	2.3	12.4	2.7
01/12/2015 19:00	16.1	2.6	2.3	12.6	2.8
01/12/2015 20:00	16.1	1.9	2.3	12.6	2.8
01/12/2015 21:00	15.5	2.6	2.2	12.2	2.6
01/12/2015 22:00	14.9	2.9	2.1	11.7	2.6
01/12/2015 23:00	13.7	2.3	1.9	10.7	2.4
Average/Sum#:	339.7 #	60.2 #	48.2 #	265.3 #	57.8 #
Minimum:	13.1	1.9	1.9	10.2	2.2
Maximum:	17.9	4.0	2.3	12.6	2.8
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/13/2015 00:00	14.4	2.9	2.0	11.2	2.4
01/13/2015 01:00	14.2	2.9	2.0	11.2	2.4
01/13/2015 02:00	16.1	3.0	2.0	11.1	2.4
01/13/2015 03:00	13.9	2.6	2.0	10.9	2.4
01/13/2015 04:00	13.6	2.3	2.0	10.7	2.4
01/13/2015 05:00	13.2	2.0	1.9	10.4	2.2
01/13/2015 06:00	13.5	2.3	1.9	10.6	2.3
01/13/2015 07:00	16.2	3.7	2.0	11.1	2.4
01/13/2015 08:00	13.7	2.3	2.0	10.7	2.4
01/13/2015 09:00	13.3	2.3	1.9	10.4	2.2
01/13/2015 10:00	16.2	3.3	2.0	11.1	2.4
01/13/2015 11:00	14.2	2.9	2.0	11.1	2.4
01/13/2015 12:00	13.6	2.6	2.0	10.7	2.4
01/13/2015 13:00	13.8	2.6	2.0	10.8	2.4
01/13/2015 14:00	13.6	2.6	2.0	10.6	2.4
01/13/2015 15:00	13.4	2.3	1.9	10.6	2.3
01/13/2015 16:00	13.4	2.3	1.9	10.6	2.3
01/13/2015 17:00	17.2	3.3	2.1	11.8	2.6
01/13/2015 18:00	16.0	2.6	2.3	12.6	2.8
01/13/2015 19:00	16.0	2.6	2.3	12.6	2.8
01/13/2015 20:00	16.0	2.0	2.3	12.6	2.8
01/13/2015 21:00	15.5	2.6	2.2	12.2	2.6
01/13/2015 22:00	14.9	2.6	2.1	11.8	2.6
01/13/2015 23:00	11.5	0.6	1.6	9.0	2.0
Average/Sum#:	347.4 #	61.2 #	48.4 #	266.4 #	58.3 #
Minimum:	11.5	0.6	1.6	9.0	2.0
Maximum:	17.2	3.7	2.3	12.6	2.8
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/14/2015 00:00	8.1	0.5	1.3	7.4	1.6
01/14/2015 01:00	7.9	0.6	1.6	8.6	1.8
01/14/2015 02:00	12.0	1.2	1.7	9.4	2.0
01/14/2015 03:00	13.7	3.0	1.9	10.7	2.4
01/14/2015 04:00	13.9	3.0	2.0	10.9	2.4
01/14/2015 05:00	13.2	2.6	1.9	10.4	2.2
01/14/2015 06:00	12.0	3.3	2.0	11.0	2.4
01/14/2015 07:00	18.2	4.1	2.3	12.5	2.7
01/14/2015 08:00	15.0	3.3	2.2	11.8	2.6
01/14/2015 09:00	13.9	2.4	2.0	10.9	2.4
01/14/2015 10:00	13.4	2.3	1.9	10.5	2.3
01/14/2015 11:00	13.1	2.3	1.9	10.3	2.2
01/14/2015 12:00	13.1	2.3	1.9	10.3	2.2
01/14/2015 13:00	13.1	2.3	1.9	10.4	2.2
01/14/2015 14:00	13.2	2.6	1.9	10.4	2.2
01/14/2015 15:00	13.2	2.6	1.9	10.4	2.2
01/14/2015 16:00	13.6	2.6	1.9	10.7	2.4
01/14/2015 17:00	17.0	4.0	2.1	11.8	2.6
01/14/2015 18:00	20.7	2.9	2.3	12.7	2.8
01/14/2015 19:00	20.8	2.6	2.3	12.7	2.8
01/14/2015 20:00	18.5	2.6	2.3	12.7	2.8
01/14/2015 21:00	18.4	2.6	2.3	12.7	2.8
01/14/2015 22:00	16.8	3.0	2.1	11.6	2.5
01/14/2015 23:00	13.3	2.3	1.9	10.5	2.3
Average/Sum#:	346.1 #	61.0 #	47.5 #	261.3 #	56.8 #
Minimum:	7.9	0.5	1.3	7.4	1.6
Maximum:	20.8	4.1	2.3	12.7	2.8
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/15/2015 00:00	13.5	2.3	1.9	10.6	2.3
01/15/2015 01:00	13.0	2.3	1.9	10.3	2.2
01/15/2015 02:00	13.0	2.3	1.9	10.3	2.2
01/15/2015 03:00	13.1	2.3	1.9	10.2	2.2
01/15/2015 04:00	13.1	2.3	1.9	10.3	2.2
01/15/2015 05:00	13.1	2.3	1.9	10.2	2.2
01/15/2015 06:00	16.0	3.4	2.0	11.0	2.4
01/15/2015 07:00	17.8	4.1	2.2	12.3	2.7
01/15/2015 08:00	16.0	2.6	2.0	11.0	2.4
01/15/2015 09:00	11.0	1.1	1.6	8.6	1.8
01/15/2015 10:00	6.5	0.5	1.3	7.2	1.6
01/15/2015 11:00	7.8	0.5	1.3	7.2	1.6
01/15/2015 12:00	9.1	0.5	1.3	7.2	1.6
01/15/2015 13:00	7.8	0.5	1.3	7.1	1.6
01/15/2015 14:00	9.1	0.5	1.3	7.1	1.6
01/15/2015 15:00	9.3	0.5	1.3	7.3	1.6
01/15/2015 16:00	13.2	2.3	1.9	10.4	2.2
01/15/2015 17:00	18.1	4.0	2.3	12.4	2.7
01/15/2015 18:00	15.1	1.3	2.0	11.8	2.5
01/15/2015 19:00	17.3	2.6	2.1	12.0	2.6
01/15/2015 20:00	16.8	3.7	2.0	11.5	2.5
01/15/2015 21:00	17.0	3.7	2.1	11.6	2.6
01/15/2015 22:00	17.3	3.4	2.2	11.9	2.6
01/15/2015 23:00	13.3	1.9	1.9	10.5	2.3
Average/Sum#:	317.3 #	50.9 #	43.5 #	240.0 #	52.2 #
Minimum:	6.5	0.5	1.3	7.1	1.6
Maximum:	18.1	4.1	2.3	12.4	2.7
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/16/2015 00:00	13.0	1.9	1.9	10.3	2.2
01/16/2015 01:00	13.0	2.3	1.9	10.3	2.2
01/16/2015 02:00	13.1	2.3	1.9	10.2	2.2
01/16/2015 03:00	11.4	1.2	1.6	9.0	2.0
01/16/2015 04:00	6.6	0.5	1.3	7.3	1.6
01/16/2015 05:00	13.0	2.3	1.9	10.2	2.2
01/16/2015 06:00	15.8	3.3	2.0	10.9	2.4
01/16/2015 07:00	17.9	4.0	2.2	12.4	2.7
01/16/2015 08:00	15.6	2.6	2.0	10.7	2.4
01/16/2015 09:00	14.9	2.0	1.9	10.2	2.2
01/16/2015 10:00	15.1	2.0	1.9	10.4	2.2
01/16/2015 11:00	12.6	1.6	1.8	9.9	2.1
01/16/2015 12:00	8.7	0.8	1.4	8.0	1.8
01/16/2015 13:00	6.7	0.5	1.3	7.3	1.6
01/16/2015 14:00	8.1	0.5	1.3	7.3	1.6
01/16/2015 15:00	8.1	0.5	1.3	7.3	1.6
01/16/2015 16:00	11.3	8.7	1.3	5.4	1.3
01/16/2015 17:00	17.5	50.9	1.4	6.2	1.4
01/16/2015 18:00	38.6	8.0	1.3	7.1	1.6
01/16/2015 19:00	6.5	0.5	1.3	7.1	1.6
01/16/2015 20:00	6.5	0.5	1.3	7.1	1.6
01/16/2015 21:00	6.6	0.5	1.3	7.3	1.6
01/16/2015 22:00	9.2	0.6	1.6	8.4	1.8
01/16/2015 23:00	6.5	0.5	1.3	7.2	1.6
Average/Sum#:	296.3 #	98.5 #	38.4 #	207.5 #	45.5 #
Minimum:	6.5	0.5	1.3	5.4	1.3
Maximum:	38.6	50.9	2.2	12.4	2.7
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/17/2015 00:00	8.0	0.5	1.3	7.3	1.6
01/17/2015 01:00	9.2	0.6	1.6	8.4	1.8
01/17/2015 02:00	8.6	0.5	1.4	7.9	1.8
01/17/2015 03:00	9.6	0.6	1.6	8.8	2.0
01/17/2015 04:00	6.6	0.5	1.3	7.3	1.6
01/17/2015 05:00	8.1	0.5	1.3	7.5	1.6
01/17/2015 06:00	11.4	1.6	1.9	10.5	2.3
01/17/2015 07:00	13.7	1.7	1.9	10.8	2.3
01/17/2015 08:00	13.3	1.7	1.9	10.4	2.3
01/17/2015 09:00	13.1	1.4	1.9	10.3	2.3
01/17/2015 10:00	13.1	1.6	1.9	10.2	2.2
01/17/2015 11:00	13.1	2.0	1.9	10.2	2.2
01/17/2015 12:00	13.1	2.0	1.9	10.2	2.2
01/17/2015 13:00	11.0	0.9	1.6	8.6	1.8
01/17/2015 14:00	7.8	0.5	1.3	7.2	1.6
01/17/2015 15:00	7.8	0.5	1.3	7.2	1.6
01/17/2015 16:00	11.5	1.2	1.6	9.1	2.0
01/17/2015 17:00	13.8	2.6	2.0	10.9	2.4
01/17/2015 18:00	17.8	4.0	2.2	12.3	2.7
01/17/2015 19:00	17.4	2.9	2.2	11.9	2.6
01/17/2015 20:00	16.2	2.6	2.0	11.2	2.4
01/17/2015 21:00	16.6	3.7	2.0	11.4	2.5
01/17/2015 22:00	16.5	3.4	2.0	11.4	2.5
01/17/2015 23:00	16.6	3.7	2.0	11.4	2.5
Average/Sum#:	293.9 #	41.2 #	42.0 #	232.4 #	50.8 #
Minimum:	6.6	0.5	1.3	7.2	1.6
Maximum:	17.8	4.0	2.2	12.3	2.7
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/18/2015 00:00	16.0	2.3	2.0	11.0	2.4
01/18/2015 01:00	12.5	1.9	1.7	9.9	2.2
01/18/2015 02:00	10.5	15.1	0.4	2.3	0.5
01/18/2015 03:00	0.0	0.0	0.0	0.0	0.0
01/18/2015 04:00	0.0	0.0	0.0	0.0	0.0
01/18/2015 05:00	0.0	0.0	0.0	0.0	0.0
01/18/2015 06:00	0.0	0.0	0.0	0.0	0.0
01/18/2015 07:00	0.0	0.0	0.0	0.0	0.0
01/18/2015 08:00	0.0	0.0	0.0	0.0	0.0
01/18/2015 09:00	0.0	0.0	0.0	0.0	0.0
01/18/2015 10:00	31.9	15.4	0.0	0.6	0.1
01/18/2015 11:00	59.5	55.8	0.3	2.8	0.6
01/18/2015 12:00	2.7	0.5	0.4	4.0	0.8
01/18/2015 13:00	4.0	0.5	0.4	4.0	0.8
01/18/2015 14:00	34.6	21.9	0.6	5.1	1.0
01/18/2015 15:00	58.8	56.4	1.0	6.5	1.4
01/18/2015 16:00	7.2	0.5	1.4	7.9	1.8
01/18/2015 17:00	13.5	2.0	1.9	10.7	2.3
01/18/2015 18:00	16.1	2.6	2.0	11.0	2.4
01/18/2015 19:00	16.1	2.7	2.0	11.1	2.4
01/18/2015 20:00	15.9	2.7	2.0	10.9	2.4
01/18/2015 21:00	13.5	2.1	1.9	10.6	2.3
01/18/2015 22:00	7.3	0.6	1.4	8.1	1.8
01/18/2015 23:00	6.5	0.5	1.3	7.2	1.6
Average/Sum#:	326.6 #	183.5 #	20.7 #	123.7 #	26.8 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	59.5	56.4	2.0	11.1	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/19/2015 00:00	7.5	0.6	1.6	8.3	1.8
01/19/2015 01:00	6.8	0.5	1.3	7.5	1.6
01/19/2015 02:00	6.5	0.5	1.3	7.2	1.6
01/19/2015 03:00	9.4	1.2	1.6	8.6	1.8
01/19/2015 04:00	13.3	2.3	1.9	10.4	2.2
01/19/2015 05:00	15.9	2.3	2.0	10.9	2.4
01/19/2015 06:00	16.0	2.3	2.0	11.0	2.4
01/19/2015 07:00	16.4	3.7	2.1	11.3	2.4
01/19/2015 08:00	13.6	2.0	2.0	10.7	2.4
01/19/2015 09:00	13.3	2.0	1.9	10.4	2.2
01/19/2015 10:00	13.5	2.3	2.0	10.6	2.4
01/19/2015 11:00	13.2	2.0	1.9	10.3	2.2
01/19/2015 12:00	13.2	2.0	1.9	10.4	2.2
01/19/2015 13:00	13.2	2.0	1.9	10.4	2.2
01/19/2015 14:00	13.2	2.0	1.9	10.4	2.2
01/19/2015 15:00	13.4	2.3	1.9	10.6	2.3
01/19/2015 16:00	15.6	2.3	2.0	10.7	2.4
01/19/2015 17:00	15.9	3.0	2.0	11.0	2.4
01/19/2015 18:00	16.3	3.6	2.1	11.2	2.5
01/19/2015 19:00	16.3	3.6	2.1	11.2	2.5
01/19/2015 20:00	16.3	3.3	2.0	11.2	2.4
01/19/2015 21:00	16.3	3.0	2.0	11.2	2.4
01/19/2015 22:00	13.6	2.3	1.9	10.7	2.4
01/19/2015 23:00	13.2	1.9	1.9	10.3	2.2
Average/Sum#:	321.9 #	53.0 #	45.2 #	246.5 #	53.5 #
Minimum:	6.5	0.5	1.3	7.2	1.6
Maximum:	16.4	3.7	2.1	11.3	2.5
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/20/2015 00:00	15.7	2.3	2.0	10.8	2.4
01/20/2015 01:00	13.1	1.9	1.9	10.2	2.2
01/20/2015 02:00	13.1	1.9	1.9	10.2	2.2
01/20/2015 03:00	13.1	1.9	1.9	10.2	2.2
01/20/2015 04:00	13.1	1.9	1.9	10.3	2.2
01/20/2015 05:00	13.1	1.9	1.9	10.2	2.2
01/20/2015 06:00	16.0	3.0	2.0	11.1	2.4
01/20/2015 07:00	16.4	3.0	2.0	11.2	2.4
01/20/2015 08:00	16.4	3.4	2.0	11.3	2.4
01/20/2015 09:00	16.4	3.4	2.0	11.2	2.4
01/20/2015 10:00	16.2	3.0	2.0	11.1	2.4
01/20/2015 11:00	16.3	3.4	2.0	11.2	2.4
01/20/2015 12:00	16.4	3.7	2.0	11.3	2.4
01/20/2015 13:00	16.2	3.4	2.0	11.1	2.4
01/20/2015 14:00	16.3	3.0	2.0	11.1	2.4
01/20/2015 15:00	16.3	3.7	2.0	11.3	2.4
01/20/2015 16:00	13.2	2.0	1.9	10.4	2.2
01/20/2015 17:00	13.5	2.3	1.9	10.6	2.3
01/20/2015 18:00	16.4	3.7	2.0	11.3	2.4
01/20/2015 19:00	16.5	3.7	2.0	11.4	2.5
01/20/2015 20:00	16.2	3.4	2.0	11.1	2.4
01/20/2015 21:00	16.4	3.4	2.0	11.3	2.4
01/20/2015 22:00	16.0	3.0	2.0	11.1	2.4
01/20/2015 23:00	13.1	2.0	1.9	10.2	2.2
Average/Sum#:	365.4 #	68.3 #	47.2 #	261.2 #	56.2 #
Minimum:	13.1	1.9	1.9	10.2	2.2
Maximum:	16.5	3.7	2.0	11.4	2.5
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/21/2015 00:00	13.2	1.3	1.9	10.4	2.2
01/21/2015 01:00	14.9	1.3	1.9	10.3	2.2
01/21/2015 02:00	15.3	1.7	1.9	10.5	2.3
01/21/2015 03:00	14.9	1.3	1.9	10.2	2.2
01/21/2015 04:00	15.1	2.0	1.9	10.4	2.2
01/21/2015 05:00	13.1	2.3	1.9	10.3	2.2
01/21/2015 06:00	13.7	2.3	2.0	10.8	2.4
01/21/2015 07:00	16.1	3.1	2.0	11.1	2.4
01/21/2015 08:00	16.5	3.7	2.0	11.3	2.4
01/21/2015 09:00	16.2	3.4	2.0	11.2	2.4
01/21/2015 10:00	15.7	2.3	2.0	10.8	2.4
01/21/2015 11:00	15.6	2.3	2.0	10.7	2.4
01/21/2015 12:00	15.5	2.3	1.9	10.6	2.3
01/21/2015 13:00	13.2	2.0	1.9	10.4	2.2
01/21/2015 14:00	13.1	2.0	1.9	10.4	2.2
01/21/2015 15:00	15.5	2.3	1.9	10.7	2.4
01/21/2015 16:00	15.9	2.6	2.0	11.0	2.4
01/21/2015 17:00	16.2	3.0	2.0	11.1	2.4
01/21/2015 18:00	16.4	3.7	2.0	11.3	2.4
01/21/2015 19:00	16.4	3.7	2.0	11.3	2.4
01/21/2015 20:00	16.2	3.0	2.0	11.1	2.4
01/21/2015 21:00	16.1	3.0	2.0	11.1	2.4
01/21/2015 22:00	13.6	2.3	1.9	10.7	2.4
01/21/2015 23:00	11.0	0.9	1.6	8.6	1.8
Average/Sum#:	359.4 #	57.8 #	46.5 #	256.3 #	55.4 #
Minimum:	11.0	0.9	1.6	8.6	1.8
Maximum:	16.5	3.7	2.0	11.3	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/22/2015 00:00	8.4	0.5	1.4	7.7	1.6
01/22/2015 01:00	6.5	0.5	1.3	7.2	1.6
01/22/2015 02:00	7.9	0.5	1.3	7.2	1.6
01/22/2015 03:00	11.0	1.2	1.6	8.6	1.8
01/22/2015 04:00	13.2	2.6	1.9	10.4	2.2
01/22/2015 05:00	13.2	2.3	1.9	10.3	2.2
01/22/2015 06:00	13.6	2.7	1.9	10.7	2.4
01/22/2015 07:00	16.2	3.4	2.0	11.2	2.4
01/22/2015 08:00	16.0	3.0	2.0	11.0	2.4
01/22/2015 09:00	16.2	3.4	2.0	11.2	2.4
01/22/2015 10:00	13.2	1.9	1.9	10.4	2.2
01/22/2015 11:00	13.2	2.3	1.9	10.3	2.2
01/22/2015 12:00	13.1	2.3	1.9	10.3	2.2
01/22/2015 13:00	10.6	0.8	1.6	8.3	1.8
01/22/2015 14:00	9.8	0.6	1.7	9.0	2.0
01/22/2015 15:00	12.2	1.2	1.7	9.6	2.1
01/22/2015 16:00	13.2	2.3	1.9	10.3	2.2
01/22/2015 17:00	15.9	3.0	2.0	10.9	2.4
01/22/2015 18:00	16.5	3.7	2.0	11.3	2.4
01/22/2015 19:00	16.4	3.4	2.0	11.3	2.4
01/22/2015 20:00	16.1	3.0	2.0	11.1	2.4
01/22/2015 21:00	13.9	2.3	2.0	10.9	2.4
01/22/2015 22:00	13.7	2.3	1.9	10.7	2.4
01/22/2015 23:00	13.3	1.6	1.9	10.4	2.2
Average/Sum#:	313.3 #	50.8 #	43.7 #	240.3 #	51.9 #
Minimum:	6.5	0.5	1.3	7.2	1.6
Maximum:	16.5	3.7	2.0	11.3	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/23/2015 00:00	15.6	2.4	2.0	10.7	2.4
01/23/2015 01:00	13.4	1.3	1.9	10.5	2.3
01/23/2015 02:00	16.1	2.4	2.0	11.1	2.4
01/23/2015 03:00	15.9	2.3	2.0	10.9	2.4
01/23/2015 04:00	15.4	2.0	1.9	10.6	2.3
01/23/2015 05:00	13.4	2.0	1.9	10.5	2.3
01/23/2015 06:00	13.8	2.3	2.0	10.9	2.4
01/23/2015 07:00	16.3	3.4	2.0	11.3	2.4
01/23/2015 08:00	16.2	3.0	2.0	11.1	2.4
01/23/2015 09:00	13.5	2.0	1.9	10.7	2.3
01/23/2015 10:00	13.4	1.7	1.9	10.5	2.3
01/23/2015 11:00	13.1	1.7	1.9	10.3	2.2
01/23/2015 12:00	13.1	1.7	1.9	10.4	2.2
01/23/2015 13:00	13.1	1.7	1.9	10.4	2.2
01/23/2015 14:00	13.1	1.7	1.9	10.3	2.2
01/23/2015 15:00	13.2	1.7	1.9	10.4	2.2
01/23/2015 16:00	15.5	2.3	1.9	10.6	2.4
01/23/2015 17:00	15.5	2.3	2.0	10.7	2.4
01/23/2015 18:00	16.5	3.3	2.0	11.3	2.4
01/23/2015 19:00	16.6	3.3	2.0	11.4	2.5
01/23/2015 20:00	16.5	3.3	2.0	11.4	2.5
01/23/2015 21:00	16.2	2.9	2.0	11.1	2.4
01/23/2015 22:00	16.3	2.6	2.0	11.1	2.4
01/23/2015 23:00	13.4	2.0	1.9	10.6	2.3
Average/Sum#:	355.1 #	55.3 #	46.8 #	258.8 #	56.2 #
Minimum:	13.1	1.3	1.9	10.3	2.2
Maximum:	16.6	3.4	2.0	11.4	2.5
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/24/2015 00:00	13.1	1.7	1.9	10.4	2.2
01/24/2015 01:00	13.3	1.7	1.9	10.5	2.3
01/24/2015 02:00	13.1	2.0	1.9	10.3	2.2
01/24/2015 03:00	15.1	2.0	1.9	10.4	2.2
01/24/2015 04:00	15.7	2.6	2.0	10.8	2.4
01/24/2015 05:00	16.1	2.6	2.0	11.1	2.4
01/24/2015 06:00	16.0	3.0	2.0	11.1	2.4
01/24/2015 07:00	16.2	3.4	2.0	11.2	2.4
01/24/2015 08:00	15.6	2.3	2.0	10.7	2.4
01/24/2015 09:00	13.4	2.3	1.9	10.5	2.3
01/24/2015 10:00	13.0	2.3	1.9	10.2	2.2
01/24/2015 11:00	13.1	2.0	1.9	10.4	2.2
01/24/2015 12:00	13.1	1.7	1.9	10.3	2.2
01/24/2015 13:00	12.9	1.6	1.9	10.1	2.2
01/24/2015 14:00	7.8	0.2	1.3	7.2	1.6
01/24/2015 15:00	9.1	0.2	1.3	7.1	1.6
01/24/2015 16:00	10.1	0.3	1.4	7.9	1.8
01/24/2015 17:00	14.6	2.4	1.8	10.1	2.2
01/24/2015 18:00	16.7	3.6	2.0	11.5	2.5
01/24/2015 19:00	16.5	3.9	2.0	11.3	2.4
01/24/2015 20:00	16.0	3.0	2.0	11.1	2.4
01/24/2015 21:00	16.2	3.4	2.0	11.1	2.4
01/24/2015 22:00	16.4	3.4	2.0	11.2	2.4
01/24/2015 23:00	16.0	3.4	2.0	10.9	2.4
Average/Sum#:	339.1 #	55.0 #	44.9 #	247.4 #	53.7 #
Minimum:	7.8	0.2	1.3	7.1	1.6
Maximum:	16.7	3.9	2.0	11.5	2.5
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/25/2015 00:00	10.3	0.5	1.4	8.1	1.8
01/25/2015 01:00	7.8	10.5	0.2	0.8	0.2
01/25/2015 02:00	0.0	0.0	0.0	0.0	0.0
01/25/2015 03:00	0.0	0.0	0.0	0.0	0.0
01/25/2015 04:00	0.0	0.0	0.0	0.0	0.0
01/25/2015 05:00	0.0	0.0	0.0	0.0	0.0
01/25/2015 06:00	0.0	0.0	0.0	0.0	0.0
01/25/2015 07:00	0.0	0.0	0.0	0.0	0.0
01/25/2015 08:00	0.0	0.0	0.0	0.0	0.0
01/25/2015 09:00	0.0	0.0	0.0	0.0	0.0
01/25/2015 10:00	0.0	0.0	0.0	0.0	0.0
01/25/2015 11:00	0.0	0.0	0.0	0.0	0.0
01/25/2015 12:00	34.1	54.9	0.1	0.5	0.1
01/25/2015 13:00	54.7	63.9	0.5	1.8	0.4
01/25/2015 14:00	23.0	12.0	1.0	3.6	0.9
01/25/2015 15:00	5.3	0.0	1.2	4.4	1.1
01/25/2015 16:00	5.0	0.0	1.2	4.2	1.0
01/25/2015 17:00	7.3	1.2	1.3	4.6	1.1
01/25/2015 18:00	8.6	3.3	1.5	5.4	1.3
01/25/2015 19:00	5.5	1.0	1.3	4.6	1.1
01/25/2015 20:00	5.4	0.0	1.3	4.5	1.1
01/25/2015 21:00	5.1	0.0	1.2	4.3	1.0
01/25/2015 22:00	5.9	10.0	0.7	2.5	0.6
01/25/2015 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	178.0 #	157.3 #	12.9 #	49.3 #	11.7 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	54.7	63.9	1.5	8.1	1.8
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/26/2015 00:00	0.0	0.0	0.0	0.0	0.0
01/26/2015 01:00	0.0	0.0	0.0	0.0	0.0
01/26/2015 02:00	0.0	0.0	0.0	0.0	0.0
01/26/2015 03:00	0.0	0.0	0.0	0.0	0.0
01/26/2015 04:00	28.3	28.5	0.3	0.9	0.2
01/26/2015 05:00	34.8	37.4	0.9	3.2	0.8
01/26/2015 06:00	5.1	0.0	1.2	4.3	1.0
01/26/2015 07:00	5.4	0.0	1.3	4.5	1.1
01/26/2015 08:00	5.4	0.0	1.3	4.5	1.1
01/26/2015 09:00	5.4	0.0	1.3	4.5	1.1
01/26/2015 10:00	7.3	0.0	1.3	4.5	1.1
01/26/2015 11:00	7.1	0.0	1.2	4.4	1.1
01/26/2015 12:00	7.3	0.0	1.3	4.5	1.1
01/26/2015 13:00	7.2	0.0	1.3	4.5	1.1
01/26/2015 14:00	7.2	0.0	1.3	4.5	1.1
01/26/2015 15:00	7.2	0.0	1.3	4.5	1.1
01/26/2015 16:00	7.2	0.0	1.3	4.5	1.1
01/26/2015 17:00	4.8	0.0	1.1	4.0	1.0
01/26/2015 18:00	5.0	0.0	1.2	4.2	1.0
01/26/2015 19:00	7.3	0.0	1.3	4.5	1.1
01/26/2015 20:00	7.3	0.0	1.3	4.5	1.1
01/26/2015 21:00	4.8	0.0	1.1	4.0	1.0
01/26/2015 22:00	2.9	0.0	1.0	3.6	0.9
01/26/2015 23:00	2.7	0.0	0.9	3.4	0.8
Average/Sum#:	169.7 #	65.9 #	23.2 #	81.5 #	19.9 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	34.8	37.4	1.3	4.5	1.1
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/27/2015 00:00	2.7	0.0	1.0	3.4	0.8
01/27/2015 01:00	2.7	0.3	0.9	3.4	0.8
01/27/2015 02:00	91.7	127.0	1.3	5.2	1.2
01/27/2015 03:00	57.3	53.3	1.4	6.5	1.4
01/27/2015 04:00	12.1	9.3	1.3	4.9	1.2
01/27/2015 05:00	7.3	0.0	1.3	4.6	1.1
01/27/2015 06:00	7.4	0.0	1.3	4.6	1.1
01/27/2015 07:00	12.2	7.3	1.3	5.0	1.2
01/27/2015 08:00	28.3	20.1	1.5	6.1	1.4
01/27/2015 09:00	8.7	14.4	1.4	5.2	1.2
01/27/2015 10:00	2.8	7.1	1.4	7.2	1.5
01/27/2015 11:00	2.6	0.4	1.3	7.1	1.6
01/27/2015 12:00	2.6	0.2	1.3	7.2	1.6
01/27/2015 13:00	10.9	0.3	1.6	8.6	1.8
01/27/2015 14:00	6.5	0.2	1.3	7.1	1.6
01/27/2015 15:00	11.0	0.6	1.6	8.6	1.8
01/27/2015 16:00	6.6	0.2	1.3	7.3	1.6
01/27/2015 17:00	11.6	1.5	1.7	9.1	2.0
01/27/2015 18:00	16.1	3.3	2.0	11.1	2.4
01/27/2015 19:00	16.0	3.0	2.0	11.0	2.4
01/27/2015 20:00	15.8	2.6	2.0	10.9	2.4
01/27/2015 21:00	15.9	3.0	2.0	10.9	2.4
01/27/2015 22:00	15.7	2.6	2.0	10.8	2.4
01/27/2015 23:00	10.9	0.9	1.6	8.6	1.8
Average/Sum#:	367.4 #	249.9 #	35.8 #	174.4 #	38.7 #
Minimum:	2.7	0.0	0.9	3.4	0.8
Maximum:	91.7	127.0	2.0	11.1	2.4
%SI	12.5	12.5	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/28/2015 00:00	7.7	0.2	1.3	7.0	1.6
01/28/2015 01:00	7.7	0.2	1.3	7.0	1.6
01/28/2015 02:00	7.6	0.2	1.3	7.0	1.6
01/28/2015 03:00	7.6	0.2	1.3	7.0	1.6
01/28/2015 04:00	7.7	0.2	1.3	7.1	1.6
01/28/2015 05:00	11.2	1.2	1.6	8.8	2.0
01/28/2015 06:00	15.0	2.0	1.9	10.3	2.2
01/28/2015 07:00	16.2	3.3	2.0	11.1	2.4
01/28/2015 08:00	13.2	1.7	1.9	10.4	2.2
01/28/2015 09:00	13.0	1.4	1.9	10.2	2.2
01/28/2015 10:00	14.8	1.4	1.9	10.2	2.2
01/28/2015 11:00	12.1	0.9	1.7	9.5	2.0
01/28/2015 12:00	8.9	0.2	1.3	7.0	1.6
01/28/2015 13:00	11.2	0.3	1.6	8.8	2.0
01/28/2015 14:00	14.7	1.6	1.9	10.1	2.2
01/28/2015 15:00	16.5	3.2	2.0	11.3	2.4
01/28/2015 16:00	16.1	2.9	2.0	11.1	2.4
01/28/2015 17:00	15.6	2.3	2.0	10.8	2.4
01/28/2015 18:00	16.1	3.0	2.0	11.1	2.4
01/28/2015 19:00	16.1	3.0	2.0	11.1	2.4
01/28/2015 20:00	15.6	2.0	2.0	10.7	2.4
01/28/2015 21:00	15.7	2.3	2.0	10.8	2.4
01/28/2015 22:00	15.5	2.3	1.9	10.6	2.4
01/28/2015 23:00	12.9	1.7	1.9	10.2	2.2
Average/Sum#:	308.7 #	37.7 #	42.0 #	229.2 #	50.4 #
Minimum:	7.6	0.2	1.3	7.0	1.6
Maximum:	16.5	3.3	2.0	11.3	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/29/2015 00:00	12.9	1.6	1.9	10.2	2.2
01/29/2015 01:00	12.9	2.0	1.9	10.2	2.2
01/29/2015 02:00	13.1	1.7	1.9	10.2	2.2
01/29/2015 03:00	12.9	1.7	1.9	10.2	2.2
01/29/2015 04:00	13.1	1.7	1.9	10.2	2.2
01/29/2015 05:00	13.0	1.7	1.9	10.2	2.2
01/29/2015 06:00	13.5	2.3	2.0	10.6	2.4
01/29/2015 07:00	16.3	3.3	2.0	11.1	2.4
01/29/2015 08:00	15.9	2.0	2.0	10.9	2.4
01/29/2015 09:00	15.7	2.0	2.0	10.9	2.4
01/29/2015 10:00	13.1	2.0	1.9	10.3	2.2
01/29/2015 11:00	13.0	1.0	1.9	10.2	2.2
01/29/2015 12:00	14.8	1.0	1.9	10.2	2.2
01/29/2015 13:00	14.8	1.0	1.9	10.2	2.2
01/29/2015 14:00	13.1	1.0	1.9	10.3	2.2
01/29/2015 15:00	16.3	3.2	2.0	11.2	2.4
01/29/2015 16:00	15.5	2.3	1.9	10.6	2.3
01/29/2015 17:00	13.3	2.0	1.9	10.4	2.2
01/29/2015 18:00	16.1	3.0	2.0	11.0	2.4
01/29/2015 19:00	16.2	3.0	2.0	11.2	2.4
01/29/2015 20:00	16.4	3.0	2.0	11.3	2.4
01/29/2015 21:00	15.9	2.3	2.0	10.9	2.4
01/29/2015 22:00	15.2	2.0	1.9	10.5	2.2
01/29/2015 23:00	14.8	1.7	1.9	10.2	2.2
Average/Sum#:	347.8 #	48.5 #	46.5 #	253.2 #	54.7 #
Minimum:	12.9	1.0	1.9	10.2	2.2
Maximum:	16.4	3.3	2.0	11.3	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/30/2015 00:00	14.9	1.7	1.9	10.2	2.2
01/30/2015 01:00	14.9	1.7	1.9	10.3	2.2
01/30/2015 02:00	13.0	1.7	1.9	10.2	2.2
01/30/2015 03:00	13.0	1.7	1.9	10.2	2.2
01/30/2015 04:00	14.9	1.7	1.9	10.3	2.2
01/30/2015 05:00	15.0	1.7	1.9	10.3	2.2
01/30/2015 06:00	11.4	1.7	1.9	10.5	2.2
01/30/2015 07:00	15.9	3.0	2.0	10.9	2.4
01/30/2015 08:00	15.9	2.3	2.0	10.9	2.4
01/30/2015 09:00	15.5	2.0	1.9	10.6	2.4
01/30/2015 10:00	13.2	1.4	1.9	10.3	2.2
01/30/2015 11:00	13.0	1.4	1.9	10.3	2.2
01/30/2015 12:00	11.4	0.3	1.6	9.0	2.0
01/30/2015 13:00	15.2	2.3	1.9	10.5	2.2
01/30/2015 14:00	15.3	2.6	1.9	10.6	2.3
01/30/2015 15:00	15.3	2.3	1.9	10.5	2.2
01/30/2015 16:00	15.9	3.0	2.0	10.9	2.4
01/30/2015 17:00	13.2	2.0	1.9	10.4	2.2
01/30/2015 18:00	13.1	2.0	1.9	10.3	2.2
01/30/2015 19:00	13.1	2.0	1.9	10.3	2.2
01/30/2015 20:00	13.1	2.0	1.9	10.3	2.2
01/30/2015 21:00	15.0	2.0	1.9	10.3	2.2
01/30/2015 22:00	11.9	1.2	1.7	9.3	2.0
01/30/2015 23:00	8.9	0.0	1.3	7.0	1.6
Average/Sum#:	332.0 #	43.7 #	44.8 #	244.4 #	52.7 #
Minimum:	8.9	0.0	1.3	7.0	1.6
Maximum:	15.9	3.0	2.0	10.9	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/31/2015 00:00	9.7	5.4	0.6	5.4	1.1
01/31/2015 01:00	7.2	0.3	0.5	5.4	1.1
01/31/2015 02:00	7.2	0.3	0.5	5.4	1.1
01/31/2015 03:00	18.8	34.1	0.8	6.1	1.2
01/31/2015 04:00	55.5	44.4	1.1	6.7	1.4
01/31/2015 05:00	12.4	1.2	1.7	9.8	2.2
01/31/2015 06:00	15.0	2.0	1.9	10.3	2.2
01/31/2015 07:00	15.0	2.0	1.9	10.3	2.2
01/31/2015 08:00	15.0	2.0	1.9	10.3	2.2
01/31/2015 09:00	15.0	2.0	1.9	10.3	2.2
01/31/2015 10:00	15.0	2.0	1.9	10.3	2.2
01/31/2015 11:00	9.6	0.0	1.4	7.5	1.6
01/31/2015 12:00	9.1	0.0	1.3	7.1	1.6
01/31/2015 13:00	9.3	0.0	1.3	7.3	1.6
01/31/2015 14:00	10.7	0.3	1.6	8.4	1.8
01/31/2015 15:00	13.5	0.6	1.7	9.3	2.0
01/31/2015 16:00	13.7	0.9	1.7	9.4	2.0
01/31/2015 17:00	11.2	0.3	1.6	8.8	2.0
01/31/2015 18:00	16.2	3.3	2.0	11.1	2.4
01/31/2015 19:00	16.3	2.9	2.0	11.2	2.4
01/31/2015 20:00	16.3	2.9	2.0	11.2	2.4
01/31/2015 21:00	16.4	3.0	2.0	11.3	2.4
01/31/2015 22:00	16.4	3.0	2.0	11.3	2.4
01/31/2015 23:00	15.7	2.3	2.0	10.8	2.4
Average/Sum#:	360.2 #	115.2 #	37.3 #	215.0 #	46.1 #
Minimum:	7.2	0.0	0.5	5.4	1.1
Maximum:	55.5	44.4	2.0	11.3	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/01/2015 00:00	16.1	3.3	2.0	11.1	2.4
02/01/2015 01:00	11.4	0.3	1.6	9.0	2.0
02/01/2015 02:00	8.4	9.1	0.1	0.7	0.2
02/01/2015 03:00	0.0	0.0	0.0	0.0	0.0
02/01/2015 04:00	0.0	0.0	0.0	0.0	0.0
02/01/2015 05:00	0.0	0.0	0.0	0.0	0.0
02/01/2015 06:00	0.0	0.0	0.0	0.0	0.0
02/01/2015 07:00	0.0	0.0	0.0	0.0	0.0
02/01/2015 08:00	0.0	0.0	0.0	0.0	0.0
02/01/2015 09:00	0.0	0.0	0.0	0.0	0.0
02/01/2015 10:00	50.0	31.1	0.2	0.7	0.2
02/01/2015 11:00	51.2	59.6	0.6	2.1	0.5
02/01/2015 12:00	2.8	0.0	1.0	3.5	0.8
02/01/2015 13:00	2.8	0.0	1.0	3.5	0.8
02/01/2015 14:00	62.7	18.4	1.3	5.3	1.2
02/01/2015 15:00	63.0	31.0	1.4	7.2	1.6
02/01/2015 16:00	12.5	1.2	1.8	9.8	2.2
02/01/2015 17:00	13.3	2.3	1.9	10.5	2.2
02/01/2015 18:00	15.9	3.0	2.0	11.0	2.4
02/01/2015 19:00	16.1	3.6	2.0	11.1	2.4
02/01/2015 20:00	16.3	3.3	2.0	11.1	2.4
02/01/2015 21:00	16.1	3.0	2.0	11.1	2.4
02/01/2015 22:00	15.5	2.0	1.9	10.6	2.3
02/01/2015 23:00	12.9	1.2	1.9	10.2	2.2
Average/Sum#:	387.0 #	172.4 #	24.7 #	128.5 #	28.2 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	63.0	59.6	2.0	11.1	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/02/2015 00:00	13.0	2.0	1.9	10.2	2.2
02/02/2015 01:00	15.9	3.3	2.0	11.0	2.4
02/02/2015 02:00	15.6	2.3	2.0	10.7	2.4
02/02/2015 03:00	13.1	1.6	1.9	10.2	2.2
02/02/2015 04:00	12.9	2.0	1.9	10.2	2.2
02/02/2015 05:00	13.1	2.0	1.9	10.4	2.2
02/02/2015 06:00	15.6	2.6	2.0	10.7	2.4
02/02/2015 07:00	15.8	2.9	2.0	10.8	2.4
02/02/2015 08:00	13.0	1.6	1.9	10.2	2.2
02/02/2015 09:00	12.9	2.0	1.9	10.2	2.2
02/02/2015 10:00	12.9	1.6	1.9	10.2	2.2
02/02/2015 11:00	13.1	1.6	1.9	10.3	2.2
02/02/2015 12:00	15.3	2.0	1.9	10.6	2.3
02/02/2015 13:00	13.2	1.6	1.9	10.3	2.2
02/02/2015 14:00	13.0	1.6	1.9	10.1	2.2
02/02/2015 15:00	13.0	1.3	1.9	10.1	2.2
02/02/2015 16:00	13.4	2.3	1.9	10.5	2.2
02/02/2015 17:00	15.6	2.3	2.0	10.6	2.4
02/02/2015 18:00	16.1	3.3	2.0	11.1	2.4
02/02/2015 19:00	16.1	2.6	2.0	11.1	2.4
02/02/2015 20:00	16.1	3.3	2.0	11.1	2.4
02/02/2015 21:00	15.7	2.3	2.0	10.8	2.4
02/02/2015 22:00	15.3	2.0	1.9	10.6	2.3
02/02/2015 23:00	12.9	1.2	1.9	10.1	2.2
Average/Sum#:	342.6 #	51.3 #	46.5 #	252.1 #	54.8 #
Minimum:	12.9	1.2	1.9	10.1	2.2
Maximum:	16.1	3.3	2.0	11.1	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/03/2015 00:00	8.0	0.2	1.3	7.3	1.6
02/03/2015 01:00	7.8	0.2	1.3	7.1	1.6
02/03/2015 02:00	7.8	0.2	1.3	7.1	1.6
02/03/2015 03:00	8.2	0.3	1.4	7.5	1.6
02/03/2015 04:00	11.9	0.9	1.7	9.4	2.0
02/03/2015 05:00	12.9	2.0	1.9	10.2	2.2
02/03/2015 06:00	13.1	2.0	1.9	10.3	2.2
02/03/2015 07:00	12.9	2.0	1.9	10.1	2.2
02/03/2015 08:00	12.9	2.0	1.9	10.1	2.2
02/03/2015 09:00	12.9	2.0	1.9	10.2	2.2
02/03/2015 10:00	11.7	1.2	1.7	9.2	2.0
02/03/2015 11:00	6.3	0.0	1.3	7.0	1.6
02/03/2015 12:00	7.8	0.0	1.3	7.1	1.6
02/03/2015 13:00	9.5	0.3	1.4	7.5	1.6
02/03/2015 14:00	11.9	0.3	1.7	9.4	2.0
02/03/2015 15:00	9.4	0.3	1.6	8.7	1.8
02/03/2015 16:00	11.5	0.9	1.7	9.0	2.0
02/03/2015 17:00	13.3	2.6	1.9	10.5	2.2
02/03/2015 18:00	16.4	3.9	2.0	11.2	2.4
02/03/2015 19:00	16.0	3.0	2.0	11.0	2.4
02/03/2015 20:00	15.9	3.0	2.0	10.9	2.4
02/03/2015 21:00	15.5	2.3	1.9	10.6	2.4
02/03/2015 22:00	14.5	2.1	1.8	10.0	2.2
02/03/2015 23:00	7.9	0.0	1.3	7.3	1.6
Average/Sum#:	276.0 #	31.7 #	40.1 #	218.7 #	47.6 #
Minimum:	6.3	0.0	1.3	7.0	1.6
Maximum:	16.4	3.9	2.0	11.2	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/04/2015 00:00	11.9	0.3	1.7	9.3	2.0
02/04/2015 01:00	9.0	0.3	1.4	8.2	1.8
02/04/2015 02:00	7.7	0.2	1.3	7.1	1.6
02/04/2015 03:00	7.8	0.2	1.3	7.1	1.6
02/04/2015 04:00	8.3	0.3	1.4	7.7	1.6
02/04/2015 05:00	11.2	1.2	1.6	8.8	2.0
02/04/2015 06:00	11.4	2.3	1.9	10.4	2.2
02/04/2015 07:00	15.1	2.3	1.9	10.4	2.2
02/04/2015 08:00	7.9	0.2	1.3	7.3	1.6
02/04/2015 09:00	7.8	0.2	1.3	7.1	1.6
02/04/2015 10:00	7.8	0.2	1.3	7.1	1.6
02/04/2015 11:00	7.8	0.2	1.3	7.1	1.6
02/04/2015 12:00	7.8	0.2	1.3	7.1	1.6
02/04/2015 13:00	7.8	0.2	1.3	7.1	1.6
02/04/2015 14:00	7.8	0.2	1.3	7.1	1.6
02/04/2015 15:00	8.1	0.3	1.3	7.5	1.6
02/04/2015 16:00	13.1	2.9	1.9	10.2	2.2
02/04/2015 17:00	15.5	3.3	1.9	10.6	2.4
02/04/2015 18:00	16.2	3.9	2.0	11.1	2.4
02/04/2015 19:00	16.1	3.9	2.0	11.1	2.4
02/04/2015 20:00	15.9	3.6	2.0	10.9	2.4
02/04/2015 21:00	16.1	3.6	2.0	11.1	2.4
02/04/2015 22:00	15.7	3.2	2.0	10.8	2.4
02/04/2015 23:00	10.9	0.9	1.6	8.6	1.8
Average/Sum#:	264.7 #	34.1 #	38.3 #	210.8 #	46.2 #
Minimum:	7.7	0.2	1.3	7.1	1.6
Maximum:	16.2	3.9	2.0	11.1	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/05/2015 00:00	7.7	0.2	1.3	7.1	1.6
02/05/2015 01:00	7.8	0.2	1.3	7.1	1.6
02/05/2015 02:00	7.8	0.2	1.3	7.1	1.6
02/05/2015 03:00	7.8	0.2	1.3	7.1	1.6
02/05/2015 04:00	10.0	0.3	1.4	7.8	1.8
02/05/2015 05:00	11.2	1.2	1.6	8.8	2.0
02/05/2015 06:00	13.3	2.9	1.9	10.4	2.2
02/05/2015 07:00	15.5	2.9	1.9	10.7	2.4
02/05/2015 08:00	10.0	0.3	1.4	7.9	1.8
02/05/2015 09:00	7.8	0.2	1.3	7.1	1.6
02/05/2015 10:00	7.8	0.2	1.3	7.1	1.6
02/05/2015 11:00	7.9	0.2	1.3	7.3	1.6
02/05/2015 12:00	8.1	0.3	1.3	7.5	1.6
02/05/2015 13:00	11.2	0.3	1.6	8.8	2.0
02/05/2015 14:00	11.6	0.3	1.7	9.1	2.0
02/05/2015 15:00	11.2	0.3	1.6	8.8	2.0
02/05/2015 16:00	12.9	2.0	1.9	10.1	2.2
02/05/2015 17:00	13.1	2.0	1.9	10.3	2.2
02/05/2015 18:00	15.9	3.8	2.0	10.9	2.4
02/05/2015 19:00	15.7	3.3	2.0	10.8	2.4
02/05/2015 20:00	15.9	3.6	2.0	10.9	2.4
02/05/2015 21:00	15.5	3.2	2.0	10.7	2.4
02/05/2015 22:00	10.2	0.3	1.4	8.0	1.8
02/05/2015 23:00	7.7	0.2	1.3	7.1	1.6
Average/Sum#:	263.6 #	28.6 #	38.0 #	208.5 #	46.4 #
Minimum:	7.7	0.2	1.3	7.1	1.6
Maximum:	15.9	3.8	2.0	10.9	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/06/2015 00:00	7.8	0.2	1.3	7.1	1.6
02/06/2015 01:00	7.8	0.2	1.3	7.1	1.6
02/06/2015 02:00	7.7	0.2	1.3	7.1	1.6
02/06/2015 03:00	7.8	0.2	1.3	7.1	1.6
02/06/2015 04:00	9.3	0.5	1.3	7.3	1.6
02/06/2015 05:00	12.5	2.1	1.7	9.8	2.2
02/06/2015 06:00	13.5	3.5	1.9	10.6	2.3
02/06/2015 07:00	15.1	3.2	1.9	10.4	2.2
02/06/2015 08:00	12.9	1.6	1.9	10.1	2.2
02/06/2015 09:00	11.6	0.3	1.7	9.0	2.0
02/06/2015 10:00	12.8	1.6	1.8	10.1	2.2
02/06/2015 11:00	12.9	2.0	1.9	10.2	2.2
02/06/2015 12:00	11.2	0.6	1.6	8.8	2.0
02/06/2015 13:00	12.9	2.0	1.9	10.2	2.2
02/06/2015 14:00	12.9	2.0	1.9	10.1	2.2
02/06/2015 15:00	12.9	2.0	1.9	10.2	2.2
02/06/2015 16:00	13.1	2.0	1.9	10.3	2.2
02/06/2015 17:00	13.9	3.5	2.0	10.9	2.4
02/06/2015 18:00	16.3	3.1	2.0	11.2	2.4
02/06/2015 19:00	13.9	3.1	2.0	10.9	2.4
02/06/2015 20:00	16.1	3.1	2.0	11.1	2.4
02/06/2015 21:00	13.2	2.3	1.9	10.4	2.2
02/06/2015 22:00	6.8	0.3	1.4	7.5	1.6
02/06/2015 23:00	11.0	0.3	1.6	8.7	1.9
Average/Sum#:	285.9 #	39.9 #	41.4 #	226.2 #	49.4 #
Minimum:	6.8	0.2	1.3	7.1	1.6
Maximum:	16.3	3.5	2.0	11.2	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/07/2015 00:00	6.5	0.2	1.3	7.2	1.6
02/07/2015 01:00	8.7	0.3	1.4	7.9	1.8
02/07/2015 02:00	8.4	0.3	1.4	7.7	1.6
02/07/2015 03:00	8.1	0.3	1.3	7.3	1.6
02/07/2015 04:00	9.4	0.3	1.3	7.3	1.6
02/07/2015 05:00	8.0	0.3	1.3	7.3	1.6
02/07/2015 06:00	8.0	0.3	1.3	7.3	1.6
02/07/2015 07:00	7.9	0.2	1.3	7.2	1.6
02/07/2015 08:00	7.7	0.2	1.3	7.1	1.6
02/07/2015 09:00	7.8	0.2	1.3	7.2	1.6
02/07/2015 10:00	8.1	0.3	1.3	7.5	1.6
02/07/2015 11:00	8.0	0.2	1.3	7.3	1.6
02/07/2015 12:00	7.8	0.2	1.3	7.1	1.6
02/07/2015 13:00	7.8	0.2	1.3	7.1	1.6
02/07/2015 14:00	8.1	0.2	1.3	7.4	1.6
02/07/2015 15:00	7.9	0.2	1.3	7.3	1.6
02/07/2015 16:00	11.5	1.2	1.7	9.0	2.0
02/07/2015 17:00	13.1	2.3	1.9	10.4	2.2
02/07/2015 18:00	16.2	3.8	2.0	11.1	2.4
02/07/2015 19:00	15.5	2.3	2.0	10.7	2.4
02/07/2015 20:00	16.1	3.5	2.0	11.1	2.4
02/07/2015 21:00	12.1	0.9	1.7	9.5	2.0
02/07/2015 22:00	8.3	0.3	1.4	7.6	1.6
02/07/2015 23:00	7.7	0.2	1.3	7.1	1.6
Average/Sum#:	228.7 #	18.4 #	35.0 #	193.7 #	42.4 #
Minimum:	6.5	0.2	1.3	7.1	1.6
Maximum:	16.2	3.8	2.0	11.1	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/08/2015 00:00	7.8	0.2	1.3	7.2	1.6
02/08/2015 01:00	8.1	0.2	1.3	7.4	1.6
02/08/2015 02:00	8.0	0.2	1.3	7.3	1.6
02/08/2015 03:00	7.8	0.2	1.3	7.1	1.6
02/08/2015 04:00	7.8	0.2	1.3	7.1	1.6
02/08/2015 05:00	7.7	0.2	1.3	7.1	1.6
02/08/2015 06:00	8.0	0.2	1.3	7.3	1.6
02/08/2015 07:00	7.8	0.2	1.3	7.2	1.6
02/08/2015 08:00	7.7	0.2	1.3	7.0	1.6
02/08/2015 09:00	7.7	0.2	1.3	7.1	1.6
02/08/2015 10:00	7.7	0.2	1.3	7.1	1.6
02/08/2015 11:00	7.8	0.2	1.3	7.1	1.6
02/08/2015 12:00	7.9	0.2	1.3	7.2	1.6
02/08/2015 13:00	7.9	0.2	1.3	7.3	1.6
02/08/2015 14:00	7.8	0.2	1.3	7.1	1.6
02/08/2015 15:00	7.8	0.2	1.3	7.1	1.6
02/08/2015 16:00	12.8	2.2	1.8	10.1	2.2
02/08/2015 17:00	13.4	2.6	1.9	10.6	2.3
02/08/2015 18:00	16.3	3.8	2.0	11.2	2.4
02/08/2015 19:00	15.9	2.9	2.0	11.0	2.4
02/08/2015 20:00	16.1	3.2	2.0	11.1	2.4
02/08/2015 21:00	14.2	1.8	1.7	9.7	2.2
02/08/2015 22:00	8.0	0.0	1.3	7.3	1.6
02/08/2015 23:00	10.7	0.3	1.6	8.4	1.8
Average/Sum#:	232.7 #	20.0 #	35.1 #	194.1 #	42.9 #
Minimum:	7.7	0.0	1.3	7.0	1.6
Maximum:	16.3	3.8	2.0	11.2	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/09/2015 00:00	7.8	0.2	1.3	7.2	1.6
02/09/2015 01:00	7.9	0.2	1.3	7.3	1.6
02/09/2015 02:00	9.0	0.2	1.3	7.1	1.6
02/09/2015 03:00	7.7	0.2	1.3	7.1	1.6
02/09/2015 04:00	7.7	0.2	1.3	7.1	1.6
02/09/2015 05:00	9.3	0.2	1.3	7.3	1.6
02/09/2015 06:00	10.4	1.5	1.7	9.5	2.0
02/09/2015 07:00	12.9	2.0	1.9	10.2	2.2
02/09/2015 08:00	12.9	1.7	1.9	10.2	2.2
02/09/2015 09:00	10.2	0.3	1.4	8.0	1.8
02/09/2015 10:00	7.8	0.0	1.3	7.1	1.6
02/09/2015 11:00	7.8	0.2	1.3	7.1	1.6
02/09/2015 12:00	7.7	0.2	1.3	7.1	1.6
02/09/2015 13:00	9.1	0.2	1.3	7.1	1.6
02/09/2015 14:00	9.1	0.2	1.3	7.1	1.6
02/09/2015 15:00	9.1	0.2	1.3	7.1	1.6
02/09/2015 16:00	9.1	0.2	1.3	7.1	1.6
02/09/2015 17:00	12.3	1.2	1.7	9.7	2.2
02/09/2015 18:00	12.9	2.2	1.9	10.1	2.2
02/09/2015 19:00	13.0	2.0	1.9	10.2	2.2
02/09/2015 20:00	13.1	2.0	1.9	10.4	2.2
02/09/2015 21:00	11.4	0.6	1.6	9.0	2.0
02/09/2015 22:00	9.3	0.2	1.3	7.3	1.6
02/09/2015 23:00	9.3	0.2	1.3	7.3	1.6
Average/Sum#:	236.8 #	16.3 #	35.4 #	194.7 #	43.0 #
Minimum:	7.7	0.0	1.3	7.1	1.6
Maximum:	13.1	2.2	1.9	10.4	2.2
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/10/2015 00:00	7.8	0.2	1.3	7.1	1.6
02/10/2015 01:00	7.8	0.2	1.3	7.1	1.6
02/10/2015 02:00	7.8	0.2	1.3	7.1	1.6
02/10/2015 03:00	7.8	0.2	1.3	7.1	1.6
02/10/2015 04:00	7.8	0.2	1.3	7.1	1.6
02/10/2015 05:00	8.0	0.2	1.3	7.3	1.6
02/10/2015 06:00	11.4	2.3	1.9	10.4	2.2
02/10/2015 07:00	15.5	3.0	2.0	10.6	2.4
02/10/2015 08:00	10.7	0.6	1.6	8.4	1.8
02/10/2015 09:00	9.1	0.0	1.3	7.1	1.6
02/10/2015 10:00	7.8	0.2	1.3	7.1	1.6
02/10/2015 11:00	7.8	0.2	1.3	7.1	1.6
02/10/2015 12:00	9.1	0.2	1.3	7.1	1.6
02/10/2015 13:00	9.1	0.2	1.3	7.1	1.6
02/10/2015 14:00	9.1	0.2	1.3	7.1	1.6
02/10/2015 15:00	9.1	0.2	1.3	7.1	1.6
02/10/2015 16:00	13.0	2.3	1.9	10.1	2.2
02/10/2015 17:00	15.9	3.6	2.0	11.0	2.4
02/10/2015 18:00	16.3	3.6	2.0	11.2	2.4
02/10/2015 19:00	16.3	3.3	2.0	11.3	2.4
02/10/2015 20:00	16.2	3.3	2.0	11.1	2.4
02/10/2015 21:00	15.8	2.6	2.0	10.9	2.4
02/10/2015 22:00	16.2	2.9	2.0	11.1	2.4
02/10/2015 23:00	16.1	3.0	2.0	11.1	2.4
Average/Sum#:	271.5 #	32.9 #	38.3 #	209.7 #	46.2 #
Minimum:	7.8	0.0	1.3	7.1	1.6
Maximum:	16.3	3.6	2.0	11.3	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/11/2015 00:00	16.1	3.0	2.0	11.1	2.4
02/11/2015 01:00	13.3	1.7	1.9	10.4	2.2
02/11/2015 02:00	12.9	1.2	1.9	10.1	2.2
02/11/2015 03:00	12.9	1.6	1.9	10.1	2.2
02/11/2015 04:00	12.9	1.6	1.9	10.1	2.2
02/11/2015 05:00	13.1	2.0	1.9	10.3	2.2
02/11/2015 06:00	13.4	2.3	1.9	10.6	2.3
02/11/2015 07:00	13.0	1.3	1.9	10.2	2.2
02/11/2015 08:00	12.9	1.2	1.9	10.2	2.2
02/11/2015 09:00	12.9	1.2	1.9	10.2	2.2
02/11/2015 10:00	11.2	0.6	1.6	8.8	2.0
02/11/2015 11:00	10.1	0.0	1.4	7.9	1.8
02/11/2015 12:00	10.5	0.0	1.4	8.2	1.8
02/11/2015 13:00	9.1	0.0	1.3	7.1	1.6
02/11/2015 14:00	9.1	0.0	1.3	7.1	1.6
02/11/2015 15:00	10.9	0.9	1.6	8.5	1.8
02/11/2015 16:00	13.2	2.3	1.9	10.4	2.2
02/11/2015 17:00	15.5	2.6	2.0	10.6	2.4
02/11/2015 18:00	16.3	3.9	2.0	11.2	2.4
02/11/2015 19:00	16.1	3.3	2.0	11.0	2.4
02/11/2015 20:00	16.1	3.3	2.0	11.1	2.4
02/11/2015 21:00	15.7	2.6	2.0	10.8	2.4
02/11/2015 22:00	15.9	3.0	2.0	10.9	2.4
02/11/2015 23:00	13.0	1.6	1.9	10.2	2.2
Average/Sum#:	316.1 #	41.2 #	43.5 #	237.1 #	51.7 #
Minimum:	9.1	0.0	1.3	7.1	1.6
Maximum:	16.3	3.9	2.0	11.2	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/12/2015 00:00	9.8	0.3	1.4	7.7	1.6
02/12/2015 01:00	9.6	0.0	1.4	7.5	1.6
02/12/2015 02:00	7.8	0.2	1.3	7.2	1.6
02/12/2015 03:00	10.3	0.3	1.4	8.1	1.8
02/12/2015 04:00	11.2	1.2	1.6	8.8	2.0
02/12/2015 05:00	15.3	2.6	1.9	10.5	2.3
02/12/2015 06:00	15.3	2.3	1.9	10.6	2.3
02/12/2015 07:00	15.4	2.6	1.9	10.6	2.3
02/12/2015 08:00	10.9	0.6	1.6	8.6	1.8
02/12/2015 09:00	7.8	0.0	1.3	7.1	1.6
02/12/2015 10:00	7.8	0.0	1.3	7.1	1.6
02/12/2015 11:00	7.8	0.0	1.3	7.1	1.6
02/12/2015 12:00	7.8	0.0	1.3	7.1	1.6
02/12/2015 13:00	11.7	0.3	1.7	9.2	2.0
02/12/2015 14:00	16.0	3.5	2.0	11.0	2.4
02/12/2015 15:00	13.3	1.9	1.9	10.4	2.2
02/12/2015 16:00	15.4	2.6	1.9	10.6	2.4
02/12/2015 17:00	15.8	2.9	2.0	10.8	2.4
02/12/2015 18:00	16.3	3.2	2.0	11.2	2.4
02/12/2015 19:00	16.4	3.3	2.0	11.2	2.4
02/12/2015 20:00	16.3	3.3	2.0	11.2	2.4
02/12/2015 21:00	15.7	2.6	2.0	10.8	2.4
02/12/2015 22:00	16.0	3.0	2.0	11.0	2.4
02/12/2015 23:00	11.4	0.3	1.6	9.0	2.0
Average/Sum#:	301.1 #	37.0 #	40.7 #	224.4 #	49.1 #
Minimum:	7.8	0.0	1.3	7.1	1.6
Maximum:	16.4	3.5	2.0	11.2	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/13/2015 00:00	12.1	0.0	1.7	9.5	2.0
02/13/2015 01:00	10.4	0.0	1.4	8.1	1.8
02/13/2015 02:00	10.3	0.3	1.4	8.1	1.8
02/13/2015 03:00	12.2	0.3	1.7	9.6	2.0
02/13/2015 04:00	10.9	0.3	1.6	8.6	1.8
02/13/2015 05:00	11.0	0.6	1.6	8.6	1.8
02/13/2015 06:00	13.3	2.0	1.9	10.5	2.2
02/13/2015 07:00	15.1	2.3	1.9	10.4	2.2
02/13/2015 08:00	10.2	0.3	1.4	8.1	1.8
02/13/2015 09:00	7.8	0.0	1.3	7.1	1.6
02/13/2015 10:00	7.8	0.0	1.3	7.1	1.6
02/13/2015 11:00	7.8	0.0	1.3	7.2	1.6
02/13/2015 12:00	9.8	0.3	1.4	7.7	1.6
02/13/2015 13:00	11.6	0.3	1.7	9.0	2.0
02/13/2015 14:00	13.1	2.3	1.9	10.3	2.2
02/13/2015 15:00	13.0	1.9	1.9	10.2	2.2
02/13/2015 16:00	13.1	1.9	1.9	10.3	2.2
02/13/2015 17:00	15.4	2.6	2.0	10.6	2.4
02/13/2015 18:00	16.0	3.3	2.0	11.0	2.4
02/13/2015 19:00	16.4	3.2	2.0	11.2	2.4
02/13/2015 20:00	16.2	3.3	2.0	11.2	2.4
02/13/2015 21:00	16.0	3.0	2.0	11.0	2.4
02/13/2015 22:00	16.2	3.3	2.0	11.1	2.4
02/13/2015 23:00	15.2	1.6	1.9	10.5	2.2
Average/Sum#:	300.9 #	33.1 #	41.2 #	227.0 #	49.0 #
Minimum:	7.8	0.0	1.3	7.1	1.6
Maximum:	16.4	3.3	2.0	11.2	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/14/2015 00:00	15.9	3.0	2.0	11.0	2.4
02/14/2015 01:00	15.7	2.6	2.0	10.8	2.4
02/14/2015 02:00	15.9	4.2	2.0	10.9	2.4
02/14/2015 03:00	15.9	3.0	2.0	10.9	2.4
02/14/2015 04:00	15.8	2.6	2.0	10.9	2.4
02/14/2015 05:00	12.9	1.6	1.9	10.2	2.2
02/14/2015 06:00	9.0	0.0	1.4	8.2	1.8
02/14/2015 07:00	7.8	0.2	1.3	7.2	1.6
02/14/2015 08:00	7.8	0.2	1.3	7.1	1.6
02/14/2015 09:00	7.8	0.2	1.3	7.2	1.6
02/14/2015 10:00	7.8	0.2	1.3	7.2	1.6
02/14/2015 11:00	9.1	0.0	1.3	7.1	1.6
02/14/2015 12:00	9.1	0.0	1.3	7.1	1.6
02/14/2015 13:00	9.1	0.0	1.3	7.1	1.6
02/14/2015 14:00	9.1	0.0	1.3	7.1	1.6
02/14/2015 15:00	9.1	0.0	1.3	7.1	1.6
02/14/2015 16:00	11.0	1.4	1.6	8.6	1.8
02/14/2015 17:00	15.2	2.6	1.9	10.4	2.2
02/14/2015 18:00	13.3	2.6	1.9	10.4	2.2
02/14/2015 19:00	16.4	3.5	2.0	11.3	2.4
02/14/2015 20:00	15.5	2.6	2.0	10.6	2.4
02/14/2015 21:00	15.4	2.6	1.9	10.6	2.4
02/14/2015 22:00	15.8	2.8	2.0	10.9	2.4
02/14/2015 23:00	10.0	0.0	1.4	7.9	1.8
Average/Sum#:	290.4 #	35.9 #	39.7 #	217.8 #	48.0 #
Minimum:	7.8	0.0	1.3	7.1	1.6
Maximum:	16.4	4.2	2.0	11.3	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/15/2015 00:00	9.8	0.0	1.4	7.7	1.6
02/15/2015 01:00	10.2	0.3	1.4	8.0	1.8
02/15/2015 02:00	6.0	8.5	0.1	0.6	0.1
02/15/2015 03:00	0.0	0.0	0.0	0.0	0.0
02/15/2015 04:00	0.0	0.0	0.0	0.0	0.0
02/15/2015 05:00	0.0	0.0	0.0	0.0	0.0
02/15/2015 06:00	0.0	0.0	0.0	0.0	0.0
02/15/2015 07:00	0.0	0.0	0.0	0.0	0.0
02/15/2015 08:00	0.0	0.0	0.0	0.0	0.0
02/15/2015 09:00	0.0	0.0	0.0	0.0	0.0
02/15/2015 10:00	50.5	22.3	0.1	1.0	0.2
02/15/2015 11:00	60.4	41.5	0.3	2.9	0.6
02/15/2015 12:00	4.0	0.0	0.4	4.0	0.8
02/15/2015 13:00	4.0	0.0	0.4	4.0	0.8
02/15/2015 14:00	6.3	0.0	0.5	4.8	1.0
02/15/2015 15:00	7.0	0.3	0.5	5.2	1.0
02/15/2015 16:00	21.0	13.2	0.6	5.5	1.1
02/15/2015 17:00	83.1	32.7	1.1	6.8	1.4
02/15/2015 18:00	8.7	0.0	1.4	7.9	1.8
02/15/2015 19:00	15.4	2.6	2.0	10.6	2.4
02/15/2015 20:00	16.0	2.5	2.0	11.0	2.4
02/15/2015 21:00	15.8	2.2	2.0	10.8	2.4
02/15/2015 22:00	15.8	2.2	2.0	10.8	2.4
02/15/2015 23:00	15.8	2.2	2.0	10.8	2.4
Average/Sum#:	349.8 #	130.5 #	18.2 #	112.4 #	24.2 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	83.1	41.5	2.0	11.0	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/16/2015 00:00	15.8	2.3	2.0	11.0	2.4
02/16/2015 01:00	15.2	1.6	1.9	10.5	2.2
02/16/2015 02:00	12.9	1.3	1.9	10.1	2.2
02/16/2015 03:00	13.0	1.3	1.9	10.1	2.2
02/16/2015 04:00	13.0	1.3	1.9	10.2	2.2
02/16/2015 05:00	15.1	1.6	1.9	10.4	2.2
02/16/2015 06:00	15.3	1.6	1.9	10.6	2.3
02/16/2015 07:00	12.9	1.2	1.9	10.2	2.2
02/16/2015 08:00	14.7	1.3	1.9	10.2	2.2
02/16/2015 09:00	14.8	1.3	1.9	10.2	2.2
02/16/2015 10:00	13.0	1.3	1.9	10.2	2.2
02/16/2015 11:00	13.0	1.3	1.9	10.2	2.2
02/16/2015 12:00	13.0	1.3	1.9	10.2	2.2
02/16/2015 13:00	10.9	0.6	1.6	8.6	1.8
02/16/2015 14:00	9.1	0.0	1.3	7.1	1.6
02/16/2015 15:00	10.8	0.6	1.6	8.5	1.8
02/16/2015 16:00	15.2	1.9	1.9	10.4	2.2
02/16/2015 17:00	15.6	2.6	2.0	10.7	2.4
02/16/2015 18:00	16.2	2.8	2.0	11.2	2.4
02/16/2015 19:00	16.2	2.8	2.0	11.2	2.4
02/16/2015 20:00	13.0	1.3	1.9	10.2	2.2
02/16/2015 21:00	13.2	1.6	1.9	10.3	2.2
02/16/2015 22:00	15.4	1.9	1.9	10.6	2.3
02/16/2015 23:00	13.0	1.3	1.9	10.1	2.2
Average/Sum#:	330.3 #	36.1 #	44.8 #	243.0 #	52.4 #
Minimum:	9.1	0.0	1.3	7.1	1.6
Maximum:	16.2	2.8	2.0	11.2	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/17/2015 00:00	13.0	1.6	1.9	10.2	2.2
02/17/2015 01:00	13.0	2.0	1.9	10.2	2.2
02/17/2015 02:00	13.0	1.3	1.9	10.2	2.2
02/17/2015 03:00	13.0	1.6	1.9	10.2	2.2
02/17/2015 04:00	13.0	1.6	1.9	10.3	2.2
02/17/2015 05:00	13.1	2.0	1.9	10.2	2.2
02/17/2015 06:00	13.1	2.0	1.9	10.3	2.2
02/17/2015 07:00	15.4	2.6	1.9	10.6	2.3
02/17/2015 08:00	12.9	2.0	1.9	10.2	2.2
02/17/2015 09:00	10.8	0.6	1.6	8.5	1.8
02/17/2015 10:00	9.8	0.0	1.4	7.7	1.6
02/17/2015 11:00	11.0	0.3	1.6	8.7	1.8
02/17/2015 12:00	10.9	0.3	1.6	8.6	1.8
02/17/2015 13:00	6.5	0.2	1.3	7.2	1.6
02/17/2015 14:00	7.8	0.2	1.3	7.1	1.6
02/17/2015 15:00	9.1	0.2	1.3	7.2	1.6
02/17/2015 16:00	11.2	0.9	1.6	8.8	2.0
02/17/2015 17:00	13.3	2.3	1.9	10.5	2.2
02/17/2015 18:00	16.2	3.5	2.0	11.1	2.4
02/17/2015 19:00	16.1	3.5	2.0	11.1	2.4
02/17/2015 20:00	15.8	2.6	2.0	10.8	2.4
02/17/2015 21:00	13.3	2.0	1.9	10.4	2.2
02/17/2015 22:00	14.7	2.4	1.9	10.1	2.2
02/17/2015 23:00	7.8	0.2	1.3	7.2	1.6
Average/Sum#:	293.8 #	35.9 #	41.8 #	227.4 #	49.1 #
Minimum:	6.5	0.0	1.3	7.1	1.6
Maximum:	16.2	3.5	2.0	11.1	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/18/2015 00:00	10.5	0.3	1.4	8.2	1.8
02/18/2015 01:00	10.7	0.3	1.6	8.3	1.8
02/18/2015 02:00	8.1	0.2	1.3	7.3	1.6
02/18/2015 03:00	7.8	0.4	1.3	7.2	1.6
02/18/2015 04:00	11.9	0.9	1.7	9.3	2.0
02/18/2015 05:00	13.2	2.0	1.9	10.4	2.2
02/18/2015 06:00	11.3	2.0	1.9	10.4	2.2
02/18/2015 07:00	15.6	2.3	2.0	10.8	2.4
02/18/2015 08:00	15.9	3.0	2.0	10.9	2.4
02/18/2015 09:00	16.0	2.7	2.0	11.0	2.4
02/18/2015 10:00	15.9	2.6	2.0	10.9	2.4
02/18/2015 11:00	12.9	2.0	1.9	10.2	2.2
02/18/2015 12:00	13.0	2.0	1.9	10.2	2.2
02/18/2015 13:00	13.0	2.0	1.9	10.2	2.2
02/18/2015 14:00	10.9	0.3	1.6	8.6	1.8
02/18/2015 15:00	10.0	0.0	1.7	9.1	2.0
02/18/2015 16:00	12.9	1.6	1.9	10.1	2.2
02/18/2015 17:00	16.0	3.3	2.0	11.0	2.4
02/18/2015 18:00	16.3	3.6	2.0	11.2	2.4
02/18/2015 19:00	16.1	3.0	2.0	11.0	2.4
02/18/2015 20:00	15.9	3.2	2.0	11.0	2.4
02/18/2015 21:00	15.9	2.6	2.0	10.9	2.4
02/18/2015 22:00	15.6	2.3	2.0	10.7	2.4
02/18/2015 23:00	13.1	2.0	1.9	10.3	2.2
Average/Sum#:	318.5 #	44.6 #	43.9 #	239.2 #	52.0 #
Minimum:	7.8	0.0	1.3	7.2	1.6
Maximum:	16.3	3.6	2.0	11.2	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/19/2015 00:00	15.7	2.9	2.0	10.8	2.4
02/19/2015 01:00	12.9	2.0	1.9	10.2	2.2
02/19/2015 02:00	8.6	0.6	1.4	7.9	1.8
02/19/2015 03:00	7.9	0.2	1.3	7.2	1.6
02/19/2015 04:00	8.7	0.6	1.4	7.9	1.8
02/19/2015 05:00	13.6	2.9	1.9	10.6	2.4
02/19/2015 06:00	15.6	2.9	2.0	10.7	2.4
02/19/2015 07:00	15.9	3.2	2.0	10.9	2.4
02/19/2015 08:00	15.9	2.6	2.0	11.0	2.4
02/19/2015 09:00	15.6	2.3	2.0	10.8	2.4
02/19/2015 10:00	16.3	3.6	2.0	11.2	2.4
02/19/2015 11:00	16.0	2.6	2.0	11.0	2.4
02/19/2015 12:00	15.6	2.3	2.0	10.8	2.4
02/19/2015 13:00	15.7	2.6	2.0	10.8	2.4
02/19/2015 14:00	13.0	2.0	1.9	10.2	2.2
02/19/2015 15:00	13.0	2.0	1.9	10.1	2.2
02/19/2015 16:00	13.1	2.0	1.9	10.3	2.2
02/19/2015 17:00	13.1	1.7	1.9	10.2	2.2
02/19/2015 18:00	15.7	2.6	2.0	10.7	2.4
02/19/2015 19:00	13.1	2.0	1.9	10.2	2.2
02/19/2015 20:00	12.9	2.0	1.9	10.2	2.2
02/19/2015 21:00	13.0	2.0	1.9	10.2	2.2
02/19/2015 22:00	13.2	2.0	1.9	10.4	2.2
02/19/2015 23:00	14.6	2.1	1.8	10.0	2.2
Average/Sum#:	328.7 #	51.7 #	44.9 #	244.3 #	53.6 #
Minimum:	7.9	0.2	1.3	7.2	1.6
Maximum:	16.3	3.6	2.0	11.2	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/20/2015 00:00	6.7	0.2	1.3	7.4	1.6
02/20/2015 01:00	5.8	11.4	0.2	0.8	0.2
02/20/2015 02:00	0.0	0.0	0.0	0.0	0.0
02/20/2015 03:00	0.0	0.0	0.0	0.0	0.0
02/20/2015 04:00	0.1	3.0	0.0	0.2	0.0
02/20/2015 05:00	21.6	34.3	0.3	3.4	0.7
02/20/2015 06:00	4.8	0.3	0.5	4.8	1.0
02/20/2015 07:00	7.2	0.3	0.5	5.4	1.1
02/20/2015 08:00	7.2	0.3	0.5	5.4	1.1
02/20/2015 09:00	7.2	0.3	0.5	5.4	1.1
02/20/2015 10:00	7.2	0.3	0.5	5.4	1.1
02/20/2015 11:00	6.9	0.3	0.5	5.2	1.0
02/20/2015 12:00	3.4	4.3	0.0	0.3	0.1
02/20/2015 13:00	0.0	0.0	0.0	0.0	0.0
02/20/2015 14:00	0.0	0.0	0.0	0.0	0.0
02/20/2015 15:00	0.0	0.0	0.0	0.0	0.0
02/20/2015 16:00	0.0	0.0	0.0	0.0	0.0
02/20/2015 17:00	0.0	0.0	0.0	0.0	0.0
02/20/2015 18:00	0.0	0.0	0.0	0.0	0.0
02/20/2015 19:00	0.0	0.0	0.0	0.0	0.0
02/20/2015 20:00	0.0	0.0	0.0	0.0	0.0
02/20/2015 21:00	0.0	0.0	0.0	0.0	0.0
02/20/2015 22:00	0.0	0.0	0.0	0.0	0.0
02/20/2015 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	78.1 #	55.0 #	4.8 #	43.7 #	9.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	21.6	34.3	1.3	7.4	1.6
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/21/2015 00:00	0.0	0.0	0.0	0.0	0.0
02/21/2015 01:00	0.0	0.0	0.0	0.0	0.0
02/21/2015 02:00	0.0	0.0	0.0	0.0	0.0
02/21/2015 03:00	0.0	0.0	0.0	0.0	0.0
02/21/2015 04:00	0.0	0.0	0.0	0.0	0.0
02/21/2015 05:00	0.0	0.0	0.0	0.0	0.0
02/21/2015 06:00	0.0	0.0	0.0	0.0	0.0
02/21/2015 07:00	0.0	0.0	0.0	0.0	0.0
02/21/2015 08:00	0.0	0.0	0.0	0.0	0.0
02/21/2015 09:00	0.0	0.0	0.0	0.0	0.0
02/21/2015 10:00	70.2	74.4	0.1	1.1	0.2
02/21/2015 11:00	54.5	67.7	0.2	2.2	0.4
02/21/2015 12:00	29.9	19.2	0.4	3.7	0.7
02/21/2015 13:00	5.1	0.0	0.4	3.8	0.8
02/21/2015 14:00	5.1	0.0	0.4	3.8	0.8
02/21/2015 15:00	61.1	169.8	0.7	5.0	1.0
02/21/2015 16:00	52.0	30.8	1.1	6.7	1.4
02/21/2015 17:00	9.0	0.3	1.6	8.3	1.8
02/21/2015 18:00	13.9	2.9	2.0	10.9	2.4
02/21/2015 19:00	16.3	2.9	2.0	11.2	2.4
02/21/2015 20:00	16.3	3.0	2.0	11.1	2.4
02/21/2015 21:00	15.9	2.3	2.0	11.0	2.4
02/21/2015 22:00	16.3	3.0	2.0	11.2	2.4
02/21/2015 23:00	15.6	2.3	2.0	10.8	2.4
Average/Sum#:	381.2 #	378.6 #	16.9 #	100.8 #	21.5 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	70.2	169.8	2.0	11.2	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/22/2015 00:00	9.8	0.0	1.4	7.7	1.6
02/22/2015 01:00	9.2	0.0	1.6	8.5	1.8
02/22/2015 02:00	9.1	0.0	1.3	7.1	1.6
02/22/2015 03:00	9.4	0.0	1.3	7.4	1.6
02/22/2015 04:00	11.1	0.0	1.6	8.8	2.0
02/22/2015 05:00	10.5	0.0	1.6	8.3	1.8
02/22/2015 06:00	2.3	4.2	0.1	0.6	0.1
02/22/2015 07:00	0.0	0.0	0.0	0.0	0.0
02/22/2015 08:00	0.0	0.0	0.0	0.0	0.0
02/22/2015 09:00	0.0	0.0	0.0	0.0	0.0
02/22/2015 10:00	0.0	0.0	0.0	0.0	0.0
02/22/2015 11:00	0.0	0.0	0.0	0.0	0.0
02/22/2015 12:00	0.0	0.0	0.0	0.0	0.0
02/22/2015 13:00	0.0	0.0	0.0	0.0	0.0
02/22/2015 14:00	71.4	25.0	0.1	1.1	0.2
02/22/2015 15:00	67.0	51.7	0.3	2.8	0.6
02/22/2015 16:00	7.1	0.0	0.5	5.3	1.1
02/22/2015 17:00	7.0	0.0	0.5	5.2	1.0
02/22/2015 18:00	7.2	0.3	0.5	5.4	1.1
02/22/2015 19:00	7.2	0.3	0.5	5.4	1.1
02/22/2015 20:00	7.3	0.3	0.5	5.4	1.1
02/22/2015 21:00	7.3	0.3	0.5	5.5	1.1
02/22/2015 22:00	8.3	6.9	0.2	1.9	0.4
02/22/2015 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	248.9 #	84.8 #	12.5 #	86.4 #	18.2 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	71.4	51.7	1.6	8.8	2.0
%SI	4.2	4.2	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/23/2015 00:00	0.0	0.0	0.0	0.0	0.0
02/23/2015 01:00	0.0	0.0	0.0	0.0	0.0
02/23/2015 02:00	0.0	0.0	0.0	0.0	0.0
02/23/2015 03:00	36.1	28.0	0.1	1.2	0.2
02/23/2015 04:00	51.5	26.3	0.4	3.9	0.8
02/23/2015 05:00	7.5	0.7	0.6	5.6	1.1
02/23/2015 06:00	8.1	1.3	0.6	6.1	1.2
02/23/2015 07:00	7.8	1.3	0.6	5.9	1.2
02/23/2015 08:00	7.2	0.3	0.5	5.4	1.1
02/23/2015 09:00	7.2	0.3	0.5	5.4	1.1
02/23/2015 10:00	7.2	0.3	0.5	5.4	1.1
02/23/2015 11:00	6.6	0.3	0.5	4.9	1.0
02/23/2015 12:00	7.3	0.3	0.5	5.4	1.1
02/23/2015 13:00	7.2	0.3	0.5	5.4	1.1
02/23/2015 14:00	6.5	0.3	0.5	4.9	1.0
02/23/2015 15:00	7.2	0.3	0.5	5.4	1.1
02/23/2015 16:00	6.7	0.3	0.5	5.0	1.0
02/23/2015 17:00	7.5	1.0	0.6	5.7	1.1
02/23/2015 18:00	8.6	1.3	0.6	6.5	1.3
02/23/2015 19:00	7.3	0.7	0.6	5.5	1.1
02/23/2015 20:00	8.7	1.3	0.7	6.5	1.3
02/23/2015 21:00	8.4	1.3	0.6	6.3	1.3
02/23/2015 22:00	7.2	0.3	0.5	5.4	1.1
02/23/2015 23:00	7.0	0.3	0.5	5.2	1.0
Average/Sum#:	228.8 #	66.5 #	10.9 #	111.0 #	22.3 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	51.5	28.0	0.7	6.5	1.3
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/24/2015 00:00	7.0	0.3	0.5	5.3	1.1
02/24/2015 01:00	7.2	0.3	0.5	5.4	1.1
02/24/2015 02:00	7.2	0.3	0.5	5.4	1.1
02/24/2015 03:00	56.3	95.9	0.7	6.0	1.3
02/24/2015 04:00	89.8	46.8	1.0	6.7	1.4
02/24/2015 05:00	63.3	7.4	1.6	9.1	2.0
02/24/2015 06:00	16.3	3.0	2.0	11.1	2.4
02/24/2015 07:00	16.2	2.7	2.0	11.1	2.4
02/24/2015 08:00	15.7	1.7	2.0	10.8	2.4
02/24/2015 09:00	10.9	0.3	1.6	8.6	1.8
02/24/2015 10:00	9.3	0.0	1.3	7.3	1.6
02/24/2015 11:00	9.1	0.0	1.3	7.1	1.6
02/24/2015 12:00	9.1	0.0	1.3	7.1	1.6
02/24/2015 13:00	9.1	0.0	1.3	7.1	1.6
02/24/2015 14:00	9.2	0.0	1.3	7.2	1.6
02/24/2015 15:00	9.6	0.0	1.4	7.5	1.6
02/24/2015 16:00	10.3	0.3	1.4	8.1	1.8
02/24/2015 17:00	15.9	3.0	2.0	10.9	2.4
02/24/2015 18:00	16.3	2.9	2.0	11.1	2.4
02/24/2015 19:00	16.2	3.0	2.0	11.1	2.4
02/24/2015 20:00	16.3	3.0	2.0	11.1	2.4
02/24/2015 21:00	16.2	3.0	2.0	11.2	2.4
02/24/2015 22:00	14.6	1.5	1.8	10.1	2.2
02/24/2015 23:00	10.5	0.0	1.4	8.2	1.8
Average/Sum#:	461.6 #	175.4 #	34.9 #	204.6 #	44.4 #
Minimum:	7.0	0.0	0.5	5.3	1.1
Maximum:	89.8	95.9	2.0	11.2	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/25/2015 00:00	9.1	0.2	1.3	7.2	1.6
02/25/2015 01:00	12.3	0.3	1.7	9.6	2.1
02/25/2015 02:00	12.1	0.3	1.7	9.5	2.0
02/25/2015 03:00	10.1	0.3	1.4	7.9	1.8
02/25/2015 04:00	9.1	0.2	1.3	7.1	1.6
02/25/2015 05:00	11.4	1.2	1.6	9.0	2.0
02/25/2015 06:00	16.0	3.0	2.0	11.0	2.4
02/25/2015 07:00	15.9	2.7	2.0	10.9	2.4
02/25/2015 08:00	13.8	0.9	1.7	9.5	2.0
02/25/2015 09:00	9.1	0.0	1.3	7.2	1.6
02/25/2015 10:00	9.1	0.0	1.3	7.1	1.6
02/25/2015 11:00	9.1	0.0	1.3	7.1	1.6
02/25/2015 12:00	9.1	0.0	1.3	7.1	1.6
02/25/2015 13:00	9.8	0.3	1.4	7.7	1.6
02/25/2015 14:00	9.1	0.0	1.3	7.1	1.6
02/25/2015 15:00	9.1	0.0	1.3	7.1	1.6
02/25/2015 16:00	10.3	0.3	1.4	8.1	1.8
02/25/2015 17:00	15.7	3.2	2.0	10.8	2.4
02/25/2015 18:00	15.9	2.9	2.0	11.0	2.4
02/25/2015 19:00	15.5	2.3	1.9	10.6	2.4
02/25/2015 20:00	15.5	2.3	1.9	10.6	2.4
02/25/2015 21:00	15.8	2.7	2.0	10.8	2.4
02/25/2015 22:00	14.3	2.1	1.8	9.8	2.2
02/25/2015 23:00	10.1	0.0	1.4	7.9	1.8
Average/Sum#:	287.3 #	25.2 #	38.3 #	211.7 #	46.9 #
Minimum:	9.1	0.0	1.3	7.1	1.6
Maximum:	16.0	3.2	2.0	11.0	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/26/2015 00:00	9.1	0.0	1.3	7.1	1.6
02/26/2015 01:00	9.1	0.2	1.3	7.2	1.6
02/26/2015 02:00	14.0	0.3	1.7	9.7	2.2
02/26/2015 03:00	14.4	0.3	1.8	9.8	2.2
02/26/2015 04:00	12.3	0.9	1.7	9.6	2.1
02/26/2015 05:00	15.5	2.3	2.0	10.7	2.4
02/26/2015 06:00	15.6	2.3	2.0	10.8	2.4
02/26/2015 07:00	15.8	2.6	2.0	10.8	2.4
02/26/2015 08:00	13.0	0.6	1.6	9.0	2.0
02/26/2015 09:00	9.6	0.0	1.4	7.5	1.6
02/26/2015 10:00	11.7	0.0	1.7	9.2	2.0
02/26/2015 11:00	11.9	0.0	1.7	9.3	2.0
02/26/2015 12:00	9.1	0.0	1.3	7.2	1.6
02/26/2015 13:00	9.1	0.0	1.3	7.1	1.6
02/26/2015 14:00	9.1	0.0	1.3	7.1	1.6
02/26/2015 15:00	10.3	0.3	1.4	8.1	1.8
02/26/2015 16:00	12.6	2.4	1.8	9.9	2.2
02/26/2015 17:00	15.7	2.9	2.0	10.9	2.4
02/26/2015 18:00	16.3	3.1	2.0	11.3	2.4
02/26/2015 19:00	16.3	2.8	2.0	11.3	2.4
02/26/2015 20:00	16.1	2.9	2.0	11.1	2.4
02/26/2015 21:00	15.9	2.9	2.0	11.0	2.4
02/26/2015 22:00	11.0	0.6	1.6	8.6	1.8
02/26/2015 23:00	7.7	0.0	1.3	7.1	1.6
Average/Sum#:	301.2 #	27.4 #	40.2 #	221.4 #	48.7 #
Minimum:	7.7	0.0	1.3	7.1	1.6
Maximum:	16.3	3.1	2.0	11.3	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/27/2015 00:00	12.0	0.3	1.7	9.5	2.0
02/27/2015 01:00	14.3	0.3	1.8	9.9	2.2
02/27/2015 02:00	14.2	0.3	1.7	9.7	2.2
02/27/2015 03:00	10.5	0.3	1.4	8.2	1.8
02/27/2015 04:00	7.8	0.2	1.3	7.1	1.6
02/27/2015 05:00	10.3	0.6	1.4	8.1	1.8
02/27/2015 06:00	16.0	3.3	2.0	11.0	2.4
02/27/2015 07:00	14.4	2.7	1.8	9.9	2.2
02/27/2015 08:00	7.8	0.0	1.3	7.2	1.6
02/27/2015 09:00	7.7	0.0	1.3	7.1	1.6
02/27/2015 10:00	9.1	0.0	1.3	7.1	1.6
02/27/2015 11:00	10.5	0.3	1.4	8.2	1.8
02/27/2015 12:00	7.8	0.0	1.3	7.1	1.6
02/27/2015 13:00	7.8	0.2	1.3	7.1	1.6
02/27/2015 14:00	9.1	0.2	1.3	7.1	1.6
02/27/2015 15:00	9.5	0.3	1.3	7.5	1.6
02/27/2015 16:00	10.1	0.3	1.4	8.0	1.8
02/27/2015 17:00	11.7	2.1	1.7	9.1	2.0
02/27/2015 18:00	16.4	3.9	2.0	11.3	2.4
02/27/2015 19:00	16.4	3.6	2.0	11.3	2.4
02/27/2015 20:00	16.4	3.3	2.0	11.3	2.4
02/27/2015 21:00	16.4	3.6	2.0	11.3	2.4
02/27/2015 22:00	16.3	3.6	2.0	11.2	2.4
02/27/2015 23:00	11.2	0.6	1.6	8.8	2.0
Average/Sum#:	283.7 #	30.0 #	38.3 #	214.1 #	47.0 #
Minimum:	7.7	0.0	1.3	7.1	1.6
Maximum:	16.4	3.9	2.0	11.3	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/28/2015 00:00	9.0	0.0	1.3	7.1	1.6
02/28/2015 01:00	6.7	8.7	0.1	0.7	0.2
02/28/2015 02:00	0.0	0.0	0.0	0.0	0.0
02/28/2015 03:00	0.0	0.0	0.0	0.0	0.0
02/28/2015 04:00	0.0	0.0	0.0	0.0	0.0
02/28/2015 05:00	0.0	0.0	0.0	0.0	0.0
02/28/2015 06:00	0.0	0.0	0.0	0.0	0.0
02/28/2015 07:00	0.0	0.0	0.0	0.0	0.0
02/28/2015 08:00	22.6	30.0	0.3	1.0	0.2
02/28/2015 09:00	33.5	31.0	0.8	2.9	0.7
02/28/2015 10:00	4.8	0.0	1.1	4.0	1.0
02/28/2015 11:00	7.3	0.0	1.3	4.5	1.1
02/28/2015 12:00	4.8	0.0	1.1	4.0	1.0
02/28/2015 13:00	4.6	0.0	1.1	3.8	0.9
02/28/2015 14:00	16.2	12.9	1.2	4.7	1.1
02/28/2015 15:00	113.7	38.2	1.3	6.3	1.4
02/28/2015 16:00	9.6	0.6	1.6	8.8	2.0
02/28/2015 17:00	16.1	3.6	2.0	11.1	2.4
02/28/2015 18:00	16.3	3.6	2.0	11.2	2.4
02/28/2015 19:00	16.3	3.3	2.0	11.2	2.4
02/28/2015 20:00	16.4	3.3	2.0	11.2	2.4
02/28/2015 21:00	16.3	3.3	2.0	11.3	2.4
02/28/2015 22:00	16.3	3.3	2.0	11.3	2.4
02/28/2015 23:00	16.1	3.0	2.0	11.1	2.4
Average/Sum#:	346.6 #	144.8 #	25.2 #	126.2 #	28.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	113.7	38.2	2.0	11.3	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/01/2015 00:00	16.0	2.7	2.0	11.0	2.4
03/01/2015 01:00	14.8	1.3	1.9	10.1	2.2
03/01/2015 02:00	11.1	0.0	1.6	8.8	2.0
03/01/2015 03:00	11.6	0.0	1.7	9.2	2.0
03/01/2015 04:00	9.6	0.0	1.4	7.5	1.6
03/01/2015 05:00	13.9	0.0	1.7	9.6	2.0
03/01/2015 06:00	14.3	0.0	1.8	9.8	2.2
03/01/2015 07:00	14.6	0.0	1.8	10.0	2.2
03/01/2015 08:00	15.0	1.7	1.9	10.3	2.2
03/01/2015 09:00	16.4	3.3	2.0	11.3	2.4
03/01/2015 10:00	16.4	3.3	2.0	11.3	2.4
03/01/2015 11:00	16.4	3.3	2.0	11.3	2.4
03/01/2015 12:00	16.4	3.3	2.0	11.3	2.4
03/01/2015 13:00	15.9	2.3	2.0	11.0	2.4
03/01/2015 14:00	16.2	2.6	2.0	11.2	2.4
03/01/2015 15:00	16.4	2.9	2.0	11.3	2.4
03/01/2015 16:00	16.2	2.6	2.0	11.2	2.4
03/01/2015 17:00	16.4	3.3	2.0	11.3	2.4
03/01/2015 18:00	16.4	2.9	2.0	11.3	2.4
03/01/2015 19:00	16.4	3.3	2.0	11.3	2.4
03/01/2015 20:00	16.4	3.3	2.0	11.3	2.4
03/01/2015 21:00	16.4	3.3	2.0	11.3	2.4
03/01/2015 22:00	16.3	3.0	2.0	11.2	2.4
03/01/2015 23:00	16.1	3.0	2.0	11.1	2.4
Average/Sum#:	365.6 #	51.4 #	45.8 #	255.0 #	54.8 #
Minimum:	9.6	0.0	1.4	7.5	1.6
Maximum:	16.4	3.3	2.0	11.3	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/02/2015 00:00	16.1	3.0	2.0	11.1	2.4
03/02/2015 01:00	16.3	3.3	2.0	11.3	2.4
03/02/2015 02:00	16.1	3.0	2.0	11.1	2.4
03/02/2015 03:00	15.6	1.7	2.0	10.8	2.4
03/02/2015 04:00	12.7	1.3	1.8	9.9	2.2
03/02/2015 05:00	15.9	3.0	2.0	10.9	2.4
03/02/2015 06:00	16.0	3.6	2.0	11.0	2.4
03/02/2015 07:00	16.3	3.9	2.0	11.3	2.4
03/02/2015 08:00	16.2	3.6	2.0	11.1	2.4
03/02/2015 09:00	16.2	3.3	2.0	11.1	2.4
03/02/2015 10:00	16.0	3.0	2.0	11.0	2.4
03/02/2015 11:00	15.8	2.4	2.0	10.8	2.4
03/02/2015 12:00	16.0	3.0	2.0	11.0	2.4
03/02/2015 13:00	16.0	3.0	2.0	11.0	2.4
03/02/2015 14:00	13.6	0.6	1.7	9.3	2.0
03/02/2015 15:00	11.4	0.0	1.6	8.9	2.0
03/02/2015 16:00	14.6	1.6	1.8	10.1	2.2
03/02/2015 17:00	15.4	2.0	1.9	10.6	2.4
03/02/2015 18:00	15.4	1.7	2.0	10.6	2.4
03/02/2015 19:00	15.5	1.7	2.0	10.6	2.4
03/02/2015 20:00	15.6	1.7	2.0	10.7	2.4
03/02/2015 21:00	15.6	1.7	2.0	10.8	2.4
03/02/2015 22:00	14.4	1.2	1.8	9.9	2.2
03/02/2015 23:00	10.8	0.0	1.6	8.5	1.8
Average/Sum#:	363.5 #	53.3 #	46.2 #	253.4 #	55.6 #
Minimum:	10.8	0.0	1.6	8.5	1.8
Maximum:	16.3	3.9	2.0	11.3	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/03/2015 00:00	7.8	0.0	1.3	7.1	1.6
03/03/2015 01:00	7.8	0.0	1.3	7.1	1.6
03/03/2015 02:00	7.8	0.0	1.3	7.1	1.6
03/03/2015 03:00	7.8	0.2	1.3	7.1	1.6
03/03/2015 04:00	11.0	1.2	1.6	8.6	1.8
03/03/2015 05:00	16.0	3.3	2.0	11.0	2.4
03/03/2015 06:00	16.3	3.3	2.0	11.2	2.4
03/03/2015 07:00	15.9	3.0	2.0	11.0	2.4
03/03/2015 08:00	11.2	0.6	1.6	8.8	2.0
03/03/2015 09:00	9.1	0.0	1.3	7.1	1.6
03/03/2015 10:00	9.1	0.0	1.3	7.1	1.6
03/03/2015 11:00	9.1	0.0	1.3	7.1	1.6
03/03/2015 12:00	9.1	0.0	1.3	7.1	1.6
03/03/2015 13:00	9.1	0.0	1.3	7.1	1.6
03/03/2015 14:00	9.1	0.0	1.3	7.1	1.6
03/03/2015 15:00	9.1	0.0	1.3	7.1	1.6
03/03/2015 16:00	9.8	0.3	1.4	7.7	1.6
03/03/2015 17:00	15.6	2.3	2.0	10.7	2.4
03/03/2015 18:00	16.1	3.0	2.0	11.0	2.4
03/03/2015 19:00	16.4	3.3	2.0	11.3	2.4
03/03/2015 20:00	16.4	3.3	2.0	11.2	2.4
03/03/2015 21:00	16.4	3.3	2.0	11.3	2.4
03/03/2015 22:00	16.1	3.0	2.0	11.0	2.4
03/03/2015 23:00	13.8	0.6	1.7	9.4	2.0
Average/Sum#:	285.9 #	30.7 #	38.6 #	212.3 #	46.6 #
Minimum:	7.8	0.0	1.3	7.1	1.6
Maximum:	16.4	3.3	2.0	11.3	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/04/2015 00:00	12.7	0.0	1.8	9.9	2.2
03/04/2015 01:00	12.5	0.0	1.8	9.8	2.2
03/04/2015 02:00	12.1	0.0	1.7	9.5	2.0
03/04/2015 03:00	12.3	0.0	1.7	9.7	2.2
03/04/2015 04:00	14.5	1.6	1.8	9.9	2.2
03/04/2015 05:00	16.1	3.0	2.0	11.1	2.4
03/04/2015 06:00	16.1	2.7	2.0	11.1	2.4
03/04/2015 07:00	16.0	3.0	2.0	11.0	2.4
03/04/2015 08:00	13.8	2.3	2.0	10.8	2.4
03/04/2015 09:00	10.2	0.3	1.4	7.9	1.8
03/04/2015 10:00	9.1	0.2	1.3	7.1	1.6
03/04/2015 11:00	9.1	0.2	1.3	7.1	1.6
03/04/2015 12:00	9.1	0.2	1.3	7.1	1.6
03/04/2015 13:00	9.1	0.2	1.3	7.1	1.6
03/04/2015 14:00	9.1	0.2	1.3	7.1	1.6
03/04/2015 15:00	9.1	0.2	1.3	7.1	1.6
03/04/2015 16:00	10.8	1.2	1.6	8.6	1.8
03/04/2015 17:00	16.1	3.9	2.0	11.1	2.4
03/04/2015 18:00	16.3	3.3	2.0	11.3	2.4
03/04/2015 19:00	16.3	3.3	2.0	11.3	2.4
03/04/2015 20:00	16.3	3.3	2.0	11.3	2.4
03/04/2015 21:00	16.2	3.0	2.0	11.1	2.4
03/04/2015 22:00	16.2	3.3	2.0	11.1	2.4
03/04/2015 23:00	15.8	2.4	2.0	10.9	2.4
Average/Sum#:	314.9 #	37.8 #	41.6 #	230.0 #	50.4 #
Minimum:	9.1	0.0	1.3	7.1	1.6
Maximum:	16.3	3.9	2.0	11.3	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/05/2015 00:00	14.5	1.6	1.8	9.9	2.2
03/05/2015 01:00	11.2	0.3	1.6	8.8	2.0
03/05/2015 02:00	10.8	0.3	1.6	8.5	1.8
03/05/2015 03:00	11.4	0.3	1.6	9.0	2.0
03/05/2015 04:00	12.3	0.9	1.7	9.7	2.2
03/05/2015 05:00	16.0	3.3	2.0	11.0	2.4
03/05/2015 06:00	14.2	3.7	2.0	11.1	2.4
03/05/2015 07:00	16.2	3.3	2.0	11.1	2.4
03/05/2015 08:00	13.6	2.3	2.0	10.8	2.4
03/05/2015 09:00	8.3	0.3	1.4	7.6	1.6
03/05/2015 10:00	7.8	0.2	1.3	7.1	1.6
03/05/2015 11:00	9.1	0.2	1.3	7.1	1.6
03/05/2015 12:00	9.1	0.2	1.3	7.1	1.6
03/05/2015 13:00	9.1	0.2	1.3	7.1	1.6
03/05/2015 14:00	9.1	0.2	1.3	7.1	1.6
03/05/2015 15:00	9.1	0.2	1.3	7.1	1.6
03/05/2015 16:00	10.8	0.9	1.6	8.5	1.8
03/05/2015 17:00	16.3	3.9	2.0	11.2	2.4
03/05/2015 18:00	16.3	3.6	2.0	11.3	2.4
03/05/2015 19:00	16.3	3.6	2.0	11.3	2.4
03/05/2015 20:00	16.3	3.6	2.0	11.3	2.4
03/05/2015 21:00	16.3	3.6	2.0	11.1	2.4
03/05/2015 22:00	16.1	3.3	2.0	11.1	2.4
03/05/2015 23:00	12.2	1.5	1.7	9.7	2.1
Average/Sum#:	302.4 #	41.5 #	40.8 #	225.6 #	49.3 #
Minimum:	7.8	0.2	1.3	7.1	1.6
Maximum:	16.3	3.9	2.0	11.3	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/06/2015 00:00	7.8	0.2	1.3	7.1	1.6
03/06/2015 01:00	7.8	0.2	1.3	7.1	1.6
03/06/2015 02:00	7.8	0.2	1.3	7.1	1.6
03/06/2015 03:00	7.8	0.2	1.3	7.1	1.6
03/06/2015 04:00	7.8	0.4	1.3	7.1	1.6
03/06/2015 05:00	11.0	1.5	1.6	8.6	1.8
03/06/2015 06:00	14.0	3.6	2.0	11.0	2.4
03/06/2015 07:00	15.7	2.7	2.0	10.8	2.4
03/06/2015 08:00	13.6	2.0	2.0	10.8	2.4
03/06/2015 09:00	13.6	2.7	2.0	10.7	2.4
03/06/2015 10:00	11.2	0.9	1.6	8.8	2.0
03/06/2015 11:00	9.1	0.2	1.3	7.1	1.6
03/06/2015 12:00	9.1	0.2	1.3	7.1	1.6
03/06/2015 13:00	9.1	0.2	1.3	7.1	1.6
03/06/2015 14:00	9.1	0.2	1.3	7.1	1.6
03/06/2015 15:00	9.1	0.2	1.3	7.1	1.6
03/06/2015 16:00	10.8	1.2	1.6	8.4	1.8
03/06/2015 17:00	16.1	3.8	2.0	11.1	2.4
03/06/2015 18:00	16.5	3.2	2.0	11.3	2.4
03/06/2015 19:00	16.5	3.2	2.0	11.3	2.4
03/06/2015 20:00	16.4	3.2	2.0	11.3	2.4
03/06/2015 21:00	16.1	3.0	2.0	11.0	2.4
03/06/2015 22:00	16.0	3.3	2.0	11.0	2.4
03/06/2015 23:00	16.0	2.9	2.0	11.0	2.4
Average/Sum#:	288.0 #	39.4 #	39.8 #	218.1 #	48.0 #
Minimum:	7.8	0.2	1.3	7.1	1.6
Maximum:	16.5	3.8	2.0	11.3	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/07/2015 00:00	15.0	2.2	1.9	10.3	2.2
03/07/2015 01:00	13.8	0.3	1.7	9.5	2.0
03/07/2015 02:00	6.0	8.3	0.1	0.5	0.2
03/07/2015 03:00	0.0	0.0	0.0	0.0	0.0
03/07/2015 04:00	0.0	0.0	0.0	0.0	0.0
03/07/2015 05:00	0.0	0.0	0.0	0.0	0.0
03/07/2015 06:00	0.0	0.0	0.0	0.0	0.0
03/07/2015 07:00	0.0	0.0	0.0	0.0	0.0
03/07/2015 08:00	0.0	0.0	0.0	0.0	0.0
03/07/2015 09:00	0.0	0.0	0.0	0.0	0.0
03/07/2015 10:00	32.1	35.9	0.3	1.0	0.2
03/07/2015 11:00	46.0	58.6	0.7	2.5	0.6
03/07/2015 12:00	7.0	0.0	1.2	4.4	1.1
03/07/2015 13:00	7.0	0.0	1.2	4.4	1.1
03/07/2015 14:00	67.5	27.0	1.3	5.3	1.2
03/07/2015 15:00	71.3	55.4	1.3	6.3	1.4
03/07/2015 16:00	13.6	1.5	1.7	9.4	2.0
03/07/2015 17:00	16.4	3.4	2.0	11.3	2.4
03/07/2015 18:00	16.1	3.2	2.0	11.1	2.4
03/07/2015 19:00	16.5	3.2	2.0	11.3	2.4
03/07/2015 20:00	16.5	2.9	2.0	11.3	2.4
03/07/2015 21:00	16.1	2.6	2.0	11.1	2.4
03/07/2015 22:00	16.0	3.3	2.0	11.0	2.4
03/07/2015 23:00	14.3	1.8	1.8	9.8	2.2
Average/Sum#:	391.2 #	209.6 #	25.2 #	130.5 #	28.6 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	71.3	58.6	2.0	11.3	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/08/2015 00:00	9.0	0.2	1.3	7.1	1.6
03/08/2015 01:00	9.0	0.2	1.3	7.1	1.6
03/08/2015 02:00	9.1	0.2	1.3	7.1	1.6
03/08/2015 03:00	9.1	0.2	1.3	7.1	1.6
03/08/2015 04:00	9.1	0.2	1.3	7.1	1.6
03/08/2015 05:00	9.1	0.5	1.3	7.1	1.6
03/08/2015 06:00	7.8	0.7	1.3	7.1	1.6
03/08/2015 07:00	9.1	0.4	1.3	7.1	1.6
03/08/2015 08:00	6.1	9.7	0.1	0.7	0.2
03/08/2015 09:00	0.0	0.0	0.0	0.0	0.0
03/08/2015 10:00	7.4	26.0	0.1	1.2	0.2
03/08/2015 11:00	31.1	40.6	0.3	3.3	0.7
03/08/2015 12:00	4.2	0.3	0.4	4.2	0.8
03/08/2015 13:00	5.6	0.3	0.4	4.2	0.8
03/08/2015 14:00	6.0	0.3	0.5	4.5	0.9
03/08/2015 15:00	38.7	67.2	0.9	5.9	1.2
03/08/2015 16:00	29.9	1.9	1.3	7.2	1.6
03/08/2015 17:00	7.8	0.2	1.3	7.1	1.6
03/08/2015 18:00	11.6	1.8	1.7	9.1	2.0
03/08/2015 19:00	14.9	2.8	1.9	10.2	2.3
03/08/2015 20:00	14.3	2.2	1.8	9.8	2.1
03/08/2015 21:00	9.6	0.5	1.3	7.6	1.7
03/08/2015 22:00	9.1	0.2	1.3	7.1	1.6
03/08/2015 23:00	9.1	0.5	1.3	7.1	1.6
Average/Sum#:	276.7 #	157.1 #	25.0 #	146.0 #	32.1 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	38.7	67.2	1.9	10.2	2.3
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/09/2015 00:00	9.1	0.5	1.3	7.1	1.6
03/09/2015 01:00	9.0	0.5	1.3	7.1	1.6
03/09/2015 02:00	9.0	0.5	1.3	7.1	1.6
03/09/2015 03:00	9.0	0.5	1.3	7.1	1.6
03/09/2015 04:00	9.8	0.8	1.4	7.7	1.6
03/09/2015 05:00	16.0	4.2	2.0	11.0	2.4
03/09/2015 06:00	16.4	4.3	2.0	11.3	2.4
03/09/2015 07:00	15.7	3.3	2.0	10.8	2.4
03/09/2015 08:00	15.6	2.6	2.0	10.7	2.4
03/09/2015 09:00	8.0	0.2	1.3	7.3	1.6
03/09/2015 10:00	9.1	0.2	1.3	7.1	1.6
03/09/2015 11:00	9.1	0.2	1.3	7.1	1.6
03/09/2015 12:00	9.1	0.2	1.3	7.1	1.6
03/09/2015 13:00	9.1	0.2	1.3	7.1	1.6
03/09/2015 14:00	11.4	1.2	1.6	8.9	2.0
03/09/2015 15:00	9.1	0.2	1.3	7.1	1.6
03/09/2015 16:00	9.1	0.2	1.3	7.1	1.6
03/09/2015 17:00	12.1	2.7	1.7	9.5	2.0
03/09/2015 18:00	16.4	3.8	2.0	11.3	2.4
03/09/2015 19:00	16.4	3.9	2.0	11.3	2.4
03/09/2015 20:00	16.2	3.5	2.0	11.1	2.4
03/09/2015 21:00	15.7	2.9	2.0	10.9	2.4
03/09/2015 22:00	14.1	3.6	2.0	11.0	2.4
03/09/2015 23:00	15.7	2.9	2.0	10.8	2.4
Average/Sum#:	290.2 #	43.1 #	39.0 #	214.6 #	47.2 #
Minimum:	8.0	0.2	1.3	7.1	1.6
Maximum:	16.4	4.3	2.0	11.3	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/10/2015 00:00	15.5	2.6	1.9	10.7	2.4
03/10/2015 01:00	15.9	3.2	2.0	10.9	2.4
03/10/2015 02:00	15.5	2.6	1.9	10.6	2.3
03/10/2015 03:00	15.5	2.6	1.9	10.6	2.4
03/10/2015 04:00	15.6	3.0	2.0	10.8	2.4
03/10/2015 05:00	16.1	3.6	2.0	11.0	2.4
03/10/2015 06:00	16.4	4.0	2.0	11.2	2.4
03/10/2015 07:00	16.0	3.6	2.0	11.0	2.4
03/10/2015 08:00	12.6	1.9	1.8	9.9	2.2
03/10/2015 09:00	7.0	0.3	1.4	7.7	1.6
03/10/2015 10:00	7.8	0.2	1.3	7.1	1.6
03/10/2015 11:00	9.1	0.2	1.3	7.1	1.6
03/10/2015 12:00	9.1	0.2	1.3	7.1	1.6
03/10/2015 13:00	9.1	0.2	1.3	7.1	1.6
03/10/2015 14:00	9.1	0.2	1.3	7.1	1.6
03/10/2015 15:00	9.1	0.2	1.3	7.1	1.6
03/10/2015 16:00	9.8	0.8	1.4	7.7	1.6
03/10/2015 17:00	16.3	4.5	2.0	11.2	2.4
03/10/2015 18:00	16.3	4.2	2.0	11.3	2.4
03/10/2015 19:00	16.4	3.9	2.0	11.3	2.4
03/10/2015 20:00	16.3	3.9	2.0	11.3	2.4
03/10/2015 21:00	16.0	3.5	2.0	11.0	2.4
03/10/2015 22:00	11.7	1.5	1.7	9.2	2.0
03/10/2015 23:00	6.5	0.2	1.3	7.1	1.6
Average/Sum#:	308.7 #	51.1 #	41.1 #	227.1 #	49.7 #
Minimum:	6.5	0.2	1.3	7.1	1.6
Maximum:	16.4	4.5	2.0	11.3	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/11/2015 00:00	7.8	0.2	1.3	7.1	1.6
03/11/2015 01:00	7.8	0.4	1.3	7.1	1.6
03/11/2015 02:00	7.8	0.7	1.3	7.1	1.6
03/11/2015 03:00	9.1	0.5	1.3	7.1	1.6
03/11/2015 04:00	9.8	0.8	1.4	7.7	1.6
03/11/2015 05:00	15.5	3.3	2.0	10.7	2.4
03/11/2015 06:00	15.8	3.3	2.0	10.9	2.4
03/11/2015 07:00	14.3	3.9	2.0	11.2	2.4
03/11/2015 08:00	16.4	3.9	2.0	11.2	2.4
03/11/2015 09:00	16.4	3.6	2.0	11.2	2.4
03/11/2015 10:00	16.4	3.6	2.0	11.3	2.4
03/11/2015 11:00	14.3	3.6	2.0	11.3	2.4
03/11/2015 12:00	14.3	3.6	2.0	11.3	2.4
03/11/2015 13:00	14.3	3.6	2.0	11.3	2.4
03/11/2015 14:00	14.3	3.6	2.0	11.3	2.4
03/11/2015 15:00	14.3	3.6	2.0	11.3	2.4
03/11/2015 16:00	14.3	3.6	2.0	11.3	2.4
03/11/2015 17:00	13.8	2.3	2.0	10.8	2.4
03/11/2015 18:00	14.3	3.6	2.0	11.3	2.4
03/11/2015 19:00	14.4	3.6	2.0	11.3	2.4
03/11/2015 20:00	14.0	3.0	2.0	11.0	2.4
03/11/2015 21:00	11.3	0.9	1.6	8.8	2.0
03/11/2015 22:00	7.8	0.2	1.3	7.1	1.6
03/11/2015 23:00	7.8	0.2	1.3	7.1	1.6
Average/Sum#:	306.3 #	59.6 #	42.8 #	237.8 #	51.6 #
Minimum:	7.8	0.2	1.3	7.1	1.6
Maximum:	16.4	3.9	2.0	11.3	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/12/2015 00:00	7.8	0.2	1.3	7.2	1.6
03/12/2015 01:00	7.8	0.2	1.3	7.2	1.6
03/12/2015 02:00	7.8	0.4	1.3	7.2	1.6
03/12/2015 03:00	7.8	0.4	1.3	7.2	1.6
03/12/2015 04:00	8.6	0.6	1.4	7.9	1.8
03/12/2015 05:00	15.6	3.0	2.0	10.7	2.4
03/12/2015 06:00	16.3	4.2	2.0	11.3	2.4
03/12/2015 07:00	16.3	3.9	2.0	11.3	2.4
03/12/2015 08:00	15.9	3.0	2.0	11.0	2.4
03/12/2015 09:00	15.6	2.3	2.0	10.8	2.4
03/12/2015 10:00	15.5	2.3	1.9	10.6	2.4
03/12/2015 11:00	6.8	0.3	1.3	7.5	1.6
03/12/2015 12:00	9.1	0.2	1.3	7.1	1.6
03/12/2015 13:00	9.1	0.2	1.3	7.1	1.6
03/12/2015 14:00	9.1	0.2	1.3	7.1	1.6
03/12/2015 15:00	9.1	0.2	1.3	7.1	1.6
03/12/2015 16:00	10.7	0.9	1.6	8.4	1.8
03/12/2015 17:00	14.3	4.2	2.0	11.2	2.4
03/12/2015 18:00	16.4	3.9	2.0	11.3	2.4
03/12/2015 19:00	16.4	3.9	2.0	11.3	2.4
03/12/2015 20:00	16.5	3.9	2.0	11.3	2.4
03/12/2015 21:00	16.3	3.9	2.0	11.3	2.4
03/12/2015 22:00	12.5	2.1	1.7	9.9	2.2
03/12/2015 23:00	9.6	0.3	1.4	7.6	1.6
Average/Sum#:	290.9 #	44.7 #	39.7 #	220.6 #	48.2 #
Minimum:	6.8	0.2	1.3	7.1	1.6
Maximum:	16.5	4.2	2.0	11.3	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/13/2015 00:00	9.6	0.3	1.4	7.6	1.6
03/13/2015 01:00	8.5	0.3	1.4	7.7	1.6
03/13/2015 02:00	10.7	0.3	1.6	8.4	1.8
03/13/2015 03:00	8.4	0.3	1.4	7.7	1.6
03/13/2015 04:00	10.9	1.2	1.6	8.6	1.8
03/13/2015 05:00	15.9	3.0	2.0	10.9	2.4
03/13/2015 06:00	16.1	3.3	2.0	11.1	2.4
03/13/2015 07:00	15.5	1.7	1.9	10.6	2.3
03/13/2015 08:00	15.5	1.7	1.9	10.6	2.4
03/13/2015 09:00	15.5	2.0	1.9	10.6	2.4
03/13/2015 10:00	11.4	0.9	1.6	9.0	2.0
03/13/2015 11:00	9.1	0.2	1.3	7.1	1.6
03/13/2015 12:00	9.8	0.3	1.4	7.7	1.6
03/13/2015 13:00	13.9	3.6	2.0	10.9	2.4
03/13/2015 14:00	13.9	3.2	2.0	10.9	2.4
03/13/2015 15:00	16.3	3.5	2.0	11.2	2.4
03/13/2015 16:00	16.4	3.5	2.0	11.3	2.4
03/13/2015 17:00	16.4	3.5	2.0	11.3	2.4
03/13/2015 18:00	16.4	3.5	2.0	11.3	2.4
03/13/2015 19:00	16.3	3.5	2.0	11.2	2.4
03/13/2015 20:00	16.3	3.5	2.0	11.3	2.4
03/13/2015 21:00	16.1	3.2	2.0	11.1	2.4
03/13/2015 22:00	16.2	3.5	2.0	11.1	2.4
03/13/2015 23:00	16.3	3.5	2.0	11.2	2.4
Average/Sum#:	331.4 #	53.5 #	43.4 #	240.4 #	51.9 #
Minimum:	8.4	0.2	1.3	7.1	1.6
Maximum:	16.4	3.6	2.0	11.3	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/14/2015 00:00	13.9	3.2	2.0	11.0	2.4
03/14/2015 01:00	15.9	3.2	2.0	11.0	2.4
03/14/2015 02:00	15.9	3.2	2.0	10.9	2.4
03/14/2015 03:00	15.5	2.3	1.9	10.7	2.4
03/14/2015 04:00	15.5	2.0	1.9	10.6	2.4
03/14/2015 05:00	15.5	2.0	1.9	10.7	2.4
03/14/2015 06:00	16.3	3.9	2.0	11.3	2.4
03/14/2015 07:00	14.1	3.6	2.0	11.1	2.4
03/14/2015 08:00	15.7	2.6	2.0	10.8	2.4
03/14/2015 09:00	15.7	2.6	2.0	10.8	2.4
03/14/2015 10:00	15.7	2.6	2.0	10.8	2.4
03/14/2015 11:00	15.8	2.6	2.0	10.8	2.4
03/14/2015 12:00	16.4	3.9	2.0	11.2	2.4
03/14/2015 13:00	16.4	3.5	2.0	11.3	2.4
03/14/2015 14:00	16.4	3.1	2.0	11.3	2.4
03/14/2015 15:00	16.2	3.1	2.0	11.1	2.4
03/14/2015 16:00	16.5	3.1	2.0	11.3	2.4
03/14/2015 17:00	16.4	3.1	2.0	11.3	2.4
03/14/2015 18:00	16.4	3.1	2.0	11.3	2.4
03/14/2015 19:00	16.4	3.1	2.0	11.3	2.4
03/14/2015 20:00	16.4	3.1	2.0	11.3	2.4
03/14/2015 21:00	16.4	3.5	2.0	11.3	2.4
03/14/2015 22:00	16.4	3.5	2.0	11.3	2.4
03/14/2015 23:00	14.1	3.5	2.0	11.1	2.4
Average/Sum#:	379.9 #	73.4 #	47.7 #	265.6 #	57.6 #
Minimum:	13.9	2.0	1.9	10.6	2.4
Maximum:	16.5	3.9	2.0	11.3	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/15/2015 00:00	15.7	2.6	2.0	10.8	2.4
03/15/2015 01:00	14.0	3.2	2.0	11.0	2.4
03/15/2015 02:00	12.7	1.5	1.8	10.0	2.2
03/15/2015 03:00	12.4	0.3	1.7	9.7	2.2
03/15/2015 04:00	12.5	0.3	1.7	9.9	2.2
03/15/2015 05:00	12.4	0.3	1.7	9.7	2.2
03/15/2015 06:00	12.6	0.3	1.7	9.9	2.2
03/15/2015 07:00	9.4	0.3	1.6	8.6	1.8
03/15/2015 08:00	7.8	0.2	1.3	7.1	1.6
03/15/2015 09:00	9.1	0.2	1.3	7.1	1.6
03/15/2015 10:00	9.1	0.2	1.3	7.1	1.6
03/15/2015 11:00	11.0	0.3	1.6	8.6	1.8
03/15/2015 12:00	12.4	0.3	1.7	9.7	2.2
03/15/2015 13:00	15.4	3.2	1.9	10.6	2.4
03/15/2015 14:00	16.5	3.9	2.0	11.3	2.4
03/15/2015 15:00	16.3	3.6	2.0	11.3	2.4
03/15/2015 16:00	16.3	3.6	2.0	11.3	2.4
03/15/2015 17:00	16.3	3.6	2.0	11.3	2.4
03/15/2015 18:00	16.3	3.6	2.0	11.3	2.4
03/15/2015 19:00	16.3	3.6	2.0	11.3	2.4
03/15/2015 20:00	14.3	3.6	2.0	11.3	2.4
03/15/2015 21:00	16.3	3.6	2.0	11.2	2.4
03/15/2015 22:00	12.9	2.2	1.9	10.2	2.2
03/15/2015 23:00	7.8	0.2	1.3	7.1	1.6
Average/Sum#:	315.8 #	44.7 #	42.5 #	237.4 #	51.8 #
Minimum:	7.8	0.2	1.3	7.1	1.6
Maximum:	16.5	3.9	2.0	11.3	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/16/2015 00:00	7.8	0.2	1.3	7.1	1.6
03/16/2015 01:00	7.8	0.2	1.3	7.1	1.6
03/16/2015 02:00	7.8	0.2	1.3	7.1	1.6
03/16/2015 03:00	9.1	0.2	1.3	7.1	1.6
03/16/2015 04:00	10.9	1.2	1.6	8.6	1.8
03/16/2015 05:00	14.1	3.3	2.0	11.0	2.4
03/16/2015 06:00	16.3	3.9	2.0	11.3	2.4
03/16/2015 07:00	14.0	3.6	2.0	11.0	2.4
03/16/2015 08:00	14.3	3.6	2.0	11.3	2.4
03/16/2015 09:00	14.3	3.6	2.0	11.3	2.4
03/16/2015 10:00	14.2	3.6	2.0	11.1	2.4
03/16/2015 11:00	16.3	3.6	2.0	11.3	2.4
03/16/2015 12:00	14.3	3.6	2.0	11.3	2.4
03/16/2015 13:00	14.3	3.6	2.0	11.3	2.4
03/16/2015 14:00	16.3	3.3	2.0	11.3	2.4
03/16/2015 15:00	14.3	3.6	2.0	11.2	2.4
03/16/2015 16:00	13.9	2.9	2.0	10.9	2.4
03/16/2015 17:00	15.7	2.6	2.0	10.8	2.4
03/16/2015 18:00	14.1	3.6	2.0	11.1	2.4
03/16/2015 19:00	14.3	3.6	2.0	11.2	2.4
03/16/2015 20:00	14.0	2.6	2.0	11.0	2.4
03/16/2015 21:00	15.8	2.3	2.0	10.8	2.4
03/16/2015 22:00	10.2	0.3	1.4	8.0	1.8
03/16/2015 23:00	6.5	0.2	1.3	7.1	1.6
Average/Sum#:	310.6 #	59.4 #	43.5 #	241.3 #	52.4 #
Minimum:	6.5	0.2	1.3	7.1	1.6
Maximum:	16.3	3.9	2.0	11.3	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/17/2015 00:00	7.8	0.2	1.3	7.1	1.6
03/17/2015 01:00	7.8	0.2	1.3	7.1	1.6
03/17/2015 02:00	7.8	0.2	1.3	7.1	1.6
03/17/2015 03:00	7.8	0.2	1.3	7.1	1.6
03/17/2015 04:00	7.8	0.4	1.3	7.1	1.6
03/17/2015 05:00	7.8	0.4	1.3	7.1	1.6
03/17/2015 06:00	7.8	0.4	1.3	7.1	1.6
03/17/2015 07:00	7.8	0.4	1.3	7.1	1.6
03/17/2015 08:00	7.8	0.4	1.3	7.1	1.6
03/17/2015 09:00	7.8	0.4	1.3	7.1	1.6
03/17/2015 10:00	5.2	0.2	1.3	7.1	1.6
03/17/2015 11:00	8.1	0.2	1.1	6.2	1.4
03/17/2015 12:00	9.1	0.2	1.3	7.1	1.6
03/17/2015 13:00	7.8	0.2	1.3	7.1	1.6
03/17/2015 14:00	9.1	0.2	1.3	7.1	1.6
03/17/2015 15:00	9.1	0.2	1.3	7.1	1.6
03/17/2015 16:00	7.8	0.2	1.3	7.1	1.6
03/17/2015 17:00	7.8	0.2	1.3	7.1	1.6
03/17/2015 18:00	7.8	0.2	1.3	7.1	1.6
03/17/2015 19:00	9.1	0.2	1.3	7.1	1.6
03/17/2015 20:00	9.1	0.2	1.3	7.1	1.6
03/17/2015 21:00	9.1	0.2	1.3	7.1	1.6
03/17/2015 22:00	9.1	0.2	1.3	7.1	1.6
03/17/2015 23:00	9.1	0.2	1.3	7.1	1.6
Average/Sum#:	190.1 #	5.8 #	31.0 #	169.5 #	38.2 #
Minimum:	7.8	0.2	1.1	6.2	1.4
Maximum:	9.1	0.4	1.3	7.1	1.6
%SI	4.2	4.2	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/18/2015 00:00	9.1	0.2	1.3	7.1	1.6
03/18/2015 01:00	9.1	0.2	1.3	7.1	1.6
03/18/2015 02:00	9.1	0.2	1.3	7.2	1.6
03/18/2015 03:00	9.1	0.2	1.3	7.2	1.6
03/18/2015 04:00	9.1	0.2	1.3	7.2	1.6
03/18/2015 05:00	9.1	0.2	1.3	7.2	1.6
03/18/2015 06:00	7.8	0.0	1.3	7.2	1.6
03/18/2015 07:00	9.1	0.0	1.3	7.2	1.6
03/18/2015 08:00	9.1	0.0	1.3	7.2	1.6
03/18/2015 09:00	7.8	0.0	1.2	6.2	1.4
03/18/2015 10:00	3.9	0.0	1.1	5.6	1.3
03/18/2015 11:00	8.6	0.0	1.3	6.7	1.5
03/18/2015 12:00	9.1	0.0	1.3	7.1	1.6
03/18/2015 13:00	9.1	0.0	1.3	7.1	1.6
03/18/2015 14:00	9.2	0.0	1.3	7.2	1.6
03/18/2015 15:00	13.3	0.0	1.7	9.1	2.0
03/18/2015 16:00	13.4	0.0	1.7	9.3	2.0
03/18/2015 17:00	8.9	0.0	1.3	7.1	1.6
03/18/2015 18:00	9.0	0.0	1.3	7.1	1.6
03/18/2015 19:00	8.9	0.0	1.3	7.1	1.6
03/18/2015 20:00	9.1	0.0	1.3	7.1	1.6
03/18/2015 21:00	9.1	0.0	1.3	7.1	1.6
03/18/2015 22:00	8.9	0.0	1.3	7.1	1.6
03/18/2015 23:00	8.9	0.0	1.3	7.1	1.6
Average/Sum#:	213.9 #	1.2 #	31.7 #	172.6 #	38.6 #
Minimum:	7.8	0.2	1.1	5.6	1.3
Maximum:	13.4	0.2	1.7	9.3	2.0
%SI	4.2	75.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/19/2015 00:00	8.9	0.0	1.3	7.1	1.6
03/19/2015 01:00	8.9	0.0	1.3	7.1	1.6
03/19/2015 02:00	8.9	0.0	1.3	7.1	1.6
03/19/2015 03:00	8.9	0.0	1.3	7.1	1.6
03/19/2015 04:00	9.0	0.5	1.3	7.1	1.6
03/19/2015 05:00	9.1	1.0	1.3	7.1	1.6
03/19/2015 06:00	8.4	1.0	1.4	7.7	1.6
03/19/2015 07:00	14.0	4.9	2.0	11.0	2.4
03/19/2015 08:00	7.8	1.3	2.0	10.7	2.4
03/19/2015 09:00	7.8	1.3	2.0	10.7	2.4
03/19/2015 10:00	7.8	1.3	2.0	10.8	2.4
03/19/2015 11:00	7.9	1.3	2.0	10.8	2.4
03/19/2015 12:00	16.4	4.2	2.0	11.2	2.4
03/19/2015 13:00	15.8	3.6	2.0	10.9	2.4
03/19/2015 14:00	11.0	1.2	1.6	8.6	1.8
03/19/2015 15:00	9.3	0.5	1.3	7.3	1.6
03/19/2015 16:00	9.8	0.8	1.4	7.7	1.6
03/19/2015 17:00	15.5	3.9	2.0	10.7	2.4
03/19/2015 18:00	13.9	3.9	2.0	10.9	2.4
03/19/2015 19:00	16.5	4.5	2.0	11.3	2.4
03/19/2015 20:00	15.6	2.9	2.0	10.7	2.4
03/19/2015 21:00	12.2	2.4	1.7	9.7	2.1
03/19/2015 22:00	8.8	0.6	1.4	8.1	1.8
03/19/2015 23:00	7.8	0.7	1.3	7.2	1.6
Average/Sum#:	228.7 #	36.6 #	39.9 #	218.6 #	48.1 #
Minimum:	7.8	0.5	1.3	7.1	1.6
Maximum:	16.5	4.9	2.0	11.3	2.4
%SI	16.7	33.3	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/20/2015 00:00	10.2	1.0	1.4	8.0	1.8
03/20/2015 01:00	7.8	1.0	1.3	7.1	1.6
03/20/2015 02:00	11.7	1.2	1.7	9.2	2.0
03/20/2015 03:00	8.0	1.3	1.3	7.3	1.6
03/20/2015 04:00	11.8	2.7	1.7	9.2	2.0
03/20/2015 05:00	16.0	4.6	2.0	11.0	2.4
03/20/2015 06:00	16.3	5.2	2.0	11.2	2.4
03/20/2015 07:00	7.9	3.3	2.0	10.8	2.4
03/20/2015 08:00	7.7	2.6	2.0	10.6	2.4
03/20/2015 09:00	7.3	0.3	1.8	10.0	2.2
03/20/2015 10:00	7.3	1.0	1.8	10.0	2.2
03/20/2015 11:00	12.8	1.9	1.8	10.1	2.2
03/20/2015 12:00	14.0	4.3	2.0	11.0	2.4
03/20/2015 13:00	16.1	4.2	2.0	11.0	2.4
03/20/2015 14:00	15.8	4.2	2.0	10.9	2.4
03/20/2015 15:00	15.8	4.2	2.0	10.8	2.4
03/20/2015 16:00	15.6	3.3	2.0	10.8	2.4
03/20/2015 17:00	15.6	3.3	2.0	10.7	2.4
03/20/2015 18:00	15.6	3.6	2.0	10.8	2.4
03/20/2015 19:00	15.6	3.3	2.0	10.7	2.4
03/20/2015 20:00	15.6	3.3	2.0	10.7	2.4
03/20/2015 21:00	15.6	3.3	2.0	10.7	2.4
03/20/2015 22:00	12.1	1.8	1.7	9.5	2.0
03/20/2015 23:00	7.8	0.7	1.3	7.1	1.6
Average/Sum#:	269.8 #	58.4 #	43.8 #	239.2 #	52.8 #
Minimum:	7.8	0.7	1.3	7.1	1.6
Maximum:	16.3	5.2	2.0	11.2	2.4
%SI	16.7	16.7	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/21/2015 00:00	7.7	0.7	1.3	7.1	1.6
03/21/2015 01:00	10.7	0.9	1.6	8.4	1.8
03/21/2015 02:00	8.1	1.0	1.3	7.3	1.6
03/21/2015 03:00	10.9	0.9	1.6	8.6	1.8
03/21/2015 04:00	11.1	0.9	1.6	8.8	2.0
03/21/2015 05:00	10.5	1.9	1.4	8.2	1.8
03/21/2015 06:00	16.0	4.0	2.0	11.0	2.4
03/21/2015 07:00	12.5	2.8	1.8	9.8	2.2
03/21/2015 08:00	8.1	1.1	1.3	7.4	1.6
03/21/2015 09:00	7.8	0.9	1.3	7.2	1.6
03/21/2015 10:00	7.8	0.7	1.3	7.2	1.6
03/21/2015 11:00	7.9	0.7	1.3	7.2	1.6
03/21/2015 12:00	9.4	0.8	1.3	7.4	1.6
03/21/2015 13:00	9.2	0.7	1.3	7.2	1.6
03/21/2015 14:00	9.8	0.8	1.4	7.7	1.6
03/21/2015 15:00	10.5	0.9	1.4	8.2	1.8
03/21/2015 16:00	11.5	0.6	1.6	9.0	2.0
03/21/2015 17:00	12.6	3.1	1.8	9.9	2.2
03/21/2015 18:00	14.1	4.5	2.0	11.0	2.4
03/21/2015 19:00	16.1	4.2	2.0	11.0	2.4
03/21/2015 20:00	16.2	4.5	2.0	11.1	2.4
03/21/2015 21:00	14.0	4.2	2.0	11.0	2.4
03/21/2015 22:00	12.5	1.9	1.8	9.9	2.2
03/21/2015 23:00	12.3	0.6	1.7	9.7	2.2
Average/Sum#:	267.3 #	43.3 #	38.1 #	211.3 #	46.4 #
Minimum:	7.7	0.6	1.3	7.1	1.6
Maximum:	16.2	4.5	2.0	11.1	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/22/2015 00:00	12.6	0.6	1.8	9.9	2.2
03/22/2015 01:00	8.0	0.6	1.6	8.8	2.0
03/22/2015 02:00	11.6	0.6	1.7	9.1	2.0
03/22/2015 03:00	12.3	0.6	1.7	9.7	2.2
03/22/2015 04:00	10.7	0.9	1.6	8.4	1.8
03/22/2015 05:00	11.2	0.9	1.6	8.8	2.0
03/22/2015 06:00	9.8	0.9	1.6	9.0	2.0
03/22/2015 07:00	11.6	1.8	1.7	9.2	2.0
03/22/2015 08:00	16.4	4.9	2.0	11.2	2.4
03/22/2015 09:00	16.2	4.2	2.0	11.0	2.4
03/22/2015 10:00	15.6	3.6	2.0	10.8	2.4
03/22/2015 11:00	15.6	3.8	2.0	10.8	2.4
03/22/2015 12:00	15.8	3.6	2.0	10.8	2.4
03/22/2015 13:00	11.9	1.8	1.7	9.3	2.0
03/22/2015 14:00	11.2	0.6	1.6	8.8	2.0
03/22/2015 15:00	9.6	0.6	1.6	8.8	2.0
03/22/2015 16:00	9.4	0.6	1.6	8.6	1.8
03/22/2015 17:00	12.0	2.7	1.7	9.5	2.0
03/22/2015 18:00	14.1	4.2	2.0	11.1	2.4
03/22/2015 19:00	15.9	3.9	2.0	10.9	2.4
03/22/2015 20:00	15.7	3.3	2.0	10.8	2.4
03/22/2015 21:00	10.2	1.1	1.4	8.1	1.8
03/22/2015 22:00	7.8	0.9	1.3	7.2	1.6
03/22/2015 23:00	8.4	11.7	0.7	2.7	0.7
Average/Sum#:	293.6 #	58.4 #	40.9 #	223.3 #	49.3 #
Minimum:	7.8	0.6	0.7	2.7	0.7
Maximum:	16.4	11.7	2.0	11.2	2.4
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/23/2015 00:00	0.0	0.0	0.0	0.0	0.0
03/23/2015 01:00	0.0	0.0	0.0	0.0	0.0
03/23/2015 02:00	0.0	0.0	0.0	0.0	0.0
03/23/2015 03:00	0.0	0.0	0.0	0.0	0.0
03/23/2015 04:00	0.0	0.0	0.0	0.0	0.0
03/23/2015 05:00	0.0	0.0	0.0	0.0	0.0
03/23/2015 06:00	0.0	0.0	0.0	0.0	0.0
03/23/2015 07:00	0.0	0.0	0.0	0.0	0.0
03/23/2015 08:00	0.0	0.0	0.0	0.0	0.0
03/23/2015 09:00	0.0	0.0	0.0	0.0	0.0
03/23/2015 10:00	0.0	0.0	0.0	0.0	0.0
03/23/2015 11:00	0.0	0.0	0.0	0.0	0.0
03/23/2015 12:00	0.0	0.0	0.0	0.0	0.0
03/23/2015 13:00	0.0	0.0	0.0	0.0	0.0
03/23/2015 14:00	0.0	0.0	0.0	0.0	0.0
03/23/2015 15:00	0.0	0.0	0.0	0.0	0.0
03/23/2015 16:00	0.0	0.0	0.0	0.0	0.0
03/23/2015 17:00	0.0	0.0	0.0	0.0	0.0
03/23/2015 18:00	0.0	0.0	0.0	0.0	0.0
03/23/2015 19:00	0.0	0.0	0.0	0.0	0.0
03/23/2015 20:00	0.0	0.0	0.0	0.0	0.0
03/23/2015 21:00	0.0	0.0	0.0	0.0	0.0
03/23/2015 22:00	0.0	0.0	0.0	0.0	0.0
03/23/2015 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/24/2015 00:00	0.0	0.0	0.0	0.0	0.0
03/24/2015 01:00	0.0	0.0	0.0	0.0	0.0
03/24/2015 02:00	0.0	0.0	0.0	0.0	0.0
03/24/2015 03:00	0.0	0.0	0.0	0.0	0.0
03/24/2015 04:00	0.0	0.0	0.0	0.0	0.0
03/24/2015 05:00	0.0	0.0	0.0	0.0	0.0
03/24/2015 06:00	0.0	0.0	0.0	0.0	0.0
03/24/2015 07:00	0.0	0.0	0.0	0.0	0.0
03/24/2015 08:00	0.0	0.0	0.0	0.0	0.0
03/24/2015 09:00	0.0	0.0	0.0	0.0	0.0
03/24/2015 10:00	0.0	0.0	0.0	0.0	0.0
03/24/2015 11:00	0.0	0.0	0.0	0.0	0.0
03/24/2015 12:00	0.0	0.0	0.0	0.0	0.0
03/24/2015 13:00	0.0	0.0	0.0	0.0	0.0
03/24/2015 14:00	0.0	0.0	0.0	0.0	0.0
03/24/2015 15:00	0.0	0.0	0.0	0.0	0.0
03/24/2015 16:00	0.0	0.0	0.0	0.0	0.0
03/24/2015 17:00	0.0	0.0	0.0	0.0	0.0
03/24/2015 18:00	0.0	0.0	0.0	0.0	0.0
03/24/2015 19:00	0.0	0.0	0.0	0.0	0.0
03/24/2015 20:00	0.0	0.0	0.0	0.0	0.0
03/24/2015 21:00	0.0	0.0	0.0	0.0	0.0
03/24/2015 22:00	0.0	0.0	0.0	0.0	0.0
03/24/2015 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/25/2015 00:00	0.0	0.0	0.0	0.0	0.0
03/25/2015 01:00	0.0	0.0	0.0	0.0	0.0
03/25/2015 02:00	0.0	0.0	0.0	0.0	0.0
03/25/2015 03:00	0.0	0.0	0.0	0.0	0.0
03/25/2015 04:00	0.0	0.0	0.0	0.0	0.0
03/25/2015 05:00	0.0	0.0	0.0	0.0	0.0
03/25/2015 06:00	0.0	0.0	0.0	0.0	0.0
03/25/2015 07:00	0.0	0.0	0.0	0.0	0.0
03/25/2015 08:00	0.0	0.0	0.0	0.0	0.0
03/25/2015 09:00	0.0	0.0	0.0	0.0	0.0
03/25/2015 10:00	0.0	0.0	0.0	0.0	0.0
03/25/2015 11:00	0.0	0.0	0.0	0.0	0.0
03/25/2015 12:00	0.0	0.0	0.0	0.0	0.0
03/25/2015 13:00	0.0	0.0	0.0	0.0	0.0
03/25/2015 14:00	0.0	0.0	0.0	0.0	0.0
03/25/2015 15:00	0.0	0.0	0.0	0.0	0.0
03/25/2015 16:00	0.0	0.0	0.0	0.0	0.0
03/25/2015 17:00	0.0	0.0	0.0	0.0	0.0
03/25/2015 18:00	0.0	0.0	0.0	0.0	0.0
03/25/2015 19:00	0.0	0.0	0.0	0.0	0.0
03/25/2015 20:00	0.0	0.0	0.0	0.0	0.0
03/25/2015 21:00	0.0	0.0	0.0	0.0	0.0
03/25/2015 22:00	0.0	0.0	0.0	0.0	0.0
03/25/2015 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/26/2015 00:00	0.0	0.0	0.0	0.0	0.0
03/26/2015 01:00	0.0	0.0	0.0	0.0	0.0
03/26/2015 02:00	0.0	0.0	0.0	0.0	0.0
03/26/2015 03:00	43.0	85.4	0.2	0.7	0.2
03/26/2015 04:00	34.5	97.4	0.4	1.5	0.4
03/26/2015 05:00	13.6	75.4	0.5	1.9	0.5
03/26/2015 06:00	1.4	0.3	1.0	3.4	0.8
03/26/2015 07:00	2.8	0.3	1.0	3.4	0.8
03/26/2015 08:00	2.8	0.3	1.0	3.5	0.8
03/26/2015 09:00	2.8	0.3	1.0	3.5	0.8
03/26/2015 10:00	2.8	0.3	1.0	3.5	0.8
03/26/2015 11:00	2.8	0.3	1.0	3.5	0.8
03/26/2015 12:00	2.8	0.3	1.0	3.5	0.8
03/26/2015 13:00	3.3	0.3	1.2	4.1	1.0
03/26/2015 14:00	2.8	0.3	1.0	3.5	0.8
03/26/2015 15:00	2.8	0.3	1.0	3.5	0.8
03/26/2015 16:00	3.4	0.3	1.2	4.2	1.0
03/26/2015 17:00	5.3	0.3	1.2	4.4	1.1
03/26/2015 18:00	5.3	0.3	1.2	4.4	1.1
03/26/2015 19:00	5.3	0.3	1.2	4.5	1.1
03/26/2015 20:00	5.4	0.3	1.2	4.5	1.1
03/26/2015 21:00	2.7	0.3	1.0	3.4	0.8
03/26/2015 22:00	1.0	3.3	0.0	0.1	0.0
03/26/2015 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	146.6 #	266.3 #	18.3 #	65.0 #	15.5 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	43.0	97.4	1.2	4.5	1.1
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/27/2015 00:00	0.0	0.0	0.0	0.0	0.0
03/27/2015 01:00	0.0	0.0	0.0	0.0	0.0
03/27/2015 02:00	0.0	0.0	0.0	0.0	0.0
03/27/2015 03:00	0.0	0.0	0.0	0.0	0.0
03/27/2015 04:00	0.0	6.9	0.0	0.1	0.0
03/27/2015 05:00	70.2	31.1	0.6	2.0	0.5
03/27/2015 06:00	1.4	0.5	1.0	3.5	0.8
03/27/2015 07:00	2.8	0.5	1.0	3.4	0.8
03/27/2015 08:00	2.8	0.3	1.0	3.4	0.8
03/27/2015 09:00	2.8	0.3	1.0	3.4	0.8
03/27/2015 10:00	2.8	0.3	1.0	3.4	0.8
03/27/2015 11:00	2.8	0.3	1.0	3.5	0.8
03/27/2015 12:00	2.8	0.3	1.0	3.5	0.8
03/27/2015 13:00	2.8	0.3	1.0	3.5	0.8
03/27/2015 14:00	2.8	0.3	1.0	3.4	0.8
03/27/2015 15:00	2.8	0.3	1.0	3.4	0.8
03/27/2015 16:00	2.8	0.3	1.0	3.5	0.8
03/27/2015 17:00	3.1	0.3	1.1	3.9	0.9
03/27/2015 18:00	2.8	0.3	1.0	3.5	0.8
03/27/2015 19:00	2.7	0.3	1.0	3.4	0.8
03/27/2015 20:00	4.5	6.7	0.5	1.9	0.4
03/27/2015 21:00	0.0	0.0	0.0	0.0	0.0
03/27/2015 22:00	0.0	0.0	0.0	0.0	0.0
03/27/2015 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	112.7 #	49.3 #	15.2 #	52.7 #	12.2 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	70.2	31.1	1.1	3.9	0.9
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/28/2015 00:00	0.0	0.0	0.0	0.0	0.0
03/28/2015 01:00	0.0	0.0	0.0	0.0	0.0
03/28/2015 02:00	0.0	0.0	0.0	0.0	0.0
03/28/2015 03:00	0.0	0.0	0.0	0.0	0.0
03/28/2015 04:00	0.0	0.0	0.0	0.0	0.0
03/28/2015 05:00	0.0	0.0	0.0	0.0	0.0
03/28/2015 06:00	0.0	0.0	0.0	0.0	0.0
03/28/2015 07:00	0.0	0.0	0.0	0.0	0.0
03/28/2015 08:00	0.0	0.0	0.0	0.0	0.0
03/28/2015 09:00	0.0	0.0	0.0	0.0	0.0
03/28/2015 10:00	0.0	0.0	0.0	0.0	0.0
03/28/2015 11:00	0.0	0.0	0.0	0.0	0.0
03/28/2015 12:00	0.0	0.0	0.0	0.0	0.0
03/28/2015 13:00	0.0	0.0	0.0	0.0	0.0
03/28/2015 14:00	0.0	0.0	0.0	0.0	0.0
03/28/2015 15:00	0.0	0.0	0.0	0.0	0.0
03/28/2015 16:00	0.0	0.0	0.0	0.0	0.0
03/28/2015 17:00	0.0	0.0	0.0	0.0	0.0
03/28/2015 18:00	0.0	0.0	0.0	0.0	0.0
03/28/2015 19:00	0.0	0.0	0.0	0.0	0.0
03/28/2015 20:00	0.0	0.0	0.0	0.0	0.0
03/28/2015 21:00	0.0	0.0	0.0	0.0	0.0
03/28/2015 22:00	0.0	0.0	0.0	0.0	0.0
03/28/2015 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/29/2015 00:00	0.0	0.0	0.0	0.0	0.0
03/29/2015 01:00	0.0	0.0	0.0	0.0	0.0
03/29/2015 02:00	0.0	0.0	0.0	0.0	0.0
03/29/2015 03:00	0.0	0.0	0.0	0.0	0.0
03/29/2015 04:00	0.0	0.0	0.0	0.0	0.0
03/29/2015 05:00	0.0	0.0	0.0	0.0	0.0
03/29/2015 06:00	0.0	0.0	0.0	0.0	0.0
03/29/2015 07:00	0.0	0.0	0.0	0.0	0.0
03/29/2015 08:00	0.0	0.0	0.0	0.0	0.0
03/29/2015 09:00	0.0	0.0	0.0	0.0	0.0
03/29/2015 10:00	0.0	0.0	0.0	0.0	0.0
03/29/2015 11:00	0.0	0.0	0.0	0.0	0.0
03/29/2015 12:00	0.0	0.0	0.0	0.0	0.0
03/29/2015 13:00	0.0	0.0	0.0	0.0	0.0
03/29/2015 14:00	0.0	0.0	0.0	0.0	0.0
03/29/2015 15:00	0.0	0.0	0.0	0.0	0.0
03/29/2015 16:00	0.0	0.0	0.0	0.0	0.0
03/29/2015 17:00	0.0	0.0	0.0	0.0	0.0
03/29/2015 18:00	0.0	0.0	0.0	0.0	0.0
03/29/2015 19:00	0.0	0.0	0.0	0.0	0.0
03/29/2015 20:00	0.0	0.0	0.0	0.0	0.0
03/29/2015 21:00	0.0	0.0	0.0	0.0	0.0
03/29/2015 22:00	0.0	0.0	0.0	0.0	0.0
03/29/2015 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/30/2015 00:00	0.0	0.0	0.0	0.0	0.0
03/30/2015 01:00	0.0	0.0	0.0	0.0	0.0
03/30/2015 02:00	0.0	0.0	0.0	0.0	0.0
03/30/2015 03:00	46.4	78.9	0.2	0.7	0.2
03/30/2015 04:00	53.7	57.6	0.5	1.8	0.4
03/30/2015 05:00	32.6	28.5	0.8	2.7	0.7
03/30/2015 06:00	1.4	0.0	1.0	3.5	0.8
03/30/2015 07:00	2.8	0.0	1.0	3.5	0.8
03/30/2015 08:00	2.8	0.0	1.0	3.5	0.8
03/30/2015 09:00	2.8	0.0	1.0	3.5	0.8
03/30/2015 10:00	2.8	0.0	1.0	3.4	0.8
03/30/2015 11:00	2.8	0.0	1.0	3.4	0.8
03/30/2015 12:00	3.0	0.0	1.1	3.8	0.9
03/30/2015 13:00	3.1	0.0	1.1	3.8	0.9
03/30/2015 14:00	3.0	0.0	1.1	3.8	0.9
03/30/2015 15:00	2.7	0.0	0.9	3.4	0.8
03/30/2015 16:00	1.3	0.0	0.9	3.3	0.8
03/30/2015 17:00	2.9	0.0	1.0	3.7	0.9
03/30/2015 18:00	3.4	0.0	1.2	4.2	1.0
03/30/2015 19:00	3.2	0.0	1.1	4.0	1.0
03/30/2015 20:00	3.5	5.7	0.3	1.1	0.3
03/30/2015 21:00	0.0	0.0	0.0	0.0	0.0
03/30/2015 22:00	0.0	0.0	0.0	0.0	0.0
03/30/2015 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	174.2 #	170.7 #	16.2 #	57.1 #	13.6 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	53.7	78.9	1.2	4.2	1.0
%SI	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

AQ-25 Hourly

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 12:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/31/2015 00:00	0.0	0.0	0.0	0.0	0.0
03/31/2015 01:00	0.0	0.0	0.0	0.0	0.0
03/31/2015 02:00	0.0	0.0	0.0	0.0	0.0
03/31/2015 03:00	0.0	0.0	0.0	0.0	0.0
03/31/2015 04:00	53.1	29.2	0.3	0.8	0.2
03/31/2015 05:00	18.7	15.7	0.9	3.1	0.7
03/31/2015 06:00	1.4	0.0	1.0	3.4	0.8
03/31/2015 07:00	2.8	0.0	1.0	3.5	0.8
03/31/2015 08:00	2.8	0.0	1.0	3.5	0.8
03/31/2015 09:00	2.8	0.0	1.0	3.5	0.8
03/31/2015 10:00	2.8	0.0	1.0	3.4	0.8
03/31/2015 11:00	2.7	0.0	1.0	3.4	0.8
03/31/2015 12:00	2.8	0.0	1.0	3.4	0.8
03/31/2015 13:00	2.8	0.0	1.0	3.4	0.8
03/31/2015 14:00	2.8	0.0	1.0	3.5	0.8
03/31/2015 15:00	2.8	0.0	1.0	3.4	0.8
03/31/2015 16:00	3.0	0.0	1.1	3.8	0.9
03/31/2015 17:00	3.0	0.0	1.1	3.8	0.9
03/31/2015 18:00	3.2	0.0	1.1	4.0	1.0
03/31/2015 19:00	3.5	0.0	1.2	4.4	1.1
03/31/2015 20:00	3.2	0.0	1.1	4.0	1.0
03/31/2015 21:00	3.8	5.8	0.3	1.2	0.3
03/31/2015 22:00	0.0	0.0	0.0	0.0	0.0
03/31/2015 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	118.0 #	50.7 #	17.1 #	59.5 #	14.1 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	53.1	29.2	1.2	4.4	1.1
%SI	0.0	0.0	0.0	0.0	0.0

ATTACHMENT 11

CGA/Linearity

FCD:	AQ-19
Title V:	#13

Linearity Report (RT601/602)

04/22/2015

ORIS Code:	56298	Facility Name:	COLUSA GENERATION		
EDR Site ID:	CT1	Component ID:	A11	ReasonForTest:	QA
		Component Type:	NOXA	Grace Period:	0
Instrument Name:	CT1_NOXDualRg_P_Instrument	Test End Date/Time:	03/19/2015	Scale:	High
Performance Spec:	5 %	Test No.:	50	Highest Error:	0.7
		Status (Pass/Fail):	**Passed**		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
03/19/2015	1033	L	200	50.6	50.2		25.3 %
03/19/2015	1039	M	200	109.1	108.9		54.6 %
03/19/2015	1045	H	200	182.4	182.1		91.2 %
03/19/2015	1054	L	200	50.6	50.3		25.3 %
03/19/2015	1100	M	200	109.1	108.6		54.6 %
03/19/2015	1106	H	200	182.4	182.1		91.2 %
03/19/2015	1114	L	200	50.6	50.2		25.3 %
03/19/2015	1120	M	200	109.1	108.7		54.6 %
03/19/2015	1126	H	200	182.4	181.8		91.2 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
H	182.400	182.000	No	**0.2**
L	50.600	50.233	No	**0.7**
M	109.100	108.733	No	**0.3**

Linearity Report

ORIS Code:	56298	Facility Name:	COLUSA GENERATION		
EDR Site ID:	CT1	Component ID:	A12	ReasonForTest:	QA
		Component Type:	O2D	Grace Period:	0
Instrument Name:	CT1_O2D_P_Instrument	Test End Date/Time:	03/19/2015	Scale:	High
Performance Spec:	5 %	Test No.:	51	Highest Error:	0.2
		Status (Pass/Fail):	**Passed**		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
03/19/2015	1132	L	25.0	5.5	5.5		22.0 %
03/19/2015	1138	M	25.0	13.2	13.2		52.8 %
03/19/2015	1144	H	25.0	21.0	21.0		84.0 %
03/19/2015	1153	L	25.0	5.5	5.5		22.0 %
03/19/2015	1159	M	25.0	13.2	13.2		52.8 %
03/19/2015	1205	H	25.0	21.0	21.0		84.0 %
03/19/2015	1213	L	25.0	5.5	5.5		22.0 %
03/19/2015	1219	M	25.0	13.2	13.2		52.8 %
03/19/2015	1225	H	25.0	21.0	21.1		84.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.500	5.500	No	**0.0**
M	13.200	13.200	No	**0.0**
H	21.000	21.033	No	**0.2**

Linearity Report (RT601/602)

04/22/2015

ORIS Code:	56298	Facility Name:	COLUSA GENERATION		
EDR Site ID:	CT2	Component ID:	A21	ReasonForTest:	QA
		Component Type:	NOXA	Grace Period:	0
Instrument Name:	CT2_NOXDualRg_P_Instrument	Test End Date/Time:	03/20/2015	Scale:	High
Performance Spec:	5 %	Test No.:	46	Highest Error:	1.8
		Status (Pass/Fail):	**Passed**		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
03/20/2015	0912	L	200	49.7	48.8		24.9 %
03/20/2015	0918	M	200	108.5	107.9		54.3 %
03/20/2015	0924	H	200	182.8	182.3		91.4 %
03/20/2015	0933	L	200	49.7	48.8		24.9 %
03/20/2015	0939	M	200	108.5	107.8		54.3 %
03/20/2015	0945	H	200	182.8	182.4		91.4 %
03/20/2015	0953	L	200	49.7	48.8		24.9 %
03/20/2015	0959	M	200	108.5	107.8		54.3 %
03/20/2015	1005	H	200	182.8	182.4		91.4 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
H	182.800	182.367	No	**0.2**
L	49.700	48.800	No	**1.8**
M	108.500	107.833	No	**0.6**

Linearity Report (RT601/602)

ORIS Code:	56298	Facility Name:	COLUSA GENERATION		
EDR Site ID:	CT2	Component ID:	A22	ReasonForTest:	QA
		Component Type:	O2D	Grace Period:	0
Instrument Name:	CT2_O2D_P_Instrument	Test End Date/Time:	03/20/2015	Scale:	High
Performance Spec:	5 %	Test No.:	47	Highest Error:	0.0
		Status (Pass/Fail):	**Passed**		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
03/20/2015	1011	L	25	5.5	5.5		22.0 %
03/20/2015	1017	M	25	13.0	13.0		52.0 %
03/20/2015	1023	H	25	21.0	21.0		84.0 %
03/20/2015	1032	L	25	5.5	5.5		22.0 %
03/20/2015	1038	M	25	13.0	13.0		52.0 %
03/20/2015	1044	H	25	21.0	21.0		84.0 %
03/20/2015	1052	L	25	5.5	5.5		22.0 %
03/20/2015	1058	M	25	13.0	13.0		52.0 %
03/20/2015	1104	H	25	21.0	21.0		84.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
H	21.000	21.000	No	**0.0**
L	5.500	5.500	No	**0.0**
M	13.000	13.000	No	**0.0**

Cylinder Gas Audit

04/22/2015

Facility:	COLUSA GENERATION			Instrument Name:	CT1_CODualRg_P_Instrum
Unit/Stack:	CT1	Test Date:	03/19/2015	Performance Spec:	15 Pct
Parameter/Scale:	CO / Low	Test Result:	**Pass**	Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
03/19/2015	08:10	L	20	4.900	5.100	24.5 %
03/19/2015	08:16	M	20	11.300	11.300	56.5 %
03/19/2015	08:25	L	20	4.900	5.100	24.5 %
03/19/2015	08:31	M	20	11.300	11.300	56.5 %
03/19/2015	08:39	L	20	4.900	5.000	24.5 %
03/19/2015	08:45	M	20	11.300	11.300	56.5 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	4.900	5.067	Std	**3.4**
M	11.300	11.300	Std	**0.0**

Cylinder Gas Audit

04/22/2015

Facility:	COLUSA GENERATION			Instrument Name:	CT1_NOXDualRg_P_Instru
Unit/Stack:	CT1	Test Date:	03/19/2015	Performance Spec:	15 Pct
Parameter/Scale:	NOX / Low	Test Result:	**Pass**	Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
03/19/2015	08:51	L	10	2.500	2.200	25.0 %
03/19/2015	08:57	M	10	5.500	5.300	55.0 %
03/19/2015	09:06	L	10	2.500	2.200	25.0 %
03/19/2015	09:12	M	10	5.500	5.300	55.0 %
03/19/2015	09:20	L	10	2.500	2.200	25.0 %
03/19/2015	09:26	M	10	5.500	5.300	55.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	2.500	2.200	Std	**12.0**
M	5.500	5.300	Std	**3.6**

Cylinder Gas Audit

04/22/2015

Facility:	COLUSA GENERATION			Instrument Name:	CT1_CODualRg_P_Instrum
Unit/Stack:	CT1	Test Date:	03/19/2015	Performance Spec:	15 Pct
Parameter/Scale:	CO / High	Test Result:	**Pass**	Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
03/19/2015	09:51	L	2000	508.800	496.400	25.4 %
03/19/2015	09:57	M	2000	1147.000	1151.400	57.4 %
03/19/2015	10:06	L	2000	508.800	496.100	25.4 %
03/19/2015	10:12	M	2000	1147.000	1151.900	57.4 %
03/19/2015	10:20	L	2000	508.800	496.100	25.4 %
03/19/2015	10:26	M	2000	1147.000	1151.900	57.4 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	508.800	496.200	Std	**2.5**
M	1147.000	1151.733	Std	**0.4**

Cylinder Gas Audit

04/22/2015

Facility:	COLUSA GENERATION			Instrument Name:	CT1_NOXInlet_P_Instrum
Unit/Stack:	CT1	Test Date:	03/19/2015	Performance Spec:	15 Pct
Parameter/Scale:	NOX / High	Test Result:	**Pass**	Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
03/19/2015	12:31	L	200	50.600	49.600	25.3 %
03/19/2015	12:37	M	200	109.100	107.400	54.6 %
03/19/2015	12:46	L	200	50.600	49.300	25.3 %
03/19/2015	12:52	M	200	109.100	106.600	54.6 %
03/19/2015	13:00	L	200	50.600	49.400	25.3 %
03/19/2015	13:06	M	200	109.100	106.300	54.6 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	50.600	49.433	Std	**2.3**
M	109.100	106.767	Std	**2.1**

Cylinder Gas Audit

04/22/2015

Facility:	COLUSA GENERATION			Instrument Name:	CT1_O2DInlet_P_Instrum
Unit/Stack:	CT1	Test Date:	03/19/2015	Performance Spec:	15 Pct
Parameter/Scale:	O2D / High	Test Result:	**Pass**	Alternate Spec:	0.5 Pct

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
03/19/2015	13:13	L	25	5.500	5.500	22.0 %
03/19/2015	13:19	M	25	13.200	13.300	52.8 %
03/19/2015	13:28	L	25	5.500	5.500	22.0 %
03/19/2015	13:34	M	25	13.200	13.300	52.8 %
03/19/2015	13:42	L	25	5.500	5.500	22.0 %
03/19/2015	13:48	M	25	13.200	13.300	52.8 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	5.500	5.500	Std	**0.0**
M	13.200	13.300	Std	**0.8**

Cylinder Gas Audit

04/22/2015

Facility:	COLUSA GENERATION			Instrument Name:	CT2_CODualRg_P_Instrum
Unit/Stack:	CT2	Test Date:	03/20/2015	Performance Spec:	15 Pct
Parameter/Scale:	CO / Low	Test Result:	**Pass**	Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
03/20/2015	07:01	L	20	4.700	4.300	23.5 %
03/20/2015	07:07	M	20	11.100	10.600	55.5 %
03/20/2015	07:16	L	20	4.700	4.300	23.5 %
03/20/2015	07:22	M	20	11.100	10.600	55.5 %
03/20/2015	07:30	L	20	4.700	4.300	23.5 %
03/20/2015	07:36	M	20	11.100	10.600	55.5 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	4.700	4.300	Std	**8.5**
M	11.100	10.600	Std	**4.5**

Cylinder Gas Audit

04/22/2015

Facility:	COLUSA GENERATION			Instrument Name:	CT2_NOXDualRg_P_Instru
Unit/Stack:	CT2	Test Date:	03/20/2015	Performance Spec:	15 Pct
Parameter/Scale:	NOX / Low	Test Result:	**Pass**	Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
03/20/2015	07:44	L	10	2.500	2.200	25.0 %
03/20/2015	07:50	M	10	5.600	4.900	56.0 %
03/20/2015	07:59	L	10	2.500	2.200	25.0 %
03/20/2015	08:05	M	10	5.600	5.000	56.0 %
03/20/2015	08:13	L	10	2.500	2.200	25.0 %
03/20/2015	08:19	M	10	5.600	5.000	56.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	2.500	2.200	Std	**12.0**
M	5.600	4.967	Std	**11.3**

Cylinder Gas Audit

04/22/2015

Facility:	COLUSA GENERATION			Instrument Name:	CT2_CODualRg_P_Instrum
Unit/Stack:	CT2	Test Date:	03/20/2015	Performance Spec:	15 Pct
Parameter/Scale:	CO / High	Test Result:	**Pass**	Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
03/20/2015	08:25	L	2000	509.800	496.900	25.5 %
03/20/2015	08:31	M	2000	1144.000	1143.900	57.2 %
03/20/2015	08:40	L	2000	509.800	496.700	25.5 %
03/20/2015	08:46	M	2000	1144.000	1143.900	57.2 %
03/20/2015	08:54	L	2000	509.800	496.900	25.5 %
03/20/2015	09:00	M	2000	1144.000	1143.900	57.2 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	509.800	496.833	Std	**2.5**
M	1144.000	1143.900	Std	**0.0**

Cylinder Gas Audit

04/22/2015

Facility:	COLUSA GENERATION			Instrument Name:	CT2_NOXInlet_P_Instrum
Unit/Stack:	CT2	Test Date:	03/20/2015	Performance Spec:	15 Pct
Parameter/Scale:	NOX / High	Test Result:	**Pass**	Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
03/20/2015	11:11	L	200	49.700	48.800	24.9 %
03/20/2015	11:17	M	200	108.500	108.000	54.3 %
03/20/2015	11:26	L	200	49.700	48.900	24.9 %
03/20/2015	11:32	M	200	108.500	108.000	54.3 %
03/20/2015	11:40	L	200	49.700	48.900	24.9 %
03/20/2015	11:46	M	200	108.500	107.900	54.3 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	49.700	48.867	Std	**1.7**
M	108.500	107.967	Std	**0.5**

Cylinder Gas Audit

04/22/2015

Facility:	COLUSA GENERATION			Instrument Name:	CT2_O2DInlet_P_Instrum
Unit/Stack:	CT2	Test Date:	03/20/2015	Performance Spec:	15 Pct
Parameter/Scale:	O2D / High	Test Result:	**Pass**	Alternate Spec:	0.5 Pct

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
03/20/2015	11:52	L	25	5.500	5.400	22.0 %
03/20/2015	11:58	M	25	13.000	13.000	52.0 %
03/20/2015	12:07	L	25	5.500	5.400	22.0 %
03/20/2015	12:13	M	25	13.000	13.000	52.0 %
03/20/2015	12:21	L	25	5.500	5.400	22.0 %
03/20/2015	12:27	M	25	13.000	13.000	52.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	5.500	5.400	Std	**1.8**
M	13.000	13.000	Std	**0.0**

ATTACHMENT 12
Startup/Shutdown Emissions

Title V: #13

CT1 Process Event Report

CT1 Cold and Hot Startup Events

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 13:11 **Location:** Maxwell, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	1	3	0.16
Hot Startup/Startup Shutdown Event Text 02 Add	7	15	0.80
Warm Startup	8	20	1.07
Total Process Events:	16	38	2.03

Total Report Time:	2,160 Hour(s)
Total Operating Time:	1,870 Hour(s)
Total Startup Time:	38 Hour(s)
Total Shutdown Time:	0 Hour(s)
Total Startup/Shutdown Time:	38 Hour(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	2.03 %

CT2 Process Event Report

CT2 Cold and Hot Startup Events

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/22/2015 13:11 **Location:** Maxwell, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	0		0.00
Hot Startup	6	15	0.83
Warm startup	8	18	0.99
Total Process Events:	14	33	1.82

Total Report Time:	2,160 Hour(s)
Total Operating Time:	1,811 Hour(s)
Total Startup Time:	33 Hour(s)
Total Shutdown Time:	0 Hour(s)
Total Startup/Shutdown Time:	33 Hour(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	1.82 %

Pound Per Event Report

CT1 - CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:16 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,851.95 Hours

Non-Operating Time: 308.05 Hours Report Time: 2,160.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
01/18/2015 02:16 01/18/2015 02:24 Shut Down - Gas	9	2.7	483.5		
01/18/2015 14:34 01/18/2015 16:03 Warm Start - Gas	90	71.9	790.5		
01/25/2015 01:05 01/25/2015 01:12 Shut Down - Gas	8	2.1	483.5		
01/25/2015 12:35 01/25/2015 14:15 Warm Start - Gas	101	125.3	790.5		
01/25/2015 22:35 01/25/2015 22:43 Shut Down - Gas	9	2.7	483.5		
01/26/2015 04:22 01/26/2015 05:26 Hot Start - Gas	65	56.3	679.6		
01/31/2015 00:05 01/31/2015 00:12 Shut Down - Gas	8	2.3	483.5		
01/31/2015 03:18 01/31/2015 04:36 Hot Start - Gas	79	69.9	679.6		
02/01/2015 02:06 02/01/2015 02:13 Shut Down - Gas	8	2.3	483.5		
02/01/2015 10:23 02/01/2015 11:59 Warm Start - Gas	97	84.8	790.5		
02/15/2015 02:01 02/15/2015 02:09 Shut Down - Gas	9	2.8	483.5		
02/15/2015 16:42 02/15/2015 17:35 Warm Start - Gas	54	39.5	790.5		
02/20/2015 01:05 02/20/2015 01:13 Shut Down - Gas	9	3.2	483.5		

Pound Per Event Report

CT1 - CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:16 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,851.95 Hours

Non-Operating Time: 308.05 Hours Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
02/21/2015 15:20 02/21/2015 16:40 Warm Start - Gas	81	188.8	790.5		
02/22/2015 06:02 02/22/2015 06:10 Shut Down - Gas	9	2.6	483.5		
02/24/2015 03:25 02/24/2015 05:15 Warm Start - Gas	111	144.0	790.5		
02/28/2015 01:05 02/28/2015 01:12 Shut Down - Gas	8	2.2	483.5		
02/28/2015 08:18 02/28/2015 09:27 Hot Start - Gas	70	55.2	679.6		
03/07/2015 02:04 03/07/2015 02:10 Shut Down - Gas	7	2.1	483.5		
03/07/2015 10:18 03/07/2015 11:44 Warm Start - Gas	87	85.4	790.5		
03/08/2015 08:05 03/08/2015 08:12 Shut Down - Gas	8	2.6	483.5		
03/08/2015 14:58 03/08/2015 16:10 Hot Start - Gas	73	68.9	679.6		
03/17/2015 11:59 03/17/2015 12:04 Hot Start - Gas	6	0.0	679.6		
03/22/2015 23:43 03/22/2015 23:51 Shut Down - Gas	9	2.7	483.5		
03/26/2015 03:27 03/26/2015 05:58 Cold Start - Gas	152	251.9	1,355.6		
03/26/2015 22:01 03/26/2015 22:09 Shut Down - Gas	9	2.0	483.5		
03/27/2015 04:52 03/27/2015 05:53 Hot Start - Gas	62	33.5	679.6		

Pound Per Event Report

CT1 - CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:16 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,851.95 Hours

Non-Operating Time: 308.05 Hours Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
03/27/2015 20:31 03/27/2015 20:39 Shut Down - Gas	9	2.0	483.5		
03/30/2015 03:27 03/30/2015 05:35 Warm Start - Gas	129	158.5	790.5		
03/30/2015 20:17 03/30/2015 20:26 Shut Down - Gas	10	1.9	483.5		
03/31/2015 04:22 03/31/2015 05:20 Hot Start - Gas	59	39.2	679.6		
03/31/2015 21:17 03/31/2015 21:26 Shut Down - Gas	10	1.9	483.5		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT1 - CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:16 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,851.95 Hours

Non-Operating Time: 308.05 Hours Report Time: 2,160.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Pound Per Event Report

CT1 - CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:16 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,851.95 Hours

Non-Operating Time: 308.05 Hours Report Time: 2,160.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/01/2015 00:00	0.0	0	0	0	0	1
01/01/2015 01:00	0.0	0	0	0	0	1
01/01/2015 02:00	0.0	0	0	0	0	1
01/01/2015 03:00	0.0	0	0	0	0	1
01/01/2015 04:00	0.0	0	0	0	0	1
01/01/2015 05:00	0.0	0	0	0	0	1
01/01/2015 06:00	0.0	0	0	0	0	1
01/01/2015 07:00	0.0	0	0	0	0	1
01/01/2015 08:00	0.0	0	0	0	0	1
01/01/2015 09:00	0.0	0	0	0	0	1
01/01/2015 10:00	0.0	0	0	0	0	1
01/01/2015 11:00	0.0	0	0	0	0	1
01/01/2015 12:00	0.0	0	0	0	0	1
01/01/2015 13:00	0.0	0	0	0	0	1
01/01/2015 14:00	0.0	0	0	0	0	1
01/01/2015 15:00	0.0	0	0	0	0	1
01/01/2015 16:00	0.0	0	0	0	0	1
01/01/2015 17:00	0.0	0	0	0	0	1
01/01/2015 18:00	0.0	0	0	0	0	1
01/01/2015 19:00	0.0	0	0	0	0	1
01/01/2015 20:00	0.0	0	0	0	0	1
01/01/2015 21:00	0.0	0	0	0	0	1
01/01/2015 22:00	0.0	0	0	0	0	1
01/01/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/02/2015 00:00	0.0	0	0	0	0	1
01/02/2015 01:00	0.0	0	0	0	0	1
01/02/2015 02:00	0.0	0	0	0	0	1
01/02/2015 03:00	0.0	0	0	0	0	1
01/02/2015 04:00	0.0	0	0	0	0	1
01/02/2015 05:00	0.0	0	0	0	0	1
01/02/2015 06:00	0.0	0	0	0	0	1
01/02/2015 07:00	0.0	0	0	0	0	1
01/02/2015 08:00	0.0	0	0	0	0	1
01/02/2015 09:00	0.0	0	0	0	0	1
01/02/2015 10:00	0.0	0	0	0	0	1
01/02/2015 11:00	0.0	0	0	0	0	1
01/02/2015 12:00	0.0	0	0	0	0	1
01/02/2015 13:00	0.0	0	0	0	0	1
01/02/2015 14:00	0.0	0	0	0	0	1
01/02/2015 15:00	0.0	0	0	0	0	1
01/02/2015 16:00	0.0	0	0	0	0	1
01/02/2015 17:00	0.0	0	0	0	0	1
01/02/2015 18:00	0.0	0	0	0	0	1
01/02/2015 19:00	0.0	0	0	0	0	1
01/02/2015 20:00	0.0	0	0	0	0	1
01/02/2015 21:00	0.0	0	0	0	0	1
01/02/2015 22:00	0.0	0	0	0	0	1
01/02/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/03/2015 00:00	0.0	0	0	0	0	1
01/03/2015 01:00	0.0	0	0	0	0	1
01/03/2015 02:00	0.0	0	0	0	0	1
01/03/2015 03:00	0.0	0	0	0	0	1
01/03/2015 04:00	0.0	0	0	0	0	1
01/03/2015 05:00	0.0	0	0	0	0	1
01/03/2015 06:00	0.0	0	0	0	0	1
01/03/2015 07:00	0.0	0	0	0	0	1
01/03/2015 08:00	0.0	0	0	0	0	1
01/03/2015 09:00	0.0	0	0	0	0	1
01/03/2015 10:00	0.0	0	0	0	0	1
01/03/2015 11:00	0.0	0	0	0	0	1
01/03/2015 12:00	0.0	0	0	0	0	1
01/03/2015 13:00	0.0	0	0	0	0	1
01/03/2015 14:00	0.0	0	0	0	0	1
01/03/2015 15:00	0.0	0	0	0	0	1
01/03/2015 16:00	0.0	0	0	0	0	1
01/03/2015 17:00	0.0	0	0	0	0	1
01/03/2015 18:00	0.0	0	0	0	0	1
01/03/2015 19:00	0.0	0	0	0	0	1
01/03/2015 20:00	0.0	0	0	0	0	1
01/03/2015 21:00	0.0	0	0	0	0	1
01/03/2015 22:00	0.0	0	0	0	0	1
01/03/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/04/2015 00:00	0.0	0	0	0	0	1
01/04/2015 01:00	0.0	0	0	0	0	1
01/04/2015 02:00	0.0	0	0	0	0	1
01/04/2015 03:00	0.0	0	0	0	0	1
01/04/2015 04:00	0.0	0	0	0	0	1
01/04/2015 05:00	0.0	0	0	0	0	1
01/04/2015 06:00	0.0	0	0	0	0	1
01/04/2015 07:00	0.0	0	0	0	0	1
01/04/2015 08:00	0.0	0	0	0	0	1
01/04/2015 09:00	0.0	0	0	0	0	1
01/04/2015 10:00	0.0	0	0	0	0	1
01/04/2015 11:00	0.0	0	0	0	0	1
01/04/2015 12:00	0.0	0	0	0	0	1
01/04/2015 13:00	0.0	0	0	0	0	1
01/04/2015 14:00	0.0	0	0	0	0	1
01/04/2015 15:00	0.0	0	0	0	0	1
01/04/2015 16:00	0.0	0	0	0	0	1
01/04/2015 17:00	0.0	0	0	0	0	1
01/04/2015 18:00	0.0	0	0	0	0	1
01/04/2015 19:00	0.0	0	0	0	0	1
01/04/2015 20:00	0.0	0	0	0	0	1
01/04/2015 21:00	0.0	0	0	0	0	1
01/04/2015 22:00	0.0	0	0	0	0	1
01/04/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/05/2015 00:00	0.0	0	0	0	0	1
01/05/2015 01:00	0.0	0	0	0	0	1
01/05/2015 02:00	0.0	0	0	0	0	1
01/05/2015 03:00	0.0	0	0	0	0	1
01/05/2015 04:00	0.0	0	0	0	0	1
01/05/2015 05:00	0.0	0	0	0	0	1
01/05/2015 06:00	0.0	0	0	0	0	1
01/05/2015 07:00	0.0	0	0	0	0	1
01/05/2015 08:00	0.0	0	0	0	0	1
01/05/2015 09:00	0.0	0	0	0	0	1
01/05/2015 10:00	0.0	0	0	0	0	1
01/05/2015 11:00	0.0	0	0	0	0	1
01/05/2015 12:00	0.0	0	0	0	0	1
01/05/2015 13:00	0.0	0	0	0	0	1
01/05/2015 14:00	0.0	0	0	0	0	1
01/05/2015 15:00	0.0	0	0	0	0	1
01/05/2015 16:00	0.0	0	0	0	0	1
01/05/2015 17:00	0.0	0	0	0	0	1
01/05/2015 18:00	0.0	0	0	0	0	1
01/05/2015 19:00	0.0	0	0	0	0	1
01/05/2015 20:00	0.0	0	0	0	0	1
01/05/2015 21:00	0.0	0	0	0	0	1
01/05/2015 22:00	0.0	0	0	0	0	1
01/05/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/06/2015 00:00	0.0	0	0	0	0	1
01/06/2015 01:00	0.0	0	0	0	0	1
01/06/2015 02:00	0.0	0	0	0	0	1
01/06/2015 03:00	0.0	0	0	0	0	1
01/06/2015 04:00	0.0	0	0	0	0	1
01/06/2015 05:00	0.0	0	0	0	0	1
01/06/2015 06:00	0.0	0	0	0	0	1
01/06/2015 07:00	0.0	0	0	0	0	1
01/06/2015 08:00	0.0	0	0	0	0	1
01/06/2015 09:00	0.0	0	0	0	0	1
01/06/2015 10:00	0.0	0	0	0	0	1
01/06/2015 11:00	0.0	0	0	0	0	1
01/06/2015 12:00	0.0	0	0	0	0	1
01/06/2015 13:00	0.0	0	0	0	0	1
01/06/2015 14:00	0.0	0	0	0	0	1
01/06/2015 15:00	0.0	0	0	0	0	1
01/06/2015 16:00	0.0	0	0	0	0	1
01/06/2015 17:00	0.0	0	0	0	0	1
01/06/2015 18:00	0.0	0	0	0	0	1
01/06/2015 19:00	0.0	0	0	0	0	1
01/06/2015 20:00	0.0	0	0	0	0	1
01/06/2015 21:00	0.0	0	0	0	0	1
01/06/2015 22:00	0.0	0	0	0	0	1
01/06/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/07/2015 00:00	0.0	0	0	0	0	1
01/07/2015 01:00	0.0	0	0	0	0	1
01/07/2015 02:00	0.0	0	0	0	0	1
01/07/2015 03:00	0.0	0	0	0	0	1
01/07/2015 04:00	0.0	0	0	0	0	1
01/07/2015 05:00	0.0	0	0	0	0	1
01/07/2015 06:00	0.0	0	0	0	0	1
01/07/2015 07:00	0.0	0	0	0	0	1
01/07/2015 08:00	0.0	0	0	0	0	1
01/07/2015 09:00	0.0	0	0	0	0	1
01/07/2015 10:00	0.0	0	0	0	0	1
01/07/2015 11:00	0.0	0	0	0	0	1
01/07/2015 12:00	0.0	0	0	0	0	1
01/07/2015 13:00	0.0	0	0	0	0	1
01/07/2015 14:00	0.0	0	0	0	0	1
01/07/2015 15:00	0.0	0	0	0	0	1
01/07/2015 16:00	0.0	0	0	0	0	1
01/07/2015 17:00	0.0	0	0	0	0	1
01/07/2015 18:00	0.0	0	0	0	0	1
01/07/2015 19:00	0.0	0	0	0	0	1
01/07/2015 20:00	0.0	0	0	0	0	1
01/07/2015 21:00	0.0	0	0	0	0	1
01/07/2015 22:00	0.0	0	0	0	0	1
01/07/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/08/2015 00:00	0.0	0	0	0	0	1
01/08/2015 01:00	0.0	0	0	0	0	1
01/08/2015 02:00	0.0	0	0	0	0	1
01/08/2015 03:00	0.0	0	0	0	0	1
01/08/2015 04:00	0.0	0	0	0	0	1
01/08/2015 05:00	0.0	0	0	0	0	1
01/08/2015 06:00	0.0	0	0	0	0	1
01/08/2015 07:00	0.0	0	0	0	0	1
01/08/2015 08:00	0.0	0	0	0	0	1
01/08/2015 09:00	0.0	0	0	0	0	1
01/08/2015 10:00	0.0	0	0	0	0	1
01/08/2015 11:00	0.0	0	0	0	0	1
01/08/2015 12:00	0.0	0	0	0	0	1
01/08/2015 13:00	0.0	0	0	0	0	1
01/08/2015 14:00	0.0	0	0	0	0	1
01/08/2015 15:00	0.0	0	0	0	0	1
01/08/2015 16:00	0.0	0	0	0	0	1
01/08/2015 17:00	0.0	0	0	0	0	1
01/08/2015 18:00	0.0	0	0	0	0	1
01/08/2015 19:00	0.0	0	0	0	0	1
01/08/2015 20:00	0.0	0	0	0	0	1
01/08/2015 21:00	0.0	0	0	0	0	1
01/08/2015 22:00	0.0	0	0	0	0	1
01/08/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/09/2015 00:00	0.0	0	0	0	0	1
01/09/2015 01:00	0.0	0	0	0	0	1
01/09/2015 02:00	0.0	0	0	0	0	1
01/09/2015 03:00	0.0	0	0	0	0	1
01/09/2015 04:00	0.0	0	0	0	0	1
01/09/2015 05:00	0.0	0	0	0	0	1
01/09/2015 06:00	0.0	0	0	0	0	1
01/09/2015 07:00	0.0	0	0	0	0	1
01/09/2015 08:00	0.0	0	0	0	0	1
01/09/2015 09:00	0.0	0	0	0	0	1
01/09/2015 10:00	0.0	0	0	0	0	1
01/09/2015 11:00	0.0	0	0	0	0	1
01/09/2015 12:00	0.0	0	0	0	0	1
01/09/2015 13:00	0.0	0	0	0	0	1
01/09/2015 14:00	0.0	0	0	0	0	1
01/09/2015 15:00	0.0	0	0	0	0	1
01/09/2015 16:00	0.0	0	0	0	0	1
01/09/2015 17:00	0.0	0	0	0	0	1
01/09/2015 18:00	0.0	0	0	0	0	1
01/09/2015 19:00	0.0	0	0	0	0	1
01/09/2015 20:00	0.0	0	0	0	0	1
01/09/2015 21:00	0.0	0	0	0	0	1
01/09/2015 22:00	0.0	0	0	0	0	1
01/09/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/10/2015 00:00	0.0	0	0	0	0	1
01/10/2015 01:00	0.0	0	0	0	0	1
01/10/2015 02:00	0.0	0	0	0	0	1
01/10/2015 03:00	0.0	0	0	0	0	1
01/10/2015 04:00	0.0	0	0	0	0	1
01/10/2015 05:00	0.0	0	0	0	0	1
01/10/2015 06:00	0.0	0	0	0	0	1
01/10/2015 07:00	0.0	0	0	0	0	1
01/10/2015 08:00	0.0	0	0	0	0	1
01/10/2015 09:00	0.0	0	0	0	0	1
01/10/2015 10:00	0.0	0	0	0	0	1
01/10/2015 11:00	0.0	0	0	0	0	1
01/10/2015 12:00	0.0	0	0	0	0	1
01/10/2015 13:00	0.0	0	0	0	0	1
01/10/2015 14:00	0.0	0	0	0	0	1
01/10/2015 15:00	0.0	0	0	0	0	1
01/10/2015 16:00	0.0	0	0	0	0	1
01/10/2015 17:00	0.0	0	0	0	0	1
01/10/2015 18:00	0.0	0	0	0	0	1
01/10/2015 19:00	0.0	0	0	0	0	1
01/10/2015 20:00	0.0	0	0	0	0	1
01/10/2015 21:00	0.0	0	0	0	0	1
01/10/2015 22:00	0.0	0	0	0	0	1
01/10/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/11/2015 00:00	0.0	0	0	0	0	1
01/11/2015 01:00	0.0	0	0	0	0	1
01/11/2015 02:00	0.0	0	0	0	0	1
01/11/2015 03:00	0.0	0	0	0	0	1
01/11/2015 04:00	0.0	0	0	0	0	1
01/11/2015 05:00	0.0	0	0	0	0	1
01/11/2015 06:00	0.0	0	0	0	0	1
01/11/2015 07:00	0.0	0	0	0	0	1
01/11/2015 08:00	0.0	0	0	0	0	1
01/11/2015 09:00	0.0	0	0	0	0	1
01/11/2015 10:00	0.0	0	0	0	0	1
01/11/2015 11:00	0.0	0	0	0	0	1
01/11/2015 12:00	0.0	0	0	0	0	1
01/11/2015 13:00	0.0	0	0	0	0	1
01/11/2015 14:00	0.0	0	0	0	0	1
01/11/2015 15:00	0.0	0	0	0	0	1
01/11/2015 16:00	0.0	0	0	0	0	1
01/11/2015 17:00	0.0	0	0	0	0	1
01/11/2015 18:00	0.0	0	0	0	0	1
01/11/2015 19:00	0.0	0	0	0	0	1
01/11/2015 20:00	0.0	0	0	0	0	1
01/11/2015 21:00	0.0	0	0	0	0	1
01/11/2015 22:00	0.0	0	0	0	0	1
01/11/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/12/2015 00:00	0.0	0	0	0	0	1
01/12/2015 01:00	0.0	0	0	0	0	1
01/12/2015 02:00	0.0	0	0	0	0	1
01/12/2015 03:00	0.0	0	0	0	0	1
01/12/2015 04:00	0.0	0	0	0	0	1
01/12/2015 05:00	0.0	0	0	0	0	1
01/12/2015 06:00	0.0	0	0	0	0	1
01/12/2015 07:00	0.0	0	0	0	0	1
01/12/2015 08:00	0.0	0	0	0	0	1
01/12/2015 09:00	0.0	0	0	0	0	1
01/12/2015 10:00	0.0	0	0	0	0	1
01/12/2015 11:00	0.0	0	0	0	0	1
01/12/2015 12:00	0.0	0	0	0	0	1
01/12/2015 13:00	0.0	0	0	0	0	1
01/12/2015 14:00	0.0	0	0	0	0	1
01/12/2015 15:00	0.0	0	0	0	0	1
01/12/2015 16:00	0.0	0	0	0	0	1
01/12/2015 17:00	0.0	0	0	0	0	1
01/12/2015 18:00	0.0	0	0	0	0	1
01/12/2015 19:00	0.0	0	0	0	0	1
01/12/2015 20:00	0.0	0	0	0	0	1
01/12/2015 21:00	0.0	0	0	0	0	1
01/12/2015 22:00	0.0	0	0	0	0	1
01/12/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/13/2015 00:00	0.0	0	0	0	0	1
01/13/2015 01:00	0.0	0	0	0	0	1
01/13/2015 02:00	0.0	0	0	0	0	1
01/13/2015 03:00	0.0	0	0	0	0	1
01/13/2015 04:00	0.0	0	0	0	0	1
01/13/2015 05:00	0.0	0	0	0	0	1
01/13/2015 06:00	0.0	0	0	0	0	1
01/13/2015 07:00	0.0	0	0	0	0	1
01/13/2015 08:00	0.0	0	0	0	0	1
01/13/2015 09:00	0.0	0	0	0	0	1
01/13/2015 10:00	0.0	0	0	0	0	1
01/13/2015 11:00	0.0	0	0	0	0	1
01/13/2015 12:00	0.0	0	0	0	0	1
01/13/2015 13:00	0.0	0	0	0	0	1
01/13/2015 14:00	0.0	0	0	0	0	1
01/13/2015 15:00	0.0	0	0	0	0	1
01/13/2015 16:00	0.0	0	0	0	0	1
01/13/2015 17:00	0.0	0	0	0	0	1
01/13/2015 18:00	0.0	0	0	0	0	1
01/13/2015 19:00	0.0	0	0	0	0	1
01/13/2015 20:00	0.0	0	0	0	0	1
01/13/2015 21:00	0.0	0	0	0	0	1
01/13/2015 22:00	0.0	0	0	0	0	1
01/13/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/14/2015 00:00	0.0	0	0	0	0	1
01/14/2015 01:00	0.0	0	0	0	0	1
01/14/2015 02:00	0.0	0	0	0	0	1
01/14/2015 03:00	0.0	0	0	0	0	1
01/14/2015 04:00	0.0	0	0	0	0	1
01/14/2015 05:00	0.0	0	0	0	0	1
01/14/2015 06:00	0.0	0	0	0	0	1
01/14/2015 07:00	0.0	0	0	0	0	1
01/14/2015 08:00	0.0	0	0	0	0	1
01/14/2015 09:00	0.0	0	0	0	0	1
01/14/2015 10:00	0.0	0	0	0	0	1
01/14/2015 11:00	0.0	0	0	0	0	1
01/14/2015 12:00	0.0	0	0	0	0	1
01/14/2015 13:00	0.0	0	0	0	0	1
01/14/2015 14:00	0.0	0	0	0	0	1
01/14/2015 15:00	0.0	0	0	0	0	1
01/14/2015 16:00	0.0	0	0	0	0	1
01/14/2015 17:00	0.0	0	0	0	0	1
01/14/2015 18:00	0.0	0	0	0	0	1
01/14/2015 19:00	0.0	0	0	0	0	1
01/14/2015 20:00	0.0	0	0	0	0	1
01/14/2015 21:00	0.0	0	0	0	0	1
01/14/2015 22:00	0.0	0	0	0	0	1
01/14/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/15/2015 00:00	0.0	0	0	0	0	1
01/15/2015 01:00	0.0	0	0	0	0	1
01/15/2015 02:00	0.0	0	0	0	0	1
01/15/2015 03:00	0.0	0	0	0	0	1
01/15/2015 04:00	0.0	0	0	0	0	1
01/15/2015 05:00	0.0	0	0	0	0	1
01/15/2015 06:00	0.0	0	0	0	0	1
01/15/2015 07:00	0.0	0	0	0	0	1
01/15/2015 08:00	0.0	0	0	0	0	1
01/15/2015 09:00	0.0	0	0	0	0	1
01/15/2015 10:00	0.0	0	0	0	0	1
01/15/2015 11:00	0.0	0	0	0	0	1
01/15/2015 12:00	0.0	0	0	0	0	1
01/15/2015 13:00	0.0	0	0	0	0	1
01/15/2015 14:00	0.0	0	0	0	0	1
01/15/2015 15:00	0.0	0	0	0	0	1
01/15/2015 16:00	0.0	0	0	0	0	1
01/15/2015 17:00	0.0	0	0	0	0	1
01/15/2015 18:00	0.0	0	0	0	0	1
01/15/2015 19:00	0.0	0	0	0	0	1
01/15/2015 20:00	0.0	0	0	0	0	1
01/15/2015 21:00	0.0	0	0	0	0	1
01/15/2015 22:00	0.0	0	0	0	0	1
01/15/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/16/2015 00:00	0.0	0	0	0	0	1
01/16/2015 01:00	0.0	0	0	0	0	1
01/16/2015 02:00	0.0	0	0	0	0	1
01/16/2015 03:00	0.0	0	0	0	0	1
01/16/2015 04:00	0.0	0	0	0	0	1
01/16/2015 05:00	0.0	0	0	0	0	1
01/16/2015 06:00	0.0	0	0	0	0	1
01/16/2015 07:00	0.0	0	0	0	0	1
01/16/2015 08:00	0.0	0	0	0	0	1
01/16/2015 09:00	0.0	0	0	0	0	1
01/16/2015 10:00	0.0	0	0	0	0	1
01/16/2015 11:00	0.0	0	0	0	0	1
01/16/2015 12:00	0.0	0	0	0	0	1
01/16/2015 13:00	0.0	0	0	0	0	1
01/16/2015 14:00	0.0	0	0	0	0	1
01/16/2015 15:00	0.0	0	0	0	0	1
01/16/2015 16:00	0.0	0	0	0	0	1
01/16/2015 17:00	0.0	0	0	0	0	1
01/16/2015 18:00	0.0	0	0	0	0	1
01/16/2015 19:00	0.0	0	0	0	0	1
01/16/2015 20:00	0.0	0	0	0	0	1
01/16/2015 21:00	0.0	0	0	0	0	1
01/16/2015 22:00	0.0	0	0	0	0	1
01/16/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/17/2015 00:00	0.0	0	0	0	0	1
01/17/2015 01:00	0.0	0	0	0	0	1
01/17/2015 02:00	0.0	0	0	0	0	1
01/17/2015 03:00	0.0	0	0	0	0	1
01/17/2015 04:00	0.0	0	0	0	0	1
01/17/2015 05:00	0.0	0	0	0	0	1
01/17/2015 06:00	0.0	0	0	0	0	1
01/17/2015 07:00	0.0	0	0	0	0	1
01/17/2015 08:00	0.0	0	0	0	0	1
01/17/2015 09:00	0.0	0	0	0	0	1
01/17/2015 10:00	0.0	0	0	0	0	1
01/17/2015 11:00	0.0	0	0	0	0	1
01/17/2015 12:00	0.0	0	0	0	0	1
01/17/2015 13:00	0.0	0	0	0	0	1
01/17/2015 14:00	0.0	0	0	0	0	1
01/17/2015 15:00	0.0	0	0	0	0	1
01/17/2015 16:00	0.0	0	0	0	0	1
01/17/2015 17:00	0.0	0	0	0	0	1
01/17/2015 18:00	0.0	0	0	0	0	1
01/17/2015 19:00	0.0	0	0	0	0	1
01/17/2015 20:00	0.0	0	0	0	0	1
01/17/2015 21:00	0.0	0	0	0	0	1
01/17/2015 22:00	0.0	0	0	0	0	1
01/17/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/18/2015 00:00	0.0	0	0	0	0	1
01/18/2015 01:00	0.0	0	0	0	0	1
01/18/2015 02:00	2.7	0	0	0	1	0
01/18/2015 03:00	0.0	0	0	0	0	0
01/18/2015 04:00	0.0	0	0	0	0	0
01/18/2015 05:00	0.0	0	0	0	0	0
01/18/2015 06:00	0.0	0	0	0	0	0
01/18/2015 07:00	0.0	0	0	0	0	0
01/18/2015 08:00	0.0	0	0	0	0	0
01/18/2015 09:00	0.0	0	0	0	0	0
01/18/2015 10:00	0.0	0	0	0	0	0
01/18/2015 11:00	0.0	0	0	0	0	0
01/18/2015 12:00	0.0	0	0	0	0	0
01/18/2015 13:00	0.0	0	0	0	0	0
01/18/2015 14:00	21.3	0	1	0	0	0
01/18/2015 15:00	55.8	0	1	0	0	0
01/18/2015 16:00	0.0	0	1	0	0	0
01/18/2015 17:00	0.0	0	0	0	0	1
01/18/2015 18:00	0.0	0	0	0	0	1
01/18/2015 19:00	0.0	0	0	0	0	1
01/18/2015 20:00	0.0	0	0	0	0	1
01/18/2015 21:00	0.0	0	0	0	0	1
01/18/2015 22:00	0.0	0	0	0	0	1
01/18/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	79.8 #	0 #	3 #	0 #	1 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	55.8	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/19/2015 00:00	0.0	0	0	0	0	1
01/19/2015 01:00	0.0	0	0	0	0	1
01/19/2015 02:00	0.0	0	0	0	0	1
01/19/2015 03:00	0.0	0	0	0	0	1
01/19/2015 04:00	0.0	0	0	0	0	1
01/19/2015 05:00	0.0	0	0	0	0	1
01/19/2015 06:00	0.0	0	0	0	0	1
01/19/2015 07:00	0.0	0	0	0	0	1
01/19/2015 08:00	0.0	0	0	0	0	1
01/19/2015 09:00	0.0	0	0	0	0	1
01/19/2015 10:00	0.0	0	0	0	0	1
01/19/2015 11:00	0.0	0	0	0	0	1
01/19/2015 12:00	0.0	0	0	0	0	1
01/19/2015 13:00	0.0	0	0	0	0	1
01/19/2015 14:00	0.0	0	0	0	0	1
01/19/2015 15:00	0.0	0	0	0	0	1
01/19/2015 16:00	0.0	0	0	0	0	1
01/19/2015 17:00	0.0	0	0	0	0	1
01/19/2015 18:00	0.0	0	0	0	0	1
01/19/2015 19:00	0.0	0	0	0	0	1
01/19/2015 20:00	0.0	0	0	0	0	1
01/19/2015 21:00	0.0	0	0	0	0	1
01/19/2015 22:00	0.0	0	0	0	0	1
01/19/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/20/2015 00:00	0.0	0	0	0	0	1
01/20/2015 01:00	0.0	0	0	0	0	1
01/20/2015 02:00	0.0	0	0	0	0	1
01/20/2015 03:00	0.0	0	0	0	0	1
01/20/2015 04:00	0.0	0	0	0	0	1
01/20/2015 05:00	0.0	0	0	0	0	1
01/20/2015 06:00	0.0	0	0	0	0	1
01/20/2015 07:00	0.0	0	0	0	0	1
01/20/2015 08:00	0.0	0	0	0	0	1
01/20/2015 09:00	0.0	0	0	0	0	1
01/20/2015 10:00	0.0	0	0	0	0	1
01/20/2015 11:00	0.0	0	0	0	0	1
01/20/2015 12:00	0.0	0	0	0	0	1
01/20/2015 13:00	0.0	0	0	0	0	1
01/20/2015 14:00	0.0	0	0	0	0	1
01/20/2015 15:00	0.0	0	0	0	0	1
01/20/2015 16:00	0.0	0	0	0	0	1
01/20/2015 17:00	0.0	0	0	0	0	1
01/20/2015 18:00	0.0	0	0	0	0	1
01/20/2015 19:00	0.0	0	0	0	0	1
01/20/2015 20:00	0.0	0	0	0	0	1
01/20/2015 21:00	0.0	0	0	0	0	1
01/20/2015 22:00	0.0	0	0	0	0	1
01/20/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/21/2015 00:00	0.0	0	0	0	0	1
01/21/2015 01:00	0.0	0	0	0	0	1
01/21/2015 02:00	0.0	0	0	0	0	1
01/21/2015 03:00	0.0	0	0	0	0	1
01/21/2015 04:00	0.0	0	0	0	0	1
01/21/2015 05:00	0.0	0	0	0	0	1
01/21/2015 06:00	0.0	0	0	0	0	1
01/21/2015 07:00	0.0	0	0	0	0	1
01/21/2015 08:00	0.0	0	0	0	0	1
01/21/2015 09:00	0.0	0	0	0	0	1
01/21/2015 10:00	0.0	0	0	0	0	1
01/21/2015 11:00	0.0	0	0	0	0	1
01/21/2015 12:00	0.0	0	0	0	0	1
01/21/2015 13:00	0.0	0	0	0	0	1
01/21/2015 14:00	0.0	0	0	0	0	1
01/21/2015 15:00	0.0	0	0	0	0	1
01/21/2015 16:00	0.0	0	0	0	0	1
01/21/2015 17:00	0.0	0	0	0	0	1
01/21/2015 18:00	0.0	0	0	0	0	1
01/21/2015 19:00	0.0	0	0	0	0	1
01/21/2015 20:00	0.0	0	0	0	0	1
01/21/2015 21:00	0.0	0	0	0	0	1
01/21/2015 22:00	0.0	0	0	0	0	1
01/21/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/22/2015 00:00	0.0	0	0	0	0	1
01/22/2015 01:00	0.0	0	0	0	0	1
01/22/2015 02:00	0.0	0	0	0	0	1
01/22/2015 03:00	0.0	0	0	0	0	1
01/22/2015 04:00	0.0	0	0	0	0	1
01/22/2015 05:00	0.0	0	0	0	0	1
01/22/2015 06:00	0.0	0	0	0	0	1
01/22/2015 07:00	0.0	0	0	0	0	1
01/22/2015 08:00	0.0	0	0	0	0	1
01/22/2015 09:00	0.0	0	0	0	0	1
01/22/2015 10:00	0.0	0	0	0	0	1
01/22/2015 11:00	0.0	0	0	0	0	1
01/22/2015 12:00	0.0	0	0	0	0	1
01/22/2015 13:00	0.0	0	0	0	0	1
01/22/2015 14:00	0.0	0	0	0	0	1
01/22/2015 15:00	0.0	0	0	0	0	1
01/22/2015 16:00	0.0	0	0	0	0	1
01/22/2015 17:00	0.0	0	0	0	0	1
01/22/2015 18:00	0.0	0	0	0	0	1
01/22/2015 19:00	0.0	0	0	0	0	1
01/22/2015 20:00	0.0	0	0	0	0	1
01/22/2015 21:00	0.0	0	0	0	0	1
01/22/2015 22:00	0.0	0	0	0	0	1
01/22/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/23/2015 00:00	0.0	0	0	0	0	1
01/23/2015 01:00	0.0	0	0	0	0	1
01/23/2015 02:00	0.0	0	0	0	0	1
01/23/2015 03:00	0.0	0	0	0	0	1
01/23/2015 04:00	0.0	0	0	0	0	1
01/23/2015 05:00	0.0	0	0	0	0	1
01/23/2015 06:00	0.0	0	0	0	0	1
01/23/2015 07:00	0.0	0	0	0	0	1
01/23/2015 08:00	0.0	0	0	0	0	1
01/23/2015 09:00	0.0	0	0	0	0	1
01/23/2015 10:00	0.0	0	0	0	0	1
01/23/2015 11:00	0.0	0	0	0	0	1
01/23/2015 12:00	0.0	0	0	0	0	1
01/23/2015 13:00	0.0	0	0	0	0	1
01/23/2015 14:00	0.0	0	0	0	0	1
01/23/2015 15:00	0.0	0	0	0	0	1
01/23/2015 16:00	0.0	0	0	0	0	1
01/23/2015 17:00	0.0	0	0	0	0	1
01/23/2015 18:00	0.0	0	0	0	0	1
01/23/2015 19:00	0.0	0	0	0	0	1
01/23/2015 20:00	0.0	0	0	0	0	1
01/23/2015 21:00	0.0	0	0	0	0	1
01/23/2015 22:00	0.0	0	0	0	0	1
01/23/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/24/2015 00:00	0.0	0	0	0	0	1
01/24/2015 01:00	0.0	0	0	0	0	1
01/24/2015 02:00	0.0	0	0	0	0	1
01/24/2015 03:00	0.0	0	0	0	0	1
01/24/2015 04:00	0.0	0	0	0	0	1
01/24/2015 05:00	0.0	0	0	0	0	1
01/24/2015 06:00	0.0	0	0	0	0	1
01/24/2015 07:00	0.0	0	0	0	0	1
01/24/2015 08:00	0.0	0	0	0	0	1
01/24/2015 09:00	0.0	0	0	0	0	1
01/24/2015 10:00	0.0	0	0	0	0	1
01/24/2015 11:00	0.0	0	0	0	0	1
01/24/2015 12:00	0.0	0	0	0	0	1
01/24/2015 13:00	0.0	0	0	0	0	1
01/24/2015 14:00	0.0	0	0	0	0	1
01/24/2015 15:00	0.0	0	0	0	0	1
01/24/2015 16:00	0.0	0	0	0	0	1
01/24/2015 17:00	0.0	0	0	0	0	1
01/24/2015 18:00	0.0	0	0	0	0	1
01/24/2015 19:00	0.0	0	0	0	0	1
01/24/2015 20:00	0.0	0	0	0	0	1
01/24/2015 21:00	0.0	0	0	0	0	1
01/24/2015 22:00	0.0	0	0	0	0	1
01/24/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/25/2015 00:00	0.0	0	0	0	0	1
01/25/2015 01:00	2.8	0	0	0	1	0
01/25/2015 02:00	0.0	0	0	0	0	0
01/25/2015 03:00	0.0	0	0	0	0	0
01/25/2015 04:00	0.0	0	0	0	0	0
01/25/2015 05:00	0.0	0	0	0	0	0
01/25/2015 06:00	0.0	0	0	0	0	0
01/25/2015 07:00	0.0	0	0	0	0	0
01/25/2015 08:00	0.0	0	0	0	0	0
01/25/2015 09:00	0.0	0	0	0	0	0
01/25/2015 10:00	0.0	0	0	0	0	0
01/25/2015 11:00	0.0	0	0	0	0	0
01/25/2015 12:00	54.9	0	1	0	0	0
01/25/2015 13:00	63.9	0	1	0	0	0
01/25/2015 14:00	3.2	0	1	0	0	0
01/25/2015 15:00	0.0	0	0	0	0	1
01/25/2015 16:00	0.0	0	0	0	0	1
01/25/2015 17:00	0.0	0	0	0	0	1
01/25/2015 18:00	0.0	0	0	0	0	1
01/25/2015 19:00	0.0	0	0	0	0	1
01/25/2015 20:00	0.0	0	0	0	0	1
01/25/2015 21:00	0.0	0	0	0	0	1
01/25/2015 22:00	2.1	0	0	0	1	0
01/25/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	126.9 #	0 #	3 #	0 #	2 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	63.9	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/26/2015 00:00	0.0	0	0	0	0	0
01/26/2015 01:00	0.0	0	0	0	0	0
01/26/2015 02:00	0.0	0	0	0	0	0
01/26/2015 03:00	0.0	0	0	0	0	0
01/26/2015 04:00	28.5	0	0	1	0	0
01/26/2015 05:00	16.8	0	0	1	0	0
01/26/2015 06:00	0.0	0	0	0	0	1
01/26/2015 07:00	0.0	0	0	0	0	1
01/26/2015 08:00	0.0	0	0	0	0	1
01/26/2015 09:00	0.0	0	0	0	0	1
01/26/2015 10:00	0.0	0	0	0	0	1
01/26/2015 11:00	0.0	0	0	0	0	1
01/26/2015 12:00	0.0	0	0	0	0	1
01/26/2015 13:00	0.0	0	0	0	0	1
01/26/2015 14:00	0.0	0	0	0	0	1
01/26/2015 15:00	0.0	0	0	0	0	1
01/26/2015 16:00	0.0	0	0	0	0	1
01/26/2015 17:00	0.0	0	0	0	0	1
01/26/2015 18:00	0.0	0	0	0	0	1
01/26/2015 19:00	0.0	0	0	0	0	1
01/26/2015 20:00	0.0	0	0	0	0	1
01/26/2015 21:00	0.0	0	0	0	0	1
01/26/2015 22:00	0.0	0	0	0	0	1
01/26/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	45.3 #	0 #	0 #	2 #	0 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	28.5	0	0	1	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/27/2015 00:00	0.0	0	0	0	0	1
01/27/2015 01:00	0.0	0	0	0	0	1
01/27/2015 02:00	0.0	0	0	0	0	1
01/27/2015 03:00	0.0	0	0	0	0	1
01/27/2015 04:00	0.0	0	0	0	0	1
01/27/2015 05:00	0.0	0	0	0	0	1
01/27/2015 06:00	0.0	0	0	0	0	1
01/27/2015 07:00	0.0	0	0	0	0	1
01/27/2015 08:00	0.0	0	0	0	0	1
01/27/2015 09:00	0.0	0	0	0	0	1
01/27/2015 10:00	0.0	0	0	0	0	1
01/27/2015 11:00	0.0	0	0	0	0	1
01/27/2015 12:00	0.0	0	0	0	0	1
01/27/2015 13:00	0.0	0	0	0	0	1
01/27/2015 14:00	0.0	0	0	0	0	1
01/27/2015 15:00	0.0	0	0	0	0	1
01/27/2015 16:00	0.0	0	0	0	0	1
01/27/2015 17:00	0.0	0	0	0	0	1
01/27/2015 18:00	0.0	0	0	0	0	1
01/27/2015 19:00	0.0	0	0	0	0	1
01/27/2015 20:00	0.0	0	0	0	0	1
01/27/2015 21:00	0.0	0	0	0	0	1
01/27/2015 22:00	0.0	0	0	0	0	1
01/27/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/28/2015 00:00	0.0	0	0	0	0	1
01/28/2015 01:00	0.0	0	0	0	0	1
01/28/2015 02:00	0.0	0	0	0	0	1
01/28/2015 03:00	0.0	0	0	0	0	1
01/28/2015 04:00	0.0	0	0	0	0	1
01/28/2015 05:00	0.0	0	0	0	0	1
01/28/2015 06:00	0.0	0	0	0	0	1
01/28/2015 07:00	0.0	0	0	0	0	1
01/28/2015 08:00	0.0	0	0	0	0	1
01/28/2015 09:00	0.0	0	0	0	0	1
01/28/2015 10:00	0.0	0	0	0	0	1
01/28/2015 11:00	0.0	0	0	0	0	1
01/28/2015 12:00	0.0	0	0	0	0	1
01/28/2015 13:00	0.0	0	0	0	0	1
01/28/2015 14:00	0.0	0	0	0	0	1
01/28/2015 15:00	0.0	0	0	0	0	1
01/28/2015 16:00	0.0	0	0	0	0	1
01/28/2015 17:00	0.0	0	0	0	0	1
01/28/2015 18:00	0.0	0	0	0	0	1
01/28/2015 19:00	0.0	0	0	0	0	1
01/28/2015 20:00	0.0	0	0	0	0	1
01/28/2015 21:00	0.0	0	0	0	0	1
01/28/2015 22:00	0.0	0	0	0	0	1
01/28/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/29/2015 00:00	0.0	0	0	0	0	1
01/29/2015 01:00	0.0	0	0	0	0	1
01/29/2015 02:00	0.0	0	0	0	0	1
01/29/2015 03:00	0.0	0	0	0	0	1
01/29/2015 04:00	0.0	0	0	0	0	1
01/29/2015 05:00	0.0	0	0	0	0	1
01/29/2015 06:00	0.0	0	0	0	0	1
01/29/2015 07:00	0.0	0	0	0	0	1
01/29/2015 08:00	0.0	0	0	0	0	1
01/29/2015 09:00	0.0	0	0	0	0	1
01/29/2015 10:00	0.0	0	0	0	0	1
01/29/2015 11:00	0.0	0	0	0	0	1
01/29/2015 12:00	0.0	0	0	0	0	1
01/29/2015 13:00	0.0	0	0	0	0	1
01/29/2015 14:00	0.0	0	0	0	0	1
01/29/2015 15:00	0.0	0	0	0	0	1
01/29/2015 16:00	0.0	0	0	0	0	1
01/29/2015 17:00	0.0	0	0	0	0	1
01/29/2015 18:00	0.0	0	0	0	0	1
01/29/2015 19:00	0.0	0	0	0	0	1
01/29/2015 20:00	0.0	0	0	0	0	1
01/29/2015 21:00	0.0	0	0	0	0	1
01/29/2015 22:00	0.0	0	0	0	0	1
01/29/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/30/2015 00:00	0.0	0	0	0	0	1
01/30/2015 01:00	0.0	0	0	0	0	1
01/30/2015 02:00	0.0	0	0	0	0	1
01/30/2015 03:00	0.0	0	0	0	0	1
01/30/2015 04:00	0.0	0	0	0	0	1
01/30/2015 05:00	0.0	0	0	0	0	1
01/30/2015 06:00	0.0	0	0	0	0	1
01/30/2015 07:00	0.0	0	0	0	0	1
01/30/2015 08:00	0.0	0	0	0	0	1
01/30/2015 09:00	0.0	0	0	0	0	1
01/30/2015 10:00	0.0	0	0	0	0	1
01/30/2015 11:00	0.0	0	0	0	0	1
01/30/2015 12:00	0.0	0	0	0	0	1
01/30/2015 13:00	0.0	0	0	0	0	1
01/30/2015 14:00	0.0	0	0	0	0	1
01/30/2015 15:00	0.0	0	0	0	0	1
01/30/2015 16:00	0.0	0	0	0	0	1
01/30/2015 17:00	0.0	0	0	0	0	1
01/30/2015 18:00	0.0	0	0	0	0	1
01/30/2015 19:00	0.0	0	0	0	0	1
01/30/2015 20:00	0.0	0	0	0	0	1
01/30/2015 21:00	0.0	0	0	0	0	1
01/30/2015 22:00	0.0	0	0	0	0	1
01/30/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/31/2015 00:00	3.0	0	0	0	1	0
01/31/2015 01:00	0.0	0	0	0	0	0
01/31/2015 02:00	0.0	0	0	0	0	0
01/31/2015 03:00	33.8	0	0	1	0	0
01/31/2015 04:00	27.3	0	0	1	0	0
01/31/2015 05:00	0.0	0	0	0	0	1
01/31/2015 06:00	0.0	0	0	0	0	1
01/31/2015 07:00	0.0	0	0	0	0	1
01/31/2015 08:00	0.0	0	0	0	0	1
01/31/2015 09:00	0.0	0	0	0	0	1
01/31/2015 10:00	0.0	0	0	0	0	1
01/31/2015 11:00	0.0	0	0	0	0	1
01/31/2015 12:00	0.0	0	0	0	0	1
01/31/2015 13:00	0.0	0	0	0	0	1
01/31/2015 14:00	0.0	0	0	0	0	1
01/31/2015 15:00	0.0	0	0	0	0	1
01/31/2015 16:00	0.0	0	0	0	0	1
01/31/2015 17:00	0.0	0	0	0	0	1
01/31/2015 18:00	0.0	0	0	0	0	1
01/31/2015 19:00	0.0	0	0	0	0	1
01/31/2015 20:00	0.0	0	0	0	0	1
01/31/2015 21:00	0.0	0	0	0	0	1
01/31/2015 22:00	0.0	0	0	0	0	1
01/31/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	64.1 #	0 #	0 #	2 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	33.8	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/01/2015 00:00	0.0	0	0	0	0	1
02/01/2015 01:00	0.0	0	0	0	0	1
02/01/2015 02:00	2.9	0	0	0	1	0
02/01/2015 03:00	0.0	0	0	0	0	0
02/01/2015 04:00	0.0	0	0	0	0	0
02/01/2015 05:00	0.0	0	0	0	0	0
02/01/2015 06:00	0.0	0	0	0	0	0
02/01/2015 07:00	0.0	0	0	0	0	0
02/01/2015 08:00	0.0	0	0	0	0	0
02/01/2015 09:00	0.0	0	0	0	0	0
02/01/2015 10:00	31.1	0	1	0	0	0
02/01/2015 11:00	59.6	0	1	0	0	0
02/01/2015 12:00	0.0	0	0	0	0	1
02/01/2015 13:00	0.0	0	0	0	0	1
02/01/2015 14:00	0.0	0	0	0	0	1
02/01/2015 15:00	0.0	0	0	0	0	1
02/01/2015 16:00	0.0	0	0	0	0	1
02/01/2015 17:00	0.0	0	0	0	0	1
02/01/2015 18:00	0.0	0	0	0	0	1
02/01/2015 19:00	0.0	0	0	0	0	1
02/01/2015 20:00	0.0	0	0	0	0	1
02/01/2015 21:00	0.0	0	0	0	0	1
02/01/2015 22:00	0.0	0	0	0	0	1
02/01/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	93.6 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	59.6	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/02/2015 00:00	0.0	0	0	0	0	1
02/02/2015 01:00	0.0	0	0	0	0	1
02/02/2015 02:00	0.0	0	0	0	0	1
02/02/2015 03:00	0.0	0	0	0	0	1
02/02/2015 04:00	0.0	0	0	0	0	1
02/02/2015 05:00	0.0	0	0	0	0	1
02/02/2015 06:00	0.0	0	0	0	0	1
02/02/2015 07:00	0.0	0	0	0	0	1
02/02/2015 08:00	0.0	0	0	0	0	1
02/02/2015 09:00	0.0	0	0	0	0	1
02/02/2015 10:00	0.0	0	0	0	0	1
02/02/2015 11:00	0.0	0	0	0	0	1
02/02/2015 12:00	0.0	0	0	0	0	1
02/02/2015 13:00	0.0	0	0	0	0	1
02/02/2015 14:00	0.0	0	0	0	0	1
02/02/2015 15:00	0.0	0	0	0	0	1
02/02/2015 16:00	0.0	0	0	0	0	1
02/02/2015 17:00	0.0	0	0	0	0	1
02/02/2015 18:00	0.0	0	0	0	0	1
02/02/2015 19:00	0.0	0	0	0	0	1
02/02/2015 20:00	0.0	0	0	0	0	1
02/02/2015 21:00	0.0	0	0	0	0	1
02/02/2015 22:00	0.0	0	0	0	0	1
02/02/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/03/2015 00:00	0.0	0	0	0	0	1
02/03/2015 01:00	0.0	0	0	0	0	1
02/03/2015 02:00	0.0	0	0	0	0	1
02/03/2015 03:00	0.0	0	0	0	0	1
02/03/2015 04:00	0.0	0	0	0	0	1
02/03/2015 05:00	0.0	0	0	0	0	1
02/03/2015 06:00	0.0	0	0	0	0	1
02/03/2015 07:00	0.0	0	0	0	0	1
02/03/2015 08:00	0.0	0	0	0	0	1
02/03/2015 09:00	0.0	0	0	0	0	1
02/03/2015 10:00	0.0	0	0	0	0	1
02/03/2015 11:00	0.0	0	0	0	0	1
02/03/2015 12:00	0.0	0	0	0	0	1
02/03/2015 13:00	0.0	0	0	0	0	1
02/03/2015 14:00	0.0	0	0	0	0	1
02/03/2015 15:00	0.0	0	0	0	0	1
02/03/2015 16:00	0.0	0	0	0	0	1
02/03/2015 17:00	0.0	0	0	0	0	1
02/03/2015 18:00	0.0	0	0	0	0	1
02/03/2015 19:00	0.0	0	0	0	0	1
02/03/2015 20:00	0.0	0	0	0	0	1
02/03/2015 21:00	0.0	0	0	0	0	1
02/03/2015 22:00	0.0	0	0	0	0	1
02/03/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/04/2015 00:00	0.0	0	0	0	0	1
02/04/2015 01:00	0.0	0	0	0	0	1
02/04/2015 02:00	0.0	0	0	0	0	1
02/04/2015 03:00	0.0	0	0	0	0	1
02/04/2015 04:00	0.0	0	0	0	0	1
02/04/2015 05:00	0.0	0	0	0	0	1
02/04/2015 06:00	0.0	0	0	0	0	1
02/04/2015 07:00	0.0	0	0	0	0	1
02/04/2015 08:00	0.0	0	0	0	0	1
02/04/2015 09:00	0.0	0	0	0	0	1
02/04/2015 10:00	0.0	0	0	0	0	1
02/04/2015 11:00	0.0	0	0	0	0	1
02/04/2015 12:00	0.0	0	0	0	0	1
02/04/2015 13:00	0.0	0	0	0	0	1
02/04/2015 14:00	0.0	0	0	0	0	1
02/04/2015 15:00	0.0	0	0	0	0	1
02/04/2015 16:00	0.0	0	0	0	0	1
02/04/2015 17:00	0.0	0	0	0	0	1
02/04/2015 18:00	0.0	0	0	0	0	1
02/04/2015 19:00	0.0	0	0	0	0	1
02/04/2015 20:00	0.0	0	0	0	0	1
02/04/2015 21:00	0.0	0	0	0	0	1
02/04/2015 22:00	0.0	0	0	0	0	1
02/04/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/05/2015 00:00	0.0	0	0	0	0	1
02/05/2015 01:00	0.0	0	0	0	0	1
02/05/2015 02:00	0.0	0	0	0	0	1
02/05/2015 03:00	0.0	0	0	0	0	1
02/05/2015 04:00	0.0	0	0	0	0	1
02/05/2015 05:00	0.0	0	0	0	0	1
02/05/2015 06:00	0.0	0	0	0	0	1
02/05/2015 07:00	0.0	0	0	0	0	1
02/05/2015 08:00	0.0	0	0	0	0	1
02/05/2015 09:00	0.0	0	0	0	0	1
02/05/2015 10:00	0.0	0	0	0	0	1
02/05/2015 11:00	0.0	0	0	0	0	1
02/05/2015 12:00	0.0	0	0	0	0	1
02/05/2015 13:00	0.0	0	0	0	0	1
02/05/2015 14:00	0.0	0	0	0	0	1
02/05/2015 15:00	0.0	0	0	0	0	1
02/05/2015 16:00	0.0	0	0	0	0	1
02/05/2015 17:00	0.0	0	0	0	0	1
02/05/2015 18:00	0.0	0	0	0	0	1
02/05/2015 19:00	0.0	0	0	0	0	1
02/05/2015 20:00	0.0	0	0	0	0	1
02/05/2015 21:00	0.0	0	0	0	0	1
02/05/2015 22:00	0.0	0	0	0	0	1
02/05/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/06/2015 00:00	0.0	0	0	0	0	1
02/06/2015 01:00	0.0	0	0	0	0	1
02/06/2015 02:00	0.0	0	0	0	0	1
02/06/2015 03:00	0.0	0	0	0	0	1
02/06/2015 04:00	0.0	0	0	0	0	1
02/06/2015 05:00	0.0	0	0	0	0	1
02/06/2015 06:00	0.0	0	0	0	0	1
02/06/2015 07:00	0.0	0	0	0	0	1
02/06/2015 08:00	0.0	0	0	0	0	1
02/06/2015 09:00	0.0	0	0	0	0	1
02/06/2015 10:00	0.0	0	0	0	0	1
02/06/2015 11:00	0.0	0	0	0	0	1
02/06/2015 12:00	0.0	0	0	0	0	1
02/06/2015 13:00	0.0	0	0	0	0	1
02/06/2015 14:00	0.0	0	0	0	0	1
02/06/2015 15:00	0.0	0	0	0	0	1
02/06/2015 16:00	0.0	0	0	0	0	1
02/06/2015 17:00	0.0	0	0	0	0	1
02/06/2015 18:00	0.0	0	0	0	0	1
02/06/2015 19:00	0.0	0	0	0	0	1
02/06/2015 20:00	0.0	0	0	0	0	1
02/06/2015 21:00	0.0	0	0	0	0	1
02/06/2015 22:00	0.0	0	0	0	0	1
02/06/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/07/2015 00:00	0.0	0	0	0	0	1
02/07/2015 01:00	0.0	0	0	0	0	1
02/07/2015 02:00	0.0	0	0	0	0	1
02/07/2015 03:00	0.0	0	0	0	0	1
02/07/2015 04:00	0.0	0	0	0	0	1
02/07/2015 05:00	0.0	0	0	0	0	1
02/07/2015 06:00	0.0	0	0	0	0	1
02/07/2015 07:00	0.0	0	0	0	0	1
02/07/2015 08:00	0.0	0	0	0	0	1
02/07/2015 09:00	0.0	0	0	0	0	1
02/07/2015 10:00	0.0	0	0	0	0	1
02/07/2015 11:00	0.0	0	0	0	0	1
02/07/2015 12:00	0.0	0	0	0	0	1
02/07/2015 13:00	0.0	0	0	0	0	1
02/07/2015 14:00	0.0	0	0	0	0	1
02/07/2015 15:00	0.0	0	0	0	0	1
02/07/2015 16:00	0.0	0	0	0	0	1
02/07/2015 17:00	0.0	0	0	0	0	1
02/07/2015 18:00	0.0	0	0	0	0	1
02/07/2015 19:00	0.0	0	0	0	0	1
02/07/2015 20:00	0.0	0	0	0	0	1
02/07/2015 21:00	0.0	0	0	0	0	1
02/07/2015 22:00	0.0	0	0	0	0	1
02/07/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/08/2015 00:00	0.0	0	0	0	0	1
02/08/2015 01:00	0.0	0	0	0	0	1
02/08/2015 02:00	0.0	0	0	0	0	1
02/08/2015 03:00	0.0	0	0	0	0	1
02/08/2015 04:00	0.0	0	0	0	0	1
02/08/2015 05:00	0.0	0	0	0	0	1
02/08/2015 06:00	0.0	0	0	0	0	1
02/08/2015 07:00	0.0	0	0	0	0	1
02/08/2015 08:00	0.0	0	0	0	0	1
02/08/2015 09:00	0.0	0	0	0	0	1
02/08/2015 10:00	0.0	0	0	0	0	1
02/08/2015 11:00	0.0	0	0	0	0	1
02/08/2015 12:00	0.0	0	0	0	0	1
02/08/2015 13:00	0.0	0	0	0	0	1
02/08/2015 14:00	0.0	0	0	0	0	1
02/08/2015 15:00	0.0	0	0	0	0	1
02/08/2015 16:00	0.0	0	0	0	0	1
02/08/2015 17:00	0.0	0	0	0	0	1
02/08/2015 18:00	0.0	0	0	0	0	1
02/08/2015 19:00	0.0	0	0	0	0	1
02/08/2015 20:00	0.0	0	0	0	0	1
02/08/2015 21:00	0.0	0	0	0	0	1
02/08/2015 22:00	0.0	0	0	0	0	1
02/08/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/09/2015 00:00	0.0	0	0	0	0	1
02/09/2015 01:00	0.0	0	0	0	0	1
02/09/2015 02:00	0.0	0	0	0	0	1
02/09/2015 03:00	0.0	0	0	0	0	1
02/09/2015 04:00	0.0	0	0	0	0	1
02/09/2015 05:00	0.0	0	0	0	0	1
02/09/2015 06:00	0.0	0	0	0	0	1
02/09/2015 07:00	0.0	0	0	0	0	1
02/09/2015 08:00	0.0	0	0	0	0	1
02/09/2015 09:00	0.0	0	0	0	0	1
02/09/2015 10:00	0.0	0	0	0	0	1
02/09/2015 11:00	0.0	0	0	0	0	1
02/09/2015 12:00	0.0	0	0	0	0	1
02/09/2015 13:00	0.0	0	0	0	0	1
02/09/2015 14:00	0.0	0	0	0	0	1
02/09/2015 15:00	0.0	0	0	0	0	1
02/09/2015 16:00	0.0	0	0	0	0	1
02/09/2015 17:00	0.0	0	0	0	0	1
02/09/2015 18:00	0.0	0	0	0	0	1
02/09/2015 19:00	0.0	0	0	0	0	1
02/09/2015 20:00	0.0	0	0	0	0	1
02/09/2015 21:00	0.0	0	0	0	0	1
02/09/2015 22:00	0.0	0	0	0	0	1
02/09/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/10/2015 00:00	0.0	0	0	0	0	1
02/10/2015 01:00	0.0	0	0	0	0	1
02/10/2015 02:00	0.0	0	0	0	0	1
02/10/2015 03:00	0.0	0	0	0	0	1
02/10/2015 04:00	0.0	0	0	0	0	1
02/10/2015 05:00	0.0	0	0	0	0	1
02/10/2015 06:00	0.0	0	0	0	0	1
02/10/2015 07:00	0.0	0	0	0	0	1
02/10/2015 08:00	0.0	0	0	0	0	1
02/10/2015 09:00	0.0	0	0	0	0	1
02/10/2015 10:00	0.0	0	0	0	0	1
02/10/2015 11:00	0.0	0	0	0	0	1
02/10/2015 12:00	0.0	0	0	0	0	1
02/10/2015 13:00	0.0	0	0	0	0	1
02/10/2015 14:00	0.0	0	0	0	0	1
02/10/2015 15:00	0.0	0	0	0	0	1
02/10/2015 16:00	0.0	0	0	0	0	1
02/10/2015 17:00	0.0	0	0	0	0	1
02/10/2015 18:00	0.0	0	0	0	0	1
02/10/2015 19:00	0.0	0	0	0	0	1
02/10/2015 20:00	0.0	0	0	0	0	1
02/10/2015 21:00	0.0	0	0	0	0	1
02/10/2015 22:00	0.0	0	0	0	0	1
02/10/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/11/2015 00:00	0.0	0	0	0	0	1
02/11/2015 01:00	0.0	0	0	0	0	1
02/11/2015 02:00	0.0	0	0	0	0	1
02/11/2015 03:00	0.0	0	0	0	0	1
02/11/2015 04:00	0.0	0	0	0	0	1
02/11/2015 05:00	0.0	0	0	0	0	1
02/11/2015 06:00	0.0	0	0	0	0	1
02/11/2015 07:00	0.0	0	0	0	0	1
02/11/2015 08:00	0.0	0	0	0	0	1
02/11/2015 09:00	0.0	0	0	0	0	1
02/11/2015 10:00	0.0	0	0	0	0	1
02/11/2015 11:00	0.0	0	0	0	0	1
02/11/2015 12:00	0.0	0	0	0	0	1
02/11/2015 13:00	0.0	0	0	0	0	1
02/11/2015 14:00	0.0	0	0	0	0	1
02/11/2015 15:00	0.0	0	0	0	0	1
02/11/2015 16:00	0.0	0	0	0	0	1
02/11/2015 17:00	0.0	0	0	0	0	1
02/11/2015 18:00	0.0	0	0	0	0	1
02/11/2015 19:00	0.0	0	0	0	0	1
02/11/2015 20:00	0.0	0	0	0	0	1
02/11/2015 21:00	0.0	0	0	0	0	1
02/11/2015 22:00	0.0	0	0	0	0	1
02/11/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/12/2015 00:00	0.0	0	0	0	0	1
02/12/2015 01:00	0.0	0	0	0	0	1
02/12/2015 02:00	0.0	0	0	0	0	1
02/12/2015 03:00	0.0	0	0	0	0	1
02/12/2015 04:00	0.0	0	0	0	0	1
02/12/2015 05:00	0.0	0	0	0	0	1
02/12/2015 06:00	0.0	0	0	0	0	1
02/12/2015 07:00	0.0	0	0	0	0	1
02/12/2015 08:00	0.0	0	0	0	0	1
02/12/2015 09:00	0.0	0	0	0	0	1
02/12/2015 10:00	0.0	0	0	0	0	1
02/12/2015 11:00	0.0	0	0	0	0	1
02/12/2015 12:00	0.0	0	0	0	0	1
02/12/2015 13:00	0.0	0	0	0	0	1
02/12/2015 14:00	0.0	0	0	0	0	1
02/12/2015 15:00	0.0	0	0	0	0	1
02/12/2015 16:00	0.0	0	0	0	0	1
02/12/2015 17:00	0.0	0	0	0	0	1
02/12/2015 18:00	0.0	0	0	0	0	1
02/12/2015 19:00	0.0	0	0	0	0	1
02/12/2015 20:00	0.0	0	0	0	0	1
02/12/2015 21:00	0.0	0	0	0	0	1
02/12/2015 22:00	0.0	0	0	0	0	1
02/12/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/13/2015 00:00	0.0	0	0	0	0	1
02/13/2015 01:00	0.0	0	0	0	0	1
02/13/2015 02:00	0.0	0	0	0	0	1
02/13/2015 03:00	0.0	0	0	0	0	1
02/13/2015 04:00	0.0	0	0	0	0	1
02/13/2015 05:00	0.0	0	0	0	0	1
02/13/2015 06:00	0.0	0	0	0	0	1
02/13/2015 07:00	0.0	0	0	0	0	1
02/13/2015 08:00	0.0	0	0	0	0	1
02/13/2015 09:00	0.0	0	0	0	0	1
02/13/2015 10:00	0.0	0	0	0	0	1
02/13/2015 11:00	0.0	0	0	0	0	1
02/13/2015 12:00	0.0	0	0	0	0	1
02/13/2015 13:00	0.0	0	0	0	0	1
02/13/2015 14:00	0.0	0	0	0	0	1
02/13/2015 15:00	0.0	0	0	0	0	1
02/13/2015 16:00	0.0	0	0	0	0	1
02/13/2015 17:00	0.0	0	0	0	0	1
02/13/2015 18:00	0.0	0	0	0	0	1
02/13/2015 19:00	0.0	0	0	0	0	1
02/13/2015 20:00	0.0	0	0	0	0	1
02/13/2015 21:00	0.0	0	0	0	0	1
02/13/2015 22:00	0.0	0	0	0	0	1
02/13/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/14/2015 00:00	0.0	0	0	0	0	1
02/14/2015 01:00	0.0	0	0	0	0	1
02/14/2015 02:00	0.0	0	0	0	0	1
02/14/2015 03:00	0.0	0	0	0	0	1
02/14/2015 04:00	0.0	0	0	0	0	1
02/14/2015 05:00	0.0	0	0	0	0	1
02/14/2015 06:00	0.0	0	0	0	0	1
02/14/2015 07:00	0.0	0	0	0	0	1
02/14/2015 08:00	0.0	0	0	0	0	1
02/14/2015 09:00	0.0	0	0	0	0	1
02/14/2015 10:00	0.0	0	0	0	0	1
02/14/2015 11:00	0.0	0	0	0	0	1
02/14/2015 12:00	0.0	0	0	0	0	1
02/14/2015 13:00	0.0	0	0	0	0	1
02/14/2015 14:00	0.0	0	0	0	0	1
02/14/2015 15:00	0.0	0	0	0	0	1
02/14/2015 16:00	0.0	0	0	0	0	1
02/14/2015 17:00	0.0	0	0	0	0	1
02/14/2015 18:00	0.0	0	0	0	0	1
02/14/2015 19:00	0.0	0	0	0	0	1
02/14/2015 20:00	0.0	0	0	0	0	1
02/14/2015 21:00	0.0	0	0	0	0	1
02/14/2015 22:00	0.0	0	0	0	0	1
02/14/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/15/2015 00:00	0.0	0	0	0	0	1
02/15/2015 01:00	0.0	0	0	0	0	1
02/15/2015 02:00	3.5	0	0	0	1	0
02/15/2015 03:00	0.0	0	0	0	0	0
02/15/2015 04:00	0.0	0	0	0	0	0
02/15/2015 05:00	0.0	0	0	0	0	0
02/15/2015 06:00	0.0	0	0	0	0	0
02/15/2015 07:00	0.0	0	0	0	0	0
02/15/2015 08:00	0.0	0	0	0	0	0
02/15/2015 09:00	0.0	0	0	0	0	0
02/15/2015 10:00	0.0	0	0	0	0	0
02/15/2015 11:00	0.0	0	0	0	0	0
02/15/2015 12:00	0.0	0	0	0	0	0
02/15/2015 13:00	0.0	0	0	0	0	0
02/15/2015 14:00	0.0	0	0	0	0	0
02/15/2015 15:00	0.0	0	0	0	0	0
02/15/2015 16:00	12.9	0	1	0	0	0
02/15/2015 17:00	19.6	0	1	0	0	0
02/15/2015 18:00	0.0	0	0	0	0	1
02/15/2015 19:00	0.0	0	0	0	0	1
02/15/2015 20:00	0.0	0	0	0	0	1
02/15/2015 21:00	0.0	0	0	0	0	1
02/15/2015 22:00	0.0	0	0	0	0	1
02/15/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	36.0 #	0 #	2 #	0 #	1 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	19.6	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/16/2015 00:00	0.0	0	0	0	0	1
02/16/2015 01:00	0.0	0	0	0	0	1
02/16/2015 02:00	0.0	0	0	0	0	1
02/16/2015 03:00	0.0	0	0	0	0	1
02/16/2015 04:00	0.0	0	0	0	0	1
02/16/2015 05:00	0.0	0	0	0	0	1
02/16/2015 06:00	0.0	0	0	0	0	1
02/16/2015 07:00	0.0	0	0	0	0	1
02/16/2015 08:00	0.0	0	0	0	0	1
02/16/2015 09:00	0.0	0	0	0	0	1
02/16/2015 10:00	0.0	0	0	0	0	1
02/16/2015 11:00	0.0	0	0	0	0	1
02/16/2015 12:00	0.0	0	0	0	0	1
02/16/2015 13:00	0.0	0	0	0	0	1
02/16/2015 14:00	0.0	0	0	0	0	1
02/16/2015 15:00	0.0	0	0	0	0	1
02/16/2015 16:00	0.0	0	0	0	0	1
02/16/2015 17:00	0.0	0	0	0	0	1
02/16/2015 18:00	0.0	0	0	0	0	1
02/16/2015 19:00	0.0	0	0	0	0	1
02/16/2015 20:00	0.0	0	0	0	0	1
02/16/2015 21:00	0.0	0	0	0	0	1
02/16/2015 22:00	0.0	0	0	0	0	1
02/16/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/17/2015 00:00	0.0	0	0	0	0	1
02/17/2015 01:00	0.0	0	0	0	0	1
02/17/2015 02:00	0.0	0	0	0	0	1
02/17/2015 03:00	0.0	0	0	0	0	1
02/17/2015 04:00	0.0	0	0	0	0	1
02/17/2015 05:00	0.0	0	0	0	0	1
02/17/2015 06:00	0.0	0	0	0	0	1
02/17/2015 07:00	0.0	0	0	0	0	1
02/17/2015 08:00	0.0	0	0	0	0	1
02/17/2015 09:00	0.0	0	0	0	0	1
02/17/2015 10:00	0.0	0	0	0	0	1
02/17/2015 11:00	0.0	0	0	0	0	1
02/17/2015 12:00	0.0	0	0	0	0	1
02/17/2015 13:00	0.0	0	0	0	0	1
02/17/2015 14:00	0.0	0	0	0	0	1
02/17/2015 15:00	0.0	0	0	0	0	1
02/17/2015 16:00	0.0	0	0	0	0	1
02/17/2015 17:00	0.0	0	0	0	0	1
02/17/2015 18:00	0.0	0	0	0	0	1
02/17/2015 19:00	0.0	0	0	0	0	1
02/17/2015 20:00	0.0	0	0	0	0	1
02/17/2015 21:00	0.0	0	0	0	0	1
02/17/2015 22:00	0.0	0	0	0	0	1
02/17/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/18/2015 00:00	0.0	0	0	0	0	1
02/18/2015 01:00	0.0	0	0	0	0	1
02/18/2015 02:00	0.0	0	0	0	0	1
02/18/2015 03:00	0.0	0	0	0	0	1
02/18/2015 04:00	0.0	0	0	0	0	1
02/18/2015 05:00	0.0	0	0	0	0	1
02/18/2015 06:00	0.0	0	0	0	0	1
02/18/2015 07:00	0.0	0	0	0	0	1
02/18/2015 08:00	0.0	0	0	0	0	1
02/18/2015 09:00	0.0	0	0	0	0	1
02/18/2015 10:00	0.0	0	0	0	0	1
02/18/2015 11:00	0.0	0	0	0	0	1
02/18/2015 12:00	0.0	0	0	0	0	1
02/18/2015 13:00	0.0	0	0	0	0	1
02/18/2015 14:00	0.0	0	0	0	0	1
02/18/2015 15:00	0.0	0	0	0	0	1
02/18/2015 16:00	0.0	0	0	0	0	1
02/18/2015 17:00	0.0	0	0	0	0	1
02/18/2015 18:00	0.0	0	0	0	0	1
02/18/2015 19:00	0.0	0	0	0	0	1
02/18/2015 20:00	0.0	0	0	0	0	1
02/18/2015 21:00	0.0	0	0	0	0	1
02/18/2015 22:00	0.0	0	0	0	0	1
02/18/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/19/2015 00:00	0.0	0	0	0	0	1
02/19/2015 01:00	0.0	0	0	0	0	1
02/19/2015 02:00	0.0	0	0	0	0	1
02/19/2015 03:00	0.0	0	0	0	0	1
02/19/2015 04:00	0.0	0	0	0	0	1
02/19/2015 05:00	0.0	0	0	0	0	1
02/19/2015 06:00	0.0	0	0	0	0	1
02/19/2015 07:00	0.0	0	0	0	0	1
02/19/2015 08:00	0.0	0	0	0	0	1
02/19/2015 09:00	0.0	0	0	0	0	1
02/19/2015 10:00	0.0	0	0	0	0	1
02/19/2015 11:00	0.0	0	0	0	0	1
02/19/2015 12:00	0.0	0	0	0	0	1
02/19/2015 13:00	0.0	0	0	0	0	1
02/19/2015 14:00	0.0	0	0	0	0	1
02/19/2015 15:00	0.0	0	0	0	0	1
02/19/2015 16:00	0.0	0	0	0	0	1
02/19/2015 17:00	0.0	0	0	0	0	1
02/19/2015 18:00	0.0	0	0	0	0	1
02/19/2015 19:00	0.0	0	0	0	0	1
02/19/2015 20:00	0.0	0	0	0	0	1
02/19/2015 21:00	0.0	0	0	0	0	1
02/19/2015 22:00	0.0	0	0	0	0	1
02/19/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/20/2015 00:00	0.0	0	0	0	0	1
02/20/2015 01:00	3.7	0	0	0	1	0
02/20/2015 02:00	0.0	0	0	0	0	0
02/20/2015 03:00	0.0	0	0	0	0	0
02/20/2015 04:00	0.0	0	0	0	0	0
02/20/2015 05:00	0.0	0	0	0	0	0
02/20/2015 06:00	0.0	0	0	0	0	0
02/20/2015 07:00	0.0	0	0	0	0	0
02/20/2015 08:00	0.0	0	0	0	0	0
02/20/2015 09:00	0.0	0	0	0	0	0
02/20/2015 10:00	0.0	0	0	0	0	0
02/20/2015 11:00	0.0	0	0	0	0	0
02/20/2015 12:00	0.0	0	0	0	0	0
02/20/2015 13:00	0.0	0	0	0	0	0
02/20/2015 14:00	0.0	0	0	0	0	0
02/20/2015 15:00	0.0	0	0	0	0	0
02/20/2015 16:00	0.0	0	0	0	0	0
02/20/2015 17:00	0.0	0	0	0	0	0
02/20/2015 18:00	0.0	0	0	0	0	0
02/20/2015 19:00	0.0	0	0	0	0	0
02/20/2015 20:00	0.0	0	0	0	0	0
02/20/2015 21:00	0.0	0	0	0	0	0
02/20/2015 22:00	0.0	0	0	0	0	0
02/20/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	3.7 #	0 #	0 #	0 #	1 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3.7	0	0	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/21/2015 00:00	0.0	0	0	0	0	0
02/21/2015 01:00	0.0	0	0	0	0	0
02/21/2015 02:00	0.0	0	0	0	0	0
02/21/2015 03:00	0.0	0	0	0	0	0
02/21/2015 04:00	0.0	0	0	0	0	0
02/21/2015 05:00	0.0	0	0	0	0	0
02/21/2015 06:00	0.0	0	0	0	0	0
02/21/2015 07:00	0.0	0	0	0	0	0
02/21/2015 08:00	0.0	0	0	0	0	0
02/21/2015 09:00	0.0	0	0	0	0	0
02/21/2015 10:00	0.0	0	0	0	0	0
02/21/2015 11:00	0.0	0	0	0	0	0
02/21/2015 12:00	0.0	0	0	0	0	0
02/21/2015 13:00	0.0	0	0	0	0	0
02/21/2015 14:00	0.0	0	0	0	0	0
02/21/2015 15:00	169.5	0	1	0	0	0
02/21/2015 16:00	20.7	0	1	0	0	0
02/21/2015 17:00	0.0	0	0	0	0	1
02/21/2015 18:00	0.0	0	0	0	0	1
02/21/2015 19:00	0.0	0	0	0	0	1
02/21/2015 20:00	0.0	0	0	0	0	1
02/21/2015 21:00	0.0	0	0	0	0	1
02/21/2015 22:00	0.0	0	0	0	0	1
02/21/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	190.2 #	0 #	2 #	0 #	0 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	169.5	0	1	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/22/2015 00:00	0.0	0	0	0	0	1
02/22/2015 01:00	0.0	0	0	0	0	1
02/22/2015 02:00	0.0	0	0	0	0	1
02/22/2015 03:00	0.0	0	0	0	0	1
02/22/2015 04:00	0.0	0	0	0	0	1
02/22/2015 05:00	0.0	0	0	0	0	1
02/22/2015 06:00	3.5	0	0	0	1	0
02/22/2015 07:00	0.0	0	0	0	0	0
02/22/2015 08:00	0.0	0	0	0	0	0
02/22/2015 09:00	0.0	0	0	0	0	0
02/22/2015 10:00	0.0	0	0	0	0	0
02/22/2015 11:00	0.0	0	0	0	0	0
02/22/2015 12:00	0.0	0	0	0	0	0
02/22/2015 13:00	0.0	0	0	0	0	0
02/22/2015 14:00	0.0	0	0	0	0	0
02/22/2015 15:00	0.0	0	0	0	0	0
02/22/2015 16:00	0.0	0	0	0	0	0
02/22/2015 17:00	0.0	0	0	0	0	0
02/22/2015 18:00	0.0	0	0	0	0	0
02/22/2015 19:00	0.0	0	0	0	0	0
02/22/2015 20:00	0.0	0	0	0	0	0
02/22/2015 21:00	0.0	0	0	0	0	0
02/22/2015 22:00	0.0	0	0	0	0	0
02/22/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	3.5 #	0 #	0 #	0 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3.5	0	0	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/23/2015 00:00	0.0	0	0	0	0	0
02/23/2015 01:00	0.0	0	0	0	0	0
02/23/2015 02:00	0.0	0	0	0	0	0
02/23/2015 03:00	0.0	0	0	0	0	0
02/23/2015 04:00	0.0	0	0	0	0	0
02/23/2015 05:00	0.0	0	0	0	0	0
02/23/2015 06:00	0.0	0	0	0	0	0
02/23/2015 07:00	0.0	0	0	0	0	0
02/23/2015 08:00	0.0	0	0	0	0	0
02/23/2015 09:00	0.0	0	0	0	0	0
02/23/2015 10:00	0.0	0	0	0	0	0
02/23/2015 11:00	0.0	0	0	0	0	0
02/23/2015 12:00	0.0	0	0	0	0	0
02/23/2015 13:00	0.0	0	0	0	0	0
02/23/2015 14:00	0.0	0	0	0	0	0
02/23/2015 15:00	0.0	0	0	0	0	0
02/23/2015 16:00	0.0	0	0	0	0	0
02/23/2015 17:00	0.0	0	0	0	0	0
02/23/2015 18:00	0.0	0	0	0	0	0
02/23/2015 19:00	0.0	0	0	0	0	0
02/23/2015 20:00	0.0	0	0	0	0	0
02/23/2015 21:00	0.0	0	0	0	0	0
02/23/2015 22:00	0.0	0	0	0	0	0
02/23/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/24/2015 00:00	0.0	0	0	0	0	0
02/24/2015 01:00	0.0	0	0	0	0	0
02/24/2015 02:00	0.0	0	0	0	0	0
02/24/2015 03:00	95.6	0	1	0	0	0
02/24/2015 04:00	46.5	0	1	0	0	0
02/24/2015 05:00	1.8	0	1	0	0	0
02/24/2015 06:00	0.0	0	0	0	0	1
02/24/2015 07:00	0.0	0	0	0	0	1
02/24/2015 08:00	0.0	0	0	0	0	1
02/24/2015 09:00	0.0	0	0	0	0	1
02/24/2015 10:00	0.0	0	0	0	0	1
02/24/2015 11:00	0.0	0	0	0	0	1
02/24/2015 12:00	0.0	0	0	0	0	1
02/24/2015 13:00	0.0	0	0	0	0	1
02/24/2015 14:00	0.0	0	0	0	0	1
02/24/2015 15:00	0.0	0	0	0	0	1
02/24/2015 16:00	0.0	0	0	0	0	1
02/24/2015 17:00	0.0	0	0	0	0	1
02/24/2015 18:00	0.0	0	0	0	0	1
02/24/2015 19:00	0.0	0	0	0	0	1
02/24/2015 20:00	0.0	0	0	0	0	1
02/24/2015 21:00	0.0	0	0	0	0	1
02/24/2015 22:00	0.0	0	0	0	0	1
02/24/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	143.9 #	0 #	3 #	0 #	0 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	95.6	0	1	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/25/2015 00:00	0.0	0	0	0	0	1
02/25/2015 01:00	0.0	0	0	0	0	1
02/25/2015 02:00	0.0	0	0	0	0	1
02/25/2015 03:00	0.0	0	0	0	0	1
02/25/2015 04:00	0.0	0	0	0	0	1
02/25/2015 05:00	0.0	0	0	0	0	1
02/25/2015 06:00	0.0	0	0	0	0	1
02/25/2015 07:00	0.0	0	0	0	0	1
02/25/2015 08:00	0.0	0	0	0	0	1
02/25/2015 09:00	0.0	0	0	0	0	1
02/25/2015 10:00	0.0	0	0	0	0	1
02/25/2015 11:00	0.0	0	0	0	0	1
02/25/2015 12:00	0.0	0	0	0	0	1
02/25/2015 13:00	0.0	0	0	0	0	1
02/25/2015 14:00	0.0	0	0	0	0	1
02/25/2015 15:00	0.0	0	0	0	0	1
02/25/2015 16:00	0.0	0	0	0	0	1
02/25/2015 17:00	0.0	0	0	0	0	1
02/25/2015 18:00	0.0	0	0	0	0	1
02/25/2015 19:00	0.0	0	0	0	0	1
02/25/2015 20:00	0.0	0	0	0	0	1
02/25/2015 21:00	0.0	0	0	0	0	1
02/25/2015 22:00	0.0	0	0	0	0	1
02/25/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/26/2015 00:00	0.0	0	0	0	0	1
02/26/2015 01:00	0.0	0	0	0	0	1
02/26/2015 02:00	0.0	0	0	0	0	1
02/26/2015 03:00	0.0	0	0	0	0	1
02/26/2015 04:00	0.0	0	0	0	0	1
02/26/2015 05:00	0.0	0	0	0	0	1
02/26/2015 06:00	0.0	0	0	0	0	1
02/26/2015 07:00	0.0	0	0	0	0	1
02/26/2015 08:00	0.0	0	0	0	0	1
02/26/2015 09:00	0.0	0	0	0	0	1
02/26/2015 10:00	0.0	0	0	0	0	1
02/26/2015 11:00	0.0	0	0	0	0	1
02/26/2015 12:00	0.0	0	0	0	0	1
02/26/2015 13:00	0.0	0	0	0	0	1
02/26/2015 14:00	0.0	0	0	0	0	1
02/26/2015 15:00	0.0	0	0	0	0	1
02/26/2015 16:00	0.0	0	0	0	0	1
02/26/2015 17:00	0.0	0	0	0	0	1
02/26/2015 18:00	0.0	0	0	0	0	1
02/26/2015 19:00	0.0	0	0	0	0	1
02/26/2015 20:00	0.0	0	0	0	0	1
02/26/2015 21:00	0.0	0	0	0	0	1
02/26/2015 22:00	0.0	0	0	0	0	1
02/26/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/27/2015 00:00	0.0	0	0	0	0	1
02/27/2015 01:00	0.0	0	0	0	0	1
02/27/2015 02:00	0.0	0	0	0	0	1
02/27/2015 03:00	0.0	0	0	0	0	1
02/27/2015 04:00	0.0	0	0	0	0	1
02/27/2015 05:00	0.0	0	0	0	0	1
02/27/2015 06:00	0.0	0	0	0	0	1
02/27/2015 07:00	0.0	0	0	0	0	1
02/27/2015 08:00	0.0	0	0	0	0	1
02/27/2015 09:00	0.0	0	0	0	0	1
02/27/2015 10:00	0.0	0	0	0	0	1
02/27/2015 11:00	0.0	0	0	0	0	1
02/27/2015 12:00	0.0	0	0	0	0	1
02/27/2015 13:00	0.0	0	0	0	0	1
02/27/2015 14:00	0.0	0	0	0	0	1
02/27/2015 15:00	0.0	0	0	0	0	1
02/27/2015 16:00	0.0	0	0	0	0	1
02/27/2015 17:00	0.0	0	0	0	0	1
02/27/2015 18:00	0.0	0	0	0	0	1
02/27/2015 19:00	0.0	0	0	0	0	1
02/27/2015 20:00	0.0	0	0	0	0	1
02/27/2015 21:00	0.0	0	0	0	0	1
02/27/2015 22:00	0.0	0	0	0	0	1
02/27/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/28/2015 00:00	0.0	0	0	0	0	1
02/28/2015 01:00	2.7	0	0	0	1	0
02/28/2015 02:00	0.0	0	0	0	0	0
02/28/2015 03:00	0.0	0	0	0	0	0
02/28/2015 04:00	0.0	0	0	0	0	0
02/28/2015 05:00	0.0	0	0	0	0	0
02/28/2015 06:00	0.0	0	0	0	0	0
02/28/2015 07:00	0.0	0	0	0	0	0
02/28/2015 08:00	30.0	0	0	1	0	0
02/28/2015 09:00	14.6	0	0	1	0	0
02/28/2015 10:00	0.0	0	0	0	0	1
02/28/2015 11:00	0.0	0	0	0	0	1
02/28/2015 12:00	0.0	0	0	0	0	1
02/28/2015 13:00	0.0	0	0	0	0	1
02/28/2015 14:00	0.0	0	0	0	0	1
02/28/2015 15:00	0.0	0	0	0	0	1
02/28/2015 16:00	0.0	0	0	0	0	1
02/28/2015 17:00	0.0	0	0	0	0	1
02/28/2015 18:00	0.0	0	0	0	0	1
02/28/2015 19:00	0.0	0	0	0	0	1
02/28/2015 20:00	0.0	0	0	0	0	1
02/28/2015 21:00	0.0	0	0	0	0	1
02/28/2015 22:00	0.0	0	0	0	0	1
02/28/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	47.3 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	30.0	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/01/2015 00:00	0.0	0	0	0	0	1
03/01/2015 01:00	0.0	0	0	0	0	1
03/01/2015 02:00	0.0	0	0	0	0	1
03/01/2015 03:00	0.0	0	0	0	0	1
03/01/2015 04:00	0.0	0	0	0	0	1
03/01/2015 05:00	0.0	0	0	0	0	1
03/01/2015 06:00	0.0	0	0	0	0	1
03/01/2015 07:00	0.0	0	0	0	0	1
03/01/2015 08:00	0.0	0	0	0	0	1
03/01/2015 09:00	0.0	0	0	0	0	1
03/01/2015 10:00	0.0	0	0	0	0	1
03/01/2015 11:00	0.0	0	0	0	0	1
03/01/2015 12:00	0.0	0	0	0	0	1
03/01/2015 13:00	0.0	0	0	0	0	1
03/01/2015 14:00	0.0	0	0	0	0	1
03/01/2015 15:00	0.0	0	0	0	0	1
03/01/2015 16:00	0.0	0	0	0	0	1
03/01/2015 17:00	0.0	0	0	0	0	1
03/01/2015 18:00	0.0	0	0	0	0	1
03/01/2015 19:00	0.0	0	0	0	0	1
03/01/2015 20:00	0.0	0	0	0	0	1
03/01/2015 21:00	0.0	0	0	0	0	1
03/01/2015 22:00	0.0	0	0	0	0	1
03/01/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/02/2015 00:00	0.0	0	0	0	0	1
03/02/2015 01:00	0.0	0	0	0	0	1
03/02/2015 02:00	0.0	0	0	0	0	1
03/02/2015 03:00	0.0	0	0	0	0	1
03/02/2015 04:00	0.0	0	0	0	0	1
03/02/2015 05:00	0.0	0	0	0	0	1
03/02/2015 06:00	0.0	0	0	0	0	1
03/02/2015 07:00	0.0	0	0	0	0	1
03/02/2015 08:00	0.0	0	0	0	0	1
03/02/2015 09:00	0.0	0	0	0	0	1
03/02/2015 10:00	0.0	0	0	0	0	1
03/02/2015 11:00	0.0	0	0	0	0	1
03/02/2015 12:00	0.0	0	0	0	0	1
03/02/2015 13:00	0.0	0	0	0	0	1
03/02/2015 14:00	0.0	0	0	0	0	1
03/02/2015 15:00	0.0	0	0	0	0	1
03/02/2015 16:00	0.0	0	0	0	0	1
03/02/2015 17:00	0.0	0	0	0	0	1
03/02/2015 18:00	0.0	0	0	0	0	1
03/02/2015 19:00	0.0	0	0	0	0	1
03/02/2015 20:00	0.0	0	0	0	0	1
03/02/2015 21:00	0.0	0	0	0	0	1
03/02/2015 22:00	0.0	0	0	0	0	1
03/02/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/03/2015 00:00	0.0	0	0	0	0	1
03/03/2015 01:00	0.0	0	0	0	0	1
03/03/2015 02:00	0.0	0	0	0	0	1
03/03/2015 03:00	0.0	0	0	0	0	1
03/03/2015 04:00	0.0	0	0	0	0	1
03/03/2015 05:00	0.0	0	0	0	0	1
03/03/2015 06:00	0.0	0	0	0	0	1
03/03/2015 07:00	0.0	0	0	0	0	1
03/03/2015 08:00	0.0	0	0	0	0	1
03/03/2015 09:00	0.0	0	0	0	0	1
03/03/2015 10:00	0.0	0	0	0	0	1
03/03/2015 11:00	0.0	0	0	0	0	1
03/03/2015 12:00	0.0	0	0	0	0	1
03/03/2015 13:00	0.0	0	0	0	0	1
03/03/2015 14:00	0.0	0	0	0	0	1
03/03/2015 15:00	0.0	0	0	0	0	1
03/03/2015 16:00	0.0	0	0	0	0	1
03/03/2015 17:00	0.0	0	0	0	0	1
03/03/2015 18:00	0.0	0	0	0	0	1
03/03/2015 19:00	0.0	0	0	0	0	1
03/03/2015 20:00	0.0	0	0	0	0	1
03/03/2015 21:00	0.0	0	0	0	0	1
03/03/2015 22:00	0.0	0	0	0	0	1
03/03/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/04/2015 00:00	0.0	0	0	0	0	1
03/04/2015 01:00	0.0	0	0	0	0	1
03/04/2015 02:00	0.0	0	0	0	0	1
03/04/2015 03:00	0.0	0	0	0	0	1
03/04/2015 04:00	0.0	0	0	0	0	1
03/04/2015 05:00	0.0	0	0	0	0	1
03/04/2015 06:00	0.0	0	0	0	0	1
03/04/2015 07:00	0.0	0	0	0	0	1
03/04/2015 08:00	0.0	0	0	0	0	1
03/04/2015 09:00	0.0	0	0	0	0	1
03/04/2015 10:00	0.0	0	0	0	0	1
03/04/2015 11:00	0.0	0	0	0	0	1
03/04/2015 12:00	0.0	0	0	0	0	1
03/04/2015 13:00	0.0	0	0	0	0	1
03/04/2015 14:00	0.0	0	0	0	0	1
03/04/2015 15:00	0.0	0	0	0	0	1
03/04/2015 16:00	0.0	0	0	0	0	1
03/04/2015 17:00	0.0	0	0	0	0	1
03/04/2015 18:00	0.0	0	0	0	0	1
03/04/2015 19:00	0.0	0	0	0	0	1
03/04/2015 20:00	0.0	0	0	0	0	1
03/04/2015 21:00	0.0	0	0	0	0	1
03/04/2015 22:00	0.0	0	0	0	0	1
03/04/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/05/2015 00:00	0.0	0	0	0	0	1
03/05/2015 01:00	0.0	0	0	0	0	1
03/05/2015 02:00	0.0	0	0	0	0	1
03/05/2015 03:00	0.0	0	0	0	0	1
03/05/2015 04:00	0.0	0	0	0	0	1
03/05/2015 05:00	0.0	0	0	0	0	1
03/05/2015 06:00	0.0	0	0	0	0	1
03/05/2015 07:00	0.0	0	0	0	0	1
03/05/2015 08:00	0.0	0	0	0	0	1
03/05/2015 09:00	0.0	0	0	0	0	1
03/05/2015 10:00	0.0	0	0	0	0	1
03/05/2015 11:00	0.0	0	0	0	0	1
03/05/2015 12:00	0.0	0	0	0	0	1
03/05/2015 13:00	0.0	0	0	0	0	1
03/05/2015 14:00	0.0	0	0	0	0	1
03/05/2015 15:00	0.0	0	0	0	0	1
03/05/2015 16:00	0.0	0	0	0	0	1
03/05/2015 17:00	0.0	0	0	0	0	1
03/05/2015 18:00	0.0	0	0	0	0	1
03/05/2015 19:00	0.0	0	0	0	0	1
03/05/2015 20:00	0.0	0	0	0	0	1
03/05/2015 21:00	0.0	0	0	0	0	1
03/05/2015 22:00	0.0	0	0	0	0	1
03/05/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/06/2015 00:00	0.0	0	0	0	0	1
03/06/2015 01:00	0.0	0	0	0	0	1
03/06/2015 02:00	0.0	0	0	0	0	1
03/06/2015 03:00	0.0	0	0	0	0	1
03/06/2015 04:00	0.0	0	0	0	0	1
03/06/2015 05:00	0.0	0	0	0	0	1
03/06/2015 06:00	0.0	0	0	0	0	1
03/06/2015 07:00	0.0	0	0	0	0	1
03/06/2015 08:00	0.0	0	0	0	0	1
03/06/2015 09:00	0.0	0	0	0	0	1
03/06/2015 10:00	0.0	0	0	0	0	1
03/06/2015 11:00	0.0	0	0	0	0	1
03/06/2015 12:00	0.0	0	0	0	0	1
03/06/2015 13:00	0.0	0	0	0	0	1
03/06/2015 14:00	0.0	0	0	0	0	1
03/06/2015 15:00	0.0	0	0	0	0	1
03/06/2015 16:00	0.0	0	0	0	0	1
03/06/2015 17:00	0.0	0	0	0	0	1
03/06/2015 18:00	0.0	0	0	0	0	1
03/06/2015 19:00	0.0	0	0	0	0	1
03/06/2015 20:00	0.0	0	0	0	0	1
03/06/2015 21:00	0.0	0	0	0	0	1
03/06/2015 22:00	0.0	0	0	0	0	1
03/06/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/07/2015 00:00	0.0	0	0	0	0	1
03/07/2015 01:00	0.0	0	0	0	0	1
03/07/2015 02:00	2.9	0	0	0	1	0
03/07/2015 03:00	0.0	0	0	0	0	0
03/07/2015 04:00	0.0	0	0	0	0	0
03/07/2015 05:00	0.0	0	0	0	0	0
03/07/2015 06:00	0.0	0	0	0	0	0
03/07/2015 07:00	0.0	0	0	0	0	0
03/07/2015 08:00	0.0	0	0	0	0	0
03/07/2015 09:00	0.0	0	0	0	0	0
03/07/2015 10:00	35.9	0	1	0	0	0
03/07/2015 11:00	44.0	0	1	0	0	0
03/07/2015 12:00	0.0	0	0	0	0	1
03/07/2015 13:00	0.0	0	0	0	0	1
03/07/2015 14:00	0.0	0	0	0	0	1
03/07/2015 15:00	0.0	0	0	0	0	1
03/07/2015 16:00	0.0	0	0	0	0	1
03/07/2015 17:00	0.0	0	0	0	0	1
03/07/2015 18:00	0.0	0	0	0	0	1
03/07/2015 19:00	0.0	0	0	0	0	1
03/07/2015 20:00	0.0	0	0	0	0	1
03/07/2015 21:00	0.0	0	0	0	0	1
03/07/2015 22:00	0.0	0	0	0	0	1
03/07/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	82.8 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	44.0	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/08/2015 00:00	0.0	0	0	0	0	1
03/08/2015 01:00	0.0	0	0	0	0	1
03/08/2015 02:00	0.0	0	0	0	0	1
03/08/2015 03:00	0.0	0	0	0	0	1
03/08/2015 04:00	0.0	0	0	0	0	1
03/08/2015 05:00	0.0	0	0	0	0	1
03/08/2015 06:00	0.0	0	0	0	0	1
03/08/2015 07:00	0.0	0	0	0	0	1
03/08/2015 08:00	3.0	0	0	0	1	0
03/08/2015 09:00	0.0	0	0	0	0	0
03/08/2015 10:00	0.0	0	0	0	0	0
03/08/2015 11:00	0.0	0	0	0	0	0
03/08/2015 12:00	0.0	0	0	0	0	0
03/08/2015 13:00	0.0	0	0	0	0	0
03/08/2015 14:00	0.0	0	0	1	0	0
03/08/2015 15:00	66.9	0	0	1	0	0
03/08/2015 16:00	0.3	0	0	1	0	0
03/08/2015 17:00	0.0	0	0	0	0	1
03/08/2015 18:00	0.0	0	0	0	0	1
03/08/2015 19:00	0.0	0	0	0	0	1
03/08/2015 20:00	0.0	0	0	0	0	1
03/08/2015 21:00	0.0	0	0	0	0	1
03/08/2015 22:00	0.0	0	0	0	0	1
03/08/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	70.2 #	0 #	0 #	3 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	66.9	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/09/2015 00:00	0.0	0	0	0	0	1
03/09/2015 01:00	0.0	0	0	0	0	1
03/09/2015 02:00	0.0	0	0	0	0	1
03/09/2015 03:00	0.0	0	0	0	0	1
03/09/2015 04:00	0.0	0	0	0	0	1
03/09/2015 05:00	0.0	0	0	0	0	1
03/09/2015 06:00	0.0	0	0	0	0	1
03/09/2015 07:00	0.0	0	0	0	0	1
03/09/2015 08:00	0.0	0	0	0	0	1
03/09/2015 09:00	0.0	0	0	0	0	1
03/09/2015 10:00	0.0	0	0	0	0	1
03/09/2015 11:00	0.0	0	0	0	0	1
03/09/2015 12:00	0.0	0	0	0	0	1
03/09/2015 13:00	0.0	0	0	0	0	1
03/09/2015 14:00	0.0	0	0	0	0	1
03/09/2015 15:00	0.0	0	0	0	0	1
03/09/2015 16:00	0.0	0	0	0	0	1
03/09/2015 17:00	0.0	0	0	0	0	1
03/09/2015 18:00	0.0	0	0	0	0	1
03/09/2015 19:00	0.0	0	0	0	0	1
03/09/2015 20:00	0.0	0	0	0	0	1
03/09/2015 21:00	0.0	0	0	0	0	1
03/09/2015 22:00	0.0	0	0	0	0	1
03/09/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/10/2015 00:00	0.0	0	0	0	0	1
03/10/2015 01:00	0.0	0	0	0	0	1
03/10/2015 02:00	0.0	0	0	0	0	1
03/10/2015 03:00	0.0	0	0	0	0	1
03/10/2015 04:00	0.0	0	0	0	0	1
03/10/2015 05:00	0.0	0	0	0	0	1
03/10/2015 06:00	0.0	0	0	0	0	1
03/10/2015 07:00	0.0	0	0	0	0	1
03/10/2015 08:00	0.0	0	0	0	0	1
03/10/2015 09:00	0.0	0	0	0	0	1
03/10/2015 10:00	0.0	0	0	0	0	1
03/10/2015 11:00	0.0	0	0	0	0	1
03/10/2015 12:00	0.0	0	0	0	0	1
03/10/2015 13:00	0.0	0	0	0	0	1
03/10/2015 14:00	0.0	0	0	0	0	1
03/10/2015 15:00	0.0	0	0	0	0	1
03/10/2015 16:00	0.0	0	0	0	0	1
03/10/2015 17:00	0.0	0	0	0	0	1
03/10/2015 18:00	0.0	0	0	0	0	1
03/10/2015 19:00	0.0	0	0	0	0	1
03/10/2015 20:00	0.0	0	0	0	0	1
03/10/2015 21:00	0.0	0	0	0	0	1
03/10/2015 22:00	0.0	0	0	0	0	1
03/10/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/11/2015 00:00	0.0	0	0	0	0	1
03/11/2015 01:00	0.0	0	0	0	0	1
03/11/2015 02:00	0.0	0	0	0	0	1
03/11/2015 03:00	0.0	0	0	0	0	1
03/11/2015 04:00	0.0	0	0	0	0	1
03/11/2015 05:00	0.0	0	0	0	0	1
03/11/2015 06:00	0.0	0	0	0	0	1
03/11/2015 07:00	0.0	0	0	0	0	1
03/11/2015 08:00	0.0	0	0	0	0	1
03/11/2015 09:00	0.0	0	0	0	0	1
03/11/2015 10:00	0.0	0	0	0	0	1
03/11/2015 11:00	0.0	0	0	0	0	1
03/11/2015 12:00	0.0	0	0	0	0	1
03/11/2015 13:00	0.0	0	0	0	0	1
03/11/2015 14:00	0.0	0	0	0	0	1
03/11/2015 15:00	0.0	0	0	0	0	1
03/11/2015 16:00	0.0	0	0	0	0	1
03/11/2015 17:00	0.0	0	0	0	0	1
03/11/2015 18:00	0.0	0	0	0	0	1
03/11/2015 19:00	0.0	0	0	0	0	1
03/11/2015 20:00	0.0	0	0	0	0	1
03/11/2015 21:00	0.0	0	0	0	0	1
03/11/2015 22:00	0.0	0	0	0	0	1
03/11/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/12/2015 00:00	0.0	0	0	0	0	1
03/12/2015 01:00	0.0	0	0	0	0	1
03/12/2015 02:00	0.0	0	0	0	0	1
03/12/2015 03:00	0.0	0	0	0	0	1
03/12/2015 04:00	0.0	0	0	0	0	1
03/12/2015 05:00	0.0	0	0	0	0	1
03/12/2015 06:00	0.0	0	0	0	0	1
03/12/2015 07:00	0.0	0	0	0	0	1
03/12/2015 08:00	0.0	0	0	0	0	1
03/12/2015 09:00	0.0	0	0	0	0	1
03/12/2015 10:00	0.0	0	0	0	0	1
03/12/2015 11:00	0.0	0	0	0	0	1
03/12/2015 12:00	0.0	0	0	0	0	1
03/12/2015 13:00	0.0	0	0	0	0	1
03/12/2015 14:00	0.0	0	0	0	0	1
03/12/2015 15:00	0.0	0	0	0	0	1
03/12/2015 16:00	0.0	0	0	0	0	1
03/12/2015 17:00	0.0	0	0	0	0	1
03/12/2015 18:00	0.0	0	0	0	0	1
03/12/2015 19:00	0.0	0	0	0	0	1
03/12/2015 20:00	0.0	0	0	0	0	1
03/12/2015 21:00	0.0	0	0	0	0	1
03/12/2015 22:00	0.0	0	0	0	0	1
03/12/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/13/2015 00:00	0.0	0	0	0	0	1
03/13/2015 01:00	0.0	0	0	0	0	1
03/13/2015 02:00	0.0	0	0	0	0	1
03/13/2015 03:00	0.0	0	0	0	0	1
03/13/2015 04:00	0.0	0	0	0	0	1
03/13/2015 05:00	0.0	0	0	0	0	1
03/13/2015 06:00	0.0	0	0	0	0	1
03/13/2015 07:00	0.0	0	0	0	0	1
03/13/2015 08:00	0.0	0	0	0	0	1
03/13/2015 09:00	0.0	0	0	0	0	1
03/13/2015 10:00	0.0	0	0	0	0	1
03/13/2015 11:00	0.0	0	0	0	0	1
03/13/2015 12:00	0.0	0	0	0	0	1
03/13/2015 13:00	0.0	0	0	0	0	1
03/13/2015 14:00	0.0	0	0	0	0	1
03/13/2015 15:00	0.0	0	0	0	0	1
03/13/2015 16:00	0.0	0	0	0	0	1
03/13/2015 17:00	0.0	0	0	0	0	1
03/13/2015 18:00	0.0	0	0	0	0	1
03/13/2015 19:00	0.0	0	0	0	0	1
03/13/2015 20:00	0.0	0	0	0	0	1
03/13/2015 21:00	0.0	0	0	0	0	1
03/13/2015 22:00	0.0	0	0	0	0	1
03/13/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/14/2015 00:00	0.0	0	0	0	0	1
03/14/2015 01:00	0.0	0	0	0	0	1
03/14/2015 02:00	0.0	0	0	0	0	1
03/14/2015 03:00	0.0	0	0	0	0	1
03/14/2015 04:00	0.0	0	0	0	0	1
03/14/2015 05:00	0.0	0	0	0	0	1
03/14/2015 06:00	0.0	0	0	0	0	1
03/14/2015 07:00	0.0	0	0	0	0	1
03/14/2015 08:00	0.0	0	0	0	0	1
03/14/2015 09:00	0.0	0	0	0	0	1
03/14/2015 10:00	0.0	0	0	0	0	1
03/14/2015 11:00	0.0	0	0	0	0	1
03/14/2015 12:00	0.0	0	0	0	0	1
03/14/2015 13:00	0.0	0	0	0	0	1
03/14/2015 14:00	0.0	0	0	0	0	1
03/14/2015 15:00	0.0	0	0	0	0	1
03/14/2015 16:00	0.0	0	0	0	0	1
03/14/2015 17:00	0.0	0	0	0	0	1
03/14/2015 18:00	0.0	0	0	0	0	1
03/14/2015 19:00	0.0	0	0	0	0	1
03/14/2015 20:00	0.0	0	0	0	0	1
03/14/2015 21:00	0.0	0	0	0	0	1
03/14/2015 22:00	0.0	0	0	0	0	1
03/14/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/15/2015 00:00	0.0	0	0	0	0	1
03/15/2015 01:00	0.0	0	0	0	0	1
03/15/2015 02:00	0.0	0	0	0	0	1
03/15/2015 03:00	0.0	0	0	0	0	1
03/15/2015 04:00	0.0	0	0	0	0	1
03/15/2015 05:00	0.0	0	0	0	0	1
03/15/2015 06:00	0.0	0	0	0	0	1
03/15/2015 07:00	0.0	0	0	0	0	1
03/15/2015 08:00	0.0	0	0	0	0	1
03/15/2015 09:00	0.0	0	0	0	0	1
03/15/2015 10:00	0.0	0	0	0	0	1
03/15/2015 11:00	0.0	0	0	0	0	1
03/15/2015 12:00	0.0	0	0	0	0	1
03/15/2015 13:00	0.0	0	0	0	0	1
03/15/2015 14:00	0.0	0	0	0	0	1
03/15/2015 15:00	0.0	0	0	0	0	1
03/15/2015 16:00	0.0	0	0	0	0	1
03/15/2015 17:00	0.0	0	0	0	0	1
03/15/2015 18:00	0.0	0	0	0	0	1
03/15/2015 19:00	0.0	0	0	0	0	1
03/15/2015 20:00	0.0	0	0	0	0	1
03/15/2015 21:00	0.0	0	0	0	0	1
03/15/2015 22:00	0.0	0	0	0	0	1
03/15/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/16/2015 00:00	0.0	0	0	0	0	1
03/16/2015 01:00	0.0	0	0	0	0	1
03/16/2015 02:00	0.0	0	0	0	0	1
03/16/2015 03:00	0.0	0	0	0	0	1
03/16/2015 04:00	0.0	0	0	0	0	1
03/16/2015 05:00	0.0	0	0	0	0	1
03/16/2015 06:00	0.0	0	0	0	0	1
03/16/2015 07:00	0.0	0	0	0	0	1
03/16/2015 08:00	0.0	0	0	0	0	1
03/16/2015 09:00	0.0	0	0	0	0	1
03/16/2015 10:00	0.0	0	0	0	0	1
03/16/2015 11:00	0.0	0	0	0	0	1
03/16/2015 12:00	0.0	0	0	0	0	1
03/16/2015 13:00	0.0	0	0	0	0	1
03/16/2015 14:00	0.0	0	0	0	0	1
03/16/2015 15:00	0.0	0	0	0	0	1
03/16/2015 16:00	0.0	0	0	0	0	1
03/16/2015 17:00	0.0	0	0	0	0	1
03/16/2015 18:00	0.0	0	0	0	0	1
03/16/2015 19:00	0.0	0	0	0	0	1
03/16/2015 20:00	0.0	0	0	0	0	1
03/16/2015 21:00	0.0	0	0	0	0	1
03/16/2015 22:00	0.0	0	0	0	0	1
03/16/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/17/2015 00:00	0.0	0	0	0	0	1
03/17/2015 01:00	0.0	0	0	0	0	1
03/17/2015 02:00	0.0	0	0	0	0	1
03/17/2015 03:00	0.0	0	0	0	0	1
03/17/2015 04:00	0.0	0	0	0	0	1
03/17/2015 05:00	0.0	0	0	0	0	1
03/17/2015 06:00	0.0	0	0	0	0	1
03/17/2015 07:00	0.0	0	0	0	0	1
03/17/2015 08:00	0.0	0	0	0	0	1
03/17/2015 09:00	0.0	0	0	0	0	1
03/17/2015 10:00	0.0	0	0	0	0	1
03/17/2015 11:00	0.0	0	0	1	0	0
03/17/2015 12:00	0.0	0	0	1	0	0
03/17/2015 13:00	0.0	0	0	0	0	1
03/17/2015 14:00	0.0	0	0	0	0	1
03/17/2015 15:00	0.0	0	0	0	0	1
03/17/2015 16:00	0.0	0	0	0	0	1
03/17/2015 17:00	0.0	0	0	0	0	1
03/17/2015 18:00	0.0	0	0	0	0	1
03/17/2015 19:00	0.0	0	0	0	0	1
03/17/2015 20:00	0.0	0	0	0	0	1
03/17/2015 21:00	0.0	0	0	0	0	1
03/17/2015 22:00	0.0	0	0	0	0	1
03/17/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	2 #	0 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	1	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/18/2015 00:00	0.0	0	0	0	0	1
03/18/2015 01:00	0.0	0	0	0	0	1
03/18/2015 02:00	0.0	0	0	0	0	1
03/18/2015 03:00	0.0	0	0	0	0	1
03/18/2015 04:00	0.0	0	0	0	0	1
03/18/2015 05:00	0.0	0	0	0	0	1
03/18/2015 06:00	0.0	0	0	0	0	1
03/18/2015 07:00	0.0	0	0	0	0	1
03/18/2015 08:00	0.0	0	0	0	0	1
03/18/2015 09:00	0.0	0	0	0	0	1
03/18/2015 10:00	0.0	0	0	0	0	1
03/18/2015 11:00	0.0	0	0	0	0	1
03/18/2015 12:00	0.0	0	0	0	0	1
03/18/2015 13:00	0.0	0	0	0	0	1
03/18/2015 14:00	0.0	0	0	0	0	1
03/18/2015 15:00	0.0	0	0	0	0	1
03/18/2015 16:00	0.0	0	0	0	0	1
03/18/2015 17:00	0.0	0	0	0	0	1
03/18/2015 18:00	0.0	0	0	0	0	1
03/18/2015 19:00	0.0	0	0	0	0	1
03/18/2015 20:00	0.0	0	0	0	0	1
03/18/2015 21:00	0.0	0	0	0	0	1
03/18/2015 22:00	0.0	0	0	0	0	1
03/18/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/19/2015 00:00	0.0	0	0	0	0	1
03/19/2015 01:00	0.0	0	0	0	0	1
03/19/2015 02:00	0.0	0	0	0	0	1
03/19/2015 03:00	0.0	0	0	0	0	1
03/19/2015 04:00	0.0	0	0	0	0	1
03/19/2015 05:00	0.0	0	0	0	0	1
03/19/2015 06:00	0.0	0	0	0	0	1
03/19/2015 07:00	0.0	0	0	0	0	1
03/19/2015 08:00	0.0	0	0	0	0	1
03/19/2015 09:00	0.0	0	0	0	0	1
03/19/2015 10:00	0.0	0	0	0	0	1
03/19/2015 11:00	0.0	0	0	0	0	1
03/19/2015 12:00	0.0	0	0	0	0	1
03/19/2015 13:00	0.0	0	0	0	0	1
03/19/2015 14:00	0.0	0	0	0	0	1
03/19/2015 15:00	0.0	0	0	0	0	1
03/19/2015 16:00	0.0	0	0	0	0	1
03/19/2015 17:00	0.0	0	0	0	0	1
03/19/2015 18:00	0.0	0	0	0	0	1
03/19/2015 19:00	0.0	0	0	0	0	1
03/19/2015 20:00	0.0	0	0	0	0	1
03/19/2015 21:00	0.0	0	0	0	0	1
03/19/2015 22:00	0.0	0	0	0	0	1
03/19/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/20/2015 00:00	0.0	0	0	0	0	1
03/20/2015 01:00	0.0	0	0	0	0	1
03/20/2015 02:00	0.0	0	0	0	0	1
03/20/2015 03:00	0.0	0	0	0	0	1
03/20/2015 04:00	0.0	0	0	0	0	1
03/20/2015 05:00	0.0	0	0	0	0	1
03/20/2015 06:00	0.0	0	0	0	0	1
03/20/2015 07:00	0.0	0	0	0	0	1
03/20/2015 08:00	0.0	0	0	0	0	1
03/20/2015 09:00	0.0	0	0	0	0	1
03/20/2015 10:00	0.0	0	0	0	0	1
03/20/2015 11:00	0.0	0	0	0	0	1
03/20/2015 12:00	0.0	0	0	0	0	1
03/20/2015 13:00	0.0	0	0	0	0	1
03/20/2015 14:00	0.0	0	0	0	0	1
03/20/2015 15:00	0.0	0	0	0	0	1
03/20/2015 16:00	0.0	0	0	0	0	1
03/20/2015 17:00	0.0	0	0	0	0	1
03/20/2015 18:00	0.0	0	0	0	0	1
03/20/2015 19:00	0.0	0	0	0	0	1
03/20/2015 20:00	0.0	0	0	0	0	1
03/20/2015 21:00	0.0	0	0	0	0	1
03/20/2015 22:00	0.0	0	0	0	0	1
03/20/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/21/2015 00:00	0.0	0	0	0	0	1
03/21/2015 01:00	0.0	0	0	0	0	1
03/21/2015 02:00	0.0	0	0	0	0	1
03/21/2015 03:00	0.0	0	0	0	0	1
03/21/2015 04:00	0.0	0	0	0	0	1
03/21/2015 05:00	0.0	0	0	0	0	1
03/21/2015 06:00	0.0	0	0	0	0	1
03/21/2015 07:00	0.0	0	0	0	0	1
03/21/2015 08:00	0.0	0	0	0	0	1
03/21/2015 09:00	0.0	0	0	0	0	1
03/21/2015 10:00	0.0	0	0	0	0	1
03/21/2015 11:00	0.0	0	0	0	0	1
03/21/2015 12:00	0.0	0	0	0	0	1
03/21/2015 13:00	0.0	0	0	0	0	1
03/21/2015 14:00	0.0	0	0	0	0	1
03/21/2015 15:00	0.0	0	0	0	0	1
03/21/2015 16:00	0.0	0	0	0	0	1
03/21/2015 17:00	0.0	0	0	0	0	1
03/21/2015 18:00	0.0	0	0	0	0	1
03/21/2015 19:00	0.0	0	0	0	0	1
03/21/2015 20:00	0.0	0	0	0	0	1
03/21/2015 21:00	0.0	0	0	0	0	1
03/21/2015 22:00	0.0	0	0	0	0	1
03/21/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/22/2015 00:00	0.0	0	0	0	0	1
03/22/2015 01:00	0.0	0	0	0	0	1
03/22/2015 02:00	0.0	0	0	0	0	1
03/22/2015 03:00	0.0	0	0	0	0	1
03/22/2015 04:00	0.0	0	0	0	0	1
03/22/2015 05:00	0.0	0	0	0	0	1
03/22/2015 06:00	0.0	0	0	0	0	1
03/22/2015 07:00	0.0	0	0	0	0	1
03/22/2015 08:00	0.0	0	0	0	0	1
03/22/2015 09:00	0.0	0	0	0	0	1
03/22/2015 10:00	0.0	0	0	0	0	1
03/22/2015 11:00	0.0	0	0	0	0	1
03/22/2015 12:00	0.0	0	0	0	0	1
03/22/2015 13:00	0.0	0	0	0	0	1
03/22/2015 14:00	0.0	0	0	0	0	1
03/22/2015 15:00	0.0	0	0	0	0	1
03/22/2015 16:00	0.0	0	0	0	0	1
03/22/2015 17:00	0.0	0	0	0	0	1
03/22/2015 18:00	0.0	0	0	0	0	1
03/22/2015 19:00	0.0	0	0	0	0	1
03/22/2015 20:00	0.0	0	0	0	0	1
03/22/2015 21:00	0.0	0	0	0	0	1
03/22/2015 22:00	0.0	0	0	0	0	1
03/22/2015 23:00	1.3	0	0	0	1	0
Average/Sum#:	1.3 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.3	0	0	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/23/2015 00:00	0.0	0	0	0	0	0
03/23/2015 01:00	0.0	0	0	0	0	0
03/23/2015 02:00	0.0	0	0	0	0	0
03/23/2015 03:00	0.0	0	0	0	0	0
03/23/2015 04:00	0.0	0	0	0	0	0
03/23/2015 05:00	0.0	0	0	0	0	0
03/23/2015 06:00	0.0	0	0	0	0	0
03/23/2015 07:00	0.0	0	0	0	0	0
03/23/2015 08:00	0.0	0	0	0	0	0
03/23/2015 09:00	0.0	0	0	0	0	0
03/23/2015 10:00	0.0	0	0	0	0	0
03/23/2015 11:00	0.0	0	0	0	0	0
03/23/2015 12:00	0.0	0	0	0	0	0
03/23/2015 13:00	0.0	0	0	0	0	0
03/23/2015 14:00	0.0	0	0	0	0	0
03/23/2015 15:00	0.0	0	0	0	0	0
03/23/2015 16:00	0.0	0	0	0	0	0
03/23/2015 17:00	0.0	0	0	0	0	0
03/23/2015 18:00	0.0	0	0	0	0	0
03/23/2015 19:00	0.0	0	0	0	0	0
03/23/2015 20:00	0.0	0	0	0	0	0
03/23/2015 21:00	0.0	0	0	0	0	0
03/23/2015 22:00	0.0	0	0	0	0	0
03/23/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/24/2015 00:00	0.0	0	0	0	0	0
03/24/2015 01:00	0.0	0	0	0	0	0
03/24/2015 02:00	0.0	0	0	0	0	0
03/24/2015 03:00	0.0	0	0	0	0	0
03/24/2015 04:00	0.0	0	0	0	0	0
03/24/2015 05:00	0.0	0	0	0	0	0
03/24/2015 06:00	0.0	0	0	0	0	0
03/24/2015 07:00	0.0	0	0	0	0	0
03/24/2015 08:00	0.0	0	0	0	0	0
03/24/2015 09:00	0.0	0	0	0	0	0
03/24/2015 10:00	0.0	0	0	0	0	0
03/24/2015 11:00	0.0	0	0	0	0	0
03/24/2015 12:00	0.0	0	0	0	0	0
03/24/2015 13:00	0.0	0	0	0	0	0
03/24/2015 14:00	0.0	0	0	0	0	0
03/24/2015 15:00	0.0	0	0	0	0	0
03/24/2015 16:00	0.0	0	0	0	0	0
03/24/2015 17:00	0.0	0	0	0	0	0
03/24/2015 18:00	0.0	0	0	0	0	0
03/24/2015 19:00	0.0	0	0	0	0	0
03/24/2015 20:00	0.0	0	0	0	0	0
03/24/2015 21:00	0.0	0	0	0	0	0
03/24/2015 22:00	0.0	0	0	0	0	0
03/24/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/25/2015 00:00	0.0	0	0	0	0	0
03/25/2015 01:00	0.0	0	0	0	0	0
03/25/2015 02:00	0.0	0	0	0	0	0
03/25/2015 03:00	0.0	0	0	0	0	0
03/25/2015 04:00	0.0	0	0	0	0	0
03/25/2015 05:00	0.0	0	0	0	0	0
03/25/2015 06:00	0.0	0	0	0	0	0
03/25/2015 07:00	0.0	0	0	0	0	0
03/25/2015 08:00	0.0	0	0	0	0	0
03/25/2015 09:00	0.0	0	0	0	0	0
03/25/2015 10:00	0.0	0	0	0	0	0
03/25/2015 11:00	0.0	0	0	0	0	0
03/25/2015 12:00	0.0	0	0	0	0	0
03/25/2015 13:00	0.0	0	0	0	0	0
03/25/2015 14:00	0.0	0	0	0	0	0
03/25/2015 15:00	0.0	0	0	0	0	0
03/25/2015 16:00	0.0	0	0	0	0	0
03/25/2015 17:00	0.0	0	0	0	0	0
03/25/2015 18:00	0.0	0	0	0	0	0
03/25/2015 19:00	0.0	0	0	0	0	0
03/25/2015 20:00	0.0	0	0	0	0	0
03/25/2015 21:00	0.0	0	0	0	0	0
03/25/2015 22:00	0.0	0	0	0	0	0
03/25/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/26/2015 00:00	0.0	0	0	0	0	0
03/26/2015 01:00	0.0	0	0	0	0	0
03/26/2015 02:00	0.0	0	0	0	0	0
03/26/2015 03:00	85.4	1	0	0	0	0
03/26/2015 04:00	97.4	1	0	0	0	0
03/26/2015 05:00	75.4	1	0	0	0	0
03/26/2015 06:00	0.0	0	0	0	0	1
03/26/2015 07:00	0.0	0	0	0	0	1
03/26/2015 08:00	0.0	0	0	0	0	1
03/26/2015 09:00	0.0	0	0	0	0	1
03/26/2015 10:00	0.0	0	0	0	0	1
03/26/2015 11:00	0.0	0	0	0	0	1
03/26/2015 12:00	0.0	0	0	0	0	1
03/26/2015 13:00	0.0	0	0	0	0	1
03/26/2015 14:00	0.0	0	0	0	0	1
03/26/2015 15:00	0.0	0	0	0	0	1
03/26/2015 16:00	0.0	0	0	0	0	1
03/26/2015 17:00	0.0	0	0	0	0	1
03/26/2015 18:00	0.0	0	0	0	0	1
03/26/2015 19:00	0.0	0	0	0	0	1
03/26/2015 20:00	0.0	0	0	0	0	1
03/26/2015 21:00	0.0	0	0	0	0	1
03/26/2015 22:00	2.9	0	0	0	1	0
03/26/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	261.1 #	3 #	0 #	0 #	1 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	97.4	1	0	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/27/2015 00:00	0.0	0	0	0	0	0
03/27/2015 01:00	0.0	0	0	0	0	0
03/27/2015 02:00	0.0	0	0	0	0	0
03/27/2015 03:00	0.0	0	0	0	0	0
03/27/2015 04:00	6.9	0	0	1	0	0
03/27/2015 05:00	28.0	0	0	1	0	0
03/27/2015 06:00	0.0	0	0	0	0	1
03/27/2015 07:00	0.0	0	0	0	0	1
03/27/2015 08:00	0.0	0	0	0	0	1
03/27/2015 09:00	0.0	0	0	0	0	1
03/27/2015 10:00	0.0	0	0	0	0	1
03/27/2015 11:00	0.0	0	0	0	0	1
03/27/2015 12:00	0.0	0	0	0	0	1
03/27/2015 13:00	0.0	0	0	0	0	1
03/27/2015 14:00	0.0	0	0	0	0	1
03/27/2015 15:00	0.0	0	0	0	0	1
03/27/2015 16:00	0.0	0	0	0	0	1
03/27/2015 17:00	0.0	0	0	0	0	1
03/27/2015 18:00	0.0	0	0	0	0	1
03/27/2015 19:00	0.0	0	0	0	0	1
03/27/2015 20:00	1.5	0	0	0	1	0
03/27/2015 21:00	0.0	0	0	0	0	0
03/27/2015 22:00	0.0	0	0	0	0	0
03/27/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	36.4 #	0 #	0 #	2 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	28.0	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/28/2015 00:00	0.0	0	0	0	0	0
03/28/2015 01:00	0.0	0	0	0	0	0
03/28/2015 02:00	0.0	0	0	0	0	0
03/28/2015 03:00	0.0	0	0	0	0	0
03/28/2015 04:00	0.0	0	0	0	0	0
03/28/2015 05:00	0.0	0	0	0	0	0
03/28/2015 06:00	0.0	0	0	0	0	0
03/28/2015 07:00	0.0	0	0	0	0	0
03/28/2015 08:00	0.0	0	0	0	0	0
03/28/2015 09:00	0.0	0	0	0	0	0
03/28/2015 10:00	0.0	0	0	0	0	0
03/28/2015 11:00	0.0	0	0	0	0	0
03/28/2015 12:00	0.0	0	0	0	0	0
03/28/2015 13:00	0.0	0	0	0	0	0
03/28/2015 14:00	0.0	0	0	0	0	0
03/28/2015 15:00	0.0	0	0	0	0	0
03/28/2015 16:00	0.0	0	0	0	0	0
03/28/2015 17:00	0.0	0	0	0	0	0
03/28/2015 18:00	0.0	0	0	0	0	0
03/28/2015 19:00	0.0	0	0	0	0	0
03/28/2015 20:00	0.0	0	0	0	0	0
03/28/2015 21:00	0.0	0	0	0	0	0
03/28/2015 22:00	0.0	0	0	0	0	0
03/28/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/29/2015 00:00	0.0	0	0	0	0	0
03/29/2015 01:00	0.0	0	0	0	0	0
03/29/2015 02:00	0.0	0	0	0	0	0
03/29/2015 03:00	0.0	0	0	0	0	0
03/29/2015 04:00	0.0	0	0	0	0	0
03/29/2015 05:00	0.0	0	0	0	0	0
03/29/2015 06:00	0.0	0	0	0	0	0
03/29/2015 07:00	0.0	0	0	0	0	0
03/29/2015 08:00	0.0	0	0	0	0	0
03/29/2015 09:00	0.0	0	0	0	0	0
03/29/2015 10:00	0.0	0	0	0	0	0
03/29/2015 11:00	0.0	0	0	0	0	0
03/29/2015 12:00	0.0	0	0	0	0	0
03/29/2015 13:00	0.0	0	0	0	0	0
03/29/2015 14:00	0.0	0	0	0	0	0
03/29/2015 15:00	0.0	0	0	0	0	0
03/29/2015 16:00	0.0	0	0	0	0	0
03/29/2015 17:00	0.0	0	0	0	0	0
03/29/2015 18:00	0.0	0	0	0	0	0
03/29/2015 19:00	0.0	0	0	0	0	0
03/29/2015 20:00	0.0	0	0	0	0	0
03/29/2015 21:00	0.0	0	0	0	0	0
03/29/2015 22:00	0.0	0	0	0	0	0
03/29/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/30/2015 00:00	0.0	0	0	0	0	0
03/30/2015 01:00	0.0	0	0	0	0	0
03/30/2015 02:00	0.0	0	0	0	0	0
03/30/2015 03:00	78.9	0	1	0	0	0
03/30/2015 04:00	57.6	0	1	0	0	0
03/30/2015 05:00	17.1	0	1	0	0	0
03/30/2015 06:00	0.0	0	0	0	0	1
03/30/2015 07:00	0.0	0	0	0	0	1
03/30/2015 08:00	0.0	0	0	0	0	1
03/30/2015 09:00	0.0	0	0	0	0	1
03/30/2015 10:00	0.0	0	0	0	0	1
03/30/2015 11:00	0.0	0	0	0	0	1
03/30/2015 12:00	0.0	0	0	0	0	1
03/30/2015 13:00	0.0	0	0	0	0	1
03/30/2015 14:00	0.0	0	0	0	0	1
03/30/2015 15:00	0.0	0	0	0	0	1
03/30/2015 16:00	0.0	0	0	0	0	1
03/30/2015 17:00	0.0	0	0	0	0	1
03/30/2015 18:00	0.0	0	0	0	0	1
03/30/2015 19:00	0.0	0	0	0	0	1
03/30/2015 20:00	2.1	0	0	0	1	0
03/30/2015 21:00	0.0	0	0	0	0	0
03/30/2015 22:00	0.0	0	0	0	0	0
03/30/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	155.7 #	0 #	3 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	78.9	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/31/2015 00:00	0.0	0	0	0	0	0
03/31/2015 01:00	0.0	0	0	0	0	0
03/31/2015 02:00	0.0	0	0	0	0	0
03/31/2015 03:00	0.0	0	0	0	0	0
03/31/2015 04:00	29.2	0	0	1	0	0
03/31/2015 05:00	5.5	0	0	1	0	0
03/31/2015 06:00	0.0	0	0	0	0	1
03/31/2015 07:00	0.0	0	0	0	0	1
03/31/2015 08:00	0.0	0	0	0	0	1
03/31/2015 09:00	0.0	0	0	0	0	1
03/31/2015 10:00	0.0	0	0	0	0	1
03/31/2015 11:00	0.0	0	0	0	0	1
03/31/2015 12:00	0.0	0	0	0	0	1
03/31/2015 13:00	0.0	0	0	0	0	1
03/31/2015 14:00	0.0	0	0	0	0	1
03/31/2015 15:00	0.0	0	0	0	0	1
03/31/2015 16:00	0.0	0	0	0	0	1
03/31/2015 17:00	0.0	0	0	0	0	1
03/31/2015 18:00	0.0	0	0	0	0	1
03/31/2015 19:00	0.0	0	0	0	0	1
03/31/2015 20:00	0.0	0	0	0	0	1
03/31/2015 21:00	2.2	0	0	0	1	0
03/31/2015 22:00	0.0	0	0	0	0	0
03/31/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	36.9 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	29.2	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/01/2015 00:00	0.0	0	0	0	0	1
01/01/2015 01:00	0.0	0	0	0	0	1
01/01/2015 02:00	0.0	0	0	0	0	1
01/01/2015 03:00	0.0	0	0	0	0	1
01/01/2015 04:00	0.0	0	0	0	0	1
01/01/2015 05:00	0.0	0	0	0	0	1
01/01/2015 06:00	0.0	0	0	0	0	1
01/01/2015 07:00	0.0	0	0	0	0	1
01/01/2015 08:00	0.0	0	0	0	0	1
01/01/2015 09:00	0.0	0	0	0	0	1
01/01/2015 10:00	0.0	0	0	0	0	1
01/01/2015 11:00	0.0	0	0	0	0	1
01/01/2015 12:00	0.0	0	0	0	0	1
01/01/2015 13:00	0.0	0	0	0	0	1
01/01/2015 14:00	0.0	0	0	0	0	1
01/01/2015 15:00	0.0	0	0	0	0	1
01/01/2015 16:00	0.0	0	0	0	0	1
01/01/2015 17:00	0.0	0	0	0	0	1
01/01/2015 18:00	0.0	0	0	0	0	1
01/01/2015 19:00	0.0	0	0	0	0	1
01/01/2015 20:00	0.0	0	0	0	0	1
01/01/2015 21:00	0.0	0	0	0	0	1
01/01/2015 22:00	0.0	0	0	0	0	1
01/01/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/02/2015 00:00	0.0	0	0	0	0	1
01/02/2015 01:00	0.0	0	0	0	0	1
01/02/2015 02:00	0.0	0	0	0	0	1
01/02/2015 03:00	0.0	0	0	0	0	1
01/02/2015 04:00	0.0	0	0	0	0	1
01/02/2015 05:00	0.0	0	0	0	0	1
01/02/2015 06:00	0.0	0	0	0	0	1
01/02/2015 07:00	0.0	0	0	0	0	1
01/02/2015 08:00	0.0	0	0	0	0	1
01/02/2015 09:00	0.0	0	0	0	0	1
01/02/2015 10:00	0.0	0	0	0	0	1
01/02/2015 11:00	0.0	0	0	0	0	1
01/02/2015 12:00	0.0	0	0	0	0	1
01/02/2015 13:00	0.0	0	0	0	0	1
01/02/2015 14:00	0.0	0	0	0	0	1
01/02/2015 15:00	0.0	0	0	0	0	1
01/02/2015 16:00	0.0	0	0	0	0	1
01/02/2015 17:00	0.0	0	0	0	0	1
01/02/2015 18:00	0.0	0	0	0	0	1
01/02/2015 19:00	0.0	0	0	0	0	1
01/02/2015 20:00	0.0	0	0	0	0	1
01/02/2015 21:00	0.0	0	0	0	0	1
01/02/2015 22:00	0.0	0	0	0	0	1
01/02/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/03/2015 00:00	0.0	0	0	0	0	1
01/03/2015 01:00	0.0	0	0	0	0	1
01/03/2015 02:00	0.0	0	0	0	0	1
01/03/2015 03:00	0.0	0	0	0	0	1
01/03/2015 04:00	0.0	0	0	0	0	1
01/03/2015 05:00	0.0	0	0	0	0	1
01/03/2015 06:00	0.0	0	0	0	0	1
01/03/2015 07:00	0.0	0	0	0	0	1
01/03/2015 08:00	0.0	0	0	0	0	1
01/03/2015 09:00	0.0	0	0	0	0	1
01/03/2015 10:00	0.0	0	0	0	0	1
01/03/2015 11:00	0.0	0	0	0	0	1
01/03/2015 12:00	0.0	0	0	0	0	1
01/03/2015 13:00	0.0	0	0	0	0	1
01/03/2015 14:00	0.0	0	0	0	0	1
01/03/2015 15:00	0.0	0	0	0	0	1
01/03/2015 16:00	0.0	0	0	0	0	1
01/03/2015 17:00	0.0	0	0	0	0	1
01/03/2015 18:00	0.0	0	0	0	0	1
01/03/2015 19:00	0.0	0	0	0	0	1
01/03/2015 20:00	0.0	0	0	0	0	1
01/03/2015 21:00	0.0	0	0	0	0	1
01/03/2015 22:00	0.0	0	0	0	0	1
01/03/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/04/2015 00:00	0.0	0	0	0	0	1
01/04/2015 01:00	0.0	0	0	0	0	1
01/04/2015 02:00	0.0	0	0	0	0	1
01/04/2015 03:00	0.0	0	0	0	0	1
01/04/2015 04:00	0.0	0	0	0	0	1
01/04/2015 05:00	0.0	0	0	0	0	1
01/04/2015 06:00	0.0	0	0	0	0	1
01/04/2015 07:00	0.0	0	0	0	0	1
01/04/2015 08:00	0.0	0	0	0	0	1
01/04/2015 09:00	0.0	0	0	0	0	1
01/04/2015 10:00	0.0	0	0	0	0	1
01/04/2015 11:00	0.0	0	0	0	0	1
01/04/2015 12:00	0.0	0	0	0	0	1
01/04/2015 13:00	0.0	0	0	0	0	1
01/04/2015 14:00	0.0	0	0	0	0	1
01/04/2015 15:00	0.0	0	0	0	0	1
01/04/2015 16:00	0.0	0	0	0	0	1
01/04/2015 17:00	0.0	0	0	0	0	1
01/04/2015 18:00	0.0	0	0	0	0	1
01/04/2015 19:00	0.0	0	0	0	0	1
01/04/2015 20:00	0.0	0	0	0	0	1
01/04/2015 21:00	0.0	0	0	0	0	1
01/04/2015 22:00	0.0	0	0	0	0	1
01/04/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/05/2015 00:00	0.0	0	0	0	0	1
01/05/2015 01:00	0.0	0	0	0	0	1
01/05/2015 02:00	0.0	0	0	0	0	1
01/05/2015 03:00	0.0	0	0	0	0	1
01/05/2015 04:00	0.0	0	0	0	0	1
01/05/2015 05:00	0.0	0	0	0	0	1
01/05/2015 06:00	0.0	0	0	0	0	1
01/05/2015 07:00	0.0	0	0	0	0	1
01/05/2015 08:00	0.0	0	0	0	0	1
01/05/2015 09:00	0.0	0	0	0	0	1
01/05/2015 10:00	0.0	0	0	0	0	1
01/05/2015 11:00	0.0	0	0	0	0	1
01/05/2015 12:00	0.0	0	0	0	0	1
01/05/2015 13:00	0.0	0	0	0	0	1
01/05/2015 14:00	0.0	0	0	0	0	1
01/05/2015 15:00	0.0	0	0	0	0	1
01/05/2015 16:00	0.0	0	0	0	0	1
01/05/2015 17:00	0.0	0	0	0	0	1
01/05/2015 18:00	0.0	0	0	0	0	1
01/05/2015 19:00	0.0	0	0	0	0	1
01/05/2015 20:00	0.0	0	0	0	0	1
01/05/2015 21:00	0.0	0	0	0	0	1
01/05/2015 22:00	0.0	0	0	0	0	1
01/05/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/06/2015 00:00	0.0	0	0	0	0	1
01/06/2015 01:00	0.0	0	0	0	0	1
01/06/2015 02:00	0.0	0	0	0	0	1
01/06/2015 03:00	0.0	0	0	0	0	1
01/06/2015 04:00	0.0	0	0	0	0	1
01/06/2015 05:00	0.0	0	0	0	0	1
01/06/2015 06:00	0.0	0	0	0	0	1
01/06/2015 07:00	0.0	0	0	0	0	1
01/06/2015 08:00	0.0	0	0	0	0	1
01/06/2015 09:00	0.0	0	0	0	0	1
01/06/2015 10:00	0.0	0	0	0	0	1
01/06/2015 11:00	0.0	0	0	0	0	1
01/06/2015 12:00	0.0	0	0	0	0	1
01/06/2015 13:00	0.0	0	0	0	0	1
01/06/2015 14:00	0.0	0	0	0	0	1
01/06/2015 15:00	0.0	0	0	0	0	1
01/06/2015 16:00	0.0	0	0	0	0	1
01/06/2015 17:00	0.0	0	0	0	0	1
01/06/2015 18:00	0.0	0	0	0	0	1
01/06/2015 19:00	0.0	0	0	0	0	1
01/06/2015 20:00	0.0	0	0	0	0	1
01/06/2015 21:00	0.0	0	0	0	0	1
01/06/2015 22:00	0.0	0	0	0	0	1
01/06/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/07/2015 00:00	0.0	0	0	0	0	1
01/07/2015 01:00	0.0	0	0	0	0	1
01/07/2015 02:00	0.0	0	0	0	0	1
01/07/2015 03:00	0.0	0	0	0	0	1
01/07/2015 04:00	0.0	0	0	0	0	1
01/07/2015 05:00	0.0	0	0	0	0	1
01/07/2015 06:00	0.0	0	0	0	0	1
01/07/2015 07:00	0.0	0	0	0	0	1
01/07/2015 08:00	0.0	0	0	0	0	1
01/07/2015 09:00	0.0	0	0	0	0	1
01/07/2015 10:00	0.0	0	0	0	0	1
01/07/2015 11:00	0.0	0	0	0	0	1
01/07/2015 12:00	0.0	0	0	0	0	1
01/07/2015 13:00	0.0	0	0	0	0	1
01/07/2015 14:00	0.0	0	0	0	0	1
01/07/2015 15:00	0.0	0	0	0	0	1
01/07/2015 16:00	0.0	0	0	0	0	1
01/07/2015 17:00	0.0	0	0	0	0	1
01/07/2015 18:00	0.0	0	0	0	0	1
01/07/2015 19:00	0.0	0	0	0	0	1
01/07/2015 20:00	0.0	0	0	0	0	1
01/07/2015 21:00	0.0	0	0	0	0	1
01/07/2015 22:00	0.0	0	0	0	0	1
01/07/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/08/2015 00:00	0.0	0	0	0	0	1
01/08/2015 01:00	0.0	0	0	0	0	1
01/08/2015 02:00	0.0	0	0	0	0	1
01/08/2015 03:00	0.0	0	0	0	0	1
01/08/2015 04:00	0.0	0	0	0	0	1
01/08/2015 05:00	0.0	0	0	0	0	1
01/08/2015 06:00	0.0	0	0	0	0	1
01/08/2015 07:00	0.0	0	0	0	0	1
01/08/2015 08:00	0.0	0	0	0	0	1
01/08/2015 09:00	0.0	0	0	0	0	1
01/08/2015 10:00	0.0	0	0	0	0	1
01/08/2015 11:00	0.0	0	0	0	0	1
01/08/2015 12:00	0.0	0	0	0	0	1
01/08/2015 13:00	0.0	0	0	0	0	1
01/08/2015 14:00	0.0	0	0	0	0	1
01/08/2015 15:00	0.0	0	0	0	0	1
01/08/2015 16:00	0.0	0	0	0	0	1
01/08/2015 17:00	0.0	0	0	0	0	1
01/08/2015 18:00	0.0	0	0	0	0	1
01/08/2015 19:00	0.0	0	0	0	0	1
01/08/2015 20:00	0.0	0	0	0	0	1
01/08/2015 21:00	0.0	0	0	0	0	1
01/08/2015 22:00	0.0	0	0	0	0	1
01/08/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/09/2015 00:00	0.0	0	0	0	0	1
01/09/2015 01:00	0.0	0	0	0	0	1
01/09/2015 02:00	0.0	0	0	0	0	1
01/09/2015 03:00	0.0	0	0	0	0	1
01/09/2015 04:00	0.0	0	0	0	0	1
01/09/2015 05:00	0.0	0	0	0	0	1
01/09/2015 06:00	0.0	0	0	0	0	1
01/09/2015 07:00	0.0	0	0	0	0	1
01/09/2015 08:00	0.0	0	0	0	0	1
01/09/2015 09:00	0.0	0	0	0	0	1
01/09/2015 10:00	0.0	0	0	0	0	1
01/09/2015 11:00	0.0	0	0	0	0	1
01/09/2015 12:00	0.0	0	0	0	0	1
01/09/2015 13:00	0.0	0	0	0	0	1
01/09/2015 14:00	0.0	0	0	0	0	1
01/09/2015 15:00	0.0	0	0	0	0	1
01/09/2015 16:00	0.0	0	0	0	0	1
01/09/2015 17:00	0.0	0	0	0	0	1
01/09/2015 18:00	0.0	0	0	0	0	1
01/09/2015 19:00	0.0	0	0	0	0	1
01/09/2015 20:00	0.0	0	0	0	0	1
01/09/2015 21:00	0.0	0	0	0	0	1
01/09/2015 22:00	0.0	0	0	0	0	1
01/09/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/10/2015 00:00	0.0	0	0	0	0	1
01/10/2015 01:00	0.0	0	0	0	0	1
01/10/2015 02:00	0.0	0	0	0	0	1
01/10/2015 03:00	0.0	0	0	0	0	1
01/10/2015 04:00	0.0	0	0	0	0	1
01/10/2015 05:00	0.0	0	0	0	0	1
01/10/2015 06:00	0.0	0	0	0	0	1
01/10/2015 07:00	0.0	0	0	0	0	1
01/10/2015 08:00	0.0	0	0	0	0	1
01/10/2015 09:00	0.0	0	0	0	0	1
01/10/2015 10:00	0.0	0	0	0	0	1
01/10/2015 11:00	0.0	0	0	0	0	1
01/10/2015 12:00	0.0	0	0	0	0	1
01/10/2015 13:00	0.0	0	0	0	0	1
01/10/2015 14:00	0.0	0	0	0	0	1
01/10/2015 15:00	0.0	0	0	0	0	1
01/10/2015 16:00	0.0	0	0	0	0	1
01/10/2015 17:00	0.0	0	0	0	0	1
01/10/2015 18:00	0.0	0	0	0	0	1
01/10/2015 19:00	0.0	0	0	0	0	1
01/10/2015 20:00	0.0	0	0	0	0	1
01/10/2015 21:00	0.0	0	0	0	0	1
01/10/2015 22:00	0.0	0	0	0	0	1
01/10/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/11/2015 00:00	0.0	0	0	0	0	1
01/11/2015 01:00	0.0	0	0	0	0	1
01/11/2015 02:00	0.0	0	0	0	0	1
01/11/2015 03:00	0.0	0	0	0	0	1
01/11/2015 04:00	0.0	0	0	0	0	1
01/11/2015 05:00	0.0	0	0	0	0	1
01/11/2015 06:00	0.0	0	0	0	0	1
01/11/2015 07:00	0.0	0	0	0	0	1
01/11/2015 08:00	0.0	0	0	0	0	1
01/11/2015 09:00	0.0	0	0	0	0	1
01/11/2015 10:00	0.0	0	0	0	0	1
01/11/2015 11:00	0.0	0	0	0	0	1
01/11/2015 12:00	0.0	0	0	0	0	1
01/11/2015 13:00	0.0	0	0	0	0	1
01/11/2015 14:00	0.0	0	0	0	0	1
01/11/2015 15:00	0.0	0	0	0	0	1
01/11/2015 16:00	0.0	0	0	0	0	1
01/11/2015 17:00	0.0	0	0	0	0	1
01/11/2015 18:00	0.0	0	0	0	0	1
01/11/2015 19:00	0.0	0	0	0	0	1
01/11/2015 20:00	0.0	0	0	0	0	1
01/11/2015 21:00	0.0	0	0	0	0	1
01/11/2015 22:00	0.0	0	0	0	0	1
01/11/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/12/2015 00:00	0.0	0	0	0	0	1
01/12/2015 01:00	0.0	0	0	0	0	1
01/12/2015 02:00	0.0	0	0	0	0	1
01/12/2015 03:00	0.0	0	0	0	0	1
01/12/2015 04:00	0.0	0	0	0	0	1
01/12/2015 05:00	0.0	0	0	0	0	1
01/12/2015 06:00	0.0	0	0	0	0	1
01/12/2015 07:00	0.0	0	0	0	0	1
01/12/2015 08:00	0.0	0	0	0	0	1
01/12/2015 09:00	0.0	0	0	0	0	1
01/12/2015 10:00	0.0	0	0	0	0	1
01/12/2015 11:00	0.0	0	0	0	0	1
01/12/2015 12:00	0.0	0	0	0	0	1
01/12/2015 13:00	0.0	0	0	0	0	1
01/12/2015 14:00	0.0	0	0	0	0	1
01/12/2015 15:00	0.0	0	0	0	0	1
01/12/2015 16:00	0.0	0	0	0	0	1
01/12/2015 17:00	0.0	0	0	0	0	1
01/12/2015 18:00	0.0	0	0	0	0	1
01/12/2015 19:00	0.0	0	0	0	0	1
01/12/2015 20:00	0.0	0	0	0	0	1
01/12/2015 21:00	0.0	0	0	0	0	1
01/12/2015 22:00	0.0	0	0	0	0	1
01/12/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/13/2015 00:00	0.0	0	0	0	0	1
01/13/2015 01:00	0.0	0	0	0	0	1
01/13/2015 02:00	0.0	0	0	0	0	1
01/13/2015 03:00	0.0	0	0	0	0	1
01/13/2015 04:00	0.0	0	0	0	0	1
01/13/2015 05:00	0.0	0	0	0	0	1
01/13/2015 06:00	0.0	0	0	0	0	1
01/13/2015 07:00	0.0	0	0	0	0	1
01/13/2015 08:00	0.0	0	0	0	0	1
01/13/2015 09:00	0.0	0	0	0	0	1
01/13/2015 10:00	0.0	0	0	0	0	1
01/13/2015 11:00	0.0	0	0	0	0	1
01/13/2015 12:00	0.0	0	0	0	0	1
01/13/2015 13:00	0.0	0	0	0	0	1
01/13/2015 14:00	0.0	0	0	0	0	1
01/13/2015 15:00	0.0	0	0	0	0	1
01/13/2015 16:00	0.0	0	0	0	0	1
01/13/2015 17:00	0.0	0	0	0	0	1
01/13/2015 18:00	0.0	0	0	0	0	1
01/13/2015 19:00	0.0	0	0	0	0	1
01/13/2015 20:00	0.0	0	0	0	0	1
01/13/2015 21:00	0.0	0	0	0	0	1
01/13/2015 22:00	0.0	0	0	0	0	1
01/13/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/14/2015 00:00	0.0	0	0	0	0	1
01/14/2015 01:00	0.0	0	0	0	0	1
01/14/2015 02:00	0.0	0	0	0	0	1
01/14/2015 03:00	0.0	0	0	0	0	1
01/14/2015 04:00	0.0	0	0	0	0	1
01/14/2015 05:00	0.0	0	0	0	0	1
01/14/2015 06:00	0.0	0	0	0	0	1
01/14/2015 07:00	0.0	0	0	0	0	1
01/14/2015 08:00	0.0	0	0	0	0	1
01/14/2015 09:00	0.0	0	0	0	0	1
01/14/2015 10:00	0.0	0	0	0	0	1
01/14/2015 11:00	0.0	0	0	0	0	1
01/14/2015 12:00	0.0	0	0	0	0	1
01/14/2015 13:00	0.0	0	0	0	0	1
01/14/2015 14:00	0.0	0	0	0	0	1
01/14/2015 15:00	0.0	0	0	0	0	1
01/14/2015 16:00	0.0	0	0	0	0	1
01/14/2015 17:00	0.0	0	0	0	0	1
01/14/2015 18:00	0.0	0	0	0	0	1
01/14/2015 19:00	0.0	0	0	0	0	1
01/14/2015 20:00	0.0	0	0	0	0	1
01/14/2015 21:00	0.0	0	0	0	0	1
01/14/2015 22:00	0.0	0	0	0	0	1
01/14/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/15/2015 00:00	0.0	0	0	0	0	1
01/15/2015 01:00	0.0	0	0	0	0	1
01/15/2015 02:00	0.0	0	0	0	0	1
01/15/2015 03:00	0.0	0	0	0	0	1
01/15/2015 04:00	0.0	0	0	0	0	1
01/15/2015 05:00	0.0	0	0	0	0	1
01/15/2015 06:00	0.0	0	0	0	0	1
01/15/2015 07:00	0.0	0	0	0	0	1
01/15/2015 08:00	0.0	0	0	0	0	1
01/15/2015 09:00	0.0	0	0	0	0	1
01/15/2015 10:00	0.0	0	0	0	0	1
01/15/2015 11:00	0.0	0	0	0	0	1
01/15/2015 12:00	0.0	0	0	0	0	1
01/15/2015 13:00	0.0	0	0	0	0	1
01/15/2015 14:00	0.0	0	0	0	0	1
01/15/2015 15:00	0.0	0	0	0	0	1
01/15/2015 16:00	0.0	0	0	0	0	1
01/15/2015 17:00	0.0	0	0	0	0	1
01/15/2015 18:00	0.0	0	0	0	0	1
01/15/2015 19:00	0.0	0	0	0	0	1
01/15/2015 20:00	0.0	0	0	0	0	1
01/15/2015 21:00	0.0	0	0	0	0	1
01/15/2015 22:00	0.0	0	0	0	0	1
01/15/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/16/2015 00:00	0.0	0	0	0	0	1
01/16/2015 01:00	0.0	0	0	0	0	1
01/16/2015 02:00	0.0	0	0	0	0	1
01/16/2015 03:00	0.0	0	0	0	0	1
01/16/2015 04:00	0.0	0	0	0	0	1
01/16/2015 05:00	0.0	0	0	0	0	1
01/16/2015 06:00	0.0	0	0	0	0	1
01/16/2015 07:00	0.0	0	0	0	0	1
01/16/2015 08:00	0.0	0	0	0	0	1
01/16/2015 09:00	0.0	0	0	0	0	1
01/16/2015 10:00	0.0	0	0	0	0	1
01/16/2015 11:00	0.0	0	0	0	0	1
01/16/2015 12:00	0.0	0	0	0	0	1
01/16/2015 13:00	0.0	0	0	0	0	1
01/16/2015 14:00	0.0	0	0	0	0	1
01/16/2015 15:00	0.0	0	0	0	0	1
01/16/2015 16:00	0.0	0	0	0	0	1
01/16/2015 17:00	0.0	0	0	0	0	1
01/16/2015 18:00	0.0	0	0	0	0	1
01/16/2015 19:00	0.0	0	0	0	0	1
01/16/2015 20:00	0.0	0	0	0	0	1
01/16/2015 21:00	0.0	0	0	0	0	1
01/16/2015 22:00	0.0	0	0	0	0	1
01/16/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/17/2015 00:00	0.0	0	0	0	0	1
01/17/2015 01:00	0.0	0	0	0	0	1
01/17/2015 02:00	0.0	0	0	0	0	1
01/17/2015 03:00	0.0	0	0	0	0	1
01/17/2015 04:00	0.0	0	0	0	0	1
01/17/2015 05:00	0.0	0	0	0	0	1
01/17/2015 06:00	0.0	0	0	0	0	1
01/17/2015 07:00	0.0	0	0	0	0	1
01/17/2015 08:00	0.0	0	0	0	0	1
01/17/2015 09:00	0.0	0	0	0	0	1
01/17/2015 10:00	0.0	0	0	0	0	1
01/17/2015 11:00	0.0	0	0	0	0	1
01/17/2015 12:00	0.0	0	0	0	0	1
01/17/2015 13:00	0.0	0	0	0	0	1
01/17/2015 14:00	0.0	0	0	0	0	1
01/17/2015 15:00	0.0	0	0	0	0	1
01/17/2015 16:00	0.0	0	0	0	0	1
01/17/2015 17:00	0.0	0	0	0	0	1
01/17/2015 18:00	0.0	0	0	0	0	1
01/17/2015 19:00	0.0	0	0	0	0	1
01/17/2015 20:00	0.0	0	0	0	0	1
01/17/2015 21:00	0.0	0	0	0	0	1
01/17/2015 22:00	0.0	0	0	0	0	1
01/17/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/18/2015 00:00	0.0	0	0	0	0	1
01/18/2015 01:00	0.0	0	0	0	0	1
01/18/2015 02:00	419.4	0	0	0	1	0
01/18/2015 03:00	0.0	0	0	0	0	0
01/18/2015 04:00	0.0	0	0	0	0	0
01/18/2015 05:00	0.0	0	0	0	0	0
01/18/2015 06:00	0.0	0	0	0	0	0
01/18/2015 07:00	0.0	0	0	0	0	0
01/18/2015 08:00	0.0	0	0	0	0	0
01/18/2015 09:00	0.0	0	0	0	0	0
01/18/2015 10:00	0.0	0	0	0	0	0
01/18/2015 11:00	0.0	0	0	0	0	0
01/18/2015 12:00	0.0	0	0	0	0	0
01/18/2015 13:00	0.0	0	0	0	0	0
01/18/2015 14:00	1,922.8	0	1	0	0	0
01/18/2015 15:00	7,560.1	0	1	0	0	0
01/18/2015 16:00	871.9	0	1	0	0	0
01/18/2015 17:00	0.0	0	0	0	0	1
01/18/2015 18:00	0.0	0	0	0	0	1
01/18/2015 19:00	0.0	0	0	0	0	1
01/18/2015 20:00	0.0	0	0	0	0	1
01/18/2015 21:00	0.0	0	0	0	0	1
01/18/2015 22:00	0.0	0	0	0	0	1
01/18/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	10,774.2 #	0 #	3 #	0 #	1 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	7,560.1	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/19/2015 00:00	0.0	0	0	0	0	1
01/19/2015 01:00	0.0	0	0	0	0	1
01/19/2015 02:00	0.0	0	0	0	0	1
01/19/2015 03:00	0.0	0	0	0	0	1
01/19/2015 04:00	0.0	0	0	0	0	1
01/19/2015 05:00	0.0	0	0	0	0	1
01/19/2015 06:00	0.0	0	0	0	0	1
01/19/2015 07:00	0.0	0	0	0	0	1
01/19/2015 08:00	0.0	0	0	0	0	1
01/19/2015 09:00	0.0	0	0	0	0	1
01/19/2015 10:00	0.0	0	0	0	0	1
01/19/2015 11:00	0.0	0	0	0	0	1
01/19/2015 12:00	0.0	0	0	0	0	1
01/19/2015 13:00	0.0	0	0	0	0	1
01/19/2015 14:00	0.0	0	0	0	0	1
01/19/2015 15:00	0.0	0	0	0	0	1
01/19/2015 16:00	0.0	0	0	0	0	1
01/19/2015 17:00	0.0	0	0	0	0	1
01/19/2015 18:00	0.0	0	0	0	0	1
01/19/2015 19:00	0.0	0	0	0	0	1
01/19/2015 20:00	0.0	0	0	0	0	1
01/19/2015 21:00	0.0	0	0	0	0	1
01/19/2015 22:00	0.0	0	0	0	0	1
01/19/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/20/2015 00:00	0.0	0	0	0	0	1
01/20/2015 01:00	0.0	0	0	0	0	1
01/20/2015 02:00	0.0	0	0	0	0	1
01/20/2015 03:00	0.0	0	0	0	0	1
01/20/2015 04:00	0.0	0	0	0	0	1
01/20/2015 05:00	0.0	0	0	0	0	1
01/20/2015 06:00	0.0	0	0	0	0	1
01/20/2015 07:00	0.0	0	0	0	0	1
01/20/2015 08:00	0.0	0	0	0	0	1
01/20/2015 09:00	0.0	0	0	0	0	1
01/20/2015 10:00	0.0	0	0	0	0	1
01/20/2015 11:00	0.0	0	0	0	0	1
01/20/2015 12:00	0.0	0	0	0	0	1
01/20/2015 13:00	0.0	0	0	0	0	1
01/20/2015 14:00	0.0	0	0	0	0	1
01/20/2015 15:00	0.0	0	0	0	0	1
01/20/2015 16:00	0.0	0	0	0	0	1
01/20/2015 17:00	0.0	0	0	0	0	1
01/20/2015 18:00	0.0	0	0	0	0	1
01/20/2015 19:00	0.0	0	0	0	0	1
01/20/2015 20:00	0.0	0	0	0	0	1
01/20/2015 21:00	0.0	0	0	0	0	1
01/20/2015 22:00	0.0	0	0	0	0	1
01/20/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/21/2015 00:00	0.0	0	0	0	0	1
01/21/2015 01:00	0.0	0	0	0	0	1
01/21/2015 02:00	0.0	0	0	0	0	1
01/21/2015 03:00	0.0	0	0	0	0	1
01/21/2015 04:00	0.0	0	0	0	0	1
01/21/2015 05:00	0.0	0	0	0	0	1
01/21/2015 06:00	0.0	0	0	0	0	1
01/21/2015 07:00	0.0	0	0	0	0	1
01/21/2015 08:00	0.0	0	0	0	0	1
01/21/2015 09:00	0.0	0	0	0	0	1
01/21/2015 10:00	0.0	0	0	0	0	1
01/21/2015 11:00	0.0	0	0	0	0	1
01/21/2015 12:00	0.0	0	0	0	0	1
01/21/2015 13:00	0.0	0	0	0	0	1
01/21/2015 14:00	0.0	0	0	0	0	1
01/21/2015 15:00	0.0	0	0	0	0	1
01/21/2015 16:00	0.0	0	0	0	0	1
01/21/2015 17:00	0.0	0	0	0	0	1
01/21/2015 18:00	0.0	0	0	0	0	1
01/21/2015 19:00	0.0	0	0	0	0	1
01/21/2015 20:00	0.0	0	0	0	0	1
01/21/2015 21:00	0.0	0	0	0	0	1
01/21/2015 22:00	0.0	0	0	0	0	1
01/21/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/22/2015 00:00	0.0	0	0	0	0	1
01/22/2015 01:00	0.0	0	0	0	0	1
01/22/2015 02:00	0.0	0	0	0	0	1
01/22/2015 03:00	0.0	0	0	0	0	1
01/22/2015 04:00	0.0	0	0	0	0	1
01/22/2015 05:00	0.0	0	0	0	0	1
01/22/2015 06:00	0.0	0	0	0	0	1
01/22/2015 07:00	0.0	0	0	0	0	1
01/22/2015 08:00	0.0	0	0	0	0	1
01/22/2015 09:00	0.0	0	0	0	0	1
01/22/2015 10:00	0.0	0	0	0	0	1
01/22/2015 11:00	0.0	0	0	0	0	1
01/22/2015 12:00	0.0	0	0	0	0	1
01/22/2015 13:00	0.0	0	0	0	0	1
01/22/2015 14:00	0.0	0	0	0	0	1
01/22/2015 15:00	0.0	0	0	0	0	1
01/22/2015 16:00	0.0	0	0	0	0	1
01/22/2015 17:00	0.0	0	0	0	0	1
01/22/2015 18:00	0.0	0	0	0	0	1
01/22/2015 19:00	0.0	0	0	0	0	1
01/22/2015 20:00	0.0	0	0	0	0	1
01/22/2015 21:00	0.0	0	0	0	0	1
01/22/2015 22:00	0.0	0	0	0	0	1
01/22/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/23/2015 00:00	0.0	0	0	0	0	1
01/23/2015 01:00	0.0	0	0	0	0	1
01/23/2015 02:00	0.0	0	0	0	0	1
01/23/2015 03:00	0.0	0	0	0	0	1
01/23/2015 04:00	0.0	0	0	0	0	1
01/23/2015 05:00	0.0	0	0	0	0	1
01/23/2015 06:00	0.0	0	0	0	0	1
01/23/2015 07:00	0.0	0	0	0	0	1
01/23/2015 08:00	0.0	0	0	0	0	1
01/23/2015 09:00	0.0	0	0	0	0	1
01/23/2015 10:00	0.0	0	0	0	0	1
01/23/2015 11:00	0.0	0	0	0	0	1
01/23/2015 12:00	0.0	0	0	0	0	1
01/23/2015 13:00	0.0	0	0	0	0	1
01/23/2015 14:00	0.0	0	0	0	0	1
01/23/2015 15:00	0.0	0	0	0	0	1
01/23/2015 16:00	0.0	0	0	0	0	1
01/23/2015 17:00	0.0	0	0	0	0	1
01/23/2015 18:00	0.0	0	0	0	0	1
01/23/2015 19:00	0.0	0	0	0	0	1
01/23/2015 20:00	0.0	0	0	0	0	1
01/23/2015 21:00	0.0	0	0	0	0	1
01/23/2015 22:00	0.0	0	0	0	0	1
01/23/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/24/2015 00:00	0.0	0	0	0	0	1
01/24/2015 01:00	0.0	0	0	0	0	1
01/24/2015 02:00	0.0	0	0	0	0	1
01/24/2015 03:00	0.0	0	0	0	0	1
01/24/2015 04:00	0.0	0	0	0	0	1
01/24/2015 05:00	0.0	0	0	0	0	1
01/24/2015 06:00	0.0	0	0	0	0	1
01/24/2015 07:00	0.0	0	0	0	0	1
01/24/2015 08:00	0.0	0	0	0	0	1
01/24/2015 09:00	0.0	0	0	0	0	1
01/24/2015 10:00	0.0	0	0	0	0	1
01/24/2015 11:00	0.0	0	0	0	0	1
01/24/2015 12:00	0.0	0	0	0	0	1
01/24/2015 13:00	0.0	0	0	0	0	1
01/24/2015 14:00	0.0	0	0	0	0	1
01/24/2015 15:00	0.0	0	0	0	0	1
01/24/2015 16:00	0.0	0	0	0	0	1
01/24/2015 17:00	0.0	0	0	0	0	1
01/24/2015 18:00	0.0	0	0	0	0	1
01/24/2015 19:00	0.0	0	0	0	0	1
01/24/2015 20:00	0.0	0	0	0	0	1
01/24/2015 21:00	0.0	0	0	0	0	1
01/24/2015 22:00	0.0	0	0	0	0	1
01/24/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/25/2015 00:00	0.0	0	0	0	0	1
01/25/2015 01:00	349.3	0	0	0	1	0
01/25/2015 02:00	0.0	0	0	0	0	0
01/25/2015 03:00	0.0	0	0	0	0	0
01/25/2015 04:00	0.0	0	0	0	0	0
01/25/2015 05:00	0.0	0	0	0	0	0
01/25/2015 06:00	0.0	0	0	0	0	0
01/25/2015 07:00	0.0	0	0	0	0	0
01/25/2015 08:00	0.0	0	0	0	0	0
01/25/2015 09:00	0.0	0	0	0	0	0
01/25/2015 10:00	0.0	0	0	0	0	0
01/25/2015 11:00	0.0	0	0	0	0	0
01/25/2015 12:00	1,866.8	0	1	0	0	0
01/25/2015 13:00	6,817.4	0	1	0	0	0
01/25/2015 14:00	2,873.7	0	1	0	0	0
01/25/2015 15:00	0.0	0	0	0	0	1
01/25/2015 16:00	0.0	0	0	0	0	1
01/25/2015 17:00	0.0	0	0	0	0	1
01/25/2015 18:00	0.0	0	0	0	0	1
01/25/2015 19:00	0.0	0	0	0	0	1
01/25/2015 20:00	0.0	0	0	0	0	1
01/25/2015 21:00	0.0	0	0	0	0	1
01/25/2015 22:00	439.0	0	0	0	1	0
01/25/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	12,346.2 #	0 #	3 #	0 #	2 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,817.4	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/26/2015 00:00	0.0	0	0	0	0	0
01/26/2015 01:00	0.0	0	0	0	0	0
01/26/2015 02:00	0.0	0	0	0	0	0
01/26/2015 03:00	0.0	0	0	0	0	0
01/26/2015 04:00	3,369.0	0	0	1	0	0
01/26/2015 05:00	4,117.5	0	0	1	0	0
01/26/2015 06:00	0.0	0	0	0	0	1
01/26/2015 07:00	0.0	0	0	0	0	1
01/26/2015 08:00	0.0	0	0	0	0	1
01/26/2015 09:00	0.0	0	0	0	0	1
01/26/2015 10:00	0.0	0	0	0	0	1
01/26/2015 11:00	0.0	0	0	0	0	1
01/26/2015 12:00	0.0	0	0	0	0	1
01/26/2015 13:00	0.0	0	0	0	0	1
01/26/2015 14:00	0.0	0	0	0	0	1
01/26/2015 15:00	0.0	0	0	0	0	1
01/26/2015 16:00	0.0	0	0	0	0	1
01/26/2015 17:00	0.0	0	0	0	0	1
01/26/2015 18:00	0.0	0	0	0	0	1
01/26/2015 19:00	0.0	0	0	0	0	1
01/26/2015 20:00	0.0	0	0	0	0	1
01/26/2015 21:00	0.0	0	0	0	0	1
01/26/2015 22:00	0.0	0	0	0	0	1
01/26/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,486.5 #	0 #	0 #	2 #	0 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,117.5	0	0	1	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/27/2015 00:00	0.0	0	0	0	0	1
01/27/2015 01:00	0.0	0	0	0	0	1
01/27/2015 02:00	0.0	0	0	0	0	1
01/27/2015 03:00	0.0	0	0	0	0	1
01/27/2015 04:00	0.0	0	0	0	0	1
01/27/2015 05:00	0.0	0	0	0	0	1
01/27/2015 06:00	0.0	0	0	0	0	1
01/27/2015 07:00	0.0	0	0	0	0	1
01/27/2015 08:00	0.0	0	0	0	0	1
01/27/2015 09:00	0.0	0	0	0	0	1
01/27/2015 10:00	0.0	0	0	0	0	1
01/27/2015 11:00	0.0	0	0	0	0	1
01/27/2015 12:00	0.0	0	0	0	0	1
01/27/2015 13:00	0.0	0	0	0	0	1
01/27/2015 14:00	0.0	0	0	0	0	1
01/27/2015 15:00	0.0	0	0	0	0	1
01/27/2015 16:00	0.0	0	0	0	0	1
01/27/2015 17:00	0.0	0	0	0	0	1
01/27/2015 18:00	0.0	0	0	0	0	1
01/27/2015 19:00	0.0	0	0	0	0	1
01/27/2015 20:00	0.0	0	0	0	0	1
01/27/2015 21:00	0.0	0	0	0	0	1
01/27/2015 22:00	0.0	0	0	0	0	1
01/27/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/28/2015 00:00	0.0	0	0	0	0	1
01/28/2015 01:00	0.0	0	0	0	0	1
01/28/2015 02:00	0.0	0	0	0	0	1
01/28/2015 03:00	0.0	0	0	0	0	1
01/28/2015 04:00	0.0	0	0	0	0	1
01/28/2015 05:00	0.0	0	0	0	0	1
01/28/2015 06:00	0.0	0	0	0	0	1
01/28/2015 07:00	0.0	0	0	0	0	1
01/28/2015 08:00	0.0	0	0	0	0	1
01/28/2015 09:00	0.0	0	0	0	0	1
01/28/2015 10:00	0.0	0	0	0	0	1
01/28/2015 11:00	0.0	0	0	0	0	1
01/28/2015 12:00	0.0	0	0	0	0	1
01/28/2015 13:00	0.0	0	0	0	0	1
01/28/2015 14:00	0.0	0	0	0	0	1
01/28/2015 15:00	0.0	0	0	0	0	1
01/28/2015 16:00	0.0	0	0	0	0	1
01/28/2015 17:00	0.0	0	0	0	0	1
01/28/2015 18:00	0.0	0	0	0	0	1
01/28/2015 19:00	0.0	0	0	0	0	1
01/28/2015 20:00	0.0	0	0	0	0	1
01/28/2015 21:00	0.0	0	0	0	0	1
01/28/2015 22:00	0.0	0	0	0	0	1
01/28/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/29/2015 00:00	0.0	0	0	0	0	1
01/29/2015 01:00	0.0	0	0	0	0	1
01/29/2015 02:00	0.0	0	0	0	0	1
01/29/2015 03:00	0.0	0	0	0	0	1
01/29/2015 04:00	0.0	0	0	0	0	1
01/29/2015 05:00	0.0	0	0	0	0	1
01/29/2015 06:00	0.0	0	0	0	0	1
01/29/2015 07:00	0.0	0	0	0	0	1
01/29/2015 08:00	0.0	0	0	0	0	1
01/29/2015 09:00	0.0	0	0	0	0	1
01/29/2015 10:00	0.0	0	0	0	0	1
01/29/2015 11:00	0.0	0	0	0	0	1
01/29/2015 12:00	0.0	0	0	0	0	1
01/29/2015 13:00	0.0	0	0	0	0	1
01/29/2015 14:00	0.0	0	0	0	0	1
01/29/2015 15:00	0.0	0	0	0	0	1
01/29/2015 16:00	0.0	0	0	0	0	1
01/29/2015 17:00	0.0	0	0	0	0	1
01/29/2015 18:00	0.0	0	0	0	0	1
01/29/2015 19:00	0.0	0	0	0	0	1
01/29/2015 20:00	0.0	0	0	0	0	1
01/29/2015 21:00	0.0	0	0	0	0	1
01/29/2015 22:00	0.0	0	0	0	0	1
01/29/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/30/2015 00:00	0.0	0	0	0	0	1
01/30/2015 01:00	0.0	0	0	0	0	1
01/30/2015 02:00	0.0	0	0	0	0	1
01/30/2015 03:00	0.0	0	0	0	0	1
01/30/2015 04:00	0.0	0	0	0	0	1
01/30/2015 05:00	0.0	0	0	0	0	1
01/30/2015 06:00	0.0	0	0	0	0	1
01/30/2015 07:00	0.0	0	0	0	0	1
01/30/2015 08:00	0.0	0	0	0	0	1
01/30/2015 09:00	0.0	0	0	0	0	1
01/30/2015 10:00	0.0	0	0	0	0	1
01/30/2015 11:00	0.0	0	0	0	0	1
01/30/2015 12:00	0.0	0	0	0	0	1
01/30/2015 13:00	0.0	0	0	0	0	1
01/30/2015 14:00	0.0	0	0	0	0	1
01/30/2015 15:00	0.0	0	0	0	0	1
01/30/2015 16:00	0.0	0	0	0	0	1
01/30/2015 17:00	0.0	0	0	0	0	1
01/30/2015 18:00	0.0	0	0	0	0	1
01/30/2015 19:00	0.0	0	0	0	0	1
01/30/2015 20:00	0.0	0	0	0	0	1
01/30/2015 21:00	0.0	0	0	0	0	1
01/30/2015 22:00	0.0	0	0	0	0	1
01/30/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/31/2015 00:00	306.7	0	0	0	1	0
01/31/2015 01:00	0.0	0	0	0	0	0
01/31/2015 02:00	0.0	0	0	0	0	0
01/31/2015 03:00	3,860.0	0	0	1	0	0
01/31/2015 04:00	5,396.2	0	0	1	0	0
01/31/2015 05:00	0.0	0	0	0	0	1
01/31/2015 06:00	0.0	0	0	0	0	1
01/31/2015 07:00	0.0	0	0	0	0	1
01/31/2015 08:00	0.0	0	0	0	0	1
01/31/2015 09:00	0.0	0	0	0	0	1
01/31/2015 10:00	0.0	0	0	0	0	1
01/31/2015 11:00	0.0	0	0	0	0	1
01/31/2015 12:00	0.0	0	0	0	0	1
01/31/2015 13:00	0.0	0	0	0	0	1
01/31/2015 14:00	0.0	0	0	0	0	1
01/31/2015 15:00	0.0	0	0	0	0	1
01/31/2015 16:00	0.0	0	0	0	0	1
01/31/2015 17:00	0.0	0	0	0	0	1
01/31/2015 18:00	0.0	0	0	0	0	1
01/31/2015 19:00	0.0	0	0	0	0	1
01/31/2015 20:00	0.0	0	0	0	0	1
01/31/2015 21:00	0.0	0	0	0	0	1
01/31/2015 22:00	0.0	0	0	0	0	1
01/31/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	9,562.9 #	0 #	0 #	2 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,396.2	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/01/2015 00:00	0.0	0	0	0	0	1
02/01/2015 01:00	0.0	0	0	0	0	1
02/01/2015 02:00	294.5	0	0	0	1	0
02/01/2015 03:00	0.0	0	0	0	0	0
02/01/2015 04:00	0.0	0	0	0	0	0
02/01/2015 05:00	0.0	0	0	0	0	0
02/01/2015 06:00	0.0	0	0	0	0	0
02/01/2015 07:00	0.0	0	0	0	0	0
02/01/2015 08:00	0.0	0	0	0	0	0
02/01/2015 09:00	0.0	0	0	0	0	0
02/01/2015 10:00	2,853.3	0	1	0	0	0
02/01/2015 11:00	8,139.4	0	1	0	0	0
02/01/2015 12:00	0.0	0	0	0	0	1
02/01/2015 13:00	0.0	0	0	0	0	1
02/01/2015 14:00	0.0	0	0	0	0	1
02/01/2015 15:00	0.0	0	0	0	0	1
02/01/2015 16:00	0.0	0	0	0	0	1
02/01/2015 17:00	0.0	0	0	0	0	1
02/01/2015 18:00	0.0	0	0	0	0	1
02/01/2015 19:00	0.0	0	0	0	0	1
02/01/2015 20:00	0.0	0	0	0	0	1
02/01/2015 21:00	0.0	0	0	0	0	1
02/01/2015 22:00	0.0	0	0	0	0	1
02/01/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	11,287.2 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	8,139.4	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/02/2015 00:00	0.0	0	0	0	0	1
02/02/2015 01:00	0.0	0	0	0	0	1
02/02/2015 02:00	0.0	0	0	0	0	1
02/02/2015 03:00	0.0	0	0	0	0	1
02/02/2015 04:00	0.0	0	0	0	0	1
02/02/2015 05:00	0.0	0	0	0	0	1
02/02/2015 06:00	0.0	0	0	0	0	1
02/02/2015 07:00	0.0	0	0	0	0	1
02/02/2015 08:00	0.0	0	0	0	0	1
02/02/2015 09:00	0.0	0	0	0	0	1
02/02/2015 10:00	0.0	0	0	0	0	1
02/02/2015 11:00	0.0	0	0	0	0	1
02/02/2015 12:00	0.0	0	0	0	0	1
02/02/2015 13:00	0.0	0	0	0	0	1
02/02/2015 14:00	0.0	0	0	0	0	1
02/02/2015 15:00	0.0	0	0	0	0	1
02/02/2015 16:00	0.0	0	0	0	0	1
02/02/2015 17:00	0.0	0	0	0	0	1
02/02/2015 18:00	0.0	0	0	0	0	1
02/02/2015 19:00	0.0	0	0	0	0	1
02/02/2015 20:00	0.0	0	0	0	0	1
02/02/2015 21:00	0.0	0	0	0	0	1
02/02/2015 22:00	0.0	0	0	0	0	1
02/02/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/03/2015 00:00	0.0	0	0	0	0	1
02/03/2015 01:00	0.0	0	0	0	0	1
02/03/2015 02:00	0.0	0	0	0	0	1
02/03/2015 03:00	0.0	0	0	0	0	1
02/03/2015 04:00	0.0	0	0	0	0	1
02/03/2015 05:00	0.0	0	0	0	0	1
02/03/2015 06:00	0.0	0	0	0	0	1
02/03/2015 07:00	0.0	0	0	0	0	1
02/03/2015 08:00	0.0	0	0	0	0	1
02/03/2015 09:00	0.0	0	0	0	0	1
02/03/2015 10:00	0.0	0	0	0	0	1
02/03/2015 11:00	0.0	0	0	0	0	1
02/03/2015 12:00	0.0	0	0	0	0	1
02/03/2015 13:00	0.0	0	0	0	0	1
02/03/2015 14:00	0.0	0	0	0	0	1
02/03/2015 15:00	0.0	0	0	0	0	1
02/03/2015 16:00	0.0	0	0	0	0	1
02/03/2015 17:00	0.0	0	0	0	0	1
02/03/2015 18:00	0.0	0	0	0	0	1
02/03/2015 19:00	0.0	0	0	0	0	1
02/03/2015 20:00	0.0	0	0	0	0	1
02/03/2015 21:00	0.0	0	0	0	0	1
02/03/2015 22:00	0.0	0	0	0	0	1
02/03/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/04/2015 00:00	0.0	0	0	0	0	1
02/04/2015 01:00	0.0	0	0	0	0	1
02/04/2015 02:00	0.0	0	0	0	0	1
02/04/2015 03:00	0.0	0	0	0	0	1
02/04/2015 04:00	0.0	0	0	0	0	1
02/04/2015 05:00	0.0	0	0	0	0	1
02/04/2015 06:00	0.0	0	0	0	0	1
02/04/2015 07:00	0.0	0	0	0	0	1
02/04/2015 08:00	0.0	0	0	0	0	1
02/04/2015 09:00	0.0	0	0	0	0	1
02/04/2015 10:00	0.0	0	0	0	0	1
02/04/2015 11:00	0.0	0	0	0	0	1
02/04/2015 12:00	0.0	0	0	0	0	1
02/04/2015 13:00	0.0	0	0	0	0	1
02/04/2015 14:00	0.0	0	0	0	0	1
02/04/2015 15:00	0.0	0	0	0	0	1
02/04/2015 16:00	0.0	0	0	0	0	1
02/04/2015 17:00	0.0	0	0	0	0	1
02/04/2015 18:00	0.0	0	0	0	0	1
02/04/2015 19:00	0.0	0	0	0	0	1
02/04/2015 20:00	0.0	0	0	0	0	1
02/04/2015 21:00	0.0	0	0	0	0	1
02/04/2015 22:00	0.0	0	0	0	0	1
02/04/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/05/2015 00:00	0.0	0	0	0	0	1
02/05/2015 01:00	0.0	0	0	0	0	1
02/05/2015 02:00	0.0	0	0	0	0	1
02/05/2015 03:00	0.0	0	0	0	0	1
02/05/2015 04:00	0.0	0	0	0	0	1
02/05/2015 05:00	0.0	0	0	0	0	1
02/05/2015 06:00	0.0	0	0	0	0	1
02/05/2015 07:00	0.0	0	0	0	0	1
02/05/2015 08:00	0.0	0	0	0	0	1
02/05/2015 09:00	0.0	0	0	0	0	1
02/05/2015 10:00	0.0	0	0	0	0	1
02/05/2015 11:00	0.0	0	0	0	0	1
02/05/2015 12:00	0.0	0	0	0	0	1
02/05/2015 13:00	0.0	0	0	0	0	1
02/05/2015 14:00	0.0	0	0	0	0	1
02/05/2015 15:00	0.0	0	0	0	0	1
02/05/2015 16:00	0.0	0	0	0	0	1
02/05/2015 17:00	0.0	0	0	0	0	1
02/05/2015 18:00	0.0	0	0	0	0	1
02/05/2015 19:00	0.0	0	0	0	0	1
02/05/2015 20:00	0.0	0	0	0	0	1
02/05/2015 21:00	0.0	0	0	0	0	1
02/05/2015 22:00	0.0	0	0	0	0	1
02/05/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/06/2015 00:00	0.0	0	0	0	0	1
02/06/2015 01:00	0.0	0	0	0	0	1
02/06/2015 02:00	0.0	0	0	0	0	1
02/06/2015 03:00	0.0	0	0	0	0	1
02/06/2015 04:00	0.0	0	0	0	0	1
02/06/2015 05:00	0.0	0	0	0	0	1
02/06/2015 06:00	0.0	0	0	0	0	1
02/06/2015 07:00	0.0	0	0	0	0	1
02/06/2015 08:00	0.0	0	0	0	0	1
02/06/2015 09:00	0.0	0	0	0	0	1
02/06/2015 10:00	0.0	0	0	0	0	1
02/06/2015 11:00	0.0	0	0	0	0	1
02/06/2015 12:00	0.0	0	0	0	0	1
02/06/2015 13:00	0.0	0	0	0	0	1
02/06/2015 14:00	0.0	0	0	0	0	1
02/06/2015 15:00	0.0	0	0	0	0	1
02/06/2015 16:00	0.0	0	0	0	0	1
02/06/2015 17:00	0.0	0	0	0	0	1
02/06/2015 18:00	0.0	0	0	0	0	1
02/06/2015 19:00	0.0	0	0	0	0	1
02/06/2015 20:00	0.0	0	0	0	0	1
02/06/2015 21:00	0.0	0	0	0	0	1
02/06/2015 22:00	0.0	0	0	0	0	1
02/06/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/07/2015 00:00	0.0	0	0	0	0	1
02/07/2015 01:00	0.0	0	0	0	0	1
02/07/2015 02:00	0.0	0	0	0	0	1
02/07/2015 03:00	0.0	0	0	0	0	1
02/07/2015 04:00	0.0	0	0	0	0	1
02/07/2015 05:00	0.0	0	0	0	0	1
02/07/2015 06:00	0.0	0	0	0	0	1
02/07/2015 07:00	0.0	0	0	0	0	1
02/07/2015 08:00	0.0	0	0	0	0	1
02/07/2015 09:00	0.0	0	0	0	0	1
02/07/2015 10:00	0.0	0	0	0	0	1
02/07/2015 11:00	0.0	0	0	0	0	1
02/07/2015 12:00	0.0	0	0	0	0	1
02/07/2015 13:00	0.0	0	0	0	0	1
02/07/2015 14:00	0.0	0	0	0	0	1
02/07/2015 15:00	0.0	0	0	0	0	1
02/07/2015 16:00	0.0	0	0	0	0	1
02/07/2015 17:00	0.0	0	0	0	0	1
02/07/2015 18:00	0.0	0	0	0	0	1
02/07/2015 19:00	0.0	0	0	0	0	1
02/07/2015 20:00	0.0	0	0	0	0	1
02/07/2015 21:00	0.0	0	0	0	0	1
02/07/2015 22:00	0.0	0	0	0	0	1
02/07/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/08/2015 00:00	0.0	0	0	0	0	1
02/08/2015 01:00	0.0	0	0	0	0	1
02/08/2015 02:00	0.0	0	0	0	0	1
02/08/2015 03:00	0.0	0	0	0	0	1
02/08/2015 04:00	0.0	0	0	0	0	1
02/08/2015 05:00	0.0	0	0	0	0	1
02/08/2015 06:00	0.0	0	0	0	0	1
02/08/2015 07:00	0.0	0	0	0	0	1
02/08/2015 08:00	0.0	0	0	0	0	1
02/08/2015 09:00	0.0	0	0	0	0	1
02/08/2015 10:00	0.0	0	0	0	0	1
02/08/2015 11:00	0.0	0	0	0	0	1
02/08/2015 12:00	0.0	0	0	0	0	1
02/08/2015 13:00	0.0	0	0	0	0	1
02/08/2015 14:00	0.0	0	0	0	0	1
02/08/2015 15:00	0.0	0	0	0	0	1
02/08/2015 16:00	0.0	0	0	0	0	1
02/08/2015 17:00	0.0	0	0	0	0	1
02/08/2015 18:00	0.0	0	0	0	0	1
02/08/2015 19:00	0.0	0	0	0	0	1
02/08/2015 20:00	0.0	0	0	0	0	1
02/08/2015 21:00	0.0	0	0	0	0	1
02/08/2015 22:00	0.0	0	0	0	0	1
02/08/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/09/2015 00:00	0.0	0	0	0	0	1
02/09/2015 01:00	0.0	0	0	0	0	1
02/09/2015 02:00	0.0	0	0	0	0	1
02/09/2015 03:00	0.0	0	0	0	0	1
02/09/2015 04:00	0.0	0	0	0	0	1
02/09/2015 05:00	0.0	0	0	0	0	1
02/09/2015 06:00	0.0	0	0	0	0	1
02/09/2015 07:00	0.0	0	0	0	0	1
02/09/2015 08:00	0.0	0	0	0	0	1
02/09/2015 09:00	0.0	0	0	0	0	1
02/09/2015 10:00	0.0	0	0	0	0	1
02/09/2015 11:00	0.0	0	0	0	0	1
02/09/2015 12:00	0.0	0	0	0	0	1
02/09/2015 13:00	0.0	0	0	0	0	1
02/09/2015 14:00	0.0	0	0	0	0	1
02/09/2015 15:00	0.0	0	0	0	0	1
02/09/2015 16:00	0.0	0	0	0	0	1
02/09/2015 17:00	0.0	0	0	0	0	1
02/09/2015 18:00	0.0	0	0	0	0	1
02/09/2015 19:00	0.0	0	0	0	0	1
02/09/2015 20:00	0.0	0	0	0	0	1
02/09/2015 21:00	0.0	0	0	0	0	1
02/09/2015 22:00	0.0	0	0	0	0	1
02/09/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/10/2015 00:00	0.0	0	0	0	0	1
02/10/2015 01:00	0.0	0	0	0	0	1
02/10/2015 02:00	0.0	0	0	0	0	1
02/10/2015 03:00	0.0	0	0	0	0	1
02/10/2015 04:00	0.0	0	0	0	0	1
02/10/2015 05:00	0.0	0	0	0	0	1
02/10/2015 06:00	0.0	0	0	0	0	1
02/10/2015 07:00	0.0	0	0	0	0	1
02/10/2015 08:00	0.0	0	0	0	0	1
02/10/2015 09:00	0.0	0	0	0	0	1
02/10/2015 10:00	0.0	0	0	0	0	1
02/10/2015 11:00	0.0	0	0	0	0	1
02/10/2015 12:00	0.0	0	0	0	0	1
02/10/2015 13:00	0.0	0	0	0	0	1
02/10/2015 14:00	0.0	0	0	0	0	1
02/10/2015 15:00	0.0	0	0	0	0	1
02/10/2015 16:00	0.0	0	0	0	0	1
02/10/2015 17:00	0.0	0	0	0	0	1
02/10/2015 18:00	0.0	0	0	0	0	1
02/10/2015 19:00	0.0	0	0	0	0	1
02/10/2015 20:00	0.0	0	0	0	0	1
02/10/2015 21:00	0.0	0	0	0	0	1
02/10/2015 22:00	0.0	0	0	0	0	1
02/10/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/11/2015 00:00	0.0	0	0	0	0	1
02/11/2015 01:00	0.0	0	0	0	0	1
02/11/2015 02:00	0.0	0	0	0	0	1
02/11/2015 03:00	0.0	0	0	0	0	1
02/11/2015 04:00	0.0	0	0	0	0	1
02/11/2015 05:00	0.0	0	0	0	0	1
02/11/2015 06:00	0.0	0	0	0	0	1
02/11/2015 07:00	0.0	0	0	0	0	1
02/11/2015 08:00	0.0	0	0	0	0	1
02/11/2015 09:00	0.0	0	0	0	0	1
02/11/2015 10:00	0.0	0	0	0	0	1
02/11/2015 11:00	0.0	0	0	0	0	1
02/11/2015 12:00	0.0	0	0	0	0	1
02/11/2015 13:00	0.0	0	0	0	0	1
02/11/2015 14:00	0.0	0	0	0	0	1
02/11/2015 15:00	0.0	0	0	0	0	1
02/11/2015 16:00	0.0	0	0	0	0	1
02/11/2015 17:00	0.0	0	0	0	0	1
02/11/2015 18:00	0.0	0	0	0	0	1
02/11/2015 19:00	0.0	0	0	0	0	1
02/11/2015 20:00	0.0	0	0	0	0	1
02/11/2015 21:00	0.0	0	0	0	0	1
02/11/2015 22:00	0.0	0	0	0	0	1
02/11/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/12/2015 00:00	0.0	0	0	0	0	1
02/12/2015 01:00	0.0	0	0	0	0	1
02/12/2015 02:00	0.0	0	0	0	0	1
02/12/2015 03:00	0.0	0	0	0	0	1
02/12/2015 04:00	0.0	0	0	0	0	1
02/12/2015 05:00	0.0	0	0	0	0	1
02/12/2015 06:00	0.0	0	0	0	0	1
02/12/2015 07:00	0.0	0	0	0	0	1
02/12/2015 08:00	0.0	0	0	0	0	1
02/12/2015 09:00	0.0	0	0	0	0	1
02/12/2015 10:00	0.0	0	0	0	0	1
02/12/2015 11:00	0.0	0	0	0	0	1
02/12/2015 12:00	0.0	0	0	0	0	1
02/12/2015 13:00	0.0	0	0	0	0	1
02/12/2015 14:00	0.0	0	0	0	0	1
02/12/2015 15:00	0.0	0	0	0	0	1
02/12/2015 16:00	0.0	0	0	0	0	1
02/12/2015 17:00	0.0	0	0	0	0	1
02/12/2015 18:00	0.0	0	0	0	0	1
02/12/2015 19:00	0.0	0	0	0	0	1
02/12/2015 20:00	0.0	0	0	0	0	1
02/12/2015 21:00	0.0	0	0	0	0	1
02/12/2015 22:00	0.0	0	0	0	0	1
02/12/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/13/2015 00:00	0.0	0	0	0	0	1
02/13/2015 01:00	0.0	0	0	0	0	1
02/13/2015 02:00	0.0	0	0	0	0	1
02/13/2015 03:00	0.0	0	0	0	0	1
02/13/2015 04:00	0.0	0	0	0	0	1
02/13/2015 05:00	0.0	0	0	0	0	1
02/13/2015 06:00	0.0	0	0	0	0	1
02/13/2015 07:00	0.0	0	0	0	0	1
02/13/2015 08:00	0.0	0	0	0	0	1
02/13/2015 09:00	0.0	0	0	0	0	1
02/13/2015 10:00	0.0	0	0	0	0	1
02/13/2015 11:00	0.0	0	0	0	0	1
02/13/2015 12:00	0.0	0	0	0	0	1
02/13/2015 13:00	0.0	0	0	0	0	1
02/13/2015 14:00	0.0	0	0	0	0	1
02/13/2015 15:00	0.0	0	0	0	0	1
02/13/2015 16:00	0.0	0	0	0	0	1
02/13/2015 17:00	0.0	0	0	0	0	1
02/13/2015 18:00	0.0	0	0	0	0	1
02/13/2015 19:00	0.0	0	0	0	0	1
02/13/2015 20:00	0.0	0	0	0	0	1
02/13/2015 21:00	0.0	0	0	0	0	1
02/13/2015 22:00	0.0	0	0	0	0	1
02/13/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/14/2015 00:00	0.0	0	0	0	0	1
02/14/2015 01:00	0.0	0	0	0	0	1
02/14/2015 02:00	0.0	0	0	0	0	1
02/14/2015 03:00	0.0	0	0	0	0	1
02/14/2015 04:00	0.0	0	0	0	0	1
02/14/2015 05:00	0.0	0	0	0	0	1
02/14/2015 06:00	0.0	0	0	0	0	1
02/14/2015 07:00	0.0	0	0	0	0	1
02/14/2015 08:00	0.0	0	0	0	0	1
02/14/2015 09:00	0.0	0	0	0	0	1
02/14/2015 10:00	0.0	0	0	0	0	1
02/14/2015 11:00	0.0	0	0	0	0	1
02/14/2015 12:00	0.0	0	0	0	0	1
02/14/2015 13:00	0.0	0	0	0	0	1
02/14/2015 14:00	0.0	0	0	0	0	1
02/14/2015 15:00	0.0	0	0	0	0	1
02/14/2015 16:00	0.0	0	0	0	0	1
02/14/2015 17:00	0.0	0	0	0	0	1
02/14/2015 18:00	0.0	0	0	0	0	1
02/14/2015 19:00	0.0	0	0	0	0	1
02/14/2015 20:00	0.0	0	0	0	0	1
02/14/2015 21:00	0.0	0	0	0	0	1
02/14/2015 22:00	0.0	0	0	0	0	1
02/14/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/15/2015 00:00	0.0	0	0	0	0	1
02/15/2015 01:00	0.0	0	0	0	0	1
02/15/2015 02:00	477.2	0	0	0	1	0
02/15/2015 03:00	0.0	0	0	0	0	0
02/15/2015 04:00	0.0	0	0	0	0	0
02/15/2015 05:00	0.0	0	0	0	0	0
02/15/2015 06:00	0.0	0	0	0	0	0
02/15/2015 07:00	0.0	0	0	0	0	0
02/15/2015 08:00	0.0	0	0	0	0	0
02/15/2015 09:00	0.0	0	0	0	0	0
02/15/2015 10:00	0.0	0	0	0	0	0
02/15/2015 11:00	0.0	0	0	0	0	0
02/15/2015 12:00	0.0	0	0	0	0	0
02/15/2015 13:00	0.0	0	0	0	0	0
02/15/2015 14:00	0.0	0	0	0	0	0
02/15/2015 15:00	0.0	0	0	0	0	0
02/15/2015 16:00	1,123.5	0	1	0	0	0
02/15/2015 17:00	5,088.4	0	1	0	0	0
02/15/2015 18:00	0.0	0	0	0	0	1
02/15/2015 19:00	0.0	0	0	0	0	1
02/15/2015 20:00	0.0	0	0	0	0	1
02/15/2015 21:00	0.0	0	0	0	0	1
02/15/2015 22:00	0.0	0	0	0	0	1
02/15/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,689.1 #	0 #	2 #	0 #	1 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,088.4	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/16/2015 00:00	0.0	0	0	0	0	1
02/16/2015 01:00	0.0	0	0	0	0	1
02/16/2015 02:00	0.0	0	0	0	0	1
02/16/2015 03:00	0.0	0	0	0	0	1
02/16/2015 04:00	0.0	0	0	0	0	1
02/16/2015 05:00	0.0	0	0	0	0	1
02/16/2015 06:00	0.0	0	0	0	0	1
02/16/2015 07:00	0.0	0	0	0	0	1
02/16/2015 08:00	0.0	0	0	0	0	1
02/16/2015 09:00	0.0	0	0	0	0	1
02/16/2015 10:00	0.0	0	0	0	0	1
02/16/2015 11:00	0.0	0	0	0	0	1
02/16/2015 12:00	0.0	0	0	0	0	1
02/16/2015 13:00	0.0	0	0	0	0	1
02/16/2015 14:00	0.0	0	0	0	0	1
02/16/2015 15:00	0.0	0	0	0	0	1
02/16/2015 16:00	0.0	0	0	0	0	1
02/16/2015 17:00	0.0	0	0	0	0	1
02/16/2015 18:00	0.0	0	0	0	0	1
02/16/2015 19:00	0.0	0	0	0	0	1
02/16/2015 20:00	0.0	0	0	0	0	1
02/16/2015 21:00	0.0	0	0	0	0	1
02/16/2015 22:00	0.0	0	0	0	0	1
02/16/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/17/2015 00:00	0.0	0	0	0	0	1
02/17/2015 01:00	0.0	0	0	0	0	1
02/17/2015 02:00	0.0	0	0	0	0	1
02/17/2015 03:00	0.0	0	0	0	0	1
02/17/2015 04:00	0.0	0	0	0	0	1
02/17/2015 05:00	0.0	0	0	0	0	1
02/17/2015 06:00	0.0	0	0	0	0	1
02/17/2015 07:00	0.0	0	0	0	0	1
02/17/2015 08:00	0.0	0	0	0	0	1
02/17/2015 09:00	0.0	0	0	0	0	1
02/17/2015 10:00	0.0	0	0	0	0	1
02/17/2015 11:00	0.0	0	0	0	0	1
02/17/2015 12:00	0.0	0	0	0	0	1
02/17/2015 13:00	0.0	0	0	0	0	1
02/17/2015 14:00	0.0	0	0	0	0	1
02/17/2015 15:00	0.0	0	0	0	0	1
02/17/2015 16:00	0.0	0	0	0	0	1
02/17/2015 17:00	0.0	0	0	0	0	1
02/17/2015 18:00	0.0	0	0	0	0	1
02/17/2015 19:00	0.0	0	0	0	0	1
02/17/2015 20:00	0.0	0	0	0	0	1
02/17/2015 21:00	0.0	0	0	0	0	1
02/17/2015 22:00	0.0	0	0	0	0	1
02/17/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/18/2015 00:00	0.0	0	0	0	0	1
02/18/2015 01:00	0.0	0	0	0	0	1
02/18/2015 02:00	0.0	0	0	0	0	1
02/18/2015 03:00	0.0	0	0	0	0	1
02/18/2015 04:00	0.0	0	0	0	0	1
02/18/2015 05:00	0.0	0	0	0	0	1
02/18/2015 06:00	0.0	0	0	0	0	1
02/18/2015 07:00	0.0	0	0	0	0	1
02/18/2015 08:00	0.0	0	0	0	0	1
02/18/2015 09:00	0.0	0	0	0	0	1
02/18/2015 10:00	0.0	0	0	0	0	1
02/18/2015 11:00	0.0	0	0	0	0	1
02/18/2015 12:00	0.0	0	0	0	0	1
02/18/2015 13:00	0.0	0	0	0	0	1
02/18/2015 14:00	0.0	0	0	0	0	1
02/18/2015 15:00	0.0	0	0	0	0	1
02/18/2015 16:00	0.0	0	0	0	0	1
02/18/2015 17:00	0.0	0	0	0	0	1
02/18/2015 18:00	0.0	0	0	0	0	1
02/18/2015 19:00	0.0	0	0	0	0	1
02/18/2015 20:00	0.0	0	0	0	0	1
02/18/2015 21:00	0.0	0	0	0	0	1
02/18/2015 22:00	0.0	0	0	0	0	1
02/18/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/19/2015 00:00	0.0	0	0	0	0	1
02/19/2015 01:00	0.0	0	0	0	0	1
02/19/2015 02:00	0.0	0	0	0	0	1
02/19/2015 03:00	0.0	0	0	0	0	1
02/19/2015 04:00	0.0	0	0	0	0	1
02/19/2015 05:00	0.0	0	0	0	0	1
02/19/2015 06:00	0.0	0	0	0	0	1
02/19/2015 07:00	0.0	0	0	0	0	1
02/19/2015 08:00	0.0	0	0	0	0	1
02/19/2015 09:00	0.0	0	0	0	0	1
02/19/2015 10:00	0.0	0	0	0	0	1
02/19/2015 11:00	0.0	0	0	0	0	1
02/19/2015 12:00	0.0	0	0	0	0	1
02/19/2015 13:00	0.0	0	0	0	0	1
02/19/2015 14:00	0.0	0	0	0	0	1
02/19/2015 15:00	0.0	0	0	0	0	1
02/19/2015 16:00	0.0	0	0	0	0	1
02/19/2015 17:00	0.0	0	0	0	0	1
02/19/2015 18:00	0.0	0	0	0	0	1
02/19/2015 19:00	0.0	0	0	0	0	1
02/19/2015 20:00	0.0	0	0	0	0	1
02/19/2015 21:00	0.0	0	0	0	0	1
02/19/2015 22:00	0.0	0	0	0	0	1
02/19/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/20/2015 00:00	0.0	0	0	0	0	1
02/20/2015 01:00	401.3	0	0	0	1	0
02/20/2015 02:00	0.0	0	0	0	0	0
02/20/2015 03:00	0.0	0	0	0	0	0
02/20/2015 04:00	0.0	0	0	0	0	0
02/20/2015 05:00	0.0	0	0	0	0	0
02/20/2015 06:00	0.0	0	0	0	0	0
02/20/2015 07:00	0.0	0	0	0	0	0
02/20/2015 08:00	0.0	0	0	0	0	0
02/20/2015 09:00	0.0	0	0	0	0	0
02/20/2015 10:00	0.0	0	0	0	0	0
02/20/2015 11:00	0.0	0	0	0	0	0
02/20/2015 12:00	0.0	0	0	0	0	0
02/20/2015 13:00	0.0	0	0	0	0	0
02/20/2015 14:00	0.0	0	0	0	0	0
02/20/2015 15:00	0.0	0	0	0	0	0
02/20/2015 16:00	0.0	0	0	0	0	0
02/20/2015 17:00	0.0	0	0	0	0	0
02/20/2015 18:00	0.0	0	0	0	0	0
02/20/2015 19:00	0.0	0	0	0	0	0
02/20/2015 20:00	0.0	0	0	0	0	0
02/20/2015 21:00	0.0	0	0	0	0	0
02/20/2015 22:00	0.0	0	0	0	0	0
02/20/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	401.3 #	0 #	0 #	0 #	1 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	401.3	0	0	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/21/2015 00:00	0.0	0	0	0	0	0
02/21/2015 01:00	0.0	0	0	0	0	0
02/21/2015 02:00	0.0	0	0	0	0	0
02/21/2015 03:00	0.0	0	0	0	0	0
02/21/2015 04:00	0.0	0	0	0	0	0
02/21/2015 05:00	0.0	0	0	0	0	0
02/21/2015 06:00	0.0	0	0	0	0	0
02/21/2015 07:00	0.0	0	0	0	0	0
02/21/2015 08:00	0.0	0	0	0	0	0
02/21/2015 09:00	0.0	0	0	0	0	0
02/21/2015 10:00	0.0	0	0	0	0	0
02/21/2015 11:00	0.0	0	0	0	0	0
02/21/2015 12:00	0.0	0	0	0	0	0
02/21/2015 13:00	0.0	0	0	0	0	0
02/21/2015 14:00	0.0	0	0	0	0	0
02/21/2015 15:00	3,290.7	0	1	0	0	0
02/21/2015 16:00	5,984.7	0	1	0	0	0
02/21/2015 17:00	0.0	0	0	0	0	1
02/21/2015 18:00	0.0	0	0	0	0	1
02/21/2015 19:00	0.0	0	0	0	0	1
02/21/2015 20:00	0.0	0	0	0	0	1
02/21/2015 21:00	0.0	0	0	0	0	1
02/21/2015 22:00	0.0	0	0	0	0	1
02/21/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	9,275.4 #	0 #	2 #	0 #	0 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,984.7	0	1	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/22/2015 00:00	0.0	0	0	0	0	1
02/22/2015 01:00	0.0	0	0	0	0	1
02/22/2015 02:00	0.0	0	0	0	0	1
02/22/2015 03:00	0.0	0	0	0	0	1
02/22/2015 04:00	0.0	0	0	0	0	1
02/22/2015 05:00	0.0	0	0	0	0	1
02/22/2015 06:00	401.0	0	0	0	1	0
02/22/2015 07:00	0.0	0	0	0	0	0
02/22/2015 08:00	0.0	0	0	0	0	0
02/22/2015 09:00	0.0	0	0	0	0	0
02/22/2015 10:00	0.0	0	0	0	0	0
02/22/2015 11:00	0.0	0	0	0	0	0
02/22/2015 12:00	0.0	0	0	0	0	0
02/22/2015 13:00	0.0	0	0	0	0	0
02/22/2015 14:00	0.0	0	0	0	0	0
02/22/2015 15:00	0.0	0	0	0	0	0
02/22/2015 16:00	0.0	0	0	0	0	0
02/22/2015 17:00	0.0	0	0	0	0	0
02/22/2015 18:00	0.0	0	0	0	0	0
02/22/2015 19:00	0.0	0	0	0	0	0
02/22/2015 20:00	0.0	0	0	0	0	0
02/22/2015 21:00	0.0	0	0	0	0	0
02/22/2015 22:00	0.0	0	0	0	0	0
02/22/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	401.0 #	0 #	0 #	0 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	401.0	0	0	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/23/2015 00:00	0.0	0	0	0	0	0
02/23/2015 01:00	0.0	0	0	0	0	0
02/23/2015 02:00	0.0	0	0	0	0	0
02/23/2015 03:00	0.0	0	0	0	0	0
02/23/2015 04:00	0.0	0	0	0	0	0
02/23/2015 05:00	0.0	0	0	0	0	0
02/23/2015 06:00	0.0	0	0	0	0	0
02/23/2015 07:00	0.0	0	0	0	0	0
02/23/2015 08:00	0.0	0	0	0	0	0
02/23/2015 09:00	0.0	0	0	0	0	0
02/23/2015 10:00	0.0	0	0	0	0	0
02/23/2015 11:00	0.0	0	0	0	0	0
02/23/2015 12:00	0.0	0	0	0	0	0
02/23/2015 13:00	0.0	0	0	0	0	0
02/23/2015 14:00	0.0	0	0	0	0	0
02/23/2015 15:00	0.0	0	0	0	0	0
02/23/2015 16:00	0.0	0	0	0	0	0
02/23/2015 17:00	0.0	0	0	0	0	0
02/23/2015 18:00	0.0	0	0	0	0	0
02/23/2015 19:00	0.0	0	0	0	0	0
02/23/2015 20:00	0.0	0	0	0	0	0
02/23/2015 21:00	0.0	0	0	0	0	0
02/23/2015 22:00	0.0	0	0	0	0	0
02/23/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/24/2015 00:00	0.0	0	0	0	0	0
02/24/2015 01:00	0.0	0	0	0	0	0
02/24/2015 02:00	0.0	0	0	0	0	0
02/24/2015 03:00	2,587.1	0	1	0	0	0
02/24/2015 04:00	6,957.9	0	1	0	0	0
02/24/2015 05:00	3,062.5	0	1	0	0	0
02/24/2015 06:00	0.0	0	0	0	0	1
02/24/2015 07:00	0.0	0	0	0	0	1
02/24/2015 08:00	0.0	0	0	0	0	1
02/24/2015 09:00	0.0	0	0	0	0	1
02/24/2015 10:00	0.0	0	0	0	0	1
02/24/2015 11:00	0.0	0	0	0	0	1
02/24/2015 12:00	0.0	0	0	0	0	1
02/24/2015 13:00	0.0	0	0	0	0	1
02/24/2015 14:00	0.0	0	0	0	0	1
02/24/2015 15:00	0.0	0	0	0	0	1
02/24/2015 16:00	0.0	0	0	0	0	1
02/24/2015 17:00	0.0	0	0	0	0	1
02/24/2015 18:00	0.0	0	0	0	0	1
02/24/2015 19:00	0.0	0	0	0	0	1
02/24/2015 20:00	0.0	0	0	0	0	1
02/24/2015 21:00	0.0	0	0	0	0	1
02/24/2015 22:00	0.0	0	0	0	0	1
02/24/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	12,607.5 #	0 #	3 #	0 #	0 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,957.9	0	1	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/25/2015 00:00	0.0	0	0	0	0	1
02/25/2015 01:00	0.0	0	0	0	0	1
02/25/2015 02:00	0.0	0	0	0	0	1
02/25/2015 03:00	0.0	0	0	0	0	1
02/25/2015 04:00	0.0	0	0	0	0	1
02/25/2015 05:00	0.0	0	0	0	0	1
02/25/2015 06:00	0.0	0	0	0	0	1
02/25/2015 07:00	0.0	0	0	0	0	1
02/25/2015 08:00	0.0	0	0	0	0	1
02/25/2015 09:00	0.0	0	0	0	0	1
02/25/2015 10:00	0.0	0	0	0	0	1
02/25/2015 11:00	0.0	0	0	0	0	1
02/25/2015 12:00	0.0	0	0	0	0	1
02/25/2015 13:00	0.0	0	0	0	0	1
02/25/2015 14:00	0.0	0	0	0	0	1
02/25/2015 15:00	0.0	0	0	0	0	1
02/25/2015 16:00	0.0	0	0	0	0	1
02/25/2015 17:00	0.0	0	0	0	0	1
02/25/2015 18:00	0.0	0	0	0	0	1
02/25/2015 19:00	0.0	0	0	0	0	1
02/25/2015 20:00	0.0	0	0	0	0	1
02/25/2015 21:00	0.0	0	0	0	0	1
02/25/2015 22:00	0.0	0	0	0	0	1
02/25/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/26/2015 00:00	0.0	0	0	0	0	1
02/26/2015 01:00	0.0	0	0	0	0	1
02/26/2015 02:00	0.0	0	0	0	0	1
02/26/2015 03:00	0.0	0	0	0	0	1
02/26/2015 04:00	0.0	0	0	0	0	1
02/26/2015 05:00	0.0	0	0	0	0	1
02/26/2015 06:00	0.0	0	0	0	0	1
02/26/2015 07:00	0.0	0	0	0	0	1
02/26/2015 08:00	0.0	0	0	0	0	1
02/26/2015 09:00	0.0	0	0	0	0	1
02/26/2015 10:00	0.0	0	0	0	0	1
02/26/2015 11:00	0.0	0	0	0	0	1
02/26/2015 12:00	0.0	0	0	0	0	1
02/26/2015 13:00	0.0	0	0	0	0	1
02/26/2015 14:00	0.0	0	0	0	0	1
02/26/2015 15:00	0.0	0	0	0	0	1
02/26/2015 16:00	0.0	0	0	0	0	1
02/26/2015 17:00	0.0	0	0	0	0	1
02/26/2015 18:00	0.0	0	0	0	0	1
02/26/2015 19:00	0.0	0	0	0	0	1
02/26/2015 20:00	0.0	0	0	0	0	1
02/26/2015 21:00	0.0	0	0	0	0	1
02/26/2015 22:00	0.0	0	0	0	0	1
02/26/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/27/2015 00:00	0.0	0	0	0	0	1
02/27/2015 01:00	0.0	0	0	0	0	1
02/27/2015 02:00	0.0	0	0	0	0	1
02/27/2015 03:00	0.0	0	0	0	0	1
02/27/2015 04:00	0.0	0	0	0	0	1
02/27/2015 05:00	0.0	0	0	0	0	1
02/27/2015 06:00	0.0	0	0	0	0	1
02/27/2015 07:00	0.0	0	0	0	0	1
02/27/2015 08:00	0.0	0	0	0	0	1
02/27/2015 09:00	0.0	0	0	0	0	1
02/27/2015 10:00	0.0	0	0	0	0	1
02/27/2015 11:00	0.0	0	0	0	0	1
02/27/2015 12:00	0.0	0	0	0	0	1
02/27/2015 13:00	0.0	0	0	0	0	1
02/27/2015 14:00	0.0	0	0	0	0	1
02/27/2015 15:00	0.0	0	0	0	0	1
02/27/2015 16:00	0.0	0	0	0	0	1
02/27/2015 17:00	0.0	0	0	0	0	1
02/27/2015 18:00	0.0	0	0	0	0	1
02/27/2015 19:00	0.0	0	0	0	0	1
02/27/2015 20:00	0.0	0	0	0	0	1
02/27/2015 21:00	0.0	0	0	0	0	1
02/27/2015 22:00	0.0	0	0	0	0	1
02/27/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/28/2015 00:00	0.0	0	0	0	0	1
02/28/2015 01:00	338.1	0	0	0	1	0
02/28/2015 02:00	0.0	0	0	0	0	0
02/28/2015 03:00	0.0	0	0	0	0	0
02/28/2015 04:00	0.0	0	0	0	0	0
02/28/2015 05:00	0.0	0	0	0	0	0
02/28/2015 06:00	0.0	0	0	0	0	0
02/28/2015 07:00	0.0	0	0	0	0	0
02/28/2015 08:00	3,844.8	0	0	1	0	0
02/28/2015 09:00	4,171.5	0	0	1	0	0
02/28/2015 10:00	0.0	0	0	0	0	1
02/28/2015 11:00	0.0	0	0	0	0	1
02/28/2015 12:00	0.0	0	0	0	0	1
02/28/2015 13:00	0.0	0	0	0	0	1
02/28/2015 14:00	0.0	0	0	0	0	1
02/28/2015 15:00	0.0	0	0	0	0	1
02/28/2015 16:00	0.0	0	0	0	0	1
02/28/2015 17:00	0.0	0	0	0	0	1
02/28/2015 18:00	0.0	0	0	0	0	1
02/28/2015 19:00	0.0	0	0	0	0	1
02/28/2015 20:00	0.0	0	0	0	0	1
02/28/2015 21:00	0.0	0	0	0	0	1
02/28/2015 22:00	0.0	0	0	0	0	1
02/28/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	8,354.4 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,171.5	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/01/2015 00:00	0.0	0	0	0	0	1
03/01/2015 01:00	0.0	0	0	0	0	1
03/01/2015 02:00	0.0	0	0	0	0	1
03/01/2015 03:00	0.0	0	0	0	0	1
03/01/2015 04:00	0.0	0	0	0	0	1
03/01/2015 05:00	0.0	0	0	0	0	1
03/01/2015 06:00	0.0	0	0	0	0	1
03/01/2015 07:00	0.0	0	0	0	0	1
03/01/2015 08:00	0.0	0	0	0	0	1
03/01/2015 09:00	0.0	0	0	0	0	1
03/01/2015 10:00	0.0	0	0	0	0	1
03/01/2015 11:00	0.0	0	0	0	0	1
03/01/2015 12:00	0.0	0	0	0	0	1
03/01/2015 13:00	0.0	0	0	0	0	1
03/01/2015 14:00	0.0	0	0	0	0	1
03/01/2015 15:00	0.0	0	0	0	0	1
03/01/2015 16:00	0.0	0	0	0	0	1
03/01/2015 17:00	0.0	0	0	0	0	1
03/01/2015 18:00	0.0	0	0	0	0	1
03/01/2015 19:00	0.0	0	0	0	0	1
03/01/2015 20:00	0.0	0	0	0	0	1
03/01/2015 21:00	0.0	0	0	0	0	1
03/01/2015 22:00	0.0	0	0	0	0	1
03/01/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/02/2015 00:00	0.0	0	0	0	0	1
03/02/2015 01:00	0.0	0	0	0	0	1
03/02/2015 02:00	0.0	0	0	0	0	1
03/02/2015 03:00	0.0	0	0	0	0	1
03/02/2015 04:00	0.0	0	0	0	0	1
03/02/2015 05:00	0.0	0	0	0	0	1
03/02/2015 06:00	0.0	0	0	0	0	1
03/02/2015 07:00	0.0	0	0	0	0	1
03/02/2015 08:00	0.0	0	0	0	0	1
03/02/2015 09:00	0.0	0	0	0	0	1
03/02/2015 10:00	0.0	0	0	0	0	1
03/02/2015 11:00	0.0	0	0	0	0	1
03/02/2015 12:00	0.0	0	0	0	0	1
03/02/2015 13:00	0.0	0	0	0	0	1
03/02/2015 14:00	0.0	0	0	0	0	1
03/02/2015 15:00	0.0	0	0	0	0	1
03/02/2015 16:00	0.0	0	0	0	0	1
03/02/2015 17:00	0.0	0	0	0	0	1
03/02/2015 18:00	0.0	0	0	0	0	1
03/02/2015 19:00	0.0	0	0	0	0	1
03/02/2015 20:00	0.0	0	0	0	0	1
03/02/2015 21:00	0.0	0	0	0	0	1
03/02/2015 22:00	0.0	0	0	0	0	1
03/02/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/03/2015 00:00	0.0	0	0	0	0	1
03/03/2015 01:00	0.0	0	0	0	0	1
03/03/2015 02:00	0.0	0	0	0	0	1
03/03/2015 03:00	0.0	0	0	0	0	1
03/03/2015 04:00	0.0	0	0	0	0	1
03/03/2015 05:00	0.0	0	0	0	0	1
03/03/2015 06:00	0.0	0	0	0	0	1
03/03/2015 07:00	0.0	0	0	0	0	1
03/03/2015 08:00	0.0	0	0	0	0	1
03/03/2015 09:00	0.0	0	0	0	0	1
03/03/2015 10:00	0.0	0	0	0	0	1
03/03/2015 11:00	0.0	0	0	0	0	1
03/03/2015 12:00	0.0	0	0	0	0	1
03/03/2015 13:00	0.0	0	0	0	0	1
03/03/2015 14:00	0.0	0	0	0	0	1
03/03/2015 15:00	0.0	0	0	0	0	1
03/03/2015 16:00	0.0	0	0	0	0	1
03/03/2015 17:00	0.0	0	0	0	0	1
03/03/2015 18:00	0.0	0	0	0	0	1
03/03/2015 19:00	0.0	0	0	0	0	1
03/03/2015 20:00	0.0	0	0	0	0	1
03/03/2015 21:00	0.0	0	0	0	0	1
03/03/2015 22:00	0.0	0	0	0	0	1
03/03/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/04/2015 00:00	0.0	0	0	0	0	1
03/04/2015 01:00	0.0	0	0	0	0	1
03/04/2015 02:00	0.0	0	0	0	0	1
03/04/2015 03:00	0.0	0	0	0	0	1
03/04/2015 04:00	0.0	0	0	0	0	1
03/04/2015 05:00	0.0	0	0	0	0	1
03/04/2015 06:00	0.0	0	0	0	0	1
03/04/2015 07:00	0.0	0	0	0	0	1
03/04/2015 08:00	0.0	0	0	0	0	1
03/04/2015 09:00	0.0	0	0	0	0	1
03/04/2015 10:00	0.0	0	0	0	0	1
03/04/2015 11:00	0.0	0	0	0	0	1
03/04/2015 12:00	0.0	0	0	0	0	1
03/04/2015 13:00	0.0	0	0	0	0	1
03/04/2015 14:00	0.0	0	0	0	0	1
03/04/2015 15:00	0.0	0	0	0	0	1
03/04/2015 16:00	0.0	0	0	0	0	1
03/04/2015 17:00	0.0	0	0	0	0	1
03/04/2015 18:00	0.0	0	0	0	0	1
03/04/2015 19:00	0.0	0	0	0	0	1
03/04/2015 20:00	0.0	0	0	0	0	1
03/04/2015 21:00	0.0	0	0	0	0	1
03/04/2015 22:00	0.0	0	0	0	0	1
03/04/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/05/2015 00:00	0.0	0	0	0	0	1
03/05/2015 01:00	0.0	0	0	0	0	1
03/05/2015 02:00	0.0	0	0	0	0	1
03/05/2015 03:00	0.0	0	0	0	0	1
03/05/2015 04:00	0.0	0	0	0	0	1
03/05/2015 05:00	0.0	0	0	0	0	1
03/05/2015 06:00	0.0	0	0	0	0	1
03/05/2015 07:00	0.0	0	0	0	0	1
03/05/2015 08:00	0.0	0	0	0	0	1
03/05/2015 09:00	0.0	0	0	0	0	1
03/05/2015 10:00	0.0	0	0	0	0	1
03/05/2015 11:00	0.0	0	0	0	0	1
03/05/2015 12:00	0.0	0	0	0	0	1
03/05/2015 13:00	0.0	0	0	0	0	1
03/05/2015 14:00	0.0	0	0	0	0	1
03/05/2015 15:00	0.0	0	0	0	0	1
03/05/2015 16:00	0.0	0	0	0	0	1
03/05/2015 17:00	0.0	0	0	0	0	1
03/05/2015 18:00	0.0	0	0	0	0	1
03/05/2015 19:00	0.0	0	0	0	0	1
03/05/2015 20:00	0.0	0	0	0	0	1
03/05/2015 21:00	0.0	0	0	0	0	1
03/05/2015 22:00	0.0	0	0	0	0	1
03/05/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/06/2015 00:00	0.0	0	0	0	0	1
03/06/2015 01:00	0.0	0	0	0	0	1
03/06/2015 02:00	0.0	0	0	0	0	1
03/06/2015 03:00	0.0	0	0	0	0	1
03/06/2015 04:00	0.0	0	0	0	0	1
03/06/2015 05:00	0.0	0	0	0	0	1
03/06/2015 06:00	0.0	0	0	0	0	1
03/06/2015 07:00	0.0	0	0	0	0	1
03/06/2015 08:00	0.0	0	0	0	0	1
03/06/2015 09:00	0.0	0	0	0	0	1
03/06/2015 10:00	0.0	0	0	0	0	1
03/06/2015 11:00	0.0	0	0	0	0	1
03/06/2015 12:00	0.0	0	0	0	0	1
03/06/2015 13:00	0.0	0	0	0	0	1
03/06/2015 14:00	0.0	0	0	0	0	1
03/06/2015 15:00	0.0	0	0	0	0	1
03/06/2015 16:00	0.0	0	0	0	0	1
03/06/2015 17:00	0.0	0	0	0	0	1
03/06/2015 18:00	0.0	0	0	0	0	1
03/06/2015 19:00	0.0	0	0	0	0	1
03/06/2015 20:00	0.0	0	0	0	0	1
03/06/2015 21:00	0.0	0	0	0	0	1
03/06/2015 22:00	0.0	0	0	0	0	1
03/06/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/07/2015 00:00	0.0	0	0	0	0	1
03/07/2015 01:00	0.0	0	0	0	0	1
03/07/2015 02:00	228.0	0	0	0	1	0
03/07/2015 03:00	0.0	0	0	0	0	0
03/07/2015 04:00	0.0	0	0	0	0	0
03/07/2015 05:00	0.0	0	0	0	0	0
03/07/2015 06:00	0.0	0	0	0	0	0
03/07/2015 07:00	0.0	0	0	0	0	0
03/07/2015 08:00	0.0	0	0	0	0	0
03/07/2015 09:00	0.0	0	0	0	0	0
03/07/2015 10:00	3,874.0	0	1	0	0	0
03/07/2015 11:00	6,072.2	0	1	0	0	0
03/07/2015 12:00	0.0	0	0	0	0	1
03/07/2015 13:00	0.0	0	0	0	0	1
03/07/2015 14:00	0.0	0	0	0	0	1
03/07/2015 15:00	0.0	0	0	0	0	1
03/07/2015 16:00	0.0	0	0	0	0	1
03/07/2015 17:00	0.0	0	0	0	0	1
03/07/2015 18:00	0.0	0	0	0	0	1
03/07/2015 19:00	0.0	0	0	0	0	1
03/07/2015 20:00	0.0	0	0	0	0	1
03/07/2015 21:00	0.0	0	0	0	0	1
03/07/2015 22:00	0.0	0	0	0	0	1
03/07/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	10,174.2 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,072.2	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/08/2015 00:00	0.0	0	0	0	0	1
03/08/2015 01:00	0.0	0	0	0	0	1
03/08/2015 02:00	0.0	0	0	0	0	1
03/08/2015 03:00	0.0	0	0	0	0	1
03/08/2015 04:00	0.0	0	0	0	0	1
03/08/2015 05:00	0.0	0	0	0	0	1
03/08/2015 06:00	0.0	0	0	0	0	1
03/08/2015 07:00	0.0	0	0	0	0	1
03/08/2015 08:00	342.4	0	0	0	1	0
03/08/2015 09:00	0.0	0	0	0	0	0
03/08/2015 10:00	0.0	0	0	0	0	0
03/08/2015 11:00	0.0	0	0	0	0	0
03/08/2015 12:00	0.0	0	0	0	0	0
03/08/2015 13:00	0.0	0	0	0	0	0
03/08/2015 14:00	0.0	0	0	1	0	0
03/08/2015 15:00	6,524.8	0	0	1	0	0
03/08/2015 16:00	2,230.7	0	0	1	0	0
03/08/2015 17:00	0.0	0	0	0	0	1
03/08/2015 18:00	0.0	0	0	0	0	1
03/08/2015 19:00	0.0	0	0	0	0	1
03/08/2015 20:00	0.0	0	0	0	0	1
03/08/2015 21:00	0.0	0	0	0	0	1
03/08/2015 22:00	0.0	0	0	0	0	1
03/08/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	9,097.9 #	0 #	0 #	3 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,524.8	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/09/2015 00:00	0.0	0	0	0	0	1
03/09/2015 01:00	0.0	0	0	0	0	1
03/09/2015 02:00	0.0	0	0	0	0	1
03/09/2015 03:00	0.0	0	0	0	0	1
03/09/2015 04:00	0.0	0	0	0	0	1
03/09/2015 05:00	0.0	0	0	0	0	1
03/09/2015 06:00	0.0	0	0	0	0	1
03/09/2015 07:00	0.0	0	0	0	0	1
03/09/2015 08:00	0.0	0	0	0	0	1
03/09/2015 09:00	0.0	0	0	0	0	1
03/09/2015 10:00	0.0	0	0	0	0	1
03/09/2015 11:00	0.0	0	0	0	0	1
03/09/2015 12:00	0.0	0	0	0	0	1
03/09/2015 13:00	0.0	0	0	0	0	1
03/09/2015 14:00	0.0	0	0	0	0	1
03/09/2015 15:00	0.0	0	0	0	0	1
03/09/2015 16:00	0.0	0	0	0	0	1
03/09/2015 17:00	0.0	0	0	0	0	1
03/09/2015 18:00	0.0	0	0	0	0	1
03/09/2015 19:00	0.0	0	0	0	0	1
03/09/2015 20:00	0.0	0	0	0	0	1
03/09/2015 21:00	0.0	0	0	0	0	1
03/09/2015 22:00	0.0	0	0	0	0	1
03/09/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/10/2015 00:00	0.0	0	0	0	0	1
03/10/2015 01:00	0.0	0	0	0	0	1
03/10/2015 02:00	0.0	0	0	0	0	1
03/10/2015 03:00	0.0	0	0	0	0	1
03/10/2015 04:00	0.0	0	0	0	0	1
03/10/2015 05:00	0.0	0	0	0	0	1
03/10/2015 06:00	0.0	0	0	0	0	1
03/10/2015 07:00	0.0	0	0	0	0	1
03/10/2015 08:00	0.0	0	0	0	0	1
03/10/2015 09:00	0.0	0	0	0	0	1
03/10/2015 10:00	0.0	0	0	0	0	1
03/10/2015 11:00	0.0	0	0	0	0	1
03/10/2015 12:00	0.0	0	0	0	0	1
03/10/2015 13:00	0.0	0	0	0	0	1
03/10/2015 14:00	0.0	0	0	0	0	1
03/10/2015 15:00	0.0	0	0	0	0	1
03/10/2015 16:00	0.0	0	0	0	0	1
03/10/2015 17:00	0.0	0	0	0	0	1
03/10/2015 18:00	0.0	0	0	0	0	1
03/10/2015 19:00	0.0	0	0	0	0	1
03/10/2015 20:00	0.0	0	0	0	0	1
03/10/2015 21:00	0.0	0	0	0	0	1
03/10/2015 22:00	0.0	0	0	0	0	1
03/10/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/11/2015 00:00	0.0	0	0	0	0	1
03/11/2015 01:00	0.0	0	0	0	0	1
03/11/2015 02:00	0.0	0	0	0	0	1
03/11/2015 03:00	0.0	0	0	0	0	1
03/11/2015 04:00	0.0	0	0	0	0	1
03/11/2015 05:00	0.0	0	0	0	0	1
03/11/2015 06:00	0.0	0	0	0	0	1
03/11/2015 07:00	0.0	0	0	0	0	1
03/11/2015 08:00	0.0	0	0	0	0	1
03/11/2015 09:00	0.0	0	0	0	0	1
03/11/2015 10:00	0.0	0	0	0	0	1
03/11/2015 11:00	0.0	0	0	0	0	1
03/11/2015 12:00	0.0	0	0	0	0	1
03/11/2015 13:00	0.0	0	0	0	0	1
03/11/2015 14:00	0.0	0	0	0	0	1
03/11/2015 15:00	0.0	0	0	0	0	1
03/11/2015 16:00	0.0	0	0	0	0	1
03/11/2015 17:00	0.0	0	0	0	0	1
03/11/2015 18:00	0.0	0	0	0	0	1
03/11/2015 19:00	0.0	0	0	0	0	1
03/11/2015 20:00	0.0	0	0	0	0	1
03/11/2015 21:00	0.0	0	0	0	0	1
03/11/2015 22:00	0.0	0	0	0	0	1
03/11/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/12/2015 00:00	0.0	0	0	0	0	1
03/12/2015 01:00	0.0	0	0	0	0	1
03/12/2015 02:00	0.0	0	0	0	0	1
03/12/2015 03:00	0.0	0	0	0	0	1
03/12/2015 04:00	0.0	0	0	0	0	1
03/12/2015 05:00	0.0	0	0	0	0	1
03/12/2015 06:00	0.0	0	0	0	0	1
03/12/2015 07:00	0.0	0	0	0	0	1
03/12/2015 08:00	0.0	0	0	0	0	1
03/12/2015 09:00	0.0	0	0	0	0	1
03/12/2015 10:00	0.0	0	0	0	0	1
03/12/2015 11:00	0.0	0	0	0	0	1
03/12/2015 12:00	0.0	0	0	0	0	1
03/12/2015 13:00	0.0	0	0	0	0	1
03/12/2015 14:00	0.0	0	0	0	0	1
03/12/2015 15:00	0.0	0	0	0	0	1
03/12/2015 16:00	0.0	0	0	0	0	1
03/12/2015 17:00	0.0	0	0	0	0	1
03/12/2015 18:00	0.0	0	0	0	0	1
03/12/2015 19:00	0.0	0	0	0	0	1
03/12/2015 20:00	0.0	0	0	0	0	1
03/12/2015 21:00	0.0	0	0	0	0	1
03/12/2015 22:00	0.0	0	0	0	0	1
03/12/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/13/2015 00:00	0.0	0	0	0	0	1
03/13/2015 01:00	0.0	0	0	0	0	1
03/13/2015 02:00	0.0	0	0	0	0	1
03/13/2015 03:00	0.0	0	0	0	0	1
03/13/2015 04:00	0.0	0	0	0	0	1
03/13/2015 05:00	0.0	0	0	0	0	1
03/13/2015 06:00	0.0	0	0	0	0	1
03/13/2015 07:00	0.0	0	0	0	0	1
03/13/2015 08:00	0.0	0	0	0	0	1
03/13/2015 09:00	0.0	0	0	0	0	1
03/13/2015 10:00	0.0	0	0	0	0	1
03/13/2015 11:00	0.0	0	0	0	0	1
03/13/2015 12:00	0.0	0	0	0	0	1
03/13/2015 13:00	0.0	0	0	0	0	1
03/13/2015 14:00	0.0	0	0	0	0	1
03/13/2015 15:00	0.0	0	0	0	0	1
03/13/2015 16:00	0.0	0	0	0	0	1
03/13/2015 17:00	0.0	0	0	0	0	1
03/13/2015 18:00	0.0	0	0	0	0	1
03/13/2015 19:00	0.0	0	0	0	0	1
03/13/2015 20:00	0.0	0	0	0	0	1
03/13/2015 21:00	0.0	0	0	0	0	1
03/13/2015 22:00	0.0	0	0	0	0	1
03/13/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/14/2015 00:00	0.0	0	0	0	0	1
03/14/2015 01:00	0.0	0	0	0	0	1
03/14/2015 02:00	0.0	0	0	0	0	1
03/14/2015 03:00	0.0	0	0	0	0	1
03/14/2015 04:00	0.0	0	0	0	0	1
03/14/2015 05:00	0.0	0	0	0	0	1
03/14/2015 06:00	0.0	0	0	0	0	1
03/14/2015 07:00	0.0	0	0	0	0	1
03/14/2015 08:00	0.0	0	0	0	0	1
03/14/2015 09:00	0.0	0	0	0	0	1
03/14/2015 10:00	0.0	0	0	0	0	1
03/14/2015 11:00	0.0	0	0	0	0	1
03/14/2015 12:00	0.0	0	0	0	0	1
03/14/2015 13:00	0.0	0	0	0	0	1
03/14/2015 14:00	0.0	0	0	0	0	1
03/14/2015 15:00	0.0	0	0	0	0	1
03/14/2015 16:00	0.0	0	0	0	0	1
03/14/2015 17:00	0.0	0	0	0	0	1
03/14/2015 18:00	0.0	0	0	0	0	1
03/14/2015 19:00	0.0	0	0	0	0	1
03/14/2015 20:00	0.0	0	0	0	0	1
03/14/2015 21:00	0.0	0	0	0	0	1
03/14/2015 22:00	0.0	0	0	0	0	1
03/14/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/15/2015 00:00	0.0	0	0	0	0	1
03/15/2015 01:00	0.0	0	0	0	0	1
03/15/2015 02:00	0.0	0	0	0	0	1
03/15/2015 03:00	0.0	0	0	0	0	1
03/15/2015 04:00	0.0	0	0	0	0	1
03/15/2015 05:00	0.0	0	0	0	0	1
03/15/2015 06:00	0.0	0	0	0	0	1
03/15/2015 07:00	0.0	0	0	0	0	1
03/15/2015 08:00	0.0	0	0	0	0	1
03/15/2015 09:00	0.0	0	0	0	0	1
03/15/2015 10:00	0.0	0	0	0	0	1
03/15/2015 11:00	0.0	0	0	0	0	1
03/15/2015 12:00	0.0	0	0	0	0	1
03/15/2015 13:00	0.0	0	0	0	0	1
03/15/2015 14:00	0.0	0	0	0	0	1
03/15/2015 15:00	0.0	0	0	0	0	1
03/15/2015 16:00	0.0	0	0	0	0	1
03/15/2015 17:00	0.0	0	0	0	0	1
03/15/2015 18:00	0.0	0	0	0	0	1
03/15/2015 19:00	0.0	0	0	0	0	1
03/15/2015 20:00	0.0	0	0	0	0	1
03/15/2015 21:00	0.0	0	0	0	0	1
03/15/2015 22:00	0.0	0	0	0	0	1
03/15/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/16/2015 00:00	0.0	0	0	0	0	1
03/16/2015 01:00	0.0	0	0	0	0	1
03/16/2015 02:00	0.0	0	0	0	0	1
03/16/2015 03:00	0.0	0	0	0	0	1
03/16/2015 04:00	0.0	0	0	0	0	1
03/16/2015 05:00	0.0	0	0	0	0	1
03/16/2015 06:00	0.0	0	0	0	0	1
03/16/2015 07:00	0.0	0	0	0	0	1
03/16/2015 08:00	0.0	0	0	0	0	1
03/16/2015 09:00	0.0	0	0	0	0	1
03/16/2015 10:00	0.0	0	0	0	0	1
03/16/2015 11:00	0.0	0	0	0	0	1
03/16/2015 12:00	0.0	0	0	0	0	1
03/16/2015 13:00	0.0	0	0	0	0	1
03/16/2015 14:00	0.0	0	0	0	0	1
03/16/2015 15:00	0.0	0	0	0	0	1
03/16/2015 16:00	0.0	0	0	0	0	1
03/16/2015 17:00	0.0	0	0	0	0	1
03/16/2015 18:00	0.0	0	0	0	0	1
03/16/2015 19:00	0.0	0	0	0	0	1
03/16/2015 20:00	0.0	0	0	0	0	1
03/16/2015 21:00	0.0	0	0	0	0	1
03/16/2015 22:00	0.0	0	0	0	0	1
03/16/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/17/2015 00:00	0.0	0	0	0	0	1
03/17/2015 01:00	0.0	0	0	0	0	1
03/17/2015 02:00	0.0	0	0	0	0	1
03/17/2015 03:00	0.0	0	0	0	0	1
03/17/2015 04:00	0.0	0	0	0	0	1
03/17/2015 05:00	0.0	0	0	0	0	1
03/17/2015 06:00	0.0	0	0	0	0	1
03/17/2015 07:00	0.0	0	0	0	0	1
03/17/2015 08:00	0.0	0	0	0	0	1
03/17/2015 09:00	0.0	0	0	0	0	1
03/17/2015 10:00	0.0	0	0	0	0	1
03/17/2015 11:00	208.2	0	0	1	0	0
03/17/2015 12:00	1,042.2	0	0	1	0	0
03/17/2015 13:00	0.0	0	0	0	0	1
03/17/2015 14:00	0.0	0	0	0	0	1
03/17/2015 15:00	0.0	0	0	0	0	1
03/17/2015 16:00	0.0	0	0	0	0	1
03/17/2015 17:00	0.0	0	0	0	0	1
03/17/2015 18:00	0.0	0	0	0	0	1
03/17/2015 19:00	0.0	0	0	0	0	1
03/17/2015 20:00	0.0	0	0	0	0	1
03/17/2015 21:00	0.0	0	0	0	0	1
03/17/2015 22:00	0.0	0	0	0	0	1
03/17/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	1,250.4 #	0 #	0 #	2 #	0 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1,042.2	0	0	1	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/18/2015 00:00	0.0	0	0	0	0	1
03/18/2015 01:00	0.0	0	0	0	0	1
03/18/2015 02:00	0.0	0	0	0	0	1
03/18/2015 03:00	0.0	0	0	0	0	1
03/18/2015 04:00	0.0	0	0	0	0	1
03/18/2015 05:00	0.0	0	0	0	0	1
03/18/2015 06:00	0.0	0	0	0	0	1
03/18/2015 07:00	0.0	0	0	0	0	1
03/18/2015 08:00	0.0	0	0	0	0	1
03/18/2015 09:00	0.0	0	0	0	0	1
03/18/2015 10:00	0.0	0	0	0	0	1
03/18/2015 11:00	0.0	0	0	0	0	1
03/18/2015 12:00	0.0	0	0	0	0	1
03/18/2015 13:00	0.0	0	0	0	0	1
03/18/2015 14:00	0.0	0	0	0	0	1
03/18/2015 15:00	0.0	0	0	0	0	1
03/18/2015 16:00	0.0	0	0	0	0	1
03/18/2015 17:00	0.0	0	0	0	0	1
03/18/2015 18:00	0.0	0	0	0	0	1
03/18/2015 19:00	0.0	0	0	0	0	1
03/18/2015 20:00	0.0	0	0	0	0	1
03/18/2015 21:00	0.0	0	0	0	0	1
03/18/2015 22:00	0.0	0	0	0	0	1
03/18/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/19/2015 00:00	0.0	0	0	0	0	1
03/19/2015 01:00	0.0	0	0	0	0	1
03/19/2015 02:00	0.0	0	0	0	0	1
03/19/2015 03:00	0.0	0	0	0	0	1
03/19/2015 04:00	0.0	0	0	0	0	1
03/19/2015 05:00	0.0	0	0	0	0	1
03/19/2015 06:00	0.0	0	0	0	0	1
03/19/2015 07:00	0.0	0	0	0	0	1
03/19/2015 08:00	0.0	0	0	0	0	1
03/19/2015 09:00	0.0	0	0	0	0	1
03/19/2015 10:00	0.0	0	0	0	0	1
03/19/2015 11:00	0.0	0	0	0	0	1
03/19/2015 12:00	0.0	0	0	0	0	1
03/19/2015 13:00	0.0	0	0	0	0	1
03/19/2015 14:00	0.0	0	0	0	0	1
03/19/2015 15:00	0.0	0	0	0	0	1
03/19/2015 16:00	0.0	0	0	0	0	1
03/19/2015 17:00	0.0	0	0	0	0	1
03/19/2015 18:00	0.0	0	0	0	0	1
03/19/2015 19:00	0.0	0	0	0	0	1
03/19/2015 20:00	0.0	0	0	0	0	1
03/19/2015 21:00	0.0	0	0	0	0	1
03/19/2015 22:00	0.0	0	0	0	0	1
03/19/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/20/2015 00:00	0.0	0	0	0	0	1
03/20/2015 01:00	0.0	0	0	0	0	1
03/20/2015 02:00	0.0	0	0	0	0	1
03/20/2015 03:00	0.0	0	0	0	0	1
03/20/2015 04:00	0.0	0	0	0	0	1
03/20/2015 05:00	0.0	0	0	0	0	1
03/20/2015 06:00	0.0	0	0	0	0	1
03/20/2015 07:00	0.0	0	0	0	0	1
03/20/2015 08:00	0.0	0	0	0	0	1
03/20/2015 09:00	0.0	0	0	0	0	1
03/20/2015 10:00	0.0	0	0	0	0	1
03/20/2015 11:00	0.0	0	0	0	0	1
03/20/2015 12:00	0.0	0	0	0	0	1
03/20/2015 13:00	0.0	0	0	0	0	1
03/20/2015 14:00	0.0	0	0	0	0	1
03/20/2015 15:00	0.0	0	0	0	0	1
03/20/2015 16:00	0.0	0	0	0	0	1
03/20/2015 17:00	0.0	0	0	0	0	1
03/20/2015 18:00	0.0	0	0	0	0	1
03/20/2015 19:00	0.0	0	0	0	0	1
03/20/2015 20:00	0.0	0	0	0	0	1
03/20/2015 21:00	0.0	0	0	0	0	1
03/20/2015 22:00	0.0	0	0	0	0	1
03/20/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/21/2015 00:00	0.0	0	0	0	0	1
03/21/2015 01:00	0.0	0	0	0	0	1
03/21/2015 02:00	0.0	0	0	0	0	1
03/21/2015 03:00	0.0	0	0	0	0	1
03/21/2015 04:00	0.0	0	0	0	0	1
03/21/2015 05:00	0.0	0	0	0	0	1
03/21/2015 06:00	0.0	0	0	0	0	1
03/21/2015 07:00	0.0	0	0	0	0	1
03/21/2015 08:00	0.0	0	0	0	0	1
03/21/2015 09:00	0.0	0	0	0	0	1
03/21/2015 10:00	0.0	0	0	0	0	1
03/21/2015 11:00	0.0	0	0	0	0	1
03/21/2015 12:00	0.0	0	0	0	0	1
03/21/2015 13:00	0.0	0	0	0	0	1
03/21/2015 14:00	0.0	0	0	0	0	1
03/21/2015 15:00	0.0	0	0	0	0	1
03/21/2015 16:00	0.0	0	0	0	0	1
03/21/2015 17:00	0.0	0	0	0	0	1
03/21/2015 18:00	0.0	0	0	0	0	1
03/21/2015 19:00	0.0	0	0	0	0	1
03/21/2015 20:00	0.0	0	0	0	0	1
03/21/2015 21:00	0.0	0	0	0	0	1
03/21/2015 22:00	0.0	0	0	0	0	1
03/21/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/22/2015 00:00	0.0	0	0	0	0	1
03/22/2015 01:00	0.0	0	0	0	0	1
03/22/2015 02:00	0.0	0	0	0	0	1
03/22/2015 03:00	0.0	0	0	0	0	1
03/22/2015 04:00	0.0	0	0	0	0	1
03/22/2015 05:00	0.0	0	0	0	0	1
03/22/2015 06:00	0.0	0	0	0	0	1
03/22/2015 07:00	0.0	0	0	0	0	1
03/22/2015 08:00	0.0	0	0	0	0	1
03/22/2015 09:00	0.0	0	0	0	0	1
03/22/2015 10:00	0.0	0	0	0	0	1
03/22/2015 11:00	0.0	0	0	0	0	1
03/22/2015 12:00	0.0	0	0	0	0	1
03/22/2015 13:00	0.0	0	0	0	0	1
03/22/2015 14:00	0.0	0	0	0	0	1
03/22/2015 15:00	0.0	0	0	0	0	1
03/22/2015 16:00	0.0	0	0	0	0	1
03/22/2015 17:00	0.0	0	0	0	0	1
03/22/2015 18:00	0.0	0	0	0	0	1
03/22/2015 19:00	0.0	0	0	0	0	1
03/22/2015 20:00	0.0	0	0	0	0	1
03/22/2015 21:00	0.0	0	0	0	0	1
03/22/2015 22:00	0.0	0	0	0	0	1
03/22/2015 23:00	455.8	0	0	0	1	0
Average/Sum#:	455.8 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	455.8	0	0	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/23/2015 00:00	0.0	0	0	0	0	0
03/23/2015 01:00	0.0	0	0	0	0	0
03/23/2015 02:00	0.0	0	0	0	0	0
03/23/2015 03:00	0.0	0	0	0	0	0
03/23/2015 04:00	0.0	0	0	0	0	0
03/23/2015 05:00	0.0	0	0	0	0	0
03/23/2015 06:00	0.0	0	0	0	0	0
03/23/2015 07:00	0.0	0	0	0	0	0
03/23/2015 08:00	0.0	0	0	0	0	0
03/23/2015 09:00	0.0	0	0	0	0	0
03/23/2015 10:00	0.0	0	0	0	0	0
03/23/2015 11:00	0.0	0	0	0	0	0
03/23/2015 12:00	0.0	0	0	0	0	0
03/23/2015 13:00	0.0	0	0	0	0	0
03/23/2015 14:00	0.0	0	0	0	0	0
03/23/2015 15:00	0.0	0	0	0	0	0
03/23/2015 16:00	0.0	0	0	0	0	0
03/23/2015 17:00	0.0	0	0	0	0	0
03/23/2015 18:00	0.0	0	0	0	0	0
03/23/2015 19:00	0.0	0	0	0	0	0
03/23/2015 20:00	0.0	0	0	0	0	0
03/23/2015 21:00	0.0	0	0	0	0	0
03/23/2015 22:00	0.0	0	0	0	0	0
03/23/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/24/2015 00:00	0.0	0	0	0	0	0
03/24/2015 01:00	0.0	0	0	0	0	0
03/24/2015 02:00	0.0	0	0	0	0	0
03/24/2015 03:00	0.0	0	0	0	0	0
03/24/2015 04:00	0.0	0	0	0	0	0
03/24/2015 05:00	0.0	0	0	0	0	0
03/24/2015 06:00	0.0	0	0	0	0	0
03/24/2015 07:00	0.0	0	0	0	0	0
03/24/2015 08:00	0.0	0	0	0	0	0
03/24/2015 09:00	0.0	0	0	0	0	0
03/24/2015 10:00	0.0	0	0	0	0	0
03/24/2015 11:00	0.0	0	0	0	0	0
03/24/2015 12:00	0.0	0	0	0	0	0
03/24/2015 13:00	0.0	0	0	0	0	0
03/24/2015 14:00	0.0	0	0	0	0	0
03/24/2015 15:00	0.0	0	0	0	0	0
03/24/2015 16:00	0.0	0	0	0	0	0
03/24/2015 17:00	0.0	0	0	0	0	0
03/24/2015 18:00	0.0	0	0	0	0	0
03/24/2015 19:00	0.0	0	0	0	0	0
03/24/2015 20:00	0.0	0	0	0	0	0
03/24/2015 21:00	0.0	0	0	0	0	0
03/24/2015 22:00	0.0	0	0	0	0	0
03/24/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/25/2015 00:00	0.0	0	0	0	0	0
03/25/2015 01:00	0.0	0	0	0	0	0
03/25/2015 02:00	0.0	0	0	0	0	0
03/25/2015 03:00	0.0	0	0	0	0	0
03/25/2015 04:00	0.0	0	0	0	0	0
03/25/2015 05:00	0.0	0	0	0	0	0
03/25/2015 06:00	0.0	0	0	0	0	0
03/25/2015 07:00	0.0	0	0	0	0	0
03/25/2015 08:00	0.0	0	0	0	0	0
03/25/2015 09:00	0.0	0	0	0	0	0
03/25/2015 10:00	0.0	0	0	0	0	0
03/25/2015 11:00	0.0	0	0	0	0	0
03/25/2015 12:00	0.0	0	0	0	0	0
03/25/2015 13:00	0.0	0	0	0	0	0
03/25/2015 14:00	0.0	0	0	0	0	0
03/25/2015 15:00	0.0	0	0	0	0	0
03/25/2015 16:00	0.0	0	0	0	0	0
03/25/2015 17:00	0.0	0	0	0	0	0
03/25/2015 18:00	0.0	0	0	0	0	0
03/25/2015 19:00	0.0	0	0	0	0	0
03/25/2015 20:00	0.0	0	0	0	0	0
03/25/2015 21:00	0.0	0	0	0	0	0
03/25/2015 22:00	0.0	0	0	0	0	0
03/25/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/26/2015 00:00	0.0	0	0	0	0	0
03/26/2015 01:00	0.0	0	0	0	0	0
03/26/2015 02:00	0.0	0	0	0	0	0
03/26/2015 03:00	2,496.4	1	0	0	0	0
03/26/2015 04:00	5,737.0	1	0	0	0	0
03/26/2015 05:00	7,097.0	1	0	0	0	0
03/26/2015 06:00	0.0	0	0	0	0	1
03/26/2015 07:00	0.0	0	0	0	0	1
03/26/2015 08:00	0.0	0	0	0	0	1
03/26/2015 09:00	0.0	0	0	0	0	1
03/26/2015 10:00	0.0	0	0	0	0	1
03/26/2015 11:00	0.0	0	0	0	0	1
03/26/2015 12:00	0.0	0	0	0	0	1
03/26/2015 13:00	0.0	0	0	0	0	1
03/26/2015 14:00	0.0	0	0	0	0	1
03/26/2015 15:00	0.0	0	0	0	0	1
03/26/2015 16:00	0.0	0	0	0	0	1
03/26/2015 17:00	0.0	0	0	0	0	1
03/26/2015 18:00	0.0	0	0	0	0	1
03/26/2015 19:00	0.0	0	0	0	0	1
03/26/2015 20:00	0.0	0	0	0	0	1
03/26/2015 21:00	0.0	0	0	0	0	1
03/26/2015 22:00	392.7	0	0	0	1	0
03/26/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	15,723.1 #	3 #	0 #	0 #	1 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	7,097.0	1	0	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/27/2015 00:00	0.0	0	0	0	0	0
03/27/2015 01:00	0.0	0	0	0	0	0
03/27/2015 02:00	0.0	0	0	0	0	0
03/27/2015 03:00	0.0	0	0	0	0	0
03/27/2015 04:00	219.4	0	0	1	0	0
03/27/2015 05:00	6,456.6	0	0	1	0	0
03/27/2015 06:00	0.0	0	0	0	0	1
03/27/2015 07:00	0.0	0	0	0	0	1
03/27/2015 08:00	0.0	0	0	0	0	1
03/27/2015 09:00	0.0	0	0	0	0	1
03/27/2015 10:00	0.0	0	0	0	0	1
03/27/2015 11:00	0.0	0	0	0	0	1
03/27/2015 12:00	0.0	0	0	0	0	1
03/27/2015 13:00	0.0	0	0	0	0	1
03/27/2015 14:00	0.0	0	0	0	0	1
03/27/2015 15:00	0.0	0	0	0	0	1
03/27/2015 16:00	0.0	0	0	0	0	1
03/27/2015 17:00	0.0	0	0	0	0	1
03/27/2015 18:00	0.0	0	0	0	0	1
03/27/2015 19:00	0.0	0	0	0	0	1
03/27/2015 20:00	455.7	0	0	0	1	0
03/27/2015 21:00	0.0	0	0	0	0	0
03/27/2015 22:00	0.0	0	0	0	0	0
03/27/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	7,131.7 #	0 #	0 #	2 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,456.6	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/28/2015 00:00	0.0	0	0	0	0	0
03/28/2015 01:00	0.0	0	0	0	0	0
03/28/2015 02:00	0.0	0	0	0	0	0
03/28/2015 03:00	0.0	0	0	0	0	0
03/28/2015 04:00	0.0	0	0	0	0	0
03/28/2015 05:00	0.0	0	0	0	0	0
03/28/2015 06:00	0.0	0	0	0	0	0
03/28/2015 07:00	0.0	0	0	0	0	0
03/28/2015 08:00	0.0	0	0	0	0	0
03/28/2015 09:00	0.0	0	0	0	0	0
03/28/2015 10:00	0.0	0	0	0	0	0
03/28/2015 11:00	0.0	0	0	0	0	0
03/28/2015 12:00	0.0	0	0	0	0	0
03/28/2015 13:00	0.0	0	0	0	0	0
03/28/2015 14:00	0.0	0	0	0	0	0
03/28/2015 15:00	0.0	0	0	0	0	0
03/28/2015 16:00	0.0	0	0	0	0	0
03/28/2015 17:00	0.0	0	0	0	0	0
03/28/2015 18:00	0.0	0	0	0	0	0
03/28/2015 19:00	0.0	0	0	0	0	0
03/28/2015 20:00	0.0	0	0	0	0	0
03/28/2015 21:00	0.0	0	0	0	0	0
03/28/2015 22:00	0.0	0	0	0	0	0
03/28/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/29/2015 00:00	0.0	0	0	0	0	0
03/29/2015 01:00	0.0	0	0	0	0	0
03/29/2015 02:00	0.0	0	0	0	0	0
03/29/2015 03:00	0.0	0	0	0	0	0
03/29/2015 04:00	0.0	0	0	0	0	0
03/29/2015 05:00	0.0	0	0	0	0	0
03/29/2015 06:00	0.0	0	0	0	0	0
03/29/2015 07:00	0.0	0	0	0	0	0
03/29/2015 08:00	0.0	0	0	0	0	0
03/29/2015 09:00	0.0	0	0	0	0	0
03/29/2015 10:00	0.0	0	0	0	0	0
03/29/2015 11:00	0.0	0	0	0	0	0
03/29/2015 12:00	0.0	0	0	0	0	0
03/29/2015 13:00	0.0	0	0	0	0	0
03/29/2015 14:00	0.0	0	0	0	0	0
03/29/2015 15:00	0.0	0	0	0	0	0
03/29/2015 16:00	0.0	0	0	0	0	0
03/29/2015 17:00	0.0	0	0	0	0	0
03/29/2015 18:00	0.0	0	0	0	0	0
03/29/2015 19:00	0.0	0	0	0	0	0
03/29/2015 20:00	0.0	0	0	0	0	0
03/29/2015 21:00	0.0	0	0	0	0	0
03/29/2015 22:00	0.0	0	0	0	0	0
03/29/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/30/2015 00:00	0.0	0	0	0	0	0
03/30/2015 01:00	0.0	0	0	0	0	0
03/30/2015 02:00	0.0	0	0	0	0	0
03/30/2015 03:00	2,529.9	0	1	0	0	0
03/30/2015 04:00	6,905.6	0	1	0	0	0
03/30/2015 05:00	5,148.6	0	1	0	0	0
03/30/2015 06:00	0.0	0	0	0	0	1
03/30/2015 07:00	0.0	0	0	0	0	1
03/30/2015 08:00	0.0	0	0	0	0	1
03/30/2015 09:00	0.0	0	0	0	0	1
03/30/2015 10:00	0.0	0	0	0	0	1
03/30/2015 11:00	0.0	0	0	0	0	1
03/30/2015 12:00	0.0	0	0	0	0	1
03/30/2015 13:00	0.0	0	0	0	0	1
03/30/2015 14:00	0.0	0	0	0	0	1
03/30/2015 15:00	0.0	0	0	0	0	1
03/30/2015 16:00	0.0	0	0	0	0	1
03/30/2015 17:00	0.0	0	0	0	0	1
03/30/2015 18:00	0.0	0	0	0	0	1
03/30/2015 19:00	0.0	0	0	0	0	1
03/30/2015 20:00	587.2	0	0	0	1	0
03/30/2015 21:00	0.0	0	0	0	0	0
03/30/2015 22:00	0.0	0	0	0	0	0
03/30/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	15,171.3 #	0 #	3 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,905.6	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/31/2015 00:00	0.0	0	0	0	0	0
03/31/2015 01:00	0.0	0	0	0	0	0
03/31/2015 02:00	0.0	0	0	0	0	0
03/31/2015 03:00	0.0	0	0	0	0	0
03/31/2015 04:00	3,176.9	0	0	1	0	0
03/31/2015 05:00	3,388.9	0	0	1	0	0
03/31/2015 06:00	0.0	0	0	0	0	1
03/31/2015 07:00	0.0	0	0	0	0	1
03/31/2015 08:00	0.0	0	0	0	0	1
03/31/2015 09:00	0.0	0	0	0	0	1
03/31/2015 10:00	0.0	0	0	0	0	1
03/31/2015 11:00	0.0	0	0	0	0	1
03/31/2015 12:00	0.0	0	0	0	0	1
03/31/2015 13:00	0.0	0	0	0	0	1
03/31/2015 14:00	0.0	0	0	0	0	1
03/31/2015 15:00	0.0	0	0	0	0	1
03/31/2015 16:00	0.0	0	0	0	0	1
03/31/2015 17:00	0.0	0	0	0	0	1
03/31/2015 18:00	0.0	0	0	0	0	1
03/31/2015 19:00	0.0	0	0	0	0	1
03/31/2015 20:00	0.0	0	0	0	0	1
03/31/2015 21:00	618.8	0	0	0	1	0
03/31/2015 22:00	0.0	0	0	0	0	0
03/31/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	7,184.6 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3,388.9	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/01/2015 00:00	0.0	0	0	0	0	1
01/01/2015 01:00	0.0	0	0	0	0	1
01/01/2015 02:00	0.0	0	0	0	0	1
01/01/2015 03:00	0.0	0	0	0	0	1
01/01/2015 04:00	0.0	0	0	0	0	1
01/01/2015 05:00	0.0	0	0	0	0	1
01/01/2015 06:00	0.0	0	0	0	0	1
01/01/2015 07:00	0.0	0	0	0	0	1
01/01/2015 08:00	0.0	0	0	0	0	1
01/01/2015 09:00	0.0	0	0	0	0	1
01/01/2015 10:00	0.0	0	0	0	0	1
01/01/2015 11:00	0.0	0	0	0	0	1
01/01/2015 12:00	0.0	0	0	0	0	1
01/01/2015 13:00	0.0	0	0	0	0	1
01/01/2015 14:00	0.0	0	0	0	0	1
01/01/2015 15:00	0.0	0	0	0	0	1
01/01/2015 16:00	0.0	0	0	0	0	1
01/01/2015 17:00	0.0	0	0	0	0	1
01/01/2015 18:00	0.0	0	0	0	0	1
01/01/2015 19:00	0.0	0	0	0	0	1
01/01/2015 20:00	0.0	0	0	0	0	1
01/01/2015 21:00	0.0	0	0	0	0	1
01/01/2015 22:00	0.0	0	0	0	0	1
01/01/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/02/2015 00:00	0.0	0	0	0	0	1
01/02/2015 01:00	0.0	0	0	0	0	1
01/02/2015 02:00	0.0	0	0	0	0	1
01/02/2015 03:00	0.0	0	0	0	0	1
01/02/2015 04:00	0.0	0	0	0	0	1
01/02/2015 05:00	0.0	0	0	0	0	1
01/02/2015 06:00	0.0	0	0	0	0	1
01/02/2015 07:00	0.0	0	0	0	0	1
01/02/2015 08:00	0.0	0	0	0	0	1
01/02/2015 09:00	0.0	0	0	0	0	1
01/02/2015 10:00	0.0	0	0	0	0	1
01/02/2015 11:00	0.0	0	0	0	0	1
01/02/2015 12:00	0.0	0	0	0	0	1
01/02/2015 13:00	0.0	0	0	0	0	1
01/02/2015 14:00	0.0	0	0	0	0	1
01/02/2015 15:00	0.0	0	0	0	0	1
01/02/2015 16:00	0.0	0	0	0	0	1
01/02/2015 17:00	0.0	0	0	0	0	1
01/02/2015 18:00	0.0	0	0	0	0	1
01/02/2015 19:00	0.0	0	0	0	0	1
01/02/2015 20:00	0.0	0	0	0	0	1
01/02/2015 21:00	0.0	0	0	0	0	1
01/02/2015 22:00	0.0	0	0	0	0	1
01/02/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/03/2015 00:00	0.0	0	0	0	0	1
01/03/2015 01:00	0.0	0	0	0	0	1
01/03/2015 02:00	0.0	0	0	0	0	1
01/03/2015 03:00	0.0	0	0	0	0	1
01/03/2015 04:00	0.0	0	0	0	0	1
01/03/2015 05:00	0.0	0	0	0	0	1
01/03/2015 06:00	0.0	0	0	0	0	1
01/03/2015 07:00	0.0	0	0	0	0	1
01/03/2015 08:00	0.0	0	0	0	0	1
01/03/2015 09:00	0.0	0	0	0	0	1
01/03/2015 10:00	0.0	0	0	0	0	1
01/03/2015 11:00	0.0	0	0	0	0	1
01/03/2015 12:00	0.0	0	0	0	0	1
01/03/2015 13:00	0.0	0	0	0	0	1
01/03/2015 14:00	0.0	0	0	0	0	1
01/03/2015 15:00	0.0	0	0	0	0	1
01/03/2015 16:00	0.0	0	0	0	0	1
01/03/2015 17:00	0.0	0	0	0	0	1
01/03/2015 18:00	0.0	0	0	0	0	1
01/03/2015 19:00	0.0	0	0	0	0	1
01/03/2015 20:00	0.0	0	0	0	0	1
01/03/2015 21:00	0.0	0	0	0	0	1
01/03/2015 22:00	0.0	0	0	0	0	1
01/03/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/04/2015 00:00	0.0	0	0	0	0	1
01/04/2015 01:00	0.0	0	0	0	0	1
01/04/2015 02:00	0.0	0	0	0	0	1
01/04/2015 03:00	0.0	0	0	0	0	1
01/04/2015 04:00	0.0	0	0	0	0	1
01/04/2015 05:00	0.0	0	0	0	0	1
01/04/2015 06:00	0.0	0	0	0	0	1
01/04/2015 07:00	0.0	0	0	0	0	1
01/04/2015 08:00	0.0	0	0	0	0	1
01/04/2015 09:00	0.0	0	0	0	0	1
01/04/2015 10:00	0.0	0	0	0	0	1
01/04/2015 11:00	0.0	0	0	0	0	1
01/04/2015 12:00	0.0	0	0	0	0	1
01/04/2015 13:00	0.0	0	0	0	0	1
01/04/2015 14:00	0.0	0	0	0	0	1
01/04/2015 15:00	0.0	0	0	0	0	1
01/04/2015 16:00	0.0	0	0	0	0	1
01/04/2015 17:00	0.0	0	0	0	0	1
01/04/2015 18:00	0.0	0	0	0	0	1
01/04/2015 19:00	0.0	0	0	0	0	1
01/04/2015 20:00	0.0	0	0	0	0	1
01/04/2015 21:00	0.0	0	0	0	0	1
01/04/2015 22:00	0.0	0	0	0	0	1
01/04/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/05/2015 00:00	0.0	0	0	0	0	1
01/05/2015 01:00	0.0	0	0	0	0	1
01/05/2015 02:00	0.0	0	0	0	0	1
01/05/2015 03:00	0.0	0	0	0	0	1
01/05/2015 04:00	0.0	0	0	0	0	1
01/05/2015 05:00	0.0	0	0	0	0	1
01/05/2015 06:00	0.0	0	0	0	0	1
01/05/2015 07:00	0.0	0	0	0	0	1
01/05/2015 08:00	0.0	0	0	0	0	1
01/05/2015 09:00	0.0	0	0	0	0	1
01/05/2015 10:00	0.0	0	0	0	0	1
01/05/2015 11:00	0.0	0	0	0	0	1
01/05/2015 12:00	0.0	0	0	0	0	1
01/05/2015 13:00	0.0	0	0	0	0	1
01/05/2015 14:00	0.0	0	0	0	0	1
01/05/2015 15:00	0.0	0	0	0	0	1
01/05/2015 16:00	0.0	0	0	0	0	1
01/05/2015 17:00	0.0	0	0	0	0	1
01/05/2015 18:00	0.0	0	0	0	0	1
01/05/2015 19:00	0.0	0	0	0	0	1
01/05/2015 20:00	0.0	0	0	0	0	1
01/05/2015 21:00	0.0	0	0	0	0	1
01/05/2015 22:00	0.0	0	0	0	0	1
01/05/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/06/2015 00:00	0.0	0	0	0	0	1
01/06/2015 01:00	0.0	0	0	0	0	1
01/06/2015 02:00	0.0	0	0	0	0	1
01/06/2015 03:00	0.0	0	0	0	0	1
01/06/2015 04:00	0.0	0	0	0	0	1
01/06/2015 05:00	0.0	0	0	0	0	1
01/06/2015 06:00	0.0	0	0	0	0	1
01/06/2015 07:00	0.0	0	0	0	0	1
01/06/2015 08:00	0.0	0	0	0	0	1
01/06/2015 09:00	0.0	0	0	0	0	1
01/06/2015 10:00	0.0	0	0	0	0	1
01/06/2015 11:00	0.0	0	0	0	0	1
01/06/2015 12:00	0.0	0	0	0	0	1
01/06/2015 13:00	0.0	0	0	0	0	1
01/06/2015 14:00	0.0	0	0	0	0	1
01/06/2015 15:00	0.0	0	0	0	0	1
01/06/2015 16:00	0.0	0	0	0	0	1
01/06/2015 17:00	0.0	0	0	0	0	1
01/06/2015 18:00	0.0	0	0	0	0	1
01/06/2015 19:00	0.0	0	0	0	0	1
01/06/2015 20:00	0.0	0	0	0	0	1
01/06/2015 21:00	0.0	0	0	0	0	1
01/06/2015 22:00	0.0	0	0	0	0	1
01/06/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/07/2015 00:00	0.0	0	0	0	0	1
01/07/2015 01:00	0.0	0	0	0	0	1
01/07/2015 02:00	0.0	0	0	0	0	1
01/07/2015 03:00	0.0	0	0	0	0	1
01/07/2015 04:00	0.0	0	0	0	0	1
01/07/2015 05:00	0.0	0	0	0	0	1
01/07/2015 06:00	0.0	0	0	0	0	1
01/07/2015 07:00	0.0	0	0	0	0	1
01/07/2015 08:00	0.0	0	0	0	0	1
01/07/2015 09:00	0.0	0	0	0	0	1
01/07/2015 10:00	0.0	0	0	0	0	1
01/07/2015 11:00	0.0	0	0	0	0	1
01/07/2015 12:00	0.0	0	0	0	0	1
01/07/2015 13:00	0.0	0	0	0	0	1
01/07/2015 14:00	0.0	0	0	0	0	1
01/07/2015 15:00	0.0	0	0	0	0	1
01/07/2015 16:00	0.0	0	0	0	0	1
01/07/2015 17:00	0.0	0	0	0	0	1
01/07/2015 18:00	0.0	0	0	0	0	1
01/07/2015 19:00	0.0	0	0	0	0	1
01/07/2015 20:00	0.0	0	0	0	0	1
01/07/2015 21:00	0.0	0	0	0	0	1
01/07/2015 22:00	0.0	0	0	0	0	1
01/07/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/08/2015 00:00	0.0	0	0	0	0	1
01/08/2015 01:00	0.0	0	0	0	0	1
01/08/2015 02:00	0.0	0	0	0	0	1
01/08/2015 03:00	0.0	0	0	0	0	1
01/08/2015 04:00	0.0	0	0	0	0	1
01/08/2015 05:00	0.0	0	0	0	0	1
01/08/2015 06:00	0.0	0	0	0	0	1
01/08/2015 07:00	0.0	0	0	0	0	1
01/08/2015 08:00	0.0	0	0	0	0	1
01/08/2015 09:00	0.0	0	0	0	0	1
01/08/2015 10:00	0.0	0	0	0	0	1
01/08/2015 11:00	0.0	0	0	0	0	1
01/08/2015 12:00	0.0	0	0	0	0	1
01/08/2015 13:00	0.0	0	0	0	0	1
01/08/2015 14:00	0.0	0	0	0	0	1
01/08/2015 15:00	0.0	0	0	0	0	1
01/08/2015 16:00	0.0	0	0	0	0	1
01/08/2015 17:00	0.0	0	0	0	0	1
01/08/2015 18:00	0.0	0	0	0	0	1
01/08/2015 19:00	0.0	0	0	0	0	1
01/08/2015 20:00	0.0	0	0	0	0	1
01/08/2015 21:00	0.0	0	0	0	0	1
01/08/2015 22:00	0.0	0	0	0	0	1
01/08/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/09/2015 00:00	0.0	0	0	0	0	1
01/09/2015 01:00	0.0	0	0	0	0	1
01/09/2015 02:00	0.0	0	0	0	0	1
01/09/2015 03:00	0.0	0	0	0	0	1
01/09/2015 04:00	0.0	0	0	0	0	1
01/09/2015 05:00	0.0	0	0	0	0	1
01/09/2015 06:00	0.0	0	0	0	0	1
01/09/2015 07:00	0.0	0	0	0	0	1
01/09/2015 08:00	0.0	0	0	0	0	1
01/09/2015 09:00	0.0	0	0	0	0	1
01/09/2015 10:00	0.0	0	0	0	0	1
01/09/2015 11:00	0.0	0	0	0	0	1
01/09/2015 12:00	0.0	0	0	0	0	1
01/09/2015 13:00	0.0	0	0	0	0	1
01/09/2015 14:00	0.0	0	0	0	0	1
01/09/2015 15:00	0.0	0	0	0	0	1
01/09/2015 16:00	0.0	0	0	0	0	1
01/09/2015 17:00	0.0	0	0	0	0	1
01/09/2015 18:00	0.0	0	0	0	0	1
01/09/2015 19:00	0.0	0	0	0	0	1
01/09/2015 20:00	0.0	0	0	0	0	1
01/09/2015 21:00	0.0	0	0	0	0	1
01/09/2015 22:00	0.0	0	0	0	0	1
01/09/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/10/2015 00:00	0.0	0	0	0	0	1
01/10/2015 01:00	0.0	0	0	0	0	1
01/10/2015 02:00	0.0	0	0	0	0	1
01/10/2015 03:00	0.0	0	0	0	0	1
01/10/2015 04:00	0.0	0	0	0	0	1
01/10/2015 05:00	0.0	0	0	0	0	1
01/10/2015 06:00	0.0	0	0	0	0	1
01/10/2015 07:00	0.0	0	0	0	0	1
01/10/2015 08:00	0.0	0	0	0	0	1
01/10/2015 09:00	0.0	0	0	0	0	1
01/10/2015 10:00	0.0	0	0	0	0	1
01/10/2015 11:00	0.0	0	0	0	0	1
01/10/2015 12:00	0.0	0	0	0	0	1
01/10/2015 13:00	0.0	0	0	0	0	1
01/10/2015 14:00	0.0	0	0	0	0	1
01/10/2015 15:00	0.0	0	0	0	0	1
01/10/2015 16:00	0.0	0	0	0	0	1
01/10/2015 17:00	0.0	0	0	0	0	1
01/10/2015 18:00	0.0	0	0	0	0	1
01/10/2015 19:00	0.0	0	0	0	0	1
01/10/2015 20:00	0.0	0	0	0	0	1
01/10/2015 21:00	0.0	0	0	0	0	1
01/10/2015 22:00	0.0	0	0	0	0	1
01/10/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/11/2015 00:00	0.0	0	0	0	0	1
01/11/2015 01:00	0.0	0	0	0	0	1
01/11/2015 02:00	0.0	0	0	0	0	1
01/11/2015 03:00	0.0	0	0	0	0	1
01/11/2015 04:00	0.0	0	0	0	0	1
01/11/2015 05:00	0.0	0	0	0	0	1
01/11/2015 06:00	0.0	0	0	0	0	1
01/11/2015 07:00	0.0	0	0	0	0	1
01/11/2015 08:00	0.0	0	0	0	0	1
01/11/2015 09:00	0.0	0	0	0	0	1
01/11/2015 10:00	0.0	0	0	0	0	1
01/11/2015 11:00	0.0	0	0	0	0	1
01/11/2015 12:00	0.0	0	0	0	0	1
01/11/2015 13:00	0.0	0	0	0	0	1
01/11/2015 14:00	0.0	0	0	0	0	1
01/11/2015 15:00	0.0	0	0	0	0	1
01/11/2015 16:00	0.0	0	0	0	0	1
01/11/2015 17:00	0.0	0	0	0	0	1
01/11/2015 18:00	0.0	0	0	0	0	1
01/11/2015 19:00	0.0	0	0	0	0	1
01/11/2015 20:00	0.0	0	0	0	0	1
01/11/2015 21:00	0.0	0	0	0	0	1
01/11/2015 22:00	0.0	0	0	0	0	1
01/11/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/12/2015 00:00	0.0	0	0	0	0	1
01/12/2015 01:00	0.0	0	0	0	0	1
01/12/2015 02:00	0.0	0	0	0	0	1
01/12/2015 03:00	0.0	0	0	0	0	1
01/12/2015 04:00	0.0	0	0	0	0	1
01/12/2015 05:00	0.0	0	0	0	0	1
01/12/2015 06:00	0.0	0	0	0	0	1
01/12/2015 07:00	0.0	0	0	0	0	1
01/12/2015 08:00	0.0	0	0	0	0	1
01/12/2015 09:00	0.0	0	0	0	0	1
01/12/2015 10:00	0.0	0	0	0	0	1
01/12/2015 11:00	0.0	0	0	0	0	1
01/12/2015 12:00	0.0	0	0	0	0	1
01/12/2015 13:00	0.0	0	0	0	0	1
01/12/2015 14:00	0.0	0	0	0	0	1
01/12/2015 15:00	0.0	0	0	0	0	1
01/12/2015 16:00	0.0	0	0	0	0	1
01/12/2015 17:00	0.0	0	0	0	0	1
01/12/2015 18:00	0.0	0	0	0	0	1
01/12/2015 19:00	0.0	0	0	0	0	1
01/12/2015 20:00	0.0	0	0	0	0	1
01/12/2015 21:00	0.0	0	0	0	0	1
01/12/2015 22:00	0.0	0	0	0	0	1
01/12/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/13/2015 00:00	0.0	0	0	0	0	1
01/13/2015 01:00	0.0	0	0	0	0	1
01/13/2015 02:00	0.0	0	0	0	0	1
01/13/2015 03:00	0.0	0	0	0	0	1
01/13/2015 04:00	0.0	0	0	0	0	1
01/13/2015 05:00	0.0	0	0	0	0	1
01/13/2015 06:00	0.0	0	0	0	0	1
01/13/2015 07:00	0.0	0	0	0	0	1
01/13/2015 08:00	0.0	0	0	0	0	1
01/13/2015 09:00	0.0	0	0	0	0	1
01/13/2015 10:00	0.0	0	0	0	0	1
01/13/2015 11:00	0.0	0	0	0	0	1
01/13/2015 12:00	0.0	0	0	0	0	1
01/13/2015 13:00	0.0	0	0	0	0	1
01/13/2015 14:00	0.0	0	0	0	0	1
01/13/2015 15:00	0.0	0	0	0	0	1
01/13/2015 16:00	0.0	0	0	0	0	1
01/13/2015 17:00	0.0	0	0	0	0	1
01/13/2015 18:00	0.0	0	0	0	0	1
01/13/2015 19:00	0.0	0	0	0	0	1
01/13/2015 20:00	0.0	0	0	0	0	1
01/13/2015 21:00	0.0	0	0	0	0	1
01/13/2015 22:00	0.0	0	0	0	0	1
01/13/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/14/2015 00:00	0.0	0	0	0	0	1
01/14/2015 01:00	0.0	0	0	0	0	1
01/14/2015 02:00	0.0	0	0	0	0	1
01/14/2015 03:00	0.0	0	0	0	0	1
01/14/2015 04:00	0.0	0	0	0	0	1
01/14/2015 05:00	0.0	0	0	0	0	1
01/14/2015 06:00	0.0	0	0	0	0	1
01/14/2015 07:00	0.0	0	0	0	0	1
01/14/2015 08:00	0.0	0	0	0	0	1
01/14/2015 09:00	0.0	0	0	0	0	1
01/14/2015 10:00	0.0	0	0	0	0	1
01/14/2015 11:00	0.0	0	0	0	0	1
01/14/2015 12:00	0.0	0	0	0	0	1
01/14/2015 13:00	0.0	0	0	0	0	1
01/14/2015 14:00	0.0	0	0	0	0	1
01/14/2015 15:00	0.0	0	0	0	0	1
01/14/2015 16:00	0.0	0	0	0	0	1
01/14/2015 17:00	0.0	0	0	0	0	1
01/14/2015 18:00	0.0	0	0	0	0	1
01/14/2015 19:00	0.0	0	0	0	0	1
01/14/2015 20:00	0.0	0	0	0	0	1
01/14/2015 21:00	0.0	0	0	0	0	1
01/14/2015 22:00	0.0	0	0	0	0	1
01/14/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/15/2015 00:00	0.0	0	0	0	0	1
01/15/2015 01:00	0.0	0	0	0	0	1
01/15/2015 02:00	0.0	0	0	0	0	1
01/15/2015 03:00	0.0	0	0	0	0	1
01/15/2015 04:00	0.0	0	0	0	0	1
01/15/2015 05:00	0.0	0	0	0	0	1
01/15/2015 06:00	0.0	0	0	0	0	1
01/15/2015 07:00	0.0	0	0	0	0	1
01/15/2015 08:00	0.0	0	0	0	0	1
01/15/2015 09:00	0.0	0	0	0	0	1
01/15/2015 10:00	0.0	0	0	0	0	1
01/15/2015 11:00	0.0	0	0	0	0	1
01/15/2015 12:00	0.0	0	0	0	0	1
01/15/2015 13:00	0.0	0	0	0	0	1
01/15/2015 14:00	0.0	0	0	0	0	1
01/15/2015 15:00	0.0	0	0	0	0	1
01/15/2015 16:00	0.0	0	0	0	0	1
01/15/2015 17:00	0.0	0	0	0	0	1
01/15/2015 18:00	0.0	0	0	0	0	1
01/15/2015 19:00	0.0	0	0	0	0	1
01/15/2015 20:00	0.0	0	0	0	0	1
01/15/2015 21:00	0.0	0	0	0	0	1
01/15/2015 22:00	0.0	0	0	0	0	1
01/15/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/16/2015 00:00	0.0	0	0	0	0	1
01/16/2015 01:00	0.0	0	0	0	0	1
01/16/2015 02:00	0.0	0	0	0	0	1
01/16/2015 03:00	0.0	0	0	0	0	1
01/16/2015 04:00	0.0	0	0	0	0	1
01/16/2015 05:00	0.0	0	0	0	0	1
01/16/2015 06:00	0.0	0	0	0	0	1
01/16/2015 07:00	0.0	0	0	0	0	1
01/16/2015 08:00	0.0	0	0	0	0	1
01/16/2015 09:00	0.0	0	0	0	0	1
01/16/2015 10:00	0.0	0	0	0	0	1
01/16/2015 11:00	0.0	0	0	0	0	1
01/16/2015 12:00	0.0	0	0	0	0	1
01/16/2015 13:00	0.0	0	0	0	0	1
01/16/2015 14:00	0.0	0	0	0	0	1
01/16/2015 15:00	0.0	0	0	0	0	1
01/16/2015 16:00	0.0	0	0	0	0	1
01/16/2015 17:00	0.0	0	0	0	0	1
01/16/2015 18:00	0.0	0	0	0	0	1
01/16/2015 19:00	0.0	0	0	0	0	1
01/16/2015 20:00	0.0	0	0	0	0	1
01/16/2015 21:00	0.0	0	0	0	0	1
01/16/2015 22:00	0.0	0	0	0	0	1
01/16/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/17/2015 00:00	0.0	0	0	0	0	1
01/17/2015 01:00	0.0	0	0	0	0	1
01/17/2015 02:00	0.0	0	0	0	0	1
01/17/2015 03:00	0.0	0	0	0	0	1
01/17/2015 04:00	0.0	0	0	0	0	1
01/17/2015 05:00	0.0	0	0	0	0	1
01/17/2015 06:00	0.0	0	0	0	0	1
01/17/2015 07:00	0.0	0	0	0	0	1
01/17/2015 08:00	0.0	0	0	0	0	1
01/17/2015 09:00	0.0	0	0	0	0	1
01/17/2015 10:00	0.0	0	0	0	0	1
01/17/2015 11:00	0.0	0	0	0	0	1
01/17/2015 12:00	0.0	0	0	0	0	1
01/17/2015 13:00	0.0	0	0	0	0	1
01/17/2015 14:00	0.0	0	0	0	0	1
01/17/2015 15:00	0.0	0	0	0	0	1
01/17/2015 16:00	0.0	0	0	0	0	1
01/17/2015 17:00	0.0	0	0	0	0	1
01/17/2015 18:00	0.0	0	0	0	0	1
01/17/2015 19:00	0.0	0	0	0	0	1
01/17/2015 20:00	0.0	0	0	0	0	1
01/17/2015 21:00	0.0	0	0	0	0	1
01/17/2015 22:00	0.0	0	0	0	0	1
01/17/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/18/2015 00:00	0.0	0	0	0	0	1
01/18/2015 01:00	0.0	0	0	0	0	1
01/18/2015 02:00	1.3	0	0	0	1	0
01/18/2015 03:00	0.0	0	0	0	0	0
01/18/2015 04:00	0.0	0	0	0	0	0
01/18/2015 05:00	0.0	0	0	0	0	0
01/18/2015 06:00	0.0	0	0	0	0	0
01/18/2015 07:00	0.0	0	0	0	0	0
01/18/2015 08:00	0.0	0	0	0	0	0
01/18/2015 09:00	0.0	0	0	0	0	0
01/18/2015 10:00	0.0	0	0	0	0	0
01/18/2015 11:00	0.0	0	0	0	0	0
01/18/2015 12:00	0.0	0	0	0	0	0
01/18/2015 13:00	0.0	0	0	0	0	0
01/18/2015 14:00	30.0	0	1	0	0	0
01/18/2015 15:00	54.3	0	1	0	0	0
01/18/2015 16:00	0.2	0	1	0	0	0
01/18/2015 17:00	0.0	0	0	0	0	1
01/18/2015 18:00	0.0	0	0	0	0	1
01/18/2015 19:00	0.0	0	0	0	0	1
01/18/2015 20:00	0.0	0	0	0	0	1
01/18/2015 21:00	0.0	0	0	0	0	1
01/18/2015 22:00	0.0	0	0	0	0	1
01/18/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	85.8 #	0 #	3 #	0 #	1 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	54.3	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/19/2015 00:00	0.0	0	0	0	0	1
01/19/2015 01:00	0.0	0	0	0	0	1
01/19/2015 02:00	0.0	0	0	0	0	1
01/19/2015 03:00	0.0	0	0	0	0	1
01/19/2015 04:00	0.0	0	0	0	0	1
01/19/2015 05:00	0.0	0	0	0	0	1
01/19/2015 06:00	0.0	0	0	0	0	1
01/19/2015 07:00	0.0	0	0	0	0	1
01/19/2015 08:00	0.0	0	0	0	0	1
01/19/2015 09:00	0.0	0	0	0	0	1
01/19/2015 10:00	0.0	0	0	0	0	1
01/19/2015 11:00	0.0	0	0	0	0	1
01/19/2015 12:00	0.0	0	0	0	0	1
01/19/2015 13:00	0.0	0	0	0	0	1
01/19/2015 14:00	0.0	0	0	0	0	1
01/19/2015 15:00	0.0	0	0	0	0	1
01/19/2015 16:00	0.0	0	0	0	0	1
01/19/2015 17:00	0.0	0	0	0	0	1
01/19/2015 18:00	0.0	0	0	0	0	1
01/19/2015 19:00	0.0	0	0	0	0	1
01/19/2015 20:00	0.0	0	0	0	0	1
01/19/2015 21:00	0.0	0	0	0	0	1
01/19/2015 22:00	0.0	0	0	0	0	1
01/19/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/20/2015 00:00	0.0	0	0	0	0	1
01/20/2015 01:00	0.0	0	0	0	0	1
01/20/2015 02:00	0.0	0	0	0	0	1
01/20/2015 03:00	0.0	0	0	0	0	1
01/20/2015 04:00	0.0	0	0	0	0	1
01/20/2015 05:00	0.0	0	0	0	0	1
01/20/2015 06:00	0.0	0	0	0	0	1
01/20/2015 07:00	0.0	0	0	0	0	1
01/20/2015 08:00	0.0	0	0	0	0	1
01/20/2015 09:00	0.0	0	0	0	0	1
01/20/2015 10:00	0.0	0	0	0	0	1
01/20/2015 11:00	0.0	0	0	0	0	1
01/20/2015 12:00	0.0	0	0	0	0	1
01/20/2015 13:00	0.0	0	0	0	0	1
01/20/2015 14:00	0.0	0	0	0	0	1
01/20/2015 15:00	0.0	0	0	0	0	1
01/20/2015 16:00	0.0	0	0	0	0	1
01/20/2015 17:00	0.0	0	0	0	0	1
01/20/2015 18:00	0.0	0	0	0	0	1
01/20/2015 19:00	0.0	0	0	0	0	1
01/20/2015 20:00	0.0	0	0	0	0	1
01/20/2015 21:00	0.0	0	0	0	0	1
01/20/2015 22:00	0.0	0	0	0	0	1
01/20/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/21/2015 00:00	0.0	0	0	0	0	1
01/21/2015 01:00	0.0	0	0	0	0	1
01/21/2015 02:00	0.0	0	0	0	0	1
01/21/2015 03:00	0.0	0	0	0	0	1
01/21/2015 04:00	0.0	0	0	0	0	1
01/21/2015 05:00	0.0	0	0	0	0	1
01/21/2015 06:00	0.0	0	0	0	0	1
01/21/2015 07:00	0.0	0	0	0	0	1
01/21/2015 08:00	0.0	0	0	0	0	1
01/21/2015 09:00	0.0	0	0	0	0	1
01/21/2015 10:00	0.0	0	0	0	0	1
01/21/2015 11:00	0.0	0	0	0	0	1
01/21/2015 12:00	0.0	0	0	0	0	1
01/21/2015 13:00	0.0	0	0	0	0	1
01/21/2015 14:00	0.0	0	0	0	0	1
01/21/2015 15:00	0.0	0	0	0	0	1
01/21/2015 16:00	0.0	0	0	0	0	1
01/21/2015 17:00	0.0	0	0	0	0	1
01/21/2015 18:00	0.0	0	0	0	0	1
01/21/2015 19:00	0.0	0	0	0	0	1
01/21/2015 20:00	0.0	0	0	0	0	1
01/21/2015 21:00	0.0	0	0	0	0	1
01/21/2015 22:00	0.0	0	0	0	0	1
01/21/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/22/2015 00:00	0.0	0	0	0	0	1
01/22/2015 01:00	0.0	0	0	0	0	1
01/22/2015 02:00	0.0	0	0	0	0	1
01/22/2015 03:00	0.0	0	0	0	0	1
01/22/2015 04:00	0.0	0	0	0	0	1
01/22/2015 05:00	0.0	0	0	0	0	1
01/22/2015 06:00	0.0	0	0	0	0	1
01/22/2015 07:00	0.0	0	0	0	0	1
01/22/2015 08:00	0.0	0	0	0	0	1
01/22/2015 09:00	0.0	0	0	0	0	1
01/22/2015 10:00	0.0	0	0	0	0	1
01/22/2015 11:00	0.0	0	0	0	0	1
01/22/2015 12:00	0.0	0	0	0	0	1
01/22/2015 13:00	0.0	0	0	0	0	1
01/22/2015 14:00	0.0	0	0	0	0	1
01/22/2015 15:00	0.0	0	0	0	0	1
01/22/2015 16:00	0.0	0	0	0	0	1
01/22/2015 17:00	0.0	0	0	0	0	1
01/22/2015 18:00	0.0	0	0	0	0	1
01/22/2015 19:00	0.0	0	0	0	0	1
01/22/2015 20:00	0.0	0	0	0	0	1
01/22/2015 21:00	0.0	0	0	0	0	1
01/22/2015 22:00	0.0	0	0	0	0	1
01/22/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/23/2015 00:00	0.0	0	0	0	0	1
01/23/2015 01:00	0.0	0	0	0	0	1
01/23/2015 02:00	0.0	0	0	0	0	1
01/23/2015 03:00	0.0	0	0	0	0	1
01/23/2015 04:00	0.0	0	0	0	0	1
01/23/2015 05:00	0.0	0	0	0	0	1
01/23/2015 06:00	0.0	0	0	0	0	1
01/23/2015 07:00	0.0	0	0	0	0	1
01/23/2015 08:00	0.0	0	0	0	0	1
01/23/2015 09:00	0.0	0	0	0	0	1
01/23/2015 10:00	0.0	0	0	0	0	1
01/23/2015 11:00	0.0	0	0	0	0	1
01/23/2015 12:00	0.0	0	0	0	0	1
01/23/2015 13:00	0.0	0	0	0	0	1
01/23/2015 14:00	0.0	0	0	0	0	1
01/23/2015 15:00	0.0	0	0	0	0	1
01/23/2015 16:00	0.0	0	0	0	0	1
01/23/2015 17:00	0.0	0	0	0	0	1
01/23/2015 18:00	0.0	0	0	0	0	1
01/23/2015 19:00	0.0	0	0	0	0	1
01/23/2015 20:00	0.0	0	0	0	0	1
01/23/2015 21:00	0.0	0	0	0	0	1
01/23/2015 22:00	0.0	0	0	0	0	1
01/23/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/24/2015 00:00	0.0	0	0	0	0	1
01/24/2015 01:00	0.0	0	0	0	0	1
01/24/2015 02:00	0.0	0	0	0	0	1
01/24/2015 03:00	0.0	0	0	0	0	1
01/24/2015 04:00	0.0	0	0	0	0	1
01/24/2015 05:00	0.0	0	0	0	0	1
01/24/2015 06:00	0.0	0	0	0	0	1
01/24/2015 07:00	0.0	0	0	0	0	1
01/24/2015 08:00	0.0	0	0	0	0	1
01/24/2015 09:00	0.0	0	0	0	0	1
01/24/2015 10:00	0.0	0	0	0	0	1
01/24/2015 11:00	0.0	0	0	0	0	1
01/24/2015 12:00	0.0	0	0	0	0	1
01/24/2015 13:00	0.0	0	0	0	0	1
01/24/2015 14:00	0.0	0	0	0	0	1
01/24/2015 15:00	0.0	0	0	0	0	1
01/24/2015 16:00	0.0	0	0	0	0	1
01/24/2015 17:00	0.0	0	0	0	0	1
01/24/2015 18:00	0.0	0	0	0	0	1
01/24/2015 19:00	0.0	0	0	0	0	1
01/24/2015 20:00	0.0	0	0	0	0	1
01/24/2015 21:00	0.0	0	0	0	0	1
01/24/2015 22:00	0.0	0	0	0	0	1
01/24/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/25/2015 00:00	0.0	0	0	0	0	1
01/25/2015 01:00	1.6	0	0	0	1	0
01/25/2015 02:00	0.0	0	0	0	0	0
01/25/2015 03:00	0.0	0	0	0	0	0
01/25/2015 04:00	0.0	0	0	0	0	0
01/25/2015 05:00	0.0	0	0	0	0	0
01/25/2015 06:00	0.0	0	0	0	0	0
01/25/2015 07:00	0.0	0	0	0	0	0
01/25/2015 08:00	0.0	0	0	0	0	0
01/25/2015 09:00	0.0	0	0	0	0	0
01/25/2015 10:00	0.0	0	0	0	0	0
01/25/2015 11:00	0.0	0	0	0	0	0
01/25/2015 12:00	34.1	0	1	0	0	0
01/25/2015 13:00	54.7	0	1	0	0	0
01/25/2015 14:00	6.2	0	1	0	0	0
01/25/2015 15:00	0.0	0	0	0	0	1
01/25/2015 16:00	0.0	0	0	0	0	1
01/25/2015 17:00	0.0	0	0	0	0	1
01/25/2015 18:00	0.0	0	0	0	0	1
01/25/2015 19:00	0.0	0	0	0	0	1
01/25/2015 20:00	0.0	0	0	0	0	1
01/25/2015 21:00	0.0	0	0	0	0	1
01/25/2015 22:00	1.2	0	0	0	1	0
01/25/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	97.8 #	0 #	3 #	0 #	2 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	54.7	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/26/2015 00:00	0.0	0	0	0	0	0
01/26/2015 01:00	0.0	0	0	0	0	0
01/26/2015 02:00	0.0	0	0	0	0	0
01/26/2015 03:00	0.0	0	0	0	0	0
01/26/2015 04:00	28.3	0	0	1	0	0
01/26/2015 05:00	15.7	0	0	1	0	0
01/26/2015 06:00	0.0	0	0	0	0	1
01/26/2015 07:00	0.0	0	0	0	0	1
01/26/2015 08:00	0.0	0	0	0	0	1
01/26/2015 09:00	0.0	0	0	0	0	1
01/26/2015 10:00	0.0	0	0	0	0	1
01/26/2015 11:00	0.0	0	0	0	0	1
01/26/2015 12:00	0.0	0	0	0	0	1
01/26/2015 13:00	0.0	0	0	0	0	1
01/26/2015 14:00	0.0	0	0	0	0	1
01/26/2015 15:00	0.0	0	0	0	0	1
01/26/2015 16:00	0.0	0	0	0	0	1
01/26/2015 17:00	0.0	0	0	0	0	1
01/26/2015 18:00	0.0	0	0	0	0	1
01/26/2015 19:00	0.0	0	0	0	0	1
01/26/2015 20:00	0.0	0	0	0	0	1
01/26/2015 21:00	0.0	0	0	0	0	1
01/26/2015 22:00	0.0	0	0	0	0	1
01/26/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	44.0 #	0 #	0 #	2 #	0 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	28.3	0	0	1	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/27/2015 00:00	0.0	0	0	0	0	1
01/27/2015 01:00	0.0	0	0	0	0	1
01/27/2015 02:00	0.0	0	0	0	0	1
01/27/2015 03:00	0.0	0	0	0	0	1
01/27/2015 04:00	0.0	0	0	0	0	1
01/27/2015 05:00	0.0	0	0	0	0	1
01/27/2015 06:00	0.0	0	0	0	0	1
01/27/2015 07:00	0.0	0	0	0	0	1
01/27/2015 08:00	0.0	0	0	0	0	1
01/27/2015 09:00	0.0	0	0	0	0	1
01/27/2015 10:00	0.0	0	0	0	0	1
01/27/2015 11:00	0.0	0	0	0	0	1
01/27/2015 12:00	0.0	0	0	0	0	1
01/27/2015 13:00	0.0	0	0	0	0	1
01/27/2015 14:00	0.0	0	0	0	0	1
01/27/2015 15:00	0.0	0	0	0	0	1
01/27/2015 16:00	0.0	0	0	0	0	1
01/27/2015 17:00	0.0	0	0	0	0	1
01/27/2015 18:00	0.0	0	0	0	0	1
01/27/2015 19:00	0.0	0	0	0	0	1
01/27/2015 20:00	0.0	0	0	0	0	1
01/27/2015 21:00	0.0	0	0	0	0	1
01/27/2015 22:00	0.0	0	0	0	0	1
01/27/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/28/2015 00:00	0.0	0	0	0	0	1
01/28/2015 01:00	0.0	0	0	0	0	1
01/28/2015 02:00	0.0	0	0	0	0	1
01/28/2015 03:00	0.0	0	0	0	0	1
01/28/2015 04:00	0.0	0	0	0	0	1
01/28/2015 05:00	0.0	0	0	0	0	1
01/28/2015 06:00	0.0	0	0	0	0	1
01/28/2015 07:00	0.0	0	0	0	0	1
01/28/2015 08:00	0.0	0	0	0	0	1
01/28/2015 09:00	0.0	0	0	0	0	1
01/28/2015 10:00	0.0	0	0	0	0	1
01/28/2015 11:00	0.0	0	0	0	0	1
01/28/2015 12:00	0.0	0	0	0	0	1
01/28/2015 13:00	0.0	0	0	0	0	1
01/28/2015 14:00	0.0	0	0	0	0	1
01/28/2015 15:00	0.0	0	0	0	0	1
01/28/2015 16:00	0.0	0	0	0	0	1
01/28/2015 17:00	0.0	0	0	0	0	1
01/28/2015 18:00	0.0	0	0	0	0	1
01/28/2015 19:00	0.0	0	0	0	0	1
01/28/2015 20:00	0.0	0	0	0	0	1
01/28/2015 21:00	0.0	0	0	0	0	1
01/28/2015 22:00	0.0	0	0	0	0	1
01/28/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/29/2015 00:00	0.0	0	0	0	0	1
01/29/2015 01:00	0.0	0	0	0	0	1
01/29/2015 02:00	0.0	0	0	0	0	1
01/29/2015 03:00	0.0	0	0	0	0	1
01/29/2015 04:00	0.0	0	0	0	0	1
01/29/2015 05:00	0.0	0	0	0	0	1
01/29/2015 06:00	0.0	0	0	0	0	1
01/29/2015 07:00	0.0	0	0	0	0	1
01/29/2015 08:00	0.0	0	0	0	0	1
01/29/2015 09:00	0.0	0	0	0	0	1
01/29/2015 10:00	0.0	0	0	0	0	1
01/29/2015 11:00	0.0	0	0	0	0	1
01/29/2015 12:00	0.0	0	0	0	0	1
01/29/2015 13:00	0.0	0	0	0	0	1
01/29/2015 14:00	0.0	0	0	0	0	1
01/29/2015 15:00	0.0	0	0	0	0	1
01/29/2015 16:00	0.0	0	0	0	0	1
01/29/2015 17:00	0.0	0	0	0	0	1
01/29/2015 18:00	0.0	0	0	0	0	1
01/29/2015 19:00	0.0	0	0	0	0	1
01/29/2015 20:00	0.0	0	0	0	0	1
01/29/2015 21:00	0.0	0	0	0	0	1
01/29/2015 22:00	0.0	0	0	0	0	1
01/29/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/30/2015 00:00	0.0	0	0	0	0	1
01/30/2015 01:00	0.0	0	0	0	0	1
01/30/2015 02:00	0.0	0	0	0	0	1
01/30/2015 03:00	0.0	0	0	0	0	1
01/30/2015 04:00	0.0	0	0	0	0	1
01/30/2015 05:00	0.0	0	0	0	0	1
01/30/2015 06:00	0.0	0	0	0	0	1
01/30/2015 07:00	0.0	0	0	0	0	1
01/30/2015 08:00	0.0	0	0	0	0	1
01/30/2015 09:00	0.0	0	0	0	0	1
01/30/2015 10:00	0.0	0	0	0	0	1
01/30/2015 11:00	0.0	0	0	0	0	1
01/30/2015 12:00	0.0	0	0	0	0	1
01/30/2015 13:00	0.0	0	0	0	0	1
01/30/2015 14:00	0.0	0	0	0	0	1
01/30/2015 15:00	0.0	0	0	0	0	1
01/30/2015 16:00	0.0	0	0	0	0	1
01/30/2015 17:00	0.0	0	0	0	0	1
01/30/2015 18:00	0.0	0	0	0	0	1
01/30/2015 19:00	0.0	0	0	0	0	1
01/30/2015 20:00	0.0	0	0	0	0	1
01/30/2015 21:00	0.0	0	0	0	0	1
01/30/2015 22:00	0.0	0	0	0	0	1
01/30/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/31/2015 00:00	1.8	0	0	0	1	0
01/31/2015 01:00	0.0	0	0	0	0	0
01/31/2015 02:00	0.0	0	0	0	0	0
01/31/2015 03:00	12.0	0	0	1	0	0
01/31/2015 04:00	31.1	0	0	1	0	0
01/31/2015 05:00	0.0	0	0	0	0	1
01/31/2015 06:00	0.0	0	0	0	0	1
01/31/2015 07:00	0.0	0	0	0	0	1
01/31/2015 08:00	0.0	0	0	0	0	1
01/31/2015 09:00	0.0	0	0	0	0	1
01/31/2015 10:00	0.0	0	0	0	0	1
01/31/2015 11:00	0.0	0	0	0	0	1
01/31/2015 12:00	0.0	0	0	0	0	1
01/31/2015 13:00	0.0	0	0	0	0	1
01/31/2015 14:00	0.0	0	0	0	0	1
01/31/2015 15:00	0.0	0	0	0	0	1
01/31/2015 16:00	0.0	0	0	0	0	1
01/31/2015 17:00	0.0	0	0	0	0	1
01/31/2015 18:00	0.0	0	0	0	0	1
01/31/2015 19:00	0.0	0	0	0	0	1
01/31/2015 20:00	0.0	0	0	0	0	1
01/31/2015 21:00	0.0	0	0	0	0	1
01/31/2015 22:00	0.0	0	0	0	0	1
01/31/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	44.9 #	0 #	0 #	2 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	31.1	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/01/2015 00:00	0.0	0	0	0	0	1
02/01/2015 01:00	0.0	0	0	0	0	1
02/01/2015 02:00	1.9	0	0	0	1	0
02/01/2015 03:00	0.0	0	0	0	0	0
02/01/2015 04:00	0.0	0	0	0	0	0
02/01/2015 05:00	0.0	0	0	0	0	0
02/01/2015 06:00	0.0	0	0	0	0	0
02/01/2015 07:00	0.0	0	0	0	0	0
02/01/2015 08:00	0.0	0	0	0	0	0
02/01/2015 09:00	0.0	0	0	0	0	0
02/01/2015 10:00	50.0	0	1	0	0	0
02/01/2015 11:00	51.2	0	1	0	0	0
02/01/2015 12:00	0.0	0	0	0	0	1
02/01/2015 13:00	0.0	0	0	0	0	1
02/01/2015 14:00	0.0	0	0	0	0	1
02/01/2015 15:00	0.0	0	0	0	0	1
02/01/2015 16:00	0.0	0	0	0	0	1
02/01/2015 17:00	0.0	0	0	0	0	1
02/01/2015 18:00	0.0	0	0	0	0	1
02/01/2015 19:00	0.0	0	0	0	0	1
02/01/2015 20:00	0.0	0	0	0	0	1
02/01/2015 21:00	0.0	0	0	0	0	1
02/01/2015 22:00	0.0	0	0	0	0	1
02/01/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	103.1 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	51.2	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/02/2015 00:00	0.0	0	0	0	0	1
02/02/2015 01:00	0.0	0	0	0	0	1
02/02/2015 02:00	0.0	0	0	0	0	1
02/02/2015 03:00	0.0	0	0	0	0	1
02/02/2015 04:00	0.0	0	0	0	0	1
02/02/2015 05:00	0.0	0	0	0	0	1
02/02/2015 06:00	0.0	0	0	0	0	1
02/02/2015 07:00	0.0	0	0	0	0	1
02/02/2015 08:00	0.0	0	0	0	0	1
02/02/2015 09:00	0.0	0	0	0	0	1
02/02/2015 10:00	0.0	0	0	0	0	1
02/02/2015 11:00	0.0	0	0	0	0	1
02/02/2015 12:00	0.0	0	0	0	0	1
02/02/2015 13:00	0.0	0	0	0	0	1
02/02/2015 14:00	0.0	0	0	0	0	1
02/02/2015 15:00	0.0	0	0	0	0	1
02/02/2015 16:00	0.0	0	0	0	0	1
02/02/2015 17:00	0.0	0	0	0	0	1
02/02/2015 18:00	0.0	0	0	0	0	1
02/02/2015 19:00	0.0	0	0	0	0	1
02/02/2015 20:00	0.0	0	0	0	0	1
02/02/2015 21:00	0.0	0	0	0	0	1
02/02/2015 22:00	0.0	0	0	0	0	1
02/02/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/03/2015 00:00	0.0	0	0	0	0	1
02/03/2015 01:00	0.0	0	0	0	0	1
02/03/2015 02:00	0.0	0	0	0	0	1
02/03/2015 03:00	0.0	0	0	0	0	1
02/03/2015 04:00	0.0	0	0	0	0	1
02/03/2015 05:00	0.0	0	0	0	0	1
02/03/2015 06:00	0.0	0	0	0	0	1
02/03/2015 07:00	0.0	0	0	0	0	1
02/03/2015 08:00	0.0	0	0	0	0	1
02/03/2015 09:00	0.0	0	0	0	0	1
02/03/2015 10:00	0.0	0	0	0	0	1
02/03/2015 11:00	0.0	0	0	0	0	1
02/03/2015 12:00	0.0	0	0	0	0	1
02/03/2015 13:00	0.0	0	0	0	0	1
02/03/2015 14:00	0.0	0	0	0	0	1
02/03/2015 15:00	0.0	0	0	0	0	1
02/03/2015 16:00	0.0	0	0	0	0	1
02/03/2015 17:00	0.0	0	0	0	0	1
02/03/2015 18:00	0.0	0	0	0	0	1
02/03/2015 19:00	0.0	0	0	0	0	1
02/03/2015 20:00	0.0	0	0	0	0	1
02/03/2015 21:00	0.0	0	0	0	0	1
02/03/2015 22:00	0.0	0	0	0	0	1
02/03/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/04/2015 00:00	0.0	0	0	0	0	1
02/04/2015 01:00	0.0	0	0	0	0	1
02/04/2015 02:00	0.0	0	0	0	0	1
02/04/2015 03:00	0.0	0	0	0	0	1
02/04/2015 04:00	0.0	0	0	0	0	1
02/04/2015 05:00	0.0	0	0	0	0	1
02/04/2015 06:00	0.0	0	0	0	0	1
02/04/2015 07:00	0.0	0	0	0	0	1
02/04/2015 08:00	0.0	0	0	0	0	1
02/04/2015 09:00	0.0	0	0	0	0	1
02/04/2015 10:00	0.0	0	0	0	0	1
02/04/2015 11:00	0.0	0	0	0	0	1
02/04/2015 12:00	0.0	0	0	0	0	1
02/04/2015 13:00	0.0	0	0	0	0	1
02/04/2015 14:00	0.0	0	0	0	0	1
02/04/2015 15:00	0.0	0	0	0	0	1
02/04/2015 16:00	0.0	0	0	0	0	1
02/04/2015 17:00	0.0	0	0	0	0	1
02/04/2015 18:00	0.0	0	0	0	0	1
02/04/2015 19:00	0.0	0	0	0	0	1
02/04/2015 20:00	0.0	0	0	0	0	1
02/04/2015 21:00	0.0	0	0	0	0	1
02/04/2015 22:00	0.0	0	0	0	0	1
02/04/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/05/2015 00:00	0.0	0	0	0	0	1
02/05/2015 01:00	0.0	0	0	0	0	1
02/05/2015 02:00	0.0	0	0	0	0	1
02/05/2015 03:00	0.0	0	0	0	0	1
02/05/2015 04:00	0.0	0	0	0	0	1
02/05/2015 05:00	0.0	0	0	0	0	1
02/05/2015 06:00	0.0	0	0	0	0	1
02/05/2015 07:00	0.0	0	0	0	0	1
02/05/2015 08:00	0.0	0	0	0	0	1
02/05/2015 09:00	0.0	0	0	0	0	1
02/05/2015 10:00	0.0	0	0	0	0	1
02/05/2015 11:00	0.0	0	0	0	0	1
02/05/2015 12:00	0.0	0	0	0	0	1
02/05/2015 13:00	0.0	0	0	0	0	1
02/05/2015 14:00	0.0	0	0	0	0	1
02/05/2015 15:00	0.0	0	0	0	0	1
02/05/2015 16:00	0.0	0	0	0	0	1
02/05/2015 17:00	0.0	0	0	0	0	1
02/05/2015 18:00	0.0	0	0	0	0	1
02/05/2015 19:00	0.0	0	0	0	0	1
02/05/2015 20:00	0.0	0	0	0	0	1
02/05/2015 21:00	0.0	0	0	0	0	1
02/05/2015 22:00	0.0	0	0	0	0	1
02/05/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/06/2015 00:00	0.0	0	0	0	0	1
02/06/2015 01:00	0.0	0	0	0	0	1
02/06/2015 02:00	0.0	0	0	0	0	1
02/06/2015 03:00	0.0	0	0	0	0	1
02/06/2015 04:00	0.0	0	0	0	0	1
02/06/2015 05:00	0.0	0	0	0	0	1
02/06/2015 06:00	0.0	0	0	0	0	1
02/06/2015 07:00	0.0	0	0	0	0	1
02/06/2015 08:00	0.0	0	0	0	0	1
02/06/2015 09:00	0.0	0	0	0	0	1
02/06/2015 10:00	0.0	0	0	0	0	1
02/06/2015 11:00	0.0	0	0	0	0	1
02/06/2015 12:00	0.0	0	0	0	0	1
02/06/2015 13:00	0.0	0	0	0	0	1
02/06/2015 14:00	0.0	0	0	0	0	1
02/06/2015 15:00	0.0	0	0	0	0	1
02/06/2015 16:00	0.0	0	0	0	0	1
02/06/2015 17:00	0.0	0	0	0	0	1
02/06/2015 18:00	0.0	0	0	0	0	1
02/06/2015 19:00	0.0	0	0	0	0	1
02/06/2015 20:00	0.0	0	0	0	0	1
02/06/2015 21:00	0.0	0	0	0	0	1
02/06/2015 22:00	0.0	0	0	0	0	1
02/06/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/07/2015 00:00	0.0	0	0	0	0	1
02/07/2015 01:00	0.0	0	0	0	0	1
02/07/2015 02:00	0.0	0	0	0	0	1
02/07/2015 03:00	0.0	0	0	0	0	1
02/07/2015 04:00	0.0	0	0	0	0	1
02/07/2015 05:00	0.0	0	0	0	0	1
02/07/2015 06:00	0.0	0	0	0	0	1
02/07/2015 07:00	0.0	0	0	0	0	1
02/07/2015 08:00	0.0	0	0	0	0	1
02/07/2015 09:00	0.0	0	0	0	0	1
02/07/2015 10:00	0.0	0	0	0	0	1
02/07/2015 11:00	0.0	0	0	0	0	1
02/07/2015 12:00	0.0	0	0	0	0	1
02/07/2015 13:00	0.0	0	0	0	0	1
02/07/2015 14:00	0.0	0	0	0	0	1
02/07/2015 15:00	0.0	0	0	0	0	1
02/07/2015 16:00	0.0	0	0	0	0	1
02/07/2015 17:00	0.0	0	0	0	0	1
02/07/2015 18:00	0.0	0	0	0	0	1
02/07/2015 19:00	0.0	0	0	0	0	1
02/07/2015 20:00	0.0	0	0	0	0	1
02/07/2015 21:00	0.0	0	0	0	0	1
02/07/2015 22:00	0.0	0	0	0	0	1
02/07/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/08/2015 00:00	0.0	0	0	0	0	1
02/08/2015 01:00	0.0	0	0	0	0	1
02/08/2015 02:00	0.0	0	0	0	0	1
02/08/2015 03:00	0.0	0	0	0	0	1
02/08/2015 04:00	0.0	0	0	0	0	1
02/08/2015 05:00	0.0	0	0	0	0	1
02/08/2015 06:00	0.0	0	0	0	0	1
02/08/2015 07:00	0.0	0	0	0	0	1
02/08/2015 08:00	0.0	0	0	0	0	1
02/08/2015 09:00	0.0	0	0	0	0	1
02/08/2015 10:00	0.0	0	0	0	0	1
02/08/2015 11:00	0.0	0	0	0	0	1
02/08/2015 12:00	0.0	0	0	0	0	1
02/08/2015 13:00	0.0	0	0	0	0	1
02/08/2015 14:00	0.0	0	0	0	0	1
02/08/2015 15:00	0.0	0	0	0	0	1
02/08/2015 16:00	0.0	0	0	0	0	1
02/08/2015 17:00	0.0	0	0	0	0	1
02/08/2015 18:00	0.0	0	0	0	0	1
02/08/2015 19:00	0.0	0	0	0	0	1
02/08/2015 20:00	0.0	0	0	0	0	1
02/08/2015 21:00	0.0	0	0	0	0	1
02/08/2015 22:00	0.0	0	0	0	0	1
02/08/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/09/2015 00:00	0.0	0	0	0	0	1
02/09/2015 01:00	0.0	0	0	0	0	1
02/09/2015 02:00	0.0	0	0	0	0	1
02/09/2015 03:00	0.0	0	0	0	0	1
02/09/2015 04:00	0.0	0	0	0	0	1
02/09/2015 05:00	0.0	0	0	0	0	1
02/09/2015 06:00	0.0	0	0	0	0	1
02/09/2015 07:00	0.0	0	0	0	0	1
02/09/2015 08:00	0.0	0	0	0	0	1
02/09/2015 09:00	0.0	0	0	0	0	1
02/09/2015 10:00	0.0	0	0	0	0	1
02/09/2015 11:00	0.0	0	0	0	0	1
02/09/2015 12:00	0.0	0	0	0	0	1
02/09/2015 13:00	0.0	0	0	0	0	1
02/09/2015 14:00	0.0	0	0	0	0	1
02/09/2015 15:00	0.0	0	0	0	0	1
02/09/2015 16:00	0.0	0	0	0	0	1
02/09/2015 17:00	0.0	0	0	0	0	1
02/09/2015 18:00	0.0	0	0	0	0	1
02/09/2015 19:00	0.0	0	0	0	0	1
02/09/2015 20:00	0.0	0	0	0	0	1
02/09/2015 21:00	0.0	0	0	0	0	1
02/09/2015 22:00	0.0	0	0	0	0	1
02/09/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/10/2015 00:00	0.0	0	0	0	0	1
02/10/2015 01:00	0.0	0	0	0	0	1
02/10/2015 02:00	0.0	0	0	0	0	1
02/10/2015 03:00	0.0	0	0	0	0	1
02/10/2015 04:00	0.0	0	0	0	0	1
02/10/2015 05:00	0.0	0	0	0	0	1
02/10/2015 06:00	0.0	0	0	0	0	1
02/10/2015 07:00	0.0	0	0	0	0	1
02/10/2015 08:00	0.0	0	0	0	0	1
02/10/2015 09:00	0.0	0	0	0	0	1
02/10/2015 10:00	0.0	0	0	0	0	1
02/10/2015 11:00	0.0	0	0	0	0	1
02/10/2015 12:00	0.0	0	0	0	0	1
02/10/2015 13:00	0.0	0	0	0	0	1
02/10/2015 14:00	0.0	0	0	0	0	1
02/10/2015 15:00	0.0	0	0	0	0	1
02/10/2015 16:00	0.0	0	0	0	0	1
02/10/2015 17:00	0.0	0	0	0	0	1
02/10/2015 18:00	0.0	0	0	0	0	1
02/10/2015 19:00	0.0	0	0	0	0	1
02/10/2015 20:00	0.0	0	0	0	0	1
02/10/2015 21:00	0.0	0	0	0	0	1
02/10/2015 22:00	0.0	0	0	0	0	1
02/10/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/11/2015 00:00	0.0	0	0	0	0	1
02/11/2015 01:00	0.0	0	0	0	0	1
02/11/2015 02:00	0.0	0	0	0	0	1
02/11/2015 03:00	0.0	0	0	0	0	1
02/11/2015 04:00	0.0	0	0	0	0	1
02/11/2015 05:00	0.0	0	0	0	0	1
02/11/2015 06:00	0.0	0	0	0	0	1
02/11/2015 07:00	0.0	0	0	0	0	1
02/11/2015 08:00	0.0	0	0	0	0	1
02/11/2015 09:00	0.0	0	0	0	0	1
02/11/2015 10:00	0.0	0	0	0	0	1
02/11/2015 11:00	0.0	0	0	0	0	1
02/11/2015 12:00	0.0	0	0	0	0	1
02/11/2015 13:00	0.0	0	0	0	0	1
02/11/2015 14:00	0.0	0	0	0	0	1
02/11/2015 15:00	0.0	0	0	0	0	1
02/11/2015 16:00	0.0	0	0	0	0	1
02/11/2015 17:00	0.0	0	0	0	0	1
02/11/2015 18:00	0.0	0	0	0	0	1
02/11/2015 19:00	0.0	0	0	0	0	1
02/11/2015 20:00	0.0	0	0	0	0	1
02/11/2015 21:00	0.0	0	0	0	0	1
02/11/2015 22:00	0.0	0	0	0	0	1
02/11/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/12/2015 00:00	0.0	0	0	0	0	1
02/12/2015 01:00	0.0	0	0	0	0	1
02/12/2015 02:00	0.0	0	0	0	0	1
02/12/2015 03:00	0.0	0	0	0	0	1
02/12/2015 04:00	0.0	0	0	0	0	1
02/12/2015 05:00	0.0	0	0	0	0	1
02/12/2015 06:00	0.0	0	0	0	0	1
02/12/2015 07:00	0.0	0	0	0	0	1
02/12/2015 08:00	0.0	0	0	0	0	1
02/12/2015 09:00	0.0	0	0	0	0	1
02/12/2015 10:00	0.0	0	0	0	0	1
02/12/2015 11:00	0.0	0	0	0	0	1
02/12/2015 12:00	0.0	0	0	0	0	1
02/12/2015 13:00	0.0	0	0	0	0	1
02/12/2015 14:00	0.0	0	0	0	0	1
02/12/2015 15:00	0.0	0	0	0	0	1
02/12/2015 16:00	0.0	0	0	0	0	1
02/12/2015 17:00	0.0	0	0	0	0	1
02/12/2015 18:00	0.0	0	0	0	0	1
02/12/2015 19:00	0.0	0	0	0	0	1
02/12/2015 20:00	0.0	0	0	0	0	1
02/12/2015 21:00	0.0	0	0	0	0	1
02/12/2015 22:00	0.0	0	0	0	0	1
02/12/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/13/2015 00:00	0.0	0	0	0	0	1
02/13/2015 01:00	0.0	0	0	0	0	1
02/13/2015 02:00	0.0	0	0	0	0	1
02/13/2015 03:00	0.0	0	0	0	0	1
02/13/2015 04:00	0.0	0	0	0	0	1
02/13/2015 05:00	0.0	0	0	0	0	1
02/13/2015 06:00	0.0	0	0	0	0	1
02/13/2015 07:00	0.0	0	0	0	0	1
02/13/2015 08:00	0.0	0	0	0	0	1
02/13/2015 09:00	0.0	0	0	0	0	1
02/13/2015 10:00	0.0	0	0	0	0	1
02/13/2015 11:00	0.0	0	0	0	0	1
02/13/2015 12:00	0.0	0	0	0	0	1
02/13/2015 13:00	0.0	0	0	0	0	1
02/13/2015 14:00	0.0	0	0	0	0	1
02/13/2015 15:00	0.0	0	0	0	0	1
02/13/2015 16:00	0.0	0	0	0	0	1
02/13/2015 17:00	0.0	0	0	0	0	1
02/13/2015 18:00	0.0	0	0	0	0	1
02/13/2015 19:00	0.0	0	0	0	0	1
02/13/2015 20:00	0.0	0	0	0	0	1
02/13/2015 21:00	0.0	0	0	0	0	1
02/13/2015 22:00	0.0	0	0	0	0	1
02/13/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/14/2015 00:00	0.0	0	0	0	0	1
02/14/2015 01:00	0.0	0	0	0	0	1
02/14/2015 02:00	0.0	0	0	0	0	1
02/14/2015 03:00	0.0	0	0	0	0	1
02/14/2015 04:00	0.0	0	0	0	0	1
02/14/2015 05:00	0.0	0	0	0	0	1
02/14/2015 06:00	0.0	0	0	0	0	1
02/14/2015 07:00	0.0	0	0	0	0	1
02/14/2015 08:00	0.0	0	0	0	0	1
02/14/2015 09:00	0.0	0	0	0	0	1
02/14/2015 10:00	0.0	0	0	0	0	1
02/14/2015 11:00	0.0	0	0	0	0	1
02/14/2015 12:00	0.0	0	0	0	0	1
02/14/2015 13:00	0.0	0	0	0	0	1
02/14/2015 14:00	0.0	0	0	0	0	1
02/14/2015 15:00	0.0	0	0	0	0	1
02/14/2015 16:00	0.0	0	0	0	0	1
02/14/2015 17:00	0.0	0	0	0	0	1
02/14/2015 18:00	0.0	0	0	0	0	1
02/14/2015 19:00	0.0	0	0	0	0	1
02/14/2015 20:00	0.0	0	0	0	0	1
02/14/2015 21:00	0.0	0	0	0	0	1
02/14/2015 22:00	0.0	0	0	0	0	1
02/14/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/15/2015 00:00	0.0	0	0	0	0	1
02/15/2015 01:00	0.0	0	0	0	0	1
02/15/2015 02:00	1.5	0	0	0	1	0
02/15/2015 03:00	0.0	0	0	0	0	0
02/15/2015 04:00	0.0	0	0	0	0	0
02/15/2015 05:00	0.0	0	0	0	0	0
02/15/2015 06:00	0.0	0	0	0	0	0
02/15/2015 07:00	0.0	0	0	0	0	0
02/15/2015 08:00	0.0	0	0	0	0	0
02/15/2015 09:00	0.0	0	0	0	0	0
02/15/2015 10:00	0.0	0	0	0	0	0
02/15/2015 11:00	0.0	0	0	0	0	0
02/15/2015 12:00	0.0	0	0	0	0	0
02/15/2015 13:00	0.0	0	0	0	0	0
02/15/2015 14:00	0.0	0	0	0	0	0
02/15/2015 15:00	0.0	0	0	0	0	0
02/15/2015 16:00	14.0	0	1	0	0	0
02/15/2015 17:00	47.3	0	1	0	0	0
02/15/2015 18:00	0.0	0	0	0	0	1
02/15/2015 19:00	0.0	0	0	0	0	1
02/15/2015 20:00	0.0	0	0	0	0	1
02/15/2015 21:00	0.0	0	0	0	0	1
02/15/2015 22:00	0.0	0	0	0	0	1
02/15/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	62.8 #	0 #	2 #	0 #	1 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	47.3	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/16/2015 00:00	0.0	0	0	0	0	1
02/16/2015 01:00	0.0	0	0	0	0	1
02/16/2015 02:00	0.0	0	0	0	0	1
02/16/2015 03:00	0.0	0	0	0	0	1
02/16/2015 04:00	0.0	0	0	0	0	1
02/16/2015 05:00	0.0	0	0	0	0	1
02/16/2015 06:00	0.0	0	0	0	0	1
02/16/2015 07:00	0.0	0	0	0	0	1
02/16/2015 08:00	0.0	0	0	0	0	1
02/16/2015 09:00	0.0	0	0	0	0	1
02/16/2015 10:00	0.0	0	0	0	0	1
02/16/2015 11:00	0.0	0	0	0	0	1
02/16/2015 12:00	0.0	0	0	0	0	1
02/16/2015 13:00	0.0	0	0	0	0	1
02/16/2015 14:00	0.0	0	0	0	0	1
02/16/2015 15:00	0.0	0	0	0	0	1
02/16/2015 16:00	0.0	0	0	0	0	1
02/16/2015 17:00	0.0	0	0	0	0	1
02/16/2015 18:00	0.0	0	0	0	0	1
02/16/2015 19:00	0.0	0	0	0	0	1
02/16/2015 20:00	0.0	0	0	0	0	1
02/16/2015 21:00	0.0	0	0	0	0	1
02/16/2015 22:00	0.0	0	0	0	0	1
02/16/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/17/2015 00:00	0.0	0	0	0	0	1
02/17/2015 01:00	0.0	0	0	0	0	1
02/17/2015 02:00	0.0	0	0	0	0	1
02/17/2015 03:00	0.0	0	0	0	0	1
02/17/2015 04:00	0.0	0	0	0	0	1
02/17/2015 05:00	0.0	0	0	0	0	1
02/17/2015 06:00	0.0	0	0	0	0	1
02/17/2015 07:00	0.0	0	0	0	0	1
02/17/2015 08:00	0.0	0	0	0	0	1
02/17/2015 09:00	0.0	0	0	0	0	1
02/17/2015 10:00	0.0	0	0	0	0	1
02/17/2015 11:00	0.0	0	0	0	0	1
02/17/2015 12:00	0.0	0	0	0	0	1
02/17/2015 13:00	0.0	0	0	0	0	1
02/17/2015 14:00	0.0	0	0	0	0	1
02/17/2015 15:00	0.0	0	0	0	0	1
02/17/2015 16:00	0.0	0	0	0	0	1
02/17/2015 17:00	0.0	0	0	0	0	1
02/17/2015 18:00	0.0	0	0	0	0	1
02/17/2015 19:00	0.0	0	0	0	0	1
02/17/2015 20:00	0.0	0	0	0	0	1
02/17/2015 21:00	0.0	0	0	0	0	1
02/17/2015 22:00	0.0	0	0	0	0	1
02/17/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/18/2015 00:00	0.0	0	0	0	0	1
02/18/2015 01:00	0.0	0	0	0	0	1
02/18/2015 02:00	0.0	0	0	0	0	1
02/18/2015 03:00	0.0	0	0	0	0	1
02/18/2015 04:00	0.0	0	0	0	0	1
02/18/2015 05:00	0.0	0	0	0	0	1
02/18/2015 06:00	0.0	0	0	0	0	1
02/18/2015 07:00	0.0	0	0	0	0	1
02/18/2015 08:00	0.0	0	0	0	0	1
02/18/2015 09:00	0.0	0	0	0	0	1
02/18/2015 10:00	0.0	0	0	0	0	1
02/18/2015 11:00	0.0	0	0	0	0	1
02/18/2015 12:00	0.0	0	0	0	0	1
02/18/2015 13:00	0.0	0	0	0	0	1
02/18/2015 14:00	0.0	0	0	0	0	1
02/18/2015 15:00	0.0	0	0	0	0	1
02/18/2015 16:00	0.0	0	0	0	0	1
02/18/2015 17:00	0.0	0	0	0	0	1
02/18/2015 18:00	0.0	0	0	0	0	1
02/18/2015 19:00	0.0	0	0	0	0	1
02/18/2015 20:00	0.0	0	0	0	0	1
02/18/2015 21:00	0.0	0	0	0	0	1
02/18/2015 22:00	0.0	0	0	0	0	1
02/18/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/19/2015 00:00	0.0	0	0	0	0	1
02/19/2015 01:00	0.0	0	0	0	0	1
02/19/2015 02:00	0.0	0	0	0	0	1
02/19/2015 03:00	0.0	0	0	0	0	1
02/19/2015 04:00	0.0	0	0	0	0	1
02/19/2015 05:00	0.0	0	0	0	0	1
02/19/2015 06:00	0.0	0	0	0	0	1
02/19/2015 07:00	0.0	0	0	0	0	1
02/19/2015 08:00	0.0	0	0	0	0	1
02/19/2015 09:00	0.0	0	0	0	0	1
02/19/2015 10:00	0.0	0	0	0	0	1
02/19/2015 11:00	0.0	0	0	0	0	1
02/19/2015 12:00	0.0	0	0	0	0	1
02/19/2015 13:00	0.0	0	0	0	0	1
02/19/2015 14:00	0.0	0	0	0	0	1
02/19/2015 15:00	0.0	0	0	0	0	1
02/19/2015 16:00	0.0	0	0	0	0	1
02/19/2015 17:00	0.0	0	0	0	0	1
02/19/2015 18:00	0.0	0	0	0	0	1
02/19/2015 19:00	0.0	0	0	0	0	1
02/19/2015 20:00	0.0	0	0	0	0	1
02/19/2015 21:00	0.0	0	0	0	0	1
02/19/2015 22:00	0.0	0	0	0	0	1
02/19/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/20/2015 00:00	0.0	0	0	0	0	1
02/20/2015 01:00	1.4	0	0	0	1	0
02/20/2015 02:00	0.0	0	0	0	0	0
02/20/2015 03:00	0.0	0	0	0	0	0
02/20/2015 04:00	0.0	0	0	0	0	0
02/20/2015 05:00	0.0	0	0	0	0	0
02/20/2015 06:00	0.0	0	0	0	0	0
02/20/2015 07:00	0.0	0	0	0	0	0
02/20/2015 08:00	0.0	0	0	0	0	0
02/20/2015 09:00	0.0	0	0	0	0	0
02/20/2015 10:00	0.0	0	0	0	0	0
02/20/2015 11:00	0.0	0	0	0	0	0
02/20/2015 12:00	0.0	0	0	0	0	0
02/20/2015 13:00	0.0	0	0	0	0	0
02/20/2015 14:00	0.0	0	0	0	0	0
02/20/2015 15:00	0.0	0	0	0	0	0
02/20/2015 16:00	0.0	0	0	0	0	0
02/20/2015 17:00	0.0	0	0	0	0	0
02/20/2015 18:00	0.0	0	0	0	0	0
02/20/2015 19:00	0.0	0	0	0	0	0
02/20/2015 20:00	0.0	0	0	0	0	0
02/20/2015 21:00	0.0	0	0	0	0	0
02/20/2015 22:00	0.0	0	0	0	0	0
02/20/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.4 #	0 #	0 #	0 #	1 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.4	0	0	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/21/2015 00:00	0.0	0	0	0	0	0
02/21/2015 01:00	0.0	0	0	0	0	0
02/21/2015 02:00	0.0	0	0	0	0	0
02/21/2015 03:00	0.0	0	0	0	0	0
02/21/2015 04:00	0.0	0	0	0	0	0
02/21/2015 05:00	0.0	0	0	0	0	0
02/21/2015 06:00	0.0	0	0	0	0	0
02/21/2015 07:00	0.0	0	0	0	0	0
02/21/2015 08:00	0.0	0	0	0	0	0
02/21/2015 09:00	0.0	0	0	0	0	0
02/21/2015 10:00	0.0	0	0	0	0	0
02/21/2015 11:00	0.0	0	0	0	0	0
02/21/2015 12:00	0.0	0	0	0	0	0
02/21/2015 13:00	0.0	0	0	0	0	0
02/21/2015 14:00	0.0	0	0	0	0	0
02/21/2015 15:00	55.6	0	1	0	0	0
02/21/2015 16:00	32.6	0	1	0	0	0
02/21/2015 17:00	0.0	0	0	0	0	1
02/21/2015 18:00	0.0	0	0	0	0	1
02/21/2015 19:00	0.0	0	0	0	0	1
02/21/2015 20:00	0.0	0	0	0	0	1
02/21/2015 21:00	0.0	0	0	0	0	1
02/21/2015 22:00	0.0	0	0	0	0	1
02/21/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	88.2 #	0 #	2 #	0 #	0 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	55.6	0	1	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/22/2015 00:00	0.0	0	0	0	0	1
02/22/2015 01:00	0.0	0	0	0	0	1
02/22/2015 02:00	0.0	0	0	0	0	1
02/22/2015 03:00	0.0	0	0	0	0	1
02/22/2015 04:00	0.0	0	0	0	0	1
02/22/2015 05:00	0.0	0	0	0	0	1
02/22/2015 06:00	1.9	0	0	0	1	0
02/22/2015 07:00	0.0	0	0	0	0	0
02/22/2015 08:00	0.0	0	0	0	0	0
02/22/2015 09:00	0.0	0	0	0	0	0
02/22/2015 10:00	0.0	0	0	0	0	0
02/22/2015 11:00	0.0	0	0	0	0	0
02/22/2015 12:00	0.0	0	0	0	0	0
02/22/2015 13:00	0.0	0	0	0	0	0
02/22/2015 14:00	0.0	0	0	0	0	0
02/22/2015 15:00	0.0	0	0	0	0	0
02/22/2015 16:00	0.0	0	0	0	0	0
02/22/2015 17:00	0.0	0	0	0	0	0
02/22/2015 18:00	0.0	0	0	0	0	0
02/22/2015 19:00	0.0	0	0	0	0	0
02/22/2015 20:00	0.0	0	0	0	0	0
02/22/2015 21:00	0.0	0	0	0	0	0
02/22/2015 22:00	0.0	0	0	0	0	0
02/22/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.9 #	0 #	0 #	0 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.9	0	0	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/23/2015 00:00	0.0	0	0	0	0	0
02/23/2015 01:00	0.0	0	0	0	0	0
02/23/2015 02:00	0.0	0	0	0	0	0
02/23/2015 03:00	0.0	0	0	0	0	0
02/23/2015 04:00	0.0	0	0	0	0	0
02/23/2015 05:00	0.0	0	0	0	0	0
02/23/2015 06:00	0.0	0	0	0	0	0
02/23/2015 07:00	0.0	0	0	0	0	0
02/23/2015 08:00	0.0	0	0	0	0	0
02/23/2015 09:00	0.0	0	0	0	0	0
02/23/2015 10:00	0.0	0	0	0	0	0
02/23/2015 11:00	0.0	0	0	0	0	0
02/23/2015 12:00	0.0	0	0	0	0	0
02/23/2015 13:00	0.0	0	0	0	0	0
02/23/2015 14:00	0.0	0	0	0	0	0
02/23/2015 15:00	0.0	0	0	0	0	0
02/23/2015 16:00	0.0	0	0	0	0	0
02/23/2015 17:00	0.0	0	0	0	0	0
02/23/2015 18:00	0.0	0	0	0	0	0
02/23/2015 19:00	0.0	0	0	0	0	0
02/23/2015 20:00	0.0	0	0	0	0	0
02/23/2015 21:00	0.0	0	0	0	0	0
02/23/2015 22:00	0.0	0	0	0	0	0
02/23/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/24/2015 00:00	0.0	0	0	0	0	0
02/24/2015 01:00	0.0	0	0	0	0	0
02/24/2015 02:00	0.0	0	0	0	0	0
02/24/2015 03:00	49.1	0	1	0	0	0
02/24/2015 04:00	83.3	0	1	0	0	0
02/24/2015 05:00	15.3	0	1	0	0	0
02/24/2015 06:00	0.0	0	0	0	0	1
02/24/2015 07:00	0.0	0	0	0	0	1
02/24/2015 08:00	0.0	0	0	0	0	1
02/24/2015 09:00	0.0	0	0	0	0	1
02/24/2015 10:00	0.0	0	0	0	0	1
02/24/2015 11:00	0.0	0	0	0	0	1
02/24/2015 12:00	0.0	0	0	0	0	1
02/24/2015 13:00	0.0	0	0	0	0	1
02/24/2015 14:00	0.0	0	0	0	0	1
02/24/2015 15:00	0.0	0	0	0	0	1
02/24/2015 16:00	0.0	0	0	0	0	1
02/24/2015 17:00	0.0	0	0	0	0	1
02/24/2015 18:00	0.0	0	0	0	0	1
02/24/2015 19:00	0.0	0	0	0	0	1
02/24/2015 20:00	0.0	0	0	0	0	1
02/24/2015 21:00	0.0	0	0	0	0	1
02/24/2015 22:00	0.0	0	0	0	0	1
02/24/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	147.7 #	0 #	3 #	0 #	0 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	83.3	0	1	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/25/2015 00:00	0.0	0	0	0	0	1
02/25/2015 01:00	0.0	0	0	0	0	1
02/25/2015 02:00	0.0	0	0	0	0	1
02/25/2015 03:00	0.0	0	0	0	0	1
02/25/2015 04:00	0.0	0	0	0	0	1
02/25/2015 05:00	0.0	0	0	0	0	1
02/25/2015 06:00	0.0	0	0	0	0	1
02/25/2015 07:00	0.0	0	0	0	0	1
02/25/2015 08:00	0.0	0	0	0	0	1
02/25/2015 09:00	0.0	0	0	0	0	1
02/25/2015 10:00	0.0	0	0	0	0	1
02/25/2015 11:00	0.0	0	0	0	0	1
02/25/2015 12:00	0.0	0	0	0	0	1
02/25/2015 13:00	0.0	0	0	0	0	1
02/25/2015 14:00	0.0	0	0	0	0	1
02/25/2015 15:00	0.0	0	0	0	0	1
02/25/2015 16:00	0.0	0	0	0	0	1
02/25/2015 17:00	0.0	0	0	0	0	1
02/25/2015 18:00	0.0	0	0	0	0	1
02/25/2015 19:00	0.0	0	0	0	0	1
02/25/2015 20:00	0.0	0	0	0	0	1
02/25/2015 21:00	0.0	0	0	0	0	1
02/25/2015 22:00	0.0	0	0	0	0	1
02/25/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/26/2015 00:00	0.0	0	0	0	0	1
02/26/2015 01:00	0.0	0	0	0	0	1
02/26/2015 02:00	0.0	0	0	0	0	1
02/26/2015 03:00	0.0	0	0	0	0	1
02/26/2015 04:00	0.0	0	0	0	0	1
02/26/2015 05:00	0.0	0	0	0	0	1
02/26/2015 06:00	0.0	0	0	0	0	1
02/26/2015 07:00	0.0	0	0	0	0	1
02/26/2015 08:00	0.0	0	0	0	0	1
02/26/2015 09:00	0.0	0	0	0	0	1
02/26/2015 10:00	0.0	0	0	0	0	1
02/26/2015 11:00	0.0	0	0	0	0	1
02/26/2015 12:00	0.0	0	0	0	0	1
02/26/2015 13:00	0.0	0	0	0	0	1
02/26/2015 14:00	0.0	0	0	0	0	1
02/26/2015 15:00	0.0	0	0	0	0	1
02/26/2015 16:00	0.0	0	0	0	0	1
02/26/2015 17:00	0.0	0	0	0	0	1
02/26/2015 18:00	0.0	0	0	0	0	1
02/26/2015 19:00	0.0	0	0	0	0	1
02/26/2015 20:00	0.0	0	0	0	0	1
02/26/2015 21:00	0.0	0	0	0	0	1
02/26/2015 22:00	0.0	0	0	0	0	1
02/26/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/27/2015 00:00	0.0	0	0	0	0	1
02/27/2015 01:00	0.0	0	0	0	0	1
02/27/2015 02:00	0.0	0	0	0	0	1
02/27/2015 03:00	0.0	0	0	0	0	1
02/27/2015 04:00	0.0	0	0	0	0	1
02/27/2015 05:00	0.0	0	0	0	0	1
02/27/2015 06:00	0.0	0	0	0	0	1
02/27/2015 07:00	0.0	0	0	0	0	1
02/27/2015 08:00	0.0	0	0	0	0	1
02/27/2015 09:00	0.0	0	0	0	0	1
02/27/2015 10:00	0.0	0	0	0	0	1
02/27/2015 11:00	0.0	0	0	0	0	1
02/27/2015 12:00	0.0	0	0	0	0	1
02/27/2015 13:00	0.0	0	0	0	0	1
02/27/2015 14:00	0.0	0	0	0	0	1
02/27/2015 15:00	0.0	0	0	0	0	1
02/27/2015 16:00	0.0	0	0	0	0	1
02/27/2015 17:00	0.0	0	0	0	0	1
02/27/2015 18:00	0.0	0	0	0	0	1
02/27/2015 19:00	0.0	0	0	0	0	1
02/27/2015 20:00	0.0	0	0	0	0	1
02/27/2015 21:00	0.0	0	0	0	0	1
02/27/2015 22:00	0.0	0	0	0	0	1
02/27/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/28/2015 00:00	0.0	0	0	0	0	1
02/28/2015 01:00	1.3	0	0	0	1	0
02/28/2015 02:00	0.0	0	0	0	0	0
02/28/2015 03:00	0.0	0	0	0	0	0
02/28/2015 04:00	0.0	0	0	0	0	0
02/28/2015 05:00	0.0	0	0	0	0	0
02/28/2015 06:00	0.0	0	0	0	0	0
02/28/2015 07:00	0.0	0	0	0	0	0
02/28/2015 08:00	22.6	0	0	1	0	0
02/28/2015 09:00	15.7	0	0	1	0	0
02/28/2015 10:00	0.0	0	0	0	0	1
02/28/2015 11:00	0.0	0	0	0	0	1
02/28/2015 12:00	0.0	0	0	0	0	1
02/28/2015 13:00	0.0	0	0	0	0	1
02/28/2015 14:00	0.0	0	0	0	0	1
02/28/2015 15:00	0.0	0	0	0	0	1
02/28/2015 16:00	0.0	0	0	0	0	1
02/28/2015 17:00	0.0	0	0	0	0	1
02/28/2015 18:00	0.0	0	0	0	0	1
02/28/2015 19:00	0.0	0	0	0	0	1
02/28/2015 20:00	0.0	0	0	0	0	1
02/28/2015 21:00	0.0	0	0	0	0	1
02/28/2015 22:00	0.0	0	0	0	0	1
02/28/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	39.6 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	22.6	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/01/2015 00:00	0.0	0	0	0	0	1
03/01/2015 01:00	0.0	0	0	0	0	1
03/01/2015 02:00	0.0	0	0	0	0	1
03/01/2015 03:00	0.0	0	0	0	0	1
03/01/2015 04:00	0.0	0	0	0	0	1
03/01/2015 05:00	0.0	0	0	0	0	1
03/01/2015 06:00	0.0	0	0	0	0	1
03/01/2015 07:00	0.0	0	0	0	0	1
03/01/2015 08:00	0.0	0	0	0	0	1
03/01/2015 09:00	0.0	0	0	0	0	1
03/01/2015 10:00	0.0	0	0	0	0	1
03/01/2015 11:00	0.0	0	0	0	0	1
03/01/2015 12:00	0.0	0	0	0	0	1
03/01/2015 13:00	0.0	0	0	0	0	1
03/01/2015 14:00	0.0	0	0	0	0	1
03/01/2015 15:00	0.0	0	0	0	0	1
03/01/2015 16:00	0.0	0	0	0	0	1
03/01/2015 17:00	0.0	0	0	0	0	1
03/01/2015 18:00	0.0	0	0	0	0	1
03/01/2015 19:00	0.0	0	0	0	0	1
03/01/2015 20:00	0.0	0	0	0	0	1
03/01/2015 21:00	0.0	0	0	0	0	1
03/01/2015 22:00	0.0	0	0	0	0	1
03/01/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/02/2015 00:00	0.0	0	0	0	0	1
03/02/2015 01:00	0.0	0	0	0	0	1
03/02/2015 02:00	0.0	0	0	0	0	1
03/02/2015 03:00	0.0	0	0	0	0	1
03/02/2015 04:00	0.0	0	0	0	0	1
03/02/2015 05:00	0.0	0	0	0	0	1
03/02/2015 06:00	0.0	0	0	0	0	1
03/02/2015 07:00	0.0	0	0	0	0	1
03/02/2015 08:00	0.0	0	0	0	0	1
03/02/2015 09:00	0.0	0	0	0	0	1
03/02/2015 10:00	0.0	0	0	0	0	1
03/02/2015 11:00	0.0	0	0	0	0	1
03/02/2015 12:00	0.0	0	0	0	0	1
03/02/2015 13:00	0.0	0	0	0	0	1
03/02/2015 14:00	0.0	0	0	0	0	1
03/02/2015 15:00	0.0	0	0	0	0	1
03/02/2015 16:00	0.0	0	0	0	0	1
03/02/2015 17:00	0.0	0	0	0	0	1
03/02/2015 18:00	0.0	0	0	0	0	1
03/02/2015 19:00	0.0	0	0	0	0	1
03/02/2015 20:00	0.0	0	0	0	0	1
03/02/2015 21:00	0.0	0	0	0	0	1
03/02/2015 22:00	0.0	0	0	0	0	1
03/02/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/03/2015 00:00	0.0	0	0	0	0	1
03/03/2015 01:00	0.0	0	0	0	0	1
03/03/2015 02:00	0.0	0	0	0	0	1
03/03/2015 03:00	0.0	0	0	0	0	1
03/03/2015 04:00	0.0	0	0	0	0	1
03/03/2015 05:00	0.0	0	0	0	0	1
03/03/2015 06:00	0.0	0	0	0	0	1
03/03/2015 07:00	0.0	0	0	0	0	1
03/03/2015 08:00	0.0	0	0	0	0	1
03/03/2015 09:00	0.0	0	0	0	0	1
03/03/2015 10:00	0.0	0	0	0	0	1
03/03/2015 11:00	0.0	0	0	0	0	1
03/03/2015 12:00	0.0	0	0	0	0	1
03/03/2015 13:00	0.0	0	0	0	0	1
03/03/2015 14:00	0.0	0	0	0	0	1
03/03/2015 15:00	0.0	0	0	0	0	1
03/03/2015 16:00	0.0	0	0	0	0	1
03/03/2015 17:00	0.0	0	0	0	0	1
03/03/2015 18:00	0.0	0	0	0	0	1
03/03/2015 19:00	0.0	0	0	0	0	1
03/03/2015 20:00	0.0	0	0	0	0	1
03/03/2015 21:00	0.0	0	0	0	0	1
03/03/2015 22:00	0.0	0	0	0	0	1
03/03/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/04/2015 00:00	0.0	0	0	0	0	1
03/04/2015 01:00	0.0	0	0	0	0	1
03/04/2015 02:00	0.0	0	0	0	0	1
03/04/2015 03:00	0.0	0	0	0	0	1
03/04/2015 04:00	0.0	0	0	0	0	1
03/04/2015 05:00	0.0	0	0	0	0	1
03/04/2015 06:00	0.0	0	0	0	0	1
03/04/2015 07:00	0.0	0	0	0	0	1
03/04/2015 08:00	0.0	0	0	0	0	1
03/04/2015 09:00	0.0	0	0	0	0	1
03/04/2015 10:00	0.0	0	0	0	0	1
03/04/2015 11:00	0.0	0	0	0	0	1
03/04/2015 12:00	0.0	0	0	0	0	1
03/04/2015 13:00	0.0	0	0	0	0	1
03/04/2015 14:00	0.0	0	0	0	0	1
03/04/2015 15:00	0.0	0	0	0	0	1
03/04/2015 16:00	0.0	0	0	0	0	1
03/04/2015 17:00	0.0	0	0	0	0	1
03/04/2015 18:00	0.0	0	0	0	0	1
03/04/2015 19:00	0.0	0	0	0	0	1
03/04/2015 20:00	0.0	0	0	0	0	1
03/04/2015 21:00	0.0	0	0	0	0	1
03/04/2015 22:00	0.0	0	0	0	0	1
03/04/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/05/2015 00:00	0.0	0	0	0	0	1
03/05/2015 01:00	0.0	0	0	0	0	1
03/05/2015 02:00	0.0	0	0	0	0	1
03/05/2015 03:00	0.0	0	0	0	0	1
03/05/2015 04:00	0.0	0	0	0	0	1
03/05/2015 05:00	0.0	0	0	0	0	1
03/05/2015 06:00	0.0	0	0	0	0	1
03/05/2015 07:00	0.0	0	0	0	0	1
03/05/2015 08:00	0.0	0	0	0	0	1
03/05/2015 09:00	0.0	0	0	0	0	1
03/05/2015 10:00	0.0	0	0	0	0	1
03/05/2015 11:00	0.0	0	0	0	0	1
03/05/2015 12:00	0.0	0	0	0	0	1
03/05/2015 13:00	0.0	0	0	0	0	1
03/05/2015 14:00	0.0	0	0	0	0	1
03/05/2015 15:00	0.0	0	0	0	0	1
03/05/2015 16:00	0.0	0	0	0	0	1
03/05/2015 17:00	0.0	0	0	0	0	1
03/05/2015 18:00	0.0	0	0	0	0	1
03/05/2015 19:00	0.0	0	0	0	0	1
03/05/2015 20:00	0.0	0	0	0	0	1
03/05/2015 21:00	0.0	0	0	0	0	1
03/05/2015 22:00	0.0	0	0	0	0	1
03/05/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/06/2015 00:00	0.0	0	0	0	0	1
03/06/2015 01:00	0.0	0	0	0	0	1
03/06/2015 02:00	0.0	0	0	0	0	1
03/06/2015 03:00	0.0	0	0	0	0	1
03/06/2015 04:00	0.0	0	0	0	0	1
03/06/2015 05:00	0.0	0	0	0	0	1
03/06/2015 06:00	0.0	0	0	0	0	1
03/06/2015 07:00	0.0	0	0	0	0	1
03/06/2015 08:00	0.0	0	0	0	0	1
03/06/2015 09:00	0.0	0	0	0	0	1
03/06/2015 10:00	0.0	0	0	0	0	1
03/06/2015 11:00	0.0	0	0	0	0	1
03/06/2015 12:00	0.0	0	0	0	0	1
03/06/2015 13:00	0.0	0	0	0	0	1
03/06/2015 14:00	0.0	0	0	0	0	1
03/06/2015 15:00	0.0	0	0	0	0	1
03/06/2015 16:00	0.0	0	0	0	0	1
03/06/2015 17:00	0.0	0	0	0	0	1
03/06/2015 18:00	0.0	0	0	0	0	1
03/06/2015 19:00	0.0	0	0	0	0	1
03/06/2015 20:00	0.0	0	0	0	0	1
03/06/2015 21:00	0.0	0	0	0	0	1
03/06/2015 22:00	0.0	0	0	0	0	1
03/06/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/07/2015 00:00	0.0	0	0	0	0	1
03/07/2015 01:00	0.0	0	0	0	0	1
03/07/2015 02:00	1.6	0	0	0	1	0
03/07/2015 03:00	0.0	0	0	0	0	0
03/07/2015 04:00	0.0	0	0	0	0	0
03/07/2015 05:00	0.0	0	0	0	0	0
03/07/2015 06:00	0.0	0	0	0	0	0
03/07/2015 07:00	0.0	0	0	0	0	0
03/07/2015 08:00	0.0	0	0	0	0	0
03/07/2015 09:00	0.0	0	0	0	0	0
03/07/2015 10:00	32.1	0	1	0	0	0
03/07/2015 11:00	34.5	0	1	0	0	0
03/07/2015 12:00	0.0	0	0	0	0	1
03/07/2015 13:00	0.0	0	0	0	0	1
03/07/2015 14:00	0.0	0	0	0	0	1
03/07/2015 15:00	0.0	0	0	0	0	1
03/07/2015 16:00	0.0	0	0	0	0	1
03/07/2015 17:00	0.0	0	0	0	0	1
03/07/2015 18:00	0.0	0	0	0	0	1
03/07/2015 19:00	0.0	0	0	0	0	1
03/07/2015 20:00	0.0	0	0	0	0	1
03/07/2015 21:00	0.0	0	0	0	0	1
03/07/2015 22:00	0.0	0	0	0	0	1
03/07/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	68.2 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	34.5	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/08/2015 00:00	0.0	0	0	0	0	1
03/08/2015 01:00	0.0	0	0	0	0	1
03/08/2015 02:00	0.0	0	0	0	0	1
03/08/2015 03:00	0.0	0	0	0	0	1
03/08/2015 04:00	0.0	0	0	0	0	1
03/08/2015 05:00	0.0	0	0	0	0	1
03/08/2015 06:00	0.0	0	0	0	0	1
03/08/2015 07:00	0.0	0	0	0	0	1
03/08/2015 08:00	1.3	0	0	0	1	0
03/08/2015 09:00	0.0	0	0	0	0	0
03/08/2015 10:00	0.0	0	0	0	0	0
03/08/2015 11:00	0.0	0	0	0	0	0
03/08/2015 12:00	0.0	0	0	0	0	0
03/08/2015 13:00	0.0	0	0	0	0	0
03/08/2015 14:00	0.0	0	0	1	0	0
03/08/2015 15:00	34.5	0	0	1	0	0
03/08/2015 16:00	4.4	0	0	1	0	0
03/08/2015 17:00	0.0	0	0	0	0	1
03/08/2015 18:00	0.0	0	0	0	0	1
03/08/2015 19:00	0.0	0	0	0	0	1
03/08/2015 20:00	0.0	0	0	0	0	1
03/08/2015 21:00	0.0	0	0	0	0	1
03/08/2015 22:00	0.0	0	0	0	0	1
03/08/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	40.2 #	0 #	0 #	3 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	34.5	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/09/2015 00:00	0.0	0	0	0	0	1
03/09/2015 01:00	0.0	0	0	0	0	1
03/09/2015 02:00	0.0	0	0	0	0	1
03/09/2015 03:00	0.0	0	0	0	0	1
03/09/2015 04:00	0.0	0	0	0	0	1
03/09/2015 05:00	0.0	0	0	0	0	1
03/09/2015 06:00	0.0	0	0	0	0	1
03/09/2015 07:00	0.0	0	0	0	0	1
03/09/2015 08:00	0.0	0	0	0	0	1
03/09/2015 09:00	0.0	0	0	0	0	1
03/09/2015 10:00	0.0	0	0	0	0	1
03/09/2015 11:00	0.0	0	0	0	0	1
03/09/2015 12:00	0.0	0	0	0	0	1
03/09/2015 13:00	0.0	0	0	0	0	1
03/09/2015 14:00	0.0	0	0	0	0	1
03/09/2015 15:00	0.0	0	0	0	0	1
03/09/2015 16:00	0.0	0	0	0	0	1
03/09/2015 17:00	0.0	0	0	0	0	1
03/09/2015 18:00	0.0	0	0	0	0	1
03/09/2015 19:00	0.0	0	0	0	0	1
03/09/2015 20:00	0.0	0	0	0	0	1
03/09/2015 21:00	0.0	0	0	0	0	1
03/09/2015 22:00	0.0	0	0	0	0	1
03/09/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/10/2015 00:00	0.0	0	0	0	0	1
03/10/2015 01:00	0.0	0	0	0	0	1
03/10/2015 02:00	0.0	0	0	0	0	1
03/10/2015 03:00	0.0	0	0	0	0	1
03/10/2015 04:00	0.0	0	0	0	0	1
03/10/2015 05:00	0.0	0	0	0	0	1
03/10/2015 06:00	0.0	0	0	0	0	1
03/10/2015 07:00	0.0	0	0	0	0	1
03/10/2015 08:00	0.0	0	0	0	0	1
03/10/2015 09:00	0.0	0	0	0	0	1
03/10/2015 10:00	0.0	0	0	0	0	1
03/10/2015 11:00	0.0	0	0	0	0	1
03/10/2015 12:00	0.0	0	0	0	0	1
03/10/2015 13:00	0.0	0	0	0	0	1
03/10/2015 14:00	0.0	0	0	0	0	1
03/10/2015 15:00	0.0	0	0	0	0	1
03/10/2015 16:00	0.0	0	0	0	0	1
03/10/2015 17:00	0.0	0	0	0	0	1
03/10/2015 18:00	0.0	0	0	0	0	1
03/10/2015 19:00	0.0	0	0	0	0	1
03/10/2015 20:00	0.0	0	0	0	0	1
03/10/2015 21:00	0.0	0	0	0	0	1
03/10/2015 22:00	0.0	0	0	0	0	1
03/10/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/11/2015 00:00	0.0	0	0	0	0	1
03/11/2015 01:00	0.0	0	0	0	0	1
03/11/2015 02:00	0.0	0	0	0	0	1
03/11/2015 03:00	0.0	0	0	0	0	1
03/11/2015 04:00	0.0	0	0	0	0	1
03/11/2015 05:00	0.0	0	0	0	0	1
03/11/2015 06:00	0.0	0	0	0	0	1
03/11/2015 07:00	0.0	0	0	0	0	1
03/11/2015 08:00	0.0	0	0	0	0	1
03/11/2015 09:00	0.0	0	0	0	0	1
03/11/2015 10:00	0.0	0	0	0	0	1
03/11/2015 11:00	0.0	0	0	0	0	1
03/11/2015 12:00	0.0	0	0	0	0	1
03/11/2015 13:00	0.0	0	0	0	0	1
03/11/2015 14:00	0.0	0	0	0	0	1
03/11/2015 15:00	0.0	0	0	0	0	1
03/11/2015 16:00	0.0	0	0	0	0	1
03/11/2015 17:00	0.0	0	0	0	0	1
03/11/2015 18:00	0.0	0	0	0	0	1
03/11/2015 19:00	0.0	0	0	0	0	1
03/11/2015 20:00	0.0	0	0	0	0	1
03/11/2015 21:00	0.0	0	0	0	0	1
03/11/2015 22:00	0.0	0	0	0	0	1
03/11/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/12/2015 00:00	0.0	0	0	0	0	1
03/12/2015 01:00	0.0	0	0	0	0	1
03/12/2015 02:00	0.0	0	0	0	0	1
03/12/2015 03:00	0.0	0	0	0	0	1
03/12/2015 04:00	0.0	0	0	0	0	1
03/12/2015 05:00	0.0	0	0	0	0	1
03/12/2015 06:00	0.0	0	0	0	0	1
03/12/2015 07:00	0.0	0	0	0	0	1
03/12/2015 08:00	0.0	0	0	0	0	1
03/12/2015 09:00	0.0	0	0	0	0	1
03/12/2015 10:00	0.0	0	0	0	0	1
03/12/2015 11:00	0.0	0	0	0	0	1
03/12/2015 12:00	0.0	0	0	0	0	1
03/12/2015 13:00	0.0	0	0	0	0	1
03/12/2015 14:00	0.0	0	0	0	0	1
03/12/2015 15:00	0.0	0	0	0	0	1
03/12/2015 16:00	0.0	0	0	0	0	1
03/12/2015 17:00	0.0	0	0	0	0	1
03/12/2015 18:00	0.0	0	0	0	0	1
03/12/2015 19:00	0.0	0	0	0	0	1
03/12/2015 20:00	0.0	0	0	0	0	1
03/12/2015 21:00	0.0	0	0	0	0	1
03/12/2015 22:00	0.0	0	0	0	0	1
03/12/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/13/2015 00:00	0.0	0	0	0	0	1
03/13/2015 01:00	0.0	0	0	0	0	1
03/13/2015 02:00	0.0	0	0	0	0	1
03/13/2015 03:00	0.0	0	0	0	0	1
03/13/2015 04:00	0.0	0	0	0	0	1
03/13/2015 05:00	0.0	0	0	0	0	1
03/13/2015 06:00	0.0	0	0	0	0	1
03/13/2015 07:00	0.0	0	0	0	0	1
03/13/2015 08:00	0.0	0	0	0	0	1
03/13/2015 09:00	0.0	0	0	0	0	1
03/13/2015 10:00	0.0	0	0	0	0	1
03/13/2015 11:00	0.0	0	0	0	0	1
03/13/2015 12:00	0.0	0	0	0	0	1
03/13/2015 13:00	0.0	0	0	0	0	1
03/13/2015 14:00	0.0	0	0	0	0	1
03/13/2015 15:00	0.0	0	0	0	0	1
03/13/2015 16:00	0.0	0	0	0	0	1
03/13/2015 17:00	0.0	0	0	0	0	1
03/13/2015 18:00	0.0	0	0	0	0	1
03/13/2015 19:00	0.0	0	0	0	0	1
03/13/2015 20:00	0.0	0	0	0	0	1
03/13/2015 21:00	0.0	0	0	0	0	1
03/13/2015 22:00	0.0	0	0	0	0	1
03/13/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/14/2015 00:00	0.0	0	0	0	0	1
03/14/2015 01:00	0.0	0	0	0	0	1
03/14/2015 02:00	0.0	0	0	0	0	1
03/14/2015 03:00	0.0	0	0	0	0	1
03/14/2015 04:00	0.0	0	0	0	0	1
03/14/2015 05:00	0.0	0	0	0	0	1
03/14/2015 06:00	0.0	0	0	0	0	1
03/14/2015 07:00	0.0	0	0	0	0	1
03/14/2015 08:00	0.0	0	0	0	0	1
03/14/2015 09:00	0.0	0	0	0	0	1
03/14/2015 10:00	0.0	0	0	0	0	1
03/14/2015 11:00	0.0	0	0	0	0	1
03/14/2015 12:00	0.0	0	0	0	0	1
03/14/2015 13:00	0.0	0	0	0	0	1
03/14/2015 14:00	0.0	0	0	0	0	1
03/14/2015 15:00	0.0	0	0	0	0	1
03/14/2015 16:00	0.0	0	0	0	0	1
03/14/2015 17:00	0.0	0	0	0	0	1
03/14/2015 18:00	0.0	0	0	0	0	1
03/14/2015 19:00	0.0	0	0	0	0	1
03/14/2015 20:00	0.0	0	0	0	0	1
03/14/2015 21:00	0.0	0	0	0	0	1
03/14/2015 22:00	0.0	0	0	0	0	1
03/14/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/15/2015 00:00	0.0	0	0	0	0	1
03/15/2015 01:00	0.0	0	0	0	0	1
03/15/2015 02:00	0.0	0	0	0	0	1
03/15/2015 03:00	0.0	0	0	0	0	1
03/15/2015 04:00	0.0	0	0	0	0	1
03/15/2015 05:00	0.0	0	0	0	0	1
03/15/2015 06:00	0.0	0	0	0	0	1
03/15/2015 07:00	0.0	0	0	0	0	1
03/15/2015 08:00	0.0	0	0	0	0	1
03/15/2015 09:00	0.0	0	0	0	0	1
03/15/2015 10:00	0.0	0	0	0	0	1
03/15/2015 11:00	0.0	0	0	0	0	1
03/15/2015 12:00	0.0	0	0	0	0	1
03/15/2015 13:00	0.0	0	0	0	0	1
03/15/2015 14:00	0.0	0	0	0	0	1
03/15/2015 15:00	0.0	0	0	0	0	1
03/15/2015 16:00	0.0	0	0	0	0	1
03/15/2015 17:00	0.0	0	0	0	0	1
03/15/2015 18:00	0.0	0	0	0	0	1
03/15/2015 19:00	0.0	0	0	0	0	1
03/15/2015 20:00	0.0	0	0	0	0	1
03/15/2015 21:00	0.0	0	0	0	0	1
03/15/2015 22:00	0.0	0	0	0	0	1
03/15/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/16/2015 00:00	0.0	0	0	0	0	1
03/16/2015 01:00	0.0	0	0	0	0	1
03/16/2015 02:00	0.0	0	0	0	0	1
03/16/2015 03:00	0.0	0	0	0	0	1
03/16/2015 04:00	0.0	0	0	0	0	1
03/16/2015 05:00	0.0	0	0	0	0	1
03/16/2015 06:00	0.0	0	0	0	0	1
03/16/2015 07:00	0.0	0	0	0	0	1
03/16/2015 08:00	0.0	0	0	0	0	1
03/16/2015 09:00	0.0	0	0	0	0	1
03/16/2015 10:00	0.0	0	0	0	0	1
03/16/2015 11:00	0.0	0	0	0	0	1
03/16/2015 12:00	0.0	0	0	0	0	1
03/16/2015 13:00	0.0	0	0	0	0	1
03/16/2015 14:00	0.0	0	0	0	0	1
03/16/2015 15:00	0.0	0	0	0	0	1
03/16/2015 16:00	0.0	0	0	0	0	1
03/16/2015 17:00	0.0	0	0	0	0	1
03/16/2015 18:00	0.0	0	0	0	0	1
03/16/2015 19:00	0.0	0	0	0	0	1
03/16/2015 20:00	0.0	0	0	0	0	1
03/16/2015 21:00	0.0	0	0	0	0	1
03/16/2015 22:00	0.0	0	0	0	0	1
03/16/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/17/2015 00:00	0.0	0	0	0	0	1
03/17/2015 01:00	0.0	0	0	0	0	1
03/17/2015 02:00	0.0	0	0	0	0	1
03/17/2015 03:00	0.0	0	0	0	0	1
03/17/2015 04:00	0.0	0	0	0	0	1
03/17/2015 05:00	0.0	0	0	0	0	1
03/17/2015 06:00	0.0	0	0	0	0	1
03/17/2015 07:00	0.0	0	0	0	0	1
03/17/2015 08:00	0.0	0	0	0	0	1
03/17/2015 09:00	0.0	0	0	0	0	1
03/17/2015 10:00	0.0	0	0	0	0	1
03/17/2015 11:00	0.1	0	0	1	0	0
03/17/2015 12:00	0.3	0	0	1	0	0
03/17/2015 13:00	0.0	0	0	0	0	1
03/17/2015 14:00	0.0	0	0	0	0	1
03/17/2015 15:00	0.0	0	0	0	0	1
03/17/2015 16:00	0.0	0	0	0	0	1
03/17/2015 17:00	0.0	0	0	0	0	1
03/17/2015 18:00	0.0	0	0	0	0	1
03/17/2015 19:00	0.0	0	0	0	0	1
03/17/2015 20:00	0.0	0	0	0	0	1
03/17/2015 21:00	0.0	0	0	0	0	1
03/17/2015 22:00	0.0	0	0	0	0	1
03/17/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.4 #	0 #	0 #	2 #	0 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.3	0	0	1	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/18/2015 00:00	0.0	0	0	0	0	1
03/18/2015 01:00	0.0	0	0	0	0	1
03/18/2015 02:00	0.0	0	0	0	0	1
03/18/2015 03:00	0.0	0	0	0	0	1
03/18/2015 04:00	0.0	0	0	0	0	1
03/18/2015 05:00	0.0	0	0	0	0	1
03/18/2015 06:00	0.0	0	0	0	0	1
03/18/2015 07:00	0.0	0	0	0	0	1
03/18/2015 08:00	0.0	0	0	0	0	1
03/18/2015 09:00	0.0	0	0	0	0	1
03/18/2015 10:00	0.0	0	0	0	0	1
03/18/2015 11:00	0.0	0	0	0	0	1
03/18/2015 12:00	0.0	0	0	0	0	1
03/18/2015 13:00	0.0	0	0	0	0	1
03/18/2015 14:00	0.0	0	0	0	0	1
03/18/2015 15:00	0.0	0	0	0	0	1
03/18/2015 16:00	0.0	0	0	0	0	1
03/18/2015 17:00	0.0	0	0	0	0	1
03/18/2015 18:00	0.0	0	0	0	0	1
03/18/2015 19:00	0.0	0	0	0	0	1
03/18/2015 20:00	0.0	0	0	0	0	1
03/18/2015 21:00	0.0	0	0	0	0	1
03/18/2015 22:00	0.0	0	0	0	0	1
03/18/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/19/2015 00:00	0.0	0	0	0	0	1
03/19/2015 01:00	0.0	0	0	0	0	1
03/19/2015 02:00	0.0	0	0	0	0	1
03/19/2015 03:00	0.0	0	0	0	0	1
03/19/2015 04:00	0.0	0	0	0	0	1
03/19/2015 05:00	0.0	0	0	0	0	1
03/19/2015 06:00	0.0	0	0	0	0	1
03/19/2015 07:00	0.0	0	0	0	0	1
03/19/2015 08:00	0.0	0	0	0	0	1
03/19/2015 09:00	0.0	0	0	0	0	1
03/19/2015 10:00	0.0	0	0	0	0	1
03/19/2015 11:00	0.0	0	0	0	0	1
03/19/2015 12:00	0.0	0	0	0	0	1
03/19/2015 13:00	0.0	0	0	0	0	1
03/19/2015 14:00	0.0	0	0	0	0	1
03/19/2015 15:00	0.0	0	0	0	0	1
03/19/2015 16:00	0.0	0	0	0	0	1
03/19/2015 17:00	0.0	0	0	0	0	1
03/19/2015 18:00	0.0	0	0	0	0	1
03/19/2015 19:00	0.0	0	0	0	0	1
03/19/2015 20:00	0.0	0	0	0	0	1
03/19/2015 21:00	0.0	0	0	0	0	1
03/19/2015 22:00	0.0	0	0	0	0	1
03/19/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/20/2015 00:00	0.0	0	0	0	0	1
03/20/2015 01:00	0.0	0	0	0	0	1
03/20/2015 02:00	0.0	0	0	0	0	1
03/20/2015 03:00	0.0	0	0	0	0	1
03/20/2015 04:00	0.0	0	0	0	0	1
03/20/2015 05:00	0.0	0	0	0	0	1
03/20/2015 06:00	0.0	0	0	0	0	1
03/20/2015 07:00	0.0	0	0	0	0	1
03/20/2015 08:00	0.0	0	0	0	0	1
03/20/2015 09:00	0.0	0	0	0	0	1
03/20/2015 10:00	0.0	0	0	0	0	1
03/20/2015 11:00	0.0	0	0	0	0	1
03/20/2015 12:00	0.0	0	0	0	0	1
03/20/2015 13:00	0.0	0	0	0	0	1
03/20/2015 14:00	0.0	0	0	0	0	1
03/20/2015 15:00	0.0	0	0	0	0	1
03/20/2015 16:00	0.0	0	0	0	0	1
03/20/2015 17:00	0.0	0	0	0	0	1
03/20/2015 18:00	0.0	0	0	0	0	1
03/20/2015 19:00	0.0	0	0	0	0	1
03/20/2015 20:00	0.0	0	0	0	0	1
03/20/2015 21:00	0.0	0	0	0	0	1
03/20/2015 22:00	0.0	0	0	0	0	1
03/20/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/21/2015 00:00	0.0	0	0	0	0	1
03/21/2015 01:00	0.0	0	0	0	0	1
03/21/2015 02:00	0.0	0	0	0	0	1
03/21/2015 03:00	0.0	0	0	0	0	1
03/21/2015 04:00	0.0	0	0	0	0	1
03/21/2015 05:00	0.0	0	0	0	0	1
03/21/2015 06:00	0.0	0	0	0	0	1
03/21/2015 07:00	0.0	0	0	0	0	1
03/21/2015 08:00	0.0	0	0	0	0	1
03/21/2015 09:00	0.0	0	0	0	0	1
03/21/2015 10:00	0.0	0	0	0	0	1
03/21/2015 11:00	0.0	0	0	0	0	1
03/21/2015 12:00	0.0	0	0	0	0	1
03/21/2015 13:00	0.0	0	0	0	0	1
03/21/2015 14:00	0.0	0	0	0	0	1
03/21/2015 15:00	0.0	0	0	0	0	1
03/21/2015 16:00	0.0	0	0	0	0	1
03/21/2015 17:00	0.0	0	0	0	0	1
03/21/2015 18:00	0.0	0	0	0	0	1
03/21/2015 19:00	0.0	0	0	0	0	1
03/21/2015 20:00	0.0	0	0	0	0	1
03/21/2015 21:00	0.0	0	0	0	0	1
03/21/2015 22:00	0.0	0	0	0	0	1
03/21/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/22/2015 00:00	0.0	0	0	0	0	1
03/22/2015 01:00	0.0	0	0	0	0	1
03/22/2015 02:00	0.0	0	0	0	0	1
03/22/2015 03:00	0.0	0	0	0	0	1
03/22/2015 04:00	0.0	0	0	0	0	1
03/22/2015 05:00	0.0	0	0	0	0	1
03/22/2015 06:00	0.0	0	0	0	0	1
03/22/2015 07:00	0.0	0	0	0	0	1
03/22/2015 08:00	0.0	0	0	0	0	1
03/22/2015 09:00	0.0	0	0	0	0	1
03/22/2015 10:00	0.0	0	0	0	0	1
03/22/2015 11:00	0.0	0	0	0	0	1
03/22/2015 12:00	0.0	0	0	0	0	1
03/22/2015 13:00	0.0	0	0	0	0	1
03/22/2015 14:00	0.0	0	0	0	0	1
03/22/2015 15:00	0.0	0	0	0	0	1
03/22/2015 16:00	0.0	0	0	0	0	1
03/22/2015 17:00	0.0	0	0	0	0	1
03/22/2015 18:00	0.0	0	0	0	0	1
03/22/2015 19:00	0.0	0	0	0	0	1
03/22/2015 20:00	0.0	0	0	0	0	1
03/22/2015 21:00	0.0	0	0	0	0	1
03/22/2015 22:00	0.0	0	0	0	0	1
03/22/2015 23:00	0.8	0	0	0	1	0
Average/Sum#:	0.8 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.8	0	0	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/23/2015 00:00	0.0	0	0	0	0	0
03/23/2015 01:00	0.0	0	0	0	0	0
03/23/2015 02:00	0.0	0	0	0	0	0
03/23/2015 03:00	0.0	0	0	0	0	0
03/23/2015 04:00	0.0	0	0	0	0	0
03/23/2015 05:00	0.0	0	0	0	0	0
03/23/2015 06:00	0.0	0	0	0	0	0
03/23/2015 07:00	0.0	0	0	0	0	0
03/23/2015 08:00	0.0	0	0	0	0	0
03/23/2015 09:00	0.0	0	0	0	0	0
03/23/2015 10:00	0.0	0	0	0	0	0
03/23/2015 11:00	0.0	0	0	0	0	0
03/23/2015 12:00	0.0	0	0	0	0	0
03/23/2015 13:00	0.0	0	0	0	0	0
03/23/2015 14:00	0.0	0	0	0	0	0
03/23/2015 15:00	0.0	0	0	0	0	0
03/23/2015 16:00	0.0	0	0	0	0	0
03/23/2015 17:00	0.0	0	0	0	0	0
03/23/2015 18:00	0.0	0	0	0	0	0
03/23/2015 19:00	0.0	0	0	0	0	0
03/23/2015 20:00	0.0	0	0	0	0	0
03/23/2015 21:00	0.0	0	0	0	0	0
03/23/2015 22:00	0.0	0	0	0	0	0
03/23/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/24/2015 00:00	0.0	0	0	0	0	0
03/24/2015 01:00	0.0	0	0	0	0	0
03/24/2015 02:00	0.0	0	0	0	0	0
03/24/2015 03:00	0.0	0	0	0	0	0
03/24/2015 04:00	0.0	0	0	0	0	0
03/24/2015 05:00	0.0	0	0	0	0	0
03/24/2015 06:00	0.0	0	0	0	0	0
03/24/2015 07:00	0.0	0	0	0	0	0
03/24/2015 08:00	0.0	0	0	0	0	0
03/24/2015 09:00	0.0	0	0	0	0	0
03/24/2015 10:00	0.0	0	0	0	0	0
03/24/2015 11:00	0.0	0	0	0	0	0
03/24/2015 12:00	0.0	0	0	0	0	0
03/24/2015 13:00	0.0	0	0	0	0	0
03/24/2015 14:00	0.0	0	0	0	0	0
03/24/2015 15:00	0.0	0	0	0	0	0
03/24/2015 16:00	0.0	0	0	0	0	0
03/24/2015 17:00	0.0	0	0	0	0	0
03/24/2015 18:00	0.0	0	0	0	0	0
03/24/2015 19:00	0.0	0	0	0	0	0
03/24/2015 20:00	0.0	0	0	0	0	0
03/24/2015 21:00	0.0	0	0	0	0	0
03/24/2015 22:00	0.0	0	0	0	0	0
03/24/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/25/2015 00:00	0.0	0	0	0	0	0
03/25/2015 01:00	0.0	0	0	0	0	0
03/25/2015 02:00	0.0	0	0	0	0	0
03/25/2015 03:00	0.0	0	0	0	0	0
03/25/2015 04:00	0.0	0	0	0	0	0
03/25/2015 05:00	0.0	0	0	0	0	0
03/25/2015 06:00	0.0	0	0	0	0	0
03/25/2015 07:00	0.0	0	0	0	0	0
03/25/2015 08:00	0.0	0	0	0	0	0
03/25/2015 09:00	0.0	0	0	0	0	0
03/25/2015 10:00	0.0	0	0	0	0	0
03/25/2015 11:00	0.0	0	0	0	0	0
03/25/2015 12:00	0.0	0	0	0	0	0
03/25/2015 13:00	0.0	0	0	0	0	0
03/25/2015 14:00	0.0	0	0	0	0	0
03/25/2015 15:00	0.0	0	0	0	0	0
03/25/2015 16:00	0.0	0	0	0	0	0
03/25/2015 17:00	0.0	0	0	0	0	0
03/25/2015 18:00	0.0	0	0	0	0	0
03/25/2015 19:00	0.0	0	0	0	0	0
03/25/2015 20:00	0.0	0	0	0	0	0
03/25/2015 21:00	0.0	0	0	0	0	0
03/25/2015 22:00	0.0	0	0	0	0	0
03/25/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/26/2015 00:00	0.0	0	0	0	0	0
03/26/2015 01:00	0.0	0	0	0	0	0
03/26/2015 02:00	0.0	0	0	0	0	0
03/26/2015 03:00	43.0	1	0	0	0	0
03/26/2015 04:00	34.5	1	0	0	0	0
03/26/2015 05:00	13.6	1	0	0	0	0
03/26/2015 06:00	0.0	0	0	0	0	1
03/26/2015 07:00	0.0	0	0	0	0	1
03/26/2015 08:00	0.0	0	0	0	0	1
03/26/2015 09:00	0.0	0	0	0	0	1
03/26/2015 10:00	0.0	0	0	0	0	1
03/26/2015 11:00	0.0	0	0	0	0	1
03/26/2015 12:00	0.0	0	0	0	0	1
03/26/2015 13:00	0.0	0	0	0	0	1
03/26/2015 14:00	0.0	0	0	0	0	1
03/26/2015 15:00	0.0	0	0	0	0	1
03/26/2015 16:00	0.0	0	0	0	0	1
03/26/2015 17:00	0.0	0	0	0	0	1
03/26/2015 18:00	0.0	0	0	0	0	1
03/26/2015 19:00	0.0	0	0	0	0	1
03/26/2015 20:00	0.0	0	0	0	0	1
03/26/2015 21:00	0.0	0	0	0	0	1
03/26/2015 22:00	0.9	0	0	0	1	0
03/26/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	92.0 #	3 #	0 #	0 #	1 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	43.0	1	0	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/27/2015 00:00	0.0	0	0	0	0	0
03/27/2015 01:00	0.0	0	0	0	0	0
03/27/2015 02:00	0.0	0	0	0	0	0
03/27/2015 03:00	0.0	0	0	0	0	0
03/27/2015 04:00	0.0	0	0	1	0	0
03/27/2015 05:00	63.2	0	0	1	0	0
03/27/2015 06:00	0.0	0	0	0	0	1
03/27/2015 07:00	0.0	0	0	0	0	1
03/27/2015 08:00	0.0	0	0	0	0	1
03/27/2015 09:00	0.0	0	0	0	0	1
03/27/2015 10:00	0.0	0	0	0	0	1
03/27/2015 11:00	0.0	0	0	0	0	1
03/27/2015 12:00	0.0	0	0	0	0	1
03/27/2015 13:00	0.0	0	0	0	0	1
03/27/2015 14:00	0.0	0	0	0	0	1
03/27/2015 15:00	0.0	0	0	0	0	1
03/27/2015 16:00	0.0	0	0	0	0	1
03/27/2015 17:00	0.0	0	0	0	0	1
03/27/2015 18:00	0.0	0	0	0	0	1
03/27/2015 19:00	0.0	0	0	0	0	1
03/27/2015 20:00	1.0	0	0	0	1	0
03/27/2015 21:00	0.0	0	0	0	0	0
03/27/2015 22:00	0.0	0	0	0	0	0
03/27/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	64.2 #	0 #	0 #	2 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	63.2	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/28/2015 00:00	0.0	0	0	0	0	0
03/28/2015 01:00	0.0	0	0	0	0	0
03/28/2015 02:00	0.0	0	0	0	0	0
03/28/2015 03:00	0.0	0	0	0	0	0
03/28/2015 04:00	0.0	0	0	0	0	0
03/28/2015 05:00	0.0	0	0	0	0	0
03/28/2015 06:00	0.0	0	0	0	0	0
03/28/2015 07:00	0.0	0	0	0	0	0
03/28/2015 08:00	0.0	0	0	0	0	0
03/28/2015 09:00	0.0	0	0	0	0	0
03/28/2015 10:00	0.0	0	0	0	0	0
03/28/2015 11:00	0.0	0	0	0	0	0
03/28/2015 12:00	0.0	0	0	0	0	0
03/28/2015 13:00	0.0	0	0	0	0	0
03/28/2015 14:00	0.0	0	0	0	0	0
03/28/2015 15:00	0.0	0	0	0	0	0
03/28/2015 16:00	0.0	0	0	0	0	0
03/28/2015 17:00	0.0	0	0	0	0	0
03/28/2015 18:00	0.0	0	0	0	0	0
03/28/2015 19:00	0.0	0	0	0	0	0
03/28/2015 20:00	0.0	0	0	0	0	0
03/28/2015 21:00	0.0	0	0	0	0	0
03/28/2015 22:00	0.0	0	0	0	0	0
03/28/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/29/2015 00:00	0.0	0	0	0	0	0
03/29/2015 01:00	0.0	0	0	0	0	0
03/29/2015 02:00	0.0	0	0	0	0	0
03/29/2015 03:00	0.0	0	0	0	0	0
03/29/2015 04:00	0.0	0	0	0	0	0
03/29/2015 05:00	0.0	0	0	0	0	0
03/29/2015 06:00	0.0	0	0	0	0	0
03/29/2015 07:00	0.0	0	0	0	0	0
03/29/2015 08:00	0.0	0	0	0	0	0
03/29/2015 09:00	0.0	0	0	0	0	0
03/29/2015 10:00	0.0	0	0	0	0	0
03/29/2015 11:00	0.0	0	0	0	0	0
03/29/2015 12:00	0.0	0	0	0	0	0
03/29/2015 13:00	0.0	0	0	0	0	0
03/29/2015 14:00	0.0	0	0	0	0	0
03/29/2015 15:00	0.0	0	0	0	0	0
03/29/2015 16:00	0.0	0	0	0	0	0
03/29/2015 17:00	0.0	0	0	0	0	0
03/29/2015 18:00	0.0	0	0	0	0	0
03/29/2015 19:00	0.0	0	0	0	0	0
03/29/2015 20:00	0.0	0	0	0	0	0
03/29/2015 21:00	0.0	0	0	0	0	0
03/29/2015 22:00	0.0	0	0	0	0	0
03/29/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/30/2015 00:00	0.0	0	0	0	0	0
03/30/2015 01:00	0.0	0	0	0	0	0
03/30/2015 02:00	0.0	0	0	0	0	0
03/30/2015 03:00	46.4	0	1	0	0	0
03/30/2015 04:00	53.7	0	1	0	0	0
03/30/2015 05:00	19.6	0	1	0	0	0
03/30/2015 06:00	0.0	0	0	0	0	1
03/30/2015 07:00	0.0	0	0	0	0	1
03/30/2015 08:00	0.0	0	0	0	0	1
03/30/2015 09:00	0.0	0	0	0	0	1
03/30/2015 10:00	0.0	0	0	0	0	1
03/30/2015 11:00	0.0	0	0	0	0	1
03/30/2015 12:00	0.0	0	0	0	0	1
03/30/2015 13:00	0.0	0	0	0	0	1
03/30/2015 14:00	0.0	0	0	0	0	1
03/30/2015 15:00	0.0	0	0	0	0	1
03/30/2015 16:00	0.0	0	0	0	0	1
03/30/2015 17:00	0.0	0	0	0	0	1
03/30/2015 18:00	0.0	0	0	0	0	1
03/30/2015 19:00	0.0	0	0	0	0	1
03/30/2015 20:00	1.3	0	0	0	1	0
03/30/2015 21:00	0.0	0	0	0	0	0
03/30/2015 22:00	0.0	0	0	0	0	0
03/30/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	121.0 #	0 #	3 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	53.7	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/31/2015 00:00	0.0	0	0	0	0	0
03/31/2015 01:00	0.0	0	0	0	0	0
03/31/2015 02:00	0.0	0	0	0	0	0
03/31/2015 03:00	0.0	0	0	0	0	0
03/31/2015 04:00	53.0	0	0	1	0	0
03/31/2015 05:00	6.5	0	0	1	0	0
03/31/2015 06:00	0.0	0	0	0	0	1
03/31/2015 07:00	0.0	0	0	0	0	1
03/31/2015 08:00	0.0	0	0	0	0	1
03/31/2015 09:00	0.0	0	0	0	0	1
03/31/2015 10:00	0.0	0	0	0	0	1
03/31/2015 11:00	0.0	0	0	0	0	1
03/31/2015 12:00	0.0	0	0	0	0	1
03/31/2015 13:00	0.0	0	0	0	0	1
03/31/2015 14:00	0.0	0	0	0	0	1
03/31/2015 15:00	0.0	0	0	0	0	1
03/31/2015 16:00	0.0	0	0	0	0	1
03/31/2015 17:00	0.0	0	0	0	0	1
03/31/2015 18:00	0.0	0	0	0	0	1
03/31/2015 19:00	0.0	0	0	0	0	1
03/31/2015 20:00	0.0	0	0	0	0	1
03/31/2015 21:00	1.4	0	0	0	1	0
03/31/2015 22:00	0.0	0	0	0	0	0
03/31/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	60.9 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	53.0	0	0	1	1	1
%SI	0.0	0	0	0	0	0

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:15 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,851.95 Hours

Non-Operating Time: 308.05 Hours Report Time: 2,160.00 Hours

Unit Operation and Excess Events

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
01/18/2015 02:16 01/18/2015 02:24 Shut Down - Gas	9	7.0		
01/18/2015 14:34 01/18/2015 16:03 Warm Start - Gas	90	172.6		
01/25/2015 01:05 01/25/2015 01:12 Shut Down - Gas	8	5.8		
01/25/2015 12:35 01/25/2015 14:15 Warm Start - Gas	101	192.6		
01/25/2015 22:35 01/25/2015 22:43 Shut Down - Gas	9	7.3		
01/26/2015 04:22 01/26/2015 05:26 Hot Start - Gas	65	124.8		
01/31/2015 00:05 01/31/2015 00:12 Shut Down - Gas	8	5.1		
01/31/2015 03:18 01/31/2015 04:36 Hot Start - Gas	79	154.3		
02/01/2015 02:06 02/01/2015 02:13 Shut Down - Gas	8	4.9		
02/01/2015 10:23 02/01/2015 11:59 Warm Start - Gas	97	183.2		
02/15/2015 02:01 02/15/2015 02:09 Shut Down - Gas	9	8.0		
02/15/2015 16:42 02/15/2015 17:35 Warm Start - Gas	54	103.5		
02/20/2015 01:05 02/20/2015 01:13 Shut Down - Gas	9	6.7		

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:15 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,851.95 Hours

Non-Operating Time: 308.05 Hours Report Time: 2,160.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
02/21/2015 15:20 02/21/2015 16:40 Warm Start - Gas	81	154.6		
02/22/2015 06:02 02/22/2015 06:10 Shut Down - Gas	9	6.7		
02/24/2015 03:25 02/24/2015 05:15 Warm Start - Gas	111	210.1		
02/28/2015 01:05 02/28/2015 01:12 Shut Down - Gas	8	5.6		
02/28/2015 08:18 02/28/2015 09:27 Hot Start - Gas	70	133.6		
03/07/2015 02:04 03/07/2015 02:10 Shut Down - Gas	7	3.8		
03/07/2015 10:18 03/07/2015 11:44 Warm Start - Gas	87	165.8		
03/08/2015 08:05 03/08/2015 08:12 Shut Down - Gas	8	5.7		
03/08/2015 14:58 03/08/2015 16:10 Hot Start - Gas	73	145.9		
03/17/2015 11:59 03/17/2015 12:04 Hot Start - Gas	6	20.8		
03/22/2015 23:43 03/22/2015 23:51 Shut Down - Gas	9	7.6		
03/26/2015 03:27 03/26/2015 05:58 Cold Start - Gas	152	255.5		
03/26/2015 22:01 03/26/2015 22:09 Shut Down - Gas	9	6.5		
03/27/2015 04:52 03/27/2015 05:53 Hot Start - Gas	62	111.3		

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:15 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,851.95 Hours

Non-Operating Time: 308.05 Hours Report Time: 2,160.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
03/27/2015 20:31 03/27/2015 20:39 Shut Down - Gas	9	7.6		
03/30/2015 03:27 03/30/2015 05:35 Warm Start - Gas	129	243.1		
03/30/2015 20:17 03/30/2015 20:26 Shut Down - Gas	10	9.8		
03/31/2015 04:22 03/31/2015 05:20 Hot Start - Gas	59	109.4		
03/31/2015 21:17 03/31/2015 21:26 Shut Down - Gas	10	10.3		

No excess emissions were found in the reporting period.

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:15 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,851.95 Hours

Non-Operating Time: 308.05 Hours Report Time: 2,160.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:15 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,851.95 Hours

Non-Operating Time: 308.05 Hours Report Time: 2,160.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Pound Per Event Report

CT1 - NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:18 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,851.95 Hours

Non-Operating Time: 308.05 Hours Report Time: 2,160.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
01/18/2015 02:16 01/18/2015 02:24 Shut Down - Gas	9	1.77	115.00		
01/18/2015 14:34 01/18/2015 16:03 Warm Start - Gas	90	87.19	456.20		
01/25/2015 01:05 01/25/2015 01:12 Shut Down - Gas	8	1.60	115.00		
01/25/2015 12:35 01/25/2015 14:15 Warm Start - Gas	101	106.35	456.20		
01/25/2015 22:35 01/25/2015 22:43 Shut Down - Gas	9	1.60	115.00		
01/26/2015 04:22 01/26/2015 05:26 Hot Start - Gas	65	56.34	259.90		
01/31/2015 00:05 01/31/2015 00:12 Shut Down - Gas	8	1.68	115.00		
01/31/2015 03:18 01/31/2015 04:36 Hot Start - Gas	79	58.65	259.90		
02/01/2015 02:06 02/01/2015 02:13 Shut Down - Gas	8	1.38	115.00		
02/01/2015 10:23 02/01/2015 11:59 Warm Start - Gas	97	103.34	456.20		
02/15/2015 02:01 02/15/2015 02:09 Shut Down - Gas	9	1.84	115.00		
02/15/2015 16:42 02/15/2015 17:35 Warm Start - Gas	54	82.80	456.20		
02/20/2015 01:05 02/20/2015 01:13 Shut Down - Gas	9	1.29	115.00		

Pound Per Event Report

CT1 - NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:18 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,851.95 Hours

Non-Operating Time: 308.05 Hours Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
02/21/2015 15:20 02/21/2015 16:40 Warm Start - Gas	81	99.47	456.20		
02/22/2015 06:02 02/22/2015 06:10 Shut Down - Gas	9	1.95	115.00		
02/24/2015 03:25 02/24/2015 05:15 Warm Start - Gas	111	177.11	456.20		
02/28/2015 01:05 02/28/2015 01:12 Shut Down - Gas	8	1.29	115.00		
02/28/2015 08:18 02/28/2015 09:27 Hot Start - Gas	70	52.47	259.90		
03/07/2015 02:04 03/07/2015 02:10 Shut Down - Gas	7	1.07	115.00		
03/07/2015 10:18 03/07/2015 11:44 Warm Start - Gas	87	74.72	456.20		
03/08/2015 08:05 03/08/2015 08:12 Shut Down - Gas	8	1.24	115.00		
03/08/2015 14:58 03/08/2015 16:10 Hot Start - Gas	73	57.18	259.90		
03/17/2015 11:59 03/17/2015 12:04 Hot Start - Gas	6	0.24	259.90		
03/22/2015 23:43 03/22/2015 23:51 Shut Down - Gas	9	1.81	115.00		
03/26/2015 03:27 03/26/2015 05:58 Cold Start - Gas	152	93.10	779.10		
03/26/2015 22:01 03/26/2015 22:09 Shut Down - Gas	9	1.14	115.00		
03/27/2015 04:52 03/27/2015 05:53 Hot Start - Gas	62	65.11	259.90		

Pound Per Event Report

CT1 - NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:18 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,851.95 Hours

Non-Operating Time: 308.05 Hours Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
03/27/2015 20:31 03/27/2015 20:39 Shut Down - Gas	9	1.57	115.00		
03/30/2015 03:27 03/30/2015 05:35 Warm Start - Gas	129	130.55	456.20		
03/30/2015 20:17 03/30/2015 20:26 Shut Down - Gas	10	1.82	115.00		
03/31/2015 04:22 03/31/2015 05:20 Hot Start - Gas	59	71.02	259.90		
03/31/2015 21:17 03/31/2015 21:26 Shut Down - Gas	10	1.86	115.00		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT1 - NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:18 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,851.95 Hours

Non-Operating Time: 308.05 Hours Report Time: 2,160.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Pound Per Event Report

CT1 - NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:18 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,851.95 Hours

Non-Operating Time: 308.05 Hours Report Time: 2,160.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Pound Per Event Report

CT2 - CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:25 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,851.95 Hours

Non-Operating Time: 308.05 Hours Report Time: 2,160.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
01/16/2015 16:15 01/16/2015 16:21 Shut Down - Gas	7	2.6	483.5		
01/16/2015 17:17 01/16/2015 18:14 Hot Start - Gas	58	55.7	679.6		
01/18/2015 02:20 01/18/2015 02:27 Shut Down - Gas	8	2.6	483.5		
01/18/2015 10:35 01/18/2015 11:50 Warm Start - Gas	76	65.0	790.5		
01/25/2015 01:06 01/25/2015 01:14 Shut Down - Gas	9	2.6	483.5		
01/27/2015 02:08 01/27/2015 04:12 Warm Start - Gas	125	233.8	790.5		
01/27/2015 07:40 01/27/2015 08:54 Hot Start - Gas	75	27.3	679.6		
01/27/2015 09:38 01/27/2015 10:25 Hot Start - Gas	48	15.5	679.6		
02/01/2015 02:05 02/01/2015 02:12 Shut Down - Gas	8	1.8	483.5		
02/01/2015 14:21 02/01/2015 15:33 Warm Start - Gas	73	42.7	790.5		
02/15/2015 02:05 02/15/2015 02:12 Shut Down - Gas	8	2.0	483.5		
02/15/2015 10:23 02/15/2015 11:46 Warm Start - Gas	84	58.3	790.5		
02/20/2015 01:06 02/20/2015 01:14 Shut Down - Gas	9	2.6	483.5		

Pound Per Event Report

CT2 - CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:25 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,851.95 Hours

Non-Operating Time: 308.05 Hours Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
02/20/2015 04:48 02/20/2015 05:30 Hot Start - Gas	43	30.9	679.6		
02/20/2015 12:02 02/20/2015 12:11 Shut Down - Gas	10	2.6	483.5		
02/21/2015 10:16 02/21/2015 12:19 Warm Start - Gas	124	157.0	790.5		
02/22/2015 06:06 02/22/2015 06:13 Shut Down - Gas	8	0.0 SI	483.5		
02/22/2015 14:19 02/22/2015 15:50 Warm Start - Gas	92	70.2	790.5		
02/22/2015 22:23 02/22/2015 22:30 Shut Down - Gas	8	1.8	483.5		
02/23/2015 03:18 02/23/2015 04:24 Hot Start - Gas	67	47.8	679.6		
02/28/2015 01:05 02/28/2015 01:12 Shut Down - Gas	8	1.7	483.5		
02/28/2015 14:46 02/28/2015 15:58 Warm Start - Gas	73	46.5	790.5		
03/07/2015 02:05 03/07/2015 02:11 Shut Down - Gas	7	1.7	483.5		
03/07/2015 14:18 03/07/2015 15:51 Warm Start - Gas	94	76.8	790.5		
03/08/2015 08:05 03/08/2015 08:12 Shut Down - Gas	8	2.1	483.5		
03/08/2015 10:18 03/08/2015 11:31 Hot Start - Gas	74	59.4	679.6		
03/18/2015 09:15 03/18/2015 09:20 Hot Start - Gas	6	0.0 SI	679.6		

Pound Per Event Report

CT2 - CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:25 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,851.95 Hours

Non-Operating Time: 308.05 Hours Report Time: 2,160.00 Hours

Event Period					Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)		Limit	Code - Description	Code - Description
03/18/2015 10:14 03/18/2015 10:19 Hot Start - Gas	6	0.0	SI	679.6		
03/18/2015 11:06 03/18/2015 11:11 Hot Start - Gas	6	0.0	SI	679.6		
03/22/2015 23:03 03/22/2015 23:11 Shut Down - Gas	9	2.3		483.5		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT2 - CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:25 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,851.95 Hours

Non-Operating Time: 308.05 Hours Report Time: 2,160.00 Hours

Event Invalid Information

Invalid Event Period		Reason	Action
Begin/End	Duration in Minute(s)	Code - Description	Code - Description
02/22/2015 06:06 02/22/2015 06:13	8		
03/18/2015 09:15 03/18/2015 09:20	6		
03/18/2015 10:14 03/18/2015 10:19	6		
03/18/2015 11:06 03/18/2015 11:11	6		

Total CMS Downtime	26	Minute(s)
Total Downtime as a percentage of operating time	0.02	%
Total Availability as a percentage of operating time	99.98	%

Pound Per Event Report

CT2 - CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:25 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,851.95 Hours

Non-Operating Time: 308.05 Hours Report Time: 2,160.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	26
2. Total CMS Downtime in Minute(s)	26
3. Total Downtime as a percentage of operating time	0.02
4. Total Availability as a percentage of operating time	99.98

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/01/2015 00:00	0.0	0	0	0	0	1
01/01/2015 01:00	0.0	0	0	0	0	1
01/01/2015 02:00	0.0	0	0	0	0	1
01/01/2015 03:00	0.0	0	0	0	0	1
01/01/2015 04:00	0.0	0	0	0	0	1
01/01/2015 05:00	0.0	0	0	0	0	1
01/01/2015 06:00	0.0	0	0	0	0	1
01/01/2015 07:00	0.0	0	0	0	0	1
01/01/2015 08:00	0.0	0	0	0	0	1
01/01/2015 09:00	0.0	0	0	0	0	1
01/01/2015 10:00	0.0	0	0	0	0	1
01/01/2015 11:00	0.0	0	0	0	0	1
01/01/2015 12:00	0.0	0	0	0	0	1
01/01/2015 13:00	0.0	0	0	0	0	1
01/01/2015 14:00	0.0	0	0	0	0	1
01/01/2015 15:00	0.0	0	0	0	0	1
01/01/2015 16:00	0.0	0	0	0	0	1
01/01/2015 17:00	0.0	0	0	0	0	1
01/01/2015 18:00	0.0	0	0	0	0	1
01/01/2015 19:00	0.0	0	0	0	0	1
01/01/2015 20:00	0.0	0	0	0	0	1
01/01/2015 21:00	0.0	0	0	0	0	1
01/01/2015 22:00	0.0	0	0	0	0	1
01/01/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/02/2015 00:00	0.0	0	0	0	0	1
01/02/2015 01:00	0.0	0	0	0	0	1
01/02/2015 02:00	0.0	0	0	0	0	1
01/02/2015 03:00	0.0	0	0	0	0	1
01/02/2015 04:00	0.0	0	0	0	0	1
01/02/2015 05:00	0.0	0	0	0	0	1
01/02/2015 06:00	0.0	0	0	0	0	1
01/02/2015 07:00	0.0	0	0	0	0	1
01/02/2015 08:00	0.0	0	0	0	0	1
01/02/2015 09:00	0.0	0	0	0	0	1
01/02/2015 10:00	0.0	0	0	0	0	1
01/02/2015 11:00	0.0	0	0	0	0	1
01/02/2015 12:00	0.0	0	0	0	0	1
01/02/2015 13:00	0.0	0	0	0	0	1
01/02/2015 14:00	0.0	0	0	0	0	1
01/02/2015 15:00	0.0	0	0	0	0	1
01/02/2015 16:00	0.0	0	0	0	0	1
01/02/2015 17:00	0.0	0	0	0	0	1
01/02/2015 18:00	0.0	0	0	0	0	1
01/02/2015 19:00	0.0	0	0	0	0	1
01/02/2015 20:00	0.0	0	0	0	0	1
01/02/2015 21:00	0.0	0	0	0	0	1
01/02/2015 22:00	0.0	0	0	0	0	1
01/02/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/03/2015 00:00	0.0	0	0	0	0	1
01/03/2015 01:00	0.0	0	0	0	0	1
01/03/2015 02:00	0.0	0	0	0	0	1
01/03/2015 03:00	0.0	0	0	0	0	1
01/03/2015 04:00	0.0	0	0	0	0	1
01/03/2015 05:00	0.0	0	0	0	0	1
01/03/2015 06:00	0.0	0	0	0	0	1
01/03/2015 07:00	0.0	0	0	0	0	1
01/03/2015 08:00	0.0	0	0	0	0	1
01/03/2015 09:00	0.0	0	0	0	0	1
01/03/2015 10:00	0.0	0	0	0	0	1
01/03/2015 11:00	0.0	0	0	0	0	1
01/03/2015 12:00	0.0	0	0	0	0	1
01/03/2015 13:00	0.0	0	0	0	0	1
01/03/2015 14:00	0.0	0	0	0	0	1
01/03/2015 15:00	0.0	0	0	0	0	1
01/03/2015 16:00	0.0	0	0	0	0	1
01/03/2015 17:00	0.0	0	0	0	0	1
01/03/2015 18:00	0.0	0	0	0	0	1
01/03/2015 19:00	0.0	0	0	0	0	1
01/03/2015 20:00	0.0	0	0	0	0	1
01/03/2015 21:00	0.0	0	0	0	0	1
01/03/2015 22:00	0.0	0	0	0	0	1
01/03/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/04/2015 00:00	0.0	0	0	0	0	1
01/04/2015 01:00	0.0	0	0	0	0	1
01/04/2015 02:00	0.0	0	0	0	0	1
01/04/2015 03:00	0.0	0	0	0	0	1
01/04/2015 04:00	0.0	0	0	0	0	1
01/04/2015 05:00	0.0	0	0	0	0	1
01/04/2015 06:00	0.0	0	0	0	0	1
01/04/2015 07:00	0.0	0	0	0	0	1
01/04/2015 08:00	0.0	0	0	0	0	1
01/04/2015 09:00	0.0	0	0	0	0	1
01/04/2015 10:00	0.0	0	0	0	0	1
01/04/2015 11:00	0.0	0	0	0	0	1
01/04/2015 12:00	0.0	0	0	0	0	1
01/04/2015 13:00	0.0	0	0	0	0	1
01/04/2015 14:00	0.0	0	0	0	0	1
01/04/2015 15:00	0.0	0	0	0	0	1
01/04/2015 16:00	0.0	0	0	0	0	1
01/04/2015 17:00	0.0	0	0	0	0	1
01/04/2015 18:00	0.0	0	0	0	0	1
01/04/2015 19:00	0.0	0	0	0	0	1
01/04/2015 20:00	0.0	0	0	0	0	1
01/04/2015 21:00	0.0	0	0	0	0	1
01/04/2015 22:00	0.0	0	0	0	0	1
01/04/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/05/2015 00:00	0.0	0	0	0	0	1
01/05/2015 01:00	0.0	0	0	0	0	1
01/05/2015 02:00	0.0	0	0	0	0	1
01/05/2015 03:00	0.0	0	0	0	0	1
01/05/2015 04:00	0.0	0	0	0	0	1
01/05/2015 05:00	0.0	0	0	0	0	1
01/05/2015 06:00	0.0	0	0	0	0	1
01/05/2015 07:00	0.0	0	0	0	0	1
01/05/2015 08:00	0.0	0	0	0	0	1
01/05/2015 09:00	0.0	0	0	0	0	1
01/05/2015 10:00	0.0	0	0	0	0	1
01/05/2015 11:00	0.0	0	0	0	0	1
01/05/2015 12:00	0.0	0	0	0	0	1
01/05/2015 13:00	0.0	0	0	0	0	1
01/05/2015 14:00	0.0	0	0	0	0	1
01/05/2015 15:00	0.0	0	0	0	0	1
01/05/2015 16:00	0.0	0	0	0	0	1
01/05/2015 17:00	0.0	0	0	0	0	1
01/05/2015 18:00	0.0	0	0	0	0	1
01/05/2015 19:00	0.0	0	0	0	0	1
01/05/2015 20:00	0.0	0	0	0	0	1
01/05/2015 21:00	0.0	0	0	0	0	1
01/05/2015 22:00	0.0	0	0	0	0	1
01/05/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/06/2015 00:00	0.0	0	0	0	0	1
01/06/2015 01:00	0.0	0	0	0	0	1
01/06/2015 02:00	0.0	0	0	0	0	1
01/06/2015 03:00	0.0	0	0	0	0	1
01/06/2015 04:00	0.0	0	0	0	0	1
01/06/2015 05:00	0.0	0	0	0	0	1
01/06/2015 06:00	0.0	0	0	0	0	1
01/06/2015 07:00	0.0	0	0	0	0	1
01/06/2015 08:00	0.0	0	0	0	0	1
01/06/2015 09:00	0.0	0	0	0	0	1
01/06/2015 10:00	0.0	0	0	0	0	1
01/06/2015 11:00	0.0	0	0	0	0	1
01/06/2015 12:00	0.0	0	0	0	0	1
01/06/2015 13:00	0.0	0	0	0	0	1
01/06/2015 14:00	0.0	0	0	0	0	1
01/06/2015 15:00	0.0	0	0	0	0	1
01/06/2015 16:00	0.0	0	0	0	0	1
01/06/2015 17:00	0.0	0	0	0	0	1
01/06/2015 18:00	0.0	0	0	0	0	1
01/06/2015 19:00	0.0	0	0	0	0	1
01/06/2015 20:00	0.0	0	0	0	0	1
01/06/2015 21:00	0.0	0	0	0	0	1
01/06/2015 22:00	0.0	0	0	0	0	1
01/06/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/07/2015 00:00	0.0	0	0	0	0	1
01/07/2015 01:00	0.0	0	0	0	0	1
01/07/2015 02:00	0.0	0	0	0	0	1
01/07/2015 03:00	0.0	0	0	0	0	1
01/07/2015 04:00	0.0	0	0	0	0	1
01/07/2015 05:00	0.0	0	0	0	0	1
01/07/2015 06:00	0.0	0	0	0	0	1
01/07/2015 07:00	0.0	0	0	0	0	1
01/07/2015 08:00	0.0	0	0	0	0	1
01/07/2015 09:00	0.0	0	0	0	0	1
01/07/2015 10:00	0.0	0	0	0	0	1
01/07/2015 11:00	0.0	0	0	0	0	1
01/07/2015 12:00	0.0	0	0	0	0	1
01/07/2015 13:00	0.0	0	0	0	0	1
01/07/2015 14:00	0.0	0	0	0	0	1
01/07/2015 15:00	0.0	0	0	0	0	1
01/07/2015 16:00	0.0	0	0	0	0	1
01/07/2015 17:00	0.0	0	0	0	0	1
01/07/2015 18:00	0.0	0	0	0	0	1
01/07/2015 19:00	0.0	0	0	0	0	1
01/07/2015 20:00	0.0	0	0	0	0	1
01/07/2015 21:00	0.0	0	0	0	0	1
01/07/2015 22:00	0.0	0	0	0	0	1
01/07/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/08/2015 00:00	0.0	0	0	0	0	1
01/08/2015 01:00	0.0	0	0	0	0	1
01/08/2015 02:00	0.0	0	0	0	0	1
01/08/2015 03:00	0.0	0	0	0	0	1
01/08/2015 04:00	0.0	0	0	0	0	1
01/08/2015 05:00	0.0	0	0	0	0	1
01/08/2015 06:00	0.0	0	0	0	0	1
01/08/2015 07:00	0.0	0	0	0	0	1
01/08/2015 08:00	0.0	0	0	0	0	1
01/08/2015 09:00	0.0	0	0	0	0	1
01/08/2015 10:00	0.0	0	0	0	0	1
01/08/2015 11:00	0.0	0	0	0	0	1
01/08/2015 12:00	0.0	0	0	0	0	1
01/08/2015 13:00	0.0	0	0	0	0	1
01/08/2015 14:00	0.0	0	0	0	0	1
01/08/2015 15:00	0.0	0	0	0	0	1
01/08/2015 16:00	0.0	0	0	0	0	1
01/08/2015 17:00	0.0	0	0	0	0	1
01/08/2015 18:00	0.0	0	0	0	0	1
01/08/2015 19:00	0.0	0	0	0	0	1
01/08/2015 20:00	0.0	0	0	0	0	1
01/08/2015 21:00	0.0	0	0	0	0	1
01/08/2015 22:00	0.0	0	0	0	0	1
01/08/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/09/2015 00:00	0.0	0	0	0	0	1
01/09/2015 01:00	0.0	0	0	0	0	1
01/09/2015 02:00	0.0	0	0	0	0	1
01/09/2015 03:00	0.0	0	0	0	0	1
01/09/2015 04:00	0.0	0	0	0	0	1
01/09/2015 05:00	0.0	0	0	0	0	1
01/09/2015 06:00	0.0	0	0	0	0	1
01/09/2015 07:00	0.0	0	0	0	0	1
01/09/2015 08:00	0.0	0	0	0	0	1
01/09/2015 09:00	0.0	0	0	0	0	1
01/09/2015 10:00	0.0	0	0	0	0	1
01/09/2015 11:00	0.0	0	0	0	0	1
01/09/2015 12:00	0.0	0	0	0	0	1
01/09/2015 13:00	0.0	0	0	0	0	1
01/09/2015 14:00	0.0	0	0	0	0	1
01/09/2015 15:00	0.0	0	0	0	0	1
01/09/2015 16:00	0.0	0	0	0	0	1
01/09/2015 17:00	0.0	0	0	0	0	1
01/09/2015 18:00	0.0	0	0	0	0	1
01/09/2015 19:00	0.0	0	0	0	0	1
01/09/2015 20:00	0.0	0	0	0	0	1
01/09/2015 21:00	0.0	0	0	0	0	1
01/09/2015 22:00	0.0	0	0	0	0	1
01/09/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/10/2015 00:00	0.0	0	0	0	0	1
01/10/2015 01:00	0.0	0	0	0	0	1
01/10/2015 02:00	0.0	0	0	0	0	1
01/10/2015 03:00	0.0	0	0	0	0	1
01/10/2015 04:00	0.0	0	0	0	0	1
01/10/2015 05:00	0.0	0	0	0	0	1
01/10/2015 06:00	0.0	0	0	0	0	1
01/10/2015 07:00	0.0	0	0	0	0	1
01/10/2015 08:00	0.0	0	0	0	0	1
01/10/2015 09:00	0.0	0	0	0	0	1
01/10/2015 10:00	0.0	0	0	0	0	1
01/10/2015 11:00	0.0	0	0	0	0	1
01/10/2015 12:00	0.0	0	0	0	0	1
01/10/2015 13:00	0.0	0	0	0	0	1
01/10/2015 14:00	0.0	0	0	0	0	1
01/10/2015 15:00	0.0	0	0	0	0	1
01/10/2015 16:00	0.0	0	0	0	0	1
01/10/2015 17:00	0.0	0	0	0	0	1
01/10/2015 18:00	0.0	0	0	0	0	1
01/10/2015 19:00	0.0	0	0	0	0	1
01/10/2015 20:00	0.0	0	0	0	0	1
01/10/2015 21:00	0.0	0	0	0	0	1
01/10/2015 22:00	0.0	0	0	0	0	1
01/10/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/11/2015 00:00	0.0	0	0	0	0	1
01/11/2015 01:00	0.0	0	0	0	0	1
01/11/2015 02:00	0.0	0	0	0	0	1
01/11/2015 03:00	0.0	0	0	0	0	1
01/11/2015 04:00	0.0	0	0	0	0	1
01/11/2015 05:00	0.0	0	0	0	0	1
01/11/2015 06:00	0.0	0	0	0	0	1
01/11/2015 07:00	0.0	0	0	0	0	1
01/11/2015 08:00	0.0	0	0	0	0	1
01/11/2015 09:00	0.0	0	0	0	0	1
01/11/2015 10:00	0.0	0	0	0	0	1
01/11/2015 11:00	0.0	0	0	0	0	1
01/11/2015 12:00	0.0	0	0	0	0	1
01/11/2015 13:00	0.0	0	0	0	0	1
01/11/2015 14:00	0.0	0	0	0	0	1
01/11/2015 15:00	0.0	0	0	0	0	1
01/11/2015 16:00	0.0	0	0	0	0	1
01/11/2015 17:00	0.0	0	0	0	0	1
01/11/2015 18:00	0.0	0	0	0	0	1
01/11/2015 19:00	0.0	0	0	0	0	1
01/11/2015 20:00	0.0	0	0	0	0	1
01/11/2015 21:00	0.0	0	0	0	0	1
01/11/2015 22:00	0.0	0	0	0	0	1
01/11/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/12/2015 00:00	0.0	0	0	0	0	1
01/12/2015 01:00	0.0	0	0	0	0	1
01/12/2015 02:00	0.0	0	0	0	0	1
01/12/2015 03:00	0.0	0	0	0	0	1
01/12/2015 04:00	0.0	0	0	0	0	1
01/12/2015 05:00	0.0	0	0	0	0	1
01/12/2015 06:00	0.0	0	0	0	0	1
01/12/2015 07:00	0.0	0	0	0	0	1
01/12/2015 08:00	0.0	0	0	0	0	1
01/12/2015 09:00	0.0	0	0	0	0	1
01/12/2015 10:00	0.0	0	0	0	0	1
01/12/2015 11:00	0.0	0	0	0	0	1
01/12/2015 12:00	0.0	0	0	0	0	1
01/12/2015 13:00	0.0	0	0	0	0	1
01/12/2015 14:00	0.0	0	0	0	0	1
01/12/2015 15:00	0.0	0	0	0	0	1
01/12/2015 16:00	0.0	0	0	0	0	1
01/12/2015 17:00	0.0	0	0	0	0	1
01/12/2015 18:00	0.0	0	0	0	0	1
01/12/2015 19:00	0.0	0	0	0	0	1
01/12/2015 20:00	0.0	0	0	0	0	1
01/12/2015 21:00	0.0	0	0	0	0	1
01/12/2015 22:00	0.0	0	0	0	0	1
01/12/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/13/2015 00:00	0.0	0	0	0	0	1
01/13/2015 01:00	0.0	0	0	0	0	1
01/13/2015 02:00	0.0	0	0	0	0	1
01/13/2015 03:00	0.0	0	0	0	0	1
01/13/2015 04:00	0.0	0	0	0	0	1
01/13/2015 05:00	0.0	0	0	0	0	1
01/13/2015 06:00	0.0	0	0	0	0	1
01/13/2015 07:00	0.0	0	0	0	0	1
01/13/2015 08:00	0.0	0	0	0	0	1
01/13/2015 09:00	0.0	0	0	0	0	1
01/13/2015 10:00	0.0	0	0	0	0	1
01/13/2015 11:00	0.0	0	0	0	0	1
01/13/2015 12:00	0.0	0	0	0	0	1
01/13/2015 13:00	0.0	0	0	0	0	1
01/13/2015 14:00	0.0	0	0	0	0	1
01/13/2015 15:00	0.0	0	0	0	0	1
01/13/2015 16:00	0.0	0	0	0	0	1
01/13/2015 17:00	0.0	0	0	0	0	1
01/13/2015 18:00	0.0	0	0	0	0	1
01/13/2015 19:00	0.0	0	0	0	0	1
01/13/2015 20:00	0.0	0	0	0	0	1
01/13/2015 21:00	0.0	0	0	0	0	1
01/13/2015 22:00	0.0	0	0	0	0	1
01/13/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/14/2015 00:00	0.0	0	0	0	0	1
01/14/2015 01:00	0.0	0	0	0	0	1
01/14/2015 02:00	0.0	0	0	0	0	1
01/14/2015 03:00	0.0	0	0	0	0	1
01/14/2015 04:00	0.0	0	0	0	0	1
01/14/2015 05:00	0.0	0	0	0	0	1
01/14/2015 06:00	0.0	0	0	0	0	1
01/14/2015 07:00	0.0	0	0	0	0	1
01/14/2015 08:00	0.0	0	0	0	0	1
01/14/2015 09:00	0.0	0	0	0	0	1
01/14/2015 10:00	0.0	0	0	0	0	1
01/14/2015 11:00	0.0	0	0	0	0	1
01/14/2015 12:00	0.0	0	0	0	0	1
01/14/2015 13:00	0.0	0	0	0	0	1
01/14/2015 14:00	0.0	0	0	0	0	1
01/14/2015 15:00	0.0	0	0	0	0	1
01/14/2015 16:00	0.0	0	0	0	0	1
01/14/2015 17:00	0.0	0	0	0	0	1
01/14/2015 18:00	0.0	0	0	0	0	1
01/14/2015 19:00	0.0	0	0	0	0	1
01/14/2015 20:00	0.0	0	0	0	0	1
01/14/2015 21:00	0.0	0	0	0	0	1
01/14/2015 22:00	0.0	0	0	0	0	1
01/14/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/15/2015 00:00	0.0	0	0	0	0	1
01/15/2015 01:00	0.0	0	0	0	0	1
01/15/2015 02:00	0.0	0	0	0	0	1
01/15/2015 03:00	0.0	0	0	0	0	1
01/15/2015 04:00	0.0	0	0	0	0	1
01/15/2015 05:00	0.0	0	0	0	0	1
01/15/2015 06:00	0.0	0	0	0	0	1
01/15/2015 07:00	0.0	0	0	0	0	1
01/15/2015 08:00	0.0	0	0	0	0	1
01/15/2015 09:00	0.0	0	0	0	0	1
01/15/2015 10:00	0.0	0	0	0	0	1
01/15/2015 11:00	0.0	0	0	0	0	1
01/15/2015 12:00	0.0	0	0	0	0	1
01/15/2015 13:00	0.0	0	0	0	0	1
01/15/2015 14:00	0.0	0	0	0	0	1
01/15/2015 15:00	0.0	0	0	0	0	1
01/15/2015 16:00	0.0	0	0	0	0	1
01/15/2015 17:00	0.0	0	0	0	0	1
01/15/2015 18:00	0.0	0	0	0	0	1
01/15/2015 19:00	0.0	0	0	0	0	1
01/15/2015 20:00	0.0	0	0	0	0	1
01/15/2015 21:00	0.0	0	0	0	0	1
01/15/2015 22:00	0.0	0	0	0	0	1
01/15/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/16/2015 00:00	0.0	0	0	0	0	1
01/16/2015 01:00	0.0	0	0	0	0	1
01/16/2015 02:00	0.0	0	0	0	0	1
01/16/2015 03:00	0.0	0	0	0	0	1
01/16/2015 04:00	0.0	0	0	0	0	1
01/16/2015 05:00	0.0	0	0	0	0	1
01/16/2015 06:00	0.0	0	0	0	0	1
01/16/2015 07:00	0.0	0	0	0	0	1
01/16/2015 08:00	0.0	0	0	0	0	1
01/16/2015 09:00	0.0	0	0	0	0	1
01/16/2015 10:00	0.0	0	0	0	0	1
01/16/2015 11:00	0.0	0	0	0	0	1
01/16/2015 12:00	0.0	0	0	0	0	1
01/16/2015 13:00	0.0	0	0	0	0	1
01/16/2015 14:00	0.0	0	0	0	0	1
01/16/2015 15:00	0.0	0	0	0	0	1
01/16/2015 16:00	2.4	0	0	0	1	0
01/16/2015 17:00	48.7	0	0	1	0	0
01/16/2015 18:00	2.0	0	0	1	0	0
01/16/2015 19:00	0.0	0	0	0	0	1
01/16/2015 20:00	0.0	0	0	0	0	1
01/16/2015 21:00	0.0	0	0	0	0	1
01/16/2015 22:00	0.0	0	0	0	0	1
01/16/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	53.1 #	0 #	0 #	2 #	1 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	48.7	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/17/2015 00:00	0.0	0	0	0	0	1
01/17/2015 01:00	0.0	0	0	0	0	1
01/17/2015 02:00	0.0	0	0	0	0	1
01/17/2015 03:00	0.0	0	0	0	0	1
01/17/2015 04:00	0.0	0	0	0	0	1
01/17/2015 05:00	0.0	0	0	0	0	1
01/17/2015 06:00	0.0	0	0	0	0	1
01/17/2015 07:00	0.0	0	0	0	0	1
01/17/2015 08:00	0.0	0	0	0	0	1
01/17/2015 09:00	0.0	0	0	0	0	1
01/17/2015 10:00	0.0	0	0	0	0	1
01/17/2015 11:00	0.0	0	0	0	0	1
01/17/2015 12:00	0.0	0	0	0	0	1
01/17/2015 13:00	0.0	0	0	0	0	1
01/17/2015 14:00	0.0	0	0	0	0	1
01/17/2015 15:00	0.0	0	0	0	0	1
01/17/2015 16:00	0.0	0	0	0	0	1
01/17/2015 17:00	0.0	0	0	0	0	1
01/17/2015 18:00	0.0	0	0	0	0	1
01/17/2015 19:00	0.0	0	0	0	0	1
01/17/2015 20:00	0.0	0	0	0	0	1
01/17/2015 21:00	0.0	0	0	0	0	1
01/17/2015 22:00	0.0	0	0	0	0	1
01/17/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/18/2015 00:00	0.0	0	0	0	0	1
01/18/2015 01:00	0.0	0	0	0	0	1
01/18/2015 02:00	2.1	0	0	0	1	0
01/18/2015 03:00	0.0	0	0	0	0	0
01/18/2015 04:00	0.0	0	0	0	0	0
01/18/2015 05:00	0.0	0	0	0	0	0
01/18/2015 06:00	0.0	0	0	0	0	0
01/18/2015 07:00	0.0	0	0	0	0	0
01/18/2015 08:00	0.0	0	0	0	0	0
01/18/2015 09:00	0.0	0	0	0	0	0
01/18/2015 10:00	15.4	0	1	0	0	0
01/18/2015 11:00	47.4	0	1	0	0	0
01/18/2015 12:00	0.0	0	0	0	0	1
01/18/2015 13:00	0.0	0	0	0	0	1
01/18/2015 14:00	0.0	0	0	0	0	1
01/18/2015 15:00	0.0	0	0	0	0	1
01/18/2015 16:00	0.0	0	0	0	0	1
01/18/2015 17:00	0.0	0	0	0	0	1
01/18/2015 18:00	0.0	0	0	0	0	1
01/18/2015 19:00	0.0	0	0	0	0	1
01/18/2015 20:00	0.0	0	0	0	0	1
01/18/2015 21:00	0.0	0	0	0	0	1
01/18/2015 22:00	0.0	0	0	0	0	1
01/18/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	64.9 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	47.4	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/19/2015 00:00	0.0	0	0	0	0	1
01/19/2015 01:00	0.0	0	0	0	0	1
01/19/2015 02:00	0.0	0	0	0	0	1
01/19/2015 03:00	0.0	0	0	0	0	1
01/19/2015 04:00	0.0	0	0	0	0	1
01/19/2015 05:00	0.0	0	0	0	0	1
01/19/2015 06:00	0.0	0	0	0	0	1
01/19/2015 07:00	0.0	0	0	0	0	1
01/19/2015 08:00	0.0	0	0	0	0	1
01/19/2015 09:00	0.0	0	0	0	0	1
01/19/2015 10:00	0.0	0	0	0	0	1
01/19/2015 11:00	0.0	0	0	0	0	1
01/19/2015 12:00	0.0	0	0	0	0	1
01/19/2015 13:00	0.0	0	0	0	0	1
01/19/2015 14:00	0.0	0	0	0	0	1
01/19/2015 15:00	0.0	0	0	0	0	1
01/19/2015 16:00	0.0	0	0	0	0	1
01/19/2015 17:00	0.0	0	0	0	0	1
01/19/2015 18:00	0.0	0	0	0	0	1
01/19/2015 19:00	0.0	0	0	0	0	1
01/19/2015 20:00	0.0	0	0	0	0	1
01/19/2015 21:00	0.0	0	0	0	0	1
01/19/2015 22:00	0.0	0	0	0	0	1
01/19/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/20/2015 00:00	0.0	0	0	0	0	1
01/20/2015 01:00	0.0	0	0	0	0	1
01/20/2015 02:00	0.0	0	0	0	0	1
01/20/2015 03:00	0.0	0	0	0	0	1
01/20/2015 04:00	0.0	0	0	0	0	1
01/20/2015 05:00	0.0	0	0	0	0	1
01/20/2015 06:00	0.0	0	0	0	0	1
01/20/2015 07:00	0.0	0	0	0	0	1
01/20/2015 08:00	0.0	0	0	0	0	1
01/20/2015 09:00	0.0	0	0	0	0	1
01/20/2015 10:00	0.0	0	0	0	0	1
01/20/2015 11:00	0.0	0	0	0	0	1
01/20/2015 12:00	0.0	0	0	0	0	1
01/20/2015 13:00	0.0	0	0	0	0	1
01/20/2015 14:00	0.0	0	0	0	0	1
01/20/2015 15:00	0.0	0	0	0	0	1
01/20/2015 16:00	0.0	0	0	0	0	1
01/20/2015 17:00	0.0	0	0	0	0	1
01/20/2015 18:00	0.0	0	0	0	0	1
01/20/2015 19:00	0.0	0	0	0	0	1
01/20/2015 20:00	0.0	0	0	0	0	1
01/20/2015 21:00	0.0	0	0	0	0	1
01/20/2015 22:00	0.0	0	0	0	0	1
01/20/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/21/2015 00:00	0.0	0	0	0	0	1
01/21/2015 01:00	0.0	0	0	0	0	1
01/21/2015 02:00	0.0	0	0	0	0	1
01/21/2015 03:00	0.0	0	0	0	0	1
01/21/2015 04:00	0.0	0	0	0	0	1
01/21/2015 05:00	0.0	0	0	0	0	1
01/21/2015 06:00	0.0	0	0	0	0	1
01/21/2015 07:00	0.0	0	0	0	0	1
01/21/2015 08:00	0.0	0	0	0	0	1
01/21/2015 09:00	0.0	0	0	0	0	1
01/21/2015 10:00	0.0	0	0	0	0	1
01/21/2015 11:00	0.0	0	0	0	0	1
01/21/2015 12:00	0.0	0	0	0	0	1
01/21/2015 13:00	0.0	0	0	0	0	1
01/21/2015 14:00	0.0	0	0	0	0	1
01/21/2015 15:00	0.0	0	0	0	0	1
01/21/2015 16:00	0.0	0	0	0	0	1
01/21/2015 17:00	0.0	0	0	0	0	1
01/21/2015 18:00	0.0	0	0	0	0	1
01/21/2015 19:00	0.0	0	0	0	0	1
01/21/2015 20:00	0.0	0	0	0	0	1
01/21/2015 21:00	0.0	0	0	0	0	1
01/21/2015 22:00	0.0	0	0	0	0	1
01/21/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/22/2015 00:00	0.0	0	0	0	0	1
01/22/2015 01:00	0.0	0	0	0	0	1
01/22/2015 02:00	0.0	0	0	0	0	1
01/22/2015 03:00	0.0	0	0	0	0	1
01/22/2015 04:00	0.0	0	0	0	0	1
01/22/2015 05:00	0.0	0	0	0	0	1
01/22/2015 06:00	0.0	0	0	0	0	1
01/22/2015 07:00	0.0	0	0	0	0	1
01/22/2015 08:00	0.0	0	0	0	0	1
01/22/2015 09:00	0.0	0	0	0	0	1
01/22/2015 10:00	0.0	0	0	0	0	1
01/22/2015 11:00	0.0	0	0	0	0	1
01/22/2015 12:00	0.0	0	0	0	0	1
01/22/2015 13:00	0.0	0	0	0	0	1
01/22/2015 14:00	0.0	0	0	0	0	1
01/22/2015 15:00	0.0	0	0	0	0	1
01/22/2015 16:00	0.0	0	0	0	0	1
01/22/2015 17:00	0.0	0	0	0	0	1
01/22/2015 18:00	0.0	0	0	0	0	1
01/22/2015 19:00	0.0	0	0	0	0	1
01/22/2015 20:00	0.0	0	0	0	0	1
01/22/2015 21:00	0.0	0	0	0	0	1
01/22/2015 22:00	0.0	0	0	0	0	1
01/22/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/23/2015 00:00	0.0	0	0	0	0	1
01/23/2015 01:00	0.0	0	0	0	0	1
01/23/2015 02:00	0.0	0	0	0	0	1
01/23/2015 03:00	0.0	0	0	0	0	1
01/23/2015 04:00	0.0	0	0	0	0	1
01/23/2015 05:00	0.0	0	0	0	0	1
01/23/2015 06:00	0.0	0	0	0	0	1
01/23/2015 07:00	0.0	0	0	0	0	1
01/23/2015 08:00	0.0	0	0	0	0	1
01/23/2015 09:00	0.0	0	0	0	0	1
01/23/2015 10:00	0.0	0	0	0	0	1
01/23/2015 11:00	0.0	0	0	0	0	1
01/23/2015 12:00	0.0	0	0	0	0	1
01/23/2015 13:00	0.0	0	0	0	0	1
01/23/2015 14:00	0.0	0	0	0	0	1
01/23/2015 15:00	0.0	0	0	0	0	1
01/23/2015 16:00	0.0	0	0	0	0	1
01/23/2015 17:00	0.0	0	0	0	0	1
01/23/2015 18:00	0.0	0	0	0	0	1
01/23/2015 19:00	0.0	0	0	0	0	1
01/23/2015 20:00	0.0	0	0	0	0	1
01/23/2015 21:00	0.0	0	0	0	0	1
01/23/2015 22:00	0.0	0	0	0	0	1
01/23/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/24/2015 00:00	0.0	0	0	0	0	1
01/24/2015 01:00	0.0	0	0	0	0	1
01/24/2015 02:00	0.0	0	0	0	0	1
01/24/2015 03:00	0.0	0	0	0	0	1
01/24/2015 04:00	0.0	0	0	0	0	1
01/24/2015 05:00	0.0	0	0	0	0	1
01/24/2015 06:00	0.0	0	0	0	0	1
01/24/2015 07:00	0.0	0	0	0	0	1
01/24/2015 08:00	0.0	0	0	0	0	1
01/24/2015 09:00	0.0	0	0	0	0	1
01/24/2015 10:00	0.0	0	0	0	0	1
01/24/2015 11:00	0.0	0	0	0	0	1
01/24/2015 12:00	0.0	0	0	0	0	1
01/24/2015 13:00	0.0	0	0	0	0	1
01/24/2015 14:00	0.0	0	0	0	0	1
01/24/2015 15:00	0.0	0	0	0	0	1
01/24/2015 16:00	0.0	0	0	0	0	1
01/24/2015 17:00	0.0	0	0	0	0	1
01/24/2015 18:00	0.0	0	0	0	0	1
01/24/2015 19:00	0.0	0	0	0	0	1
01/24/2015 20:00	0.0	0	0	0	0	1
01/24/2015 21:00	0.0	0	0	0	0	1
01/24/2015 22:00	0.0	0	0	0	0	1
01/24/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/25/2015 00:00	0.0	0	0	0	0	1
01/25/2015 01:00	3.4	0	0	0	1	0
01/25/2015 02:00	0.0	0	0	0	0	0
01/25/2015 03:00	0.0	0	0	0	0	0
01/25/2015 04:00	0.0	0	0	0	0	0
01/25/2015 05:00	0.0	0	0	0	0	0
01/25/2015 06:00	0.0	0	0	0	0	0
01/25/2015 07:00	0.0	0	0	0	0	0
01/25/2015 08:00	0.0	0	0	0	0	0
01/25/2015 09:00	0.0	0	0	0	0	0
01/25/2015 10:00	0.0	0	0	0	0	0
01/25/2015 11:00	0.0	0	0	0	0	0
01/25/2015 12:00	0.0	0	0	0	0	0
01/25/2015 13:00	0.0	0	0	0	0	0
01/25/2015 14:00	0.0	0	0	0	0	0
01/25/2015 15:00	0.0	0	0	0	0	0
01/25/2015 16:00	0.0	0	0	0	0	0
01/25/2015 17:00	0.0	0	0	0	0	0
01/25/2015 18:00	0.0	0	0	0	0	0
01/25/2015 19:00	0.0	0	0	0	0	0
01/25/2015 20:00	0.0	0	0	0	0	0
01/25/2015 21:00	0.0	0	0	0	0	0
01/25/2015 22:00	0.0	0	0	0	0	0
01/25/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	3.4 #	0 #	0 #	0 #	1 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3.4	0	0	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/26/2015 00:00	0.0	0	0	0	0	0
01/26/2015 01:00	0.0	0	0	0	0	0
01/26/2015 02:00	0.0	0	0	0	0	0
01/26/2015 03:00	0.0	0	0	0	0	0
01/26/2015 04:00	0.0	0	0	0	0	0
01/26/2015 05:00	0.0	0	0	0	0	0
01/26/2015 06:00	0.0	0	0	0	0	0
01/26/2015 07:00	0.0	0	0	0	0	0
01/26/2015 08:00	0.0	0	0	0	0	0
01/26/2015 09:00	0.0	0	0	0	0	0
01/26/2015 10:00	0.0	0	0	0	0	0
01/26/2015 11:00	0.0	0	0	0	0	0
01/26/2015 12:00	0.0	0	0	0	0	0
01/26/2015 13:00	0.0	0	0	0	0	0
01/26/2015 14:00	0.0	0	0	0	0	0
01/26/2015 15:00	0.0	0	0	0	0	0
01/26/2015 16:00	0.0	0	0	0	0	0
01/26/2015 17:00	0.0	0	0	0	0	0
01/26/2015 18:00	0.0	0	0	0	0	0
01/26/2015 19:00	0.0	0	0	0	0	0
01/26/2015 20:00	0.0	0	0	0	0	0
01/26/2015 21:00	0.0	0	0	0	0	0
01/26/2015 22:00	0.0	0	0	0	0	0
01/26/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/27/2015 00:00	0.0	0	0	0	0	0
01/27/2015 01:00	0.0	0	0	0	0	0
01/27/2015 02:00	127.0	0	1	0	0	0
01/27/2015 03:00	53.3	0	1	0	0	0
01/27/2015 04:00	9.3	0	1	0	0	0
01/27/2015 05:00	0.0	0	0	0	0	0
01/27/2015 06:00	0.0	0	0	0	0	0
01/27/2015 07:00	7.0	0	0	1	0	0
01/27/2015 08:00	20.1	0	0	1	0	0
01/27/2015 09:00	14.4	0	0	1	0	0
01/27/2015 10:00	2.9	0	0	1	0	0
01/27/2015 11:00	0.0	0	0	0	0	1
01/27/2015 12:00	0.0	0	0	0	0	1
01/27/2015 13:00	0.0	0	0	0	0	1
01/27/2015 14:00	0.0	0	0	0	0	1
01/27/2015 15:00	0.0	0	0	0	0	1
01/27/2015 16:00	0.0	0	0	0	0	1
01/27/2015 17:00	0.0	0	0	0	0	1
01/27/2015 18:00	0.0	0	0	0	0	1
01/27/2015 19:00	0.0	0	0	0	0	1
01/27/2015 20:00	0.0	0	0	0	0	1
01/27/2015 21:00	0.0	0	0	0	0	1
01/27/2015 22:00	0.0	0	0	0	0	1
01/27/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	234.0 #	0 #	3 #	4 #	0 #	13 #
Minimum:	0.0	0	0	0	0	0
Maximum:	127.0	0	1	1	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/28/2015 00:00	0.0	0	0	0	0	1
01/28/2015 01:00	0.0	0	0	0	0	1
01/28/2015 02:00	0.0	0	0	0	0	1
01/28/2015 03:00	0.0	0	0	0	0	1
01/28/2015 04:00	0.0	0	0	0	0	1
01/28/2015 05:00	0.0	0	0	0	0	1
01/28/2015 06:00	0.0	0	0	0	0	1
01/28/2015 07:00	0.0	0	0	0	0	1
01/28/2015 08:00	0.0	0	0	0	0	1
01/28/2015 09:00	0.0	0	0	0	0	1
01/28/2015 10:00	0.0	0	0	0	0	1
01/28/2015 11:00	0.0	0	0	0	0	1
01/28/2015 12:00	0.0	0	0	0	0	1
01/28/2015 13:00	0.0	0	0	0	0	1
01/28/2015 14:00	0.0	0	0	0	0	1
01/28/2015 15:00	0.0	0	0	0	0	1
01/28/2015 16:00	0.0	0	0	0	0	1
01/28/2015 17:00	0.0	0	0	0	0	1
01/28/2015 18:00	0.0	0	0	0	0	1
01/28/2015 19:00	0.0	0	0	0	0	1
01/28/2015 20:00	0.0	0	0	0	0	1
01/28/2015 21:00	0.0	0	0	0	0	1
01/28/2015 22:00	0.0	0	0	0	0	1
01/28/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/29/2015 00:00	0.0	0	0	0	0	1
01/29/2015 01:00	0.0	0	0	0	0	1
01/29/2015 02:00	0.0	0	0	0	0	1
01/29/2015 03:00	0.0	0	0	0	0	1
01/29/2015 04:00	0.0	0	0	0	0	1
01/29/2015 05:00	0.0	0	0	0	0	1
01/29/2015 06:00	0.0	0	0	0	0	1
01/29/2015 07:00	0.0	0	0	0	0	1
01/29/2015 08:00	0.0	0	0	0	0	1
01/29/2015 09:00	0.0	0	0	0	0	1
01/29/2015 10:00	0.0	0	0	0	0	1
01/29/2015 11:00	0.0	0	0	0	0	1
01/29/2015 12:00	0.0	0	0	0	0	1
01/29/2015 13:00	0.0	0	0	0	0	1
01/29/2015 14:00	0.0	0	0	0	0	1
01/29/2015 15:00	0.0	0	0	0	0	1
01/29/2015 16:00	0.0	0	0	0	0	1
01/29/2015 17:00	0.0	0	0	0	0	1
01/29/2015 18:00	0.0	0	0	0	0	1
01/29/2015 19:00	0.0	0	0	0	0	1
01/29/2015 20:00	0.0	0	0	0	0	1
01/29/2015 21:00	0.0	0	0	0	0	1
01/29/2015 22:00	0.0	0	0	0	0	1
01/29/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/30/2015 00:00	0.0	0	0	0	0	1
01/30/2015 01:00	0.0	0	0	0	0	1
01/30/2015 02:00	0.0	0	0	0	0	1
01/30/2015 03:00	0.0	0	0	0	0	1
01/30/2015 04:00	0.0	0	0	0	0	1
01/30/2015 05:00	0.0	0	0	0	0	1
01/30/2015 06:00	0.0	0	0	0	0	1
01/30/2015 07:00	0.0	0	0	0	0	1
01/30/2015 08:00	0.0	0	0	0	0	1
01/30/2015 09:00	0.0	0	0	0	0	1
01/30/2015 10:00	0.0	0	0	0	0	1
01/30/2015 11:00	0.0	0	0	0	0	1
01/30/2015 12:00	0.0	0	0	0	0	1
01/30/2015 13:00	0.0	0	0	0	0	1
01/30/2015 14:00	0.0	0	0	0	0	1
01/30/2015 15:00	0.0	0	0	0	0	1
01/30/2015 16:00	0.0	0	0	0	0	1
01/30/2015 17:00	0.0	0	0	0	0	1
01/30/2015 18:00	0.0	0	0	0	0	1
01/30/2015 19:00	0.0	0	0	0	0	1
01/30/2015 20:00	0.0	0	0	0	0	1
01/30/2015 21:00	0.0	0	0	0	0	1
01/30/2015 22:00	0.0	0	0	0	0	1
01/30/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/31/2015 00:00	0.0	0	0	0	0	1
01/31/2015 01:00	0.0	0	0	0	0	1
01/31/2015 02:00	0.0	0	0	0	0	1
01/31/2015 03:00	0.0	0	0	0	0	1
01/31/2015 04:00	0.0	0	0	0	0	1
01/31/2015 05:00	0.0	0	0	0	0	1
01/31/2015 06:00	0.0	0	0	0	0	1
01/31/2015 07:00	0.0	0	0	0	0	1
01/31/2015 08:00	0.0	0	0	0	0	1
01/31/2015 09:00	0.0	0	0	0	0	1
01/31/2015 10:00	0.0	0	0	0	0	1
01/31/2015 11:00	0.0	0	0	0	0	1
01/31/2015 12:00	0.0	0	0	0	0	1
01/31/2015 13:00	0.0	0	0	0	0	1
01/31/2015 14:00	0.0	0	0	0	0	1
01/31/2015 15:00	0.0	0	0	0	0	1
01/31/2015 16:00	0.0	0	0	0	0	1
01/31/2015 17:00	0.0	0	0	0	0	1
01/31/2015 18:00	0.0	0	0	0	0	1
01/31/2015 19:00	0.0	0	0	0	0	1
01/31/2015 20:00	0.0	0	0	0	0	1
01/31/2015 21:00	0.0	0	0	0	0	1
01/31/2015 22:00	0.0	0	0	0	0	1
01/31/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/01/2015 00:00	0.0	0	0	0	0	1
02/01/2015 01:00	0.0	0	0	0	0	1
02/01/2015 02:00	2.3	0	0	0	1	0
02/01/2015 03:00	0.0	0	0	0	0	0
02/01/2015 04:00	0.0	0	0	0	0	0
02/01/2015 05:00	0.0	0	0	0	0	0
02/01/2015 06:00	0.0	0	0	0	0	0
02/01/2015 07:00	0.0	0	0	0	0	0
02/01/2015 08:00	0.0	0	0	0	0	0
02/01/2015 09:00	0.0	0	0	0	0	0
02/01/2015 10:00	0.0	0	0	0	0	0
02/01/2015 11:00	0.0	0	0	0	0	0
02/01/2015 12:00	0.0	0	0	0	0	0
02/01/2015 13:00	0.0	0	0	0	0	0
02/01/2015 14:00	18.4	0	1	0	0	0
02/01/2015 15:00	17.7	0	1	0	0	0
02/01/2015 16:00	0.0	0	0	0	0	1
02/01/2015 17:00	0.0	0	0	0	0	1
02/01/2015 18:00	0.0	0	0	0	0	1
02/01/2015 19:00	0.0	0	0	0	0	1
02/01/2015 20:00	0.0	0	0	0	0	1
02/01/2015 21:00	0.0	0	0	0	0	1
02/01/2015 22:00	0.0	0	0	0	0	1
02/01/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	38.4 #	0 #	2 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	18.4	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/02/2015 00:00	0.0	0	0	0	0	1
02/02/2015 01:00	0.0	0	0	0	0	1
02/02/2015 02:00	0.0	0	0	0	0	1
02/02/2015 03:00	0.0	0	0	0	0	1
02/02/2015 04:00	0.0	0	0	0	0	1
02/02/2015 05:00	0.0	0	0	0	0	1
02/02/2015 06:00	0.0	0	0	0	0	1
02/02/2015 07:00	0.0	0	0	0	0	1
02/02/2015 08:00	0.0	0	0	0	0	1
02/02/2015 09:00	0.0	0	0	0	0	1
02/02/2015 10:00	0.0	0	0	0	0	1
02/02/2015 11:00	0.0	0	0	0	0	1
02/02/2015 12:00	0.0	0	0	0	0	1
02/02/2015 13:00	0.0	0	0	0	0	1
02/02/2015 14:00	0.0	0	0	0	0	1
02/02/2015 15:00	0.0	0	0	0	0	1
02/02/2015 16:00	0.0	0	0	0	0	1
02/02/2015 17:00	0.0	0	0	0	0	1
02/02/2015 18:00	0.0	0	0	0	0	1
02/02/2015 19:00	0.0	0	0	0	0	1
02/02/2015 20:00	0.0	0	0	0	0	1
02/02/2015 21:00	0.0	0	0	0	0	1
02/02/2015 22:00	0.0	0	0	0	0	1
02/02/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/03/2015 00:00	0.0	0	0	0	0	1
02/03/2015 01:00	0.0	0	0	0	0	1
02/03/2015 02:00	0.0	0	0	0	0	1
02/03/2015 03:00	0.0	0	0	0	0	1
02/03/2015 04:00	0.0	0	0	0	0	1
02/03/2015 05:00	0.0	0	0	0	0	1
02/03/2015 06:00	0.0	0	0	0	0	1
02/03/2015 07:00	0.0	0	0	0	0	1
02/03/2015 08:00	0.0	0	0	0	0	1
02/03/2015 09:00	0.0	0	0	0	0	1
02/03/2015 10:00	0.0	0	0	0	0	1
02/03/2015 11:00	0.0	0	0	0	0	1
02/03/2015 12:00	0.0	0	0	0	0	1
02/03/2015 13:00	0.0	0	0	0	0	1
02/03/2015 14:00	0.0	0	0	0	0	1
02/03/2015 15:00	0.0	0	0	0	0	1
02/03/2015 16:00	0.0	0	0	0	0	1
02/03/2015 17:00	0.0	0	0	0	0	1
02/03/2015 18:00	0.0	0	0	0	0	1
02/03/2015 19:00	0.0	0	0	0	0	1
02/03/2015 20:00	0.0	0	0	0	0	1
02/03/2015 21:00	0.0	0	0	0	0	1
02/03/2015 22:00	0.0	0	0	0	0	1
02/03/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/04/2015 00:00	0.0	0	0	0	0	1
02/04/2015 01:00	0.0	0	0	0	0	1
02/04/2015 02:00	0.0	0	0	0	0	1
02/04/2015 03:00	0.0	0	0	0	0	1
02/04/2015 04:00	0.0	0	0	0	0	1
02/04/2015 05:00	0.0	0	0	0	0	1
02/04/2015 06:00	0.0	0	0	0	0	1
02/04/2015 07:00	0.0	0	0	0	0	1
02/04/2015 08:00	0.0	0	0	0	0	1
02/04/2015 09:00	0.0	0	0	0	0	1
02/04/2015 10:00	0.0	0	0	0	0	1
02/04/2015 11:00	0.0	0	0	0	0	1
02/04/2015 12:00	0.0	0	0	0	0	1
02/04/2015 13:00	0.0	0	0	0	0	1
02/04/2015 14:00	0.0	0	0	0	0	1
02/04/2015 15:00	0.0	0	0	0	0	1
02/04/2015 16:00	0.0	0	0	0	0	1
02/04/2015 17:00	0.0	0	0	0	0	1
02/04/2015 18:00	0.0	0	0	0	0	1
02/04/2015 19:00	0.0	0	0	0	0	1
02/04/2015 20:00	0.0	0	0	0	0	1
02/04/2015 21:00	0.0	0	0	0	0	1
02/04/2015 22:00	0.0	0	0	0	0	1
02/04/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/05/2015 00:00	0.0	0	0	0	0	1
02/05/2015 01:00	0.0	0	0	0	0	1
02/05/2015 02:00	0.0	0	0	0	0	1
02/05/2015 03:00	0.0	0	0	0	0	1
02/05/2015 04:00	0.0	0	0	0	0	1
02/05/2015 05:00	0.0	0	0	0	0	1
02/05/2015 06:00	0.0	0	0	0	0	1
02/05/2015 07:00	0.0	0	0	0	0	1
02/05/2015 08:00	0.0	0	0	0	0	1
02/05/2015 09:00	0.0	0	0	0	0	1
02/05/2015 10:00	0.0	0	0	0	0	1
02/05/2015 11:00	0.0	0	0	0	0	1
02/05/2015 12:00	0.0	0	0	0	0	1
02/05/2015 13:00	0.0	0	0	0	0	1
02/05/2015 14:00	0.0	0	0	0	0	1
02/05/2015 15:00	0.0	0	0	0	0	1
02/05/2015 16:00	0.0	0	0	0	0	1
02/05/2015 17:00	0.0	0	0	0	0	1
02/05/2015 18:00	0.0	0	0	0	0	1
02/05/2015 19:00	0.0	0	0	0	0	1
02/05/2015 20:00	0.0	0	0	0	0	1
02/05/2015 21:00	0.0	0	0	0	0	1
02/05/2015 22:00	0.0	0	0	0	0	1
02/05/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/06/2015 00:00	0.0	0	0	0	0	1
02/06/2015 01:00	0.0	0	0	0	0	1
02/06/2015 02:00	0.0	0	0	0	0	1
02/06/2015 03:00	0.0	0	0	0	0	1
02/06/2015 04:00	0.0	0	0	0	0	1
02/06/2015 05:00	0.0	0	0	0	0	1
02/06/2015 06:00	0.0	0	0	0	0	1
02/06/2015 07:00	0.0	0	0	0	0	1
02/06/2015 08:00	0.0	0	0	0	0	1
02/06/2015 09:00	0.0	0	0	0	0	1
02/06/2015 10:00	0.0	0	0	0	0	1
02/06/2015 11:00	0.0	0	0	0	0	1
02/06/2015 12:00	0.0	0	0	0	0	1
02/06/2015 13:00	0.0	0	0	0	0	1
02/06/2015 14:00	0.0	0	0	0	0	1
02/06/2015 15:00	0.0	0	0	0	0	1
02/06/2015 16:00	0.0	0	0	0	0	1
02/06/2015 17:00	0.0	0	0	0	0	1
02/06/2015 18:00	0.0	0	0	0	0	1
02/06/2015 19:00	0.0	0	0	0	0	1
02/06/2015 20:00	0.0	0	0	0	0	1
02/06/2015 21:00	0.0	0	0	0	0	1
02/06/2015 22:00	0.0	0	0	0	0	1
02/06/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/07/2015 00:00	0.0	0	0	0	0	1
02/07/2015 01:00	0.0	0	0	0	0	1
02/07/2015 02:00	0.0	0	0	0	0	1
02/07/2015 03:00	0.0	0	0	0	0	1
02/07/2015 04:00	0.0	0	0	0	0	1
02/07/2015 05:00	0.0	0	0	0	0	1
02/07/2015 06:00	0.0	0	0	0	0	1
02/07/2015 07:00	0.0	0	0	0	0	1
02/07/2015 08:00	0.0	0	0	0	0	1
02/07/2015 09:00	0.0	0	0	0	0	1
02/07/2015 10:00	0.0	0	0	0	0	1
02/07/2015 11:00	0.0	0	0	0	0	1
02/07/2015 12:00	0.0	0	0	0	0	1
02/07/2015 13:00	0.0	0	0	0	0	1
02/07/2015 14:00	0.0	0	0	0	0	1
02/07/2015 15:00	0.0	0	0	0	0	1
02/07/2015 16:00	0.0	0	0	0	0	1
02/07/2015 17:00	0.0	0	0	0	0	1
02/07/2015 18:00	0.0	0	0	0	0	1
02/07/2015 19:00	0.0	0	0	0	0	1
02/07/2015 20:00	0.0	0	0	0	0	1
02/07/2015 21:00	0.0	0	0	0	0	1
02/07/2015 22:00	0.0	0	0	0	0	1
02/07/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/08/2015 00:00	0.0	0	0	0	0	1
02/08/2015 01:00	0.0	0	0	0	0	1
02/08/2015 02:00	0.0	0	0	0	0	1
02/08/2015 03:00	0.0	0	0	0	0	1
02/08/2015 04:00	0.0	0	0	0	0	1
02/08/2015 05:00	0.0	0	0	0	0	1
02/08/2015 06:00	0.0	0	0	0	0	1
02/08/2015 07:00	0.0	0	0	0	0	1
02/08/2015 08:00	0.0	0	0	0	0	1
02/08/2015 09:00	0.0	0	0	0	0	1
02/08/2015 10:00	0.0	0	0	0	0	1
02/08/2015 11:00	0.0	0	0	0	0	1
02/08/2015 12:00	0.0	0	0	0	0	1
02/08/2015 13:00	0.0	0	0	0	0	1
02/08/2015 14:00	0.0	0	0	0	0	1
02/08/2015 15:00	0.0	0	0	0	0	1
02/08/2015 16:00	0.0	0	0	0	0	1
02/08/2015 17:00	0.0	0	0	0	0	1
02/08/2015 18:00	0.0	0	0	0	0	1
02/08/2015 19:00	0.0	0	0	0	0	1
02/08/2015 20:00	0.0	0	0	0	0	1
02/08/2015 21:00	0.0	0	0	0	0	1
02/08/2015 22:00	0.0	0	0	0	0	1
02/08/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/09/2015 00:00	0.0	0	0	0	0	1
02/09/2015 01:00	0.0	0	0	0	0	1
02/09/2015 02:00	0.0	0	0	0	0	1
02/09/2015 03:00	0.0	0	0	0	0	1
02/09/2015 04:00	0.0	0	0	0	0	1
02/09/2015 05:00	0.0	0	0	0	0	1
02/09/2015 06:00	0.0	0	0	0	0	1
02/09/2015 07:00	0.0	0	0	0	0	1
02/09/2015 08:00	0.0	0	0	0	0	1
02/09/2015 09:00	0.0	0	0	0	0	1
02/09/2015 10:00	0.0	0	0	0	0	1
02/09/2015 11:00	0.0	0	0	0	0	1
02/09/2015 12:00	0.0	0	0	0	0	1
02/09/2015 13:00	0.0	0	0	0	0	1
02/09/2015 14:00	0.0	0	0	0	0	1
02/09/2015 15:00	0.0	0	0	0	0	1
02/09/2015 16:00	0.0	0	0	0	0	1
02/09/2015 17:00	0.0	0	0	0	0	1
02/09/2015 18:00	0.0	0	0	0	0	1
02/09/2015 19:00	0.0	0	0	0	0	1
02/09/2015 20:00	0.0	0	0	0	0	1
02/09/2015 21:00	0.0	0	0	0	0	1
02/09/2015 22:00	0.0	0	0	0	0	1
02/09/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/10/2015 00:00	0.0	0	0	0	0	1
02/10/2015 01:00	0.0	0	0	0	0	1
02/10/2015 02:00	0.0	0	0	0	0	1
02/10/2015 03:00	0.0	0	0	0	0	1
02/10/2015 04:00	0.0	0	0	0	0	1
02/10/2015 05:00	0.0	0	0	0	0	1
02/10/2015 06:00	0.0	0	0	0	0	1
02/10/2015 07:00	0.0	0	0	0	0	1
02/10/2015 08:00	0.0	0	0	0	0	1
02/10/2015 09:00	0.0	0	0	0	0	1
02/10/2015 10:00	0.0	0	0	0	0	1
02/10/2015 11:00	0.0	0	0	0	0	1
02/10/2015 12:00	0.0	0	0	0	0	1
02/10/2015 13:00	0.0	0	0	0	0	1
02/10/2015 14:00	0.0	0	0	0	0	1
02/10/2015 15:00	0.0	0	0	0	0	1
02/10/2015 16:00	0.0	0	0	0	0	1
02/10/2015 17:00	0.0	0	0	0	0	1
02/10/2015 18:00	0.0	0	0	0	0	1
02/10/2015 19:00	0.0	0	0	0	0	1
02/10/2015 20:00	0.0	0	0	0	0	1
02/10/2015 21:00	0.0	0	0	0	0	1
02/10/2015 22:00	0.0	0	0	0	0	1
02/10/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/11/2015 00:00	0.0	0	0	0	0	1
02/11/2015 01:00	0.0	0	0	0	0	1
02/11/2015 02:00	0.0	0	0	0	0	1
02/11/2015 03:00	0.0	0	0	0	0	1
02/11/2015 04:00	0.0	0	0	0	0	1
02/11/2015 05:00	0.0	0	0	0	0	1
02/11/2015 06:00	0.0	0	0	0	0	1
02/11/2015 07:00	0.0	0	0	0	0	1
02/11/2015 08:00	0.0	0	0	0	0	1
02/11/2015 09:00	0.0	0	0	0	0	1
02/11/2015 10:00	0.0	0	0	0	0	1
02/11/2015 11:00	0.0	0	0	0	0	1
02/11/2015 12:00	0.0	0	0	0	0	1
02/11/2015 13:00	0.0	0	0	0	0	1
02/11/2015 14:00	0.0	0	0	0	0	1
02/11/2015 15:00	0.0	0	0	0	0	1
02/11/2015 16:00	0.0	0	0	0	0	1
02/11/2015 17:00	0.0	0	0	0	0	1
02/11/2015 18:00	0.0	0	0	0	0	1
02/11/2015 19:00	0.0	0	0	0	0	1
02/11/2015 20:00	0.0	0	0	0	0	1
02/11/2015 21:00	0.0	0	0	0	0	1
02/11/2015 22:00	0.0	0	0	0	0	1
02/11/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/12/2015 00:00	0.0	0	0	0	0	1
02/12/2015 01:00	0.0	0	0	0	0	1
02/12/2015 02:00	0.0	0	0	0	0	1
02/12/2015 03:00	0.0	0	0	0	0	1
02/12/2015 04:00	0.0	0	0	0	0	1
02/12/2015 05:00	0.0	0	0	0	0	1
02/12/2015 06:00	0.0	0	0	0	0	1
02/12/2015 07:00	0.0	0	0	0	0	1
02/12/2015 08:00	0.0	0	0	0	0	1
02/12/2015 09:00	0.0	0	0	0	0	1
02/12/2015 10:00	0.0	0	0	0	0	1
02/12/2015 11:00	0.0	0	0	0	0	1
02/12/2015 12:00	0.0	0	0	0	0	1
02/12/2015 13:00	0.0	0	0	0	0	1
02/12/2015 14:00	0.0	0	0	0	0	1
02/12/2015 15:00	0.0	0	0	0	0	1
02/12/2015 16:00	0.0	0	0	0	0	1
02/12/2015 17:00	0.0	0	0	0	0	1
02/12/2015 18:00	0.0	0	0	0	0	1
02/12/2015 19:00	0.0	0	0	0	0	1
02/12/2015 20:00	0.0	0	0	0	0	1
02/12/2015 21:00	0.0	0	0	0	0	1
02/12/2015 22:00	0.0	0	0	0	0	1
02/12/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/13/2015 00:00	0.0	0	0	0	0	1
02/13/2015 01:00	0.0	0	0	0	0	1
02/13/2015 02:00	0.0	0	0	0	0	1
02/13/2015 03:00	0.0	0	0	0	0	1
02/13/2015 04:00	0.0	0	0	0	0	1
02/13/2015 05:00	0.0	0	0	0	0	1
02/13/2015 06:00	0.0	0	0	0	0	1
02/13/2015 07:00	0.0	0	0	0	0	1
02/13/2015 08:00	0.0	0	0	0	0	1
02/13/2015 09:00	0.0	0	0	0	0	1
02/13/2015 10:00	0.0	0	0	0	0	1
02/13/2015 11:00	0.0	0	0	0	0	1
02/13/2015 12:00	0.0	0	0	0	0	1
02/13/2015 13:00	0.0	0	0	0	0	1
02/13/2015 14:00	0.0	0	0	0	0	1
02/13/2015 15:00	0.0	0	0	0	0	1
02/13/2015 16:00	0.0	0	0	0	0	1
02/13/2015 17:00	0.0	0	0	0	0	1
02/13/2015 18:00	0.0	0	0	0	0	1
02/13/2015 19:00	0.0	0	0	0	0	1
02/13/2015 20:00	0.0	0	0	0	0	1
02/13/2015 21:00	0.0	0	0	0	0	1
02/13/2015 22:00	0.0	0	0	0	0	1
02/13/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/14/2015 00:00	0.0	0	0	0	0	1
02/14/2015 01:00	0.0	0	0	0	0	1
02/14/2015 02:00	0.0	0	0	0	0	1
02/14/2015 03:00	0.0	0	0	0	0	1
02/14/2015 04:00	0.0	0	0	0	0	1
02/14/2015 05:00	0.0	0	0	0	0	1
02/14/2015 06:00	0.0	0	0	0	0	1
02/14/2015 07:00	0.0	0	0	0	0	1
02/14/2015 08:00	0.0	0	0	0	0	1
02/14/2015 09:00	0.0	0	0	0	0	1
02/14/2015 10:00	0.0	0	0	0	0	1
02/14/2015 11:00	0.0	0	0	0	0	1
02/14/2015 12:00	0.0	0	0	0	0	1
02/14/2015 13:00	0.0	0	0	0	0	1
02/14/2015 14:00	0.0	0	0	0	0	1
02/14/2015 15:00	0.0	0	0	0	0	1
02/14/2015 16:00	0.0	0	0	0	0	1
02/14/2015 17:00	0.0	0	0	0	0	1
02/14/2015 18:00	0.0	0	0	0	0	1
02/14/2015 19:00	0.0	0	0	0	0	1
02/14/2015 20:00	0.0	0	0	0	0	1
02/14/2015 21:00	0.0	0	0	0	0	1
02/14/2015 22:00	0.0	0	0	0	0	1
02/14/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/15/2015 00:00	0.0	0	0	0	0	1
02/15/2015 01:00	0.0	0	0	0	0	1
02/15/2015 02:00	2.7	0	0	0	1	0
02/15/2015 03:00	0.0	0	0	0	0	0
02/15/2015 04:00	0.0	0	0	0	0	0
02/15/2015 05:00	0.0	0	0	0	0	0
02/15/2015 06:00	0.0	0	0	0	0	0
02/15/2015 07:00	0.0	0	0	0	0	0
02/15/2015 08:00	0.0	0	0	0	0	0
02/15/2015 09:00	0.0	0	0	0	0	0
02/15/2015 10:00	22.3	0	1	0	0	0
02/15/2015 11:00	32.4	0	1	0	0	0
02/15/2015 12:00	0.0	0	0	0	0	1
02/15/2015 13:00	0.0	0	0	0	0	1
02/15/2015 14:00	0.0	0	0	0	0	1
02/15/2015 15:00	0.0	0	0	0	0	1
02/15/2015 16:00	0.0	0	0	0	0	1
02/15/2015 17:00	0.0	0	0	0	0	1
02/15/2015 18:00	0.0	0	0	0	0	1
02/15/2015 19:00	0.0	0	0	0	0	1
02/15/2015 20:00	0.0	0	0	0	0	1
02/15/2015 21:00	0.0	0	0	0	0	1
02/15/2015 22:00	0.0	0	0	0	0	1
02/15/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	57.4 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	32.4	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/16/2015 00:00	0.0	0	0	0	0	1
02/16/2015 01:00	0.0	0	0	0	0	1
02/16/2015 02:00	0.0	0	0	0	0	1
02/16/2015 03:00	0.0	0	0	0	0	1
02/16/2015 04:00	0.0	0	0	0	0	1
02/16/2015 05:00	0.0	0	0	0	0	1
02/16/2015 06:00	0.0	0	0	0	0	1
02/16/2015 07:00	0.0	0	0	0	0	1
02/16/2015 08:00	0.0	0	0	0	0	1
02/16/2015 09:00	0.0	0	0	0	0	1
02/16/2015 10:00	0.0	0	0	0	0	1
02/16/2015 11:00	0.0	0	0	0	0	1
02/16/2015 12:00	0.0	0	0	0	0	1
02/16/2015 13:00	0.0	0	0	0	0	1
02/16/2015 14:00	0.0	0	0	0	0	1
02/16/2015 15:00	0.0	0	0	0	0	1
02/16/2015 16:00	0.0	0	0	0	0	1
02/16/2015 17:00	0.0	0	0	0	0	1
02/16/2015 18:00	0.0	0	0	0	0	1
02/16/2015 19:00	0.0	0	0	0	0	1
02/16/2015 20:00	0.0	0	0	0	0	1
02/16/2015 21:00	0.0	0	0	0	0	1
02/16/2015 22:00	0.0	0	0	0	0	1
02/16/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/17/2015 00:00	0.0	0	0	0	0	1
02/17/2015 01:00	0.0	0	0	0	0	1
02/17/2015 02:00	0.0	0	0	0	0	1
02/17/2015 03:00	0.0	0	0	0	0	1
02/17/2015 04:00	0.0	0	0	0	0	1
02/17/2015 05:00	0.0	0	0	0	0	1
02/17/2015 06:00	0.0	0	0	0	0	1
02/17/2015 07:00	0.0	0	0	0	0	1
02/17/2015 08:00	0.0	0	0	0	0	1
02/17/2015 09:00	0.0	0	0	0	0	1
02/17/2015 10:00	0.0	0	0	0	0	1
02/17/2015 11:00	0.0	0	0	0	0	1
02/17/2015 12:00	0.0	0	0	0	0	1
02/17/2015 13:00	0.0	0	0	0	0	1
02/17/2015 14:00	0.0	0	0	0	0	1
02/17/2015 15:00	0.0	0	0	0	0	1
02/17/2015 16:00	0.0	0	0	0	0	1
02/17/2015 17:00	0.0	0	0	0	0	1
02/17/2015 18:00	0.0	0	0	0	0	1
02/17/2015 19:00	0.0	0	0	0	0	1
02/17/2015 20:00	0.0	0	0	0	0	1
02/17/2015 21:00	0.0	0	0	0	0	1
02/17/2015 22:00	0.0	0	0	0	0	1
02/17/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/18/2015 00:00	0.0	0	0	0	0	1
02/18/2015 01:00	0.0	0	0	0	0	1
02/18/2015 02:00	0.0	0	0	0	0	1
02/18/2015 03:00	0.0	0	0	0	0	1
02/18/2015 04:00	0.0	0	0	0	0	1
02/18/2015 05:00	0.0	0	0	0	0	1
02/18/2015 06:00	0.0	0	0	0	0	1
02/18/2015 07:00	0.0	0	0	0	0	1
02/18/2015 08:00	0.0	0	0	0	0	1
02/18/2015 09:00	0.0	0	0	0	0	1
02/18/2015 10:00	0.0	0	0	0	0	1
02/18/2015 11:00	0.0	0	0	0	0	1
02/18/2015 12:00	0.0	0	0	0	0	1
02/18/2015 13:00	0.0	0	0	0	0	1
02/18/2015 14:00	0.0	0	0	0	0	1
02/18/2015 15:00	0.0	0	0	0	0	1
02/18/2015 16:00	0.0	0	0	0	0	1
02/18/2015 17:00	0.0	0	0	0	0	1
02/18/2015 18:00	0.0	0	0	0	0	1
02/18/2015 19:00	0.0	0	0	0	0	1
02/18/2015 20:00	0.0	0	0	0	0	1
02/18/2015 21:00	0.0	0	0	0	0	1
02/18/2015 22:00	0.0	0	0	0	0	1
02/18/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/19/2015 00:00	0.0	0	0	0	0	1
02/19/2015 01:00	0.0	0	0	0	0	1
02/19/2015 02:00	0.0	0	0	0	0	1
02/19/2015 03:00	0.0	0	0	0	0	1
02/19/2015 04:00	0.0	0	0	0	0	1
02/19/2015 05:00	0.0	0	0	0	0	1
02/19/2015 06:00	0.0	0	0	0	0	1
02/19/2015 07:00	0.0	0	0	0	0	1
02/19/2015 08:00	0.0	0	0	0	0	1
02/19/2015 09:00	0.0	0	0	0	0	1
02/19/2015 10:00	0.0	0	0	0	0	1
02/19/2015 11:00	0.0	0	0	0	0	1
02/19/2015 12:00	0.0	0	0	0	0	1
02/19/2015 13:00	0.0	0	0	0	0	1
02/19/2015 14:00	0.0	0	0	0	0	1
02/19/2015 15:00	0.0	0	0	0	0	1
02/19/2015 16:00	0.0	0	0	0	0	1
02/19/2015 17:00	0.0	0	0	0	0	1
02/19/2015 18:00	0.0	0	0	0	0	1
02/19/2015 19:00	0.0	0	0	0	0	1
02/19/2015 20:00	0.0	0	0	0	0	1
02/19/2015 21:00	0.0	0	0	0	0	1
02/19/2015 22:00	0.0	0	0	0	0	1
02/19/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/20/2015 00:00	0.0	0	0	0	0	1
02/20/2015 01:00	3.4	0	0	0	1	0
02/20/2015 02:00	0.0	0	0	0	0	0
02/20/2015 03:00	0.0	0	0	0	0	0
02/20/2015 04:00	3.0	0	0	1	0	0
02/20/2015 05:00	17.8	0	0	1	0	0
02/20/2015 06:00	0.0	0	0	0	0	1
02/20/2015 07:00	0.0	0	0	0	0	1
02/20/2015 08:00	0.0	0	0	0	0	1
02/20/2015 09:00	0.0	0	0	0	0	1
02/20/2015 10:00	0.0	0	0	0	0	1
02/20/2015 11:00	0.0	0	0	0	0	1
02/20/2015 12:00	3.6	0	0	0	1	0
02/20/2015 13:00	0.0	0	0	0	0	0
02/20/2015 14:00	0.0	0	0	0	0	0
02/20/2015 15:00	0.0	0	0	0	0	0
02/20/2015 16:00	0.0	0	0	0	0	0
02/20/2015 17:00	0.0	0	0	0	0	0
02/20/2015 18:00	0.0	0	0	0	0	0
02/20/2015 19:00	0.0	0	0	0	0	0
02/20/2015 20:00	0.0	0	0	0	0	0
02/20/2015 21:00	0.0	0	0	0	0	0
02/20/2015 22:00	0.0	0	0	0	0	0
02/20/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	27.8 #	0 #	0 #	2 #	2 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	17.8	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/21/2015 00:00	0.0	0	0	0	0	0
02/21/2015 01:00	0.0	0	0	0	0	0
02/21/2015 02:00	0.0	0	0	0	0	0
02/21/2015 03:00	0.0	0	0	0	0	0
02/21/2015 04:00	0.0	0	0	0	0	0
02/21/2015 05:00	0.0	0	0	0	0	0
02/21/2015 06:00	0.0	0	0	0	0	0
02/21/2015 07:00	0.0	0	0	0	0	0
02/21/2015 08:00	0.0	0	0	0	0	0
02/21/2015 09:00	0.0	0	0	0	0	0
02/21/2015 10:00	74.4	0	1	0	0	0
02/21/2015 11:00	67.7	0	1	0	0	0
02/21/2015 12:00	6.3	0	1	0	0	0
02/21/2015 13:00	0.0	0	0	0	0	1
02/21/2015 14:00	0.0	0	0	0	0	1
02/21/2015 15:00	0.0	0	0	0	0	1
02/21/2015 16:00	0.0	0	0	0	0	1
02/21/2015 17:00	0.0	0	0	0	0	1
02/21/2015 18:00	0.0	0	0	0	0	1
02/21/2015 19:00	0.0	0	0	0	0	1
02/21/2015 20:00	0.0	0	0	0	0	1
02/21/2015 21:00	0.0	0	0	0	0	1
02/21/2015 22:00	0.0	0	0	0	0	1
02/21/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	148.4 #	0 #	3 #	0 #	0 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	74.4	0	1	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/22/2015 00:00	0.0	0	0	0	0	1
02/22/2015 01:00	0.0	0	0	0	0	1
02/22/2015 02:00	0.0	0	0	0	0	1
02/22/2015 03:00	0.0	0	0	0	0	1
02/22/2015 04:00	0.0	0	0	0	0	1
02/22/2015 05:00	0.0	0	0	0	0	1
02/22/2015 06:00	0.0	0	0	0	1	0
02/22/2015 07:00	0.0	0	0	0	0	0
02/22/2015 08:00	0.0	0	0	0	0	0
02/22/2015 09:00	0.0	0	0	0	0	0
02/22/2015 10:00	0.0	0	0	0	0	0
02/22/2015 11:00	0.0	0	0	0	0	0
02/22/2015 12:00	0.0	0	0	0	0	0
02/22/2015 13:00	0.0	0	0	0	0	0
02/22/2015 14:00	25.0	0	1	0	0	0
02/22/2015 15:00	43.9	0	1	0	0	0
02/22/2015 16:00	0.0	0	0	0	0	1
02/22/2015 17:00	0.0	0	0	0	0	1
02/22/2015 18:00	0.0	0	0	0	0	1
02/22/2015 19:00	0.0	0	0	0	0	1
02/22/2015 20:00	0.0	0	0	0	0	1
02/22/2015 21:00	0.0	0	0	0	0	1
02/22/2015 22:00	1.7	0	0	0	1	0
02/22/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	70.6 #	0 #	2 #	0 #	2 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	43.9	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/23/2015 00:00	0.0	0	0	0	0	0
02/23/2015 01:00	0.0	0	0	0	0	0
02/23/2015 02:00	0.0	0	0	0	0	0
02/23/2015 03:00	28.0	0	0	1	0	0
02/23/2015 04:00	11.0	0	0	1	0	0
02/23/2015 05:00	0.0	0	0	0	0	1
02/23/2015 06:00	0.0	0	0	0	0	1
02/23/2015 07:00	0.0	0	0	0	0	1
02/23/2015 08:00	0.0	0	0	0	0	1
02/23/2015 09:00	0.0	0	0	0	0	1
02/23/2015 10:00	0.0	0	0	0	0	1
02/23/2015 11:00	0.0	0	0	0	0	1
02/23/2015 12:00	0.0	0	0	0	0	1
02/23/2015 13:00	0.0	0	0	0	0	1
02/23/2015 14:00	0.0	0	0	0	0	1
02/23/2015 15:00	0.0	0	0	0	0	1
02/23/2015 16:00	0.0	0	0	0	0	1
02/23/2015 17:00	0.0	0	0	0	0	1
02/23/2015 18:00	0.0	0	0	0	0	1
02/23/2015 19:00	0.0	0	0	0	0	1
02/23/2015 20:00	0.0	0	0	0	0	1
02/23/2015 21:00	0.0	0	0	0	0	1
02/23/2015 22:00	0.0	0	0	0	0	1
02/23/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	39.0 #	0 #	0 #	2 #	0 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	28.0	0	0	1	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/24/2015 00:00	0.0	0	0	0	0	1
02/24/2015 01:00	0.0	0	0	0	0	1
02/24/2015 02:00	0.0	0	0	0	0	1
02/24/2015 03:00	0.0	0	0	0	0	1
02/24/2015 04:00	0.0	0	0	0	0	1
02/24/2015 05:00	0.0	0	0	0	0	1
02/24/2015 06:00	0.0	0	0	0	0	1
02/24/2015 07:00	0.0	0	0	0	0	1
02/24/2015 08:00	0.0	0	0	0	0	1
02/24/2015 09:00	0.0	0	0	0	0	1
02/24/2015 10:00	0.0	0	0	0	0	1
02/24/2015 11:00	0.0	0	0	0	0	1
02/24/2015 12:00	0.0	0	0	0	0	1
02/24/2015 13:00	0.0	0	0	0	0	1
02/24/2015 14:00	0.0	0	0	0	0	1
02/24/2015 15:00	0.0	0	0	0	0	1
02/24/2015 16:00	0.0	0	0	0	0	1
02/24/2015 17:00	0.0	0	0	0	0	1
02/24/2015 18:00	0.0	0	0	0	0	1
02/24/2015 19:00	0.0	0	0	0	0	1
02/24/2015 20:00	0.0	0	0	0	0	1
02/24/2015 21:00	0.0	0	0	0	0	1
02/24/2015 22:00	0.0	0	0	0	0	1
02/24/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/25/2015 00:00	0.0	0	0	0	0	1
02/25/2015 01:00	0.0	0	0	0	0	1
02/25/2015 02:00	0.0	0	0	0	0	1
02/25/2015 03:00	0.0	0	0	0	0	1
02/25/2015 04:00	0.0	0	0	0	0	1
02/25/2015 05:00	0.0	0	0	0	0	1
02/25/2015 06:00	0.0	0	0	0	0	1
02/25/2015 07:00	0.0	0	0	0	0	1
02/25/2015 08:00	0.0	0	0	0	0	1
02/25/2015 09:00	0.0	0	0	0	0	1
02/25/2015 10:00	0.0	0	0	0	0	1
02/25/2015 11:00	0.0	0	0	0	0	1
02/25/2015 12:00	0.0	0	0	0	0	1
02/25/2015 13:00	0.0	0	0	0	0	1
02/25/2015 14:00	0.0	0	0	0	0	1
02/25/2015 15:00	0.0	0	0	0	0	1
02/25/2015 16:00	0.0	0	0	0	0	1
02/25/2015 17:00	0.0	0	0	0	0	1
02/25/2015 18:00	0.0	0	0	0	0	1
02/25/2015 19:00	0.0	0	0	0	0	1
02/25/2015 20:00	0.0	0	0	0	0	1
02/25/2015 21:00	0.0	0	0	0	0	1
02/25/2015 22:00	0.0	0	0	0	0	1
02/25/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/26/2015 00:00	0.0	0	0	0	0	1
02/26/2015 01:00	0.0	0	0	0	0	1
02/26/2015 02:00	0.0	0	0	0	0	1
02/26/2015 03:00	0.0	0	0	0	0	1
02/26/2015 04:00	0.0	0	0	0	0	1
02/26/2015 05:00	0.0	0	0	0	0	1
02/26/2015 06:00	0.0	0	0	0	0	1
02/26/2015 07:00	0.0	0	0	0	0	1
02/26/2015 08:00	0.0	0	0	0	0	1
02/26/2015 09:00	0.0	0	0	0	0	1
02/26/2015 10:00	0.0	0	0	0	0	1
02/26/2015 11:00	0.0	0	0	0	0	1
02/26/2015 12:00	0.0	0	0	0	0	1
02/26/2015 13:00	0.0	0	0	0	0	1
02/26/2015 14:00	0.0	0	0	0	0	1
02/26/2015 15:00	0.0	0	0	0	0	1
02/26/2015 16:00	0.0	0	0	0	0	1
02/26/2015 17:00	0.0	0	0	0	0	1
02/26/2015 18:00	0.0	0	0	0	0	1
02/26/2015 19:00	0.0	0	0	0	0	1
02/26/2015 20:00	0.0	0	0	0	0	1
02/26/2015 21:00	0.0	0	0	0	0	1
02/26/2015 22:00	0.0	0	0	0	0	1
02/26/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/27/2015 00:00	0.0	0	0	0	0	1
02/27/2015 01:00	0.0	0	0	0	0	1
02/27/2015 02:00	0.0	0	0	0	0	1
02/27/2015 03:00	0.0	0	0	0	0	1
02/27/2015 04:00	0.0	0	0	0	0	1
02/27/2015 05:00	0.0	0	0	0	0	1
02/27/2015 06:00	0.0	0	0	0	0	1
02/27/2015 07:00	0.0	0	0	0	0	1
02/27/2015 08:00	0.0	0	0	0	0	1
02/27/2015 09:00	0.0	0	0	0	0	1
02/27/2015 10:00	0.0	0	0	0	0	1
02/27/2015 11:00	0.0	0	0	0	0	1
02/27/2015 12:00	0.0	0	0	0	0	1
02/27/2015 13:00	0.0	0	0	0	0	1
02/27/2015 14:00	0.0	0	0	0	0	1
02/27/2015 15:00	0.0	0	0	0	0	1
02/27/2015 16:00	0.0	0	0	0	0	1
02/27/2015 17:00	0.0	0	0	0	0	1
02/27/2015 18:00	0.0	0	0	0	0	1
02/27/2015 19:00	0.0	0	0	0	0	1
02/27/2015 20:00	0.0	0	0	0	0	1
02/27/2015 21:00	0.0	0	0	0	0	1
02/27/2015 22:00	0.0	0	0	0	0	1
02/27/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/28/2015 00:00	0.0	0	0	0	0	1
02/28/2015 01:00	2.4	0	0	0	1	0
02/28/2015 02:00	0.0	0	0	0	0	0
02/28/2015 03:00	0.0	0	0	0	0	0
02/28/2015 04:00	0.0	0	0	0	0	0
02/28/2015 05:00	0.0	0	0	0	0	0
02/28/2015 06:00	0.0	0	0	0	0	0
02/28/2015 07:00	0.0	0	0	0	0	0
02/28/2015 08:00	0.0	0	0	0	0	0
02/28/2015 09:00	0.0	0	0	0	0	0
02/28/2015 10:00	0.0	0	0	0	0	0
02/28/2015 11:00	0.0	0	0	0	0	0
02/28/2015 12:00	0.0	0	0	0	0	0
02/28/2015 13:00	0.0	0	0	0	0	0
02/28/2015 14:00	12.9	0	1	0	0	0
02/28/2015 15:00	38.2	0	1	0	0	0
02/28/2015 16:00	0.0	0	0	0	0	1
02/28/2015 17:00	0.0	0	0	0	0	1
02/28/2015 18:00	0.0	0	0	0	0	1
02/28/2015 19:00	0.0	0	0	0	0	1
02/28/2015 20:00	0.0	0	0	0	0	1
02/28/2015 21:00	0.0	0	0	0	0	1
02/28/2015 22:00	0.0	0	0	0	0	1
02/28/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	53.5 #	0 #	2 #	0 #	1 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	38.2	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/01/2015 00:00	0.0	0	0	0	0	1
03/01/2015 01:00	0.0	0	0	0	0	1
03/01/2015 02:00	0.0	0	0	0	0	1
03/01/2015 03:00	0.0	0	0	0	0	1
03/01/2015 04:00	0.0	0	0	0	0	1
03/01/2015 05:00	0.0	0	0	0	0	1
03/01/2015 06:00	0.0	0	0	0	0	1
03/01/2015 07:00	0.0	0	0	0	0	1
03/01/2015 08:00	0.0	0	0	0	0	1
03/01/2015 09:00	0.0	0	0	0	0	1
03/01/2015 10:00	0.0	0	0	0	0	1
03/01/2015 11:00	0.0	0	0	0	0	1
03/01/2015 12:00	0.0	0	0	0	0	1
03/01/2015 13:00	0.0	0	0	0	0	1
03/01/2015 14:00	0.0	0	0	0	0	1
03/01/2015 15:00	0.0	0	0	0	0	1
03/01/2015 16:00	0.0	0	0	0	0	1
03/01/2015 17:00	0.0	0	0	0	0	1
03/01/2015 18:00	0.0	0	0	0	0	1
03/01/2015 19:00	0.0	0	0	0	0	1
03/01/2015 20:00	0.0	0	0	0	0	1
03/01/2015 21:00	0.0	0	0	0	0	1
03/01/2015 22:00	0.0	0	0	0	0	1
03/01/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/02/2015 00:00	0.0	0	0	0	0	1
03/02/2015 01:00	0.0	0	0	0	0	1
03/02/2015 02:00	0.0	0	0	0	0	1
03/02/2015 03:00	0.0	0	0	0	0	1
03/02/2015 04:00	0.0	0	0	0	0	1
03/02/2015 05:00	0.0	0	0	0	0	1
03/02/2015 06:00	0.0	0	0	0	0	1
03/02/2015 07:00	0.0	0	0	0	0	1
03/02/2015 08:00	0.0	0	0	0	0	1
03/02/2015 09:00	0.0	0	0	0	0	1
03/02/2015 10:00	0.0	0	0	0	0	1
03/02/2015 11:00	0.0	0	0	0	0	1
03/02/2015 12:00	0.0	0	0	0	0	1
03/02/2015 13:00	0.0	0	0	0	0	1
03/02/2015 14:00	0.0	0	0	0	0	1
03/02/2015 15:00	0.0	0	0	0	0	1
03/02/2015 16:00	0.0	0	0	0	0	1
03/02/2015 17:00	0.0	0	0	0	0	1
03/02/2015 18:00	0.0	0	0	0	0	1
03/02/2015 19:00	0.0	0	0	0	0	1
03/02/2015 20:00	0.0	0	0	0	0	1
03/02/2015 21:00	0.0	0	0	0	0	1
03/02/2015 22:00	0.0	0	0	0	0	1
03/02/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/03/2015 00:00	0.0	0	0	0	0	1
03/03/2015 01:00	0.0	0	0	0	0	1
03/03/2015 02:00	0.0	0	0	0	0	1
03/03/2015 03:00	0.0	0	0	0	0	1
03/03/2015 04:00	0.0	0	0	0	0	1
03/03/2015 05:00	0.0	0	0	0	0	1
03/03/2015 06:00	0.0	0	0	0	0	1
03/03/2015 07:00	0.0	0	0	0	0	1
03/03/2015 08:00	0.0	0	0	0	0	1
03/03/2015 09:00	0.0	0	0	0	0	1
03/03/2015 10:00	0.0	0	0	0	0	1
03/03/2015 11:00	0.0	0	0	0	0	1
03/03/2015 12:00	0.0	0	0	0	0	1
03/03/2015 13:00	0.0	0	0	0	0	1
03/03/2015 14:00	0.0	0	0	0	0	1
03/03/2015 15:00	0.0	0	0	0	0	1
03/03/2015 16:00	0.0	0	0	0	0	1
03/03/2015 17:00	0.0	0	0	0	0	1
03/03/2015 18:00	0.0	0	0	0	0	1
03/03/2015 19:00	0.0	0	0	0	0	1
03/03/2015 20:00	0.0	0	0	0	0	1
03/03/2015 21:00	0.0	0	0	0	0	1
03/03/2015 22:00	0.0	0	0	0	0	1
03/03/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/04/2015 00:00	0.0	0	0	0	0	1
03/04/2015 01:00	0.0	0	0	0	0	1
03/04/2015 02:00	0.0	0	0	0	0	1
03/04/2015 03:00	0.0	0	0	0	0	1
03/04/2015 04:00	0.0	0	0	0	0	1
03/04/2015 05:00	0.0	0	0	0	0	1
03/04/2015 06:00	0.0	0	0	0	0	1
03/04/2015 07:00	0.0	0	0	0	0	1
03/04/2015 08:00	0.0	0	0	0	0	1
03/04/2015 09:00	0.0	0	0	0	0	1
03/04/2015 10:00	0.0	0	0	0	0	1
03/04/2015 11:00	0.0	0	0	0	0	1
03/04/2015 12:00	0.0	0	0	0	0	1
03/04/2015 13:00	0.0	0	0	0	0	1
03/04/2015 14:00	0.0	0	0	0	0	1
03/04/2015 15:00	0.0	0	0	0	0	1
03/04/2015 16:00	0.0	0	0	0	0	1
03/04/2015 17:00	0.0	0	0	0	0	1
03/04/2015 18:00	0.0	0	0	0	0	1
03/04/2015 19:00	0.0	0	0	0	0	1
03/04/2015 20:00	0.0	0	0	0	0	1
03/04/2015 21:00	0.0	0	0	0	0	1
03/04/2015 22:00	0.0	0	0	0	0	1
03/04/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/05/2015 00:00	0.0	0	0	0	0	1
03/05/2015 01:00	0.0	0	0	0	0	1
03/05/2015 02:00	0.0	0	0	0	0	1
03/05/2015 03:00	0.0	0	0	0	0	1
03/05/2015 04:00	0.0	0	0	0	0	1
03/05/2015 05:00	0.0	0	0	0	0	1
03/05/2015 06:00	0.0	0	0	0	0	1
03/05/2015 07:00	0.0	0	0	0	0	1
03/05/2015 08:00	0.0	0	0	0	0	1
03/05/2015 09:00	0.0	0	0	0	0	1
03/05/2015 10:00	0.0	0	0	0	0	1
03/05/2015 11:00	0.0	0	0	0	0	1
03/05/2015 12:00	0.0	0	0	0	0	1
03/05/2015 13:00	0.0	0	0	0	0	1
03/05/2015 14:00	0.0	0	0	0	0	1
03/05/2015 15:00	0.0	0	0	0	0	1
03/05/2015 16:00	0.0	0	0	0	0	1
03/05/2015 17:00	0.0	0	0	0	0	1
03/05/2015 18:00	0.0	0	0	0	0	1
03/05/2015 19:00	0.0	0	0	0	0	1
03/05/2015 20:00	0.0	0	0	0	0	1
03/05/2015 21:00	0.0	0	0	0	0	1
03/05/2015 22:00	0.0	0	0	0	0	1
03/05/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/06/2015 00:00	0.0	0	0	0	0	1
03/06/2015 01:00	0.0	0	0	0	0	1
03/06/2015 02:00	0.0	0	0	0	0	1
03/06/2015 03:00	0.0	0	0	0	0	1
03/06/2015 04:00	0.0	0	0	0	0	1
03/06/2015 05:00	0.0	0	0	0	0	1
03/06/2015 06:00	0.0	0	0	0	0	1
03/06/2015 07:00	0.0	0	0	0	0	1
03/06/2015 08:00	0.0	0	0	0	0	1
03/06/2015 09:00	0.0	0	0	0	0	1
03/06/2015 10:00	0.0	0	0	0	0	1
03/06/2015 11:00	0.0	0	0	0	0	1
03/06/2015 12:00	0.0	0	0	0	0	1
03/06/2015 13:00	0.0	0	0	0	0	1
03/06/2015 14:00	0.0	0	0	0	0	1
03/06/2015 15:00	0.0	0	0	0	0	1
03/06/2015 16:00	0.0	0	0	0	0	1
03/06/2015 17:00	0.0	0	0	0	0	1
03/06/2015 18:00	0.0	0	0	0	0	1
03/06/2015 19:00	0.0	0	0	0	0	1
03/06/2015 20:00	0.0	0	0	0	0	1
03/06/2015 21:00	0.0	0	0	0	0	1
03/06/2015 22:00	0.0	0	0	0	0	1
03/06/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/07/2015 00:00	0.0	0	0	0	0	1
03/07/2015 01:00	0.0	0	0	0	0	1
03/07/2015 02:00	2.3	0	0	0	1	0
03/07/2015 03:00	0.0	0	0	0	0	0
03/07/2015 04:00	0.0	0	0	0	0	0
03/07/2015 05:00	0.0	0	0	0	0	0
03/07/2015 06:00	0.0	0	0	0	0	0
03/07/2015 07:00	0.0	0	0	0	0	0
03/07/2015 08:00	0.0	0	0	0	0	0
03/07/2015 09:00	0.0	0	0	0	0	0
03/07/2015 10:00	0.0	0	0	0	0	0
03/07/2015 11:00	0.0	0	0	0	0	0
03/07/2015 12:00	0.0	0	0	0	0	0
03/07/2015 13:00	0.0	0	0	0	0	0
03/07/2015 14:00	27.0	0	1	0	0	0
03/07/2015 15:00	48.2	0	1	0	0	0
03/07/2015 16:00	0.0	0	0	0	0	1
03/07/2015 17:00	0.0	0	0	0	0	1
03/07/2015 18:00	0.0	0	0	0	0	1
03/07/2015 19:00	0.0	0	0	0	0	1
03/07/2015 20:00	0.0	0	0	0	0	1
03/07/2015 21:00	0.0	0	0	0	0	1
03/07/2015 22:00	0.0	0	0	0	0	1
03/07/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	77.5 #	0 #	2 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	48.2	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/08/2015 00:00	0.0	0	0	0	0	1
03/08/2015 01:00	0.0	0	0	0	0	1
03/08/2015 02:00	0.0	0	0	0	0	1
03/08/2015 03:00	0.0	0	0	0	0	1
03/08/2015 04:00	0.0	0	0	0	0	1
03/08/2015 05:00	0.0	0	0	0	0	1
03/08/2015 06:00	0.0	0	0	0	0	1
03/08/2015 07:00	0.0	0	0	0	0	1
03/08/2015 08:00	2.7	0	0	0	1	0
03/08/2015 09:00	0.0	0	0	0	0	0
03/08/2015 10:00	26.0	0	0	1	0	0
03/08/2015 11:00	21.5	0	0	1	0	0
03/08/2015 12:00	0.0	0	0	0	0	1
03/08/2015 13:00	0.0	0	0	0	0	1
03/08/2015 14:00	0.0	0	0	0	0	1
03/08/2015 15:00	0.0	0	0	0	0	1
03/08/2015 16:00	0.0	0	0	0	0	1
03/08/2015 17:00	0.0	0	0	0	0	1
03/08/2015 18:00	0.0	0	0	0	0	1
03/08/2015 19:00	0.0	0	0	0	0	1
03/08/2015 20:00	0.0	0	0	0	0	1
03/08/2015 21:00	0.0	0	0	0	0	1
03/08/2015 22:00	0.0	0	0	0	0	1
03/08/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	50.2 #	0 #	0 #	2 #	1 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	26.0	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/09/2015 00:00	0.0	0	0	0	0	1
03/09/2015 01:00	0.0	0	0	0	0	1
03/09/2015 02:00	0.0	0	0	0	0	1
03/09/2015 03:00	0.0	0	0	0	0	1
03/09/2015 04:00	0.0	0	0	0	0	1
03/09/2015 05:00	0.0	0	0	0	0	1
03/09/2015 06:00	0.0	0	0	0	0	1
03/09/2015 07:00	0.0	0	0	0	0	1
03/09/2015 08:00	0.0	0	0	0	0	1
03/09/2015 09:00	0.0	0	0	0	0	1
03/09/2015 10:00	0.0	0	0	0	0	1
03/09/2015 11:00	0.0	0	0	0	0	1
03/09/2015 12:00	0.0	0	0	0	0	1
03/09/2015 13:00	0.0	0	0	0	0	1
03/09/2015 14:00	0.0	0	0	0	0	1
03/09/2015 15:00	0.0	0	0	0	0	1
03/09/2015 16:00	0.0	0	0	0	0	1
03/09/2015 17:00	0.0	0	0	0	0	1
03/09/2015 18:00	0.0	0	0	0	0	1
03/09/2015 19:00	0.0	0	0	0	0	1
03/09/2015 20:00	0.0	0	0	0	0	1
03/09/2015 21:00	0.0	0	0	0	0	1
03/09/2015 22:00	0.0	0	0	0	0	1
03/09/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/10/2015 00:00	0.0	0	0	0	0	1
03/10/2015 01:00	0.0	0	0	0	0	1
03/10/2015 02:00	0.0	0	0	0	0	1
03/10/2015 03:00	0.0	0	0	0	0	1
03/10/2015 04:00	0.0	0	0	0	0	1
03/10/2015 05:00	0.0	0	0	0	0	1
03/10/2015 06:00	0.0	0	0	0	0	1
03/10/2015 07:00	0.0	0	0	0	0	1
03/10/2015 08:00	0.0	0	0	0	0	1
03/10/2015 09:00	0.0	0	0	0	0	1
03/10/2015 10:00	0.0	0	0	0	0	1
03/10/2015 11:00	0.0	0	0	0	0	1
03/10/2015 12:00	0.0	0	0	0	0	1
03/10/2015 13:00	0.0	0	0	0	0	1
03/10/2015 14:00	0.0	0	0	0	0	1
03/10/2015 15:00	0.0	0	0	0	0	1
03/10/2015 16:00	0.0	0	0	0	0	1
03/10/2015 17:00	0.0	0	0	0	0	1
03/10/2015 18:00	0.0	0	0	0	0	1
03/10/2015 19:00	0.0	0	0	0	0	1
03/10/2015 20:00	0.0	0	0	0	0	1
03/10/2015 21:00	0.0	0	0	0	0	1
03/10/2015 22:00	0.0	0	0	0	0	1
03/10/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/11/2015 00:00	0.0	0	0	0	0	1
03/11/2015 01:00	0.0	0	0	0	0	1
03/11/2015 02:00	0.0	0	0	0	0	1
03/11/2015 03:00	0.0	0	0	0	0	1
03/11/2015 04:00	0.0	0	0	0	0	1
03/11/2015 05:00	0.0	0	0	0	0	1
03/11/2015 06:00	0.0	0	0	0	0	1
03/11/2015 07:00	0.0	0	0	0	0	1
03/11/2015 08:00	0.0	0	0	0	0	1
03/11/2015 09:00	0.0	0	0	0	0	1
03/11/2015 10:00	0.0	0	0	0	0	1
03/11/2015 11:00	0.0	0	0	0	0	1
03/11/2015 12:00	0.0	0	0	0	0	1
03/11/2015 13:00	0.0	0	0	0	0	1
03/11/2015 14:00	0.0	0	0	0	0	1
03/11/2015 15:00	0.0	0	0	0	0	1
03/11/2015 16:00	0.0	0	0	0	0	1
03/11/2015 17:00	0.0	0	0	0	0	1
03/11/2015 18:00	0.0	0	0	0	0	1
03/11/2015 19:00	0.0	0	0	0	0	1
03/11/2015 20:00	0.0	0	0	0	0	1
03/11/2015 21:00	0.0	0	0	0	0	1
03/11/2015 22:00	0.0	0	0	0	0	1
03/11/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/12/2015 00:00	0.0	0	0	0	0	1
03/12/2015 01:00	0.0	0	0	0	0	1
03/12/2015 02:00	0.0	0	0	0	0	1
03/12/2015 03:00	0.0	0	0	0	0	1
03/12/2015 04:00	0.0	0	0	0	0	1
03/12/2015 05:00	0.0	0	0	0	0	1
03/12/2015 06:00	0.0	0	0	0	0	1
03/12/2015 07:00	0.0	0	0	0	0	1
03/12/2015 08:00	0.0	0	0	0	0	1
03/12/2015 09:00	0.0	0	0	0	0	1
03/12/2015 10:00	0.0	0	0	0	0	1
03/12/2015 11:00	0.0	0	0	0	0	1
03/12/2015 12:00	0.0	0	0	0	0	1
03/12/2015 13:00	0.0	0	0	0	0	1
03/12/2015 14:00	0.0	0	0	0	0	1
03/12/2015 15:00	0.0	0	0	0	0	1
03/12/2015 16:00	0.0	0	0	0	0	1
03/12/2015 17:00	0.0	0	0	0	0	1
03/12/2015 18:00	0.0	0	0	0	0	1
03/12/2015 19:00	0.0	0	0	0	0	1
03/12/2015 20:00	0.0	0	0	0	0	1
03/12/2015 21:00	0.0	0	0	0	0	1
03/12/2015 22:00	0.0	0	0	0	0	1
03/12/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/13/2015 00:00	0.0	0	0	0	0	1
03/13/2015 01:00	0.0	0	0	0	0	1
03/13/2015 02:00	0.0	0	0	0	0	1
03/13/2015 03:00	0.0	0	0	0	0	1
03/13/2015 04:00	0.0	0	0	0	0	1
03/13/2015 05:00	0.0	0	0	0	0	1
03/13/2015 06:00	0.0	0	0	0	0	1
03/13/2015 07:00	0.0	0	0	0	0	1
03/13/2015 08:00	0.0	0	0	0	0	1
03/13/2015 09:00	0.0	0	0	0	0	1
03/13/2015 10:00	0.0	0	0	0	0	1
03/13/2015 11:00	0.0	0	0	0	0	1
03/13/2015 12:00	0.0	0	0	0	0	1
03/13/2015 13:00	0.0	0	0	0	0	1
03/13/2015 14:00	0.0	0	0	0	0	1
03/13/2015 15:00	0.0	0	0	0	0	1
03/13/2015 16:00	0.0	0	0	0	0	1
03/13/2015 17:00	0.0	0	0	0	0	1
03/13/2015 18:00	0.0	0	0	0	0	1
03/13/2015 19:00	0.0	0	0	0	0	1
03/13/2015 20:00	0.0	0	0	0	0	1
03/13/2015 21:00	0.0	0	0	0	0	1
03/13/2015 22:00	0.0	0	0	0	0	1
03/13/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/14/2015 00:00	0.0	0	0	0	0	1
03/14/2015 01:00	0.0	0	0	0	0	1
03/14/2015 02:00	0.0	0	0	0	0	1
03/14/2015 03:00	0.0	0	0	0	0	1
03/14/2015 04:00	0.0	0	0	0	0	1
03/14/2015 05:00	0.0	0	0	0	0	1
03/14/2015 06:00	0.0	0	0	0	0	1
03/14/2015 07:00	0.0	0	0	0	0	1
03/14/2015 08:00	0.0	0	0	0	0	1
03/14/2015 09:00	0.0	0	0	0	0	1
03/14/2015 10:00	0.0	0	0	0	0	1
03/14/2015 11:00	0.0	0	0	0	0	1
03/14/2015 12:00	0.0	0	0	0	0	1
03/14/2015 13:00	0.0	0	0	0	0	1
03/14/2015 14:00	0.0	0	0	0	0	1
03/14/2015 15:00	0.0	0	0	0	0	1
03/14/2015 16:00	0.0	0	0	0	0	1
03/14/2015 17:00	0.0	0	0	0	0	1
03/14/2015 18:00	0.0	0	0	0	0	1
03/14/2015 19:00	0.0	0	0	0	0	1
03/14/2015 20:00	0.0	0	0	0	0	1
03/14/2015 21:00	0.0	0	0	0	0	1
03/14/2015 22:00	0.0	0	0	0	0	1
03/14/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/15/2015 00:00	0.0	0	0	0	0	1
03/15/2015 01:00	0.0	0	0	0	0	1
03/15/2015 02:00	0.0	0	0	0	0	1
03/15/2015 03:00	0.0	0	0	0	0	1
03/15/2015 04:00	0.0	0	0	0	0	1
03/15/2015 05:00	0.0	0	0	0	0	1
03/15/2015 06:00	0.0	0	0	0	0	1
03/15/2015 07:00	0.0	0	0	0	0	1
03/15/2015 08:00	0.0	0	0	0	0	1
03/15/2015 09:00	0.0	0	0	0	0	1
03/15/2015 10:00	0.0	0	0	0	0	1
03/15/2015 11:00	0.0	0	0	0	0	1
03/15/2015 12:00	0.0	0	0	0	0	1
03/15/2015 13:00	0.0	0	0	0	0	1
03/15/2015 14:00	0.0	0	0	0	0	1
03/15/2015 15:00	0.0	0	0	0	0	1
03/15/2015 16:00	0.0	0	0	0	0	1
03/15/2015 17:00	0.0	0	0	0	0	1
03/15/2015 18:00	0.0	0	0	0	0	1
03/15/2015 19:00	0.0	0	0	0	0	1
03/15/2015 20:00	0.0	0	0	0	0	1
03/15/2015 21:00	0.0	0	0	0	0	1
03/15/2015 22:00	0.0	0	0	0	0	1
03/15/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/16/2015 00:00	0.0	0	0	0	0	1
03/16/2015 01:00	0.0	0	0	0	0	1
03/16/2015 02:00	0.0	0	0	0	0	1
03/16/2015 03:00	0.0	0	0	0	0	1
03/16/2015 04:00	0.0	0	0	0	0	1
03/16/2015 05:00	0.0	0	0	0	0	1
03/16/2015 06:00	0.0	0	0	0	0	1
03/16/2015 07:00	0.0	0	0	0	0	1
03/16/2015 08:00	0.0	0	0	0	0	1
03/16/2015 09:00	0.0	0	0	0	0	1
03/16/2015 10:00	0.0	0	0	0	0	1
03/16/2015 11:00	0.0	0	0	0	0	1
03/16/2015 12:00	0.0	0	0	0	0	1
03/16/2015 13:00	0.0	0	0	0	0	1
03/16/2015 14:00	0.0	0	0	0	0	1
03/16/2015 15:00	0.0	0	0	0	0	1
03/16/2015 16:00	0.0	0	0	0	0	1
03/16/2015 17:00	0.0	0	0	0	0	1
03/16/2015 18:00	0.0	0	0	0	0	1
03/16/2015 19:00	0.0	0	0	0	0	1
03/16/2015 20:00	0.0	0	0	0	0	1
03/16/2015 21:00	0.0	0	0	0	0	1
03/16/2015 22:00	0.0	0	0	0	0	1
03/16/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/17/2015 00:00	0.0	0	0	0	0	1
03/17/2015 01:00	0.0	0	0	0	0	1
03/17/2015 02:00	0.0	0	0	0	0	1
03/17/2015 03:00	0.0	0	0	0	0	1
03/17/2015 04:00	0.0	0	0	0	0	1
03/17/2015 05:00	0.0	0	0	0	0	1
03/17/2015 06:00	0.0	0	0	0	0	1
03/17/2015 07:00	0.0	0	0	0	0	1
03/17/2015 08:00	0.0	0	0	0	0	1
03/17/2015 09:00	0.0	0	0	0	0	1
03/17/2015 10:00	0.0	0	0	0	0	1
03/17/2015 11:00	0.0	0	0	0	0	1
03/17/2015 12:00	0.0	0	0	0	0	1
03/17/2015 13:00	0.0	0	0	0	0	1
03/17/2015 14:00	0.0	0	0	0	0	1
03/17/2015 15:00	0.0	0	0	0	0	1
03/17/2015 16:00	0.0	0	0	0	0	1
03/17/2015 17:00	0.0	0	0	0	0	1
03/17/2015 18:00	0.0	0	0	0	0	1
03/17/2015 19:00	0.0	0	0	0	0	1
03/17/2015 20:00	0.0	0	0	0	0	1
03/17/2015 21:00	0.0	0	0	0	0	1
03/17/2015 22:00	0.0	0	0	0	0	1
03/17/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/18/2015 00:00	0.0	0	0	0	0	1
03/18/2015 01:00	0.0	0	0	0	0	1
03/18/2015 02:00	0.0	0	0	0	0	1
03/18/2015 03:00	0.0	0	0	0	0	1
03/18/2015 04:00	0.0	0	0	0	0	1
03/18/2015 05:00	0.0	0	0	0	0	1
03/18/2015 06:00	0.0	0	0	0	0	1
03/18/2015 07:00	0.0	0	0	0	0	1
03/18/2015 08:00	0.0	0	0	0	0	1
03/18/2015 09:00	0.0	0	0	1	0	0
03/18/2015 10:00	0.0	0	0	1	0	0
03/18/2015 11:00	0.0	0	0	1	0	0
03/18/2015 12:00	0.0	0	0	0	0	1
03/18/2015 13:00	0.0	0	0	0	0	1
03/18/2015 14:00	0.0	0	0	0	0	1
03/18/2015 15:00	0.0	0	0	0	0	1
03/18/2015 16:00	0.0	0	0	0	0	1
03/18/2015 17:00	0.0	0	0	0	0	1
03/18/2015 18:00	0.0	0	0	0	0	1
03/18/2015 19:00	0.0	0	0	0	0	1
03/18/2015 20:00	0.0	0	0	0	0	1
03/18/2015 21:00	0.0	0	0	0	0	1
03/18/2015 22:00	0.0	0	0	0	0	1
03/18/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	3 #	0 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	1	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/19/2015 00:00	0.0	0	0	0	0	1
03/19/2015 01:00	0.0	0	0	0	0	1
03/19/2015 02:00	0.0	0	0	0	0	1
03/19/2015 03:00	0.0	0	0	0	0	1
03/19/2015 04:00	0.0	0	0	0	0	1
03/19/2015 05:00	0.0	0	0	0	0	1
03/19/2015 06:00	0.0	0	0	0	0	1
03/19/2015 07:00	0.0	0	0	0	0	1
03/19/2015 08:00	0.0	0	0	0	0	1
03/19/2015 09:00	0.0	0	0	0	0	1
03/19/2015 10:00	0.0	0	0	0	0	1
03/19/2015 11:00	0.0	0	0	0	0	1
03/19/2015 12:00	0.0	0	0	0	0	1
03/19/2015 13:00	0.0	0	0	0	0	1
03/19/2015 14:00	0.0	0	0	0	0	1
03/19/2015 15:00	0.0	0	0	0	0	1
03/19/2015 16:00	0.0	0	0	0	0	1
03/19/2015 17:00	0.0	0	0	0	0	1
03/19/2015 18:00	0.0	0	0	0	0	1
03/19/2015 19:00	0.0	0	0	0	0	1
03/19/2015 20:00	0.0	0	0	0	0	1
03/19/2015 21:00	0.0	0	0	0	0	1
03/19/2015 22:00	0.0	0	0	0	0	1
03/19/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/20/2015 00:00	0.0	0	0	0	0	1
03/20/2015 01:00	0.0	0	0	0	0	1
03/20/2015 02:00	0.0	0	0	0	0	1
03/20/2015 03:00	0.0	0	0	0	0	1
03/20/2015 04:00	0.0	0	0	0	0	1
03/20/2015 05:00	0.0	0	0	0	0	1
03/20/2015 06:00	0.0	0	0	0	0	1
03/20/2015 07:00	0.0	0	0	0	0	1
03/20/2015 08:00	0.0	0	0	0	0	1
03/20/2015 09:00	0.0	0	0	0	0	1
03/20/2015 10:00	0.0	0	0	0	0	1
03/20/2015 11:00	0.0	0	0	0	0	1
03/20/2015 12:00	0.0	0	0	0	0	1
03/20/2015 13:00	0.0	0	0	0	0	1
03/20/2015 14:00	0.0	0	0	0	0	1
03/20/2015 15:00	0.0	0	0	0	0	1
03/20/2015 16:00	0.0	0	0	0	0	1
03/20/2015 17:00	0.0	0	0	0	0	1
03/20/2015 18:00	0.0	0	0	0	0	1
03/20/2015 19:00	0.0	0	0	0	0	1
03/20/2015 20:00	0.0	0	0	0	0	1
03/20/2015 21:00	0.0	0	0	0	0	1
03/20/2015 22:00	0.0	0	0	0	0	1
03/20/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/21/2015 00:00	0.0	0	0	0	0	1
03/21/2015 01:00	0.0	0	0	0	0	1
03/21/2015 02:00	0.0	0	0	0	0	1
03/21/2015 03:00	0.0	0	0	0	0	1
03/21/2015 04:00	0.0	0	0	0	0	1
03/21/2015 05:00	0.0	0	0	0	0	1
03/21/2015 06:00	0.0	0	0	0	0	1
03/21/2015 07:00	0.0	0	0	0	0	1
03/21/2015 08:00	0.0	0	0	0	0	1
03/21/2015 09:00	0.0	0	0	0	0	1
03/21/2015 10:00	0.0	0	0	0	0	1
03/21/2015 11:00	0.0	0	0	0	0	1
03/21/2015 12:00	0.0	0	0	0	0	1
03/21/2015 13:00	0.0	0	0	0	0	1
03/21/2015 14:00	0.0	0	0	0	0	1
03/21/2015 15:00	0.0	0	0	0	0	1
03/21/2015 16:00	0.0	0	0	0	0	1
03/21/2015 17:00	0.0	0	0	0	0	1
03/21/2015 18:00	0.0	0	0	0	0	1
03/21/2015 19:00	0.0	0	0	0	0	1
03/21/2015 20:00	0.0	0	0	0	0	1
03/21/2015 21:00	0.0	0	0	0	0	1
03/21/2015 22:00	0.0	0	0	0	0	1
03/21/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/22/2015 00:00	0.0	0	0	0	0	1
03/22/2015 01:00	0.0	0	0	0	0	1
03/22/2015 02:00	0.0	0	0	0	0	1
03/22/2015 03:00	0.0	0	0	0	0	1
03/22/2015 04:00	0.0	0	0	0	0	1
03/22/2015 05:00	0.0	0	0	0	0	1
03/22/2015 06:00	0.0	0	0	0	0	1
03/22/2015 07:00	0.0	0	0	0	0	1
03/22/2015 08:00	0.0	0	0	0	0	1
03/22/2015 09:00	0.0	0	0	0	0	1
03/22/2015 10:00	0.0	0	0	0	0	1
03/22/2015 11:00	0.0	0	0	0	0	1
03/22/2015 12:00	0.0	0	0	0	0	1
03/22/2015 13:00	0.0	0	0	0	0	1
03/22/2015 14:00	0.0	0	0	0	0	1
03/22/2015 15:00	0.0	0	0	0	0	1
03/22/2015 16:00	0.0	0	0	0	0	1
03/22/2015 17:00	0.0	0	0	0	0	1
03/22/2015 18:00	0.0	0	0	0	0	1
03/22/2015 19:00	0.0	0	0	0	0	1
03/22/2015 20:00	0.0	0	0	0	0	1
03/22/2015 21:00	0.0	0	0	0	0	1
03/22/2015 22:00	0.0	0	0	0	0	1
03/22/2015 23:00	3.0	0	0	0	1	0
Average/Sum#:	3.0 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3.0	0	0	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/23/2015 00:00	0.0	0	0	0	0	0
03/23/2015 01:00	0.0	0	0	0	0	0
03/23/2015 02:00	0.0	0	0	0	0	0
03/23/2015 03:00	0.0	0	0	0	0	0
03/23/2015 04:00	0.0	0	0	0	0	0
03/23/2015 05:00	0.0	0	0	0	0	0
03/23/2015 06:00	0.0	0	0	0	0	0
03/23/2015 07:00	0.0	0	0	0	0	0
03/23/2015 08:00	0.0	0	0	0	0	0
03/23/2015 09:00	0.0	0	0	0	0	0
03/23/2015 10:00	0.0	0	0	0	0	0
03/23/2015 11:00	0.0	0	0	0	0	0
03/23/2015 12:00	0.0	0	0	0	0	0
03/23/2015 13:00	0.0	0	0	0	0	0
03/23/2015 14:00	0.0	0	0	0	0	0
03/23/2015 15:00	0.0	0	0	0	0	0
03/23/2015 16:00	0.0	0	0	0	0	0
03/23/2015 17:00	0.0	0	0	0	0	0
03/23/2015 18:00	0.0	0	0	0	0	0
03/23/2015 19:00	0.0	0	0	0	0	0
03/23/2015 20:00	0.0	0	0	0	0	0
03/23/2015 21:00	0.0	0	0	0	0	0
03/23/2015 22:00	0.0	0	0	0	0	0
03/23/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/24/2015 00:00	0.0	0	0	0	0	0
03/24/2015 01:00	0.0	0	0	0	0	0
03/24/2015 02:00	0.0	0	0	0	0	0
03/24/2015 03:00	0.0	0	0	0	0	0
03/24/2015 04:00	0.0	0	0	0	0	0
03/24/2015 05:00	0.0	0	0	0	0	0
03/24/2015 06:00	0.0	0	0	0	0	0
03/24/2015 07:00	0.0	0	0	0	0	0
03/24/2015 08:00	0.0	0	0	0	0	0
03/24/2015 09:00	0.0	0	0	0	0	0
03/24/2015 10:00	0.0	0	0	0	0	0
03/24/2015 11:00	0.0	0	0	0	0	0
03/24/2015 12:00	0.0	0	0	0	0	0
03/24/2015 13:00	0.0	0	0	0	0	0
03/24/2015 14:00	0.0	0	0	0	0	0
03/24/2015 15:00	0.0	0	0	0	0	0
03/24/2015 16:00	0.0	0	0	0	0	0
03/24/2015 17:00	0.0	0	0	0	0	0
03/24/2015 18:00	0.0	0	0	0	0	0
03/24/2015 19:00	0.0	0	0	0	0	0
03/24/2015 20:00	0.0	0	0	0	0	0
03/24/2015 21:00	0.0	0	0	0	0	0
03/24/2015 22:00	0.0	0	0	0	0	0
03/24/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/25/2015 00:00	0.0	0	0	0	0	0
03/25/2015 01:00	0.0	0	0	0	0	0
03/25/2015 02:00	0.0	0	0	0	0	0
03/25/2015 03:00	0.0	0	0	0	0	0
03/25/2015 04:00	0.0	0	0	0	0	0
03/25/2015 05:00	0.0	0	0	0	0	0
03/25/2015 06:00	0.0	0	0	0	0	0
03/25/2015 07:00	0.0	0	0	0	0	0
03/25/2015 08:00	0.0	0	0	0	0	0
03/25/2015 09:00	0.0	0	0	0	0	0
03/25/2015 10:00	0.0	0	0	0	0	0
03/25/2015 11:00	0.0	0	0	0	0	0
03/25/2015 12:00	0.0	0	0	0	0	0
03/25/2015 13:00	0.0	0	0	0	0	0
03/25/2015 14:00	0.0	0	0	0	0	0
03/25/2015 15:00	0.0	0	0	0	0	0
03/25/2015 16:00	0.0	0	0	0	0	0
03/25/2015 17:00	0.0	0	0	0	0	0
03/25/2015 18:00	0.0	0	0	0	0	0
03/25/2015 19:00	0.0	0	0	0	0	0
03/25/2015 20:00	0.0	0	0	0	0	0
03/25/2015 21:00	0.0	0	0	0	0	0
03/25/2015 22:00	0.0	0	0	0	0	0
03/25/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/26/2015 00:00	0.0	0	0	0	0	0
03/26/2015 01:00	0.0	0	0	0	0	0
03/26/2015 02:00	0.0	0	0	0	0	0
03/26/2015 03:00	0.0	0	0	0	0	0
03/26/2015 04:00	0.0	0	0	0	0	0
03/26/2015 05:00	0.0	0	0	0	0	0
03/26/2015 06:00	0.0	0	0	0	0	0
03/26/2015 07:00	0.0	0	0	0	0	0
03/26/2015 08:00	0.0	0	0	0	0	0
03/26/2015 09:00	0.0	0	0	0	0	0
03/26/2015 10:00	0.0	0	0	0	0	0
03/26/2015 11:00	0.0	0	0	0	0	0
03/26/2015 12:00	0.0	0	0	0	0	0
03/26/2015 13:00	0.0	0	0	0	0	0
03/26/2015 14:00	0.0	0	0	0	0	0
03/26/2015 15:00	0.0	0	0	0	0	0
03/26/2015 16:00	0.0	0	0	0	0	0
03/26/2015 17:00	0.0	0	0	0	0	0
03/26/2015 18:00	0.0	0	0	0	0	0
03/26/2015 19:00	0.0	0	0	0	0	0
03/26/2015 20:00	0.0	0	0	0	0	0
03/26/2015 21:00	0.0	0	0	0	0	0
03/26/2015 22:00	0.0	0	0	0	0	0
03/26/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/27/2015 00:00	0.0	0	0	0	0	0
03/27/2015 01:00	0.0	0	0	0	0	0
03/27/2015 02:00	0.0	0	0	0	0	0
03/27/2015 03:00	0.0	0	0	0	0	0
03/27/2015 04:00	0.0	0	0	0	0	0
03/27/2015 05:00	0.0	0	0	0	0	0
03/27/2015 06:00	0.0	0	0	0	0	0
03/27/2015 07:00	0.0	0	0	0	0	0
03/27/2015 08:00	0.0	0	0	0	0	0
03/27/2015 09:00	0.0	0	0	0	0	0
03/27/2015 10:00	0.0	0	0	0	0	0
03/27/2015 11:00	0.0	0	0	0	0	0
03/27/2015 12:00	0.0	0	0	0	0	0
03/27/2015 13:00	0.0	0	0	0	0	0
03/27/2015 14:00	0.0	0	0	0	0	0
03/27/2015 15:00	0.0	0	0	0	0	0
03/27/2015 16:00	0.0	0	0	0	0	0
03/27/2015 17:00	0.0	0	0	0	0	0
03/27/2015 18:00	0.0	0	0	0	0	0
03/27/2015 19:00	0.0	0	0	0	0	0
03/27/2015 20:00	0.0	0	0	0	0	0
03/27/2015 21:00	0.0	0	0	0	0	0
03/27/2015 22:00	0.0	0	0	0	0	0
03/27/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/28/2015 00:00	0.0	0	0	0	0	0
03/28/2015 01:00	0.0	0	0	0	0	0
03/28/2015 02:00	0.0	0	0	0	0	0
03/28/2015 03:00	0.0	0	0	0	0	0
03/28/2015 04:00	0.0	0	0	0	0	0
03/28/2015 05:00	0.0	0	0	0	0	0
03/28/2015 06:00	0.0	0	0	0	0	0
03/28/2015 07:00	0.0	0	0	0	0	0
03/28/2015 08:00	0.0	0	0	0	0	0
03/28/2015 09:00	0.0	0	0	0	0	0
03/28/2015 10:00	0.0	0	0	0	0	0
03/28/2015 11:00	0.0	0	0	0	0	0
03/28/2015 12:00	0.0	0	0	0	0	0
03/28/2015 13:00	0.0	0	0	0	0	0
03/28/2015 14:00	0.0	0	0	0	0	0
03/28/2015 15:00	0.0	0	0	0	0	0
03/28/2015 16:00	0.0	0	0	0	0	0
03/28/2015 17:00	0.0	0	0	0	0	0
03/28/2015 18:00	0.0	0	0	0	0	0
03/28/2015 19:00	0.0	0	0	0	0	0
03/28/2015 20:00	0.0	0	0	0	0	0
03/28/2015 21:00	0.0	0	0	0	0	0
03/28/2015 22:00	0.0	0	0	0	0	0
03/28/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/29/2015 00:00	0.0	0	0	0	0	0
03/29/2015 01:00	0.0	0	0	0	0	0
03/29/2015 02:00	0.0	0	0	0	0	0
03/29/2015 03:00	0.0	0	0	0	0	0
03/29/2015 04:00	0.0	0	0	0	0	0
03/29/2015 05:00	0.0	0	0	0	0	0
03/29/2015 06:00	0.0	0	0	0	0	0
03/29/2015 07:00	0.0	0	0	0	0	0
03/29/2015 08:00	0.0	0	0	0	0	0
03/29/2015 09:00	0.0	0	0	0	0	0
03/29/2015 10:00	0.0	0	0	0	0	0
03/29/2015 11:00	0.0	0	0	0	0	0
03/29/2015 12:00	0.0	0	0	0	0	0
03/29/2015 13:00	0.0	0	0	0	0	0
03/29/2015 14:00	0.0	0	0	0	0	0
03/29/2015 15:00	0.0	0	0	0	0	0
03/29/2015 16:00	0.0	0	0	0	0	0
03/29/2015 17:00	0.0	0	0	0	0	0
03/29/2015 18:00	0.0	0	0	0	0	0
03/29/2015 19:00	0.0	0	0	0	0	0
03/29/2015 20:00	0.0	0	0	0	0	0
03/29/2015 21:00	0.0	0	0	0	0	0
03/29/2015 22:00	0.0	0	0	0	0	0
03/29/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/30/2015 00:00	0.0	0	0	0	0	0
03/30/2015 01:00	0.0	0	0	0	0	0
03/30/2015 02:00	0.0	0	0	0	0	0
03/30/2015 03:00	0.0	0	0	0	0	0
03/30/2015 04:00	0.0	0	0	0	0	0
03/30/2015 05:00	0.0	0	0	0	0	0
03/30/2015 06:00	0.0	0	0	0	0	0
03/30/2015 07:00	0.0	0	0	0	0	0
03/30/2015 08:00	0.0	0	0	0	0	0
03/30/2015 09:00	0.0	0	0	0	0	0
03/30/2015 10:00	0.0	0	0	0	0	0
03/30/2015 11:00	0.0	0	0	0	0	0
03/30/2015 12:00	0.0	0	0	0	0	0
03/30/2015 13:00	0.0	0	0	0	0	0
03/30/2015 14:00	0.0	0	0	0	0	0
03/30/2015 15:00	0.0	0	0	0	0	0
03/30/2015 16:00	0.0	0	0	0	0	0
03/30/2015 17:00	0.0	0	0	0	0	0
03/30/2015 18:00	0.0	0	0	0	0	0
03/30/2015 19:00	0.0	0	0	0	0	0
03/30/2015 20:00	0.0	0	0	0	0	0
03/30/2015 21:00	0.0	0	0	0	0	0
03/30/2015 22:00	0.0	0	0	0	0	0
03/30/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/31/2015 00:00	0.0	0	0	0	0	0
03/31/2015 01:00	0.0	0	0	0	0	0
03/31/2015 02:00	0.0	0	0	0	0	0
03/31/2015 03:00	0.0	0	0	0	0	0
03/31/2015 04:00	0.0	0	0	0	0	0
03/31/2015 05:00	0.0	0	0	0	0	0
03/31/2015 06:00	0.0	0	0	0	0	0
03/31/2015 07:00	0.0	0	0	0	0	0
03/31/2015 08:00	0.0	0	0	0	0	0
03/31/2015 09:00	0.0	0	0	0	0	0
03/31/2015 10:00	0.0	0	0	0	0	0
03/31/2015 11:00	0.0	0	0	0	0	0
03/31/2015 12:00	0.0	0	0	0	0	0
03/31/2015 13:00	0.0	0	0	0	0	0
03/31/2015 14:00	0.0	0	0	0	0	0
03/31/2015 15:00	0.0	0	0	0	0	0
03/31/2015 16:00	0.0	0	0	0	0	0
03/31/2015 17:00	0.0	0	0	0	0	0
03/31/2015 18:00	0.0	0	0	0	0	0
03/31/2015 19:00	0.0	0	0	0	0	0
03/31/2015 20:00	0.0	0	0	0	0	0
03/31/2015 21:00	0.0	0	0	0	0	0
03/31/2015 22:00	0.0	0	0	0	0	0
03/31/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/01/2015 00:00	0.0	0	0	0	0	1
01/01/2015 01:00	0.0	0	0	0	0	1
01/01/2015 02:00	0.0	0	0	0	0	1
01/01/2015 03:00	0.0	0	0	0	0	1
01/01/2015 04:00	0.0	0	0	0	0	1
01/01/2015 05:00	0.0	0	0	0	0	1
01/01/2015 06:00	0.0	0	0	0	0	1
01/01/2015 07:00	0.0	0	0	0	0	1
01/01/2015 08:00	0.0	0	0	0	0	1
01/01/2015 09:00	0.0	0	0	0	0	1
01/01/2015 10:00	0.0	0	0	0	0	1
01/01/2015 11:00	0.0	0	0	0	0	1
01/01/2015 12:00	0.0	0	0	0	0	1
01/01/2015 13:00	0.0	0	0	0	0	1
01/01/2015 14:00	0.0	0	0	0	0	1
01/01/2015 15:00	0.0	0	0	0	0	1
01/01/2015 16:00	0.0	0	0	0	0	1
01/01/2015 17:00	0.0	0	0	0	0	1
01/01/2015 18:00	0.0	0	0	0	0	1
01/01/2015 19:00	0.0	0	0	0	0	1
01/01/2015 20:00	0.0	0	0	0	0	1
01/01/2015 21:00	0.0	0	0	0	0	1
01/01/2015 22:00	0.0	0	0	0	0	1
01/01/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/02/2015 00:00	0.0	0	0	0	0	1
01/02/2015 01:00	0.0	0	0	0	0	1
01/02/2015 02:00	0.0	0	0	0	0	1
01/02/2015 03:00	0.0	0	0	0	0	1
01/02/2015 04:00	0.0	0	0	0	0	1
01/02/2015 05:00	0.0	0	0	0	0	1
01/02/2015 06:00	0.0	0	0	0	0	1
01/02/2015 07:00	0.0	0	0	0	0	1
01/02/2015 08:00	0.0	0	0	0	0	1
01/02/2015 09:00	0.0	0	0	0	0	1
01/02/2015 10:00	0.0	0	0	0	0	1
01/02/2015 11:00	0.0	0	0	0	0	1
01/02/2015 12:00	0.0	0	0	0	0	1
01/02/2015 13:00	0.0	0	0	0	0	1
01/02/2015 14:00	0.0	0	0	0	0	1
01/02/2015 15:00	0.0	0	0	0	0	1
01/02/2015 16:00	0.0	0	0	0	0	1
01/02/2015 17:00	0.0	0	0	0	0	1
01/02/2015 18:00	0.0	0	0	0	0	1
01/02/2015 19:00	0.0	0	0	0	0	1
01/02/2015 20:00	0.0	0	0	0	0	1
01/02/2015 21:00	0.0	0	0	0	0	1
01/02/2015 22:00	0.0	0	0	0	0	1
01/02/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/03/2015 00:00	0.0	0	0	0	0	1
01/03/2015 01:00	0.0	0	0	0	0	1
01/03/2015 02:00	0.0	0	0	0	0	1
01/03/2015 03:00	0.0	0	0	0	0	1
01/03/2015 04:00	0.0	0	0	0	0	1
01/03/2015 05:00	0.0	0	0	0	0	1
01/03/2015 06:00	0.0	0	0	0	0	1
01/03/2015 07:00	0.0	0	0	0	0	1
01/03/2015 08:00	0.0	0	0	0	0	1
01/03/2015 09:00	0.0	0	0	0	0	1
01/03/2015 10:00	0.0	0	0	0	0	1
01/03/2015 11:00	0.0	0	0	0	0	1
01/03/2015 12:00	0.0	0	0	0	0	1
01/03/2015 13:00	0.0	0	0	0	0	1
01/03/2015 14:00	0.0	0	0	0	0	1
01/03/2015 15:00	0.0	0	0	0	0	1
01/03/2015 16:00	0.0	0	0	0	0	1
01/03/2015 17:00	0.0	0	0	0	0	1
01/03/2015 18:00	0.0	0	0	0	0	1
01/03/2015 19:00	0.0	0	0	0	0	1
01/03/2015 20:00	0.0	0	0	0	0	1
01/03/2015 21:00	0.0	0	0	0	0	1
01/03/2015 22:00	0.0	0	0	0	0	1
01/03/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/04/2015 00:00	0.0	0	0	0	0	1
01/04/2015 01:00	0.0	0	0	0	0	1
01/04/2015 02:00	0.0	0	0	0	0	1
01/04/2015 03:00	0.0	0	0	0	0	1
01/04/2015 04:00	0.0	0	0	0	0	1
01/04/2015 05:00	0.0	0	0	0	0	1
01/04/2015 06:00	0.0	0	0	0	0	1
01/04/2015 07:00	0.0	0	0	0	0	1
01/04/2015 08:00	0.0	0	0	0	0	1
01/04/2015 09:00	0.0	0	0	0	0	1
01/04/2015 10:00	0.0	0	0	0	0	1
01/04/2015 11:00	0.0	0	0	0	0	1
01/04/2015 12:00	0.0	0	0	0	0	1
01/04/2015 13:00	0.0	0	0	0	0	1
01/04/2015 14:00	0.0	0	0	0	0	1
01/04/2015 15:00	0.0	0	0	0	0	1
01/04/2015 16:00	0.0	0	0	0	0	1
01/04/2015 17:00	0.0	0	0	0	0	1
01/04/2015 18:00	0.0	0	0	0	0	1
01/04/2015 19:00	0.0	0	0	0	0	1
01/04/2015 20:00	0.0	0	0	0	0	1
01/04/2015 21:00	0.0	0	0	0	0	1
01/04/2015 22:00	0.0	0	0	0	0	1
01/04/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/05/2015 00:00	0.0	0	0	0	0	1
01/05/2015 01:00	0.0	0	0	0	0	1
01/05/2015 02:00	0.0	0	0	0	0	1
01/05/2015 03:00	0.0	0	0	0	0	1
01/05/2015 04:00	0.0	0	0	0	0	1
01/05/2015 05:00	0.0	0	0	0	0	1
01/05/2015 06:00	0.0	0	0	0	0	1
01/05/2015 07:00	0.0	0	0	0	0	1
01/05/2015 08:00	0.0	0	0	0	0	1
01/05/2015 09:00	0.0	0	0	0	0	1
01/05/2015 10:00	0.0	0	0	0	0	1
01/05/2015 11:00	0.0	0	0	0	0	1
01/05/2015 12:00	0.0	0	0	0	0	1
01/05/2015 13:00	0.0	0	0	0	0	1
01/05/2015 14:00	0.0	0	0	0	0	1
01/05/2015 15:00	0.0	0	0	0	0	1
01/05/2015 16:00	0.0	0	0	0	0	1
01/05/2015 17:00	0.0	0	0	0	0	1
01/05/2015 18:00	0.0	0	0	0	0	1
01/05/2015 19:00	0.0	0	0	0	0	1
01/05/2015 20:00	0.0	0	0	0	0	1
01/05/2015 21:00	0.0	0	0	0	0	1
01/05/2015 22:00	0.0	0	0	0	0	1
01/05/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/06/2015 00:00	0.0	0	0	0	0	1
01/06/2015 01:00	0.0	0	0	0	0	1
01/06/2015 02:00	0.0	0	0	0	0	1
01/06/2015 03:00	0.0	0	0	0	0	1
01/06/2015 04:00	0.0	0	0	0	0	1
01/06/2015 05:00	0.0	0	0	0	0	1
01/06/2015 06:00	0.0	0	0	0	0	1
01/06/2015 07:00	0.0	0	0	0	0	1
01/06/2015 08:00	0.0	0	0	0	0	1
01/06/2015 09:00	0.0	0	0	0	0	1
01/06/2015 10:00	0.0	0	0	0	0	1
01/06/2015 11:00	0.0	0	0	0	0	1
01/06/2015 12:00	0.0	0	0	0	0	1
01/06/2015 13:00	0.0	0	0	0	0	1
01/06/2015 14:00	0.0	0	0	0	0	1
01/06/2015 15:00	0.0	0	0	0	0	1
01/06/2015 16:00	0.0	0	0	0	0	1
01/06/2015 17:00	0.0	0	0	0	0	1
01/06/2015 18:00	0.0	0	0	0	0	1
01/06/2015 19:00	0.0	0	0	0	0	1
01/06/2015 20:00	0.0	0	0	0	0	1
01/06/2015 21:00	0.0	0	0	0	0	1
01/06/2015 22:00	0.0	0	0	0	0	1
01/06/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/07/2015 00:00	0.0	0	0	0	0	1
01/07/2015 01:00	0.0	0	0	0	0	1
01/07/2015 02:00	0.0	0	0	0	0	1
01/07/2015 03:00	0.0	0	0	0	0	1
01/07/2015 04:00	0.0	0	0	0	0	1
01/07/2015 05:00	0.0	0	0	0	0	1
01/07/2015 06:00	0.0	0	0	0	0	1
01/07/2015 07:00	0.0	0	0	0	0	1
01/07/2015 08:00	0.0	0	0	0	0	1
01/07/2015 09:00	0.0	0	0	0	0	1
01/07/2015 10:00	0.0	0	0	0	0	1
01/07/2015 11:00	0.0	0	0	0	0	1
01/07/2015 12:00	0.0	0	0	0	0	1
01/07/2015 13:00	0.0	0	0	0	0	1
01/07/2015 14:00	0.0	0	0	0	0	1
01/07/2015 15:00	0.0	0	0	0	0	1
01/07/2015 16:00	0.0	0	0	0	0	1
01/07/2015 17:00	0.0	0	0	0	0	1
01/07/2015 18:00	0.0	0	0	0	0	1
01/07/2015 19:00	0.0	0	0	0	0	1
01/07/2015 20:00	0.0	0	0	0	0	1
01/07/2015 21:00	0.0	0	0	0	0	1
01/07/2015 22:00	0.0	0	0	0	0	1
01/07/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/08/2015 00:00	0.0	0	0	0	0	1
01/08/2015 01:00	0.0	0	0	0	0	1
01/08/2015 02:00	0.0	0	0	0	0	1
01/08/2015 03:00	0.0	0	0	0	0	1
01/08/2015 04:00	0.0	0	0	0	0	1
01/08/2015 05:00	0.0	0	0	0	0	1
01/08/2015 06:00	0.0	0	0	0	0	1
01/08/2015 07:00	0.0	0	0	0	0	1
01/08/2015 08:00	0.0	0	0	0	0	1
01/08/2015 09:00	0.0	0	0	0	0	1
01/08/2015 10:00	0.0	0	0	0	0	1
01/08/2015 11:00	0.0	0	0	0	0	1
01/08/2015 12:00	0.0	0	0	0	0	1
01/08/2015 13:00	0.0	0	0	0	0	1
01/08/2015 14:00	0.0	0	0	0	0	1
01/08/2015 15:00	0.0	0	0	0	0	1
01/08/2015 16:00	0.0	0	0	0	0	1
01/08/2015 17:00	0.0	0	0	0	0	1
01/08/2015 18:00	0.0	0	0	0	0	1
01/08/2015 19:00	0.0	0	0	0	0	1
01/08/2015 20:00	0.0	0	0	0	0	1
01/08/2015 21:00	0.0	0	0	0	0	1
01/08/2015 22:00	0.0	0	0	0	0	1
01/08/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/09/2015 00:00	0.0	0	0	0	0	1
01/09/2015 01:00	0.0	0	0	0	0	1
01/09/2015 02:00	0.0	0	0	0	0	1
01/09/2015 03:00	0.0	0	0	0	0	1
01/09/2015 04:00	0.0	0	0	0	0	1
01/09/2015 05:00	0.0	0	0	0	0	1
01/09/2015 06:00	0.0	0	0	0	0	1
01/09/2015 07:00	0.0	0	0	0	0	1
01/09/2015 08:00	0.0	0	0	0	0	1
01/09/2015 09:00	0.0	0	0	0	0	1
01/09/2015 10:00	0.0	0	0	0	0	1
01/09/2015 11:00	0.0	0	0	0	0	1
01/09/2015 12:00	0.0	0	0	0	0	1
01/09/2015 13:00	0.0	0	0	0	0	1
01/09/2015 14:00	0.0	0	0	0	0	1
01/09/2015 15:00	0.0	0	0	0	0	1
01/09/2015 16:00	0.0	0	0	0	0	1
01/09/2015 17:00	0.0	0	0	0	0	1
01/09/2015 18:00	0.0	0	0	0	0	1
01/09/2015 19:00	0.0	0	0	0	0	1
01/09/2015 20:00	0.0	0	0	0	0	1
01/09/2015 21:00	0.0	0	0	0	0	1
01/09/2015 22:00	0.0	0	0	0	0	1
01/09/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/10/2015 00:00	0.0	0	0	0	0	1
01/10/2015 01:00	0.0	0	0	0	0	1
01/10/2015 02:00	0.0	0	0	0	0	1
01/10/2015 03:00	0.0	0	0	0	0	1
01/10/2015 04:00	0.0	0	0	0	0	1
01/10/2015 05:00	0.0	0	0	0	0	1
01/10/2015 06:00	0.0	0	0	0	0	1
01/10/2015 07:00	0.0	0	0	0	0	1
01/10/2015 08:00	0.0	0	0	0	0	1
01/10/2015 09:00	0.0	0	0	0	0	1
01/10/2015 10:00	0.0	0	0	0	0	1
01/10/2015 11:00	0.0	0	0	0	0	1
01/10/2015 12:00	0.0	0	0	0	0	1
01/10/2015 13:00	0.0	0	0	0	0	1
01/10/2015 14:00	0.0	0	0	0	0	1
01/10/2015 15:00	0.0	0	0	0	0	1
01/10/2015 16:00	0.0	0	0	0	0	1
01/10/2015 17:00	0.0	0	0	0	0	1
01/10/2015 18:00	0.0	0	0	0	0	1
01/10/2015 19:00	0.0	0	0	0	0	1
01/10/2015 20:00	0.0	0	0	0	0	1
01/10/2015 21:00	0.0	0	0	0	0	1
01/10/2015 22:00	0.0	0	0	0	0	1
01/10/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/11/2015 00:00	0.0	0	0	0	0	1
01/11/2015 01:00	0.0	0	0	0	0	1
01/11/2015 02:00	0.0	0	0	0	0	1
01/11/2015 03:00	0.0	0	0	0	0	1
01/11/2015 04:00	0.0	0	0	0	0	1
01/11/2015 05:00	0.0	0	0	0	0	1
01/11/2015 06:00	0.0	0	0	0	0	1
01/11/2015 07:00	0.0	0	0	0	0	1
01/11/2015 08:00	0.0	0	0	0	0	1
01/11/2015 09:00	0.0	0	0	0	0	1
01/11/2015 10:00	0.0	0	0	0	0	1
01/11/2015 11:00	0.0	0	0	0	0	1
01/11/2015 12:00	0.0	0	0	0	0	1
01/11/2015 13:00	0.0	0	0	0	0	1
01/11/2015 14:00	0.0	0	0	0	0	1
01/11/2015 15:00	0.0	0	0	0	0	1
01/11/2015 16:00	0.0	0	0	0	0	1
01/11/2015 17:00	0.0	0	0	0	0	1
01/11/2015 18:00	0.0	0	0	0	0	1
01/11/2015 19:00	0.0	0	0	0	0	1
01/11/2015 20:00	0.0	0	0	0	0	1
01/11/2015 21:00	0.0	0	0	0	0	1
01/11/2015 22:00	0.0	0	0	0	0	1
01/11/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/12/2015 00:00	0.0	0	0	0	0	1
01/12/2015 01:00	0.0	0	0	0	0	1
01/12/2015 02:00	0.0	0	0	0	0	1
01/12/2015 03:00	0.0	0	0	0	0	1
01/12/2015 04:00	0.0	0	0	0	0	1
01/12/2015 05:00	0.0	0	0	0	0	1
01/12/2015 06:00	0.0	0	0	0	0	1
01/12/2015 07:00	0.0	0	0	0	0	1
01/12/2015 08:00	0.0	0	0	0	0	1
01/12/2015 09:00	0.0	0	0	0	0	1
01/12/2015 10:00	0.0	0	0	0	0	1
01/12/2015 11:00	0.0	0	0	0	0	1
01/12/2015 12:00	0.0	0	0	0	0	1
01/12/2015 13:00	0.0	0	0	0	0	1
01/12/2015 14:00	0.0	0	0	0	0	1
01/12/2015 15:00	0.0	0	0	0	0	1
01/12/2015 16:00	0.0	0	0	0	0	1
01/12/2015 17:00	0.0	0	0	0	0	1
01/12/2015 18:00	0.0	0	0	0	0	1
01/12/2015 19:00	0.0	0	0	0	0	1
01/12/2015 20:00	0.0	0	0	0	0	1
01/12/2015 21:00	0.0	0	0	0	0	1
01/12/2015 22:00	0.0	0	0	0	0	1
01/12/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/13/2015 00:00	0.0	0	0	0	0	1
01/13/2015 01:00	0.0	0	0	0	0	1
01/13/2015 02:00	0.0	0	0	0	0	1
01/13/2015 03:00	0.0	0	0	0	0	1
01/13/2015 04:00	0.0	0	0	0	0	1
01/13/2015 05:00	0.0	0	0	0	0	1
01/13/2015 06:00	0.0	0	0	0	0	1
01/13/2015 07:00	0.0	0	0	0	0	1
01/13/2015 08:00	0.0	0	0	0	0	1
01/13/2015 09:00	0.0	0	0	0	0	1
01/13/2015 10:00	0.0	0	0	0	0	1
01/13/2015 11:00	0.0	0	0	0	0	1
01/13/2015 12:00	0.0	0	0	0	0	1
01/13/2015 13:00	0.0	0	0	0	0	1
01/13/2015 14:00	0.0	0	0	0	0	1
01/13/2015 15:00	0.0	0	0	0	0	1
01/13/2015 16:00	0.0	0	0	0	0	1
01/13/2015 17:00	0.0	0	0	0	0	1
01/13/2015 18:00	0.0	0	0	0	0	1
01/13/2015 19:00	0.0	0	0	0	0	1
01/13/2015 20:00	0.0	0	0	0	0	1
01/13/2015 21:00	0.0	0	0	0	0	1
01/13/2015 22:00	0.0	0	0	0	0	1
01/13/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/14/2015 00:00	0.0	0	0	0	0	1
01/14/2015 01:00	0.0	0	0	0	0	1
01/14/2015 02:00	0.0	0	0	0	0	1
01/14/2015 03:00	0.0	0	0	0	0	1
01/14/2015 04:00	0.0	0	0	0	0	1
01/14/2015 05:00	0.0	0	0	0	0	1
01/14/2015 06:00	0.0	0	0	0	0	1
01/14/2015 07:00	0.0	0	0	0	0	1
01/14/2015 08:00	0.0	0	0	0	0	1
01/14/2015 09:00	0.0	0	0	0	0	1
01/14/2015 10:00	0.0	0	0	0	0	1
01/14/2015 11:00	0.0	0	0	0	0	1
01/14/2015 12:00	0.0	0	0	0	0	1
01/14/2015 13:00	0.0	0	0	0	0	1
01/14/2015 14:00	0.0	0	0	0	0	1
01/14/2015 15:00	0.0	0	0	0	0	1
01/14/2015 16:00	0.0	0	0	0	0	1
01/14/2015 17:00	0.0	0	0	0	0	1
01/14/2015 18:00	0.0	0	0	0	0	1
01/14/2015 19:00	0.0	0	0	0	0	1
01/14/2015 20:00	0.0	0	0	0	0	1
01/14/2015 21:00	0.0	0	0	0	0	1
01/14/2015 22:00	0.0	0	0	0	0	1
01/14/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/15/2015 00:00	0.0	0	0	0	0	1
01/15/2015 01:00	0.0	0	0	0	0	1
01/15/2015 02:00	0.0	0	0	0	0	1
01/15/2015 03:00	0.0	0	0	0	0	1
01/15/2015 04:00	0.0	0	0	0	0	1
01/15/2015 05:00	0.0	0	0	0	0	1
01/15/2015 06:00	0.0	0	0	0	0	1
01/15/2015 07:00	0.0	0	0	0	0	1
01/15/2015 08:00	0.0	0	0	0	0	1
01/15/2015 09:00	0.0	0	0	0	0	1
01/15/2015 10:00	0.0	0	0	0	0	1
01/15/2015 11:00	0.0	0	0	0	0	1
01/15/2015 12:00	0.0	0	0	0	0	1
01/15/2015 13:00	0.0	0	0	0	0	1
01/15/2015 14:00	0.0	0	0	0	0	1
01/15/2015 15:00	0.0	0	0	0	0	1
01/15/2015 16:00	0.0	0	0	0	0	1
01/15/2015 17:00	0.0	0	0	0	0	1
01/15/2015 18:00	0.0	0	0	0	0	1
01/15/2015 19:00	0.0	0	0	0	0	1
01/15/2015 20:00	0.0	0	0	0	0	1
01/15/2015 21:00	0.0	0	0	0	0	1
01/15/2015 22:00	0.0	0	0	0	0	1
01/15/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/16/2015 00:00	0.0	0	0	0	0	1
01/16/2015 01:00	0.0	0	0	0	0	1
01/16/2015 02:00	0.0	0	0	0	0	1
01/16/2015 03:00	0.0	0	0	0	0	1
01/16/2015 04:00	0.0	0	0	0	0	1
01/16/2015 05:00	0.0	0	0	0	0	1
01/16/2015 06:00	0.0	0	0	0	0	1
01/16/2015 07:00	0.0	0	0	0	0	1
01/16/2015 08:00	0.0	0	0	0	0	1
01/16/2015 09:00	0.0	0	0	0	0	1
01/16/2015 10:00	0.0	0	0	0	0	1
01/16/2015 11:00	0.0	0	0	0	0	1
01/16/2015 12:00	0.0	0	0	0	0	1
01/16/2015 13:00	0.0	0	0	0	0	1
01/16/2015 14:00	0.0	0	0	0	0	1
01/16/2015 15:00	0.0	0	0	0	0	1
01/16/2015 16:00	219.1	0	0	0	1	0
01/16/2015 17:00	4,270.1	0	0	1	0	0
01/16/2015 18:00	2,836.0	0	0	1	0	0
01/16/2015 19:00	0.0	0	0	0	0	1
01/16/2015 20:00	0.0	0	0	0	0	1
01/16/2015 21:00	0.0	0	0	0	0	1
01/16/2015 22:00	0.0	0	0	0	0	1
01/16/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,325.2 #	0 #	0 #	2 #	1 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,270.1	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/17/2015 00:00	0.0	0	0	0	0	1
01/17/2015 01:00	0.0	0	0	0	0	1
01/17/2015 02:00	0.0	0	0	0	0	1
01/17/2015 03:00	0.0	0	0	0	0	1
01/17/2015 04:00	0.0	0	0	0	0	1
01/17/2015 05:00	0.0	0	0	0	0	1
01/17/2015 06:00	0.0	0	0	0	0	1
01/17/2015 07:00	0.0	0	0	0	0	1
01/17/2015 08:00	0.0	0	0	0	0	1
01/17/2015 09:00	0.0	0	0	0	0	1
01/17/2015 10:00	0.0	0	0	0	0	1
01/17/2015 11:00	0.0	0	0	0	0	1
01/17/2015 12:00	0.0	0	0	0	0	1
01/17/2015 13:00	0.0	0	0	0	0	1
01/17/2015 14:00	0.0	0	0	0	0	1
01/17/2015 15:00	0.0	0	0	0	0	1
01/17/2015 16:00	0.0	0	0	0	0	1
01/17/2015 17:00	0.0	0	0	0	0	1
01/17/2015 18:00	0.0	0	0	0	0	1
01/17/2015 19:00	0.0	0	0	0	0	1
01/17/2015 20:00	0.0	0	0	0	0	1
01/17/2015 21:00	0.0	0	0	0	0	1
01/17/2015 22:00	0.0	0	0	0	0	1
01/17/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/18/2015 00:00	0.0	0	0	0	0	1
01/18/2015 01:00	0.0	0	0	0	0	1
01/18/2015 02:00	318.3	0	0	0	1	0
01/18/2015 03:00	0.0	0	0	0	0	0
01/18/2015 04:00	0.0	0	0	0	0	0
01/18/2015 05:00	0.0	0	0	0	0	0
01/18/2015 06:00	0.0	0	0	0	0	0
01/18/2015 07:00	0.0	0	0	0	0	0
01/18/2015 08:00	0.0	0	0	0	0	0
01/18/2015 09:00	0.0	0	0	0	0	0
01/18/2015 10:00	1,831.9	0	1	0	0	0
01/18/2015 11:00	6,962.0	0	1	0	0	0
01/18/2015 12:00	0.0	0	0	0	0	1
01/18/2015 13:00	0.0	0	0	0	0	1
01/18/2015 14:00	0.0	0	0	0	0	1
01/18/2015 15:00	0.0	0	0	0	0	1
01/18/2015 16:00	0.0	0	0	0	0	1
01/18/2015 17:00	0.0	0	0	0	0	1
01/18/2015 18:00	0.0	0	0	0	0	1
01/18/2015 19:00	0.0	0	0	0	0	1
01/18/2015 20:00	0.0	0	0	0	0	1
01/18/2015 21:00	0.0	0	0	0	0	1
01/18/2015 22:00	0.0	0	0	0	0	1
01/18/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	9,112.2 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,962.0	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/19/2015 00:00	0.0	0	0	0	0	1
01/19/2015 01:00	0.0	0	0	0	0	1
01/19/2015 02:00	0.0	0	0	0	0	1
01/19/2015 03:00	0.0	0	0	0	0	1
01/19/2015 04:00	0.0	0	0	0	0	1
01/19/2015 05:00	0.0	0	0	0	0	1
01/19/2015 06:00	0.0	0	0	0	0	1
01/19/2015 07:00	0.0	0	0	0	0	1
01/19/2015 08:00	0.0	0	0	0	0	1
01/19/2015 09:00	0.0	0	0	0	0	1
01/19/2015 10:00	0.0	0	0	0	0	1
01/19/2015 11:00	0.0	0	0	0	0	1
01/19/2015 12:00	0.0	0	0	0	0	1
01/19/2015 13:00	0.0	0	0	0	0	1
01/19/2015 14:00	0.0	0	0	0	0	1
01/19/2015 15:00	0.0	0	0	0	0	1
01/19/2015 16:00	0.0	0	0	0	0	1
01/19/2015 17:00	0.0	0	0	0	0	1
01/19/2015 18:00	0.0	0	0	0	0	1
01/19/2015 19:00	0.0	0	0	0	0	1
01/19/2015 20:00	0.0	0	0	0	0	1
01/19/2015 21:00	0.0	0	0	0	0	1
01/19/2015 22:00	0.0	0	0	0	0	1
01/19/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/20/2015 00:00	0.0	0	0	0	0	1
01/20/2015 01:00	0.0	0	0	0	0	1
01/20/2015 02:00	0.0	0	0	0	0	1
01/20/2015 03:00	0.0	0	0	0	0	1
01/20/2015 04:00	0.0	0	0	0	0	1
01/20/2015 05:00	0.0	0	0	0	0	1
01/20/2015 06:00	0.0	0	0	0	0	1
01/20/2015 07:00	0.0	0	0	0	0	1
01/20/2015 08:00	0.0	0	0	0	0	1
01/20/2015 09:00	0.0	0	0	0	0	1
01/20/2015 10:00	0.0	0	0	0	0	1
01/20/2015 11:00	0.0	0	0	0	0	1
01/20/2015 12:00	0.0	0	0	0	0	1
01/20/2015 13:00	0.0	0	0	0	0	1
01/20/2015 14:00	0.0	0	0	0	0	1
01/20/2015 15:00	0.0	0	0	0	0	1
01/20/2015 16:00	0.0	0	0	0	0	1
01/20/2015 17:00	0.0	0	0	0	0	1
01/20/2015 18:00	0.0	0	0	0	0	1
01/20/2015 19:00	0.0	0	0	0	0	1
01/20/2015 20:00	0.0	0	0	0	0	1
01/20/2015 21:00	0.0	0	0	0	0	1
01/20/2015 22:00	0.0	0	0	0	0	1
01/20/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/21/2015 00:00	0.0	0	0	0	0	1
01/21/2015 01:00	0.0	0	0	0	0	1
01/21/2015 02:00	0.0	0	0	0	0	1
01/21/2015 03:00	0.0	0	0	0	0	1
01/21/2015 04:00	0.0	0	0	0	0	1
01/21/2015 05:00	0.0	0	0	0	0	1
01/21/2015 06:00	0.0	0	0	0	0	1
01/21/2015 07:00	0.0	0	0	0	0	1
01/21/2015 08:00	0.0	0	0	0	0	1
01/21/2015 09:00	0.0	0	0	0	0	1
01/21/2015 10:00	0.0	0	0	0	0	1
01/21/2015 11:00	0.0	0	0	0	0	1
01/21/2015 12:00	0.0	0	0	0	0	1
01/21/2015 13:00	0.0	0	0	0	0	1
01/21/2015 14:00	0.0	0	0	0	0	1
01/21/2015 15:00	0.0	0	0	0	0	1
01/21/2015 16:00	0.0	0	0	0	0	1
01/21/2015 17:00	0.0	0	0	0	0	1
01/21/2015 18:00	0.0	0	0	0	0	1
01/21/2015 19:00	0.0	0	0	0	0	1
01/21/2015 20:00	0.0	0	0	0	0	1
01/21/2015 21:00	0.0	0	0	0	0	1
01/21/2015 22:00	0.0	0	0	0	0	1
01/21/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/22/2015 00:00	0.0	0	0	0	0	1
01/22/2015 01:00	0.0	0	0	0	0	1
01/22/2015 02:00	0.0	0	0	0	0	1
01/22/2015 03:00	0.0	0	0	0	0	1
01/22/2015 04:00	0.0	0	0	0	0	1
01/22/2015 05:00	0.0	0	0	0	0	1
01/22/2015 06:00	0.0	0	0	0	0	1
01/22/2015 07:00	0.0	0	0	0	0	1
01/22/2015 08:00	0.0	0	0	0	0	1
01/22/2015 09:00	0.0	0	0	0	0	1
01/22/2015 10:00	0.0	0	0	0	0	1
01/22/2015 11:00	0.0	0	0	0	0	1
01/22/2015 12:00	0.0	0	0	0	0	1
01/22/2015 13:00	0.0	0	0	0	0	1
01/22/2015 14:00	0.0	0	0	0	0	1
01/22/2015 15:00	0.0	0	0	0	0	1
01/22/2015 16:00	0.0	0	0	0	0	1
01/22/2015 17:00	0.0	0	0	0	0	1
01/22/2015 18:00	0.0	0	0	0	0	1
01/22/2015 19:00	0.0	0	0	0	0	1
01/22/2015 20:00	0.0	0	0	0	0	1
01/22/2015 21:00	0.0	0	0	0	0	1
01/22/2015 22:00	0.0	0	0	0	0	1
01/22/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/23/2015 00:00	0.0	0	0	0	0	1
01/23/2015 01:00	0.0	0	0	0	0	1
01/23/2015 02:00	0.0	0	0	0	0	1
01/23/2015 03:00	0.0	0	0	0	0	1
01/23/2015 04:00	0.0	0	0	0	0	1
01/23/2015 05:00	0.0	0	0	0	0	1
01/23/2015 06:00	0.0	0	0	0	0	1
01/23/2015 07:00	0.0	0	0	0	0	1
01/23/2015 08:00	0.0	0	0	0	0	1
01/23/2015 09:00	0.0	0	0	0	0	1
01/23/2015 10:00	0.0	0	0	0	0	1
01/23/2015 11:00	0.0	0	0	0	0	1
01/23/2015 12:00	0.0	0	0	0	0	1
01/23/2015 13:00	0.0	0	0	0	0	1
01/23/2015 14:00	0.0	0	0	0	0	1
01/23/2015 15:00	0.0	0	0	0	0	1
01/23/2015 16:00	0.0	0	0	0	0	1
01/23/2015 17:00	0.0	0	0	0	0	1
01/23/2015 18:00	0.0	0	0	0	0	1
01/23/2015 19:00	0.0	0	0	0	0	1
01/23/2015 20:00	0.0	0	0	0	0	1
01/23/2015 21:00	0.0	0	0	0	0	1
01/23/2015 22:00	0.0	0	0	0	0	1
01/23/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/24/2015 00:00	0.0	0	0	0	0	1
01/24/2015 01:00	0.0	0	0	0	0	1
01/24/2015 02:00	0.0	0	0	0	0	1
01/24/2015 03:00	0.0	0	0	0	0	1
01/24/2015 04:00	0.0	0	0	0	0	1
01/24/2015 05:00	0.0	0	0	0	0	1
01/24/2015 06:00	0.0	0	0	0	0	1
01/24/2015 07:00	0.0	0	0	0	0	1
01/24/2015 08:00	0.0	0	0	0	0	1
01/24/2015 09:00	0.0	0	0	0	0	1
01/24/2015 10:00	0.0	0	0	0	0	1
01/24/2015 11:00	0.0	0	0	0	0	1
01/24/2015 12:00	0.0	0	0	0	0	1
01/24/2015 13:00	0.0	0	0	0	0	1
01/24/2015 14:00	0.0	0	0	0	0	1
01/24/2015 15:00	0.0	0	0	0	0	1
01/24/2015 16:00	0.0	0	0	0	0	1
01/24/2015 17:00	0.0	0	0	0	0	1
01/24/2015 18:00	0.0	0	0	0	0	1
01/24/2015 19:00	0.0	0	0	0	0	1
01/24/2015 20:00	0.0	0	0	0	0	1
01/24/2015 21:00	0.0	0	0	0	0	1
01/24/2015 22:00	0.0	0	0	0	0	1
01/24/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/25/2015 00:00	0.0	0	0	0	0	1
01/25/2015 01:00	425.2	0	0	0	1	0
01/25/2015 02:00	0.0	0	0	0	0	0
01/25/2015 03:00	0.0	0	0	0	0	0
01/25/2015 04:00	0.0	0	0	0	0	0
01/25/2015 05:00	0.0	0	0	0	0	0
01/25/2015 06:00	0.0	0	0	0	0	0
01/25/2015 07:00	0.0	0	0	0	0	0
01/25/2015 08:00	0.0	0	0	0	0	0
01/25/2015 09:00	0.0	0	0	0	0	0
01/25/2015 10:00	0.0	0	0	0	0	0
01/25/2015 11:00	0.0	0	0	0	0	0
01/25/2015 12:00	0.0	0	0	0	0	0
01/25/2015 13:00	0.0	0	0	0	0	0
01/25/2015 14:00	0.0	0	0	0	0	0
01/25/2015 15:00	0.0	0	0	0	0	0
01/25/2015 16:00	0.0	0	0	0	0	0
01/25/2015 17:00	0.0	0	0	0	0	0
01/25/2015 18:00	0.0	0	0	0	0	0
01/25/2015 19:00	0.0	0	0	0	0	0
01/25/2015 20:00	0.0	0	0	0	0	0
01/25/2015 21:00	0.0	0	0	0	0	0
01/25/2015 22:00	0.0	0	0	0	0	0
01/25/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	425.2 #	0 #	0 #	0 #	1 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	425.2	0	0	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/26/2015 00:00	0.0	0	0	0	0	0
01/26/2015 01:00	0.0	0	0	0	0	0
01/26/2015 02:00	0.0	0	0	0	0	0
01/26/2015 03:00	0.0	0	0	0	0	0
01/26/2015 04:00	0.0	0	0	0	0	0
01/26/2015 05:00	0.0	0	0	0	0	0
01/26/2015 06:00	0.0	0	0	0	0	0
01/26/2015 07:00	0.0	0	0	0	0	0
01/26/2015 08:00	0.0	0	0	0	0	0
01/26/2015 09:00	0.0	0	0	0	0	0
01/26/2015 10:00	0.0	0	0	0	0	0
01/26/2015 11:00	0.0	0	0	0	0	0
01/26/2015 12:00	0.0	0	0	0	0	0
01/26/2015 13:00	0.0	0	0	0	0	0
01/26/2015 14:00	0.0	0	0	0	0	0
01/26/2015 15:00	0.0	0	0	0	0	0
01/26/2015 16:00	0.0	0	0	0	0	0
01/26/2015 17:00	0.0	0	0	0	0	0
01/26/2015 18:00	0.0	0	0	0	0	0
01/26/2015 19:00	0.0	0	0	0	0	0
01/26/2015 20:00	0.0	0	0	0	0	0
01/26/2015 21:00	0.0	0	0	0	0	0
01/26/2015 22:00	0.0	0	0	0	0	0
01/26/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/27/2015 00:00	0.0	0	0	0	0	0
01/27/2015 01:00	0.0	0	0	0	0	0
01/27/2015 02:00	4,224.8	0	1	0	0	0
01/27/2015 03:00	7,064.2	0	1	0	0	0
01/27/2015 04:00	923.5	0	1	0	0	0
01/27/2015 05:00	0.0	0	0	0	0	0
01/27/2015 06:00	0.0	0	0	0	0	0
01/27/2015 07:00	1,333.4	0	0	1	0	0
01/27/2015 08:00	4,641.2	0	0	1	0	0
01/27/2015 09:00	1,844.5	0	0	1	0	0
01/27/2015 10:00	4,275.4	0	0	1	0	0
01/27/2015 11:00	0.0	0	0	0	0	1
01/27/2015 12:00	0.0	0	0	0	0	1
01/27/2015 13:00	0.0	0	0	0	0	1
01/27/2015 14:00	0.0	0	0	0	0	1
01/27/2015 15:00	0.0	0	0	0	0	1
01/27/2015 16:00	0.0	0	0	0	0	1
01/27/2015 17:00	0.0	0	0	0	0	1
01/27/2015 18:00	0.0	0	0	0	0	1
01/27/2015 19:00	0.0	0	0	0	0	1
01/27/2015 20:00	0.0	0	0	0	0	1
01/27/2015 21:00	0.0	0	0	0	0	1
01/27/2015 22:00	0.0	0	0	0	0	1
01/27/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	24,307.0 #	0 #	3 #	4 #	0 #	13 #
Minimum:	0.0	0	0	0	0	0
Maximum:	7,064.2	0	1	1	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/28/2015 00:00	0.0	0	0	0	0	1
01/28/2015 01:00	0.0	0	0	0	0	1
01/28/2015 02:00	0.0	0	0	0	0	1
01/28/2015 03:00	0.0	0	0	0	0	1
01/28/2015 04:00	0.0	0	0	0	0	1
01/28/2015 05:00	0.0	0	0	0	0	1
01/28/2015 06:00	0.0	0	0	0	0	1
01/28/2015 07:00	0.0	0	0	0	0	1
01/28/2015 08:00	0.0	0	0	0	0	1
01/28/2015 09:00	0.0	0	0	0	0	1
01/28/2015 10:00	0.0	0	0	0	0	1
01/28/2015 11:00	0.0	0	0	0	0	1
01/28/2015 12:00	0.0	0	0	0	0	1
01/28/2015 13:00	0.0	0	0	0	0	1
01/28/2015 14:00	0.0	0	0	0	0	1
01/28/2015 15:00	0.0	0	0	0	0	1
01/28/2015 16:00	0.0	0	0	0	0	1
01/28/2015 17:00	0.0	0	0	0	0	1
01/28/2015 18:00	0.0	0	0	0	0	1
01/28/2015 19:00	0.0	0	0	0	0	1
01/28/2015 20:00	0.0	0	0	0	0	1
01/28/2015 21:00	0.0	0	0	0	0	1
01/28/2015 22:00	0.0	0	0	0	0	1
01/28/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/29/2015 00:00	0.0	0	0	0	0	1
01/29/2015 01:00	0.0	0	0	0	0	1
01/29/2015 02:00	0.0	0	0	0	0	1
01/29/2015 03:00	0.0	0	0	0	0	1
01/29/2015 04:00	0.0	0	0	0	0	1
01/29/2015 05:00	0.0	0	0	0	0	1
01/29/2015 06:00	0.0	0	0	0	0	1
01/29/2015 07:00	0.0	0	0	0	0	1
01/29/2015 08:00	0.0	0	0	0	0	1
01/29/2015 09:00	0.0	0	0	0	0	1
01/29/2015 10:00	0.0	0	0	0	0	1
01/29/2015 11:00	0.0	0	0	0	0	1
01/29/2015 12:00	0.0	0	0	0	0	1
01/29/2015 13:00	0.0	0	0	0	0	1
01/29/2015 14:00	0.0	0	0	0	0	1
01/29/2015 15:00	0.0	0	0	0	0	1
01/29/2015 16:00	0.0	0	0	0	0	1
01/29/2015 17:00	0.0	0	0	0	0	1
01/29/2015 18:00	0.0	0	0	0	0	1
01/29/2015 19:00	0.0	0	0	0	0	1
01/29/2015 20:00	0.0	0	0	0	0	1
01/29/2015 21:00	0.0	0	0	0	0	1
01/29/2015 22:00	0.0	0	0	0	0	1
01/29/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/30/2015 00:00	0.0	0	0	0	0	1
01/30/2015 01:00	0.0	0	0	0	0	1
01/30/2015 02:00	0.0	0	0	0	0	1
01/30/2015 03:00	0.0	0	0	0	0	1
01/30/2015 04:00	0.0	0	0	0	0	1
01/30/2015 05:00	0.0	0	0	0	0	1
01/30/2015 06:00	0.0	0	0	0	0	1
01/30/2015 07:00	0.0	0	0	0	0	1
01/30/2015 08:00	0.0	0	0	0	0	1
01/30/2015 09:00	0.0	0	0	0	0	1
01/30/2015 10:00	0.0	0	0	0	0	1
01/30/2015 11:00	0.0	0	0	0	0	1
01/30/2015 12:00	0.0	0	0	0	0	1
01/30/2015 13:00	0.0	0	0	0	0	1
01/30/2015 14:00	0.0	0	0	0	0	1
01/30/2015 15:00	0.0	0	0	0	0	1
01/30/2015 16:00	0.0	0	0	0	0	1
01/30/2015 17:00	0.0	0	0	0	0	1
01/30/2015 18:00	0.0	0	0	0	0	1
01/30/2015 19:00	0.0	0	0	0	0	1
01/30/2015 20:00	0.0	0	0	0	0	1
01/30/2015 21:00	0.0	0	0	0	0	1
01/30/2015 22:00	0.0	0	0	0	0	1
01/30/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/31/2015 00:00	0.0	0	0	0	0	1
01/31/2015 01:00	0.0	0	0	0	0	1
01/31/2015 02:00	0.0	0	0	0	0	1
01/31/2015 03:00	0.0	0	0	0	0	1
01/31/2015 04:00	0.0	0	0	0	0	1
01/31/2015 05:00	0.0	0	0	0	0	1
01/31/2015 06:00	0.0	0	0	0	0	1
01/31/2015 07:00	0.0	0	0	0	0	1
01/31/2015 08:00	0.0	0	0	0	0	1
01/31/2015 09:00	0.0	0	0	0	0	1
01/31/2015 10:00	0.0	0	0	0	0	1
01/31/2015 11:00	0.0	0	0	0	0	1
01/31/2015 12:00	0.0	0	0	0	0	1
01/31/2015 13:00	0.0	0	0	0	0	1
01/31/2015 14:00	0.0	0	0	0	0	1
01/31/2015 15:00	0.0	0	0	0	0	1
01/31/2015 16:00	0.0	0	0	0	0	1
01/31/2015 17:00	0.0	0	0	0	0	1
01/31/2015 18:00	0.0	0	0	0	0	1
01/31/2015 19:00	0.0	0	0	0	0	1
01/31/2015 20:00	0.0	0	0	0	0	1
01/31/2015 21:00	0.0	0	0	0	0	1
01/31/2015 22:00	0.0	0	0	0	0	1
01/31/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/01/2015 00:00	0.0	0	0	0	0	1
02/01/2015 01:00	0.0	0	0	0	0	1
02/01/2015 02:00	366.8	0	0	0	1	0
02/01/2015 03:00	0.0	0	0	0	0	0
02/01/2015 04:00	0.0	0	0	0	0	0
02/01/2015 05:00	0.0	0	0	0	0	0
02/01/2015 06:00	0.0	0	0	0	0	0
02/01/2015 07:00	0.0	0	0	0	0	0
02/01/2015 08:00	0.0	0	0	0	0	0
02/01/2015 09:00	0.0	0	0	0	0	0
02/01/2015 10:00	0.0	0	0	0	0	0
02/01/2015 11:00	0.0	0	0	0	0	0
02/01/2015 12:00	0.0	0	0	0	0	0
02/01/2015 13:00	0.0	0	0	0	0	0
02/01/2015 14:00	3,064.3	0	1	0	0	0
02/01/2015 15:00	5,223.1	0	1	0	0	0
02/01/2015 16:00	0.0	0	0	0	0	1
02/01/2015 17:00	0.0	0	0	0	0	1
02/01/2015 18:00	0.0	0	0	0	0	1
02/01/2015 19:00	0.0	0	0	0	0	1
02/01/2015 20:00	0.0	0	0	0	0	1
02/01/2015 21:00	0.0	0	0	0	0	1
02/01/2015 22:00	0.0	0	0	0	0	1
02/01/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	8,654.2 #	0 #	2 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,223.1	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/02/2015 00:00	0.0	0	0	0	0	1
02/02/2015 01:00	0.0	0	0	0	0	1
02/02/2015 02:00	0.0	0	0	0	0	1
02/02/2015 03:00	0.0	0	0	0	0	1
02/02/2015 04:00	0.0	0	0	0	0	1
02/02/2015 05:00	0.0	0	0	0	0	1
02/02/2015 06:00	0.0	0	0	0	0	1
02/02/2015 07:00	0.0	0	0	0	0	1
02/02/2015 08:00	0.0	0	0	0	0	1
02/02/2015 09:00	0.0	0	0	0	0	1
02/02/2015 10:00	0.0	0	0	0	0	1
02/02/2015 11:00	0.0	0	0	0	0	1
02/02/2015 12:00	0.0	0	0	0	0	1
02/02/2015 13:00	0.0	0	0	0	0	1
02/02/2015 14:00	0.0	0	0	0	0	1
02/02/2015 15:00	0.0	0	0	0	0	1
02/02/2015 16:00	0.0	0	0	0	0	1
02/02/2015 17:00	0.0	0	0	0	0	1
02/02/2015 18:00	0.0	0	0	0	0	1
02/02/2015 19:00	0.0	0	0	0	0	1
02/02/2015 20:00	0.0	0	0	0	0	1
02/02/2015 21:00	0.0	0	0	0	0	1
02/02/2015 22:00	0.0	0	0	0	0	1
02/02/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/03/2015 00:00	0.0	0	0	0	0	1
02/03/2015 01:00	0.0	0	0	0	0	1
02/03/2015 02:00	0.0	0	0	0	0	1
02/03/2015 03:00	0.0	0	0	0	0	1
02/03/2015 04:00	0.0	0	0	0	0	1
02/03/2015 05:00	0.0	0	0	0	0	1
02/03/2015 06:00	0.0	0	0	0	0	1
02/03/2015 07:00	0.0	0	0	0	0	1
02/03/2015 08:00	0.0	0	0	0	0	1
02/03/2015 09:00	0.0	0	0	0	0	1
02/03/2015 10:00	0.0	0	0	0	0	1
02/03/2015 11:00	0.0	0	0	0	0	1
02/03/2015 12:00	0.0	0	0	0	0	1
02/03/2015 13:00	0.0	0	0	0	0	1
02/03/2015 14:00	0.0	0	0	0	0	1
02/03/2015 15:00	0.0	0	0	0	0	1
02/03/2015 16:00	0.0	0	0	0	0	1
02/03/2015 17:00	0.0	0	0	0	0	1
02/03/2015 18:00	0.0	0	0	0	0	1
02/03/2015 19:00	0.0	0	0	0	0	1
02/03/2015 20:00	0.0	0	0	0	0	1
02/03/2015 21:00	0.0	0	0	0	0	1
02/03/2015 22:00	0.0	0	0	0	0	1
02/03/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/04/2015 00:00	0.0	0	0	0	0	1
02/04/2015 01:00	0.0	0	0	0	0	1
02/04/2015 02:00	0.0	0	0	0	0	1
02/04/2015 03:00	0.0	0	0	0	0	1
02/04/2015 04:00	0.0	0	0	0	0	1
02/04/2015 05:00	0.0	0	0	0	0	1
02/04/2015 06:00	0.0	0	0	0	0	1
02/04/2015 07:00	0.0	0	0	0	0	1
02/04/2015 08:00	0.0	0	0	0	0	1
02/04/2015 09:00	0.0	0	0	0	0	1
02/04/2015 10:00	0.0	0	0	0	0	1
02/04/2015 11:00	0.0	0	0	0	0	1
02/04/2015 12:00	0.0	0	0	0	0	1
02/04/2015 13:00	0.0	0	0	0	0	1
02/04/2015 14:00	0.0	0	0	0	0	1
02/04/2015 15:00	0.0	0	0	0	0	1
02/04/2015 16:00	0.0	0	0	0	0	1
02/04/2015 17:00	0.0	0	0	0	0	1
02/04/2015 18:00	0.0	0	0	0	0	1
02/04/2015 19:00	0.0	0	0	0	0	1
02/04/2015 20:00	0.0	0	0	0	0	1
02/04/2015 21:00	0.0	0	0	0	0	1
02/04/2015 22:00	0.0	0	0	0	0	1
02/04/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/05/2015 00:00	0.0	0	0	0	0	1
02/05/2015 01:00	0.0	0	0	0	0	1
02/05/2015 02:00	0.0	0	0	0	0	1
02/05/2015 03:00	0.0	0	0	0	0	1
02/05/2015 04:00	0.0	0	0	0	0	1
02/05/2015 05:00	0.0	0	0	0	0	1
02/05/2015 06:00	0.0	0	0	0	0	1
02/05/2015 07:00	0.0	0	0	0	0	1
02/05/2015 08:00	0.0	0	0	0	0	1
02/05/2015 09:00	0.0	0	0	0	0	1
02/05/2015 10:00	0.0	0	0	0	0	1
02/05/2015 11:00	0.0	0	0	0	0	1
02/05/2015 12:00	0.0	0	0	0	0	1
02/05/2015 13:00	0.0	0	0	0	0	1
02/05/2015 14:00	0.0	0	0	0	0	1
02/05/2015 15:00	0.0	0	0	0	0	1
02/05/2015 16:00	0.0	0	0	0	0	1
02/05/2015 17:00	0.0	0	0	0	0	1
02/05/2015 18:00	0.0	0	0	0	0	1
02/05/2015 19:00	0.0	0	0	0	0	1
02/05/2015 20:00	0.0	0	0	0	0	1
02/05/2015 21:00	0.0	0	0	0	0	1
02/05/2015 22:00	0.0	0	0	0	0	1
02/05/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/06/2015 00:00	0.0	0	0	0	0	1
02/06/2015 01:00	0.0	0	0	0	0	1
02/06/2015 02:00	0.0	0	0	0	0	1
02/06/2015 03:00	0.0	0	0	0	0	1
02/06/2015 04:00	0.0	0	0	0	0	1
02/06/2015 05:00	0.0	0	0	0	0	1
02/06/2015 06:00	0.0	0	0	0	0	1
02/06/2015 07:00	0.0	0	0	0	0	1
02/06/2015 08:00	0.0	0	0	0	0	1
02/06/2015 09:00	0.0	0	0	0	0	1
02/06/2015 10:00	0.0	0	0	0	0	1
02/06/2015 11:00	0.0	0	0	0	0	1
02/06/2015 12:00	0.0	0	0	0	0	1
02/06/2015 13:00	0.0	0	0	0	0	1
02/06/2015 14:00	0.0	0	0	0	0	1
02/06/2015 15:00	0.0	0	0	0	0	1
02/06/2015 16:00	0.0	0	0	0	0	1
02/06/2015 17:00	0.0	0	0	0	0	1
02/06/2015 18:00	0.0	0	0	0	0	1
02/06/2015 19:00	0.0	0	0	0	0	1
02/06/2015 20:00	0.0	0	0	0	0	1
02/06/2015 21:00	0.0	0	0	0	0	1
02/06/2015 22:00	0.0	0	0	0	0	1
02/06/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/07/2015 00:00	0.0	0	0	0	0	1
02/07/2015 01:00	0.0	0	0	0	0	1
02/07/2015 02:00	0.0	0	0	0	0	1
02/07/2015 03:00	0.0	0	0	0	0	1
02/07/2015 04:00	0.0	0	0	0	0	1
02/07/2015 05:00	0.0	0	0	0	0	1
02/07/2015 06:00	0.0	0	0	0	0	1
02/07/2015 07:00	0.0	0	0	0	0	1
02/07/2015 08:00	0.0	0	0	0	0	1
02/07/2015 09:00	0.0	0	0	0	0	1
02/07/2015 10:00	0.0	0	0	0	0	1
02/07/2015 11:00	0.0	0	0	0	0	1
02/07/2015 12:00	0.0	0	0	0	0	1
02/07/2015 13:00	0.0	0	0	0	0	1
02/07/2015 14:00	0.0	0	0	0	0	1
02/07/2015 15:00	0.0	0	0	0	0	1
02/07/2015 16:00	0.0	0	0	0	0	1
02/07/2015 17:00	0.0	0	0	0	0	1
02/07/2015 18:00	0.0	0	0	0	0	1
02/07/2015 19:00	0.0	0	0	0	0	1
02/07/2015 20:00	0.0	0	0	0	0	1
02/07/2015 21:00	0.0	0	0	0	0	1
02/07/2015 22:00	0.0	0	0	0	0	1
02/07/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/08/2015 00:00	0.0	0	0	0	0	1
02/08/2015 01:00	0.0	0	0	0	0	1
02/08/2015 02:00	0.0	0	0	0	0	1
02/08/2015 03:00	0.0	0	0	0	0	1
02/08/2015 04:00	0.0	0	0	0	0	1
02/08/2015 05:00	0.0	0	0	0	0	1
02/08/2015 06:00	0.0	0	0	0	0	1
02/08/2015 07:00	0.0	0	0	0	0	1
02/08/2015 08:00	0.0	0	0	0	0	1
02/08/2015 09:00	0.0	0	0	0	0	1
02/08/2015 10:00	0.0	0	0	0	0	1
02/08/2015 11:00	0.0	0	0	0	0	1
02/08/2015 12:00	0.0	0	0	0	0	1
02/08/2015 13:00	0.0	0	0	0	0	1
02/08/2015 14:00	0.0	0	0	0	0	1
02/08/2015 15:00	0.0	0	0	0	0	1
02/08/2015 16:00	0.0	0	0	0	0	1
02/08/2015 17:00	0.0	0	0	0	0	1
02/08/2015 18:00	0.0	0	0	0	0	1
02/08/2015 19:00	0.0	0	0	0	0	1
02/08/2015 20:00	0.0	0	0	0	0	1
02/08/2015 21:00	0.0	0	0	0	0	1
02/08/2015 22:00	0.0	0	0	0	0	1
02/08/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/09/2015 00:00	0.0	0	0	0	0	1
02/09/2015 01:00	0.0	0	0	0	0	1
02/09/2015 02:00	0.0	0	0	0	0	1
02/09/2015 03:00	0.0	0	0	0	0	1
02/09/2015 04:00	0.0	0	0	0	0	1
02/09/2015 05:00	0.0	0	0	0	0	1
02/09/2015 06:00	0.0	0	0	0	0	1
02/09/2015 07:00	0.0	0	0	0	0	1
02/09/2015 08:00	0.0	0	0	0	0	1
02/09/2015 09:00	0.0	0	0	0	0	1
02/09/2015 10:00	0.0	0	0	0	0	1
02/09/2015 11:00	0.0	0	0	0	0	1
02/09/2015 12:00	0.0	0	0	0	0	1
02/09/2015 13:00	0.0	0	0	0	0	1
02/09/2015 14:00	0.0	0	0	0	0	1
02/09/2015 15:00	0.0	0	0	0	0	1
02/09/2015 16:00	0.0	0	0	0	0	1
02/09/2015 17:00	0.0	0	0	0	0	1
02/09/2015 18:00	0.0	0	0	0	0	1
02/09/2015 19:00	0.0	0	0	0	0	1
02/09/2015 20:00	0.0	0	0	0	0	1
02/09/2015 21:00	0.0	0	0	0	0	1
02/09/2015 22:00	0.0	0	0	0	0	1
02/09/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:23 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/10/2015 00:00	0.0	0	0	0	0	1
02/10/2015 01:00	0.0	0	0	0	0	1
02/10/2015 02:00	0.0	0	0	0	0	1
02/10/2015 03:00	0.0	0	0	0	0	1
02/10/2015 04:00	0.0	0	0	0	0	1
02/10/2015 05:00	0.0	0	0	0	0	1
02/10/2015 06:00	0.0	0	0	0	0	1
02/10/2015 07:00	0.0	0	0	0	0	1
02/10/2015 08:00	0.0	0	0	0	0	1
02/10/2015 09:00	0.0	0	0	0	0	1
02/10/2015 10:00	0.0	0	0	0	0	1
02/10/2015 11:00	0.0	0	0	0	0	1
02/10/2015 12:00	0.0	0	0	0	0	1
02/10/2015 13:00	0.0	0	0	0	0	1
02/10/2015 14:00	0.0	0	0	0	0	1
02/10/2015 15:00	0.0	0	0	0	0	1
02/10/2015 16:00	0.0	0	0	0	0	1
02/10/2015 17:00	0.0	0	0	0	0	1
02/10/2015 18:00	0.0	0	0	0	0	1
02/10/2015 19:00	0.0	0	0	0	0	1
02/10/2015 20:00	0.0	0	0	0	0	1
02/10/2015 21:00	0.0	0	0	0	0	1
02/10/2015 22:00	0.0	0	0	0	0	1
02/10/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/11/2015 00:00	0.0	0	0	0	0	1
02/11/2015 01:00	0.0	0	0	0	0	1
02/11/2015 02:00	0.0	0	0	0	0	1
02/11/2015 03:00	0.0	0	0	0	0	1
02/11/2015 04:00	0.0	0	0	0	0	1
02/11/2015 05:00	0.0	0	0	0	0	1
02/11/2015 06:00	0.0	0	0	0	0	1
02/11/2015 07:00	0.0	0	0	0	0	1
02/11/2015 08:00	0.0	0	0	0	0	1
02/11/2015 09:00	0.0	0	0	0	0	1
02/11/2015 10:00	0.0	0	0	0	0	1
02/11/2015 11:00	0.0	0	0	0	0	1
02/11/2015 12:00	0.0	0	0	0	0	1
02/11/2015 13:00	0.0	0	0	0	0	1
02/11/2015 14:00	0.0	0	0	0	0	1
02/11/2015 15:00	0.0	0	0	0	0	1
02/11/2015 16:00	0.0	0	0	0	0	1
02/11/2015 17:00	0.0	0	0	0	0	1
02/11/2015 18:00	0.0	0	0	0	0	1
02/11/2015 19:00	0.0	0	0	0	0	1
02/11/2015 20:00	0.0	0	0	0	0	1
02/11/2015 21:00	0.0	0	0	0	0	1
02/11/2015 22:00	0.0	0	0	0	0	1
02/11/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/12/2015 00:00	0.0	0	0	0	0	1
02/12/2015 01:00	0.0	0	0	0	0	1
02/12/2015 02:00	0.0	0	0	0	0	1
02/12/2015 03:00	0.0	0	0	0	0	1
02/12/2015 04:00	0.0	0	0	0	0	1
02/12/2015 05:00	0.0	0	0	0	0	1
02/12/2015 06:00	0.0	0	0	0	0	1
02/12/2015 07:00	0.0	0	0	0	0	1
02/12/2015 08:00	0.0	0	0	0	0	1
02/12/2015 09:00	0.0	0	0	0	0	1
02/12/2015 10:00	0.0	0	0	0	0	1
02/12/2015 11:00	0.0	0	0	0	0	1
02/12/2015 12:00	0.0	0	0	0	0	1
02/12/2015 13:00	0.0	0	0	0	0	1
02/12/2015 14:00	0.0	0	0	0	0	1
02/12/2015 15:00	0.0	0	0	0	0	1
02/12/2015 16:00	0.0	0	0	0	0	1
02/12/2015 17:00	0.0	0	0	0	0	1
02/12/2015 18:00	0.0	0	0	0	0	1
02/12/2015 19:00	0.0	0	0	0	0	1
02/12/2015 20:00	0.0	0	0	0	0	1
02/12/2015 21:00	0.0	0	0	0	0	1
02/12/2015 22:00	0.0	0	0	0	0	1
02/12/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/13/2015 00:00	0.0	0	0	0	0	1
02/13/2015 01:00	0.0	0	0	0	0	1
02/13/2015 02:00	0.0	0	0	0	0	1
02/13/2015 03:00	0.0	0	0	0	0	1
02/13/2015 04:00	0.0	0	0	0	0	1
02/13/2015 05:00	0.0	0	0	0	0	1
02/13/2015 06:00	0.0	0	0	0	0	1
02/13/2015 07:00	0.0	0	0	0	0	1
02/13/2015 08:00	0.0	0	0	0	0	1
02/13/2015 09:00	0.0	0	0	0	0	1
02/13/2015 10:00	0.0	0	0	0	0	1
02/13/2015 11:00	0.0	0	0	0	0	1
02/13/2015 12:00	0.0	0	0	0	0	1
02/13/2015 13:00	0.0	0	0	0	0	1
02/13/2015 14:00	0.0	0	0	0	0	1
02/13/2015 15:00	0.0	0	0	0	0	1
02/13/2015 16:00	0.0	0	0	0	0	1
02/13/2015 17:00	0.0	0	0	0	0	1
02/13/2015 18:00	0.0	0	0	0	0	1
02/13/2015 19:00	0.0	0	0	0	0	1
02/13/2015 20:00	0.0	0	0	0	0	1
02/13/2015 21:00	0.0	0	0	0	0	1
02/13/2015 22:00	0.0	0	0	0	0	1
02/13/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/14/2015 00:00	0.0	0	0	0	0	1
02/14/2015 01:00	0.0	0	0	0	0	1
02/14/2015 02:00	0.0	0	0	0	0	1
02/14/2015 03:00	0.0	0	0	0	0	1
02/14/2015 04:00	0.0	0	0	0	0	1
02/14/2015 05:00	0.0	0	0	0	0	1
02/14/2015 06:00	0.0	0	0	0	0	1
02/14/2015 07:00	0.0	0	0	0	0	1
02/14/2015 08:00	0.0	0	0	0	0	1
02/14/2015 09:00	0.0	0	0	0	0	1
02/14/2015 10:00	0.0	0	0	0	0	1
02/14/2015 11:00	0.0	0	0	0	0	1
02/14/2015 12:00	0.0	0	0	0	0	1
02/14/2015 13:00	0.0	0	0	0	0	1
02/14/2015 14:00	0.0	0	0	0	0	1
02/14/2015 15:00	0.0	0	0	0	0	1
02/14/2015 16:00	0.0	0	0	0	0	1
02/14/2015 17:00	0.0	0	0	0	0	1
02/14/2015 18:00	0.0	0	0	0	0	1
02/14/2015 19:00	0.0	0	0	0	0	1
02/14/2015 20:00	0.0	0	0	0	0	1
02/14/2015 21:00	0.0	0	0	0	0	1
02/14/2015 22:00	0.0	0	0	0	0	1
02/14/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/15/2015 00:00	0.0	0	0	0	0	1
02/15/2015 01:00	0.0	0	0	0	0	1
02/15/2015 02:00	318.4	0	0	0	1	0
02/15/2015 03:00	0.0	0	0	0	0	0
02/15/2015 04:00	0.0	0	0	0	0	0
02/15/2015 05:00	0.0	0	0	0	0	0
02/15/2015 06:00	0.0	0	0	0	0	0
02/15/2015 07:00	0.0	0	0	0	0	0
02/15/2015 08:00	0.0	0	0	0	0	0
02/15/2015 09:00	0.0	0	0	0	0	0
02/15/2015 10:00	3,119.2	0	1	0	0	0
02/15/2015 11:00	6,546.2	0	1	0	0	0
02/15/2015 12:00	0.0	0	0	0	0	1
02/15/2015 13:00	0.0	0	0	0	0	1
02/15/2015 14:00	0.0	0	0	0	0	1
02/15/2015 15:00	0.0	0	0	0	0	1
02/15/2015 16:00	0.0	0	0	0	0	1
02/15/2015 17:00	0.0	0	0	0	0	1
02/15/2015 18:00	0.0	0	0	0	0	1
02/15/2015 19:00	0.0	0	0	0	0	1
02/15/2015 20:00	0.0	0	0	0	0	1
02/15/2015 21:00	0.0	0	0	0	0	1
02/15/2015 22:00	0.0	0	0	0	0	1
02/15/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	9,983.8 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,546.2	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/16/2015 00:00	0.0	0	0	0	0	1
02/16/2015 01:00	0.0	0	0	0	0	1
02/16/2015 02:00	0.0	0	0	0	0	1
02/16/2015 03:00	0.0	0	0	0	0	1
02/16/2015 04:00	0.0	0	0	0	0	1
02/16/2015 05:00	0.0	0	0	0	0	1
02/16/2015 06:00	0.0	0	0	0	0	1
02/16/2015 07:00	0.0	0	0	0	0	1
02/16/2015 08:00	0.0	0	0	0	0	1
02/16/2015 09:00	0.0	0	0	0	0	1
02/16/2015 10:00	0.0	0	0	0	0	1
02/16/2015 11:00	0.0	0	0	0	0	1
02/16/2015 12:00	0.0	0	0	0	0	1
02/16/2015 13:00	0.0	0	0	0	0	1
02/16/2015 14:00	0.0	0	0	0	0	1
02/16/2015 15:00	0.0	0	0	0	0	1
02/16/2015 16:00	0.0	0	0	0	0	1
02/16/2015 17:00	0.0	0	0	0	0	1
02/16/2015 18:00	0.0	0	0	0	0	1
02/16/2015 19:00	0.0	0	0	0	0	1
02/16/2015 20:00	0.0	0	0	0	0	1
02/16/2015 21:00	0.0	0	0	0	0	1
02/16/2015 22:00	0.0	0	0	0	0	1
02/16/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/17/2015 00:00	0.0	0	0	0	0	1
02/17/2015 01:00	0.0	0	0	0	0	1
02/17/2015 02:00	0.0	0	0	0	0	1
02/17/2015 03:00	0.0	0	0	0	0	1
02/17/2015 04:00	0.0	0	0	0	0	1
02/17/2015 05:00	0.0	0	0	0	0	1
02/17/2015 06:00	0.0	0	0	0	0	1
02/17/2015 07:00	0.0	0	0	0	0	1
02/17/2015 08:00	0.0	0	0	0	0	1
02/17/2015 09:00	0.0	0	0	0	0	1
02/17/2015 10:00	0.0	0	0	0	0	1
02/17/2015 11:00	0.0	0	0	0	0	1
02/17/2015 12:00	0.0	0	0	0	0	1
02/17/2015 13:00	0.0	0	0	0	0	1
02/17/2015 14:00	0.0	0	0	0	0	1
02/17/2015 15:00	0.0	0	0	0	0	1
02/17/2015 16:00	0.0	0	0	0	0	1
02/17/2015 17:00	0.0	0	0	0	0	1
02/17/2015 18:00	0.0	0	0	0	0	1
02/17/2015 19:00	0.0	0	0	0	0	1
02/17/2015 20:00	0.0	0	0	0	0	1
02/17/2015 21:00	0.0	0	0	0	0	1
02/17/2015 22:00	0.0	0	0	0	0	1
02/17/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/18/2015 00:00	0.0	0	0	0	0	1
02/18/2015 01:00	0.0	0	0	0	0	1
02/18/2015 02:00	0.0	0	0	0	0	1
02/18/2015 03:00	0.0	0	0	0	0	1
02/18/2015 04:00	0.0	0	0	0	0	1
02/18/2015 05:00	0.0	0	0	0	0	1
02/18/2015 06:00	0.0	0	0	0	0	1
02/18/2015 07:00	0.0	0	0	0	0	1
02/18/2015 08:00	0.0	0	0	0	0	1
02/18/2015 09:00	0.0	0	0	0	0	1
02/18/2015 10:00	0.0	0	0	0	0	1
02/18/2015 11:00	0.0	0	0	0	0	1
02/18/2015 12:00	0.0	0	0	0	0	1
02/18/2015 13:00	0.0	0	0	0	0	1
02/18/2015 14:00	0.0	0	0	0	0	1
02/18/2015 15:00	0.0	0	0	0	0	1
02/18/2015 16:00	0.0	0	0	0	0	1
02/18/2015 17:00	0.0	0	0	0	0	1
02/18/2015 18:00	0.0	0	0	0	0	1
02/18/2015 19:00	0.0	0	0	0	0	1
02/18/2015 20:00	0.0	0	0	0	0	1
02/18/2015 21:00	0.0	0	0	0	0	1
02/18/2015 22:00	0.0	0	0	0	0	1
02/18/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/19/2015 00:00	0.0	0	0	0	0	1
02/19/2015 01:00	0.0	0	0	0	0	1
02/19/2015 02:00	0.0	0	0	0	0	1
02/19/2015 03:00	0.0	0	0	0	0	1
02/19/2015 04:00	0.0	0	0	0	0	1
02/19/2015 05:00	0.0	0	0	0	0	1
02/19/2015 06:00	0.0	0	0	0	0	1
02/19/2015 07:00	0.0	0	0	0	0	1
02/19/2015 08:00	0.0	0	0	0	0	1
02/19/2015 09:00	0.0	0	0	0	0	1
02/19/2015 10:00	0.0	0	0	0	0	1
02/19/2015 11:00	0.0	0	0	0	0	1
02/19/2015 12:00	0.0	0	0	0	0	1
02/19/2015 13:00	0.0	0	0	0	0	1
02/19/2015 14:00	0.0	0	0	0	0	1
02/19/2015 15:00	0.0	0	0	0	0	1
02/19/2015 16:00	0.0	0	0	0	0	1
02/19/2015 17:00	0.0	0	0	0	0	1
02/19/2015 18:00	0.0	0	0	0	0	1
02/19/2015 19:00	0.0	0	0	0	0	1
02/19/2015 20:00	0.0	0	0	0	0	1
02/19/2015 21:00	0.0	0	0	0	0	1
02/19/2015 22:00	0.0	0	0	0	0	1
02/19/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/20/2015 00:00	0.0	0	0	0	0	1
02/20/2015 01:00	397.9	0	0	0	1	0
02/20/2015 02:00	0.0	0	0	0	0	0
02/20/2015 03:00	0.0	0	0	0	0	0
02/20/2015 04:00	607.1	0	0	1	0	0
02/20/2015 05:00	4,565.5	0	0	1	0	0
02/20/2015 06:00	0.0	0	0	0	0	1
02/20/2015 07:00	0.0	0	0	0	0	1
02/20/2015 08:00	0.0	0	0	0	0	1
02/20/2015 09:00	0.0	0	0	0	0	1
02/20/2015 10:00	0.0	0	0	0	0	1
02/20/2015 11:00	0.0	0	0	0	0	1
02/20/2015 12:00	519.4	0	0	0	1	0
02/20/2015 13:00	0.0	0	0	0	0	0
02/20/2015 14:00	0.0	0	0	0	0	0
02/20/2015 15:00	0.0	0	0	0	0	0
02/20/2015 16:00	0.0	0	0	0	0	0
02/20/2015 17:00	0.0	0	0	0	0	0
02/20/2015 18:00	0.0	0	0	0	0	0
02/20/2015 19:00	0.0	0	0	0	0	0
02/20/2015 20:00	0.0	0	0	0	0	0
02/20/2015 21:00	0.0	0	0	0	0	0
02/20/2015 22:00	0.0	0	0	0	0	0
02/20/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	6,089.9 #	0 #	0 #	2 #	2 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,565.5	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/21/2015 00:00	0.0	0	0	0	0	0
02/21/2015 01:00	0.0	0	0	0	0	0
02/21/2015 02:00	0.0	0	0	0	0	0
02/21/2015 03:00	0.0	0	0	0	0	0
02/21/2015 04:00	0.0	0	0	0	0	0
02/21/2015 05:00	0.0	0	0	0	0	0
02/21/2015 06:00	0.0	0	0	0	0	0
02/21/2015 07:00	0.0	0	0	0	0	0
02/21/2015 08:00	0.0	0	0	0	0	0
02/21/2015 09:00	0.0	0	0	0	0	0
02/21/2015 10:00	3,470.3	0	1	0	0	0
02/21/2015 11:00	7,131.9	0	1	0	0	0
02/21/2015 12:00	3,293.1	0	1	0	0	0
02/21/2015 13:00	0.0	0	0	0	0	1
02/21/2015 14:00	0.0	0	0	0	0	1
02/21/2015 15:00	0.0	0	0	0	0	1
02/21/2015 16:00	0.0	0	0	0	0	1
02/21/2015 17:00	0.0	0	0	0	0	1
02/21/2015 18:00	0.0	0	0	0	0	1
02/21/2015 19:00	0.0	0	0	0	0	1
02/21/2015 20:00	0.0	0	0	0	0	1
02/21/2015 21:00	0.0	0	0	0	0	1
02/21/2015 22:00	0.0	0	0	0	0	1
02/21/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	13,895.3 #	0 #	3 #	0 #	0 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	7,131.9	0	1	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/22/2015 00:00	0.0	0	0	0	0	1
02/22/2015 01:00	0.0	0	0	0	0	1
02/22/2015 02:00	0.0	0	0	0	0	1
02/22/2015 03:00	0.0	0	0	0	0	1
02/22/2015 04:00	0.0	0	0	0	0	1
02/22/2015 05:00	0.0	0	0	0	0	1
02/22/2015 06:00	360.2	0	0	0	1	0
02/22/2015 07:00	0.0	0	0	0	0	0
02/22/2015 08:00	0.0	0	0	0	0	0
02/22/2015 09:00	0.0	0	0	0	0	0
02/22/2015 10:00	0.0	0	0	0	0	0
02/22/2015 11:00	0.0	0	0	0	0	0
02/22/2015 12:00	0.0	0	0	0	0	0
02/22/2015 13:00	0.0	0	0	0	0	0
02/22/2015 14:00	3,583.5	0	1	0	0	0
02/22/2015 15:00	6,995.7	0	1	0	0	0
02/22/2015 16:00	0.0	0	0	0	0	1
02/22/2015 17:00	0.0	0	0	0	0	1
02/22/2015 18:00	0.0	0	0	0	0	1
02/22/2015 19:00	0.0	0	0	0	0	1
02/22/2015 20:00	0.0	0	0	0	0	1
02/22/2015 21:00	0.0	0	0	0	0	1
02/22/2015 22:00	311.5	0	0	0	1	0
02/22/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	11,250.9 #	0 #	2 #	0 #	2 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,995.7	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/23/2015 00:00	0.0	0	0	0	0	0
02/23/2015 01:00	0.0	0	0	0	0	0
02/23/2015 02:00	0.0	0	0	0	0	0
02/23/2015 03:00	3,838.0	0	0	1	0	0
02/23/2015 04:00	3,890.3	0	0	1	0	0
02/23/2015 05:00	0.0	0	0	0	0	1
02/23/2015 06:00	0.0	0	0	0	0	1
02/23/2015 07:00	0.0	0	0	0	0	1
02/23/2015 08:00	0.0	0	0	0	0	1
02/23/2015 09:00	0.0	0	0	0	0	1
02/23/2015 10:00	0.0	0	0	0	0	1
02/23/2015 11:00	0.0	0	0	0	0	1
02/23/2015 12:00	0.0	0	0	0	0	1
02/23/2015 13:00	0.0	0	0	0	0	1
02/23/2015 14:00	0.0	0	0	0	0	1
02/23/2015 15:00	0.0	0	0	0	0	1
02/23/2015 16:00	0.0	0	0	0	0	1
02/23/2015 17:00	0.0	0	0	0	0	1
02/23/2015 18:00	0.0	0	0	0	0	1
02/23/2015 19:00	0.0	0	0	0	0	1
02/23/2015 20:00	0.0	0	0	0	0	1
02/23/2015 21:00	0.0	0	0	0	0	1
02/23/2015 22:00	0.0	0	0	0	0	1
02/23/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,728.3 #	0 #	0 #	2 #	0 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3,890.3	0	0	1	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/24/2015 00:00	0.0	0	0	0	0	1
02/24/2015 01:00	0.0	0	0	0	0	1
02/24/2015 02:00	0.0	0	0	0	0	1
02/24/2015 03:00	0.0	0	0	0	0	1
02/24/2015 04:00	0.0	0	0	0	0	1
02/24/2015 05:00	0.0	0	0	0	0	1
02/24/2015 06:00	0.0	0	0	0	0	1
02/24/2015 07:00	0.0	0	0	0	0	1
02/24/2015 08:00	0.0	0	0	0	0	1
02/24/2015 09:00	0.0	0	0	0	0	1
02/24/2015 10:00	0.0	0	0	0	0	1
02/24/2015 11:00	0.0	0	0	0	0	1
02/24/2015 12:00	0.0	0	0	0	0	1
02/24/2015 13:00	0.0	0	0	0	0	1
02/24/2015 14:00	0.0	0	0	0	0	1
02/24/2015 15:00	0.0	0	0	0	0	1
02/24/2015 16:00	0.0	0	0	0	0	1
02/24/2015 17:00	0.0	0	0	0	0	1
02/24/2015 18:00	0.0	0	0	0	0	1
02/24/2015 19:00	0.0	0	0	0	0	1
02/24/2015 20:00	0.0	0	0	0	0	1
02/24/2015 21:00	0.0	0	0	0	0	1
02/24/2015 22:00	0.0	0	0	0	0	1
02/24/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/25/2015 00:00	0.0	0	0	0	0	1
02/25/2015 01:00	0.0	0	0	0	0	1
02/25/2015 02:00	0.0	0	0	0	0	1
02/25/2015 03:00	0.0	0	0	0	0	1
02/25/2015 04:00	0.0	0	0	0	0	1
02/25/2015 05:00	0.0	0	0	0	0	1
02/25/2015 06:00	0.0	0	0	0	0	1
02/25/2015 07:00	0.0	0	0	0	0	1
02/25/2015 08:00	0.0	0	0	0	0	1
02/25/2015 09:00	0.0	0	0	0	0	1
02/25/2015 10:00	0.0	0	0	0	0	1
02/25/2015 11:00	0.0	0	0	0	0	1
02/25/2015 12:00	0.0	0	0	0	0	1
02/25/2015 13:00	0.0	0	0	0	0	1
02/25/2015 14:00	0.0	0	0	0	0	1
02/25/2015 15:00	0.0	0	0	0	0	1
02/25/2015 16:00	0.0	0	0	0	0	1
02/25/2015 17:00	0.0	0	0	0	0	1
02/25/2015 18:00	0.0	0	0	0	0	1
02/25/2015 19:00	0.0	0	0	0	0	1
02/25/2015 20:00	0.0	0	0	0	0	1
02/25/2015 21:00	0.0	0	0	0	0	1
02/25/2015 22:00	0.0	0	0	0	0	1
02/25/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/26/2015 00:00	0.0	0	0	0	0	1
02/26/2015 01:00	0.0	0	0	0	0	1
02/26/2015 02:00	0.0	0	0	0	0	1
02/26/2015 03:00	0.0	0	0	0	0	1
02/26/2015 04:00	0.0	0	0	0	0	1
02/26/2015 05:00	0.0	0	0	0	0	1
02/26/2015 06:00	0.0	0	0	0	0	1
02/26/2015 07:00	0.0	0	0	0	0	1
02/26/2015 08:00	0.0	0	0	0	0	1
02/26/2015 09:00	0.0	0	0	0	0	1
02/26/2015 10:00	0.0	0	0	0	0	1
02/26/2015 11:00	0.0	0	0	0	0	1
02/26/2015 12:00	0.0	0	0	0	0	1
02/26/2015 13:00	0.0	0	0	0	0	1
02/26/2015 14:00	0.0	0	0	0	0	1
02/26/2015 15:00	0.0	0	0	0	0	1
02/26/2015 16:00	0.0	0	0	0	0	1
02/26/2015 17:00	0.0	0	0	0	0	1
02/26/2015 18:00	0.0	0	0	0	0	1
02/26/2015 19:00	0.0	0	0	0	0	1
02/26/2015 20:00	0.0	0	0	0	0	1
02/26/2015 21:00	0.0	0	0	0	0	1
02/26/2015 22:00	0.0	0	0	0	0	1
02/26/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/27/2015 00:00	0.0	0	0	0	0	1
02/27/2015 01:00	0.0	0	0	0	0	1
02/27/2015 02:00	0.0	0	0	0	0	1
02/27/2015 03:00	0.0	0	0	0	0	1
02/27/2015 04:00	0.0	0	0	0	0	1
02/27/2015 05:00	0.0	0	0	0	0	1
02/27/2015 06:00	0.0	0	0	0	0	1
02/27/2015 07:00	0.0	0	0	0	0	1
02/27/2015 08:00	0.0	0	0	0	0	1
02/27/2015 09:00	0.0	0	0	0	0	1
02/27/2015 10:00	0.0	0	0	0	0	1
02/27/2015 11:00	0.0	0	0	0	0	1
02/27/2015 12:00	0.0	0	0	0	0	1
02/27/2015 13:00	0.0	0	0	0	0	1
02/27/2015 14:00	0.0	0	0	0	0	1
02/27/2015 15:00	0.0	0	0	0	0	1
02/27/2015 16:00	0.0	0	0	0	0	1
02/27/2015 17:00	0.0	0	0	0	0	1
02/27/2015 18:00	0.0	0	0	0	0	1
02/27/2015 19:00	0.0	0	0	0	0	1
02/27/2015 20:00	0.0	0	0	0	0	1
02/27/2015 21:00	0.0	0	0	0	0	1
02/27/2015 22:00	0.0	0	0	0	0	1
02/27/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/28/2015 00:00	0.0	0	0	0	0	1
02/28/2015 01:00	338.9	0	0	0	1	0
02/28/2015 02:00	0.0	0	0	0	0	0
02/28/2015 03:00	0.0	0	0	0	0	0
02/28/2015 04:00	0.0	0	0	0	0	0
02/28/2015 05:00	0.0	0	0	0	0	0
02/28/2015 06:00	0.0	0	0	0	0	0
02/28/2015 07:00	0.0	0	0	0	0	0
02/28/2015 08:00	0.0	0	0	0	0	0
02/28/2015 09:00	0.0	0	0	0	0	0
02/28/2015 10:00	0.0	0	0	0	0	0
02/28/2015 11:00	0.0	0	0	0	0	0
02/28/2015 12:00	0.0	0	0	0	0	0
02/28/2015 13:00	0.0	0	0	0	0	0
02/28/2015 14:00	755.8	0	1	0	0	0
02/28/2015 15:00	7,613.5	0	1	0	0	0
02/28/2015 16:00	0.0	0	0	0	0	1
02/28/2015 17:00	0.0	0	0	0	0	1
02/28/2015 18:00	0.0	0	0	0	0	1
02/28/2015 19:00	0.0	0	0	0	0	1
02/28/2015 20:00	0.0	0	0	0	0	1
02/28/2015 21:00	0.0	0	0	0	0	1
02/28/2015 22:00	0.0	0	0	0	0	1
02/28/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	8,708.2 #	0 #	2 #	0 #	1 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	7,613.5	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/01/2015 00:00	0.0	0	0	0	0	1
03/01/2015 01:00	0.0	0	0	0	0	1
03/01/2015 02:00	0.0	0	0	0	0	1
03/01/2015 03:00	0.0	0	0	0	0	1
03/01/2015 04:00	0.0	0	0	0	0	1
03/01/2015 05:00	0.0	0	0	0	0	1
03/01/2015 06:00	0.0	0	0	0	0	1
03/01/2015 07:00	0.0	0	0	0	0	1
03/01/2015 08:00	0.0	0	0	0	0	1
03/01/2015 09:00	0.0	0	0	0	0	1
03/01/2015 10:00	0.0	0	0	0	0	1
03/01/2015 11:00	0.0	0	0	0	0	1
03/01/2015 12:00	0.0	0	0	0	0	1
03/01/2015 13:00	0.0	0	0	0	0	1
03/01/2015 14:00	0.0	0	0	0	0	1
03/01/2015 15:00	0.0	0	0	0	0	1
03/01/2015 16:00	0.0	0	0	0	0	1
03/01/2015 17:00	0.0	0	0	0	0	1
03/01/2015 18:00	0.0	0	0	0	0	1
03/01/2015 19:00	0.0	0	0	0	0	1
03/01/2015 20:00	0.0	0	0	0	0	1
03/01/2015 21:00	0.0	0	0	0	0	1
03/01/2015 22:00	0.0	0	0	0	0	1
03/01/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/02/2015 00:00	0.0	0	0	0	0	1
03/02/2015 01:00	0.0	0	0	0	0	1
03/02/2015 02:00	0.0	0	0	0	0	1
03/02/2015 03:00	0.0	0	0	0	0	1
03/02/2015 04:00	0.0	0	0	0	0	1
03/02/2015 05:00	0.0	0	0	0	0	1
03/02/2015 06:00	0.0	0	0	0	0	1
03/02/2015 07:00	0.0	0	0	0	0	1
03/02/2015 08:00	0.0	0	0	0	0	1
03/02/2015 09:00	0.0	0	0	0	0	1
03/02/2015 10:00	0.0	0	0	0	0	1
03/02/2015 11:00	0.0	0	0	0	0	1
03/02/2015 12:00	0.0	0	0	0	0	1
03/02/2015 13:00	0.0	0	0	0	0	1
03/02/2015 14:00	0.0	0	0	0	0	1
03/02/2015 15:00	0.0	0	0	0	0	1
03/02/2015 16:00	0.0	0	0	0	0	1
03/02/2015 17:00	0.0	0	0	0	0	1
03/02/2015 18:00	0.0	0	0	0	0	1
03/02/2015 19:00	0.0	0	0	0	0	1
03/02/2015 20:00	0.0	0	0	0	0	1
03/02/2015 21:00	0.0	0	0	0	0	1
03/02/2015 22:00	0.0	0	0	0	0	1
03/02/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/03/2015 00:00	0.0	0	0	0	0	1
03/03/2015 01:00	0.0	0	0	0	0	1
03/03/2015 02:00	0.0	0	0	0	0	1
03/03/2015 03:00	0.0	0	0	0	0	1
03/03/2015 04:00	0.0	0	0	0	0	1
03/03/2015 05:00	0.0	0	0	0	0	1
03/03/2015 06:00	0.0	0	0	0	0	1
03/03/2015 07:00	0.0	0	0	0	0	1
03/03/2015 08:00	0.0	0	0	0	0	1
03/03/2015 09:00	0.0	0	0	0	0	1
03/03/2015 10:00	0.0	0	0	0	0	1
03/03/2015 11:00	0.0	0	0	0	0	1
03/03/2015 12:00	0.0	0	0	0	0	1
03/03/2015 13:00	0.0	0	0	0	0	1
03/03/2015 14:00	0.0	0	0	0	0	1
03/03/2015 15:00	0.0	0	0	0	0	1
03/03/2015 16:00	0.0	0	0	0	0	1
03/03/2015 17:00	0.0	0	0	0	0	1
03/03/2015 18:00	0.0	0	0	0	0	1
03/03/2015 19:00	0.0	0	0	0	0	1
03/03/2015 20:00	0.0	0	0	0	0	1
03/03/2015 21:00	0.0	0	0	0	0	1
03/03/2015 22:00	0.0	0	0	0	0	1
03/03/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/04/2015 00:00	0.0	0	0	0	0	1
03/04/2015 01:00	0.0	0	0	0	0	1
03/04/2015 02:00	0.0	0	0	0	0	1
03/04/2015 03:00	0.0	0	0	0	0	1
03/04/2015 04:00	0.0	0	0	0	0	1
03/04/2015 05:00	0.0	0	0	0	0	1
03/04/2015 06:00	0.0	0	0	0	0	1
03/04/2015 07:00	0.0	0	0	0	0	1
03/04/2015 08:00	0.0	0	0	0	0	1
03/04/2015 09:00	0.0	0	0	0	0	1
03/04/2015 10:00	0.0	0	0	0	0	1
03/04/2015 11:00	0.0	0	0	0	0	1
03/04/2015 12:00	0.0	0	0	0	0	1
03/04/2015 13:00	0.0	0	0	0	0	1
03/04/2015 14:00	0.0	0	0	0	0	1
03/04/2015 15:00	0.0	0	0	0	0	1
03/04/2015 16:00	0.0	0	0	0	0	1
03/04/2015 17:00	0.0	0	0	0	0	1
03/04/2015 18:00	0.0	0	0	0	0	1
03/04/2015 19:00	0.0	0	0	0	0	1
03/04/2015 20:00	0.0	0	0	0	0	1
03/04/2015 21:00	0.0	0	0	0	0	1
03/04/2015 22:00	0.0	0	0	0	0	1
03/04/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/05/2015 00:00	0.0	0	0	0	0	1
03/05/2015 01:00	0.0	0	0	0	0	1
03/05/2015 02:00	0.0	0	0	0	0	1
03/05/2015 03:00	0.0	0	0	0	0	1
03/05/2015 04:00	0.0	0	0	0	0	1
03/05/2015 05:00	0.0	0	0	0	0	1
03/05/2015 06:00	0.0	0	0	0	0	1
03/05/2015 07:00	0.0	0	0	0	0	1
03/05/2015 08:00	0.0	0	0	0	0	1
03/05/2015 09:00	0.0	0	0	0	0	1
03/05/2015 10:00	0.0	0	0	0	0	1
03/05/2015 11:00	0.0	0	0	0	0	1
03/05/2015 12:00	0.0	0	0	0	0	1
03/05/2015 13:00	0.0	0	0	0	0	1
03/05/2015 14:00	0.0	0	0	0	0	1
03/05/2015 15:00	0.0	0	0	0	0	1
03/05/2015 16:00	0.0	0	0	0	0	1
03/05/2015 17:00	0.0	0	0	0	0	1
03/05/2015 18:00	0.0	0	0	0	0	1
03/05/2015 19:00	0.0	0	0	0	0	1
03/05/2015 20:00	0.0	0	0	0	0	1
03/05/2015 21:00	0.0	0	0	0	0	1
03/05/2015 22:00	0.0	0	0	0	0	1
03/05/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/06/2015 00:00	0.0	0	0	0	0	1
03/06/2015 01:00	0.0	0	0	0	0	1
03/06/2015 02:00	0.0	0	0	0	0	1
03/06/2015 03:00	0.0	0	0	0	0	1
03/06/2015 04:00	0.0	0	0	0	0	1
03/06/2015 05:00	0.0	0	0	0	0	1
03/06/2015 06:00	0.0	0	0	0	0	1
03/06/2015 07:00	0.0	0	0	0	0	1
03/06/2015 08:00	0.0	0	0	0	0	1
03/06/2015 09:00	0.0	0	0	0	0	1
03/06/2015 10:00	0.0	0	0	0	0	1
03/06/2015 11:00	0.0	0	0	0	0	1
03/06/2015 12:00	0.0	0	0	0	0	1
03/06/2015 13:00	0.0	0	0	0	0	1
03/06/2015 14:00	0.0	0	0	0	0	1
03/06/2015 15:00	0.0	0	0	0	0	1
03/06/2015 16:00	0.0	0	0	0	0	1
03/06/2015 17:00	0.0	0	0	0	0	1
03/06/2015 18:00	0.0	0	0	0	0	1
03/06/2015 19:00	0.0	0	0	0	0	1
03/06/2015 20:00	0.0	0	0	0	0	1
03/06/2015 21:00	0.0	0	0	0	0	1
03/06/2015 22:00	0.0	0	0	0	0	1
03/06/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/07/2015 00:00	0.0	0	0	0	0	1
03/07/2015 01:00	0.0	0	0	0	0	1
03/07/2015 02:00	198.0	0	0	0	1	0
03/07/2015 03:00	0.0	0	0	0	0	0
03/07/2015 04:00	0.0	0	0	0	0	0
03/07/2015 05:00	0.0	0	0	0	0	0
03/07/2015 06:00	0.0	0	0	0	0	0
03/07/2015 07:00	0.0	0	0	0	0	0
03/07/2015 08:00	0.0	0	0	0	0	0
03/07/2015 09:00	0.0	0	0	0	0	0
03/07/2015 10:00	0.0	0	0	0	0	0
03/07/2015 11:00	0.0	0	0	0	0	0
03/07/2015 12:00	0.0	0	0	0	0	0
03/07/2015 13:00	0.0	0	0	0	0	0
03/07/2015 14:00	3,692.7	0	1	0	0	0
03/07/2015 15:00	7,053.8	0	1	0	0	0
03/07/2015 16:00	0.0	0	0	0	0	1
03/07/2015 17:00	0.0	0	0	0	0	1
03/07/2015 18:00	0.0	0	0	0	0	1
03/07/2015 19:00	0.0	0	0	0	0	1
03/07/2015 20:00	0.0	0	0	0	0	1
03/07/2015 21:00	0.0	0	0	0	0	1
03/07/2015 22:00	0.0	0	0	0	0	1
03/07/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	10,944.5 #	0 #	2 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	7,053.8	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/08/2015 00:00	0.0	0	0	0	0	1
03/08/2015 01:00	0.0	0	0	0	0	1
03/08/2015 02:00	0.0	0	0	0	0	1
03/08/2015 03:00	0.0	0	0	0	0	1
03/08/2015 04:00	0.0	0	0	0	0	1
03/08/2015 05:00	0.0	0	0	0	0	1
03/08/2015 06:00	0.0	0	0	0	0	1
03/08/2015 07:00	0.0	0	0	0	0	1
03/08/2015 08:00	337.2	0	0	0	1	0
03/08/2015 09:00	0.0	0	0	0	0	0
03/08/2015 10:00	3,727.5	0	0	1	0	0
03/08/2015 11:00	4,539.1	0	0	1	0	0
03/08/2015 12:00	0.0	0	0	0	0	1
03/08/2015 13:00	0.0	0	0	0	0	1
03/08/2015 14:00	0.0	0	0	0	0	1
03/08/2015 15:00	0.0	0	0	0	0	1
03/08/2015 16:00	0.0	0	0	0	0	1
03/08/2015 17:00	0.0	0	0	0	0	1
03/08/2015 18:00	0.0	0	0	0	0	1
03/08/2015 19:00	0.0	0	0	0	0	1
03/08/2015 20:00	0.0	0	0	0	0	1
03/08/2015 21:00	0.0	0	0	0	0	1
03/08/2015 22:00	0.0	0	0	0	0	1
03/08/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	8,603.8 #	0 #	0 #	2 #	1 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,539.1	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/09/2015 00:00	0.0	0	0	0	0	1
03/09/2015 01:00	0.0	0	0	0	0	1
03/09/2015 02:00	0.0	0	0	0	0	1
03/09/2015 03:00	0.0	0	0	0	0	1
03/09/2015 04:00	0.0	0	0	0	0	1
03/09/2015 05:00	0.0	0	0	0	0	1
03/09/2015 06:00	0.0	0	0	0	0	1
03/09/2015 07:00	0.0	0	0	0	0	1
03/09/2015 08:00	0.0	0	0	0	0	1
03/09/2015 09:00	0.0	0	0	0	0	1
03/09/2015 10:00	0.0	0	0	0	0	1
03/09/2015 11:00	0.0	0	0	0	0	1
03/09/2015 12:00	0.0	0	0	0	0	1
03/09/2015 13:00	0.0	0	0	0	0	1
03/09/2015 14:00	0.0	0	0	0	0	1
03/09/2015 15:00	0.0	0	0	0	0	1
03/09/2015 16:00	0.0	0	0	0	0	1
03/09/2015 17:00	0.0	0	0	0	0	1
03/09/2015 18:00	0.0	0	0	0	0	1
03/09/2015 19:00	0.0	0	0	0	0	1
03/09/2015 20:00	0.0	0	0	0	0	1
03/09/2015 21:00	0.0	0	0	0	0	1
03/09/2015 22:00	0.0	0	0	0	0	1
03/09/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/10/2015 00:00	0.0	0	0	0	0	1
03/10/2015 01:00	0.0	0	0	0	0	1
03/10/2015 02:00	0.0	0	0	0	0	1
03/10/2015 03:00	0.0	0	0	0	0	1
03/10/2015 04:00	0.0	0	0	0	0	1
03/10/2015 05:00	0.0	0	0	0	0	1
03/10/2015 06:00	0.0	0	0	0	0	1
03/10/2015 07:00	0.0	0	0	0	0	1
03/10/2015 08:00	0.0	0	0	0	0	1
03/10/2015 09:00	0.0	0	0	0	0	1
03/10/2015 10:00	0.0	0	0	0	0	1
03/10/2015 11:00	0.0	0	0	0	0	1
03/10/2015 12:00	0.0	0	0	0	0	1
03/10/2015 13:00	0.0	0	0	0	0	1
03/10/2015 14:00	0.0	0	0	0	0	1
03/10/2015 15:00	0.0	0	0	0	0	1
03/10/2015 16:00	0.0	0	0	0	0	1
03/10/2015 17:00	0.0	0	0	0	0	1
03/10/2015 18:00	0.0	0	0	0	0	1
03/10/2015 19:00	0.0	0	0	0	0	1
03/10/2015 20:00	0.0	0	0	0	0	1
03/10/2015 21:00	0.0	0	0	0	0	1
03/10/2015 22:00	0.0	0	0	0	0	1
03/10/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/11/2015 00:00	0.0	0	0	0	0	1
03/11/2015 01:00	0.0	0	0	0	0	1
03/11/2015 02:00	0.0	0	0	0	0	1
03/11/2015 03:00	0.0	0	0	0	0	1
03/11/2015 04:00	0.0	0	0	0	0	1
03/11/2015 05:00	0.0	0	0	0	0	1
03/11/2015 06:00	0.0	0	0	0	0	1
03/11/2015 07:00	0.0	0	0	0	0	1
03/11/2015 08:00	0.0	0	0	0	0	1
03/11/2015 09:00	0.0	0	0	0	0	1
03/11/2015 10:00	0.0	0	0	0	0	1
03/11/2015 11:00	0.0	0	0	0	0	1
03/11/2015 12:00	0.0	0	0	0	0	1
03/11/2015 13:00	0.0	0	0	0	0	1
03/11/2015 14:00	0.0	0	0	0	0	1
03/11/2015 15:00	0.0	0	0	0	0	1
03/11/2015 16:00	0.0	0	0	0	0	1
03/11/2015 17:00	0.0	0	0	0	0	1
03/11/2015 18:00	0.0	0	0	0	0	1
03/11/2015 19:00	0.0	0	0	0	0	1
03/11/2015 20:00	0.0	0	0	0	0	1
03/11/2015 21:00	0.0	0	0	0	0	1
03/11/2015 22:00	0.0	0	0	0	0	1
03/11/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/12/2015 00:00	0.0	0	0	0	0	1
03/12/2015 01:00	0.0	0	0	0	0	1
03/12/2015 02:00	0.0	0	0	0	0	1
03/12/2015 03:00	0.0	0	0	0	0	1
03/12/2015 04:00	0.0	0	0	0	0	1
03/12/2015 05:00	0.0	0	0	0	0	1
03/12/2015 06:00	0.0	0	0	0	0	1
03/12/2015 07:00	0.0	0	0	0	0	1
03/12/2015 08:00	0.0	0	0	0	0	1
03/12/2015 09:00	0.0	0	0	0	0	1
03/12/2015 10:00	0.0	0	0	0	0	1
03/12/2015 11:00	0.0	0	0	0	0	1
03/12/2015 12:00	0.0	0	0	0	0	1
03/12/2015 13:00	0.0	0	0	0	0	1
03/12/2015 14:00	0.0	0	0	0	0	1
03/12/2015 15:00	0.0	0	0	0	0	1
03/12/2015 16:00	0.0	0	0	0	0	1
03/12/2015 17:00	0.0	0	0	0	0	1
03/12/2015 18:00	0.0	0	0	0	0	1
03/12/2015 19:00	0.0	0	0	0	0	1
03/12/2015 20:00	0.0	0	0	0	0	1
03/12/2015 21:00	0.0	0	0	0	0	1
03/12/2015 22:00	0.0	0	0	0	0	1
03/12/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/13/2015 00:00	0.0	0	0	0	0	1
03/13/2015 01:00	0.0	0	0	0	0	1
03/13/2015 02:00	0.0	0	0	0	0	1
03/13/2015 03:00	0.0	0	0	0	0	1
03/13/2015 04:00	0.0	0	0	0	0	1
03/13/2015 05:00	0.0	0	0	0	0	1
03/13/2015 06:00	0.0	0	0	0	0	1
03/13/2015 07:00	0.0	0	0	0	0	1
03/13/2015 08:00	0.0	0	0	0	0	1
03/13/2015 09:00	0.0	0	0	0	0	1
03/13/2015 10:00	0.0	0	0	0	0	1
03/13/2015 11:00	0.0	0	0	0	0	1
03/13/2015 12:00	0.0	0	0	0	0	1
03/13/2015 13:00	0.0	0	0	0	0	1
03/13/2015 14:00	0.0	0	0	0	0	1
03/13/2015 15:00	0.0	0	0	0	0	1
03/13/2015 16:00	0.0	0	0	0	0	1
03/13/2015 17:00	0.0	0	0	0	0	1
03/13/2015 18:00	0.0	0	0	0	0	1
03/13/2015 19:00	0.0	0	0	0	0	1
03/13/2015 20:00	0.0	0	0	0	0	1
03/13/2015 21:00	0.0	0	0	0	0	1
03/13/2015 22:00	0.0	0	0	0	0	1
03/13/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/14/2015 00:00	0.0	0	0	0	0	1
03/14/2015 01:00	0.0	0	0	0	0	1
03/14/2015 02:00	0.0	0	0	0	0	1
03/14/2015 03:00	0.0	0	0	0	0	1
03/14/2015 04:00	0.0	0	0	0	0	1
03/14/2015 05:00	0.0	0	0	0	0	1
03/14/2015 06:00	0.0	0	0	0	0	1
03/14/2015 07:00	0.0	0	0	0	0	1
03/14/2015 08:00	0.0	0	0	0	0	1
03/14/2015 09:00	0.0	0	0	0	0	1
03/14/2015 10:00	0.0	0	0	0	0	1
03/14/2015 11:00	0.0	0	0	0	0	1
03/14/2015 12:00	0.0	0	0	0	0	1
03/14/2015 13:00	0.0	0	0	0	0	1
03/14/2015 14:00	0.0	0	0	0	0	1
03/14/2015 15:00	0.0	0	0	0	0	1
03/14/2015 16:00	0.0	0	0	0	0	1
03/14/2015 17:00	0.0	0	0	0	0	1
03/14/2015 18:00	0.0	0	0	0	0	1
03/14/2015 19:00	0.0	0	0	0	0	1
03/14/2015 20:00	0.0	0	0	0	0	1
03/14/2015 21:00	0.0	0	0	0	0	1
03/14/2015 22:00	0.0	0	0	0	0	1
03/14/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/15/2015 00:00	0.0	0	0	0	0	1
03/15/2015 01:00	0.0	0	0	0	0	1
03/15/2015 02:00	0.0	0	0	0	0	1
03/15/2015 03:00	0.0	0	0	0	0	1
03/15/2015 04:00	0.0	0	0	0	0	1
03/15/2015 05:00	0.0	0	0	0	0	1
03/15/2015 06:00	0.0	0	0	0	0	1
03/15/2015 07:00	0.0	0	0	0	0	1
03/15/2015 08:00	0.0	0	0	0	0	1
03/15/2015 09:00	0.0	0	0	0	0	1
03/15/2015 10:00	0.0	0	0	0	0	1
03/15/2015 11:00	0.0	0	0	0	0	1
03/15/2015 12:00	0.0	0	0	0	0	1
03/15/2015 13:00	0.0	0	0	0	0	1
03/15/2015 14:00	0.0	0	0	0	0	1
03/15/2015 15:00	0.0	0	0	0	0	1
03/15/2015 16:00	0.0	0	0	0	0	1
03/15/2015 17:00	0.0	0	0	0	0	1
03/15/2015 18:00	0.0	0	0	0	0	1
03/15/2015 19:00	0.0	0	0	0	0	1
03/15/2015 20:00	0.0	0	0	0	0	1
03/15/2015 21:00	0.0	0	0	0	0	1
03/15/2015 22:00	0.0	0	0	0	0	1
03/15/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/16/2015 00:00	0.0	0	0	0	0	1
03/16/2015 01:00	0.0	0	0	0	0	1
03/16/2015 02:00	0.0	0	0	0	0	1
03/16/2015 03:00	0.0	0	0	0	0	1
03/16/2015 04:00	0.0	0	0	0	0	1
03/16/2015 05:00	0.0	0	0	0	0	1
03/16/2015 06:00	0.0	0	0	0	0	1
03/16/2015 07:00	0.0	0	0	0	0	1
03/16/2015 08:00	0.0	0	0	0	0	1
03/16/2015 09:00	0.0	0	0	0	0	1
03/16/2015 10:00	0.0	0	0	0	0	1
03/16/2015 11:00	0.0	0	0	0	0	1
03/16/2015 12:00	0.0	0	0	0	0	1
03/16/2015 13:00	0.0	0	0	0	0	1
03/16/2015 14:00	0.0	0	0	0	0	1
03/16/2015 15:00	0.0	0	0	0	0	1
03/16/2015 16:00	0.0	0	0	0	0	1
03/16/2015 17:00	0.0	0	0	0	0	1
03/16/2015 18:00	0.0	0	0	0	0	1
03/16/2015 19:00	0.0	0	0	0	0	1
03/16/2015 20:00	0.0	0	0	0	0	1
03/16/2015 21:00	0.0	0	0	0	0	1
03/16/2015 22:00	0.0	0	0	0	0	1
03/16/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/17/2015 00:00	0.0	0	0	0	0	1
03/17/2015 01:00	0.0	0	0	0	0	1
03/17/2015 02:00	0.0	0	0	0	0	1
03/17/2015 03:00	0.0	0	0	0	0	1
03/17/2015 04:00	0.0	0	0	0	0	1
03/17/2015 05:00	0.0	0	0	0	0	1
03/17/2015 06:00	0.0	0	0	0	0	1
03/17/2015 07:00	0.0	0	0	0	0	1
03/17/2015 08:00	0.0	0	0	0	0	1
03/17/2015 09:00	0.0	0	0	0	0	1
03/17/2015 10:00	0.0	0	0	0	0	1
03/17/2015 11:00	0.0	0	0	0	0	1
03/17/2015 12:00	0.0	0	0	0	0	1
03/17/2015 13:00	0.0	0	0	0	0	1
03/17/2015 14:00	0.0	0	0	0	0	1
03/17/2015 15:00	0.0	0	0	0	0	1
03/17/2015 16:00	0.0	0	0	0	0	1
03/17/2015 17:00	0.0	0	0	0	0	1
03/17/2015 18:00	0.0	0	0	0	0	1
03/17/2015 19:00	0.0	0	0	0	0	1
03/17/2015 20:00	0.0	0	0	0	0	1
03/17/2015 21:00	0.0	0	0	0	0	1
03/17/2015 22:00	0.0	0	0	0	0	1
03/17/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/18/2015 00:00	0.0	0	0	0	0	1
03/18/2015 01:00	0.0	0	0	0	0	1
03/18/2015 02:00	0.0	0	0	0	0	1
03/18/2015 03:00	0.0	0	0	0	0	1
03/18/2015 04:00	0.0	0	0	0	0	1
03/18/2015 05:00	0.0	0	0	0	0	1
03/18/2015 06:00	0.0	0	0	0	0	1
03/18/2015 07:00	0.0	0	0	0	0	1
03/18/2015 08:00	0.0	0	0	0	0	1
03/18/2015 09:00	1,254.1	0	0	1	0	0
03/18/2015 10:00	1,257.1	0	0	1	0	0
03/18/2015 11:00	1,256.4	0	0	1	0	0
03/18/2015 12:00	0.0	0	0	0	0	1
03/18/2015 13:00	0.0	0	0	0	0	1
03/18/2015 14:00	0.0	0	0	0	0	1
03/18/2015 15:00	0.0	0	0	0	0	1
03/18/2015 16:00	0.0	0	0	0	0	1
03/18/2015 17:00	0.0	0	0	0	0	1
03/18/2015 18:00	0.0	0	0	0	0	1
03/18/2015 19:00	0.0	0	0	0	0	1
03/18/2015 20:00	0.0	0	0	0	0	1
03/18/2015 21:00	0.0	0	0	0	0	1
03/18/2015 22:00	0.0	0	0	0	0	1
03/18/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	3,767.6 #	0 #	0 #	3 #	0 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1,257.1	0	0	1	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/19/2015 00:00	0.0	0	0	0	0	1
03/19/2015 01:00	0.0	0	0	0	0	1
03/19/2015 02:00	0.0	0	0	0	0	1
03/19/2015 03:00	0.0	0	0	0	0	1
03/19/2015 04:00	0.0	0	0	0	0	1
03/19/2015 05:00	0.0	0	0	0	0	1
03/19/2015 06:00	0.0	0	0	0	0	1
03/19/2015 07:00	0.0	0	0	0	0	1
03/19/2015 08:00	0.0	0	0	0	0	1
03/19/2015 09:00	0.0	0	0	0	0	1
03/19/2015 10:00	0.0	0	0	0	0	1
03/19/2015 11:00	0.0	0	0	0	0	1
03/19/2015 12:00	0.0	0	0	0	0	1
03/19/2015 13:00	0.0	0	0	0	0	1
03/19/2015 14:00	0.0	0	0	0	0	1
03/19/2015 15:00	0.0	0	0	0	0	1
03/19/2015 16:00	0.0	0	0	0	0	1
03/19/2015 17:00	0.0	0	0	0	0	1
03/19/2015 18:00	0.0	0	0	0	0	1
03/19/2015 19:00	0.0	0	0	0	0	1
03/19/2015 20:00	0.0	0	0	0	0	1
03/19/2015 21:00	0.0	0	0	0	0	1
03/19/2015 22:00	0.0	0	0	0	0	1
03/19/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/20/2015 00:00	0.0	0	0	0	0	1
03/20/2015 01:00	0.0	0	0	0	0	1
03/20/2015 02:00	0.0	0	0	0	0	1
03/20/2015 03:00	0.0	0	0	0	0	1
03/20/2015 04:00	0.0	0	0	0	0	1
03/20/2015 05:00	0.0	0	0	0	0	1
03/20/2015 06:00	0.0	0	0	0	0	1
03/20/2015 07:00	0.0	0	0	0	0	1
03/20/2015 08:00	0.0	0	0	0	0	1
03/20/2015 09:00	0.0	0	0	0	0	1
03/20/2015 10:00	0.0	0	0	0	0	1
03/20/2015 11:00	0.0	0	0	0	0	1
03/20/2015 12:00	0.0	0	0	0	0	1
03/20/2015 13:00	0.0	0	0	0	0	1
03/20/2015 14:00	0.0	0	0	0	0	1
03/20/2015 15:00	0.0	0	0	0	0	1
03/20/2015 16:00	0.0	0	0	0	0	1
03/20/2015 17:00	0.0	0	0	0	0	1
03/20/2015 18:00	0.0	0	0	0	0	1
03/20/2015 19:00	0.0	0	0	0	0	1
03/20/2015 20:00	0.0	0	0	0	0	1
03/20/2015 21:00	0.0	0	0	0	0	1
03/20/2015 22:00	0.0	0	0	0	0	1
03/20/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/21/2015 00:00	0.0	0	0	0	0	1
03/21/2015 01:00	0.0	0	0	0	0	1
03/21/2015 02:00	0.0	0	0	0	0	1
03/21/2015 03:00	0.0	0	0	0	0	1
03/21/2015 04:00	0.0	0	0	0	0	1
03/21/2015 05:00	0.0	0	0	0	0	1
03/21/2015 06:00	0.0	0	0	0	0	1
03/21/2015 07:00	0.0	0	0	0	0	1
03/21/2015 08:00	0.0	0	0	0	0	1
03/21/2015 09:00	0.0	0	0	0	0	1
03/21/2015 10:00	0.0	0	0	0	0	1
03/21/2015 11:00	0.0	0	0	0	0	1
03/21/2015 12:00	0.0	0	0	0	0	1
03/21/2015 13:00	0.0	0	0	0	0	1
03/21/2015 14:00	0.0	0	0	0	0	1
03/21/2015 15:00	0.0	0	0	0	0	1
03/21/2015 16:00	0.0	0	0	0	0	1
03/21/2015 17:00	0.0	0	0	0	0	1
03/21/2015 18:00	0.0	0	0	0	0	1
03/21/2015 19:00	0.0	0	0	0	0	1
03/21/2015 20:00	0.0	0	0	0	0	1
03/21/2015 21:00	0.0	0	0	0	0	1
03/21/2015 22:00	0.0	0	0	0	0	1
03/21/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/22/2015 00:00	0.0	0	0	0	0	1
03/22/2015 01:00	0.0	0	0	0	0	1
03/22/2015 02:00	0.0	0	0	0	0	1
03/22/2015 03:00	0.0	0	0	0	0	1
03/22/2015 04:00	0.0	0	0	0	0	1
03/22/2015 05:00	0.0	0	0	0	0	1
03/22/2015 06:00	0.0	0	0	0	0	1
03/22/2015 07:00	0.0	0	0	0	0	1
03/22/2015 08:00	0.0	0	0	0	0	1
03/22/2015 09:00	0.0	0	0	0	0	1
03/22/2015 10:00	0.0	0	0	0	0	1
03/22/2015 11:00	0.0	0	0	0	0	1
03/22/2015 12:00	0.0	0	0	0	0	1
03/22/2015 13:00	0.0	0	0	0	0	1
03/22/2015 14:00	0.0	0	0	0	0	1
03/22/2015 15:00	0.0	0	0	0	0	1
03/22/2015 16:00	0.0	0	0	0	0	1
03/22/2015 17:00	0.0	0	0	0	0	1
03/22/2015 18:00	0.0	0	0	0	0	1
03/22/2015 19:00	0.0	0	0	0	0	1
03/22/2015 20:00	0.0	0	0	0	0	1
03/22/2015 21:00	0.0	0	0	0	0	1
03/22/2015 22:00	0.0	0	0	0	0	1
03/22/2015 23:00	367.2	0	0	0	1	0
Average/Sum#:	367.2 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	367.2	0	0	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/23/2015 00:00	0.0	0	0	0	0	0
03/23/2015 01:00	0.0	0	0	0	0	0
03/23/2015 02:00	0.0	0	0	0	0	0
03/23/2015 03:00	0.0	0	0	0	0	0
03/23/2015 04:00	0.0	0	0	0	0	0
03/23/2015 05:00	0.0	0	0	0	0	0
03/23/2015 06:00	0.0	0	0	0	0	0
03/23/2015 07:00	0.0	0	0	0	0	0
03/23/2015 08:00	0.0	0	0	0	0	0
03/23/2015 09:00	0.0	0	0	0	0	0
03/23/2015 10:00	0.0	0	0	0	0	0
03/23/2015 11:00	0.0	0	0	0	0	0
03/23/2015 12:00	0.0	0	0	0	0	0
03/23/2015 13:00	0.0	0	0	0	0	0
03/23/2015 14:00	0.0	0	0	0	0	0
03/23/2015 15:00	0.0	0	0	0	0	0
03/23/2015 16:00	0.0	0	0	0	0	0
03/23/2015 17:00	0.0	0	0	0	0	0
03/23/2015 18:00	0.0	0	0	0	0	0
03/23/2015 19:00	0.0	0	0	0	0	0
03/23/2015 20:00	0.0	0	0	0	0	0
03/23/2015 21:00	0.0	0	0	0	0	0
03/23/2015 22:00	0.0	0	0	0	0	0
03/23/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/24/2015 00:00	0.0	0	0	0	0	0
03/24/2015 01:00	0.0	0	0	0	0	0
03/24/2015 02:00	0.0	0	0	0	0	0
03/24/2015 03:00	0.0	0	0	0	0	0
03/24/2015 04:00	0.0	0	0	0	0	0
03/24/2015 05:00	0.0	0	0	0	0	0
03/24/2015 06:00	0.0	0	0	0	0	0
03/24/2015 07:00	0.0	0	0	0	0	0
03/24/2015 08:00	0.0	0	0	0	0	0
03/24/2015 09:00	0.0	0	0	0	0	0
03/24/2015 10:00	0.0	0	0	0	0	0
03/24/2015 11:00	0.0	0	0	0	0	0
03/24/2015 12:00	0.0	0	0	0	0	0
03/24/2015 13:00	0.0	0	0	0	0	0
03/24/2015 14:00	0.0	0	0	0	0	0
03/24/2015 15:00	0.0	0	0	0	0	0
03/24/2015 16:00	0.0	0	0	0	0	0
03/24/2015 17:00	0.0	0	0	0	0	0
03/24/2015 18:00	0.0	0	0	0	0	0
03/24/2015 19:00	0.0	0	0	0	0	0
03/24/2015 20:00	0.0	0	0	0	0	0
03/24/2015 21:00	0.0	0	0	0	0	0
03/24/2015 22:00	0.0	0	0	0	0	0
03/24/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/25/2015 00:00	0.0	0	0	0	0	0
03/25/2015 01:00	0.0	0	0	0	0	0
03/25/2015 02:00	0.0	0	0	0	0	0
03/25/2015 03:00	0.0	0	0	0	0	0
03/25/2015 04:00	0.0	0	0	0	0	0
03/25/2015 05:00	0.0	0	0	0	0	0
03/25/2015 06:00	0.0	0	0	0	0	0
03/25/2015 07:00	0.0	0	0	0	0	0
03/25/2015 08:00	0.0	0	0	0	0	0
03/25/2015 09:00	0.0	0	0	0	0	0
03/25/2015 10:00	0.0	0	0	0	0	0
03/25/2015 11:00	0.0	0	0	0	0	0
03/25/2015 12:00	0.0	0	0	0	0	0
03/25/2015 13:00	0.0	0	0	0	0	0
03/25/2015 14:00	0.0	0	0	0	0	0
03/25/2015 15:00	0.0	0	0	0	0	0
03/25/2015 16:00	0.0	0	0	0	0	0
03/25/2015 17:00	0.0	0	0	0	0	0
03/25/2015 18:00	0.0	0	0	0	0	0
03/25/2015 19:00	0.0	0	0	0	0	0
03/25/2015 20:00	0.0	0	0	0	0	0
03/25/2015 21:00	0.0	0	0	0	0	0
03/25/2015 22:00	0.0	0	0	0	0	0
03/25/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/26/2015 00:00	0.0	0	0	0	0	0
03/26/2015 01:00	0.0	0	0	0	0	0
03/26/2015 02:00	0.0	0	0	0	0	0
03/26/2015 03:00	0.0	0	0	0	0	0
03/26/2015 04:00	0.0	0	0	0	0	0
03/26/2015 05:00	0.0	0	0	0	0	0
03/26/2015 06:00	0.0	0	0	0	0	0
03/26/2015 07:00	0.0	0	0	0	0	0
03/26/2015 08:00	0.0	0	0	0	0	0
03/26/2015 09:00	0.0	0	0	0	0	0
03/26/2015 10:00	0.0	0	0	0	0	0
03/26/2015 11:00	0.0	0	0	0	0	0
03/26/2015 12:00	0.0	0	0	0	0	0
03/26/2015 13:00	0.0	0	0	0	0	0
03/26/2015 14:00	0.0	0	0	0	0	0
03/26/2015 15:00	0.0	0	0	0	0	0
03/26/2015 16:00	0.0	0	0	0	0	0
03/26/2015 17:00	0.0	0	0	0	0	0
03/26/2015 18:00	0.0	0	0	0	0	0
03/26/2015 19:00	0.0	0	0	0	0	0
03/26/2015 20:00	0.0	0	0	0	0	0
03/26/2015 21:00	0.0	0	0	0	0	0
03/26/2015 22:00	0.0	0	0	0	0	0
03/26/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/27/2015 00:00	0.0	0	0	0	0	0
03/27/2015 01:00	0.0	0	0	0	0	0
03/27/2015 02:00	0.0	0	0	0	0	0
03/27/2015 03:00	0.0	0	0	0	0	0
03/27/2015 04:00	0.0	0	0	0	0	0
03/27/2015 05:00	0.0	0	0	0	0	0
03/27/2015 06:00	0.0	0	0	0	0	0
03/27/2015 07:00	0.0	0	0	0	0	0
03/27/2015 08:00	0.0	0	0	0	0	0
03/27/2015 09:00	0.0	0	0	0	0	0
03/27/2015 10:00	0.0	0	0	0	0	0
03/27/2015 11:00	0.0	0	0	0	0	0
03/27/2015 12:00	0.0	0	0	0	0	0
03/27/2015 13:00	0.0	0	0	0	0	0
03/27/2015 14:00	0.0	0	0	0	0	0
03/27/2015 15:00	0.0	0	0	0	0	0
03/27/2015 16:00	0.0	0	0	0	0	0
03/27/2015 17:00	0.0	0	0	0	0	0
03/27/2015 18:00	0.0	0	0	0	0	0
03/27/2015 19:00	0.0	0	0	0	0	0
03/27/2015 20:00	0.0	0	0	0	0	0
03/27/2015 21:00	0.0	0	0	0	0	0
03/27/2015 22:00	0.0	0	0	0	0	0
03/27/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/28/2015 00:00	0.0	0	0	0	0	0
03/28/2015 01:00	0.0	0	0	0	0	0
03/28/2015 02:00	0.0	0	0	0	0	0
03/28/2015 03:00	0.0	0	0	0	0	0
03/28/2015 04:00	0.0	0	0	0	0	0
03/28/2015 05:00	0.0	0	0	0	0	0
03/28/2015 06:00	0.0	0	0	0	0	0
03/28/2015 07:00	0.0	0	0	0	0	0
03/28/2015 08:00	0.0	0	0	0	0	0
03/28/2015 09:00	0.0	0	0	0	0	0
03/28/2015 10:00	0.0	0	0	0	0	0
03/28/2015 11:00	0.0	0	0	0	0	0
03/28/2015 12:00	0.0	0	0	0	0	0
03/28/2015 13:00	0.0	0	0	0	0	0
03/28/2015 14:00	0.0	0	0	0	0	0
03/28/2015 15:00	0.0	0	0	0	0	0
03/28/2015 16:00	0.0	0	0	0	0	0
03/28/2015 17:00	0.0	0	0	0	0	0
03/28/2015 18:00	0.0	0	0	0	0	0
03/28/2015 19:00	0.0	0	0	0	0	0
03/28/2015 20:00	0.0	0	0	0	0	0
03/28/2015 21:00	0.0	0	0	0	0	0
03/28/2015 22:00	0.0	0	0	0	0	0
03/28/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/29/2015 00:00	0.0	0	0	0	0	0
03/29/2015 01:00	0.0	0	0	0	0	0
03/29/2015 02:00	0.0	0	0	0	0	0
03/29/2015 03:00	0.0	0	0	0	0	0
03/29/2015 04:00	0.0	0	0	0	0	0
03/29/2015 05:00	0.0	0	0	0	0	0
03/29/2015 06:00	0.0	0	0	0	0	0
03/29/2015 07:00	0.0	0	0	0	0	0
03/29/2015 08:00	0.0	0	0	0	0	0
03/29/2015 09:00	0.0	0	0	0	0	0
03/29/2015 10:00	0.0	0	0	0	0	0
03/29/2015 11:00	0.0	0	0	0	0	0
03/29/2015 12:00	0.0	0	0	0	0	0
03/29/2015 13:00	0.0	0	0	0	0	0
03/29/2015 14:00	0.0	0	0	0	0	0
03/29/2015 15:00	0.0	0	0	0	0	0
03/29/2015 16:00	0.0	0	0	0	0	0
03/29/2015 17:00	0.0	0	0	0	0	0
03/29/2015 18:00	0.0	0	0	0	0	0
03/29/2015 19:00	0.0	0	0	0	0	0
03/29/2015 20:00	0.0	0	0	0	0	0
03/29/2015 21:00	0.0	0	0	0	0	0
03/29/2015 22:00	0.0	0	0	0	0	0
03/29/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/30/2015 00:00	0.0	0	0	0	0	0
03/30/2015 01:00	0.0	0	0	0	0	0
03/30/2015 02:00	0.0	0	0	0	0	0
03/30/2015 03:00	0.0	0	0	0	0	0
03/30/2015 04:00	0.0	0	0	0	0	0
03/30/2015 05:00	0.0	0	0	0	0	0
03/30/2015 06:00	0.0	0	0	0	0	0
03/30/2015 07:00	0.0	0	0	0	0	0
03/30/2015 08:00	0.0	0	0	0	0	0
03/30/2015 09:00	0.0	0	0	0	0	0
03/30/2015 10:00	0.0	0	0	0	0	0
03/30/2015 11:00	0.0	0	0	0	0	0
03/30/2015 12:00	0.0	0	0	0	0	0
03/30/2015 13:00	0.0	0	0	0	0	0
03/30/2015 14:00	0.0	0	0	0	0	0
03/30/2015 15:00	0.0	0	0	0	0	0
03/30/2015 16:00	0.0	0	0	0	0	0
03/30/2015 17:00	0.0	0	0	0	0	0
03/30/2015 18:00	0.0	0	0	0	0	0
03/30/2015 19:00	0.0	0	0	0	0	0
03/30/2015 20:00	0.0	0	0	0	0	0
03/30/2015 21:00	0.0	0	0	0	0	0
03/30/2015 22:00	0.0	0	0	0	0	0
03/30/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/31/2015 00:00	0.0	0	0	0	0	0
03/31/2015 01:00	0.0	0	0	0	0	0
03/31/2015 02:00	0.0	0	0	0	0	0
03/31/2015 03:00	0.0	0	0	0	0	0
03/31/2015 04:00	0.0	0	0	0	0	0
03/31/2015 05:00	0.0	0	0	0	0	0
03/31/2015 06:00	0.0	0	0	0	0	0
03/31/2015 07:00	0.0	0	0	0	0	0
03/31/2015 08:00	0.0	0	0	0	0	0
03/31/2015 09:00	0.0	0	0	0	0	0
03/31/2015 10:00	0.0	0	0	0	0	0
03/31/2015 11:00	0.0	0	0	0	0	0
03/31/2015 12:00	0.0	0	0	0	0	0
03/31/2015 13:00	0.0	0	0	0	0	0
03/31/2015 14:00	0.0	0	0	0	0	0
03/31/2015 15:00	0.0	0	0	0	0	0
03/31/2015 16:00	0.0	0	0	0	0	0
03/31/2015 17:00	0.0	0	0	0	0	0
03/31/2015 18:00	0.0	0	0	0	0	0
03/31/2015 19:00	0.0	0	0	0	0	0
03/31/2015 20:00	0.0	0	0	0	0	0
03/31/2015 21:00	0.0	0	0	0	0	0
03/31/2015 22:00	0.0	0	0	0	0	0
03/31/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/01/2015 00:00	0.0	0	0	0	0	1
01/01/2015 01:00	0.0	0	0	0	0	1
01/01/2015 02:00	0.0	0	0	0	0	1
01/01/2015 03:00	0.0	0	0	0	0	1
01/01/2015 04:00	0.0	0	0	0	0	1
01/01/2015 05:00	0.0	0	0	0	0	1
01/01/2015 06:00	0.0	0	0	0	0	1
01/01/2015 07:00	0.0	0	0	0	0	1
01/01/2015 08:00	0.0	0	0	0	0	1
01/01/2015 09:00	0.0	0	0	0	0	1
01/01/2015 10:00	0.0	0	0	0	0	1
01/01/2015 11:00	0.0	0	0	0	0	1
01/01/2015 12:00	0.0	0	0	0	0	1
01/01/2015 13:00	0.0	0	0	0	0	1
01/01/2015 14:00	0.0	0	0	0	0	1
01/01/2015 15:00	0.0	0	0	0	0	1
01/01/2015 16:00	0.0	0	0	0	0	1
01/01/2015 17:00	0.0	0	0	0	0	1
01/01/2015 18:00	0.0	0	0	0	0	1
01/01/2015 19:00	0.0	0	0	0	0	1
01/01/2015 20:00	0.0	0	0	0	0	1
01/01/2015 21:00	0.0	0	0	0	0	1
01/01/2015 22:00	0.0	0	0	0	0	1
01/01/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/02/2015 00:00	0.0	0	0	0	0	1
01/02/2015 01:00	0.0	0	0	0	0	1
01/02/2015 02:00	0.0	0	0	0	0	1
01/02/2015 03:00	0.0	0	0	0	0	1
01/02/2015 04:00	0.0	0	0	0	0	1
01/02/2015 05:00	0.0	0	0	0	0	1
01/02/2015 06:00	0.0	0	0	0	0	1
01/02/2015 07:00	0.0	0	0	0	0	1
01/02/2015 08:00	0.0	0	0	0	0	1
01/02/2015 09:00	0.0	0	0	0	0	1
01/02/2015 10:00	0.0	0	0	0	0	1
01/02/2015 11:00	0.0	0	0	0	0	1
01/02/2015 12:00	0.0	0	0	0	0	1
01/02/2015 13:00	0.0	0	0	0	0	1
01/02/2015 14:00	0.0	0	0	0	0	1
01/02/2015 15:00	0.0	0	0	0	0	1
01/02/2015 16:00	0.0	0	0	0	0	1
01/02/2015 17:00	0.0	0	0	0	0	1
01/02/2015 18:00	0.0	0	0	0	0	1
01/02/2015 19:00	0.0	0	0	0	0	1
01/02/2015 20:00	0.0	0	0	0	0	1
01/02/2015 21:00	0.0	0	0	0	0	1
01/02/2015 22:00	0.0	0	0	0	0	1
01/02/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/03/2015 00:00	0.0	0	0	0	0	1
01/03/2015 01:00	0.0	0	0	0	0	1
01/03/2015 02:00	0.0	0	0	0	0	1
01/03/2015 03:00	0.0	0	0	0	0	1
01/03/2015 04:00	0.0	0	0	0	0	1
01/03/2015 05:00	0.0	0	0	0	0	1
01/03/2015 06:00	0.0	0	0	0	0	1
01/03/2015 07:00	0.0	0	0	0	0	1
01/03/2015 08:00	0.0	0	0	0	0	1
01/03/2015 09:00	0.0	0	0	0	0	1
01/03/2015 10:00	0.0	0	0	0	0	1
01/03/2015 11:00	0.0	0	0	0	0	1
01/03/2015 12:00	0.0	0	0	0	0	1
01/03/2015 13:00	0.0	0	0	0	0	1
01/03/2015 14:00	0.0	0	0	0	0	1
01/03/2015 15:00	0.0	0	0	0	0	1
01/03/2015 16:00	0.0	0	0	0	0	1
01/03/2015 17:00	0.0	0	0	0	0	1
01/03/2015 18:00	0.0	0	0	0	0	1
01/03/2015 19:00	0.0	0	0	0	0	1
01/03/2015 20:00	0.0	0	0	0	0	1
01/03/2015 21:00	0.0	0	0	0	0	1
01/03/2015 22:00	0.0	0	0	0	0	1
01/03/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/04/2015 00:00	0.0	0	0	0	0	1
01/04/2015 01:00	0.0	0	0	0	0	1
01/04/2015 02:00	0.0	0	0	0	0	1
01/04/2015 03:00	0.0	0	0	0	0	1
01/04/2015 04:00	0.0	0	0	0	0	1
01/04/2015 05:00	0.0	0	0	0	0	1
01/04/2015 06:00	0.0	0	0	0	0	1
01/04/2015 07:00	0.0	0	0	0	0	1
01/04/2015 08:00	0.0	0	0	0	0	1
01/04/2015 09:00	0.0	0	0	0	0	1
01/04/2015 10:00	0.0	0	0	0	0	1
01/04/2015 11:00	0.0	0	0	0	0	1
01/04/2015 12:00	0.0	0	0	0	0	1
01/04/2015 13:00	0.0	0	0	0	0	1
01/04/2015 14:00	0.0	0	0	0	0	1
01/04/2015 15:00	0.0	0	0	0	0	1
01/04/2015 16:00	0.0	0	0	0	0	1
01/04/2015 17:00	0.0	0	0	0	0	1
01/04/2015 18:00	0.0	0	0	0	0	1
01/04/2015 19:00	0.0	0	0	0	0	1
01/04/2015 20:00	0.0	0	0	0	0	1
01/04/2015 21:00	0.0	0	0	0	0	1
01/04/2015 22:00	0.0	0	0	0	0	1
01/04/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/05/2015 00:00	0.0	0	0	0	0	1
01/05/2015 01:00	0.0	0	0	0	0	1
01/05/2015 02:00	0.0	0	0	0	0	1
01/05/2015 03:00	0.0	0	0	0	0	1
01/05/2015 04:00	0.0	0	0	0	0	1
01/05/2015 05:00	0.0	0	0	0	0	1
01/05/2015 06:00	0.0	0	0	0	0	1
01/05/2015 07:00	0.0	0	0	0	0	1
01/05/2015 08:00	0.0	0	0	0	0	1
01/05/2015 09:00	0.0	0	0	0	0	1
01/05/2015 10:00	0.0	0	0	0	0	1
01/05/2015 11:00	0.0	0	0	0	0	1
01/05/2015 12:00	0.0	0	0	0	0	1
01/05/2015 13:00	0.0	0	0	0	0	1
01/05/2015 14:00	0.0	0	0	0	0	1
01/05/2015 15:00	0.0	0	0	0	0	1
01/05/2015 16:00	0.0	0	0	0	0	1
01/05/2015 17:00	0.0	0	0	0	0	1
01/05/2015 18:00	0.0	0	0	0	0	1
01/05/2015 19:00	0.0	0	0	0	0	1
01/05/2015 20:00	0.0	0	0	0	0	1
01/05/2015 21:00	0.0	0	0	0	0	1
01/05/2015 22:00	0.0	0	0	0	0	1
01/05/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/06/2015 00:00	0.0	0	0	0	0	1
01/06/2015 01:00	0.0	0	0	0	0	1
01/06/2015 02:00	0.0	0	0	0	0	1
01/06/2015 03:00	0.0	0	0	0	0	1
01/06/2015 04:00	0.0	0	0	0	0	1
01/06/2015 05:00	0.0	0	0	0	0	1
01/06/2015 06:00	0.0	0	0	0	0	1
01/06/2015 07:00	0.0	0	0	0	0	1
01/06/2015 08:00	0.0	0	0	0	0	1
01/06/2015 09:00	0.0	0	0	0	0	1
01/06/2015 10:00	0.0	0	0	0	0	1
01/06/2015 11:00	0.0	0	0	0	0	1
01/06/2015 12:00	0.0	0	0	0	0	1
01/06/2015 13:00	0.0	0	0	0	0	1
01/06/2015 14:00	0.0	0	0	0	0	1
01/06/2015 15:00	0.0	0	0	0	0	1
01/06/2015 16:00	0.0	0	0	0	0	1
01/06/2015 17:00	0.0	0	0	0	0	1
01/06/2015 18:00	0.0	0	0	0	0	1
01/06/2015 19:00	0.0	0	0	0	0	1
01/06/2015 20:00	0.0	0	0	0	0	1
01/06/2015 21:00	0.0	0	0	0	0	1
01/06/2015 22:00	0.0	0	0	0	0	1
01/06/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/07/2015 00:00	0.0	0	0	0	0	1
01/07/2015 01:00	0.0	0	0	0	0	1
01/07/2015 02:00	0.0	0	0	0	0	1
01/07/2015 03:00	0.0	0	0	0	0	1
01/07/2015 04:00	0.0	0	0	0	0	1
01/07/2015 05:00	0.0	0	0	0	0	1
01/07/2015 06:00	0.0	0	0	0	0	1
01/07/2015 07:00	0.0	0	0	0	0	1
01/07/2015 08:00	0.0	0	0	0	0	1
01/07/2015 09:00	0.0	0	0	0	0	1
01/07/2015 10:00	0.0	0	0	0	0	1
01/07/2015 11:00	0.0	0	0	0	0	1
01/07/2015 12:00	0.0	0	0	0	0	1
01/07/2015 13:00	0.0	0	0	0	0	1
01/07/2015 14:00	0.0	0	0	0	0	1
01/07/2015 15:00	0.0	0	0	0	0	1
01/07/2015 16:00	0.0	0	0	0	0	1
01/07/2015 17:00	0.0	0	0	0	0	1
01/07/2015 18:00	0.0	0	0	0	0	1
01/07/2015 19:00	0.0	0	0	0	0	1
01/07/2015 20:00	0.0	0	0	0	0	1
01/07/2015 21:00	0.0	0	0	0	0	1
01/07/2015 22:00	0.0	0	0	0	0	1
01/07/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/08/2015 00:00	0.0	0	0	0	0	1
01/08/2015 01:00	0.0	0	0	0	0	1
01/08/2015 02:00	0.0	0	0	0	0	1
01/08/2015 03:00	0.0	0	0	0	0	1
01/08/2015 04:00	0.0	0	0	0	0	1
01/08/2015 05:00	0.0	0	0	0	0	1
01/08/2015 06:00	0.0	0	0	0	0	1
01/08/2015 07:00	0.0	0	0	0	0	1
01/08/2015 08:00	0.0	0	0	0	0	1
01/08/2015 09:00	0.0	0	0	0	0	1
01/08/2015 10:00	0.0	0	0	0	0	1
01/08/2015 11:00	0.0	0	0	0	0	1
01/08/2015 12:00	0.0	0	0	0	0	1
01/08/2015 13:00	0.0	0	0	0	0	1
01/08/2015 14:00	0.0	0	0	0	0	1
01/08/2015 15:00	0.0	0	0	0	0	1
01/08/2015 16:00	0.0	0	0	0	0	1
01/08/2015 17:00	0.0	0	0	0	0	1
01/08/2015 18:00	0.0	0	0	0	0	1
01/08/2015 19:00	0.0	0	0	0	0	1
01/08/2015 20:00	0.0	0	0	0	0	1
01/08/2015 21:00	0.0	0	0	0	0	1
01/08/2015 22:00	0.0	0	0	0	0	1
01/08/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/09/2015 00:00	0.0	0	0	0	0	1
01/09/2015 01:00	0.0	0	0	0	0	1
01/09/2015 02:00	0.0	0	0	0	0	1
01/09/2015 03:00	0.0	0	0	0	0	1
01/09/2015 04:00	0.0	0	0	0	0	1
01/09/2015 05:00	0.0	0	0	0	0	1
01/09/2015 06:00	0.0	0	0	0	0	1
01/09/2015 07:00	0.0	0	0	0	0	1
01/09/2015 08:00	0.0	0	0	0	0	1
01/09/2015 09:00	0.0	0	0	0	0	1
01/09/2015 10:00	0.0	0	0	0	0	1
01/09/2015 11:00	0.0	0	0	0	0	1
01/09/2015 12:00	0.0	0	0	0	0	1
01/09/2015 13:00	0.0	0	0	0	0	1
01/09/2015 14:00	0.0	0	0	0	0	1
01/09/2015 15:00	0.0	0	0	0	0	1
01/09/2015 16:00	0.0	0	0	0	0	1
01/09/2015 17:00	0.0	0	0	0	0	1
01/09/2015 18:00	0.0	0	0	0	0	1
01/09/2015 19:00	0.0	0	0	0	0	1
01/09/2015 20:00	0.0	0	0	0	0	1
01/09/2015 21:00	0.0	0	0	0	0	1
01/09/2015 22:00	0.0	0	0	0	0	1
01/09/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/10/2015 00:00	0.0	0	0	0	0	1
01/10/2015 01:00	0.0	0	0	0	0	1
01/10/2015 02:00	0.0	0	0	0	0	1
01/10/2015 03:00	0.0	0	0	0	0	1
01/10/2015 04:00	0.0	0	0	0	0	1
01/10/2015 05:00	0.0	0	0	0	0	1
01/10/2015 06:00	0.0	0	0	0	0	1
01/10/2015 07:00	0.0	0	0	0	0	1
01/10/2015 08:00	0.0	0	0	0	0	1
01/10/2015 09:00	0.0	0	0	0	0	1
01/10/2015 10:00	0.0	0	0	0	0	1
01/10/2015 11:00	0.0	0	0	0	0	1
01/10/2015 12:00	0.0	0	0	0	0	1
01/10/2015 13:00	0.0	0	0	0	0	1
01/10/2015 14:00	0.0	0	0	0	0	1
01/10/2015 15:00	0.0	0	0	0	0	1
01/10/2015 16:00	0.0	0	0	0	0	1
01/10/2015 17:00	0.0	0	0	0	0	1
01/10/2015 18:00	0.0	0	0	0	0	1
01/10/2015 19:00	0.0	0	0	0	0	1
01/10/2015 20:00	0.0	0	0	0	0	1
01/10/2015 21:00	0.0	0	0	0	0	1
01/10/2015 22:00	0.0	0	0	0	0	1
01/10/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/11/2015 00:00	0.0	0	0	0	0	1
01/11/2015 01:00	0.0	0	0	0	0	1
01/11/2015 02:00	0.0	0	0	0	0	1
01/11/2015 03:00	0.0	0	0	0	0	1
01/11/2015 04:00	0.0	0	0	0	0	1
01/11/2015 05:00	0.0	0	0	0	0	1
01/11/2015 06:00	0.0	0	0	0	0	1
01/11/2015 07:00	0.0	0	0	0	0	1
01/11/2015 08:00	0.0	0	0	0	0	1
01/11/2015 09:00	0.0	0	0	0	0	1
01/11/2015 10:00	0.0	0	0	0	0	1
01/11/2015 11:00	0.0	0	0	0	0	1
01/11/2015 12:00	0.0	0	0	0	0	1
01/11/2015 13:00	0.0	0	0	0	0	1
01/11/2015 14:00	0.0	0	0	0	0	1
01/11/2015 15:00	0.0	0	0	0	0	1
01/11/2015 16:00	0.0	0	0	0	0	1
01/11/2015 17:00	0.0	0	0	0	0	1
01/11/2015 18:00	0.0	0	0	0	0	1
01/11/2015 19:00	0.0	0	0	0	0	1
01/11/2015 20:00	0.0	0	0	0	0	1
01/11/2015 21:00	0.0	0	0	0	0	1
01/11/2015 22:00	0.0	0	0	0	0	1
01/11/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/12/2015 00:00	0.0	0	0	0	0	1
01/12/2015 01:00	0.0	0	0	0	0	1
01/12/2015 02:00	0.0	0	0	0	0	1
01/12/2015 03:00	0.0	0	0	0	0	1
01/12/2015 04:00	0.0	0	0	0	0	1
01/12/2015 05:00	0.0	0	0	0	0	1
01/12/2015 06:00	0.0	0	0	0	0	1
01/12/2015 07:00	0.0	0	0	0	0	1
01/12/2015 08:00	0.0	0	0	0	0	1
01/12/2015 09:00	0.0	0	0	0	0	1
01/12/2015 10:00	0.0	0	0	0	0	1
01/12/2015 11:00	0.0	0	0	0	0	1
01/12/2015 12:00	0.0	0	0	0	0	1
01/12/2015 13:00	0.0	0	0	0	0	1
01/12/2015 14:00	0.0	0	0	0	0	1
01/12/2015 15:00	0.0	0	0	0	0	1
01/12/2015 16:00	0.0	0	0	0	0	1
01/12/2015 17:00	0.0	0	0	0	0	1
01/12/2015 18:00	0.0	0	0	0	0	1
01/12/2015 19:00	0.0	0	0	0	0	1
01/12/2015 20:00	0.0	0	0	0	0	1
01/12/2015 21:00	0.0	0	0	0	0	1
01/12/2015 22:00	0.0	0	0	0	0	1
01/12/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/13/2015 00:00	0.0	0	0	0	0	1
01/13/2015 01:00	0.0	0	0	0	0	1
01/13/2015 02:00	0.0	0	0	0	0	1
01/13/2015 03:00	0.0	0	0	0	0	1
01/13/2015 04:00	0.0	0	0	0	0	1
01/13/2015 05:00	0.0	0	0	0	0	1
01/13/2015 06:00	0.0	0	0	0	0	1
01/13/2015 07:00	0.0	0	0	0	0	1
01/13/2015 08:00	0.0	0	0	0	0	1
01/13/2015 09:00	0.0	0	0	0	0	1
01/13/2015 10:00	0.0	0	0	0	0	1
01/13/2015 11:00	0.0	0	0	0	0	1
01/13/2015 12:00	0.0	0	0	0	0	1
01/13/2015 13:00	0.0	0	0	0	0	1
01/13/2015 14:00	0.0	0	0	0	0	1
01/13/2015 15:00	0.0	0	0	0	0	1
01/13/2015 16:00	0.0	0	0	0	0	1
01/13/2015 17:00	0.0	0	0	0	0	1
01/13/2015 18:00	0.0	0	0	0	0	1
01/13/2015 19:00	0.0	0	0	0	0	1
01/13/2015 20:00	0.0	0	0	0	0	1
01/13/2015 21:00	0.0	0	0	0	0	1
01/13/2015 22:00	0.0	0	0	0	0	1
01/13/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/14/2015 00:00	0.0	0	0	0	0	1
01/14/2015 01:00	0.0	0	0	0	0	1
01/14/2015 02:00	0.0	0	0	0	0	1
01/14/2015 03:00	0.0	0	0	0	0	1
01/14/2015 04:00	0.0	0	0	0	0	1
01/14/2015 05:00	0.0	0	0	0	0	1
01/14/2015 06:00	0.0	0	0	0	0	1
01/14/2015 07:00	0.0	0	0	0	0	1
01/14/2015 08:00	0.0	0	0	0	0	1
01/14/2015 09:00	0.0	0	0	0	0	1
01/14/2015 10:00	0.0	0	0	0	0	1
01/14/2015 11:00	0.0	0	0	0	0	1
01/14/2015 12:00	0.0	0	0	0	0	1
01/14/2015 13:00	0.0	0	0	0	0	1
01/14/2015 14:00	0.0	0	0	0	0	1
01/14/2015 15:00	0.0	0	0	0	0	1
01/14/2015 16:00	0.0	0	0	0	0	1
01/14/2015 17:00	0.0	0	0	0	0	1
01/14/2015 18:00	0.0	0	0	0	0	1
01/14/2015 19:00	0.0	0	0	0	0	1
01/14/2015 20:00	0.0	0	0	0	0	1
01/14/2015 21:00	0.0	0	0	0	0	1
01/14/2015 22:00	0.0	0	0	0	0	1
01/14/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/15/2015 00:00	0.0	0	0	0	0	1
01/15/2015 01:00	0.0	0	0	0	0	1
01/15/2015 02:00	0.0	0	0	0	0	1
01/15/2015 03:00	0.0	0	0	0	0	1
01/15/2015 04:00	0.0	0	0	0	0	1
01/15/2015 05:00	0.0	0	0	0	0	1
01/15/2015 06:00	0.0	0	0	0	0	1
01/15/2015 07:00	0.0	0	0	0	0	1
01/15/2015 08:00	0.0	0	0	0	0	1
01/15/2015 09:00	0.0	0	0	0	0	1
01/15/2015 10:00	0.0	0	0	0	0	1
01/15/2015 11:00	0.0	0	0	0	0	1
01/15/2015 12:00	0.0	0	0	0	0	1
01/15/2015 13:00	0.0	0	0	0	0	1
01/15/2015 14:00	0.0	0	0	0	0	1
01/15/2015 15:00	0.0	0	0	0	0	1
01/15/2015 16:00	0.0	0	0	0	0	1
01/15/2015 17:00	0.0	0	0	0	0	1
01/15/2015 18:00	0.0	0	0	0	0	1
01/15/2015 19:00	0.0	0	0	0	0	1
01/15/2015 20:00	0.0	0	0	0	0	1
01/15/2015 21:00	0.0	0	0	0	0	1
01/15/2015 22:00	0.0	0	0	0	0	1
01/15/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/16/2015 00:00	0.0	0	0	0	0	1
01/16/2015 01:00	0.0	0	0	0	0	1
01/16/2015 02:00	0.0	0	0	0	0	1
01/16/2015 03:00	0.0	0	0	0	0	1
01/16/2015 04:00	0.0	0	0	0	0	1
01/16/2015 05:00	0.0	0	0	0	0	1
01/16/2015 06:00	0.0	0	0	0	0	1
01/16/2015 07:00	0.0	0	0	0	0	1
01/16/2015 08:00	0.0	0	0	0	0	1
01/16/2015 09:00	0.0	0	0	0	0	1
01/16/2015 10:00	0.0	0	0	0	0	1
01/16/2015 11:00	0.0	0	0	0	0	1
01/16/2015 12:00	0.0	0	0	0	0	1
01/16/2015 13:00	0.0	0	0	0	0	1
01/16/2015 14:00	0.0	0	0	0	0	1
01/16/2015 15:00	0.0	0	0	0	0	1
01/16/2015 16:00	1.9	0	0	0	1	0
01/16/2015 17:00	9.9	0	0	1	0	0
01/16/2015 18:00	9.0	0	0	1	0	0
01/16/2015 19:00	0.0	0	0	0	0	1
01/16/2015 20:00	0.0	0	0	0	0	1
01/16/2015 21:00	0.0	0	0	0	0	1
01/16/2015 22:00	0.0	0	0	0	0	1
01/16/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	20.8 #	0 #	0 #	2 #	1 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	9.9	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/17/2015 00:00	0.0	0	0	0	0	1
01/17/2015 01:00	0.0	0	0	0	0	1
01/17/2015 02:00	0.0	0	0	0	0	1
01/17/2015 03:00	0.0	0	0	0	0	1
01/17/2015 04:00	0.0	0	0	0	0	1
01/17/2015 05:00	0.0	0	0	0	0	1
01/17/2015 06:00	0.0	0	0	0	0	1
01/17/2015 07:00	0.0	0	0	0	0	1
01/17/2015 08:00	0.0	0	0	0	0	1
01/17/2015 09:00	0.0	0	0	0	0	1
01/17/2015 10:00	0.0	0	0	0	0	1
01/17/2015 11:00	0.0	0	0	0	0	1
01/17/2015 12:00	0.0	0	0	0	0	1
01/17/2015 13:00	0.0	0	0	0	0	1
01/17/2015 14:00	0.0	0	0	0	0	1
01/17/2015 15:00	0.0	0	0	0	0	1
01/17/2015 16:00	0.0	0	0	0	0	1
01/17/2015 17:00	0.0	0	0	0	0	1
01/17/2015 18:00	0.0	0	0	0	0	1
01/17/2015 19:00	0.0	0	0	0	0	1
01/17/2015 20:00	0.0	0	0	0	0	1
01/17/2015 21:00	0.0	0	0	0	0	1
01/17/2015 22:00	0.0	0	0	0	0	1
01/17/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/18/2015 00:00	0.0	0	0	0	0	1
01/18/2015 01:00	0.0	0	0	0	0	1
01/18/2015 02:00	1.9	0	0	0	1	0
01/18/2015 03:00	0.0	0	0	0	0	0
01/18/2015 04:00	0.0	0	0	0	0	0
01/18/2015 05:00	0.0	0	0	0	0	0
01/18/2015 06:00	0.0	0	0	0	0	0
01/18/2015 07:00	0.0	0	0	0	0	0
01/18/2015 08:00	0.0	0	0	0	0	0
01/18/2015 09:00	0.0	0	0	0	0	0
01/18/2015 10:00	31.9	0	1	0	0	0
01/18/2015 11:00	50.6	0	1	0	0	0
01/18/2015 12:00	0.0	0	0	0	0	1
01/18/2015 13:00	0.0	0	0	0	0	1
01/18/2015 14:00	0.0	0	0	0	0	1
01/18/2015 15:00	0.0	0	0	0	0	1
01/18/2015 16:00	0.0	0	0	0	0	1
01/18/2015 17:00	0.0	0	0	0	0	1
01/18/2015 18:00	0.0	0	0	0	0	1
01/18/2015 19:00	0.0	0	0	0	0	1
01/18/2015 20:00	0.0	0	0	0	0	1
01/18/2015 21:00	0.0	0	0	0	0	1
01/18/2015 22:00	0.0	0	0	0	0	1
01/18/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	84.4 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	50.6	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/19/2015 00:00	0.0	0	0	0	0	1
01/19/2015 01:00	0.0	0	0	0	0	1
01/19/2015 02:00	0.0	0	0	0	0	1
01/19/2015 03:00	0.0	0	0	0	0	1
01/19/2015 04:00	0.0	0	0	0	0	1
01/19/2015 05:00	0.0	0	0	0	0	1
01/19/2015 06:00	0.0	0	0	0	0	1
01/19/2015 07:00	0.0	0	0	0	0	1
01/19/2015 08:00	0.0	0	0	0	0	1
01/19/2015 09:00	0.0	0	0	0	0	1
01/19/2015 10:00	0.0	0	0	0	0	1
01/19/2015 11:00	0.0	0	0	0	0	1
01/19/2015 12:00	0.0	0	0	0	0	1
01/19/2015 13:00	0.0	0	0	0	0	1
01/19/2015 14:00	0.0	0	0	0	0	1
01/19/2015 15:00	0.0	0	0	0	0	1
01/19/2015 16:00	0.0	0	0	0	0	1
01/19/2015 17:00	0.0	0	0	0	0	1
01/19/2015 18:00	0.0	0	0	0	0	1
01/19/2015 19:00	0.0	0	0	0	0	1
01/19/2015 20:00	0.0	0	0	0	0	1
01/19/2015 21:00	0.0	0	0	0	0	1
01/19/2015 22:00	0.0	0	0	0	0	1
01/19/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/20/2015 00:00	0.0	0	0	0	0	1
01/20/2015 01:00	0.0	0	0	0	0	1
01/20/2015 02:00	0.0	0	0	0	0	1
01/20/2015 03:00	0.0	0	0	0	0	1
01/20/2015 04:00	0.0	0	0	0	0	1
01/20/2015 05:00	0.0	0	0	0	0	1
01/20/2015 06:00	0.0	0	0	0	0	1
01/20/2015 07:00	0.0	0	0	0	0	1
01/20/2015 08:00	0.0	0	0	0	0	1
01/20/2015 09:00	0.0	0	0	0	0	1
01/20/2015 10:00	0.0	0	0	0	0	1
01/20/2015 11:00	0.0	0	0	0	0	1
01/20/2015 12:00	0.0	0	0	0	0	1
01/20/2015 13:00	0.0	0	0	0	0	1
01/20/2015 14:00	0.0	0	0	0	0	1
01/20/2015 15:00	0.0	0	0	0	0	1
01/20/2015 16:00	0.0	0	0	0	0	1
01/20/2015 17:00	0.0	0	0	0	0	1
01/20/2015 18:00	0.0	0	0	0	0	1
01/20/2015 19:00	0.0	0	0	0	0	1
01/20/2015 20:00	0.0	0	0	0	0	1
01/20/2015 21:00	0.0	0	0	0	0	1
01/20/2015 22:00	0.0	0	0	0	0	1
01/20/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/21/2015 00:00	0.0	0	0	0	0	1
01/21/2015 01:00	0.0	0	0	0	0	1
01/21/2015 02:00	0.0	0	0	0	0	1
01/21/2015 03:00	0.0	0	0	0	0	1
01/21/2015 04:00	0.0	0	0	0	0	1
01/21/2015 05:00	0.0	0	0	0	0	1
01/21/2015 06:00	0.0	0	0	0	0	1
01/21/2015 07:00	0.0	0	0	0	0	1
01/21/2015 08:00	0.0	0	0	0	0	1
01/21/2015 09:00	0.0	0	0	0	0	1
01/21/2015 10:00	0.0	0	0	0	0	1
01/21/2015 11:00	0.0	0	0	0	0	1
01/21/2015 12:00	0.0	0	0	0	0	1
01/21/2015 13:00	0.0	0	0	0	0	1
01/21/2015 14:00	0.0	0	0	0	0	1
01/21/2015 15:00	0.0	0	0	0	0	1
01/21/2015 16:00	0.0	0	0	0	0	1
01/21/2015 17:00	0.0	0	0	0	0	1
01/21/2015 18:00	0.0	0	0	0	0	1
01/21/2015 19:00	0.0	0	0	0	0	1
01/21/2015 20:00	0.0	0	0	0	0	1
01/21/2015 21:00	0.0	0	0	0	0	1
01/21/2015 22:00	0.0	0	0	0	0	1
01/21/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/22/2015 00:00	0.0	0	0	0	0	1
01/22/2015 01:00	0.0	0	0	0	0	1
01/22/2015 02:00	0.0	0	0	0	0	1
01/22/2015 03:00	0.0	0	0	0	0	1
01/22/2015 04:00	0.0	0	0	0	0	1
01/22/2015 05:00	0.0	0	0	0	0	1
01/22/2015 06:00	0.0	0	0	0	0	1
01/22/2015 07:00	0.0	0	0	0	0	1
01/22/2015 08:00	0.0	0	0	0	0	1
01/22/2015 09:00	0.0	0	0	0	0	1
01/22/2015 10:00	0.0	0	0	0	0	1
01/22/2015 11:00	0.0	0	0	0	0	1
01/22/2015 12:00	0.0	0	0	0	0	1
01/22/2015 13:00	0.0	0	0	0	0	1
01/22/2015 14:00	0.0	0	0	0	0	1
01/22/2015 15:00	0.0	0	0	0	0	1
01/22/2015 16:00	0.0	0	0	0	0	1
01/22/2015 17:00	0.0	0	0	0	0	1
01/22/2015 18:00	0.0	0	0	0	0	1
01/22/2015 19:00	0.0	0	0	0	0	1
01/22/2015 20:00	0.0	0	0	0	0	1
01/22/2015 21:00	0.0	0	0	0	0	1
01/22/2015 22:00	0.0	0	0	0	0	1
01/22/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/23/2015 00:00	0.0	0	0	0	0	1
01/23/2015 01:00	0.0	0	0	0	0	1
01/23/2015 02:00	0.0	0	0	0	0	1
01/23/2015 03:00	0.0	0	0	0	0	1
01/23/2015 04:00	0.0	0	0	0	0	1
01/23/2015 05:00	0.0	0	0	0	0	1
01/23/2015 06:00	0.0	0	0	0	0	1
01/23/2015 07:00	0.0	0	0	0	0	1
01/23/2015 08:00	0.0	0	0	0	0	1
01/23/2015 09:00	0.0	0	0	0	0	1
01/23/2015 10:00	0.0	0	0	0	0	1
01/23/2015 11:00	0.0	0	0	0	0	1
01/23/2015 12:00	0.0	0	0	0	0	1
01/23/2015 13:00	0.0	0	0	0	0	1
01/23/2015 14:00	0.0	0	0	0	0	1
01/23/2015 15:00	0.0	0	0	0	0	1
01/23/2015 16:00	0.0	0	0	0	0	1
01/23/2015 17:00	0.0	0	0	0	0	1
01/23/2015 18:00	0.0	0	0	0	0	1
01/23/2015 19:00	0.0	0	0	0	0	1
01/23/2015 20:00	0.0	0	0	0	0	1
01/23/2015 21:00	0.0	0	0	0	0	1
01/23/2015 22:00	0.0	0	0	0	0	1
01/23/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/24/2015 00:00	0.0	0	0	0	0	1
01/24/2015 01:00	0.0	0	0	0	0	1
01/24/2015 02:00	0.0	0	0	0	0	1
01/24/2015 03:00	0.0	0	0	0	0	1
01/24/2015 04:00	0.0	0	0	0	0	1
01/24/2015 05:00	0.0	0	0	0	0	1
01/24/2015 06:00	0.0	0	0	0	0	1
01/24/2015 07:00	0.0	0	0	0	0	1
01/24/2015 08:00	0.0	0	0	0	0	1
01/24/2015 09:00	0.0	0	0	0	0	1
01/24/2015 10:00	0.0	0	0	0	0	1
01/24/2015 11:00	0.0	0	0	0	0	1
01/24/2015 12:00	0.0	0	0	0	0	1
01/24/2015 13:00	0.0	0	0	0	0	1
01/24/2015 14:00	0.0	0	0	0	0	1
01/24/2015 15:00	0.0	0	0	0	0	1
01/24/2015 16:00	0.0	0	0	0	0	1
01/24/2015 17:00	0.0	0	0	0	0	1
01/24/2015 18:00	0.0	0	0	0	0	1
01/24/2015 19:00	0.0	0	0	0	0	1
01/24/2015 20:00	0.0	0	0	0	0	1
01/24/2015 21:00	0.0	0	0	0	0	1
01/24/2015 22:00	0.0	0	0	0	0	1
01/24/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/25/2015 00:00	0.0	0	0	0	0	1
01/25/2015 01:00	3.0	0	0	0	1	0
01/25/2015 02:00	0.0	0	0	0	0	0
01/25/2015 03:00	0.0	0	0	0	0	0
01/25/2015 04:00	0.0	0	0	0	0	0
01/25/2015 05:00	0.0	0	0	0	0	0
01/25/2015 06:00	0.0	0	0	0	0	0
01/25/2015 07:00	0.0	0	0	0	0	0
01/25/2015 08:00	0.0	0	0	0	0	0
01/25/2015 09:00	0.0	0	0	0	0	0
01/25/2015 10:00	0.0	0	0	0	0	0
01/25/2015 11:00	0.0	0	0	0	0	0
01/25/2015 12:00	0.0	0	0	0	0	0
01/25/2015 13:00	0.0	0	0	0	0	0
01/25/2015 14:00	0.0	0	0	0	0	0
01/25/2015 15:00	0.0	0	0	0	0	0
01/25/2015 16:00	0.0	0	0	0	0	0
01/25/2015 17:00	0.0	0	0	0	0	0
01/25/2015 18:00	0.0	0	0	0	0	0
01/25/2015 19:00	0.0	0	0	0	0	0
01/25/2015 20:00	0.0	0	0	0	0	0
01/25/2015 21:00	0.0	0	0	0	0	0
01/25/2015 22:00	0.0	0	0	0	0	0
01/25/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	3.0 #	0 #	0 #	0 #	1 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3.0	0	0	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/26/2015 00:00	0.0	0	0	0	0	0
01/26/2015 01:00	0.0	0	0	0	0	0
01/26/2015 02:00	0.0	0	0	0	0	0
01/26/2015 03:00	0.0	0	0	0	0	0
01/26/2015 04:00	0.0	0	0	0	0	0
01/26/2015 05:00	0.0	0	0	0	0	0
01/26/2015 06:00	0.0	0	0	0	0	0
01/26/2015 07:00	0.0	0	0	0	0	0
01/26/2015 08:00	0.0	0	0	0	0	0
01/26/2015 09:00	0.0	0	0	0	0	0
01/26/2015 10:00	0.0	0	0	0	0	0
01/26/2015 11:00	0.0	0	0	0	0	0
01/26/2015 12:00	0.0	0	0	0	0	0
01/26/2015 13:00	0.0	0	0	0	0	0
01/26/2015 14:00	0.0	0	0	0	0	0
01/26/2015 15:00	0.0	0	0	0	0	0
01/26/2015 16:00	0.0	0	0	0	0	0
01/26/2015 17:00	0.0	0	0	0	0	0
01/26/2015 18:00	0.0	0	0	0	0	0
01/26/2015 19:00	0.0	0	0	0	0	0
01/26/2015 20:00	0.0	0	0	0	0	0
01/26/2015 21:00	0.0	0	0	0	0	0
01/26/2015 22:00	0.0	0	0	0	0	0
01/26/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/27/2015 00:00	0.0	0	0	0	0	0
01/27/2015 01:00	0.0	0	0	0	0	0
01/27/2015 02:00	87.0	0	1	0	0	0
01/27/2015 03:00	52.2	0	1	0	0	0
01/27/2015 04:00	4.8	0	1	0	0	0
01/27/2015 05:00	0.0	0	0	0	0	0
01/27/2015 06:00	0.0	0	0	0	0	0
01/27/2015 07:00	4.8	0	0	1	0	0
01/27/2015 08:00	20.9	0	0	1	0	0
01/27/2015 09:00	1.4	0	0	1	0	0
01/27/2015 10:00	0.0	0	0	1	0	0
01/27/2015 11:00	0.0	0	0	0	0	1
01/27/2015 12:00	0.0	0	0	0	0	1
01/27/2015 13:00	0.0	0	0	0	0	1
01/27/2015 14:00	0.0	0	0	0	0	1
01/27/2015 15:00	0.0	0	0	0	0	1
01/27/2015 16:00	0.0	0	0	0	0	1
01/27/2015 17:00	0.0	0	0	0	0	1
01/27/2015 18:00	0.0	0	0	0	0	1
01/27/2015 19:00	0.0	0	0	0	0	1
01/27/2015 20:00	0.0	0	0	0	0	1
01/27/2015 21:00	0.0	0	0	0	0	1
01/27/2015 22:00	0.0	0	0	0	0	1
01/27/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	171.1 #	0 #	3 #	4 #	0 #	13 #
Minimum:	0.0	0	0	0	0	0
Maximum:	87.0	0	1	1	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/28/2015 00:00	0.0	0	0	0	0	1
01/28/2015 01:00	0.0	0	0	0	0	1
01/28/2015 02:00	0.0	0	0	0	0	1
01/28/2015 03:00	0.0	0	0	0	0	1
01/28/2015 04:00	0.0	0	0	0	0	1
01/28/2015 05:00	0.0	0	0	0	0	1
01/28/2015 06:00	0.0	0	0	0	0	1
01/28/2015 07:00	0.0	0	0	0	0	1
01/28/2015 08:00	0.0	0	0	0	0	1
01/28/2015 09:00	0.0	0	0	0	0	1
01/28/2015 10:00	0.0	0	0	0	0	1
01/28/2015 11:00	0.0	0	0	0	0	1
01/28/2015 12:00	0.0	0	0	0	0	1
01/28/2015 13:00	0.0	0	0	0	0	1
01/28/2015 14:00	0.0	0	0	0	0	1
01/28/2015 15:00	0.0	0	0	0	0	1
01/28/2015 16:00	0.0	0	0	0	0	1
01/28/2015 17:00	0.0	0	0	0	0	1
01/28/2015 18:00	0.0	0	0	0	0	1
01/28/2015 19:00	0.0	0	0	0	0	1
01/28/2015 20:00	0.0	0	0	0	0	1
01/28/2015 21:00	0.0	0	0	0	0	1
01/28/2015 22:00	0.0	0	0	0	0	1
01/28/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/29/2015 00:00	0.0	0	0	0	0	1
01/29/2015 01:00	0.0	0	0	0	0	1
01/29/2015 02:00	0.0	0	0	0	0	1
01/29/2015 03:00	0.0	0	0	0	0	1
01/29/2015 04:00	0.0	0	0	0	0	1
01/29/2015 05:00	0.0	0	0	0	0	1
01/29/2015 06:00	0.0	0	0	0	0	1
01/29/2015 07:00	0.0	0	0	0	0	1
01/29/2015 08:00	0.0	0	0	0	0	1
01/29/2015 09:00	0.0	0	0	0	0	1
01/29/2015 10:00	0.0	0	0	0	0	1
01/29/2015 11:00	0.0	0	0	0	0	1
01/29/2015 12:00	0.0	0	0	0	0	1
01/29/2015 13:00	0.0	0	0	0	0	1
01/29/2015 14:00	0.0	0	0	0	0	1
01/29/2015 15:00	0.0	0	0	0	0	1
01/29/2015 16:00	0.0	0	0	0	0	1
01/29/2015 17:00	0.0	0	0	0	0	1
01/29/2015 18:00	0.0	0	0	0	0	1
01/29/2015 19:00	0.0	0	0	0	0	1
01/29/2015 20:00	0.0	0	0	0	0	1
01/29/2015 21:00	0.0	0	0	0	0	1
01/29/2015 22:00	0.0	0	0	0	0	1
01/29/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/30/2015 00:00	0.0	0	0	0	0	1
01/30/2015 01:00	0.0	0	0	0	0	1
01/30/2015 02:00	0.0	0	0	0	0	1
01/30/2015 03:00	0.0	0	0	0	0	1
01/30/2015 04:00	0.0	0	0	0	0	1
01/30/2015 05:00	0.0	0	0	0	0	1
01/30/2015 06:00	0.0	0	0	0	0	1
01/30/2015 07:00	0.0	0	0	0	0	1
01/30/2015 08:00	0.0	0	0	0	0	1
01/30/2015 09:00	0.0	0	0	0	0	1
01/30/2015 10:00	0.0	0	0	0	0	1
01/30/2015 11:00	0.0	0	0	0	0	1
01/30/2015 12:00	0.0	0	0	0	0	1
01/30/2015 13:00	0.0	0	0	0	0	1
01/30/2015 14:00	0.0	0	0	0	0	1
01/30/2015 15:00	0.0	0	0	0	0	1
01/30/2015 16:00	0.0	0	0	0	0	1
01/30/2015 17:00	0.0	0	0	0	0	1
01/30/2015 18:00	0.0	0	0	0	0	1
01/30/2015 19:00	0.0	0	0	0	0	1
01/30/2015 20:00	0.0	0	0	0	0	1
01/30/2015 21:00	0.0	0	0	0	0	1
01/30/2015 22:00	0.0	0	0	0	0	1
01/30/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/31/2015 00:00	0.0	0	0	0	0	1
01/31/2015 01:00	0.0	0	0	0	0	1
01/31/2015 02:00	0.0	0	0	0	0	1
01/31/2015 03:00	0.0	0	0	0	0	1
01/31/2015 04:00	0.0	0	0	0	0	1
01/31/2015 05:00	0.0	0	0	0	0	1
01/31/2015 06:00	0.0	0	0	0	0	1
01/31/2015 07:00	0.0	0	0	0	0	1
01/31/2015 08:00	0.0	0	0	0	0	1
01/31/2015 09:00	0.0	0	0	0	0	1
01/31/2015 10:00	0.0	0	0	0	0	1
01/31/2015 11:00	0.0	0	0	0	0	1
01/31/2015 12:00	0.0	0	0	0	0	1
01/31/2015 13:00	0.0	0	0	0	0	1
01/31/2015 14:00	0.0	0	0	0	0	1
01/31/2015 15:00	0.0	0	0	0	0	1
01/31/2015 16:00	0.0	0	0	0	0	1
01/31/2015 17:00	0.0	0	0	0	0	1
01/31/2015 18:00	0.0	0	0	0	0	1
01/31/2015 19:00	0.0	0	0	0	0	1
01/31/2015 20:00	0.0	0	0	0	0	1
01/31/2015 21:00	0.0	0	0	0	0	1
01/31/2015 22:00	0.0	0	0	0	0	1
01/31/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/01/2015 00:00	0.0	0	0	0	0	1
02/01/2015 01:00	0.0	0	0	0	0	1
02/01/2015 02:00	3.0	0	0	0	1	0
02/01/2015 03:00	0.0	0	0	0	0	0
02/01/2015 04:00	0.0	0	0	0	0	0
02/01/2015 05:00	0.0	0	0	0	0	0
02/01/2015 06:00	0.0	0	0	0	0	0
02/01/2015 07:00	0.0	0	0	0	0	0
02/01/2015 08:00	0.0	0	0	0	0	0
02/01/2015 09:00	0.0	0	0	0	0	0
02/01/2015 10:00	0.0	0	0	0	0	0
02/01/2015 11:00	0.0	0	0	0	0	0
02/01/2015 12:00	0.0	0	0	0	0	0
02/01/2015 13:00	0.0	0	0	0	0	0
02/01/2015 14:00	57.5	0	1	0	0	0
02/01/2015 15:00	33.3	0	1	0	0	0
02/01/2015 16:00	0.0	0	0	0	0	1
02/01/2015 17:00	0.0	0	0	0	0	1
02/01/2015 18:00	0.0	0	0	0	0	1
02/01/2015 19:00	0.0	0	0	0	0	1
02/01/2015 20:00	0.0	0	0	0	0	1
02/01/2015 21:00	0.0	0	0	0	0	1
02/01/2015 22:00	0.0	0	0	0	0	1
02/01/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	93.8 #	0 #	2 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	57.5	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/02/2015 00:00	0.0	0	0	0	0	1
02/02/2015 01:00	0.0	0	0	0	0	1
02/02/2015 02:00	0.0	0	0	0	0	1
02/02/2015 03:00	0.0	0	0	0	0	1
02/02/2015 04:00	0.0	0	0	0	0	1
02/02/2015 05:00	0.0	0	0	0	0	1
02/02/2015 06:00	0.0	0	0	0	0	1
02/02/2015 07:00	0.0	0	0	0	0	1
02/02/2015 08:00	0.0	0	0	0	0	1
02/02/2015 09:00	0.0	0	0	0	0	1
02/02/2015 10:00	0.0	0	0	0	0	1
02/02/2015 11:00	0.0	0	0	0	0	1
02/02/2015 12:00	0.0	0	0	0	0	1
02/02/2015 13:00	0.0	0	0	0	0	1
02/02/2015 14:00	0.0	0	0	0	0	1
02/02/2015 15:00	0.0	0	0	0	0	1
02/02/2015 16:00	0.0	0	0	0	0	1
02/02/2015 17:00	0.0	0	0	0	0	1
02/02/2015 18:00	0.0	0	0	0	0	1
02/02/2015 19:00	0.0	0	0	0	0	1
02/02/2015 20:00	0.0	0	0	0	0	1
02/02/2015 21:00	0.0	0	0	0	0	1
02/02/2015 22:00	0.0	0	0	0	0	1
02/02/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/03/2015 00:00	0.0	0	0	0	0	1
02/03/2015 01:00	0.0	0	0	0	0	1
02/03/2015 02:00	0.0	0	0	0	0	1
02/03/2015 03:00	0.0	0	0	0	0	1
02/03/2015 04:00	0.0	0	0	0	0	1
02/03/2015 05:00	0.0	0	0	0	0	1
02/03/2015 06:00	0.0	0	0	0	0	1
02/03/2015 07:00	0.0	0	0	0	0	1
02/03/2015 08:00	0.0	0	0	0	0	1
02/03/2015 09:00	0.0	0	0	0	0	1
02/03/2015 10:00	0.0	0	0	0	0	1
02/03/2015 11:00	0.0	0	0	0	0	1
02/03/2015 12:00	0.0	0	0	0	0	1
02/03/2015 13:00	0.0	0	0	0	0	1
02/03/2015 14:00	0.0	0	0	0	0	1
02/03/2015 15:00	0.0	0	0	0	0	1
02/03/2015 16:00	0.0	0	0	0	0	1
02/03/2015 17:00	0.0	0	0	0	0	1
02/03/2015 18:00	0.0	0	0	0	0	1
02/03/2015 19:00	0.0	0	0	0	0	1
02/03/2015 20:00	0.0	0	0	0	0	1
02/03/2015 21:00	0.0	0	0	0	0	1
02/03/2015 22:00	0.0	0	0	0	0	1
02/03/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/04/2015 00:00	0.0	0	0	0	0	1
02/04/2015 01:00	0.0	0	0	0	0	1
02/04/2015 02:00	0.0	0	0	0	0	1
02/04/2015 03:00	0.0	0	0	0	0	1
02/04/2015 04:00	0.0	0	0	0	0	1
02/04/2015 05:00	0.0	0	0	0	0	1
02/04/2015 06:00	0.0	0	0	0	0	1
02/04/2015 07:00	0.0	0	0	0	0	1
02/04/2015 08:00	0.0	0	0	0	0	1
02/04/2015 09:00	0.0	0	0	0	0	1
02/04/2015 10:00	0.0	0	0	0	0	1
02/04/2015 11:00	0.0	0	0	0	0	1
02/04/2015 12:00	0.0	0	0	0	0	1
02/04/2015 13:00	0.0	0	0	0	0	1
02/04/2015 14:00	0.0	0	0	0	0	1
02/04/2015 15:00	0.0	0	0	0	0	1
02/04/2015 16:00	0.0	0	0	0	0	1
02/04/2015 17:00	0.0	0	0	0	0	1
02/04/2015 18:00	0.0	0	0	0	0	1
02/04/2015 19:00	0.0	0	0	0	0	1
02/04/2015 20:00	0.0	0	0	0	0	1
02/04/2015 21:00	0.0	0	0	0	0	1
02/04/2015 22:00	0.0	0	0	0	0	1
02/04/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/05/2015 00:00	0.0	0	0	0	0	1
02/05/2015 01:00	0.0	0	0	0	0	1
02/05/2015 02:00	0.0	0	0	0	0	1
02/05/2015 03:00	0.0	0	0	0	0	1
02/05/2015 04:00	0.0	0	0	0	0	1
02/05/2015 05:00	0.0	0	0	0	0	1
02/05/2015 06:00	0.0	0	0	0	0	1
02/05/2015 07:00	0.0	0	0	0	0	1
02/05/2015 08:00	0.0	0	0	0	0	1
02/05/2015 09:00	0.0	0	0	0	0	1
02/05/2015 10:00	0.0	0	0	0	0	1
02/05/2015 11:00	0.0	0	0	0	0	1
02/05/2015 12:00	0.0	0	0	0	0	1
02/05/2015 13:00	0.0	0	0	0	0	1
02/05/2015 14:00	0.0	0	0	0	0	1
02/05/2015 15:00	0.0	0	0	0	0	1
02/05/2015 16:00	0.0	0	0	0	0	1
02/05/2015 17:00	0.0	0	0	0	0	1
02/05/2015 18:00	0.0	0	0	0	0	1
02/05/2015 19:00	0.0	0	0	0	0	1
02/05/2015 20:00	0.0	0	0	0	0	1
02/05/2015 21:00	0.0	0	0	0	0	1
02/05/2015 22:00	0.0	0	0	0	0	1
02/05/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/06/2015 00:00	0.0	0	0	0	0	1
02/06/2015 01:00	0.0	0	0	0	0	1
02/06/2015 02:00	0.0	0	0	0	0	1
02/06/2015 03:00	0.0	0	0	0	0	1
02/06/2015 04:00	0.0	0	0	0	0	1
02/06/2015 05:00	0.0	0	0	0	0	1
02/06/2015 06:00	0.0	0	0	0	0	1
02/06/2015 07:00	0.0	0	0	0	0	1
02/06/2015 08:00	0.0	0	0	0	0	1
02/06/2015 09:00	0.0	0	0	0	0	1
02/06/2015 10:00	0.0	0	0	0	0	1
02/06/2015 11:00	0.0	0	0	0	0	1
02/06/2015 12:00	0.0	0	0	0	0	1
02/06/2015 13:00	0.0	0	0	0	0	1
02/06/2015 14:00	0.0	0	0	0	0	1
02/06/2015 15:00	0.0	0	0	0	0	1
02/06/2015 16:00	0.0	0	0	0	0	1
02/06/2015 17:00	0.0	0	0	0	0	1
02/06/2015 18:00	0.0	0	0	0	0	1
02/06/2015 19:00	0.0	0	0	0	0	1
02/06/2015 20:00	0.0	0	0	0	0	1
02/06/2015 21:00	0.0	0	0	0	0	1
02/06/2015 22:00	0.0	0	0	0	0	1
02/06/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/07/2015 00:00	0.0	0	0	0	0	1
02/07/2015 01:00	0.0	0	0	0	0	1
02/07/2015 02:00	0.0	0	0	0	0	1
02/07/2015 03:00	0.0	0	0	0	0	1
02/07/2015 04:00	0.0	0	0	0	0	1
02/07/2015 05:00	0.0	0	0	0	0	1
02/07/2015 06:00	0.0	0	0	0	0	1
02/07/2015 07:00	0.0	0	0	0	0	1
02/07/2015 08:00	0.0	0	0	0	0	1
02/07/2015 09:00	0.0	0	0	0	0	1
02/07/2015 10:00	0.0	0	0	0	0	1
02/07/2015 11:00	0.0	0	0	0	0	1
02/07/2015 12:00	0.0	0	0	0	0	1
02/07/2015 13:00	0.0	0	0	0	0	1
02/07/2015 14:00	0.0	0	0	0	0	1
02/07/2015 15:00	0.0	0	0	0	0	1
02/07/2015 16:00	0.0	0	0	0	0	1
02/07/2015 17:00	0.0	0	0	0	0	1
02/07/2015 18:00	0.0	0	0	0	0	1
02/07/2015 19:00	0.0	0	0	0	0	1
02/07/2015 20:00	0.0	0	0	0	0	1
02/07/2015 21:00	0.0	0	0	0	0	1
02/07/2015 22:00	0.0	0	0	0	0	1
02/07/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/08/2015 00:00	0.0	0	0	0	0	1
02/08/2015 01:00	0.0	0	0	0	0	1
02/08/2015 02:00	0.0	0	0	0	0	1
02/08/2015 03:00	0.0	0	0	0	0	1
02/08/2015 04:00	0.0	0	0	0	0	1
02/08/2015 05:00	0.0	0	0	0	0	1
02/08/2015 06:00	0.0	0	0	0	0	1
02/08/2015 07:00	0.0	0	0	0	0	1
02/08/2015 08:00	0.0	0	0	0	0	1
02/08/2015 09:00	0.0	0	0	0	0	1
02/08/2015 10:00	0.0	0	0	0	0	1
02/08/2015 11:00	0.0	0	0	0	0	1
02/08/2015 12:00	0.0	0	0	0	0	1
02/08/2015 13:00	0.0	0	0	0	0	1
02/08/2015 14:00	0.0	0	0	0	0	1
02/08/2015 15:00	0.0	0	0	0	0	1
02/08/2015 16:00	0.0	0	0	0	0	1
02/08/2015 17:00	0.0	0	0	0	0	1
02/08/2015 18:00	0.0	0	0	0	0	1
02/08/2015 19:00	0.0	0	0	0	0	1
02/08/2015 20:00	0.0	0	0	0	0	1
02/08/2015 21:00	0.0	0	0	0	0	1
02/08/2015 22:00	0.0	0	0	0	0	1
02/08/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/09/2015 00:00	0.0	0	0	0	0	1
02/09/2015 01:00	0.0	0	0	0	0	1
02/09/2015 02:00	0.0	0	0	0	0	1
02/09/2015 03:00	0.0	0	0	0	0	1
02/09/2015 04:00	0.0	0	0	0	0	1
02/09/2015 05:00	0.0	0	0	0	0	1
02/09/2015 06:00	0.0	0	0	0	0	1
02/09/2015 07:00	0.0	0	0	0	0	1
02/09/2015 08:00	0.0	0	0	0	0	1
02/09/2015 09:00	0.0	0	0	0	0	1
02/09/2015 10:00	0.0	0	0	0	0	1
02/09/2015 11:00	0.0	0	0	0	0	1
02/09/2015 12:00	0.0	0	0	0	0	1
02/09/2015 13:00	0.0	0	0	0	0	1
02/09/2015 14:00	0.0	0	0	0	0	1
02/09/2015 15:00	0.0	0	0	0	0	1
02/09/2015 16:00	0.0	0	0	0	0	1
02/09/2015 17:00	0.0	0	0	0	0	1
02/09/2015 18:00	0.0	0	0	0	0	1
02/09/2015 19:00	0.0	0	0	0	0	1
02/09/2015 20:00	0.0	0	0	0	0	1
02/09/2015 21:00	0.0	0	0	0	0	1
02/09/2015 22:00	0.0	0	0	0	0	1
02/09/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/10/2015 00:00	0.0	0	0	0	0	1
02/10/2015 01:00	0.0	0	0	0	0	1
02/10/2015 02:00	0.0	0	0	0	0	1
02/10/2015 03:00	0.0	0	0	0	0	1
02/10/2015 04:00	0.0	0	0	0	0	1
02/10/2015 05:00	0.0	0	0	0	0	1
02/10/2015 06:00	0.0	0	0	0	0	1
02/10/2015 07:00	0.0	0	0	0	0	1
02/10/2015 08:00	0.0	0	0	0	0	1
02/10/2015 09:00	0.0	0	0	0	0	1
02/10/2015 10:00	0.0	0	0	0	0	1
02/10/2015 11:00	0.0	0	0	0	0	1
02/10/2015 12:00	0.0	0	0	0	0	1
02/10/2015 13:00	0.0	0	0	0	0	1
02/10/2015 14:00	0.0	0	0	0	0	1
02/10/2015 15:00	0.0	0	0	0	0	1
02/10/2015 16:00	0.0	0	0	0	0	1
02/10/2015 17:00	0.0	0	0	0	0	1
02/10/2015 18:00	0.0	0	0	0	0	1
02/10/2015 19:00	0.0	0	0	0	0	1
02/10/2015 20:00	0.0	0	0	0	0	1
02/10/2015 21:00	0.0	0	0	0	0	1
02/10/2015 22:00	0.0	0	0	0	0	1
02/10/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/11/2015 00:00	0.0	0	0	0	0	1
02/11/2015 01:00	0.0	0	0	0	0	1
02/11/2015 02:00	0.0	0	0	0	0	1
02/11/2015 03:00	0.0	0	0	0	0	1
02/11/2015 04:00	0.0	0	0	0	0	1
02/11/2015 05:00	0.0	0	0	0	0	1
02/11/2015 06:00	0.0	0	0	0	0	1
02/11/2015 07:00	0.0	0	0	0	0	1
02/11/2015 08:00	0.0	0	0	0	0	1
02/11/2015 09:00	0.0	0	0	0	0	1
02/11/2015 10:00	0.0	0	0	0	0	1
02/11/2015 11:00	0.0	0	0	0	0	1
02/11/2015 12:00	0.0	0	0	0	0	1
02/11/2015 13:00	0.0	0	0	0	0	1
02/11/2015 14:00	0.0	0	0	0	0	1
02/11/2015 15:00	0.0	0	0	0	0	1
02/11/2015 16:00	0.0	0	0	0	0	1
02/11/2015 17:00	0.0	0	0	0	0	1
02/11/2015 18:00	0.0	0	0	0	0	1
02/11/2015 19:00	0.0	0	0	0	0	1
02/11/2015 20:00	0.0	0	0	0	0	1
02/11/2015 21:00	0.0	0	0	0	0	1
02/11/2015 22:00	0.0	0	0	0	0	1
02/11/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/12/2015 00:00	0.0	0	0	0	0	1
02/12/2015 01:00	0.0	0	0	0	0	1
02/12/2015 02:00	0.0	0	0	0	0	1
02/12/2015 03:00	0.0	0	0	0	0	1
02/12/2015 04:00	0.0	0	0	0	0	1
02/12/2015 05:00	0.0	0	0	0	0	1
02/12/2015 06:00	0.0	0	0	0	0	1
02/12/2015 07:00	0.0	0	0	0	0	1
02/12/2015 08:00	0.0	0	0	0	0	1
02/12/2015 09:00	0.0	0	0	0	0	1
02/12/2015 10:00	0.0	0	0	0	0	1
02/12/2015 11:00	0.0	0	0	0	0	1
02/12/2015 12:00	0.0	0	0	0	0	1
02/12/2015 13:00	0.0	0	0	0	0	1
02/12/2015 14:00	0.0	0	0	0	0	1
02/12/2015 15:00	0.0	0	0	0	0	1
02/12/2015 16:00	0.0	0	0	0	0	1
02/12/2015 17:00	0.0	0	0	0	0	1
02/12/2015 18:00	0.0	0	0	0	0	1
02/12/2015 19:00	0.0	0	0	0	0	1
02/12/2015 20:00	0.0	0	0	0	0	1
02/12/2015 21:00	0.0	0	0	0	0	1
02/12/2015 22:00	0.0	0	0	0	0	1
02/12/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/13/2015 00:00	0.0	0	0	0	0	1
02/13/2015 01:00	0.0	0	0	0	0	1
02/13/2015 02:00	0.0	0	0	0	0	1
02/13/2015 03:00	0.0	0	0	0	0	1
02/13/2015 04:00	0.0	0	0	0	0	1
02/13/2015 05:00	0.0	0	0	0	0	1
02/13/2015 06:00	0.0	0	0	0	0	1
02/13/2015 07:00	0.0	0	0	0	0	1
02/13/2015 08:00	0.0	0	0	0	0	1
02/13/2015 09:00	0.0	0	0	0	0	1
02/13/2015 10:00	0.0	0	0	0	0	1
02/13/2015 11:00	0.0	0	0	0	0	1
02/13/2015 12:00	0.0	0	0	0	0	1
02/13/2015 13:00	0.0	0	0	0	0	1
02/13/2015 14:00	0.0	0	0	0	0	1
02/13/2015 15:00	0.0	0	0	0	0	1
02/13/2015 16:00	0.0	0	0	0	0	1
02/13/2015 17:00	0.0	0	0	0	0	1
02/13/2015 18:00	0.0	0	0	0	0	1
02/13/2015 19:00	0.0	0	0	0	0	1
02/13/2015 20:00	0.0	0	0	0	0	1
02/13/2015 21:00	0.0	0	0	0	0	1
02/13/2015 22:00	0.0	0	0	0	0	1
02/13/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/14/2015 00:00	0.0	0	0	0	0	1
02/14/2015 01:00	0.0	0	0	0	0	1
02/14/2015 02:00	0.0	0	0	0	0	1
02/14/2015 03:00	0.0	0	0	0	0	1
02/14/2015 04:00	0.0	0	0	0	0	1
02/14/2015 05:00	0.0	0	0	0	0	1
02/14/2015 06:00	0.0	0	0	0	0	1
02/14/2015 07:00	0.0	0	0	0	0	1
02/14/2015 08:00	0.0	0	0	0	0	1
02/14/2015 09:00	0.0	0	0	0	0	1
02/14/2015 10:00	0.0	0	0	0	0	1
02/14/2015 11:00	0.0	0	0	0	0	1
02/14/2015 12:00	0.0	0	0	0	0	1
02/14/2015 13:00	0.0	0	0	0	0	1
02/14/2015 14:00	0.0	0	0	0	0	1
02/14/2015 15:00	0.0	0	0	0	0	1
02/14/2015 16:00	0.0	0	0	0	0	1
02/14/2015 17:00	0.0	0	0	0	0	1
02/14/2015 18:00	0.0	0	0	0	0	1
02/14/2015 19:00	0.0	0	0	0	0	1
02/14/2015 20:00	0.0	0	0	0	0	1
02/14/2015 21:00	0.0	0	0	0	0	1
02/14/2015 22:00	0.0	0	0	0	0	1
02/14/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/15/2015 00:00	0.0	0	0	0	0	1
02/15/2015 01:00	0.0	0	0	0	0	1
02/15/2015 02:00	2.6	0	0	0	1	0
02/15/2015 03:00	0.0	0	0	0	0	0
02/15/2015 04:00	0.0	0	0	0	0	0
02/15/2015 05:00	0.0	0	0	0	0	0
02/15/2015 06:00	0.0	0	0	0	0	0
02/15/2015 07:00	0.0	0	0	0	0	0
02/15/2015 08:00	0.0	0	0	0	0	0
02/15/2015 09:00	0.0	0	0	0	0	0
02/15/2015 10:00	50.5	0	1	0	0	0
02/15/2015 11:00	47.1	0	1	0	0	0
02/15/2015 12:00	0.0	0	0	0	0	1
02/15/2015 13:00	0.0	0	0	0	0	1
02/15/2015 14:00	0.0	0	0	0	0	1
02/15/2015 15:00	0.0	0	0	0	0	1
02/15/2015 16:00	0.0	0	0	0	0	1
02/15/2015 17:00	0.0	0	0	0	0	1
02/15/2015 18:00	0.0	0	0	0	0	1
02/15/2015 19:00	0.0	0	0	0	0	1
02/15/2015 20:00	0.0	0	0	0	0	1
02/15/2015 21:00	0.0	0	0	0	0	1
02/15/2015 22:00	0.0	0	0	0	0	1
02/15/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	100.2 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	50.5	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/16/2015 00:00	0.0	0	0	0	0	1
02/16/2015 01:00	0.0	0	0	0	0	1
02/16/2015 02:00	0.0	0	0	0	0	1
02/16/2015 03:00	0.0	0	0	0	0	1
02/16/2015 04:00	0.0	0	0	0	0	1
02/16/2015 05:00	0.0	0	0	0	0	1
02/16/2015 06:00	0.0	0	0	0	0	1
02/16/2015 07:00	0.0	0	0	0	0	1
02/16/2015 08:00	0.0	0	0	0	0	1
02/16/2015 09:00	0.0	0	0	0	0	1
02/16/2015 10:00	0.0	0	0	0	0	1
02/16/2015 11:00	0.0	0	0	0	0	1
02/16/2015 12:00	0.0	0	0	0	0	1
02/16/2015 13:00	0.0	0	0	0	0	1
02/16/2015 14:00	0.0	0	0	0	0	1
02/16/2015 15:00	0.0	0	0	0	0	1
02/16/2015 16:00	0.0	0	0	0	0	1
02/16/2015 17:00	0.0	0	0	0	0	1
02/16/2015 18:00	0.0	0	0	0	0	1
02/16/2015 19:00	0.0	0	0	0	0	1
02/16/2015 20:00	0.0	0	0	0	0	1
02/16/2015 21:00	0.0	0	0	0	0	1
02/16/2015 22:00	0.0	0	0	0	0	1
02/16/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/17/2015 00:00	0.0	0	0	0	0	1
02/17/2015 01:00	0.0	0	0	0	0	1
02/17/2015 02:00	0.0	0	0	0	0	1
02/17/2015 03:00	0.0	0	0	0	0	1
02/17/2015 04:00	0.0	0	0	0	0	1
02/17/2015 05:00	0.0	0	0	0	0	1
02/17/2015 06:00	0.0	0	0	0	0	1
02/17/2015 07:00	0.0	0	0	0	0	1
02/17/2015 08:00	0.0	0	0	0	0	1
02/17/2015 09:00	0.0	0	0	0	0	1
02/17/2015 10:00	0.0	0	0	0	0	1
02/17/2015 11:00	0.0	0	0	0	0	1
02/17/2015 12:00	0.0	0	0	0	0	1
02/17/2015 13:00	0.0	0	0	0	0	1
02/17/2015 14:00	0.0	0	0	0	0	1
02/17/2015 15:00	0.0	0	0	0	0	1
02/17/2015 16:00	0.0	0	0	0	0	1
02/17/2015 17:00	0.0	0	0	0	0	1
02/17/2015 18:00	0.0	0	0	0	0	1
02/17/2015 19:00	0.0	0	0	0	0	1
02/17/2015 20:00	0.0	0	0	0	0	1
02/17/2015 21:00	0.0	0	0	0	0	1
02/17/2015 22:00	0.0	0	0	0	0	1
02/17/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/18/2015 00:00	0.0	0	0	0	0	1
02/18/2015 01:00	0.0	0	0	0	0	1
02/18/2015 02:00	0.0	0	0	0	0	1
02/18/2015 03:00	0.0	0	0	0	0	1
02/18/2015 04:00	0.0	0	0	0	0	1
02/18/2015 05:00	0.0	0	0	0	0	1
02/18/2015 06:00	0.0	0	0	0	0	1
02/18/2015 07:00	0.0	0	0	0	0	1
02/18/2015 08:00	0.0	0	0	0	0	1
02/18/2015 09:00	0.0	0	0	0	0	1
02/18/2015 10:00	0.0	0	0	0	0	1
02/18/2015 11:00	0.0	0	0	0	0	1
02/18/2015 12:00	0.0	0	0	0	0	1
02/18/2015 13:00	0.0	0	0	0	0	1
02/18/2015 14:00	0.0	0	0	0	0	1
02/18/2015 15:00	0.0	0	0	0	0	1
02/18/2015 16:00	0.0	0	0	0	0	1
02/18/2015 17:00	0.0	0	0	0	0	1
02/18/2015 18:00	0.0	0	0	0	0	1
02/18/2015 19:00	0.0	0	0	0	0	1
02/18/2015 20:00	0.0	0	0	0	0	1
02/18/2015 21:00	0.0	0	0	0	0	1
02/18/2015 22:00	0.0	0	0	0	0	1
02/18/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/19/2015 00:00	0.0	0	0	0	0	1
02/19/2015 01:00	0.0	0	0	0	0	1
02/19/2015 02:00	0.0	0	0	0	0	1
02/19/2015 03:00	0.0	0	0	0	0	1
02/19/2015 04:00	0.0	0	0	0	0	1
02/19/2015 05:00	0.0	0	0	0	0	1
02/19/2015 06:00	0.0	0	0	0	0	1
02/19/2015 07:00	0.0	0	0	0	0	1
02/19/2015 08:00	0.0	0	0	0	0	1
02/19/2015 09:00	0.0	0	0	0	0	1
02/19/2015 10:00	0.0	0	0	0	0	1
02/19/2015 11:00	0.0	0	0	0	0	1
02/19/2015 12:00	0.0	0	0	0	0	1
02/19/2015 13:00	0.0	0	0	0	0	1
02/19/2015 14:00	0.0	0	0	0	0	1
02/19/2015 15:00	0.0	0	0	0	0	1
02/19/2015 16:00	0.0	0	0	0	0	1
02/19/2015 17:00	0.0	0	0	0	0	1
02/19/2015 18:00	0.0	0	0	0	0	1
02/19/2015 19:00	0.0	0	0	0	0	1
02/19/2015 20:00	0.0	0	0	0	0	1
02/19/2015 21:00	0.0	0	0	0	0	1
02/19/2015 22:00	0.0	0	0	0	0	1
02/19/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/20/2015 00:00	0.0	0	0	0	0	1
02/20/2015 01:00	2.2	0	0	0	1	0
02/20/2015 02:00	0.0	0	0	0	0	0
02/20/2015 03:00	0.0	0	0	0	0	0
02/20/2015 04:00	0.1	0	0	1	0	0
02/20/2015 05:00	11.2	0	0	1	0	0
02/20/2015 06:00	0.0	0	0	0	0	1
02/20/2015 07:00	0.0	0	0	0	0	1
02/20/2015 08:00	0.0	0	0	0	0	1
02/20/2015 09:00	0.0	0	0	0	0	1
02/20/2015 10:00	0.0	0	0	0	0	1
02/20/2015 11:00	0.0	0	0	0	0	1
02/20/2015 12:00	2.9	0	0	0	1	0
02/20/2015 13:00	0.0	0	0	0	0	0
02/20/2015 14:00	0.0	0	0	0	0	0
02/20/2015 15:00	0.0	0	0	0	0	0
02/20/2015 16:00	0.0	0	0	0	0	0
02/20/2015 17:00	0.0	0	0	0	0	0
02/20/2015 18:00	0.0	0	0	0	0	0
02/20/2015 19:00	0.0	0	0	0	0	0
02/20/2015 20:00	0.0	0	0	0	0	0
02/20/2015 21:00	0.0	0	0	0	0	0
02/20/2015 22:00	0.0	0	0	0	0	0
02/20/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	16.4 #	0 #	0 #	2 #	2 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	11.2	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/21/2015 00:00	0.0	0	0	0	0	0
02/21/2015 01:00	0.0	0	0	0	0	0
02/21/2015 02:00	0.0	0	0	0	0	0
02/21/2015 03:00	0.0	0	0	0	0	0
02/21/2015 04:00	0.0	0	0	0	0	0
02/21/2015 05:00	0.0	0	0	0	0	0
02/21/2015 06:00	0.0	0	0	0	0	0
02/21/2015 07:00	0.0	0	0	0	0	0
02/21/2015 08:00	0.0	0	0	0	0	0
02/21/2015 09:00	0.0	0	0	0	0	0
02/21/2015 10:00	70.2	0	1	0	0	0
02/21/2015 11:00	54.5	0	1	0	0	0
02/21/2015 12:00	9.9	0	1	0	0	0
02/21/2015 13:00	0.0	0	0	0	0	1
02/21/2015 14:00	0.0	0	0	0	0	1
02/21/2015 15:00	0.0	0	0	0	0	1
02/21/2015 16:00	0.0	0	0	0	0	1
02/21/2015 17:00	0.0	0	0	0	0	1
02/21/2015 18:00	0.0	0	0	0	0	1
02/21/2015 19:00	0.0	0	0	0	0	1
02/21/2015 20:00	0.0	0	0	0	0	1
02/21/2015 21:00	0.0	0	0	0	0	1
02/21/2015 22:00	0.0	0	0	0	0	1
02/21/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	134.6 #	0 #	3 #	0 #	0 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	70.2	0	1	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/22/2015 00:00	0.0	0	0	0	0	1
02/22/2015 01:00	0.0	0	0	0	0	1
02/22/2015 02:00	0.0	0	0	0	0	1
02/22/2015 03:00	0.0	0	0	0	0	1
02/22/2015 04:00	0.0	0	0	0	0	1
02/22/2015 05:00	0.0	0	0	0	0	1
02/22/2015 06:00	0.0	0	0	0	1	0
02/22/2015 07:00	0.0	0	0	0	0	0
02/22/2015 08:00	0.0	0	0	0	0	0
02/22/2015 09:00	0.0	0	0	0	0	0
02/22/2015 10:00	0.0	0	0	0	0	0
02/22/2015 11:00	0.0	0	0	0	0	0
02/22/2015 12:00	0.0	0	0	0	0	0
02/22/2015 13:00	0.0	0	0	0	0	0
02/22/2015 14:00	71.4	0	1	0	0	0
02/22/2015 15:00	57.0	0	1	0	0	0
02/22/2015 16:00	0.0	0	0	0	0	1
02/22/2015 17:00	0.0	0	0	0	0	1
02/22/2015 18:00	0.0	0	0	0	0	1
02/22/2015 19:00	0.0	0	0	0	0	1
02/22/2015 20:00	0.0	0	0	0	0	1
02/22/2015 21:00	0.0	0	0	0	0	1
02/22/2015 22:00	2.1	0	0	0	1	0
02/22/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	130.5 #	0 #	2 #	0 #	2 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	71.4	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/23/2015 00:00	0.0	0	0	0	0	0
02/23/2015 01:00	0.0	0	0	0	0	0
02/23/2015 02:00	0.0	0	0	0	0	0
02/23/2015 03:00	36.1	0	0	1	0	0
02/23/2015 04:00	21.6	0	0	1	0	0
02/23/2015 05:00	0.0	0	0	0	0	1
02/23/2015 06:00	0.0	0	0	0	0	1
02/23/2015 07:00	0.0	0	0	0	0	1
02/23/2015 08:00	0.0	0	0	0	0	1
02/23/2015 09:00	0.0	0	0	0	0	1
02/23/2015 10:00	0.0	0	0	0	0	1
02/23/2015 11:00	0.0	0	0	0	0	1
02/23/2015 12:00	0.0	0	0	0	0	1
02/23/2015 13:00	0.0	0	0	0	0	1
02/23/2015 14:00	0.0	0	0	0	0	1
02/23/2015 15:00	0.0	0	0	0	0	1
02/23/2015 16:00	0.0	0	0	0	0	1
02/23/2015 17:00	0.0	0	0	0	0	1
02/23/2015 18:00	0.0	0	0	0	0	1
02/23/2015 19:00	0.0	0	0	0	0	1
02/23/2015 20:00	0.0	0	0	0	0	1
02/23/2015 21:00	0.0	0	0	0	0	1
02/23/2015 22:00	0.0	0	0	0	0	1
02/23/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	57.7 #	0 #	0 #	2 #	0 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	36.1	0	0	1	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/24/2015 00:00	0.0	0	0	0	0	1
02/24/2015 01:00	0.0	0	0	0	0	1
02/24/2015 02:00	0.0	0	0	0	0	1
02/24/2015 03:00	0.0	0	0	0	0	1
02/24/2015 04:00	0.0	0	0	0	0	1
02/24/2015 05:00	0.0	0	0	0	0	1
02/24/2015 06:00	0.0	0	0	0	0	1
02/24/2015 07:00	0.0	0	0	0	0	1
02/24/2015 08:00	0.0	0	0	0	0	1
02/24/2015 09:00	0.0	0	0	0	0	1
02/24/2015 10:00	0.0	0	0	0	0	1
02/24/2015 11:00	0.0	0	0	0	0	1
02/24/2015 12:00	0.0	0	0	0	0	1
02/24/2015 13:00	0.0	0	0	0	0	1
02/24/2015 14:00	0.0	0	0	0	0	1
02/24/2015 15:00	0.0	0	0	0	0	1
02/24/2015 16:00	0.0	0	0	0	0	1
02/24/2015 17:00	0.0	0	0	0	0	1
02/24/2015 18:00	0.0	0	0	0	0	1
02/24/2015 19:00	0.0	0	0	0	0	1
02/24/2015 20:00	0.0	0	0	0	0	1
02/24/2015 21:00	0.0	0	0	0	0	1
02/24/2015 22:00	0.0	0	0	0	0	1
02/24/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/25/2015 00:00	0.0	0	0	0	0	1
02/25/2015 01:00	0.0	0	0	0	0	1
02/25/2015 02:00	0.0	0	0	0	0	1
02/25/2015 03:00	0.0	0	0	0	0	1
02/25/2015 04:00	0.0	0	0	0	0	1
02/25/2015 05:00	0.0	0	0	0	0	1
02/25/2015 06:00	0.0	0	0	0	0	1
02/25/2015 07:00	0.0	0	0	0	0	1
02/25/2015 08:00	0.0	0	0	0	0	1
02/25/2015 09:00	0.0	0	0	0	0	1
02/25/2015 10:00	0.0	0	0	0	0	1
02/25/2015 11:00	0.0	0	0	0	0	1
02/25/2015 12:00	0.0	0	0	0	0	1
02/25/2015 13:00	0.0	0	0	0	0	1
02/25/2015 14:00	0.0	0	0	0	0	1
02/25/2015 15:00	0.0	0	0	0	0	1
02/25/2015 16:00	0.0	0	0	0	0	1
02/25/2015 17:00	0.0	0	0	0	0	1
02/25/2015 18:00	0.0	0	0	0	0	1
02/25/2015 19:00	0.0	0	0	0	0	1
02/25/2015 20:00	0.0	0	0	0	0	1
02/25/2015 21:00	0.0	0	0	0	0	1
02/25/2015 22:00	0.0	0	0	0	0	1
02/25/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/26/2015 00:00	0.0	0	0	0	0	1
02/26/2015 01:00	0.0	0	0	0	0	1
02/26/2015 02:00	0.0	0	0	0	0	1
02/26/2015 03:00	0.0	0	0	0	0	1
02/26/2015 04:00	0.0	0	0	0	0	1
02/26/2015 05:00	0.0	0	0	0	0	1
02/26/2015 06:00	0.0	0	0	0	0	1
02/26/2015 07:00	0.0	0	0	0	0	1
02/26/2015 08:00	0.0	0	0	0	0	1
02/26/2015 09:00	0.0	0	0	0	0	1
02/26/2015 10:00	0.0	0	0	0	0	1
02/26/2015 11:00	0.0	0	0	0	0	1
02/26/2015 12:00	0.0	0	0	0	0	1
02/26/2015 13:00	0.0	0	0	0	0	1
02/26/2015 14:00	0.0	0	0	0	0	1
02/26/2015 15:00	0.0	0	0	0	0	1
02/26/2015 16:00	0.0	0	0	0	0	1
02/26/2015 17:00	0.0	0	0	0	0	1
02/26/2015 18:00	0.0	0	0	0	0	1
02/26/2015 19:00	0.0	0	0	0	0	1
02/26/2015 20:00	0.0	0	0	0	0	1
02/26/2015 21:00	0.0	0	0	0	0	1
02/26/2015 22:00	0.0	0	0	0	0	1
02/26/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/27/2015 00:00	0.0	0	0	0	0	1
02/27/2015 01:00	0.0	0	0	0	0	1
02/27/2015 02:00	0.0	0	0	0	0	1
02/27/2015 03:00	0.0	0	0	0	0	1
02/27/2015 04:00	0.0	0	0	0	0	1
02/27/2015 05:00	0.0	0	0	0	0	1
02/27/2015 06:00	0.0	0	0	0	0	1
02/27/2015 07:00	0.0	0	0	0	0	1
02/27/2015 08:00	0.0	0	0	0	0	1
02/27/2015 09:00	0.0	0	0	0	0	1
02/27/2015 10:00	0.0	0	0	0	0	1
02/27/2015 11:00	0.0	0	0	0	0	1
02/27/2015 12:00	0.0	0	0	0	0	1
02/27/2015 13:00	0.0	0	0	0	0	1
02/27/2015 14:00	0.0	0	0	0	0	1
02/27/2015 15:00	0.0	0	0	0	0	1
02/27/2015 16:00	0.0	0	0	0	0	1
02/27/2015 17:00	0.0	0	0	0	0	1
02/27/2015 18:00	0.0	0	0	0	0	1
02/27/2015 19:00	0.0	0	0	0	0	1
02/27/2015 20:00	0.0	0	0	0	0	1
02/27/2015 21:00	0.0	0	0	0	0	1
02/27/2015 22:00	0.0	0	0	0	0	1
02/27/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/28/2015 00:00	0.0	0	0	0	0	1
02/28/2015 01:00	2.6	0	0	0	1	0
02/28/2015 02:00	0.0	0	0	0	0	0
02/28/2015 03:00	0.0	0	0	0	0	0
02/28/2015 04:00	0.0	0	0	0	0	0
02/28/2015 05:00	0.0	0	0	0	0	0
02/28/2015 06:00	0.0	0	0	0	0	0
02/28/2015 07:00	0.0	0	0	0	0	0
02/28/2015 08:00	0.0	0	0	0	0	0
02/28/2015 09:00	0.0	0	0	0	0	0
02/28/2015 10:00	0.0	0	0	0	0	0
02/28/2015 11:00	0.0	0	0	0	0	0
02/28/2015 12:00	0.0	0	0	0	0	0
02/28/2015 13:00	0.0	0	0	0	0	0
02/28/2015 14:00	9.1	0	1	0	0	0
02/28/2015 15:00	109.0	0	1	0	0	0
02/28/2015 16:00	0.0	0	0	0	0	1
02/28/2015 17:00	0.0	0	0	0	0	1
02/28/2015 18:00	0.0	0	0	0	0	1
02/28/2015 19:00	0.0	0	0	0	0	1
02/28/2015 20:00	0.0	0	0	0	0	1
02/28/2015 21:00	0.0	0	0	0	0	1
02/28/2015 22:00	0.0	0	0	0	0	1
02/28/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	120.7 #	0 #	2 #	0 #	1 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	109.0	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/01/2015 00:00	0.0	0	0	0	0	1
03/01/2015 01:00	0.0	0	0	0	0	1
03/01/2015 02:00	0.0	0	0	0	0	1
03/01/2015 03:00	0.0	0	0	0	0	1
03/01/2015 04:00	0.0	0	0	0	0	1
03/01/2015 05:00	0.0	0	0	0	0	1
03/01/2015 06:00	0.0	0	0	0	0	1
03/01/2015 07:00	0.0	0	0	0	0	1
03/01/2015 08:00	0.0	0	0	0	0	1
03/01/2015 09:00	0.0	0	0	0	0	1
03/01/2015 10:00	0.0	0	0	0	0	1
03/01/2015 11:00	0.0	0	0	0	0	1
03/01/2015 12:00	0.0	0	0	0	0	1
03/01/2015 13:00	0.0	0	0	0	0	1
03/01/2015 14:00	0.0	0	0	0	0	1
03/01/2015 15:00	0.0	0	0	0	0	1
03/01/2015 16:00	0.0	0	0	0	0	1
03/01/2015 17:00	0.0	0	0	0	0	1
03/01/2015 18:00	0.0	0	0	0	0	1
03/01/2015 19:00	0.0	0	0	0	0	1
03/01/2015 20:00	0.0	0	0	0	0	1
03/01/2015 21:00	0.0	0	0	0	0	1
03/01/2015 22:00	0.0	0	0	0	0	1
03/01/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/02/2015 00:00	0.0	0	0	0	0	1
03/02/2015 01:00	0.0	0	0	0	0	1
03/02/2015 02:00	0.0	0	0	0	0	1
03/02/2015 03:00	0.0	0	0	0	0	1
03/02/2015 04:00	0.0	0	0	0	0	1
03/02/2015 05:00	0.0	0	0	0	0	1
03/02/2015 06:00	0.0	0	0	0	0	1
03/02/2015 07:00	0.0	0	0	0	0	1
03/02/2015 08:00	0.0	0	0	0	0	1
03/02/2015 09:00	0.0	0	0	0	0	1
03/02/2015 10:00	0.0	0	0	0	0	1
03/02/2015 11:00	0.0	0	0	0	0	1
03/02/2015 12:00	0.0	0	0	0	0	1
03/02/2015 13:00	0.0	0	0	0	0	1
03/02/2015 14:00	0.0	0	0	0	0	1
03/02/2015 15:00	0.0	0	0	0	0	1
03/02/2015 16:00	0.0	0	0	0	0	1
03/02/2015 17:00	0.0	0	0	0	0	1
03/02/2015 18:00	0.0	0	0	0	0	1
03/02/2015 19:00	0.0	0	0	0	0	1
03/02/2015 20:00	0.0	0	0	0	0	1
03/02/2015 21:00	0.0	0	0	0	0	1
03/02/2015 22:00	0.0	0	0	0	0	1
03/02/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/03/2015 00:00	0.0	0	0	0	0	1
03/03/2015 01:00	0.0	0	0	0	0	1
03/03/2015 02:00	0.0	0	0	0	0	1
03/03/2015 03:00	0.0	0	0	0	0	1
03/03/2015 04:00	0.0	0	0	0	0	1
03/03/2015 05:00	0.0	0	0	0	0	1
03/03/2015 06:00	0.0	0	0	0	0	1
03/03/2015 07:00	0.0	0	0	0	0	1
03/03/2015 08:00	0.0	0	0	0	0	1
03/03/2015 09:00	0.0	0	0	0	0	1
03/03/2015 10:00	0.0	0	0	0	0	1
03/03/2015 11:00	0.0	0	0	0	0	1
03/03/2015 12:00	0.0	0	0	0	0	1
03/03/2015 13:00	0.0	0	0	0	0	1
03/03/2015 14:00	0.0	0	0	0	0	1
03/03/2015 15:00	0.0	0	0	0	0	1
03/03/2015 16:00	0.0	0	0	0	0	1
03/03/2015 17:00	0.0	0	0	0	0	1
03/03/2015 18:00	0.0	0	0	0	0	1
03/03/2015 19:00	0.0	0	0	0	0	1
03/03/2015 20:00	0.0	0	0	0	0	1
03/03/2015 21:00	0.0	0	0	0	0	1
03/03/2015 22:00	0.0	0	0	0	0	1
03/03/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/04/2015 00:00	0.0	0	0	0	0	1
03/04/2015 01:00	0.0	0	0	0	0	1
03/04/2015 02:00	0.0	0	0	0	0	1
03/04/2015 03:00	0.0	0	0	0	0	1
03/04/2015 04:00	0.0	0	0	0	0	1
03/04/2015 05:00	0.0	0	0	0	0	1
03/04/2015 06:00	0.0	0	0	0	0	1
03/04/2015 07:00	0.0	0	0	0	0	1
03/04/2015 08:00	0.0	0	0	0	0	1
03/04/2015 09:00	0.0	0	0	0	0	1
03/04/2015 10:00	0.0	0	0	0	0	1
03/04/2015 11:00	0.0	0	0	0	0	1
03/04/2015 12:00	0.0	0	0	0	0	1
03/04/2015 13:00	0.0	0	0	0	0	1
03/04/2015 14:00	0.0	0	0	0	0	1
03/04/2015 15:00	0.0	0	0	0	0	1
03/04/2015 16:00	0.0	0	0	0	0	1
03/04/2015 17:00	0.0	0	0	0	0	1
03/04/2015 18:00	0.0	0	0	0	0	1
03/04/2015 19:00	0.0	0	0	0	0	1
03/04/2015 20:00	0.0	0	0	0	0	1
03/04/2015 21:00	0.0	0	0	0	0	1
03/04/2015 22:00	0.0	0	0	0	0	1
03/04/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/05/2015 00:00	0.0	0	0	0	0	1
03/05/2015 01:00	0.0	0	0	0	0	1
03/05/2015 02:00	0.0	0	0	0	0	1
03/05/2015 03:00	0.0	0	0	0	0	1
03/05/2015 04:00	0.0	0	0	0	0	1
03/05/2015 05:00	0.0	0	0	0	0	1
03/05/2015 06:00	0.0	0	0	0	0	1
03/05/2015 07:00	0.0	0	0	0	0	1
03/05/2015 08:00	0.0	0	0	0	0	1
03/05/2015 09:00	0.0	0	0	0	0	1
03/05/2015 10:00	0.0	0	0	0	0	1
03/05/2015 11:00	0.0	0	0	0	0	1
03/05/2015 12:00	0.0	0	0	0	0	1
03/05/2015 13:00	0.0	0	0	0	0	1
03/05/2015 14:00	0.0	0	0	0	0	1
03/05/2015 15:00	0.0	0	0	0	0	1
03/05/2015 16:00	0.0	0	0	0	0	1
03/05/2015 17:00	0.0	0	0	0	0	1
03/05/2015 18:00	0.0	0	0	0	0	1
03/05/2015 19:00	0.0	0	0	0	0	1
03/05/2015 20:00	0.0	0	0	0	0	1
03/05/2015 21:00	0.0	0	0	0	0	1
03/05/2015 22:00	0.0	0	0	0	0	1
03/05/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/06/2015 00:00	0.0	0	0	0	0	1
03/06/2015 01:00	0.0	0	0	0	0	1
03/06/2015 02:00	0.0	0	0	0	0	1
03/06/2015 03:00	0.0	0	0	0	0	1
03/06/2015 04:00	0.0	0	0	0	0	1
03/06/2015 05:00	0.0	0	0	0	0	1
03/06/2015 06:00	0.0	0	0	0	0	1
03/06/2015 07:00	0.0	0	0	0	0	1
03/06/2015 08:00	0.0	0	0	0	0	1
03/06/2015 09:00	0.0	0	0	0	0	1
03/06/2015 10:00	0.0	0	0	0	0	1
03/06/2015 11:00	0.0	0	0	0	0	1
03/06/2015 12:00	0.0	0	0	0	0	1
03/06/2015 13:00	0.0	0	0	0	0	1
03/06/2015 14:00	0.0	0	0	0	0	1
03/06/2015 15:00	0.0	0	0	0	0	1
03/06/2015 16:00	0.0	0	0	0	0	1
03/06/2015 17:00	0.0	0	0	0	0	1
03/06/2015 18:00	0.0	0	0	0	0	1
03/06/2015 19:00	0.0	0	0	0	0	1
03/06/2015 20:00	0.0	0	0	0	0	1
03/06/2015 21:00	0.0	0	0	0	0	1
03/06/2015 22:00	0.0	0	0	0	0	1
03/06/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/07/2015 00:00	0.0	0	0	0	0	1
03/07/2015 01:00	0.0	0	0	0	0	1
03/07/2015 02:00	2.2	0	0	0	1	0
03/07/2015 03:00	0.0	0	0	0	0	0
03/07/2015 04:00	0.0	0	0	0	0	0
03/07/2015 05:00	0.0	0	0	0	0	0
03/07/2015 06:00	0.0	0	0	0	0	0
03/07/2015 07:00	0.0	0	0	0	0	0
03/07/2015 08:00	0.0	0	0	0	0	0
03/07/2015 09:00	0.0	0	0	0	0	0
03/07/2015 10:00	0.0	0	0	0	0	0
03/07/2015 11:00	0.0	0	0	0	0	0
03/07/2015 12:00	0.0	0	0	0	0	0
03/07/2015 13:00	0.0	0	0	0	0	0
03/07/2015 14:00	60.8	0	1	0	0	0
03/07/2015 15:00	58.2	0	1	0	0	0
03/07/2015 16:00	0.0	0	0	0	0	1
03/07/2015 17:00	0.0	0	0	0	0	1
03/07/2015 18:00	0.0	0	0	0	0	1
03/07/2015 19:00	0.0	0	0	0	0	1
03/07/2015 20:00	0.0	0	0	0	0	1
03/07/2015 21:00	0.0	0	0	0	0	1
03/07/2015 22:00	0.0	0	0	0	0	1
03/07/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	121.2 #	0 #	2 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	60.8	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/08/2015 00:00	0.0	0	0	0	0	1
03/08/2015 01:00	0.0	0	0	0	0	1
03/08/2015 02:00	0.0	0	0	0	0	1
03/08/2015 03:00	0.0	0	0	0	0	1
03/08/2015 04:00	0.0	0	0	0	0	1
03/08/2015 05:00	0.0	0	0	0	0	1
03/08/2015 06:00	0.0	0	0	0	0	1
03/08/2015 07:00	0.0	0	0	0	0	1
03/08/2015 08:00	2.3	0	0	0	1	0
03/08/2015 09:00	0.0	0	0	0	0	0
03/08/2015 10:00	7.4	0	0	1	0	0
03/08/2015 11:00	16.5	0	0	1	0	0
03/08/2015 12:00	0.0	0	0	0	0	1
03/08/2015 13:00	0.0	0	0	0	0	1
03/08/2015 14:00	0.0	0	0	0	0	1
03/08/2015 15:00	0.0	0	0	0	0	1
03/08/2015 16:00	0.0	0	0	0	0	1
03/08/2015 17:00	0.0	0	0	0	0	1
03/08/2015 18:00	0.0	0	0	0	0	1
03/08/2015 19:00	0.0	0	0	0	0	1
03/08/2015 20:00	0.0	0	0	0	0	1
03/08/2015 21:00	0.0	0	0	0	0	1
03/08/2015 22:00	0.0	0	0	0	0	1
03/08/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	26.2 #	0 #	0 #	2 #	1 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	16.5	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/09/2015 00:00	0.0	0	0	0	0	1
03/09/2015 01:00	0.0	0	0	0	0	1
03/09/2015 02:00	0.0	0	0	0	0	1
03/09/2015 03:00	0.0	0	0	0	0	1
03/09/2015 04:00	0.0	0	0	0	0	1
03/09/2015 05:00	0.0	0	0	0	0	1
03/09/2015 06:00	0.0	0	0	0	0	1
03/09/2015 07:00	0.0	0	0	0	0	1
03/09/2015 08:00	0.0	0	0	0	0	1
03/09/2015 09:00	0.0	0	0	0	0	1
03/09/2015 10:00	0.0	0	0	0	0	1
03/09/2015 11:00	0.0	0	0	0	0	1
03/09/2015 12:00	0.0	0	0	0	0	1
03/09/2015 13:00	0.0	0	0	0	0	1
03/09/2015 14:00	0.0	0	0	0	0	1
03/09/2015 15:00	0.0	0	0	0	0	1
03/09/2015 16:00	0.0	0	0	0	0	1
03/09/2015 17:00	0.0	0	0	0	0	1
03/09/2015 18:00	0.0	0	0	0	0	1
03/09/2015 19:00	0.0	0	0	0	0	1
03/09/2015 20:00	0.0	0	0	0	0	1
03/09/2015 21:00	0.0	0	0	0	0	1
03/09/2015 22:00	0.0	0	0	0	0	1
03/09/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/10/2015 00:00	0.0	0	0	0	0	1
03/10/2015 01:00	0.0	0	0	0	0	1
03/10/2015 02:00	0.0	0	0	0	0	1
03/10/2015 03:00	0.0	0	0	0	0	1
03/10/2015 04:00	0.0	0	0	0	0	1
03/10/2015 05:00	0.0	0	0	0	0	1
03/10/2015 06:00	0.0	0	0	0	0	1
03/10/2015 07:00	0.0	0	0	0	0	1
03/10/2015 08:00	0.0	0	0	0	0	1
03/10/2015 09:00	0.0	0	0	0	0	1
03/10/2015 10:00	0.0	0	0	0	0	1
03/10/2015 11:00	0.0	0	0	0	0	1
03/10/2015 12:00	0.0	0	0	0	0	1
03/10/2015 13:00	0.0	0	0	0	0	1
03/10/2015 14:00	0.0	0	0	0	0	1
03/10/2015 15:00	0.0	0	0	0	0	1
03/10/2015 16:00	0.0	0	0	0	0	1
03/10/2015 17:00	0.0	0	0	0	0	1
03/10/2015 18:00	0.0	0	0	0	0	1
03/10/2015 19:00	0.0	0	0	0	0	1
03/10/2015 20:00	0.0	0	0	0	0	1
03/10/2015 21:00	0.0	0	0	0	0	1
03/10/2015 22:00	0.0	0	0	0	0	1
03/10/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/11/2015 00:00	0.0	0	0	0	0	1
03/11/2015 01:00	0.0	0	0	0	0	1
03/11/2015 02:00	0.0	0	0	0	0	1
03/11/2015 03:00	0.0	0	0	0	0	1
03/11/2015 04:00	0.0	0	0	0	0	1
03/11/2015 05:00	0.0	0	0	0	0	1
03/11/2015 06:00	0.0	0	0	0	0	1
03/11/2015 07:00	0.0	0	0	0	0	1
03/11/2015 08:00	0.0	0	0	0	0	1
03/11/2015 09:00	0.0	0	0	0	0	1
03/11/2015 10:00	0.0	0	0	0	0	1
03/11/2015 11:00	0.0	0	0	0	0	1
03/11/2015 12:00	0.0	0	0	0	0	1
03/11/2015 13:00	0.0	0	0	0	0	1
03/11/2015 14:00	0.0	0	0	0	0	1
03/11/2015 15:00	0.0	0	0	0	0	1
03/11/2015 16:00	0.0	0	0	0	0	1
03/11/2015 17:00	0.0	0	0	0	0	1
03/11/2015 18:00	0.0	0	0	0	0	1
03/11/2015 19:00	0.0	0	0	0	0	1
03/11/2015 20:00	0.0	0	0	0	0	1
03/11/2015 21:00	0.0	0	0	0	0	1
03/11/2015 22:00	0.0	0	0	0	0	1
03/11/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/12/2015 00:00	0.0	0	0	0	0	1
03/12/2015 01:00	0.0	0	0	0	0	1
03/12/2015 02:00	0.0	0	0	0	0	1
03/12/2015 03:00	0.0	0	0	0	0	1
03/12/2015 04:00	0.0	0	0	0	0	1
03/12/2015 05:00	0.0	0	0	0	0	1
03/12/2015 06:00	0.0	0	0	0	0	1
03/12/2015 07:00	0.0	0	0	0	0	1
03/12/2015 08:00	0.0	0	0	0	0	1
03/12/2015 09:00	0.0	0	0	0	0	1
03/12/2015 10:00	0.0	0	0	0	0	1
03/12/2015 11:00	0.0	0	0	0	0	1
03/12/2015 12:00	0.0	0	0	0	0	1
03/12/2015 13:00	0.0	0	0	0	0	1
03/12/2015 14:00	0.0	0	0	0	0	1
03/12/2015 15:00	0.0	0	0	0	0	1
03/12/2015 16:00	0.0	0	0	0	0	1
03/12/2015 17:00	0.0	0	0	0	0	1
03/12/2015 18:00	0.0	0	0	0	0	1
03/12/2015 19:00	0.0	0	0	0	0	1
03/12/2015 20:00	0.0	0	0	0	0	1
03/12/2015 21:00	0.0	0	0	0	0	1
03/12/2015 22:00	0.0	0	0	0	0	1
03/12/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/13/2015 00:00	0.0	0	0	0	0	1
03/13/2015 01:00	0.0	0	0	0	0	1
03/13/2015 02:00	0.0	0	0	0	0	1
03/13/2015 03:00	0.0	0	0	0	0	1
03/13/2015 04:00	0.0	0	0	0	0	1
03/13/2015 05:00	0.0	0	0	0	0	1
03/13/2015 06:00	0.0	0	0	0	0	1
03/13/2015 07:00	0.0	0	0	0	0	1
03/13/2015 08:00	0.0	0	0	0	0	1
03/13/2015 09:00	0.0	0	0	0	0	1
03/13/2015 10:00	0.0	0	0	0	0	1
03/13/2015 11:00	0.0	0	0	0	0	1
03/13/2015 12:00	0.0	0	0	0	0	1
03/13/2015 13:00	0.0	0	0	0	0	1
03/13/2015 14:00	0.0	0	0	0	0	1
03/13/2015 15:00	0.0	0	0	0	0	1
03/13/2015 16:00	0.0	0	0	0	0	1
03/13/2015 17:00	0.0	0	0	0	0	1
03/13/2015 18:00	0.0	0	0	0	0	1
03/13/2015 19:00	0.0	0	0	0	0	1
03/13/2015 20:00	0.0	0	0	0	0	1
03/13/2015 21:00	0.0	0	0	0	0	1
03/13/2015 22:00	0.0	0	0	0	0	1
03/13/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/14/2015 00:00	0.0	0	0	0	0	1
03/14/2015 01:00	0.0	0	0	0	0	1
03/14/2015 02:00	0.0	0	0	0	0	1
03/14/2015 03:00	0.0	0	0	0	0	1
03/14/2015 04:00	0.0	0	0	0	0	1
03/14/2015 05:00	0.0	0	0	0	0	1
03/14/2015 06:00	0.0	0	0	0	0	1
03/14/2015 07:00	0.0	0	0	0	0	1
03/14/2015 08:00	0.0	0	0	0	0	1
03/14/2015 09:00	0.0	0	0	0	0	1
03/14/2015 10:00	0.0	0	0	0	0	1
03/14/2015 11:00	0.0	0	0	0	0	1
03/14/2015 12:00	0.0	0	0	0	0	1
03/14/2015 13:00	0.0	0	0	0	0	1
03/14/2015 14:00	0.0	0	0	0	0	1
03/14/2015 15:00	0.0	0	0	0	0	1
03/14/2015 16:00	0.0	0	0	0	0	1
03/14/2015 17:00	0.0	0	0	0	0	1
03/14/2015 18:00	0.0	0	0	0	0	1
03/14/2015 19:00	0.0	0	0	0	0	1
03/14/2015 20:00	0.0	0	0	0	0	1
03/14/2015 21:00	0.0	0	0	0	0	1
03/14/2015 22:00	0.0	0	0	0	0	1
03/14/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/15/2015 00:00	0.0	0	0	0	0	1
03/15/2015 01:00	0.0	0	0	0	0	1
03/15/2015 02:00	0.0	0	0	0	0	1
03/15/2015 03:00	0.0	0	0	0	0	1
03/15/2015 04:00	0.0	0	0	0	0	1
03/15/2015 05:00	0.0	0	0	0	0	1
03/15/2015 06:00	0.0	0	0	0	0	1
03/15/2015 07:00	0.0	0	0	0	0	1
03/15/2015 08:00	0.0	0	0	0	0	1
03/15/2015 09:00	0.0	0	0	0	0	1
03/15/2015 10:00	0.0	0	0	0	0	1
03/15/2015 11:00	0.0	0	0	0	0	1
03/15/2015 12:00	0.0	0	0	0	0	1
03/15/2015 13:00	0.0	0	0	0	0	1
03/15/2015 14:00	0.0	0	0	0	0	1
03/15/2015 15:00	0.0	0	0	0	0	1
03/15/2015 16:00	0.0	0	0	0	0	1
03/15/2015 17:00	0.0	0	0	0	0	1
03/15/2015 18:00	0.0	0	0	0	0	1
03/15/2015 19:00	0.0	0	0	0	0	1
03/15/2015 20:00	0.0	0	0	0	0	1
03/15/2015 21:00	0.0	0	0	0	0	1
03/15/2015 22:00	0.0	0	0	0	0	1
03/15/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/16/2015 00:00	0.0	0	0	0	0	1
03/16/2015 01:00	0.0	0	0	0	0	1
03/16/2015 02:00	0.0	0	0	0	0	1
03/16/2015 03:00	0.0	0	0	0	0	1
03/16/2015 04:00	0.0	0	0	0	0	1
03/16/2015 05:00	0.0	0	0	0	0	1
03/16/2015 06:00	0.0	0	0	0	0	1
03/16/2015 07:00	0.0	0	0	0	0	1
03/16/2015 08:00	0.0	0	0	0	0	1
03/16/2015 09:00	0.0	0	0	0	0	1
03/16/2015 10:00	0.0	0	0	0	0	1
03/16/2015 11:00	0.0	0	0	0	0	1
03/16/2015 12:00	0.0	0	0	0	0	1
03/16/2015 13:00	0.0	0	0	0	0	1
03/16/2015 14:00	0.0	0	0	0	0	1
03/16/2015 15:00	0.0	0	0	0	0	1
03/16/2015 16:00	0.0	0	0	0	0	1
03/16/2015 17:00	0.0	0	0	0	0	1
03/16/2015 18:00	0.0	0	0	0	0	1
03/16/2015 19:00	0.0	0	0	0	0	1
03/16/2015 20:00	0.0	0	0	0	0	1
03/16/2015 21:00	0.0	0	0	0	0	1
03/16/2015 22:00	0.0	0	0	0	0	1
03/16/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/17/2015 00:00	0.0	0	0	0	0	1
03/17/2015 01:00	0.0	0	0	0	0	1
03/17/2015 02:00	0.0	0	0	0	0	1
03/17/2015 03:00	0.0	0	0	0	0	1
03/17/2015 04:00	0.0	0	0	0	0	1
03/17/2015 05:00	0.0	0	0	0	0	1
03/17/2015 06:00	0.0	0	0	0	0	1
03/17/2015 07:00	0.0	0	0	0	0	1
03/17/2015 08:00	0.0	0	0	0	0	1
03/17/2015 09:00	0.0	0	0	0	0	1
03/17/2015 10:00	0.0	0	0	0	0	1
03/17/2015 11:00	0.0	0	0	0	0	1
03/17/2015 12:00	0.0	0	0	0	0	1
03/17/2015 13:00	0.0	0	0	0	0	1
03/17/2015 14:00	0.0	0	0	0	0	1
03/17/2015 15:00	0.0	0	0	0	0	1
03/17/2015 16:00	0.0	0	0	0	0	1
03/17/2015 17:00	0.0	0	0	0	0	1
03/17/2015 18:00	0.0	0	0	0	0	1
03/17/2015 19:00	0.0	0	0	0	0	1
03/17/2015 20:00	0.0	0	0	0	0	1
03/17/2015 21:00	0.0	0	0	0	0	1
03/17/2015 22:00	0.0	0	0	0	0	1
03/17/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/18/2015 00:00	0.0	0	0	0	0	1
03/18/2015 01:00	0.0	0	0	0	0	1
03/18/2015 02:00	0.0	0	0	0	0	1
03/18/2015 03:00	0.0	0	0	0	0	1
03/18/2015 04:00	0.0	0	0	0	0	1
03/18/2015 05:00	0.0	0	0	0	0	1
03/18/2015 06:00	0.0	0	0	0	0	1
03/18/2015 07:00	0.0	0	0	0	0	1
03/18/2015 08:00	0.0	0	0	0	0	1
03/18/2015 09:00	0.5	0	0	1	0	0
03/18/2015 10:00	0.0	0	0	1	0	0
03/18/2015 11:00	0.5	0	0	1	0	0
03/18/2015 12:00	0.0	0	0	0	0	1
03/18/2015 13:00	0.0	0	0	0	0	1
03/18/2015 14:00	0.0	0	0	0	0	1
03/18/2015 15:00	0.0	0	0	0	0	1
03/18/2015 16:00	0.0	0	0	0	0	1
03/18/2015 17:00	0.0	0	0	0	0	1
03/18/2015 18:00	0.0	0	0	0	0	1
03/18/2015 19:00	0.0	0	0	0	0	1
03/18/2015 20:00	0.0	0	0	0	0	1
03/18/2015 21:00	0.0	0	0	0	0	1
03/18/2015 22:00	0.0	0	0	0	0	1
03/18/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	1.0 #	0 #	0 #	3 #	0 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.5	0	0	1	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/19/2015 00:00	0.0	0	0	0	0	1
03/19/2015 01:00	0.0	0	0	0	0	1
03/19/2015 02:00	0.0	0	0	0	0	1
03/19/2015 03:00	0.0	0	0	0	0	1
03/19/2015 04:00	0.0	0	0	0	0	1
03/19/2015 05:00	0.0	0	0	0	0	1
03/19/2015 06:00	0.0	0	0	0	0	1
03/19/2015 07:00	0.0	0	0	0	0	1
03/19/2015 08:00	0.0	0	0	0	0	1
03/19/2015 09:00	0.0	0	0	0	0	1
03/19/2015 10:00	0.0	0	0	0	0	1
03/19/2015 11:00	0.0	0	0	0	0	1
03/19/2015 12:00	0.0	0	0	0	0	1
03/19/2015 13:00	0.0	0	0	0	0	1
03/19/2015 14:00	0.0	0	0	0	0	1
03/19/2015 15:00	0.0	0	0	0	0	1
03/19/2015 16:00	0.0	0	0	0	0	1
03/19/2015 17:00	0.0	0	0	0	0	1
03/19/2015 18:00	0.0	0	0	0	0	1
03/19/2015 19:00	0.0	0	0	0	0	1
03/19/2015 20:00	0.0	0	0	0	0	1
03/19/2015 21:00	0.0	0	0	0	0	1
03/19/2015 22:00	0.0	0	0	0	0	1
03/19/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/20/2015 00:00	0.0	0	0	0	0	1
03/20/2015 01:00	0.0	0	0	0	0	1
03/20/2015 02:00	0.0	0	0	0	0	1
03/20/2015 03:00	0.0	0	0	0	0	1
03/20/2015 04:00	0.0	0	0	0	0	1
03/20/2015 05:00	0.0	0	0	0	0	1
03/20/2015 06:00	0.0	0	0	0	0	1
03/20/2015 07:00	0.0	0	0	0	0	1
03/20/2015 08:00	0.0	0	0	0	0	1
03/20/2015 09:00	0.0	0	0	0	0	1
03/20/2015 10:00	0.0	0	0	0	0	1
03/20/2015 11:00	0.0	0	0	0	0	1
03/20/2015 12:00	0.0	0	0	0	0	1
03/20/2015 13:00	0.0	0	0	0	0	1
03/20/2015 14:00	0.0	0	0	0	0	1
03/20/2015 15:00	0.0	0	0	0	0	1
03/20/2015 16:00	0.0	0	0	0	0	1
03/20/2015 17:00	0.0	0	0	0	0	1
03/20/2015 18:00	0.0	0	0	0	0	1
03/20/2015 19:00	0.0	0	0	0	0	1
03/20/2015 20:00	0.0	0	0	0	0	1
03/20/2015 21:00	0.0	0	0	0	0	1
03/20/2015 22:00	0.0	0	0	0	0	1
03/20/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/21/2015 00:00	0.0	0	0	0	0	1
03/21/2015 01:00	0.0	0	0	0	0	1
03/21/2015 02:00	0.0	0	0	0	0	1
03/21/2015 03:00	0.0	0	0	0	0	1
03/21/2015 04:00	0.0	0	0	0	0	1
03/21/2015 05:00	0.0	0	0	0	0	1
03/21/2015 06:00	0.0	0	0	0	0	1
03/21/2015 07:00	0.0	0	0	0	0	1
03/21/2015 08:00	0.0	0	0	0	0	1
03/21/2015 09:00	0.0	0	0	0	0	1
03/21/2015 10:00	0.0	0	0	0	0	1
03/21/2015 11:00	0.0	0	0	0	0	1
03/21/2015 12:00	0.0	0	0	0	0	1
03/21/2015 13:00	0.0	0	0	0	0	1
03/21/2015 14:00	0.0	0	0	0	0	1
03/21/2015 15:00	0.0	0	0	0	0	1
03/21/2015 16:00	0.0	0	0	0	0	1
03/21/2015 17:00	0.0	0	0	0	0	1
03/21/2015 18:00	0.0	0	0	0	0	1
03/21/2015 19:00	0.0	0	0	0	0	1
03/21/2015 20:00	0.0	0	0	0	0	1
03/21/2015 21:00	0.0	0	0	0	0	1
03/21/2015 22:00	0.0	0	0	0	0	1
03/21/2015 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/22/2015 00:00	0.0	0	0	0	0	1
03/22/2015 01:00	0.0	0	0	0	0	1
03/22/2015 02:00	0.0	0	0	0	0	1
03/22/2015 03:00	0.0	0	0	0	0	1
03/22/2015 04:00	0.0	0	0	0	0	1
03/22/2015 05:00	0.0	0	0	0	0	1
03/22/2015 06:00	0.0	0	0	0	0	1
03/22/2015 07:00	0.0	0	0	0	0	1
03/22/2015 08:00	0.0	0	0	0	0	1
03/22/2015 09:00	0.0	0	0	0	0	1
03/22/2015 10:00	0.0	0	0	0	0	1
03/22/2015 11:00	0.0	0	0	0	0	1
03/22/2015 12:00	0.0	0	0	0	0	1
03/22/2015 13:00	0.0	0	0	0	0	1
03/22/2015 14:00	0.0	0	0	0	0	1
03/22/2015 15:00	0.0	0	0	0	0	1
03/22/2015 16:00	0.0	0	0	0	0	1
03/22/2015 17:00	0.0	0	0	0	0	1
03/22/2015 18:00	0.0	0	0	0	0	1
03/22/2015 19:00	0.0	0	0	0	0	1
03/22/2015 20:00	0.0	0	0	0	0	1
03/22/2015 21:00	0.0	0	0	0	0	1
03/22/2015 22:00	0.0	0	0	0	0	1
03/22/2015 23:00	2.6	0	0	0	1	0
Average/Sum#:	2.6 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.6	0	0	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/23/2015 00:00	0.0	0	0	0	0	0
03/23/2015 01:00	0.0	0	0	0	0	0
03/23/2015 02:00	0.0	0	0	0	0	0
03/23/2015 03:00	0.0	0	0	0	0	0
03/23/2015 04:00	0.0	0	0	0	0	0
03/23/2015 05:00	0.0	0	0	0	0	0
03/23/2015 06:00	0.0	0	0	0	0	0
03/23/2015 07:00	0.0	0	0	0	0	0
03/23/2015 08:00	0.0	0	0	0	0	0
03/23/2015 09:00	0.0	0	0	0	0	0
03/23/2015 10:00	0.0	0	0	0	0	0
03/23/2015 11:00	0.0	0	0	0	0	0
03/23/2015 12:00	0.0	0	0	0	0	0
03/23/2015 13:00	0.0	0	0	0	0	0
03/23/2015 14:00	0.0	0	0	0	0	0
03/23/2015 15:00	0.0	0	0	0	0	0
03/23/2015 16:00	0.0	0	0	0	0	0
03/23/2015 17:00	0.0	0	0	0	0	0
03/23/2015 18:00	0.0	0	0	0	0	0
03/23/2015 19:00	0.0	0	0	0	0	0
03/23/2015 20:00	0.0	0	0	0	0	0
03/23/2015 21:00	0.0	0	0	0	0	0
03/23/2015 22:00	0.0	0	0	0	0	0
03/23/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/24/2015 00:00	0.0	0	0	0	0	0
03/24/2015 01:00	0.0	0	0	0	0	0
03/24/2015 02:00	0.0	0	0	0	0	0
03/24/2015 03:00	0.0	0	0	0	0	0
03/24/2015 04:00	0.0	0	0	0	0	0
03/24/2015 05:00	0.0	0	0	0	0	0
03/24/2015 06:00	0.0	0	0	0	0	0
03/24/2015 07:00	0.0	0	0	0	0	0
03/24/2015 08:00	0.0	0	0	0	0	0
03/24/2015 09:00	0.0	0	0	0	0	0
03/24/2015 10:00	0.0	0	0	0	0	0
03/24/2015 11:00	0.0	0	0	0	0	0
03/24/2015 12:00	0.0	0	0	0	0	0
03/24/2015 13:00	0.0	0	0	0	0	0
03/24/2015 14:00	0.0	0	0	0	0	0
03/24/2015 15:00	0.0	0	0	0	0	0
03/24/2015 16:00	0.0	0	0	0	0	0
03/24/2015 17:00	0.0	0	0	0	0	0
03/24/2015 18:00	0.0	0	0	0	0	0
03/24/2015 19:00	0.0	0	0	0	0	0
03/24/2015 20:00	0.0	0	0	0	0	0
03/24/2015 21:00	0.0	0	0	0	0	0
03/24/2015 22:00	0.0	0	0	0	0	0
03/24/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/25/2015 00:00	0.0	0	0	0	0	0
03/25/2015 01:00	0.0	0	0	0	0	0
03/25/2015 02:00	0.0	0	0	0	0	0
03/25/2015 03:00	0.0	0	0	0	0	0
03/25/2015 04:00	0.0	0	0	0	0	0
03/25/2015 05:00	0.0	0	0	0	0	0
03/25/2015 06:00	0.0	0	0	0	0	0
03/25/2015 07:00	0.0	0	0	0	0	0
03/25/2015 08:00	0.0	0	0	0	0	0
03/25/2015 09:00	0.0	0	0	0	0	0
03/25/2015 10:00	0.0	0	0	0	0	0
03/25/2015 11:00	0.0	0	0	0	0	0
03/25/2015 12:00	0.0	0	0	0	0	0
03/25/2015 13:00	0.0	0	0	0	0	0
03/25/2015 14:00	0.0	0	0	0	0	0
03/25/2015 15:00	0.0	0	0	0	0	0
03/25/2015 16:00	0.0	0	0	0	0	0
03/25/2015 17:00	0.0	0	0	0	0	0
03/25/2015 18:00	0.0	0	0	0	0	0
03/25/2015 19:00	0.0	0	0	0	0	0
03/25/2015 20:00	0.0	0	0	0	0	0
03/25/2015 21:00	0.0	0	0	0	0	0
03/25/2015 22:00	0.0	0	0	0	0	0
03/25/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/26/2015 00:00	0.0	0	0	0	0	0
03/26/2015 01:00	0.0	0	0	0	0	0
03/26/2015 02:00	0.0	0	0	0	0	0
03/26/2015 03:00	0.0	0	0	0	0	0
03/26/2015 04:00	0.0	0	0	0	0	0
03/26/2015 05:00	0.0	0	0	0	0	0
03/26/2015 06:00	0.0	0	0	0	0	0
03/26/2015 07:00	0.0	0	0	0	0	0
03/26/2015 08:00	0.0	0	0	0	0	0
03/26/2015 09:00	0.0	0	0	0	0	0
03/26/2015 10:00	0.0	0	0	0	0	0
03/26/2015 11:00	0.0	0	0	0	0	0
03/26/2015 12:00	0.0	0	0	0	0	0
03/26/2015 13:00	0.0	0	0	0	0	0
03/26/2015 14:00	0.0	0	0	0	0	0
03/26/2015 15:00	0.0	0	0	0	0	0
03/26/2015 16:00	0.0	0	0	0	0	0
03/26/2015 17:00	0.0	0	0	0	0	0
03/26/2015 18:00	0.0	0	0	0	0	0
03/26/2015 19:00	0.0	0	0	0	0	0
03/26/2015 20:00	0.0	0	0	0	0	0
03/26/2015 21:00	0.0	0	0	0	0	0
03/26/2015 22:00	0.0	0	0	0	0	0
03/26/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/27/2015 00:00	0.0	0	0	0	0	0
03/27/2015 01:00	0.0	0	0	0	0	0
03/27/2015 02:00	0.0	0	0	0	0	0
03/27/2015 03:00	0.0	0	0	0	0	0
03/27/2015 04:00	0.0	0	0	0	0	0
03/27/2015 05:00	0.0	0	0	0	0	0
03/27/2015 06:00	0.0	0	0	0	0	0
03/27/2015 07:00	0.0	0	0	0	0	0
03/27/2015 08:00	0.0	0	0	0	0	0
03/27/2015 09:00	0.0	0	0	0	0	0
03/27/2015 10:00	0.0	0	0	0	0	0
03/27/2015 11:00	0.0	0	0	0	0	0
03/27/2015 12:00	0.0	0	0	0	0	0
03/27/2015 13:00	0.0	0	0	0	0	0
03/27/2015 14:00	0.0	0	0	0	0	0
03/27/2015 15:00	0.0	0	0	0	0	0
03/27/2015 16:00	0.0	0	0	0	0	0
03/27/2015 17:00	0.0	0	0	0	0	0
03/27/2015 18:00	0.0	0	0	0	0	0
03/27/2015 19:00	0.0	0	0	0	0	0
03/27/2015 20:00	0.0	0	0	0	0	0
03/27/2015 21:00	0.0	0	0	0	0	0
03/27/2015 22:00	0.0	0	0	0	0	0
03/27/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/28/2015 00:00	0.0	0	0	0	0	0
03/28/2015 01:00	0.0	0	0	0	0	0
03/28/2015 02:00	0.0	0	0	0	0	0
03/28/2015 03:00	0.0	0	0	0	0	0
03/28/2015 04:00	0.0	0	0	0	0	0
03/28/2015 05:00	0.0	0	0	0	0	0
03/28/2015 06:00	0.0	0	0	0	0	0
03/28/2015 07:00	0.0	0	0	0	0	0
03/28/2015 08:00	0.0	0	0	0	0	0
03/28/2015 09:00	0.0	0	0	0	0	0
03/28/2015 10:00	0.0	0	0	0	0	0
03/28/2015 11:00	0.0	0	0	0	0	0
03/28/2015 12:00	0.0	0	0	0	0	0
03/28/2015 13:00	0.0	0	0	0	0	0
03/28/2015 14:00	0.0	0	0	0	0	0
03/28/2015 15:00	0.0	0	0	0	0	0
03/28/2015 16:00	0.0	0	0	0	0	0
03/28/2015 17:00	0.0	0	0	0	0	0
03/28/2015 18:00	0.0	0	0	0	0	0
03/28/2015 19:00	0.0	0	0	0	0	0
03/28/2015 20:00	0.0	0	0	0	0	0
03/28/2015 21:00	0.0	0	0	0	0	0
03/28/2015 22:00	0.0	0	0	0	0	0
03/28/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/29/2015 00:00	0.0	0	0	0	0	0
03/29/2015 01:00	0.0	0	0	0	0	0
03/29/2015 02:00	0.0	0	0	0	0	0
03/29/2015 03:00	0.0	0	0	0	0	0
03/29/2015 04:00	0.0	0	0	0	0	0
03/29/2015 05:00	0.0	0	0	0	0	0
03/29/2015 06:00	0.0	0	0	0	0	0
03/29/2015 07:00	0.0	0	0	0	0	0
03/29/2015 08:00	0.0	0	0	0	0	0
03/29/2015 09:00	0.0	0	0	0	0	0
03/29/2015 10:00	0.0	0	0	0	0	0
03/29/2015 11:00	0.0	0	0	0	0	0
03/29/2015 12:00	0.0	0	0	0	0	0
03/29/2015 13:00	0.0	0	0	0	0	0
03/29/2015 14:00	0.0	0	0	0	0	0
03/29/2015 15:00	0.0	0	0	0	0	0
03/29/2015 16:00	0.0	0	0	0	0	0
03/29/2015 17:00	0.0	0	0	0	0	0
03/29/2015 18:00	0.0	0	0	0	0	0
03/29/2015 19:00	0.0	0	0	0	0	0
03/29/2015 20:00	0.0	0	0	0	0	0
03/29/2015 21:00	0.0	0	0	0	0	0
03/29/2015 22:00	0.0	0	0	0	0	0
03/29/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/30/2015 00:00	0.0	0	0	0	0	0
03/30/2015 01:00	0.0	0	0	0	0	0
03/30/2015 02:00	0.0	0	0	0	0	0
03/30/2015 03:00	0.0	0	0	0	0	0
03/30/2015 04:00	0.0	0	0	0	0	0
03/30/2015 05:00	0.0	0	0	0	0	0
03/30/2015 06:00	0.0	0	0	0	0	0
03/30/2015 07:00	0.0	0	0	0	0	0
03/30/2015 08:00	0.0	0	0	0	0	0
03/30/2015 09:00	0.0	0	0	0	0	0
03/30/2015 10:00	0.0	0	0	0	0	0
03/30/2015 11:00	0.0	0	0	0	0	0
03/30/2015 12:00	0.0	0	0	0	0	0
03/30/2015 13:00	0.0	0	0	0	0	0
03/30/2015 14:00	0.0	0	0	0	0	0
03/30/2015 15:00	0.0	0	0	0	0	0
03/30/2015 16:00	0.0	0	0	0	0	0
03/30/2015 17:00	0.0	0	0	0	0	0
03/30/2015 18:00	0.0	0	0	0	0	0
03/30/2015 19:00	0.0	0	0	0	0	0
03/30/2015 20:00	0.0	0	0	0	0	0
03/30/2015 21:00	0.0	0	0	0	0	0
03/30/2015 22:00	0.0	0	0	0	0	0
03/30/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/31/2015 00:00	0.0	0	0	0	0	0
03/31/2015 01:00	0.0	0	0	0	0	0
03/31/2015 02:00	0.0	0	0	0	0	0
03/31/2015 03:00	0.0	0	0	0	0	0
03/31/2015 04:00	0.0	0	0	0	0	0
03/31/2015 05:00	0.0	0	0	0	0	0
03/31/2015 06:00	0.0	0	0	0	0	0
03/31/2015 07:00	0.0	0	0	0	0	0
03/31/2015 08:00	0.0	0	0	0	0	0
03/31/2015 09:00	0.0	0	0	0	0	0
03/31/2015 10:00	0.0	0	0	0	0	0
03/31/2015 11:00	0.0	0	0	0	0	0
03/31/2015 12:00	0.0	0	0	0	0	0
03/31/2015 13:00	0.0	0	0	0	0	0
03/31/2015 14:00	0.0	0	0	0	0	0
03/31/2015 15:00	0.0	0	0	0	0	0
03/31/2015 16:00	0.0	0	0	0	0	0
03/31/2015 17:00	0.0	0	0	0	0	0
03/31/2015 18:00	0.0	0	0	0	0	0
03/31/2015 19:00	0.0	0	0	0	0	0
03/31/2015 20:00	0.0	0	0	0	0	0
03/31/2015 21:00	0.0	0	0	0	0	0
03/31/2015 22:00	0.0	0	0	0	0	0
03/31/2015 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,793.78 Hours

Non-Operating Time: 366.22 Hours Report Time: 2,160.00 Hours

Unit Operation and Excess Events

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
01/16/2015 16:15 01/16/2015 16:21 Shut Down - Gas	7	3.7		
01/16/2015 17:17 01/16/2015 18:14 Hot Start - Gas	58	118.4		
01/18/2015 02:20 01/18/2015 02:27 Shut Down - Gas	8	5.3		
01/18/2015 10:35 01/18/2015 11:50 Warm Start - Gas	76	146.6		
01/25/2015 01:06 01/25/2015 01:14 Shut Down - Gas	9	7.1		
01/27/2015 02:08 01/27/2015 04:12 Warm Start - Gas	125	203.5		
01/27/2015 07:40 01/27/2015 08:54 Hot Start - Gas	75	99.6		
01/27/2015 09:38 01/27/2015 10:25 Hot Start - Gas	48	102.0		
02/01/2015 02:05 02/01/2015 02:12 Shut Down - Gas	8	6.1		
02/01/2015 14:21 02/01/2015 15:33 Warm Start - Gas	73	138.1		
02/15/2015 02:05 02/15/2015 02:12 Shut Down - Gas	8	5.3		
02/15/2015 10:23 02/15/2015 11:46 Warm Start - Gas	84	161.1		
02/20/2015 01:06 02/20/2015 01:14 Shut Down - Gas	9	6.6		

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,793.78 Hours

Non-Operating Time: 366.22 Hours Report Time: 2,160.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
02/20/2015 04:48 02/20/2015 05:30 Hot Start - Gas	43	86.2		
02/20/2015 12:02 02/20/2015 12:11 Shut Down - Gas	10	8.7		
02/21/2015 10:16 02/21/2015 12:19 Warm Start - Gas	124	231.6		
02/22/2015 06:06 02/22/2015 06:13 Shut Down - Gas	8	6.0		
02/22/2015 14:19 02/22/2015 15:50 Warm Start - Gas	92	176.3		
02/22/2015 22:23 02/22/2015 22:30 Shut Down - Gas	8	5.2		
02/23/2015 03:18 02/23/2015 04:24 Hot Start - Gas	67	128.8		
02/28/2015 01:05 02/28/2015 01:12 Shut Down - Gas	8	5.6		
02/28/2015 14:46 02/28/2015 15:58 Warm Start - Gas	73	139.5		
03/07/2015 02:05 03/07/2015 02:11 Shut Down - Gas	7	3.3		
03/07/2015 14:18 03/07/2015 15:51 Warm Start - Gas	94	179.1		
03/08/2015 08:05 03/08/2015 08:12 Shut Down - Gas	8	5.6		
03/08/2015 10:18 03/08/2015 11:31 Hot Start - Gas	74	137.8		
03/18/2015 09:15 03/18/2015 09:20 Hot Start - Gas	6	20.9		

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,793.78 Hours

Non-Operating Time: 366.22 Hours Report Time: 2,160.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
03/18/2015 10:14 03/18/2015 10:19 Hot Start - Gas	6	21.0		
03/18/2015 11:06 03/18/2015 11:11 Hot Start - Gas	6	20.9		
03/22/2015 23:03 03/22/2015 23:11 Shut Down - Gas	9	6.1		

No excess emissions were found in the reporting period.

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,793.78 Hours

Non-Operating Time: 366.22 Hours Report Time: 2,160.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:22 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,793.78 Hours

Non-Operating Time: 366.22 Hours Report Time: 2,160.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Pound Per Event Report

CT2 - NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:26 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,793.78 Hours

Non-Operating Time: 366.22 Hours Report Time: 2,160.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
01/16/2015 16:15 01/16/2015 16:21 Shut Down - Gas	7	1.25	115.00		
01/16/2015 17:17 01/16/2015 18:14 Hot Start - Gas	58	43.14	259.90		
01/18/2015 02:20 01/18/2015 02:27 Shut Down - Gas	8	2.37	115.00		
01/18/2015 10:35 01/18/2015 11:50 Warm Start - Gas	76	89.23	456.20		
01/25/2015 01:06 01/25/2015 01:14 Shut Down - Gas	9	3.43	115.00		
01/27/2015 02:08 01/27/2015 04:12 Warm Start - Gas	125	143.10	456.20		
01/27/2015 07:40 01/27/2015 08:54 Hot Start - Gas	75	26.24	259.90		
01/27/2015 09:38 01/27/2015 10:25 Hot Start - Gas	48	1.62	259.90		
02/01/2015 02:05 02/01/2015 02:12 Shut Down - Gas	8	3.14	115.00		
02/01/2015 14:21 02/01/2015 15:33 Warm Start - Gas	73	107.73	456.20		
02/15/2015 02:05 02/15/2015 02:12 Shut Down - Gas	8	2.55	115.00		
02/15/2015 10:23 02/15/2015 11:46 Warm Start - Gas	84	105.96	456.20		
02/20/2015 01:06 02/20/2015 01:14 Shut Down - Gas	9	2.45	115.00		

Pound Per Event Report

CT2 - NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:26 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,793.78 Hours

Non-Operating Time: 366.22 Hours Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
02/20/2015 04:48 02/20/2015 05:30 Hot Start - Gas	43	20.47	259.90		
02/20/2015 12:02 02/20/2015 12:11 Shut Down - Gas	10	3.38	115.00		
02/21/2015 10:16 02/21/2015 12:19 Warm Start - Gas	124	153.42	456.20		
02/22/2015 06:06 02/22/2015 06:13 Shut Down - Gas	8	0.00 SI	115.00		
02/22/2015 14:19 02/22/2015 15:50 Warm Start - Gas	92	136.83	456.20		
02/22/2015 22:23 02/22/2015 22:30 Shut Down - Gas	8	2.21	115.00		
02/23/2015 03:18 02/23/2015 04:24 Hot Start - Gas	67	78.72	259.90		
02/28/2015 01:05 02/28/2015 01:12 Shut Down - Gas	8	2.68	115.00		
02/28/2015 14:46 02/28/2015 15:58 Warm Start - Gas	73	116.98	456.20		
03/07/2015 02:05 03/07/2015 02:11 Shut Down - Gas	7	1.31	115.00		
03/07/2015 14:18 03/07/2015 15:51 Warm Start - Gas	94	126.64	456.20		
03/08/2015 08:05 03/08/2015 08:12 Shut Down - Gas	8	2.32	115.00		
03/08/2015 10:18 03/08/2015 11:31 Hot Start - Gas	74	34.28	259.90		
03/18/2015 09:15 03/18/2015 09:20 Hot Start - Gas	6	0.00 SI	259.90		

Pound Per Event Report

CT2 - NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:26 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,793.78 Hours

Non-Operating Time: 366.22 Hours Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
03/18/2015 10:14 03/18/2015 10:19 Hot Start - Gas	6	0.42	259.90		
03/18/2015 11:06 03/18/2015 11:11 Hot Start - Gas	6	0.11	259.90		
03/22/2015 23:03 03/22/2015 23:11 Shut Down - Gas	9	2.74	115.00		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT2 - NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:26 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,793.78 Hours

Non-Operating Time: 366.22 Hours Report Time: 2,160.00 Hours

Event Invalid Information

Invalid Event Period		Reason	Action
Begin/End	Duration in Minute(s)	Code - Description	Code - Description
02/22/2015 06:06 02/22/2015 06:13	8		
03/18/2015 09:15 03/18/2015 09:20	6		

Total CMS Downtime	14	Minute(s)
Total Downtime as a percentage of operating time	0.01	%
Total Availability as a percentage of operating time	99.99	%

Pound Per Event Report

CT2 - NOx Lbs

From: 01/01/2015 00:00 **To:** 03/31/2015 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/22/2015 13:26 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,793.78 Hours

Non-Operating Time: 366.22 Hours Report Time: 2,160.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	14
2. Total CMS Downtime in Minute(s)	14
3. Total Downtime as a percentage of operating time	0.01
4. Total Availability as a percentage of operating time	99.99

ATTACHMENT 13
Water Bath Heater Operations (AQ-17)

The Natural Gas Fired Water Bath Heater did not operate in the 1st Quarter of 2015.

ATTACHMENT 14
Toxics

FCD:	AQ-29
Title V:	#6

TOXICS AND GHG TRACKING AND COMPLIANCE PLAN

PG&E Colusa Generating Station

Reporting/Tracking Year: 2014

Combustion Turbines/HRSGs

	CAS #	Emissions Factors lb/mmbtu	Emissions Factors lb/mmscf	EF Source	Source Test Results lb/hr	Max Hourly Emissions lbs	Annual Emissions lbs	Annual Emissions tons
Ammonia Unit #1	7664417	0.00E+00	0.00E+00	Test 11/10	4.03	4.03	7536.10	3.768
Formaldehyde Unit #1	50000	7.00E-05	9.19E-02	Test	0.0579	0.0579	108.27	0.054
Ammonia Unit #2	7664417	0.00E+00	0.00E+00	Test 11/10	2.39	2.39	4328.29	2.164
Formaldehyde Unit #2	50000	7.00E-05	9.19E-02	Test	0.2141	0.2141	387.74	0.194
1-3 Butadiene	106990	1.24E-07	1.27E-04	CATEF	0	0.001	0.78	0.000
Acetaldehyde	75070	1.34E-04	1.37E-01	CATEF	0	0.656	845.13	0.423
Acrolein	107028	1.85E-05	1.89E-02	CATEF	0	0.091	116.59	0.058
Benzene	71432	1.30E-05	1.33E-02	CATEF	0	0.064	82.05	0.041
Ethylbenzene	100414	1.75E-05	1.79E-02	CATEF	0	0.086	110.42	0.055
Hexane	110543	2.53E-04	2.59E-01	CATEF	0	1.240	1597.72	0.799
Propylene	115071	7.53E-04	7.71E-01	CATEF	0	3.692	4756.14	2.378
Propylene Oxide	75569	4.67E-05	4.78E-02	CATEF	0	0.229	294.87	0.147
Toluene	108883	6.93E-05	7.10E-02	CATEF	0	0.340	437.98	0.219
Xylenes	1330207	2.55E-05	2.61E-02	CATEF	0	0.125	161.01	0.081
Naphthalene	91203	1.62E-06	1.66E-03	CATEF	0	0.008	10.24	0.005
Total PAH w/o Naph	1151	1.30E-07	1.31E-04	CATEF	0	0.001	0.81	0.000

GHG	kg/mmbtu	Frac Ox.	lbs/mmbtu	lb/mmscf				
CO2	53.06	1	1.17E+02	1.20E+05	CCAR	0	573603.7	7.389E+08	3.695E+05
CH4	0.003901	na	8.60E-03	8.81E+00	CCAR	0	42.172	5.433E+04	27.163
N2O	0.001361	na	3.00E-03	3.07E+00	CCAR	0	14.713	1.895E+04	9.477
CO2e	372968.4	tons/yr		*CO2e*	*338293.4*	*metric tons/yr*			

Total Turbines/HRSGs

Fuel Use Rate Data			
NG HHV	1024	btu/scf	
Fuel Meter Data			
Max Hourly Fuel Use	4.7887	mmscf	(for both units)
Annual Fuel Use	6168.80	mmscf	(for both units)
Calculated Heat Rate Data			
Max Hourly Heat Rate	4903.60	mmbtu	(for both units)
Annual Heat Rate	6316851.2	mmbtu	(for both units)
DAHS/Op Log Data			
Unit #1 Annual Ops Hrs	1870	Hrs/Yr	
Unit #2 Annual Ops Hrs	1811	Hrs/Yr	
Total Hrs, All Units	3681	Hrs/Yr	(for both units)
CT1 Annual Fuel Use	3110.6	mmscf	
CT2 Annual Fuel Use	3058.2	mmscf	

Fuel Gas Heater (10 mmbtu/hr)

	CAS #	Emissions Factors lb/mmbtu	Emissions Factors lb/mmscf	EF Source	Source Test Results lb/hr	Max Hourly Emissions lbs	Annual Emissions lbs	Annual Emissions tons
Acetaldehyde	75070	8.66E-06	8.87E-03	CATEF	0	0.0001	0.000	0.0000
Benzene	71432	4.21E-06	4.31E-03	CATEF	0	0.0000	0.000	0.0000
Formaldehyde	50000	2.16E-04	2.21E-01	CATEF	0	0.0022	0.000	0.0000

Total FG Heater

Fuel Use Rate Data		
NG HHV	1000	btu/scf
Fuel Use Data		
Max Hourly Fuel Use	0.00977	mmscf
Annual Fuel Use	0.00	mmscf
Calculated Heat Rate Data		
Max Hourly Heat Rate	9.77	mmbtu
Annual Heat Rate	0.00	mmbtu