

DOCKETED

Docket Number:	15-RETI-02
Project Title:	Renewable Energy Transmission Initiative 2.0
TN #:	212495
Document Title:	Transmission Technical Input Group Update
Description:	N/A
Filer:	Eli Harland
Organization:	California Energy Commission
Submitter Role:	Commission Staff
Submission Date:	7/28/2016 3:18:56 PM
Docketed Date:	7/28/2016

Renewable Energy Transmission Initiative v2.0


Transmission Technical Input Group Update

TTIG Meeting
29 July, 2016

RETI Background

- Cooperative project of four state and one federal agency
- Statewide, non-regulatory planning effort to help meet statewide GHG and renewable energy goals.
- Explore combinations of renewable generation resources in California and throughout the West that can best meet goals
- Build understanding of transmission implications of renewable scenarios, and identify common transmission elements
- Identify land use and environmental opportunities and constraints to accessing these resources
- Accelerated, agency-driven, high-level assessment to inform future planning and regulatory proceedings

RETI 2.0 Process and Timeline



TTIG Background

Goals and Objectives:

The Transmission Technical Input Group will assemble relevant in-state and west-wide transmission capability and upgrade cost information to inform resource development conversations on the reasonably-needed transmission system implications and to assist in the developing potential corridor scenarios.

TTIG participants include all California Transmission Planning Entities

Sacramento Municipal Utility District	California Independent System Operator
Imperial Irrigation District	Los Angeles Department of Water and Power
Silicon Valley Power	Turlock Irrigation District
Modesto Irrigation District	Western Area Power Administration - SNR
San Francisco PUC	Transmission Agency of Northern California
City of Santa Clara	Pacific Gas & Electric
Southern California Edison	San Diego Gas & Electric

TTIG Deliverables Status

Identified Deliverables	Status
Characterize existing transmission system capacity and planned improvements/changes and their implications for accessing additional renewable resources	Interim Report June 9, 2016
Provide initial transmission input on likely in-state developments necessary to access potential renewable generation and refine the data as combinations of renewable resources are developed through other RETI groups' activities	Today
Provide planning level transmission cost estimates and any available information on environmental and other permitting issues for in-state requirements, using existing data to the greatest extent possible	Today
Compile transmission planning information on potential WECC-wide system reinforcements that may provide or improve access to renewable generation or to integration resources	WIEB outreach project; Aug-Sept
Work interactively with RETI Plenary Group to evaluate transmission implications for accessing potential renewable energy generation areas	Sept-Oct

Transmission Assessment Focus Area Map



Transmission Assessment Focus Areas

Study Ranges Hypothetical additions of new renewable resources	
Delivery Area or path	Study Range of New Capacity (MW)
Tehachapi	Up to 5000
Victorville/Barstow	Up to 5000
Riverside East	Up to 5000
Imperial Valley	Up to 5000
San Joaquin Valley	Up to 5000
Solano	1500-3000
Sacramento River Valley	1500-3000
Lassen / Round Mountain	1450-2450
Path 46 / Palo Verde / Delaney	Up to 3000
Path 46 / Eldorado / Marketplace	Up to 3000
Path 66 / California-Oregon Intertie	Up to 2000
Central/Northern Sierra (Path 76; Path 24; Path 52)	Up to 500

Methodology to Assess/Design Transmission for California Planning Areas


- Collaboration of affected Transmission Planning Areas for assessing TAFAs
- Transmission information from prior/existing studies and analyses
- Potential transmission upgrade information limited to *conceptual* transmission development identified in prior studies.
- Costs provided for conceptual mitigations are very *high-level* estimates

Note: The transmission implications were evaluated with an assumption of incremental resources with FCDS (Full Capacity Deliverability Status) because this assumption allowed us to look at conceptual upgrades which were based on FCDS studies. TTIG is not indicating a specific preference towards FCDS procurement in future.

Interaction Between TAFAs

Not all capacity from all transmission areas is simultaneously available

- Transmission capacity is dynamic – resources additions in one area may impact transmission availability in another area
- Mitigating a constraint that limits multiple TAFAs can benefit two or more renewable development areas
- The TAFAs capacity assumes all incremental MW in each area to be FCDS (for the purpose of identifying conceptual upgrades)
- Specific studies will be required to estimate impact of a mix of resources across TAFAs



Assessment Data

TAFAs assessments include the following information

Impacted transmission system(s)

Data sources used

Proposed TAFAs new capacity by technology (Solar/Wind/Geo)

Anticipated FC (Full Capacity)/EO (Energy Only) capacity (MW)

Current Interconnection Queue applications (for CAISO -through Cluster 8)

Existing Gen. in TAFAs


Planned upgrades impacting transfer capability estimates

Transmission implications (Next conceptual upgrades/observations)

Tehachapi

Impacted Transmission Planner/s	Data Sources	Proposed MW (Solar/Wind/Geo)	Anticipated FC/EO	Interconnection Queue (through C8)	Existing Gen. in TAFE	Planned Upgrades impacting Tx Capability estimates
CAISO	(1) CAISO cluster studies (2) CAISO TPP (3) CAISO RPS studies	4,500 / 500 / 0	4,500 / 5,600	~4490	~5,200	- TRTP - Whirlwind Substation expansion (In-service) - Whirlwind AA bank - Northern Area 500 kV SPS - Vincent SCD mitigation - All the TPP approved projects


- No major issues accommodating the prescribed amount of MW in this area
- Queued generation - high



Victorville/Barstow

Impacted Transmission Planner/s	Data Sources	Proposed MW (Solar/Wind/Geo)	Anticipated FC/EO	Interconnection Queue (through C8)	Existing Gen. in TAFA	Planned Upgrades impacting Tx Capability estimates
CAISO, LADWP	(1) LADWP generation queue (2) LADWP transmission projects mapped to queue info. (3) CAISO cluster studies (North of Lugo) (4) CAISO RPS studies	4500 / 500 / 0	<p><u>North of Lugo (NOL) Area:</u></p> <ul style="list-style-type: none"> ~1,000 MW in entire NOL, (Can only accommodate up to ~470 MW North of Kramer) ~400 MW behind Calcite - Lugo constraint (Pisgah area) <p><u>East of Lugo (EOL) Area:</u></p> <p>~5,500 MW to ~8,500 MW behind Lugo-Victorville 500 kV constraint (Eldorado area, and some parts of Riverside and Imperial)</p>	<p>(1) <u>NOL area:</u> ~1083 MW</p> <p>(2) <u>EOL area:</u> ~2,100 MW ~1000 MW at Marketplace 500kV bus (LADWP) would feed into Lugo (similar impact as EOL generation)</p> <p>(3) <u>LADWP area:</u> ~1724 MW at Intermountain 345kV Bus would feed into Adelanto ~1700 MW near Owens Valley</p>	<p>(1) <u>NOL area:</u> ~1,600 MW</p> <p>(2) <u>EOL area:</u> ~1,100 MW</p> <p>(3) <u>LADWP area:</u> ~250 MW</p>	<ul style="list-style-type: none"> Victorville-LA Basin Transmission System Upgrade (LADWP upgrade) Lugo-Eldorado and Lugo-Mohave 500 kV series capacitor upgrades Eldorado line re-route Lugo-Victorville SPS (only a partial mitigation)

- Victorville TAFA is a combination of several smaller generation rich areas such as North of Lugo and East of Lugo (Eldorado-Mtn Pass)
- Queued generation - high




Expected Transmission constraints and conceptual mitigations to Interconnect 5000 MW

Transmission Implications	Cost
North of Lugo Area	
(i) Lugo 500/230 kV banks constraint ==> Upgrade: A new 3rd AA bank at Lugo	~\$150 million
(ii) South of Kramer constraint ==> Upgrade: Coolwater-Lugo 220 kV transmission line	~\$480 million
(iii) Calcite-Lugo transfer constraint ==> Upgrade: Calcite - Lugo 220 kV segment of Coolwater - Lugo 500 kV line	~\$260 million
Assuming that at least 1,500 MW out of the prescribed range shows up in NOL, all these upgrades may be needed. The constraints and mitigations identified here address the Inyokern area resources assuming these resources will connect to SCE's North of Kramer system.	
Desert Area Constraint (East of Lugo, Riverside and Imperial)	
(i) Lugo-Victorville 500 kV overload for the N-1 of Lugo-Eldorado 500 kV and for N-2 of Lugo-Eldorado and Lugo-Mohave 500 kV lines ==> Upgrade: Lugo-Victorville 500 kV line (coordination between LADWP and CAISO underway). This upgrade will add > 2,000 MW transmission capability to the existing capability estimate in Riverside TAFE.	~\$34 million
(ii) The next likely constraint will be normal overloads on Devers – Red Bluff 500kV lines and Alberhill - Valley 500kV line ==> Upgrade: A new Mira Loma - Red Bluff 500 kV line	> \$1 billion

Riverside East

Impacted Transmission Planner/s	Data Sources	Proposed MW (Solar/Wind/Geo)	Anticipated FC/EO	Interconnection Queue (MW)	Existing Gen. in TAFE	Planned Upgrades impacting Tx Capability estimates
CAISO LADWP	(1) CAISO cluster studies (Riverside and Imperial) (2) CAISO RPS studies (3) IID generation interconnection studies (4) IID transmission capability estimates	2000-4000 / 500-1000 / 0	<u>Riverside:</u> ~800 MW / ~4,754 MW <u>East of Lugo, Riverside and Imperial:</u> ~5,500 MW to 8,500 MW behind Lugo-Victorville 500 kV constraint (Eldorado area, and some parts of Riverside and Imperial)	~6,000	~1,500	- WOD upgrades - Colorado River Corridor SPS - Red Bluff AA bank - Colorado River AA bank - Lugo - Eldorado upgrade - Lugo - Mohave upgrade - Eldorado 500kV line re-route

- Once West of Devers upgrades are in service, deliverability is limited by Lugo - Victorville constraint
- Queued generation - high



Expected Transmission constraints and conceptual mitigations to Interconnect 5000 MW


Transmission Implications	Cost
Desert Area Constraint (East of Lugo, Riverside and Imperial)	
(i) Lugo-Victorville 500 kV overload for the N-1 of Lugo-Eldorado 500 kV and for N-2 of Lugo-Eldorado and Lugo-Mohave 500 kV lines ==> Upgrade: Lugo-Victorville 500 kV line (coordination between LADWP and CAISO underway). This upgrade will add > 2,000 MW transmission capability to the existing capability estimate in Riverside TAFE.	~\$34 million
(ii) The next likely constraint will be normal overloads on Red Bluff - Devers 500kV lines and Valley - Alberhill 500kV line ==> Upgrade: A new Mira Loma - Red Bluff 500 kV line	> \$1 billion

Imperial Valley

Impacted Transmission Planner/s	Data Sources	Proposed MW (Solar/Wind/Geo)	Anticipated FC/EO	Interconnection Queue (MW)	Existing Gen. in TAFA	Planned Upgrades impacting Tx Capability estimates
CAISO						
Greater Imperial	(1) CAISO cluster studies (Riverside and Imperial) (2) CAISO RPS studies (3) IID generation interconnection studies (4) IID transmission capability estimates	3500 / 500 / 1000	<u>Imperial</u> : 523* MW / 1,829 MW <u>East of Lugo, Riverside and Imperial</u> : ~5,500 MW to 8,500 MW behind Lugo-Victorville 500 kV constraint (Eldorado area, and some parts of Riverside and Imperial)	~4375 (CAISO queue)	~2,200	- IV Phase shifting transformer - Sunrise/SWPL series capacitor bypass - Suncrest SVC - Sycamore-Penasquitos 230 kV line
Imperial Irrigation District						
IID North	(1) CAISO cluster studies (Imperial North) (2) IID RPS studies	1200/0/1000	1200/1400	1375/1000 (IID queue)		• Path 42 • West of Devers
IID South	(3) IID generation interconnection studies (4) IID transmission capability analysis	2300/ 500/ 0	200/370	3000/260		* IV Phase shifting transformer * Sunrise/SWPL series capacitor bypass * Suncrest SVC * Sycamore-Penasquitos 230 kV line

* This number is subject to change. IID has recently provided the ISO with new study assumptions regarding its system that will require further study. The ISO 2016-2017 Transmission Plan currently under development will take into account the latest system conditions and provide information regarding additional deliverability expected to be available for IID and ISO connected Imperial area generation.

- IID distinguishes Imperial North and South, while CAISO combines these areas as Greater Imperial
- Queued generation - high



Imperial Valley


Expected Transmission constraints and conceptual mitigations to Interconnect 5000 MW

Transmission Implication	Cost (\$ M)
CAISO	
Imperial area:	
East of Miguel constraint: Overload on Miguel 500/230 kV banks, ECO-Miguel 500 kV and Ocotillo-Suncrest 500 kV lines ==> Upgrade: New IV-Valley 500 kV line.	>\$2 Billion
Desert Area Constraint (East of Lugo, Riverside and Imperial)	
(i) Lugo-Victorville 500 kV overload for the N-1 of Lugo-Eldorado 500 kV and for N-2 of Lugo-Eldorado and Lugo-Mohave 500 kV lines ==> Upgrade: Lugo-Victorville 500 kV line (coordination between LADWP and CAISO underway). This upgrade will add > 2,000 MW transmission capability to the existing capability estimate in Riverside TAFE.	~\$34 million
(ii) The next likely constraint will be normal overloads on Red Bluff - Devers 500kV lines and Valley - Alberhill 500kV line ==> Upgrade: A new Mira Loma - Red Bluff 500 kV line	> \$1 billion
West of the River Constraint:	
Some prior studies have indicated that West of the River (Path 46) flows would approach the path rating and a path rating increase will have to be explored if enough renewable generation materializes.	
IID	
STEP 500 KV line from IID Midway to SCE Devers substation	\$350 Million

San Joaquin Valley

Impacted Transmission Planner/s	Data Sources	Proposed MW (Solar/Wind/Geo)	Anticipated FC/EO (MW)	Interconnection Queue (MW)	Existing Gen. in TAFE	Planned Upgrades impacting Tx Capability estimates
CAISO LADWP	(1) CAISO cluster studies (2) CAISO RPS studies (3) San Joaquin renewables study	5000 / 0 / 0	1823 / 3131	~3,500	~4,300 (Greater Fresno) ~3,500 (Kern area)	<ul style="list-style-type: none"> Warnerville - Wilson series reactor Gates 500/230 kV transformer Kearney - Herndon 230 kV reconductor

- At the prescribed level of generation in San Joaquin Valley, multiple 230 kV and local constraints were observed between Gates and Los Banos
- Queued generation - high



San Joaquin Valley


Expected Transmission constraints and conceptual mitigations to Interconnect 5000 MW

Transmission Implications	Cost
Fresno area constraints: Several overloads on the 230 kV system between Gates and Los Banos ==> Upgrade: Multiple upgrades between Gates and Los Banos (230 kV and below)	~\$440 million

Solano

Impacted Transmission Planner/s	Data Sources	Proposed MW (Solar/Wind/Geo)	Anticipated FC/EO (MW)	Interconnection Queue (MW)	Existing Gen. in TAFE	Planned Upgrades impacting Tx Capability estimates
CAISO	(1) CAISO RPS studies (2) CAISO cluster studies (2) CAISO TPP	500-1000 / 0 / 0	unknown / ~880 MW	~1100	~5,800	None at this time

- Smaller facilities may be able to interconnect to existing network with minor upgrades
- Queued generation - moderate




Expected Transmission constraints and conceptual mitigations to Interconnect 5000 MW

Transmission Implication	Cost
Smaller facilities may be able to interconnect to existing transmission network with minor upgrades	
Depending on size and specific location of the facilities, develop new 230-kV or 500 kV collector substation to interconnect facilities to the existing Vaca Dixon substation or Table Mountain-Tesla 500 kV line.	TBD

Sacramento River Valley

Impacted Transmission Planner/s	Data Sources	Proposed MW (Solar/Wind/Geo)	Anticipated FC/EO (MW)	Interconnection Queue (MW)	Existing Gen. in TAFE	Planned Upgrades impacting Tx Capability estimates
CAISO SMUD TANC	(1) CAISO TPP (2) TANC 10 Year Plan (3) Seasonal operating studies done by the OSS (4) CAISO RPS studies (5) CAISO cluster studies	500-1000 / 0 / 0	Unknown / ~2100 MW	~18	~980	None at this time


- Transmission capability estimate for FCDS resources in Sac River Valley is unknown at this point.
- Queued generation - low



Lassen / Round Mtn.

Impacted Transmission Planner/s	Data Sources	Proposed MW (Solar/Wind/Geo)	Anticipated FC/EO (MW)	Interconnection Queue (MW)	Existing Gen. in TAFE	Planned Upgrades impacting Tx Capacity estimates
CAISO SMUD TANC	(1) CAISO TPP (2) TANC 10 Year Plan (3) Seasonal operating studies done by the OSS (4) CAISO RPS studies (5) CAISO cluster studies	500-1000 / 500-1000 / 450	Unknown / ~1,250 MW	~200	~250	None at present

- Transmission capacity estimate for FCDS resources in Northern CA is unknown at this point.
- Import transfer capability on COI is reduced currently when the northern California hydro generation output is high, in the 80% range or higher
- Queued generation - low




Expected Transmission Upgrades Required to Interconnect 3,500 MW

Transmission Implication	Cost
<p>In the recent past there have not been many generation interconnection requests in these areas. However, planning level studies done by the CAISO and TANC have provided information on allowable COI flows/NorCal hydro levels similar to those from the operating studies. These studies have indicated that the allowable total of COI flows and hydro output would be less than 8,000 MW. (Operating Study Subcommittee 2016 nomogram studies)</p>	<p>\$2-4 billion</p> <p>(estimated costs for modifications to the existing 500-kV grid and for a 4th 500 kV line between the California/Oregon border area and the Tracy/Tesla area)</p>
<p>The CAISO's 50% special study results indicated that approximately 3,400 MW of EO resources could be accommodated in this area, if steps were taken to mitigate the impacts of a number of pre- and post-contingency overloads on 230-kV and lower voltage facilities and if the total of COI flows/hydro production was limited below the levels discussed above. While studies have not been done to quantify such limitations; COI + Northern CA hydro may have to be curtailed by ~3,000 MW.</p>	
<p>Additional generation in Northern California would likely drive the need for transmission development to maintain the import transfer capabilities on COI and the deliverability of existing hydro resources unless the new resources were EO resources and were curtailed as required. The extent of such upgrades would need to be determined</p>	

Import / Export Paths

- All imports will be subject to the transmission constraints of the TAFAs at their point of injection into the California grid
- Imports will compete with in-state resources for available transmission in respective TAFAs
- Export potential has not been looked at because we do not know enough about ability of neighboring system to absorb energy



TAFAs of Import / Export Paths

Delivery point or path	Potential MW	Affected TAFA
Eldorado/Mead/Marketplace	3000	Victorville (East of Lugo) and Riverside
Palo Verde/Delaney	3000	Riverside
California-Oregon Intertie / Path 66	2000	Northern CA (Round Mtn, Lassen and Sacramento R.)
Central/Northern Sierra (Path 76; Path 24; Path 52)	500	NA

TAFAs Evaluation Summary

TAFAs	Transmission Issues at the Prescribed Ranges	Basket of Conceptual Mitigations
Tehachapi	None	Current system can accommodate 5000 MW of FC/EO capacity
Victorville	Desert area constraint North of Lugo constraints	Coolwater – Lugo 220 kV line + Lugo 500/230 kV bank Lugo – Victorville 500 KV upgrade Red Bluff – Mira Loma 500 kV upgrade
Riverside	Desert area constraint	Lugo – Victorville 500 KV upgrade Red Bluff – Mira Loma 500 kV upgrade
Imperial	East of Miguel constraint Desert area constraint West of River constraint	IV – Valley 500 kV line STEP (Midway – Devers 500 kV) Lugo – Victorville 500 KV upgrade Red Bluff – Mira Loma 500 kV upgrade
San Joaquin Valley	Multiple 230 kV constraints	230 kV system upgrades and local upgrades between Gates and Los Banos
Solano	Lack of a collector station	A 230 kV or 500 kV collector station
Northern CA (Sac River Valley, Lassen, Rnd Mtn)	COI import constraint	A new 500 kV line between the California/Oregon border area and the Tracy/Tesla area

Regional outreach project

- Goal is to gather regional stakeholders' input about existing and potential transmission capability to deliver out-of-state renewable energy to California (and for California to deliver out-of-state)
- Western Interstate Energy Board is conducting a “regional consultation” to solicit input from non-California entities on expected renewable supply and demand patterns in the Western U.S. and identify transmission implications of renewable developments
- Target audience/participants are state officials, utilities, renewables and transmission developers, environmental and other advocates
- WIEB will host meetings in Portland in August and Las Vegas in September 2016. WIEB will write report summarizing input for presentation to RETI 2.0

Stakeholder discussion questions

1. Do you agree with the TAFE evaluations? including...
 1. Existing capacity
 2. Potential constraints
 3. Likely solutions
2. Please provide input on potential constraints and mitigations for combinations of TAFAs and import/export
 1. Northern California counties and the California-Oregon Intertie
 2. San Joaquin and the California “backbone” (paths 15 and 26)
 3. Victorville, Riverside, Imperial TAFAs and imports from Eldorado
 4. Victorville, Riverside, Imperial TAFAs and imports from Palo Verde
 5. Path 76 (Alturas line)