

DOCKETED

Docket Number:	16-AFC-01
Project Title:	Stanton Energy Reliability Center
TN #:	214207-13
Document Title:	Appendix 5.1B - Air Quality Impact Analysis Support Data
Description:	Application for Certification Vol. 2
Filer:	Sabrina Savala
Organization:	Stanton Energy Reliability Center, LLC
Submitter Role:	Applicant
Submission Date:	10/27/2016 10:23:29 AM
Docketed Date:	10/26/2016

Appendix 5.1B
Air Quality Impact Analysis Support
Data

Modeling Support Data

Tables presented in this Appendix are as follows:

5.1B-1	ASHRAE Climatology Summary for Fullerton Airport
5.1B-2	Air Monitoring Summary Data for 2013-2015
5.1B-3	Locations of SCAQMD AERMOD Meteorological Data
5.1B-4	Facility Impact/Modeling Results Summary
5.1B-5	Fumigation Modeling Results
5.1B-6	Deposition Modeling Results
5.1B-7	Construction Impact/Modeling Summary

In addition, this Appendix contains the following figures:

5.1B-1a-e	Annual and Quarterly Wind Roses
5.1B-2	Deposition Modeling for Seal Beach National Wildlife Refuge

Modeling input/output files are included in the enclosed CD's.

Figures showing the Facility BPIP Structures and the Coarse and Downwash Receptor Grids are contained in the main report in Section 5.1.

Table 5.1B-1 ASHRAE Climatology Summary for Fullerton Airport (2 pages)

FULLERTON MUNICIPAL, CA, USA

WMO#: 722976

Lat: 33.87N Long: 117.98W Elev: 95 StdP: 14.65 Time Zone: -8.00 (NAP) Period: 98-10 WBAN: 03166

Annual Heating and Humidification Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest month WS/MCDB				MCWS/PCWD to 99.6% DB	
			99.6%			99%			0.4%		1%			
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)
(1) 12	39.2	42.8	9.9	9.2	67.0	16.4	12.6	66.5	19.7	67.8	16.4	65.6	1.2	90

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(2) 8	19.2	93.4	67.0	90.6	66.8	88.0	66.7	72.4	86.5	71.0	84.3	69.7	82.3	6.7	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Hours 8 to 4 & 55/69
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(3) 67.6	101.7	79.6	65.9	95.8	78.1	64.3	90.4	75.0	36.1	86.6	34.7	84.1	33.6	83.1	1354

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Max WB	Extreme Annual DB				n-Year Return Period Values of Extreme DB							
1%		2.5%		Mean		Standard deviation		n=5 years		n=10 years		n=20 years		n=50 years	
1%	2.5%	5%		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(4) 12.9	11.0	10.2	81.5	34.9	102.7	2.8	4.5	32.8	105.9	31.2	108.5	29.6	111.0	27.6	114.3

Monthly Climatic Design Conditions

		Annual (d)	Jan (e)	Feb (f)	Mar (g)	Apr (h)	May (i)	Jun (j)	Jul (k)	Aug (l)	Sep (m)	Oct (n)	Nov (o)	Dec (p)	
(5)	Tavg	65.1	57.2	57.5	60.0	61.9	66.5	69.8	74.2	74.9	73.0	67.8	61.8	56.2	
(6)	Sd		5.18	4.57	4.97	5.25	4.20	3.80	3.85	3.93	4.77	4.73	5.06	4.28	
(7)	HDD50	9	3	1	1	0	0	0	0	0	0	0	0	4	
(8)	HDD65	1202	250	215	170	120	29	3	0	0	0	21	121	273	
(9)	CDD50	5522	226	210	311	358	510	594	751	772	689	551	353	197	
(10)	CDD65	1240	7	4	15	28	74	147	286	307	239	108	24	1	
(11)	CDH74	9455	184	138	242	408	505	773	1912	2195	1724	933	364	77	
(12)	CDH80	3475	38	41	77	181	183	220	651	836	716	394	130	8	
(13)	PrecAvg	13.2	3.1	2.6	2.0	1.3	0.3	0.1	0.0	0.1	0.3	0.3	1.6	1.8	
(14)	PrecMax	87.6	6.4	6.4	6.3	6.9	7.6	8.1	8.9	9.2	9.3	8.0	7.2	6.3	
(15)	PrecMin	73.0	4.2	0.4	0.0	0.1	0.0	6.5	0.1	6.3	6.3	6.1	5.4	3.9	
(16)	PrecSD	3.7	0.5	1.2	1.4	1.8	2.0	0.5	1.8	0.7	0.7	0.6	0.5	0.7	
(17)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	84.0	86.1	89.7	96.9	93.3	92.8	93.0	97.1	100.1	94.8	90.4	81.0
(18)		MCWB	56.7	56.5	60.6	59.6	62.8	69.1	70.4	69.4	68.8	64.7	60.2	56.0	
(19)	2%	DB	79.5	78.9	81.1	83.9	83.9	85.6	90.1	91.3	92.7	90.1	83.1	75.2	
(20)		MCWB	55.8	55.6	56.6	59.5	63.5	67.6	69.3	69.5	68.4	62.4	57.3	53.6	
(21)	5%	DB	73.4	72.6	74.6	77.2	79.4	81.4	87.5	88.4	88.3	83.8	77.4	71.9	
(22)		MCWB	53.4	54.0	56.3	58.5	62.9	66.3	69.7	69.3	67.9	61.5	55.9	52.8	
(23)	10%	DB	69.8	67.6	70.3	72.1	74.7	78.8	83.5	84.0	82.4	79.1	72.4	66.2	
(24)		MCWB	52.7	53.2	56.4	57.9	61.9	65.4	68.8	68.8	67.1	62.0	56.4	51.5	
(25)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	61.4	61.2	64.1	65.0	68.6	70.9	74.5	74.1	73.8	70.9	63.6	60.4
(26)		MCDB	73.9	77.3	78.9	80.4	81.5	87.0	88.9	90.1	90.0	84.3	74.0	70.0	
(27)	2%	WB	58.9	58.7	61.2	62.2	65.9	68.9	72.2	72.0	71.6	67.5	61.9	58.3	
(28)		MCDB	67.8	69.2	72.8	76.8	78.3	82.9	84.7	86.8	85.6	79.3	73.4	65.6	
(29)	5%	WB	57.2	57.2	59.4	60.2	64.3	67.4	70.8	70.7	69.9	65.4	60.3	56.9	
(30)		MCDB	65.9	66.1	69.0	73.2	75.9	79.8	82.6	84.5	82.7	75.8	70.7	64.0	
(31)	10%	WB	55.6	55.8	57.7	58.5	62.5	65.9	69.3	69.3	68.5	63.9	59.1	55.5	
(32)		MCDB	64.5	63.8	66.5	69.3	72.4	76.9	80.7	82.1	80.7	72.5	68.2	62.3	

Table 5.1B-1 ASHRAE Climatology Summary for Fullerton Airport (2 pages)

FULLERTON MUNICIPAL, CA, USA

WMO#: **722976**

Lat: **33.87N** Long: **117.98W** Elev: **95** StdP: **14.65** Time Zone: **-8.00 (NAP)** Period: **98-10** WBAN: **03166**

(33)	Mean Daily Temperature Range	MDBR	21.6	19.4	18.7	18.1	16.3	15.7	17.8	19.2	19.7	19.8	21.7	21.5	
(34)		5% DB	MCDBR	31.3	30.3	29.0	30.5	25.9	21.5	23.1	25.7	28.7	32.1	31.7	30.9
(35)			MCWBR	13.6	13.3	12.2	12.3	10.4	8.4	8.1	9.2	10.4	12.3	12.5	14.2
(36)		5% WB	MCDBR	21.8	21.0	20.7	22.8	19.6	20.0	20.1	21.8	22.7	21.8	22.3	20.6
(37)	MCWBR		11.3	10.9	10.3	10.5	8.8	8.4	7.8	8.7	9.2	10.2	10.9	11.6	
(38)	Clear Sky Solar Irradiance	taub	0.334	0.345	0.338	0.326	0.338	0.336	0.350	0.361	0.347	0.360	0.333	0.331	
(39)		taud	2.624	2.545	2.524	2.495	2.431	2.423	2.411	2.428	2.519	2.479	2.610	2.613	
(40)		Ebn,noon	280	287	298	305	300	299	294	290	291	277	278	274	
(41)		Edh,noon	24	29	32	34	37	37	37	36	31	30	24	23	

Nomenclature: See separate page

Nomenclature - Tables of Climatic Design Conditions

CDD _n	Cooling degree-days base n°F, °F-day
CDH _n	Cooling degree-hours base n°F, °F-hour
DB	Dry bulb temperature, °F
DP	Dew point temperature, °F
Ebn,noon	Clear sky beam normal irradiances at solar noon, Btu/h/ft ²
Edh,noon	Clear sky diffuse horizontal irradiance at solar noon, Btu/h/ft ²
Elev	Elevation, ft
Enth	Enthalpy, Btu/lb
HDD _n	Heating degree-days base n°F, °F-day
Hours 8/4 & 55/69	Number of hours between 8 a.m. and 4 p.m. with DB between 55 and 69 °F
HR	Humidity ratio, grains of moisture per lb of dry air
Lat	Latitude, °
Long	Longitude, °
MCDB	Mean coincident dry bulb temperature, °F
MCDBR	Mean coincident dry bulb temp. range, °F
MCDP	Mean coincident dew point temperature, °F
MCWB	Mean coincident wet bulb temperature, °F
MCWBR	Mean coincident wet bulb temp. range, °F
MCWS	Mean coincident wind speed, mph
MDBR	Mean dry bulb temp. range, °F
PCWD	Prevailing coincident wind direction, °, 0 = North, 90 = East
Period	Years used to calculate the design conditions
PrecAvg	Average precipitation, in
PrecSD	Standard deviation of precipitation, in
PrecMin	Minimum precipitation, in
PrecMax	Maximum precipitation, in
Sd	Standard deviation of daily average temperature, °F
StdP	Standard pressure at station elevation, psi
taub	Clear sky optical depth for beam irradiance
taud	Clear sky optical depth for diffuse irradiance
Tavg	Average temperature, °F
Time Zone	Hours ahead or behind UTC, and time zone code
WB	Wet bulb temperature, °F
WBAN	Weather Bureau Army Navy number
WMO#	Station identifier from the World Meteorological Organization
WS	Wind speed, mph

Numbers (1) to (41) and letters (a) to (p) are row and column references to quickly point to an element in the table.

For example the 5% design wet bulb temperature for July can be found in row (29), column (k).

Table 5.1B-2 SERC Background Air Quality Values for 2013-2015 (3 Pages)

Historical Monitored Air Quality Values

Pollutant	Units	Avg Time	Station	2013	2014	2015	Pollutant	Units	Avg Time	Station	2013	2014	2015
Ozone	ppm	1-Hr State	Anaheim	0.084	0.111	0.100	NO2	ppm	1-Hr State	Anaheim 1	0.081	0.075	0.059
			Costa Mesa	0.095	0.096	0.099				Anaheim 2	nd	0.078	0.070
						Costa Mesa				0.075	0.060	0.052	
	ppm	8-Hr State	Anaheim	0.070	0.082	0.081		AAM-State	Anaheim 1	nd	nd	0.014	
			Costa Mesa	0.084	0.080	0.080			Anaheim 2	nd	0.027	0.025	
						Costa Mesa			nd	0.010	0.011		
ppm	8-Hr Federal 4th High	Anaheim	0.063	0.076	0.065	1-Hr Federal 98th %	Anaheim 1	0.0587	0.0598	0.0546			
		Costa Mesa	0.065	0.076	0.068		Anaheim 2	nd	0.0660	0.0614			
						AAM-Federal	Anaheim 1	0.017	0.015	0.015			
							Anaheim 2	nd	0.027	0.025			
							Costa Mesa	0.011	0.011	0.012			

Data Sources: CARB iADAM website, 2016
EPA AIRS website, 2016

All Values Taken from CARB iADAM Website

1. CAAQS background is the highest value in the 3 year period.
2. NAAQS background is the 3 year avg of the 4th high 8 hr values.

Background Values:	ppm	ug/m3	
1-Hr State	0.111	222.0	Anaheim (2014)
8-Hr State	0.084	164.4	CostaMesa (2013)
8-Hr Fed	0.070	137.2	CostaMesa (Avg)

AAM = annual arithmetic mean.

12-Oct-16

All Values Taken from CARB iADAM Website

1. CAAQS background is the highest value in the 3 year period.
2. NAAQS background for 1 hr is the 3 year avg of the 1 hr 98th percentile values.
3. NAAQS background for annual is highest value in the 3 yr period

Background Values:	ppm	ug/m3	
1-Hr State	0.081	152.6	Anaheim1 (2013)
AAM-State	0.027	51.3	Anaheim2 (2014) - Used AAM Fed
1-Hr Fed	0.0620	116.6	An1 (2013) + An2 (2014-15) Avg.
AAM Fed	0.027	50.9	Anaheim2 (2014)

Historical Monitored Air Quality Values

Pollutant	Units	Avg Time	Station	2013	2014	2015
CO	ppm	1-Hr State	Anaheim1	3.4	3.1	3.1
			Anaheim2	nd	nd	3.1
			Costa Mesa	2.4	2.7	3.0
	ppm	8-Hr State	Anaheim1	2.6	2.1	2.2
			Anaheim2	nd	nd	2.3
			Costa Mesa	2.0	1.9	2.2
	ppm	1-Hr Federal	Anaheim1	3.3	2.6	2.6
			Anaheim2	nd	nd	2.9
	ppm	2nd High	Anaheim1	2.4	2.1	2.0
			Costa Mesa	2.4	2.2	2.6
ppm	8-Hr Federal	Anaheim1	2.4	2.1	2.0	
		Anaheim2	nd	nd	2.3	
ppm	2nd High	Anaheim1	1.7	1.6	1.8	
		Costa Mesa	1.7	1.6	1.8	

Pollutant	Units	Avg Time	Station	2013	2014	2015	
SO2	ppm	1-Hr State	Costa Mesa	0.0041	0.0088	0.0045	
			24-Hr State/Fed (only H2H Available)	Costa Mesa	0.0012	0.0014	0.0011
				Costa Mesa	0.003	0.004	0.003
	ppm	1-Hr Federal 99th %	Costa Mesa	0.00022	0.00031	0.00013	
			Annual Mean Federal	Costa Mesa	0.00022	0.00031	0.00013

All Values Taken from EPA AirData Website

1. CAAQS background is the highest value in the 3 year period.
2. NAAQS background is the highest of the 2nd highs

Background Values:	ppm	ug/m3	
1-Hr State	3.4	3910.0	Anaheim1 (2013)
8-Hr State	2.6	2888.9	Anaheim1 (2013)
1-Hr Fed	3.3	3795.0	Anaheim1 (2013)
8-Hr Fed	2.4	2666.7	Anaheim1 (2013)

Used Maximum State Values for both CAAQS/NAAQS assessments

All Values Taken from EPA AirData Website

1. CAAQS background is the highest value in the 3 year period.
2. NAAQS background is the 3 year avg of the 1 hr 99th % values.
3. NAAQS 3 hr background not available - used 1-hour Max
4. NAAQS background for annual is highest value in the 3 yr period

Background Values:	ppm	ug/m3	
1-Hr State	0.0088	23.1	CostaMesa (2014)
24-Hr State/Fed	0.0014	3.7	CostaMesa (2014)/H2H
1-Hr Fed	0.0033	8.6	CostaMesa - Used 1-hr State
AAM-Fed	0.00031	0.8	CostaMesa (2014)

Used Maximum State Value for both CAAQS/NAAQS 1-hour SO2 assessments

Historical Monitored Air Quality Values

Pollutant	Units	Avg Time	Station	2013	2014	2015
PM10	ug/m3	AAM-State	Anaheim	77	84	59
			24-Hr State			
			Anaheim	25.2	26.7	25.3
			24-Hr Federal 2nd High	46	58	57

Pollutant	Units	Avg Time	Station	2013	2014	2015
PM2.5	ug/m3	24-Hr Federal 98th %	Anaheim	10.1	16.1	14.8
			AAM-State			
			Anaheim	23	30	30
			AAM-Federal	10.1	10.5	9.4

All Values Taken from CARB iADAM Website

1. annual refers to "arithmetic means".
2. CAAQS background is the highest value in the 3 year period.
3. NAAQS 24 hr background is the highest of the 2nd highs

Background Values:	ug/m3	
24-Hr State	84.0	Anaheim (2014)
AAM-State	26.7	Anaheim (2014)
24-Hr Fed	58.0	Anaheim (2014)

AAM-State from CARB iADAM, 24-hr/AAM-Federal from EPA AirData

1. annual refers to "arithmetic means".
2. CAAQS background is the highest value in the 3 year period.
3. NAAQS 24 hr background is the 3 year avg of the 24 hr 98th percentile values.
4. NAAQS annual background is the 3 year avg of the AAMs.

Background Values:	ug/m3	
AAM-State	16.1	Anaheim (2014) - Used Max AAM-Fed
24-Hr Fed	27.7	Anaheim (Avg)
AAM-Fed	10.0	Anaheim (Avg)

Used Maximum Federal Value for CAAQS Annual PM2.5 assessments (10.5 ug/m3)

Table 5.1B-3 Locations of SCAQMD AERMOD Meteorological Data* (1 page)

Station	Latitude/Longitude		UTM Coordinates		Elevation (m)	Dist. From Project (km)	Direction From Project (deg)	
	Latitude	Longitude	Easting (km)	Northing (km)				
Anaheim	33:49:50	117:56:19	413.14	3743.57	41	5.001	61.6	ENE
La Habra	33:55:31	117:57:08	411.98	3754.08	82	13.291	14.1	NNE
Costa Mesa	33:40:26	117:55:33	414.16	3726.19	20	15.948	160.1	SSE
Long Beach	33:49:25	118:11:19	389.99	3743.04	30	18.843	275.6	W
Compton	33:54:05	118:12:18	388.59	3751.88	22	22.812	297.9	WNW
Pico Rivera	34:00:37	118:04:07	401.31	3763.61	58	23.621	341.7	NNW
Lynnwood	33:55:44	118:12:39	388.07	3754.73	29	24.712	303.2	WNW
Mission Viejo	33:37:49	117:40:30	437.39	3721.17	170	34.950	124.9	SE
Pomona	34:04:00	117:45:00	430.78	3769.61	270	35.964	37.8	NE
Central LA	34:03:59	118:13:36	386.79	3770.00	87	36.221	322.7	NW
Azusa	34:08:11	117:55:26	414.81	3777.47	182	36.785	9.5	N
LAX	33:57:15	118:25:49	367.83	3757.80	42	44.156	292.1	WNW
Upland	34:06:14	117:37:45	441.96	3773.66	379	46.452	45.7	NE
Burbank	34:10:33	118:19:01	378.62	3782.24	175	50.917	323.7	NW
West LA	34:03:02	118:27:24	365.54	3768.52	97	51.121	302.3	WNW
Fontana	34:06:01	117:29:31	454.62	3773.19	367	55.936	55.1	NE
Riverside	34:00:02	117:24:55	461.64	3762.10	250	56.881	68.4	ENE
Lake Elsinore	33:40:35	117:19:51	469.33	3726.13	406	62.431	104.0	ESE
Reseda	34:11:57	118:31:58	358.76	3785.11	228	66.538	311.3	NW
Perris	33:47:20	117:13:40	478.91	3738.58	442	70.216	92.1	E
San Bernardino	34:06:24	117:16:25	474.76	3773.82	305	73.642	63.7	ENE
Santa Clarita	34:23:00	118:31:42	359.48	3805.52	375	81.026	322.6	NW
Crestline	34:14:29	117:16:32	474.62	3788.76	1387	81.258	54.2	NE
Redlands	34:03:32	117:08:52	486.36	3768.50	481	82.283	70.6	ENE
Banning Airport	33:55:15	116:51:30	513.10	3753.19	660	105.046	83.4	E
Palm Springs	33:51:10	116:32:28	542.46	3745.73	171	133.795	88.1	E
Indio	33:42:30	116:12:57	572.67	3729.90	-4	164.316	93.9	E
SERC Project Site	33:48:25	117:59:10	408.742	3741.189	21			

Locations of SCAQMD AERMOD Meteorological Data likely correspond to SCAQMD Air Quality (AQ) Monitoring Sites, which would include one of the Anaheim AQ monitoring sites and the Costa Mesa AQ monitoring site used for background air quality in this report.

Table 5.1B-4 Facility Impact/Model Results Summary (2 pages)

Stack Ht= 70.7' above grade elevation of 72' amsl = 21.549m & 21.946m

Stanton 2x0
Combustion Turbine AERMOD Screening Analysis



		Hot Ambient Conditions			Average Ambient Conditions			Cold Ambient Conditions		
		Case 100	Case 101	Case 102	Case 103	Case 104	Case 105	Case 106	Case 107	Case 108
		Base	Mid	Min	Base	Mid	Min	Base	Mid	Min
Operating Conditions										
Ambient Dry Bulb Temp.	deg. F	102.7	102.7	102.7	65.0	65.0	65.0	40.0	40.0	40.0
Combustion Turbine Load	%	100%	50%	21%	100%	50%	21%	100%	50%	20%
Evap Cooling or Fogging? (Yes/No)		Yes	No	No	Yes	No	No	No	No	No
Performance Water Injection? (Yes/No)		Yes	No	No	Yes	No	No	Yes	No	No
Stack Exhaust Analysis (each CT)										
Stack Temperature	deg. F	847.69	816.23	813.37	839.13	751.91	721.22	826.85	701.10	662.16
Stack Temperature	deg. K	726.31	708.83	707.24	721.56	673.10	656.05	714.73	644.87	623.24
Stack Flow	cf/hr	35,718,000	26,008,000	19,857,000	36,414,000	26,419,000	19,811,000	37,197,000	26,916,000	19,936,000
Effective Stack Diameter	feet	12.036	12.036	12.036	12.036	12.036	12.036	12.036	12.036	12.036
Effective Stack Diameter	meters	3.6698	3.6698	3.6698	3.6698	3.6698	3.6698	3.6698	3.6698	3.6698
Calc'd Stack Velocity	ft/sec	87.203	63.497	48.479	88.902	64.500	48.367	90.814	65.713	48.672
Calc'd Stack Velocity	m/sec	26.579	19.354	14.776	27.097	19.660	14.742	27.680	20.029	14.835
Initial Stack Buoyancy Flux	m4/s3	500.26	357.40	272.50	533.52	368.15	270.52	559.14	376.80	271.82
AERMOD Results for Grade Elevation (72.0'amsl)= Base Elevation										
1-Hour Maximum Impacts	Conc(ug/m3)	2.77323	3.85047	8.92608	2.72261	3.90582	8.76243	2.67117	3.94542	9.15561
(ug/m3 for 1 g/s/turbine)	UTM-X(m)	408960.00	408960.00	409040.00	408960.00	408960.00	409040.00	408960.00	408980.00	409040.00
	UTM-Y(m)	3741320.00	3741320.00	3741140.00	3741320.00	3741320.00	3741200.00	3741320.00	3741240.00	3741200.00
	Elev(m)	22.01	22.01	22.01	22.01	22.01	22.01	22.01	21.97	22.01
	Period	09062911	09062911	08031516	09062911	09062911	12031814	09062911	12040813	12031814
Max 5-Yr Avg/1-Hr Max Daily Yearly Impacts for NO2 NAAQS SIL	Conc(ug/m3)	2.50346	3.53104	4.63626	2.45958	3.58690	4.81286	2.41503	3.62081	4.93696
(ug/m3 for 1 g/s/turbine)	UTM-X(m)	408560.00	408560.00	409020.00	408560.00	408560.00	409040.00	408560.00	408560.00	409040.00
	UTM-Y(m)	3741100.00	3741100.00	3741140.00	3741100.00	3741100.00	3741180.00	3741100.00	3741100.00	3741180.00
	Elev(m)	21.97	21.97	22.01	21.97	21.97	22.01	21.97	21.97	22.01
Max 5-Yr Avg/1-Hr 98th% Yearly Impacts for NO2 NAAQS	Conc(ug/m3)	1.78130	2.55096	3.38811	1.75241	2.59655	3.55993	1.72296	2.62741	3.66381
(ug/m3 for 1 g/s/turbine)	UTM-X(m)	408480.00	408580.00	408580.00	408480.00	408580.00	408580.00	408480.00	408580.00	408580.00
	UTM-Y(m)	3741060.00	3741060.00	3741060.00	3741060.00	3741060.00	3741060.00	3741060.00	3741060.00	3741060.00
	Elev(m)	20.90	22.01	22.01	20.90	22.01	22.01	20.90	22.01	22.01
3-Hour Maximum Impacts	Conc(ug/m3)	2.39391	3.22393	4.84896	2.35836	3.26722	5.43071	2.32221	3.29269	5.57162
(ug/m3 for 1 g/s/turbine)	UTM-X(m)	408480.00	408500.00	409080.00	408480.00	408500.00	409060.00	408480.00	408500.00	409060.00
	UTM-Y(m)	3741120.00	3741120.00	3741220.00	3741120.00	3741120.00	3741220.00	3741120.00	3741120.00	3741220.00
	Elev(m)	21.35	21.40	22.01	21.35	21.40	22.01	21.35	21.40	22.01
	Period	06012412	06012412	12031815	06012412	06012412	12031815	06012412	06012412	12031815
8-Hour Maximum Impacts	Conc(ug/m3)	1.57576	2.20306	2.83186	1.54952	2.24065	2.97724	1.52281	2.26462	3.05729
(ug/m3 for 1 g/s/turbine)	UTM-X(m)	408500.00	408520.00	408540.00	408500.00	408520.00	409100.00	408500.00	408520.00	408560.00
	UTM-Y(m)	3740980.00	3741000.00	3741000.00	3740980.00	3741000.00	3741240.00	3740980.00	3741000.00	3741020.00
	Elev(m)	19.88	20.25	20.33	19.88	20.25	22.01	19.88	20.25	21.21
	Period	06020616	06020616	06020616	06020616	06020616	12031816	06020616	06020616	06020616
24-Hour Maximum Impacts for CAAQS and PM10 NAAQS	Conc(ug/m3)	0.56590	0.84038	1.21636	0.55707	0.86532	1.30520	0.54827	0.88287	1.36124
(ug/m3 for 1 g/s/turbine)	UTM-X(m)	408340.00	408220.00	408280.00	408340.00	408220.00	408320.00	408360.00	408220.00	408320.00
	UTM-Y(m)	3740960.00	3740960.00	3740980.00	3740960.00	3740960.00	3741000.00	3741040.00	3740960.00	3741000.00
	Elev(m)	20.48	20.48	20.48	20.48	20.48	20.64	20.63	20.48	20.64
	Period	06112924	07102224	07102224	06112924	07102224	07102224	06120324	07102224	07102224
Max 5-Year Avg/24-Hr Max Yearly Impacts for PM25 NAAQS SIL	Conc(ug/m3)	0.49623	0.73039	0.97312	0.48866	0.74499	1.02875	0.48104	0.75444	1.06394
(ug/m3 for 1 g/s/turbine)	UTM-X(m)	408400.00	408960.00	408960.00	408400.00	408960.00	408960.00	408400.00	408960.00	408960.00
	UTM-Y(m)	3741040.00	3741360.00	3741340.00	3741040.00	3741360.00	3741340.00	3741040.00	3741360.00	3741340.00
	Elev(m)	20.47	22.01	22.01	20.47	22.01	22.01	20.47	22.01	22.01
Max 5-Year Avg/24-Hr 98th% Yearly Impacts for PM25 NAAQS	Conc(ug/m3)	0.41136	0.61414	0.83049	0.40336	0.62774	0.88071	0.39542	0.63664	0.91302
(ug/m3 for 1 g/s/turbine)	UTM-X(m)	408980.00	408980.00	408980.00	408980.00	408980.00	408960.00	408980.00	408980.00	408960.00
	UTM-Y(m)	3741360.00	3741340.00	3741340.00	3741360.00	3741340.00	3741320.00	3741360.00	3741340.00	3741320.00
	Elev(m)	22.01	22.01	22.01	22.01	22.01	22.01	22.01	22.01	22.01
Annual Maximum Impacts for CAAQS and NO2/SO2/PM10 NAAQS	Conc(ug/m3)	0.20153	0.29759	0.40126	0.19780	0.30395	0.42535	0.19409	0.30815	0.44077
(ug/m3 for 1 g/s/turbine)	UTM-X(m)	409020.00	409000.00	409000.00	409020.00	409000.00	409000.00	409020.00	409000.00	409000.00
	UTM-Y(m)	3741360.00	3741340.00	3741340.00	3741360.00	3741340.00	3741340.00	3741360.00	3741340.00	3741340.00
	Elev(m)	22.01	22.01	22.01	22.01	22.01	22.01	22.01	22.01	22.01
	Period	06123124	06123124	06123124	06123124	06123124	06123124	06123124	06123124	06123124
Max 5-Year Avg/Annual Impacts for PM25 NAAQS & SIL	Conc(ug/m3)	0.18504	0.27238	0.36686	0.18161	0.27813	0.38881	0.17819	0.28192	0.40278
(ug/m3 for 1 g/s/turbine)	UTM-X(m)	409000.00	409000.00	408980.00	409000.00	409000.00	408980.00	409000.00	409000.00	408980.00
	UTM-Y(m)	3741360.00	3741360.00	3741340.00	3741360.00	3741360.00	3741340.00	3741360.00	3741360.00	3741340.00
	Elev(m)	22.01	22.01	22.01	22.01	22.01	22.01	22.01	22.01	22.01
Permitted Short-Term Stack Emissions (each CT) - Normal Ops										
NO _x , @ 15% O ₂	ppmvd	2.5	2.5	2.5	2.5	2.5	2.5	2.5	2.5	2.5
CO, @ 15% O ₂	ppmvd	4.0	4.0	4.0	4.0	4.0	4.0	4.0	4.0	4.0
VOC, as CH ₄ @ 15% O ₂	ppmvd	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
NH ₃ Slip, @ 15% O ₂	ppmvd	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0
NO _x , as NO ₂	lb/hr	4.151	2.505	1.670	4.297	2.547	1.634	4.459	2.612	1.640
CO	lb/hr	4.044	2.441	1.627	4.186	2.482	1.592	4.344	2.544	1.598
VOC, as CH ₄	lb/hr	0.579	0.350	0.233	0.599	0.355	0.228	0.622	0.364	0.229
Maximum Total PM ₁₀	lb/hr	3.000	3.000	3.000	3.000	3.000	3.000	3.000	3.000	3.000
Annual Average Total PM ₁₀	lb/hr	1.870	1.140	0.760	1.930	1.160	0.750	2.000	1.190	0.750
NH ₃	lb/hr	3.073	1.855	1.237	3.181	1.886	1.210	3.302	1.934	1.214
Maximum SO ₂	lb/hr	0.954	0.578	0.389	0.986	0.590	0.382	1.019	0.606	0.384
Annual Average SO ₂	lb/hr	0.318	0.193	0.130	0.329	0.197	0.127	0.340	0.202	0.128
NO _x , as NO ₂	g/s/turbine	0.5230	0.3156	0.2104	0.5414	0.3209	0.2059	0.5618	0.3291	0.2066
CO	g/s/turbine	0.5095	0.3076	0.2050	0.5274	0.3127	0.2006	0.5473	0.3205	0.2013
Maximum Total PM ₁₀	g/s/turbine	0.3780	0.3780	0.3780	0.3780	0.3780	0.3780	0.3780	0.3780	0.3780
Annual Average Total PM ₁₀	g/s/turbine	0.2356	0.1436	0.0958	0.2432	0.1462	0.0945	0.2520	0.1499	0.0945
Maximum SO ₂	g/s/turbine	0.1202	0.0728	0.0490	0.1242	0.0743	0.0481	0.1284	0.0764	0.0484
Annual Average SO ₂	g/s/turbine	0.0401	0.0243	0.0164	0.0415	0.0248	0.0160	0.0428	0.0255	0.0161

Table 5.1B-4 Facility Impact/Model Results Summary (2 pages)

Stack Ht= 70.7' above grade elevation of 72' amsl = 21.549m & 21.946m

Stanton 2x0
Combustion Turbine AERMOD Screening Analysis



		Hot Ambient Conditions			Average Ambient Conditions			Cold Ambient Conditions		
		Case 100	Case 101	Case 102	Case 103	Case 104	Case 105	Case 106	Case 107	Case 108
		Base	Mid	Min	Base	Mid	Min	Base	Mid	Min
Short-Term Pollutant Impacts (ug/m³) - Normal Operations										
1-hour NO _x CAAQS	Conc(ug/m ³)	1.45040	1.21521	1.87805	1.47402	1.25338	1.80418	1.50066	1.29844	1.89155
1-hour NO _x NAAQS SIL	Conc(ug/m ³)	1.30931	1.11440	0.97547	1.33162	1.15104	0.99097	1.35676	1.19161	1.01998
1-hour NO _x NAAQS	Conc(ug/m ³)	0.93162	0.80508	0.71286	0.94875	0.83323	0.73299	0.96796	0.86468	0.75694
1-hour NO ₂ CAAQS	Conc(ug/m ³)	1.16032	0.97217	1.50244	1.17922	1.00270	1.44335	1.20053	1.03875	1.51324
1-hour NO ₂ NAAQS SIL	Conc(ug/m ³)	1.04745	0.89152	0.78038	1.06529	0.92083	0.79277	1.08541	0.95329	0.81598
1-hour NO ₂ NAAQS	Conc(ug/m ³)	0.74530	0.64407	0.57029	0.75900	0.66659	0.58639	0.77437	0.69174	0.60555
Annual NO _x	Conc(ug/m ³)	0.10540	0.09392	0.08443	0.10709	0.09754	0.08758	0.10904	0.10141	0.09106
Annual NO ₂	Conc(ug/m ³)	0.07905	0.07044	0.06332	0.08032	0.07315	0.06568	0.08178	0.07606	0.06830
1-hour CO	Conc(ug/m ³)	1.41296	1.18440	1.82985	1.43590	1.22135	1.75774	1.46193	1.26451	1.84302
8-hour CO	Conc(ug/m ³)	0.80285	0.67766	0.58053	0.81722	0.70065	0.59723	0.83343	0.72581	0.61543
24-hour PM _{2.5} CAAQS & PM ₁₀	Conc(ug/m ³)	0.21391	0.31766	0.45978	0.21057	0.32709	0.49337	0.20725	0.33372	0.51455
24-hour PM _{2.5} NAAQS SIL	Conc(ug/m ³)	0.18757	0.27609	0.36784	0.18471	0.28161	0.38887	0.18183	0.28518	0.40217
24-hour PM _{2.5} NAAQS	Conc(ug/m ³)	0.15549	0.23214	0.31393	0.15247	0.23729	0.33291	0.14947	0.24065	0.34512
Annual PM _{2.5} /PM ₁₀	Conc(ug/m ³)	0.04748	0.04273	0.03844	0.04810	0.04444	0.04020	0.04891	0.04619	0.04165
5-year PM _{2.5}	Conc(ug/m ³)	0.04360	0.03911	0.03515	0.04417	0.04066	0.03674	0.04490	0.04226	0.03806
1-hour SO ₂	Conc(ug/m ³)	0.33334	0.28031	0.43738	0.33815	0.29020	0.42147	0.34298	0.30143	0.44313
3-hour SO ₂	Conc(ug/m ³)	0.28775	0.23470	0.23760	0.29291	0.24275	0.26122	0.29817	0.25156	0.26967
24-hour SO ₂	Conc(ug/m ³)	0.06802	0.06118	0.05960	0.06919	0.06429	0.06278	0.07040	0.06745	0.06588
Annual SO ₂	Conc(ug/m ³)	0.00808	0.00723	0.00658	0.00821	0.00754	0.00681	0.00831	0.00786	0.00710
Permitted Stack Emissions (each CT) - Startup/Shutdown Conditions										
1-hour NO _x , as NO ₂	lb/hr	6.68	6.68	6.68	6.68	6.68	6.68	6.68	6.68	6.68
1-hour CO	lb/hr	13.23	13.23	13.23	13.23	13.23	13.23	13.23	13.23	13.23
8-hour CO	lb/hr	7.68	7.68	7.68	7.68	7.68	7.68	7.68	7.68	7.68
1-hour NO _x , as NO ₂	g/s/turbine	0.8417	0.8417	0.8417	0.8417	0.8417	0.8417	0.8417	0.8417	0.8417
1-hour CO	g/s/turbine	1.6670	1.6670	1.6670	1.6670	1.6670	1.6670	1.6670	1.6670	1.6670
8-hour CO	g/s/turbine	0.9677	0.9677	0.9677	0.9677	0.9677	0.9677	0.9677	0.9677	0.9677
Pollutant Impacts (ug/m³) - Startup/Shutdown Conditions										
1-hour NO _x CAAQS	Conc(ug/m ³)	2.33423	3.24094	7.51308	2.29162	3.28753	7.37534	2.24832	3.32086	7.70628
1-hour NO _x NAAQS SIL	Conc(ug/m ³)	2.10716	2.97208	3.90234	2.07023	3.01909	4.05098	2.03273	3.04764	4.15544
1-hour NO _x NAAQS	Conc(ug/m ³)	1.49932	2.14714	2.85177	1.47500	2.18552	2.99639	1.45022	2.21149	3.08383
1-hour NO ₂ CAAQS	Conc(ug/m ³)	1.86738	2.59275	6.01047	1.83330	2.63002	5.90027	1.79866	2.65669	6.16502
1-hour NO ₂ NAAQS SIL	Conc(ug/m ³)	1.68573	2.37766	3.12187	1.65618	2.41527	3.24079	1.62618	2.43811	3.32435
1-hour NO ₂ NAAQS	Conc(ug/m ³)	1.19946	1.71771	2.28142	1.18000	1.74841	2.39711	1.16017	1.76919	2.46706
1-hour CO	Conc(ug/m ³)	4.62297	6.41873	14.87978	4.53859	6.51100	14.60697	4.45284	6.57702	15.26240
8-hour CO	Conc(ug/m ³)	1.52486	2.13190	2.74039	1.49947	2.16828	2.88108	1.47362	2.19147	2.95854
Permitted Stack Emissions (each CT) - Annual Totals										
Annual NO _x , as NO ₂ (total, both turbines)	tons/year	3.89	3.89	3.89	3.89	3.89	3.89	3.89	3.89	3.89
Annual PM (total for both turbines)	tons/year	2.08	2.08	2.08	2.08	2.08	2.08	2.08	2.08	2.08
Annual SO ₂ (total for both turbines)	tons/year	0.35	0.35	0.35	0.35	0.35	0.35	0.35	0.35	0.35
Annual NO _x , as NO ₂	lb/hr/turbine	0.4441	0.4441	0.4441	0.4441	0.4441	0.4441	0.4441	0.4441	0.4441
Annual PM	lb/hr/turbine	0.2374	0.2374	0.2374	0.2374	0.2374	0.2374	0.2374	0.2374	0.2374
Annual SO ₂	lb/hr/turbine	0.0400	0.0400	0.0400	0.0400	0.0400	0.0400	0.0400	0.0400	0.0400
Annual NO _x , as NO ₂	g/s/turbine	0.0560	0.0560	0.0560	0.0560	0.0560	0.0560	0.0560	0.0560	0.0560
Annual PM	g/s/turbine	0.0299	0.0299	0.0299	0.0299	0.0299	0.0299	0.0299	0.0299	0.0299
Annual SO ₂	g/s/turbine	0.0050	0.0050	0.0050	0.0050	0.0050	0.0050	0.0050	0.0050	0.0050
Pollutant Impacts (ug/m³) - Annual Periods										
Annual NO _x	Conc(ug/m ³)	0.01129	0.01667	0.02247	0.01108	0.01702	0.02382	0.01087	0.01726	0.02468
Annual NO ₂	Conc(ug/m ³)	0.00846	0.01250	0.01685	0.00831	0.01277	0.01786	0.00815	0.01294	0.01851
Annual PM _{2.5} /PM ₁₀	Conc(ug/m ³)	0.00603	0.00890	0.01200	0.00591	0.00909	0.01272	0.00580	0.00921	0.01318
5-year PM _{2.5}	Conc(ug/m ³)	0.00553	0.00814	0.01097	0.00543	0.00832	0.01163	0.00533	0.00843	0.01204
Annual SO ₂	Conc(ug/m ³)	0.00101	0.00149	0.00201	0.00099	0.00152	0.00213	0.00097	0.00154	0.00220
Stack Emissions (each CT) - Commissioning Activities										
1-hour NO _x , as NO ₂	lb/hr	42.81	42.81	42.81	42.81	42.81	42.81	42.81	42.81	42.81
1-hour CO	lb/hr	55.30	55.30	55.30	55.30	55.30	55.30	55.30	55.30	55.30
8-hour CO	lb/hr	55.30	55.30	55.30	55.30	55.30	55.30	55.30	55.30	55.30
1-hour NO _x , as NO ₂	g/s/turbine	5.3941	5.3941	5.3941	5.3941	5.3941	5.3941	5.3941	5.3941	5.3941
1-hour CO	g/s/turbine	6.9678	6.9678	6.9678	6.9678	6.9678	6.9678	6.9678	6.9678	6.9678
8-hour CO	g/s/turbine	6.9678	6.9678	6.9678	6.9678	6.9678	6.9678	6.9678	6.9678	6.9678
Pollutant Impacts (ug/m³) - Commissioning Activities										
1-hour NO _x CAAQS	Conc(ug/m ³)	14.95908	20.76982	48.14817	14.68603	21.06838	47.26542	14.40856	21.28199	49.38628
1-hour NO _x NAAQS SIL	Conc(ug/m ³)	13.50391	19.04678	25.00845	13.26722	19.34810	25.96105	13.02691	19.53101	26.63046
1-hour NO _x NAAQS	Conc(ug/m ³)	9.60851	13.76013	18.27580	9.45267	14.00605	19.20262	9.29382	14.17251	19.76296
1-hour NO ₂ CAAQS	Conc(ug/m ³)	11.96726	16.61586	38.51853	11.74882	16.85471	37.81234	11.52685	17.02559	39.50902
1-hour NO ₂ NAAQS SIL	Conc(ug/m ³)	10.80313	15.23743	20.00676	10.61378	15.47848	20.76884	10.42153	15.62481	21.30436
1-hour NO ₂ NAAQS	Conc(ug/m ³)	7.68681	11.00811	14.62064	7.56214	11.20484	15.36209	7.43505	11.33801	15.81037
1-hour CO	Conc(ug/m ³)	19.32331	26.82930	62.19514	18.97060	27.21497	61.05486	18.61218	27.49090	63.79446
8-hour CO	Conc(ug/m ³)	10.97958	15.35048	19.73183	10.79675	15.61240	20.74481	10.61064	15.77942	21.30259

Worst-Case Operating Scenarios are bolded/highlighted.

5-year impacts are the average of annual impacts for PM_{2.5} NAAQS. Annual impacts are used for the CAAQS and the NO₂/PM₁₀/SO₂ NAAQS. NO₂ impacts shown reflect the NO₂ Ambient Ratio Method (ARM) USEPA-default values of 0.80 (80%) for 1-hour and 0.75 (75%) for annual averages.

Table 5.1B-5 Fumigation Modeling Results (1 page)
SERC Turbine Fumigation Impacts - Case 103

AERSCREEN Unitized Impacts -		Dist(m)	1-hour	3-hour	8-hour	24-hour	Annual
Fumigation - Turbine*		7850m	2.465	2.465	2.219	1.479	0.2465
AERSCREEN Max Normal - Turbine		213m	5.032	5.032	4.529	3.019	0.5032
AERMOD Unitized Impacts -			1-hour	3-hour	8-hour	24-hour	Annual
2 Turbines		#N/A	2.72261	2.35836	1.54952	0.55707	0.19780
Ratioed 1 Turbine		#N/A	1.36131	1.17918	0.77476	0.27854	0.09890
		Emissions					
NOx 1-hour Impacts - Normal Ops		(g/s)					
Fumigation - 2 Turbines*		1.0828	2.669				
AERSCREEN Max Normal - 2 Turbines		1.0828	5.449				
AERMOD Max - 2 Turbines		1.0828	1.474				
SOx 1-hour/3-hour/24-hour Impacts - Normal Ops							
Fumigation - 2 Turbines*		0.2484	0.612	0.612		0.367	
AERSCREEN Max Normal - 2 Turbines		0.2484	1.250	1.250		0.750	
AERMOD Max - 2 Turbines		0.2484	0.338	0.293		0.069	
CO 1-hour/8-hour Impacts - Normal Ops							
Fumigation - 2 Turbines*		1.0548	2.600		2.341		
AERSCREEN Max Normal - 2 Turbines		1.0548	5.308		4.777		
AERMOD Max - 2 Turbines		1.0548	1.436		0.817		
PM 24-hour Impacts - Normal Ops							
Fumigation - 2 Turbines*		0.7560				1.118	
AERSCREEN Max Normal - 2 Turbines		0.7560				2.282	
AERMOD Max - 2 Turbines		0.7560				0.211	
NOx 1-hour Impacts - Startup/Shutdown Conditions							
Fumigation - 2 Turbines*		1.6834	4.150				
AERSCREEN Max Normal - 2 Turbines		1.6834	8.471				
AERMOD Max - 2 Turbines		1.6834	2.292				
CO 1-hour/8-hour Impacts - Startup/Shutdown Conditions				8-hr(g/s)	8-hr(ug/m3)		
Fumigation - 2 Turbines*		3.3340	8.218	1.9354	4.295		
AERSCREEN Max Normal - 2 Turbines		3.3340	16.777	1.9354	8.765		
AERMOD Max - 2 Turbines		3.3340	4.539	1.9354	1.499		

NOTE: For fumigation maxima less than the AERSCREEN regular dispersion maxima for 1-hour averaging times, additional averaging times do NOT need to be considered consistent with past USEPA guidance for SCREEN3.

Table 5.1B-6 Deposition Modeling Results (1 page)

SERC Deposition Modeling Analyses

Calculated Nitrogen Emission Rates					
		Regular Fenceline-Coarse AERMOD Receptors		250m-Spaced AERMOD Receptors in Seal Beach NWR	
Deposition Modeling Emissions:		Nitrogen (NOx and NH3)		Nitrogen (NOx and NH3)	
		NOx as NO2	NH3	NOx as NO2	NH3
Emissions (per turbine):		3.90 tons/year		3.90 tons/year	
		x 2000 lbs/ton	2753.88 lbs/year	x 2000 lbs/ton	2753.88 lbs/year
		/ 8760 hrs/year	/ 8760 hrs/year	/ 8760 hrs/year	/ 8760 hrs/year
		= 0.8904 lbs/hr	= 0.3144 lbs/hr	= 0.8904 lbs/hr	= 0.3144 lbs/hr
		x 0.126 (g/s)/(lb/hr)	x 0.126 (g/s)/(lb/hr)	x 0.126 (g/s)/(lb/hr)	x 0.126 (g/s)/(lb/hr)
Pollutant Emissions:		= 0.1122 g/s	= 0.0396 g/s	= 0.1122 g/s	= 0.0396 g/s
Mol.Wt N		x 14 lbs/lb-mole	x 14 lbs/lb-mole	x 14 lbs/lb-mole	x 14 lbs/lb-mole
Mol.Wt NO2/NH3		/ 46 lbs/lb-mole	/ 17 lbs/lb-mole	/ 46 lbs/lb-mole	/ 17 lbs/lb-mole
Nitrogen Emissions:		= 0.0341 g/s	= 0.0326 g/s	= 0.0341 g/s	= 0.0326 g/s
Total Nitrogen Emissions:		= 0.0668 g/s		= 0.0668 g/s	

Modeled Nitrogen Deposition Rates*					
		Regular Fenceline-Coarse AERMOD Receptors		250m-Spaced AERMOD Receptors in Seal Beach NWR	
Modeled Deposition Rates:		Nitrogen (NOx and NH3)		Nitrogen (NOx and NH3)	
		Maximum Impact	Average Impacts**	Maximum Impact	Average Impacts
Deposition* at 1 g/s/turb:		0.28122 g/sq.m/yr	0.05366 g/sq.m/yr	0.01785 g/sq.m/yr	0.01580 g/sq.m/yr
		x 0.0668 g/s	x 0.0668 g/s	x 0.0668 g/s	x 0.0668 g/s
Pollutant Deposition:		= 0.01877 g/sq.m/yr	= 0.00358 g/sq.m/yr	= 0.00119 g/sq.m/yr	= 0.00105 g/sq.m/yr
		x 10,000 sq.m/hectare	x 10,000 sq.m/hectare	x 10,000 sq.m/hectare	x 10,000 sq.m/hectare
		/ 1000 g/kg	/ 1000 g/kg	/ 1000 g/kg	/ 1000 g/kg
		= 0.1877 kg/hectare/yr	= 0.0358 kg/hectare/yr	= 0.0119 kg/hectare/yr	= 0.0105 kg/hectare/yr

*Modeled Depositions Rates are 5-year averages, i.e., the mean of the 1-year annual-average values.

**Average Impacts are EXTREMELY conservative for the regular AERMOD receptors as these are the arithmetic averages of the all the receptors - which are HEAVILY weighted by the larger number of downwash/intermediate grid receptors near the facility with greater impacts than the coarse grid receptors.

Table 5.1B-7 Construction Impact/Modeling Summary (1 page)

Modeling Inputs/Results for SERC Construction Impacts (Combustion Sources as Point Sources) - 10m Fence + 20m Downwash Recs. - FASTAREA

Short Term Impacts (24 hrs and less)						Long Term Impacts (annual)							
	NOx	CO	SOx	PM10	PM2.5		NOx	CO	SOx	PM10	PM2.5		
Combustion (lbs/day)	35.48	27.35	0.0641	2.251	2.231	Combustion (tons/year)	4.684	3.610	0.00847	0.2972	0.2945		
Combustion (days/month)	22	22	22	22	22	Combustion (days/year)*	264	264	264	264	264		
Combustion (hrs/day)	8	8	8	8	8	Combustion (hrs/day)	8	8	8	8	8		
Combustion (lbs/hr)	4.44	3.42	0.01	0.28	0.28	Combustion (lbs/hr)*	3.21	2.47	0.01	0.20	0.20		
Combustion (g/sec)	5.59E-1	4.31E-1	1.01E-3	3.55E-2	3.51E-2	Combustion (g/sec)	4.04E-1	3.12E-1	7.31E-4	2.56E-2	2.54E-2		
Construction Dust (lbs/day)					5.279	0.753	Construction Dust (tons/year)					0.6968	0.09942
Construction Dust (days/month)					22	22	Construction Dust (days/year)					264	264
Construction Dust (hrs/day)					8	8	Construction Dust (hrs/day)					8	8
Construction Dust (lbs/hr)					0.66	0.09	Construction Dust (lbs/hr)*					0.477	0.068
Construction Dust (g/sec)	3.17 acres				8.31E-2	1.19E-2	Construction Dust (g/sec)	3.17 acres				6.01E-2	8.58E-3
AERMOD Inputs	12,840 m²				37 Pt.Srcs			12,840 m²				37 Pt.Srcs	
Combustion (g/s/src)	1.510E-2	1.164E-2	2.729E-5	9.582E-4	9.497E-4	Combustion (g/s/src)	1.093E-2	8.420E-3	1.976E-5	6.932E-4	6.869E-4		
Construction Dust (g/s/m ²)					6.476E-6	9.237E-7	Construction Dust (g/s/m ²)					4.684E-6	6.683E-7
AERMOD Results (ug/m³)													
Combustion Only						Combustion Only							
1-hour Max	36.777	28.349	0.066	2.33326									
3-hour Max			0.031	1.08825									
8-hour Max		13.680		1.12594									
24-hour Max			0.011	0.37732	0.37397	Annual	1.340		0.002	0.08501	0.08424		
All Particulate Sources						All Particulate Sources							
24-hour Max					27.43745	3.93816	Annual					7.64782	1.15215
1-hour NO2 w/ ARM	29.421 based on ARM Ratio of:				80%		Annual NO2 w/ ARM	1.005 based on ARM Ratio of:				75%	
Background (ug/m³)	152.6 CAAQS					Background (ug/m³)							
1-hour Max	116.6	3910	23.1										
3-hour Max			23.1										
8-hour Max		2889											
24-hour Max			3.7	84	27.7	Annual	50.9		0.8	26.7	10.5		
Total + Background (ug/m³)	182.0 CAAQS					Total + Background (ug/m³)							
1-hour Max	146.0	3938	23.17										
3-hour Max			23.13										
8-hour Max		2903											
24-hour Max			3.71	111.4	31.6	Annual	51.9		0.8	34.3	11.7		

Maximum NOx/CO/SO2 impacts ratioed from PM10 combustion source impact.

*Even for construction projects taking less than 12-months or 7 days/wk, the hourly emissions for modeling are still based on total tons (for projects<12 months) or annualized tons/year (for projects>12months) divided by 365 days since all days in the met dataset (i.e., all 12 months and all 365 days - i.e., 7 days/week) are modeled.

Total Construction Period	NOx	CO	SOx	PM10	PM2.5
Combustion (lbs/month)	780.6	601.7	1.411	49.53	49.08
Fugitives (lbs/month)				116.13	16.57

FIGURE 5.1B-1a
ANNUAL WIND ROSE OF
2006-2009 & 2012 ANAHEIM SURFACE DATA
FROM SCAQMD AERMOD METEOROLOGY WEBSITE




FIGURE 5.1B-1b
 1ST QUARTER (JANUARY-MARCH) WIND ROSE OF
 2006-2009 & 2012 ANAHEIM SURFACE DATA
 FROM SCAQMD AERMOD METEOROLOGY WEBSITE




FIGURE 5.1B-1c
2ND QUARTER (APRIL-JUNE) WIND ROSE OF
2006-2009 & 2012 ANAHEIM SURFACE DATA
FROM SCAQMD AERMOD METEOROLOGY WEBSITE




FIGURE 5.1B-1d
3RD QUARTER (JULY-SEPTEMBER) WIND ROSE OF
2006-2009 & 2012 ANAHEIM SURFACE DATA
FROM SCAQMD AERMOD METEOROLOGY WEBSITE




FIGURE 5.1B-1e
4TH QUARTER (OCTOBER-DECEMBER) WIND ROSE OF
2006-2009 & 2012 ANAHEIM SURFACE DATA
FROM SCAQMD AERMOD METEOROLOGY WEBSITE




FIGURE 5.1B-2

Deposition Modeling for Seal Beach National Wildlife Refuge

