

DOCKETED

Docket Number:	16-OIR-04
Project Title:	Integrated Resource Plans (Publicly Owned Utilities)
TN #:	214850
Document Title:	Presentation - Putting Customers First By: James Barner
Description:	Lead Commissioner Workshop Integrated Resource Plans - Renewable Energy, Pursuant to SB350, December 13, 2016
Filer:	Le-Huy Nguyen
Organization:	Los Angeles Department of Water and Power
Submitter Role:	Public Agency
Submission Date:	12/16/2016 3:15:20 PM
Docketed Date:	12/16/2016






Putting Customers First



Lead Commissioner Workshop Integrated Resource Plans – Renewable Energy, Pursuant to SB350

December 13, 2016

Energy Transformation



Over the next 15 years, LADWP will replace over 70% of its generation infrastructure used to reliably deliver power to its customers

Coal is eliminated and renewables increases

Transformation Elements



Eliminate Coal from LADWP's Power Supply



Reach 33% RPS by 2020 and 50% by 2030



Achieve 15% Energy Efficiency by 2020



Once-through Cooling Repowering



Invest in Power System Reliability Program (KPIs)



Support Electric Vehicle Expansion

2016 Major Accomplishments




Project/ Program	Accomplishment
Renewable Portfolio Standard	25% RPS in 2016
Sale of Navajo to Salt River Project	Sold 477 MW share of Navajo Generating Station to Salt River Project
Moapa Southern Paiute Solar	250 MW in-service
Springbok 1 and 2 Solar	105 MW and 155 MW solar in-service
RE Cinco Solar	60 MW in-service
Springbok 3 Solar	City Council approved 90 MW solar project (COD 2019)
Electric Vehicle Charger Program for Home, Workplace, and Public Charging: “Charge-up LA!!!”	\$21.5 million budgeted program through June 30, 2018 for residential and commercial customers
Barren Ridge Renewable Transmission Project	1,750 MW of added transmission capacity in-service

2016 IRP Case Scenarios




Coal Cases

1. Intermountain Power Plant (IPP) 2027* (base)
2. IPP 2025*



Renewable (RPS), Local Solar, Energy Storage and Electrification (EV) Cases

4. 50% RPS, Low Local Solar, Low Storage, Low EV*
5. 50% RPS, Low Local Solar, Low Storage, High EV
6. 50% RPS, High Local Solar, Low Storage, High EV
7. 50% RPS, High Local Solar, High Storage, High EV
8. 65% RPS, High Local Solar, High Storage, High EV
- 8LLS. 65% RPS, Low Local Solar, High Storage, High EV
- 8MLS. 65% RPS, Med Local Solar, High Storage, High EV
- 8SF. 65% Solar Focus RPS, High Local Solar, High Storage, High EV
(high local solar and storage in accordance to LA Sustainability pLAn goals)




Recommended Case

**Expected, Low, and High Fuel Cost Sensitivity Analysis was performed*

Resource Adequacy Methodology



Net Load (Load minus Solar and Wind)
Typical Summer Day



Resource Assumptions




Resource Type	Levelized Cost (\$/MWh) ¹	Capacity Factor	Peak Load Dependable Capacity (3 to 5 PM)	Net Load Dependable Capacity ² (7 to 9 PM)
Solar Photovoltaic – PPA	\$67	28% - 35%	27% - 38%	0 - 2%
Solar Photovoltaic – LA Solar	\$176	19% - 23%	27%	3% - 5%
Solar Feed-in-Tariff	\$175	20%	27%	3% - 5%
Wind	\$106	24% - 33%	10%	0%
Wind Firmed and Shaped	\$106 to \$122	24% - 33%	45% - 100%	45% - 100%
Geothermal	\$81	91% - 95%	90%	90%
New Combined Cycle Gas	\$61-70	47-52%	96%	96%
New Simple Cycle Gas	\$400-500	3-5%	96%	96%
Castaic Improvement	\$53	25%	100%	100%
Valley Thermal	\$31	28%	100%	99%
Battery	\$554	5%	43-61%	21 to 100%
CAES	\$56	44%	92%	92%


¹Net Present Value (annual costs, 2016-2036) / NPV of Energy Produced

²Net Load represents the hour when the net energy for load minus variable energy resources is maximum

Resource Adequacy – 50% RPS




Resource Adequacy – 65% RPS




Achieving 50% RPS by 2030




2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036
24.5%	31.2%	34.8%	37.2%	37.7%	39.7%	41.2%	43.3%	42.3%	44.0%	44.2%	46.0%	47.8%	48.3%	50.0%	50.0%	50.0%	50.0%	50.0%	50.2%	50.0%



Achieving 65% RPS by 2036




Electric Vehicle (EV) Charging Forecast



- Base Case Transportation Electrification (IEPR)
- High Case Transportation Electrification (Double IEPR Forecast)

GHG Emissions: 50% vs 65% RPS



Transmission Upgrade Challenges




- Increased capacity from 450 to 2,200 MW
- Renewable interconnection requests of 3,773 MW from wind and solar developers
- New Haskell Canyon Switching Station (SS)
- New double-circuit 230 kV transmission line from Barren Ridge SS to the new Haskell Canyon SS.
- New 230-kV circuit on existing structures from the new Haskell Canyon SS to the Castaic Power Plant.
- Reconductoring of existing 230 kV transmission line from Barren Ridge to the existing Rinaldi Receiving Station
- Expand the existing Barren Ridge SS

DER Integration Study



- Leverage DER program efforts and resources
- Minimize duplications and increase system efficiency
- Achieve optimal DER deployment
- Achieve a common objective



Energy Storage Plan for 50% RPS



GENERATION	TRANSMISSION	DISTRIBUTION	CUSTOMER	JFB ES
Gas Fired + Thermal Energy	Battery Energy Storage System	Battery Energy Storage System	Battery, Thermal Energy Storage	Battery Energy Storage System
				
<u>Location:</u> Valley Generating Station	<u>Location:</u> Beacon & Springbok Area Solar	<u>Location:</u> Distributing and Receiving Stations	<u>Location:</u> Customers	<u>Location:</u> John Ferraro Building Parking lots
<u>Capacity:</u> 60 MW or greater	<u>Capacity:</u> 50 MW or greater	<u>Capacity:</u> 4 MW or greater	<u>Capacity:</u> 40 MW	<u>Capacity:</u> 300KW/1MWh
<u>Key Applications:</u> <ul style="list-style-type: none"> • Increase CT output during hot weather 10%-20% • Peak Shifting • Ramping regulation capacity • May eliminate need for added capacity 	<u>Key Applications:</u> <ul style="list-style-type: none"> • Regulation Service (ramping up and down) • Solar Power Output Leveling • Peak Shaving 	<u>Key Applications:</u> <ul style="list-style-type: none"> • Peak Shaving • Distributed PV Solar Integration • Deferring Distribution Infrastructure Upgrades 	<u>Key Applications:</u> <ul style="list-style-type: none"> • Permanent Load Shifting • Dispatchable Peak Shifting • Deferring Distribution Infrastructure Upgrades • Demand Response • Energy Efficiency 	<u>Key Applications:</u> <ul style="list-style-type: none"> • Demand Response • Dispatchable Peak Shifting • Energy Management System • Research and Development
<u>Schedule</u> <ul style="list-style-type: none"> • Completion by December 2017 	<u>Schedule</u> <ul style="list-style-type: none"> • Completion by September 2020 	<u>Schedule</u> <ul style="list-style-type: none"> • Completion by March 2019 for DS and September 2020 for RS 	<u>Schedule</u> <ul style="list-style-type: none"> • Completion by July 2020 	<u>Schedule</u> <ul style="list-style-type: none"> • Completion by June 2016

Summary – Challenges



- Limited available Transmission Capacity for Renewable Projects
Increased RPS Category 2 and 3 percentages may be needed
- Disposition of grandfathered RPS power purchase agreements at the end of the contract term or when purchased (Category 0 or 1?)
- Cap and Trade Allocations Post 2020, as currently proposed at 82% below 2020 levels by 2030 or double the 40% required by SB32, will divert a minimum of \$500 Million of revenue from LADWP over 10 years that could otherwise support EV charging and clean energy programs
- PV Solar and Wind adds little to no dependable capacity to effect the Net Peak Load without energy storage
- Residential TOU, CPP, RTP effectiveness at reducing Net Peak Load uncertain. Concerns about IT infrastructure and AMI having high cost and short life cycles.
- Local distributed generation deployment is challenging especially within a dense urban environment (i.e., permitting, safety, underground wiring).

Summary – Opportunities



- Improved coordination, cooperation, and flexibility among Agencies and POU's recognizing past and future investments and good faith efforts made by POU's to reach State goals.
- Continue to recognize existing grandfathered RPS projects beyond the original contract term to continue meeting 50% RPS
- CEC forecasts, especially electrification, can be very helpful for IRP planning
- Committed certification process timelines to assist development
- Increased research funding for new RPS and long term energy storage technologies (i.e., Enhanced Geothermal Systems, Hydrogen) to achieve AB32 emissions goals.
- Promote batteries to be included with net metered PV systems
- Energy Storage needs should be based on control area/utility operational requirements to integrate renewables (Optimization, not Prescription)


Appendix



Resource Adequacy Methodology




Net Load (Load minus Solar and Wind) Typical Summer Day



Resource Adequacy Methodology




Net Load (Load minus Solar and Wind) Typical Summer Day



Local Solar Cases (Low vs. High)




Case 8 LLS (Low Local Solar):



800 Megawatts (MW) by 2025 and 1,200 MW by 2035

Case 8 (High Local Solar):



1,200 Megawatts (MW) by 2025 and 1,800 MW by 2035