

DOCKETED

| | |
|-------------------------|--|
| Docket Number: | 16-SPPE-01 |
| Project Title: | AltaGas Pomona Energy |
| TN #: | 210803-9 |
| Document Title: | Appendix 4.1E |
| Description: | Application for Small Power Plant Exemption Volume 2 |
| Filer: | Sabrina Savala |
| Organization: | AltaGas Pomona Energy, Inc. |
| Submitter Role: | Applicant |
| Submission Date: | 3/22/2016 12:28:10 PM |
| Docketed Date: | 3/21/2016 |

Appendix 4.1E
Air Quality Modeling Inputs

**Table 4.1E-1
Pomona Repower Project
Dimensions of the Major Project Features**

| Feature | Length (feet) | Width (feet) | Height (feet) | Diameter (feet) |
|---------------------------------|--------------------------|-------------------------|--------------------------|----------------------------|
| SCR and Transition (Tier 1) | 53 | 23 | 23 | |
| SCR and Transition (Tier 2) | 23 | 23 | 33 | |
| Combustion Gas Turbine (CGT), | 27 | 13 | 29 | — |
| CGT Generator Enclosure (Tier1) | 30 | 16 | 15 | — |
| CGT Generator Enclosure (Tier2) | 11 | 16 | 34 | — |
| CGT Air Intake System | 44 | 38 | 46 | — |
| VBV Silencer | — | — | 48 | 12 |
| Inter Cooler | 40 | 12 | 12 | — |
| Cooling water pump skid | 25 | 10 | 12 | |
| CEMS | 10 | 7 | 10 | |
| CO2 Storage | 16 | 10 | 5 | |
| Maintenance/Warehouse Building | 162 | 62 | 20 | — |
| Aux Transformer | 34 | 18 | 15 | |
| Power Control Module | 50 | 15 | 12 | |
| Ammonia Tank and Containment | 49 | 26 | 15 | |
| Warehouse | 162 | 62 | 20 | |
| Water Treatment Building | 65 | 74 | 19 | |
| Fuel gas enclosure | 50 | 56 | 20 | |
| Raw Water Tank | — | — | 30 | 40 |
| Demin Water Tank | — | — | 30 | 40 |
| Cooling Tower | 88 | 35 | 25 | — |

**Table 4.1E-2
Pomona Repower Project
Screening Modeling Inputs**

| Case | Amb Temp deg F | Stack height feet | Stack Height meters | Stack Diam feet | Stack Diam meters | Stack flow wacfm | Stack flow m3/sec | Stack Vel ft/sec | Stack Vel m/sec | Stack Temp deg F | Stack Temp deg K |
|---------------------------------------|----------------------|----------------------|------------------------|----------------------|----------------------|----------------------|----------------------|-----------------------|----------------------|---------------------|---------------------|
| Winter/Maximum w/o cooling | 28.0 | 90.0 | 27.43 | 14.5 | 4.42 | 978,274 | 461.75 | 98.74 | 30.10 | 779.0 | 688.15 |
| Winter/Minimum w/o cooling | 28.0 | 90.0 | 27.43 | 14.5 | 4.42 | 536,090 | 253.04 | 54.11 | 16.49 | 796.0 | 697.59 |
| ISO/Maximum w/o cooling | 59.0 | 90.0 | 27.43 | 14.5 | 4.42 | 984,667 | 464.77 | 99.38 | 30.29 | 753.0 | 673.71 |
| ISO/Minimum w/o cooling | 59.0 | 90.0 | 27.43 | 14.5 | 4.42 | 525,992 | 248.27 | 53.09 | 16.18 | 789.0 | 693.71 |
| Avg. Summer Temp./Maximum w/o cooling | 74.0 | 90.0 | 27.43 | 14.5 | 4.42 | 966,143 | 456.03 | 97.51 | 29.72 | 763.0 | 679.26 |
| Avg. Summer Temp./Minimum w/o cooling | 74.0 | 90.0 | 27.43 | 14.5 | 4.42 | 511,447 | 241.41 | 51.62 | 15.73 | 777.0 | 687.04 |
| Summer High Temp./Maximum w/o cooling | 99.8 | 90.0 | 27.43 | 14.5 | 4.42 | 915,411 | 432.08 | 92.39 | 28.16 | 778.0 | 687.59 |
| Summer High Temp./Minimum w/o cooling | 99.8 | 90.0 | 27.43 | 14.5 | 4.42 | 493,001 | 232.70 | 49.76 | 15.17 | 806.0 | 703.15 |
| Winter/Maximum w/cooling | 28.0 | 90.0 | 27.43 | 14.5 | 4.42 | 1,003,199 | 473.52 | 101.25 | 30.86 | 747.0 | 670.37 |
| Winter/Minimum w/cooling | 28.0 | 90.0 | 27.43 | 14.5 | 4.42 | 535,523 | 252.77 | 54.05 | 16.47 | 796.0 | 697.59 |
| ISO/Maximum w/cooling | 59.0 | 90.0 | 27.43 | 14.5 | 4.42 | 989,951 | 467.27 | 99.92 | 30.45 | 749.0 | 671.48 |
| ISO/Minimum w/cooling | 59.0 | 90.0 | 27.43 | 14.5 | 4.42 | 528,307 | 249.37 | 53.32 | 16.25 | 786.0 | 692.04 |
| Avg. Summer Temp./Maximum w/cooling | 74.0 | 90.0 | 27.43 | 14.5 | 4.42 | 975,224 | 460.32 | 98.43 | 30.00 | 747.0 | 670.37 |
| Avg. Summer Temp./Minimum w/cooling | 74.0 | 90.0 | 27.43 | 14.5 | 4.42 | 517,888 | 244.45 | 52.27 | 15.93 | 774.0 | 685.37 |
| Summer High Temp./Maximum w/cooling | 99.8 | 90.0 | 27.43 | 14.5 | 4.42 | 949,139 | 448.00 | 95.80 | 29.20 | 768.0 | 682.04 |
| Summer High Temp./Minimum w/cooling | 99.8 | 90.0 | 27.43 | 14.5 | 4.42 | 506,601 | 239.12 | 51.13 | 15.58 | 801.0 | 700.37 |
| | NOx lb/hr | CO lb/hr | PM10 lb/hr | SOx lb/hr | | NOx g/sec | CO g/sec | PM10 g/sec | SOx g/sec | | |
| Winter/Maximum w/o cooling | 8.84 | 8.61 | 3.50 | 2.00 | | 1.114 | 1.085 | 0.441 | 0.253 | | |
| Winter/Minimum w/o cooling | 3.37 | 3.29 | 3.50 | 0.76 | | 0.425 | 0.414 | 0.441 | 0.096 | | |
| ISO/Maximum w/o cooling | 8.65 | 8.42 | 3.50 | 1.96 | | 1.089 | 1.061 | 0.441 | 0.247 | | |
| ISO/Minimum w/o cooling | 3.30 | 3.22 | 3.50 | 0.75 | | 0.416 | 0.405 | 0.441 | 0.094 | | |
| Avg. Summer Temp./Maximum w/o cooling | 8.43 | 8.21 | 3.50 | 1.91 | | 1.063 | 1.035 | 0.441 | 0.241 | | |
| Avg. Summer Temp./Minimum w/o cooling | 3.23 | 3.14 | 3.50 | 0.73 | | 0.407 | 0.396 | 0.441 | 0.092 | | |
| Summer High Temp./Maximum w/o cooling | 7.84 | 7.64 | 3.50 | 1.78 | | 0.988 | 0.963 | 0.441 | 0.224 | | |
| Summer High Temp./Minimum w/o cooling | 3.06 | 2.98 | 3.50 | 0.69 | | 0.386 | 0.376 | 0.441 | 0.087 | | |
| Winter/Maximum w/cooling | 8.84 | 8.61 | 3.50 | 2.00 | | 1.113 | 1.084 | 0.441 | 0.252 | | |
| Winter/Minimum w/cooling | 3.37 | 3.28 | 3.50 | 0.76 | | 0.425 | 0.414 | 0.441 | 0.096 | | |
| ISO/Maximum w/cooling | 8.72 | 8.49 | 3.50 | 1.98 | | 1.099 | 1.070 | 0.441 | 0.249 | | |
| ISO/Minimum w/cooling | 3.32 | 3.23 | 3.50 | 0.75 | | 0.418 | 0.407 | 0.441 | 0.095 | | |
| Avg. Summer Temp./Maximum w/cooling | 8.61 | 8.38 | 3.50 | 1.95 | | 1.085 | 1.056 | 0.441 | 0.246 | | |
| Avg. Summer Temp./Minimum w/cooling | 3.28 | 3.20 | 3.50 | 0.74 | | 0.414 | 0.403 | 0.441 | 0.094 | | |
| Summer High Temp./Maximum w/cooling | 8.23 | 8.02 | 3.50 | 1.86 | | 1.037 | 1.010 | 0.441 | 0.235 | | |
| Summer High Temp./Minimum w/cooling | 3.18 | 3.09 | 3.50 | 0.72 | | 0.400 | 0.390 | 0.441 | 0.090 | | |

Table 4.1E-3

**Pomona Repower Project
Screening Level Modeling Impacts**

| Operating Mode | Conc. (ug/m3) | Conc. (ug/m3) | Conc. (ug/m3) | Conc. (ug/m3) | Conc. (ug/m3) | Conc. (ug/m3) | Conc. (ug/m3) | Conc. (ug/m3) | Conc. (ug/m3) | Conc. (ug/m3) | Conc. (ug/m3) |
|---------------------------------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|----------------|---------------|
| | NO2 1-hr | SO2 1-hr | CO 1-hr | SO2 3-hr | CO 8-hr | SO2 24-hr | PM10 24-hr | NO2 Annual | SO2 Annual | PM10 Annual | |
| Winter/Maximum w/o cooling | 1.117 | 0.260 | 1.088 | 0.177 | 0.516 | 0.054 | 0.092 | 0.079 | 0.018 | 0.031 | |
| Winter/Minimum w/o cooling | 0.745 | 0.173 | 0.725 | 0.134 | 0.405 | 0.039 | 0.173 | 0.043 | 0.010 | 0.044 | |
| ISO/Maximum w/o cooling | 1.100 | 0.256 | 1.071 | 0.175 | 0.510 | 0.053 | 0.093 | 0.078 | 0.018 | 0.031 | |
| ISO/Minimum w/o cooling | 0.742 | 0.172 | 0.723 | 0.134 | 0.406 | 0.039 | 0.177 | 0.043 | 0.010 | 0.045 | |
| Avg. Summer Temp./Maximum w/o cooling | 1.089 | 0.254 | 1.060 | 0.174 | 0.507 | 0.053 | 0.094 | 0.076 | 0.018 | 0.032 | |
| Avg. Summer Temp./Minimum w/o cooling | 0.744 | 0.173 | 0.725 | 0.136 | 0.411 | 0.039 | 0.183 | 0.043 | 0.010 | 0.047 | |
| Summer High Temp./Maximum w/o cooling | 1.062 | 0.247 | 1.034 | 0.171 | 0.501 | 0.052 | 0.099 | 0.073 | 0.017 | 0.032 | |
| Summer High Temp./Minimum w/o cooling | 0.717 | 0.166 | 0.699 | 0.131 | 0.398 | 0.038 | 0.187 | 0.042 | 0.010 | 0.048 | |
| Winter/Maximum w/cooling | 1.106 | 0.258 | 1.077 | 0.175 | 0.510 | 0.054 | 0.091 | 0.079 | 0.018 | 0.031 | |
| Winter/Minimum w/cooling | 0.745 | 0.173 | 0.726 | 0.134 | 0.406 | 0.039 | 0.173 | 0.043 | 0.010 | 0.044 | |
| ISO/Maximum w/cooling | 1.105 | 0.257 | 1.076 | 0.175 | 0.512 | 0.054 | 0.092 | 0.078 | 0.018 | 0.031 | |
| ISO/Minimum w/cooling | 0.744 | 0.173 | 0.725 | 0.135 | 0.407 | 0.039 | 0.176 | 0.043 | 0.010 | 0.045 | |
| Avg. Summer Temp./Maximum w/cooling | 1.109 | 0.258 | 1.080 | 0.177 | 0.516 | 0.054 | 0.094 | 0.078 | 0.018 | 0.032 | |
| Avg. Summer Temp./Minimum w/cooling | 0.751 | 0.175 | 0.731 | 0.137 | 0.414 | 0.039 | 0.181 | 0.044 | 0.010 | 0.046 | |
| Summer High Temp./Maximum w/cooling | 1.079 | 0.251 | 1.051 | 0.173 | 0.504 | 0.052 | 0.096 | 0.075 | 0.017 | 0.032 | |
| Summer High Temp./Minimum w/cooling | 0.731 | 0.170 | 0.712 | 0.133 | 0.403 | 0.038 | 0.182 | 0.042 | 0.010 | 0.047 | |

Table 4.1E-4

Emission Rates and Stack Parameters for Refined Modeling (cont.)

| | Stack Diam, m | Stack Height, m | Temp, deg K | Exhaust Flow, m3/s | Exhaust Velocity, m/s | NOx | Emission Rates, g/s | | | Stack Diam, ft | Stack Height, ft | Exh Temp, Deg F | Exh Flow Rate, ft3/m | Exhaust Velocity, ft/s | Emission Rates, lb/hr | | | |
|---|------------------|--------------------|-------------|-----------------------|--------------------------|-----|---------------------|--------|--------|-------------------|---------------------|--------------------|-------------------------|---------------------------|-----------------------|------|------|------|
| | | | | | | | SO2 | CO | PM10 | | | | | | NOx | SO2 | CO | PM10 |
| Averaging Period: Eight hours CO | | | | | | | | | | | | | | | | | | |
| New GT | 4.4 | 27.4 | 688 | 461.7 | 30.1 | n/a | n/a | 1.0846 | n/a | 14.5 | 90 | 779 | 978,274 | 99 | n/a | n/a | 8.61 | n/a |
| New Cooling Tower - vent 1 | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a |
| New Cooling Tower - vent 2 | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a |
| Averaging Period: 24-hour SOx | | | | | | | | | | | | | | | | | | |
| New GT | 4.4 | 27.4 | 688 | 461.7 | 30.1 | n/a | 0.2525 | n/a | n/a | 14.5 | 90 | 779 | 978,274 | 99 | n/a | 2.00 | n/a | n/a |
| New Cooling Tower - vent 1 | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a |
| New Cooling Tower - vent 2 | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a |
| Averaging Period: 24-hour PM10 | | | | | | | | | | | | | | | | | | |
| New GT | 4.4 | 27.4 | 703 | 232.7 | 15.2 | n/a | n/a | n/a | 0.4410 | 14.5 | 90 | 806 | 493,001 | 50 | n/a | n/a | n/a | 3.50 |
| New Cooling Tower - vent 1 | 6.1 | 10.7 | 316 | 271.4 | 9.3 | n/a | n/a | n/a | 0.0033 | 20.0 | 35 | 110 | 575,000 | 31 | n/a | n/a | n/a | 0.03 |
| New Cooling Tower - vent 2 | 6.1 | 10.7 | 316 | 271.4 | 9.3 | n/a | n/a | n/a | 0.0033 | 20.0 | 35 | 110 | 575,000 | 31 | n/a | n/a | n/a | 0.03 |

Table 4.1E-4

Emission Rates and Stack Parameters for Refined Modeling (cont.)

| | Stack Diam, | | Temp, deg K | Exhaust Flow, m3/s | Exhaust Velocity, m/s | Emission Rates, g/s | | | | Stack Diam, ft | Stack Height, ft | Exh Temp, Deg F | Exh Flow Rate, ft3/m | Emission Rates, lb/hr | | | | |
|---|-------------|------|-------------|--------------------|-----------------------|---------------------|--------|-----|--------|----------------|------------------|-----------------|----------------------|-----------------------|------|------|------|------|
| | m | | | | | NOx | SO2 | CO | PM10 | | | | | NOx | SO2 | CO | PM10 | |
| Averaging Period: Annual NOx and SOx | | | | | | | | | | | | | | | | | | |
| New GT | 4.4 | 27.4 | 688 | 461.7 | 30.1 | 0.5756 | 0.0360 | n/a | n/a | 14.5 | 90 | 779 | 978,274 | 99 | 4.57 | 0.29 | n/a | n/a |
| New Cooling Tower - vent 1 | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a |
| New Cooling Tower - vent 2 | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a |
| Averaging Period: Annual PM10 | | | | | | | | | | | | | | | | | | |
| New GT | 4.4 | 27.4 | 703 | 232.7 | 15.2 | n/a | n/a | n/a | 0.1093 | 14.5 | 90 | 806 | 493,001 | 50 | n/a | n/a | n/a | 0.87 |
| New Cooling Tower - vent 1 | 6.1 | 10.7 | 316 | 271.4 | 9.3 | n/a | n/a | n/a | 0.0014 | 20.0 | 35 | 110 | 575,000 | 31 | n/a | n/a | n/a | 0.01 |
| New Cooling Tower - vent 2 | 6.1 | 10.7 | 316 | 271.4 | 9.3 | n/a | n/a | n/a | 0.0014 | 20.0 | 35 | 110 | 575,000 | 31 | n/a | n/a | n/a | 0.01 |

**Table 4.1E-5
Pomona Repower Project
Startup/Shutdown Modeling Inputs**

| Operating Case | Stack Ht. feet | Stack Dia. ft | Stack flow wacfm | Stack flow m3/sec | Stack Vel ft/sec | Stack Vel m/sec | Stack Temp deg F | Stack Temp deg K | NOx lb/hr | CO lb/hr | NOx g/sec | CO g/sec |
|-----------------------------------|----------------|---------------|------------------|-------------------|------------------|-----------------|------------------|------------------|-----------|----------|-----------|----------|
| New GT - Startup/Shutdown/Restart | 90 | 14.5 | 493,001 | 233 | 50 | 15 | 806 | 703 | 35.30 | 21.64 | 4.45 | 2.73 |
| New Cooling Tower - vent 1 | 35 | 20 | 575,000 | 271 | 31 | 9 | 110 | 316 | n/a | n/a | n/a | n/a |
| New Cooling Tower - vent 2 | 35 | 20 | 575,000 | 271 | 31 | 9 | 110 | 316 | n/a | n/a | n/a | n/a |

**Table 4.1E-6
Pomona Repower Project
Commissioning Modeling Inputs**

| Operating Case | Stack Ht. feet | Stack Dia. ft | Stack flow wacfm | Stack flow m3/sec | Stack Vel ft/sec | Stack Vel m/sec | Stack Temp deg F | Stack Temp deg K | NOx lb/hr | CO lb/hr | PM10 lb/hr | SOx lb/hr | NOx g/sec | CO g/sec | PM10 g/sec | SOx g/sec |
|----------------------------|----------------|---------------|------------------|-------------------|------------------|-----------------|------------------|------------------|-----------|----------|------------|-----------|-----------|----------|------------|-----------|
| New GT - Commissioning | 90 | 14.5 | 493,001 | 233 | 50 | 15 | 806 | 703 | 88.07 | 242.37 | 3.50 | 2.00 | 11.10 | 30.54 | 0.44 | 0.25 |
| New Cooling Tower - vent 1 | 35 | 20 | 575,000 | 271 | 31 | 9 | 110 | 316 | n/a | n/a | 0.03 | n/a | n/a | n/a | 0.00 | n/a |
| New Cooling Tower - vent 2 | 35 | 20 | 575,000 | 271 | 31 | 9 | 110 | 316 | n/a | n/a | 0.03 | n/a | n/a | n/a | 0.00 | n/a |