

DOCKETED

| | |
|-------------------------|---------------------------------------------------------------------|
| Docket Number: | 16-SPPE-01 |
| Project Title: | AltaGas Pomona Energy |
| TN #: | 210868 |
| Document Title: | Correspondence from The South Coast Air Quality Management District |
| Description: | N/A |
| Filer: | Judith Warmuth |
| Organization: | Stoel Rives LLP |
| Submitter Role: | Applicant |
| Submission Date: | 3/28/2016 10:51:41 AM |
| Docketed Date: | 3/28/2016 |



South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

March 25, 2016

George Munoz
Plant Manager
AltaGas Pomona Energy, Inc.
1507 Mt. Vernon Ave.
Pomona, CA 91768

Subject: Permit Applications for the Pomona Repower Project, located at
1507 Mt. Vernon Ave., Pomona, CA 91768 (Facility ID# 176708)

Dear Mr. Munoz:

The South Coast Air Quality Management District (SCAQMD) received permit applications for the proposed Pomona Repower Project (PRP) on February 24, 2016. As a first step in our review process, we have briefly evaluated the applications to determine whether they are complete and ready for review. Based on our initial review of the submitted materials it has been determined that the application package is incomplete. The reference application numbers for this project and our initial review determination are provided in the table below:

| Application | Equipment Description | Completeness Determination |
|-------------|------------------------------------------|----------------------------|
| 582424 | RECLAIM/Title V Revision | Deemed Incomplete |
| 582426 | Simple Cycle Turbine | Deemed Incomplete |
| 582427 | SCR/CO Catalyst for Simple Cycle Turbine | Deemed Incomplete |
| 582429 | Ammonia Tank for Simple Cycle Turbine | Deemed Incomplete |

Please be aware that, in addition to the information required below, other information will be needed during the course of our full engineering evaluation. Your cooperation is key to the timely review of the applications. The following issues have been identified during the completeness review:

- Cursory background information on the project is included in the cover letter. Please provide more detailed information on the project and equipment to be installed and the turbine electrical generation process and equipment to be installed.
- Emissions data is mostly provided in a series of tables. The series of tables provide little introduction or description which can make it difficult to decipher and interpret the data included in the tables. Please provide more information to guide the reader on the relevancy of the information provided in the tables (e.g. or assumptions made for calculated emissions in table or the description of the commissioning schedule to interpret Table 4.1B-5).
- Only hard copies of the data have been provided in the package. Some of the tables included contain a lot of data, and are printed in very small font as to fit on the page. Please provide data in a format which would help make the data easier to read.

Please feel free to contact me at (909) 396-2643, or alee@aqmd.gov, for further information or clarification.

Sincerely,

A handwritten signature in cursive script, appearing to read "Andrew Y. Lee".

Andrew Y. Lee, P.E.
Sr. Engineering Manager
Engineering and Compliance

AYL:CDT:JTY:CSA

cc: Tom Andrews/Sierra Research
Leonidas Payne/California Energy Commission
Mohsen Nazemi