

## DOCKETED

<b>Docket Number:</b>	17-AAER-01
<b>Project Title:</b>	Appliance Efficiency Pre-Rulemaking for Commercial Tumble Dryers and Air Filter Labeling
<b>TN #:</b>	220556
<b>Document Title:</b>	Peter J. McKinney Comments Comment for Docket # 17-AAER-01
<b>Description:</b>	N/A
<b>Filer:</b>	System
<b>Organization:</b>	Peter J. McKinney
<b>Submitter Role:</b>	Public
<b>Submission Date:</b>	8/4/2017 3:48:49 PM
<b>Docketed Date:</b>	8/4/2017

*Comment Received From: Peter J. McKinney*

*Submitted On: 8/4/2017*

*Docket Number: 17-AAER-01*

**Comment for Docket #: 17-AAER-01**

*Additional submitted attachment is included below.*

**From:** [McKinney, Peter J StrionAir](#)  
**To:** [Energy - Docket Optical System](#)  
**Cc:** [Saxton, Patrick@Energy](#)  
**Subject:** Comment for Docket #: 17-AAER-01 Project Title: Appliance Efficiency Pre-Rulemaking for Commercial Tumble Dryers and Air Filter Labeling  
**Date:** Friday, August 04, 2017 3:42:43 PM

---

Hello –

Per the request from Patrick Saxton, this email is a written form of a comment I made during the CEC Staff Workshop on August 3<sup>rd</sup>, Docket #: 17-AAER-01, Project Title: Appliance Efficiency Pre-Rulemaking for Commercial Tumble Dryers and Air Filter Labeling.

With regard to Air filter labeling, when a replaceable filter designed for an electrically enhanced air purifier is tested, it will be done so within the air purifier it is designed for and will typically only achieve the tested levels or performance when used in such an air purifier. It is therefore suggested that additional text be added next to the rating box on an electrically enhanced air filter to indicate that the filter efficiency measurements are only valid when the filters is used in the electrically enhanced air purifier for which it was designed.

Please let me know if you have questions or would like to discuss the matter further,

- Peter McKinney

Peter J. McKinney  
Principal Engineer, Research Engineering  
StrionAir, Inc.  
410 South Arthur Ave.  
Louisville, CO 80027  
email: [pmckinney@strionair.com](mailto:pmckinney@strionair.com)  
phone: 303.926.5668  
mobile: 303.547.8847  
fax: 303.664.1210  
[www.strionair.com](http://www.strionair.com)