

## DOCKETED

<b>Docket Number:</b>	17-BSTD-01
<b>Project Title:</b>	2019 Building Energy Efficiency Standards PreRulemaking
<b>TN #:</b>	219880
<b>Document Title:</b>	UC Davis Comments Questionable Energy Savings Assumptions
<b>Description:</b>	N/A
<b>Filer:</b>	System
<b>Organization:</b>	UC Davis/Chris Jakober
<b>Submitter Role:</b>	Public Agency
<b>Submission Date:</b>	6/23/2017 1:55:15 PM
<b>Docketed Date:</b>	6/23/2017

*Comment Received From: Chris Jakober*

*Submitted On: 6/23/2017*

*Docket Number: 17-BSTD-01*

## **Questionable Energy Savings Assumptions**

Most of our teachings laboratories, which would meet the fume hood density criteria of 1:35, are operated from 07:00-22:00 on weekdays.