

DOCKETED

Docket Number:	17-BSTD-01
Project Title:	2019 Building Energy Efficiency Standards PreRulemaking
TN #:	220186
Document Title:	RNM Engineering, Inc. Comments On 2019 Nonresidential Standards - 130.1(b)2
Description:	N/A
Filer:	System
Organization:	RNM Engineering, Inc.
Submitter Role:	Public
Submission Date:	7/14/2017 1:46:59 PM
Docketed Date:	7/14/2017

Comment Received From: RNM Engineering, Inc.

Submitted On: 7/14/2017

Docket Number: 17-BSTD-01

On 2019 Nonresidential Standards - 130.1(b)2

Additional submitted attachment is included below.

From: rickmiller@rnm-eng.com
Sent: Friday, July 14, 2017 11:48 AM
To: Energy - Docket Optical System
Subject: RE: Docket #17-BSTD-01 - 2019 Nonresidential Standards - 130.1(b)2

Existing language:

130.1(b)2. Multi-level lighting controls shall not override the functionality of other lighting controls required for compliance with Sections 130.1(a), and (c) through (e); and

Situation:

Many conference rooms and seminar rooms have windows and these windows are often times fitted with means to block out the daylight during AV presentations. During these presentations, the speakers need to be able to manually adjust the illumination within the room. With the current code language, the automatic daylighting controls, as defined in 130.1(d), take priority over manual control of the illumination.

Proposed language:

Add an Exception to allow manual dimming for the duration of a presentation.

Rick Miller
RNM Engineering, Inc.
90 Baron Canyon Ranch Road
San Luis Obispo, CA 93401
Fax: 805-781-0816
Mobile: 415-307-5106
Email: RickMiller@RNM-eng.com