

DOCKETED

Docket Number:	17-BSTD-02
Project Title:	2019 Title 24, Part 6, Building Energy Efficiency Standards Rulemaking
TN #:	222867
Document Title:	ARMA Comments Roof Slope
Description:	N/A
Filer:	System
Organization:	Michael D. Fischer
Submitter Role:	Public
Submission Date:	3/5/2018 3:05:56 PM
Docketed Date:	3/5/2018

Comment Received From: Michael D. Fischer

Submitted On: 3/5/2018

Docket Number: 17-BSTD-02

ARMA Comments Roof Slope

The Asphalt Roofing Manufacturers Association (ARMA) supports the proposed modification to define low-slope roofs less than 2:12. This change will correlate with building standards for both low and steep slope roofing systems in the California Building Code roofing provisions.