

DOCKETED

Docket Number:	07-AFC-09C
Project Title:	Canyon Power Plant - Compliance
TN #:	203397
Document Title:	Canyon Power Plant Amendment 2 Revised Air Dispersion Modeling Files
Description:	N/A
Filer:	Jerry Salamy
Organization:	CH2M HILL
Submitter Role:	Applicant Consultant
Submission Date:	12/2/2014 3:14:54 PM
Docketed Date:	12/2/2014



City of Anaheim
PUBLIC UTILITIES DEPARTMENT
Electric Operations Division

November 24, 2014

Mr. Dale Rundquist
Compliance Project Manager
Siting, Transmission and Environmental Protection (STEP) Division
California Energy Commission
1516 Ninth Street, MS-2000
Sacramento, CA 95814

Subject: Canyon Power Plant Petition to Amend (07-AFC-09C)

Dear Mr. Rundquist:

The City of Anaheim (City) received a request from the South Coast Air Quality Management District to include building induced downwash in the air dispersion modeling. In response to this request, the City incorporated building induced downwash into the air dispersion model and confirmed that the public health impact results presented in the City's Petition to Amend (TN203123) were not affected by such incorporation.

Attached are five compact discs, which include the revised air dispersion modeling input and output files and the revised health risk assessment files showing that the public health impacts presented in the Petition to Amend are still representative of the proposed project.

Please call me with any questions.

Sincerely,

Manny Robledo
Electric Operations Manager
City of Anaheim, as Operating Agent for Southern California Public Power Authority's
Canyon Power Plant