

<b>DOCKET</b>	
<b>06-NSHP-1</b>	
<b>DATE</b>	FEB 10 2011
<b>RECD.</b>	FEB10 2011

**From:** Michael Winkler <mlwinkle@yahoo.com>  
**To:** <docket@energy.state.ca.us>, <smiller@energy.state.ca.us>  
**Date:** 2/10/2011 1:07 PM  
**Subject:** Comments on NSHP and NSHP Workshop February 8, 2011

Climate zone 1 (north coast/Eureka) has virtually no air conditioning load so air conditioning is rarely installed. Even if space heating is being done with a heat pump, which also happens to include an an air conditioning capability, it is virtually impossible using EnergyPro to achieve the 30% reduction in cooling energy required for Tier 2. A 30% reduction in heating energy use is very feasible.

For these reasons, in climate zone 1, the 30% reduction in cooling energy should be dropped as a requirement for Tier 2 energy efficiency for NSHP.

Michael Winkler, CEPE, HERS

(707) 822-1857