

DOCKETED

Docket Number:	08-AFC-09C
Project Title:	Palmdale Energy Project (Formerly Palmdale Hybrid Power Plant) - Compliance
TN #:	206521-6
Document Title:	Palmdale Energy LLC's Response to City of Lancaster Data Request Set No.1 (1-13) DR-5 (Part 5)
Description:	N/A
Filer:	Marie Fleming
Organization:	DayZen LLC
Submitter Role:	Applicant Representative
Submission Date:	11/5/2015 4:21:44 PM
Docketed Date:	11/5/2015

APPENDIX C

Modeling Support Data

This appendix contains the following data and figures:

- C-1 Facility Plot Plan
- C-2a-2b-2c Site Layout
- C-3a-3b Facility Elevation Views
- C-4a-4e Wind Rose Figures (5)
- C-5 AVAQMD (MDAB) Air Monitoring Station Map

Modeling input/output files are included in the enclosed CD's.

Steam turbine hall outline. It is 99' tall.

Exhaust on CL of long axis; center of exhaust is 6' from south end.

Stack on CL of long axis, 8' in from south end of enclosure.

NOTES

1. THE EQUIPMENT SHOWN IS REPRESENTATIVE INFORMATION. THIS DESIGN IS SUBJECT TO CHANGE AT THE DISCRETION OF SIEMENS ENERGY, INC.
2. ROTOR AIR COOLER (ITEM 12) CANNOT BE MOVED DUE TO PRE-ENGINEERED PIPING. MOVING THE UNIT WILL IMPACT COOLER PIPING STRESSES AND LOADS.
3. CLOSED COOLING WATER FIN FAN COOLER (ITEM 29) IS FOR COOLING BALANCE OF PLANT EQUIPMENT AND STEAM TURBINE GENERATOR ONLY.
4. REFERENCE DRAWING GH99050101 FOR POWER ISLAND EQUIPMENT IDENTIFICATION.

LEGEND

1	UMB	GAS TURBINE ENCLOSURE
2	MKJ	GENERATOR AIR INLET FILTER
3	MBL	GAS TURBINE AIR INLET FILTER
4	CJT	SEE/SFC PACKAGE
5	UBA03-04	MV SWITCHGEAR
6	BAC	GENERATOR CIRCUIT BREAKER
7	BBT	AUXILIARY TRANSFORMER
8	BAT	GENERATOR STEP UP TRANSFORMER
9	BAA	ISOPHASE BUS DUCT
10	UBH	OIL/WATER SEPARATOR
11	MBY	MOBILE COMPRESSOR WASH SKID
12	MBH	ROTOR AIR COOLER
13	EKT	DUCT FIRING SKID
14	HSK	SCR SKID
15	UHA	HEAT RECOVERY STEAM GENERATOR
16	UHN	HRSG EXHAUST STACK
17	CFE	CONTINUOUS EMISSIONS MONITORING
18	UHB	AUXILIARY BOILER
19	LAC	BOILER FEED WATER PUMPS
20	LCN	CONDENSATE RECIRC. PUMP
21	UHW	BOILER BLOWDOWN
22	EKC	FUEL GAS PREHEATER
23	QU	SAMPLING CONTAINER
24	USV	LABORATORY CONTAINER
25	UMA/MKA02	STEAM TURBINE ENCLOSURE & GENERATOR
26	MAL	DRAIN PIT
27	SCA	AIR COMPRESSOR SKID
28	PGB	CLOSED COOLING WATER PUMPS
29	URB	CLOSED COOLING WATER FIN FAN COOLER
30	URX	SURGE TANK
31	UBA05	CCW FIN FAN MOTOR CONTROL CENTER
32	MAJ	VACUUM PUMPS
33	ULC	CONDENSATE RETURN TANK
34	LCB	CONDENSATE EXTRACTION PUMPS
35	URC	AIR COOLED CONDENSER
36	UBA06	ACC POWER CONTROL CENTER
37	UBA07	STEAM TURBINE POWER CONTROL CENTER
38	UBA08	BALANCE OF PLANT POWER CONTROL CENTER
39	BFT	LV TRANSFORMER
40	XKA	EMERGENCY DIESEL GENERATOR
41	UGX	DEMIN. WATER FORWARDING PUMPS
42	UGC	DEMIN. WATER STORAGE TANK
43	UGD/GCB	WATER TREATMENT MODULE/MULTI-MEDIA FILTER
44	GAJ	RAW WATER FORWARDING PUMPS
45	UGA/UGF	RAW/FIRE WATER STORAGE TANK
46	USG	FIRE WATER PUMPS
47	UBA09	WATER TREATMENT AREA MCC
48	UTR	AMMONIA STORAGE/UNLOADING
49	EKE	FUEL GAS CONDITIONING/METERING
50	UCA/UST/UYC	ADMIN./CONTROL RM. WAREHOUSE BUILDING
51	UYX	SAFETY SHOWER & EYE WASH
52	UZA	ROAD
53	UZD	PARKING AREA
54	UZJ	FENCE & GATES





Figure C1 Plot Plan



This document contains information confidential to Siemens Energy, Inc. It is submitted in confidence and is to be used solely for the purpose for which it is furnished and returned upon request. This document and such information is not to be reproduced, transmitted, disclosed or used otherwise, in whole or in part, without written authorization from Siemens Energy, Inc.
© 2015 Siemens Energy, Inc.

Rev.	Date	Coor.	Checked	Details of Revision

CONCEPTUAL				
Origin	Origin No.	Origin PC		
Project		SUMMIT POWER - PALMDALE		PIZPC
				US1327
Drawn	Date	Name	Scale	UADCC Type
16/04/18	16/04/18	D. STALLERBURGER		General Code
Coord.	16/04/18	A. KIBAL		
Checked	16/04/18	G. SPRODE		
Title				Reg. No.
GENERAL ARRANGEMENT				A-3363-02
FACILITY PLOT PLAN				Rev.
SCC6-5000F 2 X 1 W AIR COOLED CONDENSER				01
HEAVY DUCT FIRING				Page No.
				1 of 1
Dep.		UADCC		Application
SIEMENS		ORL PLCI		
Energy, Inc.				
Designed with: GH99100101				
Integrating: GH99100101_R1.dgn				
Supersedes: 1				

Figure C2a

See Drawing File GH99090101_R1

Figure C2b

See Drawing File GH99100101_R1

Figure C2c

See Drawing File SKH99110101_R1

8 7 6 5 4 3 2 1

- NOTES**
1. THE EQUIPMENT SHOWN IS REPRESENTATIVE INFORMATION. THIS DESIGN IS SUBJECT TO CHANGE AT THE DISCRETION OF SIEMENS ENERGY, INC.
 2. ROTOR AIR COOLER (ITEM 12) CANNOT BE MOVED DUE TO PRE-ENGINEERED PIPING. MOVING THE UNIT WILL IMPACT COOLER PIPING STRESSES AND LOADS.
 3. CLOSED COOLING WATER FIN FAN COOLER (ITEM 29) IS FOR COOLING BALANCE OF PLANT EQUIPMENT AND STEAM TURBINE GENERATOR ONLY.
 4. REFERENCE DRAWING GH99050101 FOR POWER ISLAND EQUIPMENT IDENTIFICATION.

- LEGEND**
- | | | |
|----|-------------|---|
| 1 | UMB | GAS TURBINE ENCLOSURE |
| 2 | MKJ | GENERATOR AIR INLET FILTER |
| 3 | MBL | GAS TURBINE AIR INLET FILTER |
| 4 | CJT | SEE/SFC PACKAGE |
| 5 | UBA03-04 | MV SWITCHGEAR |
| 6 | BAC | GENERATOR CIRCUIT BREAKER |
| 7 | BBT | AUXILIARY TRANSFORMER |
| 8 | BAT | GENERATOR STEP UP TRANSFORMER |
| 9 | BAA | ISOPHASE BUS DUCT |
| 10 | UBH | OIL/WATER SEPERATOR |
| 11 | MBY | MOBILE COMPRESSOR WASH SKID |
| 12 | MBH | ROTOR AIR COOLER |
| 13 | EKT | DUCT FIRING SKID |
| 14 | HSK | SCR SKID |
| 15 | UHA | HEAT RECOVERY STEAM GENERATOR |
| 16 | UHN | HRSG EXHAUST STACK |
| 17 | CFE | CONTINUOUS EMISSIONS MONITORING |
| 18 | UHB | AUXILIARY BOILER |
| 19 | LAC | BOILER FEED WATER PUMPS |
| 20 | LCN | CONDENSATE RECIRC. PUMP |
| 21 | UHW | BOILER BLOWDOWN |
| 22 | EKC | FUEL GAS PREHEATER |
| 23 | QU | SAMPLING CONTAINER |
| 24 | USV | LABORATORY CONTAINER |
| 25 | UMA/MKA02 | STEAM TURBINE ENCLOSURE & GENERATOR |
| 26 | MAL | DRAIN PIT |
| 27 | SCA | AIR COMPRESSOR SKID |
| 28 | PGB | CLOSED COOLING WATER PUMPS |
| 29 | URB | CLOSED COOLING WATER FIN FAN COOLER |
| 30 | URX | SURGE TANK |
| 31 | UBA05 | CCW FIN FAN MOTOR CONTROL CENTER |
| 32 | MAJ | VACUUM PUMPS |
| 33 | ULC | CONDENSATE RETURN TANK |
| 34 | LCB | CONDENSATE EXTRACTION PUMPS |
| 35 | URC | AIR COOLED CONDENSER |
| 36 | UBA06 | ACC POWER CONTROL CENTER |
| 37 | UBA07 | STEAM TURBINE POWER CONTROL CENTER |
| 38 | UBA08 | BALANCE OF PLANT POWER CONTROL CENTER |
| 39 | BFT | LV TRANSFORMER |
| 40 | XKA | EMERGENCY DIESEL GENERATOR |
| 41 | UGX | DEMIN. WATER FORWARDING PUMPS |
| 42 | UGC | DEMIN. WATER STORAGE TANK |
| 43 | UGD/GCB | WATER TREATMENT MODULE/MULTI-MEDIA FILTER |
| 44 | GAJ | RAW WATER FORWARDING PUMPS |
| 45 | UGA/UGF | RAW/FIRE WATER STORAGE TANK |
| 46 | USG | FIRE WATER PUMPS |
| 47 | UBA09 | WATER TREATMENT AREA MCC |
| 48 | UTR | AMMONIA STORAGE/UNLOADING |
| 49 | EKE | FUEL GAS CONDITIONING/METERING |
| 50 | UCA/UST/UYC | ADMIN./CONTROL RM. WAREHOUSE BUILDING |
| 51 | UYX | SAFETY SHOWER & EYE WASH |
| 52 | UZA | ROAD |
| 53 | UZD | PARKING AREA |
| 54 | UZJ | FENCE & GATES |






Figure C2b Site Layout





Rev.	Date	Coor.	Checked	Details of Revision

CONCEPTUAL				Original No.	Orig-PC
Project				SUMMIT POWER - PALMDALE	
Title				US1327	
Drawn	Date	Name	Scale	UADCC Type	Control Code
16/04/18	16/04/18	D. STALLERBURGER			
Coord.	16/04/18	A. KIBAL			
Checked	16/04/18	G. SPRODE			
HEAVY DUCT FIRING				Reg No.	A-3363-02
SIEMENS				Dep.	ORL PLCI
Energy, Inc.				UADCC	01
GH99100101				Application	Page No.
GH99100101_R1.dgn				Supersedes	1 of 1

This document contains information confidential to Siemens Energy, Inc. It is submitted in confidence and is to be used solely for the purpose for which it is furnished and returned upon request. This document and such information is not to be reproduced, transmitted, disclosed or used otherwise, in whole or in part, without written authorization from Siemens Energy, Inc.
© 2015 Siemens Energy, Inc.

8 7 6 5 4 3 2 1



NOTES

1. THE EQUIPMENT SHOWN IS REPRESENTATIVE INFORMATION. THIS DESIGN IS SUBJECT TO CHANGE AT THE DISCRETION OF SIEMENS ENERGY, INC.
2. REFERENCE DRAWING GH99050101 FOR POWER ISLAND EQUIPMENT IDENTIFICATION.
3. REFERENCE DRAWING GH99060101 FOR FACILITY PLOT PLAN EQUIPMENT IDENTIFICATION.


LEGEND

- | | | |
|----|-------------|---|
| 1 | UMB | GAS TURBINE ENCLOSURE |
| 2 | UHA | HEAT RECOVERY STEAM GENERATOR |
| 3 | BAT | GENERATOR STEP UP TRANSFORMER |
| 4 | UBH | OIL/WATER SEPERATOR |
| 5 | XKA | EMERGENCY DIESEL GENERATOR |
| 6 | MA/MKA | STEAM TURBINE & GENERATOR |
| 7 | UHB | AUXILIARY BOILER |
| 8 | URC | AIR COOLED CONDENSER |
| 9 | URB | CLOSED COOLING WATER FIN FAN COOLER |
| 10 | UGC | DEMIN. WATER STORAGE TANK |
| 11 | UGD | WATER TREATMENT MODULES |
| 12 | UCA/UGF | RAW/FIRE WATER STORAGE TANK |
| 13 | UYX | AMMONIA STORAGE/UNLOADING |
| 14 | EKD/EKE | FUEL GAS REGULATION/CONDITIONING/METERING |
| 15 | UCA/UST/UYC | ADMIN./CONTROL RM. WAREHOUSE BUILDING |
| 16 | UYE | GUARD HOUSE |
| 17 | UZA | ROAD |
| 18 | UZD | PARKING AREA |
| 19 | UZJ | FENCE & GATES |
| 20 | | PROPERTY BOUNDARY |
| 21 | | 20 ACRE LAYDOWN AREA |
| 22 | | SWITCHYARD (BY OTHERS) |
| 23 | | SWITCHYARD FENCE (BY OTHERS) |
| 24 | | EXISTING ROAD |

TERMINAL POINTS

- | | |
|---|-------------------------------|
| A | FUEL GAS SUPPLY |
| B | RAW WATER SUPPLY |
| C | AMMONIA SUPPLY |
| D | HV POWER |
| E | OILY WATER (MANUAL DISCHARGE) |
| F | POTABLE WATER |
| G | SANITARY SEWER |
| H | TEMPORARY CONSTRUCTION POWER |

Figure C2c Site Layout



This document contains information confidential to Siemens Energy, Inc. It is submitted in confidence and is to be used solely for the purpose for which it is furnished and returned upon request. This document and such information is not to be reproduced, transmitted, disclosed or used otherwise, in whole or in part, without written authorization from Siemens Energy, Inc.
© 2015 Siemens Energy, Inc.

CONCEPTUAL			
Origin	Origin No.	Orig. PC	
Project: SUMMIT POWER - PALMDALE			PIZPC: US1327
Drawn	Date	Name	Scale
16 / 04 / 18		D. STULLENBURGER	
Title: GENERAL ARRANGEMENT			UADCC Type
Coord.	16 / 04 / 18	A. KIBAL	Control Code
Checked	16 / 04 / 18	G. SPRODE	
Description: SCC6-5000F 2 X 1 W AIR COOLED CONDENSER HEAVY DUCT FIRING			Reg No. A-3353-02
SIEMENS Energy, Inc.			Rev. 01
Dep. ORL PLCI			Version
UADCC			Page No. 1 of 1
GH99110101			
Designed with: Ingraph GH99110101_R1.dgn			Supersedes
Rev.	Date	Coord.	Checked
Details of Revision			

Rev.	Date	Coord.	Checked	Details of Revision




Figure C3a Elevation View #1

LEGEND

- | | | |
|----|----------|-------------------------------|
| 1 | MKA01/02 | GAS TURBINE GENERATOR |
| 2 | UBA01-02 | GAS TURBINE PCC |
| 3 | MBL | TURBINE AIR INLET FILTER |
| 4 | UHA | HEAT RECOVERY STEAM GENERATOR |
| 5 | UHN | HRSG EXHAUST STACK |
| 6 | BAT | GENERATOR STEP UP TRANSFORMER |
| 7 | UBA03-04 | MEDIUM VOLTAGE SWITCHGEAR |
| 8 | UMA | HP/IP STEAM TURBINE ENCLOSURE |
| 9 | MAC | LP STEAM TURBINE |
| 10 | UAA | ISOPHASE BUS DUCT |

NOTES

1. THE EQUIPMENT SHOWN IS REPRESENTATIVE INFORMATION. THIS DESIGN IS SUBJECT TO CHANGE AT THE DISCRETION OF SIEMENS ENERGY, INC.
2. ALL DIMENSIONS SHOWN ARE IN FEET AND INCHES (METERS).

This document contains information confidential to Siemens Energy, Inc. It is submitted in confidence and is to be used solely for the purpose for which it is furnished and returned upon request. This document and such information is not to be reproduced, transmitted, disclosed or used otherwise, in whole or in part, without written authorization from Siemens Energy, Inc.
 © 2015 Siemens Energy, Inc.

CONCEPTUAL

Original		Original No.		Orig-PC
Project: SUMMIT POWER - PALMDALE				
				PIZZO US1327
Drawn	16 / 04 / 28	D. STULLENBURGER	Title	UADCC Type
Coord.	16 / 04 / 28	A. KIBAL	GENERAL ARRANGEMENT	Contract Code
Checked	16 / 04 / 28	G. SPINDE	POWER BLOCK ELEVATION	
Dep't: SIEMENS Energy, Inc.				Reg. No. A-3363-02
Dep't: ORL PLCI			UADCC	Rev. 01
Application: GH99120101				Page No. 1 of 1
Designed with: Inograph		GH99120101_R1.dgn		Supersedes: 1

Rev.	Date	Coord.	Checked	Details of Revision




Figure C3b Elevation View #2

LEGEND

- 1 UMB GAS TURBINE ENCLOSURE
- 2 MKA01/02 GAS TURBINE GENERATOR
- 3 MBL TURBINE AIR INLET FILTER
- 4 UHA HEAT RECOVERY STEAM GENERATOR
- 5 UHN HRSG EXHAUST STACK
- 6 CFE CONTINUOUS EMISSIONS MONITORING
- 7 HSK SCR SKID
- 8 UHN DUCT FIRING SKID
- 9 BAC GENERATOR CIRCUIT BREAKER
- 10 BBT AUXILIARY TRANSFORMER
- 11 BAT GENERATOR STEP UP TRANSFORMER
- 12 BAA ISOPHASE BUS DUCT

NOTES

- 1. THE EQUIPMENT SHOWN IS REPRESENTATIVE INFORMATION. THIS DESIGN IS SUBJECT TO CHANGE AT THE DISCRETION OF SIEMENS ENERGY, INC.
- 2. ALL DIMENSIONS SHOWN ARE IN FEET AND INCHES (METERS).

CONCEPTUAL			
Original	Original No.	Orig.-PC	
Project: SUMMIT POWER - PALMDALE			PIZPC: US1327
Drawn	Date	Name	Scale
16/04/18	16/04/18	D. STALLERBURGER	
Coord.	16/04/18	A. KIBAL	
Checked	16/04/18	G. SPINDE	
Title: GENERAL ARRANGEMENT			UADCC Type
Title: GAS TURBINE ELEVATION			Control Code
Title: SCC6-5000F 2 X 1 W/AIR COOLED CONDENSER			
Title: HEAVY DUCT FIRING			Reg. No. A-3363-02
Dept. SIEMENS Energy, Inc.		ORL PLCI	Version 01
Designation: GH99080101			Page No. 1 of 1
Designed with: Integrgraph			Supersedes

This document contains information confidential to Siemens Energy, Inc. It is submitted in confidence and is to be used solely for the purpose for which it is furnished and returned upon request. This document and such information is not to be reproduced, transmitted, disclosed or used otherwise, in whole or in part, without written authorization from Siemens Energy, Inc.
 © 2015 Siemens Energy, Inc.

Rev.	Date	Coord.	Checked	Details of Revision

Figure C4a

Winter Composite Wind Rose




Figure C4b
Spring Composite Wind Rose




Figure C4c

Summer Composite Wind Rose




Figure C4d

Fall Composite Wind Rose





Figure C4e

Annual Composite Wind Rose



Palmdale AERMOD Turbine Screening Results

Regular Receptor Grids

160' Stack Height

Emissions Case	Case 1	Case 2	Case 3	Case 4	Case 25	Case 10	Case 11	Case 12	Case 13	Case 14	Case 27
Modeling Case	11	12	13	14	15	21	22	23	24	25	26
Evaporative Cooler	OFF	OFF	OFF	OFF	OFF	OFF	ON	ON	OFF	OFF	OFF
Duct Firing	OFF	ON	OFF	OFF	OFF	OFF	OFF	ON	OFF	OFF	OFF
Load %	100%	100%	75%	50%	40%	100%	100%	100%	75%	50%	43%
Ambient Temp, °F	23	23	23	23	23	64	64	64	64	64	64
Stack Exit Temp (deg.F)	195	186	190	184	182	194	195	187	181	178	177
Volumetric Flowrate ACFM	1,337,241	1,322,717	1,075,349	875,178	797,863	1,327,666	1,334,691	1,323,975	1,022,155	836,978	784,096
Stack Inside Diameter (ft)	22.00	22.00	22.00	22.00	22.00	22.00	22.00	22.00	22.00	22.00	22.00
Stack Height (m)	48.768	48.768	48.768	48.768	48.768	48.768	48.768	48.768	48.768	48.768	48.768
Stack Exit Temp (deg.K)	363.7	358.7	360.9	357.6	356.5	363.2	363.7	359.3	355.9	354.3	353.7
Stack Exit Velocity (m/s)	17.87	17.68	14.37	11.70	10.66	17.74	17.84	17.69	13.66	11.19	10.48
Stack Inside Diameter (m)	6.7056	6.7056	6.7056	6.7056	6.7056	6.7056	6.7056	6.7056	6.7056	6.7056	6.7056

Normal Operations - Short-term Screening Emissions (lb/hr/turbine) and Unitized Screening Impacts (for 1.0 g/s/turbine)

NOx (lb/hr/turbine)	17.1	18.5	13.6	10.5	9.2	16.4	16.7	18.1	13.0	10.0	9.2
CO (lb/hr/turbine)	10.4	11.3	8.3	6.4	5.6	10.0	10.2	11.0	7.9	6.1	5.6
SO2 (lb/hr/turbine)	1.4	1.5	1.1	0.9	0.8	1.4	1.4	1.5	1.1	0.9	0.8
PM10 (lb/hr/turbine)	9.8	11.8	8.0	8.0	8.0	9.7	9.7	11.7	8.0	8.0	8.0
1-Hr Unitized Conc (ug/m ³)	7.34915	7.62897	8.26260	9.78110	10.41849	7.39375	7.35479	7.59418	8.93690	10.30569	10.72298
X(m)	392500.0	388000.0	398020.0	398020.0	398020.0	392500.0	392500.0	388000.0	398020.0	398020.0	398020.0
Y(m)	3825500.0	3831000.0	3834380.0	3834380.0	3834380.0	3825500.0	3825500.0	3831000.0	3834380.0	3834380.0	3834380.0
Z(m)	914.3	910.1	764.8	764.8	764.8	914.3	914.3	910.1	764.8	764.8	764.8
YYMMDDHH	14102504	12060105	10082424	10082424	10082424	14102504	14102504	12060105	10082424	10082424	10082424
3-Hr Unitized Conc (ug/m ³)	5.93334	6.06396	7.14942	8.24275	8.75465	5.98564	5.93870	6.05471	7.42850	8.57670	8.92811
X(m)	398702.1	398702.1	398702.1	398702.1	398702.1	398702.1	398702.1	398702.1	398702.1	398702.1	398702.1
Y(m)	3833866.5	3833866.5	3833866.5	3833866.5	3833866.5	3833866.5	3833866.5	3833866.5	3833866.5	3833866.5	3833866.5
Z(m)	761.3	761.3	761.3	761.3	761.3	761.3	761.3	761.3	761.3	761.3	761.3
YYMMDDHH	11083015	11083015	11083015	10080118	10080118	11083015	11083015	11083015	11083015	10080118	10080118
8-Hr Unitized Conc (ug/m ³)	5.30183	5.41476	6.34053	7.39423	7.89625	5.33892	5.30345	5.39359	6.63047	7.70439	8.04539
X(m)	398722.1	398722.1	398722.1	398702.1	398702.1	398722.1	398722.1	398722.1	398722.1	398702.1	398702.1
Y(m)	3833866.5	3833866.5	3833866.5	3833866.5	3833866.5	3833866.5	3833866.5	3833866.5	3833866.5	3833866.5	3833866.5
Z(m)	761.3	761.3	761.3	761.3	761.3	761.3	761.3	761.3	761.3	761.3	761.3
YYMMDDHH	12052516	12052516	12052516	10071216	10071216	12052516	12052516	12052516	12052516	10071216	10071216
24-Hr Unitized Conc (ug/m ³)	4.08550	4.19621	5.15790	6.35490	6.84349	4.12166	4.09336	4.18367	5.55867	6.65417	6.99455
X(m)	398880.0	398880.0	398722.1	398722.1	398722.1	398880.0	398880.0	398880.0	398722.1	398722.1	398722.1
Y(m)	3833880.0	3833880.0	3833866.5	3833866.5	3833866.5	3833880.0	3833880.0	3833880.0	3833866.5	3833866.5	3833866.5
Z(m)	762.9	762.9	761.3	761.3	761.3	762.9	762.9	762.9	761.3	761.3	761.3
YYMMDDHH	12102124	12102124	12050224	12050224	12050224	12102124	12102124	12102124	12050224	12050224	12050224

Normal Operations - Short-term Pollutant Emissions (g/s/turbine) and Pollutant Screening Impacts

NOx (g/s/turbine)	2.155	2.331	1.714	1.323	1.159	2.066	2.104	2.281	1.638	1.260	1.159
CO (g/s/turbine)	1.310	1.424	1.046	0.806	0.706	1.260	1.285	1.386	0.995	0.769	0.706
SO2 (g/s/turbine)	0.176	0.189	0.139	0.113	0.101	0.176	0.176	0.189	0.139	0.113	0.101
PM10 (g/s/turbine)	1.235	1.487	1.008	1.008	1.008	1.222	1.222	1.474	1.008	1.008	1.008
1-Hour NOx (ug/m ³)	15.837	17.783	14.162	12.940	12.075	15.275	15.474	17.322	14.639	12.985	12.428
1-Hour CO (ug/m ³)	9.627	10.864	8.643	7.884	7.355	9.316	9.451	10.526	8.892	7.925	7.570
8-Hour CO (ug/m ³)	6.945	7.711	6.632	5.960	5.575	6.727	6.815	7.476	6.597	5.925	5.680
1-Hour SO2 (ug/m ³)	1.293	1.442	1.149	1.105	1.052	1.301	1.294	1.435	1.242	1.165	1.083
3-Hour SO2 (ug/m ³)	1.044	1.146	0.994	0.931	0.884	1.053	1.045	1.144	1.033	0.969	0.902
24-Hour SO2 (ug/m ³)	0.719	0.793	0.717	0.718	0.691	0.725	0.720	0.791	0.773	0.752	0.706
24-Hour PM10 (ug/m ³)	5.046	6.240	5.199	6.406	6.898	5.037	5.002	6.167	5.603	6.707	7.051

Worst-Case Operating Scenarios are **bolded**.

Palmdale AERMOD Turbine Screening Results

Regular Receptor Grids

160' Stack Height

60' SH

Emissions Case	Case 15	Case 16	Case 17	Case 18	Case 19	Case 20	Case 21	Case 22	Case 23	Case 24	Aux.Boiler
Modeling Case	31	32	33	34	35	41	42	43	44	45	NA
Evaporative Cooler	OFF	ON	ON	OFF	OFF	OFF	ON	ON	OFF	OFF	NA
Duct Firing	OFF	OFF	ON	OFF	OFF	OFF	OFF	ON	OFF	OFF	NA
Load %	100%	100%	100%	75%	50%	100%	100%	100%	75%	53%	NA
Ambient Temp, °F	98	98	98	98	98	108	108	108	108	108	NA
Stack Exit Temp (deg.F)	201	208	200	192	184	205	213	206	196	190	300
Volumetric Flowrate ACFM	1,222,268	1,346,870	1,335,763	967,113	792,896	1,182,441	1,344,061	1,333,863	951,970	803,665	28,413
Stack Inside Diameter (ft)	22.00	22.00	22.00	22.00	22.00	22.00	22.00	22.00	22.00	22.00	3.00
Stack Height (m)	48.768	48.768	48.768	48.768	48.768	48.768	48.768	48.768	48.768	48.768	18.288
Stack Exit Temp (deg.K)	367.0	370.9	366.5	362.0	357.6	369.3	373.7	369.8	364.3	369.9	422.0
Stack Exit Velocity (m/s)	16.33	18.00	17.85	12.92	10.60	15.80	17.96	17.83	12.72	10.74	20.42
Stack Inside Diameter (m)	6.7056	6.7056	6.7056	6.7056	6.7056	6.7056	6.7056	6.7056	6.7056	6.7056	0.9144
Normal Operations - Short-ter:											
NOx (lb/hr/turbine)	14.6	16.3	17.7	11.9	9.2	14.0	16.1	17.6	11.4	9.2	1.21
CO (lb/hr/turbine)	8.9	9.9	10.8	7.2	5.6	8.5	9.8	10.7	6.9	5.6	4.05
SO2 (lb/hr/turbine)	1.2	1.3	1.5	1.0	0.8	1.2	1.3	1.4	1.0	0.8	0.066
PM10 (lb/hr/turbine)	8.8	9.5	11.5	8.0	8.0	8.5	9.4	11.5	8.0	8.0	0.81
1-Hr Unitized Conc (ug/m3)	7.54027	7.01690	7.23661	8.87323	10.38507	7.57268	6.90535	7.10146	8.81644	10.08316	96.63587
X(m)	388000.0	392500.0	392500.0	398020.0	398020.0	388000.0	392500.0	392500.0	398020.0	398020.0	398552.4
Y(m)	3831000.0	3825500.0	3825500.0	3834380.0	3834380.0	3831000.0	3825500.0	3825500.0	3834380.0	3834380.0	3833866.2
Z(m)	910.1	914.3	914.3	764.8	764.8	910.1	914.3	914.3	764.8	764.8	763.3
YYMMDDHH	12060105	14102504	14102504	10082424	10082424	12060105	14102504	14102504	10082424	10082424	13060103
3-Hr Unitized Conc (ug/m3)	6.37238	5.80534	5.90489	7.61867	8.75119	6.52908	5.78373	5.86125	7.64129	8.58672	65.34734
X(m)	398702.1	398702.1	398702.1	398702.1	398702.1	398702.1	398702.1	398702.1	398702.1	398702.1	398702.1
Y(m)	3833866.5	3833866.5	3833866.5	3833866.5	3833866.5	3833866.5	3833866.5	3833866.5	3833866.5	3833866.5	3833866.5
Z(m)	761.3	761.3	761.3	761.3	761.3	761.3	761.3	761.3	761.3	761.3	761.3
YYMMDDHH	11083015	11083015	11083015	10080118	10080118	11083015	11083015	11083015	10080118	10080118	14012006
8-Hr Unitized Conc (ug/m3)	5.69155	5.18881	5.27143	6.76642	7.89350	5.82701	5.15941	5.23020	6.79465	7.75323	56.26533
X(m)	398722.1	398722.1	398722.1	398722.1	398702.1	398722.1	398722.1	398722.1	398722.1	398702.1	398722.1
Y(m)	3833866.5	3833866.5	3833866.5	3833866.5	3833866.5	3833866.5	3833866.5	3833866.5	3833866.5	3833866.5	3833866.5
Z(m)	761.3	761.3	761.3	761.3	761.3	761.3	761.3	761.3	761.3	761.3	761.3
YYMMDDHH	12052516	12052516	12052516	12052516	10071216	12052516	12052516	12052516	12052516	10071216	14110808
24-Hr Unitized Conc (ug/m3)	4.37740	3.96185	4.05058	5.73758	6.84287	4.46619	3.93228	4.00657	5.77013	6.70560	34.30093
X(m)	398861.8	398880.0	398880.0	398722.1	398722.1	398861.8	398880.0	398880.0	398722.1	398722.1	398722.1
Y(m)	3833866.8	3833880.0	3833880.0	3833866.5	3833866.5	3833866.8	3833880.0	3833880.0	3833866.5	3833866.5	3833866.5
Z(m)	762.8	762.9	762.9	761.3	761.3	762.8	762.9	762.9	761.3	761.3	761.3
YYMMDDHH	12102124	12102124	12102124	12050224	12050224	12102124	12102124	12102124	12050224	12050224	14010224
Normal Operations - Short-ter:											
NOx (g/s/turbine)	1.840	2.054	2.230	1.499	1.159	1.764	2.029	2.218	1.436	1.159	0.152
CO (g/s/turbine)	1.121	1.247	1.361	0.907	0.706	1.071	1.235	1.348	0.869	0.706	0.510
SO2 (g/s/turbine)	0.151	0.164	0.189	0.126	0.101	0.151	0.164	0.176	0.126	0.101	0.009
PM10 (g/s/turbine)	1.109	1.197	1.449	1.008	1.008	1.071	1.184	1.449	1.008	1.008	0.102
1-Hour NOx (ug/m3)	13.874	14.413	16.138	13.301	12.036	13.358	14.011	15.751	12.660	11.686	14.689
1-Hour CO (ug/m3)	8.453	8.750	9.849	8.048	7.332	8.110	8.528	9.573	7.661	7.119	49.284
8-Hour CO (ug/m3)	6.380	6.470	7.174	6.137	5.573	6.241	6.372	7.050	5.905	5.474	28.695
1-Hour SO2 (ug/m3)	1.139	1.151	1.368	1.118	1.049	1.143	1.132	1.250	1.111	1.018	0.870
3-Hour SO2 (ug/m3)	0.962	0.952	1.116	0.960	0.884	0.986	0.949	1.032	0.963	0.867	0.588
24-Hour SO2 (ug/m3)	0.661	0.650	0.766	0.723	0.691	0.674	0.645	0.705	0.727	0.677	0.309
24-Hour PM10 (ug/m3)	4.855	4.742	5.869	5.783	6.898	4.783	4.656	5.806	5.816	6.759	3.499

Worst-Case Operating Scenario

Keyword: DFAULT

**Table 5.1B-4B
Palmdale Emission Rates and Stack Parameters for Refined Modeling**

	Stack Height, meters	Temp, deg K	Exhaust Velocity, m/s	Stack Diam, m	Emission Rates, g/s				Emission Rates, lb/hr				
					NOx	SO2	CO	PM10	NOx	SO2	CO	PM10	
Averaging Period: One hour for Normal Operations													
Turbine S/HRSG	48.768	358.7	17.68	6.7056	2.331	0.189	1.424	-	18.5	1.5	11.3	-	-
Turbine N/HRSG	48.768	358.7	17.68	6.7056	2.331	0.189	1.424	-	18.5	1.5	11.3	-	-
Auxiliary Boiler	18.288	422.04	20.42	0.9144	0.152	8.316E-3	0.510	-	1.21	0.066	4.05	0.81	-
Fire Pump	5.944	823.71	28.13	0.1270	0.109	2.389E-4	0.144	-	0.864	1.896E-3	1.142	-	-
Emergency Generator	6.096	677.04	158.76	0.2032	1.056	1.358E-3	0.187	-	8.379	1.078E-2	1.485	-	-
Averaging Period: Three hours for Normal Operations													
Turbine S/HRSG	48.768	358.7	17.68	6.7056	-	0.189	-	-	-	1.5	-	-	-
Turbine N/HRSG	48.768	358.7	17.68	6.7056	-	0.189	-	-	-	1.5	-	-	-
Auxiliary Boiler	18.288	422.04	20.42	0.9144	-	2.772E-3	-	-	-	2.200E-2	-	-	-
Fire Pump	5.944	823.71	28.13	0.1270	-	7.964E-5	-	-	-	6.320E-4	-	-	-
Emergency Generator	6.096	677.04	158.76	0.2032	-	4.527E-4	-	-	-	3.593E-3	-	-	-
Averaging Period: Eight hours for Normal Operations													
Turbine S/HRSG	48.768	358.7	17.68	6.7056	-	-	1.424	-	-	-	11.3	-	-
Turbine N/HRSG	48.768	358.7	17.68	6.7056	-	-	1.424	-	-	-	11.3	-	-
Auxiliary Boiler	18.288	422.04	20.42	0.9144	-	-	0.064	-	-	-	0.506	-	-
Fire Pump	5.944	823.71	28.13	0.1270	-	-	0.018	-	-	-	0.143	-	-
Emergency Generator	6.096	677.04	158.76	0.2032	-	-	0.023	-	-	-	0.186	-	-
Averaging Period: 24 hours for Normal Operations													
Turbine S/HRSG - SO2/Case 2	48.768	358.7	17.68	6.7056	-	0.189	-	1.487	-	1.5	-	11.8	-
Turbine N/HRSG - SO2/Case 2	48.768	358.7	17.68	6.7056	-	0.189	-	1.487	-	1.5	-	11.8	-
Turbine S/HRSG - PM/Case 27	48.768	353.7	10.48	6.7056	-	-	-	1.008	-	-	-	8.0	-
Turbine N/HRSG - PM/Case 27	48.768	353.7	10.48	6.7056	-	-	-	1.008	-	-	-	8.0	-
Auxiliary Boiler	18.288	422.04	20.42	0.9144	-	6.930E-4	-	8.505E-3	-	5.500E-3	-	6.750E-2	-
Fire Pump	5.944	823.71	28.13	0.1270	-	9.954E-6	-	3.565E-4	-	7.900E-5	-	2.829E-3	-
Emergency Generator	6.096	677.04	158.76	0.2032	-	5.659E-5	-	1.047E-3	-	4.491E-4	-	8.313E-3	-
Averaging Period: Annual Periods (includes all Startups/Shutdowns), based on Case 11 (No DB, EVAP on)													
Turbine S/HRSG	48.768	363.7	17.84	6.7056	1.988	-	-	1.160	15.781	-	-	9.209	-
Turbine N/HRSG	48.768	363.7	17.84	6.7056	1.988	-	-	1.160	15.781	-	-	9.209	-
Auxiliary Boiler	18.288	422.04	20.42	0.9144	1.455E-2	-	-	9.740E-3	1.155E-1	-	-	7.730E-2	-
Fire Pump	5.944	823.71	28.13	0.1270	6.464E-4	-	-	5.079E-5	5.130E-3	-	-	4.031E-4	-
Emergency Generator	6.096	677.04	158.76	0.2032	6.267E-3	-	-	1.492E-4	4.974E-2	-	-	1.184E-3	-
Averaging Period: One hour for Cold Start based on Case 27 (CAAQS)													
Turbine S/HRSG	48.768	353.7	10.48	6.7056	7.241	-	52.849	-	57.465	-	419.440	-	-
Turbine N/HRSG	48.768	353.7	10.48	6.7056	7.241	-	52.849	-	57.465	-	419.44	-	-
Auxiliary Boiler	18.288	422.04	20.42	0.9144	0.152	-	0.510	-	1.21	-	4.05	-	-
Averaging Period: One hour for Warm Start based on Case 27 (NAAQS) for NO2, Cold start for CO													
Turbine S/HRSG	48.768	353.7	10.48	6.7056	6.795	-	52.849	-	53.925	-	419.440	-	-
Turbine N/HRSG	48.768	353.7	10.48	6.7056	6.795	-	52.849	-	53.925	-	419.440	-	-
Auxiliary Boiler	18.288	422.04	20.42	0.9144	0.152	-	0.510	-	1.21	-	4.05	-	-
Averaging Period: Eight hours for Cold Start based on Case 2													
Turbine S/HRSG	48.768	358.7	17.68	6.7056	-	-	15.944	-	-	-	126.541	-	-
Turbine N/HRSG	48.768	358.7	17.68	6.7056	-	-	15.944	-	-	-	126.541	-	-
Auxiliary Boiler	18.288	422.04	20.42	0.9144	-	-	0.128	-	-	-	1.013	-	-
Fire Pump	5.944	823.71	28.13	0.1270	-	-	0.018	-	-	-	0.143	-	-
Emergency Generator	6.096	677.04	158.76	0.2032	-	-	0.023	-	-	-	0.186	-	-
Averaging Period: One hour for Commissioning (Case 27)													
Turbine N/HRSG	48.768	353.7	10.66	6.7056	16.632	-	567.000	-	132.000	-	4500.000	-	-
Turbine S/HRSG	48.768	353.7	10.66	6.7056	15.372	-	100.296	-	122.000	-	796.000	-	-
Auxiliary Boiler	18.288	422.04	20.42	0.9144	0.152	-	0.510	-	1.21	-	4.05	-	-
Averaging Period: Eight hours for Commissioning (Case 27)													
Turbine N/HRSG	48.768	353.7	17.68	6.7056	-	-	567.000	-	-	-	4500.000	-	-
Turbine S/HRSG	48.768	353.7	17.68	6.7056	-	-	100.296	-	-	-	796.000	-	-
Auxiliary Boiler	18.288	422.04	20.42	0.9144	-	-	0.128	-	-	-	1.013	-	-

Assumptions:

Turbine operates 24 hours per day for all cases and pollutants
 Aux.Boiler operates up to 1 hours per day **836 hours per year**
 Fire Pump operates up to 1 hours per day 52 hours per year
 Emer. Gen operates up to 0.5 hours per day 26 hours per year

Startup Emissions Calculations				
	1-hr NOx	1-hr CO	8-hr CO	mins/event
Cold Start (lb/event)	51.480	415.800	415.8	39
Shutdown (lb/event)	-	-	-	75.9
Warm Start (lb/event)	-	-	378	35
Balance (lb/hr)	17.10	10.40	10.40	-
Total (lb/hr)	57.465	419.440	126.541	-

Annual NOx & PM: Case 1 calc sheet (8000 hours made up of 1500 hours DB, 5 cold starts, 35 warm starts 40 shutdowns)
 CO and NOx 1-hour Startup Impacts: Cold start is 39 minutes, which is the worst case start, plus 21 minutes of worst-case base load emissions, but no DB.
 CO 8-hour Startup Impacts: Calculated as one cold start (39 mins) + one shutdown (25 mins) + one warm start (35 mins) + one shutdown (25 minutes)
 + one hour of max CO with DB plus remaining hours with DB.
 Fire pump and gen set not tested during 1 hour start cycle
 Aux boiler assumed to operate 2 hours for 8-hour CO startup modeling

Figure C5

AVAQMD (MDAB) Air Monitoring Sites

