DOCKETED	
Docket Number:	08-AFC-09C
Project Title:	Palmdale Energy Project (Formerly Palmdale Hybrid Power Plant) - Compliance
TN #:	210594
Document Title:	Palmdale Energy LLC's Revised Supplemental Response to California Energy Commission Staff Data Request 55 and 58
Description:	N/A
Filer:	Marie Fleming
Organization:	DayZen LLC
Submitter Role:	Applicant Representative
Submission Date:	3/2/2016 12:26:27 PM
Docketed Date:	3/2/2016

INTRODUCTION

Attached is Palmdale Energy, LLC's revised responses to California Energy Commission Staff (Staff) Data Requests 55 and 58 for the Palmdale Energy Project (PEP) Petition For Amendment. For context the text of the Data Requests precedes the Data Responses.

Data Request 55

Resubmit Figure 3-1a and Figure 3-1b.

- 1. Show bay arrangement of the necessary equipment which is required to interconnect the project.
- 2. Provide ratings of the breakers, disconnect switches, relays, buses, and etc.

Response to Data Request 55

Palmdale Energy has revised Figure AO1 to show rating for the generations and step-up transforms, Please also note that Figure 3-1b already includes ratings for the generators and step-up transformers and, as a single line drawing of the power block.

Data Request 58

Provide generator tie-line conductor type, current carrying capacity, and conductor size.

Response to Data Request 58

The generator tie-line conductor will be a horizontal double bundle (two conductors per phase) 1272 kcmil ACSR that will have rating of 2500 amps at the maximum designed operating temperature.

