

DOCKETED

Docket Number:	08-AFC-10C
Project Title:	Lodi Energy Center Project
TN #:	201866
Document Title:	AQ-19: Report of Startup Time and Proposed New Startup Time Limits
Description:	N/A
Filer:	Nancy Matthews
Organization:	Sierra Research
Submitter Role:	Applicant Consultant
Submission Date:	3/11/2014 12:51:33 PM
Docketed Date:	3/11/2014



March 10, 2014

PO Box 1478
12745 N Thornton Road
Lodi, CA 95241
(209) 333-6370
www.ncpa.com

Ms. Christine Stora
Compliance Project Manager
California Energy Commission
1516 Ninth Street, MS-2000
Sacramento, CA 95814

Subject: Lodi Energy Center [Docket 08-AFC-10C]
AQ-19: Report of Startup Time and Proposed New Startup Time Limits

Dear Ms. Stora:

In compliance with Condition of Certification AQ-19 as set forth in the California Energy Commission's Final Decision for the Lodi Energy Center, enclosed is a copy of the review of startup time limits and recommended new time limits for each type of startup that reflect the effect of the Siemens "Flex Plant 30" fast start-up technology.

If you have any questions regarding the attached analysis and recommendations, please do not hesitate to contact me at (209) 210-5009 or Nancy Matthews of Sierra Research at (916) 273-5124.

Sincerely,

Vinnie Venethongkham
Compliance Manager

Attachment



February 10, 2014

Mr. Rupi Gill
San Joaquin Valley APCD
4800 Enterprise Way
Modesto, CA 95356-8718

PO Box 1478
12745 N. Thornton Road
Lodi, CA 95241
(209) 333-6370
www.ncpa.com

Re: Northern California Power Agency, Lodi Energy Center
District Facility # N-2697
Proposed New Time Limits for Gas Turbine Startup

Dear Mr. Gill:

Enclosed is the summary and analysis of gas turbine startup emissions for the Northern California Power Agency (NCPA) Lodi Energy Center for the period of January 2013 through December 2013. This analysis fulfills the requirements of the San Joaquin Valley Air Pollution Control District (SJVAPCD) Permit N-2697-5-1, condition #9, which requires submission of proposed new startup time limits based on the data collected during the first 12 months of operation following the commissioning period.

If you have any questions regarding the attached analysis, please feel free to call me at (916) 521-0047 or Jeff Adkins of Sierra Research at (916) 273-5127.

Sincerely,

Michael DeBortoli
Plant Manager
NCPA Lodi Energy Center

Attachment

cc: Jeffrey D. Adkins, Sierra Research
Andrea Grenier, Grenier and Associates

Turbine Startup Time Analysis for Lodi Energy Center

Introduction

The time required to start up a combined cycle power plant and bring it into compliance with short-term permit limits can vary depending on a number of factors, such as ambient temperature, turbine and HRSG temperature, catalyst age, etc. It is not always possible to accurately predict, prior to construction and initial operation, the amount of time startups will take for any given plant, particularly for new technologies or new combinations of existing technologies, which can lead to uncertainty in establishing permit limits for startup time.

Northern California Power Agency (NCPA) has installed a Siemens “Flex Plant 30” natural gas-fired gas turbine with fast-startup technology at the new Lodi Energy Center (LEC) power plant. The Flex Plant technology was designed to reduce startup times, thereby increasing plant efficiency and reducing startup emissions. However, because no Siemens Flex Plant configuration facilities had been built or operated at the time the LEC project was approved by the regulatory agencies, no in-use operating data were available during the permitting process that could be used to accurately verify or establish expected startup times for the gas turbine. Furthermore, turbine vendors typically do not guarantee startup times (including time to compliance with air emission limits).

To address this uncertainty regarding startup times, during the permitting process NCPA proposed to monitor and evaluate startup times over the first 12 months of operation to assess the performance of the Flex Plant technology and to develop appropriate startup time limits to be placed in the permit. The results of the startup time evaluation are presented in this analysis.

Permit Requirements

The San Joaquin Valley Air Pollution Control District (SJVAPCD) permit to operate for LEC¹ allows relief from short-term emission limits for up to three hours per startup,² but requires NCPA to monitor and record startup times and minute-by-minute NO_x and CO concentrations during the 12-month period following commissioning.³ The permit also requires NCPA to submit proposed new startup time limits for each type of startup (hot, warm, and cold starts) based on the data collected.⁴ The required data were collected by the LEC continuous emissions monitoring system (CEMS) for each startup that occurred during the period from January 2013 through December 2013. Please see Attachment A for a summary of the startup time data. Copies of the CEMS record for each startup event are included in Attachment B.

¹ Permit number N-2697-5-1, issued August 8, 2013

² Permit Condition #6

³ Permit Condition #8

⁴ Permit Condition #9

Startup Data

Table 1 summarizes the LEC turbine startup data for each type of startup. For the purposes of our analysis, a “hot start” is defined as a startup initiated less than 16 hours after previous operation (i.e., after less than 16 hours of downtime). A “warm start” occurs after 16 hours or more but less than or equal to 64 hours of downtime, and a “cold start” occurs after more than 64 hours of downtime⁵. To determine startup duration, the CEMS data were reviewed to find the time when startup commenced (commencement of fuel flow to the gas turbine) and the times when compliance with the 2.0 ppm NOx and CO limits were achieved on a 1-minute average basis⁶. A separate determination of startup time was made for each pollutant.

As shown in Table 1, a cold start tends to take the longest for both NOx and CO, on average. There were significantly more hot starts than there were warm or cold starts during the 12-month time period, yielding a larger number of data points for hot starts.

A small number of startups were excluded from the data set due to termination of the startup while partially through the startup process. No useful information regarding startup times can be taken from these particular instances, since the startup was not completed. All successful startups were included in the data set. Aborted startups were not common in the data set and a list of dates and times of aborted startups is included in the data summary in Appendix A.

Table 1 Summary of Startup Data January-December 2013			
NOx Time to Compliance			
	Hot Start	Warm Start	Cold Start
Number of startups	144	23	10
Minimum startup time (minutes)	19	33	38
Average startup time (minutes)	24	37	41
Maximum startup time (minutes)	39	42	45
CO Time to Compliance			
	Hot Start	Warm Start	Cold Start
Number of startups	144	23	10
Minimum startup time (minutes)	16	17	22
Average startup time (minutes)	19	22	25
Maximum startup time (minutes)	42	27	35
Overall Time to Compliance			
	Hot Start	Warm Start	Cold Start
Maximum startup time (minutes)	42	42	45

⁵ As defined by CAISO for LEC.

⁶ The startup was determined to have ended when the turbine load was greater than 140 MW and minute by minute emission concentrations were below the 2.0 ppm permit limit consistently.

Conclusion

Startup times vary widely based on a number of conditions, as previously discussed. Because of the complexity of the gas turbine and fuel system, no two startups are the same and it is not possible to accurately predict how long an individual startup will take. While many of the startups do occur in the timeframe one would expect of fast start technology, some startups take longer because of turbine conditions or events that are not within the control of the operators. Any startup limit placed on the LEC permit should be a limit with which compliance can be consistently achieved on an ongoing basis for the life of the facility.

Condition #10 of the permit allows a margin of compliance of up to 60 minutes to be added to the longest startup to establish the startup duration limits for each type of event. Since the longest startups vary so little (from 42 minutes for warm and hot starts to 45 minutes for cold starts), NCPA proposes to establish a single new startup time limit of 100 minutes for all three types of startup events. This proposed single new limit includes margins of compliance of between 55 and 58 minutes and will simplify startup monitoring, recordkeeping and reporting for NCPA. This proposed startup time limit will enable LEC to achieve compliance while still reducing allowable startup times below the three-hour (180-minute) startup times in the original permit.

ATTACHMENT A
Startup Data Summary

Cold Startups					
Date	Start Time	Start Type	Downtime, hrs	Minutes to CO Compliance	Minutes to NOx Compliance
3-Feb-13	1:23 PM	Cold	133	24	38
4-Mar-13	2:59 AM	Cold	74	25	40
13-Mar-13	2:00 AM	Cold	97	23	39
15-Jun-13	5:31 AM	Cold	117	24	41
13-Aug-13	5:15 AM	Cold	79	22	40
18-Aug-13	6:44 AM	Cold	82	22	39
16-Sep-13	3:34 AM	Cold	67	24	41
14-Nov-13	5:45 AM	Cold	137	35	45
4-Dec-13	8:40 AM	Cold	81	31	44
22-Dec-13	12:24 PM	Cold	108	23	45

Cold	Number of starts	10	10
	Min	22	38
	Average	25	41
	Max	35	45

Hot Startups					
Date	Start Time	Start Type	Downtime, hrs	Minutes to CO Compliance	Minutes to NOx Compliance
1-Jan-13	5:20 PM	Hot	0	20	19
11-Jan-13	2:34 PM	Hot	3	30	28
12-Jan-13	1:48 PM	Hot	14	24	28
13-Jan-13	4:55 PM	Hot	3	24	32
14-Jan-13	3:48 AM	Hot	3	22	20
16-Jan-13	1:57 AM	Hot	1	24	22
17-Jan-13	3:39 AM	Hot	4	22	21
19-Jan-13	7:51 PM	Hot	1	22	21
20-Jan-13	2:34 PM	Hot	13	23	29
21-Jan-13	4:28 AM	Hot	4	21	21
22-Jan-13	4:23 AM	Hot	4	22	22
23-Jan-13	4:29 AM	Hot	5	22	21
23-Jan-13	12:13 PM	Hot	3	20	21
24-Jan-13	6:37 AM	Hot	8	22	23
24-Jan-13	12:41 PM	Hot	2	22	20
25-Jan-13	4:49 AM	Hot	13	22	29
28-Jan-13	4:32 AM	Hot	5	24	27
3-Feb-13	6:32 PM	Hot	2	27	27
4-Feb-13	5:29 AM	Hot	6	23	22
4-Feb-13	7:06 AM	Hot	1	25	23
7-Feb-13	10:25 AM	Hot	10	21	28
8-Feb-13	4:23 AM	Hot	5	23	22
11-Feb-13	1:48 PM	Hot	14	19	29
12-Feb-13	4:55 AM	Hot	6	20	21
13-Feb-13	7:30 PM	Hot	5	21	24
15-Feb-13	3:44 AM	Hot	4	20	21
16-Feb-13	2:30 PM	Hot	14	20	29
17-Feb-13	2:30 PM	Hot	15	20	30
18-Feb-13	2:30 PM	Hot	15	22	31
22-Feb-13	3:55 AM	Hot	3	17	21
22-Feb-13	12:01 PM	Hot	3	18	21
26-Feb-13	3:25 AM	Hot	5	19	24
27-Feb-13	3:26 AM	Hot	3	19	22
5-Mar-13	4:30 AM	Hot	5	18	21
8-Mar-13	4:26 AM	Hot	4	21	22
14-Mar-13	7:41 AM	Hot	9	19	24
16-Mar-13	4:51 AM	Hot	6	18	24
18-Mar-13	3:30 AM	Hot	4	18	23
21-Mar-13	3:54 AM	Hot	5	19	23
21-Mar-13	3:54 AM	Hot	5	18	22
22-Mar-13	3:54 AM	Hot	5	19	23
23-Mar-13	3:50 AM	Hot	5	18	23

Hot Startups					
Date	Start Time	Start Type	Downtime, hrs	Minutes to CO Compliance	Minutes to NOx Compliance
29-Mar-13	3:31 AM	Hot	4	18	22
2-Apr-13	3:43 AM	Hot	4	18	22
3-Apr-13	3:43 AM	Hot	4	18	22
6-Apr-13	6:44 AM	Hot	7	18	22
9-Apr-13	3:50 AM	Hot	5	18	23
10-Apr-13	3:41 AM	Hot	4	18	22
11-Apr-13	3:39 AM	Hot	5	18	22
12-Apr-13	3:33 AM	Hot	5	17	22
13-Apr-13	6:46 AM	Hot	7	17	24
16-Apr-13	3:33 AM	Hot	4	18	23
18-Apr-13	3:41 AM	Hot	4	18	22
19-Apr-13	3:40 AM	Hot	4	17	22
20-Apr-13	5:26 AM	Hot	6	20	26
21-Apr-13	8:41 AM	Hot	9	18	29
23-Apr-13	3:26 AM	Hot	4	19	22
26-Apr-13	4:26 AM	Hot	5	17	22
27-Apr-13	7:11 AM	Hot	8	17	25
27-Apr-13	9:46 AM	Hot	2	18	22
28-Apr-13	8:41 AM	Hot	10	17	27
29-Apr-13	5:26 AM	Hot	6	18	22
30-Apr-13	4:41 AM	Hot	6	17	22
1-May-13	4:41 AM	Hot	6	19	23
2-May-13	4:41 AM	Hot	5	19	29
3-May-13	5:34 AM	Hot	6	18	23
28-May-13	3:52 AM	Hot	0	42	39
29-May-13	3:26 AM	Hot	5	19	23
30-May-13	3:36 AM	Hot	4	18	23
31-May-13	3:30 AM	Hot	5	19	22
1-Jun-13	7:32 AM	Hot	8	18	23
2-Jun-13	10:12 AM	Hot	12	20	27
3-Jun-13	4:31 AM	Hot	5	19	23
4-Jun-13	8:13 AM	Hot	9	19	26
5-Jun-13	10:27 AM	Hot	13	19	31
6-Jun-13	6:35 AM	Hot	9	20	27
7-Jun-13	7:31 AM	Hot	10	21	28
8-Jun-13	7:41 AM	Hot	6	20	22
9-Jun-13	8:32 AM	Hot	10	19	27
21-Jun-13	3:42 AM	Hot	5	18	22
22-Jun-13	8:12 AM	Hot	9	18	25
25-Jun-13	5:41 AM	Hot	7	18	21
26-Jun-13	6:42 AM	Hot	8	18	22
27-Jun-13	3:42 AM	Hot	4	19	22

Hot Startups					
Date	Start Time	Start Type	Downtime, hrs	Minutes to CO Compliance	Minutes to NOx Compliance
28-Jun-13	3:37 AM	Hot	3	19	22
29-Jun-13	5:42 AM	Hot	5	19	22
30-Jun-13	6:41 AM	Hot	6	19	22
4-Jul-13	7:52 AM	Hot	2	18	20
7-Jul-13	8:42 AM	Hot	7	17	21
8-Jul-13	7:42 AM	Hot	9	17	23
9-Jul-13	7:23 AM	Hot	8	19	22
10-Jul-13	5:42 AM	Hot	7	17	21
12-Jul-13	7:27 AM	Hot	8	19	23
13-Jul-13	8:48 AM	Hot	9	16	24
14-Jul-13	8:44 AM	Hot	11	16	25
15-Jul-13	7:27 AM	Hot	9	18	26
16-Jul-13	11:24 AM	Hot	14	18	29
17-Jul-13	3:42 AM	Hot	6	18	21
18-Jul-13	7:27 AM	Hot	11	17	26
19-Jul-13	7:28 AM	Hot	8	17	22
20-Jul-13	8:22 AM	Hot	10	17	25
23-Jul-13	8:17 AM	Hot	10	18	25
24-Jul-13	7:51 AM	Hot	<1	19	27
25-Jul-13	6:44 AM	Hot	9	16	26
26-Jul-13	7:52 AM	Hot	8	17	25
27-Jul-13	5:56 AM	Hot	8	18	25
28-Jul-13	9:27 AM	Hot	10	17	24
29-Jul-13	6:48 AM	Hot	9	18	24
30-Jul-13	6:42 AM	Hot	6	17	24
31-Jul-13	6:48 AM	Hot	9	17	24
4-Aug-13	7:17 AM	Hot	<1	17	31
6-Aug-13	4:57 AM	Hot	6	16	20
8-Aug-13	6:37 AM	Hot	10	16	23
9-Aug-13	3:57 AM	Hot	6	16	21
19-Aug-13	7:44 AM	Hot	10	20	24
21-Aug-13	3:43 AM	Hot	6	17	21
22-Aug-13	4:42 AM	Hot	7	18	22
23-Aug-13	6:47 AM	Hot	9	18	25
27-Aug-13	4:54 AM	Hot	7	17	21
30-Aug-13	3:57 AM	Hot	6	17	21
2-Sep-13	7:37 AM	Hot	10	19	24
5-Sep-13	8:47 AM	Hot	1	19	22
10-Sep-13	4:57 AM	Hot	5	17	22
11-Sep-13	4:57 AM	Hot	6	16	21
17-Sep-13	6:48 AM	Hot	9	17	26
23-Sep-13	4:42 AM	Hot	6	17	21
24-Sep-13	4:42 AM	Hot	7	16	20
14-Oct-13	4:22 AM	Hot	<1	17	31
17-Oct-13	6:33 AM	Hot	8	17	24
18-Oct-13	3:42 AM	Hot	6	17	22
19-Oct-13	12:38 PM	Hot	15	18	32
22-Oct-13	3:58 AM	Hot	5	17	21
4-Nov-13	4:39 AM	Hot	5	16	21
8-Nov-13	3:53 AM	Hot	4	16	20
8-Nov-13	9:42 AM	Hot	3	16	21
16-Nov-13	2:18 PM	Hot	14	17	32
17-Nov-13	1:56 PM	Hot	14	17	31
17-Dec-13	10:40 AM	Hot	1	17	21
26-Dec-13	2:19 PM	Hot	14	17	30
27-Dec-13	4:54 AM	Hot	5	17	21
28-Dec-13	7:19 AM	Hot	8	19	23
29-Dec-13	2:14 PM	Hot	13	16	30
30-Dec-13	3:35 AM	Hot	4	16	21
31-Dec-13	2:24 PM	Hot	13	16	30

Hot	Number of Starts	144	146
	Min	16	19
	Average	19	24
	Max	42	39

Warm Startups					
Date	Start Time	Start Type	Downtime, hrs	Minutes to CO Compliance	Minutes to NOx Compliance
19-Jan-13	2:26 PM	Warm	39	24	38
27-Jan-13	2:41 PM	Warm	39	27	38
6-Feb-13	3:25 AM	Warm	27	25	36
21-Feb-13	2:12 PM	Warm	38	24	37
24-Feb-13	12:58 PM	Warm	45	24	38
30-Mar-13	8:40 PM	Warm	20	20	35
30-Mar-13	8:40 PM	Warm	20	19	34
1-Apr-13	2:38 AM	Warm	23	21	36
8-Apr-13	2:38 AM	Warm	27	22	38
15-Apr-13	2:13 AM	Warm	27	23	39
17-Jun-13	6:29 AM	Warm	32	22	38
20-Jun-13	5:39 AM	Warm	56	24	41
24-Jun-13	6:31 AM	Warm	31	22	37
22-Jul-13	6:14 AM	Warm	32	21	35
26-Aug-13	2:15 AM	Warm	52	21	38
22-Sep-13	1:55 PM	Warm	49	23	39
27-Sep-13	2:35 AM	Warm	52	23	41
30-Sep-13	3:15 AM	Warm	29	20	37
28-Oct-13	1:49 AM	Warm	24	19	35
3-Nov-13	2:15 PM	Warm	16	20	35
7-Nov-13	1:46 AM	Warm	60	23	39
15-Nov-13	3:32 AM	Warm	17	17	33
30-Nov-13	11:46 AM	Warm	60	22	42

Warm	Number of starts	23	23
	Min	17	33
	Average	22	37
	Max	27	42

Aborted startups:	
Date	Time
1/1/2013	16:08
1/11/2013	2:44
1/11/2013	7:55
1/11/2013	10:55
1/13/2013	13:49
5/26/2013	12:18
5/26/2013	12:47
5/28/2013	2:43
7/24/2013	7:29
8/4/2013	6:02
9/13/2013	5:44
9/20/2013	11:45
10/14/2013	2:17
10/14/2013	3:30

ATTACHMENT B
CEMS Startup Records

Condition 18 Startup Report



From: 01/01/2013 00:00 **To:** 03/31/2013 23:59 **Facility Name:** Lodi Energy Center
Generated: 02/04/2014 11:01 **Location:** Lodi, CA
Gas Turbine Downtime Tag: CT1_GT_Downtime_Min_1M
Steam Turbine Downtime Tag: CT1_GT_Downtime_Min_1M
 *ST Downtime Determines Startup Type: Cold > 64 hours , 16 hours >= Warm <= 64, Hot < 16
 Red = Invalid Data

Date/Time Startup Commences: 01/01/2013 16:08
 Gas Turbine Downtime: 16 Hours
 Steam Turbine Downtime: 16 Hours
 Startup Type*: Warm

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
01/01/2013 16:08	0	0.0	0.0	0.00	1,600.0	0.00
01/01/2013 16:09	0	0.0	0.0	0.00	2,244.4	0.00
01/01/2013 16:10	0	29.5	64.9	0.66	2,666.7	0.50
01/01/2013 16:11	0	5.1	1,329.1	17.13	3,377.8	0.11
01/01/2013 16:12	0	6.2	2,465.1	39.52	4,200.0	0.16
01/01/2013 16:13	0	9.0	2,262.5	43.56	5,044.4	0.28
01/01/2013 16:14	0	14.9	2,417.5	51.46	5,577.8	0.52
01/01/2013 16:15	0	21.9	2,554.9	59.80	6,133.3	0.85
01/01/2013 16:16	0	25.3	2,735.2	65.88	6,311.1	1.00
01/01/2013 16:17	0	30.1	2,993.8	71.87	6,288.9	1.19
01/01/2013 16:18	3	31.1	3,085.7	76.94	6,533.3	1.28
01/01/2013 16:19	13	34.6	3,080.4	85.69	7,288.9	1.59
01/01/2013 16:20	23	38.9	3,205.7	93.80	7,666.7	1.87
01/01/2013 16:21	32	43.9	2,988.4	95.04	8,333.3	2.30
01/01/2013 16:22	42	40.6	1,938.0	66.57	9,000.0	2.30
01/01/2013 16:23	52	41.2	1,119.8	40.18	9,400.0	2.44
01/01/2013 16:24	66	35.4	1,430.8	54.85	10,044.4	2.23
01/01/2013 16:25	78	30.2	740.4	30.51	10,800.0	2.04
01/01/2013 16:26	90	30.1	52.7	2.34	11,644.4	2.20
01/01/2013 16:27	102	26.7	4.5	0.21	12,466.7	2.08
Total				896.01		24.94

Date/Time Startup Commences: 01/01/2013 17:20
 Gas Turbine Downtime: 0 Hours
 Steam Turbine Downtime: 0 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
01/01/2013 17:20	0	0.0	0.0	0.00	2,066.7	0.00
01/01/2013 17:21	0	0.0	0.0	0.00	2,333.3	0.00
01/01/2013 17:22	0	31.5	2.0	0.02	2,800.0	0.55
01/01/2013 17:23	0	8.4	24.8	0.34	3,511.1	0.19
01/01/2013 17:24	0	12.8	36.9	0.61	4,333.3	0.35
01/01/2013 17:25	0	13.7	43.8	0.85	5,111.1	0.44
01/01/2013 17:26	0	17.9	63.8	1.38	5,644.4	0.64
01/01/2013 17:27	0	22.9	81.9	1.89	6,066.7	0.88
01/01/2013 17:28	0	27.0	95.7	2.24	6,133.3	1.04
01/01/2013 17:29	2	30.3	112.7	2.73	6,355.6	1.21
01/01/2013 17:30	8	33.4	120.4	3.23	7,022.2	1.47
01/01/2013 17:31	18	35.6	139.2	3.90	7,333.3	1.64
01/01/2013 17:32	28	41.7	150.0	4.51	7,866.7	2.07
01/01/2013 17:33	37	42.1	118.7	3.89	8,577.8	2.27
01/01/2013 17:34	46	42.2	87.0	3.01	9,044.4	2.39
01/01/2013 17:35	59	42.8	70.4	2.62	9,711.1	2.62
01/01/2013 17:36	68	25.7	79.4	3.08	10,133.3	1.64
01/01/2013 17:37	78	6.5	44.1	1.82	10,755.6	0.44
01/01/2013 17:38	88	3.0	6.2	0.27	11,444.4	0.21
01/01/2013 17:39	98	1.4	2.3	0.10	12,133.3	0.10
01/01/2013 17:40	108	1.1	0.5	0.02	12,888.9	0.09
01/01/2013 17:41	118	0.9	0.3	0.02	13,533.3	0.07
01/01/2013 17:42	128	0.8	0.2	0.00	14,200.0	0.07
01/01/2013 17:43	137	0.6	0.1	0.00	14,844.4	0.05
01/01/2013 17:44	140	0.4	0.0	0.00	14,955.6	0.05
01/01/2013 17:45	140	0.3	-0.1	0.00	14,911.1	0.03
01/01/2013 17:46	140	0.3	-0.2	0.00	14,888.9	0.03
01/01/2013 17:47	140	0.3	-0.3	0.00	14,866.7	0.03
01/01/2013 17:48	140	0.3	-0.4	0.00	14,866.7	0.03
01/01/2013 17:49	140	0.3	-0.4	0.00	14,866.7	0.03
Total				36.53		20.63

Date/Time Startup Commences: 01/11/2013 02:44
 Gas Turbine Downtime: 146 Hours
 Steam Turbine Downtime: 146 Hours
 Startup Type*: Cold

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
01/11/2013 02:44	0	0.0	0.0	0.00	2,488.9	0.00
01/11/2013 02:45	0	0.0	0.0	0.00	2,288.9	0.00
01/11/2013 02:46	0	0.0	271.4	2.90	2,800.0	0.00
01/11/2013 02:47	0	2.0	2,751.4	37.57	3,577.8	0.04
01/11/2013 02:48	0	4.4	2,674.8	45.37	4,444.4	0.12
01/11/2013 02:49	0	6.4	2,280.6	45.65	5,244.4	0.21
01/11/2013 02:50	0	10.1	2,341.0	51.62	5,777.8	0.36
01/11/2013 02:51	0	12.3	2,573.8	10.04	1,022.2	0.08
Total				193.15		0.81

Date/Time Startup Commences: 01/11/2013 07:55
 Gas Turbine Downtime: 5 Hours
 Steam Turbine Downtime: 5 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
01/11/2013 07:55	0	0.0	0.0	0.00	1,111.1	0.00
01/11/2013 07:56	0	0.0	0.0	0.00	2,222.2	0.00
01/11/2013 07:57	0	0.0	0.0	0.00	2,511.1	0.00
01/11/2013 07:58	0	18.9	132.2	1.55	3,066.7	0.37
01/11/2013 07:59	0	5.9	2,694.8	39.99	3,888.9	0.15
01/11/2013 08:00	0	7.2	2,498.0	45.98	4,822.2	0.21
01/11/2013 08:01	0	7.6	2,297.3	44.03	5,022.2	0.24
Total				131.55		0.97

Date/Time Startup Commences: 01/11/2013 10:55
 Gas Turbine Downtime: 2 Hours
 Steam Turbine Downtime: 2 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
01/11/2013 10:55	0	0.0	0.0	0.00	1,355.6	0.00
01/11/2013 10:56	0	0.0	0.0	0.00	2,311.1	0.00
01/11/2013 10:57	0	0.0	0.0	0.00	2,577.8	0.00
01/11/2013 10:58	0	27.5	104.2	1.25	3,155.6	0.54
01/11/2013 10:59	0	10.4	2,681.0	39.79	3,888.9	0.25
01/11/2013 11:00	0	12.0	2,410.2	44.15	4,800.0	0.36
01/11/2013 11:01	0	13.1	2,277.2	47.50	5,466.7	0.45
01/11/2013 11:02	0	14.9	2,391.0	54.75	6,000.0	0.56
01/11/2013 11:03	0	19.0	2,520.2	63.90	6,644.4	0.79
01/11/2013 11:04	0	23.8	2,672.5	66.18	6,488.9	0.97
01/11/2013 11:05	0	26.4	2,900.8	71.59	6,466.7	1.07
01/11/2013 11:06	0	29.7	2,973.0	72.62	6,400.0	1.19
01/11/2013 11:07	0	30.1	2,923.1	70.90	6,355.6	1.20
01/11/2013 11:08	0	33.0	2,949.2	71.04	6,311.1	1.31
01/11/2013 11:09	0	34.4	2,972.2	71.34	6,288.9	1.36
01/11/2013 11:10	0	35.0	2,981.1	71.05	6,244.4	1.37
01/11/2013 11:11	0	35.6	2,985.2	71.14	6,244.4	1.39
01/11/2013 11:12	2	36.0	2,993.5	73.63	6,444.4	1.46
01/11/2013 11:13	10	36.8	3,004.1	82.81	7,222.2	1.66
01/11/2013 11:14	21	37.2	3,009.0	87.03	7,577.8	1.77
01/11/2013 11:15	30	41.1	2,940.5	92.77	8,266.7	2.13
01/11/2013 11:16	40	35.6	1,652.5	57.18	9,066.7	2.03
01/11/2013 11:17	45	25.2	101.8	3.62	9,311.1	1.48
01/11/2013 11:18	40	0.5	79.9	2.63	8,622.2	0.03
01/11/2013 11:19	41	0.2	3.0	0.10	8,333.3	0.01
Total				1216.97		23.38

Date/Time Startup Commences: 01/11/2013 14:34
 Gas Turbine Downtime: 3 Hours
 Steam Turbine Downtime: 3 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
01/11/2013 14:34	0	0.0	0.0	0.00	2,666.7	0.00
01/11/2013 14:35	0	0.0	0.0	0.00	2,511.1	0.00
01/11/2013 14:36	0	0.0	23.6	0.27	2,933.3	0.00
01/11/2013 14:37	0	0.4	38.0	0.53	3,622.2	0.01
01/11/2013 14:38	0	1.5	803.7	13.56	4,422.2	0.05
01/11/2013 14:39	0	4.4	1,176.3	23.35	5,200.0	0.14
01/11/2013 14:40	0	9.4	1,648.1	36.20	5,755.6	0.34
01/11/2013 14:41	0	14.4	1,995.7	48.74	6,400.0	0.58
01/11/2013 14:42	0	21.3	2,183.6	53.71	6,444.4	0.86
01/11/2013 14:43	0	24.0	2,540.0	62.04	6,400.0	0.96
01/11/2013 14:44	2	23.8	2,551.6	63.41	6,511.1	0.98
01/11/2013 14:45	11	24.0	2,352.7	65.25	7,266.7	1.09
01/11/2013 14:46	22	25.3	2,088.8	60.94	7,644.4	1.21
01/11/2013 14:47	31	24.9	1,347.4	43.08	8,377.8	1.31
01/11/2013 14:48	41	20.8	501.2	17.39	9,088.9	1.19
01/11/2013 14:49	49	16.7	171.5	6.15	9,400.0	0.98
01/11/2013 14:50	62	15.7	119.1	4.55	10,000.0	0.99
01/11/2013 14:51	71	10.2	120.9	4.85	10,488.9	0.68
01/11/2013 14:52	81	9.9	50.1	2.12	11,088.9	0.68
01/11/2013 14:53	91	10.5	9.2	0.42	11,777.8	0.78
01/11/2013 14:54	101	9.0	6.6	0.32	12,400.0	0.70
01/11/2013 14:55	110	8.4	4.6	0.22	13,066.7	0.69
01/11/2013 14:56	122	8.0	2.8	0.14	13,844.4	0.71
01/11/2013 14:57	131	7.6	1.9	0.10	14,511.1	0.69
01/11/2013 14:58	134	7.7	1.9	0.10	14,733.3	0.70
01/11/2013 14:59	137	8.5	2.2	0.13	14,977.8	0.79
01/11/2013 15:00	140	8.6	2.2	0.13	15,111.1	0.82
01/11/2013 15:01	140	1.6	2.3	0.13	15,066.7	0.15
01/11/2013 15:02	140	0.7	2.2	0.13	15,044.4	0.08
01/11/2013 15:03	140	0.7	2.0	0.10	15,044.4	0.05
01/11/2013 15:04	140	0.6	1.7	0.10	15,044.4	0.05
01/11/2013 15:05	140	0.5	1.3	0.08	15,044.4	0.05
01/11/2013 15:06	140	0.5	1.0	0.05	15,022.2	0.05
01/11/2013 15:07	140	0.5	0.8	0.05	15,022.2	0.05
01/11/2013 15:08	140	0.5	0.6	0.03	15,044.4	0.05
01/11/2013 15:09	140	0.5	0.4	0.03	15,022.2	0.05
01/11/2013 15:10	140	0.5	0.3	0.03	15,022.2	0.05
01/11/2013 15:11	140	0.6	0.3	0.03	15,022.2	0.05
01/11/2013 15:12	140	0.6	0.2	0.00	15,022.2	0.05
01/11/2013 15:13	140	0.6	0.1	0.00	15,022.2	0.05
01/11/2013 15:14	140	0.7	0.0	0.00	15,000.0	0.05
Total				508.46		18.76

Date/Time Startup Commences: 01/12/2013 13:48
 Gas Turbine Downtime: 14 Hours
 Steam Turbine Downtime: 14 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
01/12/2013 13:48	0	0.0	0.0	0.00	1,600.0	0.00
01/12/2013 13:49	0	0.0	0.0	0.00	2,355.6	0.00
01/12/2013 13:50	0	0.0	0.0	0.00	2,733.3	0.00
01/12/2013 13:51	0	3.6	33.1	0.43	3,400.0	0.08
01/12/2013 13:52	0	3.8	940.5	14.99	4,177.8	0.10
01/12/2013 13:53	0	5.9	1,782.3	34.47	5,066.7	0.19
01/12/2013 13:54	0	12.5	2,205.0	47.32	5,622.2	0.44
01/12/2013 13:55	0	19.4	2,591.0	62.63	6,333.3	0.77
01/12/2013 13:56	0	25.6	2,706.1	66.09	6,400.0	1.03
01/12/2013 13:57	0	31.2	2,976.4	72.45	6,377.8	1.25
01/12/2013 13:58	2	32.5	3,120.3	77.55	6,511.1	1.33
01/12/2013 13:59	10	37.1	3,191.5	88.79	7,288.9	1.70
01/12/2013 14:00	21	39.3	3,161.2	91.96	7,622.2	1.88
01/12/2013 14:01	31	45.0	3,097.5	97.47	8,244.4	2.33
01/12/2013 14:02	40	42.2	2,133.0	72.55	8,911.1	2.36
01/12/2013 14:03	49	39.7	1,012.6	35.91	9,288.9	2.31
01/12/2013 14:04	62	37.3	796.2	30.38	10,000.0	2.34
01/12/2013 14:05	72	31.7	1,102.5	43.67	10,377.8	2.07
01/12/2013 14:06	81	28.7	290.6	12.06	10,866.7	1.96
01/12/2013 14:07	90	28.1	56.6	2.49	11,488.9	2.02
01/12/2013 14:08	100	26.0	20.7	0.95	12,066.7	1.98
01/12/2013 14:09	111	24.4	5.4	0.26	12,888.9	1.98
01/12/2013 14:10	121	22.7	3.6	0.19	13,688.9	1.96
01/12/2013 14:11	131	20.8	2.0	0.12	14,333.3	1.88
01/12/2013 14:12	138	18.8	1.2	0.08	14,844.4	1.75
01/12/2013 14:13	142	18.7	0.9	0.05	15,133.3	1.78
01/12/2013 14:14	143	13.9	0.9	0.05	15,155.6	1.32
01/12/2013 14:15	143	0.5	0.7	0.05	15,133.3	0.05
01/12/2013 14:16	143	0.3	0.6	0.03	15,133.3	0.03
01/12/2013 14:17	143	0.2	0.4	0.03	15,133.3	0.03
01/12/2013 14:18	144	0.3	0.3	0.03	15,244.4	0.03
01/12/2013 14:19	145	0.3	0.1	0.00	15,266.7	0.03
01/12/2013 14:20	145	0.3	0.0	0.00	15,266.7	0.03
01/12/2013 14:21	145	0.3	0.0	0.00	15,266.7	0.03
01/12/2013 14:22	145	0.3	-0.1	0.00	15,244.4	0.03
01/12/2013 14:23	145	0.3	-0.1	0.00	15,244.4	0.03
01/12/2013 14:24	145	0.3	-0.1	0.00	15,266.7	0.03
Total				853.05		37.13

Date/Time Startup Commences: 01/13/2013 13:49
 Gas Turbine Downtime: 14 Hours
 Steam Turbine Downtime: 14 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
01/13/2013 13:49	0	0.0	0.0	0.00	2,444.4	0.00
01/13/2013 13:50	0	0.0	0.0	0.00	2,444.4	0.00
01/13/2013 13:51	0	17.7	29.5	0.32	2,866.7	0.32
01/13/2013 13:52	0	2.8	40.1	0.00	0.0	0.00
Total				0.32		0.32

Date/Time Startup Commences: 01/13/2013 16:55
 Gas Turbine Downtime: 3 Hours
 Steam Turbine Downtime: 3 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
01/13/2013 16:55	0	0.0	0.0	0.00	1,577.8	0.00
01/13/2013 16:56	0	0.0	0.0	0.00	2,333.3	0.00
01/13/2013 16:57	0	0.0	0.0	0.00	2,688.9	0.00
01/13/2013 16:58	0	5.4	64.9	0.83	3,355.6	0.11
01/13/2013 16:59	0	5.0	2,686.1	42.60	4,155.6	0.13
01/13/2013 17:00	0	8.0	2,465.3	47.67	5,066.7	0.26
01/13/2013 17:01	0	14.3	2,523.6	54.16	5,622.2	0.51
01/13/2013 17:02	0	20.1	2,748.5	64.80	6,177.8	0.78
01/13/2013 17:03	0	26.3	2,801.6	68.91	6,444.4	1.07
01/13/2013 17:04	0	31.2	2,984.5	73.16	6,422.2	1.26
01/13/2013 17:05	3	33.1	3,135.2	79.77	6,666.7	1.39
01/13/2013 17:06	12	37.5	3,230.9	90.70	7,355.6	1.73
01/13/2013 17:07	22	40.7	3,239.1	94.50	7,644.4	1.96
01/13/2013 17:08	31	47.2	3,237.7	102.44	8,288.9	2.46
01/13/2013 17:09	41	43.7	2,362.3	81.35	9,022.2	2.48
01/13/2013 17:10	50	42.4	1,419.4	50.80	9,377.8	2.49
01/13/2013 17:11	63	40.5	1,445.2	55.40	10,044.4	2.55
01/13/2013 17:12	72	34.6	1,596.4	63.90	10,488.9	2.29
01/13/2013 17:13	82	31.3	437.7	18.42	11,022.2	2.16
01/13/2013 17:14	91	29.9	49.7	2.21	11,666.7	2.19
01/13/2013 17:15	101	26.4	7.0	0.33	12,266.7	2.03
01/13/2013 17:16	112	23.7	3.4	0.18	13,111.1	1.94
01/13/2013 17:17	122	21.1	2.3	0.12	13,800.0	1.84
01/13/2013 17:18	132	17.1	1.4	0.07	14,444.4	1.55
01/13/2013 17:19	141	16.3	0.9	0.05	15,133.3	1.55
01/13/2013 17:20	144	16.0	0.9	0.05	15,333.3	1.54
01/13/2013 17:21	145	16.5	0.8	0.05	15,333.3	1.59
01/13/2013 17:22	145	16.5	0.7	0.05	15,311.1	1.59
01/13/2013 17:23	145	16.2	0.6	0.03	15,311.1	1.57
01/13/2013 17:24	145	15.9	0.4	0.03	15,311.1	1.51
01/13/2013 17:25	145	11.6	0.3	0.03	15,333.3	1.12
01/13/2013 17:26	145	0.5	0.2	0.00	15,333.3	0.05
01/13/2013 17:27	145	0.3	0.1	0.00	15,355.6	0.03
01/13/2013 17:28	145	0.3	0.0	0.00	15,355.6	0.03
01/13/2013 17:29	145	0.3	-0.1	0.00	15,355.6	0.03
01/13/2013 17:30	145	0.3	-0.2	0.00	15,355.6	0.03
01/13/2013 17:31	145	0.2	-0.2	0.00	15,355.6	0.03
01/13/2013 17:32	145	0.2	-0.2	0.00	15,333.3	0.03
01/13/2013 17:33	145	0.2	-0.3	0.00	15,355.6	0.03
01/13/2013 17:34	145	0.2	-0.3	0.00	15,333.3	0.03
01/13/2013 17:35	145	0.2	-0.3	0.00	15,355.6	0.03
Total				992.61		43.97

Date/Time Startup Commences: 01/14/2013 03:48
 Gas Turbine Downtime: 3 Hours
 Steam Turbine Downtime: 3 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
01/14/2013 03:48	0	0.0	0.0	0.00	1,933.3	0.00
01/14/2013 03:49	0	0.0	0.0	0.00	2,488.9	0.00
01/14/2013 03:50	0	0.0	-17.7	0.00	2,888.9	0.00
01/14/2013 03:51	0	0.4	25.1	0.34	3,600.0	0.01
01/14/2013 03:52	0	1.1	39.9	0.67	4,422.2	0.03
01/14/2013 03:53	0	2.6	48.1	0.96	5,200.0	0.09
01/14/2013 03:54	0	4.0	72.7	1.59	5,733.3	0.15
01/14/2013 03:55	0	6.1	91.6	2.17	6,200.0	0.24
01/14/2013 03:56	0	9.5	103.9	2.53	6,377.8	0.38
01/14/2013 03:57	0	13.3	123.0	3.00	6,400.0	0.53
01/14/2013 03:58	4	15.6	129.2	3.32	6,733.3	0.65
01/14/2013 03:59	13	20.3	127.2	3.60	7,400.0	0.95
01/14/2013 04:00	23	22.6	154.0	4.50	7,644.4	1.08
01/14/2013 04:01	33	27.5	153.6	4.85	8,266.7	1.42
01/14/2013 04:02	43	28.8	116.9	4.03	9,022.2	1.63
01/14/2013 04:03	52	31.4	84.2	3.03	9,400.0	1.86
01/14/2013 04:04	64	31.0	81.0	3.10	10,044.4	1.95
01/14/2013 04:05	73	17.8	74.8	2.99	10,511.1	1.18
01/14/2013 04:06	82	4.5	39.9	1.69	11,155.6	0.30
01/14/2013 04:07	92	2.4	6.3	0.28	11,822.2	0.18
01/14/2013 04:08	103	1.2	2.2	0.11	12,555.6	0.09
01/14/2013 04:09	114	0.9	1.0	0.05	13,288.9	0.07
01/14/2013 04:10	123	0.7	0.7	0.05	13,933.3	0.07
01/14/2013 04:11	133	0.5	0.4	0.02	14,600.0	0.05
01/14/2013 04:12	142	0.4	0.3	0.03	15,200.0	0.05
01/14/2013 04:13	145	0.3	0.2	0.00	15,311.1	0.03
01/14/2013 04:14	145	0.3	0.1	0.00	15,288.9	0.03
01/14/2013 04:15	145	0.3	0.0	0.00	15,266.7	0.03
01/14/2013 04:16	145	0.4	-0.1	0.00	15,244.4	0.05
01/14/2013 04:17	145	0.4	-0.2	0.00	15,222.2	0.05
01/14/2013 04:18	145	0.4	-0.2	0.00	15,222.2	0.05
Total				42.91		13.2

Date/Time Startup Commences: 01/16/2013 01:57
 Gas Turbine Downtime: 1 Hours
 Steam Turbine Downtime: 1 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
01/16/2013 01:57	0	0.0	0.0	0.00	1,355.6	0.00
01/16/2013 01:58	0	0.0	0.0	0.00	2,488.9	0.00
01/16/2013 01:59	0	0.0	0.0	0.00	2,777.8	0.00
01/16/2013 02:00	0	0.5	20.7	0.26	3,355.6	0.01
01/16/2013 02:01	0	1.2	30.1	0.47	4,066.7	0.03
01/16/2013 02:02	0	2.8	42.2	0.81	4,977.8	0.09
01/16/2013 02:03	0	4.3	58.5	1.25	5,555.6	0.15
01/16/2013 02:04	0	7.0	84.2	1.98	6,133.3	0.27
01/16/2013 02:05	0	10.9	102.1	2.45	6,244.4	0.43
01/16/2013 02:06	0	13.9	108.9	2.63	6,288.9	0.55
01/16/2013 02:07	0	16.4	118.6	2.87	6,288.9	0.66
01/16/2013 02:08	4	17.9	111.9	2.92	6,800.0	0.77
01/16/2013 02:09	14	20.7	113.9	3.24	7,400.0	0.96
01/16/2013 02:10	24	26.2	143.2	4.23	7,688.9	1.28
01/16/2013 02:11	34	28.8	125.2	4.01	8,355.6	1.52
01/16/2013 02:12	44	29.3	99.0	3.48	9,133.3	1.69
01/16/2013 02:13	52	31.9	72.5	2.62	9,444.4	1.91
01/16/2013 02:14	64	29.9	70.5	2.72	10,022.2	1.89
01/16/2013 02:15	74	17.8	59.9	2.42	10,533.3	1.19
01/16/2013 02:16	84	6.4	29.6	1.27	11,200.0	0.46
01/16/2013 02:17	94	2.5	6.5	0.31	11,888.9	0.18
01/16/2013 02:18	104	1.3	4.4	0.22	12,622.2	0.11
01/16/2013 02:19	114	0.8	2.1	0.11	13,288.9	0.07
01/16/2013 02:20	124	0.7	0.6	0.02	13,977.8	0.07
01/16/2013 02:21	134	0.6	0.2	0.00	14,711.1	0.05
01/16/2013 02:22	142	0.5	0.0	0.00	15,266.7	0.05
01/16/2013 02:23	140	0.4	-0.1	0.00	15,155.6	0.05
01/16/2013 02:24	140	0.5	-0.2	0.00	15,133.3	0.05
01/16/2013 02:25	140	0.5	-0.2	0.00	15,088.9	0.05
01/16/2013 02:26	140	0.5	-0.2	0.00	15,066.7	0.05
01/16/2013 02:27	140	0.5	-0.2	0.00	15,066.7	0.05
01/16/2013 02:28	140	0.5	-0.2	0.00	15,066.7	0.05
01/16/2013 02:29	141	0.5	-0.3	0.00	15,044.4	0.05
Total				40.29		14.74

Date/Time Startup Commences: 01/17/2013 03:39
 Gas Turbine Downtime: 4 Hours
 Steam Turbine Downtime: 4 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
01/17/2013 03:39	0	0.0	0.0	0.00	1,911.1	0.00
01/17/2013 03:40	0	0.0	0.0	0.00	2,511.1	0.00
01/17/2013 03:41	0	0.0	-5.9	0.00	2,911.1	0.00
01/17/2013 03:42	0	0.7	26.6	0.37	3,622.2	0.02
01/17/2013 03:43	0	2.4	41.3	0.69	4,400.0	0.07
01/17/2013 03:44	0	3.2	52.0	1.03	5,200.0	0.11
01/17/2013 03:45	0	5.0	77.6	1.71	5,733.3	0.18
01/17/2013 03:46	0	7.7	106.0	2.57	6,311.1	0.30
01/17/2013 03:47	0	11.6	123.9	3.02	6,355.6	0.47
01/17/2013 03:48	0	15.4	148.3	3.62	6,355.6	0.62
01/17/2013 03:49	3	16.9	146.7	3.65	6,488.9	0.69
01/17/2013 03:50	10	20.3	135.3	3.63	6,977.8	0.90
01/17/2013 03:51	20	21.3	124.4	3.60	7,533.3	1.01
01/17/2013 03:52	30	25.5	117.3	3.68	8,155.6	1.31
01/17/2013 03:53	40	27.8	99.7	3.41	8,911.1	1.56
01/17/2013 03:54	47	29.9	85.4	3.04	9,266.7	1.75
01/17/2013 03:55	61	31.6	72.0	2.73	9,888.9	1.97
01/17/2013 03:56	70	23.5	80.4	3.19	10,333.3	1.52
01/17/2013 03:57	80	12.9	43.2	1.82	10,955.6	0.90
01/17/2013 03:58	90	5.3	7.8	0.34	11,644.4	0.38
01/17/2013 03:59	100	2.0	3.9	0.19	12,333.3	0.15
01/17/2013 04:00	111	1.3	0.6	0.02	13,088.9	0.11
01/17/2013 04:01	120	0.8	0.4	0.02	13,755.6	0.07
01/17/2013 04:02	130	0.7	0.3	0.02	14,444.4	0.05
01/17/2013 04:03	140	0.6	0.3	0.03	15,133.3	0.05
01/17/2013 04:04	142	0.5	0.2	0.00	15,266.7	0.05
01/17/2013 04:05	141	0.4	0.1	0.00	15,200.0	0.05
01/17/2013 04:06	141	0.4	-0.1	0.00	15,177.8	0.05
01/17/2013 04:07	141	0.4	-0.2	0.00	15,133.3	0.05
01/17/2013 04:08	141	0.4	-0.2	0.00	15,111.1	0.05
01/17/2013 04:09	142	0.4	-0.2	0.00	15,177.8	0.05
Total				42.38		14.49

Date/Time Startup Commences: 01/19/2013 14:26
 Gas Turbine Downtime: 39 Hours
 Steam Turbine Downtime: 39 Hours
 Startup Type*: warm

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
01/19/2013 14:26	0	0.0	0.0	0.00	0.0	0.00
01/19/2013 14:27	0	0.0	0.0	0.00	822.2	0.00
01/19/2013 14:28	0	0.0	0.0	0.00	1,066.7	0.00
01/19/2013 14:29	0	26.6	63.4	0.45	1,844.4	0.31
01/19/2013 14:30	0	9.7	2,613.0	26.53	2,644.4	0.16
01/19/2013 14:31	0	12.8	2,378.4	32.47	3,555.6	0.29
01/19/2013 14:32	0	16.4	2,113.3	34.61	4,266.7	0.45
01/19/2013 14:33	0	20.2	2,215.2	40.26	4,733.3	0.61
01/19/2013 14:34	0	24.9	2,458.3	57.67	6,111.1	0.96
01/19/2013 14:35	0	29.7	2,640.0	52.93	5,222.2	0.98
01/19/2013 14:36	0	33.0	2,938.2	58.66	5,200.0	1.08
01/19/2013 14:37	4	34.2	3,024.7	62.19	5,355.6	1.16
01/19/2013 14:38	13	38.4	2,985.2	67.74	5,911.1	1.43
01/19/2013 14:39	23	42.2	2,647.5	67.30	6,622.2	1.76
01/19/2013 14:40	33	43.9	2,129.2	59.76	7,311.1	2.03
01/19/2013 14:41	43	43.9	1,604.8	49.56	8,044.4	2.24
01/19/2013 14:42	53	44.0	1,283.0	44.11	8,955.6	2.49
01/19/2013 14:43	64	39.2	2,051.9	75.10	9,533.3	2.35
01/19/2013 14:44	74	36.6	1,528.6	59.21	10,088.9	2.34
01/19/2013 14:45	83	38.5	404.7	16.61	10,688.9	2.60
01/19/2013 14:46	94	35.3	40.6	1.80	11,533.3	2.57
01/19/2013 14:47	103	31.4	6.7	0.32	12,288.9	2.44
01/19/2013 14:48	114	26.5	3.8	0.20	13,088.9	2.18
01/19/2013 14:49	124	22.3	2.8	0.14	13,755.6	1.93
01/19/2013 14:50	133	17.6	1.8	0.10	14,444.4	1.61
01/19/2013 14:51	139	17.2	1.1	0.05	14,933.3	1.61
01/19/2013 14:52	140	16.6	0.8	0.05	14,955.6	1.56
01/19/2013 14:53	140	16.1	0.7	0.03	14,955.6	1.51
01/19/2013 14:54	140	16.1	0.5	0.03	14,955.6	1.51
01/19/2013 14:55	140	15.6	0.4	0.03	14,933.3	1.49
01/19/2013 14:56	140	15.4	0.3	0.03	14,933.3	1.46
01/19/2013 14:57	140	15.6	0.2	0.03	14,933.3	1.49
01/19/2013 14:58	140	16.0	0.2	0.00	14,933.3	1.51
01/19/2013 14:59	140	16.6	0.2	0.00	14,955.6	1.56
01/19/2013 15:00	140	16.9	0.1	0.00	14,955.6	1.59
01/19/2013 15:01	140	15.2	0.0	0.00	14,933.3	1.43
01/19/2013 15:02	140	15.2	0.0	0.00	14,933.3	1.43
01/19/2013 15:03	140	0.4	-0.1	0.00	14,933.3	0.05
01/19/2013 15:04	140	0.3	-0.1	0.00	14,933.3	0.03
01/19/2013 15:05	140	0.3	-0.2	0.00	14,955.6	0.03
01/19/2013 15:06	140	0.2	-0.2	0.00	14,911.1	0.03
01/19/2013 15:07	140	0.2	-0.2	0.00	14,933.3	0.03
01/19/2013 15:08	140	0.2	-0.3	0.00	14,955.6	0.03
01/19/2013 15:09	140	0.2	-0.3	0.00	14,955.6	0.03
01/19/2013 15:10	140	0.2	-0.3	0.00	14,933.3	0.03
01/19/2013 15:11	140	0.2	-0.3	0.00	14,955.6	0.03
01/19/2013 15:12	140	0.2	-0.3	0.00	14,933.3	0.03
Total				807.97		52.44

Date/Time Startup Commences: 01/19/2013 19:51
 Gas Turbine Downtime: 1 Hours
 Steam Turbine Downtime: 1 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
01/19/2013 19:51	0	0.0	0.0	0.00	711.1	0.00
01/19/2013 19:52	0	0.0	0.0	0.00	400.0	0.00
01/19/2013 19:53	0	0.0	-8.9	0.00	1,555.6	0.00
01/19/2013 19:54	0	0.7	25.0	0.22	2,311.1	0.01
01/19/2013 19:55	0	1.8	36.4	0.44	3,111.1	0.04
01/19/2013 19:56	0	2.6	41.1	0.62	3,955.6	0.07
01/19/2013 19:57	0	4.2	59.2	1.02	4,466.7	0.11
01/19/2013 19:58	0	7.3	80.3	1.57	5,088.9	0.24
01/19/2013 19:59	0	10.5	90.2	1.80	5,200.0	0.35
01/19/2013 20:00	0	13.3	103.7	2.05	5,155.6	0.43
01/19/2013 20:01	1	15.5	105.2	2.10	5,200.0	0.51
01/19/2013 20:02	8	17.7	104.4	2.19	5,466.7	0.61
01/19/2013 20:03	18	21.3	103.2	2.46	6,200.0	0.84
01/19/2013 20:04	28	26.0	98.4	2.62	6,933.3	1.14
01/19/2013 20:05	38	29.3	87.7	2.56	7,622.2	1.41
01/19/2013 20:06	46	31.9	76.9	2.44	8,266.7	1.67
01/19/2013 20:07	60	33.2	62.3	2.20	9,244.4	1.93
01/19/2013 20:08	69	24.2	70.2	2.61	9,688.9	1.48
01/19/2013 20:09	78	12.6	39.4	1.57	10,377.8	0.82
01/19/2013 20:10	88	3.0	5.6	0.25	11,266.7	0.21
01/19/2013 20:11	99	1.2	3.6	0.17	12,044.4	0.08
01/19/2013 20:12	108	1.0	2.0	0.09	12,755.6	0.09
01/19/2013 20:13	118	0.8	0.6	0.02	13,444.4	0.07
01/19/2013 20:14	128	0.6	0.1	0.00	14,066.7	0.05
01/19/2013 20:15	137	0.5	0.0	0.00	14,666.7	0.05
01/19/2013 20:16	138	0.4	-0.1	0.00	14,666.7	0.05
01/19/2013 20:17	138	0.4	-0.2	0.00	14,666.7	0.05
01/19/2013 20:18	138	0.5	-0.3	0.00	14,622.2	0.05
01/19/2013 20:19	138	0.5	-0.3	0.00	14,600.0	0.05
01/19/2013 20:20	138	0.5	-0.3	0.00	14,622.2	0.05
01/19/2013 20:21	138	0.5	-0.3	0.00	14,644.4	0.05
01/19/2013 20:22	138	0.5	-0.3	0.00	14,622.2	0.05
Total				29		12.56

Date/Time Startup Commences: 01/20/2013 14:34
 Gas Turbine Downtime: 13 Hours
 Steam Turbine Downtime: 13 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
01/20/2013 14:34	0	0.0	0.0	0.00	911.1	0.00
01/20/2013 14:35	0	0.0	0.0	0.00	200.0	0.00
01/20/2013 14:36	0	0.0	0.0	0.00	1,422.2	0.00
01/20/2013 14:37	0	3.2	28.4	0.23	2,133.3	0.04
01/20/2013 14:38	0	2.5	1,285.4	14.26	2,888.9	0.04
01/20/2013 14:39	0	4.3	1,965.8	29.01	3,844.4	0.11
01/20/2013 14:40	0	9.2	2,163.3	36.73	4,422.2	0.26
01/20/2013 14:41	0	15.3	2,391.0	44.67	4,866.7	0.47
01/20/2013 14:42	0	24.0	2,609.5	52.09	5,200.0	0.79
01/20/2013 14:43	0	27.2	2,937.8	58.39	5,177.8	0.89
01/20/2013 14:44	3	30.8	3,209.0	64.60	5,244.4	1.02
01/20/2013 14:45	12	33.4	3,162.8	69.35	5,711.1	1.20
01/20/2013 14:46	22	36.8	2,761.6	68.56	6,466.7	1.51
01/20/2013 14:47	32	39.0	2,209.1	60.49	7,133.3	1.76
01/20/2013 14:48	42	38.0	1,460.7	44.12	7,866.7	1.89
01/20/2013 14:49	51	36.3	888.7	29.87	8,755.6	2.01
01/20/2013 14:50	62	31.7	1,519.0	55.07	9,444.4	1.90
01/20/2013 14:51	73	27.4	1,146.7	43.54	9,888.9	1.71
01/20/2013 14:52	82	24.8	202.3	8.17	10,511.1	1.66
01/20/2013 14:53	92	22.2	30.9	1.34	11,333.3	1.59
01/20/2013 14:54	102	19.5	6.2	0.29	12,111.1	1.50
01/20/2013 14:55	112	18.0	3.6	0.18	13,000.0	1.47
01/20/2013 14:56	122	16.3	2.4	0.12	13,577.8	1.40
01/20/2013 14:57	132	13.3	1.3	0.07	14,244.4	1.20
01/20/2013 14:58	139	13.0	0.8	0.05	14,733.3	1.21
01/20/2013 14:59	140	12.8	0.7	0.05	14,844.4	1.20
01/20/2013 15:00	140	14.0	0.6	0.03	14,866.7	1.33
01/20/2013 15:01	140	11.2	0.4	0.03	14,844.4	1.04
01/20/2013 15:02	140	1.5	0.2	0.03	14,844.4	0.15
01/20/2013 15:03	140	0.7	0.2	0.00	14,844.4	0.08
01/20/2013 15:04	140	0.7	0.0	0.00	14,866.7	0.05
01/20/2013 15:05	140	0.5	-0.1	0.00	14,866.7	0.05
01/20/2013 15:06	140	0.4	-0.1	0.00	14,866.7	0.05
01/20/2013 15:07	140	0.4	-0.2	0.00	14,844.4	0.05
01/20/2013 15:08	140	0.4	-0.2	0.00	14,866.7	0.05
01/20/2013 15:09	140	0.3	-0.3	0.00	14,866.7	0.03
01/20/2013 15:10	140	0.4	-0.3	0.00	14,866.7	0.05
01/20/2013 15:11	140	0.4	-0.3	0.00	14,888.9	0.05
01/20/2013 15:12	140	0.5	-0.3	0.00	14,888.9	0.05
Total				681.34		29.86

Date/Time Startup Commences: 01/21/2013 04:28
 Gas Turbine Downtime: 4 Hours
 Steam Turbine Downtime: 4 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
01/21/2013 04:28	0	0.0	0.0	0.00	666.7	0.00
01/21/2013 04:29	0	0.0	0.0	0.00	511.1	0.00
01/21/2013 04:30	0	0.0	7.9	0.05	1,600.0	0.00
01/21/2013 04:31	0	0.3	28.1	0.26	2,400.0	0.00
01/21/2013 04:32	0	1.1	44.8	0.55	3,222.2	0.02
01/21/2013 04:33	0	1.8	62.4	0.98	4,088.9	0.05
01/21/2013 04:34	0	3.9	113.5	2.00	4,600.0	0.11
01/21/2013 04:35	0	6.1	156.1	3.10	5,177.8	0.20
01/21/2013 04:36	0	9.6	173.9	3.56	5,333.3	0.32
01/21/2013 04:37	0	12.2	200.2	4.08	5,311.1	0.41
01/21/2013 04:38	4	13.6	189.8	3.94	5,400.0	0.46
01/21/2013 04:39	13	15.9	163.0	3.69	5,888.9	0.60
01/21/2013 04:40	23	19.3	142.3	3.65	6,666.7	0.81
01/21/2013 04:41	33	21.3	118.8	3.35	7,333.3	0.98
01/21/2013 04:42	45	23.9	94.6	2.95	8,111.1	1.22
01/21/2013 04:43	53	26.3	79.1	2.71	8,911.1	1.48
01/21/2013 04:44	65	24.6	86.3	3.18	9,622.2	1.50
01/21/2013 04:45	74	15.7	65.6	2.55	10,133.3	1.01
01/21/2013 04:46	83	14.6	32.6	1.35	10,800.0	1.00
01/21/2013 04:47	95	4.1	5.3	0.24	11,755.6	0.30
01/21/2013 04:48	105	1.9	1.5	0.06	12,600.0	0.15
01/21/2013 04:49	114	1.3	0.9	0.05	13,244.4	0.11
01/21/2013 04:50	123	1.1	0.7	0.05	13,888.9	0.10
01/21/2013 04:51	133	0.8	0.4	0.02	14,511.1	0.07
01/21/2013 04:52	141	0.6	0.3	0.03	15,044.4	0.05
01/21/2013 04:53	142	0.4	0.2	0.00	15,133.3	0.05
01/21/2013 04:54	142	0.4	0.1	0.00	15,111.1	0.05
01/21/2013 04:55	142	0.3	0.0	0.00	15,111.1	0.03
01/21/2013 04:56	142	0.3	-0.1	0.00	15,088.9	0.03
01/21/2013 04:57	142	0.3	-0.2	0.00	15,088.9	0.03
01/21/2013 04:58	142	0.3	-0.2	0.00	15,088.9	0.03
Total				42.4		11.17

Date/Time Startup Commences: 01/22/2013 04:23
 Gas Turbine Downtime: 4 Hours
 Steam Turbine Downtime: 4 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
01/22/2013 04:23	0	0.0	0.0	0.00	688.9	0.00
01/22/2013 04:24	0	0.0	0.0	0.00	88.9	0.00
01/22/2013 04:25	0	0.0	0.0	0.00	1,355.6	0.00
01/22/2013 04:26	0	0.5	24.6	0.20	2,066.7	0.01
01/22/2013 04:27	0	0.9	39.2	0.43	2,844.4	0.01
01/22/2013 04:28	0	2.4	51.2	0.75	3,800.0	0.06
01/22/2013 04:29	0	3.2	75.6	1.28	4,400.0	0.09
01/22/2013 04:30	0	5.4	111.6	2.16	5,044.4	0.17
01/22/2013 04:31	0	9.3	141.8	2.92	5,377.8	0.31
01/22/2013 04:32	0	12.2	170.3	3.47	5,311.1	0.41
01/22/2013 04:33	1	14.4	185.7	3.81	5,333.3	0.48
01/22/2013 04:34	9	16.3	168.7	3.64	5,622.2	0.58
01/22/2013 04:35	19	19.5	146.0	3.55	6,333.3	0.78
01/22/2013 04:36	29	21.9	130.0	3.50	7,022.2	0.98
01/22/2013 04:37	39	24.7	106.0	3.16	7,777.8	1.21
01/22/2013 04:38	48	26.2	86.3	2.80	8,444.4	1.39
01/22/2013 04:39	61	28.4	78.3	2.83	9,444.4	1.70
01/22/2013 04:40	70	21.1	90.1	3.41	9,844.4	1.32
01/22/2013 04:41	79	13.1	50.1	2.01	10,488.9	0.86
01/22/2013 04:42	89	6.3	7.9	0.35	11,222.2	0.44
01/22/2013 04:43	100	2.8	4.1	0.19	12,177.8	0.21
01/22/2013 04:44	110	1.5	0.8	0.04	12,888.9	0.13
01/22/2013 04:45	119	1.2	0.5	0.02	13,600.0	0.09
01/22/2013 04:46	129	0.7	0.5	0.02	14,222.2	0.07
01/22/2013 04:47	139	0.6	0.4	0.03	14,977.8	0.05
01/22/2013 04:48	143	0.6	0.2	0.03	15,244.4	0.05
01/22/2013 04:49	144	0.5	0.2	0.00	15,266.7	0.05
01/22/2013 04:50	144	0.5	0.0	0.00	15,266.7	0.05
01/22/2013 04:51	144	0.4	-0.1	0.00	15,222.2	0.05
01/22/2013 04:52	144	0.4	-0.2	0.00	15,222.2	0.05
01/22/2013 04:53	144	0.4	-0.2	0.00	15,200.0	0.05
Total				40.6		11.65

Date/Time Startup Commences: 01/23/2013 04:29
 Gas Turbine Downtime: 5 Hours
 Steam Turbine Downtime: 5 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
01/23/2013 04:29	0	0.0	0.0	0.00	222.2	0.00
01/23/2013 04:30	0	0.0	0.0	0.00	355.6	0.00
01/23/2013 04:31	0	0.0	0.0	0.00	977.8	0.00
01/23/2013 04:32	0	0.7	19.0	0.14	1,888.9	0.01
01/23/2013 04:33	0	0.6	29.5	0.30	2,688.9	0.01
01/23/2013 04:34	0	1.7	41.3	0.58	3,644.4	0.04
01/23/2013 04:35	0	2.6	53.8	0.87	4,244.4	0.07
01/23/2013 04:36	0	3.9	76.7	1.38	4,688.9	0.11
01/23/2013 04:37	0	7.0	95.5	2.28	6,200.0	0.28
01/23/2013 04:38	0	10.1	106.2	2.11	5,177.8	0.33
01/23/2013 04:39	1	12.6	117.8	2.37	5,244.4	0.41
01/23/2013 04:40	9	14.9	119.6	2.54	5,533.3	0.52
01/23/2013 04:41	19	19.5	109.2	2.63	6,288.9	0.78
01/23/2013 04:42	28	21.9	101.1	2.69	6,933.3	0.96
01/23/2013 04:43	39	24.7	89.3	2.62	7,644.4	1.19
01/23/2013 04:44	47	27.1	75.5	2.42	8,333.3	1.43
01/23/2013 04:45	61	28.4	69.9	2.49	9,288.9	1.67
01/23/2013 04:46	70	20.8	69.2	2.60	9,777.8	1.29
01/23/2013 04:47	79	11.9	34.3	1.38	10,466.7	0.79
01/23/2013 04:48	88	4.8	6.2	0.27	11,200.0	0.35
01/23/2013 04:49	99	2.0	4.2	0.19	12,044.4	0.14
01/23/2013 04:50	110	1.1	2.2	0.11	12,844.4	0.09
01/23/2013 04:51	119	1.0	0.8	0.05	13,533.3	0.09
01/23/2013 04:52	129	0.8	0.3	0.02	14,133.3	0.07
01/23/2013 04:53	138	0.6	0.2	0.00	14,755.6	0.05
01/23/2013 04:54	140	0.5	0.1	0.00	14,844.4	0.05
01/23/2013 04:55	140	0.4	0.0	0.00	14,800.0	0.05
01/23/2013 04:56	140	0.4	-0.2	0.00	14,800.0	0.05
01/23/2013 04:57	140	0.4	-0.2	0.00	14,777.8	0.05
01/23/2013 04:58	140	0.4	-0.2	0.00	14,711.1	0.05
01/23/2013 04:59	140	0.4	-0.3	0.00	14,711.1	0.05
01/23/2013 05:00	140	0.4	-0.3	0.00	14,733.3	0.05
Total				30.04		11.03

Date/Time Startup Commences: 01/23/2013 12:13
 Gas Turbine Downtime: 3 Hours
 Steam Turbine Downtime: 3 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
01/23/2013 12:13	0	0.0	0.0	0.00	688.9	0.00
01/23/2013 12:14	0	0.0	0.0	0.00	0.0	0.00
01/23/2013 12:15	0	0.0	0.0	0.00	1,333.3	0.00
01/23/2013 12:16	0	0.5	22.5	0.17	2,000.0	0.01
01/23/2013 12:17	0	1.4	32.9	0.36	2,800.0	0.02
01/23/2013 12:18	0	2.6	40.0	0.58	3,755.6	0.06
01/23/2013 12:19	0	3.7	58.3	0.97	4,333.3	0.10
01/23/2013 12:20	0	5.7	83.3	1.57	4,911.1	0.18
01/23/2013 12:21	0	8.7	96.6	1.94	5,244.4	0.29
01/23/2013 12:22	0	11.8	115.9	2.30	5,177.8	0.38
01/23/2013 12:23	2	14.0	125.5	2.55	5,288.9	0.47
01/23/2013 12:24	7	15.9	121.3	2.51	5,377.8	0.54
01/23/2013 12:25	18	19.9	113.8	2.72	6,222.2	0.78
01/23/2013 12:26	31	22.6	106.0	2.88	7,088.9	1.01
01/23/2013 12:27	44	27.0	88.0	2.72	8,044.4	1.38
01/23/2013 12:28	59	29.6	67.0	2.35	9,133.3	1.71
01/23/2013 12:29	72	25.5	70.7	2.68	9,888.9	1.59
01/23/2013 12:30	84	16.8	24.1	1.01	10,933.3	1.16
01/23/2013 12:31	99	10.3	3.7	0.17	12,066.7	0.79
01/23/2013 12:32	113	3.0	1.5	0.07	13,066.7	0.25
01/23/2013 12:33	125	1.5	1.0	0.05	13,844.4	0.14
01/23/2013 12:34	137	1.1	0.5	0.03	14,533.3	0.10
01/23/2013 12:35	139	0.7	0.4	0.03	14,622.2	0.08
01/23/2013 12:36	140	0.4	0.7	0.05	14,755.6	0.05
01/23/2013 12:37	140	0.3	0.7	0.05	14,711.1	0.03
01/23/2013 12:38	140	0.3	0.3	0.03	14,733.3	0.03
01/23/2013 12:39	140	0.3	-0.1	0.00	14,733.3	0.03
01/23/2013 12:40	140	0.3	-0.2	0.00	14,733.3	0.03
01/23/2013 12:41	140	0.4	-0.2	0.00	14,800.0	0.05
01/23/2013 12:42	142	0.4	-0.3	0.00	14,888.9	0.05
01/23/2013 12:43	142	0.6	-0.3	0.00	14,888.9	0.05
Total				27.79		11.36

Date/Time Startup Commences: 01/24/2013 06:37
 Gas Turbine Downtime: 8 Hours
 Steam Turbine Downtime: 8 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
01/24/2013 06:37	0	0.0	0.0	0.00	755.6	0.00
01/24/2013 06:38	0	0.0	0.0	0.00	200.0	0.00
01/24/2013 06:39	0	0.0	0.0	0.00	1,422.2	0.00
01/24/2013 06:40	0	2.5	22.3	0.18	2,133.3	0.03
01/24/2013 06:41	0	1.7	44.4	0.49	2,911.1	0.03
01/24/2013 06:42	0	1.7	66.4	0.99	3,866.7	0.04
01/24/2013 06:43	0	3.9	187.5	3.20	4,444.4	0.11
01/24/2013 06:44	0	6.1	317.7	6.02	4,933.3	0.19
01/24/2013 06:45	0	10.9	508.9	10.24	5,244.4	0.36
01/24/2013 06:46	0	15.2	861.4	17.27	5,222.2	0.50
01/24/2013 06:47	3	17.1	835.0	16.95	5,288.9	0.57
01/24/2013 06:48	10	20.8	702.3	15.22	5,644.4	0.75
01/24/2013 06:49	20	21.5	554.2	13.62	6,400.0	0.87
01/24/2013 06:50	30	24.8	318.9	8.65	7,066.7	1.10
01/24/2013 06:51	40	25.8	166.3	4.98	7,800.0	1.27
01/24/2013 06:52	49	26.3	103.8	3.36	8,444.4	1.40
01/24/2013 06:53	61	26.1	103.9	3.76	9,400.0	1.55
01/24/2013 06:54	69	21.7	95.8	3.61	9,800.0	1.34
01/24/2013 06:55	79	22.8	46.0	1.85	10,488.9	1.51
01/24/2013 06:56	90	21.8	6.0	0.25	11,400.0	1.56
01/24/2013 06:57	100	10.5	2.8	0.13	12,200.0	0.82
01/24/2013 06:58	111	2.6	1.8	0.09	12,911.1	0.22
01/24/2013 06:59	120	1.4	1.0	0.05	13,533.3	0.12
01/24/2013 07:00	130	0.8	0.6	0.02	14,200.0	0.07
01/24/2013 07:01	139	0.8	0.5	0.03	14,866.7	0.08
01/24/2013 07:02	142	0.6	0.3	0.03	14,955.6	0.05
01/24/2013 07:03	142	0.5	0.2	0.03	14,933.3	0.05
01/24/2013 07:04	142	0.4	0.1	0.00	14,933.3	0.05
01/24/2013 07:05	142	0.3	0.0	0.00	14,888.9	0.03
01/24/2013 07:06	142	0.3	-0.1	0.00	14,866.7	0.03
01/24/2013 07:07	142	0.3	-0.2	0.00	14,888.9	0.03
01/24/2013 07:08	142	0.3	-0.2	0.00	14,911.1	0.03
01/24/2013 07:09	142	0.3	-0.2	0.00	14,911.1	0.03
Total				111.02		14.79

Date/Time Startup Commences: 01/24/2013 12:41
 Gas Turbine Downtime: 2 Hours
 Steam Turbine Downtime: 2 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
01/24/2013 12:41	0	0.0	0.0	0.00	622.2	0.00
01/24/2013 12:42	0	0.0	0.0	0.00	666.7	0.00
01/24/2013 12:43	0	1.5	14.8	0.10	1,688.9	0.01
01/24/2013 12:44	0	1.6	25.8	0.25	2,466.7	0.03
01/24/2013 12:45	0	3.4	37.9	0.49	3,355.6	0.07
01/24/2013 12:46	0	4.2	47.4	0.75	4,111.1	0.11
01/24/2013 12:47	0	5.7	68.4	1.21	4,622.2	0.17
01/24/2013 12:48	0	8.3	86.5	1.83	5,511.1	0.29
01/24/2013 12:49	0	11.4	100.9	2.03	5,244.4	0.38
01/24/2013 12:50	0	14.0	118.6	2.38	5,222.2	0.47
01/24/2013 12:51	6	16.1	122.9	2.53	5,355.6	0.54
01/24/2013 12:52	15	19.8	113.4	2.60	5,977.8	0.75
01/24/2013 12:53	25	22.9	104.8	2.70	6,688.9	0.96
01/24/2013 12:54	35	26.2	93.0	2.62	7,355.6	1.21
01/24/2013 12:55	44	28.3	79.4	2.48	8,111.1	1.45
01/24/2013 12:56	55	32.0	66.3	2.28	8,977.8	1.82
01/24/2013 12:57	66	26.9	80.7	2.96	9,533.3	1.62
01/24/2013 12:58	75	14.6	45.4	1.78	10,155.6	0.94
01/24/2013 12:59	85	4.6	7.8	0.32	10,933.3	0.32
01/24/2013 13:00	95	1.8	4.9	0.22	11,822.2	0.14
01/24/2013 13:01	105	1.3	3.1	0.15	12,533.3	0.11
01/24/2013 13:02	115	0.9	1.4	0.07	13,200.0	0.07
01/24/2013 13:03	125	0.7	0.4	0.02	13,844.4	0.05
01/24/2013 13:04	135	0.5	0.2	0.00	14,511.1	0.05
01/24/2013 13:05	138	0.4	0.1	0.00	14,622.2	0.05
01/24/2013 13:06	138	0.3	0.0	0.00	14,622.2	0.03
01/24/2013 13:07	138	0.3	-0.2	0.00	14,622.2	0.03
01/24/2013 13:08	138	0.3	-0.2	0.00	14,577.8	0.03
01/24/2013 13:09	138	0.3	-0.3	0.00	14,577.8	0.03
01/24/2013 13:10	138	0.4	-0.3	0.00	14,577.8	0.05
01/24/2013 13:11	138	0.4	-0.3	0.00	14,600.0	0.05
01/24/2013 13:12	138	0.4	-0.3	0.00	14,644.4	0.05
Total				29.77		11.88

Date/Time Startup Commences: 01/25/2013 04:49
 Gas Turbine Downtime: 13 Hours
 Steam Turbine Downtime: 13 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
01/25/2013 04:49	0	0.0	0.0	0.00	222.2	0.00
01/25/2013 04:50	0	0.0	0.0	0.00	355.6	0.00
01/25/2013 04:51	0	0.0	0.0	0.00	1,066.7	0.00
01/25/2013 04:52	0	8.9	27.5	0.20	1,866.7	0.11
01/25/2013 04:53	0	3.5	523.6	5.36	2,666.7	0.06
01/25/2013 04:54	0	5.7	1,838.9	25.41	3,600.0	0.13
01/25/2013 04:55	0	9.4	2,221.7	36.58	4,288.9	0.26
01/25/2013 04:56	0	14.6	2,398.2	43.79	4,755.6	0.44
01/25/2013 04:57	0	22.3	2,597.7	62.27	6,244.4	0.88
01/25/2013 04:58	0	25.1	2,804.2	56.45	5,244.4	0.83
01/25/2013 04:59	4	29.5	3,219.5	65.92	5,333.3	1.00
01/25/2013 05:00	13	33.0	3,223.8	72.88	5,888.9	1.22
01/25/2013 05:01	23	35.9	2,858.5	72.67	6,622.2	1.50
01/25/2013 05:02	33	38.7	2,272.0	63.58	7,288.9	1.78
01/25/2013 05:03	43	36.9	1,505.3	46.35	8,022.2	1.87
01/25/2013 05:04	52	37.9	879.1	29.70	8,800.0	2.11
01/25/2013 05:05	64	35.0	1,078.9	39.21	9,466.7	2.09
01/25/2013 05:06	73	29.7	492.6	19.00	10,044.4	1.90
01/25/2013 05:07	83	30.6	43.8	1.81	10,777.8	2.09
01/25/2013 05:08	93	29.1	5.8	0.26	11,711.1	2.15
01/25/2013 05:09	103	26.2	2.1	0.11	12,466.7	2.05
01/25/2013 05:10	113	23.4	1.5	0.07	13,155.6	1.94
01/25/2013 05:11	123	19.2	1.1	0.05	13,822.2	1.68
01/25/2013 05:12	133	17.1	0.8	0.05	14,444.4	1.56
01/25/2013 05:13	139	16.5	0.7	0.05	14,844.4	1.55
01/25/2013 05:14	140	16.5	0.7	0.05	14,844.4	1.55
01/25/2013 05:15	140	16.4	0.6	0.03	14,844.4	1.53
01/25/2013 05:16	140	13.4	0.5	0.03	14,800.0	1.24
01/25/2013 05:17	140	2.0	0.3	0.03	14,777.8	0.18
01/25/2013 05:18	140	0.7	0.2	0.00	14,800.0	0.08
01/25/2013 05:19	140	0.6	0.1	0.00	14,800.0	0.05
01/25/2013 05:20	140	0.5	0.0	0.00	14,800.0	0.05
01/25/2013 05:21	140	0.4	-0.1	0.00	14,800.0	0.05
01/25/2013 05:22	141	0.3	-0.1	0.00	14,933.3	0.03
01/25/2013 05:23	142	0.3	-0.1	0.00	14,911.1	0.03
01/25/2013 05:24	142	0.3	-0.2	0.00	14,955.6	0.03
01/25/2013 05:25	142	0.3	-0.2	0.00	14,977.8	0.03
01/25/2013 05:26	142	0.3	-0.2	0.00	14,977.8	0.03
01/25/2013 05:27	142	0.3	-0.3	0.00	14,977.8	0.03
Total				641.91		34.11

Date/Time Startup Commences: 01/27/2013 14:41
 Gas Turbine Downtime: 39 Hours
 Steam Turbine Downtime: 39 Hours
 Startup Type*: warm

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
01/27/2013 14:41	0	0.0	0.0	0.00	955.6	0.00
01/27/2013 14:42	0	0.0	0.0	0.00	400.0	0.00
01/27/2013 14:43	0	0.0	0.0	0.00	1,511.1	0.00
01/27/2013 14:44	0	14.5	2,699.5	23.72	2,288.9	0.21
01/27/2013 14:45	0	12.1	2,752.1	32.40	3,066.7	0.24
01/27/2013 14:46	0	14.8	2,257.9	34.09	3,933.3	0.36
01/27/2013 14:47	0	19.4	2,275.4	39.01	4,466.7	0.55
01/27/2013 14:48	0	24.7	2,519.8	50.08	5,177.8	0.81
01/27/2013 14:49	0	28.6	2,598.6	51.66	5,177.8	0.93
01/27/2013 14:50	0	33.5	2,915.9	57.96	5,177.8	1.09
01/27/2013 14:51	1	35.0	3,116.0	61.40	5,133.3	1.14
01/27/2013 14:52	3	35.4	3,059.5	63.16	5,377.8	1.20
01/27/2013 14:53	4	38.4	3,019.6	63.88	5,511.1	1.33
01/27/2013 14:54	4	39.1	3,131.5	67.59	5,622.2	1.39
01/27/2013 14:55	11	40.0	3,138.0	72.01	5,977.8	1.51
01/27/2013 14:56	21	43.0	3,272.3	82.36	6,555.6	1.79
01/27/2013 14:57	30	46.6	3,340.8	90.63	7,066.7	2.08
01/27/2013 14:58	40	44.2	2,701.1	79.26	7,644.4	2.14
01/27/2013 14:59	49	42.4	1,669.7	53.99	8,422.2	2.25
01/27/2013 15:00	61	43.3	1,630.3	58.55	9,355.6	2.57
01/27/2013 15:01	71	38.3	2,470.9	92.75	9,777.8	2.36
01/27/2013 15:02	80	36.0	1,000.5	39.78	10,355.6	2.36
01/27/2013 15:03	90	36.3	149.4	6.34	11,066.7	2.54
01/27/2013 15:04	100	31.8	20.3	0.93	11,800.0	2.37
01/27/2013 15:05	110	28.6	4.5	0.22	12,644.4	2.30
01/27/2013 15:06	121	25.8	2.5	0.14	13,422.2	2.19
01/27/2013 15:07	131	20.4	1.9	0.10	14,044.4	1.81
01/27/2013 15:08	139	18.8	1.3	0.08	14,733.3	1.74
01/27/2013 15:09	140	18.0	1.0	0.05	14,844.4	1.68
01/27/2013 15:10	141	17.7	0.9	0.05	14,911.1	1.66
01/27/2013 15:11	141	17.5	0.8	0.05	14,866.7	1.63
01/27/2013 15:12	141	17.0	0.7	0.05	14,866.7	1.58
01/27/2013 15:13	141	16.5	0.6	0.03	14,866.7	1.56
01/27/2013 15:14	141	16.4	0.5	0.03	14,866.7	1.53
01/27/2013 15:15	141	16.7	0.3	0.03	14,866.7	1.56
01/27/2013 15:16	141	16.8	0.2	0.00	14,866.7	1.58
01/27/2013 15:17	141	12.6	0.1	0.00	14,866.7	1.20
01/27/2013 15:18	142	1.0	0.0	0.00	14,866.7	0.10
01/27/2013 15:19	141	0.6	0.0	0.00	14,844.4	0.05
01/27/2013 15:20	141	0.5	-0.1	0.00	14,866.7	0.05
01/27/2013 15:21	141	0.3	-0.1	0.00	14,866.7	0.03
01/27/2013 15:22	141	0.3	-0.2	0.00	14,866.7	0.03
01/27/2013 15:23	141	0.3	-0.2	0.00	14,844.4	0.03
01/27/2013 15:24	141	0.3	-0.2	0.00	14,866.7	0.03
01/27/2013 15:25	141	0.3	-0.3	0.00	14,844.4	0.03
01/27/2013 15:26	141	0.3	-0.3	0.00	14,844.4	0.03
01/27/2013 15:27	141	0.3	-0.3	0.00	14,866.7	0.03
01/27/2013 15:28	141	0.4	-0.3	0.00	14,866.7	0.05
Total				1122.38		53.7

Date/Time Startup Commences: 01/28/2013 04:32
 Gas Turbine Downtime: 5 Hours
 Steam Turbine Downtime: 5 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
01/28/2013 04:32	0	0.0	0.0	0.00	800.0	0.00
01/28/2013 04:33	0	0.0	0.0	0.00	88.9	0.00
01/28/2013 04:34	0	0.0	0.0	0.00	1,222.2	0.00
01/28/2013 04:35	0	4.1	24.8	0.19	1,977.8	0.05
01/28/2013 04:36	0	2.4	89.7	0.95	2,755.6	0.04
01/28/2013 04:37	0	3.5	545.9	7.82	3,733.3	0.08
01/28/2013 04:38	0	6.4	1,442.8	24.00	4,333.3	0.17
01/28/2013 04:39	0	12.7	2,039.5	37.93	4,844.4	0.39
01/28/2013 04:40	0	22.7	2,151.9	43.69	5,288.9	0.76
01/28/2013 04:41	0	24.9	2,549.5	51.12	5,222.2	0.82
01/28/2013 04:42	0	26.6	2,688.3	53.67	5,200.0	0.87
01/28/2013 04:43	4	29.1	2,675.2	54.31	5,288.9	0.97
01/28/2013 04:44	9	31.1	2,500.2	54.82	5,711.1	1.12
01/28/2013 04:45	19	32.0	2,256.8	55.26	6,377.8	1.29
01/28/2013 04:46	29	33.4	1,537.6	41.19	6,977.8	1.47
01/28/2013 04:47	39	31.5	621.5	18.29	7,666.7	1.53
01/28/2013 04:48	48	30.1	192.9	6.22	8,400.0	1.60
01/28/2013 04:49	59	30.0	125.8	4.47	9,244.4	1.76
01/28/2013 04:50	70	23.0	162.9	6.11	9,755.6	1.42
01/28/2013 04:51	79	23.4	50.5	2.02	10,400.0	1.53
01/28/2013 04:52	88	27.2	7.3	0.31	11,200.0	1.92
01/28/2013 04:53	99	26.4	3.5	0.16	12,000.0	2.00
01/28/2013 04:54	109	26.7	2.2	0.11	12,800.0	2.15
01/28/2013 04:55	119	24.5	1.5	0.07	13,533.3	2.09
01/28/2013 04:56	129	16.6	0.9	0.05	14,111.1	1.48
01/28/2013 04:57	138	2.7	0.8	0.05	14,733.3	0.25
01/28/2013 04:58	140	0.9	0.7	0.03	14,844.4	0.08
01/28/2013 04:59	140	0.6	0.5	0.03	14,844.4	0.05
01/28/2013 05:00	140	0.5	0.2	0.03	14,800.0	0.05
01/28/2013 05:01	140	0.4	0.2	0.00	14,777.8	0.05
01/28/2013 05:02	140	0.3	0.0	0.00	14,777.8	0.03
01/28/2013 05:03	141	0.3	-0.1	0.00	14,755.6	0.03
01/28/2013 05:04	141	0.3	-0.1	0.00	14,755.6	0.03
01/28/2013 05:05	141	0.3	-0.2	0.00	14,733.3	0.03
01/28/2013 05:06	141	0.3	-0.2	0.00	14,733.3	0.03
01/28/2013 05:07	141	0.3	-0.3	0.00	14,777.8	0.03
Total				462.9		26.17

Date/Time Startup Commences: 02/03/2013 13:23
 Gas Turbine Downtime: 133 Hours
 Steam Turbine Downtime: 133 Hours
 Startup Type*: Cold

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
02/03/2013 13:23	0	0.0	0.0	0.00	1,155.6	0.00
02/03/2013 13:24	0	0.0	0.0	0.00	600.0	0.00
02/03/2013 13:25	0	53.1	147.5	0.93	1,644.4	0.55
02/03/2013 13:26	0	10.4	2,552.9	23.74	2,422.2	0.16
02/03/2013 13:27	0	10.7	2,629.2	32.30	3,200.0	0.21
02/03/2013 13:28	0	12.9	2,067.7	32.46	4,088.9	0.33
02/03/2013 13:29	0	17.7	2,169.5	38.31	4,600.0	0.51
02/03/2013 13:30	0	22.9	2,425.6	46.77	5,022.2	0.73
02/03/2013 13:31	0	27.0	2,541.8	51.17	5,244.4	0.89
02/03/2013 13:32	0	31.1	2,890.6	57.95	5,222.2	1.03
02/03/2013 13:33	3	32.1	3,051.7	67.68	5,777.8	1.17
02/03/2013 13:34	8	35.8	3,066.2	66.71	5,666.7	1.28
02/03/2013 13:35	18	38.4	2,806.4	68.71	6,377.8	1.54
02/03/2013 13:36	28	42.5	2,376.9	64.49	7,066.7	1.89
02/03/2013 13:37	38	42.5	1,827.0	54.87	7,822.2	2.11
02/03/2013 13:38	46	43.7	1,382.6	45.18	8,511.1	2.35
02/03/2013 13:39	58	44.8	1,357.7	47.95	9,200.0	2.60
02/03/2013 13:40	68	38.8	1,534.2	57.98	9,844.4	2.41
02/03/2013 13:41	77	40.3	329.2	13.34	10,555.6	2.70
02/03/2013 13:42	87	41.7	20.0	0.88	11,422.2	3.02
02/03/2013 13:43	98	38.0	5.8	0.27	12,222.2	2.93
02/03/2013 13:44	107	31.5	3.6	0.17	12,600.0	2.51
02/03/2013 13:45	118	23.1	3.0	0.16	13,288.9	1.94
02/03/2013 13:46	128	18.8	2.0	0.12	14,022.2	1.66
02/03/2013 13:47	137	16.7	1.3	0.08	14,711.1	1.54
02/03/2013 13:48	139	15.3	0.9	0.05	14,888.9	1.43
02/03/2013 13:49	140	15.0	0.7	0.03	14,888.9	1.40
02/03/2013 13:50	140	14.4	0.5	0.03	14,866.7	1.35
02/03/2013 13:51	140	13.4	0.4	0.03	14,866.7	1.25
02/03/2013 13:52	140	13.5	0.3	0.03	14,866.7	1.27
02/03/2013 13:53	140	13.7	0.2	0.03	14,888.9	1.30
02/03/2013 13:54	140	14.0	0.2	0.03	14,888.9	1.30
02/03/2013 13:55	140	14.2	0.2	0.00	14,888.9	1.33
02/03/2013 13:56	140	14.5	0.2	0.00	14,888.9	1.35
02/03/2013 13:57	140	14.7	0.1	0.00	14,888.9	1.38
02/03/2013 13:58	140	15.3	0.0	0.00	14,911.1	1.43
02/03/2013 13:59	140	12.1	0.0	0.00	14,888.9	1.12
02/03/2013 14:00	140	1.3	-0.1	0.00	14,911.1	0.13
02/03/2013 14:01	140	0.7	-0.1	0.00	14,911.1	0.05
02/03/2013 14:02	140	0.6	-0.1	0.00	14,933.3	0.05
02/03/2013 14:03	140	0.4	-0.2	0.00	14,933.3	0.05
02/03/2013 14:04	140	0.3	-0.2	0.00	14,933.3	0.03
02/03/2013 14:05	141	0.3	-0.2	0.00	14,933.3	0.03
02/03/2013 14:06	141	0.3	-0.2	0.00	14,888.9	0.03
02/03/2013 14:07	141	0.3	-0.3	0.00	14,866.7	0.03
02/03/2013 14:08	141	0.3	-0.3	0.00	14,866.7	0.03
02/03/2013 14:09	140	0.3	-0.3	0.00	14,866.7	0.03
02/03/2013 14:10	141	0.3	-0.3	0.00	14,844.4	0.03
Total				772.45		52.46

Date/Time Startup Commences: 02/03/2013 18:32
 Gas Turbine Downtime: 2 Hours
 Steam Turbine Downtime: 2 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
02/03/2013 18:32	0	0.0	0.0	0.00	911.1	0.00
02/03/2013 18:33	0	0.0	0.0	0.00	311.1	0.00
02/03/2013 18:34	0	0.0	-8.9	0.00	1,555.6	0.00
02/03/2013 18:35	0	0.0	23.9	0.21	2,311.1	0.00
02/03/2013 18:36	0	0.0	38.5	0.47	3,155.6	0.00
02/03/2013 18:37	0	0.0	43.7	0.66	3,955.6	0.00
02/03/2013 18:38	0	0.0	63.8	1.10	4,488.9	0.00
02/03/2013 18:39	0	0.2	88.0	1.71	5,066.7	0.01
02/03/2013 18:40	0	0.2	99.2	1.98	5,200.0	0.01
02/03/2013 18:41	0	0.4	121.2	2.41	5,177.8	0.02
02/03/2013 18:42	1	0.6	122.9	2.44	5,177.8	0.02
02/03/2013 18:43	4	0.8	123.7	2.48	5,222.2	0.03
02/03/2013 18:44	4	1.1	119.7	2.52	5,488.9	0.04
02/03/2013 18:45	4	1.6	133.5	2.88	5,622.2	0.06
02/03/2013 18:46	4	2.2	145.9	3.22	5,733.3	0.08
02/03/2013 18:47	10	3.7	163.0	3.77	6,022.2	0.14
02/03/2013 18:48	20	4.6	170.2	4.28	6,555.6	0.19
02/03/2013 18:49	29	5.9	152.3	4.15	7,088.9	0.27
02/03/2013 18:50	40	7.4	116.7	3.46	7,733.3	0.36
02/03/2013 18:51	48	9.4	85.2	2.80	8,555.6	0.51
02/03/2013 18:52	60	10.2	86.1	3.05	9,222.2	0.60
02/03/2013 18:53	70	7.6	77.8	2.90	9,711.1	0.47
02/03/2013 18:54	79	6.0	37.6	1.50	10,422.2	0.39
02/03/2013 18:55	89	4.1	7.2	0.31	11,244.4	0.29
02/03/2013 18:56	100	2.5	5.0	0.23	12,066.7	0.19
02/03/2013 18:57	110	2.2	2.6	0.13	12,777.8	0.18
02/03/2013 18:58	120	1.6	0.9	0.05	13,400.0	0.14
02/03/2013 18:59	129	1.2	0.3	0.02	13,977.8	0.10
02/03/2013 19:00	139	1.1	0.2	0.00	14,711.1	0.10
02/03/2013 19:01	144	1.0	0.1	0.00	15,111.1	0.10
02/03/2013 19:02	141	1.1	-0.1	0.00	14,844.4	0.10
02/03/2013 19:03	141	1.2	-0.2	0.00	14,800.0	0.13
02/03/2013 19:04	140	1.2	-0.2	0.00	14,777.8	0.13
02/03/2013 19:05	140	1.2	-0.3	0.00	14,733.3	0.10
02/03/2013 19:06	140	1.1	-0.3	0.00	14,755.6	0.10
02/03/2013 19:07	140	1.0	-0.3	0.00	14,755.6	0.10
02/03/2013 19:08	140	1.0	-0.3	0.00	14,777.8	0.10
Total				48.73		5.06

Date/Time Startup Commences: 02/04/2013 05:29
 Gas Turbine Downtime: 6 Hours
 Steam Turbine Downtime: 6 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
02/04/2013 05:29	0	0.0	0.0	0.00	666.7	0.00
02/04/2013 05:30	0	0.0	0.0	0.00	488.9	0.00
02/04/2013 05:31	0	0.0	3.0	0.02	1,555.6	0.00
02/04/2013 05:32	0	0.7	27.4	0.25	2,377.8	0.01
02/04/2013 05:33	0	2.6	45.9	0.57	3,244.4	0.05
02/04/2013 05:34	0	3.1	62.9	0.99	4,088.9	0.08
02/04/2013 05:35	0	5.2	101.2	1.78	4,577.8	0.15
02/04/2013 05:36	0	7.9	140.0	2.78	5,177.8	0.26
02/04/2013 05:37	0	11.8	163.9	3.33	5,288.9	0.39
02/04/2013 05:38	0	15.4	207.1	4.19	5,266.7	0.51
02/04/2013 05:39	4	16.5	205.1	4.20	5,333.3	0.56
02/04/2013 05:40	13	20.7	184.5	4.19	5,911.1	0.77
02/04/2013 05:41	23	21.7	160.5	4.08	6,622.2	0.91
02/04/2013 05:42	33	25.2	140.6	3.93	7,266.7	1.16
02/04/2013 05:43	43	27.4	111.6	3.44	8,022.2	1.39
02/04/2013 05:44	52	28.9	90.2	3.08	8,888.9	1.63
02/04/2013 05:45	64	26.4	115.8	4.24	9,555.6	1.59
02/04/2013 05:46	74	16.0	76.7	2.98	10,088.9	1.02
02/04/2013 05:47	83	10.8	35.3	1.47	10,822.2	0.74
02/04/2013 05:48	93	4.2	5.5	0.24	11,622.2	0.30
02/04/2013 05:49	104	2.0	3.3	0.15	12,488.9	0.15
02/04/2013 05:50	114	1.3	2.1	0.11	13,200.0	0.11
02/04/2013 05:51	123	0.8	1.0	0.05	13,844.4	0.07
02/04/2013 05:52	134	0.6	0.7	0.05	14,555.6	0.05
02/04/2013 05:53	139	0.5	0.5	0.03	14,933.3	0.05
02/04/2013 05:54	140	0.4	0.3	0.03	14,911.1	0.05
02/04/2013 05:55	140	0.3	0.2	0.00	14,933.3	0.03
02/04/2013 05:56	139	0.3	0.1	0.00	14,844.4	0.03
02/04/2013 05:57	140	0.3	0.0	0.00	14,844.4	0.03
02/04/2013 05:58	140	0.2	-0.1	0.00	14,844.4	0.03
02/04/2013 05:59	89	0.3	-0.1	0.00	9,444.4	0.02
Total				46.18		12.14

Date/Time Startup Commences: 02/04/2013 07:06
 Gas Turbine Downtime: 1 Hours
 Steam Turbine Downtime: 1 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
02/04/2013 07:06	0	0.0	0.0	0.00	800.0	0.00
02/04/2013 07:07	0	0.0	0.0	0.00	200.0	0.00
02/04/2013 07:08	0	0.0	-5.9	0.00	1,488.9	0.00
02/04/2013 07:09	0	0.0	26.9	0.23	2,266.7	0.00
02/04/2013 07:10	0	0.0	37.0	0.44	3,088.9	0.00
02/04/2013 07:11	0	0.2	42.8	0.65	3,977.8	0.01
02/04/2013 07:12	0	0.2	63.3	1.09	4,488.9	0.01
02/04/2013 07:13	0	0.7	85.1	1.64	5,044.4	0.03
02/04/2013 07:14	0	1.3	98.3	2.00	5,288.9	0.05
02/04/2013 07:15	0	2.5	114.2	2.31	5,266.7	0.08
02/04/2013 07:16	1	2.6	117.8	2.39	5,288.9	0.09
02/04/2013 07:17	3	3.9	118.6	2.42	5,311.1	0.13
02/04/2013 07:18	4	4.9	115.0	2.45	5,555.6	0.17
02/04/2013 07:19	10	6.1	123.7	2.85	6,000.0	0.23
02/04/2013 07:20	21	9.0	139.2	3.56	6,644.4	0.38
02/04/2013 07:21	30	12.2	134.8	3.75	7,244.4	0.56
02/04/2013 07:22	40	17.4	117.5	3.56	7,888.9	0.87
02/04/2013 07:23	49	19.0	89.1	2.94	8,622.2	1.04
02/04/2013 07:24	61	22.0	80.5	2.90	9,377.8	1.30
02/04/2013 07:25	71	15.9	84.0	3.19	9,888.9	0.98
02/04/2013 07:26	80	14.4	39.9	1.61	10,533.3	0.96
02/04/2013 07:27	90	3.6	6.6	0.29	11,377.8	0.25
02/04/2013 07:28	101	1.7	4.4	0.21	12,222.2	0.13
02/04/2013 07:29	111	1.3	2.5	0.13	12,977.8	0.11
02/04/2013 07:30	120	1.1	0.9	0.05	13,622.2	0.09
02/04/2013 07:31	130	0.9	0.3	0.02	14,311.1	0.07
02/04/2013 07:32	138	0.8	0.2	0.00	14,888.9	0.08
02/04/2013 07:33	140	0.7	0.1	0.00	14,955.6	0.05
02/04/2013 07:34	140	0.7	0.0	0.00	14,933.3	0.05
02/04/2013 07:35	140	0.7	-0.1	0.00	14,933.3	0.05
02/04/2013 07:36	140	0.7	-0.1	0.00	14,888.9	0.05
02/04/2013 07:37	140	0.7	-0.1	0.00	14,866.7	0.05
02/04/2013 07:38	140	0.7	-0.2	0.00	14,888.9	0.05
02/04/2013 07:39	140	0.7	-0.2	0.00	14,866.7	0.05
Total				40.68		7.97

Date/Time Startup Commences: 02/06/2013 03:25
 Gas Turbine Downtime: 27 Hours
 Steam Turbine Downtime: 27 Hours
 Startup Type*: warm

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
02/06/2013 03:25	0	0.0	0.0	0.00	822.2	0.00
02/06/2013 03:26	0	0.0	0.0	0.00	333.3	0.00
02/06/2013 03:27	0	0.0	0.0	0.00	1,511.1	0.00
02/06/2013 03:28	0	10.0	2,392.2	21.02	2,288.9	0.15
02/06/2013 03:29	0	9.1	2,822.3	33.71	3,111.1	0.18
02/06/2013 03:30	0	10.7	2,382.7	37.20	4,066.7	0.27
02/06/2013 03:31	0	15.5	2,417.5	42.89	4,622.2	0.45
02/06/2013 03:32	0	19.7	2,640.9	51.38	5,066.7	0.63
02/06/2013 03:33	0	25.3	2,670.5	54.68	5,333.3	0.85
02/06/2013 03:34	0	30.1	2,793.7	56.95	5,311.1	1.01
02/06/2013 03:35	3	32.2	2,981.6	79.11	6,911.1	1.41
02/06/2013 03:36	3	34.8	2,935.6	61.60	5,466.7	1.20
02/06/2013 03:37	4	35.8	2,982.1	65.13	5,688.9	1.29
02/06/2013 03:38	4	36.4	3,019.6	67.23	5,800.0	1.33
02/06/2013 03:39	8	37.2	3,073.7	71.84	6,088.9	1.43
02/06/2013 03:40	19	39.6	3,176.5	81.03	6,644.4	1.66
02/06/2013 03:41	28	44.4	3,184.4	88.02	7,200.0	2.03
02/06/2013 03:42	38	43.2	2,417.7	72.39	7,800.0	2.13
02/06/2013 03:43	48	40.5	1,455.5	47.81	8,555.6	2.19
02/06/2013 03:44	58	41.4	1,041.7	37.15	9,288.9	2.44
02/06/2013 03:45	68	32.1	1,411.5	53.33	9,844.4	1.99
02/06/2013 03:46	78	30.3	241.7	9.79	10,555.6	2.03
02/06/2013 03:47	88	30.9	8.3	0.37	11,355.6	2.22
02/06/2013 03:48	98	28.1	3.6	0.17	12,200.0	2.16
02/06/2013 03:49	109	24.5	1.8	0.09	12,955.6	2.00
02/06/2013 03:50	119	20.4	1.5	0.07	13,666.7	1.76
02/06/2013 03:51	128	17.1	1.2	0.07	14,311.1	1.55
02/06/2013 03:52	137	15.8	1.0	0.05	14,977.8	1.49
02/06/2013 03:53	140	15.3	0.9	0.05	15,133.3	1.45
02/06/2013 03:54	140	15.0	0.9	0.05	15,133.3	1.43
02/06/2013 03:55	140	14.7	0.7	0.05	15,066.7	1.40
02/06/2013 03:56	141	13.7	0.7	0.03	15,022.2	1.31
02/06/2013 03:57	141	13.8	0.5	0.03	14,977.8	1.31
02/06/2013 03:58	141	13.9	0.3	0.03	15,000.0	1.31
02/06/2013 03:59	141	12.2	0.2	0.03	14,977.8	1.16
02/06/2013 04:00	140	1.4	0.2	0.00	14,977.8	0.13
02/06/2013 04:01	140	0.7	0.1	0.00	14,977.8	0.05
02/06/2013 04:02	140	0.6	0.1	0.00	14,977.8	0.05
02/06/2013 04:03	140	0.4	0.0	0.00	14,977.8	0.05
02/06/2013 04:04	140	0.3	-0.1	0.00	14,977.8	0.03
02/06/2013 04:05	140	0.3	-0.1	0.00	15,000.0	0.03
02/06/2013 04:06	140	0.3	-0.1	0.00	14,977.8	0.03
02/06/2013 04:07	141	0.3	-0.2	0.00	14,933.3	0.03
02/06/2013 04:08	140	0.3	-0.2	0.00	14,955.6	0.03
02/06/2013 04:09	140	0.3	-0.2	0.00	14,955.6	0.03
02/06/2013 04:10	140	0.3	-0.2	0.00	14,977.8	0.03
Total				1033.35		45.71

Date/Time Startup Commences: 02/07/2013 10:25
 Gas Turbine Downtime: 10 Hours
 Steam Turbine Downtime: 10 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
02/07/2013 10:25	0	0.0	0.0	0.00	888.9	0.00
02/07/2013 10:26	0	0.0	0.0	0.00	822.2	0.00
02/07/2013 10:27	0	9.8	21.6	0.14	1,733.3	0.11
02/07/2013 10:28	0	2.6	31.1	0.31	2,555.6	0.04
02/07/2013 10:29	0	3.7	1,182.0	15.63	3,444.4	0.08
02/07/2013 10:30	0	5.7	1,973.0	31.30	4,133.3	0.15
02/07/2013 10:31	0	12.0	2,332.5	41.39	4,622.2	0.35
02/07/2013 10:32	0	18.6	2,590.8	52.82	5,311.1	0.63
02/07/2013 10:33	0	24.7	2,783.5	55.33	5,177.8	0.81
02/07/2013 10:34	0	28.4	3,101.1	61.38	5,155.6	0.93
02/07/2013 10:35	5	30.6	3,198.4	64.94	5,288.9	1.02
02/07/2013 10:36	15	34.0	3,065.6	69.82	5,933.3	1.27
02/07/2013 10:37	25	37.0	2,704.9	68.76	6,622.2	1.54
02/07/2013 10:38	35	38.0	1,881.6	52.81	7,311.1	1.76
02/07/2013 10:39	45	36.9	1,079.9	33.53	8,088.9	1.89
02/07/2013 10:40	54	36.9	504.6	17.44	9,000.0	2.10
02/07/2013 10:41	66	29.4	1,145.8	41.84	9,511.1	1.76
02/07/2013 10:42	75	26.8	209.2	8.10	10,088.9	1.71
02/07/2013 10:43	84	27.0	22.4	0.93	10,844.4	1.84
02/07/2013 10:44	95	25.5	4.5	0.20	11,755.6	1.90
02/07/2013 10:45	105	23.2	1.9	0.09	12,555.6	1.85
02/07/2013 10:46	116	20.9	1.5	0.07	13,222.2	1.75
02/07/2013 10:47	126	17.1	1.0	0.05	13,844.4	1.50
02/07/2013 10:48	135	16.4	0.9	0.05	14,488.9	1.52
02/07/2013 10:49	139	16.0	0.8	0.05	14,755.6	1.49
02/07/2013 10:50	140	14.2	0.7	0.05	14,711.1	1.31
02/07/2013 10:51	140	2.8	0.6	0.03	14,711.1	0.25
02/07/2013 10:52	140	0.7	0.4	0.03	14,688.9	0.08
02/07/2013 10:53	140	0.6	0.2	0.03	14,711.1	0.05
02/07/2013 10:54	140	0.5	0.2	0.00	14,688.9	0.05
02/07/2013 10:55	140	0.3	0.0	0.00	14,688.9	0.03
02/07/2013 10:56	140	0.3	-0.1	0.00	14,688.9	0.03
02/07/2013 10:57	140	0.3	-0.1	0.00	14,688.9	0.03
02/07/2013 10:58	140	0.3	-0.2	0.00	14,711.1	0.03
02/07/2013 10:59	140	0.3	-0.2	0.00	14,688.9	0.03
02/07/2013 11:00	140	0.3	-0.2	0.00	14,711.1	0.03
02/07/2013 11:01	140	0.3	-0.2	0.00	14,688.9	0.03
Total				617.12		29.95

Date/Time Startup Commences: 02/08/2013 04:23
 Gas Turbine Downtime: 5 Hours
 Steam Turbine Downtime: 5 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
02/08/2013 04:23	0	0.0	0.0	0.00	622.2	0.00
02/08/2013 04:24	0	0.0	0.0	0.00	622.2	0.00
02/08/2013 04:25	0	5.9	14.8	0.10	1,688.9	0.06
02/08/2013 04:26	0	2.3	28.5	0.27	2,466.7	0.03
02/08/2013 04:27	0	3.3	44.9	0.56	3,288.9	0.07
02/08/2013 04:28	0	3.9	64.2	1.01	4,088.9	0.10
02/08/2013 04:29	0	6.1	114.4	2.01	4,577.8	0.18
02/08/2013 04:30	0	9.5	161.8	3.17	5,111.1	0.31
02/08/2013 04:31	0	14.0	178.5	3.58	5,222.2	0.47
02/08/2013 04:32	0	17.7	197.7	3.93	5,177.8	0.58
02/08/2013 04:33	3	19.4	186.1	4.33	6,066.7	0.74
02/08/2013 04:34	4	22.4	161.9	3.38	5,422.2	0.76
02/08/2013 04:35	13	22.8	150.7	3.47	6,000.0	0.86
02/08/2013 04:36	23	26.4	147.5	3.76	6,644.4	1.11
02/08/2013 04:37	33	30.2	134.5	3.76	7,288.9	1.39
02/08/2013 04:38	43	30.9	111.6	3.40	7,933.3	1.55
02/08/2013 04:39	51	33.0	81.6	2.73	8,688.9	1.80
02/08/2013 04:40	63	30.9	82.5	2.98	9,377.8	1.83
02/08/2013 04:41	73	19.8	59.0	2.26	9,977.8	1.25
02/08/2013 04:42	82	11.3	9.3	0.39	10,733.3	0.75
02/08/2013 04:43	92	3.7	4.1	0.18	11,622.2	0.28
02/08/2013 04:44	103	1.8	2.5	0.13	12,288.9	0.15
02/08/2013 04:45	113	1.2	1.4	0.07	13,000.0	0.09
02/08/2013 04:46	122	0.9	0.6	0.02	13,644.4	0.07
02/08/2013 04:47	133	0.8	0.4	0.02	14,355.6	0.07
02/08/2013 04:48	139	0.6	0.3	0.03	14,844.4	0.05
02/08/2013 04:49	140	0.4	0.2	0.00	14,844.4	0.05
02/08/2013 04:50	140	0.4	0.0	0.00	14,844.4	0.05
02/08/2013 04:51	140	0.3	-0.1	0.00	14,800.0	0.03
02/08/2013 04:52	140	0.3	-0.2	0.00	14,800.0	0.03
02/08/2013 04:53	140	0.3	-0.2	0.00	14,800.0	0.03
02/08/2013 04:54	140	0.3	-0.2	0.00	14,777.8	0.03
02/08/2013 04:55	140	0.4	-0.3	0.00	14,800.0	0.05
Total				45.54		14.82

Date/Time Startup Commences: 02/11/2013 13:48
 Gas Turbine Downtime: 14 Hours
 Steam Turbine Downtime: 14 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
02/11/2013 13:48	0	0.0	0.0	0.00	955.6	0.00
02/11/2013 13:49	0	0.0	0.0	0.00	400.0	0.00
02/11/2013 13:50	0	35.4	5.9	0.04	1,577.8	0.35
02/11/2013 13:51	0	4.8	32.1	0.29	2,377.8	0.07
02/11/2013 13:52	0	5.4	1,435.8	17.32	3,155.6	0.11
02/11/2013 13:53	0	7.0	1,937.6	29.47	3,977.8	0.18
02/11/2013 13:54	0	12.9	2,218.0	38.26	4,511.1	0.36
02/11/2013 13:55	0	23.4	2,575.6	48.59	4,933.3	0.72
02/11/2013 13:56	0	26.2	2,739.8	54.01	5,155.6	0.85
02/11/2013 13:57	0	31.2	3,108.0	60.75	5,111.1	1.00
02/11/2013 13:58	1	32.9	3,246.7	63.74	5,133.3	1.06
02/11/2013 13:59	11	35.6	3,214.5	70.48	5,733.3	1.28
02/11/2013 14:00	22	41.5	2,804.0	67.44	6,288.9	1.64
02/11/2013 14:01	33	44.3	1,550.6	42.03	7,088.9	1.97
02/11/2013 14:02	45	45.4	801.6	24.59	8,022.2	2.29
02/11/2013 14:03	57	52.7	222.2	7.49	8,822.2	2.92
02/11/2013 14:04	69	35.2	8.7	0.32	9,755.6	2.17
02/11/2013 14:05	79	36.9	3.7	0.14	10,577.8	2.46
02/11/2013 14:06	91	36.9	1.6	0.08	11,533.3	2.68
02/11/2013 14:07	104	31.7	1.2	0.06	12,177.8	2.43
02/11/2013 14:08	115	23.3	0.9	0.04	13,000.0	1.91
02/11/2013 14:09	126	18.5	0.9	0.05	13,777.8	1.60
02/11/2013 14:10	137	18.1	0.9	0.05	14,533.3	1.66
02/11/2013 14:11	140	17.8	0.8	0.05	14,733.3	1.66
02/11/2013 14:12	140	17.6	0.6	0.03	14,711.1	1.63
02/11/2013 14:13	140	17.7	0.5	0.03	14,688.9	1.63
02/11/2013 14:14	140	16.7	0.4	0.03	14,688.9	1.56
02/11/2013 14:15	140	13.6	0.3	0.03	14,688.9	1.25
02/11/2013 14:16	140	1.8	0.2	0.00	14,711.1	0.18
02/11/2013 14:17	140	0.8	0.0	0.00	14,711.1	0.08
02/11/2013 14:18	140	0.7	-0.1	0.00	14,711.1	0.05
02/11/2013 14:19	140	0.5	-0.2	0.00	14,733.3	0.05
02/11/2013 14:20	140	0.4	-0.2	0.00	14,733.3	0.05
02/11/2013 14:21	140	0.4	-0.2	0.00	14,733.3	0.05
02/11/2013 14:22	140	0.3	-0.3	0.00	14,711.1	0.03
02/11/2013 14:23	140	0.3	-0.3	0.00	14,733.3	0.03
02/11/2013 14:24	140	0.3	-0.3	0.00	14,733.3	0.03
02/11/2013 14:25	140	0.3	-0.3	0.00	14,733.3	0.03
02/11/2013 14:26	140	0.4	-0.3	0.00	14,755.6	0.05
Total				525.41		38.07

Date/Time Startup Commences: 02/12/2013 04:55
 Gas Turbine Downtime: 6 Hours
 Steam Turbine Downtime: 6 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
02/12/2013 04:55	0	0.0	0.0	0.00	866.7	0.00
02/12/2013 04:56	0	0.0	0.0	0.00	822.2	0.00
02/12/2013 04:57	0	0.0	14.2	0.09	1,733.3	0.00
02/12/2013 04:58	0	0.7	29.5	0.29	2,533.3	0.01
02/12/2013 04:59	0	2.1	43.9	0.57	3,400.0	0.05
02/12/2013 05:00	0	2.4	56.4	0.90	4,177.8	0.06
02/12/2013 05:01	0	4.3	89.0	1.59	4,666.7	0.13
02/12/2013 05:02	0	6.8	115.3	2.33	5,288.9	0.23
02/12/2013 05:03	0	10.1	132.0	2.67	5,288.9	0.33
02/12/2013 05:04	0	12.9	148.3	2.97	5,244.4	0.42
02/12/2013 05:05	9	14.4	140.8	2.97	5,511.1	0.50
02/12/2013 05:06	18	19.0	121.3	2.85	6,133.3	0.73
02/12/2013 05:07	28	20.3	86.6	2.25	6,777.8	0.87
02/12/2013 05:08	38	24.6	59.4	1.71	7,511.1	1.15
02/12/2013 05:09	49	29.3	40.1	1.28	8,333.3	1.54
02/12/2013 05:10	58	37.3	24.1	0.82	8,933.3	2.11
02/12/2013 05:11	68	18.6	6.6	0.25	9,733.3	1.15
02/12/2013 05:12	78	10.6	4.3	0.18	10,488.9	0.70
02/12/2013 05:13	88	4.9	3.0	0.14	11,288.9	0.35
02/12/2013 05:14	99	2.8	1.8	0.08	12,088.9	0.21
02/12/2013 05:15	109	1.8	0.9	0.04	12,777.8	0.15
02/12/2013 05:16	119	1.1	0.6	0.02	13,444.4	0.09
02/12/2013 05:17	128	0.8	0.4	0.02	14,111.1	0.07
02/12/2013 05:18	137	0.7	0.3	0.03	14,755.6	0.05
02/12/2013 05:19	140	0.5	0.3	0.03	14,866.7	0.05
02/12/2013 05:20	140	0.4	0.1	0.00	14,866.7	0.05
02/12/2013 05:21	140	0.3	0.0	0.00	14,866.7	0.03
02/12/2013 05:22	140	0.3	-0.1	0.00	14,844.4	0.03
02/12/2013 05:23	140	0.3	-0.2	0.00	14,844.4	0.03
02/12/2013 05:24	140	0.3	-0.2	0.00	14,866.7	0.03
02/12/2013 05:25	140	0.4	-0.3	0.00	14,844.4	0.05
Total				24.08		11.17

Date/Time Startup Commences: 02/13/2013 19:30
 Gas Turbine Downtime: 5 Hours
 Steam Turbine Downtime: 5 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
02/13/2013 19:30	0	0.0	0.0	0.00	711.1	0.00
02/13/2013 19:31	0	0.0	0.0	0.00	88.9	0.00
02/13/2013 19:32	0	0.0	0.0	0.00	1,422.2	0.00
02/13/2013 19:33	0	4.6	23.6	0.20	2,200.0	0.06
02/13/2013 19:34	0	4.0	49.1	0.56	2,977.8	0.08
02/13/2013 19:35	0	4.6	88.3	1.31	3,866.7	0.11
02/13/2013 19:36	0	6.8	244.1	4.08	4,377.8	0.19
02/13/2013 19:37	0	11.3	623.1	14.09	5,911.1	0.42
02/13/2013 19:38	0	18.4	1,258.2	24.80	5,155.6	0.60
02/13/2013 19:39	0	24.9	1,964.9	38.57	5,133.3	0.81
02/13/2013 19:40	2	27.4	1,976.3	39.47	5,222.2	0.90
02/13/2013 19:41	11	29.9	1,792.0	37.46	5,466.7	1.03
02/13/2013 19:42	20	32.8	1,274.6	29.89	6,133.3	1.27
02/13/2013 19:43	30	35.6	419.2	10.90	6,800.0	1.52
02/13/2013 19:44	40	36.6	105.8	3.06	7,555.6	1.74
02/13/2013 19:45	49	41.7	45.2	1.43	8,266.7	2.16
02/13/2013 19:46	60	38.2	22.9	0.79	9,022.2	2.17
02/13/2013 19:47	71	30.3	6.6	0.25	9,866.7	1.89
02/13/2013 19:48	80	33.7	4.9	0.20	10,511.1	2.23
02/13/2013 19:49	90	33.7	3.1	0.14	11,333.3	2.40
02/13/2013 19:50	100	30.9	1.6	0.08	12,133.3	2.36
02/13/2013 19:51	111	22.5	0.9	0.04	12,844.4	1.82
02/13/2013 19:52	120	3.5	0.6	0.02	13,422.2	0.30
02/13/2013 19:53	130	1.0	0.5	0.02	14,044.4	0.10
02/13/2013 19:54	138	0.8	0.3	0.03	14,600.0	0.07
02/13/2013 19:55	138	0.6	0.3	0.03	14,600.0	0.05
02/13/2013 19:56	138	0.4	0.1	0.00	14,577.8	0.05
02/13/2013 19:57	138	0.3	0.0	0.00	14,577.8	0.02
02/13/2013 19:58	138	0.3	-0.1	0.00	14,555.6	0.02
02/13/2013 19:59	138	0.3	-0.2	0.00	14,555.6	0.02
02/13/2013 20:00	138	0.3	-0.3	0.00	14,577.8	0.02
02/13/2013 20:01	138	0.3	-0.3	0.00	14,555.6	0.02
02/13/2013 20:02	138	0.3	-0.3	0.00	14,555.6	0.02
Total				207.42		24.45

Date/Time Startup Commences: 02/15/2013 03:44
 Gas Turbine Downtime: 4 Hours
 Steam Turbine Downtime: 4 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
02/15/2013 03:44	0	0.0	0.0	0.00	622.2	0.00
02/15/2013 03:45	0	0.0	0.0	0.00	222.2	0.00
02/15/2013 03:46	0	0.0	0.0	0.00	1,111.1	0.00
02/15/2013 03:47	0	3.0	17.7	0.13	1,955.6	0.04
02/15/2013 03:48	0	2.4	28.9	0.30	2,711.1	0.04
02/15/2013 03:49	0	3.9	37.9	0.52	3,600.0	0.09
02/15/2013 03:50	0	5.1	46.6	0.75	4,244.4	0.14
02/15/2013 03:51	0	7.0	63.2	1.14	4,711.1	0.21
02/15/2013 03:52	0	10.7	78.2	1.56	5,222.2	0.36
02/15/2013 03:53	0	14.4	91.1	1.80	5,177.8	0.47
02/15/2013 03:54	0	16.9	102.4	2.01	5,133.3	0.54
02/15/2013 03:55	8	19.2	103.2	2.11	5,355.6	0.65
02/15/2013 03:56	18	23.6	97.5	2.23	6,000.0	0.89
02/15/2013 03:57	27	27.9	74.5	1.90	6,666.7	1.17
02/15/2013 03:58	37	31.1	50.9	1.44	7,377.8	1.45
02/15/2013 03:59	47	36.0	33.1	1.04	8,200.0	1.86
02/15/2013 04:00	57	43.7	18.8	0.63	8,844.4	2.43
02/15/2013 04:01	67	20.9	5.4	0.20	9,666.7	1.27
02/15/2013 04:02	77	5.6	2.2	0.09	10,444.4	0.37
02/15/2013 04:03	87	3.0	1.7	0.08	11,200.0	0.21
02/15/2013 04:04	98	1.8	1.0	0.04	11,911.1	0.14
02/15/2013 04:05	108	1.5	0.5	0.02	12,711.1	0.13
02/15/2013 04:06	118	0.9	0.4	0.02	13,355.6	0.07
02/15/2013 04:07	127	0.8	0.3	0.02	13,955.6	0.07
02/15/2013 04:08	137	0.7	0.1	0.00	14,644.4	0.08
02/15/2013 04:09	140	0.6	0.0	0.00	14,755.6	0.05
02/15/2013 04:10	140	0.6	-0.2	0.00	14,755.6	0.05
02/15/2013 04:11	140	0.6	-0.2	0.00	14,755.6	0.05
02/15/2013 04:12	140	0.5	-0.2	0.00	14,711.1	0.05
02/15/2013 04:13	140	0.5	-0.3	0.00	14,666.7	0.05
02/15/2013 04:14	140	0.5	-0.3	0.00	14,688.9	0.05
Total				18.03		12.98

Date/Time Startup Commences: 02/16/2013 14:30
 Gas Turbine Downtime: 14 Hours
 Steam Turbine Downtime: 14 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
02/16/2013 14:30	0	0.0	0.0	0.00	733.3	0.00
02/16/2013 14:31	0	0.0	0.0	0.00	88.9	0.00
02/16/2013 14:32	0	0.0	0.0	0.00	1,377.8	0.00
02/16/2013 14:33	0	6.5	21.2	0.17	2,066.7	0.08
02/16/2013 14:34	0	3.9	600.7	6.43	2,800.0	0.07
02/16/2013 14:35	0	5.2	1,411.2	20.15	3,733.3	0.12
02/16/2013 14:36	0	9.5	1,875.4	30.92	4,311.1	0.26
02/16/2013 14:37	0	15.7	2,255.3	46.57	5,400.0	0.54
02/16/2013 14:38	0	24.0	2,573.9	50.31	5,111.1	0.78
02/16/2013 14:39	0	28.0	3,074.7	59.84	5,088.9	0.90
02/16/2013 14:40	0	31.4	3,217.8	62.62	5,088.9	1.01
02/16/2013 14:41	8	31.9	3,141.6	63.80	5,311.1	1.07
02/16/2013 14:42	18	38.4	2,883.4	65.91	5,977.8	1.45
02/16/2013 14:43	28	41.3	1,710.2	43.74	6,688.9	1.74
02/16/2013 14:44	38	41.3	824.1	23.47	7,444.4	1.93
02/16/2013 14:45	47	44.5	289.6	9.03	8,155.6	2.28
02/16/2013 14:46	58	42.6	53.1	1.81	8,911.1	2.39
02/16/2013 14:47	68	31.3	5.9	0.22	9,733.3	1.91
02/16/2013 14:48	78	32.8	2.6	0.11	10,466.7	2.16
02/16/2013 14:49	89	31.8	1.9	0.08	11,333.3	2.27
02/16/2013 14:50	98	28.3	1.2	0.06	11,844.4	2.10
02/16/2013 14:51	109	22.3	0.7	0.04	12,577.8	1.76
02/16/2013 14:52	118	19.7	0.6	0.02	13,200.0	1.65
02/16/2013 14:53	128	17.3	0.6	0.02	13,866.7	1.52
02/16/2013 14:54	137	17.1	0.5	0.02	14,555.6	1.57
02/16/2013 14:55	138	17.0	0.5	0.02	14,577.8	1.57
02/16/2013 14:56	138	16.7	0.3	0.03	14,600.0	1.55
02/16/2013 14:57	138	11.9	0.3	0.02	14,577.8	1.10
02/16/2013 14:58	138	1.2	0.1	0.00	14,555.6	0.10
02/16/2013 14:59	138	0.8	0.0	0.00	14,577.8	0.07
02/16/2013 15:00	138	0.6	-0.1	0.00	14,577.8	0.05
02/16/2013 15:01	138	0.4	-0.2	0.00	14,577.8	0.05
02/16/2013 15:02	138	0.3	-0.2	0.00	14,577.8	0.02
02/16/2013 15:03	138	0.3	-0.3	0.00	14,577.8	0.02
02/16/2013 15:04	138	0.3	-0.3	0.00	14,555.6	0.02
02/16/2013 15:05	137	0.3	-0.3	0.00	14,555.6	0.02
02/16/2013 15:06	138	0.3	-0.3	0.00	14,555.6	0.02
02/16/2013 15:07	137	0.3	-0.3	0.00	14,555.6	0.02
02/16/2013 15:08	137	0.3	-0.3	0.00	14,533.3	0.02
Total				485.41		34.19

Date/Time Startup Commences: 02/17/2013 14:30
 Gas Turbine Downtime: 15 Hours
 Steam Turbine Downtime: 15 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
02/17/2013 14:30	0	0.0	0.0	0.00	600.0	0.00
02/17/2013 14:31	0	0.0	0.0	0.00	288.9	0.00
02/17/2013 14:32	0	0.0	0.0	0.00	1,466.7	0.00
02/17/2013 14:33	0	5.5	25.7	0.22	2,244.4	0.08
02/17/2013 14:34	0	5.1	1,463.7	16.67	2,977.8	0.10
02/17/2013 14:35	0	6.8	1,905.7	28.02	3,844.4	0.16
02/17/2013 14:36	0	11.8	2,081.6	34.85	4,377.8	0.32
02/17/2013 14:37	0	18.1	2,428.4	47.05	5,066.7	0.58
02/17/2013 14:38	0	24.9	2,680.6	52.16	5,088.9	0.80
02/17/2013 14:39	0	30.1	3,100.2	60.07	5,066.7	0.96
02/17/2013 14:40	2	32.7	3,283.6	64.18	5,111.1	1.05
02/17/2013 14:41	10	34.6	3,235.6	66.82	5,400.0	1.17
02/17/2013 14:42	20	40.0	2,843.2	66.21	6,088.9	1.53
02/17/2013 14:43	30	43.0	1,692.4	43.86	6,777.8	1.83
02/17/2013 14:44	40	44.7	897.3	26.01	7,577.8	2.12
02/17/2013 14:45	50	48.6	319.6	10.17	8,311.1	2.54
02/17/2013 14:46	60	41.2	47.0	1.63	9,111.1	2.37
02/17/2013 14:47	70	32.8	5.5	0.20	9,866.7	2.04
02/17/2013 14:48	79	34.6	2.4	0.09	10,600.0	2.32
02/17/2013 14:49	90	31.7	1.7	0.08	11,466.7	2.29
02/17/2013 14:50	100	27.6	1.1	0.04	11,911.1	2.08
02/17/2013 14:51	111	21.5	0.8	0.04	12,733.3	1.72
02/17/2013 14:52	120	19.1	0.9	0.05	13,333.3	1.59
02/17/2013 14:53	130	17.4	0.8	0.05	14,022.2	1.53
02/17/2013 14:54	137	17.2	0.5	0.02	14,533.3	1.56
02/17/2013 14:55	138	17.1	0.4	0.02	14,555.6	1.57
02/17/2013 14:56	138	17.5	0.3	0.02	14,555.6	1.62
02/17/2013 14:57	138	16.0	0.3	0.02	14,533.3	1.46
02/17/2013 14:58	138	10.4	0.1	0.00	14,533.3	0.94
02/17/2013 14:59	138	1.1	0.0	0.00	14,555.6	0.10
02/17/2013 15:00	138	0.7	-0.1	0.00	14,577.8	0.05
02/17/2013 15:01	138	0.6	-0.2	0.00	14,555.6	0.05
02/17/2013 15:02	138	0.5	-0.2	0.00	14,577.8	0.05
02/17/2013 15:03	138	0.4	-0.3	0.00	14,555.6	0.05
02/17/2013 15:04	138	0.4	-0.3	0.00	14,577.8	0.05
02/17/2013 15:05	138	0.3	-0.3	0.00	14,577.8	0.02
02/17/2013 15:06	138	0.3	-0.3	0.00	14,577.8	0.02
02/17/2013 15:07	138	0.3	-0.3	0.00	14,577.8	0.02
02/17/2013 15:08	138	0.4	-0.3	0.00	14,577.8	0.05
Total				518.55		36.79

Date/Time Startup Commences: 02/18/2013 14:30
 Gas Turbine Downtime: 15 Hours
 Steam Turbine Downtime: 15 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
02/18/2013 14:30	0	0.0	0.0	0.00	977.8	0.00
02/18/2013 14:31	0	0.0	0.0	0.00	200.0	0.00
02/18/2013 14:32	0	0.0	0.0	0.00	1,444.4	0.00
02/18/2013 14:33	0	7.0	30.6	0.25	2,155.6	0.10
02/18/2013 14:34	0	5.3	2,058.0	23.26	2,955.6	0.10
02/18/2013 14:35	0	7.2	2,126.0	31.43	3,866.7	0.18
02/18/2013 14:36	0	12.9	2,299.9	38.70	4,400.0	0.35
02/18/2013 14:37	0	18.8	2,614.4	48.65	4,866.7	0.57
02/18/2013 14:38	0	24.7	2,721.4	53.43	5,133.3	0.80
02/18/2013 14:39	0	29.3	3,044.8	59.52	5,111.1	0.94
02/18/2013 14:40	1	32.5	3,278.3	64.07	5,111.1	1.05
02/18/2013 14:41	10	34.2	3,243.4	67.53	5,444.4	1.17
02/18/2013 14:42	20	40.0	2,899.3	67.76	6,111.1	1.53
02/18/2013 14:43	30	43.4	1,969.3	51.04	6,777.8	1.85
02/18/2013 14:44	39	43.5	1,163.4	33.41	7,511.1	2.05
02/18/2013 14:45	49	47.2	574.9	18.13	8,244.4	2.45
02/18/2013 14:46	60	44.0	122.0	4.20	9,000.0	2.49
02/18/2013 14:47	70	32.9	7.8	0.29	9,844.4	2.04
02/18/2013 14:48	80	33.7	4.1	0.16	10,555.6	2.24
02/18/2013 14:49	90	31.6	2.6	0.12	11,288.9	2.24
02/18/2013 14:50	99	27.1	2.0	0.10	12,022.2	2.05
02/18/2013 14:51	110	24.0	1.2	0.07	12,755.6	1.94
02/18/2013 14:52	120	19.4	0.8	0.05	13,400.0	1.65
02/18/2013 14:53	130	16.6	0.6	0.02	14,044.4	1.46
02/18/2013 14:54	138	16.1	0.6	0.03	14,644.4	1.48
02/18/2013 14:55	140	16.4	0.6	0.03	14,733.3	1.51
02/18/2013 14:56	140	17.0	0.5	0.03	14,733.3	1.56
02/18/2013 14:57	140	16.6	0.4	0.03	14,733.3	1.54
02/18/2013 14:58	140	14.2	0.2	0.03	14,711.1	1.31
02/18/2013 14:59	140	8.9	0.2	0.00	14,711.1	0.83
02/18/2013 15:00	140	0.9	0.1	0.00	14,733.3	0.08
02/18/2013 15:01	140	0.8	-0.1	0.00	14,733.3	0.08
02/18/2013 15:02	140	0.6	-0.2	0.00	14,755.6	0.05
02/18/2013 15:03	140	0.5	-0.2	0.00	14,733.3	0.05
02/18/2013 15:04	140	0.4	-0.3	0.00	14,733.3	0.05
02/18/2013 15:05	140	0.3	-0.3	0.00	14,733.3	0.03
02/18/2013 15:06	140	0.3	-0.3	0.00	14,711.1	0.03
02/18/2013 15:07	140	0.3	-0.3	0.00	14,711.1	0.03
02/18/2013 15:08	140	0.3	-0.3	0.00	14,733.3	0.03
02/18/2013 15:09	140	0.3	-0.3	0.00	14,733.3	0.03
Total				562.34		37.94

Date/Time Startup Commences: 02/21/2013 14:12
 Gas Turbine Downtime: 38 Hours
 Steam Turbine Downtime: 38 Hours
 Startup Type*: warm

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
02/21/2013 14:12	0	0.0	0.0	0.00	0.0	0.00
02/21/2013 14:13	0	0.0	0.0	0.00	733.3	0.00
02/21/2013 14:14	0	0.0	0.0	0.00	1,088.9	0.00
02/21/2013 14:15	0	35.4	72.8	0.52	1,866.7	0.41
02/21/2013 14:16	0	10.4	2,669.6	26.77	2,622.2	0.17
02/21/2013 14:17	0	13.3	2,471.1	32.75	3,466.7	0.29
02/21/2013 14:18	0	17.7	2,178.0	34.98	4,200.0	0.47
02/21/2013 14:19	0	22.3	2,289.9	41.06	4,688.9	0.66
02/21/2013 14:20	0	26.6	2,548.1	51.97	5,333.3	0.89
02/21/2013 14:21	0	31.2	2,732.4	53.86	5,155.6	1.01
02/21/2013 14:22	1	35.4	3,022.1	60.10	5,200.0	1.15
02/21/2013 14:23	10	36.9	3,122.2	66.07	5,533.3	1.29
02/21/2013 14:24	21	44.7	2,798.5	67.30	6,288.9	1.77
02/21/2013 14:25	32	47.2	1,909.1	51.58	7,066.7	2.10
02/21/2013 14:26	44	50.2	1,239.3	37.91	8,000.0	2.53
02/21/2013 14:27	55	58.9	691.7	23.10	8,733.3	3.24
02/21/2013 14:28	67	46.7	184.4	6.80	9,644.4	2.83
02/21/2013 14:29	78	42.6	8.0	0.32	10,533.3	2.83
02/21/2013 14:30	90	44.0	5.5	0.23	11,377.8	3.15
02/21/2013 14:31	101	36.5	4.8	0.23	12,177.8	2.79
02/21/2013 14:32	114	31.6	4.5	0.22	13,044.4	2.61
02/21/2013 14:33	125	23.4	3.5	0.19	13,777.8	2.02
02/21/2013 14:34	135	18.8	2.4	0.12	14,511.1	1.71
02/21/2013 14:35	139	16.4	1.3	0.08	14,777.8	1.51
02/21/2013 14:36	140	15.9	0.8	0.05	14,844.4	1.47
02/21/2013 14:37	140	15.0	0.5	0.03	14,844.4	1.39
02/21/2013 14:38	140	14.1	0.4	0.03	14,844.4	1.32
02/21/2013 14:39	140	14.2	0.3	0.03	14,866.7	1.32
02/21/2013 14:40	140	15.0	0.3	0.03	14,844.4	1.39
02/21/2013 14:41	140	16.2	0.2	0.00	14,844.4	1.52
02/21/2013 14:42	140	16.4	0.1	0.00	14,866.7	1.52
02/21/2013 14:43	140	16.6	0.1	0.00	14,866.7	1.55
02/21/2013 14:44	140	16.9	0.0	0.00	14,822.2	1.57
02/21/2013 14:45	140	17.3	0.0	0.00	14,822.2	1.62
02/21/2013 14:46	140	17.4	-0.1	0.00	14,844.4	1.62
02/21/2013 14:47	140	12.1	-0.1	0.00	14,844.4	1.12
02/21/2013 14:48	141	1.5	-0.1	0.00	14,822.2	0.15
02/21/2013 14:49	140	0.9	-0.1	0.00	14,822.2	0.08
02/21/2013 14:50	140	0.7	-0.2	0.00	14,844.4	0.08
02/21/2013 14:51	140	0.5	-0.2	0.00	14,822.2	0.05
02/21/2013 14:52	140	0.3	-0.2	0.00	14,822.2	0.03
02/21/2013 14:53	140	0.3	-0.2	0.00	14,800.0	0.03
02/21/2013 14:54	140	0.3	-0.2	0.00	14,822.2	0.03
02/21/2013 14:55	140	0.3	-0.3	0.00	14,822.2	0.03
02/21/2013 14:56	140	0.3	-0.3	0.00	14,844.4	0.03
02/21/2013 14:57	140	0.3	-0.3	0.00	14,844.4	0.03
02/21/2013 14:58	140	0.3	-0.3	0.00	14,822.2	0.03
Total				556.33		53.41

Date/Time Startup Commences: 02/22/2013 03:55
 Gas Turbine Downtime: 3 Hours
 Steam Turbine Downtime: 3 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
02/22/2013 03:55	0	0.0	0.0	0.00	777.8	0.00
02/22/2013 03:56	0	0.0	0.0	0.00	288.9	0.00
02/22/2013 03:57	0	0.0	-11.8	0.00	1,533.3	0.00
02/22/2013 03:58	0	0.4	26.9	0.24	2,311.1	0.00
02/22/2013 03:59	0	1.3	37.0	0.45	3,155.6	0.03
02/22/2013 04:00	0	2.3	41.5	0.64	4,000.0	0.05
02/22/2013 04:01	0	2.7	58.5	1.00	4,488.9	0.08
02/22/2013 04:02	0	5.0	76.7	1.50	5,111.1	0.16
02/22/2013 04:03	0	7.2	86.5	1.75	5,288.9	0.24
02/22/2013 04:04	2	9.7	100.9	2.07	5,355.6	0.33
02/22/2013 04:05	12	12.2	104.4	2.27	5,666.7	0.44
02/22/2013 04:06	23	18.1	89.4	2.19	6,400.0	0.73
02/22/2013 04:07	34	20.9	61.7	1.69	7,155.6	0.94
02/22/2013 04:08	46	26.3	40.7	1.26	8,088.9	1.34
02/22/2013 04:09	56	37.4	25.0	0.84	8,800.0	2.07
02/22/2013 04:10	69	21.6	5.8	0.22	9,822.2	1.34
02/22/2013 04:11	80	10.8	1.9	0.07	10,688.9	0.73
02/22/2013 04:12	92	4.7	1.0	0.04	11,533.3	0.34
02/22/2013 04:13	104	3.2	0.7	0.04	12,422.2	0.25
02/22/2013 04:14	115	2.2	0.3	0.02	13,244.4	0.18
02/22/2013 04:15	126	1.5	0.1	0.00	14,044.4	0.14
02/22/2013 04:16	137	1.0	0.0	0.00	14,844.4	0.10
02/22/2013 04:17	140	0.8	0.0	0.00	14,977.8	0.08
02/22/2013 04:18	141	0.7	-0.1	0.00	14,822.2	0.08
02/22/2013 04:19	140	0.6	-0.1	0.00	14,822.2	0.05
02/22/2013 04:20	140	0.5	0.0	0.00	14,800.0	0.05
02/22/2013 04:21	140	0.5	-0.1	0.00	14,800.0	0.05
02/22/2013 04:22	140	0.5	-0.2	0.00	14,800.0	0.05
02/22/2013 04:23	140	0.6	-0.3	0.00	14,800.0	0.05
02/22/2013 04:24	141	0.6	-0.3	0.00	14,800.0	0.05
Total				16.29		9.95

Date/Time Startup Commences: 02/22/2013 12:01
 Gas Turbine Downtime: 3 Hours
 Steam Turbine Downtime: 3 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
02/22/2013 12:01	0	0.0	0.0	0.00	666.7	0.00
02/22/2013 12:02	0	0.0	0.0	0.00	511.1	0.00
02/22/2013 12:03	0	0.0	10.6	0.07	1,666.7	0.00
02/22/2013 12:04	0	0.6	25.8	0.24	2,466.7	0.01
02/22/2013 12:05	0	1.9	36.3	0.46	3,355.6	0.04
02/22/2013 12:06	0	2.6	46.5	0.72	4,066.7	0.07
02/22/2013 12:07	0	3.5	64.7	1.13	4,555.6	0.10
02/22/2013 12:08	0	5.7	86.9	1.72	5,177.8	0.19
02/22/2013 12:09	0	7.6	97.6	1.93	5,177.8	0.25
02/22/2013 12:10	0	9.7	117.6	2.31	5,133.3	0.32
02/22/2013 12:11	8	11.0	117.0	2.40	5,355.6	0.37
02/22/2013 12:12	18	13.7	106.2	2.43	5,977.8	0.51
02/22/2013 12:13	29	18.5	80.0	2.06	6,733.3	0.78
02/22/2013 12:14	40	20.6	52.0	1.51	7,622.2	0.99
02/22/2013 12:15	52	27.8	33.6	1.08	8,400.0	1.46
02/22/2013 12:16	64	24.5	8.2	0.29	9,377.8	1.44
02/22/2013 12:17	76	11.4	3.7	0.14	10,288.9	0.74
02/22/2013 12:18	87	6.4	1.4	0.06	11,133.3	0.44
02/22/2013 12:19	98	3.8	1.1	0.04	11,955.6	0.29
02/22/2013 12:20	110	2.5	0.6	0.02	12,844.4	0.20
02/22/2013 12:21	122	1.5	0.3	0.02	13,533.3	0.14
02/22/2013 12:22	133	0.9	0.2	0.00	14,311.1	0.07
02/22/2013 12:23	139	0.7	0.1	0.00	14,644.4	0.05
02/22/2013 12:24	139	0.7	0.0	0.00	14,622.2	0.05
02/22/2013 12:25	139	0.6	0.0	0.00	14,688.9	0.05
02/22/2013 12:26	140	0.6	0.0	0.00	14,688.9	0.05
02/22/2013 12:27	140	0.7	-0.2	0.00	14,688.9	0.05
02/22/2013 12:28	140	0.7	-0.3	0.00	14,688.9	0.05
02/22/2013 12:29	140	0.8	-0.3	0.00	14,688.9	0.08
02/22/2013 12:30	140	0.8	-0.3	0.00	14,711.1	0.08
02/22/2013 12:31	140	0.8	-0.3	0.00	14,733.3	0.08
Total				18.63		8.95

Date/Time Startup Commences: 02/24/2013 12:58
 Gas Turbine Downtime: 45 Hours
 Steam Turbine Downtime: 45 Hours
 Startup Type*: warm

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
02/24/2013 12:58	0	0.0	0.0	0.00	733.3	0.00
02/24/2013 12:59	0	0.0	0.0	0.00	733.3	0.00
02/24/2013 13:00	0	76.7	141.6	0.94	1,733.3	0.84
02/24/2013 13:01	0	11.8	2,814.7	27.27	2,533.3	0.19
02/24/2013 13:02	0	13.4	2,534.3	33.17	3,422.2	0.29
02/24/2013 13:03	0	16.2	2,135.1	33.92	4,155.6	0.43
02/24/2013 13:04	0	21.0	2,235.2	39.70	4,644.4	0.61
02/24/2013 13:05	0	25.6	2,502.7	49.13	5,133.3	0.82
02/24/2013 13:06	0	31.5	2,654.1	53.00	5,222.2	1.03
02/24/2013 13:07	0	35.8	2,990.5	59.47	5,200.0	1.17
02/24/2013 13:08	0	36.7	3,111.6	61.34	5,155.6	1.19
02/24/2013 13:09	7	37.7	3,123.0	64.76	5,422.2	1.29
02/24/2013 13:10	18	42.5	3,050.9	70.52	6,044.4	1.62
02/24/2013 13:11	29	48.6	2,530.6	65.81	6,800.0	2.08
02/24/2013 13:12	41	48.4	1,626.2	47.67	7,666.7	2.33
02/24/2013 13:13	52	52.8	1,072.6	35.00	8,533.3	2.84
02/24/2013 13:14	65	50.5	584.9	20.87	9,333.3	2.97
02/24/2013 13:15	76	40.0	190.2	7.42	10,200.0	2.56
02/24/2013 13:16	87	43.7	27.5	1.17	11,000.0	3.03
02/24/2013 13:17	99	41.0	9.1	0.41	11,888.9	3.07
02/24/2013 13:18	110	36.6	7.9	0.39	12,777.8	2.95
02/24/2013 13:19	123	32.0	6.0	0.30	13,711.1	2.76
02/24/2013 13:20	134	23.6	3.5	0.20	14,511.1	2.16
02/24/2013 13:21	139	19.9	1.9	0.10	14,866.7	1.85
02/24/2013 13:22	140	19.0	1.0	0.05	14,888.9	1.78
02/24/2013 13:23	140	17.9	0.7	0.03	14,888.9	1.68
02/24/2013 13:24	140	16.5	0.5	0.03	14,888.9	1.55
02/24/2013 13:25	140	16.4	0.4	0.03	14,888.9	1.53
02/24/2013 13:26	140	16.5	0.3	0.03	14,866.7	1.55
02/24/2013 13:27	140	16.8	0.3	0.03	14,888.9	1.58
02/24/2013 13:28	140	17.3	0.2	0.00	14,866.7	1.63
02/24/2013 13:29	140	17.8	0.2	0.00	14,888.9	1.68
02/24/2013 13:30	140	18.2	0.1	0.00	14,888.9	1.70
02/24/2013 13:31	140	18.5	0.0	0.00	14,888.9	1.73
02/24/2013 13:32	140	18.7	0.0	0.00	14,911.1	1.76
02/24/2013 13:33	140	19.1	0.0	0.00	14,911.1	1.78
02/24/2013 13:34	140	13.8	-0.1	0.00	14,911.1	1.30
02/24/2013 13:35	140	1.5	-0.1	0.00	14,888.9	0.13
02/24/2013 13:36	140	0.8	-0.1	0.00	14,888.9	0.08
02/24/2013 13:37	141	0.6	-0.1	0.00	14,888.9	0.05
02/24/2013 13:38	141	0.4	-0.2	0.00	14,888.9	0.05
02/24/2013 13:39	141	0.3	-0.2	0.00	14,888.9	0.03
02/24/2013 13:40	141	0.3	-0.2	0.00	14,866.7	0.03
02/24/2013 13:41	141	0.3	-0.2	0.00	14,822.2	0.03
02/24/2013 13:42	140	0.3	-0.2	0.00	14,911.1	0.03
02/24/2013 13:43	140	0.3	-0.2	0.00	14,755.6	0.03
02/24/2013 13:44	140	0.3	-0.3	0.00	14,888.9	0.03
02/24/2013 13:45	140	0.4	-0.3	0.00	14,866.7	0.05
Total				672.76		59.87

Date/Time Startup Commences: 02/26/2013 03:25
 Gas Turbine Downtime: 5 Hours
 Steam Turbine Downtime: 5 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
02/26/2013 03:25	0	0.0	0.0	0.00	622.2	0.00
02/26/2013 03:26	0	0.0	0.0	0.00	355.6	0.00
02/26/2013 03:27	0	0.0	0.0	0.00	1,088.9	0.00
02/26/2013 03:28	0	5.2	24.3	0.18	1,933.3	0.06
02/26/2013 03:29	0	2.4	32.5	0.34	2,733.3	0.04
02/26/2013 03:30	0	3.3	146.6	2.03	3,622.2	0.07
02/26/2013 03:31	0	4.5	574.8	9.33	4,244.4	0.12
02/26/2013 03:32	0	9.1	1,155.5	20.82	4,711.1	0.27
02/26/2013 03:33	0	16.3	1,440.1	30.23	5,488.9	0.56
02/26/2013 03:34	0	24.0	1,712.7	33.91	5,177.8	0.79
02/26/2013 03:35	1	24.7	1,885.1	37.49	5,200.0	0.81
02/26/2013 03:36	8	27.6	1,831.5	37.98	5,422.2	0.94
02/26/2013 03:37	21	31.0	1,532.1	36.59	6,244.4	1.22
02/26/2013 03:38	34	33.6	632.6	17.26	7,133.3	1.51
02/26/2013 03:39	48	34.5	142.0	4.45	8,200.0	1.78
02/26/2013 03:40	61	39.7	36.9	1.29	9,088.9	2.27
02/26/2013 03:41	75	29.2	5.4	0.21	10,155.6	1.87
02/26/2013 03:42	88	32.0	3.1	0.13	11,133.3	2.24
02/26/2013 03:43	101	32.5	2.0	0.08	12,222.2	2.51
02/26/2013 03:44	114	30.4	0.9	0.05	13,244.4	2.53
02/26/2013 03:45	120	26.4	0.5	0.02	13,622.2	2.26
02/26/2013 03:46	128	22.1	0.5	0.02	14,200.0	1.97
02/26/2013 03:47	138	13.1	0.5	0.03	14,822.2	1.22
02/26/2013 03:48	141	1.5	0.5	0.03	14,866.7	0.15
02/26/2013 03:49	140	0.9	0.4	0.03	14,733.3	0.08
02/26/2013 03:50	140	0.7	0.4	0.03	14,755.6	0.08
02/26/2013 03:51	140	0.4	0.3	0.03	14,755.6	0.05
02/26/2013 03:52	141	0.3	0.2	0.00	14,755.6	0.03
02/26/2013 03:53	141	0.3	-0.1	0.00	14,733.3	0.03
02/26/2013 03:54	141	0.3	-0.2	0.00	14,711.1	0.03
02/26/2013 03:55	140	0.3	-0.2	0.00	14,711.1	0.03
02/26/2013 03:56	140	0.3	-0.2	0.00	14,711.1	0.03
02/26/2013 03:57	140	0.3	-0.3	0.00	14,711.1	0.03
02/26/2013 03:58	140	0.3	-0.3	0.00	14,733.3	0.03
Total				232.56		25.61

Date/Time Startup Commences: 02/27/2013 03:26
 Gas Turbine Downtime: 3 Hours
 Steam Turbine Downtime: 3 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
02/27/2013 03:26	0	0.0	0.0	0.00	955.6	0.00
02/27/2013 03:27	0	0.0	0.0	0.00	288.9	0.00
02/27/2013 03:28	0	0.0	-11.8	0.00	1,533.3	0.00
02/27/2013 03:29	0	0.7	25.1	0.22	2,288.9	0.01
02/27/2013 03:30	0	2.7	37.0	0.44	3,133.3	0.05
02/27/2013 03:31	0	2.8	41.1	0.62	3,955.6	0.07
02/27/2013 03:32	0	4.5	59.7	1.02	4,466.7	0.13
02/27/2013 03:33	0	6.4	78.5	1.48	4,933.3	0.19
02/27/2013 03:34	0	9.4	90.2	1.81	5,244.4	0.31
02/27/2013 03:35	0	12.4	105.4	2.10	5,200.0	0.41
02/27/2013 03:36	1	14.2	108.4	2.18	5,244.4	0.47
02/27/2013 03:37	10	17.1	108.4	2.28	5,488.9	0.59
02/27/2013 03:38	21	20.1	96.1	2.30	6,266.7	0.79
02/27/2013 03:39	33	24.4	69.9	1.87	7,000.0	1.08
02/27/2013 03:40	44	29.1	46.9	1.42	7,933.3	1.45
02/27/2013 03:41	55	37.4	28.0	0.93	8,666.7	2.04
02/27/2013 03:42	68	26.6	7.2	0.26	9,666.7	1.62
02/27/2013 03:43	79	11.3	2.8	0.11	10,511.1	0.75
02/27/2013 03:44	90	4.7	1.3	0.06	11,333.3	0.33
02/27/2013 03:45	102	2.8	0.9	0.04	12,288.9	0.21
02/27/2013 03:46	114	2.1	0.5	0.02	13,177.8	0.18
02/27/2013 03:47	125	1.3	0.3	0.02	13,933.3	0.12
02/27/2013 03:48	136	0.9	0.2	0.00	14,733.3	0.08
02/27/2013 03:49	140	0.8	0.1	0.00	14,844.4	0.08
02/27/2013 03:50	140	0.7	0.0	0.00	14,688.9	0.05
02/27/2013 03:51	140	0.5	0.0	0.00	14,711.1	0.05
02/27/2013 03:52	140	0.4	0.0	0.00	14,688.9	0.05
02/27/2013 03:53	140	0.4	-0.1	0.00	14,711.1	0.05
02/27/2013 03:54	140	0.4	-0.2	0.00	14,688.9	0.05
02/27/2013 03:55	140	0.5	-0.3	0.00	14,711.1	0.05
02/27/2013 03:56	140	0.5	-0.3	0.00	14,711.1	0.05
Total				19.18		11.31

Date/Time Startup Commences: 03/04/2013 02:59
 Gas Turbine Downtime: 74 Hours
 Steam Turbine Downtime: 74 Hours
 Startup Type*: Cold

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
03/04/2013 02:59	0	0.0	0.0	0.00	666.7	0.00
03/04/2013 03:00	0	0.0	0.0	0.00	288.9	0.00
03/04/2013 03:01	0	0.0	0.0	0.00	1,400.0	0.00
03/04/2013 03:02	0	16.9	136.5	1.09	2,088.9	0.22
03/04/2013 03:03	0	9.5	2,743.8	30.31	2,888.9	0.17
03/04/2013 03:04	0	12.3	2,125.6	31.07	3,822.2	0.29
03/04/2013 03:05	0	15.5	1,965.9	33.08	4,400.0	0.43
03/04/2013 03:06	0	20.8	2,088.8	39.23	4,911.1	0.64
03/04/2013 03:07	0	24.0	2,272.7	45.19	5,200.0	0.78
03/04/2013 03:08	0	29.7	2,807.4	56.06	5,222.2	0.97
03/04/2013 03:09	0	31.8	2,911.9	57.90	5,200.0	1.04
03/04/2013 03:10	0	34.6	2,923.9	57.64	5,155.6	1.13
03/04/2013 03:11	9	35.0	2,929.4	62.73	5,600.0	1.23
03/04/2013 03:12	21	41.5	2,755.7	66.74	6,333.3	1.66
03/04/2013 03:13	32	46.3	1,909.7	52.10	7,133.3	2.07
03/04/2013 03:14	43	48.1	1,215.5	37.40	8,044.4	2.43
03/04/2013 03:15	55	57.6	665.7	22.57	8,866.7	3.21
03/04/2013 03:16	67	47.0	164.6	6.18	9,822.2	2.90
03/04/2013 03:17	78	41.9	6.4	0.26	10,666.7	2.81
03/04/2013 03:18	89	45.6	4.3	0.20	11,577.8	3.32
03/04/2013 03:19	101	40.6	4.1	0.19	12,444.4	3.19
03/04/2013 03:20	113	36.0	3.8	0.18	13,377.8	3.04
03/04/2013 03:21	121	29.9	3.2	0.17	14,000.0	2.63
03/04/2013 03:22	126	25.3	2.2	0.12	14,288.9	2.27
03/04/2013 03:23	130	21.8	1.3	0.07	14,577.8	1.99
03/04/2013 03:24	136	18.7	0.7	0.05	15,000.0	1.77
03/04/2013 03:25	140	18.0	0.5	0.03	15,288.9	1.72
03/04/2013 03:26	140	17.3	0.3	0.03	15,288.9	1.67
03/04/2013 03:27	140	16.0	0.2	0.03	15,288.9	1.54
03/04/2013 03:28	140	16.2	0.3	0.03	15,311.1	1.57
03/04/2013 03:29	141	17.9	0.2	0.00	15,466.7	1.74
03/04/2013 03:30	141	18.2	0.1	0.00	15,422.2	1.77
03/04/2013 03:31	141	18.1	0.1	0.00	15,377.8	1.76
03/04/2013 03:32	141	18.1	0.0	0.00	15,333.3	1.76
03/04/2013 03:33	141	18.3	0.0	0.00	15,311.1	1.75
03/04/2013 03:34	140	18.5	0.0	0.00	15,311.1	1.78
03/04/2013 03:35	140	18.6	-0.1	0.00	15,311.1	1.80
03/04/2013 03:36	141	14.7	-0.1	0.00	15,288.9	1.41
03/04/2013 03:37	140	2.4	-0.1	0.00	15,288.9	0.24
03/04/2013 03:38	140	0.8	-0.2	0.00	15,288.9	0.08
03/04/2013 03:39	140	0.7	-0.2	0.00	15,311.1	0.05
03/04/2013 03:40	140	0.6	-0.2	0.00	15,311.1	0.05
03/04/2013 03:41	140	0.4	-0.2	0.00	15,288.9	0.05
03/04/2013 03:42	140	0.3	-0.2	0.00	15,311.1	0.03
03/04/2013 03:43	140	0.3	-0.3	0.00	15,288.9	0.03
03/04/2013 03:44	141	0.3	-0.3	0.00	15,288.9	0.03
03/04/2013 03:45	140	0.3	-0.3	0.00	15,288.9	0.03
03/04/2013 03:46	140	0.3	-0.3	0.00	15,266.7	0.03
03/04/2013 03:47	140	0.3	-0.3	0.00	15,288.9	0.03
Total				600.65		61.11

Date/Time Startup Commences: 03/05/2013 04:30
 Gas Turbine Downtime: 5 Hours
 Steam Turbine Downtime: 5 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
03/05/2013 04:30	0	0.0	0.0	0.00	800.0	0.00
03/05/2013 04:31	0	0.0	0.0	0.00	311.1	0.00
03/05/2013 04:32	0	0.0	0.0	0.00	1,444.4	0.00
03/05/2013 04:33	0	0.8	22.8	0.19	2,200.0	0.01
03/05/2013 04:34	0	2.2	39.9	0.46	3,000.0	0.04
03/05/2013 04:35	0	2.6	45.5	0.68	3,888.9	0.07
03/05/2013 04:36	0	4.3	68.1	1.15	4,422.2	0.12
03/05/2013 04:37	0	6.4	90.8	1.72	4,955.6	0.19
03/05/2013 04:38	0	9.6	102.0	2.03	5,200.0	0.31
03/05/2013 04:39	0	13.1	119.5	2.35	5,155.6	0.42
03/05/2013 04:40	3	15.3	122.9	2.50	5,311.1	0.51
03/05/2013 04:41	15	19.9	116.4	2.56	5,733.3	0.72
03/05/2013 04:42	26	21.6	91.4	2.30	6,555.6	0.88
03/05/2013 04:43	37	25.8	63.0	1.76	7,311.1	1.19
03/05/2013 04:44	48	29.9	40.8	1.27	8,200.0	1.54
03/05/2013 04:45	60	36.6	22.3	0.77	9,000.0	2.08
03/05/2013 04:46	72	17.2	5.2	0.20	9,977.8	1.07
03/05/2013 04:47	83	9.9	1.6	0.07	10,800.0	0.66
03/05/2013 04:48	96	4.9	1.1	0.04	11,777.8	0.36
03/05/2013 04:49	107	3.0	0.7	0.04	12,666.7	0.24
03/05/2013 04:50	118	1.9	0.4	0.02	13,466.7	0.16
03/05/2013 04:51	129	1.2	0.2	0.02	14,244.4	0.12
03/05/2013 04:52	139	0.8	0.2	0.00	14,866.7	0.08
03/05/2013 04:53	141	0.7	0.1	0.00	14,800.0	0.08
03/05/2013 04:54	140	0.7	0.0	0.00	14,666.7	0.05
03/05/2013 04:55	140	0.5	0.1	0.00	14,711.1	0.05
03/05/2013 04:56	140	0.3	0.0	0.00	14,688.9	0.03
03/05/2013 04:57	140	0.3	-0.1	0.00	14,711.1	0.03
03/05/2013 04:58	140	0.3	-0.2	0.00	14,688.9	0.03
03/05/2013 04:59	140	0.3	-0.3	0.00	14,688.9	0.03
03/05/2013 05:00	140	0.4	-0.3	0.00	14,711.1	0.05
Total				20.13		11.12

Date/Time Startup Commences: 03/08/2013 04:26
 Gas Turbine Downtime: 4 Hours
 Steam Turbine Downtime: 4 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
03/08/2013 04:26	0	0.0	0.0	0.00	577.8	0.00
03/08/2013 04:27	0	0.0	0.0	0.00	955.6	0.00
03/08/2013 04:28	0	0.8	19.4	0.13	1,822.2	0.01
03/08/2013 04:29	0	1.2	31.1	0.31	2,577.8	0.02
03/08/2013 04:30	0	2.7	56.3	0.74	3,444.4	0.06
03/08/2013 04:31	0	3.2	100.3	1.59	4,133.3	0.08
03/08/2013 04:32	0	5.7	223.1	3.92	4,600.0	0.17
03/08/2013 04:33	0	9.8	321.6	7.19	5,844.4	0.36
03/08/2013 04:34	0	14.6	491.7	9.66	5,133.3	0.47
03/08/2013 04:35	0	18.1	598.9	11.76	5,133.3	0.59
03/08/2013 04:36	4	20.1	533.2	12.06	5,911.1	0.75
03/08/2013 04:37	12	21.4	438.4	9.35	5,577.8	0.75
03/08/2013 04:38	22	23.3	234.3	5.61	6,266.7	0.92
03/08/2013 04:39	32	26.2	109.1	2.90	6,955.6	1.14
03/08/2013 04:40	42	28.2	61.2	1.80	7,688.9	1.37
03/08/2013 04:41	52	33.3	35.4	1.13	8,377.8	1.76
03/08/2013 04:42	62	33.4	9.7	0.34	9,133.3	1.92
03/08/2013 04:43	72	14.1	6.7	0.25	9,911.1	0.88
03/08/2013 04:44	82	7.0	4.6	0.18	10,644.4	0.47
03/08/2013 04:45	92	4.0	2.4	0.10	11,444.4	0.29
03/08/2013 04:46	103	2.4	1.1	0.04	12,244.4	0.19
03/08/2013 04:47	113	1.8	0.7	0.04	13,022.2	0.13
03/08/2013 04:48	123	1.1	0.5	0.02	13,644.4	0.09
03/08/2013 04:49	132	0.9	0.4	0.02	14,244.4	0.07
03/08/2013 04:50	139	0.7	0.3	0.03	14,733.3	0.05
03/08/2013 04:51	140	0.6	0.1	0.00	14,733.3	0.05
03/08/2013 04:52	140	0.5	0.0	0.00	14,733.3	0.05
03/08/2013 04:53	140	0.5	-0.1	0.00	14,711.1	0.05
03/08/2013 04:54	140	0.5	-0.2	0.00	14,711.1	0.05
03/08/2013 04:55	140	0.4	-0.2	0.00	14,688.9	0.05
03/08/2013 04:56	140	0.4	-0.2	0.00	14,688.9	0.05
03/08/2013 04:57	140	0.4	-0.3	0.00	14,666.7	0.05
Total				69.17		12.89

Date/Time Startup Commences: 03/13/2013 02:00
 Gas Turbine Downtime: 97 Hours
 Steam Turbine Downtime: 97 Hours
 Startup Type*: Cold

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
03/13/2013 02:00	0	0.0	0.0	0.00	1,133.3	0.00
03/13/2013 02:01	0	0.0	0.0	0.00	844.4	0.00
03/13/2013 02:02	0	32.5	147.5	1.01	1,777.8	0.37
03/13/2013 02:03	0	8.7	2,664.8	26.15	2,555.6	0.14
03/13/2013 02:04	0	10.3	2,438.0	31.82	3,400.0	0.22
03/13/2013 02:05	0	12.4	2,085.2	33.45	4,177.8	0.33
03/13/2013 02:06	0	16.0	2,202.0	39.45	4,666.7	0.47
03/13/2013 02:07	0	22.7	2,462.0	48.52	5,133.3	0.74
03/13/2013 02:08	0	24.9	2,620.9	52.55	5,222.2	0.82
03/13/2013 02:09	0	29.3	2,954.3	58.72	5,177.8	0.96
03/13/2013 02:10	7	32.1	3,064.5	64.84	5,511.1	1.12
03/13/2013 02:11	17	37.9	2,879.4	67.54	6,111.1	1.47
03/13/2013 02:12	29	42.8	2,201.5	58.41	6,911.1	1.87
03/13/2013 02:13	40	45.6	1,419.0	42.25	7,755.6	2.23
03/13/2013 02:14	51	49.4	864.4	28.47	8,577.8	2.68
03/13/2013 02:15	63	49.2	363.6	13.22	9,466.7	2.94
03/13/2013 02:16	75	39.2	32.2	1.28	10,355.6	2.56
03/13/2013 02:17	86	43.2	4.5	0.19	11,222.2	3.06
03/13/2013 02:18	98	39.2	3.0	0.15	12,133.3	3.00
03/13/2013 02:19	110	33.3	3.0	0.16	12,977.8	2.74
03/13/2013 02:20	122	26.5	3.1	0.17	13,800.0	2.30
03/13/2013 02:21	133	21.0	2.8	0.15	14,488.9	1.91
03/13/2013 02:22	139	17.1	1.9	0.10	14,866.7	1.61
03/13/2013 02:23	140	14.3	1.1	0.08	14,800.0	1.35
03/13/2013 02:24	140	12.1	0.8	0.05	14,866.7	1.15
03/13/2013 02:25	140	12.5	0.6	0.03	14,844.4	1.17
03/13/2013 02:26	140	12.2	0.4	0.03	14,822.2	1.14
03/13/2013 02:27	140	12.5	0.3	0.03	14,822.2	1.17
03/13/2013 02:28	140	12.6	0.2	0.03	14,822.2	1.19
03/13/2013 02:29	140	13.3	0.2	0.00	14,844.4	1.25
03/13/2013 02:30	140	14.4	0.2	0.00	14,844.4	1.35
03/13/2013 02:31	140	14.6	0.1	0.00	14,800.0	1.37
03/13/2013 02:32	140	14.9	0.1	0.00	14,844.4	1.40
03/13/2013 02:33	140	15.5	0.0	0.00	14,844.4	1.45
03/13/2013 02:34	140	15.9	0.0	0.00	14,822.2	1.50
03/13/2013 02:35	140	16.4	0.0	0.00	14,844.4	1.53
03/13/2013 02:36	140	15.3	-0.1	0.00	14,844.4	1.43
03/13/2013 02:37	140	9.0	-0.1	0.00	14,844.4	0.84
03/13/2013 02:38	141	1.2	-0.1	0.00	14,844.4	0.10
03/13/2013 02:39	140	0.8	-0.1	0.00	14,844.4	0.08
03/13/2013 02:40	140	0.7	-0.1	0.00	14,844.4	0.05
03/13/2013 02:41	140	0.5	-0.2	0.00	14,777.8	0.05
03/13/2013 02:42	140	0.4	-0.2	0.00	14,800.0	0.05
03/13/2013 02:43	140	0.3	-0.2	0.00	14,800.0	0.03
03/13/2013 02:44	141	0.3	-0.2	0.00	14,800.0	0.03
03/13/2013 02:45	140	0.3	-0.2	0.00	14,800.0	0.03
03/13/2013 02:46	140	0.3	-0.3	0.00	14,777.8	0.03
03/13/2013 02:47	140	0.3	-0.3	0.00	14,800.0	0.03
03/13/2013 02:48	140	0.3	-0.3	0.00	14,800.0	0.03
Total				568.85		53.34

Date/Time Startup Commences: 03/14/2013 07:41
 Gas Turbine Downtime: 9 Hours
 Steam Turbine Downtime: 9 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
03/14/2013 07:41	0	0.0	0.0	0.00	666.7	0.00
03/14/2013 07:42	0	0.0	0.0	0.00	222.2	0.00
03/14/2013 07:43	0	0.0	0.0	0.00	1,222.2	0.00
03/14/2013 07:44	0	6.5	22.4	0.17	2,000.0	0.08
03/14/2013 07:45	0	3.1	43.3	0.46	2,755.6	0.05
03/14/2013 07:46	0	3.9	106.6	1.50	3,666.7	0.09
03/14/2013 07:47	0	5.7	374.9	6.14	4,266.7	0.15
03/14/2013 07:48	0	9.6	773.1	14.05	4,733.3	0.28
03/14/2013 07:49	0	15.7	1,059.8	20.97	5,155.6	0.51
03/14/2013 07:50	0	22.1	1,503.0	29.49	5,111.1	0.72
03/14/2013 07:51	3	23.2	1,555.6	33.18	5,555.6	0.81
03/14/2013 07:52	12	26.0	1,424.1	30.38	5,555.6	0.91
03/14/2013 07:53	24	29.2	832.2	20.38	6,377.8	1.17
03/14/2013 07:54	35	31.3	285.1	7.80	7,133.3	1.41
03/14/2013 07:55	47	32.6	80.6	2.50	8,088.9	1.66
03/14/2013 07:56	58	37.4	30.9	1.05	8,888.9	2.10
03/14/2013 07:57	70	27.6	5.8	0.22	9,800.0	1.71
03/14/2013 07:58	81	30.1	2.5	0.11	10,600.0	2.02
03/14/2013 07:59	93	31.6	1.7	0.08	11,622.2	2.31
03/14/2013 08:00	105	29.3	1.0	0.04	12,466.7	2.31
03/14/2013 08:01	117	24.4	0.5	0.02	13,311.1	2.05
03/14/2013 08:02	128	19.4	0.4	0.02	14,022.2	1.73
03/14/2013 08:03	138	12.4	0.4	0.03	14,644.4	1.16
03/14/2013 08:04	140	1.5	0.3	0.03	14,644.4	0.13
03/14/2013 08:05	140	0.9	0.3	0.03	14,644.4	0.08
03/14/2013 08:06	140	0.8	0.3	0.03	14,688.9	0.08
03/14/2013 08:07	140	0.6	0.2	0.03	14,688.9	0.05
03/14/2013 08:08	140	0.5	0.1	0.00	14,688.9	0.05
03/14/2013 08:09	140	0.5	-0.1	0.00	14,688.9	0.05
03/14/2013 08:10	140	0.4	-0.2	0.00	14,688.9	0.05
03/14/2013 08:11	140	0.4	-0.2	0.00	14,688.9	0.05
03/14/2013 08:12	140	0.4	-0.2	0.00	14,688.9	0.05
03/14/2013 08:13	140	0.4	-0.2	0.00	14,688.9	0.05
03/14/2013 08:14	140	0.4	-0.3	0.00	14,711.1	0.05
Total				168.71		23.92

Date/Time Startup Commences: 03/16/2013 04:51
 Gas Turbine Downtime: 6 Hours
 Steam Turbine Downtime: 6 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
03/16/2013 04:51	0	0.0	0.0	0.00	777.8	0.00
03/16/2013 04:52	0	0.0	0.0	0.00	511.1	0.00
03/16/2013 04:53	0	14.8	3.0	0.02	1,577.8	0.15
03/16/2013 04:54	0	3.1	27.1	0.25	2,377.8	0.05
03/16/2013 04:55	0	4.1	42.8	0.52	3,177.8	0.08
03/16/2013 04:56	0	4.6	55.5	0.85	3,977.8	0.12
03/16/2013 04:57	0	6.6	96.6	1.67	4,511.1	0.19
03/16/2013 04:58	0	10.0	152.3	2.95	5,044.4	0.32
03/16/2013 04:59	0	13.7	201.0	4.01	5,200.0	0.45
03/16/2013 05:00	1	18.1	266.1	5.29	5,177.8	0.60
03/16/2013 05:01	9	20.8	245.0	5.12	5,444.4	0.71
03/16/2013 05:02	20	24.4	191.8	4.53	6,155.6	0.95
03/16/2013 05:03	31	27.8	86.6	2.31	6,933.3	1.21
03/16/2013 05:04	43	32.0	50.2	1.50	7,822.2	1.58
03/16/2013 05:05	54	40.1	31.2	1.04	8,666.7	2.20
03/16/2013 05:06	66	32.0	7.1	0.26	9,622.2	1.95
03/16/2013 05:07	77	32.0	2.9	0.11	10,466.7	2.12
03/16/2013 05:08	89	30.1	0.6	0.02	11,355.6	2.16
03/16/2013 05:09	101	17.5	0.4	0.02	12,244.4	1.36
03/16/2013 05:10	113	11.1	0.3	0.02	13,088.9	0.92
03/16/2013 05:11	124	11.0	0.3	0.02	13,866.7	0.95
03/16/2013 05:12	135	4.4	0.2	0.03	14,622.2	0.40
03/16/2013 05:13	140	2.4	0.2	0.00	14,800.0	0.23
03/16/2013 05:14	140	1.1	0.1	0.00	14,666.7	0.10
03/16/2013 05:15	140	0.5	0.1	0.00	14,688.9	0.05
03/16/2013 05:16	140	0.4	0.1	0.00	14,688.9	0.05
03/16/2013 05:17	140	0.3	0.0	0.00	14,688.9	0.03
03/16/2013 05:18	140	0.3	-0.2	0.00	14,711.1	0.03
03/16/2013 05:19	140	0.3	-0.3	0.00	14,711.1	0.03
03/16/2013 05:20	140	0.3	-0.3	0.00	14,711.1	0.03
03/16/2013 05:21	140	0.3	-0.3	0.00	14,733.3	0.03
03/16/2013 05:22	140	0.3	-0.3	0.00	14,711.1	0.03
03/16/2013 05:23	140	0.3	-0.3	0.00	14,711.1	0.03
Total				30.54		19.11

Date/Time Startup Commences: 03/18/2013 03:30
 Gas Turbine Downtime: 4 Hours
 Steam Turbine Downtime: 4 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
03/18/2013 03:30	0	0.0	0.0	0.00	733.3	0.00
03/18/2013 03:31	0	0.0	0.0	0.00	88.9	0.00
03/18/2013 03:32	0	0.0	0.0	0.00	1,377.8	0.00
03/18/2013 03:33	0	0.9	21.8	0.17	2,066.7	0.01
03/18/2013 03:34	0	1.1	35.1	0.39	2,866.7	0.02
03/18/2013 03:35	0	1.6	42.7	0.62	3,777.8	0.04
03/18/2013 03:36	0	3.5	58.3	0.97	4,333.3	0.10
03/18/2013 03:37	0	5.2	81.2	1.50	4,800.0	0.16
03/18/2013 03:38	0	8.3	92.9	1.86	5,200.0	0.28
03/18/2013 03:39	0	11.6	107.0	2.12	5,155.6	0.38
03/18/2013 03:40	3	13.8	114.5	2.31	5,266.7	0.46
03/18/2013 03:41	14	19.7	111.5	2.44	5,688.9	0.70
03/18/2013 03:42	25	20.7	91.8	2.28	6,488.9	0.85
03/18/2013 03:43	36	25.1	63.9	1.78	7,244.4	1.14
03/18/2013 03:44	48	29.8	40.8	1.27	8,155.6	1.54
03/18/2013 03:45	59	36.4	22.7	0.78	8,955.6	2.06
03/18/2013 03:46	72	20.5	5.2	0.20	9,911.1	1.29
03/18/2013 03:47	83	14.7	1.5	0.06	10,755.6	1.00
03/18/2013 03:48	94	12.0	1.0	0.04	11,711.1	0.88
03/18/2013 03:49	106	9.7	0.7	0.04	12,533.3	0.77
03/18/2013 03:50	117	6.6	0.3	0.02	13,400.0	0.55
03/18/2013 03:51	129	2.6	0.2	0.02	14,133.3	0.22
03/18/2013 03:52	138	0.9	0.2	0.00	14,688.9	0.08
03/18/2013 03:53	141	0.7	0.1	0.00	14,733.3	0.05
03/18/2013 03:54	140	0.5	0.0	0.00	14,622.2	0.05
03/18/2013 03:55	140	0.3	0.1	0.00	14,666.7	0.03
03/18/2013 03:56	140	0.2	0.1	0.00	14,644.4	0.03
03/18/2013 03:57	140	0.2	0.0	0.00	14,666.7	0.03
03/18/2013 03:58	140	0.1	-0.2	0.00	14,644.4	0.00
03/18/2013 03:59	140	0.1	-0.3	0.00	14,644.4	0.00
03/18/2013 04:00	140	0.1	-0.3	0.00	14,666.7	0.00
03/18/2013 04:01	140	0.1	-0.3	0.00	14,666.7	0.00
Total				18.87		12.72

Date/Time Startup Commences: 03/21/2013 03:54
 Gas Turbine Downtime: 5 Hours
 Steam Turbine Downtime: 5 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
03/21/2013 03:54	0	0.0	0.0	0.00	488.9	0.00
03/21/2013 03:55	0	0.0	0.0	0.00	222.2	0.00
03/21/2013 03:56	0	0.0	0.0	0.00	1,222.2	0.00
03/21/2013 03:57	0	0.6	19.5	0.15	1,955.6	0.01
03/21/2013 03:58	0	1.2	30.7	0.32	2,688.9	0.02
03/21/2013 03:59	0	2.4	44.4	0.61	3,600.0	0.06
03/21/2013 04:00	0	2.6	57.5	0.94	4,244.4	0.07
03/21/2013 04:01	0	4.8	85.1	1.54	4,733.3	0.15
03/21/2013 04:02	0	7.2	99.2	1.95	5,133.3	0.24
03/21/2013 04:03	0	10.7	114.2	2.26	5,155.6	0.35
03/21/2013 04:04	0	12.8	123.7	2.44	5,133.3	0.41
03/21/2013 04:05	8	14.9	123.7	2.58	5,422.2	0.51
03/21/2013 04:06	20	19.7	107.5	2.54	6,133.3	0.77
03/21/2013 04:07	31	21.9	76.4	2.02	6,888.9	0.96
03/21/2013 04:08	43	25.6	48.1	1.44	7,800.0	1.26
03/21/2013 04:09	54	33.8	27.9	0.92	8,666.7	1.86
03/21/2013 04:10	66	26.4	6.2	0.23	9,533.3	1.59
03/21/2013 04:11	77	16.0	2.1	0.09	10,422.2	1.05
03/21/2013 04:12	89	13.7	1.1	0.04	11,377.8	1.00
03/21/2013 04:13	101	10.9	0.7	0.04	12,177.8	0.84
03/21/2013 04:14	113	8.8	0.4	0.02	13,088.9	0.72
03/21/2013 04:15	124	4.1	0.3	0.02	13,844.4	0.36
03/21/2013 04:16	133	1.2	0.2	0.00	14,488.9	0.12
03/21/2013 04:17	140	0.8	0.1	0.00	14,777.8	0.08
03/21/2013 04:18	141	0.3	0.0	0.00	14,688.9	0.03
03/21/2013 04:19	140	0.3	0.1	0.00	14,711.1	0.03
03/21/2013 04:20	141	0.3	0.2	0.00	14,755.6	0.03
03/21/2013 04:21	141	0.2	0.2	0.00	14,733.3	0.03
03/21/2013 04:22	140	0.2	-0.1	0.00	14,733.3	0.03
03/21/2013 04:23	141	0.2	-0.3	0.00	14,777.8	0.03
03/21/2013 04:24	141	0.2	-0.3	0.00	14,800.0	0.03
03/21/2013 04:25	142	0.2	-0.3	0.00	14,844.4	0.03
03/21/2013 04:26	142	0.2	-0.3	0.00	14,844.4	0.03
Total				20.15		12.7

Date/Time Startup Commences: 03/22/2013 03:54
 Gas Turbine Downtime: 5 Hours
 Steam Turbine Downtime: 5 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
03/22/2013 03:54	0	0.0	0.0	0.00	777.8	0.00
03/22/2013 03:55	0	0.0	0.0	0.00	200.0	0.00
03/22/2013 03:56	0	0.0	0.0	0.00	1,377.8	0.00
03/22/2013 03:57	0	0.9	22.7	0.18	2,022.2	0.01
03/22/2013 03:58	0	2.0	37.4	0.40	2,777.8	0.03
03/22/2013 03:59	0	3.0	45.4	0.65	3,711.1	0.07
03/22/2013 04:00	0	3.9	62.9	1.04	4,288.9	0.10
03/22/2013 04:01	0	6.4	90.8	1.76	5,044.4	0.20
03/22/2013 04:02	0	10.1	106.6	2.12	5,177.8	0.33
03/22/2013 04:03	0	13.9	123.9	2.44	5,133.3	0.45
03/22/2013 04:04	1	16.3	132.2	2.62	5,155.6	0.53
03/22/2013 04:05	9	21.0	131.4	2.72	5,400.0	0.71
03/22/2013 04:06	21	23.6	114.5	2.71	6,177.8	0.92
03/22/2013 04:07	32	28.9	80.3	2.15	6,955.6	1.26
03/22/2013 04:08	43	32.9	49.7	1.49	7,844.4	1.63
03/22/2013 04:09	54	41.8	28.8	0.96	8,644.4	2.28
03/22/2013 04:10	66	31.8	6.3	0.23	9,577.8	1.92
03/22/2013 04:11	78	20.0	2.1	0.09	10,488.9	1.33
03/22/2013 04:12	89	17.7	1.1	0.04	11,377.8	1.27
03/22/2013 04:13	102	13.6	0.8	0.04	12,311.1	1.06
03/22/2013 04:14	114	10.4	0.5	0.02	13,044.4	0.85
03/22/2013 04:15	124	8.6	0.4	0.02	13,577.8	0.75
03/22/2013 04:16	135	1.0	0.4	0.02	14,311.1	0.10
03/22/2013 04:17	139	0.6	0.4	0.03	14,644.4	0.05
03/22/2013 04:18	140	0.4	0.3	0.03	14,644.4	0.05
03/22/2013 04:19	140	0.2	0.2	0.00	14,666.7	0.03
03/22/2013 04:20	140	0.2	0.0	0.00	14,644.4	0.03
03/22/2013 04:21	140	0.2	-0.1	0.00	14,644.4	0.03
03/22/2013 04:22	140	0.2	-0.1	0.00	14,666.7	0.03
03/22/2013 04:23	140	0.1	-0.1	0.00	14,688.9	0.00
03/22/2013 04:24	140	0.1	-0.1	0.00	14,688.9	0.00
03/22/2013 04:25	140	0.1	-0.2	0.00	14,666.7	0.00
03/22/2013 04:26	140	0.1	-0.2	0.00	14,688.9	0.00
Total				21.76		16.02

Date/Time Startup Commences: 03/23/2013 03:50
 Gas Turbine Downtime: 5 Hours
 Steam Turbine Downtime: 5 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
03/23/2013 03:50	0	0.0	0.0	0.00	822.2	0.00
03/23/2013 03:51	0	0.0	0.0	0.00	111.1	0.00
03/23/2013 03:52	0	0.0	0.0	0.00	1,377.8	0.00
03/23/2013 03:53	0	2.7	20.4	0.16	2,066.7	0.04
03/23/2013 03:54	0	2.0	37.4	0.41	2,822.2	0.03
03/23/2013 03:55	0	3.2	46.3	0.67	3,733.3	0.08
03/23/2013 03:56	0	4.2	63.8	1.06	4,333.3	0.11
03/23/2013 03:57	0	6.6	91.7	1.69	4,800.0	0.20
03/23/2013 03:58	0	10.3	107.5	2.16	5,222.2	0.34
03/23/2013 03:59	0	14.3	123.9	2.47	5,200.0	0.47
03/23/2013 04:00	3	16.7	131.4	2.66	5,266.7	0.55
03/23/2013 04:01	13	22.0	131.4	2.87	5,688.9	0.79
03/23/2013 04:02	25	25.0	106.4	2.66	6,511.1	1.03
03/23/2013 04:03	36	29.6	69.5	1.95	7,288.9	1.36
03/23/2013 04:04	48	35.0	44.4	1.40	8,222.2	1.82
03/23/2013 04:05	59	42.9	23.7	0.82	9,022.2	2.44
03/23/2013 04:06	71	24.7	5.1	0.19	9,977.8	1.56
03/23/2013 04:07	82	19.1	1.6	0.07	10,822.2	1.30
03/23/2013 04:08	94	16.7	1.1	0.04	11,777.8	1.25
03/23/2013 04:09	106	12.7	0.7	0.04	12,666.7	1.02
03/23/2013 04:10	118	9.7	0.5	0.02	13,422.2	0.83
03/23/2013 04:11	129	3.3	0.4	0.02	14,088.9	0.29
03/23/2013 04:12	138	0.8	0.3	0.03	14,688.9	0.08
03/23/2013 04:13	140	0.6	0.3	0.03	14,644.4	0.05
03/23/2013 04:14	140	0.3	0.3	0.03	14,688.9	0.03
03/23/2013 04:15	140	0.3	0.3	0.03	14,688.9	0.03
03/23/2013 04:16	140	0.2	0.2	0.00	14,666.7	0.03
03/23/2013 04:17	140	0.2	0.0	0.00	14,688.9	0.03
03/23/2013 04:18	140	0.1	0.0	0.00	14,733.3	0.00
03/23/2013 04:19	140	0.1	-0.1	0.00	14,733.3	0.00
03/23/2013 04:20	140	0.1	-0.1	0.00	14,755.6	0.00
03/23/2013 04:21	140	0.1	-0.2	0.00	14,755.6	0.00
Total				21.48		15.76

Date/Time Startup Commences: 03/29/2013 03:31
 Gas Turbine Downtime: 4 Hours
 Steam Turbine Downtime: 4 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
03/29/2013 03:31	0	0.0	0.0	0.00	888.9	0.00
03/29/2013 03:32	0	0.0	0.0	0.00	88.9	0.00
03/29/2013 03:33	0	0.0	0.0	0.00	1,422.2	0.00
03/29/2013 03:34	0	0.4	24.9	0.20	2,111.1	0.01
03/29/2013 03:35	0	0.5	37.0	0.40	2,844.4	0.01
03/29/2013 03:36	0	0.9	43.7	0.63	3,777.8	0.02
03/29/2013 03:37	0	1.5	61.8	1.03	4,333.3	0.04
03/29/2013 03:38	0	3.3	83.7	1.56	4,866.7	0.10
03/29/2013 03:39	0	5.5	94.8	1.89	5,200.0	0.18
03/29/2013 03:40	0	8.0	114.2	2.26	5,155.6	0.26
03/29/2013 03:41	6	10.0	120.4	2.47	5,333.3	0.34
03/29/2013 03:42	17	12.9	113.4	2.60	5,977.8	0.49
03/29/2013 03:43	28	18.0	84.4	2.18	6,711.1	0.76
03/29/2013 03:44	40	21.1	56.7	1.64	7,533.3	1.01
03/29/2013 03:45	51	28.0	34.9	1.12	8,377.8	1.48
03/29/2013 03:46	63	30.0	6.2	0.22	9,288.9	1.77
03/29/2013 03:47	74	16.7	4.3	0.17	10,177.8	1.08
03/29/2013 03:48	86	13.2	1.5	0.06	11,066.7	0.93
03/29/2013 03:49	98	10.2	1.1	0.04	11,933.3	0.76
03/29/2013 03:50	110	7.4	0.7	0.04	12,866.7	0.60
03/29/2013 03:51	121	4.6	0.4	0.02	13,622.2	0.40
03/29/2013 03:52	132	1.4	0.2	0.02	14,422.2	0.12
03/29/2013 03:53	140	0.7	0.2	0.00	14,822.2	0.08
03/29/2013 03:54	141	0.6	0.1	0.00	14,666.7	0.05
03/29/2013 03:55	140	0.4	0.1	0.00	14,666.7	0.05
03/29/2013 03:56	140	0.3	0.3	0.03	14,711.1	0.03
03/29/2013 03:57	140	0.2	0.3	0.03	14,688.9	0.03
03/29/2013 03:58	140	0.2	0.2	0.00	14,711.1	0.03
03/29/2013 03:59	140	0.2	-0.1	0.00	14,688.9	0.03
03/29/2013 04:00	140	0.1	-0.1	0.00	14,711.1	0.00
03/29/2013 04:01	140	0.1	-0.1	0.00	14,688.9	0.00
03/29/2013 04:02	140	0.1	-0.2	0.00	14,711.1	0.00
Total				18.61		10.66

Date/Time Startup Commences: 03/30/2013 20:40
 Gas Turbine Downtime: 20 Hours
 Steam Turbine Downtime: 20 Hours
 Startup Type*: warm

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
03/30/2013 20:40	0	0.0	0.0	0.00	888.9	0.00
03/30/2013 20:41	0	0.0	0.0	0.00	733.3	0.00
03/30/2013 20:42	0	32.5	129.8	0.84	1,688.9	0.35
03/30/2013 20:43	0	6.9	2,217.0	20.99	2,466.7	0.11
03/30/2013 20:44	0	8.7	2,605.7	32.90	3,288.9	0.18
03/30/2013 20:45	0	11.0	2,253.8	35.19	4,066.7	0.28
03/30/2013 20:46	0	15.8	2,358.3	41.25	4,555.6	0.45
03/30/2013 20:47	0	22.9	2,605.8	53.35	5,333.3	0.78
03/30/2013 20:48	0	26.1	2,743.7	54.54	5,177.8	0.85
03/30/2013 20:49	0	29.7	3,061.9	60.34	5,133.3	0.96
03/30/2013 20:50	7	30.7	3,176.4	64.76	5,311.1	1.03
03/30/2013 20:51	17	35.8	3,059.4	69.43	5,911.1	1.34
03/30/2013 20:52	28	40.5	2,330.7	60.05	6,711.1	1.72
03/30/2013 20:53	40	42.7	1,380.1	40.03	7,555.6	2.03
03/30/2013 20:54	51	47.0	805.8	26.06	8,422.2	2.50
03/30/2013 20:55	63	43.0	215.2	7.73	9,355.6	2.54
03/30/2013 20:56	75	35.6	8.3	0.33	10,222.2	2.30
03/30/2013 20:57	85	38.4	4.2	0.17	11,066.7	2.68
03/30/2013 20:58	97	33.8	2.5	0.12	11,888.9	2.53
03/30/2013 20:59	110	28.4	1.9	0.09	12,800.0	2.31
03/30/2013 21:00	121	21.9	1.3	0.07	13,533.3	1.88
03/30/2013 21:01	133	17.8	0.9	0.05	14,288.9	1.62
03/30/2013 21:02	139	15.8	0.8	0.05	14,755.6	1.47
03/30/2013 21:03	140	15.9	0.7	0.05	14,733.3	1.47
03/30/2013 21:04	140	13.7	0.8	0.05	14,755.6	1.29
03/30/2013 21:05	140	15.0	0.8	0.05	14,755.6	1.39
03/30/2013 21:06	140	15.2	0.7	0.03	14,777.8	1.42
03/30/2013 21:07	140	15.3	0.5	0.03	14,777.8	1.42
03/30/2013 21:08	140	15.7	0.3	0.03	14,755.6	1.47
03/30/2013 21:09	140	13.5	0.2	0.03	14,755.6	1.27
03/30/2013 21:10	140	9.1	0.2	0.00	14,777.8	0.84
03/30/2013 21:11	140	4.1	0.1	0.00	14,777.8	0.38
03/30/2013 21:12	140	2.7	0.1	0.00	14,777.8	0.25
03/30/2013 21:13	140	2.2	0.0	0.00	14,777.8	0.20
03/30/2013 21:14	140	1.4	0.0	0.00	14,800.0	0.13
03/30/2013 21:15	140	1.1	-0.1	0.00	14,800.0	0.10
03/30/2013 21:16	140	0.9	-0.1	0.00	14,777.8	0.08
03/30/2013 21:17	140	0.7	-0.1	0.00	14,822.2	0.05
03/30/2013 21:18	140	0.5	-0.1	0.00	14,800.0	0.05
03/30/2013 21:19	140	0.4	-0.1	0.00	14,777.8	0.05
03/30/2013 21:20	140	0.3	-0.2	0.00	14,755.6	0.03
03/30/2013 21:21	140	0.3	-0.2	0.00	14,777.8	0.03
03/30/2013 21:22	140	0.3	-0.2	0.00	14,755.6	0.03
03/30/2013 21:23	140	0.3	-0.2	0.00	14,777.8	0.03
03/30/2013 21:24	140	0.3	-0.2	0.00	14,755.6	0.03
Total				568.61		41.92



Condition 18 Startup Report

From: 04/01/2013 00:00 To: 06/30/2013 23:59 Facility Name: Lodi Energy Center

Generated: 07/11/2013 09:21 Location: Lodi, CA

Gas Turbine Downtime Tag: CT1_GT_Downtime_Min_1M

Steam Turbine Downtime Tag: CT1_GT_Downtime_Min_1M

*ST Downtime Determines Startup Type: Cold > 64 hours, 16 hours >= Warm <= 64, Hot < 16

Red = Invalid Data

Date/Time Startup Commences: 04/01/2013 02:38

Gas Turbine Downtime: 23 Hours

Steam Turbine Downtime: 23 Hours

Startup Type*: Warm

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
04/01/2013 02:38	0	0.0	0.0	0.00	622.2	0.00
04/01/2013 02:39	0	0.0	0.0	0.00	288.9	0.00
04/01/2013 02:40	0	0.0	0.0	0.00	1,422.2	0.00
04/01/2013 02:41	0	11.8	86.7	0.70	2,111.1	0.16
04/01/2013 02:42	0	7.0	2,585.9	28.24	2,844.4	0.13
04/01/2013 02:43	0	9.2	2,255.3	32.90	3,800.0	0.22
04/01/2013 02:44	0	14.1	2,275.7	38.25	4,377.8	0.39
04/01/2013 02:45	0	18.8	2,483.9	46.83	4,911.1	0.58
04/01/2013 02:46	0	24.0	2,555.8	50.58	5,155.6	0.78
04/01/2013 02:47	0	29.3	2,935.0	58.09	5,155.6	0.95
04/01/2013 02:48	2	30.5	3,090.0	61.16	5,155.6	0.99
04/01/2013 02:49	11	32.8	3,063.9	65.61	5,577.8	1.16
04/01/2013 02:50	23	39.3	2,741.4	67.35	6,400.0	1.59
04/01/2013 02:51	35	42.6	1,731.4	48.30	7,266.7	1.96
04/01/2013 02:52	47	45.3	1,043.5	32.67	8,155.6	2.34
04/01/2013 02:53	57	52.9	529.5	17.97	8,844.4	2.96
04/01/2013 02:54	69	35.6	61.9	2.31	9,777.8	2.20
04/01/2013 02:55	80	37.4	6.3	0.26	10,622.2	2.51
04/01/2013 02:56	92	37.5	3.6	0.16	11,555.6	2.74
04/01/2013 02:57	103	31.1	2.8	0.13	12,422.2	2.45
04/01/2013 02:58	116	24.8	2.0	0.11	13,266.7	2.07
04/01/2013 02:59	127	18.9	1.2	0.07	14,022.2	1.68
04/01/2013 03:00	137	16.1	0.9	0.05	14,666.7	1.48
04/01/2013 03:01	140	14.5	0.8	0.05	14,800.0	1.35
04/01/2013 03:02	140	12.7	0.7	0.05	14,755.6	1.19
04/01/2013 03:03	140	12.2	0.9	0.05	14,777.8	1.14
04/01/2013 03:04	140	13.4	0.8	0.05	14,800.0	1.24
04/01/2013 03:05	140	13.4	0.7	0.05	14,777.8	1.27
04/01/2013 03:06	140	14.0	0.6	0.03	14,800.0	1.29
04/01/2013 03:07	140	14.4	0.4	0.03	14,777.8	1.34
04/01/2013 03:08	140	14.8	0.3	0.03	14,777.8	1.37
04/01/2013 03:09	140	10.5	0.2	0.03	14,800.0	0.99
04/01/2013 03:10	140	5.5	0.2	0.00	14,777.8	0.51
04/01/2013 03:11	140	3.4	0.2	0.00	14,800.0	0.33
04/01/2013 03:12	140	2.3	0.1	0.00	14,800.0	0.23
04/01/2013 03:13	141	1.9	0.1	0.00	14,800.0	0.18
04/01/2013 03:14	140	1.2	0.1	0.00	14,800.0	0.10
04/01/2013 03:15	140	0.8	0.0	0.00	14,800.0	0.08
04/01/2013 03:16	141	0.8	0.0	0.00	14,800.0	0.08
04/01/2013 03:17	140	0.5	0.0	0.00	14,777.8	0.05
04/01/2013 03:18	140	0.4	-0.1	0.00	14,800.0	0.05
04/01/2013 03:19	140	0.3	-0.1	0.00	14,800.0	0.03
04/01/2013 03:20	140	0.3	-0.1	0.00	14,800.0	0.03
04/01/2013 03:21	140	0.3	-0.2	0.00	14,800.0	0.03
04/01/2013 03:22	140	0.3	-0.2	0.00	14,800.0	0.03
04/01/2013 03:23	140	0.3	-0.2	0.00	14,777.8	0.03
Total				552.11		42.28

Date/Time Startup Commences: 04/02/2013 03:43
 Gas Turbine Downtime: 4 Hours
 Steam Turbine Downtime: 4 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
04/02/2013 03:43	0	0.0	0.0	0.00	644.4	0.00
04/02/2013 03:44	0	0.0	0.0	0.00	622.2	0.00
04/02/2013 03:45	0	1.5	10.3	0.07	1,666.7	0.01
04/02/2013 03:46	0	0.9	26.1	0.24	2,444.4	0.01
04/02/2013 03:47	0	2.7	42.0	0.53	3,311.1	0.06
04/02/2013 03:48	0	2.7	47.4	0.74	4,044.4	0.07
04/02/2013 03:49	0	4.6	68.4	1.19	4,533.3	0.13
04/02/2013 03:50	0	6.8	86.5	1.77	5,311.1	0.23
04/02/2013 03:51	0	10.1	100.1	1.99	5,177.8	0.33
04/02/2013 03:52	0	13.0	117.8	2.33	5,155.6	0.42
04/02/2013 03:53	7	15.1	121.3	2.49	5,355.6	0.51
04/02/2013 03:54	18	20.0	111.0	2.54	5,977.8	0.76
04/02/2013 03:55	29	22.0	81.0	2.09	6,733.3	0.94
04/02/2013 03:56	40	27.3	53.8	1.56	7,577.8	1.31
04/02/2013 03:57	52	34.1	34.5	1.11	8,400.0	1.82
04/02/2013 03:58	64	32.4	8.1	0.29	9,377.8	1.91
04/02/2013 03:59	76	17.3	3.8	0.14	10,244.4	1.12
04/02/2013 04:00	86	13.5	1.7	0.08	11,088.9	0.95
04/02/2013 04:01	98	10.3	1.3	0.06	11,911.1	0.78
04/02/2013 04:02	110	9.8	0.8	0.04	12,822.2	0.79
04/02/2013 04:03	122	4.4	0.4	0.02	13,600.0	0.37
04/02/2013 04:04	133	1.3	0.3	0.02	14,422.2	0.12
04/02/2013 04:05	140	0.7	0.2	0.03	14,711.1	0.08
04/02/2013 04:06	140	0.7	0.2	0.00	14,600.0	0.05
04/02/2013 04:07	139	0.4	0.1	0.00	14,644.4	0.05
04/02/2013 04:08	140	0.3	0.2	0.00	14,644.4	0.03
04/02/2013 04:09	140	0.2	0.1	0.00	14,666.7	0.03
04/02/2013 04:10	140	0.2	-0.1	0.00	14,666.7	0.03
04/02/2013 04:11	140	0.2	-0.2	0.00	14,644.4	0.03
04/02/2013 04:12	140	0.2	-0.2	0.00	14,666.7	0.03
04/02/2013 04:13	140	0.2	-0.2	0.00	14,666.7	0.03
04/02/2013 04:14	140	0.3	-0.2	0.00	14,644.4	0.03
Total				19.33		13.03

Date/Time Startup Commences: 04/03/2013 03:43
 Gas Turbine Downtime: 4 Hours
 Steam Turbine Downtime: 4 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
04/03/2013 03:43	0	0.0	0.0	0.00	711.1	0.00
04/03/2013 03:44	0	0.0	0.0	0.00	311.1	0.00
04/03/2013 03:45	0	0.0	-5.9	0.00	1,533.3	0.00
04/03/2013 03:46	0	0.4	24.0	0.21	2,266.7	0.00
04/03/2013 03:47	0	1.1	41.3	0.48	3,044.4	0.02
04/03/2013 03:48	0	1.5	48.3	0.73	3,933.3	0.03
04/03/2013 03:49	0	3.4	72.9	1.25	4,466.7	0.09
04/03/2013 03:50	0	4.8	100.1	2.30	5,977.8	0.18
04/03/2013 03:51	0	8.0	113.4	2.28	5,222.2	0.26
04/03/2013 03:52	1	10.8	132.2	2.70	5,311.1	0.36
04/03/2013 03:53	6	13.0	138.1	2.83	5,333.3	0.44
04/03/2013 03:54	17	15.3	120.6	2.78	6,000.0	0.58
04/03/2013 03:55	28	18.8	91.7	2.37	6,733.3	0.80
04/03/2013 03:56	40	21.8	60.1	1.75	7,555.6	1.04
04/03/2013 03:57	51	27.0	36.3	1.17	8,400.0	1.44
04/03/2013 03:58	63	28.2	6.8	0.24	9,311.1	1.66
04/03/2013 03:59	74	16.5	4.8	0.19	10,177.8	1.06
04/03/2013 04:00	85	12.5	1.7	0.08	11,044.4	0.87
04/03/2013 04:01	97	9.9	1.3	0.06	12,000.0	0.74
04/03/2013 04:02	110	7.0	0.8	0.04	12,866.7	0.57
04/03/2013 04:03	121	4.2	0.4	0.02	13,666.7	0.38
04/03/2013 04:04	132	1.5	0.3	0.02	14,355.6	0.15
04/03/2013 04:05	139	1.0	0.2	0.03	14,777.8	0.10
04/03/2013 04:06	140	0.6	0.2	0.00	14,711.1	0.05
04/03/2013 04:07	140	0.3	0.2	0.00	14,755.6	0.03
04/03/2013 04:08	140	0.3	0.2	0.00	14,755.6	0.03
04/03/2013 04:09	140	0.2	0.1	0.00	14,755.6	0.03
04/03/2013 04:10	140	0.2	0.0	0.00	14,733.3	0.03
04/03/2013 04:11	140	0.2	-0.1	0.00	14,777.8	0.03
04/03/2013 04:12	140	0.2	-0.1	0.00	14,777.8	0.03
04/03/2013 04:13	140	0.2	-0.2	0.00	14,777.8	0.03
04/03/2013 04:14	140	0.2	-0.2	0.00	14,755.6	0.03
Total				21.53		11.06

Date/Time Startup Commences: 04/06/2013 06: 44
 Gas Turbine Downtime: 7 Hours
 Steam Turbine Downtime: 7 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
04/06/2013 06: 44	0	0.0	0.0	0.00	844.4	0.00
04/06/2013 06: 45	0	0.0	0.0	0.00	288.9	0.00
04/06/2013 06: 46	0	0.0	0.0	0.00	1,422.2	0.00
04/06/2013 06: 47	0	0.4	22.8	0.19	2,133.3	0.01
04/06/2013 06: 48	0	1.3	41.3	0.46	2,888.9	0.02
04/06/2013 06: 49	0	2.1	52.7	0.77	3,822.2	0.05
04/06/2013 06: 50	0	3.2	85.1	1.44	4,400.0	0.09
04/06/2013 06: 51	0	5.9	138.3	2.58	4,844.4	0.18
04/06/2013 06: 52	0	9.7	168.6	3.36	5,200.0	0.32
04/06/2013 06: 53	0	13.4	228.9	4.55	5,177.8	0.44
04/06/2013 06: 54	4	15.5	229.5	4.70	5,333.3	0.52
04/06/2013 06: 55	16	20.4	204.6	4.59	5,844.4	0.75
04/06/2013 06: 56	27	22.3	136.5	3.49	6,644.4	0.93
04/06/2013 06: 57	39	25.7	73.8	2.11	7,466.7	1.22
04/06/2013 06: 58	50	30.6	42.1	1.35	8,355.6	1.62
04/06/2013 06: 59	62	31.5	21.5	0.76	9,200.0	1.83
04/06/2013 07: 00	73	19.5	5.8	0.23	10,111.1	1.25
04/06/2013 07: 01	84	15.2	1.4	0.06	11,000.0	1.06
04/06/2013 07: 02	96	11.4	0.8	0.04	11,933.3	0.86
04/06/2013 07: 03	109	8.9	0.6	0.02	12,800.0	0.72
04/06/2013 07: 04	120	5.1	0.5	0.02	13,555.6	0.44
04/06/2013 07: 05	131	1.9	0.4	0.02	14,288.9	0.17
04/06/2013 07: 06	139	0.9	0.3	0.03	14,755.6	0.08
04/06/2013 07: 07	140	0.7	0.2	0.03	14,688.9	0.08
04/06/2013 07: 08	140	0.6	0.3	0.03	14,755.6	0.05
04/06/2013 07: 09	140	0.3	0.3	0.03	14,755.6	0.03
04/06/2013 07: 10	140	0.2	0.2	0.00	14,755.6	0.03
04/06/2013 07: 11	140	0.2	0.0	0.00	14,755.6	0.03
04/06/2013 07: 12	140	0.2	-0.1	0.00	14,755.6	0.03
04/06/2013 07: 13	140	0.2	-0.1	0.00	14,777.8	0.03
04/06/2013 07: 14	140	0.2	-0.1	0.00	14,800.0	0.03
04/06/2013 07: 15	140	0.2	-0.2	0.00	14,800.0	0.03
Total				30.86		12.9

Date/Time Startup Commences: 04/08/2013 02: 38
 Gas Turbine Downtime: 27 Hours
 Steam Turbine Downtime: 27 Hours
 Startup Type*: Warm

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
04/08/2013 02: 38	0	0.0	0.0	0.00	933.3	0.00
04/08/2013 02: 39	0	0.0	0.0	0.00	600.0	0.00
04/08/2013 02: 40	0	0.0	0.0	0.00	1,577.8	0.00
04/08/2013 02: 41	0	11.8	2,439.2	21.85	2,333.3	0.17
04/08/2013 02: 42	0	11.5	2,767.4	33.76	3,177.8	0.23
04/08/2013 02: 43	0	13.3	2,274.3	35.31	4,044.4	0.34
04/08/2013 02: 44	0	17.7	2,378.1	41.59	4,555.6	0.51
04/08/2013 02: 45	0	23.6	2,613.5	50.61	5,044.4	0.75
04/08/2013 02: 46	0	26.9	2,686.9	53.87	5,222.2	0.89
04/08/2013 02: 47	0	31.0	2,979.9	59.49	5,200.0	1.02
04/08/2013 02: 48	4	32.1	3,049.3	62.17	5,311.1	1.07
04/08/2013 02: 49	14	35.6	3,018.0	67.46	5,822.2	1.31
04/08/2013 02: 50	26	41.5	2,433.8	61.87	6,622.2	1.74
04/08/2013 02: 51	37	45.5	1,513.4	43.00	7,400.0	2.13
04/08/2013 02: 52	48	49.3	992.1	31.66	8,311.1	2.59
04/08/2013 02: 53	59	59.6	464.4	16.29	9,133.3	3.45
04/08/2013 02: 54	71	39.7	40.3	1.55	10,066.7	2.52
04/08/2013 02: 55	83	43.1	6.0	0.24	10,955.6	2.99
04/08/2013 02: 56	95	43.1	4.3	0.20	11,911.1	3.25
04/08/2013 02: 57	106	37.9	3.8	0.17	12,733.3	3.06
04/08/2013 02: 58	118	33.2	2.9	0.16	13,644.4	2.85
04/08/2013 02: 59	128	26.4	1.8	0.10	14,177.8	2.36
04/08/2013 03: 00	135	20.6	1.1	0.05	14,644.4	1.91
04/08/2013 03: 01	141	17.1	0.7	0.05	14,955.6	1.62
04/08/2013 03: 02	140	13.8	0.7	0.03	14,822.2	1.30
04/08/2013 03: 03	140	13.6	0.7	0.05	14,866.7	1.27
04/08/2013 03: 04	140	15.2	0.7	0.03	14,866.7	1.43
04/08/2013 03: 05	140	15.3	0.6	0.03	14,844.4	1.43
04/08/2013 03: 06	140	15.5	0.4	0.03	14,866.7	1.45
04/08/2013 03: 07	141	15.8	0.3	0.03	14,844.4	1.48
04/08/2013 03: 08	140	16.1	0.2	0.03	14,844.4	1.50
04/08/2013 03: 09	141	16.7	0.2	0.00	14,866.7	1.56
04/08/2013 03: 10	143	15.6	0.2	0.00	15,000.0	1.47
04/08/2013 03: 11	143	10.1	0.1	0.00	14,977.8	0.95
04/08/2013 03: 12	143	5.2	0.1	0.00	15,000.0	0.49
04/08/2013 03: 13	143	3.5	0.0	0.00	15,022.2	0.34
04/08/2013 03: 14	143	2.6	0.0	0.00	15,000.0	0.26
04/08/2013 03: 15	143	1.9	0.0	0.00	15,022.2	0.18
04/08/2013 03: 16	143	1.3	0.0	0.00	15,022.2	0.13
04/08/2013 03: 17	143	0.8	-0.1	0.00	15,022.2	0.08
04/08/2013 03: 18	143	0.7	-0.1	0.00	15,044.4	0.05
04/08/2013 03: 19	143	0.6	-0.1	0.00	15,022.2	0.05
04/08/2013 03: 20	143	0.4	-0.1	0.00	15,044.4	0.05
04/08/2013 03: 21	143	0.3	-0.1	0.00	15,044.4	0.03
04/08/2013 03: 22	143	0.3	-0.2	0.00	15,044.4	0.03
04/08/2013 03: 23	143	0.3	-0.2	0.00	15,044.4	0.03
04/08/2013 03: 24	143	0.3	-0.2	0.00	15,044.4	0.03
04/08/2013 03: 25	143	0.3	-0.2	0.00	15,044.4	0.03
Total				581.68		52.38

Date/Time Startup Commences: 04/09/2013 03:50
 Gas Turbine Downtime: 5 Hours
 Steam Turbine Downtime: 5 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
04/09/2013 03:50	0	0.0	0.0	0.00	311.1	0.00
04/09/2013 03:51	0	0.0	0.0	0.00	422.2	0.00
04/09/2013 03:52	0	0.0	0.0	0.00	1,088.9	0.00
04/09/2013 03:53	0	0.7	20.3	0.00	1,888.9	0.00
04/09/2013 03:54	0	0.6	29.5	0.00	2,644.4	0.00
04/09/2013 03:55	0	1.2	42.2	0.01	3,533.3	0.00
04/09/2013 03:56	0	2.4	55.5	0.01	4,200.0	0.00
04/09/2013 03:57	0	3.9	81.9	0.01	4,688.9	0.00
04/09/2013 03:58	0	7.0	103.8	0.02	5,244.4	0.00
04/09/2013 03:59	0	10.3	124.7	0.02	5,155.6	0.00
04/09/2013 04:00	2	12.6	137.3	0.03	5,222.2	0.00
04/09/2013 04:01	11	15.7	132.2	0.03	5,533.3	0.01
04/09/2013 04:02	22	20.4	105.8	0.03	6,311.1	0.01
04/09/2013 04:03	34	23.9	67.6	0.02	7,111.1	0.01
04/09/2013 04:04	45	29.9	44.4	0.01	8,022.2	0.02
04/09/2013 04:05	57	39.3	25.9	0.01	8,822.2	0.02
04/09/2013 04:06	69	23.7	5.4	0.00	9,755.6	0.01
04/09/2013 04:07	79	17.4	1.9	0.00	10,600.0	0.01
04/09/2013 04:08	91	14.9	1.3	0.00	11,577.8	0.01
04/09/2013 04:09	104	11.4	0.8	0.00	12,377.8	0.01
04/09/2013 04:10	115	8.9	0.5	0.00	13,222.2	0.01
04/09/2013 04:11	126	3.4	0.3	0.00	14,022.2	0.00
04/09/2013 04:12	138	1.1	0.3	0.00	14,733.3	0.00
04/09/2013 04:13	143	0.7	0.2	0.00	14,977.8	0.00
04/09/2013 04:14	141	0.6	0.2	0.00	14,755.6	0.00
04/09/2013 04:15	140	0.4	0.1	0.00	14,688.9	0.00
04/09/2013 04:16	140	0.3	0.1	0.00	14,711.1	0.00
04/09/2013 04:17	140	0.2	0.0	0.00	14,711.1	0.00
04/09/2013 04:18	140	0.2	-0.1	0.00	14,688.9	0.00
04/09/2013 04:19	140	0.2	-0.2	0.00	14,688.9	0.00
04/09/2013 04:20	140	0.2	-0.2	0.00	14,711.1	0.00
04/09/2013 04:21	140	0.2	-0.2	0.00	14,733.3	0.00
04/09/2013 04:22	140	0.2	-0.2	0.00	14,711.1	0.00
Total				0.2		0.12

Date/Time Startup Commences: 04/10/2013 03:41
 Gas Turbine Downtime: 4 Hours
 Steam Turbine Downtime: 4 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
04/10/2013 03:41	0	0.0	0.0	0.00	488.9	0.00
04/10/2013 03:42	0	0.0	0.0	0.00	266.7	0.00
04/10/2013 03:43	0	0.0	0.0	0.00	1,200.0	0.00
04/10/2013 03:44	0	4.1	20.7	0.00	1,933.3	0.00
04/10/2013 03:45	0	2.8	29.2	0.00	2,711.1	0.00
04/10/2013 03:46	0	3.6	43.6	0.01	3,622.2	0.00
04/10/2013 03:47	0	4.6	56.3	0.01	4,200.0	0.00
04/10/2013 03:48	0	6.6	81.1	0.02	5,644.4	0.00
04/10/2013 03:49	0	10.3	99.2	0.02	5,155.6	0.00
04/10/2013 03:50	0	13.9	115.9	0.02	5,111.1	0.00
04/10/2013 03:51	7	16.3	127.2	0.03	5,288.9	0.01
04/10/2013 03:52	17	21.8	123.7	0.03	5,911.1	0.01
04/10/2013 03:53	27	23.8	92.3	0.02	6,644.4	0.01
04/10/2013 03:54	39	28.1	60.8	0.02	7,466.7	0.01
04/10/2013 03:55	50	34.0	37.1	0.01	8,333.3	0.02
04/10/2013 03:56	63	33.9	8.7	0.00	9,266.7	0.02
04/10/2013 03:57	74	19.1	3.9	0.00	10,177.8	0.01
04/10/2013 03:58	85	15.8	1.4	0.00	11,022.2	0.01
04/10/2013 03:59	97	11.9	1.1	0.00	11,911.1	0.01
04/10/2013 04:00	109	9.3	0.7	0.00	12,777.8	0.01
04/10/2013 04:01	120	5.2	0.4	0.00	13,533.3	0.00
04/10/2013 04:02	132	1.6	0.3	0.00	14,333.3	0.00
04/10/2013 04:03	140	0.9	0.2	0.00	14,733.3	0.00
04/10/2013 04:04	141	0.7	0.2	0.00	14,666.7	0.00
04/10/2013 04:05	139	0.5	0.2	0.00	14,688.9	0.00
04/10/2013 04:06	140	0.3	0.2	0.00	14,688.9	0.00
04/10/2013 04:07	140	0.2	0.2	0.00	14,688.9	0.00
04/10/2013 04:08	140	0.2	0.0	0.00	14,711.1	0.00
04/10/2013 04:09	140	0.2	-0.1	0.00	14,711.1	0.00
04/10/2013 04:10	140	0.2	-0.2	0.00	14,733.3	0.00
04/10/2013 04:11	140	0.2	-0.2	0.00	14,711.1	0.00
04/10/2013 04:12	140	0.2	-0.2	0.00	14,733.3	0.00
Total				0.19		0.12

Date/Time Startup Commences: 04/11/2013 03:39
 Gas Turbine Downtime: 5 Hours
 Steam Turbine Downtime: 5 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
04/11/2013 03:39	0	0.0	0.0	0.00	666.7	0.00
04/11/2013 03:40	0	0.0	0.0	0.00	200.0	0.00
04/11/2013 03:41	0	0.0	-5.9	0.00	1,488.9	0.00
04/11/2013 03:42	0	0.7	22.5	0.00	2,244.4	0.00
04/11/2013 03:43	0	1.8	41.8	0.01	3,066.7	0.00
04/11/2013 03:44	0	2.3	50.2	0.01	3,933.3	0.00
04/11/2013 03:45	0	3.5	72.8	0.01	4,444.4	0.00
04/11/2013 03:46	0	5.9	96.6	0.02	5,155.6	0.00
04/11/2013 03:47	0	9.7	112.3	0.02	5,200.0	0.00
04/11/2013 03:48	0	13.4	134.9	0.03	5,155.6	0.00
04/11/2013 03:49	5	15.9	143.2	0.03	5,288.9	0.01
04/11/2013 03:50	16	20.4	130.0	0.03	5,866.7	0.01
04/11/2013 03:51	28	22.8	100.5	0.03	6,666.7	0.01
04/11/2013 03:52	38	26.7	66.7	0.02	7,422.2	0.01
04/11/2013 03:53	50	31.5	40.1	0.01	8,311.1	0.02
04/11/2013 03:54	62	32.1	6.4	0.00	9,222.2	0.02
04/11/2013 03:55	74	18.6	4.9	0.00	10,155.6	0.01
04/11/2013 03:56	85	14.3	1.7	0.00	11,044.4	0.01
04/11/2013 03:57	97	11.0	1.3	0.00	11,933.3	0.01
04/11/2013 03:58	108	8.9	0.8	0.00	12,755.6	0.01
04/11/2013 03:59	120	4.7	0.5	0.00	13,488.9	0.00
04/11/2013 04:00	131	1.6	0.3	0.00	14,222.2	0.00
04/11/2013 04:01	139	0.9	0.3	0.00	14,711.1	0.00
04/11/2013 04:02	140	0.7	0.2	0.00	14,644.4	0.00
04/11/2013 04:03	139	0.4	0.3	0.00	14,733.3	0.00
04/11/2013 04:04	140	0.3	0.3	0.00	14,755.6	0.00
04/11/2013 04:05	140	0.2	0.2	0.00	14,755.6	0.00
04/11/2013 04:06	140	0.2	0.0	0.00	14,755.6	0.00
04/11/2013 04:07	140	0.2	-0.1	0.00	14,755.6	0.00
04/11/2013 04:08	140	0.2	-0.1	0.00	14,755.6	0.00
04/11/2013 04:09	140	0.2	-0.2	0.00	14,800.0	0.00
04/11/2013 04:10	140	0.2	-0.2	0.00	14,777.8	0.00
Total				0.22		0.12

Date/Time Startup Commences: 04/12/2013 03:33
 Gas Turbine Downtime: 5 Hours
 Steam Turbine Downtime: 5 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
04/12/2013 03:33	0	0.0	0.0	0.00	644.4	0.00
04/12/2013 03:34	0	0.0	0.0	0.00	288.9	0.00
04/12/2013 03:35	0	5.9	-5.9	0.00	1,488.9	0.00
04/12/2013 03:36	0	2.2	22.5	0.00	2,222.2	0.00
04/12/2013 03:37	0	2.4	41.3	0.00	3,000.0	0.00
04/12/2013 03:38	0	3.3	49.2	0.01	3,888.9	0.00
04/12/2013 03:39	0	4.4	70.1	0.01	4,422.2	0.00
04/12/2013 03:40	0	7.0	97.4	0.02	5,022.2	0.00
04/12/2013 03:41	0	9.9	109.8	0.02	5,200.0	0.00
04/12/2013 03:42	0	13.5	138.7	0.03	5,177.8	0.00
04/12/2013 03:43	5	15.1	140.8	0.03	5,288.9	0.01
04/12/2013 03:44	17	20.1	131.2	0.03	5,866.7	0.01
04/12/2013 03:45	30	21.5	96.4	0.03	6,844.4	0.01
04/12/2013 03:46	45	27.0	59.4	0.02	7,911.1	0.01
04/12/2013 03:47	57	35.4	33.8	0.01	8,822.2	0.02
04/12/2013 03:48	70	23.0	7.2	0.00	9,888.9	0.01
04/12/2013 03:49	83	16.6	2.0	0.00	10,822.2	0.01
04/12/2013 03:50	97	13.8	0.7	0.00	12,000.0	0.01
04/12/2013 03:51	109	10.5	0.6	0.00	12,911.1	0.01
04/12/2013 03:52	116	8.4	0.4	0.00	13,311.1	0.01
04/12/2013 03:53	124	3.4	0.3	0.00	13,844.4	0.00
04/12/2013 03:54	133	1.1	0.2	0.00	14,400.0	0.00
04/12/2013 03:55	140	0.6	0.2	0.00	14,777.8	0.00
04/12/2013 03:56	140	0.5	0.2	0.00	14,711.1	0.00
04/12/2013 03:57	140	0.3	0.3	0.00	14,733.3	0.00
04/12/2013 03:58	140	0.3	0.3	0.00	14,711.1	0.00
04/12/2013 03:59	140	0.2	0.1	0.00	14,733.3	0.00
04/12/2013 04:00	140	0.2	-0.1	0.00	14,733.3	0.00
04/12/2013 04:01	140	0.2	-0.2	0.00	14,755.6	0.00
04/12/2013 04:02	140	0.2	-0.2	0.00	14,755.6	0.00
04/12/2013 04:03	140	0.2	-0.2	0.00	14,755.6	0.00
04/12/2013 04:04	140	0.2	-0.2	0.00	14,755.6	0.00
Total				0.21		0.11

Date/Time Startup Commences: 04/13/2013 06: 46
 Gas Turbine Downtime: 7 Hours
 Steam Turbine Downtime: 7 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
04/13/2013 06: 46	0	0.0	0.0	0.00	800.0	0.00
04/13/2013 06: 47	0	0.0	0.0	0.00	955.6	0.00
04/13/2013 06: 48	0	4.9	23.6	0.00	1,800.0	0.00
04/13/2013 06: 49	0	2.1	29.2	0.00	2,600.0	0.00
04/13/2013 06: 50	0	3.1	77.6	0.01	3,466.7	0.00
04/13/2013 06: 51	0	3.8	241.5	0.04	4,155.6	0.00
04/13/2013 06: 52	0	6.6	498.0	0.09	4,644.4	0.00
04/13/2013 06: 53	0	10.7	637.4	0.13	5,111.1	0.00
04/13/2013 06: 54	0	16.0	874.5	0.17	5,177.8	0.01
04/13/2013 06: 55	1	19.5	1,065.7	0.21	5,155.6	0.01
04/13/2013 06: 56	10	22.0	1,035.1	0.22	5,488.9	0.01
04/13/2013 06: 57	23	25.8	768.3	0.19	6,333.3	0.01
04/13/2013 06: 58	36	28.6	253.3	0.07	7,266.7	0.01
04/13/2013 06: 59	50	32.0	65.5	0.02	8,355.6	0.02
04/13/2013 07: 00	63	34.2	10.4	0.00	9,355.6	0.02
04/13/2013 07: 01	77	28.7	3.4	0.00	10,488.9	0.02
04/13/2013 07: 02	90	33.3	1.0	0.00	11,533.3	0.02
04/13/2013 07: 03	104	32.4	0.8	0.00	12,533.3	0.03
04/13/2013 07: 04	112	27.9	0.6	0.00	13,088.9	0.02
04/13/2013 07: 05	120	22.9	0.4	0.00	13,600.0	0.02
04/13/2013 07: 06	130	12.7	0.4	0.00	14,177.8	0.01
04/13/2013 07: 07	139	12.7	0.4	0.00	14,733.3	0.01
04/13/2013 07: 08	141	3.2	0.4	0.00	14,755.6	0.00
04/13/2013 07: 09	139	1.9	0.3	0.00	14,711.1	0.00
04/13/2013 07: 10	140	1.5	0.4	0.00	14,733.3	0.00
04/13/2013 07: 11	140	1.2	0.3	0.00	14,755.6	0.00
04/13/2013 07: 12	140	0.7	0.2	0.00	14,755.6	0.00
04/13/2013 07: 13	140	0.7	0.0	0.00	14,755.6	0.00
04/13/2013 07: 14	140	0.6	0.0	0.00	14,777.8	0.00
04/13/2013 07: 15	140	0.5	-0.1	0.00	14,777.8	0.00
04/13/2013 07: 16	140	0.4	-0.1	0.00	14,755.6	0.00
04/13/2013 07: 17	140	0.3	-0.1	0.00	14,755.6	0.00
04/13/2013 07: 18	140	0.3	-0.1	0.00	14,777.8	0.00
04/13/2013 07: 19	140	0.3	-0.1	0.00	14,777.8	0.00
Total				1.15		0.22

Date/Time Startup Commences: 04/15/2013 02:13
 Gas Turbine Downtime: 27 Hours
 Steam Turbine Downtime: 27 Hours
 Startup Type*: Warm

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
04/15/2013 02:13	0	0.0	0.0	0.00	422.2	0.00
04/15/2013 02:14	0	0.0	0.0	0.00	333.3	0.00
04/15/2013 02:15	0	0.0	0.0	0.00	1,311.1	0.00
04/15/2013 02:16	0	24.8	77.9	0.01	1,911.1	0.00
04/15/2013 02:17	0	10.2	2,753.3	0.29	2,711.1	0.00
04/15/2013 02:18	0	12.5	2,415.0	0.34	3,644.4	0.00
04/15/2013 02:19	0	15.5	2,330.1	0.38	4,311.1	0.00
04/15/2013 02:20	0	19.2	2,473.8	0.45	4,777.8	0.01
04/15/2013 02:21	0	24.5	2,608.7	0.62	6,177.8	0.01
04/15/2013 02:22	0	29.1	2,737.6	0.54	5,177.8	0.01
04/15/2013 02:23	1	31.7	2,944.1	0.58	5,177.8	0.01
04/15/2013 02:24	6	33.8	3,020.4	0.62	5,355.6	0.01
04/15/2013 02:25	17	38.3	2,905.7	0.67	6,044.4	0.01
04/15/2013 02:26	30	43.4	2,250.0	0.60	6,933.3	0.02
04/15/2013 02:27	43	46.7	1,307.5	0.40	7,911.1	0.02
04/15/2013 02:28	55	53.6	665.2	0.23	8,888.9	0.03
04/15/2013 02:29	70	44.5	102.9	0.04	10,066.7	0.03
04/15/2013 02:30	83	43.8	6.0	0.00	11,044.4	0.03
04/15/2013 02:31	97	44.5	4.2	0.00	12,200.0	0.03
04/15/2013 02:32	103	39.7	3.7	0.00	12,577.8	0.03
04/15/2013 02:33	113	33.0	3.2	0.00	13,266.7	0.03
04/15/2013 02:34	123	24.8	2.4	0.00	13,911.1	0.02
04/15/2013 02:35	132	18.3	1.5	0.00	14,422.2	0.02
04/15/2013 02:36	140	14.8	0.9	0.00	14,955.6	0.01
04/15/2013 02:37	140	12.9	0.7	0.00	14,866.7	0.01
04/15/2013 02:38	140	11.7	0.7	0.00	14,888.9	0.01
04/15/2013 02:39	140	13.5	0.7	0.00	14,888.9	0.01
04/15/2013 02:40	140	13.8	0.7	0.00	14,911.1	0.01
04/15/2013 02:41	140	14.0	0.5	0.00	14,911.1	0.01
04/15/2013 02:42	140	14.5	0.4	0.00	14,888.9	0.01
04/15/2013 02:43	140	15.3	0.3	0.00	14,888.9	0.01
04/15/2013 02:44	140	15.8	0.3	0.00	14,888.9	0.01
04/15/2013 02:45	140	16.1	0.2	0.00	14,888.9	0.02
04/15/2013 02:46	141	13.1	0.2	0.00	14,888.9	0.01
04/15/2013 02:47	141	8.6	0.2	0.00	14,888.9	0.01
04/15/2013 02:48	141	4.2	0.1	0.00	14,888.9	0.00
04/15/2013 02:49	141	2.8	0.1	0.00	14,866.7	0.00
04/15/2013 02:50	141	2.2	0.1	0.00	14,866.7	0.00
04/15/2013 02:51	141	1.3	0.1	0.00	14,866.7	0.00
04/15/2013 02:52	140	1.1	0.1	0.00	14,866.7	0.00
04/15/2013 02:53	140	0.9	0.0	0.00	14,866.7	0.00
04/15/2013 02:54	140	0.7	0.0	0.00	14,866.7	0.00
04/15/2013 02:55	140	0.5	0.0	0.00	14,866.7	0.00
04/15/2013 02:56	141	0.4	0.0	0.00	14,844.4	0.00
04/15/2013 02:57	141	0.3	0.0	0.00	14,866.7	0.00
04/15/2013 02:58	140	0.3	0.0	0.00	14,844.4	0.00
04/15/2013 02:59	140	0.3	-0.1	0.00	14,844.4	0.00
04/15/2013 03:00	140	0.3	-0.1	0.00	14,822.2	0.00
04/15/2013 03:01	140	0.3	-0.1	0.00	14,800.0	0.00
Total				5.77		0.45

Date/Time Startup Commences: 04/16/2013 03:33
 Gas Turbine Downtime: 4 Hours
 Steam Turbine Downtime: 4 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
04/16/2013 03:33	0	0.0	0.0	0.00	711.1	0.00
04/16/2013 03:34	0	0.0	0.0	0.00	88.9	0.00
04/16/2013 03:35	0	0.0	0.0	0.00	1,355.6	0.00
04/16/2013 03:36	0	0.5	24.1	0.00	2,022.2	0.00
04/16/2013 03:37	0	0.6	38.8	0.00	2,777.8	0.00
04/16/2013 03:38	0	1.1	52.0	0.01	3,733.3	0.00
04/16/2013 03:39	0	2.6	90.2	0.01	4,311.1	0.00
04/16/2013 03:40	0	4.5	156.1	0.03	5,066.7	0.00
04/16/2013 03:41	0	7.9	194.9	0.04	5,177.8	0.00
04/16/2013 03:42	0	11.4	272.2	0.05	5,133.3	0.00
04/16/2013 03:43	2	14.0	278.9	0.06	5,266.7	0.00
04/16/2013 03:44	11	16.3	249.2	0.05	5,511.1	0.01
04/16/2013 03:45	25	20.4	165.4	0.04	6,444.4	0.01
04/16/2013 03:46	38	23.6	73.8	0.02	7,377.8	0.01
04/16/2013 03:47	50	28.5	42.4	0.01	8,400.0	0.02
04/16/2013 03:48	64	32.3	9.8	0.00	9,422.2	0.02
04/16/2013 03:49	78	20.0	3.5	0.00	10,511.1	0.01
04/16/2013 03:50	91	17.7	0.7	0.00	11,555.6	0.01
04/16/2013 03:51	104	14.3	0.6	0.00	12,533.3	0.01
04/16/2013 03:52	111	11.2	0.5	0.00	13,000.0	0.01
04/16/2013 03:53	121	8.7	0.4	0.00	13,644.4	0.01
04/16/2013 03:54	129	2.3	0.4	0.00	14,200.0	0.00
04/16/2013 03:55	138	0.9	0.4	0.00	14,711.1	0.00
04/16/2013 03:56	141	0.7	0.3	0.00	14,688.9	0.00
04/16/2013 03:57	139	0.5	0.3	0.00	14,644.4	0.00
04/16/2013 03:58	140	0.3	0.3	0.00	14,666.7	0.00
04/16/2013 03:59	140	0.2	0.3	0.00	14,688.9	0.00
04/16/2013 04:00	140	0.2	0.1	0.00	14,666.7	0.00
04/16/2013 04:01	140	0.2	0.0	0.00	14,688.9	0.00
04/16/2013 04:02	140	0.2	-0.1	0.00	14,688.9	0.00
04/16/2013 04:03	140	0.2	-0.1	0.00	14,688.9	0.00
04/16/2013 04:04	140	0.2	-0.1	0.00	14,711.1	0.00
Total				0.32		0.12

Date/Time Startup Commences: 04/18/2013 03: 41
 Gas Turbine Downtime: 4 Hours
 Steam Turbine Downtime: 4 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
04/18/2013 03: 41	0	0.0	0.0	0.00	911.1	0.00
04/18/2013 03: 42	0	0.0	0.0	0.00	200.0	0.00
04/18/2013 03: 43	0	0.0	0.0	0.00	1,444.4	0.00
04/18/2013 03: 44	0	0.8	22.8	0.00	2,177.8	0.00
04/18/2013 03: 45	0	1.6	39.2	0.00	2,977.8	0.00
04/18/2013 03: 46	0	2.4	43.7	0.01	3,844.4	0.00
04/18/2013 03: 47	0	3.3	61.8	0.01	4,377.8	0.00
04/18/2013 03: 48	0	5.7	88.0	0.02	5,044.4	0.00
04/18/2013 03: 49	0	9.2	100.1	0.02	5,222.2	0.00
04/18/2013 03: 50	1	12.9	118.6	0.02	5,222.2	0.00
04/18/2013 03: 51	11	15.5	123.7	0.03	5,533.3	0.01
04/18/2013 03: 52	23	20.7	111.4	0.03	6,377.8	0.01
04/18/2013 03: 53	35	24.5	78.3	0.02	7,288.9	0.01
04/18/2013 03: 54	49	31.3	43.9	0.01	8,355.6	0.02
04/18/2013 03: 55	63	38.0	6.2	0.00	9,355.6	0.02
04/18/2013 03: 56	77	22.1	5.6	0.00	10,466.7	0.01
04/18/2013 03: 57	90	18.4	3.4	0.00	11,555.6	0.01
04/18/2013 03: 58	104	15.0	1.5	0.00	12,555.6	0.01
04/18/2013 03: 59	114	11.2	0.5	0.00	13,244.4	0.01
04/18/2013 04: 00	121	8.4	0.4	0.00	13,666.7	0.01
04/18/2013 04: 01	132	2.2	0.3	0.00	14,400.0	0.00
04/18/2013 04: 02	140	0.9	0.3	0.00	14,911.1	0.00
04/18/2013 04: 03	141	0.7	0.2	0.00	14,711.1	0.00
04/18/2013 04: 04	139	0.4	0.3	0.00	14,711.1	0.00
04/18/2013 04: 05	140	0.3	0.3	0.00	14,733.3	0.00
04/18/2013 04: 06	140	0.2	0.3	0.00	14,733.3	0.00
04/18/2013 04: 07	140	0.2	0.1	0.00	14,733.3	0.00
04/18/2013 04: 08	140	0.2	-0.1	0.00	14,733.3	0.00
04/18/2013 04: 09	140	0.2	-0.1	0.00	14,755.6	0.00
04/18/2013 04: 10	140	0.2	-0.1	0.00	14,755.6	0.00
04/18/2013 04: 11	140	0.2	-0.1	0.00	14,755.6	0.00
Total				0.17		0.12

Date/Time Startup Commences: 04/19/2013 03:40
 Gas Turbine Downtime: 4 Hours
 Steam Turbine Downtime: 4 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
04/19/2013 03:40	0	0.0	0.0	0.00	688.9	0.00
04/19/2013 03:41	0	0.0	0.0	0.00	844.4	0.00
04/19/2013 03:42	0	0.0	17.7	0.00	1,777.8	0.00
04/19/2013 03:43	0	0.3	26.8	0.00	2,555.6	0.00
04/19/2013 03:44	0	0.7	42.2	0.01	3,444.4	0.00
04/19/2013 03:45	0	1.1	54.6	0.01	4,177.8	0.00
04/19/2013 03:46	0	3.1	76.5	0.01	4,644.4	0.00
04/19/2013 03:47	0	4.8	94.6	0.02	5,133.3	0.00
04/19/2013 03:48	0	7.8	109.8	0.02	5,222.2	0.00
04/19/2013 03:49	0	10.6	125.5	0.02	5,177.8	0.00
04/19/2013 03:50	4	12.8	128.8	0.03	5,311.1	0.00
04/19/2013 03:51	17	15.0	117.4	0.03	5,933.3	0.01
04/19/2013 03:52	30	19.2	89.5	0.02	6,822.2	0.01
04/19/2013 03:53	43	24.1	56.7	0.02	7,866.7	0.01
04/19/2013 03:54	55	33.1	30.9	0.01	8,755.6	0.02
04/19/2013 03:55	70	26.1	5.9	0.00	9,955.6	0.02
04/19/2013 03:56	83	17.3	1.6	0.00	10,955.6	0.01
04/19/2013 03:57	98	14.8	0.7	0.00	12,066.7	0.01
04/19/2013 03:58	110	11.0	0.6	0.00	13,000.0	0.01
04/19/2013 03:59	117	8.5	0.5	0.00	13,377.8	0.01
04/19/2013 04:00	127	3.8	0.4	0.00	14,022.2	0.00
04/19/2013 04:01	137	1.1	0.3	0.00	14,733.3	0.00
04/19/2013 04:02	141	0.7	0.2	0.00	14,755.6	0.00
04/19/2013 04:03	140	0.5	0.2	0.00	14,688.9	0.00
04/19/2013 04:04	140	0.3	0.4	0.00	14,733.3	0.00
04/19/2013 04:05	140	0.2	0.5	0.00	14,733.3	0.00
04/19/2013 04:06	140	0.2	0.3	0.00	14,755.6	0.00
04/19/2013 04:07	140	0.2	0.0	0.00	14,755.6	0.00
04/19/2013 04:08	140	0.2	0.0	0.00	14,777.8	0.00
04/19/2013 04:09	140	0.2	0.0	0.00	14,777.8	0.00
04/19/2013 04:10	140	0.2	-0.1	0.00	14,733.3	0.00
04/19/2013 04:11	140	0.2	-0.1	0.00	14,733.3	0.00
Total				0.2		0.11

Date/Time Startup Commences: 04/20/2013 05: 26
 Gas Turbine Downtime: 6 Hours
 Steam Turbine Downtime: 6 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
04/20/2013 05: 26	0	0.0	0.0	0.00	666.7	0.00
04/20/2013 05: 27	0	0.0	0.0	0.00	400.0	0.00
04/20/2013 05: 28	0	5.9	0.0	0.00	1,511.1	0.00
04/20/2013 05: 29	0	2.2	24.3	0.00	2,266.7	0.00
04/20/2013 05: 30	0	1.9	61.4	0.01	3,111.1	0.00
04/20/2013 05: 31	0	3.1	176.6	0.03	3,955.6	0.00
04/20/2013 05: 32	0	5.2	334.1	0.06	4,488.9	0.00
04/20/2013 05: 33	0	9.2	456.3	0.09	5,066.7	0.00
04/20/2013 05: 34	0	13.3	525.9	0.11	5,222.2	0.00
04/20/2013 05: 35	0	16.9	677.3	0.14	5,200.0	0.01
04/20/2013 05: 36	5	18.7	632.3	0.13	5,288.9	0.01
04/20/2013 05: 37	14	21.7	514.6	0.12	5,777.8	0.01
04/20/2013 05: 38	24	24.1	269.8	0.07	6,466.7	0.01
04/20/2013 05: 39	34	27.3	118.1	0.03	7,177.8	0.01
04/20/2013 05: 40	44	30.1	65.4	0.02	7,977.8	0.02
04/20/2013 05: 41	53	37.5	35.7	0.01	8,600.0	0.02
04/20/2013 05: 42	65	30.9	6.8	0.00	9,488.9	0.02
04/20/2013 05: 43	76	29.7	4.9	0.00	10,355.6	0.02
04/20/2013 05: 44	88	34.3	3.2	0.00	11,244.4	0.02
04/20/2013 05: 45	100	31.9	1.5	0.00	12,088.9	0.02
04/20/2013 05: 46	111	24.8	0.8	0.00	12,933.3	0.02
04/20/2013 05: 47	122	12.6	0.6	0.00	13,600.0	0.01
04/20/2013 05: 48	134	8.5	0.5	0.00	14,333.3	0.01
04/20/2013 05: 49	139	3.7	0.4	0.00	14,755.6	0.00
04/20/2013 05: 50	140	3.0	0.3	0.00	14,733.3	0.00
04/20/2013 05: 51	140	2.0	0.2	0.00	14,755.6	0.00
04/20/2013 05: 52	140	1.2	0.1	0.00	14,733.3	0.00
04/20/2013 05: 53	140	0.7	0.0	0.00	14,733.3	0.00
04/20/2013 05: 54	140	0.5	0.0	0.00	14,755.6	0.00
04/20/2013 05: 55	140	0.4	-0.1	0.00	14,755.6	0.00
04/20/2013 05: 56	140	0.4	-0.1	0.00	14,755.6	0.00
04/20/2013 05: 57	140	0.3	-0.1	0.00	14,777.8	0.00
04/20/2013 05: 58	140	0.3	-0.1	0.00	14,755.6	0.00
04/20/2013 05: 59	140	0.3	-0.2	0.00	14,755.6	0.00
04/20/2013 06: 00	140	0.3	-0.2	0.00	14,777.8	0.00
04/20/2013 06: 01	140	0.3	-0.2	0.00	14,755.6	0.00
Total				0.82		0.21

Date/Time Startup Commences: 04/21/2013 08:41
 Gas Turbine Downtime: 9 Hours
 Steam Turbine Downtime: 9 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
04/21/2013 08:41	0	0.0	0.0	0.00	933.3	0.00
04/21/2013 08:42	0	0.0	0.0	0.00	400.0	0.00
04/21/2013 08:43	0	17.7	20.7	0.00	1,600.0	0.00
04/21/2013 08:44	0	3.3	27.2	0.00	2,377.8	0.00
04/21/2013 08:45	0	4.2	1,125.7	0.14	3,244.4	0.00
04/21/2013 08:46	0	6.7	1,799.9	0.28	4,044.4	0.00
04/21/2013 08:47	0	12.7	2,219.7	0.39	4,533.3	0.00
04/21/2013 08:48	0	18.6	2,503.8	0.50	5,133.3	0.01
04/21/2013 08:49	0	23.4	2,622.6	0.52	5,155.6	0.01
04/21/2013 08:50	2	28.4	3,014.9	0.61	5,244.4	0.01
04/21/2013 08:51	12	30.3	3,049.3	0.66	5,622.2	0.01
04/21/2013 08:52	24	36.7	2,655.7	0.65	6,422.2	0.01
04/21/2013 08:53	35	38.8	1,521.8	0.42	7,200.0	0.02
04/21/2013 08:54	47	39.5	642.8	0.20	8,177.8	0.02
04/21/2013 08:55	58	44.5	132.5	0.05	8,911.1	0.03
04/21/2013 08:56	70	30.1	7.2	0.00	9,844.4	0.02
04/21/2013 08:57	81	32.2	3.0	0.00	10,644.4	0.02
04/21/2013 08:58	93	29.9	1.6	0.00	11,533.3	0.02
04/21/2013 08:59	105	25.7	1.3	0.00	12,400.0	0.02
04/21/2013 09:00	117	21.5	1.0	0.00	13,200.0	0.02
04/21/2013 09:01	127	17.0	0.8	0.00	13,933.3	0.02
04/21/2013 09:02	137	16.0	0.7	0.00	14,666.7	0.01
04/21/2013 09:03	140	15.7	0.7	0.00	14,800.0	0.01
04/21/2013 09:04	139	15.6	0.7	0.00	14,688.9	0.01
04/21/2013 09:05	138	10.6	0.6	0.00	14,666.7	0.01
04/21/2013 09:06	138	4.6	0.4	0.00	14,644.4	0.00
04/21/2013 09:07	138	2.8	0.3	0.00	14,666.7	0.00
04/21/2013 09:08	139	2.2	0.2	0.00	14,666.7	0.00
04/21/2013 09:09	138	1.5	0.2	0.00	14,644.4	0.00
04/21/2013 09:10	138	1.2	0.1	0.00	14,666.7	0.00
04/21/2013 09:11	138	1.1	0.0	0.00	14,666.7	0.00
04/21/2013 09:12	141	0.8	0.0	0.00	14,866.7	0.00
04/21/2013 09:13	142	0.7	0.0	0.00	14,911.1	0.00
04/21/2013 09:14	142	0.5	-0.1	0.00	14,911.1	0.00
04/21/2013 09:15	142	0.4	-0.1	0.00	14,955.6	0.00
04/21/2013 09:16	142	0.3	-0.1	0.00	14,911.1	0.00
04/21/2013 09:17	142	0.3	-0.1	0.00	14,933.3	0.00
04/21/2013 09:18	142	0.3	-0.1	0.00	14,955.6	0.00
04/21/2013 09:19	142	0.3	-0.1	0.00	14,955.6	0.00
Total				4.42		0.28

Date/Time Startup Commences: 04/23/2013 03:26
 Gas Turbine Downtime: 4 Hours
 Steam Turbine Downtime: 4 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
04/23/2013 03:26	0	0.0	0.0	0.00	822.2	0.00
04/23/2013 03:27	0	0.0	0.0	0.00	200.0	0.00
04/23/2013 03:28	0	0.0	0.0	0.00	1,400.0	0.00
04/23/2013 03:29	0	0.5	22.7	0.00	2,088.9	0.00
04/23/2013 03:30	0	0.8	37.4	0.00	2,800.0	0.00
04/23/2013 03:31	0	1.3	42.0	0.01	3,733.3	0.00
04/23/2013 03:32	0	2.8	57.5	0.01	4,288.9	0.00
04/23/2013 03:33	0	4.4	78.2	0.01	4,800.0	0.00
04/23/2013 03:34	0	7.4	93.7	0.02	5,111.1	0.00
04/23/2013 03:35	0	10.5	110.6	0.02	5,088.9	0.00
04/23/2013 03:36	1	12.8	116.2	0.02	5,066.7	0.00
04/23/2013 03:37	10	14.9	117.8	0.02	5,400.0	0.01
04/23/2013 03:38	24	21.5	109.4	0.03	6,355.6	0.01
04/23/2013 03:39	37	24.5	66.9	0.02	7,266.7	0.01
04/23/2013 03:40	50	30.5	35.9	0.01	8,333.3	0.02
04/23/2013 03:41	65	32.6	7.2	0.00	9,511.1	0.02
04/23/2013 03:42	77	20.4	3.7	0.00	10,466.7	0.01
04/23/2013 03:43	91	17.8	2.3	0.00	11,533.3	0.01
04/23/2013 03:44	106	14.3	0.9	0.00	12,266.7	0.01
04/23/2013 03:45	118	9.5	0.4	0.00	13,200.0	0.01
04/23/2013 03:46	130	4.0	0.4	0.00	14,088.9	0.00
04/23/2013 03:47	137	1.8	0.3	0.00	14,511.1	0.00
04/23/2013 03:48	141	0.8	0.2	0.00	14,822.2	0.00
04/23/2013 03:49	142	0.5	0.2	0.00	14,777.8	0.00
04/23/2013 03:50	140	0.4	0.2	0.00	14,733.3	0.00
04/23/2013 03:51	141	0.3	0.3	0.00	14,800.0	0.00
04/23/2013 03:52	141	0.2	0.2	0.00	14,800.0	0.00
04/23/2013 03:53	141	0.2	0.0	0.00	14,777.8	0.00
04/23/2013 03:54	141	0.3	-0.1	0.00	14,755.6	0.00
04/23/2013 03:55	140	0.3	-0.1	0.00	14,755.6	0.00
04/23/2013 03:56	140	0.3	-0.1	0.00	14,777.8	0.00
04/23/2013 03:57	140	0.3	-0.1	0.00	14,777.8	0.00
Total				0.17		0.11

Date/Time Startup Commences: 04/26/2013 04:26
 Gas Turbine Downtime: 5 Hours
 Steam Turbine Downtime: 5 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
04/26/2013 04:26	0	0.0	0.0	0.00	600.0	0.00
04/26/2013 04:27	0	0.0	0.0	0.00	733.3	0.00
04/26/2013 04:28	0	0.0	10.6	0.07	1,711.1	0.00
04/26/2013 04:29	0	0.6	27.3	0.26	2,511.1	0.01
04/26/2013 04:30	0	1.0	42.0	0.54	3,333.3	0.02
04/26/2013 04:31	0	1.5	53.8	0.84	4,066.7	0.04
04/26/2013 04:32	0	3.3	77.4	1.36	4,555.6	0.09
04/26/2013 04:33	0	5.2	100.1	2.09	5,422.2	0.18
04/26/2013 04:34	0	8.2	115.9	2.31	5,177.8	0.27
04/26/2013 04:35	0	10.8	134.9	2.68	5,155.6	0.35
04/26/2013 04:36	6	13.0	137.3	2.80	5,311.1	0.44
04/26/2013 04:37	18	15.6	123.7	2.85	5,977.8	0.59
04/26/2013 04:38	31	19.6	91.1	2.42	6,911.1	0.86
04/26/2013 04:39	45	24.4	54.2	1.67	8,000.0	1.24
04/26/2013 04:40	58	32.3	27.8	0.95	8,888.9	1.82
04/26/2013 04:41	72	21.7	5.6	0.23	10,066.7	1.39
04/26/2013 04:42	84	16.4	1.2	0.06	11,022.2	1.14
04/26/2013 04:43	98	14.2	0.6	0.02	12,155.6	1.09
04/26/2013 04:44	106	11.0	0.5	0.02	12,733.3	0.88
04/26/2013 04:45	112	8.6	0.4	0.02	13,177.8	0.73
04/26/2013 04:46	119	3.7	0.3	0.02	13,666.7	0.33
04/26/2013 04:47	125	1.1	0.3	0.02	14,044.4	0.10
04/26/2013 04:48	130	0.7	0.2	0.02	14,400.0	0.05
04/26/2013 04:49	135	0.6	0.2	0.00	14,755.6	0.05
04/26/2013 04:50	139	0.4	0.1	0.00	15,111.1	0.05
04/26/2013 04:51	140	0.2	0.0	0.00	15,133.3	0.03
04/26/2013 04:52	140	0.2	-0.1	0.00	15,133.3	0.03
04/26/2013 04:53	140	0.2	-0.1	0.00	15,155.6	0.03
04/26/2013 04:54	140	0.2	-0.1	0.00	15,177.8	0.03
04/26/2013 04:55	140	0.2	-0.1	0.00	15,155.6	0.03
04/26/2013 04:56	140	0.2	-0.2	0.00	15,155.6	0.03
04/26/2013 04:57	140	0.2	-0.2	0.00	15,155.6	0.03
Total				21.25		11.93

Date/Time Startup Commences: 04/27/2013 07: 11
 Gas Turbine Downtime: 8 Hours
 Steam Turbine Downtime: 8 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
04/27/2013 07: 11	0	0.0	0.0	0.00	844.4	0.00
04/27/2013 07: 12	0	0.0	0.0	0.00	844.4	0.00
04/27/2013 07: 13	0	5.9	16.5	0.11	1,755.6	0.07
04/27/2013 07: 14	0	2.2	28.6	0.28	2,533.3	0.03
04/27/2013 07: 15	0	2.8	107.1	1.41	3,422.2	0.06
04/27/2013 07: 16	0	4.0	316.1	5.03	4,133.3	0.11
04/27/2013 07: 17	0	7.0	611.9	10.94	4,644.4	0.21
04/27/2013 07: 18	0	11.8	810.3	15.88	5,088.9	0.38
04/27/2013 07: 19	0	16.9	1,079.1	21.60	5,200.0	0.55
04/27/2013 07: 20	0	20.5	1,292.7	25.77	5,177.8	0.68
04/27/2013 07: 21	5	21.8	1,191.0	24.05	5,244.4	0.72
04/27/2013 07: 22	15	24.4	951.6	21.49	5,866.7	0.91
04/27/2013 07: 23	29	27.2	466.4	12.21	6,800.0	1.17
04/27/2013 07: 24	42	30.0	139.5	4.20	7,822.2	1.49
04/27/2013 07: 25	55	35.6	41.4	1.39	8,688.9	1.96
04/27/2013 07: 26	68	29.9	6.3	0.24	9,844.4	1.86
04/27/2013 07: 27	81	30.1	2.0	0.07	10,844.4	2.07
04/27/2013 07: 28	96	33.0	1.1	0.04	12,000.0	2.52
04/27/2013 07: 29	109	30.8	0.8	0.04	12,977.8	2.52
04/27/2013 07: 30	117	25.3	0.6	0.02	13,377.8	2.14
04/27/2013 07: 31	125	21.4	0.5	0.02	13,933.3	1.89
04/27/2013 07: 32	135	12.8	0.5	0.03	14,511.1	1.17
04/27/2013 07: 33	141	12.8	0.5	0.03	14,800.0	1.20
04/27/2013 07: 34	140	2.6	0.4	0.03	14,777.8	0.23
04/27/2013 07: 35	140	1.6	0.5	0.03	14,755.6	0.15
04/27/2013 07: 36	140	1.4	0.4	0.03	14,755.6	0.13
04/27/2013 07: 37	140	1.0	0.2	0.03	14,777.8	0.10
04/27/2013 07: 38	140	0.6	0.1	0.00	14,800.0	0.05
04/27/2013 07: 39	140	0.5	0.0	0.00	14,800.0	0.05
04/27/2013 07: 40	140	0.3	0.0	0.00	14,800.0	0.03
04/27/2013 07: 41	35	0.3	-0.1	0.00	3,711.1	0.01
Total				144.97		24.46

Date/Time Startup Commences: 04/27/2013 09: 46
 Gas Turbine Downtime: 2 Hours
 Steam Turbine Downtime: 2 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
04/27/2013 09: 46	0	0.0	0.0	0.00	666.7	0.00
04/27/2013 09: 47	0	0.0	0.0	0.00	200.0	0.00
04/27/2013 09: 48	0	0.0	-5.9	0.00	1,444.4	0.00
04/27/2013 09: 49	0	0.7	24.3	0.20	2,200.0	0.01
04/27/2013 09: 50	0	1.8	38.5	0.44	2,955.6	0.04
04/27/2013 09: 51	0	2.5	47.4	0.70	3,844.4	0.06
04/27/2013 09: 52	0	4.8	66.8	1.13	4,377.8	0.14
04/27/2013 09: 53	0	8.1	92.9	1.79	5,000.0	0.26
04/27/2013 09: 54	0	11.8	103.7	2.07	5,177.8	0.38
04/27/2013 09: 55	0	15.5	118.6	2.35	5,133.3	0.50
04/27/2013 09: 56	2	17.1	120.6	2.40	5,177.8	0.56
04/27/2013 09: 57	12	20.5	116.4	2.49	5,555.6	0.72
04/27/2013 09: 58	25	23.1	101.4	2.53	6,466.7	0.95
04/27/2013 09: 59	38	28.1	61.2	1.76	7,488.9	1.33
04/27/2013 10: 00	51	32.9	34.7	1.13	8,422.2	1.75
04/27/2013 10: 01	65	31.7	7.5	0.28	9,555.6	1.92
04/27/2013 10: 02	78	17.7	3.3	0.13	10,622.2	1.19
04/27/2013 10: 03	92	14.7	0.6	0.02	11,666.7	1.08
04/27/2013 10: 04	101	10.5	0.4	0.02	12,111.1	0.81
04/27/2013 10: 05	101	10.5	0.4	0.02	11,955.6	0.80
04/27/2013 10: 06	100	3.5	1.3	0.06	11,888.9	0.27
04/27/2013 10: 07	101	1.6	3.0	0.14	11,911.1	0.12
04/27/2013 10: 08	100	0.7	0.9	0.04	11,911.1	0.06
04/27/2013 10: 09	100	0.6	0.9	0.04	11,888.9	0.04
04/27/2013 10: 10	99	0.4	0.7	0.04	11,977.8	0.04
04/27/2013 10: 11	100	0.4	0.5	0.02	12,088.9	0.02
04/27/2013 10: 12	100	0.3	0.1	0.00	12,111.1	0.02
04/27/2013 10: 13	100	0.3	0.0	0.00	12,177.8	0.02
04/27/2013 10: 14	100	0.2	-0.1	0.00	12,177.8	0.02
04/27/2013 10: 15	101	0.2	-0.1	0.00	12,244.4	0.02
04/27/2013 10: 16	106	0.2	-0.2	0.00	12,600.0	0.02
04/27/2013 10: 17	111	0.2	-0.2	0.00	12,955.6	0.02
Total				19.8		13.17

Date/Time Startup Commences: 04/28/2013 08:41
 Gas Turbine Downtime: 10 Hours
 Steam Turbine Downtime: 10 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
04/28/2013 08:41	0	0.0	0.0	0.00	866.7	0.00
04/28/2013 08:42	0	0.0	0.0	0.00	111.1	0.00
04/28/2013 08:43	0	0.0	0.0	0.00	1,422.2	0.00
04/28/2013 08:44	0	3.4	22.3	0.19	2,177.8	0.05
04/28/2013 08:45	0	2.4	90.6	1.03	2,955.6	0.05
04/28/2013 08:46	0	3.6	316.1	4.74	3,888.9	0.09
04/28/2013 08:47	0	6.3	817.4	13.92	4,422.2	0.18
04/28/2013 08:48	0	10.9	1,317.4	26.15	5,155.6	0.35
04/28/2013 08:49	0	16.6	1,572.6	31.22	5,155.6	0.54
04/28/2013 08:50	0	23.0	2,137.1	42.24	5,133.3	0.75
04/28/2013 08:51	3	23.6	2,123.6	42.70	5,222.2	0.78
04/28/2013 08:52	15	26.7	1,977.3	43.82	5,755.6	0.98
04/28/2013 08:53	28	30.8	1,117.5	28.97	6,733.3	1.32
04/28/2013 08:54	41	32.1	318.5	9.46	7,711.1	1.57
04/28/2013 08:55	54	36.6	72.8	2.42	8,644.4	2.01
04/28/2013 08:56	68	30.5	6.3	0.24	9,844.4	1.90
04/28/2013 08:57	81	30.1	2.0	0.09	10,844.4	2.07
04/28/2013 08:58	95	31.3	1.1	0.06	11,955.6	2.36
04/28/2013 08:59	110	26.8	0.7	0.04	12,844.4	2.19
04/28/2013 09:00	122	21.5	0.5	0.02	13,711.1	1.86
04/28/2013 09:01	130	19.0	0.4	0.02	14,200.0	1.71
04/28/2013 09:02	137	16.9	0.4	0.03	14,688.9	1.57
04/28/2013 09:03	140	15.5	0.4	0.03	14,844.4	1.46
04/28/2013 09:04	140	10.2	0.4	0.03	14,755.6	0.94
04/28/2013 09:05	140	3.3	0.4	0.03	14,777.8	0.31
04/28/2013 09:06	140	2.4	0.5	0.03	14,822.2	0.23
04/28/2013 09:07	140	1.8	0.3	0.03	14,822.2	0.18
04/28/2013 09:08	140	1.6	0.2	0.00	14,800.0	0.15
04/28/2013 09:09	140	1.0	0.0	0.00	14,822.2	0.10
04/28/2013 09:10	140	0.8	0.0	0.00	14,844.4	0.08
04/28/2013 09:11	140	0.7	0.0	0.00	14,844.4	0.08
04/28/2013 09:12	140	0.6	0.0	0.00	14,844.4	0.05
04/28/2013 09:13	140	0.5	0.0	0.00	14,822.2	0.05
04/28/2013 09:14	140	0.4	-0.1	0.00	14,844.4	0.05
04/28/2013 09:15	140	0.3	-0.1	0.00	14,822.2	0.03
04/28/2013 09:16	140	0.3	-0.1	0.00	14,844.4	0.03
04/28/2013 09:17	140	0.3	-0.1	0.00	14,844.4	0.03
Total				247.51		26.1

Date/Time Startup Commences: 04/29/2013 05:26
 Gas Turbine Downtime: 6 Hours
 Steam Turbine Downtime: 6 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
04/29/2013 05:26	0	0.0	0.0	0.00	777.8	0.00
04/29/2013 05:27	0	0.0	0.0	0.00	711.1	0.00
04/29/2013 05:28	0	2.0	15.7	0.10	1,688.9	0.02
04/29/2013 05:29	0	0.9	26.7	0.25	2,466.7	0.01
04/29/2013 05:30	0	1.5	46.2	0.58	3,288.9	0.03
04/29/2013 05:31	0	2.1	57.9	0.90	4,044.4	0.06
04/29/2013 05:32	0	4.2	98.3	1.72	4,533.3	0.12
04/29/2013 05:33	0	6.8	138.3	2.88	5,400.0	0.23
04/29/2013 05:34	0	10.5	185.2	3.68	5,155.6	0.35
04/29/2013 05:35	0	13.2	239.9	4.74	5,133.3	0.43
04/29/2013 05:36	3	15.3	220.3	4.41	5,200.0	0.50
04/29/2013 05:37	14	16.9	188.4	4.11	5,666.7	0.60
04/29/2013 05:38	26	20.7	135.9	3.40	6,511.1	0.85
04/29/2013 05:39	37	24.8	77.4	2.18	7,333.3	1.15
04/29/2013 05:40	49	29.3	45.6	1.45	8,244.4	1.53
04/29/2013 05:41	61	31.3	23.3	0.81	9,066.7	1.79
04/29/2013 05:42	72	18.2	4.5	0.17	10,044.4	1.16
04/29/2013 05:43	83	14.4	1.8	0.07	10,844.4	0.99
04/29/2013 05:44	95	11.2	1.4	0.06	11,755.6	0.83
04/29/2013 05:45	107	9.0	0.8	0.04	12,600.0	0.72
04/29/2013 05:46	119	4.9	0.5	0.02	13,311.1	0.41
04/29/2013 05:47	130	1.8	0.4	0.02	14,088.9	0.17
04/29/2013 05:48	139	0.9	0.3	0.03	14,688.9	0.08
04/29/2013 05:49	140	0.8	0.3	0.03	14,711.1	0.08
04/29/2013 05:50	140	0.6	0.2	0.00	14,688.9	0.05
04/29/2013 05:51	140	0.3	0.2	0.00	14,755.6	0.03
04/29/2013 05:52	140	0.2	0.1	0.00	14,755.6	0.03
04/29/2013 05:53	140	0.2	0.0	0.00	14,777.8	0.03
04/29/2013 05:54	140	0.2	-0.1	0.00	14,755.6	0.03
04/29/2013 05:55	140	0.2	-0.1	0.00	14,755.6	0.03
04/29/2013 05:56	140	0.2	-0.2	0.00	14,800.0	0.03
04/29/2013 05:57	140	0.2	-0.2	0.00	14,755.6	0.03
Total				31.65		12.37

Date/Time Startup Commences: 04/30/2013 04: 41
 Gas Turbine Downtime: 6 Hours
 Steam Turbine Downtime: 6 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
04/30/2013 04: 41	0	0.0	0.0	0.00	800.0	0.00
04/30/2013 04: 42	0	0.0	0.0	0.00	955.6	0.00
04/30/2013 04: 43	0	1.0	18.7	0.13	1,800.0	0.01
04/30/2013 04: 44	0	0.9	27.7	0.27	2,577.8	0.01
04/30/2013 04: 45	0	2.3	45.4	0.61	3,488.9	0.05
04/30/2013 04: 46	0	2.7	60.7	0.97	4,155.6	0.07
04/30/2013 04: 47	0	4.8	92.0	1.63	4,600.0	0.14
04/30/2013 04: 48	0	7.6	117.6	2.64	5,844.4	0.28
04/30/2013 04: 49	0	11.0	140.5	2.77	5,111.1	0.35
04/30/2013 04: 50	0	13.6	167.0	3.27	5,088.9	0.44
04/30/2013 04: 51	6	15.5	161.9	3.30	5,288.9	0.52
04/30/2013 04: 52	19	19.6	140.5	3.19	5,911.1	0.73
04/30/2013 04: 53	31	21.4	99.0	2.61	6,844.4	0.93
04/30/2013 04: 54	44	25.2	59.8	1.81	7,866.7	1.26
04/30/2013 04: 55	57	32.5	31.2	1.06	8,777.8	1.81
04/30/2013 04: 56	71	21.3	5.1	0.19	9,888.9	1.33
04/30/2013 04: 57	84	16.7	1.5	0.06	10,933.3	1.15
04/30/2013 04: 58	98	13.2	0.9	0.04	12,022.2	1.01
04/30/2013 04: 59	111	9.9	0.7	0.04	12,955.6	0.80
04/30/2013 05: 00	118	8.1	0.4	0.02	13,400.0	0.69
04/30/2013 05: 01	128	3.1	0.4	0.02	14,000.0	0.26
04/30/2013 05: 02	139	1.1	0.3	0.03	14,688.9	0.10
04/30/2013 05: 03	140	0.7	0.3	0.03	14,733.3	0.08
04/30/2013 05: 04	140	0.5	0.2	0.03	14,644.4	0.05
04/30/2013 05: 05	140	0.3	0.3	0.03	14,711.1	0.03
04/30/2013 05: 06	140	0.3	0.3	0.03	14,711.1	0.03
04/30/2013 05: 07	140	0.2	0.1	0.00	14,733.3	0.03
04/30/2013 05: 08	140	0.2	-0.1	0.00	14,733.3	0.03
04/30/2013 05: 09	140	0.2	-0.1	0.00	14,733.3	0.03
04/30/2013 05: 10	140	0.2	-0.1	0.00	14,755.6	0.03
04/30/2013 05: 11	140	0.1	-0.1	0.00	14,755.6	0.00
Total				24.78		12.25

Date/Time Startup Commences: 05/01/2013 04: 41
 Gas Turbine Downtime: 6 Hours
 Steam Turbine Downtime: 6 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
05/01/2013 04: 41	0	0.0	0.0	0.00	1,022.2	0.00
05/01/2013 04: 42	0	0.0	0.0	0.00	511.1	0.00
05/01/2013 04: 43	0	23.6	0.0	0.00	1,577.8	0.24
05/01/2013 04: 44	0	2.8	26.7	0.24	2,355.6	0.04
05/01/2013 04: 45	0	3.3	53.4	0.65	3,177.8	0.07
05/01/2013 04: 46	0	4.4	113.8	1.74	3,977.8	0.11
05/01/2013 04: 47	0	7.0	279.5	4.80	4,466.7	0.20
05/01/2013 04: 48	0	11.3	444.3	8.40	4,911.1	0.35
05/01/2013 04: 49	0	17.7	642.9	12.69	5,133.3	0.57
05/01/2013 04: 50	0	23.0	929.9	18.29	5,111.1	0.75
05/01/2013 04: 51	3	24.0	805.2	15.84	5,111.1	0.77
05/01/2013 04: 52	10	25.8	667.9	13.76	5,355.6	0.87
05/01/2013 04: 53	21	28.5	519.4	12.26	6,133.3	1.11
05/01/2013 04: 54	33	32.6	234.2	6.18	6,866.7	1.42
05/01/2013 04: 55	45	34.4	104.8	3.14	7,777.8	1.70
05/01/2013 04: 56	59	39.6	51.7	1.75	8,777.8	2.20
05/01/2013 04: 57	73	27.7	26.0	0.98	9,800.0	1.72
05/01/2013 04: 58	85	22.1	5.0	0.20	10,733.3	1.49
05/01/2013 04: 59	99	16.4	2.0	0.10	11,755.6	1.23
05/01/2013 05: 00	112	11.2	1.5	0.07	12,777.8	0.90
05/01/2013 05: 01	126	9.1	1.1	0.07	13,777.8	0.78
05/01/2013 05: 02	137	3.6	0.8	0.05	14,488.9	0.32
05/01/2013 05: 03	138	1.4	0.6	0.03	14,622.2	0.13
05/01/2013 05: 04	139	0.8	0.5	0.03	14,733.3	0.08
05/01/2013 05: 05	140	0.4	0.5	0.03	14,711.1	0.05
05/01/2013 05: 06	140	0.4	0.3	0.03	14,711.1	0.05
05/01/2013 05: 07	140	0.3	0.2	0.00	14,711.1	0.03
05/01/2013 05: 08	140	0.3	0.1	0.00	14,733.3	0.03
05/01/2013 05: 09	140	0.2	0.0	0.00	14,733.3	0.03
05/01/2013 05: 10	140	0.2	0.0	0.00	14,755.6	0.03
05/01/2013 05: 11	140	0.2	-0.1	0.00	14,755.6	0.03
05/01/2013 05: 12	140	0.2	-0.1	0.00	14,777.8	0.03
05/01/2013 05: 13	140	0.2	-0.1	0.00	14,777.8	0.03
Total				101.33		17.36

Date/Time Startup Commences: 05/02/2013 04: 41
 Gas Turbine Downtime: 5 Hours
 Steam Turbine Downtime: 5 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
05/02/2013 04: 41	0	0.0	0.0	0.00	777.8	0.00
05/02/2013 04: 42	0	0.0	0.0	0.00	644.4	0.00
05/02/2013 04: 43	0	13.8	17.7	0.11	1,666.7	0.15
05/02/2013 04: 44	0	3.0	30.2	0.28	2,422.2	0.05
05/02/2013 04: 45	0	3.9	899.3	11.38	3,288.9	0.08
05/02/2013 04: 46	0	6.1	1,708.2	26.72	4,066.7	0.16
05/02/2013 04: 47	0	12.0	2,084.2	36.52	4,555.6	0.34
05/02/2013 04: 48	0	22.7	2,446.9	54.17	5,755.6	0.83
05/02/2013 04: 49	0	24.9	2,554.0	50.64	5,155.6	0.82
05/02/2013 04: 50	0	28.9	2,801.7	55.31	5,133.3	0.94
05/02/2013 04: 51	5	29.7	2,867.4	71.33	6,466.7	1.21
05/02/2013 04: 52	18	33.0	2,740.7	61.85	5,866.7	1.22
05/02/2013 04: 53	31	37.8	1,991.3	52.42	6,844.4	1.63
05/02/2013 04: 54	45	37.8	681.8	20.51	7,822.2	1.87
05/02/2013 04: 55	57	40.1	140.0	4.70	8,733.3	2.22
05/02/2013 04: 56	71	30.7	27.7	1.04	9,777.8	1.90
05/02/2013 04: 57	84	30.3	5.0	0.20	10,733.3	2.07
05/02/2013 04: 58	98	30.3	2.5	0.12	11,755.6	2.26
05/02/2013 04: 59	112	26.1	1.9	0.09	12,800.0	2.11
05/02/2013 05: 00	125	22.5	1.2	0.07	13,733.3	1.96
05/02/2013 05: 01	137	18.3	0.9	0.05	14,511.1	1.67
05/02/2013 05: 02	139	16.3	0.9	0.05	14,688.9	1.51
05/02/2013 05: 03	139	16.0	0.9	0.05	14,777.8	1.50
05/02/2013 05: 04	140	12.1	0.8	0.05	14,755.6	1.14
05/02/2013 05: 05	140	6.1	0.6	0.03	14,733.3	0.56
05/02/2013 05: 06	140	3.8	0.4	0.03	14,733.3	0.35
05/02/2013 05: 07	140	2.9	0.3	0.03	14,733.3	0.28
05/02/2013 05: 08	140	2.4	0.2	0.00	14,755.6	0.23
05/02/2013 05: 09	140	1.4	0.1	0.00	14,777.8	0.13
05/02/2013 05: 10	140	1.1	0.0	0.00	14,755.6	0.10
05/02/2013 05: 11	140	0.9	0.0	0.00	14,777.8	0.08
05/02/2013 05: 12	140	0.7	-0.1	0.00	14,777.8	0.05
05/02/2013 05: 13	140	0.5	-0.1	0.00	14,777.8	0.05
05/02/2013 05: 14	140	0.4	-0.1	0.00	14,777.8	0.05
05/02/2013 05: 15	140	0.3	-0.1	0.00	14,777.8	0.03
05/02/2013 05: 16	140	0.3	-0.1	0.00	14,777.8	0.03
05/02/2013 05: 17	140	0.3	-0.2	0.00	14,777.8	0.03
05/02/2013 05: 18	140	0.3	-0.2	0.00	14,777.8	0.03
05/02/2013 05: 19	140	0.4	-0.2	0.00	14,755.6	0.05
Total				447.75		29.69

Date/Time Startup Commences: 05/03/2013 05: 34
 Gas Turbine Downtime: 6 Hours
 Steam Turbine Downtime: 6 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
05/03/2013 05: 34	0	0.0	0.0	0.00	955.6	0.00
05/03/2013 05: 35	0	0.0	0.0	0.00	733.3	0.00
05/03/2013 05: 36	0	4.7	15.3	0.10	1,755.6	0.05
05/03/2013 05: 37	0	1.8	25.7	0.25	2,511.1	0.03
05/03/2013 05: 38	0	2.6	43.2	0.55	3,311.1	0.06
05/03/2013 05: 39	0	3.2	57.1	0.89	4,066.7	0.08
05/03/2013 05: 40	0	5.0	92.9	1.63	4,555.6	0.15
05/03/2013 05: 41	0	8.3	126.5	2.83	5,822.2	0.31
05/03/2013 05: 42	0	12.0	155.5	3.06	5,111.1	0.39
05/03/2013 05: 43	0	15.3	193.3	3.79	5,088.9	0.49
05/03/2013 05: 44	2	17.3	185.7	3.69	5,155.6	0.57
05/03/2013 05: 45	12	20.7	161.5	3.42	5,511.1	0.72
05/03/2013 05: 46	23	22.5	132.7	3.23	6,333.3	0.90
05/03/2013 05: 47	35	26.3	81.7	2.24	7,133.3	1.19
05/03/2013 05: 48	47	30.4	47.1	1.46	8,066.7	1.55
05/03/2013 05: 49	57	38.3	25.9	0.88	8,822.2	2.14
05/03/2013 05: 50	69	22.4	6.0	0.22	9,777.8	1.39
05/03/2013 05: 51	80	18.1	1.7	0.07	10,622.2	1.22
05/03/2013 05: 52	93	14.7	0.8	0.04	11,600.0	1.08
05/03/2013 05: 53	105	10.6	0.7	0.04	12,466.7	0.84
05/03/2013 05: 54	116	8.4	0.6	0.02	13,200.0	0.70
05/03/2013 05: 55	127	2.8	0.5	0.02	13,888.9	0.24
05/03/2013 05: 56	137	1.1	0.4	0.03	14,555.6	0.10
05/03/2013 05: 57	140	0.8	0.4	0.03	14,666.7	0.08
05/03/2013 05: 58	139	0.6	0.3	0.03	14,622.2	0.05
05/03/2013 05: 59	139	0.3	0.3	0.03	14,688.9	0.03
05/03/2013 06: 00	140	0.2	0.2	0.03	14,711.1	0.03
05/03/2013 06: 01	139	0.2	0.1	0.00	14,688.9	0.03
05/03/2013 06: 02	140	0.2	0.0	0.00	14,733.3	0.03
05/03/2013 06: 03	140	0.2	0.0	0.00	14,733.3	0.03
05/03/2013 06: 04	140	0.2	0.0	0.00	14,733.3	0.03
05/03/2013 06: 05	140	0.1	0.0	0.00	14,755.6	0.00
Total				28.58		14.51

Date/Time Startup Commences: 05/26/2013 12: 18
 Gas Turbine Downtime: 541 Hours
 Steam Turbine Downtime: 541 Hours
 Startup Type*: Cold

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
05/26/2013 12: 18	0	0.0	0.0	0.00	444.4	0.00
05/26/2013 12: 19	0	0.0	0.0	0.00	200.0	0.00
05/26/2013 12: 20	0	0.0	0.0	0.00	866.7	0.00
05/26/2013 12: 21	0	0.0	144.6	1.00	1,800.0	0.00
05/26/2013 12: 22	0	3.1	2,781.3	26.39	2,466.7	0.05
05/26/2013 12: 23	0	5.7	2,328.3	25.28	2,822.2	0.10
Total				52.67		0.15

Date/Time Startup Commences: 05/26/2013 12: 47
 Gas Turbine Downtime: 0 Hours
 Steam Turbine Downtime: 0 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
05/26/2013 12: 47	0	0.0	0.0	0.00	911.1	0.00
05/26/2013 12: 48	0	0.0	0.0	0.00	733.3	0.00
05/26/2013 12: 49	0	20.7	70.8	0.47	1,733.3	0.23
05/26/2013 12: 50	0	5.5	2,459.9	23.97	2,533.3	0.09
05/26/2013 12: 51	0	6.4	2,427.5	31.54	3,377.8	0.14
05/26/2013 12: 52	0	7.5	1,940.5	30.69	4,111.1	0.20
05/26/2013 12: 53	0	11.2	1,929.9	5.94	800.0	0.06
Total				92.61		0.72

Date/Time Startup Commences: 05/28/2013 02:43
 Gas Turbine Downtime: 37 Hours
 Steam Turbine Downtime: 37 Hours
 Startup Type*: Warm

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
05/28/2013 02:43	0	0.0	0.0	0.00	311.1	0.00
05/28/2013 02:44	0	0.0	0.0	0.00	400.0	0.00
05/28/2013 02:45	0	0.0	0.0	0.00	1,177.8	0.00
05/28/2013 02:46	0	32.5	126.9	0.92	1,888.9	0.39
05/28/2013 02:47	0	10.2	2,602.7	26.69	2,666.7	0.17
05/28/2013 02:48	0	10.8	2,473.4	34.04	3,577.8	0.25
05/28/2013 02:49	0	11.2	2,021.9	33.18	4,266.7	0.30
05/28/2013 02:50	0	12.8	2,127.7	38.74	4,733.3	0.38
05/28/2013 02:51	0	16.0	2,389.9	46.79	5,088.9	0.52
05/28/2013 02:52	0	21.0	2,543.9	50.22	5,133.3	0.68
05/28/2013 02:53	0	23.8	2,834.6	55.73	5,111.1	0.77
05/28/2013 02:54	0	26.9	2,906.5	56.90	5,088.9	0.87
05/28/2013 02:55	0	28.1	2,935.3	57.20	5,066.7	0.91
05/28/2013 02:56	0	28.9	2,946.7	57.18	5,044.4	0.93
05/28/2013 02:57	0	31.3	2,956.5	47.51	4,177.8	0.83
Total				505.1		7

Date/Time Startup Commences: 05/28/2013 03:52
 Gas Turbine Downtime: 0 Hours
 Steam Turbine Downtime: 0 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
05/28/2013 03:52	0	0.0	0.0	0.00	822.2	0.00
05/28/2013 03:53	0	0.0	0.0	0.00	288.9	0.00
05/28/2013 03:54	0	0.0	0.0	0.00	1,511.1	0.00
05/28/2013 03:55	0	17.7	2,028.1	17.68	2,266.7	0.25
05/28/2013 03:56	0	12.3	2,528.7	29.83	3,066.7	0.24
05/28/2013 03:57	0	13.3	2,078.3	31.26	3,911.1	0.33
05/28/2013 03:58	0	16.6	2,173.9	36.97	4,422.2	0.46
05/28/2013 03:59	0	18.5	2,378.5	44.12	4,822.2	0.56
05/28/2013 04:00	0	23.8	2,542.7	49.99	5,111.1	0.77
05/28/2013 04:01	0	27.9	2,793.1	54.67	5,088.9	0.90
05/28/2013 04:02	1	29.5	2,995.0	57.86	5,022.2	0.94
05/28/2013 04:03	11	30.9	2,962.4	65.33	5,733.3	1.12
05/28/2013 04:04	22	35.0	2,665.4	66.29	6,466.7	1.43
05/28/2013 04:05	34	38.0	1,678.0	46.76	7,244.4	1.74
05/28/2013 04:06	46	37.3	811.3	25.87	8,288.9	1.97
05/28/2013 04:07	57	41.6	239.3	8.31	9,022.2	2.37
05/28/2013 04:08	69	27.5	29.5	1.12	9,888.9	1.72
05/28/2013 04:09	80	25.7	6.7	0.28	10,844.4	1.77
05/28/2013 04:10	92	25.4	4.8	0.22	11,688.9	1.89
05/28/2013 04:11	103	21.5	4.4	0.22	12,511.1	1.70
05/28/2013 04:12	115	17.0	3.5	0.18	13,288.9	1.44
05/28/2013 04:13	127	13.4	2.7	0.14	14,044.4	1.18
05/28/2013 04:14	135	11.5	2.1	0.13	14,600.0	1.05
05/28/2013 04:15	135	10.8	2.0	0.10	14,444.4	0.99
05/28/2013 04:16	134	10.4	2.0	0.10	14,355.6	0.94
05/28/2013 04:17	135	10.7	2.1	0.12	14,422.2	0.97
05/28/2013 04:18	135	11.5	1.9	0.10	14,422.2	1.04
05/28/2013 04:19	137	11.3	1.4	0.08	14,555.6	1.05
05/28/2013 04:20	139	13.0	0.8	0.05	14,822.2	1.22
05/28/2013 04:21	140	14.6	0.6	0.03	14,800.0	1.37
05/28/2013 04:22	140	14.6	0.4	0.03	14,822.2	1.38
05/28/2013 04:23	140	11.2	0.3	0.03	14,844.4	1.05
05/28/2013 04:24	140	0.7	0.2	0.03	14,844.4	0.05
05/28/2013 04:25	131	0.6	0.2	0.02	14,155.6	0.05
05/28/2013 04:26	120	0.7	0.2	0.00	13,244.4	0.05
05/28/2013 04:27	109	1.3	0.1	0.00	12,377.8	0.11
05/28/2013 04:28	98	2.1	0.1	0.00	11,555.6	0.16
05/28/2013 04:29	87	4.0	0.4	0.02	10,688.9	0.28
05/28/2013 04:30	85	1.2	0.9	0.04	10,444.4	0.09
05/28/2013 04:31	95	0.3	1.9	0.08	11,311.1	0.02
05/28/2013 04:32	108	0.3	2.5	0.13	12,288.9	0.02
05/28/2013 04:33	119	0.3	1.7	0.09	13,088.9	0.02
05/28/2013 04:34	130	0.2	0.5	0.02	13,866.7	0.02
05/28/2013 04:35	139	0.2	0.0	0.00	14,511.1	0.03
05/28/2013 04:36	139	0.2	-0.1	0.00	14,577.8	0.03
05/28/2013 04:37	140	0.2	-0.1	0.00	14,577.8	0.03
05/28/2013 04:38	140	0.2	-0.1	0.00	14,600.0	0.03
05/28/2013 04:39	140	0.2	-0.1	0.00	14,644.4	0.03
05/28/2013 04:40	140	0.2	-0.2	0.00	14,577.8	0.03
05/28/2013 04:41	140	0.3	-0.2	0.00	14,600.0	0.03
05/28/2013 04:42	140	0.3	-0.1	0.00	14,600.0	0.03
05/28/2013 04:43	140	0.3	-0.1	0.00	14,600.0	0.03
Total				538.3		34.98

Date/Time Startup Commences: 05/29/2013 03:26
 Gas Turbine Downtime: 5 Hours
 Steam Turbine Downtime: 5 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
05/29/2013 03:26	0	0.0	0.0	0.00	800.0	0.00
05/29/2013 03:27	0	0.0	0.0	0.00	88.9	0.00
05/29/2013 03:28	0	0.0	0.0	0.00	1,377.8	0.00
05/29/2013 03:29	0	2.4	20.7	0.16	2,044.4	0.03
05/29/2013 03:30	0	2.0	41.0	0.44	2,755.6	0.03
05/29/2013 03:31	0	1.7	49.2	0.69	3,666.7	0.04
05/29/2013 03:32	0	3.6	71.2	1.15	4,222.2	0.09
05/29/2013 03:33	0	5.7	105.5	1.90	4,688.9	0.17
05/29/2013 03:34	0	9.2	123.0	2.37	5,022.2	0.29
05/29/2013 03:35	0	12.0	138.7	2.65	4,977.8	0.38
05/29/2013 03:36	1	13.8	146.7	2.83	5,022.2	0.44
05/29/2013 03:37	11	14.9	134.3	2.76	5,333.3	0.50
05/29/2013 03:38	22	19.5	113.2	2.67	6,133.3	0.76
05/29/2013 03:39	33	22.1	77.6	2.06	6,888.9	0.96
05/29/2013 03:40	46	25.8	48.6	1.47	7,844.4	1.28
05/29/2013 03:41	56	33.1	27.5	0.91	8,644.4	1.81
05/29/2013 03:42	67	24.1	6.1	0.23	9,466.7	1.45
05/29/2013 03:43	79	13.6	2.7	0.11	10,400.0	0.89
05/29/2013 03:44	91	11.6	1.8	0.08	11,266.7	0.83
05/29/2013 03:45	103	9.2	1.3	0.06	12,111.1	0.71
05/29/2013 03:46	115	6.5	0.8	0.04	12,911.1	0.53
05/29/2013 03:47	126	3.0	0.6	0.02	13,555.6	0.26
05/29/2013 03:48	136	1.1	0.5	0.02	14,266.7	0.10
05/29/2013 03:49	140	0.8	0.4	0.02	14,444.4	0.07
05/29/2013 03:50	139	0.6	0.3	0.02	14,444.4	0.05
05/29/2013 03:51	140	0.4	0.3	0.03	14,511.1	0.05
05/29/2013 03:52	140	0.2	0.2	0.00	14,488.9	0.02
05/29/2013 03:53	140	0.2	0.1	0.00	14,488.9	0.02
05/29/2013 03:54	140	0.2	0.0	0.00	14,511.1	0.03
05/29/2013 03:55	140	0.2	0.0	0.00	14,511.1	0.03
05/29/2013 03:56	140	0.2	-0.1	0.00	14,511.1	0.03
05/29/2013 03:57	140	0.2	-0.1	0.00	14,533.3	0.03
Total				22.69		11.88

Date/Time Startup Commences: 05/30/2013 03:36
 Gas Turbine Downtime: 4 Hours
 Steam Turbine Downtime: 4 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
05/30/2013 03:36	0	0.0	0.0	0.00	1,000.0	0.00
05/30/2013 03:37	0	0.0	0.0	0.00	88.9	0.00
05/30/2013 03:38	0	0.0	0.0	0.00	1,444.4	0.00
05/30/2013 03:39	0	3.2	22.2	0.19	2,155.6	0.04
05/30/2013 03:40	0	2.7	43.7	0.49	2,911.1	0.05
05/30/2013 03:41	0	3.5	44.6	0.64	3,733.3	0.08
05/30/2013 03:42	0	5.0	60.1	0.99	4,266.7	0.14
05/30/2013 03:43	0	7.0	80.2	1.73	5,577.8	0.25
05/30/2013 03:44	0	10.3	91.2	1.77	5,044.4	0.33
05/30/2013 03:45	0	13.9	110.6	2.13	5,000.0	0.44
05/30/2013 03:46	4	15.7	116.2	2.30	5,155.6	0.51
05/30/2013 03:47	15	20.3	113.1	2.51	5,777.8	0.74
05/30/2013 03:48	26	22.9	92.5	2.32	6,511.1	0.94
05/30/2013 03:49	38	26.9	61.2	1.72	7,288.9	1.24
05/30/2013 03:50	50	31.5	37.4	1.19	8,244.4	1.64
05/30/2013 03:51	61	38.0	20.2	0.70	9,022.2	2.17
05/30/2013 03:52	72	19.3	4.8	0.19	9,933.3	1.21
05/30/2013 03:53	83	12.8	1.8	0.07	10,755.6	0.87
05/30/2013 03:54	95	10.5	1.3	0.06	11,644.4	0.78
05/30/2013 03:55	106	8.8	0.9	0.04	12,444.4	0.68
05/30/2013 03:56	119	5.8	0.6	0.02	13,311.1	0.48
05/30/2013 03:57	131	2.2	0.4	0.02	14,022.2	0.19
05/30/2013 03:58	139	0.7	0.3	0.02	14,422.2	0.07
05/30/2013 03:59	140	0.6	0.2	0.02	14,488.9	0.05
05/30/2013 04:00	139	0.5	0.2	0.00	14,511.1	0.05
05/30/2013 04:01	140	0.3	0.1	0.00	14,688.9	0.03
05/30/2013 04:02	140	0.2	0.0	0.00	14,466.7	0.02
05/30/2013 04:03	140	0.2	0.0	0.00	14,622.2	0.03
05/30/2013 04:04	140	0.2	-0.1	0.00	14,755.6	0.03
05/30/2013 04:05	139	0.2	-0.1	0.00	14,488.9	0.02
05/30/2013 04:06	141	0.2	-0.1	0.00	14,711.1	0.03
05/30/2013 04:07	140	0.2	-0.1	0.00	14,555.6	0.03
Total				19.12		13.14

Date/Time Startup Commences: 05/31/2013 03:30
 Gas Turbine Downtime: 5 Hours
 Steam Turbine Downtime: 5 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
05/31/2013 03:30	0	0.0	0.0	0.00	644.4	0.00
05/31/2013 03:31	0	0.0	0.0	0.00	200.0	0.00
05/31/2013 03:32	0	0.0	0.0	0.00	1,444.4	0.00
05/31/2013 03:33	0	0.5	23.1	0.20	2,200.0	0.01
05/31/2013 03:34	0	0.8	43.7	0.49	2,911.1	0.02
05/31/2013 03:35	0	1.1	46.5	0.67	3,755.6	0.03
05/31/2013 03:36	0	2.8	61.8	1.02	4,311.1	0.07
05/31/2013 03:37	0	4.4	82.8	1.55	4,888.9	0.13
05/31/2013 03:38	0	7.0	94.8	1.85	5,066.7	0.23
05/31/2013 03:39	1	9.4	113.5	2.21	5,066.7	0.30
05/31/2013 03:40	6	11.0	123.7	2.44	5,133.3	0.35
05/31/2013 03:41	17	13.9	115.0	2.56	5,800.0	0.51
05/31/2013 03:42	28	18.8	88.2	2.22	6,555.6	0.78
05/31/2013 03:43	39	22.3	59.1	1.67	7,355.6	1.04
05/31/2013 03:44	52	28.5	38.5	1.23	8,333.3	1.50
05/31/2013 03:45	62	31.9	5.4	0.19	9,111.1	1.85
05/31/2013 03:46	74	15.3	4.6	0.17	10,000.0	0.96
05/31/2013 03:47	84	11.1	2.1	0.09	10,844.4	0.76
05/31/2013 03:48	97	9.7	1.5	0.06	11,688.9	0.72
05/31/2013 03:49	109	7.0	0.9	0.04	12,622.2	0.56
05/31/2013 03:50	120	4.6	0.6	0.02	13,311.1	0.39
05/31/2013 03:51	132	1.5	0.4	0.02	14,000.0	0.14
05/31/2013 03:52	139	0.7	0.3	0.02	14,466.7	0.07
05/31/2013 03:53	139	0.7	0.2	0.02	14,422.2	0.05
05/31/2013 03:54	139	0.4	0.2	0.00	14,511.1	0.05
05/31/2013 03:55	140	0.3	0.1	0.00	14,511.1	0.03
05/31/2013 03:56	140	0.2	0.0	0.00	14,466.7	0.02
05/31/2013 03:57	139	0.2	0.0	0.00	14,488.9	0.02
05/31/2013 03:58	140	0.2	-0.1	0.00	14,511.1	0.03
05/31/2013 03:59	140	0.2	-0.1	0.00	14,533.3	0.03
05/31/2013 04:00	140	0.2	-0.1	0.00	14,511.1	0.03
05/31/2013 04:01	140	0.3	-0.1	0.00	14,533.3	0.03
Total				18.74		10.71

Date/Time Startup Commences: 06/01/2013 07: 32
 Gas Turbine Downtime: 8 Hours
 Steam Turbine Downtime: 8 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
06/01/2013 07: 32	0	0.0	0.0	0.00	888.9	0.00
06/01/2013 07: 33	0	0.0	0.0	0.00	111.1	0.00
06/01/2013 07: 34	0	0.0	0.0	0.00	1,377.8	0.00
06/01/2013 07: 35	0	4.3	22.5	0.18	2,088.9	0.06
06/01/2013 07: 36	0	2.4	42.4	0.46	2,800.0	0.04
06/01/2013 07: 37	0	3.4	57.9	0.82	3,666.7	0.08
06/01/2013 07: 38	0	5.1	132.5	2.14	4,200.0	0.14
06/01/2013 07: 39	0	7.4	233.5	4.19	4,666.7	0.22
06/01/2013 07: 40	0	11.4	273.1	5.23	4,977.8	0.36
06/01/2013 07: 41	0	15.1	347.5	6.62	4,955.6	0.47
06/01/2013 07: 42	4	17.1	342.4	6.64	5,044.4	0.55
06/01/2013 07: 43	14	21.0	286.0	6.04	5,488.9	0.74
06/01/2013 07: 44	25	22.2	180.8	4.39	6,311.1	0.89
06/01/2013 07: 45	37	26.3	82.3	2.25	7,111.1	1.19
06/01/2013 07: 46	49	29.4	47.6	1.48	8,133.3	1.51
06/01/2013 07: 47	60	34.0	4.5	0.15	8,911.1	1.91
06/01/2013 07: 48	72	24.5	4.4	0.17	9,800.0	1.52
06/01/2013 07: 49	83	19.2	1.6	0.07	10,622.2	1.30
06/01/2013 07: 50	94	12.7	1.2	0.06	11,400.0	0.92
06/01/2013 07: 51	106	9.7	1.0	0.04	12,244.4	0.76
06/01/2013 07: 52	118	5.3	0.7	0.04	13,022.2	0.43
06/01/2013 07: 53	129	2.8	0.6	0.02	13,777.8	0.24
06/01/2013 07: 54	138	1.3	0.5	0.02	14,422.2	0.12
06/01/2013 07: 55	139	0.7	0.4	0.02	14,488.9	0.05
06/01/2013 07: 56	139	0.5	0.3	0.02	14,488.9	0.05
06/01/2013 07: 57	139	0.4	0.2	0.00	14,511.1	0.05
06/01/2013 07: 58	140	0.3	0.1	0.00	14,511.1	0.03
06/01/2013 07: 59	140	0.2	0.0	0.00	14,533.3	0.03
06/01/2013 08: 00	140	0.2	0.0	0.00	14,533.3	0.03
06/01/2013 08: 01	140	0.2	-0.1	0.00	14,511.1	0.03
06/01/2013 08: 02	140	0.2	-0.1	0.00	14,511.1	0.03
06/01/2013 08: 03	140	0.2	-0.1	0.00	14,533.3	0.03
06/01/2013 08: 04	140	0.2	-0.1	0.00	14,533.3	0.03
Total				41.05		13.81

Date/Time Startup Commences: 06/02/2013 10:12
 Gas Turbine Downtime: 12 Hours
 Steam Turbine Downtime: 12 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
06/02/2013 10:12	0	0.0	0.0	0.00	1,044.4	0.00
06/02/2013 10:13	0	0.0	0.0	0.00	511.1	0.00
06/02/2013 10:14	0	0.0	0.0	0.00	1,622.2	0.00
06/02/2013 10:15	0	4.4	24.3	0.22	2,333.3	0.06
06/02/2013 10:16	0	4.0	217.4	2.59	3,088.9	0.08
06/02/2013 10:17	0	5.3	710.4	10.50	3,844.4	0.13
06/02/2013 10:18	0	9.6	1,312.2	21.87	4,333.3	0.26
06/02/2013 10:19	0	15.8	1,730.6	31.81	4,777.8	0.48
06/02/2013 10:20	0	23.4	2,407.4	45.07	4,866.7	0.72
06/02/2013 10:21	4	27.1	2,970.3	56.62	4,955.6	0.85
06/02/2013 10:22	13	29.9	2,992.3	62.15	5,400.0	1.02
06/02/2013 10:23	25	35.6	2,466.8	58.62	6,177.8	1.39
06/02/2013 10:24	36	37.1	1,157.3	31.17	7,000.0	1.65
06/02/2013 10:25	49	38.0	376.4	11.46	7,911.1	1.90
06/02/2013 10:26	60	40.1	86.0	2.87	8,666.7	2.20
06/02/2013 10:27	71	27.0	27.6	1.02	9,533.3	1.64
06/02/2013 10:28	82	28.6	7.7	0.30	10,377.8	1.87
06/02/2013 10:29	93	27.8	6.1	0.27	11,200.0	1.96
06/02/2013 10:30	106	25.7	3.7	0.17	12,200.0	1.99
06/02/2013 10:31	118	23.2	1.8	0.09	13,022.2	1.90
06/02/2013 10:32	129	18.1	1.0	0.05	13,822.2	1.59
06/02/2013 10:33	137	17.4	0.8	0.05	14,400.0	1.58
06/02/2013 10:34	138	13.0	0.8	0.05	14,377.8	1.19
06/02/2013 10:35	138	8.9	0.7	0.05	14,400.0	0.82
06/02/2013 10:36	138	3.8	0.7	0.02	14,400.0	0.35
06/02/2013 10:37	136	2.4	0.5	0.02	14,266.7	0.22
06/02/2013 10:38	135	1.8	0.3	0.02	14,244.4	0.17
06/02/2013 10:39	135	1.2	0.2	0.00	14,222.2	0.12
06/02/2013 10:40	135	0.9	0.1	0.00	14,222.2	0.07
06/02/2013 10:41	135	0.8	0.0	0.00	14,222.2	0.07
06/02/2013 10:42	135	0.7	0.0	0.00	14,244.4	0.05
06/02/2013 10:43	135	0.5	0.0	0.00	14,244.4	0.05
06/02/2013 10:44	135	0.4	-0.1	0.00	14,222.2	0.05
06/02/2013 10:45	135	0.3	-0.1	0.00	14,222.2	0.02
06/02/2013 10:46	135	0.3	-0.1	0.00	14,222.2	0.02
06/02/2013 10:47	135	0.3	-0.1	0.00	14,222.2	0.02
06/02/2013 10:48	135	0.3	-0.1	0.00	14,222.2	0.02
06/02/2013 10:49	135	0.3	-0.1	0.00	14,222.2	0.02
Total				337.06		26.53

Date/Time Startup Commences: 06/03/2013 04: 31
 Gas Turbine Downtime: 5 Hours
 Steam Turbine Downtime: 5 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
06/03/2013 04: 31	0	0.0	0.0	0.00	444.4	0.00
06/03/2013 04: 32	0	0.0	0.0	0.00	355.6	0.00
06/03/2013 04: 33	0	0.0	0.0	0.00	1,222.2	0.00
06/03/2013 04: 34	0	0.8	21.9	0.16	1,911.1	0.01
06/03/2013 04: 35	0	1.1	29.5	0.30	2,666.7	0.02
06/03/2013 04: 36	0	2.5	43.6	0.60	3,555.6	0.06
06/03/2013 04: 37	0	3.0	55.4	0.88	4,133.3	0.08
06/03/2013 04: 38	0	4.6	83.7	1.69	5,244.4	0.15
06/03/2013 04: 39	0	7.2	102.0	1.95	4,977.8	0.23
06/03/2013 04: 40	0	9.7	117.6	2.24	4,955.6	0.31
06/03/2013 04: 41	1	11.4	128.8	2.46	4,977.8	0.36
06/03/2013 04: 42	8	13.2	126.3	2.52	5,177.8	0.44
06/03/2013 04: 43	20	18.1	109.9	2.52	5,955.6	0.69
06/03/2013 04: 44	31	19.5	81.0	2.10	6,755.6	0.84
06/03/2013 04: 45	42	22.8	51.4	1.50	7,600.0	1.10
06/03/2013 04: 46	54	28.9	30.4	0.98	8,422.2	1.55
06/03/2013 04: 47	65	23.6	6.8	0.24	9,266.7	1.39
06/03/2013 04: 48	77	12.8	2.9	0.11	10,200.0	0.82
06/03/2013 04: 49	88	10.5	1.6	0.08	11,111.1	0.74
06/03/2013 04: 50	100	8.9	1.2	0.06	11,911.1	0.68
06/03/2013 04: 51	112	6.2	0.7	0.04	12,755.6	0.50
06/03/2013 04: 52	123	3.4	0.5	0.02	13,444.4	0.28
06/03/2013 04: 53	134	1.2	0.4	0.02	14,133.3	0.12
06/03/2013 04: 54	138	1.0	0.3	0.02	14,266.7	0.10
06/03/2013 04: 55	138	0.7	0.2	0.02	14,288.9	0.05
06/03/2013 04: 56	138	0.4	0.2	0.00	14,333.3	0.05
06/03/2013 04: 57	138	0.3	0.1	0.00	14,311.1	0.02
06/03/2013 04: 58	138	0.2	0.0	0.00	14,311.1	0.02
06/03/2013 04: 59	138	0.2	0.0	0.00	14,333.3	0.02
06/03/2013 05: 00	138	0.2	-0.1	0.00	14,355.6	0.02
06/03/2013 05: 01	138	0.2	-0.1	0.00	14,355.6	0.02
06/03/2013 05: 02	137	0.3	-0.1	0.00	14,311.1	0.02
06/03/2013 05: 03	138	0.3	-0.1	0.00	14,333.3	0.02
Total				20.51		10.71

Date/Time Startup Commences: 06/04/2013 08:13
 Gas Turbine Downtime: 9 Hours
 Steam Turbine Downtime: 9 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
06/04/2013 08:13	0	0.0	0.0	0.00	911.1	0.00
06/04/2013 08:14	0	0.0	0.0	0.00	955.6	0.00
06/04/2013 08:15	0	1.5	25.1	0.18	1,844.4	0.02
06/04/2013 08:16	0	0.9	29.8	0.30	2,577.8	0.01
06/04/2013 08:17	0	1.2	89.4	1.18	3,444.4	0.02
06/04/2013 08:18	0	2.7	266.1	4.19	4,088.9	0.07
06/04/2013 08:19	0	5.5	530.4	9.29	4,555.6	0.16
06/04/2013 08:20	0	10.9	868.6	17.74	5,311.1	0.37
06/04/2013 08:21	0	16.9	1,697.1	32.49	4,977.8	0.53
06/04/2013 08:22	0	20.5	2,005.6	38.22	4,955.6	0.65
06/04/2013 08:23	9	22.0	1,945.6	39.75	5,311.1	0.74
06/04/2013 08:24	20	25.9	1,534.6	35.28	5,977.8	0.98
06/04/2013 08:25	31	28.1	555.4	14.43	6,755.6	1.20
06/04/2013 08:26	43	29.4	140.8	4.14	7,644.4	1.42
06/04/2013 08:27	55	34.4	50.1	1.64	8,533.3	1.86
06/04/2013 08:28	66	28.0	7.8	0.29	9,355.6	1.66
06/04/2013 08:29	77	23.9	3.9	0.16	10,222.2	1.55
06/04/2013 08:30	89	27.2	2.4	0.10	11,088.9	1.91
06/04/2013 08:31	100	26.6	1.6	0.08	11,911.1	2.01
06/04/2013 08:32	113	22.2	1.0	0.04	12,755.6	1.80
06/04/2013 08:33	124	12.3	0.9	0.05	13,422.2	1.04
06/04/2013 08:34	135	6.0	0.8	0.05	14,200.0	0.54
06/04/2013 08:35	139	4.0	0.7	0.05	14,511.1	0.37
06/04/2013 08:36	140	3.1	0.7	0.03	14,511.1	0.27
06/04/2013 08:37	140	2.3	0.5	0.03	14,511.1	0.20
06/04/2013 08:38	140	1.3	0.3	0.02	14,488.9	0.12
06/04/2013 08:39	140	1.1	0.2	0.00	14,488.9	0.10
06/04/2013 08:40	140	0.9	0.1	0.00	14,533.3	0.08
06/04/2013 08:41	140	0.7	0.0	0.00	14,533.3	0.05
06/04/2013 08:42	140	0.5	0.0	0.00	14,533.3	0.05
06/04/2013 08:43	140	0.4	-0.1	0.00	14,555.6	0.05
06/04/2013 08:44	140	0.4	-0.1	0.00	14,533.3	0.05
06/04/2013 08:45	140	0.3	-0.1	0.00	14,533.3	0.03
06/04/2013 08:46	140	0.3	-0.1	0.00	14,555.6	0.03
06/04/2013 08:47	140	0.3	-0.1	0.00	14,555.6	0.03
Total				199.73		19.97

Date/Time Startup Commences: 06/05/2013 10:27
 Gas Turbine Downtime: 13 Hours
 Steam Turbine Downtime: 13 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
06/05/2013 10:27	0	0.0	0.0	0.00	888.9	0.00
06/05/2013 10:28	0	0.0	0.0	0.00	288.9	0.00
06/05/2013 10:29	0	0.0	0.0	0.00	1,511.1	0.00
06/05/2013 10:30	0	3.6	17.2	0.15	2,266.7	0.05
06/05/2013 10:31	0	2.6	1,024.0	12.08	3,066.7	0.05
06/05/2013 10:32	0	4.4	1,673.5	24.75	3,844.4	0.11
06/05/2013 10:33	0	9.3	2,018.4	33.82	4,355.6	0.25
06/05/2013 10:34	0	15.5	2,412.0	45.97	4,955.6	0.49
06/05/2013 10:35	0	22.1	2,578.7	49.81	5,022.2	0.71
06/05/2013 10:36	0	26.1	3,168.7	60.94	5,000.0	0.82
06/05/2013 10:37	5	26.9	3,279.8	65.32	5,177.8	0.88
06/05/2013 10:38	16	30.5	3,209.0	70.21	5,688.9	1.09
06/05/2013 10:39	27	34.6	2,373.3	59.24	6,488.9	1.42
06/05/2013 10:40	38	37.4	1,265.8	35.70	7,333.3	1.74
06/05/2013 10:41	51	39.3	525.0	16.74	8,288.9	2.07
06/05/2013 10:42	62	38.2	90.0	3.12	9,044.4	2.19
06/05/2013 10:43	74	26.1	6.1	0.24	9,977.8	1.65
06/05/2013 10:44	85	27.6	2.7	0.11	10,755.6	1.89
06/05/2013 10:45	96	25.3	2.0	0.08	11,511.1	1.84
06/05/2013 10:46	108	21.7	1.5	0.06	12,377.8	1.70
06/05/2013 10:47	120	18.0	1.2	0.07	13,177.8	1.49
06/05/2013 10:48	131	14.8	1.0	0.05	13,977.8	1.32
06/05/2013 10:49	139	14.2	1.0	0.05	14,533.3	1.30
06/05/2013 10:50	140	14.0	1.0	0.05	14,577.8	1.28
06/05/2013 10:51	140	13.9	0.9	0.05	14,533.3	1.27
06/05/2013 10:52	140	11.5	0.8	0.05	14,533.3	1.05
06/05/2013 10:53	140	5.8	0.6	0.03	14,533.3	0.52
06/05/2013 10:54	140	3.6	0.4	0.03	14,533.3	0.32
06/05/2013 10:55	140	2.5	0.2	0.03	14,555.6	0.23
06/05/2013 10:56	140	2.2	0.2	0.00	14,533.3	0.20
06/05/2013 10:57	140	1.4	0.1	0.00	14,555.6	0.13
06/05/2013 10:58	140	1.1	0.0	0.00	14,533.3	0.10
06/05/2013 10:59	140	0.9	0.0	0.00	14,555.6	0.08
06/05/2013 11:00	140	0.7	0.0	0.00	14,555.6	0.05
06/05/2013 11:01	140	0.5	-0.1	0.00	14,555.6	0.05
06/05/2013 11:02	140	0.3	-0.1	0.00	14,533.3	0.03
06/05/2013 11:03	140	0.2	-0.1	0.00	14,555.6	0.03
06/05/2013 11:04	140	0.2	-0.1	0.00	14,555.6	0.03
06/05/2013 11:05	140	0.2	-0.1	0.00	14,555.6	0.03
06/05/2013 11:06	140	0.3	-0.1	0.00	14,577.8	0.03
06/05/2013 11:07	140	0.3	-0.1	0.00	14,555.6	0.03
Total				478.75		28.52

Date/Time Startup Commences: 06/06/2013 06: 35
 Gas Turbine Downtime: 9 Hours
 Steam Turbine Downtime: 9 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
06/06/2013 06: 35	0	0.0	0.0	0.00	711.1	0.00
06/06/2013 06: 36	0	0.0	0.0	0.00	222.2	0.00
06/06/2013 06: 37	0	0.0	0.0	0.00	1,111.1	0.00
06/06/2013 06: 38	0	3.7	23.6	0.18	2,000.0	0.05
06/06/2013 06: 39	0	1.7	156.8	1.66	2,755.6	0.03
06/06/2013 06: 40	0	2.4	425.2	5.96	3,644.4	0.06
06/06/2013 06: 41	0	4.6	766.6	12.32	4,177.8	0.12
06/06/2013 06: 42	0	9.0	1,121.7	20.13	4,666.7	0.26
06/06/2013 06: 43	0	14.4	1,370.3	26.35	5,000.0	0.46
06/06/2013 06: 44	0	21.5	1,870.9	35.66	4,955.6	0.67
06/06/2013 06: 45	3	21.4	1,939.5	37.46	5,022.2	0.68
06/06/2013 06: 46	12	22.8	1,828.6	38.13	5,422.2	0.78
06/06/2013 06: 47	23	25.7	1,256.7	29.97	6,200.0	1.01
06/06/2013 06: 48	35	27.7	496.7	13.33	6,977.8	1.22
06/06/2013 06: 49	47	28.1	143.8	4.40	7,955.6	1.41
06/06/2013 06: 50	58	33.2	42.2	1.41	8,755.6	1.84
06/06/2013 06: 51	70	22.7	6.6	0.25	9,666.7	1.40
06/06/2013 06: 52	80	23.7	5.2	0.22	10,511.1	1.57
06/06/2013 06: 53	92	26.8	3.4	0.16	11,377.8	1.94
06/06/2013 06: 54	103	25.4	1.6	0.08	12,200.0	1.97
06/06/2013 06: 55	116	22.7	0.9	0.04	13,000.0	1.85
06/06/2013 06: 56	126	18.7	0.8	0.05	13,644.4	1.62
06/06/2013 06: 57	133	14.1	0.8	0.05	14,044.4	1.26
06/06/2013 06: 58	134	9.4	0.8	0.05	14,022.2	0.84
06/06/2013 06: 59	133	3.7	0.8	0.05	14,066.7	0.34
06/06/2013 07: 00	134	2.6	0.7	0.05	14,111.1	0.24
06/06/2013 07: 01	135	1.8	0.5	0.02	14,133.3	0.17
06/06/2013 07: 02	135	1.5	0.2	0.02	14,133.3	0.15
06/06/2013 07: 03	135	1.0	0.2	0.00	14,155.6	0.10
06/06/2013 07: 04	135	0.8	0.1	0.00	14,177.8	0.07
06/06/2013 07: 05	135	0.8	0.0	0.00	14,177.8	0.07
06/06/2013 07: 06	135	0.6	0.0	0.00	14,177.8	0.05
06/06/2013 07: 07	135	0.5	-0.1	0.00	14,200.0	0.05
06/06/2013 07: 08	135	0.4	-0.1	0.00	14,177.8	0.05
06/06/2013 07: 09	135	0.3	-0.1	0.00	14,200.0	0.02
06/06/2013 07: 10	135	0.3	-0.1	0.00	14,177.8	0.02
06/06/2013 07: 11	135	0.3	-0.1	0.00	14,200.0	0.02
06/06/2013 07: 12	135	0.3	-0.1	0.00	14,200.0	0.02
Total				228		22.41

Date/Time Startup Commences: 06/07/2013 07: 31
 Gas Turbine Downtime: 10 Hours
 Steam Turbine Downtime: 10 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
06/07/2013 07: 31	0	0.0	0.0	0.00	266.7	0.00
06/07/2013 07: 32	0	0.0	0.0	0.00	488.9	0.00
06/07/2013 07: 33	0	0.0	0.0	0.00	1,222.2	0.00
06/07/2013 07: 34	0	0.8	25.3	0.19	1,955.6	0.01
06/07/2013 07: 35	0	1.1	166.3	1.73	2,711.1	0.02
06/07/2013 07: 36	0	2.5	472.7	6.51	3,577.8	0.06
06/07/2013 07: 37	0	4.2	838.4	13.33	4,133.3	0.11
06/07/2013 07: 38	0	8.2	1,247.6	22.18	4,622.2	0.24
06/07/2013 07: 39	0	14.0	1,573.3	30.12	4,977.8	0.44
06/07/2013 07: 40	0	21.7	2,179.2	41.54	4,955.6	0.68
06/07/2013 07: 41	0	21.6	2,294.7	43.54	4,933.3	0.67
06/07/2013 07: 42	6	22.0	2,227.8	44.56	5,200.0	0.72
06/07/2013 07: 43	17	24.0	1,829.6	40.03	5,688.9	0.86
06/07/2013 07: 44	28	26.1	904.8	22.66	6,511.1	1.07
06/07/2013 07: 45	40	26.8	293.3	8.33	7,377.8	1.26
06/07/2013 07: 46	52	29.0	75.3	2.41	8,333.3	1.53
06/07/2013 07: 47	63	27.3	3.1	0.11	9,177.8	1.59
06/07/2013 07: 48	74	21.5	5.4	0.21	10,022.2	1.36
06/07/2013 07: 49	86	24.6	3.8	0.17	10,866.7	1.70
06/07/2013 07: 50	97	24.1	2.2	0.10	11,644.4	1.78
06/07/2013 07: 51	110	21.9	1.2	0.06	12,555.6	1.75
06/07/2013 07: 52	121	18.1	0.9	0.05	13,222.2	1.52
06/07/2013 07: 53	124	15.1	0.9	0.05	13,444.4	1.29
06/07/2013 07: 54	125	12.1	0.8	0.05	13,444.4	1.04
06/07/2013 07: 55	125	9.2	0.8	0.05	13,444.4	0.79
06/07/2013 07: 56	125	3.5	0.7	0.05	13,422.2	0.30
06/07/2013 07: 57	125	2.4	0.5	0.02	13,422.2	0.21
06/07/2013 07: 58	125	1.9	0.4	0.02	13,444.4	0.16
06/07/2013 07: 59	125	1.3	0.3	0.02	13,488.9	0.12
06/07/2013 08: 00	125	1.0	0.2	0.00	13,511.1	0.09
06/07/2013 08: 01	125	0.9	0.1	0.00	13,511.1	0.07
06/07/2013 08: 02	125	0.7	0.0	0.00	13,511.1	0.07
06/07/2013 08: 03	125	0.5	0.0	0.00	13,511.1	0.05
06/07/2013 08: 04	125	0.4	-0.1	0.00	13,511.1	0.05
06/07/2013 08: 05	125	0.3	-0.1	0.00	13,511.1	0.02
06/07/2013 08: 06	125	0.3	-0.1	0.00	13,533.3	0.02
06/07/2013 08: 07	125	0.3	-0.1	0.00	13,511.1	0.02
06/07/2013 08: 08	125	0.3	-0.1	0.00	13,511.1	0.02
06/07/2013 08: 09	125	0.3	-0.1	0.00	13,533.3	0.02
Total				278.09		21.71

Date/Time Startup Commences: 06/08/2013 07: 41
 Gas Turbine Downtime: 6 Hours
 Steam Turbine Downtime: 6 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
06/08/2013 07: 41	0	0.0	0.0	0.00	222.2	0.00
06/08/2013 07: 42	0	0.0	0.0	0.00	355.6	0.00
06/08/2013 07: 43	0	0.0	0.0	0.00	1,088.9	0.00
06/08/2013 07: 44	0	1.0	20.7	0.15	1,888.9	0.01
06/08/2013 07: 45	0	0.8	26.2	0.26	2,577.8	0.01
06/08/2013 07: 46	0	1.1	43.8	0.58	3,466.7	0.02
06/08/2013 07: 47	0	2.6	59.0	0.92	4,044.4	0.06
06/08/2013 07: 48	0	3.7	106.8	1.86	4,533.3	0.10
06/08/2013 07: 49	0	6.1	151.0	2.83	4,866.7	0.18
06/08/2013 07: 50	0	8.3	223.0	4.14	4,822.2	0.26
06/08/2013 07: 51	2	9.4	208.1	3.88	4,844.4	0.29
06/08/2013 07: 52	12	10.2	168.7	3.41	5,244.4	0.34
06/08/2013 07: 53	23	13.5	131.5	3.05	6,044.4	0.52
06/08/2013 07: 54	35	16.6	84.2	2.20	6,822.2	0.72
06/08/2013 07: 55	47	16.9	49.7	1.48	7,777.8	0.83
06/08/2013 07: 56	57	21.3	28.9	0.95	8,533.3	1.14
06/08/2013 07: 57	69	12.9	9.4	0.34	9,333.3	0.77
06/08/2013 07: 58	80	9.9	5.6	0.23	10,222.2	0.63
06/08/2013 07: 59	92	6.3	2.4	0.10	11,133.3	0.44
06/08/2013 08: 00	104	4.4	1.8	0.08	12,044.4	0.33
06/08/2013 08: 01	116	3.0	1.1	0.07	12,866.7	0.24
06/08/2013 08: 02	126	1.5	0.7	0.05	13,577.8	0.14
06/08/2013 08: 03	129	1.1	0.4	0.02	13,777.8	0.09
06/08/2013 08: 04	130	0.9	0.3	0.02	13,777.8	0.07
06/08/2013 08: 05	130	0.6	0.2	0.00	13,777.8	0.05
06/08/2013 08: 06	130	0.4	0.1	0.00	13,800.0	0.05
06/08/2013 08: 07	130	0.3	0.0	0.00	13,800.0	0.02
06/08/2013 08: 08	130	0.3	0.0	0.00	13,777.8	0.02
06/08/2013 08: 09	130	0.3	0.0	0.00	13,800.0	0.02
06/08/2013 08: 10	130	0.3	-0.1	0.00	13,822.2	0.02
06/08/2013 08: 11	130	0.3	-0.1	0.00	13,844.4	0.02
06/08/2013 08: 12	130	0.3	-0.1	0.00	13,844.4	0.02
Total				26.62		7.41

Date/Time Startup Commences: 06/09/2013 08:32
 Gas Turbine Downtime: 10 Hours
 Steam Turbine Downtime: 10 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
06/09/2013 08:32	0	0.0	0.0	0.00	577.8	0.00
06/09/2013 08:33	0	0.0	0.0	0.00	977.8	0.00
06/09/2013 08:34	0	5.9	29.5	0.21	1,866.7	0.07
06/09/2013 08:35	0	1.7	34.8	0.35	2,622.2	0.03
06/09/2013 08:36	0	2.7	442.5	5.98	3,511.1	0.06
06/09/2013 08:37	0	4.5	765.6	12.11	4,111.1	0.11
06/09/2013 08:38	0	8.2	1,258.2	22.15	4,577.8	0.24
06/09/2013 08:39	0	14.4	1,741.8	33.05	4,933.3	0.45
06/09/2013 08:40	0	22.3	2,502.2	47.69	4,955.6	0.70
06/09/2013 08:41	0	23.2	2,801.7	60.11	5,577.8	0.81
06/09/2013 08:42	4	24.8	2,794.0	53.97	5,022.2	0.79
06/09/2013 08:43	15	26.9	2,619.0	56.64	5,622.2	0.96
06/09/2013 08:44	26	29.8	1,681.8	41.40	6,400.0	1.21
06/09/2013 08:45	37	30.4	532.4	14.75	7,200.0	1.39
06/09/2013 08:46	50	31.7	133.7	4.20	8,177.8	1.64
06/09/2013 08:47	61	33.0	36.3	1.25	8,977.8	1.88
06/09/2013 08:48	72	22.2	5.1	0.19	9,911.1	1.40
06/09/2013 08:49	84	25.1	2.4	0.09	10,755.6	1.70
06/09/2013 08:50	95	24.1	1.9	0.08	11,511.1	1.76
06/09/2013 08:51	107	21.6	1.4	0.06	12,333.3	1.67
06/09/2013 08:52	119	18.5	1.0	0.04	13,066.7	1.53
06/09/2013 08:53	128	15.4	1.0	0.05	13,733.3	1.35
06/09/2013 08:54	129	12.6	1.0	0.05	13,844.4	1.09
06/09/2013 08:55	130	8.6	0.9	0.05	13,822.2	0.76
06/09/2013 08:56	130	3.7	0.7	0.05	13,800.0	0.33
06/09/2013 08:57	130	2.4	0.6	0.02	13,800.0	0.21
06/09/2013 08:58	132	1.8	0.4	0.02	13,933.3	0.17
06/09/2013 08:59	134	1.4	0.3	0.02	14,066.7	0.12
06/09/2013 09:00	134	0.8	0.2	0.00	14,088.9	0.07
06/09/2013 09:01	134	0.8	0.1	0.00	14,088.9	0.07
06/09/2013 09:02	133	0.7	0.0	0.00	14,066.7	0.05
06/09/2013 09:03	133	0.6	0.0	0.00	14,066.7	0.05
06/09/2013 09:04	133	0.4	0.0	0.00	14,111.1	0.05
06/09/2013 09:05	134	0.4	-0.1	0.00	14,133.3	0.05
06/09/2013 09:06	134	0.3	-0.1	0.00	14,133.3	0.02
06/09/2013 09:07	134	0.3	-0.1	0.00	14,133.3	0.02
06/09/2013 09:08	134	0.3	-0.1	0.00	14,155.6	0.02
Total				354.58		22.83

Date/Time Startup Commences: 06/15/2013 05: 31
 Gas Turbine Downtime: 117 Hours
 Steam Turbine Downtime: 117 Hours
 Startup Type*: Cold

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
06/15/2013 05: 31	0	0.0	0.0	0.00	866.7	0.00
06/15/2013 05: 32	0	0.0	0.0	0.00	800.0	0.00
06/15/2013 05: 33	0	0.0	0.0	0.00	1,733.3	0.00
06/15/2013 05: 34	0	9.5	2,708.1	26.28	2,511.1	0.15
06/15/2013 05: 35	0	9.4	2,632.7	34.14	3,355.6	0.20
06/15/2013 05: 36	0	11.4	2,129.1	33.47	4,066.7	0.29
06/15/2013 05: 37	0	15.0	2,232.7	39.32	4,555.6	0.43
06/15/2013 05: 38	0	18.5	2,433.8	48.91	5,200.0	0.61
06/15/2013 05: 39	0	23.6	2,646.2	51.59	5,044.4	0.76
06/15/2013 05: 40	0	29.1	3,019.6	58.61	5,022.2	0.93
06/15/2013 05: 41	4	32.3	3,156.1	63.16	5,177.8	1.06
06/15/2013 05: 42	15	36.6	3,097.5	70.24	5,866.7	1.37
06/15/2013 05: 43	27	42.3	2,523.5	64.38	6,600.0	1.78
06/15/2013 05: 44	38	44.2	1,571.6	44.95	7,400.0	2.08
06/15/2013 05: 45	49	45.7	904.4	29.37	8,400.0	2.44
06/15/2013 05: 46	61	50.8	385.3	13.64	9,155.6	2.96
06/15/2013 05: 47	73	36.0	31.0	1.20	10,088.9	2.32
06/15/2013 05: 48	84	39.4	4.1	0.17	10,955.6	2.74
06/15/2013 05: 49	96	40.2	2.3	0.10	11,822.2	3.02
06/15/2013 05: 50	107	36.1	2.3	0.11	12,577.8	2.89
06/15/2013 05: 51	119	28.5	2.7	0.14	13,400.0	2.43
06/15/2013 05: 52	131	22.3	2.9	0.17	14,200.0	2.01
06/15/2013 05: 53	139	17.6	2.4	0.13	14,688.9	1.65
06/15/2013 05: 54	140	15.4	1.5	0.08	14,666.7	1.44
06/15/2013 05: 55	139	12.8	0.9	0.05	14,666.7	1.19
06/15/2013 05: 56	140	11.8	0.8	0.05	14,711.1	1.09
06/15/2013 05: 57	140	12.5	0.7	0.03	14,666.7	1.17
06/15/2013 05: 58	140	12.8	0.6	0.03	14,644.4	1.19
06/15/2013 05: 59	140	13.4	0.5	0.03	14,644.4	1.24
06/15/2013 06: 00	140	13.9	0.4	0.03	14,644.4	1.29
06/15/2013 06: 01	140	14.4	0.3	0.03	14,644.4	1.34
06/15/2013 06: 02	140	14.9	0.2	0.03	14,622.2	1.39
06/15/2013 06: 03	140	15.4	0.2	0.03	14,644.4	1.44
06/15/2013 06: 04	140	15.8	0.2	0.03	14,644.4	1.47
06/15/2013 06: 05	140	16.1	0.2	0.00	14,644.4	1.49
06/15/2013 06: 06	140	16.2	0.2	0.00	14,666.7	1.52
06/15/2013 06: 07	141	10.7	0.2	0.00	14,666.7	0.99
06/15/2013 06: 08	140	6.0	0.2	0.00	14,666.7	0.56
06/15/2013 06: 09	140	4.3	0.1	0.00	14,666.7	0.41
06/15/2013 06: 10	141	2.8	0.1	0.00	14,666.7	0.25
06/15/2013 06: 11	140	1.7	0.1	0.00	14,644.4	0.15
06/15/2013 06: 12	140	0.8	0.1	0.00	14,666.7	0.08
06/15/2013 06: 13	139	0.7	0.1	0.00	14,733.3	0.05
06/15/2013 06: 14	139	0.5	0.1	0.00	14,800.0	0.05
06/15/2013 06: 15	140	0.4	0.0	0.00	14,844.4	0.05
06/15/2013 06: 16	140	0.3	0.1	0.00	14,866.7	0.03
06/15/2013 06: 17	140	0.3	0.1	0.00	14,866.7	0.03
06/15/2013 06: 18	140	0.2	0.1	0.00	14,888.9	0.03
06/15/2013 06: 19	140	0.2	0.0	0.00	14,888.9	0.03
06/15/2013 06: 20	140	0.2	0.0	0.00	14,911.1	0.03
06/15/2013 06: 21	140	0.2	0.0	0.00	14,888.9	0.03
Total				580.5		52.15

Date/Time Startup Commences: 06/17/2013 06:29
 Gas Turbine Downtime: 32 Hours
 Steam Turbine Downtime: 32 Hours
 Startup Type*: Warm

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
06/17/2013 06:29	0	0.0	0.0	0.00	955.6	0.00
06/17/2013 06:30	0	0.0	0.0	0.00	488.9	0.00
06/17/2013 06:31	0	0.0	0.0	0.00	1,533.3	0.00
06/17/2013 06:32	0	14.5	2,603.5	23.03	2,288.9	0.21
06/17/2013 06:33	0	10.1	2,687.9	32.55	3,133.3	0.20
06/17/2013 06:34	0	12.0	2,091.3	32.33	4,000.0	0.30
06/17/2013 06:35	0	17.1	2,183.6	38.07	4,511.1	0.49
06/17/2013 06:36	0	22.5	2,443.7	46.60	4,933.3	0.71
06/17/2013 06:37	0	25.1	2,529.4	50.62	5,177.8	0.82
06/17/2013 06:38	0	28.9	2,894.1	57.67	5,155.6	0.94
06/17/2013 06:39	6	31.3	3,128.8	64.23	5,311.1	1.05
06/17/2013 06:40	16	35.8	3,059.7	70.17	5,933.3	1.35
06/17/2013 06:41	28	40.2	2,324.4	60.49	6,733.3	1.72
06/17/2013 06:42	39	44.3	1,523.0	44.74	7,600.0	2.14
06/17/2013 06:43	51	49.0	901.0	29.80	8,555.6	2.67
06/17/2013 06:44	61	50.7	318.7	11.46	9,311.1	3.01
06/17/2013 06:45	73	34.4	7.7	0.30	10,244.4	2.25
06/17/2013 06:46	85	39.5	4.9	0.21	11,155.6	2.81
06/17/2013 06:47	97	37.2	3.4	0.17	11,955.6	2.83
06/17/2013 06:48	109	30.1	3.0	0.15	12,688.9	2.43
06/17/2013 06:49	120	23.1	2.4	0.12	13,466.7	1.98
06/17/2013 06:50	130	17.5	1.9	0.10	14,200.0	1.59
06/17/2013 06:51	134	15.0	1.3	0.07	14,444.4	1.37
06/17/2013 06:52	134	13.0	1.0	0.05	14,488.9	1.20
06/17/2013 06:53	135	12.7	0.8	0.05	14,533.3	1.18
06/17/2013 06:54	135	12.3	0.7	0.05	14,511.1	1.13
06/17/2013 06:55	135	12.2	0.7	0.03	14,533.3	1.13
06/17/2013 06:56	135	12.1	0.6	0.03	14,488.9	1.13
06/17/2013 06:57	135	12.4	0.5	0.03	14,488.9	1.15
06/17/2013 06:58	135	12.6	0.4	0.03	14,488.9	1.18
06/17/2013 06:59	135	13.2	0.3	0.03	14,488.9	1.23
06/17/2013 07:00	135	13.6	0.3	0.03	14,488.9	1.25
06/17/2013 07:01	135	13.8	0.2	0.00	14,488.9	1.28
06/17/2013 07:02	135	11.8	0.2	0.00	14,511.1	1.08
06/17/2013 07:03	135	6.1	0.1	0.00	14,511.1	0.55
06/17/2013 07:04	135	3.8	0.1	0.00	14,511.1	0.35
06/17/2013 07:05	135	2.5	0.1	0.00	14,511.1	0.23
06/17/2013 07:06	135	1.7	0.1	0.00	14,488.9	0.15
06/17/2013 07:07	135	1.3	0.0	0.00	14,511.1	0.13
06/17/2013 07:08	136	0.8	0.0	0.00	14,511.1	0.08
06/17/2013 07:09	135	0.7	0.0	0.00	14,511.1	0.05
06/17/2013 07:10	136	0.6	0.0	0.00	14,511.1	0.05
06/17/2013 07:11	136	0.4	0.0	0.00	14,533.3	0.05
06/17/2013 07:12	135	0.3	0.0	0.00	14,511.1	0.03
06/17/2013 07:13	135	0.3	-0.1	0.00	14,511.1	0.03
06/17/2013 07:14	135	0.3	-0.1	0.00	14,488.9	0.03
06/17/2013 07:15	135	0.3	-0.1	0.00	14,511.1	0.03
06/17/2013 07:16	136	0.3	-0.1	0.00	14,511.1	0.03
Total				563.21		45.6

Date/Time Startup Commences: 06/20/2013 05:39
 Gas Turbine Downtime: 56 Hours
 Steam Turbine Downtime: 56 Hours
 Startup Type*: Warm

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
06/20/2013 05:39	0	0.0	0.0	0.00	888.9	0.00
06/20/2013 05:40	0	0.0	0.0	0.00	488.9	0.00
06/20/2013 05:41	0	0.0	0.0	0.00	1,511.1	0.00
06/20/2013 05:42	0	14.0	236.7	2.05	2,244.4	0.20
06/20/2013 05:43	0	9.3	2,819.3	32.93	3,022.2	0.18
06/20/2013 05:44	0	12.0	2,291.9	35.04	3,955.6	0.30
06/20/2013 05:45	0	15.6	2,214.2	38.60	4,511.1	0.44
06/20/2013 05:46	0	18.5	2,386.3	47.14	5,111.1	0.60
06/20/2013 05:47	0	23.8	2,547.1	51.41	5,222.2	0.79
06/20/2013 05:48	0	28.1	2,780.5	55.88	5,200.0	0.92
06/20/2013 05:49	2	31.3	3,039.1	61.34	5,222.2	1.04
06/20/2013 05:50	8	32.8	2,998.4	63.62	5,488.9	1.15
06/20/2013 05:51	19	37.6	2,841.8	68.09	6,200.0	1.49
06/20/2013 05:52	31	41.5	2,197.8	59.28	6,977.8	1.84
06/20/2013 05:53	42	44.2	1,354.4	40.95	7,822.2	2.20
06/20/2013 05:54	53	47.6	781.3	26.38	8,733.3	2.64
06/20/2013 05:55	65	43.7	234.0	8.67	9,577.8	2.66
06/20/2013 05:56	76	34.9	7.1	0.29	10,511.1	2.34
06/20/2013 05:57	88	39.7	4.5	0.20	11,400.0	2.87
06/20/2013 05:58	99	36.4	3.5	0.17	12,266.7	2.84
06/20/2013 05:59	111	32.1	3.4	0.18	13,155.6	2.68
06/20/2013 06:00	123	25.6	3.2	0.17	13,866.7	2.25
06/20/2013 06:01	134	20.1	2.5	0.15	14,555.6	1.86
06/20/2013 06:02	139	16.6	1.7	0.10	14,888.9	1.57
06/20/2013 06:03	140	14.9	1.1	0.05	14,866.7	1.41
06/20/2013 06:04	140	12.6	0.8	0.05	14,911.1	1.18
06/20/2013 06:05	140	13.2	0.7	0.05	14,888.9	1.26
06/20/2013 06:06	140	13.1	0.6	0.03	14,911.1	1.24
06/20/2013 06:07	140	13.2	0.5	0.03	14,888.9	1.26
06/20/2013 06:08	140	13.5	0.4	0.03	14,888.9	1.29
06/20/2013 06:09	140	14.0	0.3	0.03	14,888.9	1.34
06/20/2013 06:10	140	14.5	0.2	0.03	14,888.9	1.36
06/20/2013 06:11	140	15.0	0.2	0.03	14,888.9	1.41
06/20/2013 06:12	140	15.5	0.2	0.03	14,911.1	1.47
06/20/2013 06:13	139	15.8	0.2	0.00	14,844.4	1.49
06/20/2013 06:14	136	16.0	0.2	0.00	14,555.6	1.48
06/20/2013 06:15	136	15.9	0.2	0.00	14,555.6	1.48
06/20/2013 06:16	135	9.9	0.1	0.00	14,555.6	0.93
06/20/2013 06:17	136	5.1	0.1	0.00	14,555.6	0.48
06/20/2013 06:18	136	3.5	0.1	0.00	14,555.6	0.33
06/20/2013 06:19	135	2.0	0.1	0.00	14,533.3	0.18
06/20/2013 06:20	135	1.2	0.1	0.00	14,511.1	0.10
06/20/2013 06:21	135	1.0	0.1	0.00	14,555.6	0.10
06/20/2013 06:22	135	0.8	0.1	0.00	14,533.3	0.08
06/20/2013 06:23	135	0.6	0.0	0.00	14,533.3	0.05
06/20/2013 06:24	135	0.4	0.0	0.00	14,511.1	0.05
06/20/2013 06:25	135	0.3	0.0	0.00	14,533.3	0.03
06/20/2013 06:26	135	0.3	0.0	0.00	14,533.3	0.03
06/20/2013 06:27	136	0.3	0.0	0.00	14,533.3	0.03
06/20/2013 06:28	135	0.3	0.0	0.00	14,533.3	0.03
06/20/2013 06:29	135	0.3	0.0	0.00	14,533.3	0.03
Total				593		52.98

Date/Time Startup Commences: 06/21/2013 03:42
 Gas Turbine Downtime: 5 Hours
 Steam Turbine Downtime: 5 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
06/21/2013 03:42	0	0.0	0.0	0.00	644.4	0.00
06/21/2013 03:43	0	0.0	0.0	0.00	844.4	0.00
06/21/2013 03:44	0	0.0	5.9	0.04	1,733.3	0.00
06/21/2013 03:45	0	0.3	25.8	0.25	2,511.1	0.00
06/21/2013 03:46	0	0.7	38.8	0.51	3,377.8	0.02
06/21/2013 03:47	0	1.1	45.7	0.73	4,133.3	0.03
06/21/2013 03:48	0	2.4	67.3	1.20	4,600.0	0.07
06/21/2013 03:49	0	4.4	87.4	1.90	5,622.2	0.16
06/21/2013 03:50	0	7.2	100.9	2.02	5,177.8	0.23
06/21/2013 03:51	0	9.8	117.8	2.35	5,155.6	0.32
06/21/2013 03:52	6	11.8	119.6	2.47	5,333.3	0.40
06/21/2013 03:53	18	14.7	110.2	2.55	5,977.8	0.56
06/21/2013 03:54	29	19.0	85.4	2.22	6,733.3	0.81
06/21/2013 03:55	39	22.5	58.0	1.69	7,511.1	1.08
06/21/2013 03:56	52	27.5	35.2	1.16	8,466.7	1.48
06/21/2013 03:57	62	29.6	8.6	0.30	9,266.7	1.74
06/21/2013 03:58	75	14.2	4.7	0.19	10,244.4	0.92
06/21/2013 03:59	84	10.6	2.0	0.08	11,000.0	0.74
06/21/2013 04:00	97	9.4	1.5	0.06	11,977.8	0.72
06/21/2013 04:01	109	6.3	0.9	0.04	12,822.2	0.51
06/21/2013 04:02	121	3.8	0.5	0.02	13,555.6	0.33
06/21/2013 04:03	133	1.3	0.3	0.02	14,333.3	0.12
06/21/2013 04:04	139	0.8	0.3	0.03	14,733.3	0.08
06/21/2013 04:05	140	0.7	0.2	0.03	14,688.9	0.05
06/21/2013 04:06	139	0.4	0.3	0.03	14,755.6	0.05
06/21/2013 04:07	140	0.3	0.3	0.03	14,755.6	0.03
06/21/2013 04:08	140	0.2	0.2	0.03	14,777.8	0.03
06/21/2013 04:09	140	0.2	0.1	0.00	14,777.8	0.03
06/21/2013 04:10	140	0.2	0.0	0.00	14,800.0	0.03
06/21/2013 04:11	140	0.2	-0.1	0.00	14,800.0	0.03
06/21/2013 04:12	140	0.2	-0.1	0.00	14,800.0	0.03
06/21/2013 04:13	140	0.2	-0.1	0.00	14,800.0	0.03
Total				19.95		10.63

Date/Time Startup Commences: 06/22/2013 08:12
 Gas Turbine Downtime: 9 Hours
 Steam Turbine Downtime: 9 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
06/22/2013 08:12	0	0.0	0.0	0.00	933.3	0.00
06/22/2013 08:13	0	0.0	0.0	0.00	800.0	0.00
06/22/2013 08:14	0	0.0	8.9	0.06	1,733.3	0.00
06/22/2013 08:15	0	0.7	24.9	0.24	2,511.1	0.01
06/22/2013 08:16	0	0.9	56.2	0.73	3,377.8	0.02
06/22/2013 08:17	0	2.0	167.8	2.67	4,111.1	0.05
06/22/2013 08:18	0	4.2	404.8	7.20	4,600.0	0.13
06/22/2013 08:19	0	7.8	647.9	13.41	5,355.6	0.27
06/22/2013 08:20	0	13.1	1,186.1	23.53	5,133.3	0.43
06/22/2013 08:21	4	17.9	1,698.8	34.29	5,222.2	0.60
06/22/2013 08:22	13	22.8	1,674.2	36.53	5,644.4	0.82
06/22/2013 08:23	25	23.3	1,057.8	26.35	6,444.4	0.96
06/22/2013 08:24	36	25.7	308.6	8.67	7,266.7	1.19
06/22/2013 08:25	48	27.7	85.2	2.73	8,266.7	1.46
06/22/2013 08:26	59	32.0	32.3	1.11	8,955.6	1.82
06/22/2013 08:27	70	21.3	5.3	0.20	9,866.7	1.35
06/22/2013 08:28	82	23.6	2.4	0.09	10,711.1	1.61
06/22/2013 08:29	94	23.4	1.8	0.08	11,511.1	1.71
06/22/2013 08:30	106	20.7	1.1	0.04	12,488.9	1.64
06/22/2013 08:31	117	15.5	0.8	0.05	13,200.0	1.30
06/22/2013 08:32	128	9.2	0.6	0.02	13,911.1	0.82
06/22/2013 08:33	138	3.9	0.6	0.03	14,711.1	0.36
06/22/2013 08:34	139	2.9	0.5	0.03	14,800.0	0.28
06/22/2013 08:35	140	2.1	0.3	0.03	14,800.0	0.20
06/22/2013 08:36	140	1.3	0.2	0.03	14,777.8	0.13
06/22/2013 08:37	140	1.0	0.2	0.00	14,777.8	0.10
06/22/2013 08:38	140	0.8	0.1	0.00	14,777.8	0.08
06/22/2013 08:39	140	0.7	0.0	0.00	14,800.0	0.05
06/22/2013 08:40	140	0.5	0.0	0.00	14,800.0	0.05
06/22/2013 08:41	140	0.4	-0.1	0.00	14,777.8	0.05
06/22/2013 08:42	140	0.4	-0.1	0.00	14,777.8	0.05
06/22/2013 08:43	140	0.3	-0.1	0.00	14,800.0	0.03
06/22/2013 08:44	140	0.3	-0.1	0.00	14,800.0	0.03
06/22/2013 08:45	140	0.3	-0.1	0.00	14,800.0	0.03
06/22/2013 08:46	140	0.3	-0.1	0.00	14,822.2	0.03
Total				158.12		17.66

Date/Time Startup Commences: 06/24/2013 06: 31
 Gas Turbine Downtime: 31 Hours
 Steam Turbine Downtime: 31 Hours
 Startup Type*: Warm

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
06/24/2013 06: 31	0	0.0	0.0	0.00	866.7	0.00
06/24/2013 06: 32	0	0.0	0.0	0.00	555.6	0.00
06/24/2013 06: 33	0	0.0	0.0	0.00	1,600.0	0.00
06/24/2013 06: 34	0	10.9	2,445.3	22.47	2,377.8	0.16
06/24/2013 06: 35	0	8.9	2,668.4	33.00	3,200.0	0.18
06/24/2013 06: 36	0	11.4	2,159.8	33.58	4,022.2	0.29
06/24/2013 06: 37	0	15.7	2,166.7	37.96	4,533.3	0.45
06/24/2013 06: 38	0	21.3	2,435.4	47.07	5,000.0	0.67
06/24/2013 06: 39	0	24.4	2,606.7	51.72	5,133.3	0.80
06/24/2013 06: 40	0	28.3	2,913.6	57.56	5,111.1	0.92
06/24/2013 06: 41	1	30.3	3,101.8	62.60	5,222.2	1.01
06/24/2013 06: 42	9	30.1	3,055.8	66.41	5,622.2	1.08
06/24/2013 06: 43	20	36.5	2,984.8	71.52	6,200.0	1.45
06/24/2013 06: 44	31	39.9	2,222.5	59.56	6,933.3	1.76
06/24/2013 06: 45	42	40.9	1,310.7	39.40	7,777.8	2.03
06/24/2013 06: 46	54	46.0	686.4	23.16	8,733.3	2.56
06/24/2013 06: 47	66	37.2	127.5	4.74	9,622.2	2.28
06/24/2013 06: 48	77	32.5	7.0	0.29	10,511.1	2.18
06/24/2013 06: 49	89	34.5	4.5	0.20	11,422.2	2.50
06/24/2013 06: 50	100	29.5	3.7	0.17	12,155.6	2.29
06/24/2013 06: 51	112	23.5	2.9	0.16	12,977.8	1.95
06/24/2013 06: 52	123	17.2	1.9	0.09	13,733.3	1.49
06/24/2013 06: 53	134	13.5	1.3	0.08	14,577.8	1.26
06/24/2013 06: 54	139	12.3	0.9	0.05	14,911.1	1.16
06/24/2013 06: 55	140	11.9	0.7	0.05	14,888.9	1.13
06/24/2013 06: 56	140	10.1	0.7	0.05	14,866.7	0.95
06/24/2013 06: 57	140	9.9	0.8	0.05	14,911.1	0.93
06/24/2013 06: 58	140	10.9	0.7	0.05	14,888.9	1.03
06/24/2013 06: 59	140	11.0	0.6	0.03	14,888.9	1.03
06/24/2013 07: 00	140	11.3	0.5	0.03	14,888.9	1.08
06/24/2013 07: 01	140	12.1	0.3	0.03	14,888.9	1.16
06/24/2013 07: 02	140	12.6	0.2	0.03	14,888.9	1.21
06/24/2013 07: 03	140	11.6	0.2	0.03	14,888.9	1.11
06/24/2013 07: 04	141	8.7	0.2	0.00	14,911.1	0.82
06/24/2013 07: 05	140	3.6	0.2	0.00	14,888.9	0.33
06/24/2013 07: 06	140	2.2	0.1	0.00	14,911.1	0.21
06/24/2013 07: 07	140	1.6	0.1	0.00	14,888.9	0.15
06/24/2013 07: 08	141	1.2	0.1	0.00	14,888.9	0.10
06/24/2013 07: 09	140	1.1	0.1	0.00	14,888.9	0.10
06/24/2013 07: 10	140	0.8	0.1	0.00	14,888.9	0.08
06/24/2013 07: 11	141	0.7	0.0	0.00	14,888.9	0.05
06/24/2013 07: 12	140	0.5	0.0	0.00	14,888.9	0.05
06/24/2013 07: 13	140	0.3	0.0	0.00	14,888.9	0.03
06/24/2013 07: 14	140	0.3	0.0	0.00	14,888.9	0.03
06/24/2013 07: 15	140	0.3	0.0	0.00	14,888.9	0.03
06/24/2013 07: 16	140	0.3	0.0	0.00	14,888.9	0.03
06/24/2013 07: 17	140	0.3	0.0	0.00	14,888.9	0.03
Total				612.14		40.14

Date/Time Startup Commences: 06/25/2013 05: 41
 Gas Turbine Downtime: 7 Hours
 Steam Turbine Downtime: 7 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
06/25/2013 05: 41	0	0.0	0.0	0.00	844.4	0.00
06/25/2013 05: 42	0	0.0	0.0	0.00	200.0	0.00
06/25/2013 05: 43	0	0.0	0.0	0.00	1,377.8	0.00
06/25/2013 05: 44	0	2.6	25.6	0.20	2,066.7	0.04
06/25/2013 05: 45	0	1.9	41.3	0.45	2,822.2	0.03
06/25/2013 05: 46	0	2.1	49.1	0.71	3,711.1	0.05
06/25/2013 05: 47	0	3.9	71.2	1.17	4,244.4	0.10
06/25/2013 05: 48	0	5.9	117.6	2.45	5,400.0	0.21
06/25/2013 05: 49	0	9.1	148.3	2.92	5,088.9	0.29
06/25/2013 05: 50	0	12.0	192.5	3.75	5,044.4	0.38
06/25/2013 05: 51	10	13.0	215.5	4.44	5,333.3	0.44
06/25/2013 05: 52	23	16.2	184.0	4.44	6,244.4	0.65
06/25/2013 05: 53	35	19.6	117.7	3.24	7,133.3	0.89
06/25/2013 05: 54	49	22.6	54.5	1.75	8,288.9	1.19
06/25/2013 05: 55	62	27.7	4.2	0.14	9,177.8	1.62
06/25/2013 05: 56	76	14.9	4.3	0.18	10,288.9	0.98
06/25/2013 05: 57	89	11.7	2.1	0.10	11,288.9	0.84
06/25/2013 05: 58	103	9.1	1.3	0.06	12,311.1	0.70
06/25/2013 05: 59	114	6.1	0.7	0.02	13,044.4	0.52
06/25/2013 06: 00	122	3.7	0.5	0.02	13,466.7	0.33
06/25/2013 06: 01	132	1.5	0.4	0.02	14,155.6	0.15
06/25/2013 06: 02	139	0.8	0.4	0.03	14,711.1	0.08
06/25/2013 06: 03	140	0.7	0.3	0.03	14,644.4	0.08
06/25/2013 06: 04	140	0.5	0.2	0.03	14,577.8	0.05
06/25/2013 06: 05	140	0.3	0.2	0.00	14,622.2	0.03
06/25/2013 06: 06	140	0.3	0.2	0.00	14,644.4	0.03
06/25/2013 06: 07	140	0.2	0.1	0.00	14,666.7	0.03
06/25/2013 06: 08	140	0.2	0.0	0.00	14,666.7	0.03
06/25/2013 06: 09	140	0.2	-0.1	0.00	14,644.4	0.03
06/25/2013 06: 10	140	0.2	-0.1	0.00	14,644.4	0.03
06/25/2013 06: 11	140	0.2	-0.1	0.00	14,666.7	0.03
Total				26.15		9.82999999999999

Date/Time Startup Commences: 06/26/2013 06:42
 Gas Turbine Downtime: 8 Hours
 Steam Turbine Downtime: 8 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
06/26/2013 06:42	0	0.0	0.0	0.00	755.6	0.00
06/26/2013 06:43	0	0.0	0.0	0.00	511.1	0.00
06/26/2013 06:44	0	0.0	8.9	0.06	1,644.4	0.00
06/26/2013 06:45	0	0.7	25.6	0.24	2,400.0	0.01
06/26/2013 06:46	0	1.2	51.1	0.63	3,200.0	0.03
06/26/2013 06:47	0	2.2	73.9	1.13	3,955.6	0.05
06/26/2013 06:48	0	4.5	183.9	3.18	4,466.7	0.12
06/26/2013 06:49	0	8.0	288.0	5.49	4,933.3	0.25
06/26/2013 06:50	0	11.4	372.9	7.27	5,044.4	0.37
06/26/2013 06:51	0	15.3	513.7	9.97	5,022.2	0.49
06/26/2013 06:52	6	15.7	482.6	9.99	5,355.6	0.54
06/26/2013 06:53	18	20.3	407.3	9.31	5,911.1	0.77
06/26/2013 06:54	31	22.4	200.9	5.32	6,844.4	0.98
06/26/2013 06:55	46	25.5	68.1	2.08	7,933.3	1.29
06/26/2013 06:56	58	32.0	34.9	1.20	8,888.9	1.81
06/26/2013 06:57	71	24.5	5.4	0.20	9,888.9	1.54
06/26/2013 06:58	85	23.5	3.0	0.13	11,000.0	1.65
06/26/2013 06:59	98	15.9	2.0	0.10	11,933.3	1.22
06/26/2013 07:00	113	9.9	1.0	0.04	13,000.0	0.81
06/26/2013 07:01	121	5.6	0.6	0.02	13,377.8	0.49
06/26/2013 07:02	130	3.2	0.6	0.02	14,000.0	0.29
06/26/2013 07:03	138	1.7	0.6	0.03	14,577.8	0.15
06/26/2013 07:04	140	0.7	0.5	0.03	14,711.1	0.08
06/26/2013 07:05	141	0.5	0.3	0.03	14,644.4	0.05
06/26/2013 07:06	139	0.4	0.3	0.03	14,622.2	0.05
06/26/2013 07:07	140	0.3	0.3	0.03	14,666.7	0.03
06/26/2013 07:08	140	0.2	0.2	0.00	14,666.7	0.03
06/26/2013 07:09	140	0.2	0.1	0.00	14,666.7	0.03
06/26/2013 07:10	140	0.2	0.0	0.00	14,666.7	0.03
06/26/2013 07:11	140	0.2	-0.1	0.00	14,688.9	0.03
06/26/2013 07:12	140	0.1	-0.1	0.00	14,688.9	0.00
06/26/2013 07:13	140	0.1	-0.1	0.00	14,666.7	0.00
Total				56.53		13.19

Date/Time Startup Commences: 06/27/2013 03:42
 Gas Turbine Downtime: 4 Hours
 Steam Turbine Downtime: 4 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
06/27/2013 03:42	0	0.0	0.0	0.00	755.6	0.00
06/27/2013 03:43	0	0.0	0.0	0.00	822.2	0.00
06/27/2013 03:44	0	0.0	13.8	0.09	1,733.3	0.00
06/27/2013 03:45	0	0.6	25.8	0.25	2,488.9	0.01
06/27/2013 03:46	0	1.4	53.1	0.69	3,355.6	0.03
06/27/2013 03:47	0	2.2	73.9	1.15	4,044.4	0.06
06/27/2013 03:48	0	3.8	182.7	3.19	4,511.1	0.11
06/27/2013 03:49	0	6.3	273.1	5.44	5,155.6	0.20
06/27/2013 03:50	0	9.2	364.6	7.14	5,066.7	0.30
06/27/2013 03:51	0	11.6	454.3	8.86	5,044.4	0.37
06/27/2013 03:52	7	12.6	396.7	9.23	6,022.2	0.48
06/27/2013 03:53	17	14.3	295.0	6.69	5,866.7	0.54
06/27/2013 03:54	28	17.5	149.6	3.83	6,622.2	0.74
06/27/2013 03:55	40	18.8	72.6	2.08	7,444.4	0.89
06/27/2013 03:56	52	22.9	40.8	1.32	8,400.0	1.22
06/27/2013 03:57	63	21.3	7.9	0.29	9,244.4	1.26
06/27/2013 03:58	75	11.9	4.2	0.16	10,177.8	0.77
06/27/2013 03:59	86	9.5	2.4	0.10	11,000.0	0.66
06/27/2013 04:00	97	7.0	1.7	0.08	11,733.3	0.53
06/27/2013 04:01	110	4.8	1.0	0.04	12,622.2	0.39
06/27/2013 04:02	121	2.7	0.8	0.05	13,288.9	0.23
06/27/2013 04:03	132	1.1	0.7	0.05	14,111.1	0.10
06/27/2013 04:04	139	0.9	0.6	0.03	14,644.4	0.08
06/27/2013 04:05	140	0.7	0.4	0.03	14,644.4	0.05
06/27/2013 04:06	140	0.5	0.2	0.03	14,644.4	0.05
06/27/2013 04:07	140	0.3	0.2	0.00	14,622.2	0.03
06/27/2013 04:08	140	0.2	0.1	0.00	14,622.2	0.03
06/27/2013 04:09	140	0.2	0.0	0.00	14,644.4	0.03
06/27/2013 04:10	140	0.2	0.0	0.00	14,688.9	0.03
06/27/2013 04:11	140	0.2	-0.1	0.00	14,688.9	0.03
06/27/2013 04:12	140	0.2	-0.1	0.00	14,688.9	0.03
Total				50.82		9.25

Date/Time Startup Commences: 06/28/2013 03:37
 Gas Turbine Downtime: 3 Hours
 Steam Turbine Downtime: 3 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
06/28/2013 03:37	0	0.0	0.0	0.00	755.6	0.00
06/28/2013 03:38	0	0.0	0.0	0.00	288.9	0.00
06/28/2013 03:39	0	0.0	0.0	0.00	1,466.7	0.00
06/28/2013 03:40	0	0.5	23.1	0.20	2,177.8	0.01
06/28/2013 03:41	0	0.8	45.9	0.53	2,955.6	0.02
06/28/2013 03:42	0	1.2	45.8	0.67	3,800.0	0.03
06/28/2013 03:43	0	2.8	61.0	1.02	4,311.1	0.07
06/28/2013 03:44	0	4.2	85.1	1.66	5,022.2	0.14
06/28/2013 03:45	0	5.9	97.5	1.90	5,044.4	0.19
06/28/2013 03:46	0	8.1	121.3	2.35	5,022.2	0.26
06/28/2013 03:47	5	9.2	126.3	2.55	5,222.2	0.31
06/28/2013 03:48	16	11.0	127.0	2.79	5,688.9	0.40
06/28/2013 03:49	27	14.2	106.4	2.66	6,466.7	0.58
06/28/2013 03:50	39	16.3	70.2	1.98	7,311.1	0.76
06/28/2013 03:51	51	20.2	43.9	1.40	8,266.7	1.06
06/28/2013 03:52	61	22.5	22.7	0.79	9,000.0	1.29
06/28/2013 03:53	73	12.0	7.2	0.27	9,844.4	0.75
06/28/2013 03:54	85	8.3	2.7	0.11	10,711.1	0.57
06/28/2013 03:55	96	5.8	1.5	0.06	11,466.7	0.42
06/28/2013 03:56	109	3.9	1.4	0.06	12,488.9	0.30
06/28/2013 03:57	119	2.6	1.0	0.05	13,177.8	0.23
06/28/2013 03:58	130	1.2	0.7	0.05	13,911.1	0.10
06/28/2013 03:59	139	0.9	0.4	0.03	14,533.3	0.08
06/28/2013 04:00	139	0.7	0.4	0.03	14,600.0	0.08
06/28/2013 04:01	140	0.5	0.3	0.03	14,644.4	0.05
06/28/2013 04:02	140	0.3	0.2	0.00	14,644.4	0.03
06/28/2013 04:03	140	0.3	0.0	0.00	14,644.4	0.03
06/28/2013 04:04	140	0.2	-0.1	0.00	14,666.7	0.03
06/28/2013 04:05	140	0.2	-0.1	0.00	14,666.7	0.03
06/28/2013 04:06	140	0.3	-0.1	0.00	14,666.7	0.03
06/28/2013 04:07	140	0.3	-0.1	0.00	14,688.9	0.03
Total				21.19		7.88

Date/Time Startup Commences: 06/29/2013 05:42
 Gas Turbine Downtime: 5 Hours
 Steam Turbine Downtime: 5 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
06/29/2013 05:42	0	0.0	0.0	0.00	622.2	0.00
06/29/2013 05:43	0	0.0	0.0	0.00	444.4	0.00
06/29/2013 05:44	0	0.0	11.8	0.07	1,600.0	0.00
06/29/2013 05:45	0	0.7	26.0	0.24	2,355.6	0.01
06/29/2013 05:46	0	1.2	50.2	0.62	3,200.0	0.03
06/29/2013 05:47	0	2.2	52.5	0.80	3,955.6	0.05
06/29/2013 05:48	0	3.8	73.8	1.27	4,444.4	0.11
06/29/2013 05:49	0	5.5	95.7	1.93	5,222.2	0.18
06/29/2013 05:50	0	8.9	113.4	2.21	5,044.4	0.29
06/29/2013 05:51	0	11.0	133.9	2.59	5,000.0	0.35
06/29/2013 05:52	2	12.2	133.5	2.58	5,000.0	0.39
06/29/2013 05:53	13	14.2	134.3	2.83	5,444.4	0.49
06/29/2013 05:54	26	19.9	123.7	3.04	6,355.6	0.80
06/29/2013 05:55	39	21.0	85.2	2.40	7,266.7	0.97
06/29/2013 05:56	53	24.8	51.8	1.67	8,333.3	1.31
06/29/2013 05:57	65	25.1	26.0	0.92	9,200.0	1.48
06/29/2013 05:58	79	13.8	5.8	0.23	10,200.0	0.90
06/29/2013 05:59	93	10.2	2.6	0.12	11,288.9	0.74
06/29/2013 06:00	107	6.8	1.3	0.06	12,355.6	0.53
06/29/2013 06:01	120	4.6	1.0	0.05	13,311.1	0.39
06/29/2013 06:02	128	2.7	0.7	0.02	13,888.9	0.24
06/29/2013 06:03	133	1.5	0.4	0.02	14,200.0	0.12
06/29/2013 06:04	139	0.9	0.3	0.03	14,666.7	0.08
06/29/2013 06:05	140	0.7	0.2	0.03	14,644.4	0.08
06/29/2013 06:06	140	0.5	0.2	0.00	14,577.8	0.05
06/29/2013 06:07	140	0.3	0.2	0.00	14,666.7	0.03
06/29/2013 06:08	140	0.3	0.2	0.00	14,644.4	0.03
06/29/2013 06:09	140	0.2	0.1	0.00	14,666.7	0.03
06/29/2013 06:10	140	0.2	0.0	0.00	14,666.7	0.03
06/29/2013 06:11	140	0.2	-0.1	0.00	14,644.4	0.03
06/29/2013 06:12	140	0.2	-0.1	0.00	14,666.7	0.03
06/29/2013 06:13	140	0.2	-0.1	0.00	14,666.7	0.03
Total				23.73		9.8

Date/Time Startup Commences: 06/30/2013 06: 41
 Gas Turbine Downtime: 6 Hours
 Steam Turbine Downtime: 6 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
06/30/2013 06: 41	0	0.0	0.0	0.00	288.9	0.00
06/30/2013 06: 42	0	0.0	0.0	0.00	400.0	0.00
06/30/2013 06: 43	0	0.0	0.0	0.00	1,066.7	0.00
06/30/2013 06: 44	0	4.2	23.6	0.18	1,933.3	0.05
06/30/2013 06: 45	0	2.1	38.1	0.39	2,688.9	0.04
06/30/2013 06: 46	0	3.5	45.5	0.63	3,600.0	0.08
06/30/2013 06: 47	0	4.5	55.9	0.90	4,177.8	0.12
06/30/2013 06: 48	0	6.1	79.0	1.42	4,644.4	0.18
06/30/2013 06: 49	0	9.3	98.4	1.93	5,088.9	0.30
06/30/2013 06: 50	0	12.0	120.4	2.34	5,022.2	0.38
06/30/2013 06: 51	0	14.2	138.1	2.67	5,000.0	0.45
06/30/2013 06: 52	8	15.1	133.5	2.78	5,377.8	0.52
06/30/2013 06: 53	21	20.7	132.8	3.07	5,977.8	0.78
06/30/2013 06: 54	33	22.6	103.3	2.75	6,888.9	0.99
06/30/2013 06: 55	48	26.3	63.5	1.96	7,977.8	1.34
06/30/2013 06: 56	61	32.2	36.2	1.24	8,888.9	1.81
06/30/2013 06: 57	74	17.0	2.8	0.10	9,911.1	1.08
06/30/2013 06: 58	88	11.6	3.8	0.15	10,933.3	0.81
06/30/2013 06: 59	101	11.1	1.3	0.06	11,955.6	0.85
06/30/2013 07: 00	114	5.7	1.0	0.04	13,000.0	0.47
06/30/2013 07: 01	125	3.6	0.7	0.05	13,800.0	0.31
06/30/2013 07: 02	130	1.9	0.5	0.02	14,066.7	0.17
06/30/2013 07: 03	138	1.1	0.3	0.03	14,644.4	0.10
06/30/2013 07: 04	140	0.9	0.2	0.03	14,777.8	0.08
06/30/2013 07: 05	140	0.7	0.2	0.00	14,688.9	0.05
06/30/2013 07: 06	140	0.4	0.1	0.00	14,711.1	0.05
06/30/2013 07: 07	140	0.3	0.1	0.00	14,733.3	0.03
06/30/2013 07: 08	140	0.2	0.1	0.00	14,733.3	0.03
06/30/2013 07: 09	140	0.2	0.0	0.00	14,755.6	0.03
06/30/2013 07: 10	140	0.2	-0.1	0.00	14,755.6	0.03
06/30/2013 07: 11	140	0.2	-0.1	0.00	14,733.3	0.03
06/30/2013 07: 12	140	0.2	-0.1	0.00	14,755.6	0.03
Total				22.74		11.19

Condition 18 Startup Report



From: 07/01/2013 00:00 **To:** 12/31/2013 23:59 **Facility Name:** Lodi Energy Center
Generated: 02/04/2014 11:01 **Location:** Lodi, CA
Gas Turbine Downtime Tag: CT1_GT_Downtime_Min_1M
Steam Turbine Downtime Tag: CT1_GT_Downtime_Min_1M
 *ST Downtime Determines Startup Type: Cold > 64 hours , 16 hours >= Warm <= 64, Hot < 16
 Red = Invalid Data

Date/Time Startup Commences: 07/04/2013 07:52
Gas Turbine Downtime: 2 Hours
Steam Turbine Downtime: 2 Hours
Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
07/04/2013 07:52	0	0.0	0.0	0.00	688.9	0.00
07/04/2013 07:53	0	0.0	0.0	0.00	622.2	0.00
07/04/2013 07:54	0	0.0	13.8	0.09	1,711.1	0.00
07/04/2013 07:55	0	0.9	25.1	0.24	2,466.7	0.01
07/04/2013 07:56	0	2.7	44.5	0.58	3,355.6	0.06
07/04/2013 07:57	0	3.3	51.7	0.81	4,022.2	0.08
07/04/2013 07:58	0	4.7	70.4	1.23	4,511.1	0.13
07/04/2013 07:59	0	6.7	93.1	1.81	5,044.4	0.22
07/04/2013 08:00	0	9.2	109.5	2.12	5,022.2	0.29
07/04/2013 08:01	1	10.6	126.3	2.45	5,022.2	0.34
07/04/2013 08:02	8	12.4	127.8	2.60	5,266.7	0.42
07/04/2013 08:03	20	14.7	123.7	2.86	5,977.8	0.56
07/04/2013 08:04	30	17.7	97.0	2.51	6,688.9	0.75
07/04/2013 08:05	42	19.2	66.2	1.93	7,533.3	0.92
07/04/2013 08:06	53	24.0	40.1	1.30	8,377.8	1.27
07/04/2013 08:07	65	17.7	18.9	0.67	9,244.4	1.04
07/04/2013 08:08	76	11.3	7.0	0.28	10,111.1	0.73
07/04/2013 08:09	88	6.7	2.8	0.11	10,977.8	0.47
07/04/2013 08:10	99	4.4	1.9	0.08	11,844.4	0.33
07/04/2013 08:11	111	3.0	1.3	0.07	12,688.9	0.24
07/04/2013 08:12	122	1.7	0.7	0.05	13,511.1	0.14
07/04/2013 08:13	134	0.9	0.4	0.02	14,355.6	0.07
07/04/2013 08:14	139	0.8	0.3	0.03	14,755.6	0.08
07/04/2013 08:15	140	0.6	0.2	0.00	14,755.6	0.05
07/04/2013 08:16	140	0.5	0.0	0.00	14,755.6	0.05
07/04/2013 08:17	140	0.3	0.0	0.00	14,777.8	0.03
07/04/2013 08:18	140	0.3	0.0	0.00	14,777.8	0.03
07/04/2013 08:19	140	0.2	-0.1	0.00	14,777.8	0.03
07/04/2013 08:20	140	0.2	-0.1	0.00	14,777.8	0.03
07/04/2013 08:21	140	0.2	-0.1	0.00	14,800.0	0.03
07/04/2013 08:22	140	0.2	-0.1	0.00	14,822.2	0.03
Total				21.84		8.43

Date/Time Startup Commences: 07/07/2013 08:42
 Gas Turbine Downtime: 7 Hours
 Steam Turbine Downtime: 7 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
07/07/2013 08:42	0	0.0	0.0	0.00	733.3	0.00
07/07/2013 08:43	0	0.0	0.0	0.00	488.9	0.00
07/07/2013 08:44	0	0.0	0.0	0.00	1,533.3	0.00
07/07/2013 08:45	0	0.4	25.3	0.22	2,266.7	0.01
07/07/2013 08:46	0	0.8	45.9	0.55	3,066.7	0.02
07/07/2013 08:47	0	1.3	57.9	0.87	3,888.9	0.03
07/07/2013 08:48	0	3.2	100.1	1.71	4,422.2	0.09
07/07/2013 08:49	0	5.7	161.3	3.21	5,155.6	0.19
07/07/2013 08:50	0	9.1	203.8	4.01	5,088.9	0.29
07/07/2013 08:51	0	11.8	255.1	5.00	5,066.7	0.38
07/07/2013 08:52	2	14.0	250.9	4.96	5,111.1	0.46
07/07/2013 08:53	14	15.9	210.6	4.54	5,577.8	0.57
07/07/2013 08:54	27	20.3	147.5	3.74	6,555.6	0.85
07/07/2013 08:55	41	23.5	79.1	2.30	7,511.1	1.12
07/07/2013 08:56	55	29.0	41.7	1.38	8,577.8	1.58
07/07/2013 08:57	67	27.0	9.0	0.33	9,600.0	1.66
07/07/2013 08:58	80	15.3	2.8	0.11	10,622.2	1.03
07/07/2013 08:59	94	12.7	0.8	0.04	11,644.4	0.95
07/07/2013 09:00	109	9.5	0.6	0.02	12,688.9	0.77
07/07/2013 09:01	120	5.8	0.5	0.02	13,466.7	0.49
07/07/2013 09:02	127	3.2	0.4	0.02	13,866.7	0.29
07/07/2013 09:03	135	1.3	0.3	0.02	14,422.2	0.12
07/07/2013 09:04	140	1.0	0.3	0.03	14,777.8	0.10
07/07/2013 09:05	140	0.7	0.2	0.03	14,688.9	0.08
07/07/2013 09:06	140	0.4	0.2	0.00	14,644.4	0.05
07/07/2013 09:07	140	0.3	0.3	0.03	14,688.9	0.03
07/07/2013 09:08	140	0.2	0.2	0.00	14,711.1	0.03
07/07/2013 09:09	140	0.2	0.1	0.00	14,688.9	0.03
07/07/2013 09:10	140	0.2	-0.1	0.00	14,711.1	0.03
07/07/2013 09:11	140	0.2	-0.1	0.00	14,733.3	0.03
07/07/2013 09:12	140	0.2	-0.1	0.00	14,711.1	0.03
07/07/2013 09:13	140	0.2	-0.1	0.00	14,711.1	0.03
Total				33.14		11.34

Date/Time Startup Commences: 07/08/2013 07:42
 Gas Turbine Downtime: 9 Hours
 Steam Turbine Downtime: 9 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
07/08/2013 07:42	0	0.0	0.0	0.00	1,066.7	0.00
07/08/2013 07:43	0	0.0	0.0	0.00	822.2	0.00
07/08/2013 07:44	0	0.0	8.9	0.06	1,711.1	0.00
07/08/2013 07:45	0	0.7	27.5	0.26	2,444.4	0.01
07/08/2013 07:46	0	1.0	57.3	0.73	3,288.9	0.02
07/08/2013 07:47	0	1.9	141.4	2.22	4,066.7	0.05
07/08/2013 07:48	0	4.0	335.5	5.91	4,555.6	0.12
07/08/2013 07:49	0	7.9	573.6	13.40	6,044.4	0.30
07/08/2013 07:50	0	12.6	1,004.5	20.01	5,155.6	0.42
07/08/2013 07:51	0	16.9	1,441.0	28.47	5,111.1	0.55
07/08/2013 07:52	4	18.3	1,398.7	28.23	5,222.2	0.60
07/08/2013 07:53	17	21.4	1,191.4	26.91	5,844.4	0.80
07/08/2013 07:54	30	23.1	526.8	13.84	6,800.0	1.00
07/08/2013 07:55	43	25.2	130.3	3.96	7,844.4	1.26
07/08/2013 07:56	57	30.9	44.3	1.51	8,844.4	1.74
07/08/2013 07:57	70	23.9	6.2	0.24	9,911.1	1.51
07/08/2013 07:58	83	23.6	2.5	0.11	10,933.3	1.64
07/08/2013 07:59	97	26.2	1.4	0.06	11,933.3	1.98
07/08/2013 08:00	111	21.8	0.9	0.04	13,000.0	1.80
07/08/2013 08:01	119	12.0	0.6	0.02	13,444.4	1.02
07/08/2013 08:02	130	11.9	0.5	0.02	14,133.3	1.07
07/08/2013 08:03	139	3.5	0.5	0.03	14,777.8	0.33
07/08/2013 08:04	140	2.5	0.4	0.03	14,822.2	0.23
07/08/2013 08:05	140	1.4	0.3	0.03	14,777.8	0.13
07/08/2013 08:06	139	1.0	0.3	0.03	14,777.8	0.10
07/08/2013 08:07	140	0.8	0.3	0.03	14,800.0	0.08
07/08/2013 08:08	140	0.6	0.2	0.00	14,800.0	0.05
07/08/2013 08:09	140	0.5	0.0	0.00	14,822.2	0.05
07/08/2013 08:10	140	0.4	-0.1	0.00	14,800.0	0.05
07/08/2013 08:11	140	0.4	-0.1	0.00	14,777.8	0.05
07/08/2013 08:12	140	0.3	-0.1	0.00	14,822.2	0.03
07/08/2013 08:13	140	0.3	-0.1	0.00	14,800.0	0.03
07/08/2013 08:14	140	0.3	-0.1	0.00	14,822.2	0.03
07/08/2013 08:15	140	0.3	-0.2	0.00	14,822.2	0.03
Total				146.15		17.08

Date/Time Startup Commences: 07/09/2013 07:32
 Gas Turbine Downtime: 8 Hours
 Steam Turbine Downtime: 8 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
07/09/2013 07:32	0	0.0	0.0	0.00	800.0	0.00
07/09/2013 07:33	0	0.0	0.0	0.00	288.9	0.00
07/09/2013 07:34	0	0.0	0.0	0.00	1,400.0	0.00
07/09/2013 07:35	0	0.7	22.9	0.18	2,066.7	0.01
07/09/2013 07:36	0	0.8	30.6	0.33	2,822.2	0.01
07/09/2013 07:37	0	1.3	50.0	0.73	3,777.8	0.03
07/09/2013 07:38	0	2.8	73.9	1.25	4,377.8	0.08
07/09/2013 07:39	0	4.4	129.2	2.54	5,088.9	0.14
07/09/2013 07:40	0	7.6	179.1	3.62	5,222.2	0.25
07/09/2013 07:41	0	10.2	259.4	5.22	5,200.0	0.33
07/09/2013 07:42	4	12.2	273.0	5.67	5,377.8	0.42
07/09/2013 07:43	4	14.5	238.7	4.94	5,355.6	0.49
07/09/2013 07:44	7	14.7	190.1	3.96	5,400.0	0.50
07/09/2013 07:45	20	17.7	148.9	3.48	6,044.4	0.68
07/09/2013 07:46	32	20.4	106.4	2.88	7,000.0	0.91
07/09/2013 07:47	46	24.4	61.4	1.92	8,111.1	1.26
07/09/2013 07:48	59	32.0	33.1	1.15	9,000.0	1.83
07/09/2013 07:49	72	17.9	5.1	0.19	10,133.3	1.15
07/09/2013 07:50	86	13.4	2.0	0.10	11,177.8	0.95
07/09/2013 07:51	100	9.7	1.4	0.06	12,177.8	0.76
07/09/2013 07:52	113	6.7	0.8	0.05	13,133.3	0.57
07/09/2013 07:53	125	3.9	0.4	0.02	13,888.9	0.34
07/09/2013 07:54	131	1.9	0.3	0.02	14,244.4	0.17
07/09/2013 07:55	138	1.1	0.3	0.03	14,800.0	0.10
07/09/2013 07:56	141	0.9	0.2	0.03	14,911.1	0.08
07/09/2013 07:57	140	0.7	0.2	0.00	14,822.2	0.05
07/09/2013 07:58	139	0.4	0.2	0.00	14,844.4	0.05
07/09/2013 07:59	140	0.3	0.3	0.03	14,866.7	0.03
07/09/2013 08:00	140	0.2	0.2	0.00	14,866.7	0.03
07/09/2013 08:01	140	0.2	0.0	0.00	14,866.7	0.03
07/09/2013 08:02	140	0.2	-0.1	0.00	14,888.9	0.03
07/09/2013 08:03	140	0.2	-0.1	0.00	14,866.7	0.03
07/09/2013 08:04	140	0.2	-0.1	0.00	14,866.7	0.03
Total				38.4		11.34

Date/Time Startup Commences: 07/10/2013 05:42
 Gas Turbine Downtime: 7 Hours
 Steam Turbine Downtime: 7 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
07/10/2013 05:42	0	0.0	0.0	0.00	933.3	0.00
07/10/2013 05:43	0	0.0	0.0	0.00	955.6	0.00
07/10/2013 05:44	0	0.0	19.2	0.14	1,844.4	0.00
07/10/2013 05:45	0	0.6	27.7	0.28	2,622.2	0.01
07/10/2013 05:46	0	0.9	46.3	0.63	3,488.9	0.02
07/10/2013 05:47	0	1.8	56.8	0.91	4,133.3	0.05
07/10/2013 05:48	0	3.4	90.4	1.62	4,644.4	0.10
07/10/2013 05:49	0	5.9	123.9	2.46	5,133.3	0.20
07/10/2013 05:50	0	8.7	158.5	3.15	5,133.3	0.28
07/10/2013 05:51	0	10.8	202.6	4.01	5,111.1	0.35
07/10/2013 05:52	6	12.8	186.6	3.77	5,222.2	0.42
07/10/2013 05:53	16	14.6	163.8	3.72	5,866.7	0.55
07/10/2013 05:54	28	19.4	124.4	3.20	6,644.4	0.83
07/10/2013 05:55	39	21.7	75.5	2.19	7,511.1	1.04
07/10/2013 05:56	51	27.7	45.6	1.49	8,444.4	1.49
07/10/2013 05:57	62	30.2	8.2	0.29	9,311.1	1.78
07/10/2013 05:58	74	14.8	5.6	0.23	10,200.0	0.97
07/10/2013 05:59	84	12.4	1.2	0.06	11,022.2	0.88
07/10/2013 06:00	96	9.6	0.7	0.04	11,800.0	0.71
07/10/2013 06:01	109	6.3	0.6	0.02	12,666.7	0.50
07/10/2013 06:02	120	3.4	0.5	0.02	13,377.8	0.28
07/10/2013 06:03	132	1.2	0.4	0.02	14,222.2	0.10
07/10/2013 06:04	139	0.8	0.4	0.03	14,800.0	0.08
07/10/2013 06:05	140	0.7	0.3	0.03	14,777.8	0.05
07/10/2013 06:06	140	0.5	0.2	0.00	14,755.6	0.05
07/10/2013 06:07	140	0.4	0.2	0.00	14,844.4	0.05
07/10/2013 06:08	140	0.3	0.3	0.03	14,844.4	0.03
07/10/2013 06:09	140	0.2	0.1	0.00	14,844.4	0.03
07/10/2013 06:10	140	0.2	-0.1	0.00	14,822.2	0.03
07/10/2013 06:11	140	0.2	-0.1	0.00	14,822.2	0.03
07/10/2013 06:12	140	0.2	-0.1	0.00	14,844.4	0.03
07/10/2013 06:13	140	0.2	-0.2	0.00	14,822.2	0.03
Total				28.34		10.97

Date/Time Startup Commences: 07/12/2013 07:27
 Gas Turbine Downtime: 8 Hours
 Steam Turbine Downtime: 8 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
07/12/2013 07:27	0	0.0	0.0	0.00	511.1	0.00
07/12/2013 07:28	0	0.0	0.0	0.00	288.9	0.00
07/12/2013 07:29	0	0.0	0.0	0.00	1,355.6	0.00
07/12/2013 07:30	0	5.9	24.4	0.19	2,022.2	0.08
07/12/2013 07:31	0	2.2	30.3	0.33	2,777.8	0.04
07/12/2013 07:32	0	3.6	59.7	0.86	3,711.1	0.08
07/12/2013 07:33	0	4.6	121.2	2.02	4,311.1	0.13
07/12/2013 07:34	0	7.0	257.3	4.73	4,755.6	0.21
07/12/2013 07:35	0	11.2	362.6	7.23	5,155.6	0.37
07/12/2013 07:36	0	15.5	613.0	12.11	5,111.1	0.50
07/12/2013 07:37	0	18.5	726.5	14.47	5,155.6	0.61
07/12/2013 07:38	7	19.7	619.5	12.67	5,288.9	0.66
07/12/2013 07:39	20	21.9	457.1	10.79	6,111.1	0.85
07/12/2013 07:40	33	26.2	190.7	5.18	7,022.2	1.16
07/12/2013 07:41	46	29.1	79.9	2.51	8,111.1	1.50
07/12/2013 07:42	59	35.6	37.3	1.31	9,044.4	2.05
07/12/2013 07:43	73	26.3	5.6	0.23	10,088.9	1.69
07/12/2013 07:44	86	27.9	3.2	0.14	11,200.0	1.99
07/12/2013 07:45	100	20.4	2.0	0.11	12,200.0	1.58
07/12/2013 07:46	112	12.4	0.8	0.05	13,133.3	1.04
07/12/2013 07:47	119	8.7	0.5	0.02	13,444.4	0.74
07/12/2013 07:48	130	4.5	0.4	0.02	14,200.0	0.42
07/12/2013 07:49	139	2.4	0.4	0.03	14,844.4	0.23
07/12/2013 07:50	140	1.2	0.3	0.03	14,777.8	0.13
07/12/2013 07:51	140	0.6	0.3	0.03	14,711.1	0.05
07/12/2013 07:52	140	0.5	0.3	0.03	14,755.6	0.05
07/12/2013 07:53	140	0.4	0.4	0.03	14,800.0	0.05
07/12/2013 07:54	140	0.3	0.3	0.03	14,777.8	0.03
07/12/2013 07:55	140	0.3	0.1	0.00	14,777.8	0.03
07/12/2013 07:56	140	0.3	0.0	0.00	14,777.8	0.03
07/12/2013 07:57	140	0.3	0.0	0.00	14,800.0	0.03
07/12/2013 07:58	140	0.3	-0.1	0.00	14,800.0	0.03
07/12/2013 07:59	140	0.3	-0.1	0.00	14,800.0	0.03
Total				75.15		16.39

Date/Time Startup Commences: 07/13/2013 08:48
 Gas Turbine Downtime: 9 Hours
 Steam Turbine Downtime: 9 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
07/13/2013 08:48	0	0.0	0.0	0.00	0.0	0.00
07/13/2013 08:49	0	0.0	0.0	0.00	733.3	0.00
07/13/2013 08:50	0	0.0	0.0	0.00	1,088.9	0.00
07/13/2013 08:51	0	1.2	21.2	0.16	1,911.1	0.01
07/13/2013 08:52	0	0.9	27.4	0.28	2,666.7	0.01
07/13/2013 08:53	0	1.4	62.4	0.87	3,577.8	0.03
07/13/2013 08:54	0	2.4	176.4	2.85	4,177.8	0.07
07/13/2013 08:55	0	4.6	368.8	6.62	4,644.4	0.14
07/13/2013 08:56	0	8.6	555.9	10.88	5,066.7	0.28
07/13/2013 08:57	0	13.4	995.3	19.66	5,111.1	0.43
07/13/2013 08:58	6	18.1	1,355.6	28.29	5,400.0	0.62
07/13/2013 08:59	18	22.4	1,256.3	29.02	5,977.8	0.86
07/13/2013 09:00	31	24.3	618.0	16.45	6,888.9	1.06
07/13/2013 09:01	44	26.6	150.9	4.62	7,911.1	1.34
07/13/2013 09:02	58	33.1	38.5	1.33	8,955.6	1.89
07/13/2013 09:03	71	24.5	5.3	0.21	10,022.2	1.56
07/13/2013 09:04	85	26.6	1.7	0.08	11,000.0	1.86
07/13/2013 09:05	98	26.2	0.8	0.04	12,000.0	1.99
07/13/2013 09:06	112	23.9	0.7	0.04	12,955.6	1.97
07/13/2013 09:07	124	17.9	0.5	0.02	13,777.8	1.57
07/13/2013 09:08	129	10.3	0.4	0.02	14,088.9	0.92
07/13/2013 09:09	137	5.0	0.4	0.03	14,644.4	0.46
07/13/2013 09:10	140	3.2	0.4	0.03	14,822.2	0.31
07/13/2013 09:11	140	2.0	0.3	0.03	14,755.6	0.18
07/13/2013 09:12	140	1.3	0.3	0.03	14,777.8	0.13
07/13/2013 09:13	140	0.8	0.3	0.03	14,777.8	0.08
07/13/2013 09:14	140	0.6	0.3	0.03	14,800.0	0.05
07/13/2013 09:15	140	0.6	0.1	0.00	14,800.0	0.05
07/13/2013 09:16	140	0.5	0.0	0.00	14,822.2	0.05
07/13/2013 09:17	140	0.5	0.0	0.00	14,822.2	0.05
07/13/2013 09:18	140	0.4	-0.1	0.00	14,822.2	0.05
07/13/2013 09:19	140	0.4	-0.1	0.00	14,800.0	0.05
07/13/2013 09:20	140	0.4	-0.1	0.00	14,800.0	0.05
07/13/2013 09:21	140	0.4	-0.1	0.00	14,822.2	0.05
Total				121.62		18.17

Date/Time Startup Commences: 07/14/2013 08:44
 Gas Turbine Downtime: 11 Hours
 Steam Turbine Downtime: 11 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
07/14/2013 08:44	0	0.0	0.0	0.00	777.8	0.00
07/14/2013 08:45	0	0.0	0.0	0.00	377.8	0.00
07/14/2013 08:46	0	0.0	0.0	0.00	1,488.9	0.00
07/14/2013 08:47	0	3.9	21.6	0.19	2,244.4	0.05
07/14/2013 08:48	0	2.4	124.2	1.45	3,022.2	0.05
07/14/2013 08:49	0	3.4	316.1	4.75	3,888.9	0.08
07/14/2013 08:50	0	5.5	730.8	12.43	4,400.0	0.15
07/14/2013 08:51	0	10.3	1,304.7	24.99	4,955.6	0.33
07/14/2013 08:52	0	16.6	1,794.7	35.91	5,177.8	0.55
07/14/2013 08:53	0	22.4	2,446.5	48.75	5,155.6	0.73
07/14/2013 08:54	2	23.8	2,580.3	51.64	5,177.8	0.79
07/14/2013 08:55	12	26.2	2,558.4	54.94	5,555.6	0.93
07/14/2013 08:56	24	29.7	2,125.7	52.94	6,444.4	1.21
07/14/2013 08:57	37	32.9	839.0	24.07	7,422.2	1.55
07/14/2013 08:58	52	34.9	172.6	5.67	8,511.1	1.90
07/14/2013 08:59	65	34.1	31.6	1.16	9,488.9	2.06
07/14/2013 09:00	78	26.1	4.4	0.18	10,533.3	1.75
07/14/2013 09:01	92	28.4	1.6	0.08	11,533.3	2.09
07/14/2013 09:02	105	25.6	1.2	0.06	12,466.7	2.02
07/14/2013 09:03	118	21.3	0.9	0.05	13,422.2	1.81
07/14/2013 09:04	129	17.8	0.7	0.02	14,244.4	1.62
07/14/2013 09:05	134	17.2	0.6	0.03	14,488.9	1.58
07/14/2013 09:06	140	11.6	0.6	0.03	14,911.1	1.11
07/14/2013 09:07	140	11.8	0.6	0.03	14,888.9	1.11
07/14/2013 09:08	140	2.9	0.5	0.03	14,844.4	0.28
07/14/2013 09:09	140	1.9	0.4	0.03	14,888.9	0.18
07/14/2013 09:10	140	1.7	0.3	0.03	14,911.1	0.15
07/14/2013 09:11	140	1.0	0.2	0.00	14,911.1	0.10
07/14/2013 09:12	140	0.8	0.0	0.00	14,911.1	0.08
07/14/2013 09:13	140	0.7	0.0	0.00	14,888.9	0.08
07/14/2013 09:14	140	0.7	-0.1	0.00	14,911.1	0.05
07/14/2013 09:15	140	0.5	-0.1	0.00	14,933.3	0.05
07/14/2013 09:16	140	0.4	-0.1	0.00	14,911.1	0.05
07/14/2013 09:17	140	0.3	-0.1	0.00	14,933.3	0.03
07/14/2013 09:18	140	0.3	-0.2	0.00	14,911.1	0.03
07/14/2013 09:19	140	0.3	-0.2	0.00	14,933.3	0.03
07/14/2013 09:20	140	0.2	-0.2	0.00	14,933.3	0.03
Total				319.46		24.61

Date/Time Startup Commences: 07/15/2013 07:27
 Gas Turbine Downtime: 9 Hours
 Steam Turbine Downtime: 9 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
07/15/2013 07:27	0	0.0	0.0	0.00	844.4	0.00
07/15/2013 07:28	0	0.0	0.0	0.00	488.9	0.00
07/15/2013 07:29	0	0.0	0.0	0.00	1,533.3	0.00
07/15/2013 07:30	0	0.8	24.0	0.22	2,311.1	0.01
07/15/2013 07:31	0	1.3	98.4	1.16	3,066.7	0.03
07/15/2013 07:32	0	2.6	293.3	4.46	3,933.3	0.07
07/15/2013 07:33	0	4.6	623.3	10.76	4,466.7	0.13
07/15/2013 07:34	0	9.0	1,085.4	20.61	4,911.1	0.28
07/15/2013 07:35	0	14.8	1,488.3	29.78	5,177.8	0.48
07/15/2013 07:36	1	21.9	2,161.5	43.44	5,200.0	0.73
07/15/2013 07:37	10	22.6	2,169.4	46.39	5,533.3	0.79
07/15/2013 07:38	21	27.8	1,958.0	47.59	6,288.9	1.11
07/15/2013 07:39	33	29.7	881.7	24.09	7,066.7	1.33
07/15/2013 07:40	45	30.4	214.8	6.63	7,977.8	1.54
07/15/2013 07:41	56	34.9	49.1	1.68	8,866.7	1.98
07/15/2013 07:42	68	26.3	7.4	0.29	9,755.6	1.63
07/15/2013 07:43	79	24.9	4.7	0.18	10,644.4	1.69
07/15/2013 07:44	90	28.4	3.3	0.14	11,488.9	2.08
07/15/2013 07:45	102	26.3	1.8	0.09	12,377.8	2.07
07/15/2013 07:46	114	23.0	0.8	0.05	13,177.8	1.93
07/15/2013 07:47	125	18.6	0.6	0.02	13,911.1	1.66
07/15/2013 07:48	136	13.2	0.6	0.03	14,644.4	1.24
07/15/2013 07:49	140	8.4	0.6	0.03	14,844.4	0.79
07/15/2013 07:50	140	4.7	0.5	0.03	14,822.2	0.44
07/15/2013 07:51	140	2.6	0.4	0.03	14,866.7	0.26
07/15/2013 07:52	140	2.0	0.3	0.03	14,844.4	0.18
07/15/2013 07:53	140	1.4	0.2	0.03	14,844.4	0.13
07/15/2013 07:54	140	1.2	0.1	0.00	14,866.7	0.10
07/15/2013 07:55	140	1.0	0.0	0.00	14,866.7	0.10
07/15/2013 07:56	140	0.7	0.0	0.00	14,866.7	0.05
07/15/2013 07:57	140	0.5	-0.1	0.00	14,866.7	0.05
07/15/2013 07:58	140	0.4	-0.1	0.00	14,866.7	0.05
07/15/2013 07:59	140	0.3	-0.1	0.00	14,888.9	0.03
07/15/2013 08:00	140	0.3	-0.1	0.00	14,888.9	0.03
07/15/2013 08:01	140	0.3	-0.2	0.00	14,888.9	0.03
07/15/2013 08:02	140	0.3	-0.2	0.00	14,888.9	0.03
Total				237.76		23.05

Date/Time Startup Commences: 07/16/2013 11:24
 Gas Turbine Downtime: 14 Hours
 Steam Turbine Downtime: 14 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
07/16/2013 11:24	0	0.0	0.0	0.00	1,022.2	0.00
07/16/2013 11:25	0	0.0	0.0	0.00	844.4	0.00
07/16/2013 11:26	0	11.8	-5.9	0.00	1,733.3	0.13
07/16/2013 11:27	0	2.2	26.9	0.26	2,466.7	0.03
07/16/2013 11:28	0	2.0	608.4	7.93	3,333.3	0.04
07/16/2013 11:29	0	4.2	1,104.6	17.76	4,111.1	0.11
07/16/2013 11:30	0	8.9	1,669.9	30.03	4,600.0	0.27
07/16/2013 11:31	0	15.3	2,108.7	43.05	5,222.2	0.51
07/16/2013 11:32	0	21.5	2,545.2	51.75	5,200.0	0.72
07/16/2013 11:33	0	24.4	2,985.6	60.44	5,177.8	0.81
07/16/2013 11:34	3	26.0	3,034.0	62.49	5,266.7	0.88
07/16/2013 11:35	14	28.9	2,966.3	66.75	5,755.6	1.08
07/16/2013 11:36	25	33.5	2,341.3	60.01	6,555.6	1.41
07/16/2013 11:37	37	35.3	1,144.0	33.20	7,422.2	1.69
07/16/2013 11:38	49	38.2	460.3	15.07	8,377.8	2.06
07/16/2013 11:39	59	39.5	100.1	3.56	9,088.9	2.30
07/16/2013 11:40	71	25.2	6.2	0.25	10,044.4	1.63
07/16/2013 11:41	83	26.6	2.6	0.11	10,888.9	1.86
07/16/2013 11:42	94	25.0	1.7	0.08	11,688.9	1.88
07/16/2013 11:43	107	21.4	1.3	0.07	12,555.6	1.73
07/16/2013 11:44	118	18.6	0.9	0.05	13,377.8	1.59
07/16/2013 11:45	129	14.9	0.7	0.05	14,111.1	1.36
07/16/2013 11:46	138	14.6	0.7	0.05	14,844.4	1.40
07/16/2013 11:47	140	14.3	0.6	0.03	14,911.1	1.38
07/16/2013 11:48	140	14.4	0.5	0.03	14,911.1	1.38
07/16/2013 11:49	140	11.2	0.4	0.03	14,888.9	1.07
07/16/2013 11:50	140	5.5	0.3	0.03	14,911.1	0.52
07/16/2013 11:51	140	3.2	0.2	0.00	14,888.9	0.31
07/16/2013 11:52	140	2.2	0.1	0.00	14,888.9	0.21
07/16/2013 11:53	140	1.8	0.0	0.00	14,911.1	0.18
07/16/2013 11:54	140	1.2	0.0	0.00	14,911.1	0.10
07/16/2013 11:55	140	0.9	0.0	0.00	14,911.1	0.08
07/16/2013 11:56	140	0.7	0.0	0.00	14,911.1	0.08
07/16/2013 11:57	140	0.6	-0.1	0.00	14,911.1	0.05
07/16/2013 11:58	140	0.4	-0.1	0.00	14,911.1	0.05
07/16/2013 11:59	140	0.3	-0.1	0.00	14,911.1	0.03
07/16/2013 12:00	140	0.3	-0.1	0.00	14,911.1	0.03
07/16/2013 12:01	140	0.3	-0.1	0.00	14,911.1	0.03
07/16/2013 12:02	140	0.3	-0.1	0.00	14,911.1	0.03
07/16/2013 12:03	140	0.3	-0.1	0.00	14,933.3	0.03
Total				453.08		29.05

Date/Time Startup Commences: 07/17/2013 03:42
 Gas Turbine Downtime: 6 Hours
 Steam Turbine Downtime: 6 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
07/17/2013 03:42	0	0.0	0.0	0.00	800.0	0.00
07/17/2013 03:43	0	0.0	0.0	0.00	622.2	0.00
07/17/2013 03:44	0	0.0	-5.9	0.00	1,622.2	0.00
07/17/2013 03:45	0	0.4	23.2	0.22	2,400.0	0.00
07/17/2013 03:46	0	0.8	42.8	0.54	3,222.2	0.02
07/17/2013 03:47	0	1.1	50.2	0.79	4,022.2	0.03
07/17/2013 03:48	0	2.5	78.2	1.38	4,511.1	0.07
07/17/2013 03:49	0	4.6	123.9	2.43	5,022.2	0.15
07/17/2013 03:50	0	7.8	150.2	3.06	5,222.2	0.26
07/17/2013 03:51	0	10.6	186.6	3.78	5,177.8	0.35
07/17/2013 03:52	3	12.2	180.3	3.70	5,244.4	0.41
07/17/2013 03:53	15	14.6	161.5	3.64	5,777.8	0.55
07/17/2013 03:54	28	19.3	122.9	3.21	6,688.9	0.83
07/17/2013 03:55	41	22.0	73.8	2.22	7,688.9	1.09
07/17/2013 03:56	55	27.3	39.6	1.36	8,777.8	1.55
07/17/2013 03:57	69	23.7	6.7	0.26	9,866.7	1.50
07/17/2013 03:58	82	14.0	3.9	0.17	10,866.7	0.97
07/17/2013 03:59	95	12.0	2.6	0.13	11,977.8	0.92
07/17/2013 04:00	108	9.4	1.3	0.07	12,955.6	0.79
07/17/2013 04:01	115	6.5	0.5	0.02	13,288.9	0.56
07/17/2013 04:02	123	3.4	0.3	0.02	13,800.0	0.31
07/17/2013 04:03	134	1.2	0.3	0.03	14,488.9	0.13
07/17/2013 04:04	141	0.7	0.3	0.03	14,955.6	0.05
07/17/2013 04:05	141	0.3	0.2	0.03	14,844.4	0.03
07/17/2013 04:06	141	0.3	0.3	0.03	14,933.3	0.03
07/17/2013 04:07	141	0.3	0.4	0.03	14,955.6	0.03
07/17/2013 04:08	142	0.2	0.3	0.03	14,977.8	0.03
07/17/2013 04:09	142	0.2	0.1	0.00	15,000.0	0.03
07/17/2013 04:10	142	0.2	-0.1	0.00	15,022.2	0.03
07/17/2013 04:11	142	0.2	-0.1	0.00	15,022.2	0.03
07/17/2013 04:12	142	0.2	0.0	0.00	14,977.8	0.03
07/17/2013 04:13	141	0.2	0.0	0.00	14,955.6	0.03
Total				27.18		10.81

Date/Time Startup Commences: 07/18/2013 07:27
 Gas Turbine Downtime: 11 Hours
 Steam Turbine Downtime: 11 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
07/18/2013 07:27	0	0.0	0.0	0.00	955.6	0.00
07/18/2013 07:28	0	0.0	0.0	0.00	844.4	0.00
07/18/2013 07:29	0	0.0	8.9	0.06	1,733.3	0.00
07/18/2013 07:30	0	0.3	27.1	0.27	2,488.9	0.00
07/18/2013 07:31	0	0.5	239.3	3.10	3,311.1	0.01
07/18/2013 07:32	0	1.3	493.5	7.89	4,088.9	0.04
07/18/2013 07:33	0	4.6	1,007.0	18.20	4,622.2	0.14
07/18/2013 07:34	0	10.3	1,631.7	34.16	5,355.6	0.36
07/18/2013 07:35	0	17.1	2,093.0	42.74	5,222.2	0.57
07/18/2013 07:36	0	22.0	2,519.3	51.00	5,177.8	0.73
07/18/2013 07:37	5	23.6	2,551.6	52.77	5,288.9	0.80
07/18/2013 07:38	18	26.2	2,455.0	57.80	6,022.2	1.01
07/18/2013 07:39	31	31.0	1,656.2	45.18	6,977.8	1.39
07/18/2013 07:40	46	31.6	476.8	15.08	8,088.9	1.64
07/18/2013 07:41	59	35.6	83.2	2.95	9,066.7	2.07
07/18/2013 07:42	72	25.2	7.0	0.28	10,111.1	1.64
07/18/2013 07:43	84	25.4	2.9	0.12	11,088.9	1.80
07/18/2013 07:44	98	25.9	1.5	0.06	12,177.8	2.02
07/18/2013 07:45	112	23.4	1.0	0.05	13,200.0	1.98
07/18/2013 07:46	119	19.2	0.6	0.02	13,577.8	1.68
07/18/2013 07:47	130	16.2	0.5	0.03	14,288.9	1.50
07/18/2013 07:48	139	15.0	0.5	0.03	14,955.6	1.44
07/18/2013 07:49	140	12.8	0.5	0.03	14,933.3	1.23
07/18/2013 07:50	140	9.0	0.5	0.03	14,911.1	0.86
07/18/2013 07:51	140	3.0	0.6	0.03	14,888.9	0.29
07/18/2013 07:52	140	2.2	0.7	0.05	14,911.1	0.21
07/18/2013 07:53	140	1.7	0.6	0.03	14,911.1	0.16
07/18/2013 07:54	140	1.3	0.2	0.03	14,888.9	0.13
07/18/2013 07:55	140	1.2	0.1	0.00	14,911.1	0.10
07/18/2013 07:56	140	0.9	0.0	0.00	14,911.1	0.08
07/18/2013 07:57	140	0.7	0.0	0.00	14,911.1	0.05
07/18/2013 07:58	140	0.5	0.0	0.00	14,933.3	0.05
07/18/2013 07:59	140	0.4	0.0	0.00	14,933.3	0.05
07/18/2013 08:00	140	0.3	0.0	0.00	14,911.1	0.03
07/18/2013 08:01	140	0.2	0.0	0.00	14,933.3	0.03
07/18/2013 08:02	140	0.3	0.0	0.00	14,933.3	0.03
07/18/2013 08:03	140	0.3	0.0	0.00	14,933.3	0.03
Total				331.99		24.15

Date/Time Startup Commences: 07/19/2013 07:28
 Gas Turbine Downtime: 8 Hours
 Steam Turbine Downtime: 8 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
07/19/2013 07:28	0	0.0	0.0	0.00	844.4	0.00
07/19/2013 07:29	0	0.0	0.0	0.00	288.9	0.00
07/19/2013 07:30	0	0.0	0.0	0.00	1,511.1	0.00
07/19/2013 07:31	0	2.7	25.9	0.23	2,244.4	0.04
07/19/2013 07:32	0	1.6	42.4	0.50	3,000.0	0.03
07/19/2013 07:33	0	2.7	56.3	0.86	3,888.9	0.07
07/19/2013 07:34	0	4.0	145.8	2.53	4,444.4	0.12
07/19/2013 07:35	0	6.3	280.0	5.67	5,177.8	0.21
07/19/2013 07:36	0	10.5	381.0	7.75	5,200.0	0.35
07/19/2013 07:37	0	13.4	557.0	11.28	5,177.8	0.44
07/19/2013 07:38	4	15.5	562.1	12.06	5,488.9	0.55
07/19/2013 07:39	16	19.7	492.5	11.25	8,844.4	0.74
07/19/2013 07:40	29	20.9	256.4	6.82	6,800.0	0.91
07/19/2013 07:41	43	24.9	92.4	2.84	7,866.7	1.26
07/19/2013 07:42	57	31.6	44.3	1.54	8,888.9	1.80
07/19/2013 07:43	69	26.4	6.4	0.24	9,888.9	1.68
07/19/2013 07:44	82	25.7	2.9	0.11	10,911.1	1.81
07/19/2013 07:45	96	26.5	1.8	0.08	11,933.3	2.04
07/19/2013 07:46	110	16.1	0.9	0.05	13,022.2	1.34
07/19/2013 07:47	119	9.4	0.4	0.02	13,466.7	0.82
07/19/2013 07:48	129	4.4	0.3	0.02	14,088.9	0.39
07/19/2013 07:49	137	2.6	0.3	0.03	14,755.6	0.26
07/19/2013 07:50	140	1.8	0.3	0.03	14,911.1	0.18
07/19/2013 07:51	140	0.9	0.2	0.03	14,844.4	0.08
07/19/2013 07:52	139	0.7	0.2	0.00	14,844.4	0.05
07/19/2013 07:53	140	0.5	0.2	0.00	14,866.7	0.05
07/19/2013 07:54	140	0.4	0.2	0.00	14,888.9	0.05
07/19/2013 07:55	140	0.3	0.0	0.00	14,866.7	0.03
07/19/2013 07:56	140	0.3	-0.1	0.00	14,866.7	0.03
07/19/2013 07:57	140	0.2	-0.1	0.00	14,888.9	0.03
07/19/2013 07:58	140	0.2	-0.1	0.00	14,888.9	0.03
07/19/2013 07:59	140	0.2	-0.1	0.00	14,911.1	0.03
07/19/2013 08:00	140	0.2	-0.1	0.00	14,911.1	0.03
Total				63.94		15.45

Date/Time Startup Commences: 07/20/2013 08:22
 Gas Turbine Downtime: 10 Hours
 Steam Turbine Downtime: 10 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
07/20/2013 08:22	0	0.0	0.0	0.00	888.9	0.00
07/20/2013 08:23	0	0.0	0.0	0.00	844.4	0.00
07/20/2013 08:24	0	5.9	8.9	0.06	1,755.6	0.07
07/20/2013 08:25	0	2.0	26.9	0.27	2,533.3	0.03
07/20/2013 08:26	0	2.5	155.6	2.07	3,400.0	0.05
07/20/2013 08:27	0	3.7	553.6	8.90	4,111.1	0.09
07/20/2013 08:28	0	7.6	1,305.6	23.37	4,577.8	0.22
07/20/2013 08:29	0	14.0	1,837.3	36.24	5,044.4	0.46
07/20/2013 08:30	0	23.0	2,332.8	47.02	5,155.6	0.77
07/20/2013 08:31	0	24.2	2,744.9	54.85	5,111.1	0.79
07/20/2013 08:32	8	25.4	2,760.2	61.87	5,733.3	0.94
07/20/2013 08:33	20	30.1	2,682.9	64.80	6,177.8	1.20
07/20/2013 08:34	33	33.4	1,736.6	47.67	7,022.2	1.51
07/20/2013 08:35	47	33.7	540.3	17.27	8,177.8	1.77
07/20/2013 08:36	60	39.1	87.5	3.12	9,111.1	2.29
07/20/2013 08:37	74	26.4	6.4	0.25	10,177.8	1.72
07/20/2013 08:38	87	28.3	2.5	0.12	11,200.0	2.03
07/20/2013 08:39	101	26.9	1.6	0.09	12,155.6	2.10
07/20/2013 08:40	114	22.9	1.1	0.05	13,133.3	1.93
07/20/2013 08:41	126	18.7	0.7	0.02	14,022.2	1.69
07/20/2013 08:42	131	17.6	0.5	0.03	14,288.9	1.62
07/20/2013 08:43	138	17.1	0.5	0.03	14,800.0	1.63
07/20/2013 08:44	140	12.0	0.5	0.03	14,911.1	1.15
07/20/2013 08:45	140	12.1	0.5	0.03	14,844.4	1.17
07/20/2013 08:46	140	2.9	0.5	0.03	14,844.4	0.29
07/20/2013 08:47	140	1.9	0.6	0.03	14,888.9	0.18
07/20/2013 08:48	140	1.8	0.5	0.03	14,888.9	0.18
07/20/2013 08:49	140	1.1	0.2	0.03	14,866.7	0.10
07/20/2013 08:50	140	0.9	0.1	0.00	14,888.9	0.08
07/20/2013 08:51	140	0.7	0.1	0.00	14,888.9	0.08
07/20/2013 08:52	140	0.7	0.0	0.00	14,911.1	0.05
07/20/2013 08:53	140	0.5	0.0	0.00	14,911.1	0.05
07/20/2013 08:54	140	0.4	0.0	0.00	14,888.9	0.05
07/20/2013 08:55	140	0.3	0.0	0.00	14,911.1	0.03
07/20/2013 08:56	140	0.3	0.0	0.00	14,911.1	0.03
07/20/2013 08:57	140	0.3	0.0	0.00	14,888.9	0.03
07/20/2013 08:58	140	0.3	0.0	0.00	14,888.9	0.03
Total				368.28		26.41

Date/Time Startup Commences: 07/22/2013 06:14
 Gas Turbine Downtime: 32 Hours
 Steam Turbine Downtime: 32 Hours
 Startup Type*: Warm

Sample Time	CT1 Load Mwe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
07/22/2013 06:14	0	0.0	0.0	0.00	688.9	0.00
07/22/2013 06:15	0	0.0	0.0	0.00	311.1	0.00
07/22/2013 06:16	0	0.0	0.0	0.00	1,377.8	0.00
07/22/2013 06:17	0	22.6	119.0	0.95	2,044.4	0.30
07/22/2013 06:18	0	9.9	2,695.1	29.74	2,822.2	0.18
07/22/2013 06:19	0	12.3	2,301.5	33.99	3,777.8	0.30
07/22/2013 06:20	0	14.9	2,110.0	35.93	4,355.6	0.42
07/22/2013 06:21	0	18.5	2,314.3	46.04	5,088.9	0.60
07/22/2013 06:22	0	23.2	2,503.9	50.47	5,155.6	0.77
07/22/2013 06:23	0	27.5	2,714.4	54.95	5,177.8	0.91
07/22/2013 06:24	1	30.3	3,059.5	62.20	5,200.0	1.02
07/22/2013 06:25	10	31.1	3,116.2	67.97	5,577.8	1.12
07/22/2013 06:26	23	36.9	2,965.8	74.47	6,422.2	1.53
07/22/2013 06:27	36	42.3	2,100.9	60.43	7,355.6	2.00
07/22/2013 06:28	50	44.3	1,106.8	36.82	8,511.1	2.42
07/22/2013 06:29	63	49.1	395.6	14.65	9,466.7	2.99
07/22/2013 06:30	76	35.8	11.5	0.48	10,600.0	2.44
07/22/2013 06:31	90	40.5	5.0	0.22	11,622.2	3.02
07/22/2013 06:32	103	37.7	3.7	0.18	12,644.4	3.07
07/22/2013 06:33	113	31.4	3.2	0.16	13,244.4	2.68
07/22/2013 06:34	121	24.0	2.5	0.14	13,755.6	2.11
07/22/2013 06:35	130	18.6	1.7	0.10	14,288.9	1.70
07/22/2013 06:36	137	14.2	1.1	0.08	14,844.4	1.35
07/22/2013 06:37	140	13.4	0.8	0.05	15,088.9	1.29
07/22/2013 06:38	140	12.1	0.7	0.03	15,022.2	1.18
07/22/2013 06:39	140	11.0	0.8	0.05	15,000.0	1.05
07/22/2013 06:40	140	13.1	0.8	0.05	15,022.2	1.26
07/22/2013 06:41	140	13.4	0.7	0.03	15,000.0	1.31
07/22/2013 06:42	140	13.9	0.5	0.03	15,000.0	1.34
07/22/2013 06:43	140	14.3	0.3	0.03	15,022.2	1.39
07/22/2013 06:44	141	14.5	0.2	0.03	15,022.2	1.42
07/22/2013 06:45	141	10.2	0.2	0.00	15,000.0	1.00
07/22/2013 06:46	141	4.7	0.2	0.00	15,000.0	0.45
07/22/2013 06:47	141	3.2	0.2	0.00	15,022.2	0.31
07/22/2013 06:48	140	2.2	0.2	0.00	15,000.0	0.21
07/22/2013 06:49	140	1.2	0.2	0.00	14,977.8	0.10
07/22/2013 06:50	140	0.9	0.1	0.00	14,977.8	0.08
07/22/2013 06:51	140	0.7	0.1	0.00	15,000.0	0.08
07/22/2013 06:52	140	0.6	0.1	0.00	14,977.8	0.05
07/22/2013 06:53	140	0.5	0.1	0.00	15,000.0	0.05
07/22/2013 06:54	140	0.4	0.1	0.00	14,977.8	0.05
07/22/2013 06:55	140	0.4	0.1	0.00	15,000.0	0.05
07/22/2013 06:56	140	0.3	0.0	0.00	15,000.0	0.03
07/22/2013 06:57	140	0.3	0.0	0.00	15,000.0	0.03
07/22/2013 06:58	140	0.4	0.0	0.00	15,000.0	0.05
Total				570.27		43.71

Date/Time Startup Commences: 07/23/2013 08:17
 Gas Turbine Downtime: 10 Hours
 Steam Turbine Downtime: 10 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
07/23/2013 08:17	0	0.0	0.0	0.00	755.6	0.00
07/23/2013 08:18	0	0.0	0.0	0.00	733.3	0.00
07/23/2013 08:19	0	11.8	8.9	0.06	1,711.1	0.13
07/23/2013 08:20	0	2.6	24.9	0.24	2,466.7	0.04
07/23/2013 08:21	0	2.7	165.0	2.15	3,333.3	0.06
07/23/2013 08:22	0	4.1	552.8	8.83	4,088.9	0.11
07/23/2013 08:23	0	7.7	1,270.7	22.74	4,577.8	0.22
07/23/2013 08:24	0	13.5	1,761.2	35.35	5,133.3	0.45
07/23/2013 08:25	0	21.5	2,330.1	46.97	5,155.6	0.71
07/23/2013 08:26	0	23.8	2,761.8	55.43	5,133.3	0.79
07/23/2013 08:27	2	25.2	2,784.8	56.38	5,177.8	0.84
07/23/2013 08:28	15	26.0	2,686.1	60.21	5,733.3	0.96
07/23/2013 08:29	28	32.5	2,164.0	56.41	6,666.7	1.40
07/23/2013 08:30	41	33.4	783.7	23.42	7,644.4	1.64
07/23/2013 08:31	55	35.4	164.1	5.57	8,688.9	1.97
07/23/2013 08:32	68	30.5	23.7	0.89	9,644.4	1.89
07/23/2013 08:33	81	25.4	4.9	0.20	10,622.2	1.74
07/23/2013 08:34	95	26.4	2.2	0.10	11,622.2	1.97
07/23/2013 08:35	109	23.0	1.7	0.09	12,711.1	1.89
07/23/2013 08:36	122	19.5	1.0	0.05	13,666.7	1.72
07/23/2013 08:37	130	17.9	0.7	0.05	14,266.7	1.64
07/23/2013 08:38	135	17.5	0.6	0.03	14,600.0	1.63
07/23/2013 08:39	140	14.0	0.6	0.03	14,955.6	1.36
07/23/2013 08:40	140	8.8	0.5	0.03	14,888.9	0.83
07/23/2013 08:41	140	3.2	0.5	0.03	14,844.4	0.31
07/23/2013 08:42	140	1.9	0.5	0.03	14,866.7	0.18
07/23/2013 08:43	140	1.7	0.5	0.03	14,866.7	0.16
07/23/2013 08:44	140	1.3	0.2	0.03	14,866.7	0.13
07/23/2013 08:45	140	0.8	0.1	0.00	14,888.9	0.08
07/23/2013 08:46	140	0.7	0.0	0.00	14,866.7	0.08
07/23/2013 08:47	140	0.7	0.0	0.00	14,888.9	0.05
07/23/2013 08:48	140	0.5	0.0	0.00	14,888.9	0.05
07/23/2013 08:49	140	0.4	0.0	0.00	14,888.9	0.05
07/23/2013 08:50	140	0.4	0.0	0.00	14,911.1	0.05
07/23/2013 08:51	140	0.3	0.0	0.00	14,888.9	0.03
07/23/2013 08:52	140	0.3	0.0	0.00	14,888.9	0.03
07/23/2013 08:53	140	0.3	0.0	0.00	14,888.9	0.03
Total				375.35		25.22

Date/Time Startup Commences: 07/24/2013 07:29
 Gas Turbine Downtime: 10 Hours
 Steam Turbine Downtime: 10 Hours
 Startup Type*: Hot

Sample Time	CT1 Load MWe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
07/24/2013 07:29	0	0.0	0.0	0.00	533.3	0.00
07/24/2013 07:30	0	0.0	0.0	0.00	622.2	0.00
07/24/2013 07:31	0	23.6	11.8	0.07	1,644.4	0.25
07/24/2013 07:32	0	3.0	28.8	0.26	2,333.3	0.04
07/24/2013 07:33	0	3.4	200.8	2.38	3,022.2	0.07
07/24/2013 07:34	0	4.5	669.8	2.97	1,133.3	0.03
Total				5.68		0.39

Date/Time Startup Commences: 07/24/2013 07:51
 Gas Turbine Downtime: 0 Hours
 Steam Turbine Downtime: 0 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
07/24/2013 07:51	0	0.0	0.0	0.00	800.0	0.00
07/24/2013 07:52	0	0.0	0.0	0.00	422.2	0.00
07/24/2013 07:53	0	0.0	0.0	0.00	1,377.8	0.00
07/24/2013 07:54	0	8.1	26.6	0.21	2,066.7	0.11
07/24/2013 07:55	0	3.5	116.1	1.28	2,822.2	0.06
07/24/2013 07:56	0	5.5	534.8	7.85	3,755.6	0.13
07/24/2013 07:57	0	9.2	1,297.8	21.76	4,288.9	0.25
07/24/2013 07:58	0	13.9	1,938.6	37.39	4,933.3	0.44
07/24/2013 07:59	0	21.9	2,238.8	44.74	5,111.1	0.72
07/24/2013 08:00	0	24.8	2,777.1	55.01	5,066.7	0.81
07/24/2013 08:01	2	27.3	3,019.6	60.08	5,088.9	0.89
07/24/2013 08:02	13	28.5	3,024.7	65.70	5,555.6	1.02
07/24/2013 08:03	25	35.0	2,788.2	70.49	6,466.7	1.46
07/24/2013 08:04	38	36.6	1,489.3	42.96	7,377.8	1.74
07/24/2013 08:05	52	37.3	473.0	15.62	8,444.4	2.04
07/24/2013 08:06	65	36.3	61.5	2.27	9,400.0	2.20
07/24/2013 08:07	79	26.6	6.8	0.27	10,444.4	1.79
07/24/2013 08:08	93	28.3	3.2	0.14	11,444.4	2.08
07/24/2013 08:09	106	24.4	2.4	0.11	12,511.1	1.97
07/24/2013 08:10	119	21.2	1.6	0.07	13,488.9	1.84
07/24/2013 08:11	128	17.9	0.9	0.05	14,111.1	1.63
07/24/2013 08:12	133	16.6	0.7	0.05	14,444.4	1.54
07/24/2013 08:13	141	15.1	0.6	0.03	15,088.9	1.48
07/24/2013 08:14	145	13.7	0.7	0.03	15,355.6	1.34
07/24/2013 08:15	145	9.4	0.6	0.03	15,288.9	0.93
07/24/2013 08:16	145	3.6	0.5	0.03	15,244.4	0.35
07/24/2013 08:17	145	2.4	0.6	0.03	15,266.7	0.24
07/24/2013 08:18	145	1.8	0.5	0.03	15,288.9	0.19
07/24/2013 08:19	145	1.5	0.3	0.03	15,311.1	0.13
07/24/2013 08:20	145	1.1	0.1	0.00	15,311.1	0.11
07/24/2013 08:21	145	0.7	0.1	0.00	15,311.1	0.08
07/24/2013 08:22	145	0.7	0.0	0.00	15,288.9	0.05
07/24/2013 08:23	145	0.6	0.0	0.00	15,333.3	0.05
07/24/2013 08:24	145	0.4	0.0	0.00	15,311.1	0.05
07/24/2013 08:25	145	0.3	0.0	0.00	15,288.9	0.03
07/24/2013 08:26	145	0.3	0.0	0.00	15,311.1	0.03
07/24/2013 08:27	145	0.3	-0.1	0.00	15,333.3	0.03
07/24/2013 08:28	145	0.2	-0.1	0.00	15,311.1	0.03
Total				426.26		27.84

Date/Time Startup Commences: 07/25/2013 06:44
 Gas Turbine Downtime: 9 Hours
 Steam Turbine Downtime: 9 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
07/25/2013 06:44	0	0.0	0.0	0.00	822.2	0.00
07/25/2013 06:45	0	0.0	0.0	0.00	955.6	0.00
07/25/2013 06:46	0	1.5	20.7	0.15	1,844.4	0.02
07/25/2013 06:47	0	0.9	30.7	0.32	2,622.2	0.01
07/25/2013 06:48	0	1.9	341.3	4.69	3,511.1	0.04
07/25/2013 06:49	0	3.7	852.0	13.77	4,133.3	0.09
07/25/2013 06:50	0	8.2	1,552.3	28.05	4,622.2	0.24
07/25/2013 06:51	0	15.1	1,966.7	40.84	5,311.1	0.52
07/25/2013 06:52	0	22.5	2,545.2	50.86	5,111.1	0.74
07/25/2013 06:53	0	24.2	2,800.9	55.73	5,088.9	0.79
07/25/2013 06:54	11	25.0	2,803.3	60.65	5,533.3	0.89
07/25/2013 06:55	24	30.5	2,693.5	66.23	6,288.9	1.23
07/25/2013 06:56	36	32.8	1,469.7	41.38	7,200.0	1.52
07/25/2013 06:57	50	32.6	423.9	13.85	8,355.6	1.75
07/25/2013 06:58	63	35.0	61.7	2.24	9,288.9	2.09
07/25/2013 06:59	77	23.7	5.9	0.24	10,377.8	1.58
07/25/2013 07:00	91	26.1	2.1	0.10	11,377.8	1.91
07/25/2013 07:01	104	23.2	1.5	0.06	12,355.6	1.86
07/25/2013 07:02	117	19.8	1.0	0.05	13,311.1	1.70
07/25/2013 07:03	128	16.3	0.7	0.05	14,066.7	1.47
07/25/2013 07:04	132	16.0	0.6	0.03	14,400.0	1.48
07/25/2013 07:05	140	15.6	0.6	0.03	14,911.1	1.48
07/25/2013 07:06	147	12.5	0.6	0.03	15,466.7	1.24
07/25/2013 07:07	150	8.9	0.5	0.03	15,666.7	0.90
07/25/2013 07:08	150	3.8	0.4	0.03	15,600.0	0.38
07/25/2013 07:09	150	2.1	0.2	0.03	15,600.0	0.22
07/25/2013 07:10	150	1.5	0.3	0.03	15,622.2	0.16
07/25/2013 07:11	150	1.4	0.2	0.00	15,622.2	0.14
07/25/2013 07:12	150	1.3	0.1	0.00	15,644.4	0.14
07/25/2013 07:13	150	1.1	0.0	0.00	15,622.2	0.11
07/25/2013 07:14	150	0.8	-0.1	0.00	15,622.2	0.08
07/25/2013 07:15	150	0.7	-0.1	0.00	15,644.4	0.05
07/25/2013 07:16	150	0.5	-0.1	0.00	15,622.2	0.05
07/25/2013 07:17	150	0.4	-0.1	0.00	15,622.2	0.05
07/25/2013 07:18	150	0.4	-0.1	0.00	15,622.2	0.05
07/25/2013 07:19	150	0.3	-0.1	0.00	15,644.4	0.03
07/25/2013 07:20	150	0.3	-0.2	0.00	15,666.7	0.03
Total				379.47		25.04

Date/Time Startup Commences: 07/26/2013 07:52
 Gas Turbine Downtime: 8 Hours
 Steam Turbine Downtime: 8 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
07/26/2013 07:52	0	0.0	0.0	0.00	755.6	0.00
07/26/2013 07:53	0	0.0	0.0	0.00	844.4	0.00
07/26/2013 07:54	0	8.9	17.7	0.12	1,755.6	0.10
07/26/2013 07:55	0	2.0	25.2	0.25	2,533.3	0.03
07/26/2013 07:56	0	2.1	152.5	2.04	3,422.2	0.05
07/26/2013 07:57	0	3.3	315.3	5.04	4,088.9	0.09
07/26/2013 07:58	0	5.9	676.0	12.04	4,555.6	0.18
07/26/2013 07:59	0	10.1	1,033.3	20.38	5,044.4	0.33
07/26/2013 08:00	0	16.0	1,699.8	34.12	5,133.3	0.53
07/26/2013 08:01	1	20.5	2,117.5	42.31	5,111.1	0.68
07/26/2013 08:02	7	21.6	2,091.2	43.07	5,266.7	0.73
07/26/2013 08:03	18	24.0	1,853.4	43.64	6,022.2	0.93
07/26/2013 08:04	31	26.8	965.7	26.02	6,888.9	1.19
07/26/2013 08:05	45	27.2	221.3	6.94	8,022.2	1.40
07/26/2013 08:06	58	32.0	44.3	1.56	9,000.0	1.86
07/26/2013 08:07	72	22.4	5.4	0.21	10,088.9	1.46
07/26/2013 08:08	85	23.8	2.7	0.12	11,133.3	1.71
07/26/2013 08:09	98	23.6	1.8	0.08	12,111.1	1.84
07/26/2013 08:10	112	22.1	1.0	0.05	13,111.1	1.88
07/26/2013 08:11	121	17.9	0.6	0.02	13,622.2	1.57
07/26/2013 08:12	129	15.6	0.5	0.02	14,155.6	1.41
07/26/2013 08:13	138	10.8	0.5	0.03	14,822.2	1.04
07/26/2013 08:14	145	5.5	0.5	0.03	15,333.3	0.54
07/26/2013 08:15	145	3.1	0.4	0.03	15,244.4	0.29
07/26/2013 08:16	145	2.0	0.3	0.03	15,244.4	0.19
07/26/2013 08:17	145	1.5	0.3	0.03	15,244.4	0.16
07/26/2013 08:18	145	1.3	0.3	0.03	15,266.7	0.13
07/26/2013 08:19	146	1.1	0.2	0.00	15,311.1	0.11
07/26/2013 08:20	146	0.7	0.0	0.00	15,288.9	0.08
07/26/2013 08:21	145	0.6	0.0	0.00	15,288.9	0.05
07/26/2013 08:22	145	0.4	-0.1	0.00	15,288.9	0.05
07/26/2013 08:23	145	0.3	-0.1	0.00	15,311.1	0.03
07/26/2013 08:24	145	0.2	-0.1	0.00	15,288.9	0.03
07/26/2013 08:25	145	0.2	-0.1	0.00	15,311.1	0.03
07/26/2013 08:26	145	0.2	-0.1	0.00	15,288.9	0.03
07/26/2013 08:27	145	0.2	-0.1	0.00	15,288.9	0.03
Total				238.21		20.76

Date/Time Startup Commences: 07/27/2013 05:56
 Gas Turbine Downtime: 8 Hours
 Steam Turbine Downtime: 8 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
07/27/2013 05:56	0	0.0	0.0	0.00	822.2	0.00
07/27/2013 05:57	0	0.0	0.0	0.00	711.1	0.00
07/27/2013 05:58	0	11.8	-5.9	0.00	1,644.4	0.12
07/27/2013 05:59	0	2.6	26.9	0.25	2,422.2	0.04
07/27/2013 06:00	0	2.8	58.7	0.74	3,244.4	0.06
07/27/2013 06:01	0	4.0	185.2	2.93	4,044.4	0.11
07/27/2013 06:02	0	6.5	552.3	9.79	4,533.3	0.19
07/27/2013 06:03	0	11.6	1,050.6	20.82	5,066.7	0.38
07/27/2013 06:04	0	17.3	1,602.3	32.44	5,177.8	0.58
07/27/2013 06:05	0	23.2	2,255.5	45.27	5,133.3	0.76
07/27/2013 06:06	4	24.0	2,209.0	45.49	5,266.7	0.81
07/27/2013 06:07	17	26.0	2,053.6	47.29	5,888.9	0.99
07/27/2013 06:08	30	31.2	1,274.1	34.10	6,844.4	1.37
07/27/2013 06:09	43	31.9	302.6	9.25	7,822.2	1.60
07/27/2013 06:10	56	36.2	64.9	2.25	8,866.7	2.06
07/27/2013 06:11	69	30.0	6.7	0.26	9,911.1	1.92
07/27/2013 06:12	83	27.3	3.3	0.13	10,933.3	1.93
07/27/2013 06:13	97	29.6	2.1	0.11	12,066.7	2.30
07/27/2013 06:14	109	27.6	1.2	0.07	12,955.6	2.31
07/27/2013 06:15	116	23.8	0.6	0.02	13,333.3	2.05
07/27/2013 06:16	124	19.7	0.5	0.02	13,844.4	1.77
07/27/2013 06:17	135	11.5	0.5	0.03	14,511.1	1.06
07/27/2013 06:18	142	5.2	0.5	0.03	15,111.1	0.50
07/27/2013 06:19	145	3.0	0.5	0.03	15,200.0	0.29
07/27/2013 06:20	145	2.0	0.4	0.03	15,155.6	0.19
07/27/2013 06:21	145	1.6	0.3	0.03	15,222.2	0.16
07/27/2013 06:22	145	1.1	0.3	0.03	15,244.4	0.11
07/27/2013 06:23	145	0.8	0.2	0.03	15,222.2	0.08
07/27/2013 06:24	145	0.7	0.1	0.00	15,244.4	0.08
07/27/2013 06:25	145	0.7	0.0	0.00	15,222.2	0.05
07/27/2013 06:26	145	0.5	0.0	0.00	15,244.4	0.05
07/27/2013 06:27	145	0.4	-0.1	0.00	15,244.4	0.05
07/27/2013 06:28	145	0.4	-0.1	0.00	15,244.4	0.05
07/27/2013 06:29	145	0.3	-0.1	0.00	15,244.4	0.03
07/27/2013 06:30	145	0.3	-0.1	0.00	15,244.4	0.03
07/27/2013 06:31	145	0.3	-0.1	0.00	15,266.7	0.03
Total				251.44		24.11

Date/Time Startup Commences: 07/28/2013 09:27
 Gas Turbine Downtime: 10 Hours
 Steam Turbine Downtime: 10 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
07/28/2013 09:27	0	0.0	0.0	0.00	911.1	0.00
07/28/2013 09:28	0	0.0	0.0	0.00	666.7	0.00
07/28/2013 09:29	0	0.0	0.0	0.00	1,666.7	0.00
07/28/2013 09:30	0	2.4	24.6	0.23	2,444.4	0.04
07/28/2013 09:31	0	2.5	61.5	0.79	3,288.9	0.05
07/28/2013 09:32	0	3.5	204.3	3.23	4,044.4	0.09
07/28/2013 09:33	0	5.7	555.2	9.84	4,533.3	0.17
07/28/2013 09:34	0	9.9	1,028.9	19.93	4,955.6	0.31
07/28/2013 09:35	0	15.6	1,621.7	32.55	5,133.3	0.51
07/28/2013 09:36	0	21.0	2,214.1	44.05	5,088.9	0.68
07/28/2013 09:37	5	22.0	2,214.1	45.21	5,222.2	0.74
07/28/2013 09:38	17	25.4	2,044.5	47.26	5,911.1	0.96
07/28/2013 09:39	31	28.0	1,013.3	27.20	6,866.7	1.24
07/28/2013 09:40	44	29.4	224.7	6.95	7,911.1	1.49
07/28/2013 09:41	57	33.7	49.2	1.71	8,888.9	1.93
07/28/2013 09:42	70	24.9	5.6	0.23	9,911.1	1.59
07/28/2013 09:43	84	25.3	2.8	0.12	11,022.2	1.79
07/28/2013 09:44	97	25.5	1.8	0.08	11,955.6	1.96
07/28/2013 09:45	112	23.3	1.0	0.05	13,022.2	1.96
07/28/2013 09:46	123	18.8	0.6	0.02	13,733.3	1.66
07/28/2013 09:47	128	14.0	0.5	0.02	14,044.4	1.28
07/28/2013 09:48	136	9.3	0.5	0.03	14,622.2	0.87
07/28/2013 09:49	144	4.1	0.4	0.03	15,222.2	0.40
07/28/2013 09:50	145	2.7	0.4	0.03	15,288.9	0.27
07/28/2013 09:51	145	1.8	0.3	0.03	15,222.2	0.19
07/28/2013 09:52	145	1.1	0.2	0.03	15,222.2	0.11
07/28/2013 09:53	145	0.9	0.3	0.03	15,244.4	0.08
07/28/2013 09:54	145	0.7	0.2	0.00	15,266.7	0.08
07/28/2013 09:55	145	0.6	0.1	0.00	15,244.4	0.05
07/28/2013 09:56	145	0.5	-0.1	0.00	15,222.2	0.05
07/28/2013 09:57	145	0.4	-0.1	0.00	15,244.4	0.05
07/28/2013 09:58	145	0.3	-0.1	0.00	15,266.7	0.03
07/28/2013 09:59	145	0.3	-0.1	0.00	15,288.9	0.03
07/28/2013 10:00	145	0.2	-0.1	0.00	15,244.4	0.03
07/28/2013 10:01	145	0.2	-0.1	0.00	15,244.4	0.03
Total				239.65		20.72

Date/Time Startup Commences: 07/29/2013 06:48
 Gas Turbine Downtime: 9 Hours
 Steam Turbine Downtime: 9 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
07/29/2013 06:48	0	0.0	0.0	0.00	777.8	0.00
07/29/2013 06:49	0	0.0	0.0	0.00	222.2	0.00
07/29/2013 06:50	0	0.0	0.0	0.00	1,333.3	0.00
07/29/2013 06:51	0	0.7	23.6	0.19	2,022.2	0.01
07/29/2013 06:52	0	0.8	29.5	0.32	2,800.0	0.01
07/29/2013 06:53	0	2.5	86.0	1.27	3,755.6	0.06
07/29/2013 06:54	0	3.4	265.1	4.47	4,311.1	0.09
07/29/2013 06:55	0	6.1	520.7	9.73	4,777.8	0.19
07/29/2013 06:56	0	11.1	841.3	17.03	5,177.8	0.37
07/29/2013 06:57	0	17.3	1,426.7	28.76	5,155.6	0.58
07/29/2013 06:58	3	20.1	1,612.3	33.06	5,244.4	0.68
07/29/2013 06:59	15	22.2	1,447.1	32.81	5,800.0	0.83
07/29/2013 07:00	28	26.7	860.4	22.65	6,733.3	1.15
07/29/2013 07:01	41	28.8	239.3	7.18	7,666.7	1.42
07/29/2013 07:02	55	32.6	57.7	1.97	8,733.3	1.83
07/29/2013 07:03	68	29.4	7.6	0.29	9,844.4	1.86
07/29/2013 07:04	81	25.5	5.3	0.23	10,866.7	1.78
07/29/2013 07:05	95	29.0	3.2	0.15	11,977.8	2.24
07/29/2013 07:06	108	27.3	1.4	0.07	12,933.3	2.26
07/29/2013 07:07	115	24.2	0.6	0.02	13,311.1	2.07
07/29/2013 07:08	123	17.1	0.4	0.02	13,800.0	1.52
07/29/2013 07:09	134	9.8	0.4	0.03	14,488.9	0.91
07/29/2013 07:10	142	3.7	0.4	0.03	15,044.4	0.37
07/29/2013 07:11	145	2.5	0.4	0.03	15,266.7	0.24
07/29/2013 07:12	145	1.6	0.3	0.03	15,222.2	0.16
07/29/2013 07:13	145	1.2	0.3	0.03	15,244.4	0.11
07/29/2013 07:14	145	0.8	0.3	0.03	15,244.4	0.08
07/29/2013 07:15	145	0.7	0.2	0.00	15,244.4	0.05
07/29/2013 07:16	145	0.6	0.0	0.00	15,244.4	0.05
07/29/2013 07:17	145	0.5	0.0	0.00	15,244.4	0.05
07/29/2013 07:18	145	0.4	-0.1	0.00	15,244.4	0.05
07/29/2013 07:19	145	0.3	-0.1	0.00	15,266.7	0.03
07/29/2013 07:20	145	0.3	-0.1	0.00	15,266.7	0.03
07/29/2013 07:21	145	0.2	-0.1	0.00	15,266.7	0.03
07/29/2013 07:22	145	0.2	-0.1	0.00	15,244.4	0.03
Total				160.4		21.14

Date/Time Startup Commences: 07/30/2013 06:42
 Gas Turbine Downtime: 6 Hours
 Steam Turbine Downtime: 6 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
07/30/2013 06:42	0	0.0	0.0	0.00	733.3	0.00
07/30/2013 06:43	0	0.0	0.0	0.00	600.0	0.00
07/30/2013 06:44	0	17.7	-5.9	0.00	1,622.2	0.18
07/30/2013 06:45	0	2.6	26.9	0.25	2,422.2	0.04
07/30/2013 06:46	0	2.8	63.1	0.80	3,266.7	0.06
07/30/2013 06:47	0	3.6	211.6	3.37	4,066.7	0.09
07/30/2013 06:48	0	5.9	505.7	9.01	4,555.6	0.18
07/30/2013 06:49	0	10.1	896.8	18.93	5,400.0	0.35
07/30/2013 06:50	0	15.8	1,348.6	27.54	5,222.2	0.53
07/30/2013 06:51	0	22.5	2,013.2	40.75	5,177.8	0.75
07/30/2013 06:52	2	23.0	1,952.3	39.35	5,155.6	0.77
07/30/2013 06:53	13	24.8	1,772.6	39.12	5,644.4	0.90
07/30/2013 06:54	25	28.4	1,168.0	29.94	6,555.6	1.20
07/30/2013 06:55	38	31.0	327.0	9.55	7,466.7	1.49
07/30/2013 06:56	53	33.2	73.8	2.48	8,600.0	1.83
07/30/2013 06:57	66	34.5	22.9	0.85	9,577.8	2.12
07/30/2013 06:58	79	26.7	4.0	0.17	10,644.4	1.84
07/30/2013 06:59	92	31.1	1.2	0.06	11,711.1	2.35
07/30/2013 07:00	106	29.5	0.9	0.04	12,800.0	2.44
07/30/2013 07:01	113	26.9	0.7	0.02	13,288.9	2.30
07/30/2013 07:02	121	20.7	0.6	0.02	13,711.1	1.82
07/30/2013 07:03	132	12.7	0.5	0.03	14,377.8	1.18
07/30/2013 07:04	141	4.9	0.5	0.03	15,000.0	0.47
07/30/2013 07:05	145	2.7	0.5	0.03	15,244.4	0.27
07/30/2013 07:06	145	1.9	0.4	0.03	15,200.0	0.19
07/30/2013 07:07	145	1.4	0.3	0.03	15,244.4	0.13
07/30/2013 07:08	145	1.3	0.3	0.03	15,244.4	0.13
07/30/2013 07:09	145	1.0	0.2	0.03	15,244.4	0.11
07/30/2013 07:10	145	0.7	0.1	0.00	15,266.7	0.08
07/30/2013 07:11	145	0.6	0.0	0.00	15,266.7	0.05
07/30/2013 07:12	145	0.4	0.0	0.00	15,288.9	0.05
07/30/2013 07:13	145	0.3	-0.1	0.00	15,288.9	0.03
07/30/2013 07:14	145	0.3	-0.1	0.00	15,288.9	0.03
07/30/2013 07:15	145	0.2	-0.1	0.00	15,266.7	0.03
07/30/2013 07:16	145	0.2	-0.1	0.00	15,266.7	0.03
Total				222.46		24.02

Date/Time Startup Commences: 07/31/2013 06:48
 Gas Turbine Downtime: 9 Hours
 Steam Turbine Downtime: 9 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
07/31/2013 06:48	0	0.0	0.0	0.00	755.6	0.00
07/31/2013 06:49	0	0.0	0.0	0.00	533.3	0.00
07/31/2013 06:50	0	0.0	0.0	0.00	1,577.8	0.00
07/31/2013 06:51	0	2.2	24.0	0.22	2,377.8	0.03
07/31/2013 06:52	0	2.1	56.7	0.71	3,200.0	0.04
07/31/2013 06:53	0	3.2	190.5	2.99	4,022.2	0.08
07/31/2013 06:54	0	5.5	447.8	7.97	4,555.6	0.16
07/31/2013 06:55	0	9.4	806.8	18.37	5,822.2	0.36
07/31/2013 06:56	0	15.0	1,220.5	24.82	5,200.0	0.50
07/31/2013 06:57	2	21.5	1,855.1	37.88	5,222.2	0.72
07/31/2013 06:58	13	22.6	1,817.4	40.73	5,733.3	0.83
07/31/2013 06:59	27	27.9	1,297.6	33.83	6,666.7	1.20
07/31/2013 07:00	40	30.1	346.5	10.33	7,622.2	1.48
07/31/2013 07:01	54	32.8	78.9	2.70	8,733.3	1.85
07/31/2013 07:02	66	32.8	9.3	0.35	9,666.7	2.04
07/31/2013 07:03	79	25.9	4.5	0.19	10,711.1	1.78
07/31/2013 07:04	93	29.4	2.6	0.12	11,800.0	2.23
07/31/2013 07:05	107	27.8	1.4	0.07	12,911.1	2.30
07/31/2013 07:06	115	25.1	0.6	0.02	13,333.3	2.14
07/31/2013 07:07	123	20.2	0.4	0.02	13,800.0	1.78
07/31/2013 07:08	133	12.9	0.4	0.03	14,422.2	1.21
07/31/2013 07:09	142	13.1	0.5	0.03	15,044.4	1.26
07/31/2013 07:10	145	3.0	0.4	0.03	15,288.9	0.29
07/31/2013 07:11	145	2.1	0.3	0.03	15,222.2	0.21
07/31/2013 07:12	145	1.5	0.3	0.03	15,244.4	0.16
07/31/2013 07:13	145	1.3	0.3	0.03	15,244.4	0.13
07/31/2013 07:14	145	1.1	0.2	0.03	15,244.4	0.11
07/31/2013 07:15	145	0.8	0.0	0.00	15,266.7	0.08
07/31/2013 07:16	145	0.7	-0.1	0.00	15,266.7	0.05
07/31/2013 07:17	145	0.5	-0.1	0.00	15,244.4	0.05
07/31/2013 07:18	145	0.3	-0.1	0.00	15,244.4	0.03
07/31/2013 07:19	145	0.3	-0.1	0.00	15,266.7	0.03
07/31/2013 07:20	145	0.2	-0.1	0.00	15,266.7	0.03
07/31/2013 07:21	145	0.2	-0.1	0.00	15,288.9	0.03
07/31/2013 07:22	145	0.2	-0.1	0.00	15,288.9	0.03
Total				181.53		23.22

Date/Time Startup Commences: 08/04/2013 06:02
 Gas Turbine Downtime: 80 Hours
 Steam Turbine Downtime: 80 Hours
 Startup Type*: Cold

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
08/04/2013 06:02	0	0.0	0.0	0.00	800.0	0.00
08/04/2013 06:03	0	0.0	0.0	0.00	400.0	0.00
08/04/2013 06:04	0	0.0	0.0	0.00	1,511.1	0.00
08/04/2013 06:05	0	14.3	2,851.4	25.02	2,244.4	0.21
08/04/2013 06:06	0	8.5	2,854.3	33.72	3,022.2	0.16
08/04/2013 06:07	0	10.4	2,345.4	35.87	3,911.1	0.26
08/04/2013 06:08	0	12.0	2,183.6	38.13	4,466.7	0.34
08/04/2013 06:09	0	14.3	2,352.2	45.37	4,933.3	0.46
08/04/2013 06:10	0	18.8	2,615.9	53.19	5,200.0	0.63
08/04/2013 06:11	0	23.2	2,866.6	58.03	5,177.8	0.77
08/04/2013 06:12	2	25.2	3,048.3	62.77	5,266.7	0.86
08/04/2013 06:13	12	29.9	3,100.1	70.58	5,822.2	1.12
08/04/2013 06:14	26	35.6	2,702.7	70.68	6,688.9	1.53
08/04/2013 06:15	39	40.8	1,746.1	52.35	7,666.7	2.01
08/04/2013 06:16	53	43.0	945.5	32.44	8,777.8	2.42
08/04/2013 06:17	66	43.3	316.9	12.16	9,822.2	2.75
08/04/2013 06:18	79	36.0	23.0	0.98	10,800.0	2.51
08/04/2013 06:19	68	41.3	3.7	0.16	11,511.1	3.06
Total				591.45		19.09

Date/Time Startup Commences: 08/04/2013 07:17
 Gas Turbine Downtime: 0 Hours
 Steam Turbine Downtime: 0 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
08/04/2013 07:17	0	0.0	0.0	0.00	644.4	0.00
08/04/2013 07:18	0	0.0	0.0	0.00	88.9	0.00
08/04/2013 07:19	0	0.0	0.0	0.00	1,377.8	0.00
08/04/2013 07:20	0	10.3	39.1	0.31	2,044.4	0.14
08/04/2013 07:21	0	6.2	730.1	7.99	2,800.0	0.11
08/04/2013 07:22	0	7.9	837.6	12.30	3,755.6	0.19
08/04/2013 07:23	0	10.7	1,046.6	17.73	4,333.3	0.30
08/04/2013 07:24	0	14.2	1,325.8	26.15	5,044.4	0.46
08/04/2013 07:25	0	21.9	1,569.6	31.37	5,111.1	0.72
08/04/2013 07:26	0	23.6	1,746.4	34.89	5,111.1	0.78
08/04/2013 07:27	3	26.0	1,909.0	38.98	5,222.2	0.88
08/04/2013 07:28	15	26.9	1,728.3	39.80	5,888.9	1.02
08/04/2013 07:29	28	32.3	1,213.3	32.47	6,844.4	1.42
08/04/2013 07:30	41	34.7	544.4	16.70	7,844.4	1.75
08/04/2013 07:31	55	37.7	195.2	6.79	8,888.9	2.16
08/04/2013 07:32	68	33.6	37.3	1.45	9,911.1	2.15
08/04/2013 07:33	81	28.3	4.0	0.17	10,933.3	1.99
08/04/2013 07:34	95	30.7	1.9	0.08	12,044.4	2.38
08/04/2013 07:35	108	28.3	1.5	0.07	13,000.0	2.36
08/04/2013 07:36	117	24.7	1.3	0.07	13,488.9	2.14
08/04/2013 07:37	126	21.2	1.0	0.05	14,066.7	1.92
08/04/2013 07:38	135	18.1	1.0	0.05	14,600.0	1.71
08/04/2013 07:39	141	16.2	1.0	0.05	15,088.9	1.58
08/04/2013 07:40	145	15.9	1.0	0.05	15,333.3	1.58
08/04/2013 07:41	145	16.1	0.9	0.05	15,244.4	1.57
08/04/2013 07:42	145	15.9	0.8	0.05	15,311.1	1.55
08/04/2013 07:43	145	18.3	0.7	0.05	15,311.1	1.79
08/04/2013 07:44	146	14.1	0.5	0.03	15,355.6	1.39
08/04/2013 07:45	146	8.3	0.4	0.03	15,355.6	0.80
08/04/2013 07:46	146	4.0	0.3	0.03	15,355.6	0.40
08/04/2013 07:47	146	2.5	0.2	0.03	15,333.3	0.24
08/04/2013 07:48	145	1.2	0.2	0.00	15,333.3	0.11
08/04/2013 07:49	146	0.5	0.1	0.00	15,355.6	0.05
08/04/2013 07:50	145	0.4	0.1	0.00	15,333.3	0.05
08/04/2013 07:51	146	0.3	0.0	0.00	15,333.3	0.03
08/04/2013 07:52	146	0.3	0.0	0.00	15,333.3	0.03
08/04/2013 07:53	146	0.3	0.0	0.00	15,333.3	0.03
08/04/2013 07:54	145	0.3	0.0	0.00	15,333.3	0.03
08/04/2013 07:55	142	0.4	-0.1	0.00	15,066.7	0.05
08/04/2013 07:56	141	0.4	-0.1	0.00	14,933.3	0.05
08/04/2013 07:57	140	0.4	-0.1	0.00	14,933.3	0.05
Total				267.79		35.96

Date/Time Startup Commences: 08/06/2013 04:57
 Gas Turbine Downtime: 6 Hours
 Steam Turbine Downtime: 6 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
08/06/2013 04:57	0	0.0	0.0	0.00	733.3	0.00
08/06/2013 04:58	0	0.0	0.0	0.00	911.1	0.00
08/06/2013 04:59	0	0.0	5.9	0.04	1,733.3	0.00
08/06/2013 05:00	0	0.3	25.9	0.25	2,511.1	0.00
08/06/2013 05:01	0	0.8	43.9	0.58	3,377.8	0.02
08/06/2013 05:02	0	1.1	48.3	0.78	4,111.1	0.03
08/06/2013 05:03	0	2.0	71.9	1.29	4,600.0	0.06
08/06/2013 05:04	0	4.2	92.0	2.21	6,133.3	0.16
08/06/2013 05:05	0	6.7	105.4	2.13	5,177.8	0.23
08/06/2013 05:06	3	9.6	122.1	2.49	5,222.2	0.32
08/06/2013 05:07	14	11.6	125.5	2.81	5,733.3	0.43
08/06/2013 05:08	27	18.0	100.5	2.62	6,666.7	0.77
08/06/2013 05:09	41	19.4	64.2	1.92	7,644.4	0.96
08/06/2013 05:10	55	24.1	37.7	1.27	8,666.7	1.35
08/06/2013 05:11	67	25.6	7.8	0.29	9,666.7	1.59
08/06/2013 05:12	80	14.5	3.8	0.17	10,711.1	0.99
08/06/2013 05:13	94	11.6	0.6	0.02	11,844.4	0.89
08/06/2013 05:14	108	9.2	0.4	0.02	12,866.7	0.76
08/06/2013 05:15	114	6.7	0.3	0.02	13,288.9	0.58
08/06/2013 05:16	122	3.7	0.2	0.02	13,688.9	0.33
08/06/2013 05:17	132	1.3	0.2	0.03	14,311.1	0.13
08/06/2013 05:18	140	0.7	0.2	0.03	14,800.0	0.08
08/06/2013 05:19	140	0.6	0.2	0.00	14,755.6	0.05
08/06/2013 05:20	139	0.3	0.2	0.00	14,777.8	0.03
08/06/2013 05:21	140	0.3	0.3	0.03	14,800.0	0.03
08/06/2013 05:22	140	0.2	0.2	0.03	14,800.0	0.03
08/06/2013 05:23	140	0.2	0.0	0.00	14,800.0	0.03
08/06/2013 05:24	140	0.2	-0.1	0.00	14,822.2	0.03
08/06/2013 05:25	140	0.2	-0.1	0.00	14,844.4	0.03
08/06/2013 05:26	140	0.2	-0.1	0.00	14,800.0	0.03
08/06/2013 05:27	140	0.2	-0.1	0.00	14,822.2	0.03
Total				19.05		9.97

Date/Time Startup Commences: 08/08/2013 06:37
 Gas Turbine Downtime: 10 Hours
 Steam Turbine Downtime: 10 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
08/08/2013 06:37	0	0.0	0.0	0.00	955.6	0.00
08/08/2013 06:38	0	0.0	0.0	0.00	844.4	0.00
08/08/2013 06:39	0	14.8	20.7	0.14	1,755.6	0.17
08/08/2013 06:40	0	2.6	27.2	0.27	2,555.6	0.04
08/08/2013 06:41	0	3.4	60.5	0.81	3,422.2	0.08
08/08/2013 06:42	0	4.2	172.2	2.78	4,133.3	0.12
08/08/2013 06:43	0	6.5	405.6	7.30	4,600.0	0.19
08/08/2013 06:44	0	11.1	693.8	14.35	5,288.9	0.38
08/08/2013 06:45	0	16.4	1,130.1	22.78	5,155.6	0.55
08/08/2013 06:46	0	21.2	1,586.9	31.85	5,133.3	0.70
08/08/2013 06:47	6	22.4	1,543.8	31.93	5,288.9	0.76
08/08/2013 06:48	19	25.3	1,316.5	31.23	6,066.7	0.99
08/08/2013 06:49	31	28.5	617.4	16.74	6,933.3	1.27
08/08/2013 06:50	45	30.6	149.3	4.69	8,044.4	1.59
08/08/2013 06:51	58	35.7	39.6	1.40	9,000.0	2.08
08/08/2013 06:52	72	26.0	5.8	0.23	10,088.9	1.69
08/08/2013 06:53	85	27.7	1.8	0.08	11,177.8	1.99
08/08/2013 06:54	99	28.8	0.9	0.04	12,155.6	2.25
08/08/2013 06:55	111	27.6	0.7	0.05	13,177.8	2.35
08/08/2013 06:56	118	20.5	0.5	0.02	13,466.7	1.79
08/08/2013 06:57	128	11.0	0.4	0.02	14,044.4	0.98
08/08/2013 06:58	137	4.7	0.4	0.03	14,733.3	0.44
08/08/2013 06:59	144	2.5	0.4	0.03	15,177.8	0.24
08/08/2013 07:00	145	1.8	0.4	0.03	15,177.8	0.19
08/08/2013 07:01	144	1.3	0.3	0.03	15,155.6	0.13
08/08/2013 07:02	145	0.8	0.3	0.03	15,200.0	0.08
08/08/2013 07:03	145	0.7	0.2	0.03	15,222.2	0.05
08/08/2013 07:04	145	0.6	0.1	0.00	15,222.2	0.05
08/08/2013 07:05	145	0.5	0.0	0.00	15,200.0	0.05
08/08/2013 07:06	145	0.4	-0.1	0.00	15,222.2	0.05
08/08/2013 07:07	145	0.3	-0.1	0.00	15,222.2	0.03
08/08/2013 07:08	145	0.3	-0.1	0.00	15,222.2	0.03
08/08/2013 07:09	145	0.3	-0.1	0.00	15,222.2	0.03
08/08/2013 07:10	145	0.3	-0.1	0.00	15,222.2	0.03
Total				166.89		21.37

Date/Time Startup Commences: 08/09/2013 03:57
 Gas Turbine Downtime: 6 Hours
 Steam Turbine Downtime: 6 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
08/09/2013 03:57	0	0.0	0.0	0.00	644.4	0.00
08/09/2013 03:58	0	0.0	0.0	0.00	400.0	0.00
08/09/2013 03:59	0	0.0	0.0	0.00	1,511.1	0.00
08/09/2013 04:00	0	0.8	23.2	0.21	2,266.7	0.01
08/09/2013 04:01	0	1.9	40.2	0.48	3,066.7	0.04
08/09/2013 04:02	0	2.8	48.3	0.74	3,933.3	0.07
08/09/2013 04:03	0	3.8	70.2	1.22	4,444.4	0.11
08/09/2013 04:04	0	6.1	108.4	2.16	5,088.9	0.20
08/09/2013 04:05	0	9.1	126.4	2.56	5,177.8	0.30
08/09/2013 04:06	0	12.4	151.1	3.03	5,133.3	0.41
08/09/2013 04:07	5	14.2	148.3	3.05	5,266.7	0.48
08/09/2013 04:08	17	19.9	131.2	3.02	5,888.9	0.75
08/09/2013 04:09	30	20.6	99.1	2.64	6,800.0	0.90
08/09/2013 04:10	43	24.7	61.5	1.87	7,777.8	1.24
08/09/2013 04:11	57	30.8	33.4	1.16	8,844.4	1.75
08/09/2013 04:12	70	24.6	5.7	0.22	9,888.9	1.57
08/09/2013 04:13	83	14.5	1.9	0.08	10,955.6	1.01
08/09/2013 04:14	97	11.6	0.8	0.04	12,044.4	0.90
08/09/2013 04:15	109	9.2	0.6	0.02	13,000.0	0.77
08/09/2013 04:16	115	6.3	0.4	0.02	13,244.4	0.53
08/09/2013 04:17	124	3.2	0.3	0.02	13,800.0	0.29
08/09/2013 04:18	134	1.2	0.2	0.03	14,444.4	0.13
08/09/2013 04:19	140	0.7	0.2	0.03	14,822.2	0.05
08/09/2013 04:20	140	0.6	0.2	0.00	14,755.6	0.05
08/09/2013 04:21	140	0.4	0.2	0.00	14,800.0	0.05
08/09/2013 04:22	140	0.3	0.3	0.03	14,800.0	0.03
08/09/2013 04:23	140	0.2	0.2	0.00	14,777.8	0.03
08/09/2013 04:24	140	0.2	0.0	0.00	14,800.0	0.03
08/09/2013 04:25	140	0.2	-0.1	0.00	14,777.8	0.03
08/09/2013 04:26	140	0.3	-0.1	0.00	14,800.0	0.03
08/09/2013 04:27	140	0.3	-0.1	0.00	14,800.0	0.03
08/09/2013 04:28	140	0.4	-0.1	0.00	14,822.2	0.05
Total				22.63		11.84

Date/Time Startup Commences: 08/13/2013 05:15
 Gas Turbine Downtime: 79 Hours
 Steam Turbine Downtime: 79 Hours
 Startup Type*: Cold

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
08/13/2013 05:15	0	0.0	0.0	0.00	755.6	0.00
08/13/2013 05:16	0	0.0	0.0	0.00	955.6	0.00
08/13/2013 05:17	0	53.1	182.9	1.27	1,800.0	0.61
08/13/2013 05:18	0	9.7	2,734.2	27.35	2,600.0	0.16
08/13/2013 05:19	0	11.0	2,424.9	32.33	3,466.7	0.24
08/13/2013 05:20	0	13.3	2,125.7	34.34	4,200.0	0.35
08/13/2013 05:21	0	16.9	2,142.9	38.46	4,666.7	0.50
08/13/2013 05:22	0	22.8	2,421.5	46.58	5,000.0	0.72
08/13/2013 05:23	0	27.0	2,630.3	52.61	5,200.0	0.88
08/13/2013 05:24	0	30.9	2,948.4	58.72	5,177.8	1.01
08/13/2013 05:25	5	32.8	3,084.9	63.81	5,377.8	1.12
08/13/2013 05:26	17	36.4	3,044.2	71.56	6,111.1	1.41
08/13/2013 05:27	30	42.8	2,419.0	64.93	6,977.8	1.89
08/13/2013 05:28	44	45.4	1,362.9	42.41	8,088.9	2.32
08/13/2013 05:29	57	52.2	699.4	24.52	9,111.1	3.01
08/13/2013 05:30	71	42.0	120.0	4.71	10,200.0	2.72
08/13/2013 05:31	84	41.3	4.7	0.21	11,200.0	2.93
08/13/2013 05:32	98	42.3	2.2	0.11	12,266.7	3.29
08/13/2013 05:33	109	38.6	2.1	0.11	13,044.4	3.18
08/13/2013 05:34	117	31.4	2.3	0.12	13,555.6	2.70
08/13/2013 05:35	127	25.0	2.6	0.15	14,222.2	2.25
08/13/2013 05:36	136	19.3	2.4	0.13	14,755.6	1.80
08/13/2013 05:37	140	15.8	1.7	0.10	15,022.2	1.50
08/13/2013 05:38	140	14.4	1.1	0.05	14,955.6	1.36
08/13/2013 05:39	139	12.6	0.7	0.05	14,955.6	1.21
08/13/2013 05:40	140	14.0	0.7	0.05	14,955.6	1.34
08/13/2013 05:41	140	14.7	0.6	0.03	14,977.8	1.39
08/13/2013 05:42	140	15.0	0.5	0.03	14,955.6	1.41
08/13/2013 05:43	140	15.4	0.3	0.03	14,977.8	1.47
08/13/2013 05:44	140	15.8	0.2	0.03	14,977.8	1.49
08/13/2013 05:45	140	16.3	0.2	0.03	14,955.6	1.54
08/13/2013 05:46	140	16.6	0.2	0.00	14,955.6	1.57
08/13/2013 05:47	140	17.0	0.2	0.00	14,977.8	1.60
08/13/2013 05:48	140	17.3	0.1	0.00	14,977.8	1.65
08/13/2013 05:49	140	17.4	0.1	0.00	14,955.6	1.64
08/13/2013 05:50	140	15.8	0.1	0.00	14,955.6	1.49
08/13/2013 05:51	140	9.2	0.1	0.00	14,977.8	0.88
08/13/2013 05:52	140	4.8	0.1	0.00	14,977.8	0.46
08/13/2013 05:53	140	3.0	0.0	0.00	14,955.6	0.28
08/13/2013 05:54	141	2.2	0.0	0.00	14,955.6	0.21
08/13/2013 05:55	140	1.6	0.0	0.00	14,955.6	0.15
08/13/2013 05:56	140	0.8	0.0	0.00	14,933.3	0.08
08/13/2013 05:57	140	0.7	0.0	0.00	14,955.6	0.05
08/13/2013 05:58	140	0.6	0.0	0.00	14,955.6	0.05
08/13/2013 05:59	140	0.4	-0.1	0.00	14,955.6	0.05
08/13/2013 06:00	140	0.3	-0.1	0.00	14,933.3	0.03
08/13/2013 06:01	139	0.3	-0.1	0.00	14,844.4	0.03
08/13/2013 06:02	139	0.3	-0.1	0.00	14,866.7	0.03
08/13/2013 06:03	140	0.3	-0.1	0.00	14,911.1	0.03
08/13/2013 06:04	140	0.3	-0.1	0.00	14,933.3	0.03
08/13/2013 06:05	140	0.3	-0.1	0.00	14,911.1	0.03
Total				564.83		56.14

Date/Time Startup Commences: 08/18/2013 06:44
 Gas Turbine Downtime: 82 Hours
 Steam Turbine Downtime: 82 Hours
 Startup Type*: Cold

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
08/18/2013 06:44	0	0.0	0.0	0.00	955.6	0.00
08/18/2013 06:45	0	0.0	0.0	0.00	844.4	0.00
08/18/2013 06:46	0	41.3	123.9	0.84	1,755.6	0.46
08/18/2013 06:47	0	9.3	2,818.5	27.71	2,555.6	0.15
08/18/2013 06:48	0	10.2	2,604.9	33.85	3,377.8	0.22
08/18/2013 06:49	0	13.0	1,986.3	31.74	4,155.6	0.34
08/18/2013 06:50	0	17.5	2,043.8	36.51	4,644.4	0.51
08/18/2013 06:51	0	22.5	2,328.4	49.96	5,577.8	0.80
08/18/2013 06:52	0	25.6	2,495.7	50.13	5,222.2	0.84
08/18/2013 06:53	0	29.7	2,984.8	59.44	5,177.8	0.97
08/18/2013 06:54	3	29.7	3,018.0	61.66	5,311.1	0.99
08/18/2013 06:55	15	32.5	3,037.7	69.33	5,933.3	1.22
08/18/2013 06:56	28	40.0	2,685.6	70.71	6,844.4	1.74
08/18/2013 06:57	41	43.3	1,539.2	46.70	7,888.9	2.17
08/18/2013 06:58	56	51.1	900.1	30.93	8,933.3	2.89
08/18/2013 06:59	69	44.1	225.1	8.64	9,977.8	2.79
08/18/2013 07:00	81	37.9	5.9	0.24	10,955.6	2.64
08/18/2013 07:01	95	39.8	2.9	0.12	11,911.1	3.01
08/18/2013 07:02	109	34.2	2.4	0.11	12,888.9	2.79
08/18/2013 07:03	122	26.9	2.6	0.14	13,888.9	2.36
08/18/2013 07:04	128	22.2	2.7	0.15	14,244.4	2.01
08/18/2013 07:05	133	18.0	2.4	0.13	14,644.4	1.66
08/18/2013 07:06	139	15.2	1.8	0.10	15,022.2	1.45
08/18/2013 07:07	140	12.7	1.1	0.05	15,022.2	1.21
08/18/2013 07:08	140	10.9	0.7	0.05	15,022.2	1.03
08/18/2013 07:09	140	10.5	0.6	0.03	15,022.2	1.01
08/18/2013 07:10	140	11.9	0.5	0.03	15,022.2	1.14
08/18/2013 07:11	140	12.3	0.4	0.03	15,000.0	1.16
08/18/2013 07:12	140	12.6	0.3	0.03	14,977.8	1.21
08/18/2013 07:13	140	13.0	0.2	0.03	15,000.0	1.24
08/18/2013 07:14	140	13.5	0.2	0.03	15,022.2	1.29
08/18/2013 07:15	140	14.0	0.2	0.00	15,022.2	1.34
08/18/2013 07:16	140	14.5	0.2	0.00	15,000.0	1.39
08/18/2013 07:17	140	15.0	0.1	0.00	15,000.0	1.42
08/18/2013 07:18	140	15.3	0.1	0.00	15,044.4	1.45
08/18/2013 07:19	140	14.7	0.1	0.00	15,022.2	1.39
08/18/2013 07:20	140	9.6	0.1	0.00	15,044.4	0.93
08/18/2013 07:21	140	4.5	0.0	0.00	15,022.2	0.44
08/18/2013 07:22	136	2.8	0.0	0.00	14,711.1	0.25
08/18/2013 07:23	136	1.9	0.0	0.00	14,644.4	0.18
08/18/2013 07:24	135	1.3	0.0	0.00	14,644.4	0.13
08/18/2013 07:25	135	0.9	0.0	0.00	14,644.4	0.08
08/18/2013 07:26	136	0.8	0.0	0.00	14,644.4	0.08
08/18/2013 07:27	135	0.6	-0.1	0.00	14,644.4	0.05
08/18/2013 07:28	136	0.5	-0.1	0.00	14,644.4	0.05
08/18/2013 07:29	135	0.3	-0.1	0.00	14,644.4	0.03
08/18/2013 07:30	136	0.3	-0.1	0.00	14,622.2	0.03
08/18/2013 07:31	136	0.3	-0.2	0.00	14,622.2	0.03
08/18/2013 07:32	135	0.3	-0.2	0.00	14,600.0	0.03
08/18/2013 07:33	135	0.3	-0.2	0.00	14,577.8	0.03
08/18/2013 07:34	136	0.3	-0.2	0.00	14,600.0	0.03
Total				579.42		50.66

Date/Time Startup Commences: 08/19/2013 07:44
 Gas Turbine Downtime: 10 Hours
 Steam Turbine Downtime: 10 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
08/19/2013 07:44	0	0.0	0.0	0.00	822.2	0.00
08/19/2013 07:45	0	0.0	0.0	0.00	200.0	0.00
08/19/2013 07:46	0	0.0	0.0	0.00	1,488.9	0.00
08/19/2013 07:47	0	0.5	24.6	0.21	2,222.2	0.01
08/19/2013 07:48	0	1.1	55.8	0.63	2,955.6	0.02
08/19/2013 07:49	0	2.4	164.4	2.43	3,844.4	0.06
08/19/2013 07:50	0	4.5	516.4	8.70	4,377.8	0.12
08/19/2013 07:51	0	8.9	1,122.1	25.04	5,800.0	0.33
08/19/2013 07:52	0	15.4	1,659.4	32.62	5,111.1	0.50
08/19/2013 07:53	0	21.8	2,328.7	45.39	5,066.7	0.70
08/19/2013 07:54	0	23.0	2,421.8	46.78	5,022.2	0.73
08/19/2013 07:55	5	23.4	2,335.4	47.11	5,244.4	0.78
08/19/2013 07:56	18	25.2	2,040.4	45.87	5,844.4	0.93
08/19/2013 07:57	31	28.3	1,164.0	30.25	6,755.6	1.21
08/19/2013 07:58	44	28.1	287.8	8.58	7,755.6	1.37
08/19/2013 07:59	57	30.1	66.7	2.22	8,688.9	1.66
08/19/2013 08:00	70	22.7	20.3	0.75	9,666.7	1.40
08/19/2013 08:01	84	22.3	6.5	0.28	10,733.3	1.51
08/19/2013 08:02	97	22.5	4.5	0.20	11,755.6	1.68
08/19/2013 08:03	111	21.0	2.4	0.11	12,844.4	1.70
08/19/2013 08:04	123	17.8	1.0	0.05	13,777.8	1.56
08/19/2013 08:05	127	11.0	0.6	0.02	14,000.0	0.96
08/19/2013 08:06	133	10.8	0.5	0.02	14,444.4	0.99
08/19/2013 08:07	135	3.0	0.5	0.02	14,466.7	0.27
08/19/2013 08:08	135	1.7	0.4	0.02	14,400.0	0.15
08/19/2013 08:09	135	1.2	0.5	0.02	14,444.4	0.10
08/19/2013 08:10	135	0.8	0.6	0.02	14,444.4	0.07
08/19/2013 08:11	135	0.7	0.5	0.02	14,444.4	0.05
08/19/2013 08:12	135	0.5	0.2	0.00	14,466.7	0.05
08/19/2013 08:13	135	0.4	0.0	0.00	14,488.9	0.05
08/19/2013 08:14	135	0.3	0.0	0.00	14,466.7	0.02
08/19/2013 08:15	135	0.3	0.0	0.00	14,466.7	0.02
08/19/2013 08:16	135	0.3	0.0	0.00	14,466.7	0.02
08/19/2013 08:17	135	0.2	0.0	0.00	14,488.9	0.02
08/19/2013 08:18	135	0.2	0.0	0.00	14,488.9	0.02
Total				297.36		19.06

Date/Time Startup Commences: 08/21/2013 03:43
 Gas Turbine Downtime: 6 Hours
 Steam Turbine Downtime: 6 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
08/21/2013 03:43	0	0.0	0.0	0.00	911.1	0.00
08/21/2013 03:44	0	0.0	0.0	0.00	711.1	0.00
08/21/2013 03:45	0	8.9	8.9	0.06	1,688.9	0.10
08/21/2013 03:46	0	2.4	26.4	0.25	2,444.4	0.04
08/21/2013 03:47	0	3.1	42.8	0.54	3,244.4	0.06
08/21/2013 03:48	0	4.0	50.2	0.77	4,022.2	0.10
08/21/2013 03:49	0	5.7	79.9	1.39	4,511.1	0.16
08/21/2013 03:50	0	8.3	126.5	2.43	5,000.0	0.27
08/21/2013 03:51	0	12.2	157.2	3.10	5,133.3	0.40
08/21/2013 03:52	0	15.3	203.4	4.00	5,111.1	0.49
08/21/2013 03:53	8	17.5	204.3	4.22	5,377.8	0.59
08/21/2013 03:54	20	21.3	166.5	3.93	6,133.3	0.83
08/21/2013 03:55	33	24.6	104.9	2.84	7,022.2	1.09
08/21/2013 03:56	48	28.7	54.1	1.70	8,177.8	1.49
08/21/2013 03:57	60	35.0	26.9	0.94	9,088.9	2.01
08/21/2013 03:58	74	20.4	5.1	0.19	10,222.2	1.32
08/21/2013 03:59	86	15.0	3.1	0.13	11,200.0	1.06
08/21/2013 04:00	101	11.4	1.8	0.08	12,288.9	0.89
08/21/2013 04:01	112	9.0	0.6	0.02	13,066.7	0.74
08/21/2013 04:02	116	5.1	0.3	0.02	13,177.8	0.43
08/21/2013 04:03	116	2.0	0.2	0.02	13,000.0	0.18
08/21/2013 04:04	119	0.7	0.5	0.02	13,333.3	0.07
08/21/2013 04:05	120	0.4	1.3	0.07	13,311.1	0.05
08/21/2013 04:06	120	0.4	1.3	0.07	13,333.3	0.05
08/21/2013 04:07	120	0.3	0.6	0.02	13,311.1	0.02
08/21/2013 04:08	120	0.2	0.2	0.00	13,333.3	0.02
08/21/2013 04:09	120	0.2	0.1	0.00	13,333.3	0.02
08/21/2013 04:10	123	0.2	0.0	0.00	13,555.6	0.02
08/21/2013 04:11	129	0.2	0.0	0.00	13,977.8	0.02
08/21/2013 04:12	130	0.2	0.0	0.00	14,022.2	0.02
08/21/2013 04:13	133	0.2	0.0	0.00	14,266.7	0.02
Total				26.81		12.56

Date/Time Startup Commences: 08/22/2013 04:42
 Gas Turbine Downtime: 7 Hours
 Steam Turbine Downtime: 7 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
08/22/2013 04:42	0	0.0	0.0	0.00	577.8	0.00
08/22/2013 04:43	0	0.0	0.0	0.00	200.0	0.00
08/22/2013 04:44	0	0.0	0.0	0.00	1,355.6	0.00
08/22/2013 04:45	0	3.9	25.6	0.20	2,044.4	0.05
08/22/2013 04:46	0	2.4	40.7	0.44	2,800.0	0.04
08/22/2013 04:47	0	3.5	49.2	0.71	3,733.3	0.08
08/22/2013 04:48	0	4.4	76.5	1.26	4,288.9	0.12
08/22/2013 04:49	0	6.6	141.2	2.58	4,755.6	0.20
08/22/2013 04:50	0	10.3	205.0	4.05	5,133.3	0.34
08/22/2013 04:51	0	13.7	293.3	5.79	5,133.3	0.44
08/22/2013 04:52	2	16.3	323.1	6.43	5,177.8	0.53
08/22/2013 04:53	11	19.9	285.2	6.07	5,533.3	0.69
08/22/2013 04:54	24	21.3	208.6	5.15	6,422.2	0.86
08/22/2013 04:55	36	25.1	95.8	2.68	7,288.9	1.16
08/22/2013 04:56	51	28.7	48.7	1.58	8,422.2	1.53
08/22/2013 04:57	64	32.5	9.4	0.34	9,422.2	1.94
08/22/2013 04:58	77	20.0	4.8	0.20	10,488.9	1.33
08/22/2013 04:59	89	15.3	3.0	0.14	11,466.7	1.12
08/22/2013 05:00	104	11.0	1.5	0.06	12,555.6	0.88
08/22/2013 05:01	113	8.7	0.6	0.02	13,200.0	0.73
08/22/2013 05:02	119	5.0	0.3	0.02	13,511.1	0.44
08/22/2013 05:03	121	2.1	0.3	0.02	13,400.0	0.18
08/22/2013 05:04	119	0.9	0.4	0.02	13,355.6	0.07
08/22/2013 05:05	120	0.4	1.1	0.07	13,333.3	0.05
08/22/2013 05:06	120	0.3	1.2	0.07	13,355.6	0.02
08/22/2013 05:07	120	0.3	0.7	0.05	13,355.6	0.02
08/22/2013 05:08	120	0.3	0.2	0.00	13,355.6	0.02
08/22/2013 05:09	120	0.2	0.1	0.00	13,355.6	0.02
08/22/2013 05:10	120	0.2	0.1	0.00	13,355.6	0.02
08/22/2013 05:11	120	0.2	0.1	0.00	13,377.8	0.02
08/22/2013 05:12	120	0.2	0.1	0.00	13,377.8	0.02
08/22/2013 05:13	120	0.2	0.1	0.00	13,377.8	0.02
Total				37.95		12.94

Date/Time Startup Commences: 08/23/2013 06:47
 Gas Turbine Downtime: 9 Hours
 Steam Turbine Downtime: 9 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
08/23/2013 06:47	0	0.0	0.0	0.00	888.9	0.00
08/23/2013 06:48	0	0.0	0.0	0.00	200.0	0.00
08/23/2013 06:49	0	0.0	0.0	0.00	1,444.4	0.00
08/23/2013 06:50	0	3.9	26.6	0.22	2,177.8	0.05
08/23/2013 06:51	0	2.8	49.2	0.55	2,911.1	0.05
08/23/2013 06:52	0	3.5	126.5	1.86	3,822.2	0.09
08/23/2013 06:53	0	5.5	365.2	6.15	4,377.8	0.15
08/23/2013 06:54	0	8.7	650.1	14.56	5,822.2	0.32
08/23/2013 06:55	0	13.9	871.9	17.29	5,155.6	0.45
08/23/2013 06:56	0	19.4	1,389.9	27.33	5,111.1	0.62
08/23/2013 06:57	0	21.4	1,465.6	28.69	5,088.9	0.69
08/23/2013 06:58	4	22.6	1,388.1	28.00	5,244.4	0.75
08/23/2013 06:59	15	24.4	1,206.3	26.60	5,733.3	0.89
08/23/2013 07:00	29	28.0	613.9	15.79	6,688.9	1.18
08/23/2013 07:01	42	30.5	164.5	4.89	7,733.3	1.49
08/23/2013 07:02	55	34.5	45.8	1.53	8,755.6	1.91
08/23/2013 07:03	68	31.5	6.8	0.25	9,755.6	1.94
08/23/2013 07:04	81	27.4	2.6	0.11	10,822.2	1.88
08/23/2013 07:05	95	30.9	1.0	0.04	11,888.9	2.33
08/23/2013 07:06	109	29.1	0.8	0.04	12,955.6	2.38
08/23/2013 07:07	116	23.7	0.6	0.02	13,288.9	1.99
08/23/2013 07:08	121	12.5	0.5	0.02	13,488.9	1.07
08/23/2013 07:09	120	12.9	0.5	0.02	13,333.3	1.08
08/23/2013 07:10	120	2.8	0.9	0.05	13,400.0	0.23
08/23/2013 07:11	120	2.2	1.3	0.07	13,355.6	0.18
08/23/2013 07:12	120	1.4	1.1	0.05	13,333.3	0.11
08/23/2013 07:13	120	1.0	0.4	0.02	13,333.3	0.09
08/23/2013 07:14	120	0.9	0.3	0.02	13,333.3	0.07
08/23/2013 07:15	120	0.7	0.3	0.02	13,355.6	0.07
08/23/2013 07:16	120	0.5	0.2	0.00	13,355.6	0.05
08/23/2013 07:17	120	0.3	0.2	0.00	13,355.6	0.02
08/23/2013 07:18	120	0.3	0.2	0.00	13,355.6	0.02
08/23/2013 07:19	120	0.3	0.1	0.00	13,377.8	0.02
08/23/2013 07:20	120	0.3	0.1	0.00	13,400.0	0.02
08/23/2013 07:21	120	0.3	0.1	0.00	13,377.8	0.02
08/23/2013 07:22	120	0.3	0.1	0.00	13,377.8	0.02
Total				174.19		22.23

Date/Time Startup Commences: 08/26/2013 02:15
 Gas Turbine Downtime: 52 Hours
 Steam Turbine Downtime: 52 Hours
 Startup Type*: Warm

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
08/26/2013 02:15	0	0.0	0.0	0.00	933.3	0.00
08/26/2013 02:16	0	0.0	0.0	0.00	733.3	0.00
08/26/2013 02:17	0	0.0	0.0	0.00	1,711.1	0.00
08/26/2013 02:18	0	10.4	2,766.6	26.72	2,511.1	0.16
08/26/2013 02:19	0	11.0	2,662.8	34.15	3,333.3	0.23
08/26/2013 02:20	0	13.9	2,133.5	33.92	4,133.3	0.36
08/26/2013 02:21	0	17.5	2,134.6	37.77	4,600.0	0.51
08/26/2013 02:22	0	22.1	2,406.6	47.11	5,088.9	0.72
08/26/2013 02:23	0	26.3	2,598.7	51.97	5,200.0	0.87
08/26/2013 02:24	0	30.3	2,922.9	58.21	5,177.8	1.00
08/26/2013 02:25	9	32.1	3,090.0	66.03	5,555.6	1.13
08/26/2013 02:26	22	36.7	2,929.4	71.86	6,377.8	1.48
08/26/2013 02:27	34	42.7	2,092.3	58.48	7,266.7	1.96
08/26/2013 02:28	48	45.0	1,170.2	37.80	8,400.0	2.40
08/26/2013 02:29	61	52.8	506.7	18.23	9,355.6	3.12
08/26/2013 02:30	74	36.9	41.9	1.68	10,422.2	2.44
08/26/2013 02:31	88	41.9	3.9	0.18	11,511.1	3.05
08/26/2013 02:32	102	39.2	2.3	0.11	12,511.1	3.10
08/26/2013 02:33	112	34.0	2.3	0.11	13,244.4	2.84
08/26/2013 02:34	121	27.2	2.4	0.12	13,755.6	2.36
08/26/2013 02:35	129	21.7	2.4	0.12	14,288.9	1.96
08/26/2013 02:36	135	16.6	1.9	0.10	14,644.4	1.54
08/26/2013 02:37	135	14.1	1.2	0.08	14,555.6	1.30
08/26/2013 02:38	134	11.9	0.8	0.05	14,577.8	1.10
08/26/2013 02:39	135	12.1	0.8	0.05	14,622.2	1.13
08/26/2013 02:40	135	13.1	0.7	0.03	14,644.4	1.21
08/26/2013 02:41	135	13.3	0.6	0.03	14,644.4	1.23
08/26/2013 02:42	135	13.6	0.3	0.03	14,644.4	1.26
08/26/2013 02:43	136	14.1	0.3	0.03	14,622.2	1.31
08/26/2013 02:44	136	14.6	0.2	0.03	14,622.2	1.36
08/26/2013 02:45	136	15.3	0.2	0.00	14,644.4	1.41
08/26/2013 02:46	135	15.6	0.2	0.00	14,600.0	1.43
08/26/2013 02:47	135	15.9	0.2	0.00	14,600.0	1.48
08/26/2013 02:48	135	16.1	0.1	0.00	14,600.0	1.48
08/26/2013 02:49	135	12.3	0.1	0.00	14,600.0	1.13
08/26/2013 02:50	135	5.5	0.1	0.00	14,600.0	0.50
08/26/2013 02:51	135	3.4	0.1	0.00	14,600.0	0.30
08/26/2013 02:52	136	2.3	0.1	0.00	14,600.0	0.20
08/26/2013 02:53	135	1.5	0.0	0.00	14,577.8	0.15
08/26/2013 02:54	135	1.2	0.0	0.00	14,577.8	0.10
08/26/2013 02:55	135	0.7	0.0	0.00	14,600.0	0.05
08/26/2013 02:56	135	0.5	0.0	0.00	14,577.8	0.05
08/26/2013 02:57	136	0.4	0.0	0.00	14,600.0	0.05
08/26/2013 02:58	136	0.4	-0.1	0.00	14,600.0	0.05
08/26/2013 02:59	135	0.3	-0.1	0.00	14,577.8	0.03
08/26/2013 03:00	135	0.3	-0.1	0.00	14,577.8	0.03
08/26/2013 03:01	135	0.3	-0.1	0.00	14,577.8	0.03
08/26/2013 03:02	135	0.3	-0.1	0.00	14,600.0	0.03
08/26/2013 03:03	135	0.3	-0.1	0.00	14,577.8	0.03
Total				545		49.66

Date/Time Startup Commences: 08/27/2013 04:54
 Gas Turbine Downtime: 7 Hours
 Steam Turbine Downtime: 7 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
08/27/2013 04:54	0	0.0	0.0	0.00	844.4	0.00
08/27/2013 04:55	0	0.0	0.0	0.00	555.6	0.00
08/27/2013 04:56	0	0.0	-5.9	0.00	1,622.2	0.00
08/27/2013 04:57	0	0.4	28.0	0.26	2,400.0	0.00
08/27/2013 04:58	0	0.8	45.9	0.57	3,222.2	0.02
08/27/2013 04:59	0	1.1	66.0	1.02	4,022.2	0.03
08/27/2013 05:00	0	2.7	187.1	3.25	4,511.1	0.08
08/27/2013 05:01	0	5.2	308.8	6.04	5,088.9	0.17
08/27/2013 05:02	0	8.9	394.2	7.82	5,155.6	0.29
08/27/2013 05:03	3	12.4	525.5	10.55	5,222.2	0.41
08/27/2013 05:04	14	14.9	497.6	10.85	5,666.7	0.54
08/27/2013 05:05	27	20.4	309.8	7.90	6,622.2	0.85
08/27/2013 05:06	40	21.7	102.6	3.00	7,600.0	1.04
08/27/2013 05:07	54	26.8	49.7	1.65	8,644.4	1.47
08/27/2013 05:08	66	27.5	7.1	0.26	9,622.2	1.67
08/27/2013 05:09	79	23.8	3.4	0.15	10,711.1	1.62
08/27/2013 05:10	94	24.3	2.1	0.10	11,777.8	1.82
08/27/2013 05:11	108	14.4	1.0	0.04	12,822.2	1.17
08/27/2013 05:12	116	9.5	0.4	0.02	13,333.3	0.80
08/27/2013 05:13	126	4.6	0.3	0.02	13,888.9	0.41
08/27/2013 05:14	130	2.8	0.2	0.02	14,133.3	0.24
08/27/2013 05:15	130	1.2	0.2	0.02	14,044.4	0.12
08/27/2013 05:16	129	0.6	0.4	0.02	14,088.9	0.05
08/27/2013 05:17	130	0.3	0.8	0.05	14,088.9	0.02
08/27/2013 05:18	130	0.3	0.7	0.05	14,088.9	0.02
08/27/2013 05:19	130	0.3	0.3	0.02	14,088.9	0.02
08/27/2013 05:20	130	0.3	0.0	0.00	14,088.9	0.02
08/27/2013 05:21	130	0.3	0.0	0.00	14,111.1	0.02
08/27/2013 05:22	130	0.2	0.0	0.00	14,111.1	0.02
08/27/2013 05:23	130	0.2	0.0	0.00	14,088.9	0.02
08/27/2013 05:24	130	0.2	0.0	0.00	14,111.1	0.02
08/27/2013 05:25	130	0.2	0.0	0.00	14,111.1	0.02
Total				53.68		12.98

Date/Time Startup Commences: 08/30/2013 03:57
 Gas Turbine Downtime: 6 Hours
 Steam Turbine Downtime: 6 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
08/30/2013 03:57	0	0.0	0.0	0.00	933.3	0.00
08/30/2013 03:58	0	0.0	0.0	0.00	822.2	0.00
08/30/2013 03:59	0	0.0	8.9	0.06	1,711.1	0.00
08/30/2013 04:00	0	0.3	26.9	0.25	2,466.7	0.00
08/30/2013 04:01	0	0.7	45.0	0.57	3,288.9	0.02
08/30/2013 04:02	0	1.4	50.9	0.79	4,044.4	0.03
08/30/2013 04:03	0	3.2	78.2	1.36	4,533.3	0.09
08/30/2013 04:04	0	5.3	108.9	2.12	5,044.4	0.16
08/30/2013 04:05	0	8.1	130.6	2.58	5,133.3	0.26
08/30/2013 04:06	0	11.0	167.8	3.29	5,088.9	0.35
08/30/2013 04:07	5	12.8	159.9	3.21	5,222.2	0.42
08/30/2013 04:08	17	14.5	138.7	3.15	5,888.9	0.54
08/30/2013 04:09	30	19.4	105.4	2.78	6,844.4	0.84
08/30/2013 04:10	45	21.8	60.6	1.86	7,977.8	1.10
08/30/2013 04:11	57	28.6	31.8	1.09	8,911.1	1.61
08/30/2013 04:12	70	20.8	5.0	0.19	9,955.6	1.32
08/30/2013 04:13	84	12.8	2.4	0.09	11,022.2	0.89
08/30/2013 04:14	98	10.2	1.6	0.08	12,000.0	0.78
08/30/2013 04:15	112	6.8	0.7	0.05	13,088.9	0.56
08/30/2013 04:16	119	4.1	0.3	0.02	13,422.2	0.35
08/30/2013 04:17	125	2.1	0.2	0.02	13,777.8	0.19
08/30/2013 04:18	125	1.1	0.2	0.02	13,733.3	0.09
08/30/2013 04:19	125	0.5	0.3	0.02	13,711.1	0.05
08/30/2013 04:20	125	0.3	0.9	0.05	13,733.3	0.02
08/30/2013 04:21	125	0.3	0.9	0.05	13,711.1	0.02
08/30/2013 04:22	125	0.3	0.5	0.02	13,733.3	0.02
08/30/2013 04:23	125	0.3	0.1	0.00	13,733.3	0.02
08/30/2013 04:24	125	0.2	0.1	0.00	13,733.3	0.02
08/30/2013 04:25	125	0.2	0.1	0.00	13,755.6	0.02
08/30/2013 04:26	125	0.2	0.1	0.00	13,755.6	0.02
08/30/2013 04:27	125	0.3	0.1	0.00	13,733.3	0.02
Total				23.72		9.81

Date/Time Startup Commences: 09/02/2013 07:37
 Gas Turbine Downtime: 10 Hours
 Steam Turbine Downtime: 10 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
09/02/2013 07:37	0	0.0	0.0	0.00	777.8	0.00
09/02/2013 07:38	0	0.0	0.0	0.00	400.0	0.00
09/02/2013 07:39	0	0.0	0.0	0.00	1,533.3	0.00
09/02/2013 07:40	0	0.4	26.6	0.23	2,266.7	0.01
09/02/2013 07:41	0	0.8	71.6	0.83	3,022.2	0.02
09/02/2013 07:42	0	1.5	231.8	3.47	3,888.9	0.03
09/02/2013 07:43	0	4.1	578.2	9.78	4,400.0	0.11
09/02/2013 07:44	0	8.6	1,102.7	20.64	4,866.7	0.27
09/02/2013 07:45	0	14.5	1,661.1	32.66	5,111.1	0.47
09/02/2013 07:46	0	21.2	2,318.5	45.19	5,066.7	0.68
09/02/2013 07:47	2	22.2	2,403.3	47.05	5,088.9	0.72
09/02/2013 07:48	6	22.8	2,272.3	45.25	5,177.8	0.75
09/02/2013 07:49	18	25.3	2,084.0	47.74	5,955.6	0.95
09/02/2013 07:50	31	28.0	1,040.3	27.48	6,866.7	1.22
09/02/2013 07:51	45	27.9	217.2	6.68	8,000.0	1.42
09/02/2013 07:52	58	31.9	45.8	1.58	8,933.3	1.81
09/02/2013 07:53	71	23.5	5.9	0.22	9,955.6	1.49
09/02/2013 07:54	84	23.8	3.0	0.13	10,911.1	1.65
09/02/2013 07:55	98	24.1	2.1	0.10	11,955.6	1.83
09/02/2013 07:56	112	22.1	1.1	0.04	12,933.3	1.80
09/02/2013 07:57	123	17.1	0.7	0.02	13,755.6	1.49
09/02/2013 07:58	125	10.5	0.6	0.02	13,800.0	0.92
09/02/2013 07:59	125	4.8	0.6	0.02	13,755.6	0.43
09/02/2013 08:00	125	2.4	0.6	0.02	13,688.9	0.21
09/02/2013 08:01	125	1.5	1.0	0.05	13,733.3	0.12
09/02/2013 08:02	125	1.2	1.1	0.05	13,733.3	0.09
09/02/2013 08:03	125	1.0	0.8	0.05	13,733.3	0.09
09/02/2013 08:04	125	0.8	0.3	0.02	13,755.6	0.07
09/02/2013 08:05	125	0.6	0.2	0.00	13,755.6	0.05
09/02/2013 08:06	125	0.5	0.2	0.00	13,755.6	0.05
09/02/2013 08:07	125	0.4	0.2	0.00	13,755.6	0.05
09/02/2013 08:08	125	0.3	0.1	0.00	13,777.8	0.02
09/02/2013 08:09	125	0.3	0.1	0.00	13,755.6	0.02
09/02/2013 08:10	125	0.3	0.1	0.00	13,755.6	0.02
09/02/2013 08:11	125	0.3	0.1	0.00	13,755.6	0.02
Total				289.32		18.88

Date/Time Startup Commences: 09/05/2013 08:47
 Gas Turbine Downtime: 1 Hours
 Steam Turbine Downtime: 1 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
09/05/2013 08:47	0	0.0	0.0	0.00	555.6	0.00
09/05/2013 08:48	0	0.0	0.0	0.00	222.2	0.00
09/05/2013 08:49	0	0.0	0.0	0.00	1,111.1	0.00
09/05/2013 08:50	0	0.0	17.7	0.13	1,955.6	0.00
09/05/2013 08:51	0	0.8	28.9	0.30	2,688.9	0.01
09/05/2013 08:52	0	3.3	38.2	0.53	3,555.6	0.07
09/05/2013 08:53	0	6.5	47.4	0.76	4,155.6	0.17
09/05/2013 08:54	0	10.1	67.3	1.21	4,644.4	0.30
09/05/2013 08:55	0	15.1	81.9	1.61	5,111.1	0.49
09/05/2013 08:56	0	19.2	94.8	1.86	5,111.1	0.62
09/05/2013 08:57	2	22.2	104.4	2.06	5,111.1	0.72
09/05/2013 08:58	5	24.4	105.2	2.07	5,133.3	0.79
09/05/2013 08:59	16	26.1	99.2	2.23	5,844.4	0.96
09/05/2013 09:00	29	31.2	86.1	2.23	6,711.1	1.33
09/05/2013 09:01	42	35.5	57.0	1.71	7,777.8	1.75
09/05/2013 09:02	56	42.7	32.1	1.08	8,755.6	2.36
09/05/2013 09:03	69	34.9	7.1	0.27	9,733.3	2.16
09/05/2013 09:04	82	15.3	4.9	0.20	10,666.7	1.03
09/05/2013 09:05	96	8.6	3.0	0.14	11,755.6	0.65
09/05/2013 09:06	108	6.5	1.1	0.07	12,600.0	0.52
09/05/2013 09:07	110	3.9	0.3	0.02	12,622.2	0.30
09/05/2013 09:08	110	2.0	0.2	0.00	12,577.8	0.15
09/05/2013 09:09	110	0.7	0.5	0.02	12,644.4	0.07
09/05/2013 09:10	111	0.4	1.0	0.04	12,666.7	0.04
09/05/2013 09:11	120	0.3	1.0	0.05	13,377.8	0.02
09/05/2013 09:12	125	0.3	0.3	0.02	13,688.9	0.02
09/05/2013 09:13	125	0.3	0.1	0.00	13,711.1	0.02
09/05/2013 09:14	125	0.2	0.2	0.00	13,711.1	0.02
09/05/2013 09:15	125	0.2	0.1	0.00	13,733.3	0.02
09/05/2013 09:16	125	0.2	0.1	0.00	13,711.1	0.02
09/05/2013 09:17	125	0.2	0.0	0.00	13,733.3	0.02
09/05/2013 09:18	125	0.2	0.1	0.00	13,711.1	0.02
Total				18.61		14.65

Date/Time Startup Commences: 09/10/2013 04:57
 Gas Turbine Downtime: 5 Hours
 Steam Turbine Downtime: 5 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
09/10/2013 04:57	0	0.0	0.0	0.00	555.6	0.00
09/10/2013 04:58	0	0.0	0.0	0.00	355.6	0.00
09/10/2013 04:59	0	0.0	0.0	0.00	1,200.0	0.00
09/10/2013 05:00	0	0.0	22.4	0.16	1,866.7	0.00
09/10/2013 05:01	0	0.6	28.3	0.28	2,600.0	0.01
09/10/2013 05:02	0	1.4	50.3	0.68	3,511.1	0.03
09/10/2013 05:03	0	2.7	72.9	1.16	4,155.6	0.07
09/10/2013 05:04	0	4.0	134.4	2.40	4,644.4	0.12
09/10/2013 05:05	0	7.4	213.1	4.25	5,200.0	0.24
09/10/2013 05:06	0	10.7	335.5	6.55	5,088.9	0.35
09/10/2013 05:07	0	13.6	386.6	7.51	5,066.7	0.43
09/10/2013 05:08	7	15.1	345.9	6.95	5,244.4	0.49
09/10/2013 05:09	19	20.3	261.4	6.04	6,022.2	0.77
09/10/2013 05:10	32	21.7	133.5	3.56	6,955.6	0.95
09/10/2013 05:11	47	24.8	59.4	1.85	8,111.1	1.26
09/10/2013 05:12	59	32.6	31.8	1.09	9,000.0	1.85
09/10/2013 05:13	72	20.1	4.8	0.19	10,066.7	1.28
09/10/2013 05:14	86	14.1	1.4	0.06	11,111.1	0.99
09/10/2013 05:15	100	10.6	0.7	0.04	12,133.3	0.81
09/10/2013 05:16	114	8.8	0.5	0.02	13,133.3	0.72
09/10/2013 05:17	120	4.6	0.3	0.02	13,400.0	0.39
09/10/2013 05:18	120	2.3	0.2	0.02	13,333.3	0.21
09/10/2013 05:19	120	1.2	0.3	0.02	13,311.1	0.09
09/10/2013 05:20	120	0.6	0.9	0.05	13,355.6	0.05
09/10/2013 05:21	120	0.5	1.1	0.05	13,333.3	0.05
09/10/2013 05:22	120	0.4	0.8	0.05	13,333.3	0.05
09/10/2013 05:23	121	0.3	0.3	0.02	13,400.0	0.02
09/10/2013 05:24	125	0.3	0.2	0.00	13,666.7	0.02
09/10/2013 05:25	125	0.3	0.2	0.00	13,666.7	0.02
09/10/2013 05:26	125	0.3	0.2	0.00	13,688.9	0.02
09/10/2013 05:27	125	0.3	0.2	0.00	13,688.9	0.02
09/10/2013 05:28	125	0.4	0.1	0.00	13,688.9	0.05
Total				43.02		11.36

Date/Time Startup Commences: 09/11/2013 04:57
 Gas Turbine Downtime: 6 Hours
 Steam Turbine Downtime: 6 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
09/11/2013 04:57	0	0.0	0.0	0.00	844.4	0.00
09/11/2013 04:58	0	0.0	0.0	0.00	444.4	0.00
09/11/2013 04:59	0	0.0	0.0	0.00	1,555.6	0.00
09/11/2013 05:00	0	2.4	25.2	0.22	2,311.1	0.04
09/11/2013 05:01	0	2.7	46.9	0.56	3,133.3	0.05
09/11/2013 05:02	0	3.6	52.7	0.80	3,977.8	0.09
09/11/2013 05:03	0	5.5	85.1	1.46	4,466.7	0.15
09/11/2013 05:04	0	7.9	137.4	2.77	5,244.4	0.26
09/11/2013 05:05	0	11.6	168.6	3.33	5,155.6	0.38
09/11/2013 05:06	0	15.3	232.3	4.57	5,133.3	0.49
09/11/2013 05:07	4	17.5	225.4	4.58	5,288.9	0.58
09/11/2013 05:08	17	21.4	191.0	4.29	5,866.7	0.79
09/11/2013 05:09	30	24.6	127.8	3.35	6,844.4	1.07
09/11/2013 05:10	43	28.3	69.7	2.10	7,866.7	1.40
09/11/2013 05:11	56	34.5	37.4	1.27	8,822.2	1.92
09/11/2013 05:12	70	25.9	7.8	0.29	9,911.1	1.61
09/11/2013 05:13	83	16.3	1.9	0.08	11,000.0	1.13
09/11/2013 05:14	97	12.6	0.5	0.02	12,022.2	0.95
09/11/2013 05:15	110	9.4	0.4	0.02	13,044.4	0.78
09/11/2013 05:16	117	5.7	0.3	0.02	13,311.1	0.48
09/11/2013 05:17	125	2.7	0.2	0.02	13,844.4	0.24
09/11/2013 05:18	126	1.0	0.2	0.02	13,777.8	0.09
09/11/2013 05:19	124	0.5	0.5	0.02	13,733.3	0.05
09/11/2013 05:20	125	0.4	1.1	0.07	13,733.3	0.05
09/11/2013 05:21	125	0.3	1.2	0.07	13,755.6	0.02
09/11/2013 05:22	125	0.3	0.6	0.02	13,755.6	0.02
09/11/2013 05:23	125	0.2	0.2	0.00	13,755.6	0.02
09/11/2013 05:24	125	0.2	0.2	0.00	13,777.8	0.02
09/11/2013 05:25	126	0.2	0.2	0.00	13,800.0	0.02
09/11/2013 05:26	126	0.2	0.1	0.00	13,800.0	0.02
09/11/2013 05:27	125	0.2	0.1	0.00	13,777.8	0.02
09/11/2013 05:28	125	0.2	0.1	0.00	13,800.0	0.02
Total				29.95		12.76

Date/Time Startup Commences: 09/13/2013 05:44
 Gas Turbine Downtime: 31 Hours
 Steam Turbine Downtime: 31 Hours
 Startup Type*: warm

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
09/13/2013 05:44	0	0.0	0.0	0.00	666.7	0.00
09/13/2013 05:45	0	0.0	0.0	0.00	200.0	0.00
09/13/2013 05:46	0	0.0	0.0	0.00	1,377.8	0.00
09/13/2013 05:47	0	24.8	102.7	0.80	2,022.2	0.32
09/13/2013 05:48	0	9.8	2,917.2	31.57	2,822.2	0.17
09/13/2013 05:49	0	12.7	2,365.9	34.08	3,755.6	0.30
09/13/2013 05:50	0	16.0	2,157.3	40.64	4,911.1	0.50
09/13/2013 05:51	0	18.8	2,295.1	42.05	4,777.8	0.56
09/13/2013 05:52	0	24.0	2,463.7	49.14	5,200.0	0.78
09/13/2013 05:53	0	28.0	2,785.0	55.31	5,177.8	0.91
09/13/2013 05:54	3	29.9	3,060.3	62.60	5,333.3	1.01
09/13/2013 05:55	15	33.6	3,143.3	70.72	5,866.7	1.25
09/13/2013 05:56	27	39.4	2,534.2	65.67	6,755.6	1.68
09/13/2013 05:57	40	44.3	1,508.0	44.98	7,777.8	2.17
09/13/2013 05:58	54	48.3	929.7	31.37	8,800.0	2.68
09/13/2013 05:59	67	47.6	288.6	10.80	9,755.6	2.93
09/13/2013 06:00	80	36.9	8.1	0.33	10,800.0	2.52
09/13/2013 06:01	94	40.0	5.0	0.22	11,933.3	3.01
09/13/2013 06:02	107	35.4	4.0	0.20	12,911.1	2.88
09/13/2013 06:03	116	28.5	3.5	0.18	13,422.2	2.41
09/13/2013 06:04	121	22.7	3.0	0.16	13,622.2	1.96
09/13/2013 06:05	120	17.9	3.1	0.16	13,488.9	1.53
09/13/2013 06:06	116	13.8	7.2	0.36	13,222.2	1.16
09/13/2013 06:07	119	16.4	5.2	0.28	13,466.7	1.38
09/13/2013 06:08	123	15.1	4.5	0.24	13,711.1	1.32
09/13/2013 06:09	124	14.9	4.8	0.26	13,777.8	1.30
09/13/2013 06:10	125	14.6	5.2	0.28	13,822.2	1.28
09/13/2013 06:11	125	14.9	5.5	0.28	13,844.4	1.30
09/13/2013 06:12	125	16.2	5.2	0.28	13,844.4	1.42
09/13/2013 06:13	125	16.5	4.8	0.26	13,822.2	1.44
09/13/2013 06:14	125	16.9	4.6	0.24	13,822.2	1.47
09/13/2013 06:15	125	17.6	4.7	0.26	13,822.2	1.54
09/13/2013 06:16	125	18.1	4.7	0.26	13,822.2	1.59
09/13/2013 06:17	125	17.4	4.7	0.26	13,822.2	1.52
09/13/2013 06:18	125	11.6	4.6	0.24	13,777.8	1.02
09/13/2013 06:19	125	5.8	4.6	0.24	13,777.8	0.50
09/13/2013 06:20	122	3.8	4.6	0.23	13,600.0	0.33
09/13/2013 06:21	122	2.7	4.5	0.23	13,511.1	0.23
09/13/2013 06:22	124	2.3	4.3	0.24	13,711.1	0.21
09/13/2013 06:23	117	1.4	4.4	0.23	13,177.8	0.11
09/13/2013 06:24	121	1.0	4.6	0.23	13,466.7	0.09
09/13/2013 06:25	122	0.6	4.7	0.23	13,511.1	0.05
09/13/2013 06:26	116	0.5	4.6	0.23	13,133.3	0.05
09/13/2013 06:27	118	0.4	4.7	0.23	13,288.9	0.05
09/13/2013 06:28	120	0.4	4.5	0.23	13,400.0	0.02
09/13/2013 06:29	119	0.3	4.4	0.23	13,400.0	0.02
09/13/2013 06:30	115	0.3	4.8	0.25	13,066.7	0.02
09/13/2013 06:31	117	0.3	5.0	0.25	13,244.4	0.02
09/13/2013 06:32	114	0.4	4.9	0.24	12,955.6	0.04
09/13/2013 06:33	116	0.4	5.4	0.27	13,111.1	0.05
09/13/2013 06:34	116	0.5	6.3	0.32	13,200.0	0.05
09/13/2013 06:35	116	0.6	6.2	0.31	13,066.7	0.04
09/13/2013 06:36	118	0.7	5.9	0.30	13,333.3	0.07
09/13/2013 06:37	113	0.8	5.5	0.26	12,844.4	0.07
09/13/2013 06:38	114	0.9	5.5	0.27	13,022.2	0.07
09/13/2013 06:39	115	1.0	5.7	0.29	13,044.4	0.09
09/13/2013 06:40	115	1.0	6.3	0.31	13,066.7	0.09
09/13/2013 06:41	115	1.0	6.9	0.34	13,066.7	0.09
09/13/2013 06:42	115	1.0	6.9	0.36	13,066.7	0.09
09/13/2013 06:43	115	1.0	6.9	0.34	13,088.9	0.09
09/13/2013 06:44	115	1.1	7.1	0.36	13,088.9	0.09
09/13/2013 06:45	115	1.1	7.4	0.38	13,066.7	0.09

09/13/2013 06:46	115	1.2	7.4	0.38	13,066.7	0.11
09/13/2013 06:47	115	1.3	7.5	0.38	13,088.9	0.11
09/13/2013 06:48	115	1.3	7.5	0.38	13,088.9	0.11
09/13/2013 06:49	115	1.4	7.4	0.38	13,066.7	0.11
09/13/2013 06:50	115	1.4	7.4	0.38	13,066.7	0.11
09/13/2013 06:51	115	1.3	7.3	0.36	13,066.7	0.11
09/13/2013 06:52	115	1.4	7.3	0.36	13,088.9	0.11
09/13/2013 06:53	115	1.4	7.3	0.36	13,088.9	0.11
09/13/2013 06:54	115	1.4	7.3	0.36	13,088.9	0.11
09/13/2013 06:55	115	1.4	7.4	0.38	13,088.9	0.11
09/13/2013 06:56	115	1.4	7.4	0.38	13,066.7	0.11
09/13/2013 06:57	115	1.4	7.4	0.38	13,088.9	0.11
09/13/2013 06:58	115	1.4	7.5	0.38	13,088.9	0.11
09/13/2013 06:59	115	1.4	7.5	0.38	13,088.9	0.11
09/13/2013 07:00	115	1.4	7.5	0.38	13,088.9	0.11
09/13/2013 07:01	115	1.4	7.6	0.38	13,066.7	0.11
09/13/2013 07:02	115	1.4	7.6	0.38	13,088.9	0.11
09/13/2013 07:03	115	1.4	7.6	0.38	13,088.9	0.11
09/13/2013 07:04	115	1.4	7.6	0.38	13,088.9	0.11
09/13/2013 07:05	115	1.4	7.7	0.38	13,066.7	0.11
09/13/2013 07:06	115	1.3	7.7	0.38	13,088.9	0.11
09/13/2013 07:07	115	1.3	7.7	0.38	13,088.9	0.11
09/13/2013 07:08	115	1.3	7.7	0.38	13,088.9	0.11
09/13/2013 07:09	115	1.3	7.7	0.38	13,066.7	0.11
09/13/2013 07:10	115	1.3	7.7	0.38	13,088.9	0.11
09/13/2013 07:11	115	1.3	7.7	0.38	13,088.9	0.11
09/13/2013 07:12	115	1.3	7.7	0.38	13,088.9	0.11
09/13/2013 07:13	115	1.3	7.8	0.40	13,088.9	0.11
09/13/2013 07:14	115	1.3	7.8	0.40	13,088.9	0.11
09/13/2013 07:15	115	1.3	7.9	0.40	13,111.1	0.11
09/13/2013 07:16	115	1.3	7.9	0.40	13,088.9	0.11
09/13/2013 07:17	115	1.3	8.0	0.40	13,111.1	0.11
09/13/2013 07:18	115	1.3	8.1	0.40	13,066.7	0.11
09/13/2013 07:19	115	1.3	8.1	0.40	13,066.7	0.11
09/13/2013 07:20	115	1.3	8.1	0.40	13,088.9	0.11
09/13/2013 07:21	115	1.3	8.1	0.40	13,111.1	0.11
09/13/2013 07:22	115	1.3	8.1	0.40	13,088.9	0.11
09/13/2013 07:23	115	1.3	8.1	0.40	13,088.9	0.11
09/13/2013 07:24	115	1.3	8.2	0.40	13,111.1	0.11
09/13/2013 07:25	115	1.3	8.3	0.43	13,111.1	0.11
09/13/2013 07:26	114	1.2	8.0	0.40	13,111.1	0.11
09/13/2013 07:27	112	1.1	7.5	0.38	12,888.9	0.09
09/13/2013 07:28	115	1.2	6.9	0.34	13,088.9	0.09
09/13/2013 07:29	116	1.3	6.3	0.32	13,200.0	0.11
09/13/2013 07:30	113	1.2	6.3	0.31	12,911.1	0.09
09/13/2013 07:31	114	1.0	6.9	0.34	13,044.4	0.09
09/13/2013 07:32	112	1.0	6.8	0.33	12,844.4	0.09
09/13/2013 07:33	110	1.2	6.9	0.33	12,733.3	0.09
09/13/2013 07:34	110	1.3	7.9	0.39	12,688.9	0.11
09/13/2013 07:35	110	1.3	8.7	0.41	12,688.9	0.11
09/13/2013 07:36	110	1.3	8.2	0.39	12,711.1	0.11
09/13/2013 07:37	110	1.3	7.7	0.37	12,688.9	0.11
09/13/2013 07:38	110	1.4	7.6	0.37	12,711.1	0.11
09/13/2013 07:39	110	1.4	7.4	0.37	12,733.3	0.11
09/13/2013 07:40	110	1.4	6.6	0.33	12,711.1	0.11
09/13/2013 07:41	110	1.5	5.7	0.28	12,733.3	0.13
09/13/2013 07:42	110	1.5	5.4	0.26	12,711.1	0.13
09/13/2013 07:43	109	1.4	5.2	0.26	12,666.7	0.11
09/13/2013 07:44	107	1.4	5.1	0.24	12,555.6	0.11
09/13/2013 07:45	107	1.8	5.1	0.24	12,688.9	0.15
09/13/2013 07:46	107	0.6	118.4	5.78	12,733.3	0.04
09/13/2013 07:47	107	0.0	2.2	0.11	12,755.6	0.00
09/13/2013 07:48	107	0.0	0.2	0.00	12,733.3	0.00
09/13/2013 07:49	107	0.0	0.2	0.00	12,755.6	0.00
09/13/2013 07:50	107	0.2	0.0	0.00	12,755.6	0.02
09/13/2013 07:51	107	1.6	0.0	0.00	12,755.6	0.13
09/13/2013 07:52	106	1.5	0.0	0.00	12,644.4	0.13
09/13/2013 07:53	104	1.5	0.0	0.00	12,488.9	0.13
09/13/2013 07:54	105	1.5	0.0	0.00	12,577.8	0.13

09/13/2013 07:55	104	1.5	0.0	0.00	12,555.6	0.13
09/13/2013 07:56	104	2.4	1.8	0.09	12,533.3	0.19
09/13/2013 07:57	104	2.5	2.6	0.13	12,555.6	0.19
09/13/2013 07:58	104	2.5	2.6	0.13	12,555.6	0.19
09/13/2013 07:59	104	2.5	2.6	0.13	12,533.3	0.19
09/13/2013 08:00	104	3.0	2.6	0.13	12,533.3	0.24
09/13/2013 08:01	104	24.8	19.0	0.90	12,533.3	1.95
09/13/2013 08:02	104	26.5	20.6	0.99	12,533.3	2.10
09/13/2013 08:03	104	26.5	20.6	0.99	12,533.3	2.10
09/13/2013 08:04	104	26.5	20.6	0.99	12,533.3	2.10
09/13/2013 08:05	104	37.9	24.6	1.18	12,533.3	3.01
09/13/2013 08:06	104	20.9	4.0	0.19	12,533.3	1.65
09/13/2013 08:07	104	1.4	39.0	1.87	12,533.3	0.11
09/13/2013 08:08	104	1.3	5.1	0.24	12,555.6	0.11
09/13/2013 08:09	104	1.3	4.3	0.22	12,555.6	0.11
09/13/2013 08:10	104	1.2	4.1	0.19	12,533.3	0.09
09/13/2013 08:11	104	1.1	3.8	0.17	12,555.6	0.09
09/13/2013 08:12	105	1.1	3.5	0.17	12,600.0	0.09
09/13/2013 08:13	106	1.1	3.4	0.17	12,666.7	0.09
09/13/2013 08:14	107	1.1	3.2	0.15	12,711.1	0.09
09/13/2013 08:15	107	1.1	3.4	0.17	12,733.3	0.09
09/13/2013 08:16	108	1.1	3.6	0.18	12,800.0	0.09
09/13/2013 08:17	109	1.2	3.7	0.18	12,866.7	0.09
09/13/2013 08:18	109	1.2	3.9	0.20	12,888.9	0.09
09/13/2013 08:19	109	1.3	4.1	0.20	12,866.7	0.11
09/13/2013 08:20	109	1.3	4.3	0.22	12,866.7	0.11
Total				590.02		72.57

Date/Time Startup Commences: 09/16/2013 03:34
 Gas Turbine Downtime: 67 Hours
 Steam Turbine Downtime: 67 Hours
 Startup Type*: Cold

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
09/16/2013 03:34	0	0.0	0.0	0.00	933.3	0.00
09/16/2013 03:35	0	0.0	0.0	0.00	622.2	0.00
09/16/2013 03:36	0	0.0	0.0	0.00	1,666.7	0.00
09/16/2013 03:37	0	10.8	2,870.4	27.16	2,466.7	0.17
09/16/2013 03:38	0	10.7	2,717.1	34.51	3,311.1	0.22
09/16/2013 03:39	0	12.9	2,065.8	32.57	4,111.1	0.33
09/16/2013 03:40	0	16.5	2,052.4	36.21	4,600.0	0.48
09/16/2013 03:41	0	22.1	2,327.6	45.42	5,088.9	0.71
09/16/2013 03:42	0	25.5	2,528.6	50.43	5,200.0	0.84
09/16/2013 03:43	0	29.5	2,912.0	57.83	5,177.8	0.97
09/16/2013 03:44	3	31.5	3,082.2	61.99	5,244.4	1.04
09/16/2013 03:45	14	35.0	3,044.2	68.49	5,866.7	1.30
09/16/2013 03:46	27	40.8	2,644.6	68.07	6,711.1	1.72
09/16/2013 03:47	39	45.9	1,587.5	47.23	7,755.6	2.25
09/16/2013 03:48	54	51.5	934.7	31.46	8,777.8	2.86
09/16/2013 03:49	67	49.5	280.8	10.61	9,844.4	3.07
09/16/2013 03:50	80	39.1	5.6	0.24	10,866.7	2.68
09/16/2013 03:51	94	42.3	2.4	0.10	12,000.0	3.21
09/16/2013 03:52	104	38.0	1.9	0.09	12,777.8	3.07
09/16/2013 03:53	101	30.8	2.1	0.11	12,333.3	2.39
09/16/2013 03:54	104	23.3	2.6	0.13	12,333.3	1.82
09/16/2013 03:55	114	19.7	3.5	0.18	13,200.0	1.63
09/16/2013 03:56	115	16.5	3.6	0.18	13,222.2	1.38
09/16/2013 03:57	115	14.1	2.6	0.14	13,200.0	1.18
09/16/2013 03:58	115	13.2	1.2	0.07	13,133.3	1.10
09/16/2013 03:59	115	12.6	0.7	0.05	13,111.1	1.03
09/16/2013 04:00	115	12.6	0.6	0.02	13,133.3	1.04
09/16/2013 04:01	115	12.7	0.5	0.02	13,111.1	1.06
09/16/2013 04:02	115	13.1	0.5	0.02	13,111.1	1.08
09/16/2013 04:03	115	14.0	0.5	0.02	13,111.1	1.17
09/16/2013 04:04	115	15.0	0.4	0.02	13,088.9	1.23
09/16/2013 04:05	116	15.4	0.4	0.02	13,111.1	1.28
09/16/2013 04:06	115	15.8	0.3	0.02	13,088.9	1.30
09/16/2013 04:07	115	16.5	0.3	0.02	13,088.9	1.37
09/16/2013 04:08	115	17.0	0.3	0.02	13,088.9	1.41
09/16/2013 04:09	115	17.5	0.3	0.02	13,088.9	1.46
09/16/2013 04:10	115	18.0	0.3	0.02	13,088.9	1.48
09/16/2013 04:11	119	14.6	0.3	0.02	13,311.1	1.23
09/16/2013 04:12	124	9.4	0.2	0.00	13,733.3	0.82
09/16/2013 04:13	124	4.7	0.2	0.00	13,733.3	0.40
09/16/2013 04:14	125	2.9	0.2	0.00	13,755.6	0.26
09/16/2013 04:15	125	2.0	0.1	0.00	13,777.8	0.17
09/16/2013 04:16	125	1.2	0.0	0.00	13,755.6	0.09
09/16/2013 04:17	125	0.9	0.0	0.00	13,800.0	0.07
09/16/2013 04:18	126	0.8	0.0	0.00	13,844.4	0.07
09/16/2013 04:19	126	0.5	0.0	0.00	13,822.2	0.05
09/16/2013 04:20	125	0.3	-0.1	0.00	13,800.0	0.02
09/16/2013 04:21	125	0.3	-0.1	0.00	13,800.0	0.02
09/16/2013 04:22	125	0.3	-0.1	0.00	13,822.2	0.02
09/16/2013 04:23	125	0.3	-0.1	0.00	13,800.0	0.02
09/16/2013 04:24	125	0.3	-0.1	0.00	13,800.0	0.02
09/16/2013 04:25	125	0.3	-0.1	0.00	13,800.0	0.02
Total				573.51		52.61

Date/Time Startup Commences: 09/17/2013 06:48
 Gas Turbine Downtime: 9 Hours
 Steam Turbine Downtime: 9 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
09/17/2013 06:48	0	0.0	0.0	0.00	577.8	0.00
09/17/2013 06:49	0	0.0	0.0	0.00	400.0	0.00
09/17/2013 06:50	0	0.0	0.0	0.00	1,555.6	0.00
09/17/2013 06:51	0	0.8	25.7	0.23	2,288.9	0.01
09/17/2013 06:52	0	1.1	243.5	2.84	3,044.4	0.02
09/17/2013 06:53	0	2.5	469.7	7.04	3,911.1	0.06
09/17/2013 06:54	0	5.1	800.7	13.65	4,444.4	0.14
09/17/2013 06:55	0	9.4	1,138.0	21.62	4,955.6	0.30
09/17/2013 06:56	0	15.0	1,460.9	28.76	5,133.3	0.48
09/17/2013 06:57	0	21.7	2,002.6	39.26	5,111.1	0.70
09/17/2013 06:58	1	22.2	1,982.8	38.86	5,111.1	0.72
09/17/2013 06:59	13	23.6	1,895.5	40.87	5,622.2	0.84
09/17/2013 07:00	26	29.1	1,536.1	38.49	6,533.3	1.20
09/17/2013 07:01	40	31.7	632.5	18.28	7,533.3	1.51
09/17/2013 07:02	54	33.8	169.5	5.60	8,622.2	1.85
09/17/2013 07:03	67	31.3	23.3	0.86	9,622.2	1.90
09/17/2013 07:04	79	25.8	3.6	0.15	10,622.2	1.73
09/17/2013 07:05	93	28.4	1.3	0.06	11,733.3	2.11
09/17/2013 07:06	107	26.6	0.9	0.04	12,777.8	2.15
09/17/2013 07:07	115	22.9	0.7	0.02	13,200.0	1.90
09/17/2013 07:08	124	18.5	0.5	0.02	13,733.3	1.60
09/17/2013 07:09	130	16.1	0.5	0.02	14,155.6	1.43
09/17/2013 07:10	130	12.7	0.5	0.02	14,066.7	1.13
09/17/2013 07:11	129	8.9	0.7	0.05	14,066.7	0.80
09/17/2013 07:12	130	3.1	0.9	0.05	14,111.1	0.27
09/17/2013 07:13	130	2.0	0.8	0.05	14,066.7	0.17
09/17/2013 07:14	130	1.4	0.4	0.02	14,066.7	0.12
09/17/2013 07:15	130	1.3	0.2	0.00	14,066.7	0.12
09/17/2013 07:16	130	1.1	0.1	0.00	14,066.7	0.10
09/17/2013 07:17	130	0.8	0.1	0.00	14,088.9	0.07
09/17/2013 07:18	130	0.7	0.1	0.00	14,088.9	0.05
09/17/2013 07:19	130	0.5	0.1	0.00	14,066.7	0.05
09/17/2013 07:20	130	0.4	0.0	0.00	14,088.9	0.05
09/17/2013 07:21	130	0.3	0.0	0.00	14,088.9	0.02
09/17/2013 07:22	130	0.3	0.0	0.00	14,088.9	0.02
09/17/2013 07:23	130	0.3	0.0	0.00	14,088.9	0.02
Total				256.86		23.64

Date/Time Startup Commences: 09/20/2013 11:45
 Gas Turbine Downtime: 74 Hours
 Steam Turbine Downtime: 74 Hours
 Startup Type*: Cold

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
09/20/2013 11:45	0	0.0	0.0	0.00	555.6	0.00
09/20/2013 11:46	0	0.0	0.0	0.00	111.1	0.00
09/20/2013 11:47	0	0.0	0.0	0.00	1,333.3	0.00
09/20/2013 11:48	0	20.7	82.6	0.65	2,044.4	0.27
09/20/2013 11:49	0	8.7	2,882.0	31.19	2,822.2	0.15
09/20/2013 11:50	0	10.2	2,217.3	31.94	3,755.6	0.24
09/20/2013 11:51	0	13.0	1,938.0	32.21	4,333.3	0.36
09/20/2013 11:52	0	16.1	2,131.9	39.07	4,777.8	0.48
09/20/2013 11:53	0	22.8	2,417.9	47.18	5,088.9	0.73
09/20/2013 11:54	0	26.2	2,695.7	52.61	5,088.9	0.85
09/20/2013 11:55	0	29.3	2,989.3	57.84	5,044.4	0.93
09/20/2013 11:56	6	32.1	3,028.7	62.22	5,355.6	1.08
09/20/2013 11:57	16	36.8	3,048.3	69.37	5,933.3	1.37
09/20/2013 11:58	26	41.0	2,596.5	65.28	6,555.6	1.70
09/20/2013 11:59	35	43.4	1,870.9	51.82	7,222.2	1.98
09/20/2013 12:00	46	43.7	1,143.9	35.49	8,088.9	2.23
09/20/2013 12:01	55	50.1	659.4	22.09	8,733.3	2.77
09/20/2013 12:02	59	34.2	233.3	8.11	9,066.7	1.96
09/20/2013 12:03	59	32.8	231.0	8.03	9,066.7	1.88
09/20/2013 12:04	59	33.7	702.2	24.66	9,155.6	1.95
09/20/2013 12:05	60	33.0	1,333.6	47.05	9,200.0	1.92
09/20/2013 12:06	58	32.5	1,430.2	49.98	9,111.1	1.87
Total				736.79		24.72

Date/Time Startup Commences: 09/22/2013 13:55
 Gas Turbine Downtime: 49 Hours
 Steam Turbine Downtime: 49 Hours
 Startup Type*: Warm

Sample Time	CT1 Load Mwe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
09/22/2013 13:55	0	0.0	0.0	0.00	955.6	0.00
09/22/2013 13:56	0	0.0	0.0	0.00	844.4	0.00
09/22/2013 13:57	0	53.1	194.7	1.31	1,755.6	0.59
09/22/2013 13:58	0	10.4	2,916.0	28.58	2,555.6	0.17
09/22/2013 13:59	0	10.7	2,637.0	34.39	3,400.0	0.23
09/22/2013 14:00	0	13.0	2,032.0	32.39	4,155.6	0.34
09/22/2013 14:01	0	17.3	2,092.1	37.09	4,622.2	0.51
09/22/2013 14:02	0	22.8	2,370.5	46.07	5,066.7	0.73
09/22/2013 14:03	0	26.2	2,479.6	49.03	5,155.6	0.86
09/22/2013 14:04	0	31.1	2,944.9	57.72	5,111.1	1.01
09/22/2013 14:05	4	32.1	3,090.0	62.68	5,288.9	1.07
09/22/2013 14:06	13	34.0	3,001.7	67.28	5,844.4	1.25
09/22/2013 14:07	24	39.5	2,709.4	67.89	6,533.3	1.63
09/22/2013 14:08	34	43.5	1,992.5	55.19	7,222.2	1.98
09/22/2013 14:09	46	43.9	1,156.5	36.28	8,177.8	2.27
09/22/2013 14:10	57	51.3	629.3	21.46	8,888.9	2.88
09/22/2013 14:11	68	36.7	139.9	5.21	9,711.1	2.25
09/22/2013 14:12	79	36.6	22.9	0.92	10,555.6	2.44
09/22/2013 14:13	90	39.6	7.5	0.33	11,244.4	2.81
09/22/2013 14:14	100	35.0	6.7	0.31	12,133.3	2.68
09/22/2013 14:15	111	33.0	5.9	0.29	12,955.6	2.71
09/22/2013 14:16	115	26.4	4.2	0.20	13,200.0	2.19
09/22/2013 14:17	115	21.8	2.5	0.14	13,200.0	1.81
09/22/2013 14:18	116	19.4	1.5	0.07	13,177.8	1.63
09/22/2013 14:19	116	18.5	1.0	0.05	13,177.8	1.54
09/22/2013 14:20	116	18.0	0.8	0.05	13,155.6	1.49
09/22/2013 14:21	115	17.8	0.7	0.05	13,111.1	1.48
09/22/2013 14:22	115	17.9	0.7	0.05	13,111.1	1.48
09/22/2013 14:23	115	18.2	0.6	0.02	13,088.9	1.50
09/22/2013 14:24	115	18.6	0.6	0.02	13,111.1	1.53
09/22/2013 14:25	115	19.0	0.5	0.02	13,111.1	1.57
09/22/2013 14:26	115	19.5	0.5	0.02	13,111.1	1.62
09/22/2013 14:27	115	19.7	0.4	0.02	13,133.3	1.64
09/22/2013 14:28	115	19.8	0.4	0.02	13,111.1	1.64
09/22/2013 14:29	115	20.0	0.4	0.02	13,088.9	1.66
09/22/2013 14:30	115	18.7	0.3	0.02	13,088.9	1.55
09/22/2013 14:31	115	10.8	0.3	0.02	13,111.1	0.90
09/22/2013 14:32	115	5.6	0.3	0.02	13,088.9	0.45
09/22/2013 14:33	115	3.6	0.3	0.02	13,088.9	0.29
09/22/2013 14:34	115	1.6	0.3	0.02	13,088.9	0.13
09/22/2013 14:35	115	0.9	0.3	0.02	13,088.9	0.07
09/22/2013 14:36	115	0.7	0.3	0.02	13,088.9	0.07
09/22/2013 14:37	115	0.5	0.3	0.02	13,088.9	0.04
09/22/2013 14:38	115	0.3	0.2	0.00	13,088.9	0.02
09/22/2013 14:39	115	0.3	0.2	0.00	13,066.7	0.02
09/22/2013 14:40	115	0.3	0.2	0.00	13,066.7	0.02
09/22/2013 14:41	115	0.3	0.2	0.00	13,066.7	0.02
09/22/2013 14:42	115	0.2	0.2	0.00	13,088.9	0.02
09/22/2013 14:43	115	0.2	0.1	0.00	13,088.9	0.02
09/22/2013 14:44	115	0.2	0.1	0.00	13,088.9	0.02
Total				605.33		54.83

Date/Time Startup Commences: 09/23/2013 04:42
 Gas Turbine Downtime: 6 Hours
 Steam Turbine Downtime: 6 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
09/23/2013 04:42	0	0.0	0.0	0.00	577.8	0.00
09/23/2013 04:43	0	0.0	0.0	0.00	311.1	0.00
09/23/2013 04:44	0	0.0	0.0	0.00	1,466.7	0.00
09/23/2013 04:45	0	0.4	23.2	0.20	2,244.4	0.01
09/23/2013 04:46	0	1.4	43.3	0.51	3,044.4	0.03
09/23/2013 04:47	0	2.1	51.8	0.78	3,911.1	0.05
09/23/2013 04:48	0	3.6	114.2	1.95	4,444.4	0.10
09/23/2013 04:49	0	5.7	231.2	4.40	4,955.6	0.18
09/23/2013 04:50	0	9.3	280.0	5.56	5,177.8	0.30
09/23/2013 04:51	0	12.4	345.9	6.84	5,155.6	0.41
09/23/2013 04:52	0	14.6	321.2	6.32	5,133.3	0.48
09/23/2013 04:53	10	15.3	227.0	4.80	5,511.1	0.54
09/23/2013 04:54	24	20.5	163.7	3.99	6,355.6	0.82
09/23/2013 04:55	36	22.7	93.9	2.61	7,266.7	1.05
09/23/2013 04:56	50	26.0	49.1	1.58	8,400.0	1.38
09/23/2013 04:57	63	31.0	6.0	0.21	9,333.3	1.82
09/23/2013 04:58	76	16.7	4.0	0.16	10,466.7	1.11
09/23/2013 04:59	90	12.9	1.2	0.06	11,533.3	0.93
09/23/2013 05:00	104	9.7	0.9	0.04	12,666.7	0.78
09/23/2013 05:01	112	9.3	0.6	0.02	13,200.0	0.77
09/23/2013 05:02	118	4.4	0.3	0.02	13,511.1	0.37
09/23/2013 05:03	121	1.7	0.3	0.02	13,466.7	0.14
09/23/2013 05:04	120	0.8	0.3	0.02	13,377.8	0.07
09/23/2013 05:05	120	0.7	1.1	0.05	13,400.0	0.07
09/23/2013 05:06	120	0.4	1.2	0.07	13,400.0	0.05
09/23/2013 05:07	120	0.3	0.8	0.05	13,400.0	0.02
09/23/2013 05:08	120	0.2	0.1	0.00	13,400.0	0.02
09/23/2013 05:09	120	0.2	0.0	0.00	13,400.0	0.02
09/23/2013 05:10	121	0.2	0.0	0.00	13,400.0	0.02
09/23/2013 05:11	120	0.2	0.0	0.00	13,400.0	0.02
09/23/2013 05:12	120	0.2	0.0	0.00	13,400.0	0.02
09/23/2013 05:13	120	0.2	0.0	0.00	13,400.0	0.02
Total				40.26		11.6

Date/Time Startup Commences: 09/24/2013 04:42
 Gas Turbine Downtime: 7 Hours
 Steam Turbine Downtime: 7 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
09/24/2013 04:42	0	0.0	0.0	0.00	577.8	0.00
09/24/2013 04:43	0	0.0	0.0	0.00	844.4	0.00
09/24/2013 04:44	0	0.0	11.8	0.08	1,755.6	0.00
09/24/2013 04:45	0	0.7	27.5	0.27	2,533.3	0.01
09/24/2013 04:46	0	1.2	45.3	0.59	3,422.2	0.02
09/24/2013 04:47	0	2.2	68.8	1.08	4,111.1	0.06
09/24/2013 04:48	0	4.4	198.5	3.48	4,577.8	0.13
09/24/2013 04:49	0	7.4	293.3	5.75	5,111.1	0.24
09/24/2013 04:50	0	11.0	390.8	7.73	5,155.6	0.35
09/24/2013 04:51	0	14.0	473.0	9.31	5,133.3	0.46
09/24/2013 04:52	9	14.9	395.9	8.30	5,466.7	0.52
09/24/2013 04:53	22	21.3	279.2	6.69	6,244.4	0.85
09/24/2013 04:54	34	22.5	117.1	3.20	7,133.3	1.01
09/24/2013 04:55	49	26.3	54.0	1.71	8,266.7	1.37
09/24/2013 04:56	61	31.4	25.5	0.90	9,222.2	1.83
09/24/2013 04:57	75	17.7	3.9	0.16	10,377.8	1.16
09/24/2013 04:58	89	13.8	1.0	0.04	11,400.0	1.00
09/24/2013 04:59	102	10.2	0.7	0.04	12,422.2	0.79
09/24/2013 05:00	114	6.7	0.5	0.02	13,288.9	0.57
09/24/2013 05:01	122	4.0	0.3	0.02	13,622.2	0.35
09/24/2013 05:02	125	1.7	0.2	0.02	13,800.0	0.14
09/24/2013 05:03	125	0.9	0.2	0.02	13,733.3	0.07
09/24/2013 05:04	125	0.7	0.6	0.02	13,777.8	0.07
09/24/2013 05:05	125	0.4	0.9	0.05	13,777.8	0.05
09/24/2013 05:06	125	0.3	0.8	0.05	13,755.6	0.02
09/24/2013 05:07	125	0.2	0.3	0.02	13,755.6	0.02
09/24/2013 05:08	125	0.2	0.1	0.00	13,777.8	0.02
09/24/2013 05:09	125	0.2	0.1	0.00	13,777.8	0.02
09/24/2013 05:10	125	0.2	0.1	0.00	13,777.8	0.02
09/24/2013 05:11	125	0.2	0.1	0.00	13,777.8	0.02
09/24/2013 05:12	125	0.2	0.1	0.00	13,777.8	0.02
Total				49.55		11.19

Date/Time Startup Commences: 09/27/2013 02:35
 Gas Turbine Downtime: 52 Hours
 Steam Turbine Downtime: 52 Hours
 Startup Type*: Warm

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
09/27/2013 02:35	0	0.0	0.0	0.00	911.1	0.00
09/27/2013 02:36	0	0.0	0.0	0.00	622.2	0.00
09/27/2013 02:37	0	0.0	0.0	0.00	1,600.0	0.00
09/27/2013 02:38	0	12.3	2,789.1	25.43	2,377.8	0.18
09/27/2013 02:39	0	11.2	2,833.2	34.78	3,200.0	0.22
09/27/2013 02:40	0	14.0	2,221.7	34.65	4,066.7	0.36
09/27/2013 02:41	0	17.5	2,227.5	38.92	4,555.6	0.50
09/27/2013 02:42	0	23.2	2,478.4	49.85	5,244.4	0.76
09/27/2013 02:43	0	27.0	2,530.3	50.89	5,244.4	0.89
09/27/2013 02:44	0	32.5	2,900.1	58.33	5,244.4	1.08
09/27/2013 02:45	4	34.0	3,028.9	62.73	5,400.0	1.16
09/27/2013 02:46	10	37.8	2,981.1	65.30	5,711.1	1.36
09/27/2013 02:47	21	41.7	2,696.7	65.73	6,355.6	1.67
09/27/2013 02:48	30	45.8	2,010.7	54.15	7,022.2	2.03
09/27/2013 02:49	40	47.9	1,352.0	40.33	7,777.8	2.35
09/27/2013 02:50	51	51.9	772.4	25.61	8,644.4	2.83
09/27/2013 02:51	61	52.4	276.1	9.88	9,333.3	3.09
09/27/2013 02:52	71	37.0	23.4	0.90	10,133.3	2.36
09/27/2013 02:53	80	40.4	6.8	0.28	10,844.4	2.77
09/27/2013 02:54	90	41.5	5.3	0.24	11,666.7	3.06
09/27/2013 02:55	100	36.3	4.9	0.23	12,377.8	2.84
09/27/2013 02:56	111	29.7	4.0	0.20	13,177.8	2.46
09/27/2013 02:57	115	23.1	2.8	0.14	13,422.2	1.95
09/27/2013 02:58	115	18.1	1.8	0.09	13,355.6	1.53
09/27/2013 02:59	116	15.8	1.1	0.05	13,311.1	1.32
09/27/2013 03:00	119	15.4	0.9	0.05	13,533.3	1.32
09/27/2013 03:01	120	15.2	0.7	0.05	13,533.3	1.30
09/27/2013 03:02	120	15.2	0.7	0.05	13,533.3	1.30
09/27/2013 03:03	120	16.9	0.6	0.02	13,533.3	1.44
09/27/2013 03:04	120	17.4	0.5	0.02	13,466.7	1.48
09/27/2013 03:05	120	17.7	0.4	0.02	13,466.7	1.50
09/27/2013 03:06	120	18.1	0.4	0.02	13,488.9	1.55
09/27/2013 03:07	120	18.6	0.3	0.02	13,466.7	1.59
09/27/2013 03:08	120	19.0	0.3	0.02	13,488.9	1.62
09/27/2013 03:09	120	19.7	0.3	0.02	13,488.9	1.69
09/27/2013 03:10	120	20.0	0.3	0.02	13,488.9	1.71
09/27/2013 03:11	120	14.3	0.3	0.02	13,466.7	1.22
09/27/2013 03:12	120	9.2	0.3	0.02	13,466.7	0.78
09/27/2013 03:13	120	4.3	0.3	0.02	13,444.4	0.37
09/27/2013 03:14	120	3.0	0.3	0.02	13,466.7	0.25
09/27/2013 03:15	120	2.3	0.3	0.02	13,466.7	0.18
09/27/2013 03:16	120	1.3	0.3	0.02	13,466.7	0.12
09/27/2013 03:17	120	1.0	0.3	0.02	13,466.7	0.09
09/27/2013 03:18	120	0.8	0.2	0.00	13,466.7	0.07
09/27/2013 03:19	120	0.6	0.2	0.00	13,444.4	0.05
09/27/2013 03:20	121	0.4	0.2	0.00	13,466.7	0.05
09/27/2013 03:21	120	0.3	0.2	0.00	13,444.4	0.02
09/27/2013 03:22	120	0.3	0.1	0.00	13,444.4	0.02
09/27/2013 03:23	120	0.3	0.0	0.00	13,466.7	0.02
09/27/2013 03:24	120	0.4	0.0	0.00	13,444.4	0.05
09/27/2013 03:25	120	0.5	0.0	0.00	13,444.4	0.05
09/27/2013 03:26	120	0.6	0.0	0.00	13,466.7	0.05
Total				619.16		56.66

Date/Time Startup Commences: 09/30/2013 03:15
 Gas Turbine Downtime: 29 Hours
 Steam Turbine Downtime: 29 Hours
 Startup Type*: Warm

Sample Time	CT1 Load Mwe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
09/30/2013 03:15	0	0.0	0.0	0.00	866.7	0.00
09/30/2013 03:16	0	0.0	0.0	0.00	377.8	0.00
09/30/2013 03:17	0	0.0	0.0	0.00	1,422.2	0.00
09/30/2013 03:18	0	19.7	141.6	1.13	2,088.9	0.26
09/30/2013 03:19	0	9.0	2,767.7	30.67	2,888.9	0.16
09/30/2013 03:20	0	11.8	2,332.5	33.99	3,800.0	0.28
09/30/2013 03:21	0	14.9	2,143.9	36.36	4,422.2	0.42
09/30/2013 03:22	0	18.1	2,358.3	47.04	5,200.0	0.60
09/30/2013 03:23	0	23.6	2,515.5	50.17	5,200.0	0.78
09/30/2013 03:24	0	27.5	2,705.9	54.19	5,222.2	0.90
09/30/2013 03:25	2	30.3	3,043.2	61.47	5,266.7	1.01
09/30/2013 03:26	14	32.1	3,006.6	67.39	5,844.4	1.18
09/30/2013 03:27	27	38.7	2,618.9	68.08	6,777.8	1.66
09/30/2013 03:28	40	43.3	1,578.8	47.10	7,777.8	2.13
09/30/2013 03:29	54	46.4	879.9	29.70	8,800.0	2.58
09/30/2013 03:30	67	44.5	237.2	8.98	9,866.7	2.77
09/30/2013 03:31	80	36.3	6.9	0.30	10,844.4	2.49
09/30/2013 03:32	94	39.9	4.1	0.18	11,977.8	3.02
09/30/2013 03:33	107	35.7	3.2	0.15	12,911.1	2.92
09/30/2013 03:34	115	28.2	2.7	0.14	13,400.0	2.39
09/30/2013 03:35	116	21.4	1.8	0.09	13,311.1	1.80
09/30/2013 03:36	115	15.7	1.3	0.07	13,200.0	1.31
09/30/2013 03:37	115	13.5	1.6	0.07	13,244.4	1.13
09/30/2013 03:38	115	14.4	1.8	0.09	13,222.2	1.20
09/30/2013 03:39	115	14.1	1.5	0.07	13,222.2	1.18
09/30/2013 03:40	115	14.5	0.8	0.05	13,200.0	1.20
09/30/2013 03:41	116	15.8	0.8	0.05	13,200.0	1.31
09/30/2013 03:42	116	16.2	0.7	0.05	13,177.8	1.35
09/30/2013 03:43	116	16.6	0.7	0.05	13,177.8	1.38
09/30/2013 03:44	115	17.3	0.6	0.02	13,177.8	1.45
09/30/2013 03:45	115	18.0	0.5	0.02	13,155.6	1.49
09/30/2013 03:46	115	18.6	0.5	0.02	13,155.6	1.53
09/30/2013 03:47	115	18.5	0.4	0.02	13,133.3	1.53
09/30/2013 03:48	115	11.8	0.4	0.02	13,133.3	0.97
09/30/2013 03:49	115	5.7	0.3	0.02	13,133.3	0.47
09/30/2013 03:50	115	3.5	0.3	0.02	13,155.6	0.29
09/30/2013 03:51	115	2.3	0.3	0.02	13,133.3	0.20
09/30/2013 03:52	115	1.7	0.3	0.02	13,133.3	0.14
09/30/2013 03:53	115	1.0	0.3	0.02	13,133.3	0.09
09/30/2013 03:54	115	0.9	0.3	0.02	13,133.3	0.07
09/30/2013 03:55	115	0.7	0.3	0.02	13,111.1	0.07
09/30/2013 03:56	115	0.5	0.3	0.02	13,111.1	0.05
09/30/2013 03:57	115	0.4	0.3	0.02	13,133.3	0.05
09/30/2013 03:58	115	0.3	0.3	0.02	13,111.1	0.02
09/30/2013 03:59	115	0.3	0.3	0.02	13,133.3	0.02
09/30/2013 04:00	115	0.3	0.2	0.00	13,133.3	0.02
09/30/2013 04:01	115	0.3	0.2	0.00	13,133.3	0.02
09/30/2013 04:02	115	0.4	0.2	0.00	13,133.3	0.05
Total				537.95		45.94

Date/Time Startup Commences: 10/14/2013 02:17
 Gas Turbine Downtime: 316 Hours
 Steam Turbine Downtime: 316 Hours
 Startup Type*: Cold

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
10/14/2013 02:17	0	0.0	0.0	0.00	755.6	0.00
10/14/2013 02:18	0	0.0	0.0	0.00	600.0	0.00
10/14/2013 02:19	0	0.0	0.0	0.00	1,622.2	0.00
10/14/2013 02:20	0	7.7	2,758.3	25.39	2,400.0	0.12
10/14/2013 02:21	0	7.5	2,865.8	35.41	3,222.2	0.15
10/14/2013 02:22	0	10.1	2,215.3	34.74	4,088.9	0.26
10/14/2013 02:23	0	13.1	2,225.8	39.08	4,577.8	0.38
10/14/2013 02:24	0	13.9	2,398.6	46.61	5,066.7	0.44
10/14/2013 02:25	0	17.3	2,552.4	51.55	5,266.7	0.58
10/14/2013 02:26	0	21.2	2,806.0	56.19	5,222.2	0.70
10/14/2013 02:27	0	23.4	3,034.8	60.53	5,200.0	0.77
10/14/2013 02:28	7	25.8	2,989.3	64.21	5,600.0	0.91
10/14/2013 02:29	16	29.3	2,927.7	69.37	6,177.8	1.14
10/14/2013 02:30	26	33.7	2,428.1	63.32	6,800.0	1.44
10/14/2013 02:31	36	38.6	1,666.8	47.73	7,466.7	1.82
10/14/2013 02:32	46	42.7	1,002.7	32.22	8,377.8	2.25
10/14/2013 02:33	57	50.3	534.5	18.67	9,111.1	2.89
10/14/2013 02:34	70	37.8	112.3	4.34	10,088.9	2.40
10/14/2013 02:35	82	40.0	6.1	0.27	11,044.4	2.78
10/14/2013 02:36	95	43.4	3.2	0.15	12,088.9	3.31
10/14/2013 02:37	17	38.8	2.7	0.07	6,911.1	1.69
Total				649.85		24.03

Date/Time Startup Commences: 10/14/2013 03:30
 Gas Turbine Downtime: 0 Hours
 Steam Turbine Downtime: 0 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
10/14/2013 03:30	0	0.0	0.0	0.00	844.4	0.00
10/14/2013 03:31	0	0.0	0.0	0.00	200.0	0.00
10/14/2013 03:32	0	0.0	0.0	0.00	1,400.0	0.00
10/14/2013 03:33	0	9.7	24.7	0.20	2,133.3	0.13
10/14/2013 03:34	0	7.7	621.9	6.94	2,911.1	0.14
10/14/2013 03:35	0	9.2	688.3	10.15	3,844.4	0.22
10/14/2013 03:36	0	12.4	933.3	15.75	4,400.0	0.35
10/14/2013 03:37	0	16.6	1,184.6	10.71	2,355.6	0.25
Total				43.75		1.09

Date/Time Startup Commences: 10/14/2013 04:22
 Gas Turbine Downtime: 0 Hours
 Steam Turbine Downtime: 0 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
10/14/2013 04:22	0	0.0	0.0	0.00	733.3	0.00
10/14/2013 04:23	0	0.0	0.0	0.00	844.4	0.00
10/14/2013 04:24	0	27.5	59.0	0.40	1,755.6	0.30
10/14/2013 04:25	0	7.6	325.5	3.16	2,533.3	0.12
10/14/2013 04:26	0	10.0	648.7	8.40	3,377.8	0.21
10/14/2013 04:27	0	11.0	728.7	11.49	4,111.1	0.28
10/14/2013 04:28	0	15.5	1,034.2	18.33	4,622.2	0.45
10/14/2013 04:29	0	21.4	1,218.2	24.61	5,266.7	0.71
10/14/2013 04:30	0	24.9	1,288.1	25.58	5,177.8	0.82
10/14/2013 04:31	0	29.1	1,536.0	30.37	5,155.6	0.95
10/14/2013 04:32	1	30.5	1,502.1	29.83	5,177.8	0.99
10/14/2013 04:33	10	32.3	1,368.4	39.07	7,444.4	1.52
10/14/2013 04:34	24	36.1	1,044.5	26.53	6,622.2	1.51
10/14/2013 04:35	38	41.5	510.6	14.84	7,577.8	1.99
10/14/2013 04:36	52	44.2	175.2	5.88	8,755.6	2.45
10/14/2013 04:37	65	49.6	34.4	1.28	9,688.9	3.04
10/14/2013 04:38	78	34.7	4.2	0.16	10,644.4	2.33
10/14/2013 04:39	91	40.0	1.3	0.06	11,755.6	2.96
10/14/2013 04:40	105	38.3	1.0	0.04	12,777.8	3.09
10/14/2013 04:41	110	36.5	0.8	0.05	13,111.1	3.01
10/14/2013 04:42	111	31.3	0.7	0.04	13,044.4	2.57
10/14/2013 04:43	110	26.7	0.8	0.04	12,866.7	2.16
10/14/2013 04:44	110	24.7	1.0	0.04	12,888.9	2.01
10/14/2013 04:45	111	28.3	1.5	0.07	12,888.9	2.30
10/14/2013 04:46	111	28.0	1.5	0.07	12,888.9	2.27
10/14/2013 04:47	111	26.9	1.1	0.04	12,800.0	2.17
10/14/2013 04:48	112	15.7	0.9	0.04	12,844.4	1.28
10/14/2013 04:49	112	10.2	0.7	0.04	12,844.4	0.84
10/14/2013 04:50	111	6.5	0.5	0.02	12,822.2	0.53
10/14/2013 04:51	111	4.9	0.3	0.02	12,800.0	0.39
10/14/2013 04:52	111	3.6	0.3	0.02	12,777.8	0.28
10/14/2013 04:53	110	1.7	0.3	0.02	12,733.3	0.13
10/14/2013 04:54	111	1.1	0.3	0.02	12,733.3	0.09
10/14/2013 04:55	110	0.5	0.3	0.02	12,733.3	0.04
10/14/2013 04:56	110	0.4	0.2	0.00	12,711.1	0.02
10/14/2013 04:57	110	0.4	0.2	0.00	12,711.1	0.02
10/14/2013 04:58	110	0.3	0.2	0.00	12,688.9	0.02
10/14/2013 04:59	110	0.3	0.2	0.00	12,688.9	0.02
10/14/2013 05:00	110	0.3	0.2	0.00	12,688.9	0.02
10/14/2013 05:01	110	0.3	0.2	0.00	12,666.7	0.02
10/14/2013 05:02	110	0.2	0.1	0.00	12,666.7	0.02
10/14/2013 05:03	110	0.3	0.1	0.00	12,688.9	0.02
Total				240.58		43.95

Date/Time Startup Commences: 10/17/2013 06:33
 Gas Turbine Downtime: 8 Hours
 Steam Turbine Downtime: 8 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
10/17/2013 06:33	0	0.0	0.0	0.00	888.9	0.00
10/17/2013 06:34	0	0.0	0.0	0.00	288.9	0.00
10/17/2013 06:35	0	0.0	0.0	0.00	1,466.7	0.00
10/17/2013 06:36	0	0.5	22.7	0.19	2,222.2	0.01
10/17/2013 06:37	0	0.9	48.1	0.56	3,022.2	0.02
10/17/2013 06:38	0	1.1	72.8	1.10	3,933.3	0.03
10/17/2013 06:39	0	2.6	205.0	3.50	4,444.4	0.08
10/17/2013 06:40	0	5.5	386.1	8.82	5,955.6	0.20
10/17/2013 06:41	0	10.7	583.7	11.74	5,244.4	0.35
10/17/2013 06:42	0	16.0	827.1	16.56	5,222.2	0.53
10/17/2013 06:43	4	19.1	871.4	17.75	5,311.1	0.64
10/17/2013 06:44	17	20.8	781.0	17.70	5,911.1	0.78
10/17/2013 06:45	30	25.3	463.5	12.13	6,822.2	1.09
10/17/2013 06:46	43	27.4	145.8	4.34	7,777.8	1.35
10/17/2013 06:47	57	32.2	42.8	1.46	8,866.7	1.81
10/17/2013 06:48	70	29.0	6.9	0.25	9,888.9	1.81
10/17/2013 06:49	83	26.5	2.6	0.11	10,888.9	1.83
10/17/2013 06:50	97	30.5	1.3	0.06	12,022.2	2.31
10/17/2013 06:51	111	29.0	0.8	0.04	13,066.7	2.40
10/17/2013 06:52	115	19.5	0.3	0.02	13,355.6	1.65
10/17/2013 06:53	116	10.2	0.2	0.00	13,266.7	0.86
10/17/2013 06:54	115	5.1	0.2	0.00	13,133.3	0.43
10/17/2013 06:55	115	2.9	0.6	0.02	13,155.6	0.25
10/17/2013 06:56	115	2.1	0.9	0.05	13,111.1	0.18
10/17/2013 06:57	115	1.2	0.8	0.05	13,111.1	0.09
10/17/2013 06:58	115	1.0	0.3	0.02	13,111.1	0.09
10/17/2013 06:59	116	0.9	0.1	0.00	13,088.9	0.07
10/17/2013 07:00	116	0.6	0.0	0.00	13,066.7	0.04
10/17/2013 07:01	116	0.5	0.0	0.00	13,066.7	0.04
10/17/2013 07:02	116	0.4	0.0	0.00	13,066.7	0.04
10/17/2013 07:03	116	0.4	0.0	0.00	13,066.7	0.04
10/17/2013 07:04	116	0.3	-0.1	0.00	13,022.2	0.02
10/17/2013 07:05	116	0.4	-0.1	0.00	13,022.2	0.04
10/17/2013 07:06	116	0.4	-0.1	0.00	13,022.2	0.04
Total				96.47		19.12

Date/Time Startup Commences: 10/18/2013 03:42
 Gas Turbine Downtime: 6 Hours
 Steam Turbine Downtime: 6 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
10/18/2013 03:42	0	0.0	0.0	0.00	488.9	0.00
10/18/2013 03:43	0	0.0	0.0	0.00	111.1	0.00
10/18/2013 03:44	0	0.0	0.0	0.00	1,333.3	0.00
10/18/2013 03:45	0	2.6	21.6	0.17	2,022.2	0.03
10/18/2013 03:46	0	1.8	30.1	0.32	2,777.8	0.03
10/18/2013 03:47	0	3.0	40.6	0.57	3,666.7	0.07
10/18/2013 03:48	0	3.6	58.8	0.97	4,266.7	0.10
10/18/2013 03:49	0	5.9	97.5	1.83	4,911.1	0.19
10/18/2013 03:50	0	9.2	126.5	2.52	5,200.0	0.30
10/18/2013 03:51	0	12.9	149.2	2.95	5,155.6	0.42
10/18/2013 03:52	1	15.3	163.6	3.25	5,177.8	0.50
10/18/2013 03:53	11	17.3	154.2	3.27	5,533.3	0.61
10/18/2013 03:54	24	20.3	129.8	3.20	6,422.2	0.83
10/18/2013 03:55	37	25.2	87.4	2.49	7,400.0	1.18
10/18/2013 03:56	52	29.1	47.6	1.56	8,511.1	1.56
10/18/2013 03:57	65	35.2	10.9	0.39	9,422.2	2.10
10/18/2013 03:58	78	19.9	3.9	0.16	10,488.9	1.31
10/18/2013 03:59	89	16.2	0.8	0.04	11,444.4	1.18
10/18/2013 04:00	104	12.1	0.5	0.02	12,533.3	0.94
10/18/2013 04:01	114	9.5	0.2	0.02	13,288.9	0.80
10/18/2013 04:02	120	5.9	0.2	0.00	13,533.3	0.51
10/18/2013 04:03	121	2.2	0.1	0.00	13,422.2	0.18
10/18/2013 04:04	119	0.8	0.2	0.00	13,377.8	0.07
10/18/2013 04:05	120	0.6	0.8	0.05	13,377.8	0.05
10/18/2013 04:06	120	0.4	0.9	0.05	13,355.6	0.05
10/18/2013 04:07	120	0.3	0.4	0.02	13,288.9	0.02
10/18/2013 04:08	120	0.2	-0.1	0.00	13,288.9	0.02
10/18/2013 04:09	120	0.2	-0.1	0.00	13,288.9	0.02
10/18/2013 04:10	120	0.2	-0.1	0.00	13,288.9	0.02
10/18/2013 04:11	120	0.2	-0.1	0.00	13,288.9	0.02
10/18/2013 04:12	120	0.2	-0.1	0.00	13,288.9	0.02
10/18/2013 04:13	120	0.2	-0.1	0.00	13,288.9	0.02
Total				23.85		13.15

Date/Time Startup Commences: 10/19/2013 12:38
 Gas Turbine Downtime: 15 Hours
 Steam Turbine Downtime: 15 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
10/19/2013 12:38	0	0.0	0.0	0.00	622.2	0.00
10/19/2013 12:39	0	0.0	0.0	0.00	88.9	0.00
10/19/2013 12:40	0	0.0	0.0	0.00	1,377.8	0.00
10/19/2013 12:41	0	7.6	21.1	0.16	2,044.4	0.10
10/19/2013 12:42	0	3.2	1,245.2	13.48	2,822.2	0.06
10/19/2013 12:43	0	5.0	1,934.5	27.86	3,755.6	0.12
10/19/2013 12:44	0	9.3	2,087.8	34.70	4,333.3	0.25
10/19/2013 12:45	0	15.2	2,373.3	43.49	4,777.8	0.46
10/19/2013 12:46	0	22.1	2,581.3	50.37	5,088.9	0.71
10/19/2013 12:47	0	26.8	2,898.2	56.56	5,088.9	0.86
10/19/2013 12:48	3	29.5	3,133.1	62.49	5,200.0	0.97
10/19/2013 12:49	15	31.7	3,188.2	70.38	5,755.6	1.15
10/19/2013 12:50	28	38.4	2,809.3	71.58	6,644.4	1.62
10/19/2013 12:51	41	41.0	1,792.1	51.94	7,555.6	1.95
10/19/2013 12:52	55	43.0	872.2	28.61	8,555.6	2.32
10/19/2013 12:53	68	38.8	175.3	6.42	9,555.6	2.34
10/19/2013 12:54	81	31.5	7.9	0.32	10,511.1	2.09
10/19/2013 12:55	95	32.5	3.7	0.16	11,622.2	2.39
10/19/2013 12:56	109	27.5	1.8	0.09	12,644.4	2.19
10/19/2013 12:57	115	22.5	1.2	0.07	13,088.9	1.86
10/19/2013 12:58	115	17.6	0.7	0.02	13,044.4	1.45
10/19/2013 12:59	114	14.4	0.5	0.02	13,088.9	1.19
10/19/2013 13:00	115	14.9	0.6	0.02	13,088.9	1.23
10/19/2013 13:01	115	14.6	0.7	0.04	13,044.4	1.21
10/19/2013 13:02	115	14.8	0.5	0.02	13,000.0	1.20
10/19/2013 13:03	115	15.0	0.5	0.02	13,022.2	1.23
10/19/2013 13:04	115	15.6	0.5	0.02	13,000.0	1.27
10/19/2013 13:05	115	15.0	0.4	0.02	13,022.2	1.23
10/19/2013 13:06	115	10.0	0.4	0.02	13,022.2	0.83
10/19/2013 13:07	115	4.8	0.3	0.02	13,000.0	0.40
10/19/2013 13:08	115	3.4	0.3	0.02	13,022.2	0.27
10/19/2013 13:09	115	2.6	0.3	0.02	13,022.2	0.22
10/19/2013 13:10	115	1.8	0.3	0.02	13,044.4	0.16
10/19/2013 13:11	115	1.3	0.3	0.02	13,022.2	0.11
10/19/2013 13:12	115	0.8	0.3	0.02	13,022.2	0.07
10/19/2013 13:13	115	0.5	0.3	0.02	13,022.2	0.04
10/19/2013 13:14	115	0.5	0.2	0.00	13,000.0	0.04
10/19/2013 13:15	115	0.4	0.2	0.00	13,022.2	0.04
10/19/2013 13:16	115	0.3	0.2	0.00	13,022.2	0.02
10/19/2013 13:17	115	0.3	0.1	0.00	13,022.2	0.02
10/19/2013 13:18	115	0.3	0.1	0.00	13,022.2	0.02
10/19/2013 13:19	115	0.3	0.1	0.00	13,022.2	0.02
10/19/2013 13:20	115	0.3	0.0	0.00	13,022.2	0.02
Total				519.02		33.73

Date/Time Startup Commences: 10/22/2013 03:58
 Gas Turbine Downtime: 5 Hours
 Steam Turbine Downtime: 5 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
10/22/2013 03:58	0	0.0	0.0	0.00	622.2	0.00
10/22/2013 03:59	0	0.0	0.0	0.00	400.0	0.00
10/22/2013 04:00	0	11.8	-17.7	0.00	1,555.6	0.11
10/22/2013 04:01	0	2.2	25.4	0.23	2,333.3	0.03
10/22/2013 04:02	0	2.7	40.2	0.48	3,111.1	0.05
10/22/2013 04:03	0	3.5	46.5	0.70	3,933.3	0.09
10/22/2013 04:04	0	5.2	78.2	1.34	4,466.7	0.15
10/22/2013 04:05	0	7.2	128.5	2.48	5,022.2	0.23
10/22/2013 04:06	0	11.2	167.7	3.34	5,200.0	0.37
10/22/2013 04:07	0	14.2	209.3	4.16	5,177.8	0.46
10/22/2013 04:08	4	16.5	209.3	4.25	5,288.9	0.55
10/22/2013 04:09	17	20.7	169.7	3.82	5,866.7	0.76
10/22/2013 04:10	30	22.9	112.4	2.96	6,844.4	0.99
10/22/2013 04:11	44	26.8	60.1	1.81	7,844.4	1.33
10/22/2013 04:12	58	33.5	31.4	1.06	8,866.7	1.88
10/22/2013 04:13	71	25.9	7.1	0.27	9,933.3	1.62
10/22/2013 04:14	83	15.3	1.8	0.07	10,911.1	1.05
10/22/2013 04:15	97	12.5	0.4	0.02	12,022.2	0.95
10/22/2013 04:16	110	9.5	0.3	0.02	12,977.8	0.78
10/22/2013 04:17	116	7.8	0.2	0.00	13,311.1	0.66
10/22/2013 04:18	124	3.3	0.1	0.00	13,800.0	0.28
10/22/2013 04:19	130	1.1	0.0	0.00	14,177.8	0.10
10/22/2013 04:20	130	0.7	0.0	0.00	14,000.0	0.07
10/22/2013 04:21	130	0.5	0.3	0.02	14,044.4	0.05
10/22/2013 04:22	130	0.3	0.8	0.05	14,022.2	0.02
10/22/2013 04:23	130	0.2	0.7	0.02	14,022.2	0.02
10/22/2013 04:24	130	0.2	0.0	0.00	14,044.4	0.02
10/22/2013 04:25	131	0.2	-0.2	0.00	14,044.4	0.02
10/22/2013 04:26	131	0.2	-0.2	0.00	14,066.7	0.02
10/22/2013 04:27	131	0.2	-0.2	0.00	14,088.9	0.02
10/22/2013 04:28	131	0.2	-0.3	0.00	14,044.4	0.02
10/22/2013 04:29	131	0.2	-0.3	0.00	14,066.7	0.02
Total				27.1		12.72

Date/Time Startup Commences: 10/28/2013 01:49
 Gas Turbine Downtime: 24 Hours
 Steam Turbine Downtime: 24 Hours
 Startup Type*: Warm

Sample Time	CT1 Load Mwe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
10/28/2013 01:49	0	0.0	0.0	0.00	933.3	0.00
10/28/2013 01:50	0	0.0	0.0	0.00	288.9	0.00
10/28/2013 01:51	0	0.0	0.0	0.00	1,444.4	0.00
10/28/2013 01:52	0	13.1	106.2	0.87	2,133.3	0.18
10/28/2013 01:53	0	8.0	2,771.8	31.18	2,933.3	0.15
10/28/2013 01:54	0	10.7	2,279.8	34.00	3,888.9	0.26
10/28/2013 01:55	0	15.0	2,268.8	38.48	4,422.2	0.42
10/28/2013 01:56	0	18.3	2,382.8	44.48	4,866.7	0.57
10/28/2013 01:57	0	23.2	2,530.3	50.25	5,177.8	0.75
10/28/2013 01:58	0	27.7	2,786.4	55.33	5,177.8	0.90
10/28/2013 01:59	10	29.3	2,987.8	63.92	5,577.8	1.03
10/28/2013 02:00	23	36.5	2,851.0	70.47	6,444.4	1.48
10/28/2013 02:01	36	42.4	1,913.7	54.15	7,377.8	1.97
10/28/2013 02:02	50	45.4	1,132.4	36.58	8,422.2	2.41
10/28/2013 02:03	63	53.6	530.6	19.00	9,333.3	3.17
10/28/2013 02:04	76	35.4	34.7	1.40	10,444.4	2.33
10/28/2013 02:05	90	39.9	5.1	0.22	11,488.9	2.89
10/28/2013 02:06	103	38.5	3.0	0.15	12,533.3	3.05
10/28/2013 02:07	111	33.3	2.5	0.13	13,066.7	2.75
10/28/2013 02:08	116	26.9	1.8	0.09	13,333.3	2.26
10/28/2013 02:09	116	19.5	1.0	0.05	13,177.8	1.63
10/28/2013 02:10	114	14.4	0.8	0.05	13,177.8	1.20
10/28/2013 02:11	115	15.4	1.0	0.05	13,177.8	1.29
10/28/2013 02:12	115	15.3	1.0	0.05	13,155.6	1.28
10/28/2013 02:13	116	15.4	0.8	0.04	13,088.9	1.28
10/28/2013 02:14	115	16.1	0.5	0.02	13,044.4	1.32
10/28/2013 02:15	116	18.0	0.4	0.02	13,022.2	1.47
10/28/2013 02:16	116	18.4	0.4	0.02	13,000.0	1.51
10/28/2013 02:17	115	18.8	0.3	0.02	13,000.0	1.54
10/28/2013 02:18	115	19.4	0.3	0.02	13,000.0	1.60
10/28/2013 02:19	115	15.0	0.3	0.02	12,977.8	1.22
10/28/2013 02:20	115	9.0	0.3	0.02	13,000.0	0.74
10/28/2013 02:21	115	4.7	0.2	0.00	13,000.0	0.38
10/28/2013 02:22	115	3.5	0.2	0.00	12,977.8	0.29
10/28/2013 02:23	115	2.8	0.1	0.00	12,955.6	0.22
10/28/2013 02:24	115	1.6	0.1	0.00	12,955.6	0.13
10/28/2013 02:25	115	1.1	0.1	0.00	12,977.8	0.09
10/28/2013 02:26	115	0.6	0.1	0.00	12,955.6	0.04
10/28/2013 02:27	115	0.5	0.1	0.00	12,977.8	0.04
10/28/2013 02:28	115	0.4	0.0	0.00	12,955.6	0.04
10/28/2013 02:29	115	0.3	0.0	0.00	12,955.6	0.02
10/28/2013 02:30	115	0.3	0.0	0.00	12,955.6	0.02
10/28/2013 02:31	115	0.3	0.0	0.00	12,955.6	0.02
10/28/2013 02:32	115	0.3	0.0	0.00	12,955.6	0.02
10/28/2013 02:33	115	0.3	-0.1	0.00	12,955.6	0.02
10/28/2013 02:34	115	0.4	-0.1	0.00	12,955.6	0.04
Total				501.08		44.02

Date/Time Startup Commences: 11/03/2013 14:15
 Gas Turbine Downtime: 16 Hours
 Steam Turbine Downtime: 16 Hours
 Startup Type*: Warm

Sample Time	CT1 Load Mwe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
11/03/2013 14:15	0	0.0	0.0	0.00	288.9	0.00
11/03/2013 14:16	0	0.0	0.0	0.00	577.8	0.00
11/03/2013 14:17	0	0.0	0.0	0.00	1,177.8	0.00
11/03/2013 14:18	0	8.3	29.5	0.21	1,888.9	0.10
11/03/2013 14:19	0	3.1	1,534.6	15.56	2,644.4	0.05
11/03/2013 14:20	0	5.9	2,279.1	30.88	3,533.3	0.13
11/03/2013 14:21	0	9.5	2,131.8	34.34	4,200.0	0.25
11/03/2013 14:22	0	15.6	2,316.2	41.65	4,688.9	0.46
11/03/2013 14:23	0	22.8	2,508.3	55.37	5,755.6	0.83
11/03/2013 14:24	0	26.9	2,722.7	53.84	5,155.6	0.87
11/03/2013 14:25	0	31.5	3,139.0	61.80	5,133.3	1.02
11/03/2013 14:26	3	32.3	3,115.6	62.39	5,222.2	1.06
11/03/2013 14:27	15	35.0	3,073.7	67.58	5,733.3	1.27
11/03/2013 14:28	28	41.8	2,619.6	67.20	6,688.9	1.76
11/03/2013 14:29	41	45.5	1,478.0	43.45	7,666.7	2.21
11/03/2013 14:30	56	49.5	763.6	25.44	8,688.9	2.71
11/03/2013 14:31	68	42.5	154.0	5.70	9,644.4	2.59
11/03/2013 14:32	81	32.8	7.4	0.31	10,511.1	2.18
11/03/2013 14:33	95	33.6	3.9	0.18	11,533.3	2.45
11/03/2013 14:34	109	28.5	2.6	0.13	12,555.6	2.26
11/03/2013 14:35	115	23.3	1.8	0.09	13,044.4	1.92
11/03/2013 14:36	115	18.8	1.0	0.04	13,044.4	1.54
11/03/2013 14:37	115	17.9	0.7	0.04	13,022.2	1.47
11/03/2013 14:38	115	17.9	0.6	0.02	13,022.2	1.47
11/03/2013 14:39	115	17.6	0.6	0.02	13,022.2	1.45
11/03/2013 14:40	115	18.4	0.6	0.02	13,000.0	1.51
11/03/2013 14:41	115	19.1	0.5	0.02	13,000.0	1.56
11/03/2013 14:42	115	19.8	0.3	0.02	12,977.8	1.62
11/03/2013 14:43	115	20.4	0.3	0.02	12,977.8	1.67
11/03/2013 14:44	115	18.0	0.2	0.00	12,977.8	1.47
11/03/2013 14:45	115	10.6	0.1	0.00	12,955.6	0.87
11/03/2013 14:46	115	5.8	0.1	0.00	12,955.6	0.47
11/03/2013 14:47	115	4.3	0.0	0.00	12,977.8	0.36
11/03/2013 14:48	116	3.4	-0.1	0.00	13,000.0	0.27
11/03/2013 14:49	115	2.3	-0.1	0.00	12,977.8	0.18
11/03/2013 14:50	115	1.2	-0.1	0.00	12,977.8	0.09
11/03/2013 14:51	115	1.0	-0.2	0.00	12,977.8	0.09
11/03/2013 14:52	115	0.8	-0.2	0.00	12,977.8	0.07
11/03/2013 14:53	115	0.6	-0.2	0.00	12,977.8	0.04
11/03/2013 14:54	115	0.4	-0.2	0.00	12,977.8	0.04
11/03/2013 14:55	115	0.3	-0.2	0.00	12,955.6	0.02
11/03/2013 14:56	115	0.3	-0.2	0.00	12,977.8	0.02
11/03/2013 14:57	115	0.3	-0.3	0.00	12,977.8	0.02
11/03/2013 14:58	115	0.3	-0.3	0.00	12,955.6	0.02
11/03/2013 14:59	115	0.3	-0.3	0.00	12,977.8	0.02
Total				566.32		40.46

Date/Time Startup Commences: 11/04/2013 04:39
 Gas Turbine Downtime: 5 Hours
 Steam Turbine Downtime: 5 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
11/04/2013 04:39	0	0.0	0.0	0.00	600.0	0.00
11/04/2013 04:40	0	0.0	0.0	0.00	977.8	0.00
11/04/2013 04:41	0	1.2	10.6	0.07	1,800.0	0.01
11/04/2013 04:42	0	0.9	26.4	0.26	2,555.6	0.01
11/04/2013 04:43	0	2.4	43.2	0.57	3,444.4	0.05
11/04/2013 04:44	0	3.2	62.4	0.99	4,133.3	0.09
11/04/2013 04:45	0	4.6	117.6	2.08	4,622.2	0.13
11/04/2013 04:46	0	8.1	184.9	3.63	5,111.1	0.26
11/04/2013 04:47	0	11.2	224.6	4.44	5,155.6	0.36
11/04/2013 04:48	0	15.3	295.0	5.78	5,111.1	0.49
11/04/2013 04:49	8	16.3	263.1	5.45	5,400.0	0.56
11/04/2013 04:50	21	20.7	218.9	5.19	6,177.8	0.80
11/04/2013 04:51	34	23.4	111.0	3.02	7,111.1	1.05
11/04/2013 04:52	49	28.1	51.9	1.64	8,244.4	1.45
11/04/2013 04:53	61	36.5	28.3	0.98	9,111.1	2.11
11/04/2013 04:54	74	24.3	6.0	0.23	10,155.6	1.55
11/04/2013 04:55	87	17.1	1.2	0.06	11,177.8	1.21
11/04/2013 04:56	101	14.1	0.4	0.02	12,311.1	1.10
11/04/2013 04:57	114	11.0	0.3	0.02	13,266.7	0.93
11/04/2013 04:58	119	8.5	0.2	0.00	13,511.1	0.72
11/04/2013 04:59	121	3.5	0.1	0.00	13,466.7	0.30
11/04/2013 05:00	120	1.0	0.1	0.00	13,355.6	0.09
11/04/2013 05:01	120	0.6	0.4	0.02	13,377.8	0.05
11/04/2013 05:02	121	0.4	0.7	0.05	13,333.3	0.05
11/04/2013 05:03	120	0.3	0.4	0.02	13,311.1	0.02
11/04/2013 05:04	121	0.3	0.0	0.00	13,288.9	0.02
11/04/2013 05:05	120	0.2	-0.1	0.00	13,288.9	0.02
11/04/2013 05:06	120	0.2	-0.1	0.00	13,288.9	0.02
11/04/2013 05:07	120	0.2	-0.1	0.00	13,288.9	0.02
11/04/2013 05:08	120	0.2	-0.1	0.00	13,288.9	0.02
11/04/2013 05:09	120	0.2	-0.1	0.00	13,288.9	0.02
Total				34.52		13.51

Date/Time Startup Commences: 11/07/2013 01:46
 Gas Turbine Downtime: 60 Hours
 Steam Turbine Downtime: 60 Hours
 Startup Type*: Warm

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
11/07/2013 01:46	0	0.0	0.0	0.00	1,044.4	0.00
11/07/2013 01:47	0	0.0	0.0	0.00	1,066.7	0.00
11/07/2013 01:48	0	23.6	76.7	0.52	1,777.8	0.27
11/07/2013 01:49	0	9.8	2,602.7	25.51	2,555.6	0.16
11/07/2013 01:50	0	11.8	2,641.6	34.00	3,355.6	0.25
11/07/2013 01:51	0	13.6	2,060.7	33.02	4,177.8	0.36
11/07/2013 01:52	0	18.5	2,152.3	38.52	4,666.7	0.54
11/07/2013 01:53	0	23.2	2,409.1	49.08	5,311.1	0.77
11/07/2013 01:54	0	27.9	2,499.0	50.05	5,222.2	0.92
11/07/2013 01:55	0	33.0	2,784.4	55.54	5,200.0	1.09
11/07/2013 01:56	9	34.0	2,910.7	61.76	5,533.3	1.19
11/07/2013 01:57	21	39.0	2,856.4	69.14	6,311.1	1.56
11/07/2013 01:58	34	46.1	2,249.4	62.69	7,266.7	2.12
11/07/2013 01:59	48	48.4	1,254.8	40.43	8,400.0	2.56
11/07/2013 02:00	61	55.1	589.6	21.11	9,333.3	3.25
11/07/2013 02:01	74	40.0	64.5	2.57	10,422.2	2.64
11/07/2013 02:02	87	43.6	4.8	0.21	11,400.0	3.14
11/07/2013 02:03	100	44.4	3.1	0.15	12,377.8	3.48
11/07/2013 02:04	105	39.4	3.0	0.15	12,711.1	3.16
11/07/2013 02:05	106	30.6	3.0	0.15	12,622.2	2.44
11/07/2013 02:06	105	23.8	3.2	0.15	12,533.3	1.89
11/07/2013 02:07	105	21.5	3.6	0.17	12,600.0	1.71
11/07/2013 02:08	106	20.4	3.0	0.15	12,533.3	1.61
11/07/2013 02:09	106	18.7	1.9	0.09	12,422.2	1.47
11/07/2013 02:10	106	18.5	1.0	0.04	12,400.0	1.44
11/07/2013 02:11	106	19.7	1.0	0.04	12,377.8	1.55
11/07/2013 02:12	106	21.3	1.0	0.04	12,422.2	1.68
11/07/2013 02:13	106	22.3	1.0	0.04	12,355.6	1.74
11/07/2013 02:14	105	24.0	1.0	0.04	12,355.6	1.86
11/07/2013 02:15	106	24.2	1.0	0.04	12,333.3	1.88
11/07/2013 02:16	105	24.7	1.0	0.04	12,333.3	1.92
11/07/2013 02:17	106	25.3	0.9	0.04	12,333.3	1.97
11/07/2013 02:18	105	25.7	0.9	0.04	12,333.3	2.01
11/07/2013 02:19	105	25.6	0.9	0.04	12,333.3	1.99
11/07/2013 02:20	105	16.9	0.9	0.04	12,311.1	1.31
11/07/2013 02:21	105	10.3	0.9	0.04	12,311.1	0.80
11/07/2013 02:22	105	6.5	0.8	0.04	12,311.1	0.51
11/07/2013 02:23	105	4.9	0.8	0.04	12,311.1	0.38
11/07/2013 02:24	105	3.7	0.7	0.04	12,311.1	0.30
11/07/2013 02:25	105	1.6	0.7	0.04	12,311.1	0.13
11/07/2013 02:26	105	1.2	0.7	0.04	12,311.1	0.08
11/07/2013 02:27	105	0.9	0.6	0.02	12,266.7	0.06
11/07/2013 02:28	105	0.6	0.5	0.02	12,288.9	0.04
11/07/2013 02:29	105	0.4	0.5	0.02	12,288.9	0.04
11/07/2013 02:30	105	0.4	0.4	0.02	12,288.9	0.02
11/07/2013 02:31	105	0.3	0.4	0.02	12,288.9	0.02
11/07/2013 02:32	105	0.3	0.4	0.02	12,288.9	0.02
11/07/2013 02:33	105	0.3	0.4	0.02	12,266.7	0.02
11/07/2013 02:34	105	0.3	0.4	0.02	12,266.7	0.02
11/07/2013 02:35	105	0.4	0.4	0.02	12,266.7	0.02
Total				546.02		58.39

Date/Time Startup Commences: 11/08/2013 03:53
 Gas Turbine Downtime: 4 Hours
 Steam Turbine Downtime: 4 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
11/08/2013 03:53	0	0.0	0.0	0.00	533.3	0.00
11/08/2013 03:54	0	0.0	0.0	0.00	200.0	0.00
11/08/2013 03:55	0	0.0	-17.7	0.00	1,400.0	0.00
11/08/2013 03:56	0	0.5	21.8	0.18	2,088.9	0.01
11/08/2013 03:57	0	0.6	37.4	0.41	2,866.7	0.01
11/08/2013 03:58	0	0.9	40.0	0.59	3,800.0	0.02
11/08/2013 03:59	0	1.3	53.5	0.89	4,333.3	0.04
11/08/2013 04:00	0	3.2	72.9	1.37	4,911.1	0.10
11/08/2013 04:01	0	5.1	88.7	1.78	5,222.2	0.17
11/08/2013 04:02	0	7.5	102.5	2.05	5,200.0	0.25
11/08/2013 04:03	11	9.6	111.5	2.40	5,600.0	0.35
11/08/2013 04:04	23	13.1	105.3	2.58	6,377.8	0.52
11/08/2013 04:05	36	17.5	73.1	2.04	7,244.4	0.81
11/08/2013 04:06	50	21.6	43.4	1.40	8,422.2	1.15
11/08/2013 04:07	63	29.3	21.9	0.78	9,333.3	1.73
11/08/2013 04:08	77	16.8	6.1	0.25	10,422.2	1.11
11/08/2013 04:09	90	12.4	1.1	0.04	11,444.4	0.90
11/08/2013 04:10	104	10.1	0.2	0.00	12,533.3	0.79
11/08/2013 04:11	113	8.2	0.2	0.00	13,177.8	0.68
11/08/2013 04:12	119	5.4	0.1	0.00	13,511.1	0.46
11/08/2013 04:13	121	1.9	0.0	0.00	13,466.7	0.16
11/08/2013 04:14	120	0.7	0.1	0.00	13,377.8	0.07
11/08/2013 04:15	120	0.6	0.7	0.05	13,400.0	0.05
11/08/2013 04:16	121	0.3	0.9	0.05	13,400.0	0.02
11/08/2013 04:17	120	0.3	0.6	0.02	13,355.6	0.02
11/08/2013 04:18	120	0.2	0.1	0.00	13,333.3	0.02
11/08/2013 04:19	121	0.2	0.1	0.00	13,333.3	0.02
11/08/2013 04:20	120	0.2	0.1	0.00	13,333.3	0.02
11/08/2013 04:21	120	0.2	0.0	0.00	13,333.3	0.02
11/08/2013 04:22	120	0.2	0.0	0.00	13,333.3	0.02
11/08/2013 04:23	120	0.2	0.0	0.00	13,333.3	0.02
Total				16.88		9.54

Date/Time Startup Commences: 11/08/2013 09:42
 Gas Turbine Downtime: 3 Hours
 Steam Turbine Downtime: 3 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
11/08/2013 09:42	0	0.0	0.0	0.00	644.4	0.00
11/08/2013 09:43	0	0.0	0.0	0.00	600.0	0.00
11/08/2013 09:44	0	0.0	3.0	0.02	1,666.7	0.00
11/08/2013 09:45	0	0.6	25.2	0.23	2,444.4	0.01
11/08/2013 09:46	0	2.2	40.1	0.51	3,311.1	0.05
11/08/2013 09:47	0	2.8	45.0	0.70	4,066.7	0.07
11/08/2013 09:48	0	4.4	66.0	1.15	4,533.3	0.12
11/08/2013 09:49	0	6.7	85.1	1.67	5,088.9	0.22
11/08/2013 09:50	0	9.8	97.5	1.95	5,222.2	0.32
11/08/2013 09:51	0	12.6	114.7	2.28	5,177.8	0.41
11/08/2013 09:52	10	14.8	119.6	2.51	5,466.7	0.51
11/08/2013 09:53	22	19.7	109.9	2.64	6,266.7	0.78
11/08/2013 09:54	34	21.5	78.2	2.15	7,155.6	0.97
11/08/2013 09:55	49	26.6	48.6	1.54	8,266.7	1.39
11/08/2013 09:56	61	33.7	25.0	0.88	9,177.8	1.95
11/08/2013 09:57	75	19.3	6.3	0.25	10,311.1	1.25
11/08/2013 09:58	88	13.7	1.0	0.04	11,311.1	0.97
11/08/2013 09:59	103	10.9	0.3	0.02	12,488.9	0.86
11/08/2013 10:00	113	9.0	0.2	0.00	13,155.6	0.74
11/08/2013 10:01	120	5.7	0.1	0.00	13,511.1	0.49
11/08/2013 10:02	126	2.2	0.0	0.00	13,844.4	0.19
11/08/2013 10:03	125	0.8	0.0	0.00	13,666.7	0.07
11/08/2013 10:04	125	0.6	0.6	0.02	13,733.3	0.05
11/08/2013 10:05	125	0.4	1.2	0.07	13,688.9	0.05
11/08/2013 10:06	125	0.2	1.0	0.05	13,644.4	0.02
11/08/2013 10:07	125	0.2	0.3	0.02	13,666.7	0.02
11/08/2013 10:08	125	0.2	0.0	0.00	13,666.7	0.02
11/08/2013 10:09	125	0.2	0.1	0.00	13,688.9	0.02
11/08/2013 10:10	125	0.2	0.0	0.00	13,688.9	0.02
11/08/2013 10:11	125	0.2	-0.1	0.00	13,711.1	0.02
11/08/2013 10:12	125	0.2	-0.1	0.00	13,688.9	0.02
Total				18.7		11.61

Date/Time Startup Commences: 11/14/2013 05:45
 Gas Turbine Downtime: 137 Hours
 Steam Turbine Downtime: 137 Hours
 Startup Type*: Cold

Sample Time	CT1 Load Mwe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
11/14/2013 05:45	0	0.0	0.0	0.00	755.6	0.00
11/14/2013 05:46	0	0.0	0.0	0.00	288.9	0.00
11/14/2013 05:47	0	0.0	0.0	0.00	1,422.2	0.00
11/14/2013 05:48	0	14.8	176.0	1.46	2,155.6	0.20
11/14/2013 05:49	0	8.5	2,734.3	30.99	2,955.6	0.16
11/14/2013 05:50	0	10.4	2,222.0	33.14	3,888.9	0.25
11/14/2013 05:51	0	12.0	2,055.6	35.21	4,466.7	0.34
11/14/2013 05:52	0	13.4	2,178.5	43.08	5,155.6	0.43
11/14/2013 05:53	0	16.6	2,421.5	49.12	5,288.9	0.55
11/14/2013 05:54	0	20.1	2,593.6	52.61	5,288.9	0.67
11/14/2013 05:55	2	21.0	2,941.7	67.19	5,955.6	0.80
11/14/2013 05:56	11	24.4	2,900.1	65.50	5,888.9	0.91
11/14/2013 05:57	21	31.8	2,694.5	67.07	6,488.9	1.30
11/14/2013 05:58	31	37.7	1,954.1	53.63	7,155.6	1.70
11/14/2013 05:59	44	40.8	1,320.9	41.32	8,155.6	2.10
11/14/2013 06:00	58	47.8	794.2	27.75	9,111.1	2.75
11/14/2013 06:01	70	41.7	207.3	8.06	10,133.3	2.67
11/14/2013 06:02	83	37.9	6.6	0.29	11,133.3	2.67
11/14/2013 06:03	97	41.8	2.8	0.13	12,244.4	3.23
11/14/2013 06:04	108	38.8	1.9	0.09	13,022.2	3.19
11/14/2013 06:05	114	32.1	2.0	0.09	13,466.7	2.72
11/14/2013 06:06	116	25.6	2.2	0.12	13,422.2	2.16
11/14/2013 06:07	115	19.2	2.2	0.11	13,311.1	1.62
11/14/2013 06:08	115	16.2	2.2	0.11	13,355.6	1.37
11/14/2013 06:09	116	17.7	2.0	0.11	13,311.1	1.48
11/14/2013 06:10	116	17.5	1.5	0.07	13,244.4	1.48
11/14/2013 06:11	116	17.5	0.8	0.05	13,222.2	1.47
11/14/2013 06:12	116	17.9	0.6	0.02	13,177.8	1.49
11/14/2013 06:13	116	19.2	0.6	0.02	13,155.6	1.60
11/14/2013 06:14	115	20.4	0.5	0.02	13,111.1	1.68
11/14/2013 06:15	116	20.7	0.5	0.02	13,133.3	1.71
11/14/2013 06:16	116	21.3	0.5	0.02	13,088.9	1.75
11/14/2013 06:17	116	22.1	0.5	0.02	13,111.1	1.82
11/14/2013 06:18	116	22.8	0.5	0.02	13,066.7	1.88
11/14/2013 06:19	116	23.3	0.5	0.02	13,066.7	1.93
11/14/2013 06:20	116	24.0	0.5	0.02	13,044.4	1.99
11/14/2013 06:21	115	24.4	0.5	0.02	13,044.4	2.01
11/14/2013 06:22	116	24.7	0.4	0.02	13,066.7	2.04
11/14/2013 06:23	115	25.0	0.4	0.02	13,044.4	2.06
11/14/2013 06:24	115	18.7	0.4	0.02	13,066.7	1.54
11/14/2013 06:25	115	10.5	0.4	0.02	13,044.4	0.87
11/14/2013 06:26	115	6.2	0.3	0.02	13,044.4	0.51
11/14/2013 06:27	115	4.4	0.3	0.02	13,044.4	0.36
11/14/2013 06:28	115	3.6	0.3	0.02	13,044.4	0.29
11/14/2013 06:29	115	2.2	0.3	0.02	13,044.4	0.18
11/14/2013 06:30	115	1.3	0.3	0.02	13,044.4	0.11
11/14/2013 06:31	115	0.8	0.2	0.00	13,044.4	0.07
11/14/2013 06:32	115	0.7	0.2	0.00	13,044.4	0.07
11/14/2013 06:33	115	0.6	0.2	0.00	13,044.4	0.04
11/14/2013 06:34	115	0.4	0.2	0.00	13,022.2	0.04
11/14/2013 06:35	115	0.4	0.1	0.00	13,044.4	0.04
11/14/2013 06:36	115	0.3	0.1	0.00	13,044.4	0.02
11/14/2013 06:37	115	0.3	0.1	0.00	13,044.4	0.02
11/14/2013 06:38	115	0.3	0.1	0.00	13,044.4	0.02
11/14/2013 06:39	115	0.3	0.1	0.00	13,044.4	0.02
Total				577.68		62.38

Date/Time Startup Commences: 11/15/2013 03:32
 Gas Turbine Downtime: 17 Hours
 Steam Turbine Downtime: 17 Hours
 Startup Type*: Warm

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
11/15/2013 03:32	0	0.0	0.0	0.00	577.8	0.00
11/15/2013 03:33	0	0.0	0.0	0.00	666.7	0.00
11/15/2013 03:34	0	14.8	11.8	0.07	1,622.2	0.15
11/15/2013 03:35	0	4.4	46.8	0.44	2,422.2	0.07
11/15/2013 03:36	0	5.4	1,996.5	24.84	3,244.4	0.11
11/15/2013 03:37	0	7.4	2,063.3	32.53	4,111.1	0.19
11/15/2013 03:38	0	13.1	2,273.2	40.10	4,600.0	0.38
11/15/2013 03:39	0	18.1	2,560.4	50.18	5,111.1	0.59
11/15/2013 03:40	0	23.4	2,674.4	53.56	5,222.2	0.77
11/15/2013 03:41	0	27.5	3,017.7	60.19	5,200.0	0.90
11/15/2013 03:42	6	28.1	3,090.2	63.48	5,355.6	0.95
11/15/2013 03:43	19	32.5	3,044.4	70.84	6,066.7	1.25
11/15/2013 03:44	32	39.3	2,317.7	62.42	7,022.2	1.74
11/15/2013 03:45	45	41.7	1,259.4	38.64	8,000.0	2.11
11/15/2013 03:46	58	47.7	600.0	20.76	9,022.2	2.72
11/15/2013 03:47	72	37.1	73.8	2.85	10,066.7	2.36
11/15/2013 03:48	85	33.0	4.3	0.19	11,088.9	2.32
11/15/2013 03:49	99	33.1	1.6	0.06	12,177.8	2.55
11/15/2013 03:50	110	28.7	1.1	0.04	13,066.7	2.37
11/15/2013 03:51	115	24.0	0.8	0.05	13,422.2	2.02
11/15/2013 03:52	116	19.4	0.6	0.02	13,288.9	1.64
11/15/2013 03:53	115	15.3	0.5	0.02	13,200.0	1.27
11/15/2013 03:54	115	13.8	0.9	0.05	13,222.2	1.16
11/15/2013 03:55	115	16.0	1.1	0.05	13,222.2	1.34
11/15/2013 03:56	115	16.3	1.0	0.05	13,155.6	1.35
11/15/2013 03:57	115	16.4	0.6	0.02	13,133.3	1.35
11/15/2013 03:58	116	17.4	0.5	0.02	13,133.3	1.44
11/15/2013 03:59	115	16.7	0.4	0.02	13,111.1	1.37
11/15/2013 04:00	115	10.7	0.3	0.02	13,111.1	0.88
11/15/2013 04:01	115	6.2	0.3	0.02	13,088.9	0.52
11/15/2013 04:02	115	4.2	0.3	0.02	13,044.4	0.34
11/15/2013 04:03	116	3.2	0.3	0.02	13,066.7	0.27
11/15/2013 04:04	115	2.3	0.3	0.02	13,022.2	0.20
11/15/2013 04:05	115	1.5	0.3	0.02	13,022.2	0.11
11/15/2013 04:06	115	0.9	0.3	0.02	13,022.2	0.07
11/15/2013 04:07	115	0.7	0.3	0.02	13,000.0	0.07
11/15/2013 04:08	115	0.6	0.3	0.02	13,000.0	0.04
11/15/2013 04:09	115	0.5	0.3	0.02	13,000.0	0.04
11/15/2013 04:10	115	0.4	0.3	0.02	13,000.0	0.04
11/15/2013 04:11	115	0.3	0.2	0.00	13,000.0	0.02
11/15/2013 04:12	115	0.3	0.2	0.00	12,977.8	0.02
11/15/2013 04:13	115	0.3	0.2	0.00	12,977.8	0.02
11/15/2013 04:14	115	0.4	0.2	0.00	12,977.8	0.04
Total				521.71		37.15

Date/Time Startup Commences: 11/16/2013 14:18
 Gas Turbine Downtime: 14 Hours
 Steam Turbine Downtime: 14 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
11/16/2013 14:18	0	0.0	0.0	0.00	1,000.0	0.00
11/16/2013 14:19	0	0.0	0.0	0.00	822.2	0.00
11/16/2013 14:20	0	5.9	44.3	0.29	1,688.9	0.06
11/16/2013 14:21	0	2.6	754.5	7.07	2,444.4	0.04
11/16/2013 14:22	0	3.1	1,871.6	23.12	3,222.2	0.06
11/16/2013 14:23	0	5.5	1,870.9	28.70	4,000.0	0.14
11/16/2013 14:24	0	11.2	2,120.9	36.69	4,511.1	0.32
11/16/2013 14:25	0	20.7	2,449.6	48.64	5,177.8	0.67
11/16/2013 14:26	0	24.2	2,660.3	51.70	5,066.7	0.77
11/16/2013 14:27	0	28.9	2,978.1	57.62	5,044.4	0.92
11/16/2013 14:28	4	30.1	3,122.1	61.47	5,133.3	0.98
11/16/2013 14:29	17	33.8	3,082.8	68.84	5,822.2	1.25
11/16/2013 14:30	30	39.3	2,355.1	61.02	6,755.6	1.68
11/16/2013 14:31	44	39.7	1,172.0	35.17	7,822.2	1.96
11/16/2013 14:32	57	43.6	356.7	12.12	8,866.7	2.45
11/16/2013 14:33	70	32.3	29.6	1.11	9,844.4	2.01
11/16/2013 14:34	83	28.1	4.2	0.17	10,844.4	1.93
11/16/2013 14:35	97	26.8	1.4	0.06	11,822.2	2.01
11/16/2013 14:36	111	22.4	1.1	0.04	12,866.7	1.83
11/16/2013 14:37	115	17.5	0.7	0.04	13,044.4	1.45
11/16/2013 14:38	115	13.7	0.5	0.02	12,977.8	1.13
11/16/2013 14:39	115	12.1	0.8	0.04	13,022.2	0.98
11/16/2013 14:40	115	13.5	1.1	0.04	13,022.2	1.12
11/16/2013 14:41	115	13.6	1.1	0.04	13,000.0	1.11
11/16/2013 14:42	115	14.5	0.7	0.04	12,955.6	1.18
11/16/2013 14:43	115	15.6	0.6	0.02	12,955.6	1.27
11/16/2013 14:44	115	15.8	0.5	0.02	12,977.8	1.29
11/16/2013 14:45	116	10.9	0.4	0.02	12,977.8	0.89
11/16/2013 14:46	115	10.9	0.4	0.02	12,955.6	0.89
11/16/2013 14:47	115	4.3	0.4	0.02	12,955.6	0.36
11/16/2013 14:48	115	3.3	0.4	0.02	12,955.6	0.27
11/16/2013 14:49	115	2.7	0.3	0.02	12,933.3	0.22
11/16/2013 14:50	115	1.6	0.3	0.02	12,955.6	0.13
11/16/2013 14:51	115	0.9	0.3	0.02	12,933.3	0.07
11/16/2013 14:52	115	0.7	0.3	0.02	12,933.3	0.07
11/16/2013 14:53	115	0.6	0.3	0.02	12,955.6	0.04
11/16/2013 14:54	115	0.5	0.3	0.02	12,933.3	0.04
11/16/2013 14:55	115	0.3	0.3	0.02	12,955.6	0.02
11/16/2013 14:56	115	0.3	0.2	0.00	12,955.6	0.02
11/16/2013 14:57	115	0.3	0.2	0.00	12,933.3	0.02
11/16/2013 14:58	115	0.3	0.2	0.00	12,933.3	0.02
11/16/2013 14:59	115	0.3	0.2	0.00	12,933.3	0.02
11/16/2013 15:00	115	0.3	0.2	0.00	12,955.6	0.02
Total				494.31		31.71

Date/Time Startup Commences: 11/17/2013 13:56
 Gas Turbine Downtime: 14 Hours
 Steam Turbine Downtime: 14 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
11/17/2013 13:56	0	0.0	0.0	0.00	800.0	0.00
11/17/2013 13:57	0	0.0	0.0	0.00	600.0	0.00
11/17/2013 13:58	0	23.6	-17.7	0.00	1,577.8	0.24
11/17/2013 13:59	0	3.9	32.3	0.29	2,377.8	0.06
11/17/2013 14:00	0	3.8	1,353.2	16.61	3,200.0	0.08
11/17/2013 14:01	0	5.9	1,777.7	27.42	4,022.2	0.15
11/17/2013 14:02	0	10.8	2,025.1	35.21	4,533.3	0.31
11/17/2013 14:03	0	16.4	2,354.7	45.36	5,022.2	0.52
11/17/2013 14:04	0	22.5	2,588.2	51.62	5,200.0	0.74
11/17/2013 14:05	0	26.4	2,975.4	59.09	5,177.8	0.86
11/17/2013 14:06	7	26.9	3,063.9	63.45	5,400.0	0.92
11/17/2013 14:07	20	32.5	2,996.8	70.49	6,133.3	1.26
11/17/2013 14:08	32	37.5	2,163.4	58.46	7,044.4	1.67
11/17/2013 14:09	46	39.6	1,105.1	34.57	8,155.6	2.04
11/17/2013 14:10	60	46.6	412.3	14.37	9,088.9	2.68
11/17/2013 14:11	73	31.2	29.4	1.15	10,155.6	2.00
11/17/2013 14:12	87	31.4	3.5	0.15	11,200.0	2.23
11/17/2013 14:13	100	29.8	1.2	0.06	12,155.6	2.29
11/17/2013 14:14	113	25.0	0.9	0.04	13,088.9	2.06
11/17/2013 14:15	116	19.8	0.7	0.02	13,088.9	1.64
11/17/2013 14:16	115	14.7	0.5	0.02	13,000.0	1.20
11/17/2013 14:17	115	14.1	1.1	0.07	13,066.7	1.16
11/17/2013 14:18	115	15.9	1.5	0.07	13,044.4	1.32
11/17/2013 14:19	115	16.0	1.3	0.07	13,022.2	1.32
11/17/2013 14:20	115	16.5	0.7	0.04	13,000.0	1.36
11/17/2013 14:21	115	17.1	0.6	0.02	12,977.8	1.40
11/17/2013 14:22	115	12.9	0.5	0.02	12,977.8	1.07
11/17/2013 14:23	115	8.4	0.4	0.02	13,000.0	0.69
11/17/2013 14:24	115	4.6	0.3	0.02	13,000.0	0.38
11/17/2013 14:25	115	3.5	0.3	0.02	12,977.8	0.29
11/17/2013 14:26	115	2.8	0.3	0.02	12,977.8	0.22
11/17/2013 14:27	115	1.7	0.3	0.02	12,977.8	0.13
11/17/2013 14:28	115	1.3	0.3	0.02	12,955.6	0.11
11/17/2013 14:29	115	0.7	0.2	0.00	12,977.8	0.07
11/17/2013 14:30	115	0.5	0.2	0.00	12,977.8	0.04
11/17/2013 14:31	115	0.5	0.2	0.00	12,955.6	0.04
11/17/2013 14:32	115	0.4	0.2	0.00	13,000.0	0.04
11/17/2013 14:33	115	0.3	0.1	0.00	12,977.8	0.02
11/17/2013 14:34	115	0.3	0.1	0.00	12,955.6	0.02
11/17/2013 14:35	115	0.3	0.1	0.00	12,977.8	0.02
11/17/2013 14:36	115	0.3	0.1	0.00	12,955.6	0.02
11/17/2013 14:37	115	0.3	0.1	0.00	12,977.8	0.02
Total				478.79		32.69

Date/Time Startup Commences: 11/30/2013 11:46
 Gas Turbine Downtime: 60 Hours
 Steam Turbine Downtime: 60 Hours
 Startup Type*: Warm

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
11/30/2013 11:46	0	0.0	0.0	0.00	1,022.2	0.00
11/30/2013 11:47	0	0.0	0.0	0.00	955.6	0.00
11/30/2013 11:48	0	32.5	73.8	0.50	1,755.6	0.36
11/30/2013 11:49	0	9.7	2,581.3	25.08	2,533.3	0.16
11/30/2013 11:50	0	11.3	2,640.5	34.43	3,400.0	0.24
11/30/2013 11:51	0	13.4	2,089.6	33.67	4,200.0	0.35
11/30/2013 11:52	0	17.7	2,177.7	39.35	4,711.1	0.52
11/30/2013 11:53	0	21.0	2,351.5	55.72	6,177.8	0.82
11/30/2013 11:54	0	25.8	2,507.5	50.65	5,266.7	0.86
11/30/2013 11:55	0	29.9	2,759.8	55.51	5,244.4	0.99
11/30/2013 11:56	7	31.3	2,926.2	62.35	5,555.6	1.09
11/30/2013 11:57	21	36.5	2,790.1	68.49	6,400.0	1.47
11/30/2013 11:58	34	42.1	2,059.3	57.75	7,311.1	1.94
11/30/2013 11:59	48	44.6	1,161.8	37.83	8,488.9	2.39
11/30/2013 12:00	61	51.8	584.1	20.90	9,333.3	3.05
11/30/2013 12:01	74	38.3	77.0	3.07	10,422.2	2.52
11/30/2013 12:02	87	40.8	4.8	0.22	11,444.4	2.94
11/30/2013 12:03	101	39.6	2.7	0.13	12,466.7	3.12
11/30/2013 12:04	110	35.8	2.5	0.14	13,177.8	2.98
11/30/2013 12:05	111	27.7	2.6	0.13	13,066.7	2.28
11/30/2013 12:06	110	21.2	2.9	0.13	12,911.1	1.73
11/30/2013 12:07	110	18.6	5.2	0.27	12,977.8	1.51
11/30/2013 12:08	111	19.2	1.7	0.09	12,911.1	1.57
11/30/2013 12:09	111	18.4	1.1	0.04	12,822.2	1.49
11/30/2013 12:10	111	18.2	1.1	0.04	12,800.0	1.47
11/30/2013 12:11	111	18.1	1.0	0.04	12,777.8	1.47
11/30/2013 12:12	110	18.6	1.0	0.04	12,777.8	1.51
11/30/2013 12:13	110	19.5	1.0	0.04	12,777.8	1.58
11/30/2013 12:14	110	20.3	1.0	0.04	12,755.6	1.64
11/30/2013 12:15	110	21.1	0.9	0.04	12,755.6	1.70
11/30/2013 12:16	110	21.8	0.8	0.04	12,755.6	1.75
11/30/2013 12:17	110	22.4	0.7	0.04	12,755.6	1.79
11/30/2013 12:18	110	22.8	0.6	0.02	12,733.3	1.83
11/30/2013 12:19	110	23.2	0.6	0.02	12,733.3	1.85
11/30/2013 12:20	110	23.4	0.6	0.02	12,733.3	1.88
11/30/2013 12:21	110	23.7	0.5	0.02	12,733.3	1.90
11/30/2013 12:22	110	20.4	0.5	0.02	12,733.3	1.64
11/30/2013 12:23	110	11.1	0.4	0.02	12,733.3	0.89
11/30/2013 12:24	110	6.7	0.4	0.02	12,733.3	0.55
11/30/2013 12:25	110	4.6	0.4	0.02	12,733.3	0.37
11/30/2013 12:26	110	3.6	0.3	0.02	12,711.1	0.28
11/30/2013 12:27	110	2.4	0.3	0.02	12,733.3	0.20
11/30/2013 12:28	110	1.3	0.3	0.02	12,733.3	0.11
11/30/2013 12:29	110	0.7	0.3	0.02	12,733.3	0.07
11/30/2013 12:30	110	0.6	0.2	0.00	12,688.9	0.04
11/30/2013 12:31	110	0.5	0.2	0.00	12,711.1	0.04
11/30/2013 12:32	110	0.4	0.2	0.00	12,733.3	0.04
11/30/2013 12:33	110	0.4	0.2	0.00	12,733.3	0.02
11/30/2013 12:34	110	0.4	0.1	0.00	12,711.1	0.02
11/30/2013 12:35	110	0.4	0.1	0.00	12,733.3	0.02
11/30/2013 12:36	110	0.4	0.1	0.00	12,711.1	0.02
11/30/2013 12:37	110	0.4	0.1	0.00	12,711.1	0.02
Total				547.01		59.08

Date/Time Startup Commences: 12/04/2013 08:40
 Gas Turbine Downtime: 81 Hours
 Steam Turbine Downtime: 81 Hours
 Startup Type*: Cold

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
12/04/2013 08:40	0	0.0	0.0	0.00	800.0	0.00
12/04/2013 08:41	0	0.0	0.0	0.00	1,044.4	0.00
12/04/2013 08:42	0	23.6	200.6	1.33	1,733.3	0.26
12/04/2013 08:43	0	7.9	2,710.6	26.33	2,533.3	0.13
12/04/2013 08:44	0	9.9	2,909.9	38.19	3,422.2	0.22
12/04/2013 08:45	0	10.9	2,359.1	38.40	4,244.4	0.29
12/04/2013 08:46	0	12.7	2,405.5	43.67	4,733.3	0.38
12/04/2013 08:47	0	15.7	2,650.2	54.44	5,355.6	0.53
12/04/2013 08:48	0	19.4	2,691.5	55.06	5,333.3	0.66
12/04/2013 08:49	0	22.1	2,854.3	58.14	5,311.1	0.75
12/04/2013 08:50	7	23.6	2,952.6	63.67	5,622.2	0.84
12/04/2013 08:51	17	28.9	2,940.2	69.91	6,200.0	1.14
12/04/2013 08:52	27	34.4	2,448.5	63.85	6,800.0	1.48
12/04/2013 08:53	35	39.0	1,752.6	49.89	7,422.2	1.83
12/04/2013 08:54	46	42.7	1,229.1	38.75	8,222.2	2.21
12/04/2013 08:55	57	47.5	701.1	24.25	9,022.2	2.71
12/04/2013 08:56	67	42.0	218.3	8.21	9,800.0	2.60
12/04/2013 08:57	77	36.6	39.9	1.61	10,533.3	2.44
12/04/2013 08:58	86	40.6	8.2	0.34	11,177.8	2.85
12/04/2013 08:59	94	39.3	6.6	0.30	11,777.8	2.93
12/04/2013 09:00	95	34.9	6.5	0.28	11,866.7	2.62
12/04/2013 09:01	95	30.7	5.8	0.26	11,844.4	2.29
12/04/2013 09:02	96	28.8	5.2	0.24	11,844.4	2.15
12/04/2013 09:03	96	26.5	4.4	0.20	11,777.8	1.98
12/04/2013 09:04	96	26.6	4.3	0.20	11,711.1	1.97
12/04/2013 09:05	95	26.6	4.5	0.20	11,644.4	1.96
12/04/2013 09:06	95	27.3	5.0	0.22	11,600.0	2.01
12/04/2013 09:07	98	28.0	5.3	0.24	11,777.8	2.08
12/04/2013 09:08	104	31.7	5.2	0.25	12,266.7	2.46
12/04/2013 09:09	105	32.1	3.8	0.19	12,333.3	2.49
12/04/2013 09:10	106	31.8	2.1	0.11	12,355.6	2.48
12/04/2013 09:11	106	31.8	1.3	0.06	12,333.3	2.47
12/04/2013 09:12	106	31.7	1.2	0.06	12,311.1	2.47
12/04/2013 09:13	106	31.7	1.3	0.06	12,311.1	2.47
12/04/2013 09:14	105	32.2	1.3	0.06	12,288.9	2.51
12/04/2013 09:15	106	33.0	1.4	0.06	12,288.9	2.57
12/04/2013 09:16	105	33.4	1.4	0.06	12,288.9	2.59
12/04/2013 09:17	105	33.6	1.3	0.06	12,266.7	2.61
12/04/2013 09:18	105	33.8	1.2	0.06	12,288.9	2.61
12/04/2013 09:19	105	33.9	1.1	0.04	12,266.7	2.63
12/04/2013 09:20	106	28.9	1.1	0.04	12,288.9	2.23
12/04/2013 09:21	105	16.8	1.0	0.04	12,288.9	1.31
12/04/2013 09:22	105	11.0	0.9	0.04	12,266.7	0.84
12/04/2013 09:23	105	2.7	0.8	0.04	12,266.7	0.21
12/04/2013 09:24	106	1.8	0.8	0.04	12,288.9	0.15
12/04/2013 09:25	105	1.5	0.7	0.04	12,266.7	0.13
12/04/2013 09:26	105	1.3	0.7	0.04	12,288.9	0.11
12/04/2013 09:27	105	1.1	0.7	0.04	12,288.9	0.08
12/04/2013 09:28	106	0.9	0.6	0.02	12,288.9	0.06
12/04/2013 09:29	106	0.8	0.6	0.02	12,288.9	0.06
12/04/2013 09:30	105	0.8	0.5	0.02	12,266.7	0.06
12/04/2013 09:31	105	0.8	0.5	0.02	12,244.4	0.06
12/04/2013 09:32	105	0.8	0.5	0.02	12,244.4	0.06
12/04/2013 09:33	105	0.8	0.5	0.02	12,266.7	0.06
12/04/2013 09:34	105	0.9	0.5	0.02	12,266.7	0.06
Total				639.71		77.15

Date/Time Startup Commences: 12/17/2013 10:40
 Gas Turbine Downtime: 1 Hours
 Steam Turbine Downtime: 1 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
12/17/2013 10:40	0	0.0	-29.5	0.00	311.1	0.00
12/17/2013 10:41	0	0.0	-29.5	0.00	111.1	0.00
12/17/2013 10:42	0	0.0	-29.5	0.00	1,222.2	0.00
12/17/2013 10:43	0	0.0	18.3	0.14	1,955.6	0.00
12/17/2013 10:44	0	0.3	30.7	0.32	2,688.9	0.00
12/17/2013 10:45	0	1.4	37.0	0.51	3,555.6	0.03
12/17/2013 10:46	0	2.5	45.7	0.74	4,222.2	0.07
12/17/2013 10:47	0	3.8	64.1	1.15	4,711.1	0.11
12/17/2013 10:48	0	6.5	78.2	1.61	5,355.6	0.22
12/17/2013 10:49	0	9.2	88.1	1.77	5,244.4	0.31
12/17/2013 10:50	1	11.4	98.3	1.88	4,977.8	0.36
12/17/2013 10:51	12	13.4	99.9	2.17	5,644.4	0.47
12/17/2013 10:52	25	18.7	83.8	2.12	6,577.8	0.78
12/17/2013 10:53	39	22.0	56.4	1.64	7,577.8	1.05
12/17/2013 10:54	53	28.8	33.3	1.11	8,622.2	1.57
12/17/2013 10:55	66	31.2	7.2	0.26	9,622.2	1.90
12/17/2013 10:56	79	15.6	4.3	0.18	10,666.7	1.04
12/17/2013 10:57	92	11.9	0.2	0.00	11,711.1	0.88
12/17/2013 10:58	106	9.1	-0.2	0.00	12,800.0	0.75
12/17/2013 10:59	111	7.0	-0.2	0.00	13,133.3	0.59
12/17/2013 11:00	119	4.2	-0.3	0.00	13,666.7	0.37
12/17/2013 11:01	126	1.4	-0.4	0.00	14,022.2	0.12
12/17/2013 11:02	126	0.8	-0.4	0.00	13,866.7	0.07
12/17/2013 11:03	124	0.3	-0.2	0.00	13,888.9	0.02
12/17/2013 11:04	125	0.3	0.6	0.02	13,844.4	0.02
12/17/2013 11:05	125	0.3	0.6	0.02	13,844.4	0.02
12/17/2013 11:06	126	0.3	0.0	0.00	13,822.2	0.02
12/17/2013 11:07	125	0.3	-0.4	0.00	13,800.0	0.02
12/17/2013 11:08	125	0.3	-0.4	0.00	13,800.0	0.02
12/17/2013 11:09	125	0.3	-0.4	0.00	13,777.8	0.02
12/17/2013 11:10	125	0.3	-0.4	0.00	13,777.8	0.02
12/17/2013 11:11	125	0.5	-0.3	0.00	13,777.8	0.05
Total				15.64		10.9

Date/Time Startup Commences: 12/22/2013 12:24
 Gas Turbine Downtime: 108 Hours
 Steam Turbine Downtime: 108 Hours
 Startup Type*: Cold

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
12/22/2013 12:24	0	0.0	0.0	0.00	600.0	0.00
12/22/2013 12:25	0	0.0	0.0	0.00	466.7	0.00
12/22/2013 12:26	0	0.0	0.0	0.00	1,311.1	0.00
12/22/2013 12:27	0	21.6	108.2	0.79	1,911.1	0.26
12/22/2013 12:28	0	9.0	2,684.5	27.68	2,688.9	0.15
12/22/2013 12:29	0	11.0	2,574.5	34.89	3,533.3	0.25
12/22/2013 12:30	0	13.5	2,073.9	34.11	4,288.9	0.37
12/22/2013 12:31	0	17.1	2,082.9	38.17	4,777.8	0.52
12/22/2013 12:32	0	22.1	2,335.3	49.17	5,488.9	0.77
12/22/2013 12:33	0	26.4	2,470.3	50.11	5,288.9	0.88
12/22/2013 12:34	0	31.7	2,921.1	59.00	5,266.7	1.06
12/22/2013 12:35	7	33.6	2,963.2	64.14	5,644.4	1.20
12/22/2013 12:36	21	40.5	2,877.1	71.11	6,444.4	1.65
12/22/2013 12:37	34	46.9	2,007.9	56.82	7,377.8	2.19
12/22/2013 12:38	48	51.3	1,151.5	37.79	8,555.6	2.77
12/22/2013 12:39	60	61.2	643.3	23.19	9,400.0	3.64
12/22/2013 12:40	74	45.3	88.3	3.54	10,444.4	2.99
12/22/2013 12:41	87	45.6	4.4	0.20	11,444.4	3.29
12/22/2013 12:42	98	44.7	2.0	0.08	12,355.6	3.49
12/22/2013 12:43	100	38.2	1.8	0.08	12,333.3	2.98
12/22/2013 12:44	100	30.4	2.2	0.10	12,200.0	2.34
12/22/2013 12:45	99	25.3	5.5	0.25	12,222.2	1.95
12/22/2013 12:46	99	24.9	3.7	0.17	12,222.2	1.93
12/22/2013 12:47	99	23.2	1.8	0.08	12,155.6	1.79
12/22/2013 12:48	99	21.6	1.6	0.08	12,022.2	1.63
12/22/2013 12:49	99	21.6	1.4	0.06	12,000.0	1.64
12/22/2013 12:50	99	21.7	1.4	0.06	11,977.8	1.64
12/22/2013 12:51	99	22.1	1.5	0.06	12,000.0	1.67
12/22/2013 12:52	99	23.1	1.6	0.08	12,000.0	1.75
12/22/2013 12:53	100	24.6	1.6	0.08	12,044.4	1.88
12/22/2013 12:54	103	26.4	1.5	0.06	12,333.3	2.05
12/22/2013 12:55	104	26.4	1.3	0.06	12,311.1	2.05
12/22/2013 12:56	104	26.6	1.0	0.04	12,355.6	2.07
12/22/2013 12:57	105	26.7	0.9	0.04	12,422.2	2.09
12/22/2013 12:58	105	27.2	0.9	0.04	12,422.2	2.13
12/22/2013 12:59	105	27.7	0.7	0.04	12,422.2	2.17
12/22/2013 13:00	106	28.0	0.6	0.02	12,422.2	2.19
12/22/2013 13:01	106	28.1	0.5	0.02	12,422.2	2.19
12/22/2013 13:02	106	28.2	0.5	0.02	12,422.2	2.21
12/22/2013 13:03	105	26.5	0.5	0.02	12,422.2	2.06
12/22/2013 13:04	105	16.2	0.4	0.02	12,422.2	1.28
12/22/2013 13:05	105	10.1	0.4	0.02	12,400.0	0.79
12/22/2013 13:06	105	6.8	0.4	0.02	12,422.2	0.53
12/22/2013 13:07	105	5.2	0.4	0.02	12,400.0	0.40
12/22/2013 13:08	105	3.7	0.3	0.02	12,400.0	0.30
12/22/2013 13:09	105	1.5	0.3	0.02	12,400.0	0.13
12/22/2013 13:10	105	1.2	0.2	0.00	12,400.0	0.09
12/22/2013 13:11	105	0.9	0.2	0.00	12,422.2	0.06
12/22/2013 13:12	105	0.6	0.2	0.00	12,400.0	0.04
12/22/2013 13:13	105	0.4	0.1	0.00	12,400.0	0.04
12/22/2013 13:14	105	0.4	0.1	0.00	12,377.8	0.02
12/22/2013 13:15	105	0.3	0.1	0.00	12,377.8	0.02
12/22/2013 13:16	101	0.3	0.0	0.00	12,066.7	0.02
12/22/2013 13:17	100	0.3	0.1	0.00	12,000.0	0.02
12/22/2013 13:18	100	0.3	0.4	0.02	12,022.2	0.02
12/22/2013 13:19	100	0.3	0.5	0.02	12,022.2	0.02
Total				552.41		71.67

Date/Time Startup Commences: 12/26/2013 14:19
 Gas Turbine Downtime: 14 Hours
 Steam Turbine Downtime: 14 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
12/26/2013 14:19	0	0.0	0.0	0.00	888.9	0.00
12/26/2013 14:20	0	0.0	0.0	0.00	844.4	0.00
12/26/2013 14:21	0	8.9	50.2	0.32	1,688.9	0.10
12/26/2013 14:22	0	2.8	613.3	5.80	2,466.7	0.04
12/26/2013 14:23	0	3.8	1,557.3	19.24	3,222.2	0.08
12/26/2013 14:24	0	5.9	1,846.3	28.80	4,066.7	0.15
12/26/2013 14:25	0	11.6	2,076.0	36.45	4,577.8	0.34
12/26/2013 14:26	0	20.4	2,404.9	46.73	5,066.7	0.65
12/26/2013 14:27	0	23.2	2,520.3	50.05	5,177.8	0.75
12/26/2013 14:28	0	29.1	2,942.5	57.93	5,133.3	0.94
12/26/2013 14:29	8	29.7	3,004.9	62.48	5,422.2	1.01
12/26/2013 14:30	21	36.0	2,929.4	70.15	6,244.4	1.42
12/26/2013 14:31	34	40.1	1,845.8	50.98	7,200.0	1.83
12/26/2013 14:32	49	40.7	843.8	26.90	8,311.1	2.14
12/26/2013 14:33	62	44.3	170.2	6.06	9,288.9	2.59
12/26/2013 14:34	75	30.4	6.6	0.27	10,377.8	1.99
12/26/2013 14:35	88	33.3	2.5	0.12	11,333.3	2.39
12/26/2013 14:36	102	29.9	1.1	0.06	12,355.6	2.33
12/26/2013 14:37	116	25.0	0.8	0.05	13,377.8	2.11
12/26/2013 14:38	124	20.1	0.5	0.02	13,911.1	1.76
12/26/2013 14:39	125	16.9	0.4	0.02	13,822.2	1.47
12/26/2013 14:40	125	14.3	0.4	0.02	13,777.8	1.25
12/26/2013 14:41	125	13.4	0.9	0.05	13,844.4	1.19
12/26/2013 14:42	125	15.8	1.1	0.05	13,844.4	1.38
12/26/2013 14:43	125	15.8	0.9	0.05	13,822.2	1.37
12/26/2013 14:44	125	15.0	0.4	0.02	13,800.0	1.30
12/26/2013 14:45	125	10.3	0.3	0.02	13,822.2	0.90
12/26/2013 14:46	125	5.0	0.3	0.02	13,822.2	0.43
12/26/2013 14:47	125	3.3	0.2	0.00	13,822.2	0.28
12/26/2013 14:48	126	2.4	0.2	0.00	13,822.2	0.21
12/26/2013 14:49	125	1.8	0.2	0.00	13,822.2	0.17
12/26/2013 14:50	125	1.2	0.2	0.00	13,822.2	0.09
12/26/2013 14:51	125	1.0	0.2	0.00	13,822.2	0.09
12/26/2013 14:52	125	0.8	0.2	0.00	13,822.2	0.07
12/26/2013 14:53	125	0.5	0.2	0.00	13,822.2	0.05
12/26/2013 14:54	125	0.4	0.2	0.00	13,844.4	0.05
12/26/2013 14:55	125	0.3	0.1	0.00	13,822.2	0.02
12/26/2013 14:56	125	0.3	0.1	0.00	13,822.2	0.02
12/26/2013 14:57	125	0.3	0.1	0.00	13,822.2	0.02
12/26/2013 14:58	125	0.3	0.1	0.00	13,844.4	0.02
12/26/2013 14:59	125	0.3	0.0	0.00	13,822.2	0.02
Total				462.66		33.02

Date/Time Startup Commences: 12/27/2013 04:54
 Gas Turbine Downtime: 5 Hours
 Steam Turbine Downtime: 5 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
12/27/2013 04:54	0	0.0	-29.5	0.00	822.2	0.00
12/27/2013 04:55	0	0.0	-29.5	0.00	955.6	0.00
12/27/2013 04:56	0	0.0	15.3	0.10	1,777.8	0.00
12/27/2013 04:57	0	0.3	29.8	0.29	2,555.6	0.00
12/27/2013 04:58	0	1.8	42.8	0.56	3,400.0	0.04
12/27/2013 04:59	0	2.7	50.2	0.80	4,177.8	0.07
12/27/2013 05:00	0	4.6	75.6	1.35	4,666.7	0.14
12/27/2013 05:01	0	6.8	97.5	1.93	5,155.6	0.22
12/27/2013 05:02	0	9.4	101.7	2.07	5,311.1	0.31
12/27/2013 05:03	0	12.6	117.0	2.36	5,266.7	0.42
12/27/2013 05:04	7	13.8	115.6	2.50	5,622.2	0.49
12/27/2013 05:05	20	18.3	106.0	2.54	6,244.4	0.72
12/27/2013 05:06	33	20.8	79.7	2.19	7,177.8	0.95
12/27/2013 05:07	48	25.6	50.2	1.59	8,288.9	1.34
12/27/2013 05:08	61	34.5	27.8	0.98	9,200.0	2.00
12/27/2013 05:09	74	23.6	7.3	0.28	10,266.7	1.53
12/27/2013 05:10	86	15.5	2.2	0.10	11,222.2	1.10
12/27/2013 05:11	101	13.3	0.3	0.02	12,377.8	1.04
12/27/2013 05:12	114	10.1	0.1	0.00	13,466.7	0.85
12/27/2013 05:13	120	8.0	0.0	0.00	13,800.0	0.69
12/27/2013 05:14	126	3.4	-0.1	0.00	14,222.2	0.29
12/27/2013 05:15	131	1.1	-0.2	0.00	14,511.1	0.10
12/27/2013 05:16	131	0.6	-0.2	0.00	14,377.8	0.05
12/27/2013 05:17	129	0.2	-0.2	0.00	14,333.3	0.02
12/27/2013 05:18	130	0.2	0.3	0.02	14,311.1	0.02
12/27/2013 05:19	130	0.2	0.2	0.02	14,333.3	0.02
12/27/2013 05:20	130	0.2	-0.1	0.00	14,333.3	0.02
12/27/2013 05:21	131	0.2	-0.3	0.00	14,333.3	0.02
12/27/2013 05:22	130	0.2	-0.3	0.00	14,288.9	0.02
12/27/2013 05:23	131	0.2	-0.3	0.00	14,311.1	0.02
12/27/2013 05:24	130	0.2	-0.3	0.00	14,288.9	0.02
12/27/2013 05:25	130	0.2	-0.3	0.00	14,288.9	0.02
Total				19.7		12.53

Date/Time Startup Commences: 12/28/2013 07:19
 Gas Turbine Downtime: 8 Hours
 Steam Turbine Downtime: 8 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
12/28/2013 07:19	0	0.0	0.0	0.00	822.2	0.00
12/28/2013 07:20	0	0.0	0.0	0.00	800.0	0.00
12/28/2013 07:21	0	0.0	11.8	0.07	1,666.7	0.00
12/28/2013 07:22	0	0.3	29.2	0.27	2,444.4	0.00
12/28/2013 07:23	0	0.6	68.0	0.84	3,244.4	0.01
12/28/2013 07:24	0	2.2	163.9	2.58	4,111.1	0.06
12/28/2013 07:25	0	4.6	295.0	5.23	4,622.2	0.13
12/28/2013 07:26	0	8.1	345.9	7.04	5,311.1	0.27
12/28/2013 07:27	0	12.2	361.8	7.40	5,333.3	0.41
12/28/2013 07:28	0	16.1	363.8	7.41	5,311.1	0.54
12/28/2013 07:29	6	17.5	337.7	6.71	5,177.8	0.57
12/28/2013 07:30	16	20.2	276.7	6.32	5,955.6	0.76
12/28/2013 07:31	26	22.0	182.4	4.66	6,666.7	0.93
12/28/2013 07:32	35	25.8	90.5	2.55	7,333.3	1.19
12/28/2013 07:33	46	28.6	54.4	1.70	8,155.6	1.47
12/28/2013 07:34	56	35.2	32.5	1.11	8,866.7	1.98
12/28/2013 07:35	65	32.1	8.4	0.31	9,555.6	1.93
12/28/2013 07:36	76	19.7	8.0	0.32	10,333.3	1.29
12/28/2013 07:37	85	14.8	4.3	0.19	11,044.4	1.02
12/28/2013 07:38	96	11.7	1.1	0.04	11,888.9	0.88
12/28/2013 07:39	104	9.2	0.8	0.04	12,533.3	0.73
12/28/2013 07:40	106	6.6	0.5	0.02	12,600.0	0.52
12/28/2013 07:41	106	2.6	0.3	0.02	12,600.0	0.22
12/28/2013 07:42	105	1.1	0.1	0.00	12,555.6	0.09
12/28/2013 07:43	105	0.5	0.2	0.00	12,533.3	0.04
12/28/2013 07:44	105	0.4	0.2	0.00	12,533.3	0.02
12/28/2013 07:45	105	0.4	0.1	0.00	12,533.3	0.02
12/28/2013 07:46	105	0.3	0.1	0.00	12,533.3	0.02
12/28/2013 07:47	105	0.2	0.0	0.00	12,533.3	0.02
12/28/2013 07:48	105	0.2	0.0	0.00	12,533.3	0.02
12/28/2013 07:49	105	0.2	0.0	0.00	12,533.3	0.02
12/28/2013 07:50	105	0.2	0.0	0.00	12,555.6	0.02
12/28/2013 07:51	105	0.2	0.0	0.00	12,533.3	0.02
Total				54.83		15.2

Date/Time Startup Commences: 12/29/2013 14:14
 Gas Turbine Downtime: 13 Hours
 Steam Turbine Downtime: 13 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOx Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
12/29/2013 14:14	0	0.0	0.0	0.00	822.2	0.00
12/29/2013 14:15	0	0.0	0.0	0.00	844.4	0.00
12/29/2013 14:16	0	0.0	17.7	0.12	1,688.9	0.00
12/29/2013 14:17	0	0.7	45.7	0.43	2,444.4	0.01
12/29/2013 14:18	0	2.3	661.6	8.29	3,266.7	0.05
12/29/2013 14:19	0	3.5	1,094.3	17.07	4,066.7	0.09
12/29/2013 14:20	0	8.1	1,642.0	28.69	4,555.6	0.23
12/29/2013 14:21	0	15.0	2,084.4	39.79	4,977.8	0.47
12/29/2013 14:22	0	21.6	2,277.0	45.02	5,155.6	0.70
12/29/2013 14:23	0	26.2	2,779.7	54.72	5,133.3	0.85
12/29/2013 14:24	8	27.5	2,737.0	57.15	5,444.4	0.94
12/29/2013 14:25	21	33.3	2,655.8	63.83	6,266.7	1.32
12/29/2013 14:26	34	37.3	1,596.0	44.07	7,200.0	1.69
12/29/2013 14:27	49	37.2	577.7	18.56	8,377.8	1.97
12/29/2013 14:28	61	41.0	105.7	3.76	9,266.7	2.40
12/29/2013 14:29	74	26.9	5.9	0.23	10,311.1	1.75
12/29/2013 14:30	88	30.0	2.2	0.10	11,333.3	2.14
12/29/2013 14:31	101	27.7	1.1	0.04	12,355.6	2.16
12/29/2013 14:32	106	24.5	0.8	0.04	12,577.8	1.94
12/29/2013 14:33	106	19.4	0.5	0.02	12,422.2	1.53
12/29/2013 14:34	105	17.0	0.8	0.04	12,466.7	1.35
12/29/2013 14:35	107	20.1	1.8	0.09	12,533.3	1.59
12/29/2013 14:36	110	20.0	1.7	0.09	12,711.1	1.61
12/29/2013 14:37	110	20.2	1.0	0.04	12,688.9	1.61
12/29/2013 14:38	110	15.8	0.8	0.04	12,688.9	1.26
12/29/2013 14:39	110	10.0	0.7	0.04	12,666.7	0.80
12/29/2013 14:40	110	6.7	0.6	0.02	12,688.9	0.54
12/29/2013 14:41	110	5.2	0.4	0.02	12,688.9	0.41
12/29/2013 14:42	110	4.2	0.3	0.02	12,666.7	0.33
12/29/2013 14:43	110	2.5	0.4	0.02	12,688.9	0.20
12/29/2013 14:44	110	1.3	0.3	0.02	12,688.9	0.11
12/29/2013 14:45	110	0.7	0.3	0.02	12,688.9	0.07
12/29/2013 14:46	110	0.6	0.3	0.02	12,688.9	0.04
12/29/2013 14:47	110	0.5	0.2	0.00	12,688.9	0.04
12/29/2013 14:48	110	0.4	0.2	0.00	12,666.7	0.02
12/29/2013 14:49	110	0.3	0.2	0.00	12,688.9	0.02
12/29/2013 14:50	110	0.3	0.1	0.00	12,688.9	0.02
12/29/2013 14:51	110	0.3	0.1	0.00	12,688.9	0.02
12/29/2013 14:52	110	0.2	0.0	0.00	12,688.9	0.02
12/29/2013 14:53	110	0.2	0.0	0.00	12,688.9	0.02
Total				382.41		30.32

Date/Time Startup Commences: 12/30/2013 03:35
 Gas Turbine Downtime: 4 Hours
 Steam Turbine Downtime: 4 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
12/30/2013 03:35	0	0.0	0.0	0.00	866.7	0.00
12/30/2013 03:36	0	0.0	0.0	0.00	622.2	0.00
12/30/2013 03:37	0	0.0	2.0	0.01	1,666.7	0.00
12/30/2013 03:38	0	0.3	27.8	0.26	2,444.4	0.00
12/30/2013 03:39	0	1.0	39.5	0.50	3,288.9	0.02
12/30/2013 03:40	0	2.1	43.0	0.68	4,111.1	0.06
12/30/2013 03:41	0	3.5	61.8	1.09	4,600.0	0.10
12/30/2013 03:42	0	5.0	81.1	1.61	5,177.8	0.17
12/30/2013 03:43	0	7.8	90.4	1.83	5,288.9	0.26
12/30/2013 03:44	0	10.2	103.4	2.08	5,266.7	0.33
12/30/2013 03:45	7	11.6	105.8	2.23	5,488.9	0.40
12/30/2013 03:46	20	14.8	101.4	2.42	6,222.2	0.59
12/30/2013 03:47	32	18.5	77.0	2.10	7,111.1	0.83
12/30/2013 03:48	46	22.9	50.3	1.57	8,133.3	1.17
12/30/2013 03:49	59	31.9	28.4	0.98	9,111.1	1.83
12/30/2013 03:50	73	24.3	7.7	0.30	10,177.8	1.57
12/30/2013 03:51	86	14.8	1.7	0.08	11,222.2	1.06
12/30/2013 03:52	100	12.8	0.2	0.00	12,333.3	0.99
12/30/2013 03:53	113	9.9	0.0	0.00	13,355.6	0.85
12/30/2013 03:54	118	8.1	-0.1	0.00	13,688.9	0.70
12/30/2013 03:55	120	4.2	-0.2	0.00	13,711.1	0.38
12/30/2013 03:56	121	1.1	-0.2	0.00	13,644.4	0.09
12/30/2013 03:57	119	0.7	-0.2	0.00	13,622.2	0.07
12/30/2013 03:58	120	0.5	0.2	0.00	13,622.2	0.05
12/30/2013 03:59	120	0.3	0.2	0.00	13,622.2	0.02
12/30/2013 04:00	120	0.3	-0.2	0.00	13,577.8	0.02
12/30/2013 04:01	120	0.2	-0.3	0.00	13,600.0	0.02
12/30/2013 04:02	120	0.2	-0.3	0.00	13,622.2	0.02
12/30/2013 04:03	120	0.2	-0.3	0.00	13,644.4	0.02
12/30/2013 04:04	120	0.2	-0.3	0.00	13,622.2	0.02
12/30/2013 04:05	120	0.2	-0.3	0.00	13,644.4	0.02
12/30/2013 04:06	120	0.2	-0.3	0.00	13,600.0	0.02
Total				17.74		11.68

Date/Time Startup Commences: 12/31/2013 14:24
 Gas Turbine Downtime: 13 Hours
 Steam Turbine Downtime: 13 Hours
 Startup Type*: Hot

Sample Time	CT1 Load Mwe	CT1 NOX Ppmvdc	CT1 CO Ppmvdc	CT1 CO_SUSD Lb	CT1 GasFlow 100scfh	CT1 NOX_SUSD Lb
12/31/2013 14:24	0	0.0	0.0	0.00	800.0	0.00
12/31/2013 14:25	0	0.0	0.0	0.00	933.3	0.00
12/31/2013 14:26	0	7.9	43.3	0.29	1,733.3	0.09
12/31/2013 14:27	0	2.8	529.3	5.10	2,511.1	0.04
12/31/2013 14:28	0	4.6	1,331.9	17.14	3,355.6	0.10
12/31/2013 14:29	0	5.9	1,592.8	25.11	4,111.1	0.16
12/31/2013 14:30	0	11.6	1,892.9	33.39	4,600.0	0.34
12/31/2013 14:31	0	17.9	2,253.0	43.78	5,066.7	0.57
12/31/2013 14:32	0	23.4	2,391.3	47.49	5,177.8	0.76
12/31/2013 14:33	0	29.5	2,816.1	55.69	5,155.6	0.96
12/31/2013 14:34	10	29.9	2,860.7	60.96	5,555.6	1.05
12/31/2013 14:35	22	36.5	2,697.2	65.98	6,377.8	1.46
12/31/2013 14:36	35	40.5	1,674.2	46.66	7,266.7	1.86
12/31/2013 14:37	49	41.4	650.9	21.08	8,444.4	2.21
12/31/2013 14:38	62	43.8	114.3	4.11	9,377.8	2.59
12/31/2013 14:39	76	30.2	5.4	0.21	10,444.4	1.99
12/31/2013 14:40	89	32.5	1.9	0.08	11,488.9	2.36
12/31/2013 14:41	103	29.6	1.1	0.04	12,444.4	2.32
12/31/2013 14:42	116	25.5	0.8	0.05	13,422.2	2.16
12/31/2013 14:43	124	20.1	0.5	0.02	13,911.1	1.76
12/31/2013 14:44	125	18.3	0.3	0.02	13,866.7	1.59
12/31/2013 14:45	125	15.4	0.4	0.02	13,888.9	1.36
12/31/2013 14:46	125	16.1	0.9	0.05	13,888.9	1.40
12/31/2013 14:47	126	17.2	0.9	0.05	13,933.3	1.50
12/31/2013 14:48	125	17.1	0.7	0.02	13,888.9	1.50
12/31/2013 14:49	126	12.6	0.3	0.02	13,866.7	1.09
12/31/2013 14:50	126	8.2	0.2	0.00	13,866.7	0.71
12/31/2013 14:51	126	4.0	0.2	0.00	13,866.7	0.36
12/31/2013 14:52	126	3.0	0.2	0.00	13,866.7	0.26
12/31/2013 14:53	126	2.1	0.2	0.00	13,866.7	0.19
12/31/2013 14:54	125	1.3	0.2	0.00	13,866.7	0.12
12/31/2013 14:55	125	0.8	0.2	0.00	13,866.7	0.07
12/31/2013 14:56	126	0.7	0.2	0.00	13,866.7	0.05
12/31/2013 14:57	126	0.5	0.2	0.00	13,888.9	0.05
12/31/2013 14:58	126	0.4	0.2	0.00	13,866.7	0.05
12/31/2013 14:59	125	0.3	0.2	0.00	13,866.7	0.02
12/31/2013 15:00	125	0.3	0.2	0.00	13,844.4	0.02
12/31/2013 15:01	125	0.3	0.2	0.00	13,866.7	0.02
12/31/2013 15:02	126	0.3	0.1	0.00	13,866.7	0.02
12/31/2013 15:03	125	0.3	0.1	0.00	13,866.7	0.02
Total				427.36		33.18