



FOSTER WHEELER ENVIRONMENTAL CORPORATION

October 3, 2001
SO-2449-100201-DD

DOCKET 01-AFC-7
DATE OCT 03 2001
RECD. OCT 03 2001

Ms. Kae Lewis
Project Manager
California Energy Commission
1516 9th Street
Sacramento, CA 95814

**SUBJECT: GEOLOGIC FOUNDATION CRITERIA AND SEIZMIC HAZARDS STUDY
RUSSELL CITY ENERGY CENTER PROJECT (01-AFC-07)**

Dear Ms. Lewis:

Attached for filing with the California Energy Commission Docket Unit are an original and 12 copies of *Appendix 10G, Geologic and Foundation Design Criteria*, and a *Seismic Hazards Study* in support of the Application for Certification for the Calpine/Béchtel Joint Development's Russell City Energy Center (01-AFC-07).

Sincerely,

Douglas M. Davy, Ph.D.
AFC Project Manager

Attachment

cc: Alex Ameri, City of Hayward
Service list



APPENDIX 10G GEOLOGIC AND FOUNDATION CRITERIA

for the
**APPLICATION FOR CERTIFICATION
RUSSELL CITY ENERGY CENTER
RUSSELL CITY, CALIFORNIA**

prepared by •

**GEOTECHNICAL AND HYDRAULIC ENGINEERING SERVICES
BECHTEL POWER CORPORATION
FREDERICK, MARYLAND**

Bechtel Confidential

© Bechtel Corporation 2001. Contains confidential and/or proprietary information to Bechtel and its affiliated companies which shall not be used, disclosed, or reproduced in any format by any non-Bechtel party without Bechtel's prior written permission. All rights reserved.


0	9/24/2001	Issued for use	<i>JK</i>	<i>HWJ</i>	<i>ckl</i>	
REV.	DATE	REASON FOR REVISION	BY	EGS	PE	
		JOB NO. 24405-004				
		DOCUMENT NO.				REV.
		24405-004-KOR-CY00-00001				000
		Sheet 10G-1		of 10G-14		

TABLE OF CONTENTS

<u>Section</u>	<u>Page</u>
COVER SHEET	10G-1
TABLE OF CONTENTS	10G-2
10G1.0 INTRODUCTION	10G-4
10G2.0 SCOPE OF WORK	10G-4
10G3.0 SITE CONDITIONS	10G-4
10G4.0 SUBSURFACE INVESTIGATION.....	10G-5
10G5.0 SITE SUBSURFACE CONDITIONS	10G-6
10G5.1 Physiography and Geology	10G-6
10G5.2 Seismology.....	10G-7
10G5.3 Stratigraphy.....	10G-7
10G5.4 Ground Water	10G-8
10G5.5 Soil Profile Type.....	10G-8
10G6.0 FIELD ELECTRICAL RESISTIVITY SURVEY.....	10G-8
10G7.0 LABORATORY TESTING PROGRAM	10G-8
10G8.0 ASSESSMENT OF SOIL-RELATED HAZARDS	10G-9
10G8.1 Liquefaction.....	10G-9
10G8.2 Seismically-Induced Settlements	10G-9
10G8.3 Expansive Soils.....	10G-9
10G8.4 Collapsible Soils.....	10G-9
10G8.5 Slope Stability	10G-10
10G9.0 PRELIMINARY FOUNDATION CONSIDERATIONS.....	10G-10
10G9.1 General Foundation Design Criteria.....	10G-10
10G9.2 Selection of Foundation Type	10G-10
10G9.3 Deep Foundations.....	10G-11
10G9.4 Shallow Foundations.....	10G-11
10G9.5 Corrosion Potential and Ground Aggressiveness.....	10G-11
10G10.0 PRELIMINARY EARTHWORK CONSIDERATIONS.....	10G-12
10G10.1 Site Preparation and Grading.....	10G-12
10G10.2 Temporary Excavations.....	10G-12
10G10.3 Permanent Slopes.....	10G-12
10G10.4 Backfill Requirements.....	10G-12
10G11.0 INSPECTION AND MONITORING	10G-13
10G12.0 SITE DESIGN CRITERIA	10G-13
10G12.1 General	10G-13
10G12.2 Datum.....	10G-13

10G13.0 FOUNDATION DESIGN CRITERIA..... 10G-14
 10G13.1 General 10G-14
 10G13.2 Ground Water Pressures 10G-14
 10G13.3 Factors of Safety 10G-14
 10G13.4 Load Factors and Load Combinations 10G-14
10G14.0 REFERENCES 10G-14

TABLES

- 10G-1 Summary of Ground Water Level Readings in OW-107 (1 page)
- 10G-2 Summary of Laboratory Test Results (2 pages)

FIGURES

- 10G-1 Site Location Map (1 page)
- 10G-2 Boring Location Plan (1 Page)
- 10G-3 Subsurface Profile Legend (1 page)
- 10G-4 Subsurface Profile Section A-A' (1 page)
- 10G-5 Subsurface Profile Section B-B' (1 page)
- 10G-6 Subsurface Profile Section C-C' (1 page)

ATTACHMENTS

- 10G-1 Boring Logs (33 pages)
- 10G-2 Ground Water Observation Well Log (1 page)
- 10G-3 Laboratory Test Results (37 pages)

10G1.0 INTRODUCTION

This appendix includes the results of the preliminary subsurface investigation, laboratory testing program and geotechnical assessment for the Russell City Energy Center (RCEC) Project to support the Application for Certification (AFC).

This appendix contains a description of the site conditions, field and laboratory testing phases of the investigation, together with the ground water, and foundation related subsurface conditions. Preliminary engineering design properties derived from the results of the investigation are discussed. Soil related hazards addressed include soil liquefaction, seismically induced settlements, expansive soils, hydrocompaction (or collapsible soils), and slope instability. Preliminary foundation and earthwork considerations are addressed based on the results of the site investigation, observations by geotechnical personnel on site, and established geotechnical engineering practices.

Information contained in this appendix reflects the codes, standards, criteria and practices generally used in the design and construction of site and foundation engineering systems for the Facility. More specific project information will be developed during execution of the project to support the preparation of detailed design, engineering, material procurement specification and construction specifications.

10G2.0 SCOPE OF WORK

The scope of geotechnical services for the preparation of this appendix included:

- developing a boring location plan and specification for a field and laboratory investigation,
- selecting a drilling and testing subcontractor and technically monitoring the work in the field,
- assigning laboratory tests for representative soil samples,
- determining current ground water levels,
- preparing this appendix to include an assessment of soils-related hazards, a summary of preliminary foundation and earthwork considerations, and preliminary guidelines for inspection and monitoring of geotechnical aspects of construction.

10G3.0 SITE CONDITIONS

The power plant site is located at the southwestern corner of the intersection of Enterprise Avenue and Whitesell Street in Russell City to the west of Hayward, California, and less than 1 mile from the eastern shore of the San Francisco Bay.

Figure 10G-1 shows the site location with respect to Hayward and other San Francisco Bay area geographical features.

The power plant site consists of the Salem property, currently occupied by KFOX radio station towers, and the Runnels Industries property. Four existing radio station towers in the Salem property will be relocated to a capped landfill site about 1 mile north of the power plant site. The paragraphs that follow provide site conditions for the Salem and the Runnels Industries properties.

Runnels Property Site Conditions – The Runnels property is located at the intersection of Enterprise Avenue and Whitesell Street. The entrance gate is on Whitesell Street, near the intersection with Enterprise Avenue. The site is bounded on the west side by the Salem property, and railroad tracks are located just outside the southern site boundary. The railroad tracks end just west of the property, to the south of the Salem property. The site is very flat, and the ground surface is covered with loose gravel, or compacted soil/gravel mix. Some asphalt was also found. There is little vegetation, which is confined to narrow and isolated patches along the property boundary. There are several 1-story, pre-fabricated metal buildings on the property. Based on verbal information obtained at the site, the area, including the neighboring Salem property, was previously used as evaporative ponds for salt production. Two borings drilled at the site (B-105 and B-109) disclosed about 4 ft of miscellaneous fill.

Salem Property Site Conditions – The Salem property is located on the south side of Enterprise Avenue, next to the Runnels property. The entrance gate is on Enterprise Avenue near the northeastern property corner (near the Runnels property boundary). A large warehouse bounds the site on the west side, and railroad tracks coming from the east end are present about halfway along the southern site boundary. The site is fairly flat, with a 20-yd wide strip along Enterprise Avenue and the warehouse along the western site boundary being a few feet higher than the remainder of the site. Enterprise Avenue, the Runnels property and the warehouse along the western site boundary are all at elevations 3 to 5 feet higher than the existing elevations throughout most of the Salem property site. The ground surface is completely covered with grass and weeds that grow about 1 ft to 1.5 ft high. There are 4 radio towers located at the site and one 1-story, pre-fabricated metal building toward the north-central part of the property that serves as a control room. A gravel-surfaced access road connects the pre-fabricated metal building to the site gate. An overhead power line supplies electricity to the pre-fabricated metal building from a wooden pole on Enterprise Avenue.

10G4.0 SUBSURFACE INVESTIGATION

The site subsurface investigation described in this appendix was conducted at the site in May-June, 2001. The investigation was conducted in accordance with a specification prepared for this project, and followed the American Society for Testing and Materials (ASTM) and other applicable standards.

As shown on Figure 10G-2, 9 soil borings were drilled at selected locations to obtain soil samples, and to perform standard penetration testing (SPT). Harding ESE of Novato, California performed the subsurface investigation. Bechtel geotechnical personnel provided technical direction of all field operations.

A total of 1001 linear feet of soil were drilled in the 9 borings. The borings ranged in depth from 100 feet to 160 feet to provide a preliminary assessment of the subsurface conditions to depths of interest for foundation design and construction. A single ground water observation well was also installed to a depth of 32 feet in a borehole drilled about 5 feet to the south of boring B-107.

The borings were drilled using a truck-mounted Failing F1500 drill rig. All borings were drilled using rotary wash methods and a bentonite drilling fluid to maintain a positive pressure and a stable borehole. An Organic Vapor Analyzer was used to check for the presence of hydrocarbon contamination of soil samples. No detectable levels were measured in any of the borings drilled in the Runnels and in the Salem property. All drill cuttings and drilling mud were contained and stored in a bin, and were disposed of at an approved landfill offsite at the end of the subsurface investigation. All boreholes were grouted to the surface upon completion.

Standard Penetration Test (SPT) soil samples were obtained in accordance with ASTM D 1586 in the borings by driving a 2-inch OD split-barrel sampler 18 inches with a 140-pound, cathead-operated hammer falling freely through a distance of 30 inches. Continuous sampling was conducted to a depth of about 15 feet, and at 5-foot intervals thereafter. The standard penetration resistance value (N-value) is defined as the number of blows required to drive the split-barrel sampler a total distance of 12 inches, the count being started after a penetration of 6 inches. When the sampler could not be driven the required 12 inches, the standard penetration resistance was shown as the number of blows over the inches actually penetrated.

Undisturbed soil samples were obtained by pushing 3-inch OD Shelby tubes into the ground at select depths in accordance with ASTM D 1587. In each case, the Shelby tubes were pushed a total of 30 inches. The unconfined compressive strength of undisturbed samples was estimated in the field using a pocket penetrometer. The Shelby tubes were sealed with a microcrystalline wax, plastic cap and tape to preserve the natural moisture content of the soil samples.

10G5.0 SITE SUBSURFACE CONDITIONS

10G5.1 Physiography and Geology

The site physiography and geology are discussed in detail in Section 8.4 of the AFC.

10G5.2 Seismology

The site seismology is included in Section 8.4 of the AFC. The site is located in Seismic Zone 4 based on the 1998 California Building Code (Reference 1).

10G5.3 Stratigraphy

The available data from the borings completed at the site indicate that the subsurface stratigraphy throughout the site is characterized by an upper layer of fill and black clay underlain by predominantly clayey soils (Clay Stratum).

The subsurface profiles, as interpreted from the borings and laboratory test results, are shown on Figures 10G-3 through 10G-6. Figure 10G-3 describes the type of information shown on the profiles. The delineation between soil types shown between boring locations on the profiles is assumed, and the descriptions on the profiles represent an interpretation of the subsurface conditions at the boring locations. The subsurface conditions between boring locations may differ from those shown on the profiles. Detailed descriptions of the materials found at the boring locations are given on the boring logs shown in Attachment 10G-1.

Descriptions of the upper fill and black clay layer and the Clay Stratum are presented in the following paragraphs. Information on layer thickness, SPT blow counts, and unconfined compressive strength is also included.

Fill and Black Clay Layer – The upper fill was encountered in the borings drilled in the Reynolds property (B-105 and B-109), and black clay was encountered in all borings, including borings B-105 and B-109. The fill is mostly granular, and the black clay contains organics and is highly plastic. The thickness of this upper layer ranged from about 3 to 7.5 feet with an average of about 4.2 feet. SPT blow counts in this layer ranged from 6 blows/foot (bpf) to 17/3" (17 blows/3" of sampler penetration on a section of asphalt pavement) with an average of about 17 bpf.

Clay Stratum - The clay stratum was encountered beneath the upper fill and black clay layer, and extended to the termination depth of all borings. The clay is mostly brown and/or gray, and ranged from low to high plasticity. Silt seams were often encountered in the clay stratum, as well as occasional pockets of silty sand and clayey sand. SPT blow counts in this layer ranged from 1/15" to 53 bpf with an average of about 15 bpf. A zone of generally low SPT blow counts was observed at a depth of about 115-ft. However, visual observation of the recovered samples, and pocket penetrometer test results generally indicated a much stiffer behavior than suggested by the low SPT values. The undrained strength measured in the laboratory ranged from 134 psf to 2111 psf with an average of 733 psf. The laboratory measured undrained strength is lower than suggested by the SPT blow counts, and may reflect some degree of sample disturbance. Consolidation test results indicated some degree of overconsolidation with pre-consolidation pressures ranging from about 1,000 psf to over 5,000 psf. These results match the consistency of the clay stratum suggested by the SPT values.

10G5.4 Ground Water

Ground water levels were measured in observation well OW-107, which was installed about 5 feet to the south of boring B-107. The ground water observation well log is shown in Attachment 10G-2, and the available ground water level readings are summarized in Table 10G-1. No long-term measurements of ground water levels were taken.

The measured ground water depths in OW-107 ranged from about 4.2 to 4.6 ft below grade, or from about El. 1.3 to 1.7 ft NGVD.

The design ground water elevation will be selected taking into account seasonal ground water level fluctuations, and will be higher than the highest observed ground water elevation. Based on the limited available ground water data, a preliminary design ground water level not lower than El. 4 ft NGVD can be used for waterproofing and buoyancy considerations. Positive drainage, and the use of impervious backfill, will also be considered to avoid the accumulation of runoff water in foundation excavations.

10G5.5 Soil Profile Type

The available subsurface data indicate that the site average soil properties for the top 100 feet of soil profile are close to the controlling criteria for both CBC Soil Profile Type S_D (Stiff Soil Profile) and Soil Profile Type S_E (Soft Soil Profile). Additional subsurface investigation, at the start of detailed design, will determine the specific soil type.

10G6.0 FIELD ELECTRICAL RESISTIVITY SURVEY

No field electrical resistivity survey was conducted on the site during the investigation. Field resistivity surveys will be conducted during a future, structure-specific subsurface investigation to be performed at the site. A Wenner four-electrode resistivity array will be used in accordance with ASTM G 57.

10G7.0 LABORATORY TESTING PROGRAM

Laboratory tests were performed to determine the preliminary physical, chemical and engineering characteristics of the subsurface soils. These tests included chemical analyses (pH, sulfates and chlorides), grain size analyses, index properties, unconfined compression and consolidation. Bechtel geotechnical personnel assigned all testing. All testing was performed using applicable ASTM Standards or other accepted procedures. Laboratory test results, as they relate to the assessment of soil-related hazards, are discussed in Section 10G8.0. The laboratory test results are shown in Attachment 10G-3, and a summary is given in Table 10G-2.

10G8.0 ASSESSMENT OF SOIL-RELATED HAZARDS

10G8.1 Liquefaction

Soil liquefaction is a process by which loose, saturated, granular deposits lose a significant portion of their shear strength due to pore water pressure buildup resulting from cyclic loading, such as that caused by an earthquake. Soil liquefaction can lead to foundation bearing failures and excessive settlements when:

- the design ground acceleration is high;
- the water level is relatively shallow; and
- low SPT blow counts are measured in granular deposits (suggesting low soil density).

The results of the site subsurface investigation indicate that the site soils are mostly cohesive and therefore are not susceptible to liquefaction.

10G8.2 Seismically-Induced Settlements

Seismically induced settlements occur when ground shaking causes soil densification. Soils susceptible to seismic densification are granular, generally loose and uncemented. Soils below the final site grade will consist of compacted structural fill and mostly cohesive soils. Thus, the potential for seismically induced settlement at this site can be considered nil.

10G8.3 Expansive Soils

Soil expansion is a phenomenon by which clayey soils expand in volume as a result of an increase in moisture content. The same soils shrink in volume upon drying. Expansive soils are usually identified with index tests, such as percentage of clay particles and liquid limit. It is generally accepted that soils with liquid limits larger than about 50 percent, i.e., soils that classify as high plasticity clays (CH) or high plasticity silts (MH), may be susceptible to volume change when subjected to moisture variations.

Laboratory test results on representative soil samples indicate the upper black clay layer to be expansive. These soils will either be covered with compacted structural fill during site grading operations beneath piled foundations, or removed and replaced beneath non-pile supported foundations. Therefore, the expansive black clay layer is not expected to adversely affect shallow foundations.

10G8.4 Collapsible Soils

Soil collapse (hydrocompaction) is a phenomenon that results in relatively rapid settlement of soil deposits due to addition of water. This generally occurs in soils having a loose particle structure cemented together with soluble minerals or with small

quantities of clay. Water infiltration into such soils can break down the interparticle cementation, resulting in collapse of the soil structure. Collapsible soils are usually identified with index tests, such as dry density and liquid limit, and by consolidation tests where soil collapse potential is measured after inundation under load.

Based on the available data, the site soils are mostly cohesive and not susceptible to collapse.

10G8.5 Slope Stability

The site is very flat, and thus no natural slope stability hazards exist at the site. Future site grading operations will result in slopes no more than about 5 ft high, and these fill slopes will be designed to remain stable.

10G9.0 PRELIMINARY FOUNDATION CONSIDERATIONS

10G9.1 General Foundation Design Criteria

For satisfactory performance, the foundation of any structure must satisfy two independent design criteria. First, it must have an acceptable factor of safety against bearing failure in the foundation soils under maximum design load. Second, settlements during the life of the structure must not be of a magnitude that will cause structural damage, endanger piping connections or impair the operational efficiency of the facility. Selection of the foundation type to satisfy these criteria depends on the nature and magnitude of dead and live loads, the base area of the structure and the settlement tolerances. Where more than one foundation type satisfies these criteria, then cost, scheduling, material availability and local practice will probably influence or determine the final selection of the type of foundation.

An evaluation of the information collected from the SPT borings, laboratory testing, and visual observations made during the site subsurface investigation indicate that that no adverse foundation related subsurface and ground water conditions were encountered that would preclude the construction and operation of the proposed plant. Thus, the site can be considered suitable for development of the proposed plant, pursuant to the preliminary foundation and earthwork considerations discussed in this appendix.

10G9.2 Selection of Foundation Type

Based on the results of the subsurface investigation, it is anticipated that all heavy equipment and settlement sensitive structures will be pile supported. Lightly loaded and/or settlement tolerant structures and equipment can be supported on shallow foundations. Preliminary foundation recommendations are provided on the next sections.

10G9.3 Deep Foundations

It is anticipated that prestressed, precast concrete piles will be suitable for use at the site. Because no dense/hard bearing layer was encountered within a depth of 160 ft, piles will be designed to function as friction piles. Preliminary estimates indicate that 14-inch to 16-inch square piles installed to a depth of no more than 80 ft will develop allowable loads on the order of 60 tons in compression, 20 tons in uplift, and 4 tons laterally. These allowable loads will be further verified after a structure-specific subsurface investigation, and also through a field load test program to be completed during construction before production pile installation.

10G9.4 Shallow Foundations

Preliminary estimates indicate that loading up to 2000 psf can be placed on the site soils with acceptable levels of settlement. Shallow foundation construction will require the earthwork measures discussed in Section 10G10.0.

Allowable bearing pressures will include a safety factor of at least 3 against bearing failures. Settlements of footings are expected to be limited to 1 inch, and differential settlement between neighboring foundations to less than 1/2 inch. These allowable bearing pressure and settlement criteria will not apply to tanks, which can usually undergo much larger settlements.

Frost depth is estimated to be less than 6 inches at the site (Reference 2). Exterior foundations and foundations in unheated areas should be placed at a depth of at least 1 ft below the ground surface for protection. Interior footings in permanently heated areas can be also be placed at a minimum depth of 1 ft below the ground surface. The minimum recommended width is 3 feet for spread footings and 2 feet for wall footings.

10G9.5 Corrosion Potential and Ground Aggressiveness

The chloride content and pH laboratory test results, summarized on Table 10G-1, indicate the site soils to be mildly corrosive to very corrosive for buried steel. This is consistent with the site proximity to the San Francisco Bay. Also, based on verbal information obtained at the site during the subsurface investigation, the site was previously used as evaporative ponds for salt production. At the time of the subsurface investigation, the existing steel frame radio towers were starting to show signs of corrosion at the top of the tower foundations, another indication of aggressiveness to steel. Soil resistivity tests will be performed during the structure-specific subsurface investigation to confirm these preliminary findings.

The sulfate content of the soil samples indicates that no special precautions are required for protection of the concrete foundations. Additional sulfate content tests will be performed during the structure-specific subsurface investigation to confirm these preliminary findings.

10G10.0 PRELIMINARY EARTHWORK CONSIDERATIONS

10G10.1 Site Preparation and Grading

After removal of all existing structures, radio towers, and debris from the site construction areas, the subgrade preparation should include the complete removal of all vegetation and topsoil. Topsoil can be stockpiled and may be reused in remote areas of the site where no future construction is expected.

Site grading will include the removal of the black clay layer from the beneath the footprint of all soil-supported foundations, and placement of fill to bring the site to a level grade. The site fill work should be performed as detailed below. All soil surfaces to receive structural fill should be proof rolled with a heavy roller or a fully loaded dump truck to detect soft areas.

10G10.2 Temporary Excavations

It is anticipated that confined temporary excavations at the site will be required during construction for the installation of the circulation water pipes and the cooling tower forebay. All excavations should be sloped in accordance with OSHA requirements. Sheet piling or shoring could also be used to support temporary excavations. The need for internal supports in the excavation will be determined based on the final depth of the excavation. Any excavation below the water table should have the ground water levels controlled by using well points or other dewatering methods installed prior to the start of excavation.

10G10.3 Permanent Slopes

At this time, only low permanent fill slopes are planned for the Russell City site. Permanent fill slopes less than 5 ft high can be made 3H:1V.

10G10.4 Backfill Requirements

All fill material must be free of organic matter, debris or clay balls, with a maximum size not exceeding 2 inches. Structural fill must also be well graded and granular. Granular material with similar specifications can be used for pipe bedding, except that the maximum size should not exceed 1/2 inch. Based on the available site grading, and the near surface soils disclosed by the borings, it is anticipated that no acceptable structural fill materials will be available from on-site.

Structural fill should be compacted to at least 95 percent of the maximum dry density as determined by ASTM D 1557 when used for roadway or foundation support. Fill placed behind retaining structures can be compacted to at least 90 percent of the maximum dry density as determined by ASTM D 1557. Common fill used to raise the grade throughout the site, or for rough grading, can be compacted to at least 85 percent of the maximum dry density as determined by ASTM D 1557. Initially, structural fill should be

placed in lifts not exceeding 8 inches loose thickness. Thicker lifts may be used for structural fill placement pursuant to approval based on results of field compaction performance. Thicker lifts can generally be used for the common fill. The moisture content of all compacted fill should fall within 3 percentage points of the optimum moisture content determined by ASTM D 1557.

Pipe bedding can be compacted in 12-inch lifts to 90 percent of the maximum dry density as determined by ASTM D 1557.

10G11.0 INSPECTION AND MONITORING

A California-registered Geotechnical Engineer or Engineering Geologist should monitor geotechnical aspects of foundation construction and/or installation, and fill placement. At a minimum the Geotechnical Engineer/Engineering Geologist should monitor the following activities:

- All surfaces to receive fill should be inspected prior to fill placement to verify that no pockets of loose/soft or otherwise unsuitable material were left in place and that the subgrade is suitable for structural fill placement.
- All fill placement operations should be monitored by an independent testing agency. Field compaction control testing should be performed regularly and in accordance with the applicable specification to be issued by the Geotechnical Engineer.
- The Geotechnical Engineer must witness all pile load testing and initial stages of production pile installation.
- Settlement monitoring of significant foundations and equipment is recommended on at least a quarterly basis during construction and the first year of operation, and then semi-annually for the next two years.

10G12.0 SITE DESIGN CRITERIA

10G12.1 General

The Facility will be located near the western limits of the City of Hayward, California. The approximate 12-acre (600 ft x 800 ft) site is relatively flat, with several existing permanent structures and 4 radio towers. The site is accessible from Enterprise Avenue and Whitesell Street.

10G12.2 Datum

The site grade varies between about El. 4.5 ft and 10 ft with respect to the 1929 National Geodetic Vertical Datum (NGVD). Final site grade will be from about El. 11.5 ft to El. 12 ft NGVD.

10G13.0 FOUNDATION DESIGN CRITERIA

10G13.1 General

Reinforced concrete structures (spread footings, mats and deep foundations) will be designed consistent with Appendix 10B, Structural Engineering Design Criteria.

Allowable soil bearing pressures for foundation design will be in accordance with this Appendix.

10G13.2 Ground Water Pressures

Hydrostatic pressures due to ground water or temporary water loads will be considered.

10G13.3 Factors of Safety

The factor of safety for structures, tanks and equipment supports with respect to overturning, sliding, and uplift due to wind and buoyancy will be as defined in Appendix 10B, Structural Engineering Design Criteria.

10G13.4 Load Factors and Load Combinations

For reinforced concrete structures and equipment supports, using the strength method, the load factors and load combinations will be in accordance with Appendix 10B, Structural Engineering Design Criteria.

10G14.0 REFERENCES

1. 1998 California Building Code.
2. Department of the Navy (1982). "Identification and Classification of Soil and Rock," Chapter 1 in *Soil Mechanics Design Manual 7.1*, Naval Facilities Engineering Command, Alexandria, VA.

Appendix 10G
Tables

Table 10G-1. Summary of Water Level Readings in OW-107

Date	Time	DTWT from TOC (ft)	WT Elevation (ft NGVD)	Comments
1-Jun-2001				Well Development, riser stickup = 21.5 in (1.79 ft)
4-Jun-2001	715	6.03	1.66	gs elev = 5.9 ft NGVD, riser casing elevation (5.9 + 1.79 = 7.69 ft)
5-Jun-2001	730	6.07	1.62	
6-Jun-2001	745	6.11	1.58	
7-Jun-2001	815	6.11	1.58	
11-Jun-2001	700	6.15	1.54	
12-Jun-2001	710	6.16	1.53	
13-Jun-2001	1445	6.15	1.54	
14-Jun-2001	1430	6.26	1.43	
15-Jun-2001	915	6.18	1.51	
11-Jul-2001	1200	6.39	1.30	
29-Aug-2001	1200	6.43	1.26	

NOTES:

OW = Observation well.
 DTWT = Depth to water table.
 TOC = Top of casing.
 WT = Water table.
 ft = Feet.
 MSL = Mean Sea Level.
 in = Inches.
 gs = Ground surface.
 elev = Elevation.
 NGVD = National Geodetic Vertical Datum of 1929.

Table 10G-2. Summary of Laboratory Test Results

Boring Number	Sample		Laboratory Test										
	Depth (ft)	Type	USCS	% Fines	Sieve Analysis	Moisture Content %	Liquid Limit %	Plastic Limit %	Unconfined Compression (psf)	Consolidation	pH	Chloride (mg/kg)	Sulfate (mg/kg)
B-101	13.5 - 15.2	ST	SM	47		24.3	NV	NP	292				
	15.2 - 16.1	SS	SW-SM	9	a								
	29 - 30	SS	CL	75	a	21	44	21					
	49 - 50	SS	SM	34	a	23	NV	NP					
B-102	12 - 13	SS	CL	79	a								
	13 - 15.5	ST	CL/SC	60		23.9	29	18	747				
	22.5 - 25	ST	CL/SC	47		19.1	36	19	1474				
	59 - 60	SS	ML	88	a								
B-103	3 - 4	SS	CH	74		22	58	24			8.3	1,500	510
	12 - 14.5	ST	CL	67		28.6	44	19	267				
	15 - 16	SS	CL	69	a								
	54 - 55	SS	ML	68	a								
	64 - 65	SS	ML	79	a								
	104 - 105	SS	CH	96		54	73	25					
	109 - 110	SS	CH	99		53	74	27					
B-104	4.5 - 5.5	SS	CH	73		23	68	23			8.0	660	180
	6 - 8.5	ST	CH	85		26	68	27	372				
	13 - 15.5	ST	CL	68		21.8	41	20	872				
	38.5 - 40	SS	SP-SM	8	a	14	NV	NP					
	54 - 55	SS	SC	40	a								
	89 - 90	SS	CL	67	a								
	109 - 110	SS	CH	100		55	77	27					
B-105	118.5 - 120	ST	CH	88		32.6	71	26	1429				
	1 - 1.5	SS	CH	90		23	51	19			8.0	120	29
	11 - 14	ST	CL	77		18.6	43	20	2455	b			
	23.5 - 26	ST	CL	61		23.4	40	19	1354	b			
	43.5 - 46	ST	CH	87		21.6	73	28	3671	b			
	73.5 - 76	ST	CH	100		26	53	24	4221	b			
	114.5 - 115	SS	CH	89		50	79	29					
B-106	118.5 - 121	ST	CH	91		47.5	79	31	3208				
	12 - 14.5	ST	CL	62		22.2	41	20	657				
	54 - 55	SS	CL	76	a								


Table 10G-2. Summary of Laboratory Test Results

Boring Number	Sample		Laboratory Test										
	Depth (ft)	Type	USCS	% Fines	Sieve Analysis	Moisture Content %	Liquid Limit %	Plastic Limit %	Unconfined Compression (psf)	Consolidation	pH	Chloride (mg/kg)	Sulfate (mg/kg)
B-107	1 - 1.5	SS	CH	98		16	59	25			8.6	200	83
	4.5 - 7	ST	CH	84		26.3	57	24	1006	b			
	11 - 11.5	SS	CH	82	a	25	53	22					
	14 - 16.5	ST	CL	90		24.7	38	19	1194	b			
	39.5 - 40	SS	CL	60	a	23	47	22					
	84 - 84.5	SS	ML	70	a	22	NV	NP					
B-108	12.5 - 13	ST	CH	81		26.9	67	26	1064				
	54 - 55	SS	SC	50	a								
	84.5 - 85	SS	ML	78	a								
B-109	1 - 1.5	SS	CH	90		32	60	16			8.4	ND (15)	68
	7.5 - 10	ST	CL	85		23.6	70	28	1686	b			
	13 - 15.5	ST	CL	78		22.9	42	18	695				
	23.5 - 26	ST	SM	12		19.1	33	19	391	b			
	48.5 - 51	ST	CH	97		27.9	68	26	2274	b			

NOTES:

- a = See Particle Size Analysis Test Report Graphs (ASTM D 422-63) in Appendix B for details.
- b = See Consolidation Test Report Graphs (ASTM D 2435) in Appendix B for details.
- ft = Feet
- mg/kg = Milligrams per kilogram
- psf = Pounds per square foot
- USCS = Unified Soil Classification System
- CH = See Plate A-1
- CL = See Plate A-1
- ML = See Plate A-1
- SC = See Plate A-1
- SM = See Plate A-1
- SP-SM = Dual Classification, See Plate A-1
- SW-SM = Dual Classification, See Plate A-1
- NP = Non Plastic
- NV = Non Viscous
- ST = Shelby Tube
- SS = Split Spoon

Appendix 10G
Figures



Note: The red star designates the site location.



BECHTEL POWER CORPORATION			
FREDERICK, MARYLAND			
RUSSELL CITY ENERGY CENTER			
SITE LOCATION MAP			
	JOB NO.	FIGURE NO.	REV
	24405	10G-1	0

Figure 10G-2 is shown as Drawing No. CY-0100-00001, Rev. C



NOTE:

Subsurface data have been obtained only at the actual borehole locations. The stratification shown between the boreholes is based on extrapolation of the data obtained from the boreholes. Actual stratification between the boreholes may differ from that shown.

<p>HORIZONTAL SCALE - FEET</p>		
<p>BECHTEL POWER CORPORATION FREDERICK, MARYLAND</p>		
<p>RUSSELL CITY ENERGY CENTER</p>		
<p>SUBSURFACE PROFILE LEGEND</p>		
JOB NO.	DRAWING NO.	REV.
24405	FIGURE 10G-3	

Appendix 10G
Attachment 10G-1 - Boring Logs

MAJOR DIVISIONS			SYMBOLS	TYPICAL NAMES
COARSE-GRAINED SOILS OVER 50% > No.200 SIEVE SIZE	GRAVELS	CLEAN GRAVELS WITH LESS THAN 5% FINES	GW	Well-graded gravels or gravel-sand mixtures, little or no fines
			GP	Poorly graded gravels or gravel-sand mixtures, little or no fines
		GRAVELS WITH OVER 15% FINES	GM	Silty gravels, gravel-sand mixtures
			GC	Clayey gravels, gravel-sand-clay mixtures
	SANDS	CLEAN SANDS WITH LESS THAN 5% FINES	SW	Well-graded sand or gravelly sands, little or no fines
			SP	Poorly graded sands or gravelly sands, little or no fines
		SANDS WITH OVER 15% FINES	SM	Silty sand, sand-silt mixtures
			SC	Clayey sands, sand-clay mixtures
FINE-GRAINED SOILS OVER 50% < No.200 SIEVE SIZE	SILTS & CLAYS LIQUID LIMIT 50% OR LESS		ML	Inorganic silts and very fine sands, rock flour, silty or clayey fine sands or clayey silts with slight plasticity
			CL	Inorganic clays of low to medium plasticity, gravelly clays, sandy clays, silty clays, lean clays
			OL	Organic silts and organic silty clays of low plasticity
	SILTS & CLAYS LIQUID LIMIT GREATER THAN 50%		MH	Inorganic silts, micaceous or diatomaceous fine sandy or silty soils, elastic silts
			CH	Inorganic clays of high plasticity, fat clays
			OH	Organic clays of medium to high plasticity, organic silty clays, organic silts
HIGHLY ORGANIC SOILS			PT	Peat and other highly organic soils

UNIFIED SOIL CLASSIFICATION SYSTEM - ASTM D2488-93

<input checked="" type="checkbox"/>	Bulk or classification sample
<input type="checkbox"/>	Sample preserved for possible laboratory analysis
<input type="checkbox"/>	No Recovery
Perm	Permeability
Consol	Consolidation
LL	Liquid Limit (%)
PI	Plastic Index (%)
Gs	Specific Gravity
MA	Particle Size Analysis
-200=55%	Percent Passing No. 200 Sieve

CLASSIFICATION	RANGE OF GRAIN SIZES	
	U.S. Standard Sieve Size	Grain Size in Millimeters
BOULDERS	Above 12"	Above 305
COBBLES	12" to 3"	305 to 76.2
GRAVEL	3" to No. 4	76.2 to 4.75
	3" to 3/4"	76.2 to 19.1
	3/4" to No. 4	19.1 to 4.75
SAND	No. 4 to No. 200	4.75 to 0.075
	No. 4 to No. 10	4.75 to 2.00
	No. 10 to No. 40	2.00 to 0.425
	No. 40 to No. 200	0.425 to 0.075
SILT & CLAY	Below No. 200	Below 0.075

KEY TO TEST DATA*

Source: ASTM D 2488-90, based on Unified Soil Classification system
 *. Not part of ASTM Classification System

SOIL_CLASS_GEOI_HARDINGESE 53483.GPJ GEOI.GDT 7/26/01



Harding ESE
 A MACTEC COMPANY

Soil Classification Chart and Key to Test Data PLATE

Russell City Energy Center
 Hayward, California

A-1

DRAWN	JOB NUMBER	APPROVED	DATE	REVISED DATE
PCB	53483 003		7/01	

RELATIVE DENSITY OF COARSE-GRAINED SOILS

Relative Density	Standard Penetration Test Blow Count (blows per foot)
very loose	<4
loose	4-10
medium dense	10-30
dense	30-50
very dense	>50

CONSISTENCY OF FINE-GRAINED SOILS

Consistency	Approximate Blows/foot (SPT)	Undrained Shear Strength (psf)
very soft	<2	0 - 250
soft	2-4	250 - 500
medium stiff	4-8	500 - 1,000
stiff	8-15	1,000 - 2,000
very stiff	15-30	2,000 - 4,000
hard	>30	>4,000

NATURAL MOISTURE CONTENT

- | | |
|-------|--|
| Dry | - Requires considerable moisture to obtain optimum moisture content for compaction |
| Moist | - Near the optimum moisture content for compaction |
| Wet | - Requires drying to obtain optimum moisture content for compaction |

Note: Where laboratory data are not available, the field classifications given above provide a general indication of material properties; the classifications may require modification based on judgment or laboratory testing.



**Physical Properties Criteria
for Soil Classification**

Russell City Energy Center
Hayward, California

PLATE

A-2

DRAWN
PCB

JOB NUMBER
53483 003

APPROVED

DATE
6/01

REVISED DATE

53483001.DWG 1.0
20010724.1425

GEOTECH_BORING_NEW_HARDINGESE_53483.GPJ GEOTECH.GDT 8/16/01

Other Tests/Drilling Notes	Moisture Content (%)	Dry Density (pcf)	Pocket Pen (Tsf)	Torvane (Tsf)	Blows per Foot	Depth (ft.)	Sampler Type:	Graphic Log	Date 6/6/01	
									Equipment Failing F1500	Drilling Method mud rotary
						0			Hammer Weight 140 lb.	Drop 30 in.
						16			Logged by M. Phelps	Datum MSL
						16			Surface Elevation 7 ft.	
						10			Northing 2057024.3 Easting 6089280.2	
Switched to wash method after taking the first 2 samples. No groundwater level reading was taken.						16			DARK GRAY SANDY CLAY (CL) Very stiff, dry, dessicated, with roots from 1-3 ft.	
						16			@ 2 ft.: Change to moist, with 5% sand	
						10			@ 3.5 ft.: Color change to OLIVE GRAY (5Y 3/2)	
						11	5		@ 5 ft.: Change to stiff, moderate to high plasticity	
						10			GRAYISH BROWN FAT CLAY (CH) (5Y4 3/2) Stiff, wet, high plasticity	
						7			GRAYISH BROWN SILTY CLAY (CL) Medium stiff, wet, low to moderate plasticity	
						13	10		GRAYISH BROWN MOTTLED SILTY CLAY (CL) Medium stiff, wet, low plasticity	
						6			SILTY SAND (SM)	
						3			BROWN WELL GRADED SAND WITH SILT (SW-SM) Medium dense, wet	
						12	15		BROWN SILTY CLAY (CL) Stiff, wet	
UC=292 -200=47%	24.3	102.0				9	20		DARK YELLOWISH BROWN SANDY SILTY CLAY (CL) Stiff, wet, low plasticity, 60% fines, 40% sand	
						16	30		DARK YELLOWISH BROWN LEAN CLAY (CL) Very stiff, wet, high plasticity, some cemented material within clay	
						15	35		YELLOWISH BROWN SANDY SILT (ML) Stiff to very stiff, wet, 50% fines, 50% sand @ 31.5 ft.: Observed sand in cuttings	



Harding ESE
A MACTEC COMPANY

Log of Boring 101
Cooling Tower (Salem Property)
Russell City Energy Center
Hayward, California

PLATE

B-101

DRAWN
PCB


JOB NUMBER
53483 003

APPROVED

DATE
8/01

REVISED DATE

GEOTECH. BORING_NEW_HARDINGESE 53483.GPJ GEOTECH.GDT 8/16/01



Harding ESE
A MACTEC COMPANY

Log of Boring 101
Cooling Tower (Salem Property)
Russell City Energy Center
Hayward, California

PLATE

B-101

DRAWN	JOB NUMBER	APPROVED	DATE	REVISED DATE
PCB	53483 003		8/01	

GEOTECH_BORING_NEW_HARDINGESE_53483.GPJ GEOTECH.GDT 8/16/01

Other Tests/Drilling Notes	Moisture Content (%)	Dry Density (pcf)	Pocket Pen (Tsf)	Torvane (Tst)	Blows per Foot	Depth (ft.)	Sampler Type	Graphic Log	Date <u>6/6/01</u> Equipment <u>Falling F1500</u> Drilling Method <u>mud rotary</u> Sampler <u>SPT, Shelby</u> Hammer Weight <u>140 lb.</u> Drop <u>30 in.</u> Logged by <u>M. Phelps</u> Datum <u>MSL</u> Surface Elevation <u>7 ft.</u> Northing <u>2057024.3</u> Easting <u>6089280.2</u>
						70			
						12			Interbedded with thin sand layers
						20			OLIVE GRAY SAND WITH SILT (SP-SM) (5Y 3/2) Medium dense, wet OLIVE GRAY FAT CLAY (CH) Very stiff, wet, high plasticity
						15			
						15			OLIVE GRAY SILTY CLAY (CL) Stiff to very stiff, wet, low plasticity
									@ 91.5 ft.: Harder drilling
						17			OLIVE BROWN FAT CLAY (CH) 5Y 4/4 Very stiff, wet
						23			@ 99 ft.: Color change to OLIVE GRAY
						100			Bottom of boring at 100 ft. Tremie grouted with cement grout.



Harding ESE
A MACTEC COMPANY

Log of Boring 101
Cooling Tower (Salem Property)
Russell City Energy Center
Hayward, California

PLATE

B-101

DRAWN
PCB

JOB NUMBER
53483 003


APPROVED

DATE
8/01

REVISED DATE

Other Tests/Drilling Notes		Moisture Content (%)	Dry Density (pcf)	Pocket Pen (Tstf)	Torvane (Tstf)	Blows per Foot	Depth (ft.)	Sampler Type	Graphic Log	Date <u>6/12/01</u> Equipment <u>Failing F1500</u> Drilling Method <u>mud rotary</u> Sampler <u>SPT, Shelby</u> Hammer Weight <u>140 lb.</u> Drop <u>30 in.</u> Logged by <u>M. Phelps</u> Datum <u>MSL</u> Surface Elevation <u>7.6 ft.</u> Northing <u>2056982.8</u> Easting <u>6089495.7</u>	
Switch to rotary wash method using 4-5/8 in. drag bit at about 4 ft. Did not measure water level during drilling.						15	0			BLACK CLAY (CL) Stiff to very stiff, dry to moist, desiccation cracks with pinhole voids, (TOPSOIL)	
						21	15			DARK BROWN TO BLACK CLAY (CH) Very stiff, moist, with organics, fine roots, desiccation cracks @ 4 ft.: Color change to BROWN TO DARK GRAY, stiff, high plasticity	
						13	21			@ 8 ft.: Rootlets	
						13	25			BROWN LEAN CLAY WITH SAND (CL) Medium stiff, wet @ 12.5 ft.: Increase in sand content BROWN CLAYEY SAND (SC)	
				1.25		180 psi	25			BROWN SANDY SILT (ML) Medium stiff, wet	
		23.9	99.8	1.0		80-110 psi	30			BROWN SILTY CLAY - CLAYEY SILT (ML-CL) Medium stiff, wet	
UC=747 -200=60%							30			BROWN LEAN SANDY CLAY (CL) @ 24.5 to 25 ft.: Clayey sand	
		19.1	106.9	2.9		60-100 psi	35			BROWN FAT CLAY (CH) Very stiff, wet, with gray streaks, slightly porous	
							35				
							35				

GEOTECH. BORING_NEW_HARDINGESE 53483.GPJ GEOTECH.GDT 8/16/01










Harding ESE
A MACTEC COMPANY

Log of Boring 102
Switchyard Area (Salem Property)
Russell City Energy Center
Hayward, California

PLATE
B-102

DRAWN	JOB NUMBER	APPROVED	DATE	REVISED DATE
PCB	53483 003		8/01	

GEOTECH. BORING_NEW_HARDINGESE 53483.GPJ GEOTECH.GDT 8/16/01

Other Tests/Drilling Notes	Moisture Content (%)	Dry Density (pcf)	Pocket Pen (Tsf)	Torvane (Tsf)	Blows per Foot	Depth (ft.)	Sampler Type	Graphic Log	Date <u>6/12/01</u> Equipment <u>Failing F1500</u> Drilling Method <u>mud rotary</u> Sampler <u>SPT, Shelby</u> Hammer Weight <u>140 lb.</u> Drop <u>30 in.</u> Logged by <u>M. Phelps</u> Datum <u>MSL</u> Surface Elevation <u>7.6 ft.</u> Northing <u>2056982.8</u> Easting <u>6089495.7</u>
Easier/faster drilling						35			@ 35 ft.: Calcite stringers
					16	40			OLIVE GRAY SILTY CLAY (CL) Stiff, wet, interbedded with silty sand layers, little to moderate plasticity
					19	50			@ 50 ft.: Change to very stiff
					16	55			@ 56-57 ft.: Layer of coarse sand, fine gravel
					21	60			OLIVE GRAY SILT (ML) Very stiff, wet, little plasticity @ 58.5-60.5 ft.: Interbedded with sand seams 2-4 in. thick
					16	65			DARK BROWN FAT CLAY (CH) Very stiff, wet, high plasticity, with blocky structure OLIVE GRAY CLAYEY SILT WITH SAND (ML) Hard, wet, low to moderate plasticity
					16	70			OLIVE GRAY FAT CLAY (CH) Very stiff, wet, high plasticity



Harding ESE
A MACTEC COMPANY

Log of Boring 102
Switchyard Area (Salem Property)
Russell City Energy Center
Hayward, California

PLATE

B-102

DRAWN
PCB

JOB NUMBER
53483 003

APPROVED

DATE
8/01

REVISED DATE

GEO TECH BORING NEW HARDINGESE 53483.GPJ GEOTECH.GDT 8/16/01

Other Tests/Drilling Notes	Moisture Content (%)	Dry Density (pct)	Pocket Pen (Tsf)	Torvane (Tsf)	Blows per Foot	Depth (ft.)	Sampler Type:	Graphic Log:	
						70			Date <u>6/12/01</u> Equipment <u>Failing F1500</u> Drilling Method <u>mud rotary</u> Sampler <u>SPT, Shelby</u> Hammer Weight <u>140 lb.</u> Drop <u>30 in.</u> Logged by <u>M. Phelps</u> Datum <u>MSL</u> Surface Elevation <u>7.6 ft.</u> Northing <u>2056982.8</u> Easting <u>6089495.7</u>
						75			@ 75 ft.: Olive gray mottling
						80			MOTTLED GRAY OLIVE BROWN SILTY CLAY (CL) Very stiff, wet, moderate plasticity @ 80 ft.: Sand seam
						85			GRAY BROWN OLIVE SILTY FAT CLAY (CH) Very stiff, wet
						90			MOTTLED OLIVE GRAY CLAYEY SILT (ML) Very stiff, wet, trace sand
						95			MOTTLED OLIVE GRAY FAT CLAY (CH) Very stiff, wet, high plasticity
						100			Bottom of boring at 100 ft. Tremie grouted with cement grout.



Harding ESE
A MACTEC COMPANY

Log of Boring 102
Switchyard Area (Salem Property)
Russell City Energy Center
Hayward, California

PLATE

B-102

DRAWN
PCB

JOB NUMBER
53483 003


APPROVED

DATE
8/01

REVISED DATE

GEOTECH_BORING_NEW_HARDINGESE_53483.GPJ GEOTECH.GDT 8/16/01

Other Tests/Drilling Notes	Moisture Content (%)	Dry Density (pcf)	Pocket Pen (Tsf)	Torvane (Tsf)	Blows per Foot	Depth (ft.)	Sampler Type	Graphic Log	Date <u>6/6/01</u>	
									Equipment <u>Failing F1500</u>	Drilling Method <u>mud rotary</u>
Switched to wash method after taking the first 2 samples and used a 4-7/8 in. tricone bit. No groundwater level reading was taken. UC=267 -200=67%	28.6	92.4	0.5		40-140 psi	0			Northing <u>2056895.6</u> Easting <u>6089063.2</u> BLACK CLAY (CL) (N1) Stiff, dry to moist, organics, (TOPSOIL) @ 1.5 ft.: Color change to GRAY BROWN (5YR 3/2), roots, very stiff	Hammer Weight <u>140 lb.</u> Drop <u>30 in.</u> Logged by <u>M. Phelps</u> Datum <u>MSL</u> Surface Elevation <u>5.8 ft.</u>
						12			BLACK CLAY (CH) (N1)	
						17			OLIVE GRAY FAT CLAY (CH) (5Y 3/2) Firm, wet	
						12			@ 8 ft.: Trace sand	
						9			OLIVE BROWN LEAN CLAY WITH SAND (CL) (5Y 4/4) Soft, wet	
						10			@ 15 ft.: Change to medium stiff	
						10			OLIVE BROWN CLAYEY SILT WITH SAND (ML) (5Y 4/4) Soft, wet	
						13			OLIVE BROWN SILTY CLAY (CL) 5Y 4/4 Very stiff, wet, low to moderate plasticity, trace sand	
						3			OLIVE BROWN FAT CLAY (CH) (5Y 4/4) Stiff, wet, high plasticity	
						5			@ 29 ft.: Color change to DARK YELLOWISH BROWN (10YR 4/2), Very stiff	
15			@ 34 ft.: Change to stiff							
17										
12										
16										
10										

 Harding ESE A MACTEC COMPANY	Log of Boring 103 City Water Treatment Area (Salem Property) Russell City Energy Center Hayward, California	PLATE B-103
	DRAWN: PCB JOB NUMBER: 53483 003 APPROVED: _____ DATE: 8/01	REVISOR: _____ REVISION: _____ REVISOR: _____ REVISION: _____

GEOTECH_BORING_NEW_HARDINGESE_53483.GPJ_GEOTECH.GDT_8/16/01

Other Tests/Drilling Notes	Moisture Content (%)	Dry Density (pcf)	Pocket Pen (Tsf)	Torvane (Tsf)	Blows per Foot	Depth (ft.)	Sampler Type	Graphic Log	Date <u>6/6/01</u>	
									Equipment <u>Failing F1500</u>	Drilling Method <u>mud rotary</u>
									Sampler <u>SPT, Shelby</u>	Hammer Weight <u>140 lb.</u> Drop <u>30 in.</u>
									Logged by <u>M. Phelps</u> Datum <u>MSL</u>	Surface Elevation <u>5.8 ft.</u>
									Northing <u>2056895.6</u> Easting <u>6089063.2</u>	
						35				
						9				@ 39 ft.: Color change to OLIVE GRAY (5Y 3/2) some thin seams of silt
						18				@ 44 ft.: Change to very stiff
						14				@ 49 ft.: Change to stiff
						18				OLIVE GRAY SANDY SILT (ML) (5Y 3/2) Very stiff, wet, low plasticity
						12				OLIVE GRAY FAT CLAY (CH) Stiff, wet, high plasticity
						12				OLIVE GRAY SILTY CLAY (CL) OLIVE GRAY SILT WITH SAND (ML) (5Y 3/2) Stiff, wet, low plasticity
						10				OLIVE GRAY FAT CLAY (CH) (5Y 3/2) Stiff, wet
						70				



Harding ESE
A MACTEC COMPANY

Log of Boring 103
City Water Treatment Area (Salem Property)
Russell City Energy Center
Hayward, California

PLATE

B-103

DRAWN
PCB

JOB NUMBER
53483 003

APPROVED

DATE
8/01

REVISED DATE

GEOTECH_BORING_NEW_HARDINGESE_53483.GPJ GEOTECH.GDT 8/16/01

Other Tests/Drilling Notes	Moisture Content (%)	Dry Density (pcf)	Pocket Pen (Tst)	Torvane (Tst)	Blows per Foot	Depth (ft.)	Sampler Type	Graphic Log	Date <u>6/6/01</u> Equipment <u>Failing F1500</u> Drilling Method <u>mud rotary</u> Sampler <u>SPT, Shelby</u> Hammer Weight <u>140 lb.</u> Drop <u>30 in.</u> Logged by <u>M. Phelps</u> Datum <u>MSL</u> Surface Elevation <u>5.8 ft.</u> Northing <u>2056895.6</u> Easting <u>6089063.2</u>	
Becoming harder drilling						70			@ 74 ft.: Change to very stiff @ 84-101 ft.: Color change to MOTTLED BROWN GRAY (5YR 4/4), samples are blocky and fissured	
	17	75	20	80	18	85	OLIVE GRAY SILTY SANDY CLAY (CL) (5Y 3/2) Stiff to very stiff, wet			
15	90	20	95	18	100	OLIVE GRAY FAT CLAY (CH) (5Y 3/2) Very stiff, wet, high plasticity				
5	105	@ 101.5 ft.: Shells observed in drill cuttings @ 104 ft.: Change to medium soft								



Harding ESE
A MACTEC COMPANY

Log of Boring 103
City Water Treatment Area (Salem Property)
Russell City Energy Center
Hayward, California

PLATE

B-103

DRAWN
PCB

JOB NUMBER
53483 003

APPROVED

DATE
8/01

REVISED DATE

GEOTECH_BORING_NEW_HARDINGESE_53483.GPJ GEOTECH.GDT 8/16/01

Other Tests/Drilling Notes	Moisture Content (%)	Dry Density (pcf)	Pocket Pen (Tsf)	Torvane (Tsf)	Blows per Foot	Depth (ft.)	Sampler Type	Graphic Log	Date <u>6/6/01</u> Equipment <u>Failing F1500</u> Drilling Method <u>mud rotary</u> Sampler <u>SPT, Shelby</u> Hammer Weight <u>140 lb.</u> Drop <u>30 in.</u> Logged by <u>M. Phelps</u> Datum <u>MSL</u> Surface Elevation <u>5.8 ft.</u> Northing <u>2056895.6</u> Easting <u>6089063.2</u>
						105			
						8			@ 109 ft.: Change to medium stiff to stiff
						110			@ 112.5 ft.: Shells observed in cuttings
						10			GRAY CLAYEY SAND WITH SHELLS (SC) Loose to medium dense, wet, <40% fines
						115			@ 117 ft.: Harder
						47			OLIVE GRAY FAT CLAY (CH) Hard, wet, high plasticity
						120			Bottom of boring at 120 ft. Tremie grouted with cement grout.



Harding ESE
A MACTEC COMPANY

Log of Boring 103
City Water Treatment Area (Salem Property)
Russell City Energy Center
Hayward, California

PLATE

B-103

DRAWN	JOB NUMBER	APPROVED	DATE	REVISED DATE
PCB	53483 003		8/01	

GEOTECH_BORING_NEW_HARDINGESE_53483.GPJ GEOTECH.GDT 8/16/01

Other Tests/Drilling Notes		Moisture Content (%)	Dry Density (pcf)	Pocket Pen (Tst)	Torvane (Tst)	Blows per Foot	Depth (ft.)	Sampler Type	Graphic Log	Date <u>6/4/01</u> Equipment <u>Failing F1500</u> Drilling Method <u>mud rotary</u> Sampler <u>SPT, Shelby</u> Hammer Weight <u>140 lb.</u> Drop <u>30 in.</u> Logged by <u>M. Phelps</u> Datum <u>MSL</u> Surface Elevation <u>6.6 ft.</u> Northing <u>2056699.5</u> Easting <u>6089495.6</u>	
Switched to rotary wash method after taking the first 2 samples. No groundwater level reading was taken. UC=372 -200=85%		26.0	97.7	1.33		160 psi	0		BLACK SANDY CLAY (CL) (1N/) Stiff, moist, organics		
							12				
							11				
							11		OLIVE GRAY FAT CLAY WITH SAND (CH) (5Y 4/1) Stiff, wet		
							9				
							5		GRAY BLACK CLAY (CH) Very stiff, wet, high plasticity		
							10		@ 9 ft.: Color change to OLIVE GRAY (5Y 4/1)		
							7		@ 10 ft.: Color change to GRAY BROWN, soft		
							3		@ 12 ft.: Change to very soft		
							UC=872 -200=68%		21.8	103.4	0.33
16		@ 16 ft.: Change to GRAYISH BROWN CLAY (CL) (5YR 3/2), very stiff, moderate to high plasticity									
7		@ 19 ft.: Change to soft									
20											
10		@ 24 ft.: Change to stiff, some cemented intervals									
25											
							30		@ 29 ft.: Change to moderate plasticity, black and white streaks		
							14		@ 30 ft.: Change to moderate to high plasticity		
							35				



Harding ESE
A MACTEC COMPANY

Log of Boring 104
Combustion Turbine-West Unit (Salem Property)
Russell City Energy Center
Hayward, California

PLATE
B-104

DRAWN	JOB NUMBER	APPROVED	DATE	REVISED DATE
PCB	53483 003		8/01	

GEOTECH_BORING_NEW_HARDINGESE_53483.GPJ GEOTECH.GDT 8/16/01

Other Tests/Drilling Notes	Moisture Content (%)	Dry Density (pcf)	Pocket Pen (Tst)	Torvane (Tsf)	Blows per Foot	Depth (ft.)	Sampler Type	Graphic Log	Date <u>6/4/01</u> Equipment <u>Falling F1500</u> Drilling Method <u>mud rotary</u> Sampler <u>SPT, Shelby</u> Hammer Weight <u>140 lb.</u> Drop <u>30 in.</u> Logged by <u>M. Phelps</u> Datum <u>MSL</u> Surface Elevation <u>6.6 ft.</u> Northing <u>2056699.5</u> Easting <u>6089495.6</u>
						35			
									@ 36.5 ft.: Encountered sand
									@ 37.5 ft.: Mixture of sand and gravel, gravel less than 1/2 in. diameter
						30			BROWN WELL GRADED SAND WITH SILT (SP-SM) Medium dense to dense, wet, 75% sand, 25% gravel to 3/8 in. diameter
						40			@ 40.5 - 42 ft.: Interbedded sands becoming clays with 4-6 in. lenses
									OLIVE GRAY CLAY (CL) (5Y 4/1) Medium stiff to stiff, wet, high plasticity
						8			
						45			
						14			@ 49 ft.: Change to stiff
						50			@ 51 - 54 ft.: Interbedded sand and clay lenses
						10			OLIVE GRAY CLAYEY SAND (SC) (5Y 4/1) Loose to medium dense, wet, <30% fines
						55			
						11			OLIVE GRAY CLAY (CL) (5Y 4/1) Stiff, wet, moderate to high plasticity
						60			
						17			@ 64 ft.: Change to very stiff
						65			
						15			
						70			



Harding ESE
A MACTEC COMPANY

Log of Boring 104
Combustion Turbine-West Unit (Salem Property)
Russell City Energy Center
Hayward, California

PLATE
B-104

DRAWN	JOB NUMBER	APPROVED	DATE	REVISED DATE
PCB	53483 003		8/01	

GEOTECH_BORING_NEW_HARDINGESE 53483.GPJ GEOTECH.GDT 8/16/01

Other Tests/Drilling Notes	Moisture Content (%)	Dry Density (pcf)	Pocket Pen (Tst)	Torvane (Tst)	Blows per Foot	Depth (ft.)	Sampler Type	Graphic Log	Date <u>6/4/01</u> Equipment <u>Failing F1500</u> Drilling Method <u>mud rotary</u> Sampler <u>SPT, Shelby</u> Hammer Weight <u>140 lb.</u> Drop <u>30 in.</u> Logged by <u>M. Phelps</u> Datum <u>MSL</u> Surface Elevation <u>6.6 ft.</u> Northing <u>2056699.5</u> Easting <u>6089495.6</u>
						70			@ 69 ft.: Change to stiff to very stiff, trace sand, moderate plasticity
					20	75			No recovery
					20	80			@ 79 ft.: Change to very stiff, high plasticity
					19	85			
					17	90			OLIVE GRAY SANDY LEAN CLAY (CL) (5Y 4/1) Medium dense, wet, low plasticity
									@ 89 - 98 ft.: Alternating layers of sandy silty and silty sand
					18	95			OLIVE GRAY SANDY SILT (ML) Hard, wet, low plasticity
					23	100			OLIVE GRAY FAT CLAY (CH) Hard, wet, moderate to high plasticity
					15	105			DARK GREENISH GRAY CLAY (CH) (5GY 4/1) Firm to hard, wet, moderate plasticity, 40%



Harding ESE
A MACTEC COMPANY

Log of Boring 104

Combustion Turbine-West Unit (Salem Property)
Russell City Energy Center
Hayward, California

PLATE

B-104

DRAWN
PCB

JOB NUMBER
53483 003

APPROVED

DATE
8/01

REVISED DATE

GEOTECH_BORING_NEW_HARDINGESE_53483.GPJ GEOTECH.GDT 8/16/01

Other Tests/Drilling Notes	Moisture Content (%)	Dry Density (pcf)	Pocket Pen (Tsf)	Torvane (Tsf)	Blows per Foot	Depth (ft.)	Sampler Type	Graphic Log	Date <u>6/4/01</u> Equipment <u>Failing F1500</u> Drilling Method <u>mud rotary</u> Sampler <u>SPT, Shelby</u> Hammer Weight <u>140 lb.</u> Drop <u>30 in.</u> Logged by <u>M. Phelps</u> Datum <u>MSL</u> Surface Elevation <u>6.6 ft.</u> Northing <u>2056699.5</u> Easting <u>6089495.6</u>
SS-27 advanced 12 in. by weight of hammer and rods UC=1429 -200=88% SS-28 advanced 6 in. by weight of hammer and rods	32.6	88.9	1.75		60-120 psi	105 110 115 120 125 130 135 140		shells, 60% fines DARK GREENISH GRAY FAT CLAY (CH) 5GY 4/1) Firm, wet, high plasticity @ 114 ft.: Color change to MEDIUM DARK GRAY (N3), soft @ 116 ft.: Change to firm @ 121.5 ft.: Getting harder @ 124 - 126 ft.: Easier drilling @ 126 ft.: Harder drilling BROWN SILTY CLAY WITH SAND (CL) Hard, wet, trace sand	



Harding ESE
A MACTEC COMPANY

Log of Boring 104
Combustion Turbine-West Unit (Salem Property)
Russell City Energy Center
Hayward, California

PLATE

B-104

DRAWN
PCB

JOB NUMBER
53483 003

APPROVED

DATE
8/01

REVISED DATE

GEOTECH_BORING_NEW_HARDINGESE_53483.GPJ GEOTECH.GDT 8/16/01

Other Tests/Drilling Notes	Moisture Content (%)	Dry Density (pcf)	Pocket Pen (Tsf)	Torvane (Tsf)	Blows per Foot	Depth (ft.)	Sampler Type	Graphic Log	Date <u>6/4/01</u> Equipment <u>Failing F1500</u> Drilling Method <u>mud rotary</u> Sampler <u>SPT, Shelby</u> Hammer Weight <u>140 lb.</u> Drop <u>30 in.</u> Logged by <u>M. Phelps</u> Datum <u>MSL</u> Surface Elevation <u>6.6 ft.</u> Northing <u>2056699.5</u> Easting <u>6089495.6</u>
						140			@ 139 ft.: Color change to OLIVE GRAY (5Y 4/1) with red brown oxidation
									DARK GRAY SANDY SILT (ML) (N3) Very hard, wet
					53	150			DARK GRAY SILT (SP-SM) Very dense, wet
									@ 152 - 154 ft.: Encountered sandy layer
					34	160			MEDIUM DARK GRAY FAT CLAY (CH) (4/ N4) Very hard, wet, high plasticity
									Bottom of boring at 160 ft.



Harding ESE
A MACTEC COMPANY

Log of Boring 104
Combustion Turbine-West Unit (Salem Property)
Russell City Energy Center
Hayward, California

PLATE

B-104

DRAWN	JOB NUMBER	APPROVED	DATE	REVISED DATE
PCB	53483 003		8/01	

GEOTECH BORING_NEW_HARDINGESE 53483.GPJ GEOTECH.GDT 8/16/01

Other Tests/Drilling Notes	Moisture Content (%)	Dry Density (pcf)	Pocket Pen (Tsf)	Torvane (Tsf)	Blows per Foot	Depth (ft.)	Sampler Type	Graphic Log
<p>Boring was located to the north of the proposed warehouse/maintenance shop because of existing structures.</p> <p>Cored 3 in. of gravel/ asphalt before taking first sample.</p> <p>UC=2455 -200=77% Consol (see Appendix) Add bentonite, conductor casing set @ 14 ft. Shelby tube sample #9 was wet. Water started running up the borehole after the sample was retrieved. Groundwater measured at a depth of 8 ft. before switching to wash method. Groundwater at 7 ft. before start of work on 5/30/2001.</p> <p>Consol (see Appendix) UC=1354 -200=61%</p>					17/3"	0		<p>Date <u>5/29/01</u> Equipment <u>Failing F1500</u> Drilling Method <u>mud rotary</u> Sampler <u>SPT, Shelby</u> Hammer Weight <u>140 lb.</u> Drop <u>30 in.</u> Logged by <u>F. Drewes</u> Datum <u>MSL</u> Surface Elevation <u>9.8 ft.</u> Northing <u>2056959</u> Easting <u>6089812</u></p>
						34		ASPHALT
						9		OLIVE BROWN SANDY CLAY (CH) (2.5Y 4/4) Stiff, dry, 30% fine sand, (FILL)
						14		BLACK CLAY (CH) (2.5/1) Stiff, moist, high plasticity
						5		@ 5 ft.: Organics present
						12		@ 6.5 ft.: Color change to DARK OLIVE GRAY (5Y 3/2), mottled
						12		
						12		
						10		BLACK LEAN CLAY WITH SAND (CL)
						8		
	18.6	111.1	4.5					OLIVE BROWN CLAYEY SILT (ML) (2.5Y 4/4) Stiff, wet, 30% fines
	18.6	102.0				12		OLIVE BROWN SILTY CLAY (CL) (2.5Y 4/4) Stiff, wet, 20% fines
						15		
						14		
	23.4		0.75			20		
						25		
						12		@ 27 ft.: Color change to LIGHT OLIVE BROWN (2.5Y 5/4)
						15		
						30		
						15		
						35		



Harding ESE
A MACTEC COMPANY

Log of Boring 105
Warehouse/Maintenance Shop (Runnels Property)
Russell City Energy Center
Hayward, California

PLATE

B-105

DRAWN	JOB NUMBER	APPROVED	DATE	REVISED DATE
PCB	53483.003		8/01	

GEOTECH_BORING_NEW_HARDINGESE_53483.GPJ GEOTECH.GDT 8/16/01

Other Tests/Drilling Notes	Moisture Content (%)	Dry Density (pcf)	Pocket Pen (Tsf)	Torvane (Tsf)	Blows per Foot	Depth (ft.)	Sampler Type	Graphic Log	Date <u>5/29/01</u> Equipment <u>Failing F1500</u> Drilling Method <u>mud rotary</u> Sampler <u>SPT, Shelby</u> Hammer Weight <u>140 lb.</u> Drop <u>30 in.</u> Logged by <u>F. Drewes</u> Datum <u>MSL</u> Surface Elevation <u>9.8 ft.</u> Northing <u>2056959</u> Easting <u>6089812</u>
						35			@ 34.5 ft.: Increasing silt
					10	40			@ 39.5 ft.: Decreasing silt
			2.5		200 psi	45			BROWN FAT CLAY (CH)
					16	50			@ 47 ft.: Change to very stiff @ 48 ft.: Fine sand present
					11	55			@ 54.5 ft.: increasing silt, fine sand present
					23	60			LIGHT OLIVE BROWN CLAYEY SILT (ML) (2.5Y 5/4) Very stiff, moist, moderate plasticity, 30% fines
					17	65			LIGHT OLIVE BROWN SILTY SAND (SM) Medium dense, wet, fine sand, 30% fines LIGHT OLIVE BROWN SANDY SILT (ML) (2.5Y 5/4) Stiff, wet, moderate to low plasticity, 30% fine sand
					16	70			LIGHT OLIVE BROWN SILTY CLAY (CL) (2.5Y 5/4) Very stiff, moist, moderate to high plasticity, 20% fines
					17				



Harding ESE
A MACTEC COMPANY

Log of Boring 105
Warehouse/Maintenance Shop (Runnels Property)
Russell City Energy Center
Hayward, California

PLATE

B-105

DRAWN
PCB

JOB NUMBER
53483 003

APPROVED

DATE
8/01

REVISED DATE

GEO TECH BORING NEW HARDINGESE 53483.GPJ GEOTECH.GDT 8/16/01

Other Tests/Drilling Notes	Moisture Content (%)	Dry Density (pcf)	Pocket Pen (Tst)	Torvane (Tst)	Blows per Foot	Depth (ft.)	Sampler Type	Graphic Log	Date 5/29/01	
									Equipment Failing F1500	Drilling Method mud rotary
						70				
			2.25		180 psi	75		DARK OLIVE GRAY CLAY (CH) (5Y 3/2) Very stiff, wet, high plasticity		
					24					
					19	80		DARK OLIVE GRAY SILTY CLAY (CL) (5Y 3/2) Stiff, wet, moderate plasticity, 20% fines		
					24					
						85		DARK OLIVE GRAY CLAYEY SAND (SC) (5Y 3/2) Medium dense, wet, fine-grained, 30% fines		
					17	90		DARK OLIVE GRAY SILTY CLAY (CL) (5Y 3/2) Very stiff, wet, moderate to high plasticity		
					17	95		@ 94 ft.: Increasing silt		
					16	100				
					15	105				



Harding ESE
A MACTEC COMPANY

Log of Boring 105
Warehouse/Maintenance Shop (Runnels Property)
Russell City Energy Center
Hayward, California

PLATE

B-105

DRAWN
PCB

JOB NUMBER
53483 003

APPROVED

DATE
8/01

REVISED DATE

Date 5/29/01

Equipment Failing F1500

Drilling Method mud rotary

Sampler SPT, Shelby

Hammer Weight 140 lb. Drop 30 in.

Logged by F. Drewes Datum MSL

Surface Elevation 9.8 ft.

Northing 2056959 Easting 6089812

Other Tests/Drilling Notes	Moisture Content (%)	Dry Density (pcf)	Pocket Pen (Tsf)	Torvane (Tsf)	Blows per Foot	Depth (ft.)	Sampler Type	Graphic Log	
<p>* One blow drove the split spoon 15" then 3 blows drove the split spoon 3"</p>						105			<p>@ 104.5 ft.: Decreasing silt</p>
					11	110			<p>@ 110 ft.: Color change to GREENISH GRAY (5G 5/1)</p>
					*1/15" *3/3"	115			<p>@ 113 ft.: Sand present GREENISH GRAY FAT CLAY (CH) (5G 5/1) @ 115 ft.: Very soft</p>
		1.75			200 psi	120			<p>GREENISH GRAY FAT CLAY (CH) (5G 5/1) @ 120 ft.: Increasing fine sand Color change to DARK GREENISH GRAY (5G 4/1) Bottom of boring at 121 ft. Tremie grouted with cement grout.</p>

GEOTECH_BORING_NEW_HARDINGESE 53483.GPJ GEOTECH.GDT 8/16/01



Harding ESE
A MACTEC COMPANY

Log of Boring 105
Warehouse/Maintenance Shop (Runnels Property)
Russell City Energy Center
Hayward, California

PLATE

B-105

DRAWN
PCB

JOB NUMBER
53483 003

APPROVED

DATE
8/01

REVISED DATE

GEOTECH_BORING_NEW_HARDINGESE 53483.GPJ GEOTECH.GDT 8/16/01

Other Tests/Drilling Notes	Moisture Content (%)	Dry Density (pcf)	Pocket Pen (Tsf)	Torvane (Tsf)	Blows per Foot	Depth (ft.)	Sampler Type	Graphic Log	Date <u>6/8/01</u>	
									Equipment <u>Failing F1500</u>	Drilling Method <u>mud rotary</u>
						0			Hammer Weight <u>140 lb.</u>	Drop <u>30 in.</u>
						17			Logged by <u>M. Phelps</u>	Datum <u>MSL</u>
						13			Surface Elevation <u>5.02 ft.</u>	
						11			<u>Northing 2056602.7</u>	<u>Easting 6089113.8</u>
Switched to rotary wash method using 4-7/8 in. drag bit at 4 ft. Did not measure water level.						9			BLACK SILTY CLAY (CL) (N1) Stiff to very stiff, dry (TOPSOIL)	
						5			@ 1.5-3.0 ft.: No sample recovery	
						11			OLIVE GRAY FAT CLAY (CH) (5Y 4/1) Stiff, moist, high plasticity	
						9			@ 6.5 ft.: Change to wet	
						11			@ 8 ft.: Change color to OLIVE BROWN (5Y 4/4)	
						10			BROWN SANDY LEAN CLAY (CL) (10YR 4/2) Stiff, wet, moderate plasticity	
						4				
						180 psi				
						22			LIGHT BROWN CLAYEY SILT (ML) Very stiff, dry to moist, low plasticity, silt exhibits a blocky texture	
						11			BROWN SILTY CLAY (CL) Stiff, wet, moderate plasticity	
					17			GRAY BROWN SILTY FAT CLAY (CH) Very stiff, wet, high plasticity		
					18			@ 29.5 ft.: Color change to BROWN, increase in sand		
					30			@ 32.5 ft.: More sand		
					10			BROWN SILTY CLAY WITH SAND (CL) Stiff, wet, low to moderate plasticity		
						35				




Log of Boring 106
 Russell City Energy Center
 Hayward, California

PLATE
B-106

DRAWN PCB	JOB NUMBER 53483 003	APPROVED	DATE 8/01	REVISED DATE
--------------	-------------------------	----------	--------------	--------------

GEOTECH BORING_NEW_HARDINGESE 53483.GPJ GEOTECH.GDT 8/16/01

Other Tests/Drilling Notes	Moisture Content (%)	Dry Density (pcf)	Pocket Pen (Tsf)	Torvane (Tsf)	Blows per Foot	Depth (ft.)	Sampler Type	Graphic Log	Date 6/8/01	
									Equipment	Falling F1500
									Drilling Method	mud rotary
									Sampler	SPT, Shelby
									Hammer Weight	140 lb.
									Drop	30 in.
									Logged by	M. Phelps
									Datum	MSL
									Surface Elevation	5.02 ft.
									Northing	2056602.7
									Easting	6089113.8
Slower, harder drilling						35				
						40			OLIVE GRAY CLAYEY SILT WITH SAND (ML)	Medium stiff to stiff, wet,
						45			OLIVE GRAY CLAY (CL)	Stiff to very stiff, wet, moderate plasticity
						50			@ 49 ft.: Color change to OLIVE BROWN, hard, cemented nodules < 3/8 in. diameter	
						55			@ 51.5 - 52 ft.: Sandy interval	
						60			BROWN TO GRAY MOTTLED LEAN CLAY WITH SAND (CL)	Very stiff, wet, cemented nodules < 1/4 in. diameter
						65			MOTTLED BROWN AND GRAY FAT CLAY (CH)	Stiff, wet, blocky - fissured
						70			OLIVE GRAY SILT WITH SAND (ML)	Stiff to very stiff, wet
								OLIVE GRAY FAT CLAY (CH)	Very stiff, wet, high plasticity	



Harding ESE
A MACTEC COMPANY

Log of Boring 106

Russell City Energy Center
Hayward, California

PLATE
B-106

DRAWN: PCB

JOB NUMBER: 53483 003

APPROVED: _____

DATE: 8/01

REVISED DATE: _____

GEOTECH BORING NEW_HARDINGESE_53483.GPJ GEOTECH.GDT 8/16/01

Other Tests/Drilling Notes	Moisture Content (%)	Dry Density (pcf)	Pocket Pen (Tst)	Torvane (Tst)	Blows per Foot	Depth (ft.)	Sampler Type	Graphic Log	Date <u>6/8/01</u> Equipment <u>Failing F1500</u> Drilling Method <u>mud rotary</u> Sampler <u>SPT, Shelby</u> Hammer Weight <u>140 lb.</u> Drop <u>30 in.</u> Logged by <u>M. Phelps</u> Datum <u>MSL</u> Surface Elevation <u>5.02 ft.</u> Northing <u>2056602.7</u> Easting <u>6089113.8</u>
						70			
						14			OLIVE GRAY SILTY CLAY WITH SAND (CL) Stiff, wet, low to moderate plasticity
						75			
						13			
						80			
						20			OLIVE GRAY SILTY FAT CLAY (CH) Very stiff, wet, high plasticity
						85			
						18			
						90			
						24			@ 94 ft.: Color change to OLIVE BROWN
						95			
						18			@ 98.5 ft.: Color change to OLIVE GRAY
						100			Bottom of boring at 100 ft. Tremie grouted with cement grout.



Harding ESE
A MACTEC COMPANY

Log of Boring 106

PLATE

Russell City Energy Center
Hayward, California

B-106

DRAWN
PCB


JOB NUMBER
53483 003

APPROVED


DATE
8/01

REVISED DATE

GEOTECH BORING NEW HARDINGESE 53483.GPJ GEOTECH.GDT 8/16/01



Date 6/1/01
 Equipment Failing F1500
 Drilling Method mud rotary
 Sampler SPT, Shelby
 Hammer Weight 140 lb. Drop 30 in.
 Logged by M. Phelps Datum MSL
 Surface Elevation 5.9 ft.
 Northing 2056528.1 Easting 6089280.2

 Harding ESE A MACTEC COMPANY	Log of Boring 107 Cooling Tower Forebay (Salem Property) Russell City Energy Center Hayward, California		PLATE B-107
	DRAWN PCB	JOB NUMBER 53483 003	APPROVED

GEOTECH_BORING_NEW_HARDINGESE 53483.GPJ GEOTECH.GDT 8/16/01

Other Tests/Drilling Notes	Moisture Content (%)	Dry Density (pcf)	Pocket Pen (Tsf)	Torvane (Tsf)	Blows per Foot	Depth (ft.)	Sampler Type	Graphic Log	Date <u>6/1/01</u>	
									Equipment <u>Falling F1500</u>	Drilling Method <u>mud rotary</u>
									Sampler <u>SPT, Shelby</u>	Hammer Weight <u>140 lb.</u> Drop <u>30 in.</u>
									Logged by <u>M. Phelps</u> Datum <u>MSL</u>	Surface Elevation <u>5.9 ft.</u>
									Northing <u>2056528.1</u> Easting <u>6089280.2</u>	
					7	35			OLIVE GRAY SANDY LEAN CLAY (CL) (5Y 4/2) Medium stiff, wet, 50% fine sand, moderate plasticity	
					15	40			OLIVE GRAY CLAY (CH) (5Y 4/2) Stiff, wet, high plasticity	
					9	45			OLIVE GRAY SILTY CLAY (CL) (5Y 4/2) Stiff, wet, 30% fines, moderate to high plasticity	
					20	50			© 55-56 ft.: Gravel present, very stiff	
					11	55			DARK GRAY CLAY (CH) (2.5Y 4/1) Stiff, wet, high plasticity	
					13	60			DARK GRAY SILTY CLAY (CL) (5Y 4/2) Stiff, wet, 30% fines, moderate to high plasticity	
					13	65				
					13	70				

Drill rate increases between 65.5 to 67.0 ft.



Harding ESE
A MACTEC COMPANY

Log of Boring 107
Cooling Tower Forebay (Salem Property)
Russell City Energy Center
Hayward, California

PLATE

B-107

DRAWN
PCB

JOB NUMBER
53483 003

APPROVED

DATE
8/01

REVISED DATE

GEOTECH_BORING_NEW_HARDINGESE 53483.GPJ GEOTECH.GDT 8/16/01

Other Tests/Drilling Notes	Moisture Content (%)	Dry Density (pcf)	Pocket Pen (Tsf)	Torvane (Tsf)	Blows per Foot	Depth (ft.)	Sampler Type	Graphic Log	Date <u>6/1/01</u>	
									Equipment <u>Failing F1500</u>	Drilling Method <u>mud rotary</u>
									Sampler <u>SPT, Shelby</u>	
									Hammer Weight <u>140 lb.</u>	Drop <u>30 in.</u>
									Logged by <u>M. Phelps</u>	Datum <u>MSL</u>
									Surface Elevation <u>5.9 ft.</u>	
									Northing <u>2056528.1</u>	Easting <u>6089280.2</u>
						70				
						19				
						75				@ 74 ft.: Color change to OLIVE GRAY (5Y 4/2), very stiff, low to moderate plasticity
						24				
						80				
						21				
						85				GRAYISH BROWN SANDY SILT (ML) (5Y4 3/2) Medium dense, wet, 40-50% fines, very fine sand, low plasticity
										OLIVE GRAY FAT CLAY (CH) (5Y 4/1) Very stiff, wet, high plasticity
						21				
						90				
						20				
						95				OLIVE GRAY SILTY SANDY CLAY (CL) (5Y 4/1) Very stiff, wet, moderate plasticity
						22				
						100				DARK GREENISH GRAY FAT CLAY (CH) (5GY 4/1) Very stiff, wet, high plasticity
										Bottom of boring at 100 ft. Tremie grouted with cement grout.



Harding ESE
A MACTEC COMPANY

Log of Boring 107
Cooling Tower Forebay (Salem Property)
Russell City Energy Center
Hayward, California

PLATE

B-107

DRAWN
PCB

JOB NUMBER
53483 003

APPROVED

DATE
8/01

REVISED DATE

GEOTECH_BORING_NEW_HARDINGESE 53483.GPJ GEOTECH.GDT 8/16/01

Other Tests/Drilling Notes	Moisture Content (%)	Dry Density (pcf)	Pocket Pen (Tsf)	Torvane (Tsf)	Blows per Foot	Depth (ft.)	Sampler Type	Graphic Log	Date 6/11/01	
									Equipment	Failing F1500
									Drilling Method	mud rotary
									Sampler	SPT, Shelby
									Hammer Weight	140 lb.
									Drop	30 in.
									Logged by	M. Phelps
									Datum	MSL
									Surface Elevation	7.0 ft.
									Northing	2056506.9
									Easting	6089495.6
Switch to rotary wash method using 4-5/8 in. drag bit at -4 ft. Did not observe water in boring. UC=1064 -200=81%	26.9	95.6	1.3	80-100 psi	6	0		BLACK SAND (SP) Loose, dry, roots (TOPSOIL)		
					17			BLACK CLAY (CL) Very stiff, moist		
					12			BLACK FAT CLAY (CH) Stiff, moist, organics, fine, rootlets		
					12	5		@ 5 ft.: Color change to OLIVE BROWN, wet		
					8			@ 6.5-7.0 ft.: BROWN SILTY CLAY (CL) Medium stiff		
					10			OLIVE GRAY FAT CLAY (CH) Stiff, wet, mottled		
					10			@ 11 ft.: Color change to OLIVE BROWN		
					10			@ 14 ft.: Color change to GRAY BROWN		
					15			@ 19 ft.: Color change to BROWN SILTY FAT CLAY (CH), high plasticity		
					9			@ 29 ft.: Change to stiff to very stiff, slightly porous and minor organics		
15										
17										



Harding ESE
A MACTEC COMPANY

Log of Boring 108
West HSRG (Salem Property)
Russell City Energy Center
Hayward, California

PLATE

B-108

DRAWN	JOB NUMBER	APPROVED	DATE	REVISED DATE
PCB	53483 003		8/01	

GEOTECH BORING NEW, HARDINGESE 53483.GPJ GEOTECH.GDT 8/16/01

Other Tests/Drilling Notes	Moisture Content (%)	Dry Density (pcf)	Pocket Pen (Tsf)	Torvane (Tsf)	Blows per Foot	Depth (ft.)	Sampler Type	Graphic Log	Date <u>6/11/01</u> Equipment <u>Failing F1500</u> Drilling Method <u>mud rotary</u> Sampler <u>SPT, Shelby</u> Hammer Weight <u>140 lb.</u> Drop <u>30 in.</u> Logged by <u>M. Phelps</u> Datum <u>MSL</u> Surface Elevation <u>7.0 ft.</u> Northing <u>2056506.9</u> Easting <u>6089495.6</u>
Easier drilling						35			@ 34 ft.: Color change to OLIVE BROWN AND GRAY MOTTLED FAT CLAY (CH) Very stiff
						10 40			OLIVE BROWN SILTY CLAY WITH SAND (CL) Stiff, wet, moderate plasticity
						20 45			OLIVE GRAY FAT CLAY (CH) Very stiff, wet
						25 50			@ 49 ft.: Iron oxide staining
Faster drilling						15 55			BROWN CLAYEY SAND (SC))
Split Sample						15 60			BROWN SILTY CLAYEY SAND (SC-SM) Medium dense, wet, > 65% sand, some interbedded silty sand and clays from 51.5 - 57 ft.
						16 65			OLIVE GRAY FAT CLAY (CH) Very stiff, wet, high plasticity
						20 70			OLIVE GRAY CLAYEY SILT (ML) Very stiff, trace sand
						13 70			OLIVE GRAY SILTY FAT CLAY (CH) Stiff, wet, fissures - blocky texture



Harding ESE
A MACTEC COMPANY

Log of Boring 108
West HSRG (Salem Property)
Russell City Energy Center
Hayward, California

PLATE

B-108

DRAWN
PCB

JOB NUMBER
53483 003

APPROVED

DATE
8/01

REVISED DATE

GEOTECH_BORING_NEW_HARDINGESE 53483.GPJ GEOTECH.GDT 8/16/01

Other Tests/Drilling Notes	Moisture Content (%)	Dry Density (pcf)	Pocket Pen (Tsf)	Torvane (Tsf)	Blows per Foot	Depth (ft.)	Sampler Type	Graphic Log	Date 6/11/01	
									Equipment	Failing F1500
									Drilling Method	mud rotary
									Sampler	SPT, Shelby
									Hammer Weight	140 lb.
									Drop	30 in.
									Logged by	M. Phelps
									Datum	MSL
									Surface Elevation	7.0 ft.
									Northing	2056506.9
									Easting	6089495.6
						70				
						18				@ 74 ft.: Change to very stiff
						75				
						24				OLIVE GRAY BROWN SILTY CLAY (CL) Very stiff, wet
						80				
						18				@ 84-84.5 ft.: Lens of OLIVE GRAY BROWN SANDY SILT (ML) Medium dense, wet, > 60% sand
						85				OLIVE GRAY BROWN SILTY CLAY (CL)
						19				OLIVE GRAY FAT CLAY (CH) Very stiff, wet, high plasticity
						90				
						17				@ 94 ft.: Mottled OLIVE BROWN GRAY
						95				
						21				@ 99 ft.: Color change to OLIVE GRAY
						100				Bottom of boring at 100 ft. Tremie grouted with cement grout.



Harding ESE
A MACTEC COMPANY

Log of Boring 108
West HSRG (Salem Property)
Russell City Energy Center
Hayward, California

PLATE

B-108

DRAWN
PCB

JOB NUMBER
53483 003

APPROVED

DATE
8/01

REVISED DATE

Other Tests/Drilling Notes	Moisture Content (%)	Dry Density (pcf)	Pocket Pen (Tsf)	Torvane (Tsf)	Blows per Foot	Depth (ft.)	Sampler Type	Graphic Log	Date <u>5/30/01</u>	
									Equipment <u>Failing F1500</u>	Drilling Method <u>mud rotary</u>
<p>Borehole was relocated about 1 ft. to the south because of obstruction (scrap metal?) at a depth of about 6 in.</p> <p>UC=1686 -200=85%</p> <p>Shelby tube sample was wet. Water started running up the borehole after sample was retrieved. UC=695 -200=78% Groundwater measured at a depth of 7 ft. before switching to wash method.</p> <p>UC=391 -200=12% Rig had electrical/ mechanical problems and was replaced by another truck-mounted Failing F-1500 rig at the start of work on 5/31/2001.</p>	23.6	101.4	2.5		200 psi	0			Surface Elevation <u>8.7 ft.</u>	
						12			Northing <u>2056457.7</u> Easting <u>6089771.7</u>	
						8			DARK GRAYISH BROWN SANDY SILT WITH SAND AND GRAVEL (ML) Stiff, 30% fine to medium sand (FILL)	
						11			BLACK FAT CLAY (CH) (2.5/1) Stiff, moist, high plasticity, roots, mottled	
						12			DARK OLIVE (5Y 3/2)	
						10			@ 10 ft.: Set conductor casing and begin rotary wash	
						14			DARK OLIVE LEAN CLAY WITH SAND (CL) (5Y 3/2) Stiff, wet, moderate to high plasticity, 30% fines	
						10			Add gel-x drilling mud	
						15			@ 16.5 ft.: Change to LIGHT OLIVE BROWN (2.5Y 5/4), increasing silt, hard	
						33			@ 20 ft.: Stiff	
10			BROWN SILTY SAND (SM) Soft, with fine to coarse sand							
20			@ 27.5 ft.: Very stiff, coarse sand present							
25			@ 32 ft.: Gravel present							
32										
19										
30										
22										
35										

GEOTECH_BORING_NEW_HARDINGESE 53483.GPJ GEOTECH.GDT 8/16/01



Harding ESE
A MACTEC COMPANY

Log of Boring 109

Russell City Energy Center
Hayward, California

PLATE

B-109

DRAWN PCB	JOB NUMBER 53483 003	APPROVED	DATE 8/01	REVISED DATE
--------------	-------------------------	----------	--------------	--------------

GEOTECH_BORING_NEW_HARDINGESE 53483.GPJ GEOTECH.GDT 8/16/01

Other Tests/Drilling Notes	Moisture Content (%)	Dry Density (pcf)	Pocket Pen (Tsf)	Torvane (Tsf)	Blows per Foot	Depth (ft.)	Sampler Type	Graphic Log	Date <u>5/30/01</u> Equipment <u>Falling F1500</u> Drilling Method <u>mud rotary</u> Sampler <u>SPT, Shelby</u> Hammer Weight <u>140 lb.</u> Drop <u>30 in.</u> Logged by <u>F. Drewes</u> Datum <u>MSL</u> Surface Elevation <u>8.7 ft.</u> Northing <u>2056457.7</u> Easting <u>6089771.7</u>
UC=2274 -200=97%	27.9	95.4	1.25		180 psi	35 40 45 50 55 60 65 70			@ 40 ft.: Gray mottling @ 45 ft.: Color change to DARK GRAYISH BROWN (2.5Y 4/2) @ 48.5 ft.: High plasticity (CH) @ 52.5 ft.: Decreasing silt, increasing plasticity DARK GRAYISH BROWN CLAYEY SILT (ML) (2.5Y 4/2) Stiff, moist, moderate to low plasticity, 30% fines @ 60 ft.: Sand lenses present. DARK GRAY SILTY CLAY (CH) (2.5Y 4/1) Stiff, moist, high plasticity, 20% fines DARK GRAY SILTY CLAY (CL) (2.5Y 4/1) Stiff, moist, moderate to high plasticity, 30% fines



Harding ESE
A MACTEC COMPANY

Log of Boring 109
Russell City Energy Center
Hayward, California

PLATE
B-109

DRAWN PCB	JOB NUMBER 53483 003	APPROVED	DATE 8/01	REVISED DATE
--------------	-------------------------	----------	--------------	--------------

GEOTECH_BORING_NEW_HARDINGESE_53483.GPJ GEOTECH.GDT 8/16/01

Other Tests/Drilling Notes	Moisture Content (%)	Dry Density (pcf)	Pocket Pen (Tsf)	Torvane (Tsf)	Blows per Foot	Depth (ft.)	Sampler Type	Graphic Log	Date <u>5/30/01</u> Equipment <u>Failing F1500</u> Drilling Method <u>mud rotary</u> Sampler <u>SPT, Shelby</u> Hammer Weight <u>140 lb.</u> Drop <u>30 in.</u> Logged by <u>F. Drewes</u> Datum <u>MSL</u> Surface Elevation <u>8.7 ft.</u> Northing <u>2056457.7</u> Easting <u>6089771.7</u>
						70			
						18			
						75			@ 73.5 ft.: Change to DARK OLIVE GRAY (5Y 3/2), increasing plasticity
						21			
						80			
						15			
						85			
						24			OLIVE BROWN CLAYEY SILT WITH FINE SAND (ML) (2.5Y 4/4) Very stiff, moderate to low plasticity, 20% fines, 15% fine sand
						90			
						17			OLIVE GRAY FAT CLAY (CH) (5Y 4/2) Very stiff, moist, high plasticity, 20% fines
						95			
						27			Bottom of boring at 100 ft. Tremie grouted with cement grout.
						100			



Harding ESE
A MACTEC COMPANY

Log of Boring 109

PLATE

B-109

Russell City Energy Center
Hayward, California

DRAWN
PCB

JOB NUMBER
53483 003

APPROVED

DATE
8/01

REVISED DATE

Appendix 10G
Attachment 10G-2 - Ground Water Observation Well Log

Date 6/1/01

Equipment Failing F1500

Drilling Method mud rotary

Sampler

Hammer Weight 140 lb. Drop 30 in.

Logged by J. Clemente Datum MSL

Surface Elevation 5.9 ft.

Northing 2056523.1 Easting 6089280.2

GROUND SURFACE

Top of casing 21.5 in. above ground surface

SCHEDULE 80 PVC BLANK CASING: 0 to 20 ft.

6.25 in. DIAMETER BOREHOLE: 0 to 32 ft.

BENTONITE-CEMENT SEAL: 0 to 15 ft.


BENTONITE PELLET SEAL: 15 to 17.5 ft.

Lonestar #2/12 SANDPACK: 17.5 to 32 ft.

SLOTTED (0.020 in.) SCREEN: 20 to 30 ft.

BOTTOM WELL CAP: 32 ft. Bottom of boring at 32 ft.

Depth (ft.) Sample



TOPSOIL and gray fine sand to 6 in. Black clay with roots below 6 in. No drilling mud was used in the borehole. Driller reported water loss in the upper 8 ft.

DARK GRAYISH BROWN SANDY CLAY, some roots

No roots below 4.5 ft.

@ 8.5-10 ft.: Gray/brown mottling

@ 10-11.5 ft.: Sandy

OLIVE BROWN SILTY CLAY (CL), with fine sand

@ 28.5-30 ft.: Little sand

Bottom of boring at 32 ft. See B-107 for sampling information. Bailed water to 18 ft. BGS after installing well. Water rose to 5 ft. BGS in 10 min. See Table 2 for water level data.

BORING WELL2-HARDINGESE 53483.GPJ GEOL.GDT 8/16/01



Harding ESE
A MACTEC COMPANY

Well Construction Details and Log of Boring 107B

Cooling Tower Forebay (Salem Property)
Russell City Energy Center
Hayward, California

PLATE

OW-107

DRAWN
PCB

JOB NUMBER
53483 003


APPROVED

DATE
8/01

REVISED DATE

Appendix 10G
Attachment 10G-3 - Laboratory Test Results

PARTICLE SIZE ANALYSIS (ASTM D 422-63)



	% +3"	% GRAVEL	% SAND	% SILT	% CLAY	USCS	LL	PI
●	0.0	0.0	21.1	78.9		CL		
▲	0.0	0.0	12.4	87.6		ML		

SIEVE inches size	PERCENT FINER		
	●	▲	
X	GRAIN SIZE		
D ₆₀			
D ₃₀			
D ₁₀			
X	COEFFICIENTS		
C _u			
C _c			

SIEVE number size	PERCENT FINER	
	●	▲
10	100.0	100.0
20	99.8	99.7
40	99.3	98.9
60	98.1	97.2
100	94.0	92.9
140	86.0	90.1
200	78.9	87.6

Sample information:


- B-102 12-13'
Dk. brn. sandy CLAY.
- ▲ B-102 59-60'
Dk. gray clayey SILT.

Remarks:

**Soil
Mechanics
Lab**

Project No.: 53483
 Project: Russell City Energy Center
 Date: 6-27-01
 Data Sheet No. _____

PARTICLE SIZE ANALYSIS (ASTM D 422-63)



	% +3"	% GRAVEL	% SAND	% SILT	% CLAY	USCS	LL	PI
●	0.0	9.4	82.6	8.0		SP-SM		
▲	0.0	0.0	60.4	39.6		SC		
■	0.0	0.0	32.8	67.2		CL		

SIEVE inches size	PERCENT FINER		
	●	▲	■
0.75	100.0		
0.375	99.4		
GRAIN SIZE			
D ₆₀	0.92	0.14	
D ₃₀	0.33		
D ₁₀	0.11		
COEFFICIENTS			
C _c	0.98		
C _u	7.8		

SIEVE number size	PERCENT FINER		
	●	▲	■
4	90.6	100.0	
10	75.1	99.9	100.0
20	58.2	99.8	99.7
40	39.7	99.2	99.4
60	20.8	89.9	97.7
100	11.8	63.8	86.9
200	8.0	39.6	67.2

Sample information:


- B-104 38.5-40.0' V.dk.brn. f-c SAND w/gravel.
- ▲ B-104 54.0-55.0' Olive brn. clayey SAND.
- B-104 89.0-90.0' Dk.gray sandy CLAY.

Remarks:

**Soil
Mechanics
Lab**

Project No.: 53483
 Project: Russell City Energy Center
 Date: 6-29-01
 Data Sheet No. _____


PARTICLE SIZE ANALYSIS (ASTM D 422-63)



% +3"	% GRAVEL	% SAND	% SILT	% CLAY	USCS	LL	PI
0.0	10.4	13.2	76.4		CL		

SIEVE inches size	PERCENT FINER			SIEVE number size	PERCENT FINER			Sample information: • B-106 54.0-55.0' Olive brown sandy CLAY w/caliche.
0.75	100.0			4	89.6			
0.375	96.6			10	86.7			
 GRAIN SIZE				20	85.2			
 COEFFICIENTS				40	84.6			
D ₆₀				60	83.4			
D ₃₀				100	80.2			
D ₁₀				200	76.4			
 				Remarks:				
 								
 								

PARTICLE SIZE ANALYSIS (ASTM D 422-63)



	% +3"	% GRAVEL	% SAND	% SILT	% CLAY	USCS	LL	PI
●	0.0	0.0	18.1	81.9		CH		
▲	0.0	0.0	40.4	59.6		CL		
■	0.0	0.0	29.8	70.2		ML		


SIEVE inches size	PERCENT FINER			SIEVE number size	PERCENT FINER		
	●	▲	■		●	▲	■
				4	100.0		
				10	99.9	100.0	
				20	99.5	99.7	
				40	98.2	98.0	100.0
				60	96.6	87.8	99.9
				100	92.4	72.0	97.1
				200	81.9	59.6	70.2
GRAIN SIZE							
D ₆₀		0.08					
D ₃₀							
D ₁₀							
COEFFICIENTS							
C _c							
C _u							

Sample information:

- B-107 11.0-11.5' Olive brown FAT CLAY w/sand.
- ▲ B-107 39.5-40.0' Olive gray sandy CLAY.
- B-107 84.0-84.5' Olive gray sandy SILT.

Remarks:

PARTICLE SIZE ANALYSIS (ASTM D 422-63)



	% +3"	% GRAVEL	% SAND	% SILT	% CLAY	USCS	LL	PI
●	0.0	2.4	47.8	49.8		SC		
▲	0.0	0.0	22.2	77.8		ML		

SIEVE inches size	PERCENT FINER	
	●	▲
0.375	100.0	
GRAIN SIZE		
D ₆₀	0.10	
D ₃₀		
D ₁₀		
COEFFICIENTS		
C _c		
C _u		

SIEVE number size	PERCENT FINER	
	●	▲
4	97.6	100.0
10	96.4	99.8
20	96.1	99.5
40	95.8	99.4
60	92.1	99.0
100	73.2	93.4
200	49.8	77.8

Sample information:


- B-108 54.5-55.0'
Olive gray clayey SAND.
- ▲ B-108 84.5-85.0'
Olive gray sandy SILT.

Remarks:

**Soil
Mechanics
Lab**

Project No.: 53483
 Project: Russell City Energy Center
 Date: 6-29-01
 Data Sheet No. _____

LIQUID AND PLASTIC LIMITS TEST REPORT




Location + Description	LL	PL	PI	-200	ASTM D 2487-90
● B-101 @ 13.5-15.2': Dark gray f-c SAND(SM)w/gravel Trace plastic fines.	NV	NP		47	SM, Silty sand
▲ B-101 @ 29-30': Brn. silty CLAY(CL) Wn=21%	44	21	23	75%	CL, Lean clay with sand
■ B-101 @ 49-50': Gray silty F-SAND(SM) Wn=23%	NV	NP		34	SM, Silty sand

NV - Non-Viscous NP - Non-Plastic

Project No.: 53483 Project: Russell City Energy Center Client: Harding ESE Location: Date: 6-27-01	Remarks: ASTM D 4318
LIQUID AND PLASTIC LIMITS TEST REPORT Soil Mechanics Lab	
Fig. No. _____	

LIQUID AND PLASTIC LIMITS TEST REPORT



Location + Description	LL	PL	PI	-200	ASTM D 2487-90
● B-101 @ 13.5-15.2': Dark gray f-c SAND(SM)w/gravel Trace plastic fines.	NV	NP			
▲ B-102 @ 13-15.5': Olive br clayey SAND(SC)	29	18	11		
■ B-102 @ 22.5-25': Olive br sandy CLAY(CL)	36	19	17		
◆ B-103 @ 12-14.5': Olive br sandy CLAY(CL)	44	19	25		

NV - Non-Viscous NP - Non-Plastic

Project No.: 53483
 Project: Russell City Energy Center
 Client: Harding ESE
 Location:
 Date: 6-27-01


Remarks:
 ASTM D 4318

LIQUID AND PLASTIC LIMITS TEST REPORT

Soil Mechanics Lab

Fig. No. _____

LIQUID AND PLASTIC LIMITS TEST REPORT



Location + Description	LL	PL	PI	-200	ASTM D 2487-90
● B-103 @ 3-4': Gray FAT CLAY(CH)w/sand. Wn=22%	58	24	34	74	CH, Fat clay with sand
▲ B103 @ 12-14.5': Olive brn sandy CLAY(CL)	44	19	25	67	CL, Sandy lean clay
■ B-103 @ 104-105': Gray FAT CLAY(CH) Wn=54%	73	25	48	96	CH, Fat clay
◆ B-103 @ 109-110': Bluish gray FAT CLAY(CH) Wn=53%	74	27	47	99	CH, Fat clay


Project No.: 53483
 Project: Russell City Energy Center
 Client: Harding ESE
 Location:
 Date: 6-27-01

Remarks:
 ASTM D 4318

LIQUID AND PLASTIC LIMITS TEST REPORT
Soil Mechanics Lab

Fig. No. _____

LIQUID AND PLASTIC LIMITS TEST REPORT



Location + Description	LL	PL	PI	-200	ASTM D 2487-90
● B-104 @ 4.5-5.5': Dark oliv gray FAT CLAY(CH) W _n =23%	68	23	45	73	CH, Fat clay with sand
▲ B-104 @ 6-8.5': V.dk.gray FAT CLAY(CH)	68	27	41	85	CH, Fat clay with sand
■ B-104 @ 13-15.5': Olive brown sandy CLAY(CL)	41	20	21	68	CL, Sandy lean clay


Project No.: 53483
 Project: Russell City Energy Center
 Client: Harding ESE
 Location:
 Date: 6-27-01

LIQUID AND PLASTIC LIMITS TEST REPORT
Soil Mechanics Lab

Remarks:
 ASTM D 4318

Fig. No. _____

LIQUID AND PLASTIC LIMITS TEST REPORT




Location + Description	LL	PL	PI	-200	ASTM D 2487-90
● B-104 @ 38.5-40': V. dark brn. silty f-c SAND(SM) w/gravel. Wn=14%	NV	NP		8	SP-SM, Poorly graded sand with silt
▲ B-104 @ 109-110': Bluish gray FAT CLAY(CH) Wn=55%	77	27	50	100	CH, Fat clay
■ B-104 @ 118.5-120': Dark gray FAT CLAY(CH) w/sand seams.	71	26	45	88	CH, Fat clay

NV - Non-Viscous NP - Non-Plastic

Project No.: 53483
 Project: Russell City Energy Center
 Client: Harding ESE
 Location:
 Date: 6-27-01

Remarks:
 ASTM D 4318

LIQUID AND PLASTIC LIMITS TEST REPORT



Location + Description	LL	PL	PI	-200	ASTM D 2487-90
● B-105 @ 6.5': Dk. gray FAT CLAY(CH)w/caliche Wn=23%	51	19	32	90	CH, Fat clay


Project No.: 53483
 Project: Russell City Energy Center
 Client: Harding ESE
 Location:
 Date: 7-11-01

Remarks:
 ASTM D 4318

LIQUID AND PLASTIC LIMITS TEST REPORT
Soil Mechanics Lab

Fig. No. _____

LIQUID AND PLASTIC LIMITS TEST REPORT



Location + Description	LL	PL	PI	-200	ASTM D 2487-90
● B-105 @ 11-14': Olive brn. sandy CLAY (CL)	43	20	23	77	CL, Lean clay with sand
▲ B-105 @ 23.5-26': Olive gr/brn. sandy CLAY (CL)	40	19	21	61	CL, Sandy lean clay
■ B-105 @ 43.5-46': Dk. gray FAT CLAY (CH)	73	28	45	87	CH, Fat clay


Project No.: 53483
 Project: Russell City Energy Center
 Client: Harding ESE
 Location:
 Date: 6-27-01

Remarks:
 ASTM D 4318

LIQUID AND PLASTIC LIMITS TEST REPORT
Soil Mechanics Lab

Fig. No. _____

LIQUID AND PLASTIC LIMITS TEST REPORT



Location + Description	LL	PL	PI	-200	ASTM D 2487-90
● B-105 @ 73.5-76': Olive gr FAT CLAY(CH)	53	24	29	100	CH, Fat clay
▲ B-105 @ 114.5-115': Bluish gray FAT CLAY(CH)	79	29	50	89	CH, Fat clay
■ B-105 @ 118.5-121': Dark gray FAT CLAY(CH)	79	31	48	91	CH, Fat clay


Project No.: 53483
 Project: Russell City Energy Center
 Client: Harding ESE
 Location:
 Date: 6-27-01

Remarks:
 ASTM D 4318

LIQUID AND PLASTIC LIMITS TEST REPORT
Soil Mechanics Lab

Fig. No. _____

LIQUID AND PLASTIC LIMITS TEST REPORT



Location + Description	LL	PL	PI	-200	ASTM D 2487-90
● B-106 @ 12-14.5': Dk. gray brn. sandy CLAY (CL)	41	20	21		
▲ B-108 @ 12.5': Dk. gray FAT CLAY (CH)	67	26	41		


Project No.: 53483
 Project: Russell City Energy Center
 Client: Harding ESE
 Location:
 Date: 6-27-01

Remarks:
 ASTM D 4318

LIQUID AND PLASTIC LIMITS TEST REPORT
Soil Mechanics Lab

Fig. No. _____

LIQUID AND PLASTIC LIMITS TEST REPORT



Location + Description	LL	PL	PI	-200	ASTM D 2487-90
● B-107 @ 1-1.5': Brownish blk. FAT CLAY(CH)	59	25	34	98	CH, Fat clay
▲ B-107 @ 4.5-7': Dk. gray FAT CLAY(CH)	57	24	33	84	CH, Fat clay with sand
■ B-107 @ 11-11.5': Oliv. brn. FAT CLAY(CH)w/sand. Wn=25%	53	22	31	82	CH, Fat clay with sand

Project No.: 53483
 Project: Russell City Energy Center

Client: Harding ESE
 Location:


Date: 6-27-01

LIQUID AND PLASTIC LIMITS TEST REPORT
Soil Mechanics Lab

Remarks:
 ASTM D 4318

Fig. No. _____

LIQUID AND PLASTIC LIMITS TEST REPORT



Location + Description	LL	PL	PI	-200	ASTM D 2487-90
● B-107 @ 14-16.5': Olive brn. sandy CLAY (CL)	38	19	19	90	CL, Lean clay
▲ B-107 @ 39.5-40': Olive gray sandy CLAY (CL) W _n =23%	47	22	25	82	CL, Lean clay with sand
■ B-107 @ 84-84.5': Olive gray f-sandy SILT (ML) W _n =22%	NV	NP		70	ML, Sandy silt

NV - Non-Viscous NP - Non-Plastic


Project No.: 53483
 Project: Russell City Energy Center
 Client: Harding ESE
 Location:
 Date: 6-27-01

LIQUID AND PLASTIC LIMITS TEST REPORT
Soil Mechanics Lab

Remarks:
 ASTM D 4318

Fig. No. _____

LIQUID AND PLASTIC LIMITS TEST REPORT




Location + Description	LL	PL	PI	-200	ASTM D 2487-90
● B-109 @ 4-4.5' Brownish blk. FAT CLAY(CH) W _n =32%	60	16	44	90	CH, Fat clay
▲ B-109 @ 7.5-10' V.dk. gray FAT CLAY(CH)	70	28	42		
■ B-109 @ 13-15.5' Olive br sandy CLAY(CL)	42	18	24	78	CL, Lean clay with sand
◆ B-109 @ 23.5-26' Olive br sandy CLAY(CL) portion of tube. (See cons.)	33	19	14		
× B-109 @ 48.5-51' Olive gr FAT CLAY(CH)	68	26	42	97	CH, Fat clay

Project No.: 53483
 Project: Russell City Energy Center
 Client: Harding ESE
 Location:
 Date: 6-27-01

Remarks:
 ASTM D 4318

UNCONFINED COMPRESSION TEST



SAMPLE NO.:	1	2	3	4
Unconfined strength, psf	292	747	1474	267
Undrained shear strength, psf	146	374	737	134
Failure strain, %	3.3	2.6	1.4	1.2
Strain rate, in/min	0.0750	0.0750	0.0750	0.0750
Water content, %	24.3	23.9	19.1	28.6
Wet density, pcf	126.8	123.6	127.4	118.9
Dry density, pcf	102.0	99.8	106.9	92.4
Saturation, %	100.6	93.6	89.6	93.8
Void ratio	0.6531	0.6892	0.5764	0.8237
Specimen diameter, in	2.88	2.88	2.88	2.88
Specimen height, in	5.40	6.12	5.64	5.10
Height/diameter ratio	1.88	2.13	1.96	1.77

- 1) Description: Sa.1/B-101 @ 14.5': Sft.,olv.brn. (SC) -#200=47%
- 2) Description: Sa.2/B-102 @ 15':Stf.brn.(CL) -#200=60%
- 3) Description: Sa.3/B-102 @ 24.5':Dns.olv.gry(SC)-#200=47%
- 4) Description: Sa.4/B-103 @ 14':Sft.,brn. sandy(CL) -#200=67%

GS= 2.7 Type: Shelby


Project No.: 53483.001
 Date: 6-19-01
 Remarks:

Client: Harding ESE
 Project: Russell City Energy Center
 Location: B-101,102 & 103

Fig. No.: _____

UNCONFINED COMPRESSION TEST
Soil Mechanics Lab

UNCONFINED COMPRESSION TEST



SAMPLE NO.:	1	2	3
Unconfined strength, psf	372	872	1429
Undrained shear strength, psf	186	436	714
Failure strain, %	1.8	5.0	3.9
Strain rate, in/min	0.0750	0.0750	0.0750
Water content, %	26.0	21.8	32.6
Wet density, pcf	123.1	126.0	117.8
Dry density, pcf	97.7	103.4	88.8
Saturation, %	96.9	93.6	98.2
Void ratio	0.7248	0.6305	0.8974
Specimen diameter, in	2.88	2.88	2.88
Specimen height, in	5.54	5.57	5.70
Height/diameter ratio	1.93	1.94	1.98
1) Description: Sa.1/8':Frm.dk.gr/ brn.(CH) -#200=85%			
2) Description: Sa.2/15':Frm.brn.sandy(CL) -#200=68%			
3) Description: Sa.3/118':Stf,dk.gry(CH)w/snd.seams. -#200=88%			
4) Description:			

GS= 2.7

Type: Shelby

Project No.: 53483.001

Date: 6-19-01

Remarks:

Client: Harding ESE


Project: Russell City Energy Center

Location: B-104 @ 8,15 & 118'

Fig. No.: _____

UNCONFINED COMPRESSION TEST
Soil Mechanics Lab

UNCONFINED COMPRESSION TEST



SAMPLE NO.:	1	2	3
Unconfined strength, psf	2455	1354	3671
Undrained shear strength, psf	1228	677	1836
Failure strain, %	2.1	6.2	2.1
Strain rate, in/min	0.0750	0.0750	0.0750
Water content, %	18.6	23.4	21.6
Wet density, pcf	131.7	125.8	128.7
Dry density, pcf	111.1	101.9	105.8
Saturation, %	97.0	96.6	98.3
Void ratio	0.5173	0.6537	0.5930
Specimen diameter, in	2.88	2.88	2.88
Specimen height, in	5.61	5.80	5.64
Height/diameter ratio	1.95	2.02	1.96
1) Description: Sa.1/12.5':Mtl.brn sndy(CL) -#200=77%			
2) Description: Sa.2/25.5':Mtl.d.brn.sandy(CL) -#200=61%			
3) Description: Sa.3/45.5':Stf,dk.gry(CH)w/caliche. -#200=87%			
4) Description:			

GS= 2.7

Type: Shelby

Project No.: 53483.001

Date: 6-19-01

Remarks:

Client: Harding ESE


Project: Russell City Energy Center

Location: B-105 @ 12.5, 25.5 & 45.5'

Fig. No.: _____

UNCONFINED COMPRESSION TEST
Soil Mechanics Lab

UNCONFINED COMPRESSION TEST



SAMPLE NO.:	1	2		
Unconfined strength, psf	4221	3208		
Undrained shear strength, psf	2110	1604		
Failure strain, %	4.6	1.4		
Strain rate, in/min	0.0750	0.0750		
Water content, %	26.0	47.5		
Wet density, pcf	126.1	109.3		
Dry density, pcf	100.1	74.1		
Saturation, %	102.5	100.6		
Void ratio	0.6844	1.2750		
Specimen diameter, in	2.88	2.88		
Specimen height, in	5.62	5.67		
Height/diameter ratio	1.95	1.97		

1) Description: Sa.1/75.5':Stf.dk.gr.(CH) - #200=100%

2) Description: Sa.2/120.5':Stf.dk.gr.(CH) -#200=91%

3) Description:

4) Description:

GS= 2.7

Type: Shelby

Project No.: 53483.001

Date: 6-19-01

Remarks:

Client: Harding ESE


Project: Russell City Energy Center

Location: B-105 @ 75.5 & 120.5'

Fig. No.: _____

UNCONFINED COMPRESSION TEST
Soil Mechanics Lab

UNCONFINED COMPRESSION TEST



SAMPLE NO.:	1			
Unconfined strength, psf	657			
Undrained shear strength, psf	328			
Failure strain, %	3.2			
Strain rate, in/min	0.0750			
Water content, %	22.2			
Wet density, pcf	124.3			
Dry density, pcf	101.7			
Saturation, %	91.0			
Void ratio	0.6571			
Specimen diameter, in	2.88			
Specimen height, in	5.55			
Height/diameter ratio	1.93			

- 1) Description: Firm, dk. gray/brn. sndy(CL) -#200=62%
- 2) Description:
- 3) Description:
- 4) Description:

	GS= 2.7	Type: Shelby
--	---------	--------------


Project No.: 53483.001
 Date: 6-19-01
 Remarks:

Fig. No.: _____

Client: Harding ESE
 Project: Russell City Energy Center
 Location: B-106 12.5'

UNCONFINED COMPRESSION TEST
Soil Mechanics Lab

UNCONFINED COMPRESSION TEST



SAMPLE NO.:	1	2	
Unconfined strength, psf	1006	1194	
Undrained shear strength, psf	503	597	
Failure strain, %	2.5	5.4	
Strain rate, in/min	0.0750	0.0750	
Water content, %	26.3	24.7	
Wet density, pcf	122.5	126.5	
Dry density, pcf	97.0	101.5	
Saturation, %	96.1	100.8	
Void ratio	0.7383	0.6609	
Specimen diameter, in	2.88	2.88	
Specimen height, in	5.70	5.54	
Height/diameter ratio	1.98	1.93	

1) Description: Sa.1/6.5':Frm.dk. gr. (CH) -#200=84%

2) Description: Sa.2/15':Stf.,olv.brn.sandy(CL) -#200=90%

3) Description:

4) Description:

GS= 2.7

Type: Shelby

Project No.: 53483.001

Date: 6-19-01

Remarks:

Client: Harding ESE


Project: Russell City Energy Center

Location: B-107 @ 6.5 & 15'

Fig. No.: _____

UNCONFINED COMPRESSION TEST
Soil Mechanics Lab


UNCONFINED COMPRESSION TEST



SAMPLE NO.:	1			
Unconfined strength, psf	1064			
Undrained shear strength, psf	532			
Failure strain, %	3.7			
Strain rate, in/min	0.0750			
Water content, %	26.9			
Wet density, pcf	121.4			
Dry density, pcf	95.6			
Saturation, %	95.2			
Void ratio	0.7623			
Specimen diameter, in	2.88			
Specimen height, in	6.00			
Height/diameter ratio	2.09			
1) Description: Stf.dk.gray (CH) -#200=81%				
2) Description:				
3) Description:				
4) Description:				

	GS= 2.7	Type: Shelby
Project No.: 53483.001	Client: Harding ESE	
Date: 6-19-01	Project: Russell City Energy Center	
Remarks:	Location: B-108 12.5'	
Fig. No.: _____	UNCONFINED COMPRESSION TEST Soil Mechanics Lab	

UNCONFINED COMPRESSION TEST



SAMPLE NO.:	1	2	3	4
Unconfined strength, psf	1686	695	391	2274
Undrained shear strength, psf	843	348	196	1137
Failure strain, %	3.2	3.9	1.4	4.6
Strain rate, in/min	0.0750	0.0750	0.0750	0.0750
Water content, %	23.6	22.9	19.1	27.9
Wet density, pcf	125.3	128.0	131.2	122.1
Dry density, pcf	101.4	104.1	110.2	95.4
Saturation, %	96.3	99.9	97.4	98.4
Void ratio	0.6628	0.6191	0.5302	0.7667
Specimen diameter, in	2.88	2.88	2.88	2.88
Specimen height, in	5.65	5.70	5.70	5.70
Height/diameter ratio	1.97	1.98	1.98	1.98

1) Description: Sa.1/9.5':Stf.v.dk gr. sndy(CL) -#200=85%

2) Description: Sa.2/15':Sft.olv.brn.sndy(CL) -#200=78%

3) Description: Sa.3/24':Sft.brn. silty f-c (SM) -#200=12%

4) Description: Sa.4/50.5':Stf.gr. ln.(CH) -#200=97%

GS= 2.7

Type: Shelby

Project No.: 53483.001

Date: 6-19-01

Remarks:

Client: Harding ESE

Project: Russell City Energy Center


Location: B-109 @ 9.5, 15, 24 & 50.5'

UNCONFINED COMPRESSION TEST

Soil Mechanics Lab

Fig. No.: _____

CONSOLIDATION TEST REPORT ASTM D 2435




Coeffs. of Consolidation (sq. ft./day) & Secondary Consolidation											
No.	Load	Cv	Cα	No.	Load	Cv	Cα	No.	Load	Cv	Cα

Natural Saturation	Natural Moisture	Dry Dens. (pcf)	LL	PI	Sp.Gr.	Precons. (ksf)	C _c	e ₀
77.0 %	18.6 %	102.0			2.700	5.00	0.23	0.6521

TEST RESULTS	MATERIAL DESCRIPTION
Compression Index = 0.23 Project No.: 53483.001 Project: Russell City Energy Center Location: B-105 13.5' Date: 6-26-01 CONSOLIDATION TEST REPORT ASTM D 2435 Soil Mechanics Lab	Stiff, mottled brown sandy CLAY. Class: CL Remarks:
Fig. No. _____	

CONSOLIDATION TEST REPORT ASTM D 2435




Coeffs. of Consolidation (sq. ft./day) & Secondary Consolidation											
No.	Load	Cv	Cα	No.	Load	Cv	Cα	No.	Load	Cv	Cα

Natural Saturation	Natural Moisture	Dry Dens. (pcf)	LL	PI	Sp.Gr.	Precons. (ksf)	Cc	e ₀
89.5 %	23.4 %	98.8			2.700	1.54	0.17	0.7058

TEST RESULTS	MATERIAL DESCRIPTION
<p>Compression Index = 0.17</p> <p>Project No.: 53483.001 Project: Russell City Energy Center Location: B-105 25'</p> <p>Date: 6-26-01</p> <p style="text-align: center;">CONSOLIDATION TEST REPORT ASTM D 2435</p> <p style="text-align: center; font-size: 1.2em;">Soil Mechanics Lab</p>	<p>Mottled brown sandy CLAY w/caliche incl's'n.</p> <p>Class: CL</p> <p>Remarks:</p> <p style="text-align: right;">Fig. No. _____</p>

CONSOLIDATION TEST REPORT ASTM D 2435




Coeffs. of Consolidation (sq. ft./day) & Secondary Consolidation											
No.	Load	Cv	Cα	No.	Load	Cv	Cα	No.	Load	Cv	Cα

Natural Saturation	Natural Moisture	Dry Dens. (pcf)	LL	PI	Sp.Gr.	Precons. (ksf)	Cc	e ₀
91.0 %	22.0 %	102.0			2.700	9.98	0.23	0.6527

TEST RESULTS	MATERIAL DESCRIPTION
Compression Index = 0.23 Project No.: 53483.001 Project: Russell City Energy Center Location: B-105 45' Date: 6-26-01 CONSOLIDATION TEST REPORT ASTM D 2435 Soil Mechanics Lab	Olive gray silty CLAY. Class: CL Remarks:
Fig. No. _____	

CONSOLIDATION TEST REPORT ASTM D 2435




Coeffs. of Consolidation (sq. ft./day) & Secondary Consolidation											
No.	Load	Cv	Cα	No.	Load	Cv	Cα	No.	Load	Cv	Cα

Natural Saturation	Natural Moisture	Dry Dens. (pcf)	LL	PI	Sp.Gr.	Precons. (ksf)	C _c	e ₀
93.6 %	24.8 %	98.2			2.700	13.06	0.25	0.7157

TEST RESULTS	MATERIAL DESCRIPTION
Compression Index = 0.25	Olive gray silty CLAY
Project No.: 53483,001 Project: Russell City Energy Center Location: B-105 75.0'	Class: CL
Date: 6-26-01	Remarks:
CONSOLIDATION TEST REPORT ASTM D 2435 Soil Mechanics Lab	Fig. No. _____

CONSOLIDATION TEST REPORT ASTM D 2435




Coeffs. of Consolidation (sq. ft./day) & Secondary Consolidation											
No.	Load	Cv	Cα	No.	Load	Cv	Cα	No.	Load	Cv	Cα

Natural Saturation	Natural Moisture	Dry Dens. (pcf)	LL	PI	Sp. Gr.	Precons. (ksf)	Cc	eo
101.9 %	26.3 %	99.3			2.700	1.09	0.13	0.6968

TEST RESULTS	MATERIAL DESCRIPTION
Compression Index = 0.13 Project No.: 53483.001 Project: Russell City Energy Center Location: B-107 6' Date: 6-26-01	Gray to v.dk.gray sandy CLAY. Class: CL-CH Remarks:
CONSOLIDATION TEST REPORT ASTM D 2435 Soil Mechanics Lab	Fig. No. _____

CONSOLIDATION TEST REPORT ASTM D 2435




Coeffs. of Consolidation (sq. ft./day) & Secondary Consolidation											
No.	Load	Cv	Cα	No.	Load	Cv	Cα	No.	Load	Cv	Cα

Natural Saturation	Natural Moisture	Dry Dens. (pcf)	LL	PI	Sp.Gr.	Precons. (ksf)	Cc	eo
105.2 %	25.2 %	102.3			2.700	1.79	0.12	0.6470

TEST RESULTS	MATERIAL DESCRIPTION
Compression Index = 0.12	Olive gr/brn.silty CLAY
Project No.: 53483.001 Project: Russell City Energy Center Location: B-107 14.5'	Class: CL
Date: 6-26-01	Remarks:
CONSOLIDATION TEST REPORT ASTM D 2435	Fig. No. _____
Soil Mechanics Lab	

CONSOLIDATION TEST REPORT ASTM D 2435




Coeffs. of Consolidation (sq. ft./day) & Secondary Consolidation											
No.	Load	Cv	Cα	No.	Load	Cv	Cα	No.	Load	Cv	Cα

Natural Saturation	Natural Moisture	Dry Dens. (pcf)	LL	PI	Sp.Gr.	Precons. (ksf)	C _c	e ₀
88.4 %	25.0 %	95.6			2.700	2.44	0.18	0.7632

TEST RESULTS	MATERIAL DESCRIPTION
Compression Index = 0.18 Project No.: 53483.001 Project: Russell City Energy Center Location: B-109 8.0' Date: 6-26-01 CONSOLIDATION TEST REPORT ASTM D 2435 Soil Mechanics Lab	Dark gray FAT CLAY. Class: CH Remarks: Fig. No. _____

CONSOLIDATION TEST REPORT ASTM D 2435




Coeffs. of Consolidation (sq. ft./day) & Secondary Consolidation											
No.	Load	Cv	Cα	No.	Load	Cv	Cα	No.	Load	Cv	Cα

Natural Saturation	Natural Moisture	Dry Dens. (pcf)	LL	PI	Sp.Gr.	Precons. (ksf)	Cc	e ₀
90.0 %	20.7 %	104.0			2.700	3.51	0.10	0.6214

TEST RESULTS	MATERIAL DESCRIPTION:
Compression Index = 0.10	Mottled, olive gray/brn. sandy CLAY.*
Project No.: 53483.001	Class: CL
Project: Russell City Energy Center	Remarks:
Location: B-109 26.0'	*Test on bott. clay portion.
Date: 6-26-01	
CONSOLIDATION TEST REPORT ASTM D 2435	
Soil Mechanics Lab	Fig. No. _____

CONSOLIDATION TEST REPORT ASTM D 2435



Coeffs. of Consolidation (sq. ft./day) & Secondary Consolidation											
No.	Load	Cv	C α	No.	Load	Cv	C α	No.	Load	Cv	C α

Natural Saturation	Natural Moisture	Dry Dens. (pcf)	LL	PI	Sp. Gr.	Precons. (ksf)	C c	e o
96.1 %	24.7 %	99.5			2.700	4.00	0.12	0.6936

TEST RESULTS	MATERIAL DESCRIPTION
Compression Index = 0.12	Olive gray silty CLAY.
Project No.: 53483.001 Project: Russell City Energy Center Location: B-109 49.5'	Class: CL
Date: 6-26-01	Remarks:
CONSOLIDATION TEST REPORT ASTM D 2435	Fig. No. _____
Soil Mechanics Lab	

ERCO Analytical, Inc.

3942-A Valley Avenue, Pleasanton, CA 94566-4715 (925) 462-2771 Fax (925) 462-2775


FINAL RESULTS

Client: Soil Mechanics Lab
 Client's Project No.: 53483.001
 Client's Project Name: Russel City Energy Center
 Authorization: Transmittal

Date Sampled: Not Indicated
 Date Received: 25-Jun-2001
 Date of Report: 6-Jul-2001
 Matrix: Soil

Job/Sample No.	Sample I.D.	Redox (mV)	pH	Conductivity (umhos/cm)*	Resistivity (100% Saturation) (ohms-cm)	Sulfide (mg/kg)*	Chloride (mg/kg)*	Sulfate (mg/kg)*
0106176-001	B-103 @ 3-4'	-	8.3	-	-	-	1,500	510
0106176-002	B-104 @ 4.5-5.5'	-	8.0	-	-	-	660	180
0106176-003	B-105 @ 1-1.5'	-	8.0	-	-	-	120	29
0106176-004	B-107 @ 2.5-3'	-	8.6	-	-	-	200	83
0106176-005	B-109 @ 1-1.5'	-	8.4	-	-	-	N.D.	68

Method:	ASTM D1498	ASTM D4972	ASTM D1125M	ASTM G57	ASTM D4658M	ASTM D4327	ASTM D4327
Detection Limit:	-	-	10	-	50	15	15
Date Analyzed:	-	2-Jul-2001	-	-	-	3-Jul-2001	3-Jul-2001


 Cheryl McMillen
 Laboratory Director

* Results Reported on "As Received" Basis
 N.D. - None Detected