

**CALIFORNIA ENERGY COMMISSION**  
**REPORT OF CONVERSATION Page 1 of 1**



**Energy Facilities Siting and  
Environmental Protection  
Division**

**FILE: 06-AFC-10**

**PROJECT TITLE: Starwood Midway Project**

<input checked="" type="checkbox"/> Telephone		<input type="checkbox"/> Meeting Location:	
<b>NAME:</b> Che McFarlin		<b>DATE:</b> 09/17/2007	<b>TIME:</b> 10:00am
<b>WITH:</b> JJ Fair with Starwood Power –Midway LLC (Applicant)			
<b>SUBJECT:</b> Size of propane tank in adjacent fuel storage area.			

**COMMENTS:** The applicant stated that the propane tank in question has a capacity of 250 gallons. This information was necessary to inform the risk assessment of a fire at the diesel fuel and propane storage area to the proposed Starwood Power Project.

**DOCKET**  
**06-AFC-10**  
**DATE** SEP 17 2007  
**RECD.** SEP 17 2007

<b>cc:</b>	<b>Signed:</b>
	<b>Name: Che McFarlin, Project Manager CEC</b>