




500 Capitol Mall, Suite 1600
Sacramento, California 95814
main 916.447.0700
fax 916.447.4781
www.stoel.com

December 20, 2011

MELISSA A. FOSTER
Direct (916) 319-4673
mafooster@stoel.com

VIA EMAIL

Mr. Eric Solorio, Siting Project Manager
California Energy Commission
1516 Ninth Street
Sacramento, CA 95814



**Re: Pio Pico Energy Center Project (11-AFC-01)
San Diego Air Pollution Control District's Publication of the Preliminary
Determination of Compliance**

Dear Mr. Solorio:

On this date, the San Diego Air Pollution Control District ("District") published the District's Preliminary Determination of Compliance ("PDOC") for Applicant Pio Pico Energy Center LLC's proposed development of the Pio Pico Energy Center Project. Applicant herein requests docketing of the enclosed PDOC and related public notice. This document will be served on the parties to this proceeding via email as the document is well within the file size limitations of most email service providers.

If you have any questions regarding the filing of this document, please contact me directly. Questions related to the PDOC should be directed to the District.

Respectfully submitted,

Melissa A. Foster

MAF:jmw

Enclosure

cc: Proof of Service List



Air Pollution Control Board

Greg Cox	District 1
Dianne Jacob	District 2
Pam Slater-Price	District 3
Ron Roberts	District 4
Bill Horn	District 5

December 16, 2016

ERIC SOLORIO
PROJECT MANAGER
CALIFORNIA ENERGY COMMISSION
1516 NINTH STREET
SACRAMENTO CA 95814

Dear Mr. Solorio:

Please find enclosed for your review and comment the District's Preliminary Determination of Compliance for Pio Pico Energy Center LLC's proposed development of the Pio Pico Energy Center (District Application No. APCD2010-APP-001251), an approximately 300 megawatt electrical generating facility consisting of three simple-cycle natural-gas-fired combustion turbine generators, to be located at 7363 Calzada de la Fuente, Otay Mesa, CA 92154. Also enclosed is a copy of the public notice that will be published on December 20, 2011.

The District performed an evaluation of the air pollution impacts of this proposal and the equipment is expected to operate in compliance with all applicable District Rules and Regulations and all applicable federal requirements that the District is authorized to implement. The proposed permit incorporates conditions necessary to ensure compliance with all District requirements and all federal and state requirements the District is authorized to implement.

Please direct your written comments concerning the District's proposed action to the attention of Steven Moore, San Diego Air Pollution Control District, 10124 Old Grove Road, San Diego, CA 92131. Should you have any questions regarding this matter, please contact Steven Moore at (858) 586-2750.

Sincerely,

TOM WEEKS
Chief of Engineering

ID#: APCD-2010-SITE-00471

FOR YOUR INFORMATION

The Following Notice was Published by the District

NOTICE OF PRELIMINARY DECISION TO APPROVE A SOURCE OF AIR POLLUTION BY THE SAN DIEGO AIR POLLUTION CONTROL DISTRICT

The San Diego County Air Pollution Control District hereby gives notice that in accordance with Rule 20.3 of the District's Rules and Regulations, the Air Pollution Control Officer has made a preliminary decision to approve the Pio Pico Energy Center (District Application No. APCD2010-APP-001251), an approximately 300 megawatt electrical generating facility consisting of three simple-cycle natural-gas-fired combustion turbine generators, to be located at 7363 Calzada de la Fuente, Otay Mesa, CA 92154.

The District performed an evaluation of the air pollution impacts of this proposal and the equipment is expected to operate in compliance with all applicable District Rules and Regulations and all applicable federal requirements that the District is authorized to implement. The proposed permit incorporates conditions necessary to ensure compliance with all District requirements and all federal and state requirements the District is authorized to implement.

The proposed permit conditions would allow the new equipment to potentially emit a maximum of 70.4 tons per year of oxides of nitrogen, 96.4 tons per year of carbon monoxide, 19.4 tons per year of volatile organic compounds, 35.8 tons per year of particulate matter less than or equal to 10 microns in diameter, and 12.4 tons per year of oxides of sulfur.

The District is seeking comments on this proposed permit action. Written comments concerning the District's proposed action may be submitted for a period of 30 days, commencing on December 20, 2011, and ending on January 18, 2012. Please direct your comments to the attention of Steven Moore, Air Pollution Control District, 10124 Old Grove Road, San Diego, CA 92131. Documents relating to the proposed action are available for public review at this address.

Should you have any questions regarding this notice or wish to make an appointment to review documents related to this action, please contact Steven Moore at (858) 586-2750.

.....

SBM:jlm
12/19/11

**PRELIMINARY
DETERMINATION OF COMPLIANCE**

PIO PICO ENERGY CENTER

SAN DIEGO AIR POLLUTION CONTROL DISTRICT

Application Number APCD2010-APP-001251

December 16, 2011

10/10/1919

10/10/1919

Project Engineer Camqui Nguyen

Senior Engineer: Steven Moore

Application Numbers: APCD201-APP-001251

Site ID Number: APCD2010-SITE-00471

Fee Schedule: 20F

BEC: New

APPLICATION INFORMATION

Owner / Operator: Pio Pico Energy Center, LLC

Mailing Address: PO Box 95592
South Jordan, UT 84095

Equipment Address: 7363 Calzada de la Fuente
Otay Mesa, CA 92154

Contact: Gary Chandler
Company: Pio Pico Energy Center LLC
Position: President
Phone Number: (801) 253-1278
Fax Number:

TABLE OF CONTENTS

I. PROJECT DESCRIPTION.....	1
II. EQUIPMENT DESCRIPTION.....	2
III. PROCESS DESCRIPTION.....	3
IV. EMISSION ESTIMATES.....	5
Combustion Turbine Generator Emissions—Standard operations.....	5
Maximum Hourly Emissions.....	5
Cooling Tower Emissions.....	9
Project Emissions—Standard operations.....	10
Combustion Turbine Generator Emissions—Commissioning period.....	11
Project Emissions—Commissioning period.....	12
V. RULES ANALYSIS.....	13
District and Federal NSR and PSD Regulations.....	13
Rule 20.1(c)(35) – Major Stationary Source.....	13
Rule 20.1(c)(58) – Prevention of Significant Deterioration (PSD) Stationary Source and 40 CFR 52.21.....	13
Rule 20.3(d)(1)- Best Available Control Technology(BACT)/Lowest Achievable Emission Rate(LAER).....	15
Rule 20.3(d)(2) – Air Quality Impact Analysis (AQIA).....	22
Rule 20.3 (d)(3), (4)-Prevention of Significant Deterioration (PSD).....	23
Rule 20.3(d)(4) – Public Notice and Comment.....	23
Rule 20.3(d)(5)-Emission Offsets.....	24
Rule 20.3(e)(1) – Compliance Certification.....	24
Rule 20.3(e)(2) – Alternative Siting and Alternatives Analysis.....	25
Rule 20.5 – Power Plants.....	25
District Prohibitory Rules.....	25
Rule 50 – Visible Emissions.....	25
Rule 51 – Nuisance.....	25
Rule 53 – Specific Air Contaminants.....	25
Rule 68 –Oxides of Nitrogen from Fuel Burning Equipment.....	27
Rule 69.3-Stationary Gas Turbines – Reasonably Available Control Technology.....	27
Rule 69.3.1 – Stationary Gas Turbines – Best Available Retrofit Control Technology.....	27
Rule 1200 – Toxic Air Contaminants.....	28
Regulation XIV – Title V Operating Permits.....	29
State Regulations Implemented by the District.....	29
National Emissions Standards for Hazardous Air Pollutants (NESHAPS).....	29
New Source Performance Standards (NSPS).....	30
40 CFR Part 60- Subpart KKKK- National Standards of Performance for New Stationary Combustion Turbines.....	30
Acid Rain.....	32
40CFR Part 72- Subpart A – Acid Rain Program.....	32
40CFR Part 72- Subpart C – Acid Rain Permit Applications.....	33
40CFR Part 73- Sulfur Dioxide Allowance System.....	33
40CFR Part 75 – Continuous Emission Monitoring.....	33
VI. ADDITIONAL ISSUES.....	34

Particulate Emission Relating to the Use of Reclaimed Water for Evaporative Cooling...	34
Commissioning Period.....	34
VII. CONCLUSIONS AND RECOMMENDATIONS.....	36

APPENDICES

- Appendix A – Approval of Air Quality Impact Analysis
- Appendix B – Approval of Health Risk Assessment
- Appendix C – Proposed Permit Conditions
- Appendix D – Emission Reduction Credits

I. PROJECT DESCRIPTION

Pio Pico Energy Center LLC (Applicant) proposes to develop the Pio Pico Energy Center (PPEC). This project is a simple-cycle electrical generating facility with a total nominal base load net power output of 300 MW. The PPEC will utilize three GE LMS100 intercooled natural gas fired combustion turbine generators (CTGs), each equipped with water injection, a selective catalytic reduction (SCR) system and an oxidation catalyst system. The nominal net power output is 100 megawatts (MW) with a corresponding heat input of 903 million British thermal units per hour (MMBtu/hr) per turbine (at 63 °F ambient temperature and based on the higher heating value of natural gas fuel). The combustion turbines are also equipped with evaporative coolers that can be used to cool the inlet air to each turbine to increase power during periods of high ambient temperature. Each CTG is followed by a selective catalytic reduction (SCR) system to reduce oxides of nitrogen (NO_x) emissions and an oxidation catalyst to control carbon monoxide (CO) and volatile organic compound (VOC) emissions.

The PPEC is subject to the approval of the California Energy Commission (CEC) because the proposed power plant has a nominal rating greater than 50 MW. The Applicant filed an application for certification (AFC) with the CEC in February 2011 (11-AFC-01). The San Diego County Air Pollution Control District (District) is considered a responsible agency for this approval and is required to submit a Preliminary Determination of Compliance (PDOC) and a Final Determination of Compliance (FDOC) to the CEC. Pursuant to District Rule 20.5, the PDOC review is functionally equivalent to an Authority to Construct review.

The PPEC is proposed to be located on an unincorporated industrial area in Otay Mesa in San Diego County. The project location is on the southeast corner of the Alta Road and Calzada de la Fuente intersection, west of the existing Otay Mesa Generating Project.

The project will be fueled by natural gas, which will be supplied by the San Diego Gas and Electric (SDG&E) Company. No provisions for use of an alternative fuel in the event of a curtailment of the natural gas supply are proposed by the Applicant.

II. EQUIPMENT DESCRIPTION

The Applicant has proposed to construct and operate the following equipment at this facility under Application No. APCD2010-APP-001251:

Three nominal 100 MW natural-gas fired simple-cycle, intercooled GE LMS100 combustion turbine generators, serial number to be determined, each equipped with an evaporative cooler for the inlet air, a compressor intercooler utilizing a common partial dry cooling system, a continuous emission monitoring system for NO_x, CO, and fuel flow, water injection, a selective catalytic reduction system, and an oxidation catalyst.

III. PROCESS DESCRIPTION

The PPEC consists of three CTGs. Each CTG consists of a stationary combustion turbine generator and associated auxiliary equipment. Thermal energy produced in the CTG through combustion of natural gas is converted to mechanical energy to drive the combustion turbine compressor and electric generator. Each CTG provides a nominal 100 MW of electricity with the combustion turbine at full load.

The chosen simple-cycle CTG incorporates a compressor intercooler and increased firing temperature to produce power at higher efficiency than other simple-cycle CTGs. Filtered and cooled air drawn into the combustion turbine is compressed and cooled, then compressed to higher pressure before being combusted in the turbine combustor. Water is injected into the combustor to temper the combustion temperature and to reduce thermal NO_x production.

The one-hour averaged NO_x emission concentration of the combustion gases exiting the turbine is controlled to 2.5 parts per million by volume on a dry basis (ppmvd) and corrected to 15 percent oxygen (O₂) by a combination of the water injection in the CTG and the SCR system. In the SCR, ammonia will be injected into the CTG exhaust stream via nozzles located upstream of the catalyst module. Ammonia slip, or the concentration of unreacted ammonia in the exhaust stack, is limited to 5.0 ppmvd averaged over one hour. The CTG is also equipped with an oxidation catalyst to control CO emissions leaving the exhaust stack to 4.0 ppmvd and VOC emissions to 2.0 ppmvd averaged over one hour. Exhaust from each CTG will be discharged from individual 14.5-foot diameter stack proposed to be 100-foot tall.

A partial dry-cooling system (PDCS), which is a closed-looped two-stage cooling system is used for the plant. In this system, heat rejected from the turbine compressor and the lube oil system is cooled using ambient air in a dry-cooling system, followed by a closed-loop evaporative fluid cooler for additional cooling. Recycled water supplied by the Otay Water District will be used for cooling system makeup, CTG water injection, and CTG inlet air evaporative cooler makeup. Makeup water for the cooling water system will be stored in a 750,000-gallon raw water storage tank. This raw water will be treated with water-conditioning chemicals to minimize corrosion,

bio-fouling, and formation of mineral scale. Demineralized water used for CTG water injection will be recycled water that is filtered, demineralized and stored in a 240,000- gallon tank.

Each CTG is equipped with a continuous emission monitoring systems (CEMS) to sample, analyze, and record the natural gas fuel flow rate, NO_x and CO concentration levels, and percentage of O₂ in the exhaust gas from the exhaust stack. The data will be transmitted to a data acquisition and handling system (DAHS) that will store the data and generate emission reports. The DAHS will also include alarms that will send signals to the plant distributed control system (DCS) when emission limits are approached or exceeded.

The PPEC will operate under a 20-year Power Purchase Agreement (PPA) with SDG&E under the Request for Offer (RFO) authorized by California Public Utilities Commission (CPUC). To meet the objectives of the RFO, the PPEC will be capable of operations at a 46% capacity factor and at greater than 98% availability.

The basic operational modes primarily affecting emissions are startups, shutdowns, and normal operations. The Applicant has provided CTG performance data and emission data based on vendor guarantees for operations under different loads and different ambient temperatures. The expected emissions used in various aspects of the evaluation are presented in Tables 1a and 1b.

Startup is defined as the thirty-minute time period starting when the fuel flow begins. Shutdown is defined as the eleven-minute period preceding the moment at which fuel flow ceases. Emissions during startups and shutdown are significantly higher than during steady state operation. The Applicant estimates that there will be up to 500 typical startups per turbine per year and up to 500 typical shutdowns per turbine per year. Maximum annual emissions are calculated based on 500 hours with a startup, 500 hours with a shutdown, and 3,335 hours per year at full-load operation under average conditions for all three CTGs.

IV. EMISSION ESTIMATES

COMBUSTION TURBINE GENERATOR EMISSIONS—STANDARD OPERATIONS

MAXIMUM HOURLY EMISSIONS

Project emissions of NO_x, CO, sulfur oxides (SO_x), VOCs, particulate matter less than or equal to 10 microns in diameter (PM₁₀), and particulate matter less than or equal to 2.5 microns in diameter (PM_{2.5}) were estimated based on data supplied by the turbine manufacturer and emission limits in the PDOC permit conditions. The startup and shutdown, emission rates were provided by the turbine manufacturer. For normal operations, emission rates for NO_x, CO, and VOCs are calculated based on emission concentration limits (in ppmvd at 15% O₂) in the PDOC permit conditions and exhaust flow rates in dry standard cubic feet per hour (dscfh) at an average ambient temperature of 63°F:

Emissions, lbs/hr = (concentration, ppmvd) x 10⁻⁶ x (exhaust flow rate, dscfh) x (molecular weight/standard molar volume).

Operation at the average ambient temperature of 63 °F provides the highest emissions among the 6 turbine operating scenarios considered. The PDOC conditions limit peak hourly and annual emissions based on this operating scenario.

Maximum hourly emissions of SO_x are calculated based on the fuel heat input in MMBtu/hr, and a SO_x emission factor of 0.0021 lbs/MMBtu, which was derived from the maximum allowable sulfur content of 0.75 grains per 100 standard cubic feet based on the California Public Utility Commission (CPUC) standard for pipeline natural gas. Emissions of PM₁₀ are calculated based on vendor supplied guaranteed emission rates. Table 1a presents the hourly emission rates in pounds per hour (lbs/hr) for all five criteria pollutants at average ambient temperature (63 °F). The PM_{2.5} emission rates are identical to PM₁₀ emission rates since all particulate matter is considered to be PM_{2.5}.

Table 1a - Maximum Single Turbine Emission Rates During Normal Operation		
Pollutant	Concentration, ppmvd @15%O₂	Emission Rate at Average Peak Ambient Temperature, lb/hr
NO _x	2.5 (1- hour average)	8.18
CO	4.0 (1-hour average)	7.97
VOCs	2.0 (1-hour average)	2.28
PM ₁₀	N/A	5.5
PM _{2.5}	N/A	5.5
SO _x	N/A	1.9

During a CTG startup hour, there are typically approximately 30 minutes of emission rates higher than emissions during normal operation. Therefore, typical hourly emission rates during startup are based on 30 minutes of high emission levels followed by 30 minutes of normal operation emission levels. During a typical CTG shutdown hour, there are approximately 49 minutes of normal operation followed by 11 minutes of higher emission levels. Therefore, typical hourly emission rates during shut down are based on 49 minutes of normal operation emission levels followed by 11 minutes of higher emission levels. For any hour when both a typical startup and a shutdown occur, there would be 30 minutes of startup emissions, 19 minutes of normal emissions and 11 minutes of shutdown emissions. Normal operation emissions were assumed to correspond to those at average ambient temperature in calculating the hourly emission rates.

Table 1b presents the maximum emission rates for each turbine during startup and shutdown in pounds per hour. The maximum emission rates of PM₁₀ and PM_{2.5} are not affected during startup and shutdown and the emission limit for normal operations remains in effect for these periods. The maximum emission rate of SO_x is reduced because the turbine operates at low loads (and low heat input) during startups and shutdowns.

Table 1b –Maximum Single Turbine Emission Rates During Startup and Shutdown			
Pollutants	Startup Emissions, lbs/hr	Shutdown Emissions, lbs/hr	Startup and Shutdown, lbs/hr
NOx	26.63	12.68	31.13
CO	21.84	53.51	67.38
VOCs	5.81	4.86	8.39
PM10	5.5	5.5	5.5
PM2.5	5.5	5.5	5.5
SOx	<1.9	<1.9	<1.9

Maximum Daily Emissions

Maximum daily emissions from each combustion turbine are calculated based on the assumption that each turbine operates up to 24 hours per day, of which 4 hours include a startup, 4 hours include a shutdown, and 16 hours for maximum normal operation at peak average ambient temperature, as follows:

$$\text{Daily emissions} = (\text{startup emissions, lbs/hr}) \times (4 \text{ hours/day}) + (\text{shutdown emissions, lbs/hr}) \times (4 \text{ hours/day}) + (\text{normal operation emissions, lbs/day}) \times (16 \text{ hours /day})$$

Table 1c presents estimated maximum daily emissions from the combustion turbines in pounds per day (lbs/day).

Table 1c – Expected Maximum Turbine Daily Emissions		
Pollutants	Emissions from Each Turbine lbs/day	Emissions from Three Turbines lbs/day
NO _x	288.12	864.36
CO	428.92	1286.76
VOCs	79.16	237.48
PM ₁₀	132	396
PM _{2.5}	132	396
SO _x	45.6	136.8

Maximum Annual Emissions

Maximum annual emissions for the combustion turbines are estimated based on the assumption that each turbine operates up to 4335 hours per year, of which 500 hours are with a startup, 500 hours are with a shutdown, and 3335 hours for maximum normal operation at average ambient temperature, as follows:

$$\text{Annual emissions} = (\text{startup emissions, lbs/hr}) \times (500 \text{ hours/year}) + (\text{shutdown emissions, lbs/hr}) \times (500 \text{ hours/year}) + (\text{normal operation emissions, lbs/day}) \times (3335 \text{ hours /years})$$

Table 1d presents estimated maximum turbine annual emissions in tons per year (tons/yr).

Table 1d – Maximum Turbine Annual Emissions		
Pollutants	Emissions from Each Turbine, tons/yr	Emissions from Three Turbines, tons/yr
NO _x	23.47	70.41
CO	32.13	96.39
VOCs	6.47	19.41
PM ₁₀	11.92	35.76
PM _{2.5}	11.92	35.76
SO _x	4.12	12.36

Note that the annual SO_x emissions are based on the PUC limit for sulfur content of natural gas. Historically, the annual average sulfur content in San Diego natural gas has been significantly less.

COOLING TOWER EMISSIONS

The cooling tower is part of the plant partial dry-cooling system (PDCS) installed to remove the plant waste heat. Water droplets from the cooling tower discharge are a source of PM₁₀ emissions. For the PPEC, a cooling tower consisting of 12 cells is proposed. The tower will circulate a maximum total of 23,520 gallons per minute or 11.755×10^6 lbs/hour of water. The maximum total dissolved solids (TDS) level is 5,600 ppm, and the guaranteed drift rate is 0.001%. PM₁₀ emission rates from the cooling tower are:

$$\begin{aligned}
 \text{PM}_{10} \text{ (lbs/hour)} &= (\text{TDS concentration}) \times (\text{drift loss of circulating water}) \times (\text{lbs water/hour}) \\
 &= (5,600 \times 10^{-6}) \times (0.00001) \times (11.755 \times 10^6) \\
 &= 0.658 \text{ lbs/hour}
 \end{aligned}$$

$$\begin{aligned}
 \text{PM}_{10} \text{ (lbs/day)} &= 0.658 \text{ lbs/day} \times 24 \text{ hours/day} \\
 &= 15.799 \text{ lbs/day}
 \end{aligned}$$

$$\begin{aligned}
 \text{PM}_{10} \text{ (tons/year)} &= 0.658 \text{ lbs/hour} \times 4335 \text{ hours/year} \times (1 \text{ ton}/2000 \text{ lbs}) \\
 &= 1.426 \text{ tons/year}
 \end{aligned}$$

PROJECT EMISSIONS—STANDARD OPERATIONS

Standard operations are those operations occurring after the commissioning period for a turbine (see below). Total emissions from the project include emission from three combustion turbines and emissions from the cooling tower. Table 2a and 2b present the estimated maximum project total daily and annual emissions in pounds per day and tons per year, respectively.

Table 2a – Maximum Project Total Daily Emissions

Pollutant	Turbines Total Daily Emissions, lbs/day	Cooling Tower Daily Emissions, lbs/day	Project Total Daily Emissions, lbs/day
NOx	864.36		864.36
CO	1286.76		1286.76
VOCs	237.48		237.48
SOx	136.8		136.8
PM10	396	15.80	411.80
PM2.5	396	15.80	411.80

Table 2b – Maximum Project Total Annual Emissions

Pollutant	Turbines Total Annual Emissions, tons/yr	Cooling Tower Annual Emissions, tons/yr	Project Total Annual Emissions, tons/yr
NOx	70.41		70.41
CO	96.39		96.39
VOCs	19.41		19.41
SOx	12.36		12.36
PM10	35.76	1.43	37.19
PM2.5	35.76	1.43	37.19

Toxic air contaminant emissions, or noncriteria pollutant emissions, are presented in the Toxic Health Risk Assessment Section in Appendix B.

COMBUSTION TURBINE GENERATOR EMISSIONS—COMMISSIONING PERIOD

Following construction of the power plant and prior to full commercial operation, the combustion turbine generators, emission control equipment, and other equipment will be tested and tuned. During this commissioning period, because the CTG burners may not yet be tuned for optimal emissions and because the post combustion control equipment will not yet be in full operation, emissions from the plant will be higher than standard operating emissions. Each turbine is expected to operate 112 hours during this commissioning period, which includes startups and shutdowns, hours of operation at different load levels, and operation with and without emission control equipment. Commissioning emission data provided by the turbine vendor consist of different emission scenarios corresponding to different phases of the commissioning period. Table 3a presents the expected commissioning maximum hourly emission rates.

Table 3a –Maximum Turbine Hourly Emissions During Commissioning		
Pollutants	Single Turbine Emissions, lbs/hr	Combined Turbine Emissions, lbs/hr
NOx	50	150
CO	75	225
VOCs	5	15
SOx	0.6	1.8
PM10	5.5	16.5
PM2.5	5.5	16.5

For a single combustion turbine, expected maximum daily emissions during commissioning are based on the peak emission day for each pollutant as forecast from the projected commissioning schedule. Table 3b presents the maximum daily commissioning emissions. The entire commissioning period may take up to 112 hours for each turbine to allow time for reviewing test and tuning information and making operational adjustments to the combustion turbines and associated plant equipment.

Table 3b – Maximum Daily Emissions During Commissioning		
Pollutants	Single Turbine Emissions, lbs/day	Combined Turbine Emissions, lbs/day
NO _x	1200	3600
CO	1800	5400
VOCs	120	360
SO _x	14.4	43.2
PM ₁₀	132	396
PM _{2.5}	132	396

Total commissioning emissions are based on turbine vendor projected emission data for the entire commissioning period. Table 3c presents total commissioning emissions.

Table 3c – Total Annual Turbine Commissioning Emissions		
Pollutants	Single Turbine Emissions, tons	Combined Turbine Emissions, tons
NO _x	1.93	5.79
CO	3.16	9.48
VOCs	0.19	0.57
SO _x	0.03	0.09
PM ₁₀	0.31	0.93
PM _{2.5}	0.31	0.93

PROJECT EMISSIONS—COMMISSIONING PERIOD

For the combustion turbines' first year of operation during which both commissioning operations and standard operations take place, PPEC will operate in such a way to ensure total combined annual emissions from all three turbines do not exceed the emissions shown in Table 1d.

V. RULES ANALYSIS

DISTRICT AND FEDERAL NSR AND PSD REGULATIONS

Rule 20.1(c)(35) – Major Stationary Source

Major stationary source means any emission unit or stationary source which has, or will have after issuance of a permit, an aggregate potential to emit one or more air contaminants, including fugitive emissions, in amounts equal to or greater than any of following emission rates:

<u>Air Pollutant</u>	<u>Emission Rates (tons/yr)</u>
PM10	100
NOx	50
VOCs	50
SOx	100
CO	100
Lead (Pb)	100

Major source status is only relevant for pollutants for which the District does not attain an applicable national air quality standard. Since the District attains all national ambient air quality standards with the exception of ozone, major source status is only relevant for NOx and VOCs, both of which are ozone precursors. Based on its potential to emit, the PPEC is a major stationary source for NOx.

Rule 20.1(c)(58) – Prevention of Significant Deterioration (PSD) Stationary Source and 40 CFR 52.21

Although the PPEC is a fossil fuel fired electrical generating plant with a heat input rating greater than 250 MMBtu/hr, it is not a steam generating plant. Therefore PSD Stationary Source status is defined by an aggregate potential to emit one or more air contaminants in amounts equal to or greater than any of the following emission rates under District rules and under federal rules except for the recently promulgated federal PSD requirements for greenhouse gases:

<u>Air Pollutant</u>	<u>Emission Rates (tons/yr)</u>
PM10	250
PM2.5	250
PM	250
NO ₂	250
VOCs	250
SO ₂	250
CO	250
Lead (Pb)	250

[Note that District Rule 20.1 does not explicitly address PM2.5 nor does it address particulate matter of all sizes (PM). However, PM2.5 is addressed as subset of PM10].

As of July 1, 2011, federal PSD requirements apply to a new stationary source that emits more than 100,000 ton per year of greenhouse gases (GHGs). PPEC's potential to emit exceeds this federal PSD stationary source threshold for GHGs. Consequently, PPEC submitted an application to EPA for a federal PSD permit in April, 2011.

The District is currently not delegated to implement federal PSD by EPA nor does it have a PSD rule that has been approved by EPA. Hence, PSD permitting for federal PSD is solely the responsibility of EPA at the current time. The District's New Source Review (NSR) rules do contain provisions for PSD that the District implements locally. The proposed project's compliance with these provisions is evaluated in the PDOC in accordance with District Rules and Regulations. It is worth noting that, although the District PSD provisions reflect many elements of federal PSD, there are some differences. In particular, the District currently has no authority in its Rules and Regulations to address greenhouse gases (GHGs).

While the District may seek federal delegation of the PSD permitting program in the future, at this time the federal PSD permit remains a separate matter under federal jurisdiction and permitting by the EPA. Thus, EPA would currently be the agency to issue a PSD permit, with no effect on the validity of the District's Final Determination of Compliance (FDOC).

**Rule 20.1(c)(16), 40 CFR §52.21, and 40 CFR Appendix S to Part 51–
Contemporaneous Emission Increase**

Contemporaneous emission increase is defined in Rule 20.1 (c)(16) as the sum of emission increases from new or modified emission units occurring at a stationary source within the calendar year in which the subject emission units is expected to “commence operation” and the preceding four calendar years, including all other emission units with complete applications under District review and which are expected to commence operation within such calendar year. The PPEC three CTGs will be the first emission units operating at this stationary source. Therefore, the Contemporaneous Emission Increase for the PPEC stationary source is the same as the project potential to emit.

**Rule 20.3(d)(1)- Best Available Control Technology(BACT)/Lowest Achievable
Emission Rate(LAER)**

Subsection 20.3(d)(1)(i) of the rule requires that Best Available Control Technology (BACT) be installed on a new or modified emission unit on a pollutant-specific basis if emissions exceed 10 lbs/day or more of PM10, NOx, VOCs, or SOx. Subsection 20.3(d)(1)(v) also requires that Lowest Achievable Emission Rate (LAER) be installed for a new emission unit which results in an emission increase which constitutes a new major source or a major modification.

LAER cannot be less stringent than BACT and is required only for air contaminants and their precursors for which the stationary source is major and for which the District is classified as non-attainment of a national ambient air quality standard. Because the District attains the National Ambient Air Quality Standards (NAAQS) for CO, SO₂, PM_{2.5} and PM₁₀, LAER does not apply to these pollutants. LAER, however, applies to NOx emissions since the PPEC constitutes a major stationary source for NOx. For the PPEC combustion turbines, BACT applies for VOCs, SOx, PM₁₀ and PM_{2.5} as a subset of PM₁₀ emissions because their emissions are more than 10 pounds per day.

In summary, based on emission estimates, LAER is triggered for NOx and, for the combustion turbines, BACT is triggered for VOCs, SOx, and PM₁₀.

Oxides of Nitrogen (NOx)—Combustion Turbines, Normal Operations

The turbine vendor has guaranteed a NOx emission level of 2.5 ppmvd at 15% oxygen with water injection for the CTG and with the SCR add-on air pollution control system to control NOx installed. The Applicant has proposed a NOx emission limit of 2.5 ppmvd averaged over one hour as BACT and LAER during normal operations.

The District consulted the EPA BACT / LAER Clearinghouse, other air district decisions and BACT Guidelines, and ARB for recent BACT/LAER determinations. A number of simple-cycle power plants of comparable size were permitted with NOx at 2.5 ppmvd, averaged over one hour. The District examined the following projects with NOx emission limits at 2.5 ppmvd at 15% oxygen:

- The Panoche Energy Center is permitted by the San Joaquin Valley Unified Air Pollution Control District with the CEC Final Approval issued on December 19, 2007 [CEC Docket No. 06-AFC-5] and has been in operation since 2009. This plant has four GE LMS100 combustion turbines similar to the ones proposed for the PPEC. This plant has been in compliance with a 2.5 ppmvd NOx limit averaged over one hour, excluding startups and shutdowns.
- The Starwood Power Project is permitted by the San Joaquin Valley Air Pollution Control District with the CEC Final Approval issued on January 16, 2008 [CEC Docket No. 06-AFC-10] and has been in operation since. This 120 MW plant consisting of two Pratt & Whitney FT8-3 SwiftPac CTGs has been in compliance with a 2.5 ppmvd NOx limit averaged over one hour, excluding startups and shutdowns.
- The Orange Grove Energy Center is permitted by the San Diego Air Pollution Control District with the CEC Final Approval issued on April 8, 2009 [CEC Docket No. 08-AFC-4] and has been in operation since 2010. This plant consisting of two 49.5 MW GE LM 6000 PC SPRINT CTGs has been able to comply with a 2.5 ppmvd NOx limit averaged over one hour, excluding startups and shutdowns.

- The Mariposa Peaker Project is permitted by the Bay Area Air Quality Management District with the CEC Final Approval issued on May 18, 2011 [CEC Docket No. 2009-AFC-3C] and is currently under construction. This 200 MW plant consisting of 4 GE LM600 PC-SPRINT CTGs is permitted with a 2.5 ppmvd NOx limit averaged over one hour, excluding startups and shutdowns.
- The CPV Sentinel, LLC project is permitted by the South Coast Air Quality Management District in 2010 with the CEC Final Approval issued on December 1, 2010 [CEC Docket No. 2007-AFC-3C], and is currently under construction. This plant consists of 8 GE LMS100 CTGs similar to the ones proposed for the PPEC. This plant is permitted with a 2.5 ppmvd NOx limit averaged over one hour, excluding startups and shutdowns.

Based on the above information, the District has determined that BACT for NOx should be 2.5 ppmvd at 15% oxygen, averaged over one hour for normal operation with exclusions for startups and shutdowns. As defined in Rule 20.1(c)(32), LAER means the most stringent emission limitation, or most effective emission control device or control technique, unless such emission limit, device or technique is not achievable. An emission limit of 2.5 ppmvd NOx at 15% oxygen averaged over one hour is considered by the District to be the current most stringent emission limit for simple-cycle combustion turbines that is achievable. Therefore, this standard also applies as LAER for NOx for such turbines.

As proposed by the Applicant, the PPEC combustion turbines will be equipped with water injection for the combustors and a SCR add-on emission control system that in combination are designed to achieve 2.5 ppmvd NOx averaged over one hour. The District is unaware of any demonstrations that alternative technologies for control of NOx such as the XONON™ catalytic combustors or EMx™ (SCONOX) catalyst system can achieve NOx emission levels lower than the combination of water injection for the combustors and SCR on large (greater than 50 MW) natural-gas-fired simple-cycled combustion turbines. A continuous emission monitoring system (CEMS) and annual source testing will be used to confirm compliance with this emission limit.

Volatile Organic Compounds (VOCs)—Combustion Turbines, Normal Operations

The turbine vendor has guaranteed a VOC emission level of 2.0 ppmvd at 15% oxygen with the oxidation catalyst add-on air pollution control system, which is the only post-combustion technology currently available to control CO, VOCs, and toxic emissions. The Applicant has proposed a VOC emission limit of 2.0 ppmvd at 15% oxygen averaged over one hour as BACT for normal operations. The limit is to be achieved by use of an oxidation catalyst system.

The District consulted the EPA BACT / LAER Clearinghouse, other air district decisions and BACT Guidelines, and ARB for recent BACT/LAER determinations. The District examined the following simple-cycle combustion turbine projects with VOC emission limits of 2.0 ppmvd or less at 15% oxygen:

- The Panoche Energy Center is permitted by the San Joaquin Valley Unified Air Pollution Control District with the CEC Final Approval issued on December 19, 2007 [CEC Docket No. 06-AFC-5] and has been in operation since 2009. This plant has four GE LMS100 combustion turbines similar to the ones proposed for the PPEC. This plant has been in compliance with a 2.0 ppmvd VOC limit averaged over three hours, excluding startups and shutdowns
- The Starwood Power Project is permitted by the San Joaquin Valley Air Pollution Control District with the CEC Final Approval issued on January 16, 2008 [CEC Docket No. 06-AFC-10] and has been in operation since 2009. This 120 MW plant consisting of two Pratt & Whitney FT8-3 SwiftPac CTGs has been in compliance with a 2.0 ppmvd VOC limit averaged over three hour, excluding startups and shutdowns.
- The Orange Grove Energy Center is permitted by the San Diego Air Pollution Control District with the CEC Final Approval issued on April 8, 2009 [CEC Docket No. 08-AFC-4] and has been in operation since 2010. This plant consists of two 49.5 MW GE

LM6000 PC SRINT CTGs has been able to comply with a 2.0 ppmvd VOC limit averaged over one hour, excluding startups and shutdowns.

- The El Cajon Energy Project consisting of one 49 MW GE LM6000 CTG is permitted by the San Diego Air Pollution Control District in 2010 with VOC limit of 2.0 ppmvd at 15 percent oxygen averaged over one hour. This plant demonstrates compliance with this limit through initial compliance testing in 2010.
- The CPV Sentinel, LLC project is permitted by the South Coast Air Quality Management District in 2010 with the CEC Final Approval issued on December 1, 2010 [CEC Docket No. 2007-AFC-3C], and is currently under construction. This plant consists of 8 GE LMS100 CTGs similar to the ones proposed for the PPEC. This plant is permitted with a 2.0 ppmvd VOC limit averaged over one hour, excluding startups and shutdowns.

Based on the above information and considerations, the District has determined that BACT for the PPEC combustion turbines is a 2.0 ppmvd VOC limit, measured as methane at 15% O₂ over a one-hour averaging period for normal operation with exclusions for startups and shutdowns.

An initial source test will be used to confirm compliance with these limits. Additionally, the source test data will be used to establish a correlation between CO emissions and VOC emissions to provide an accurate indicator of continued compliance with these limits using the CEMS data for CO on a one-hour basis. Compliance will be determined based on both source test data and a surrogate relationship with CO because CEMS technology is not yet available for VOCs.

Startups and Shutdowns—Combustion Turbines, NO_x, CO, and VOCs

Startups are limited to 30 minutes and shutdowns to 11 minutes. These times are consistent with, or more stringent than the Orange Grove Energy project permitted by the San Diego Air Pollution Control District with the CEC Final Approval issued on April 8, 2009 [CEC Docket No. 08-AFC-4], and the El Cajon Energy Project permitted by the San Diego Air

Pollution Control District in 2010. The CPV Sentinel LLC project is permitted by the South Coast Air Quality Management District in 2010 with the CEC Final Approval issued on December 1, 2010 [CEC Docket No. 2007-AFC-3C]. This project consists of eight GE LMS 100 CTGs similar to the ones proposed for the PPEC and is limited to 25 minutes for startup and 10 minutes for shutdown. Since this project is still under construction, these lower time limits for startups and shutdowns are not considered achieved in practice. Also, the emission limits for startup for the CPV Sentinel LLC project is 29.54 lbs/hour, while the startup emission limit for the PPEC 26.63 lbs/hour.

Emissions during startup and shutdown are further controlled by setting mass emission limits per startup and shutdown event (excluding the commissioning period). The mass emission limits are based on manufacturer emission estimates for the expected startup or shutdown durations.

Table 5a presents the mass emissions limits during startup and shutdown

Table 5a – Emission Limits During Startup [SCR to Operate as Soon as Feasible] and Shutdown		
Pollutants	Startup Emissions, pounds per event	Shutdown Emissions pounds per event
NOx	22.54	6.00
CO	17.86	47.00
VOCs	4.67	3

An additional requirement that applies during startups and shutdowns (and all other times the combustion turbine is operating with an SCR system) is that the SCR be in full operation as soon as it reaches its minimum operating temperature to control NOx to the maximum extent feasible.

The District has determined that the above requirements represent BACT for NO_x and VOCs and LAER, for NO_x only, during startups and shutdowns of the combustion turbines.

PM₁₀ and SO_x—Combustion Turbines

From the ARB Guidance for Power Plant Siting and Best Available Control Technology, September 1999, BACT for this equipment is the use of natural gas that contains less than 1 grain of sulfur compounds per 100 standard cubic feet of natural gas. Public Utility Commission (PUC) quality natural gas sold in San Diego County is required to meet a maximum sulfur content limit of 0.75 grains of sulfur compounds per 100 standard cubic feet of natural gas. Therefore, use of PUC quality natural gas meeting this 0.75 grains limit is recommended as BACT. In actuality, the natural gas in the local gas distribution system averages well under 0.75 grains per 100 standard cubic feet of gas. The Applicant will be required to maintain documents showing the sulfur content of natural gas used. Any alternative supplies of natural gas must meet this sulfur content limit.

PM₁₀ - Cooling Tower

PM₁₀ emission from the cooling tower results from the water droplets coming from the cooling tower discharge and is controlled with the drift eliminator to limit the drift rate. The District consulted the EPA BACT/LAER Clearinghouse, other air district decisions and BACT Guidelines, and ARB for recent BACT/LAER determinations for the most current cooling tower drift rate.

- The CPV Sentinel LLC project is permitted by the South Coast Air Quality Management District in 2010 with the CEC Final Approval issued on December 1, 2010 [CEC Docket No. 2007-AFC-3C]. This project consists of eight GE LMS 100 CTGs similar to the ones proposed for the PPEC. This project cooling tower is limited to drift rate of 0.0005%. This project is still under construction.

- The Osceola Steel Co. is permitted by the Georgia Department of Natural Resources in December 2010 for a steel mill with 3 cooling towers. The cooling towers are limited to drift rate of 0.0005%. This plant has not been constructed yet.
- The Panda Sherman Power Station is permitted by the Texas Commission on Environmental Quality in February 2010 for a 600MW combined-cycle power plant. The cooling tower for this plant is limited to 0.0005% drift rate. This plant has not been constructed yet.
- The Orange Grove Energy Center is permitted by the San Diego Air Pollution Control District with the CEC Final Approval issued on April 8, 2009 [CEC Docket No. 08-AFC-4] and has been in operation since 2010. The cooling tower for this plant is limited to 0.001% drift rate.
- The El Cajon Energy Project consisting of one 49 MW CTG is permitted by the San Diego Air Pollution Control District in 2010, with a limit of 0.001% for the cooling tower drift rate.

Since the projects permitted with the lower drift rate of 0.0005% have not been in operation, this drift rate is not considered achievable in practice and is not considered BACT. Based on this information, the District has determined that the drift rate of 0.001% is BACT for PPEC cooling tower.

Rule 20.3(d)(2) – Air Quality Impact Analysis (AQIA)

This subsection of Rule 20.3 requires that a project resulting in an emission increase equal to or greater than the AQIA Thresholds shall demonstrate through an AQIA that the project will not cause or contribute to a violation of a state or national ambient air quality standard. For the PPEC, an Air Quality Impact Analysis (AQIA) was performed to determine if the proposed project by itself contributes to an exceedance of the National Ambient Air Quality Standards or the State Ambient Air Quality Standards. The modeling was done under expected worst-case hourly and annual emission rates during commissioning, startup and shutdown, and normal operations.

The analysis shows no violation of any national or state ambient air quality standard. The analysis can be reviewed in more detailed the Appendix A of this determination. The PDOC permit conditions contain hourly and annual emission limits that are applicable at all times to ensure that the project will not cause or contribute to a violation of any National Ambient Air Quality Standard or California Ambient Air Quality Standard.

Rule 20.3 (d)(3) -Prevention of Significant Deterioration (PSD)

This subsection requires that a PSD evaluation be performed for any new PSD stationary source (source that has an aggregate potential to emit of one or more air contaminants in amount equal to or greater than the PSD thresholds) and to any PSD modification (contemporaneous emission increase occurring at a modified PSD stationary source equal to or greater than the PSD modification thresholds), for those air contaminants for which the District is classified as attainment or unclassified with respect to a national ambient air quality standard. The limits on NO_x, CO, VOC emissions on the PDOC will keep the project from triggering any PSD requirements under Rule 20.3(a)(3). Since the annual limit suffices to avoid triggering the PSD threshold and NO_x, CO and VOC emissions are monitored with CEMS, no limits on hours of normal operations or startup and shutdown are necessary

Rule 20.3(d)(4) – Public Notice and Comment

For any project that is subject to the AQIA requirements of Rule 20.3(d)(2), these provisions require that the District publish a notice of the proposed action in at least one newspaper of general circulation in San Diego County as well as send notices and specified documents to the EPA and ARB. Because the project is not subject to Rule 20.3(d)(3) the additional notification requirements of Rule 20.3(d)(3)(iii) are not applicable. Notice of proposed installation of the PPEC will be published in the San Diego Daily Transcript and mailed to EPA and ARB air districts for a 30-day comment period in accordance with Rule 20.3(d)(4).

Rule 20.3(d)(4)(i) requires that the District consider all comments received. The District will consider all comments received before taking final action.

Rule 20.3(d)(5)-Emission Offsets

This provision requires that emission offsets be provided for projects that result in an emission increase of any federal nonattainment criteria pollutant or its precursors which exceed new major source or major modification thresholds. The District is a federal nonattainment area only for ozone. Therefore, offsets are potentially only required for NO_x and VOC emissions, as ozone precursors. For the PPEC, VOC annual emission is limited to below the major stationary source thresholds by the PDOC permit conditions. Therefore, offsets are only required for NO_x emissions. The emission increase of NO_x is 70.41 tons per year for this project. An offset ratio of 1.2 to 1 is required [Rule 20.3(d)(8)(i)(B)], so a total of 84.49 tons per year of NO_x emission offsets will be required. The offsets must be surrendered to the District prior to the initial startup of the equipment for which they are required [Rule 20.1(d)(5)(iii)]. Offsets may be actual emission reductions, stationary source Class A emission reduction credits (ERCs) issued under District Rules 26.0-26.10, or mobile source emission reduction credits (MERCs) issued under District Rule 27 (if approved by ARB and EPA.). The Applicant has agreed to surrender ERCs sufficient to provide all the required offsets for the project prior to the initial operation of the first turbine.

Rule 20.3(e)(1) – Compliance Certification

This rule requires that, prior to receiving an Authority to Construct (or Final Determination of Compliance), an applicant for any new or modified stationary source required to satisfy the LAER provisions of Rule 20.3(d)(1) or the major source offset requirement of Rule 20.3(d)(8) shall certify that all major sources operated by the applicant in the state are in compliance with all applicable emissions limitations and standards under the federal Clean Air Act. The applicant, Pio Pico Energy Center, LLC, does not own or operate any other major stationary sources in California. A funds managed by Energy Investors Funds Management, LLC (EIF) indirectly owns PPEC. Other funds managed by EIF also indirectly own, control, and operate two major stationary sources in the state, the Burney Forest Power and the Panoche Energy Center. The required compliance certification for all major sources in the state has been submitted to the District.

Rule 20.3(e)(2) – Alternative Siting and Alternatives Analysis

The Applicant has provided an analysis of various alternatives to the project. This analysis included a No Project alternative, alternative sites, and alternative technologies. Since all of San Diego County is currently classified as non-attainment for ozone, an alternative location within San Diego would not avoid the project being located in a non-attainment area.

Rule 20.5 – Power Plants

This rule requires that the District submit Preliminary and Final Determinations of Compliance reports to the California Energy Commission (CEC). The Final Determination of Compliance is equivalent to a District Authority to Construct. This Preliminary Determination of Compliance will be submitted to the CEC.

DISTRICT PROHIBITORY RULES

Rule 50 – Visible Emissions

This rule limits air contaminants emissions into the atmosphere of shade darker than Ringlemann 1 (20% opacity) to not more than an aggregate of three minutes in any consecutive sixty-minute period.

Based on the proposed equipment and the type of fuel to be used (natural gas), no visible emissions at or above this level are expected during operation of the power plant.

Rule 51 – Nuisance

This rule prohibits the discharge of air contaminants that cause or have a tendency to cause injury, nuisance, annoyance to people and/or the public or damage to any business or property.

No nuisance or complaints are expected from this type of equipment.

Rule 53 – Specific Air Contaminants

This rule limits emissions of sulfur compounds (calculated as SO₂) to less than or equal to 0.05% (500 ppm) by volume, on a dry basis. The rule also limits particulate matter

emissions from gaseous fuel combustion to less than or equal 0.1 grains per dry standard cubic foot of exhaust calculated at 12% CO₂.

Sulfur Compounds

The Applicant proposes to use Public Utilities Commission (PUC) quality natural gas sold in San Diego County. Because of the low sulfur content of the fuel, the plant is expected to comply with the sulfur emission requirements of Rule 53. The fuel is expected to have a sulfur content less than 0.75 grains per 100 dry standard cubic foot (gr/100 dscf).

Using an F-Factor of 8710 standard cubic feet of exhaust gas per million Btu of heat input for natural gas combustion at 0% O₂ in the exhaust, assuming all sulfur in the fuel is converted into SO₂, the concentration by volume of SO₂ in the exhaust gas is:

$$\text{SO}_2 \text{ concentration} = (0.75 \text{ grain} / 100 \text{ scf fuel}) \times (11 \text{ lb SO}_2 / 7000 \text{ grain}) \times (385 \text{ scf SO}_2 / 64 \text{ lb SO}_2) \times (1 \text{ scf fuel} / 1015 \times 10^{-6} \text{ MMBtu}) \times (1 \text{ MMBtu} / 8710 \text{ dscf of exhaust}) \times (10^6) = 0.72 \text{ ppm SO}_2 \text{ by volume.}$$

This is well below the Rule 53 limit of 500 ppm SO₂ by volume. Therefore, the project is expected to comply with this rule.

Particulates

Using an F-Factor of 198.025 standard cubic feet of exhaust per pound of natural gas combusted @ 12% CO₂, a maximum natural gas usage of 40,035 lbs /hr, and an estimated maximum particulate matter emission rate of 5.5 lbs/hr, combustion particulate at maximum load are estimated to be:

$$\text{Grain loading} = [(5.5 \text{ lbs/hr})(7,000 \text{ gr/lb})] / (198.025 \text{ scf/lb fuel})(40,035 \text{ lbs fuel/hr}) = 0.005 \text{ gr/dscf}$$

This is well below the Rule 53 emission limit of 0.1 gr/dscf. Therefore the plant is expected to comply with this rule.

Rule 68 –Oxides of Nitrogen from Fuel Burning Equipment

This rule limits NOx emissions from any natural gas fueled combustion equipment to less than 125 ppmvd calculated at 3% oxygen on a dry basis. However, this equipment is subject to the more stringent requirements of Rule 69.3 and Rule 69.3.1 and is exempt from Rule 68.

Rule 69.3-Stationary Gas Turbines – Reasonably Available Control Technology

This rule limits NOx emissions from combustion turbines fueled with natural gas greater than 0.3 MW to 42 ppmvd at 15% oxygen when fired on natural gas. Equipment is exempt from the standards during 120 minute startup and shutdown periods.

The combustion turbines for this project will be equipped with water injection for the combustors and SCR controls for NOx. Proposed permit conditions limit NOx emissions to 2.5 ppmvd during normal operations, which is far below the 42 ppmvd rule standard.

Maximum durations of startups and shutdowns (30 minutes for startup and 11 minutes for shutdown) are shorter than Rule 69.3 requirements. However, commissioning is still subject to the rule standards. The facility permit will contain conditions to limit emissions below the emissions levels specified in Rule 69.3 (excluding startups and shutdown as defined in Rule 69.3). A CEMS will monitor emissions during combustion turbine operations.

Rule 69.3.1 – Stationary Gas Turbines – Best Available Retrofit Control Technology

This rule limits NOx emissions from combustion turbines greater than 10 MW to $15 \times (E/25)$ ppmvd when operating uncontrolled and $9 \times (E/25)$ ppm at 15% oxygen when operating with add-on emission controls and averaged over a one-hour period, where E is the thermal efficiency of the unit. The rule also specifies monitoring and record keeping requirements. Startups, shutdowns, and fuel changes are defined by the rule and excluded from compliance with these limits. Equipment is exempt from the standards during 120 minute startup and shutdown periods.

The thermal efficiency for each turbine is 38.7%. Therefore the maximum allowable uncontrolled NOx concentration is 23.2 ppmvd based on a 1-hour averaging period at 15% oxygen and the maximum allowable controlled NOx concentration is 13.9 ppmvd. The

uncontrolled concentration limit would only be applicable prior to installation of the SCR system.

The combustion turbines for this project will be equipped with water injection for the combustors and SCR controls for NO_x. The PDOC permit conditions limit NO_x emissions to 2.5 ppmvd during normal operations, which is far below the 13.9 ppmvd rule standard. Maximum durations of startups and shutdowns (30 minutes for startup and 11 minutes for shutdown) are shorter than Rule 69.3.1 requirements. However, commissioning is still subject to the rule standards. The facility permit will contain conditions to limit emissions below the emissions levels specified in Rule 69.3.1 (excluding startups and shutdown as defined in Rule 69.3.1). A CEMS will monitor emissions during combustion turbine operations. A CEMS will monitor emissions during combustion turbine operations.

Rule 1200 – Toxic Air Contaminants

Rule 1200 New Source Review for Toxic Air Contaminants requires that a Health Risk Assessment (HRA) be performed if the potential to emit toxic air contaminants will increase. A detailed HRA is necessary if toxics emissions exceed District de minimis levels. Toxic Best Available Control Technology (TBACT) must be installed if the HRA shows a cancer risk greater than one in a million at a receptor where a person could be reasonably anticipated to be exposed. The cancer risk is based on a 70-year exposure for a residence and a shorter exposure time for occupational workers. Additional requirements apply if the cancer risk is expected to exceed ten in a million.

An HRA, which was reviewed by the District, was performed using EPA AP-42 emission factors and California Air Toxics Emission Factors (CATEF) for toxic air contaminant emissions from the project for normal operations. The emissions from the operation of the three combustion turbines were considered. The HRA performed shows that the incremental cancer risk is 0.094 in a million for exposed residents and 0.014 for exposed workers for 500 startups per year. The acute and chronic incremental health impacts measured by the Health Hazard Index (HHI) are also all less than 1.0 at the point of maximum impact 0.011, 0.043, and 0.11 for the chronic, 8-hour, and acute HHIs, respectively) and, therefore, meet Rule

1200 requirements. Although TBACT is not required since the maximum cancer risk is less than one in a million, the oxidation catalyst installed as BACT for CO and VOC emissions also significantly reduces toxic air contaminant emissions and would be considered TBACT for this project—if TBACT had been required. It should be noted that, although the health risk assessment is based on 4337.5 hours of operation for each turbine (4000 hours of normal operation and 500 startups and shutdowns) the annual incremental residential cancer risk would not exceed 0.2 in a million for 8760 hours of operation for each turbine nor would the chronic HHI not exceed 0.025. The health risk assessment of this project is further discussed in Appendix B of this document.

Regulation XIV – Title V Operating Permits

The Applicant will submit an application for Title V Operating Permit for this project.

STATE REGULATIONS IMPLEMENTED BY THE DISTRICT

Health and Safety Code §42301.6

This section of the state Health and Safety Code requires the District to notify parents of students at a school if a new source of air pollution is within a 1000 feet of the boundary of that school. The District has determined that the PPEC is not within 1000 feet of any school boundary.

NATIONAL EMISSIONS STANDARDS FOR HAZARDOUS AIR POLLUTANTS (NESHAPS)

The PPEC is not a major source of hazardous air pollutants (HAPs) based on the potential to emit over the 10 ton per year major source threshold for a single HAP. Estimated total emissions of all toxic air contaminants, calculated using EPA (AP-42) emission factors were about 5.41 tons per year. Therefore, equipment at the PPEC is not subject to NESHAPS applicable to major stationary sources of HAPs.

NEW SOURCE PERFORMANCE STANDARDS (NSPS)

40 CFR Part 60- Subpart KKKK- National Standards of Performance for New Stationary Combustion Turbines.

This new source performance standard requires stationary combustion turbines with a heat input equal to or greater than 10 MMBtu/hour based on the high heating value of the fuel to comply with NOx and SOx emission standards.

Sections 60.4320 and 60.4350(b)(1) require new combustion turbines firing natural gas with a rated heat input greater than 850 MMBtu/hour and using CEMS to comply with a NOx standard of 15 ppmvd at 15% O₂ averaged over each 4 operating hours, or alternatively, a standard of 0.42 pounds per megawatt hour (lb/MWh) during normal operations.

With SCR as postcombustion emission control, NOx emissions from this combustion turbine are controlled to 2.5 ppm at 15% O₂ during normal operation. Assuming NOx emission concentration during startup is 23.1 ppm at 15% O₂, NOx emission concentration during shut down is 16.8 ppm at 15% O₂, the NOx emission concentration averaged over a 4-hour period that has 4 startups (2 hours of startup), 3 shutdowns (0.6 hours of shutdown) and 1.45 hours of normal operation is:

$$\text{NOx concentration} = [23.1 \text{ ppm} \times (2 \text{ startups hours})] \times [16.8 \text{ ppm} \times (0.6 \text{ shutdowns hours})] + (2.5 \text{ ppm} \times 1.45 \text{ normal operation hours}) / (4 \text{ hours}) = 14.8 \text{ ppm}$$

Therefore, the turbine is expected to comply with the NOx emission standard of this subpart. Compliance is required through the PDOC permit conditions.

Section 60.4330 prohibits sulfur dioxide emissions from combustion turbine in excess of 0.90 lbs/MW-hour gross output or 0.060 lbs/MMBtu heat input. SO₂ emission from the combustion turbines of this project is 0.002 lbs/MMBtu.

$$\text{SO}_2 \text{ emission rates} = (1.9 \text{ lbs/hr}) \times (1 \text{ hour} / 903 \text{ MMBtu}) = 0.002 \text{ lbs/MMBtu}$$

Therefore, the turbine is in compliance with the SO₂ limit requirement.

Section 60.4335(b) requires turbines using water injection or steam injection to install, calibrate, maintain and operate a continuous emission monitoring system (CEMS) consisting of a NO_x monitor and a diluent gas (oxygen) or carbon dioxide monitor to determine the hourly NO_x emission rate in ppmvd or lb/MWh. Turbines complying with concentration limit based standards must install calibrate, maintain and operate a fuel flow meter to measure heat input. Turbines complying with output-based standards must install, calibrate, maintain and operate a watt meter to measure the gross electrical output in megawatt-hours. This combustion turbine will be equipped with a CEMS to monitor NO_x and CO emissions in parts per million and oxygen content in the exhaust gas.

Section 60.4345 requires the CEMS to be installed and certified according to Performance Specification 2 in Appendix B to this part, or according to Appendix A of part 75 of this chapter, and each fuel meter and watt meter shall be installed, calibrated, maintained and operated according to the manufacturer's instructions. The turbine operator must develop and keep on site a QA plan for all continuous monitoring equipment. The CEMS for this combustion turbine will be required to go through Relative Accuracy Test Audit (RATA) and all other required certification tests in accordance with 40 CFR Part 75 Appendix A and B. The PDOC permit requires continuous monitoring equipment meeting these requirements to be installed, calibrated, and maintained.

Section 60.4350 requires turbine operator to use data from the CEMS to identify excess emissions in accordance with specific procedures. These requirements are included in the PDOC permit conditions.

Section 60.4365 exempts the requirement to monitor total sulfur content of the fuel if it can be demonstrated through a valid purchase contract, tariff sheet or transportation contract for the fuel that total sulfur content of natural gas used is 20 grains of sulfur or less per 100 standard cubic feet. Sulfur content of natural gas fuel used in this turbine is 0.75 grains per

100 cubic feet of gas or less. Quarterly records of natural gas sulfur content are to be kept on site to satisfy this requirement.

Section 60.4375 requires submittal of reports of excess emissions and monitor downtime for all periods of unit operation, including startup, shutdown and malfunction. The PDOC permit includes a condition to satisfy these requirements. Annual source tests are not required pursuant to Subpart KKKK for combustion turbine equipment with CEMS. Since this combustion turbine is subject to a NO_x limit that is six times more stringent than the NO_x limit of this NSPS, excess emissions are not expected to occur. In addition, reports on the CEMS system are to be submitted in accordance with Rule 19.2 requirements and CEMS protocol approved by the District and excess emissions and monitoring reports are required by the FDOC permit conditions..

Section 60.4400 requires that an initial performance test and annual NO_x performance test be conducted in accordance with certain requirements. Annual source tests are not required pursuant to Subpart KKKK for combustion turbine equipment with CEMS. This combustion turbine is required to be source tested initially to demonstrate compliance with NO_x, CO, VOC, and ammonia emission standards. The source tests are to be conducted in accordance with the applicable EPA test methods and applicable requirements of 40 CFR 75 Appendix B. The PDOC permit contains conditions satisfying these requirements of Subpart KKKK.

ACID RAIN

40 CFR Part 72- Subpart A – Acid Rain Program

This part establishes general provisions and operating permit program requirements for sources and units affected under the Acid Rain program, pursuant to Title IV of the Clean Air Act. The combustion turbines of this project are affected by this Acid Rain Program as a utility unit in accordance with Section 72.6(a).

40 CFR Part 72- Subpart C – Acid Rain Permit Applications

This subpart requires any source with an affected unit to submit a complete Acid Rain permit application by the applicable deadline. Requirement for submittal of Acid Rain Program application is included in the PDOC permit conditions.

40 CFR Part 73- Sulfur Dioxide Allowance System

This part establishes the requirements and procedures for the allocation of sulfur dioxide emission allowances; the tracking, holding and transfer of allowances; the deduction of allowances for purposes of compliance and for purposes of offsetting excess emissions pursuant to Parts 72; the sale of allowances through EPA-sponsored auctions and a direct sale; the application for allowances from the Conservation and Renewable Energy Reserve; and the application for allowances for desulfurization of fuel by small diesel refineries. Requirements from this part will be included in evaluation for the Acid Rain program application required by Part 72.

40CFR Part 75 – Continuous Emission Monitoring

This part established requirements for the monitoring, recordkeeping, and reporting of SO₂, NO_x, and CO₂ emissions, volumetric flow, and opacity data from emission units under the Acid Rain Program. The regulations include general requirements for the installation, certification, operation, and maintenance of continuous emission or opacity monitoring systems, certification tests and procedures, and quality assurance tests and procedures. Subpart B on Monitoring Provisions established general operating requirements for the monitoring systems. Subpart C establishes requirements on initial certification and recertification procedures. Subparts F and G establish requirements on recordkeeping and reporting requirements. All applicable requirements are included in the PDOC permit conditions.

VI. ADDITIONAL ISSUES

PARTICULATE EMISSION RELATING TO THE USE OF DESALINATED WATER FOR EVAPORATIVE COOLING

The proposed GE LMS100 turbines have inlet air filters located upstream of the evaporative coolers. The evaporative cooler is turned on only during normal operation in hot weather. The particulate emission factor of 5.5 lbs/hr provided by the turbine vendor includes anticipated particulate matter from the evaporative cooler parameters since the water supply is expected to comply with the vendor's recommended water quality standards. Therefore, no further particulate emissions from the evaporative cooler are included in the emission calculation.

COMMISSIONING PERIOD

After construction of the equipment has been completed, the Applicant will be allowed a commissioning period of 112 operating hours for each turbine. During the commissioning period, the turbines will go through testing and tuning to ensure that the equipment is working properly and will be able to comply with all the PDOC emission limits. However, during the initial startup, **certain** emissions standards must remain in effect. These include the hourly mass emission limits for NO_x and CO to ensure there will be no violation of any state or national ambient air quality standards, and the hourly concentration limits for NO_x to ensure compliance with the District RACT and BARCT Rules 69.3 and 69.3.1, respectively. A CEMS will be required to be installed at the time of initial startup to monitor emissions during the commissioning period from each turbine.

Once the emissions control equipment has been installed and is in good working order, the turbines must meet all BACT/LAER standards and permit requirements. CEMS and source testing will be used to show compliance with these standards.

SOURCE TEST FREQUENCY

The PDOC permit conditions require that the frequency of annual compliance source testing be in accordance with the applicable RATA frequency requirements of the federal acid rain program provisions at 40 CFR Part 75, Appendix B, Sections 2.3.1 and 2.3.3. The annual

source testing is to show compliance with the NOX, CO, VOC, and ammonia emission limits and to verify the accuracy of the continuous emission monitoring system (CEMS). At a minimum, the acid rain programs provisions require that a source test be performed after four calendar quarters in which the unit operates at least 168 hours in each quarter (any hour the turbine combusts fuel is considered an operating hour for purposes of Part 75). It is expected that a source test would be required once per year for this facility since the Applicant anticipates about 4000 operating hours per year for each turbine, or about 1000 hours per quarter on average.

In cases of where low levels of operation (less than 168 operation hours per quarter) do not trigger a source test, the acid rain program provisions require a test be conducted every eight calendar quarters even if there have not been four quarters with 168 hours or more of operating time in the eight-quarter period. Any such test must be conducted within 720 operating hours of the end of the eight-quarter period.

VII. CONCLUSIONS AND RECOMMENDATIONS

If operated in accordance with the conditions specified in this Preliminary Determination of Compliance, this equipment is expected to operate in compliance with all Rules and Regulations of the San Diego County Air Pollution Control District.

Originally Signed by	<u>Steve Moore / for</u>	<u>12-16-11</u>
Project Engineer	Camqui Nguyen	Date

Originally Signed by	<u>Steve Moore</u>	<u>12-16-11</u>
Senior Engineer Approval		Date

APPENDIX A

APPROVAL OF AIR QUALITY IMPACT ANALYSIS

**AIR QUALITY IMPACT ANALYSIS
FINAL REVIEW REPORT**

**PIO PICO ENERGY CENTER PROJECT
APPLICATION 2010-APP-001251**

DECEMBER 16, 2010

**Prepared For
Mechanical Engineering
San Diego Air Pollution Control District
10124 Old Grove Road
San Diego, California 92131**

**Prepared By
Ralph DeSiena
Monitoring and Technical Services
San Diego Air Pollution Control District
10124 Old Grove Road
San Diego, California 92131**

1.0 INTRODUCTION

An Air Quality Impact Analysis (AQIA) was performed for the Pio Pico Energy Center Project (PPEC) by Sierra Research of Sacramento, CA. This report focuses on Section 5.2 of the AFC and the AQIA analysis results provided in the original (March, 2011) and subsequent modeling analysis (October, 2011) performed.

2.0 PROJECT DESCRIPTION

Pio Pico Energy Center, LLC (PPEC LLC) is proposing a simple-cycle power generation project that consists of three General Electric (GE) LMS100 natural gas-fired combustion turbine generators (CTGs). The total net generating capacity would be 300 megawatts (MW), with each CTG capable of generating 100MW. The proposed plant will be owned and operated by PPEC LLC. The electricity generated by this project would be in support of a contract with SDG&E. NO_x emissions are controlled with a selective catalytic reduction system and CO emissions are controlled with an oxidation catalyst.

3.0 AIR QUALITY IMPACT ANALYSIS

Dispersion modeling was conducted for Normal, Startup/Shutdown and Commissioning period emissions of NO₂, CO, SO₂ and PM₁₀ and PM_{2.5}. The applicant and their consultant (Sierra Research) worked closely with the District in developing modeling and analysis procedures in support of demonstrating compliance with all applicable NSR requirements. Modeling was performed in order to determine whether emissions during these time periods would impact the State and/or Federal Ambient Air Quality Standards for all criteria pollutants.

The modeling procedures are discussed in the following subsections.

3.1 MODELING METHODOLOGIES

AERMOD was used first to "screen" the different turbine stack emission and ambient temperature parameters for the conditions that generate the highest ground-level concentrations of criteria pollutants. Gas turbine specifications were developed and modeled for three temperature scenarios: extreme hot temperature (110 F), annual average temperature (63 F) and extreme low temperature (30 F). Stack parameters and criteria pollutant emission rates were provided at each of these three ambient temperatures. Similarly, stack parameters and emission rates per turbine were provided at each ambient temperature for the turbines running at 100% and 50% load. The stack parameters and maximum emission rates for the Screening Modeling are presented in Table 3-1, Start-Up modeling inputs in Table 3-2 and Commissioning modeling inputs in Table 3-3. The maximum predicted screening model impacts are shown in Table 3-4.

After screening modeling, refined modeling was performed using EPA's AERMOD (Version 11103) model with the "maximum impact" turbine stack conditions and emission rates to determine the maximum criteria pollutant concentrations for the appropriate averaging periods for each criteria pollutant. Additionally, the EPA's SCREEN3 (Version 96043) model is used to determine the potential impacts if the project emissions are subjected to fumigation from breakup of the overnight inversion that can form. This special case is modeled as an extra precaution to avoid an exceedance of ambient air quality standards under these special atmospheric conditions.

All modeling was performed in accordance with EPA guidance and District standard procedures. The receptor grid was sufficiently dense to identify maximum impacts. AERMAP (Version 11103) was used to determine receptor elevations and controlling hill heights.

The Plume Volume Molar Ratio (PVMRM) method was used in determining predicted NO₂ impacts for all facility operations. Background Ozone data from the Chula Vista monitoring station was used for this purpose. Additionally, a data post processing program included in the new version (11103) of AERMOD was used to perform a refined analysis for the Federal 1-Hour NO₂ Standard. This program adds the predicted hour by hour NO₂ impacts to the monitored background NO₂ value (Chula Vista) for that hour for each receptor. For EPA and PSD modeling requirements, the NO₂ background data used was a very conservative composite daily background file for each calendar month. This file was comprised of the highest monitored NO₂ concentration that occurred for each hour of that month. For District NSR requirements, actual hour-by-hour background NO₂ data, with any missing data filled per the District's draft data filling guidance procedure was used. Per the form of the Federal standard, for each modeled year the highest daily combination of predicted plus background concentration at each receptor is first determined. The 98th percentile value (8th high) can then be calculated for each receptor for each of the three years. A three year average 98th percentile value for each receptor is then determined. The highest three year average 98th percentile value at any receptor can then be compared to the Federal 1-Hour standard to determine compliance with this standard.

3.2 METEOROLOGICAL DATA USED FOR DISPERSION MODELING

Meteorological data used for EPA's AERMOD model consisted of the following data for the 2008 through 2010 and 2006 through 2008 time periods. The 2008 through 2010 time period was used to assess all impacts except for 24-hr PM_{2.5} impacts for which, as discussed below, the 2006 through 2008 time period was used. The data was processed by the District using EPA's AERMET meteorological data processor (Version 11059) to produce AERMOD ready files.

- Wind speed, wind direction, standard deviation of the horizontal wind direction and temperature from the District's Otay Mesa monitoring station.
- Twice-daily upper-air soundings from Miramar Marine Corps Air Station, San Diego, CA.
- Cloud height and total opaque cloud amount from Brown Field Airport, Otay Mesa, CA.
- Wind speed, wind direction and temperature data from Brown Field Airport, Otay Mesa, CA for replacement of missing data in the Otay Mesa data set.

Table 3-1

Screening Modeling Inputs

Pio Pico Energy Center

Operating Mode	Ambient Temp deg F	Stack height feet	Stack Diam feet	Stack flow wacfm	Stack Vel ft/sec	Stack Temp deg F	Stack Height meters	Stack Diam Meters	Stack flow m3/sec	Stack Vel m/sec	Stack Temp deg K
Startup/shutdown	30	100	14.5	733,309	74.01	825	30.48	4.4196	346.13	22.56	713.8
Hot Peak	110	100	14.5	877,825	88.60	802	30.48	4.4196	414.34	27.01	700.9
Avg Peak	63	100	14.5	913,717	92.22	785	30.48	4.4196	431.28	28.11	691.2
Cold Peak	30	100	14.5	909,632	91.81	754	30.48	4.4196	429.36	27.98	674.0
Hot Low	122	100	14.5	733,309	74.01	825	30.48	4.4196	346.13	22.56	713.8
Avg Low	63	100	14.5	646,428	65.24	831	30.48	4.4196	305.12	19.89	717.2
Cold Low	30	100	14.5	645,580	65.16	820	30.48	4.4196	304.72	19.86	711.2

Operating Mode	Emissions per Turbine							
	NOx lb/hr	CO lb/hr	SOx lb/hr	PM10 lb/hr	NOx g/sec	CO g/sec	SOx g/sec	PM10 g/sec
Commissioning	50.00	75.00	0.63	5.5	6.30	9.45	0.06	0.69
Startup/Shutdown	26.63	53.51			3.36	6.74		
Hot Peak	7.72	7.52	1.79	5.50	0.97	0.95	0.23	0.69
Avg Peak	8.18	7.97	1.90	5.50	1.03	1.00	0.24	0.69
Cold Peak	8.07	7.86	1.87	5.50	1.02	0.99	0.24	0.69
Hot Low	5.92	5.77	1.38	5.50	0.75	0.73	0.17	0.69
Avg Low	4.94	4.82	1.15	5.50	0.62	0.61	0.14	0.69
Cold Low	4.92	4.79	1.14	5.50	0.62	0.60	0.14	0.69

Table 3-2

Startup Modeling Inputs

Pio Pico Energy Center

Case	Amb Temp deg F	Stack height feet	Stack Diam feet	Stack flow wacfm	Stack Vel ft/sec	Stack Temp deg F	Stack Height meters	Stack Diam meters	Stack flow m3/sec	Stack Vel m/sec	Stack Temp deg K
Hot Low	122	100	14.5	733,309	74.01	825.1	30.48	4.42	346.13	22.56	713.8

Table 3-3
Commissioning Modeling Inputs
Pio Pico Energy Center

Case	Amb Temp deg F	Stack height feet	Stack Diam feet	Stack flow wacfm	Stack Vel ft/sec	Stack Temp deg F	Stack Height meters	Stack Diam meters	Stack flow m3/sec	Stack Vel m/sec	Stack Temp deg K
Cold Low	30	100	14.5	645,580	65.16	820	30.48	4.42	304.72	19.86	711.2

Table 3-4
Screening Modeling Results
Pio Pico Energy Center (Revised 10/19/2011)

Operating Mode/Year	Conc. (ug/m3) NO2 1-hr	Conc. (ug/m3) CO 1-hr	Conc. (ug/m3) SO2 1-hr	Conc. (ug/m3) SO2 3-hr	Conc. (ug/m3) CO 8-hr	Conc. (ug/m3) PM10 24-hr	Conc. (ug/m3) SO2 24-hr	Conc. (ug/m3) NO2 Annual	Conc. (ug/m3) PM10 Annual	Conc. (ug/m3) SO2 Annual
2008 Met Data										
Startup/shutdown	121.0	243.1			43.1			N/A	N/A	N/A
Hot Peak	29.6	28.8	6.9	2.3	4.8	1.3	0.4	0.2	0.2	0.1
Avg Peak	30.8	30.0	7.2	2.4	5.0	1.3	0.5	0.3	0.2	0.1
Cold Peak	30.8	30.0	7.2	2.4	5.0	1.3	0.5	0.3	0.2	0.1
Hot Low	24.9	24.2	5.8	2.0	4.2	1.5	0.4	0.2	0.2	0.1
Avg Low	22.4	21.8	5.2	1.8	3.9	1.7	0.4	0.2	0.2	0.0
Cold Low	22.3	21.8	5.2	1.8	3.9	1.7	0.4	0.2	0.2	0.0
2009 Met Data										
Startup/shutdown	133.3	267.8			49.5	0.0	0.0	N/A	N/A	N/A
Hot Peak	33.1	32.2	7.7	2.6	6.0	1.7	0.5	0.2	0.2	0.1
Avg Peak	34.4	33.5	8.0	2.7	6.3	1.6	0.6	0.2	0.2	0.1
Cold Peak	34.4	33.6	8.0	2.7	6.3	1.7	0.6	0.2	0.2	0.1
Hot Low	27.6	26.8	6.4	2.2	5.0	1.8	0.4	0.2	0.2	0.0
Avg Low	24.6	24.0	5.7	2.0	4.4	1.9	0.4	0.2	0.2	0.0
Cold Low	24.6	24.0	5.7	2.0	4.4	1.9	0.4	0.2	0.2	0.0
2010 Met Data										
Startup/shutdown	112.1	225.2			64.3	0.0	0.0	N/A	N/A	N/A
Hot Peak	27.7	27.0	6.4	2.2	7.7	1.9	0.6	0.2	0.2	0.0
Avg Peak	28.8	28.1	6.7	2.3	8.0	1.9	0.6	0.2	0.1	0.1
Cold Peak	28.8	28.1	6.7	2.3	8.0	1.9	0.6	0.2	0.2	0.1
Hot Low	23.3	22.7	5.4	1.9	6.5	2.1	0.5	0.2	0.2	0.0
Avg Low	20.7	20.2	4.8	1.7	5.8	2.2	0.5	0.2	0.2	0.0
Cold Low	20.7	20.2	4.8	1.7	5.8	2.2	0.5	0.2	0.2	0.0

4.0 AIR QUALITY IMPACT ANALYSIS RESULTS

In accordance with EPA and San Diego Air Pollution Control District New Source Review Guidance and the modeling methodologies described above, maximum predicted concentrations associated with facility operations were determined for each of the required criteria pollutants and the applicable averaging periods during Normal, Startup/Shutdown and Commissioning conditions. The maximum predicted concentrations occurring during any of the operating conditions modeled were added to worst-case background concentrations for comparison to Federal and State Ambient Air Quality Standards. Worst case background concentrations were determined from the review of monitoring data for 3 years (2006-2008) for the original modeling and three years (2008-2010) for the October, 2011 modeling addendum. Monitoring data was taken from the District's Otay Mesa or San Diego monitoring stations, whichever was available for a specific criteria pollutant and deemed to be most representative of air quality in the facility area.

The maximum ground-level impacts at any location from normal operations, startup/shutdowns and the special circumstances of inversion breakup fumigation are presented in Table 4-1.

Table 4-2 provides the summary of project modeled maximum impacts for Commissioning period operating conditions.

Table 4-3 provides the summary of project modeled maximum impacts for Startups and Normal operating conditions.

Table 4-4 provides the summary of the proposed project modeled maximum impacts, including worst case ambient background concentrations, compared with Federal and California Ambient Air Quality Standards (AAQS).

Table 4-5 provides a summary for the compliance with the Federal 1-Hour NO₂ and 24-Hour PM_{2.5} standards (2008-2010 meteorological data) (Revised 10/19/11).

**Table 4-1
Fumigation Modeling
Pio Pico Energy Center**

Emission Rates									
Operating Mode	NOx lb/hr	CO lb/hr	SOx lb/hr	PM10 lb/hr		NOx g/sec	CO g/sec	SOx g/sec	PM10 g/sec
Startup/Shutdown	26.63	53.51				3.36	6.74		
Hot Peak	7.72	7.52	1.79	5.50		0.97	0.95	0.23	0.69
Avg Peak	8.18	7.97	1.90	5.50		1.03	1.00	0.24	0.69
Cold Peak	8.07	7.86	1.87	5.50		1.02	0.99	0.24	0.69
Hot Low	5.92	5.77	1.38	5.50		0.75	0.73	0.17	0.69
Avg Low	4.94	4.82	1.15	5.50		0.62	0.61	0.14	0.69
Cold Low	4.92	4.79	1.14	5.50		0.62	0.60	0.14	0.69

SCREEN3 Results			
	Unit Impacts	Distance to Max (m)	
Simple Terrain			
Startup/shutdown	0.5907	1197	
Hot Peak	0.5867	1198	
Avg Peak	0.5703	1206	
Cold Peak	0.5582	1214	
Hot Low	0.6321	1234	
Avg Low	0.6572	1220	
Cold Low	0.6359	1232	

Table 4-1 (Cont.)			
Fumigation Modeling			
Pio Pico Energy Center			
Inversion Breakup Results		Unit Impacts	Distance to Max (m)
Startup/shutdown		0.8536	21294
Hot Peak		0.7362	23738
Avg Peak		0.7313	23856
Cold Peak		0.7532	23343
Hot Low		0.8247	21840
Avg Low		0.9149	20236
Cold Low		0.9341	19931

Appropriate 1-hr unit impacts to use for longer averaging periods - Inversion Breakup Fumigation

		1-hr unit	3-hr unit	8-hr unit	24-hr unit
Startup/shutdown		0.8536	0.6499	0.4480	0.2429
Hot Peak		0.7362	0.5953	0.4303	0.2384
Avg Peak		0.7313	0.5857	0.4203	0.2321
Cold Peak		0.7532	0.5901	0.4163	0.2282
Hot Low		0.8247	0.6556	0.4677	0.2577
Avg Low		0.9149	0.7074	0.4939	0.2693
Cold Low		0.9341	0.7065	0.4843	0.2618

Inversion Fumigation impacts		NOx 1-hour	CO 1-hour	SO2 1-hour	SO2 3-hour	CO 8-hour	SO2 24-hour	PM 24-hour
Startup/shutdown		2.86	5.75	0.00	0.00	3.02	0.00	0.00
Hot Peak		0.72	0.70	0.17	0.13	0.41	0.05	0.17
Avg Peak		0.75	0.73	0.18	0.14	0.42	0.06	0.16
Cold Peak		0.77	0.75	0.18	0.14	0.41	0.05	0.16
Hot Low		0.62	0.60	0.14	0.11	0.34	0.04	0.18
Avg Low		0.57	0.56	0.13	0.10	0.30	0.04	0.19
Cold Low		0.58	0.56	0.13	0.10	0.29	0.04	0.18

Table 4-2
Modeled Maximum Impacts During Commissioning
(2008-2010 Meteorological Data) (Revised 10/19/11)

Pollutant	Averaging Period	Maximum Predicted Impact ($\mu\text{g}/\text{m}^3$)	Background Concentration ($\mu\text{g}/\text{m}^3$)	Total Concentration ¹ ($\mu\text{g}/\text{m}^3$)	NAAQS ($\mu\text{g}/\text{m}^3$)	CAAQS ($\mu\text{g}/\text{m}^3$)
NO ₂	1-hr	194	135	329	188	339
	Annual	--	30	--	NA	NA
SO ₂	1-hr	3	29	32	196	655
	3-hr	1	18	19	1300	--
	24-hr	0	10	10	--	105
	Annual	--	5	--	NA	--
CO	1-hr	375	2863	3238	40,000	23,000
	8-hr	90	2176	2266	10,000	20,000
PM ₁₀	24-hr	2	58	60	150	50
	Annual	--	26.7	--	--	NA
PM _{2.5}	24-hr	2.2	43.7	45.9	35	--
	Annual	--	12.3	--	NA	NA

¹ The total concentration shown in this table is the sum of the maximum predicted impact and the maximum measured background concentration. Because the maximum impact will not occur at the same time as the maximum background concentration, the actual maximum combined impact will be lower.

Table 4-3
Summary Of Modeling Results
(2008-2010 Meteorological Data) (Revised 10/19/11)

Pollutant	Averaging Period	Modeled Concentration ($\mu\text{g}/\text{m}^3$)		PSD Significant Impact Level ($\mu\text{g}/\text{m}^3$)
		Normal Operation	Startup	
NO ₂	1-hr	34	133	7.5 ¹
	Annual	0.3	--	1.0
SO ₂	1-hr	8	--	7.8 ¹
	3-hr	3	--	25
	24-hr	1	--	5
	Annual	<0.1	--	1.0
CO	1-hr	34	268	2000
	8-hr	8	64	500
PM ₁₀	24-hr	2.2	--	5
	Annual	0.24	--	1
PM _{2.5}	24-hr	2.2	--	1.2
	Annual	0.24	--	0.3

Notes:

¹ These are interim SILs and have not been formally adopted by EPA.

Table 4-4
Summary of Results (Modeled Maximum Impacts Plus Background)
(2008-2010 Meteorological Data) (Revised 10/19/11)

Pollutant	Averaging Time	Maximum Predicted Impact (operating mode) (µg/m³)	Background Concentration (µg/m³)	Total Concentration (Maximum Impact plus Background) (µg/m³)	3-Year Average of 98 th Percentile of Total Concentration (µg/m³)	NAAQS (µg/m³)	CAAQS (µg/m³)
NO ₂	1-hr	133(startup)	135	268	138	188	339
	Annual	0.3 (normal)	30	30	--	100	57
SO ₂	1-hr	8 (normal)	29	37	--	196	655
	3-hr	3 (normal)	18	21	--	1300	--
	24-hr	1 (normal)	10	11	--	--	105
	Annual	<0.1 (normal)	5	5	--	80	--
CO	1-hr	268(shutdown)	2863	3131	--	40,000	23,000
	8-hr	64(shutdown)	2176	2240	--	10,000	20,000
PM ₁₀	24-hr	2 (normal)	58	60	--	150	50
	Annual	0.2 (normal)	26.7	26.9	--	--	20
PM _{2.5}	24-hr	2.2 (normal)	43.7	--	Not Available ²	35	--
	Annual	2.6 (normal) ³	45.7 ³	--	25.9 ³	35	--
		0.24 (normal)	12.3	12.6	--	15.0	12

¹ 40 CFR 51.165 (b)(2).

² 2008-2010 PM_{2.5} measurements are only taken every three days. Data substitution to fill missing data was not performed by the District. 2006-2008 analysis is shown instead. Note that peak project impact and maximum background concentration are both lower for 2008-2010.

³ Based on 2006-2008 data.

TABLE 4-5
Summary of Results of Demonstration of Compliance with Federal 1-Hour NO₂ and
24-Hour PM_{2.5} Standards
(2008-2010 Meteorological Data)(Revised 10/19/11)

Standard	Maximum Predicted Impact (µg/m³)	Maximum Background Concentration (µg/m³)	3-Year Average of 98 th Percentile of Total Concentration (µg/m³)	NAAQS (µg/m³)
Federal 1-Hour NO₂	133 (startup)	135	138 ³	188
Federal 1-Hour NO₂	133 (startup)	135	121 ⁴	188
Federal 24-Hour PM_{2.5}	2.2 (normal)	43.7	Not Available ¹	35
Federal 24-Hour PM_{2.5}	2.6 (normal) ²	45.7 ²	25.9 ²	35

¹ 2008-2010 PM_{2.5} measurements are only taken every three days. Data substitution to fill missing data was not performed by District. 2006-2008 analysis is shown instead.

² Based on 2006-2008 data.

³ Based on composite daily NO₂ background file(Chula Vista monitoring station).

⁴ Based on actual hour by hour filled NO₂ background file(Chula Vista monitoring station).

5.0 CONCLUSION

The results of the modeling indicate that the proposed facility operations including Commissioning and Startup/Shutdowns will not cause or contribute to an exceedance of the Federal and California Ambient Air Quality Standards for NO₂, SO₂ and CO.

For PM₁₀, background concentrations already exceed the annual and 24-Hour California standard. Since the background is already in exceedance of the annual standard no additional violations can be due to facility operations. Additionally, the 0.24 µg/m³ predicted annual impact is well below PSD Significant Impact Levels (SILs) shown in Table 5-1. Predicted impacts less than SILs are normally considered to not significantly affect compliance with Federal Ambient Air Quality Standards regardless of the background level. Specifically, in non-attainment areas, project impacts less than the SILs are deemed to not significantly cause or contribute to violations of, or attainment of, the Federal Ambient Air Quality Standard. The District considers that this is the case for California Annual PM₁₀ Ambient Air Quality Standards as well.

Since the initial modeling estimated maximum 24-Hour PM₁₀ impacts of approximately 2.2 µg/m³, additional AERMOD modeling could be performed for all days in the 2008-2010 period that the 24-Hour PM₁₀ background concentrations exceeded 48 µg/m³ to determine whether additional violations of the applicable standard would result from facility operations. Data from both the Chula Vista monitoring station and the new Donovan correctional facility monitoring station were reviewed for this purpose. All days with monitored values greater than 46 µg/m³ were modeled. This analysis demonstrates that the sum of the worst case impact and monitored background value for each of these days would not result in an additional violation of the standard. The results are summarized in Table 5-2. It can therefore be concluded that facility operations would not cause or contribute to additional violations of the California 24-Hour Ambient Air Quality Standard for PM₁₀.

The modeling results also indicate that no exceedance of the Federal Annual or 24-Hour PM_{2.5} ambient air quality standard is predicted. Monitored background levels exceeded the California PM_{2.5} Annual Standard. Since the background is already in exceedance of the Annual standard no additional violations can be due to facility operations. Additionally, the 0.24 µg/m³ predicted annual impact is below PSD SILs shown in Table 5-1 for PM_{2.5}. Predicted impacts less than SILs are normally considered to not significantly affect compliance with Federal Ambient Air Quality Standards regardless of the background level. Specifically in non-attainment areas, project impacts less than the SILs are deemed to not significantly cause or contribute to violations of, or attainment of, the Federal Ambient Air Quality Standard. The District considers that this is the case for California Annual PM_{2.5} Ambient Air Quality Standards as well.

Table 5-1
Comparison Of Maximum Modeled Impacts During Normal Operation And PSD
Significant Impact Levels
(2008-2010 Meteorological Data) (Revised 10/19/11)

Pollutant	Averaging Time	Significant Impact Level, $\mu\text{g}/\text{m}^3$	Maximum Modeled Impact for PPEC, $\mu\text{g}/\text{m}^3$	Exceed Significant Impact Level?
NO ₂	1-Hour	7.5 ¹	34	
	Annual	1	0.3	No
SO ₂	1-Hour	7.8 ¹	8	No
	3-hour	25	3	
	24-Hour	5	1	
	Annual	1	<0.1	
CO	1-Hour	2000	34	No
	8-Hour	500	8	
PM _{2.5}	24-Hour	1.2	2.2	
	Annual	0.3	0.24	
PM ₁₀	24-Hour	5	2.2	No
	Annual	1	0.24	

Notes:

¹ These are interim SILs and have not been formally adopted by EPA

Table 5-2
Demonstration That Project Will Not Cause New Violation Of State 24-Hour PM₁₀ Standard
(50 $\mu\text{g}/\text{m}^3$)
(2008-2010 Meteorological Data)

Date	Ambient Measurement	Project Impact	Combined Concentration	New Violation?
Chula Vista Monitoring Data (2008-2010)				
10/27/2008	54	2	56	NO
10/28/2009	58	2	60	NO
11/9/2009	53	2	55	NO
1/1/2009	47	2	49	NO
Donovan Monitoring Data (2010)				
1/26/2010	49	0.3	49	NO
8/24/2010	57	0.7	58	NO
9/29/2010	54	0.6	55	NO
10/29/2010	56	0.6	57	NO
12/4/2010	50	0.3	50	NO
12/10/2010	50	0.3	50	NO

APPENDIX B

APPROVAL OF HEALTH RISK ASSESSMENT

Rule 1200 Health Risk Assessment Report

Site ID: 00471
Application: 001251
Project Engineer: Steven Moore
Toxics Risk Analyst: Michael Kehetian
HRA Tools Used: AERMOD (09292) / HARP On-Ramp / HARP (1.4d)
Report Date: August 30, 2011

Health Risk Assessment (HRA) evaluation for the Pio Pico Energy Center Project (PPEC)

A health risk assessment (HRA) was evaluated for the Pio Pico Energy Center Project (PPEC) by Sierra Research on behalf of Apex Power Group, LLC. The project is for a 300 megawatt power plant consisting of three simple cycle General Electric LMS 100 natural gas turbines and a cooling tower to be located in Otay Mesa on the southeast intersection of Alta Road and Calzada de la Fuente Road.

The following review references supporting documentation contained in the application for certification provided to the California Energy Commission (CEC) dated February 9, 2011, along with additional supplemental information requested by the District and received on March 8, 2011. The HRA was reviewed for adherence to the Office of Environmental Health Hazard Assessment (OEHHA), Air Resources Board (ARB), and District Rule 1200 guidelines.

Rule 1200 requires the HRA address the increases in potential to emit (PTE) associated with any new or modified emission units. The emission increases for the PPEC are associated with the following sources:

- Three simple cycle turbines each maximally rated at 890.2 MMBtu/hr and equipped with an oxidation catalyst to control volatile organic compounds (VOC) and carbon monoxide (CO) emissions. The oxidation catalyst is assumed to reduce toxic air contaminant (TAC) emissions by 50% during normal operations. The turbines are also equipped with a selective catalytic reduction (SCR) system to control oxides of nitrogen.
- A cooling tower producing aerosol particulate matter emissions from the evaporation of water drift droplets. Using a partial-dry cooling system, the drift eliminator reduces the drift loss rate to 0.001%.

The operating scenarios evaluated to determine the maximum potential health impacts include acute risk from startups and shutdowns, cancer and chronic risk from normal full load operations, the 8-hour hazard index, and health impacts for the commissioning year.

- Annual Emissions - Each turbine operates for 4,000 hours at full load plus 500 startups and 500 shutdowns (4,337.5 hours).
- Hourly Emissions – Each turbine has one startup for 30 minutes with the remainder of the hour at full load. A shutdown for each turbine is for 10.5 minutes with the remainder of the hour at full load.

Rule 1200 Health Risk Assessment Report

Worst-Case Potential Health Impacts

Category	Health Impact	Rule 1200 Significance Level
Maximum Incremental Cancer Risk—Resident (per million)	0.094	1.0 or 10 (with TBACT)
Maximum Incremental Cancer Risk—Worker (per million)	0.014	1.0 or 10 (with TBACT)
Total Chronic Noncancer Health Hazard Index	0.011	1.0
Total Acute Noncancer Health Hazard Index	0.11	1.0
Total 8-Hour Noncancer Health Hazard Index	0.42	1.0
Sub-Chronic Lead Exposure Risk (ug/m ³)	5.5E-07	0.12 (ARB Standard)

The reported cancer, chronic, 8-hour, and acute worst-case potential health impacts are at the point of maximum impact (PMI) which is the maximum impact point beyond the facility boundary. The presented worker cancer risk is a conservative ratio of residential exposure assumed to be at the PMI (8/24 hours per day, 245/365 days per year, and 40/70 years).

To determine the worst-case health impacts, modeling consisted of three years (2006, 2007, and 2008) of Otay Mesa meteorological data. For all health impacts, the 2006 meteorological data produced the worst-case results by a small margin.

Cancer risk at the PMI is primarily due to formaldehyde (~49%) and noninhalation exposure to benzo[a]pyrene (~21%) along with dibenz[a,h]anthracene (~13%). The location of the PMI is modeled grid receptor 10443, UTM NAD 83 Zone 11 coordinates 509796 E and 3603904 N.

The chronic health hazard index (HHI) to the respiratory system is mainly due to formaldehyde (~48%) and ammonia (~33%).

Acute risk to the eye endpoint is due to formaldehyde (~79%) and acrolein (~12%). The acute PMI HHI is located at grid receptor 8377, 508696 E and 3604889 N.

On June 18, 2008, the Scientific Review Panel approved OEHHA's Air Toxics Hot Spots Program Technical Support Document (TSD) for the Derivation of Noncancer Reference Exposure Levels (REL) as mandated by the Children's Environmental Health Protection Act of 1999. In addition to revising the chronic and acute health data for several chemicals, a newly added 8-hour hazard index was created. For this project and referencing the Consolidated Table of OEHHA and ARB Approved Risk Assessment Health Values updated on February 14, 2011, 8-hour RELs exist for acetaldehyde, acrolein, and formaldehyde. Since existing OEHHA draft guidance indicates the 8-hour RELs are not target organ specific, the worst-case 8-hour hazard index listed above is the combined total for acetaldehyde, acrolein, and formaldehyde.

Rule 1200 Health Risk Assessment Report

The maximum 1-hour lead concentration is estimated to be $5.5\text{E-}07 \text{ ug/m}^3$ which is much less than the 30-day High Exposure Scenario approval level of 0.12 ug/m^3 in the ARB Risk Management Guidelines for Lead, 2001. Although the hourly emissions rate equal to $3.6\text{E-}09 \text{ g/s}$ is ten times less than the 30-day, $2.1\text{E-}08 \text{ g/s}$, the results are using the 1-hour averaging period dispersion factor which is significantly higher than what the guidelines require, a 30-day average, so the results are overly conservative.

Emission Factors

Emission factors reference the U.S. EPA AP-42 (Table 3.1-3) and California Air Toxic Emission Factor (CATEF) database for toxic compounds. The turbines are proposed to be equipped with an oxidation catalyst reducing the emission factors by 50% during normal operations. The emission factor for ammonia was calculated based on the proposed permit limit.

Toxic Air Contaminant	Emission Factor Uncontrolled (lb/MMscf)	Source	Emission Factor Controlled (lb/MMBtu)
ACETALDEHYDE	4.08E-02	AP-42	2.00E-05
ACROLEIN	6.53E-03	AP-42	3.21E-06
AMMONIA	7.0	SDAPCD	6.87E-03
BENZENE	1.22E-02	AP-42	5.99E-06
BUTADIENE, 1,3-	4.39E-04	AP-42	2.15E-07
ETHYL BENZENE	3.26E-02	AP-42	1.60E-05
FORMALDEHYDE	9.17E-01	CATEF	4.50E-04
HEXANE-N	2.59E-01	CATEF	1.27E-04
NAPHTHALENE	1.33E-03	AP-42	6.53E-07
PAHs			
ACENAPHTHENE	1.90E-05	CATEF	9.32E-09
ACENAPHTHENE	1.47E-05	CATEF	7.21E-09
ANTHRACENE	3.38E-05	CATEF	1.66E-08
BENZO[a]ANTHRACENE	2.25E-05	CATEF	1.11E-08
BENZO[a]PYRENE	1.39E-05	CATEF	6.82E-09
BENZO[e]PYRENE	5.44E-07	CATEF	2.67E-10
BENZO[b]FLUORANTHENE	1.13E-05	CATEF	5.54E-09
BENZO[k]FLUORANTHENE	1.10E-05	CATEF	5.40E-09
BENZO[g,h,i]PERYLENE	1.37E-05	CATEF	6.72E-09
CHRYSENE	2.52E-05	CATEF	1.24E-08
DIBENZ[a,h]ANTHRACENE	2.36E-05	CATEF	1.15E-08
FLUORANTHENE	4.32E-05	CATEF	2.12E-08
FLUORENE	5.80E-05	CATEF	2.85E-08
INDENO(1,2,3-cd)PYRENE	2.36E-05	CATEF	1.15E-08
PHENANTHRENE	3.13E-04	CATEF	1.54E-07
PYRENE	2.77E-05	CATEF	1.36E-08
PROPYLENE	7.71E-01	CATEF	3.78E-04
PROPYLENE OXIDE	2.96E-02	AP-42	1.45E-05
TOLUENE	1.33E-01	AP-42	6.53E-05
XYLENES	6.53E-02	AP-42	3.20E-05

Rule 1200 Health Risk Assessment Report

Emissions – Normal Operations (Each Turbine, 4337.5 hours)

Toxic Air Contaminant	Emission Factor Controlled (lb/MMBtu)	Emissions (lb/hr)	Emissions (lb/yr)
ACETALDEHYDE	2.00E-05	1.78E-02	7.72E+01
ACROLEIN	3.21E-06	2.86E-03	1.24E+01
AMMONIA	6.87E-03	6.12E+00	2.66E+04
BENZENE	5.99E-06	5.33E-03	2.32E+01
BUTADIENE, 1,3-	2.15E-07	1.92E-04	8.32E-01
ETHYL BENZENE	1.60E-05	1.42E-02	6.18E+01
FORMALDEHYDE	4.50E-04	4.01E-01	1.74E+03
HEXANE-N	1.27E-04	1.13E-01	4.90E+02
NAPHTHALENE	6.53E-07	5.81E-04	2.52E+00
PAHs			
ACENAPHTHENE	9.32E-09	8.30E-06	3.60E-02
ACENAPHTHENE	7.21E-09	6.42E-06	2.78E-02
ANTHRACENE	1.66E-08	1.48E-05	6.40E-02
BENZO[a]ANTHRACENE	1.11E-08	9.87E-06	4.28E-02
BENZO[a]PYRENE	6.82E-09	6.07E-06	2.64E-02
BENZO[e]PYRENE	2.67E-10	2.38E-07	1.03E-03
BENZO[b]FLUORANTHENE	5.54E-09	4.94E-06	2.14E-02
BENZO[k]FLUORANTHENE	5.40E-09	4.81E-06	2.08E-02
BENZO[g,h,i]PERYLENE	6.72E-09	5.98E-06	2.60E-02
CHRYSENE	1.24E-08	1.10E-05	4.78E-02
DIBENZ[a,h]ANTHRACENE	1.15E-08	1.03E-05	4.46E-02
FLUORANTHENE	2.12E-08	1.89E-05	8.18E-02
FLUORENE	2.85E-08	2.53E-05	1.10E-01
INDENO(1,2,3-cd)PYRENE	1.15E-08	1.03E-05	4.46E-02
PHENANTHRENE	1.54E-07	1.37E-04	5.94E-01
PYRENE	1.36E-08	1.21E-05	5.26E-02
PROPYLENE	3.78E-04	3.37E-01	1.46E+03
PROPYLENE OXIDE	1.45E-05	1.29E-02	5.60E+01
TOLUENE	6.53E-05	5.81E-02	2.52E+02
XYLENES	3.20E-05	2.85E-02	1.24E+02

Hourly TAC emissions during startup and shutdown are scaled up as a ratio of volatile emissions from normal operations as determined by the applicant to account for overall combustion conditions and limited/non-operational control from the oxidation catalyst. Toxic emissions during an hour including a shutdown are the highest as are the worst-case acute health impacts.

Rule 1200 Health Risk Assessment Report

Emissions – Scaled VOCs for Startup and Shutdown

Operating Mode	VOC Emissions (lb/hr)	Ratio of Normal Operations
Normal Operations	2.28	--
Startup	5.81	2.55
Shutdown	6.53	2.86

Emissions – Shutdown (Worst-Case)

Toxic Air Contaminant	Emission Factor Controlled (lb/MMBtu)	Emissions (lb/hr)
ACETALDEHYDE	2.00E-05	5.10E-02
ACROLEIN	3.21E-06	8.18E-03
AMMONIA	6.87E-03	6.12E+00
BENZENE	5.99E-06	1.53E-02
BUTADIENE, 1,3-	2.15E-07	5.49E-04
ETHYL BENZENE	1.60E-05	4.08E-02
FORMALDEHYDE	4.50E-04	1.15E+00
HEXANE-N	1.27E-04	3.24E-01
NAPHTHALENE	6.53E-07	1.66E-03
PAHs		
ACENAPHTHENE	9.32E-09	2.38E-05
ACENAPHTHENE	7.21E-09	1.84E-05
ANTHRACENE	1.66E-08	4.23E-05
BENZO[a]ANTHRACENE	1.11E-08	2.83E-05
BENZO[a]PYRENE	6.82E-09	1.74E-05
BENZO[e]PYRENE	2.67E-10	6.80E-07
BENZO[b]FLUORANTHENE	5.54E-09	1.41E-05
BENZO[k]FLUORANTHENE	5.40E-09	1.38E-05
BENZO[g,h,i]PERYLENE	6.72E-09	1.71E-05
CHRYSENE	1.24E-08	3.15E-05
DIBENZ[a,h]ANTHRACENE	1.15E-08	2.94E-05
FLUORANTHENE	2.12E-08	5.40E-05
FLUORENE	2.85E-08	7.25E-05
INDENO(1,2,3-cd)PYRENE	1.15E-08	2.94E-05
PHENANTHRENE	1.54E-07	3.93E-04
PYRENE	1.36E-08	3.48E-05
PROPYLENE	3.78E-04	9.64E-01
PROPYLENE OXIDE	1.45E-05	3.70E-02
TOLUENE	6.53E-05	1.66E-01
XYLENES	3.20E-05	8.17E-02

Commissioning TAC emissions rates use those from normal operations assuming no control from the oxidation catalyst. The reported cancer, chronic, and acute commissioning worst-case

Rule 1200 Health Risk Assessment Report

potential health impacts are at the PMI. Cancer risk conservatively assumes 70 year exposure to simultaneous one year commissioning of all three turbines which is a total of 336 hours (112 hours per year for each turbine).

Commissioning Health Impacts

Category	Health Impact
Maximum Incremental Cancer Risk—Resident (per million)	0.0007
Total Chronic Noncancer Health Hazard Index	0.003
Total Acute Noncancer Health Hazard Index	0.027

The partial dry cooling tower operates annually for 4,337.5 hours, a water circulation rate of 14,000 gallons per minute (GPM), and 4.67 cycles of concentration. The maximum total dissolved solids (TSD) is 5,600 ppmw. The concentration for each TAC in the make-up water is determined from the highest water samples collected from the Otay Water District's Ralph W. Chapman Water Recycling Facility effluent in 2007, 2008, and 2009.

Based on a drift rate of 0.001% at the circulators cooling water, which results in maximum particulate emissions of 15.8 pounds per day and 1.43 tons per year, maximum toxic emissions from the cooling tower are:

Emissions - Cooling Towers (Each of the 12 Cells)

Toxic Air Contaminant	Concentration (ug/liter)	Emissions (lb/hr)	Emissions (lb/yr)
ARSENIC	1.80E+00	4.91E-09	2.12E-05
CARBON TETRACHLORIDE	2.10E+00	5.73E-09	2.48E-05
CHLORINE	2.30E+05	6.28E-04	2.72E+00
CHROMIUM	2.80E+00	7.64E-09	3.32E-05
COPPER	6.50E+00	1.77E-08	7.70E-05
FLUORIDE	6.60E+02	3.00E-06	1.30E-02
LEAD	8.60E-01	2.35E-09	1.02E-05

Air Dispersion Modeling

The US Environmental Protection Agency (EPA) AERMOD Dispersion Model (Version 09292) was used to predict concentration impacts using an emissions rate input of 1 g/s.

The District's Monitoring & Technical Services (M&TS) Division provided the AERMET preprocessor files used which included the following three years (2006, 2007, and 2008) of meteorological data:

Surface Data – Otay Mesa-Paseo International Monitoring Station.

Upper Air Data – MCAS Miramar Monitoring Station.

Rule 1200 Health Risk Assessment Report

For all health impacts, the 2006 meteorological data predicted the worst-case results by a small margin.

The dispersion results, X/Q ($\mu\text{g}/\text{m}^3$)/(g/s), were imported into ARB's Hotspots Analysis Reporting Program (HARP, Version 1.4d) via HARP On-Ramp to calculate actual chemical concentrations and resulting health impacts.

The dispersion modeling included a course 250-meter spacing grid extending out 10 km to assess the extent of maximum impacts. Refined 25-meter resolution receptor grids surrounding the areas of maximum impacts in addition to along the facility fenceline property boundary is sufficiently dense.

Release Parameters – Modeled Operating Modes

Operating Mode	Ambient Temperature (deg F)	Exhaust Temperature (deg F)	Exhaust Velocity (m/s)
Startup/Shutdown	30	820	19.86
Hot Peak	110	802	27.01
Average Peak	63	785	28.11
Cold Peak	30	754	27.98
Hot Low	122	825	22.56
Average Low	63	831	19.89
Cold Low	30	820	19.86

Release Parameters – Normal Operations (Worst-Case, Cold Peak)

Release Parameter	Value
Stack Height (ft)	100
Stack Diameter (ft)	14.5
Temperature deg F	754
Exhaust Velocity (fps)	91.81

Release Parameters – Startup/Shutdown, Commissioning, 8-Hour (Worst-Case, Cold Low)

Release Parameter	Value
Stack Height (ft)	100
Stack Diameter (ft)	14.5
Temperature deg F	820
Exhaust Velocity (fps)	65.16

Release Parameters – Cooling Towers

Release Parameter	Value
Stack Height (ft)	22
Stack Diameter (ft)	13
Temperature deg F	86
Exhaust Velocity (fps)	33.73

Rule 1200 Health Risk Assessment Report

Risk Calculations

The HRA was reviewed using ARB's Hotspots Analysis and Reporting Program (HARP), Version 1.4d, referencing the OEHHA Air Toxics Hot Spots Program Guidance Manual for Preparation of Health Risk Assessments, August 2003.

- **Inhalation Breathing Rates and Exposure Duration:** For calculating residential cancer risk over 70 years with inhalation as one of the two dominant pathways, the ARB Derived (Adjusted) Analysis Method was used which incorporates the minimum 80th percentile breathing rate equal to 302 Liters/Kilogram-day in accordance with the recommended interim risk management policy for inhalation-based residential cancer risk.

The worker cancer risk is a conservative ratio of residential exposure (8/24 hours per day, 245/365 days per year, and 40/70 years).

In accordance with the OEHHA Guidance Manual, *Calculating Cancer Risk Using Different Exposure Durations*, Section 8.2.2, *B. Worker*, a ground level concentration (GLC) adjustment factor was not applied to calculate occupational cancer risk since potential emissions are continuous (24 hours a day, 7 days per week).

- **Noninhalation Exposure:** Cancer and chronic health impacts include the required noninhalation pathways of dermal contact and soil ingestion per the OEHHA Guidance Manual, *Determination of Noninhalation (Oral) Cancer Risk*, Section 8.2.4, and *Noncancer Chronic Health Impacts from the Oral Route*, Section 8.3.2.

In addition to the exposure pathways of dermal contact and soil ingestion, residential cancer risk conservatively includes the rural home grown produce pathway with a human ingestion fraction equal to 15%.

The drinking water and fish consumption pathways using the default fraction of 1.0 (fraction of ingested fish and drinking water from contaminated source) were included in the analysis for the Otay Lake Reservoir.

- **Deposition Rate:** In accordance with the OEHHA Guidance Manual, *Criteria for Exposure Pathway Evaluation*, Section 5.2, noninhalation exposure used the OEHHA deposition rate equal to 0.05 meters per second, which conservatively assumes particulate matter of less than or equal to 10 microns in diameter (PM₁₀).
- The acute hazard index was calculated using the conservative default simple concurrent maximum approach. At each receptor, the maximum hourly dispersion factors for the entire period are summed from all sources assuming these impacts occur simultaneously at the same location. The more refined approach processes the meteorological data hourly variation dispersion impacts from different sources which for a given receptor will not necessarily be at their maximums at the same time.

APPENDIX C

PERMIT CONDITIONS

PIO PICO ENERGY CENTER (PPEC) PERMIT CONDITIONS

GENERAL CONDITIONS

1. This equipment shall be properly maintained and kept in good operating condition at all times, and, to the extent practicable, the applicant shall maintain and operate the equipment and any associated air pollution control equipment in a manner consistent with good air pollution control practices for minimizing emissions. [Rule 21 and 40 CFR §60.11]
2. The applicant shall operate the project in accordance with all data and specifications submitted with the application under which this license is issued and District Application No. APCD2010-APP-001251. [Rule 14]
3. The applicant shall provide access, facilities, utilities, and any necessary safety equipment, with the exception of personal protective equipment requiring individual fitting and specialized training, for source testing and inspection upon request of the Air Pollution Control District. [Rule 19]
4. The applicant shall obtain any necessary District permits for all ancillary combustion equipment including emergency engines, prior to on-site delivery of the equipment. [Rule 10]
5. Prior to the initial startup date for any of the three combustion turbines, the applicant shall surrender to the District Class A Emission Reduction Credits (ERCs) in an amount equivalent to 84.5 tons per year of oxides of nitrogen (NO_x) to offset the net maximum allowable increase of 70.4 tons per year of NO_x emissions for the three combustion turbines described in District Application No. APCD2010-APP-001251. [Rule 20.3(d)(8)]
6. A rolling 12-calendar-month period is one of a series of successive consecutive 12-calendar-month periods. The initial 12-month-calendar period of such a series shall begin on the first day of the month in which the applicable beginning date for that series occurs as specified in this permit. [Rule 20.3(d)(3), Rule 20.3(d)(8) and Rule 21].
7. Pursuant to 40 CFR §72.30(b)(2)(ii) of the Federal Acid Rain Program, the applicant shall submit an application for a Title IV Operating Permit at least 24 months prior to the initial startup of the combustion turbines. [40 CFR Part 72]
8. The applicant shall comply with all applicable provisions of 40 CFR Part 73, including requirements to acquire, hold and retire sulfur dioxide (SO₂) allowances. [40 CFR Part 73]
9. All records required by this permit shall be maintained on site for a minimum of five years and made available to the District upon request. [Rule 21]

COMBUSTION TURBINE CONDITIONS

Definitions

10. For purposes of determining compliance with the emission limits of this permit, a shutdown period is the 11 minutes period preceding the moment at which fuel flow ceases. [Rule 20.3(d)(1)]

11. A startup period is the period of time that begins when fuel flows to the combustion turbine following a non-operational period. For purposes of determining compliance with the emission limits of this permit, the duration of a startup period shall not exceed 30 consecutive minutes. [Rule 20.3(d)(1)]
12. A non-operational period is any five-consecutive-minute period when fuel does not flow to the combustion turbine. [Rule 20.3(d)(1)]
13. A Continuous Emission Monitoring System (CEMS) protocol is a document approved in writing by the District that describes the methodology and quality assurance and quality control procedures for monitoring, calculating, and recording stack emissions from the combustion turbine that is monitored by the CEMS. [Rules 69.3, 69.3.1, and 20.3(d)(1) and 40 CFR Part 60 Subpart KKKK, and 40 CFR Part 75]
14. For each combustion turbine, the commissioning period is the period of time commencing with the initial startup of that turbine and ending after 112 hours of turbine operation, or the date the permittee notifies the District the commissioning period has ended. For purposes of this condition, the number of hours of turbine operation is defined as the total unit operating minutes during the commissioning period divided by 60. [Rule 20.3(d)(1)]
15. For each combustion turbine, a unit operating day, hour, and minute mean the following:
 - a. A unit operating day means any calendar day in which the turbine combusts fuel.
 - b. A unit operating hour means any clock hour in which the turbine combusts fuel for any part of the hour or for the entire hour.
 - c. A unit operating minute means any clock minute in which the turbine combusts any fuel.[Rule 21, 40 CFR Part 75, Rule 20.3(d)(1), 40 CFR Part 60 Subpart KKKK]
16. Tuning is defined as adjustments to the combustion or emission control system that involves operating the combustion turbine or emission control system in a manner such that the emissions control equipment may not be fully effective or operational. Only one gas turbine shall be tuned at any given time. Tuning events shall not exceed 720 unit operating minutes in a calendar day nor exceed 40 hours in a calendar year for each turbine. The District compliance division shall be notified at least 24 hours in advance of any tuning event. For purposes of this condition, the number of hours of tuning in a calendar year is defined as the total unit operating minutes of tuning during the calendar year divided by 60. [Rule 20.3(d)(1)]

General Conditions

17. The exhaust stacks for each combustion turbine shall be at least 100 feet in height above site base elevation. [Rules 20.3(d)(2) and 1200]
18. The combustion turbines shall be fired on Public Utility Commission (PUC) quality natural gas. The permittee shall maintain, on site, quarterly records of the natural gas sulfur content (grains of sulfur compounds per 100 dscf of natural gas) and hourly records of the higher and lower heating values (btu/scf) of the natural gas; and provide records to District personnel upon request. [Rule 20.3(d)(1)]
19. Unless otherwise specified in this permit or the District approved CEMS protocol, all continuous monitoring data shall be collected at least once every minute. [Rules 69.3, 69.3.1, and 20.3(d)(1)]

Emission Limits

20. For purposes of determining compliance with emission limits based on source testing, the average of three subtests shall be used. For purposes of determining compliance with emission limits based on a Continuous Emission Monitoring System (CEMS), data collected in accordance with the CEMS protocol shall be used and the averages for averaging periods specified herein shall be calculated as specified in the CEMS protocol. [Rules 69.3, 69.3.1, and 20.3(d)(1) and 40 CFR Part 60 Subpart KKKK, and 40 CFR Part 75]
21. For purposes of determining compliance with emission limits based on CEMS data, all CEMS calculations, averages, and aggregates shall be performed in accordance with the CEMS protocol approved in writing by the District. [Rules 69.3, 69.3.1, and 20.3(d)(1) and 40 CFR Part 60 Subpart KKKK, and 40 CFR Part 75]
22. For each emission limit expressed as pounds, pounds per hour, or parts per million based on a one-hour or less averaging period or compliance period, compliance shall be based on using data collected at least once every minute when compliance is based on CEMS data except as specified in the District approved CEMS protocol [Rules 69.3, 69.3.1, and 20.3(d)(1)]
23. When a combustion turbine is combusting fuel (operating), the emission concentration of oxides of nitrogen (NO_x), calculated as nitrogen dioxide (NO₂), shall not exceed 2.5 parts per million by volume on a dry basis (ppmvd) corrected to 15% oxygen averaged over a 1-clock-hour average , except during commissioning, startup and shutdown periods for that turbine.
[Rule 20.3(d)(1)]
24. When a combustion turbine is operating, the emission concentration of carbon monoxide (CO) shall not exceed 4.0 ppmvd corrected to 15 % oxygen, averaged over a 1-clock-hour period, except during commissioning, startup and shutdown periods for that turbine.
[Rule 20.3(d)(1)]
25. When a combustion turbine is operating, the volatile organic compound (VOC) concentration, calculated as methane, measured in the exhaust stack, shall not exceed 2.0 ppmvd corrected to 15% oxygen, except during commissioning, startup and shutdown periods for that turbine. For purposes of determining compliance based on the CEMS, the District approved VOC/CO surrogate relationship, the CO CEMS data, averaged over a 1-clock-hour period be used. The VOC/CO surrogate relationship shall be verified and/or modified, if necessary, based on source testing. [Rule 20.3(d)(1)]
26. When a combustion turbine is operating, the ammonia concentration (ammonia slip), shall not exceed 5.0 ppmvd corrected to 15 % oxygen, except during commissioning, startup and shutdown periods for that turbine. [Rule 1200]
27. When a combustion turbine is operating with post-combustion air pollution control equipment that controls oxides of nitrogen (NO_x) emissions, the emission concentration NO_x, calculated as nitrogen dioxide (NO₂), shall not exceed 13.9 ppmvd calculated over each clock-hour period and corrected to 15% oxygen, except startup and shutdown periods, as defined in Rule 69.3.1. This limit does not apply during any period in which the facility is subject to a variance from the emission limits contained in Rule 69.3.1. [Rule 69.3.1]

28. When a combustion turbine is operating without any post-combustion air pollution control equipment that controls oxides of nitrogen (NOx) emissions, the emission concentration of NOx calculated as nitrogen dioxide (NO₂) from each turbine shall not exceed 23.2 parts per million by volume on a dry basis (ppmvd) calculated over each clock-hour period and corrected to 15% oxygen, except for startup and shutdown periods, as defined in Rule 69.3.1. This limit does not apply during any period in which the facility is subject to a variance from the emission limits contained in Rule 69.3.1. [Rule 69.3.1]
29. When a combustion turbine is operating, the emission concentration of oxides of nitrogen (NOx), calculated as nitrogen dioxide (NO₂) shall not exceed 42 ppmvd calculated over each clock-hour period and corrected to 15% oxygen, on a dry basis, except during startup and shutdown periods, as defined in Rule 69.3. This limit does not apply during any period in which the facility is subject to a variance from the emission limits contained in Rule 69.3. [Rule 69.3]
30. For each rolling 4-unit-operating- hour period, average emission concentration of oxides of nitrogen (NOx) for each turbine calculated as nitrogen dioxide (NO₂) in parts per million by volume dry (ppmvd) corrected to 15% oxygen or, alternatively, as elected by the permittee, the average NOx emission rate in pounds per megawatt-hour (lb/MWh) shall not exceed an average emission limit calculated in accordance with 40 CFR Section 60.4380(b)(3). The emission concentration and emission rate averages shall be calculated in accordance with 40 CFR Section 60.4380(b)(1). The average emission concentration limit and emission rate limit shall be based on an average of hourly emission limits over the 4-unit-operating-hour period. The hourly emission concentration limit and emission rate limit shall be 15 ppmvd corrected to 15% oxygen and 0.43 lb/MWh, respectively at all times during the clock hour. The averages shall exclude all clock hours occurring before the Initial Emission Source Test but shall include emissions during all other times that the equipment is operating including, but not limited to, emissions during startup and shutdown periods. For each six-calendar-month period, emissions in excess of these limits and monitor downtime shall be identified in accordance with 40 CFR Sections 60.4350 and 60.4380(b)(2), except that Section 60.4350(c) shall not apply for identifying periods in excess of a NOx concentration limit. [40 CFR Part 60 Subpart KKKK]
31. The emissions of particulate matter less than or equal to 10 microns in diameter (PM₁₀) shall not exceed 5.5 pounds per hour for each combustion turbine. [Rule 20.3(d)(2)]
32. The discharge of particulate matter from the exhaust stack of each combustion turbine shall not exceed 0.10 grains per dry standard cubic foot (0.23 grams/dscm). The District may require periodic testing to verify compliance with this standard. [Rule 53]
33. Visible emissions from the lube oil vents and the exhaust stack of each combustion turbine shall not exceed 20% opacity for more than three (3) minutes in any period of 60 consecutive minutes. [Rule 50]
34. Mass emissions from each combustion turbine of oxides of nitrogen (NOx), calculated as NO₂; carbon monoxide (CO); and volatile organic compounds (VOC), calculated as methane, shall not exceed the following limits, except during commissioning, startup and shutdown periods for that turbine. A 1-clock-hour averaging period for these limits shall apply to CEMS data.

<u>Pollutant</u>	<u>Emission Limit, lb/hour</u>
a. NOx	8.2
b. CO	8.0
c. VOC	2.3

[Rule 20.3(d)(2)]

35. Excluding any minutes that are coincident with a shutdown period, cumulative mass emissions of oxides of nitrogen (NO_x), calculated as NO₂; carbon monoxide (CO); and volatile organic compounds (VOC), calculated as methane, during a combustion turbine's startup period shall not exceed the following limits during any startup period, except during that turbine's commissioning period.

<u>Pollutant</u>	<u>Emission Limit, lb/event</u>
a. NO _x	22.5
b. CO	17.9
c. VOC	4.7

[Rule 20.3(d)(1)]

36. Cumulative mass emissions of oxides of nitrogen (NO_x), calculated as NO₂; carbon monoxide (CO); and volatile organic compounds (VOC), calculated as methane, during a combustion turbine's shutdown period shall not exceed the following limits during any shutdown period, except during that turbine's commissioning period.

<u>Pollutant</u>	<u>Emission Limit, lb/event</u>
a. NO _x	6.0
b. CO	47.0
c. VOC	3.0

[Rule 20.3(d)(1)]

37. The oxides of nitrogen (NO_x) emissions from each combustion turbine shall not exceed 50 pounds per hour and total aggregate NO_x emissions from all combustion turbines combined shall not exceed 150 pounds per hour, calculated as nitrogen dioxide and measured over each 1-clock-hour period. These emission limits shall apply during all times one or more turbines are operating, including, but not limited to, emissions during commissioning, startup and shutdown periods. [Rule 20.3(d)(2)]
38. The carbon monoxide (CO) emissions from each combustion turbine shall not exceed 75 pounds per hour and total aggregate CO emissions from all combustion turbines combined shall not exceed 225 pounds per hour measured over each 1-clock-hour period. This emission limit shall apply during all times that one or more turbines are operating, including, but not limited to emissions during commissioning, startup and shutdown periods. [Rule 20.3(d)(2)(i)]
39. Beginning with the earlier of the initial startup dates for any combustion turbine, aggregate emissions of oxides of nitrogen (NO_x), calculated as nitrogen dioxide (NO₂); carbon monoxide (CO); volatile organic compounds (VOCs), calculated as methane; particulate matter less than or equal to 10 microns in diameter (PM₁₀); and oxides of sulfur (SO_x), calculated as sulfur dioxide (SO₂), from the combustion turbines described in District Application No. APCD2010-APP-001251, except emissions or emission units excluded from the calculation of aggregate potential to emit as specified in Rule 20.1 (d) (1), shall not exceed the following limits for each rolling 12-calendar-month period:

<u>Pollutant</u>	<u>Emission Limit, tons per year</u>
a. NO _x	70.4
b. CO	96.4

c. VOC	19.4
d. PM10	35.8
e. SOx	12.4

The aggregate emissions of each pollutant shall include emissions during all times that the equipment is operating including, but not limited to, emissions during commissioning, startup and shutdown periods. [Rules 20.3(d)(3), 20.3(d)(8) and 21]

40. The cooling tower shall be equipped with a mist eliminator designed to achieve a drift rate of 0.001% or less. Not later than 90 calendar days prior to the start of construction, the applicant shall submit to the District the final selection, design parameters and details of the mist eliminator. In addition, the maximum total dissolved solids (TDS) concentration of the water used in the cooling tower shall not exceed 5,600 ppm. The TDS concentration shall be verified through quarterly testing of the water by a certified lab using an EPA approved method. [Rule 20.3(d)(1)]
41. For each calendar month, the applicant shall maintain records, as applicable, on a calendar monthly basis, of mass emissions during each calendar month of NO_x (calculated as NO₂), CO, VOCs (calculated as methane), PM10, and SO_x (calculated as SO₂), in tons, from each emission unit described in District Application No. APCD2010-APP-001251, except for emissions or emission units excluded from the calculation of aggregate potential to emit as specified in Rule 20.1 (d) (1). These records shall be made available for inspection within 15 calendar days after the end of each calendar month. [Rules 20.3(d)(3), 20.3(d)(8) and 21]
42. For each calendar month and each rolling 12-calendar-month period, the applicant shall maintain records, as applicable, on a calendar monthly basis, of aggregate mass emissions of NO_x (calculated as NO₂), CO, VOCs (calculated as methane), PM10, and SO_x (calculated as SO₂) in tons for the emission units described in District Application No. APCD2010-APP-001251, except for emissions or emission units excluded from the calculation of aggregate potential to emit as specified in Rule 20.1 (d) (1). These records shall be made available for inspection within 15 calendar days after the end of each calendar month. [Rules 20.3(d)(3), 20.3(d)(8) and 21]

Ammonia - SCR

43. Not later than 90 calendar days prior to the start of construction, the applicant shall submit to the District the final selection, design parameters and details of the selective catalytic reduction (SCR) and oxidation catalyst emission control systems for the combustion turbines including, but not limited to, the minimum ammonia injection temperature for the SCR; the catalyst volume, space velocity and area velocity at full load; and control efficiencies of the SCR and the oxidation catalyst CO at temperatures between 100 °F and 1000 °F at space velocities corresponding to 100% load. Such information may be submitted to the District as trade secret and confidential pursuant to District Rules 175 and 176. [Rules 20.3(d)(1) and 14]
44. When a combustion turbine is operating, ammonia shall be injected at all times that the associated selective catalytic reduction (SCR) system outlet temperature is 575 degrees Fahrenheit or greater. [Rules 20.3(d)(1)]
45. Continuous monitors shall be installed on each SCR system prior to their initial operation to monitor or calculate, and record the ammonia solution injection rate in pounds per hour and the SCR outlet

temperature in degrees Fahrenheit for each unit operating minute. The monitors shall be installed, calibrated and maintained in accordance with a District approved protocol, which may be part of the CEMS protocol. This protocol, which shall include the calculation methodology, shall be submitted to the District for written approval at least 90 days prior to initial startup of the gas turbines with the SCR system. The monitors shall be in full operation at all times when the turbine is in operation. [Rules 20.3(d)(1)]

46. Except during periods when the ammonia injection system is being tuned or one or more ammonia injection systems is in manual control for compliance with applicable permit conditions, the automatic ammonia injection system serving the SCR system shall be in operation in accordance with manufacturer's specifications at all times when ammonia is being injected into the SCR system. Manufacturer specifications shall be maintained on site and made available to District personnel upon request. [Rules 20.3(d)(1)]
47. The concentration of ammonia solution used in the ammonia injection system shall be less than 20% ammonia by weight. Records of ammonia solution concentration shall be maintained on site and made available to District personnel upon request. [Rule 14]

TESTING

48. All source test or other tests required by this permit shall be performed by the District or an independent contractor approved by the District. Unless otherwise specified in this permit or authorized in writing by the District, if testing will be performed by an independent contractor and witnessed by the District, a proposed test protocol shall be submitted to the District for written approval at least 60 days prior to source testing. Additionally, the District shall be notified a minimum of 30 days prior to the test so that observers may be present unless otherwise authorized in writing by the District. [Rules 20.3(d)(1) and 1200 and 40 CFR Part 60 Subpart KKKK and 40 CFR §60.8]
49. Unless otherwise specified in this permit or authorized in writing by the District, within 45 days after completion of a source test or RATA performed by an independent contractor, a final test report shall be submitted to the District for review and approval. [Rules 20.3(d)(1) and 1200 and 40 CFR Part 60 Subpart KKKK, 40 CFR §60.8, and 40 CFR Part 75]
50. The exhaust stacks for each combustion turbine shall be equipped with source test ports and platforms to allow for the measurement and collection of stack gas samples consistent with all approved test protocols. The ports and platforms shall be constructed in accordance with District Method 3A, Figure 2, and approved by the District. Ninety days prior to construction of the turbine stacks the project owner shall provide to the District for written approval detailed plan drawings of the turbine stacks that show the sampling ports and demonstrate compliance with the requirements of this condition. [Rule 20]
51. Not later than 60 calendar days after completion of the commissioning period for each combustion turbine, an Initial Emissions Source Test shall be conducted on that turbine to demonstrate compliance with the NO_x, CO, VOC, PM₁₀, and ammonia emission standards of this permit. The source test protocol shall comply with all of the following requirements:
 - a. Measurements of NO_x and CO concentrations and emissions and oxygen (O₂) concentration shall be conducted in accordance with U.S. Environmental Protection Agency (EPA) methods 7E, 10, and 3A, respectively, and District source test Method 100, or alternative methods approved by the District and EPA.

- b. Measurement of VOC emissions shall be conducted in accordance with EPA Methods 25A and/or 18, or alternative methods approved by the District and EPA.
- c. Measurements of ammonia emissions shall be conducted in accordance with Bay Area Air Quality Management District Method ST-1B or an alternative method approved by the District and EPA.
- d. Measurements of PM10 emissions shall be conducted in accordance with EPA Method 5 and 202 or alternative methods approved by the District and EPA. For purposes of this permit, all the particulate matter measured shall be considered to be PM10.
- e. Source testing shall be performed at the normal load level, as specified in 40 CFR Part 75 Appendix A Section 6.5.2.1 (d), provided it is not less than 80% of the combustion turbine's rated load unless it is demonstrated to the satisfaction of the District that the combustion turbine cannot operate under these conditions. If the demonstration is accepted, then emissions source testing shall be performed at the highest achievable continuous power level. The District may specify additional testing at different load levels or operational conditions to ensure compliance with the emission limits of this permit and District Rules and Regulations.
- f. Measurements of particulate matter emissions shall be conducted in accordance with SDAPCD Method 5 or an alternative method approved by the District and EPA.
- g. Measurements of opacity shall be conducted in accordance with EPA Method 9 or an alternative method approved by the District and EPA.
- h. Unless otherwise authorized in writing by the District, testing for NOx, CO, VOC, PM10, and ammonia concentrations and emissions, as applicable, shall be conducted concurrently with the NOx and CO continuous emission measurement system (CEMS) Relative Accuracy Test Audit (RATA).

[Rules 20.3(d)(1) and 1200]

- 52. A renewal source test and a NOx and CO Relative Accuracy Test Audit (RATA) shall be periodically conducted on each combustion turbine to demonstrate compliance with the NOx, CO, VOC and ammonia emission standards of this permit and applicable relative accuracy requirements for the CEMS systems using District approved methods. The renewal source test and the NOx and CO RATAs shall be conducted in accordance with the applicable RATA frequency requirements of 40 CFR 75, Appendix B, Sections 2.3.1 and 2.3.3. The renewal source test shall be conducted in accordance with a protocol complying with all the applicable requirements of the source test protocol for the Initial Emissions Source Test. [Rules 69.3, 69.3.1, and 20.3(d)(1) and 40 CFR Part 60 Subpart KKKK, and 40 CFR Part 75]
- 53. Relative Accuracy Test Audits (RATAs) and all other required certification tests shall be performed and completed on the NOx CEMS in accordance with applicable provisions of 40 CFR Part 75 Appendix A and B and 40 CFR §60.4405 and on the CO CEMS in accordance with applicable provisions of 40 CFR Part 60 Appendix B and F. [Rule 21, Rule 20.3 (d)(1), 40 CFR Part 60 Subpart KKKK, and 40 CFR Part 75]
- 54. Not later than 60 calendar days after completion of the commissioning period for each combustion turbine, an initial emission source test for toxic air contaminants shall be conducted on that turbine to determine the emissions of toxic air contaminants from the combustion turbines. At a minimum the following compounds shall be tested for, and emissions, if any, quantified:

- a. Acetaldehyde
- b. Acrolein
- c. Benzene
- d. Formaldehyde
- e. Toluene
- f. Xylenes

This list of compounds may be adjusted by the District based on source test results to ensure compliance with District Rule 1200 is demonstrated. The District may require one or more or additional compounds to be quantified through source testing as needed to ensure compliance with Rule 1200. Within 60 calendar days after completion of a source test performed by an independent contractor, a final test report shall be submitted to the District for review and approval. [Rule 1200]

55. The District may require one or more of the following compounds, or additional compounds, to be quantified through source testing periodically to ensure compliance with rule 1200:

- a. Acetaldehyde
- b. Acrolein
- c. Benzene
- d. Formaldehyde
- e. Toluene
- f. Xylenes

If the District requires the permittee to perform this source testing, the District shall request the testing in writing a reasonable period of time prior to the testing date. [Rule 1200]

56. The higher heating value of the combustion turbine fuel shall be measured by ASTM D1826–94, Standard Test Method for Calorific Value of Gases in Natural Gas Range by Continuous Recording Calorimeter or ASTM D1945–96, Standard Method for Analysis of Natural Gas by Gas Chromatography or an alternative test method approved by the District and EPA. [Rules 69.3, 69.3.1, and 20.3(d)(1) and 40 CFR Part 60 Subpart KKKK, and 40 CFR Part 75]

57. The sulfur content of the combustion turbine fuel shall be sampled not less than once each calendar quarter in accordance with a protocol approved by the District, which shall be submitted to the District for approval not later than 90 days before the earlier of the initial startup dates for either of the three combustion turbines and measured with ASTM D1072–90 (Reapproved 1994), Standard Test Method for Total Sulfur in Fuel Gases; ASTM D3246–05, Standard Test Method for Sulfur in Petroleum Gas by Oxidative Microcoulometry; ASTM D4468–85 (Reapproved 2000), Standard Test Method for Total Sulfur in Gaseous Fuels by Hydrogenolysis and Rateometric Colorimetry; ASTM D6228–98 (Reapproved 2003), Standard Test Method for Determination of Sulfur Compounds in Natural Gas and Gaseous Fuels by Gas Chromatography and Flame Photometric Detection; or ASTM D6667–04, Standard Test Method for Determination of Total Volatile Sulfur in Gaseous Hydrocarbons and Liquefied Petroleum Gases by Ultraviolet Fluorescence or an alternative test method approved by the

District and EPA. Sulfur content information provided by the local serving utility may be used to satisfy this condition with the advanced written approval of the District [Rule 20.3(d)(1), Rule 21, and 40 CFR Part 75]

CONTINUOUS MONITORING

58. The applicant shall comply with the applicable continuous emission monitoring requirements of 40 CFR Part 75. [40 CFR Part 75]

59. A continuous emission monitoring system (CEMS) shall be installed on each combustion turbine and properly maintained and calibrated to measure, calculate, and record the following, in accordance with the District approved CEMS protocol:

- a. Hourly average(s) concentration of oxides of nitrogen (NO_x) uncorrected and corrected to 15% oxygen, in parts per million (ppmvd), necessary to demonstrate compliance with the NO_x limits of this permit;
- b. Hourly average concentration of carbon monoxide (CO) uncorrected and corrected to 15% oxygen, in parts per million (ppmvd), necessary to demonstrate compliance with the CO limits of this permit;
- c. Percent oxygen (O₂) in the exhaust gas for each unit operating minute;
- d. Hourly mass emissions of oxides of nitrogen (NO_x), in pounds;
- e. Cumulative mass emissions of oxides of nitrogen (NO_x) in each startup and shutdown period, in pounds;
- f. Daily mass emissions of oxides of nitrogen (NO_x), in pounds;
- g. Calendar monthly mass emissions of oxides of nitrogen (NO_x), in pounds;
- h. Rolling 4-unit-operating- hour average concentration of oxides of nitrogen (NO_x) corrected to 15% oxygen, in parts per million (ppmvd);
- i. Rolling 4-unit-operating- hour average oxides of nitrogen (NO_x) emission rate, in pounds per megawatt-hour (MWh);
- j. Calendar quarter, calendar year, and rolling 12-calendar-month period mass emissions of oxides of nitrogen (NO_x), in tons;
- k. Cumulative mass emissions of carbon monoxide (CO) in each startup and shutdown period, in pounds;
- l. Hourly mass emissions of carbon monoxide (CO), in pounds;
- m. Daily mass emission of carbon monoxide (CO), in pounds;
- n. Calendar monthly mass emission of carbon monoxide (CO), in pounds;
- o. Rolling 12-calendar-month period mass emission of carbon monoxide (CO), in tons;
- p. Average concentration of oxides of nitrogen (NO_x) and carbon monoxide (CO) uncorrected and corrected to 15% oxygen, in parts per million (ppmvd), during each unit operating minute;
- q. Average emission rate in pounds per hour of oxides of nitrogen (NO_x) and carbon monoxide (CO) during each unit operating minute.

[Rules 69.3, 69.3.1, and 20.3(d)(1) and 40 CFR Part 60 Subpart KKKK, and 40 CFR Part 75]

60. No later than 90 calendar days prior to initial startup of each combustion turbine, the applicant shall submit a CEMS protocol to the District, for written approval that shows how the CEMS will be able to meet all District monitoring requirements. [Rules 69.3, 69.3.1, and 20.3(d)(1) and 40 CFR Part 60 Subpart KKKK, and 40 CFR Part 75]

61. No later than the earlier of 90 unit operating days or 180 calendar days after each combustion turbine commences commercial operation, a Relative Accuracy Test Audit (RATA) and other required certification tests shall be performed and completed on the that turbine's NO_x CEMS in accordance with 40 CFR Part 75 Appendix A and on the CO CEMS in accordance with 40 CFR Part 60 Appendix B. The RATAs shall demonstrate that the NO_x and CO CEMS comply with the applicable relative accuracy requirements. At least 60 calendar days prior to the test date, the applicant shall submit a test protocol to the District for written approval. Additionally, the District and U.S. EPA shall be notified a minimum of 45 calendar days prior to the test so that observers may be present. Within 45 calendar days of completion of this test, a written test report shall be submitted to the District for approval. For purposes of this condition, commences commercial operation is defined as the first instance when power is sold to the electrical grid. [Rules 69.3, 69.3.1, and 20.3(d)(1) and 40 CFR Part 60 Subpart KKKK, and 40 CFR Part 75]
62. A monitoring plan in conformance with 40 CFR 75.53 shall be submitted to U.S EPA Region 9 and the District at least 45 calendar days prior to the Relative Accuracy Test Audit (RATA), as required in 40 CFR 75.62. [40 CFR Part 75]
63. The oxides of nitrogen (NO_x) and oxygen (O₂) components of the CEMS shall be certified and maintained in accordance with applicable Federal Regulations including the requirements of sections 75.10 and 75.12 of title 40, Code of Federal Regulations Part 75 (40 CFR 75), the performance specifications of appendix A of 40 CFR 75, the quality assurance procedures of Appendix B of 40 CFR 75 and the CEMS protocol approved by the District. The carbon monoxide (CO) components of the CEMS shall be certified and maintained in accordance with 40 CFR 60, Appendices B and F, unless otherwise specified in this permit, and the CEMS protocol approved by the District. [Rules 69.3, 69.3.1, and 20.3(d)(1) and 40 CFR Part 60 Subpart KKKK, and 40 CFR Part 75]
64. The CEMS shall be in operation in accordance with the District approved CEMS protocol at all times when the turbine is in operation. A copy of the District approved CEMS protocol shall be maintained on site and made available to District personnel upon request. [Rules 69.3, 69.3.1, and 20.3(d)(1) and 40 CFR Part 60 Subpart KKKK, and 40 CFR Part 75]
65. When the CEMS is not recording data and the combustion turbine is operating, hourly NO_x emissions for purposes of calendar year and rolling 12-calendar-month period emission calculations shall be determined in accordance with 40 CFR 75 Subpart C. Additionally, hourly CO emissions for rolling 12-calendar-month period emission calculations shall be determined using CO emission factors to be determined from source test emission factors, recorded CEMS data, and fuel consumption data, in terms of pounds per hour of CO for the gas turbine. Emission calculations used to determine hourly emission rates shall be reviewed and approved by the District, in writing, before the hourly emission rates are incorporated into the CEMS emission data. [Rules 20.3(d)(3) and 21 and 40 CFR Part 75]
66. Any violation of any emission standard as indicated by the CEMS shall be reported to the District's compliance division within 96 hours after such occurrence. [H&S §42706]
67. The CEMS shall be maintained and operated, and reports submitted, in accordance with the requirements of rule 19.2 Sections (d), (e), (f) (1), (f) (2), (f) (3), (f) (4) and (f) (5), and a CEMS protocol approved by the District. [Rule 19.2]

68. Except for changes that are specified in the initial approved CEMS protocol or a subsequent revision to that protocol that is approved in advance, in writing, by the District, the District shall be notified in writing at least thirty (30) calendar days prior to any planned changes made in the CEMS or Data Acquisition and Handling System (DAHS), including, but not limited to, the programmable logic controller, software which affects the value of data displayed on the CEMS / DAHS monitors with respect to the parameters measured by their respective sensing devices or any planned changes to the software that controls the ammonia flow to the SCR. Unplanned or emergency changes shall be reported within 96 hours. [Rules 69.3, 69.3.1, and 20.3(d)(1) and 40 CFR Part 60 Subpart KKKK, and 40 CFR Part 75]
69. At least 90 calendar days prior to the Initial Emissions Source Test, the applicant shall submit a monitoring protocol to the District for written approval which shall specify a method of determining the VOC/CO surrogate relationship that shall be used to demonstrate compliance with all VOC emission limits. This protocol can be provided as part of the Initial Source Emissions Test Protocol. [Rule 20.3(d)(1)]
70. Fuel flowmeters shall be installed and maintained to measure the fuel flow rate, corrected for temperature and pressure, to each combustion turbine. Correction factors and constants shall be maintained on site and made available to the District upon request. The fuel flowmeters shall meet the applicable quality assurance requirements of 40 CFR Part 75, Appendix D, and Section 2.1.6. [Rules 69.3, 69.3.1, and 20.3(d)(1) and 40 CFR Part 60 Subpart KKKK, and 40 CFR Part 75]
71. Each combustion turbine shall be equipped with continuous monitors to measure, calculate, and record unit operating days and hours and the following operational characteristics:
- a. Date and time;
 - b. Natural gas flow rate to the combustion turbine during each unit operating minute, in standard cubic feet per hour;
 - c. Total heat input to the combustion turbine based the fuels higher heating value during each unit operating minute, in million British thermal units per hour (MMBtu/hr);
 - d. Higher heating value of the fuel on an hourly basis, in million British thermal units per standard cubic foot (MMBtu/scf);
 - e. Stack exhaust gas temperature during each unit operating minute, in degrees Fahrenheit;
 - f. Combustion turbine electrical energy output during each unit operating minute in gross megawatts hours (MWh);

The values of these operational characteristics shall be recorded each unit operating minute. The monitors shall be installed, calibrated, and maintained in accordance with a turbine operation monitoring protocol, which may be part of the CEMS protocol, approved by the District, which shall include any relevant calculation methodologies. The monitors shall be in full operation at all times when the combustion turbine is in operation. Calibration records for the continuous monitors shall be maintained on site and made available to the District upon request. [Rules 69.3, 69.3.1, and 20.3(d)(1) and 40 CFR Part 60 Subpart KKKK, and 40 CFR Part 75]

72. At least 90 calendar days prior to initial startup of the each combustion turbine, the applicant shall submit a turbine monitoring protocol to the District for written approval. This may be part of the CEMS protocol. [Rules 69.3, 69.3.1, and 20.3(d)(1) and 40 CFR Part 60 Subpart KKKK, and 40 CFR Part 75]

73. Operating logs or Data Acquisition and Handling System (DAHS) records shall be maintained to record the beginning and end times and durations of all startups, shutdowns, and tuning periods to the nearest minute, quantity of fuel used in each clock hour, calendar month, and 12-calendar-month period in standard cubic feet; hours of operation each day; and hours of operation during each calendar year. For purposes of this condition, the hours of turbine operation is defined as the total minutes the turbine is combusting fuel during the calendar year divided by 60. [Rules 69.3, 69.3.1, and 20.3(d)(1) and 40 CFR Part 60 Subpart KKKK, and 40 CFR Part 75]

COMMISSIONING

74. Before the end of the commissioning period for each combustion turbine, the applicant shall install post-combustion air pollution control equipment on that turbine to minimize NO_x and CO emissions. Once installed, the post-combustion air pollution control equipment shall be maintained in good condition and shall be in full operation at all times when the turbine is combusting fuel and the air pollution control equipment is at or above its minimum operating temperature. [Rule 20.3(d)(1)]
75. Thirty calendar days after the end of the commissioning period for each combustion turbine, the applicant shall submit a written progress report to the District. This report shall include, a minimum, the date the commissioning period ended, the startup and shutdown periods, the emissions of NO_x and CO during startup and shutdown periods, and the emissions of NO_x and CO during steady state operation. This report shall also detail any turbine or emission control equipment malfunction, upset, repairs, maintenance, modifications, or replacements affecting emissions of air contaminants that occurred during the commissioning period. All of the following continuous monitoring information shall be reported for each minute and, except for cumulative mass emissions, averaged over each hour of operation:
- a. Concentration of oxides of nitrogen (NO_x) uncorrected and corrected to 15% oxygen, in parts per million (ppmvd);
 - b. Concentration of carbon monoxide (CO) uncorrected and corrected to 15% oxygen, in parts per million (ppmvd);
 - c. Percent oxygen (O₂) in the exhaust gas;
 - d. Mass emissions of oxides of nitrogen (NO_x), in pounds;
 - e. Cumulative mass emissions of oxides of nitrogen (NO_x) in each startup and shutdown period, in pounds;
 - f. Cumulative mass emissions of carbon monoxide (CO) in each startup and shutdown period, in pounds
 - g. Mass emissions of carbon monoxide (CO), in pounds;
 - h. Total heat input to the combustion turbine based on the fuel's higher heating value, in million British thermal units per hour (MMBtu/hr);
 - i. Higher heating value of the fuel on an hourly basis, in million British thermal units per standard cubic foot (MMBtu/scf);
 - j. Gross electrical power output of the turbine, in megawatts hours (MWh) for each hour; and
 - k. SCR outlet temperature, in degrees Fahrenheit; and
 - l. Stack exhaust gas temperature, in degrees Fahrenheit.

The hourly average information shall be submitted in writing and in an electronic format approved by the District. The minute-by-minute information shall be submitted in an electronic format approved by the District. [Rules 69.3, 69.3.1, 20.3(d)(1) and 20.3(d)(2)]

76. For each combustion turbine, the applicant shall submit the following notifications to the District and U. S. EPA, Region IX:

- a. A notification in accordance with 40 CFR Section 60.7(a)(1) delivered or postmarked not later than 30 calendar days after construction has commenced;
- b. A notification in accordance with 40 CFR Section 60.7(a)(3) delivered or postmarked within 15 calendar days after initial startup; and
- c. An Initial Notification in accordance with 40 CFR Section 63.6145(c) and 40 CFR Section 63.9(b)(2) submitted no later than 120 calendar days after the initial startup of the turbine.

In addition, the applicant shall notify the District when: (1) construction is complete by submitting a Construction Completion Notice before operating any unit that is the subject of this permit, (2) each combustion turbine first combusts fuel by submitting a First Fuel Fire Notice within five calendar days of the initial operation of the unit, and (3) each combustion turbine first generates electrical power that is sold by providing written notice within 5 days of this event. [Rules 24 and 21 and 40 CFR Part 75, 40 CFR Part 60 Subpart KKKK, 40 CFR Part §60.7, 40 CFR Part 63 Subpart YYYY, and 40 CFR Part §63.9]

REPORTING

76. The permittee shall file semiannual reports in accordance with 40 CFR §60.4375. [40 CFR Part 60 Subpart KKKK]

77. Each semiannual report must cover the semiannual reporting period from January 1 through June 30 or the semiannual reporting period from July 1 through December 31. Each such semiannual compliance report shall be postmarked or delivered no later than January 30 or July 30, whichever date is the first date following the end of the semiannual reporting period. [40 CFR Part 60 Subpart KKKK and Rule 21]

78. All semiannual compliance reports shall be submitted to the District Compliance Division [40 CFR §60.7]

APPENDIX D

EMISSION REDUCTION CREDITS

Summary of Emission Reduction Credits (ERCs) Proposed as Offsets

ERC Certificate No.	Original Issue Date	Type	Pollutant	ERC Amount, tons per year	NOx Equivalent Amount, tons per year	Location of Emission Reductions	Description Emission Reduction	Current Owner
00019-01	4/8/2011	A	NOx	29.2	29.2	990 Bay Blvd Chula Vista, CA 91911	Shut down of Units 3 & 4	Dynergy South Bay, LLC
00019-03	4/8/2011	A	VOC	8.1	8.1	990 Bay Blvd Chula Vista, CA 91911	Shut down of Units 3 & 4	Dynergy South Bay, LLC
00039-01	8/11/2011	A	NOx	24.6	24.6	990 Bay Blvd Chula Vista, CA 91911	Shut down of Units 1 & 2 and CT	Dynergy South Bay, LLC
00039-03	8/11/2011	A	VOC	5.6	5.6	990 Bay Blvd Chula Vista, CA 91911	Shut down of Units 1 & 2 and CT	Dynergy South Bay, LLC
090819-01 090819-02	9/22/2006	A	VOC	18.7	18.7	7757 St. Andrews Ave San Diego, CA 92154	Permanent reduction in emissions from furniture coating operations	IG&E GP, LLC

BEFORE THE ENERGY RESOURCES CONSERVATION AND DEVELOPMENT
COMMISSION OF THE STATE OF CALIFORNIA
1516 NINTH STREET, SACRAMENTO, CA 95814
1-800-822-6228 – WWW.ENERGY.CA.GOV

APPLICATION FOR CERTIFICATION
FOR THE *PIO PICO ENERGY CENTER, LLC*

Docket No. 11-AFC-1
PROOF OF SERVICE
(Revised 12/16/11)

Pio Pico Energy Center, LLC

**Letter to Eric Solorio dated December 20, 2011 re San Diego Air Pollution Control
District's Publication of the Preliminary Determination of Compliance**

APPLICANT

Gary Chandler, President
Pio Pico Energy Center
P.O. Box 95592
South Jordan, UT 84095
grchandler@apexpowergroup.com

David Jenkins, Project Manager
Pio Pico Energy Center, LLC
1293 E. Jessup Way
Mooresville, IN 46158
djenkins@apexpowergroup.com

APPLICANT'S CONSULTANTS

Maggie Fitzgerald, Project Manager
URS Corporation
2020 East 1st Street, Suite 400
Santa Ana, CA 92705
maggie_fitzgerald@urscorp.com

COUNSEL FOR APPLICANT

John A. McKinsey
Melissa A. Foster
Stoel Rives, LLP
500 Capitol Mall, Suite 1600
Sacramento, CA 95814
jamckinsey@stoel.com
mafoster@stoel.com

INTERESTED AGENCIES

California ISO
e-mail service preferred
e-recipient@caiso.com

PETITIONERS

April Rose Sommer
Attorney for Rob Simpson
P.O. Box 6937
Moraga, CA 94570
e-mail service preferred
aprilsommerlaw@yahoo.com

**ENERGY COMMISSION-
DECISIONMAKERS**

CARLA PETERMAN
Commissioner and Presiding Member
cpeterma@energy.state.ca.us

KAREN DOUGLAS
Commissioner and Associate Member
e-mail service preferred
kldougla@energy.state.ca.us

Jim Bartridge
Adviser to Commissioner Peterman
jbartrid@energy.state.ca.us

Galen Lemei
Adviser to Commissioner Douglas
e-mail service preferred
glemei@energy.state.ca.us

Raoul Renaud
Hearing Officer
rrenaud@energy.state.ca.us

ENERGY COMMISSION STAFF

Eric Solorio
Siting Project Manager
esolorio@energy.state.ca.us

Kevin W. Bell
Staff Counsel
kwbell@energy.state.ca.us

Jennifer Jennings
Energy Commission Public Adviser
e-mail service preferred
publicadviser@energy.state.ca.us


DECLARATION OF SERVICE

I, Judith M. Warmuth, declare that on December 20, 2011, I deposited copies of the aforementioned document and, if applicable, a disc containing the aforementioned document in the United States mail at 500 Capitol Mall, Suite 1600, Sacramento, California 95814, with first-class postage thereon fully prepaid and addressed to those identified on the Proof of Service list above.

AND/OR

Transmission via electronic mail, personal delivery and first class U.S. mail were consistent with the requirements of California Code of Regulations, Title 20, sections 1209, 1209.5, and 1210. All electronic copies were sent to all those identified on the Proof of Service list above.

I declare under penalty of perjury under the laws of the State of California that the foregoing is true and correct, that I am employed in the county where this mailing occurred, and that I am over the age of 18 years and not a party to the proceeding.



Judith M. Warmuth