

Memorandum

To: Robert B. Weisenmiller, Chair
James D. Boyd, Vice Chair
Karen Douglas, Commissioner
Carla Peterman, Commissioner

Date: September 2, 2011
Telephone: (916) 654-4996

DOCKET

11-AFC-2

DATE SEP 02 2011

RECD. SEP 02 2011

From: California Energy Commission – Robert Oglesby
1516 Ninth Street
Sacramento, CA 95814-5512
Executive Director

**Subject: HIDDEN HILLS SOLAR ELECTRIC GENERATING SYSTEM, DATA ADEQUACY
RECOMMENDATION (11-AFC-2)**

On August 5, 2011, Hidden Hills Solar Holdings, LLC, submitted an Application for Certification (AFC) to construct and operate the Hidden Hills Solar Electric Generating System (HHSEGS). HHSEGS will be located on approximately 3,277 acres of privately owned land leased in Inyo County, California, immediately adjacent to the Nevada border. The project site is approximately 18 miles south of Pahrump, Nevada, and approximately 45 miles west of Las Vegas, Nevada.

PROJECT DESCRIPTION

HHSEGS will comprise two solar fields and associated facilities: the northern solar plant (Solar Plant 1) and the southern solar plant (Solar Plant 2). Each solar plant will generate 250 megawatts (MW), for a total net output of 500 MW. Solar Plant 1 will occupy approximately 1,483 acres (or 2.3 square miles), and Solar Plant 2 will occupy approximately 1,510 acres (or 2.4 square miles). Each solar plant will use heliostats—elevated mirrors guided by a tracking system mounted on a pylon—to focus the sun's rays on a solar receiver steam generator (SRSG) atop a 750-foot tall solar power tower near the center of each solar field. Each plant will consist of the following elements:

- One heliostat array with about 85,000 heliostats;
- A power block containing a Rankine-cycle non-reheat steam turbine, SRSG, feed water heaters, a deaerator, an emergency diesel generator, and a diesel fire pump;
- Five natural-gas-fired boilers, ranging in size from 1.2 MW to 50 MW;
- An air-cooled condenser to minimize water use in the desert environment; and,
- Access roads and drive zones will also be developed on the project site to facilitate operations and maintenance activities, emergency access, and site security.

Additionally, six onsite groundwater supply wells will be drilled and developed to provide approximately 140 acre feet/year of process water for HHSEGS. The transmission and natural gas pipeline alignments will be located in Nevada, primarily on federal land managed by the U.S. Bureau of Land Management (BLM), except for one small segment of the transmission line between HHSEGS and the Nevada border, and another in the vicinity of the Eldorado Substation in Boulder City, Nevada. A detailed

environmental impact analysis of the transmission and natural gas pipeline alignments will be prepared by Nevada BLM.

Following completion of project licensing and close of financing, HHSEGS will be constructed in approximately 29 months, and anticipates a commercial on-line date of first quarter 2015 for Solar Plant 1, and the second quarter of 2015 for Solar Plant 2. The Project's capital cost is estimated to exceed \$2.7 billion. An average of 648 construction workers is anticipated to be employed during the 29-month construction period, with peak employment reaching 1,087 personnel in month 15. Upon completion, HHSEGS will employ approximately 120 full-time employees.

The Energy Commission staff has completed its initial data adequacy review of the AFC and has determined that it does not meet all the requirements listed in Title 20, section 1704, and Division 2, Chapter 5, Appendix B of the California Code of Regulations for the 12-month permitting process. Of the 22 technical disciplines reviewed, staff has determined that the information contained in the AFC is deficient in nine (9) areas, namely: air quality, biological resources, cultural resources, efficiency, land use, traffic and transportation, transmission system design, visual resources and water.

Attached are a summary table and the data adequacy worksheets for all technical disciplines. The worksheets for the aforementioned sections identify the additional information that staff believe is necessary to fulfill the AFC data adequacy requirements. At the Energy Commission's business meeting on September 7, 2011, I will recommend that the Energy Commission adopt the list of deficiencies and not accept the AFC as complete until the additional information specified in the data adequacy worksheets is supplied. If you have any questions, please contact Mike Monasmith, staff's Project Manager, at (916) 654-4894.

Attachments

**ATTACHMENT A
OVERVIEW OF ENERGY COMMISSION STAFF'S
DATA ADEQUACY DETERMINATION
HIDDEN HILLS SOLAR ELECTRIC GENERATING SYSTEM
11-AFC-2**

TECHNICAL AREA	ATTACHMENT B PAGE No.	ADEQUATE? 12-MONTH
Air Quality	5	No
Alternatives	12	Yes
Biological Resources	14	No
Cultural Resources	27	No
Efficiency	37	No
Facility Design	40	Yes
Geological Hazards	43	Yes
Hazardous Materials Management	45	Yes
Land Use	48	No
Noise	53	Yes
Paleontological Resources	57	Yes
Project Overview	59	Yes
Public Health	65	Yes
Reliability	68	Yes
Socioeconomics	71	Yes
Soils	76	Yes
Traffic and Transportation	78	No
Transmission System Development	83	No
Trans Line Safety & Nuisance	88	Yes
Visual Resources	91	No
Waste Management	98	Yes
Water	102	No
Worker Safety	110	Yes

ATTACHMENT B

ENERGY COMMISSION STAFF'S List of Data Inadequacies

Hidden Hills Solar Electric Generating System 11-AFC-2

September 2, 2011

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET
 Technical Area: **Air Quality** Project: Hidden Hills Solar Electric Generating System (HHSEGS) Revision No. 0 Date 8/24/2011
 Project Manager: Mike Monasmith Docket: 11-AFC-2 Technical Staff: Jacquelyn Leyva
 Technical Senior: Gerry Bemis

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (1)	...provide a discussion of the existing site conditions, the expected direct, indirect and cumulative impacts due to the construction, operation and maintenance of the project, the measures proposed to mitigate adverse environmental impacts of the project, the effectiveness of the proposed measures, and any monitoring plans proposed to verify the effectiveness of the mitigation.	Section 5.1 pp. 5.1-1 to 5.1-72	Yes	
Appendix B (g) (8) (A)	The information necessary for the air pollution control district where the project is located to complete a Determination of Compliance.	Not Provided	No	Please provide the permit application completeness letter from the Great Basin Unified Air Pollution Control District (GBUAPD). This letter is expected in early September.
Appendix B (g) (8) (B)	The heating value and chemical characteristics of the proposed fuels, the stack height and diameter, the exhaust velocity and temperature, the heat rate and the expected capacity factor of the proposed facility.	Section 5.5 Table 5.5-2 to 5.5-4 pp. 5.5-10 to 5.5-12 Section 5.1.4.1.1 Tables 5.1-15 and 5.1-16 p. 5.1-33 Appendix Section 5.1D	Yes	
Appendix B (g) (8) (C)	A description of the control technologies proposed to limit the emission of criteria pollutants.	Section 5.1.4.11 Table 5.1-15 p. 5.1-33 Appendix 5.1C	Yes	

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. 0 Date 8/24/2011
 Technical Area: **Air Quality** Project: Hidden Hills Solar Electric Generating System (HHSEGS) Technical Staff: Jacquelyn Leyva
 Project Manager: Mike Monasmith Docket: 11-AFC-2 Technical Senior: Gerry Bemis

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (8) (D)	A description of the cooling system, the estimated cooling tower drift rate, the rate of water flow through the cooling tower, and the maximum concentrations of total dissolved solids.	Section 5.1.4.3.2 p. 5.1-42 Section 5.1.6.3 Table 5.1-42 p. 5.1-69 Appendix 5.1B Table 5.1B-10 p. 5.1B-10	Yes	
Appendix B (g) (8) (E)	The emission rates of criteria pollutants and greenhouse gases (CO ₂ , CH ₄ , N ₂ O, and SF ₆) from the stack, cooling towers, fuels and materials handling processes, delivery and storage systems, and from all on-site secondary emission sources.	Section 5.1.4.3.5 Table 5.1-28 p. 5.1-44 and 5.1-45 Section 5.1.5.3 Table 5.1-39 pp. 5.1-64 and 5.1-65	Yes	
Appendix B (g) (8) (F)(i)	A description of typical operational modes, and start-up and shutdown modes for the proposed project, including the estimated frequency of occurrence and duration of each mode, and estimated emission rate for each criteria pollutant during each mode.	Section 5.1.4.2 pp. 5.1-36 to 5.1-43 Section 5.1.4.5.7 p. 5.1-57 Table 5.1-36 to 5.1-37 pp. 5.1-57 to 5.1-60 Appendix 5.1B	Yes	
Appendix B (g) (8) (F)(ii)	A description of the project's planned initial commissioning phase, which is the phase between the first firing of emissions sources and the commercial operations date, including the types and durations of equipment tests, criteria pollutant emissions, and monitoring techniques to be used during such tests.	NA	NA	

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET
 Technical Area: **Air Quality** Project: Hidden Hills Solar Electric Generating System (HHSEGS) Revision No. 0 Date 8/24/2011
 Project Manager: Mike Monasmith Docket: 11-AFC-2 Technical Staff: Jacquelyn Leyva
 Technical Senior: Gerry Bemis

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (8) (G)	The ambient concentrations of all criteria pollutants for the previous three years as measured at the three Air Resources Board certified monitoring stations located closest to the project site, and an analysis of whether this data is representative of conditions at the project site. The applicant may substitute an explanation as to why information from one, two, or all stations is either not available or unnecessary.	Section 5.1.3 Sub Section 5.1.3.4 Tables 5.1-6 to 5.1-14 pp.5.1-23 to 5.1-31	Yes	
Appendix B (g) (8) (H)	One year of meteorological data collected from either the Federal Aviation Administration Class 1 station nearest to the project or from the project site, or meteorological data approved by the California Air Resources Board or the local air pollution control district.	Air Quality Modeling CD	Yes	
Appendix B (g) (8) (H) (i)	If the data is collected from the project site, the applicant shall demonstrate compliance with the requirements of the U.S. Environmental Protection Agency document entitled "On-Site Meteorological Program Guidance for Regulatory Modeling Applications" (EPA - 450/4-87-013 (August 1995)), which is incorporated by reference in its entirety.	NA	NA	
Appendix B (g) (8) (H) (ii)	The data shall include quarterly wind tables and wind roses, ambient temperatures, relative humidity, stability and mixing heights, upper atmospheric air data, and an analysis of whether this data is representative of conditions at the project site.	Section 5.1.4.5.2 pp. 5.1-51 to 5.1-55 Appendix 5.1A pp. 5.1A-1 to 5.1A-50 Figures 5.1-1 to 5.1-5 Air Quality Modeling CD	Yes	

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET
 Technical Area: **Air Quality** Project: Hidden Hills Solar Electric Generating System (HHSEGS) Revision No. 0 Date 8/24/2011
 Project Manager: Mike Monasmith Docket: 11-AFC-2 Technical Staff: Jacquelyn Leyva
 Technical Senior: Gerry Bemis

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (8) (I)	An evaluation of the project's direct and cumulative air quality impacts, consisting of the following:	Section 5.1.5 Appendix 5.1G	Yes	
Appendix B (g) (8) (I) (i)	A screening level air quality modeling analysis, or a more detailed modeling analysis if so desired by the applicant, of the direct criteria pollutant impacts of project construction activities on ambient air quality conditions, including fugitive dust (PM ₁₀) emissions from grading, excavation and site disturbance, as well as the combustion emissions [nitrogen oxides (NO _x), sulfur dioxide (SO ₂), carbon monoxide (CO), and particulate matter less than 10 microns in diameter (PM ₁₀) and particulate matter less than 2.5 microns in diameter (PM _{2.5})] from construction-related equipment;	Section 2.0 Section 5.1.4.3.8 Appendix 5.1F Air Quality Modeling CD	Yes	
Appendix B (g) (8) (I) (ii)	A screening level air quality modeling analysis, or a more detailed modeling analysis if so desired by the applicant, of the direct criteria pollutant (NO _x , SO ₂ , CO, PM ₁₀ , and PM _{2.5}) impacts on ambient air quality conditions of the project during typical (normal) operation, and during shutdown and startup modes of operation. Identify and include in the modeling of each operating mode the estimated maximum emissions rates and the assumed meteorological conditions;	Air Quality Modeling CD Appendix 5.1H	Yes	

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET
 Technical Area: **Air Quality** Project: Hidden Hills Solar Electric Generating System (HHSEGS) Revision No. 0 Date 8/24/2011
 Project Manager: Mike Monasmith Docket: 11-AFC-2 Technical Staff: Jacquelyn Leyva
 Technical Senior: Gerry Bemis

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (8) (I) (iii)	A protocol for a cumulative air quality modeling impacts analysis of the project's typical operating mode in combination with other stationary emissions sources within a six mile radius which have received construction permits but are not yet operational, or are in the permitting process. The cumulative inert pollutant impact analysis should assess whether estimated emissions concentrations will cause or contribute to a violation of any ambient air quality standard; and	Section 5.1.5 Appendix 5.1G	Yes	
Appendix B (g) (8) (I) (iv)	An air dispersion modeling analysis of the impacts of the initial commissioning phase emissions on state and federal ambient air quality standards for NO _x , SO ₂ , CO, PM ₁₀ , and PM _{2.5} .	NA	NA	
Appendix B (g) (8) (J)	If an emission offset strategy is proposed to mitigate the project's impacts under subsection (g)(1), provide the following information:	NA	NA	
Appendix B (g) (8) (J) (i)	The quantity of offsets or emission reductions that are needed to satisfy air permitting requirements of local permitting agencies (such as the air district), state and federal oversight air agencies, and the California Energy Commission. Identify by criteria air pollutant, and if appropriate, greenhouse gas; and	NA	NA	
Appendix B (g) (8) (J) (ii)	Potential offset sources, including location, and quantity of emission reductions;	NA	NA	

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET
 Technical Area: **Air Quality** Project: Hidden Hills Solar Electric Generating System (HHSEGS) Revision No. 0 Date 8/24/2011
 Project Manager: Mike Monasmith Docket: 11-AFC-2 Technical Staff: Jacquelyn Leyva
 Technical Senior: Gerry Bemis

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (8) (K)	A detailed description of the mitigation, if any, which an applicant may propose, for all projects impacts from criteria pollutants that currently exceed state or federal ambient air quality standards, but are not subject to offset requirements under the district's new source review rule.	Section 5.1.7	Yes	
Appendix B (i) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, leases, and permits applicable to the proposed project, and a discussion of the applicability of, and conformance with each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed; and	Section 5.1.2 Section 5.1.6 Table 5.1-3	Yes	
Appendix B (i) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits, leases, and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	Section 5.1.8 p. 5.1-72 Table 5.1-44	Yes	

Adequacy Issue: Adequate _____ Inadequate X **DATA ADEQUACY WORKSHEET** Revision No. 0 Date 8/24/2011
 Technical Area: **Air Quality** Project: Hidden Hills Solar Electric Generating System (HHSEGS) Technical Staff: Jacquelyn Leyva
 Project Manager: Mike Monasmith Docket: 11-AFC-2 Technical Senior: Gerry Bemis

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (i) (2)	The name, title, phone number, address (required), and email address (if known), of an official who was contacted within each agency, and also provide the name of the official who will serve as a contact person for Commission staff.	Section 5.1.8 p. 5.1-72 Table 5.1-44	Yes	
Appendix B (i) (3)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.	Section 5.1.9 p. 5.1-72	Yes	

Adequacy Issue: Adequate X Inadequate

DATA ADEQUACY WORKSHEET

Revision No. 0 Date 8/19/2011

Technical Area: Alternatives

Project: Hidden Hills SEGS

Technical Staff: Jeanine Hinde

Project Manager: Mike Monasmith

Docket: 11-AFC-02

Technical Senior: Amanda Stennick

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (b) (1) (D)	A description of how the site and related facilities were selected and the consideration given to engineering constraints, site geology, environmental impacts, water, waste and fuel constraints, electric transmission constraints, and any other factors considered by the applicant.	<p>Section 6, “Alternatives,” outlines the site selection criteria, which were used to evaluate the alternative sites’ suitability for solar power tower development (pp. 6-2 to 6-8):</p> <ul style="list-style-type: none"> • Hours of sunlight, site size, and grade • Site control (private or public) • Proximity to infrastructure (transmission lines & natural gas) • Environmental sensitivity • Jurisdiction (conformity with LORS) • Economic viability <p>Water supply was considered (pp. 6-7, 6-9 to 6-11, 6-14, & 6-19). The analysis for the No-Project Alt. includes discussions of hazardous materials, wastewater, geologic hazards, and soils (pp. 6-11 & 6-12). General effects of the No-Project Alt. are compared to the proposed project. Table 6.3-1 compares the Hidden Hills site to the Calvada South and Trona alternative sites for all environmental topic areas (pp. 6-20 & 6-21).</p>	Yes	None

Adequacy Issue: Adequate ☒ Inadequate

DATA ADEQUACY WORKSHEET

Revision No. 0 Date 8/19/2011

Technical Area: **Alternatives**

Project: Hidden Hills SEGS

Technical Staff: Jeanine Hinde

Project Manager: Mike Monasmith

Docket: 11-AFC-02

Technical Senior: Amanda Stennick

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (f) (1)	A discussion of the range of reasonable alternatives to the project, or to the location of the project, including the no project alternative, which would feasibly attain most of the basic objectives of the project but would avoid or substantially lessen any of the significant effects of the project, and an evaluation of the comparative merits of the alternatives. In accordance with Public Resources Code section 25540.6(b), a discussion of the applicant's site selection criteria, any alternative sites considered for the project, and the reasons why the applicant chose the proposed site.	<ul style="list-style-type: none"> Section 6, "Alternatives," evaluates three alternatives to the proposed project, including the No-Project Alt. The discussion of alternatives is on pp. 6-9 to 6-13. A comparative analysis of the alternatives is on pp. 6-13 to 6-20. Information on selection of the proposed site as compared to the alternative sites is on pp. 6-20 & 6-21. A discussion of alternative project configurations is on pp. 6-22 & 6-23. Project objectives are outlined on pp. 1-3 & 1-4 of Section 1, "Executive Summary," and pp. 6-1 & 6-2 of Section 6, "Alternatives." Site selection criteria are outlined on pp. 1-4 & 1-5 of Section 1 and pp. 6-2 & 6-3 of Section 6. 	Yes	None
Appendix B (f) (2)	An evaluation of the comparative engineering, economic, and environmental merits of the alternatives discussed in subsection (f)(1).	The alternatives analysis generally compares the expected environmental impacts of the alternatives on pp. 6-9 to 6-19 of Section 6, "Alternatives." The transmission line alternatives and natural gas lines are generally discussed for the project alternatives. The analysis for the No-Project Alt. briefly addresses other technologies, including a traditional natural-gas fired power plant and distribution level alternatives (pp.6-10 to 6-13). The economic viability of the alternatives is not specifically addressed, but it is implied that the alternatives carried forward for analysis are economically viable.	Yes	None

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. 0 Date 8/17/2011

Technical Area: **Biological Resources** Project: Hidden Hills Solar Electric Generating System (HHSEGS) Technical Staff: A. Golden & J. Nishida

Project Manager: Mike Monasmith Docket: Docket Number 11-AFC-02 Technical Senior: Rick York

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (1)	...provide a discussion of the existing site conditions, the expected direct, indirect and cumulative impacts due to the construction, operation and maintenance of the project, the measures proposed to mitigate adverse environmental impacts of the project, the effectiveness of the proposed measures, and any monitoring plans proposed to verify the effectiveness of the mitigation.	Existing site conditions: Section 5.2.1.1 Direct, indirect, and cumulative impacts: Sections 5.2.7 and 5.2.8 Mitigation measures: Section 5.2.9 Monitoring plans: Sections 5.2.9.1, 5.2.9.3, and Appendix 5.2I	Yes Yes Yes Yes	
Appendix B (g) (13) (A)	A regional overview and discussion of terrestrial and aquatic biological resources, with particular attention to sensitive biological resources within ten (10) miles of the project. Include a map at a scale of 1:100,000 (or other suitable scale) showing sensitive biological resource location(s) in relation to the project site and related facilities and any boundaries of a local Habitat Conservation Plan or similar open space land use plan or designation. Sensitive biological resources include the following:	Regional overview: Sections 5.2.1.1 and 5.2.6; Appendices 5.2D, 5.2F, and 5.2H Regional vicinity maps: Figures 5.2-1 and 5.2-2; Appendices 5.2D Figure 1 and 5.2F Figures 2 and 3	No	Please provide a map at 1:100,000 scale of sensitive biological resources within 10 miles of the project site and related facilities and any boundaries of a local Habitat Conservation Plan or similar open space land use plan or designation.

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. 0 Date 8/17/2011
 Technical Area: **Biological Resources** Project: Hidden Hills Solar Electric Generating System (HHSEGS) Technical Staff: A. Golden & J. Nishida
 Project Manager: Mike Monasmith Docket: Docket Number 11-AFC-02 Technical Senior: Rick York

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (13) (A) (i)	species listed under state or federal Endangered Species Acts;	Federal and State Endangered Species: Tables 5.2-2 and 5.2-7 Sections 5.2.2.1 and 5.2.6.7; Appendices 5.2B and 5.2G	Yes	
Appendix B (g) (13) (A) (ii)	resources defined in sections 1702(q) and (v) of Title 20 of the California Code of Regulations;	Areas of critical concern and species of special concern: Tables 5.2-2 and 5.2-7 Sections 5.2.1.1, 5.2.2.2, 5.2.3.1.7, and 5.2.7.9	Yes	
Appendix B (g) (13) (A) (iii)	species identified as state Fully Protected;	State Fully Protected species: Table 5.2.7 Section 5.2.6.7	Yes	
Appendix B (g) (13) (A) (iv)	species covered by Migratory Bird Treaty Act;	Migratory Bird Act species: Tables 5.2-7, 5.2-8, and 5.2-12	Yes	

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. 0 Date 8/17/2011

Technical Area: **Biological Resources** Project: Hidden Hills Solar Electric Generating System (HHSEGS) Technical Staff: A. Golden & J. Nishida

Project Manager: Mike Monasmith Docket: Docket Number 11-AFC-02 Technical Senior: Rick York

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (13) (A) (v)	species and habitats identified by local, state, and federal agencies as needing protection, including but not limited to those identified by the California Natural Diversity Database, or where applicable, in Local Coastal Programs or in relevant decisions of the California Coastal Commission; and	Species and habitats identified in the California Natural Diversity Database: Sections 5.2.2.3, 5.2.6.3, Figure 5.2-3, Appendix 5.2E	No	Please contact California Department of Fish and Game regarding delineation of state waters. Discuss the potential impacts to state waters. Please provide a copy of any record of conversation and/or letter the applicant has sent to CDFG regarding the proposed project's impacts to state waters and any response to these communications.
Appendix B (g) (13) (A) (vi)	fish and wildlife species that have commercial and/or recreational value.	Fish and wildlife of commercial or recreational value: Not applicable	N/A	
Appendix B (g) (13) (B)	Include a list of the species actually observed and those with a potential to occur within 1 mile of the project site and 1,000 feet from the outer edge of linear facility corridors. Maps or aerial photographs shall include the following:	List of species observed: Tables 5.2-2 through 5.2-5, 5.2-7 through 5.2-12	Yes	

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. 0 Date 8/17/2011

Technical Area: **Biological Resources** Project: Hidden Hills Solar Electric Generating System (HHSEGS) Technical Staff: A. Golden & J. Nishida

Project Manager: Mike Monasmith Docket: Docket Number 11-AFC-02 Technical Senior: Rick York

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (13) (B) (i)	Detailed maps at a scale of 1:6,000 or color aerial photographs taken at a recommended scale of 1 inch equals 500 feet (1:6,000) with a 30 percent overlap that show the proposed project site and related facilities, biological resources including, but not limited to, those found during project-related field surveys and in records from the California Natural Diversity Database, and the associated areas where biological surveys were conducted. Label the biological resources and survey areas as well as the project facilities;	Maps of proposed project site: Figures 5.2-5a and 2.1-2 Maps of biological resources: Figures 5.2-1, 5.2-2, 5.2-5a through 5.2-5g, 5.2-6a through 5.2-6i, 5.2-7 through 5.2-12 Map of survey area: Figure 5.2-3	Yes	
Appendix B (g) (13) (B) (ii)	A depiction of the extent of the thermal plume at the surface of the water if cooling water is proposed to be discharged to a water source. Provide the location for the intake and discharge structures on an aerial photograph(s) or detailed maps. Water sources include, but are not limited to, waterways, lakes, impoundments, oceans, bays, rivers, and estuaries; and	Depiction of the thermal plume: Not applicable Location of intake and discharge structures: Not applicable	N/A N/A	

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. 0 Date 8/17/2011

Technical Area: **Biological Resources** Project: Hidden Hills Solar Electric Generating System (HHSEGS) Technical Staff: A. Golden & J. Nishida

Project Manager: Mike Monasmith Docket: Docket Number 11-AFC-02 Technical Senior: Rick York

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (13) (B) (iii)	An aerial photo or wetlands delineation maps at a scale of (1:2,400) showing any potential jurisdictional and non-jurisdictional wetlands delineated out to 250 feet from the edge of disturbance if wetlands occur within 250 feet of the project site and/or related facilities that would be included with the US Army Corps of Engineers (USACE) Section 404 Permit application. For projects proposed to be located within the coastal zone, also provide aerial photographs or maps as described above that identify wetlands as defined by the Coastal Act.	<p>Potential jurisdictional or non-jurisdictional wetlands map: Figure 5.2-12</p> <p>Coastal zone wetlands map: Not applicable</p>	<p>No</p> <p>N/A</p>	Please provide maps a scale of 1:2,400 showing any potential jurisdictional and non-jurisdictional wetlands delineated out to 250 feet from the edge of disturbance if wetlands occur within 250 feet of the project site and/or related facilities that would be included with the US Army Corps of Engineers (USACE) Section 404 Permit application.
Appendix B (g) (13) (C)	A discussion of the biological resources at the proposed project site and related facilities. Related facilities include, but are not limited to, laydown and parking areas, gas and water supply pipelines, transmission lines, and roads. The discussion shall address the distribution of vegetation community types, denning or nesting sites, population concentrations, migration corridors, breeding habitats, and other appropriate biological resources including the following:	<p>Discussion of biological resources at project site: Section 5.2.6; Appendices 5.2D and 5.2F; Figures 5.2-5a through 5.2-5i, 5.2-6a through 5.2-6i, 5.2-7, 5.2-8, 5.2-10 through 5.2-12</p> <p>Discussion of biological resources at related facilities: Section 5.2.6; Appendices 5.2D and 5.2F; Figures 5.2-5a through 5.2-5i, 5.2-6a through 5.2-6i, 5.2-7, 5.2-8, 5.2-10 through 5.2-12</p>	<p>Yes</p> <p>Yes</p>	

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. 0 Date 8/17/2011

Technical Area: **Biological Resources** Project: Hidden Hills Solar Electric Generating System (HHSEGS) Technical Staff: A. Golden & J. Nishida

Project Manager: Mike Monasmith Docket: Docket Number 11-AFC-02 Technical Senior: Rick York

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (13) (C) (i)	A list of all the species actually observed;	List of species observed: Tables 5.2-3, 5.2-4, 5.2-8, 5.2-10 through 5.2-13	Yes	
Appendix B (g) (13) (C) (ii)	A list of sensitive species and habitats with a potential to occur (as defined in (A) above); and	Sensitive species and habitats with potential to occur: Tables 5.2-2, 5.2-7, and 5.2-11	Yes	

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. 0 Date 8/17/2011

Technical Area: **Biological Resources** Project: Hidden Hills Solar Electric Generating System (HHSEGS) Technical Staff: A. Golden & J. Nishida

Project Manager: Mike Monasmith Docket: Docket Number 11-AFC-02 Technical Senior: Rick York

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (13) (C) (iii)	If cooling water is taken directly from or discharged to a surface water feature source, include a description of the intake structure, screens, water volume, intake velocity hydraulic zone field of influence, and the thermal plume dispersion area as depicted in response to B(ii) above. Describe the thermal plume size and dispersion under high and low tides, and in response to local currents and seasonal changes. Provide a discussion of the aquatic habitats, biological resources, and critical life stages found in these affected waters. For repower projects that anticipate no change in cooling water flow, this information shall be provided in the form of the most recent federal Clean Water Act 316(a) and (b) studies of entrainment and impingement impacts that has been completed within the last five (5) years. For new projects or repower projects proposing to use once-through cooling and anticipating an increase in cooling water flow, provide a complete impingement and entrainment analysis per guidance in (D)(ii), below.	Intake structure characteristics: Not applicable Thermal plume description: Not applicable Aquatic habitat and biological resources affected: Not applicable Impingement and entrainment analysis: Not applicable	N/A N/A N/A N/A	

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. 0 Date 8/17/2011

Technical Area: **Biological Resources** Project: Hidden Hills Solar Electric Generating System (HHSEGS) Technical Staff: A. Golden & J. Nishida

Project Manager: Mike Monasmith Docket: Docket Number 11-AFC-02 Technical Senior: Rick York

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (13) (D)	A description and results of all field studies and seasonal surveys used to provide biological baseline information about the project site and associated facilities. Include copies of the California Natural Diversity Database records and field survey forms completed by the applicant's biologist(s). Identify the date(s) the surveys were completed, methods used to complete the surveys, and the name(s) and qualifications of the biologists conducting the surveys. Include:	Description of field studies: Sections 5.2.5 and 5.2.6; Appendices 5.2D, 5.2F, and 5.2H Copies of CNDDDB records and field survey forms: Qualifications of biologists: Appendices 5.2A and 5.2C	Yes No No	Have UTM coordinates for sensitive species encountered in Appendix 5.2F. Please provide verification that field forms and maps have been provided to the CNDDDB. Missing resumes of Christine Stirling, Mercy Vaughn, Steve Boland, and Dan Williams and any other biologist(s) that worked on the avian point count surveys whose resumes were not included the AFC.
Appendix B (g) (13) (D) (i)	Current biological resources surveys conducted using appropriate field survey protocols during the appropriate season(s). State and federal agencies with jurisdiction shall be consulted for field survey protocol guidance prior to surveys if a protocol exists;	Current biological surveys: Sections 5.2.5.5, 5.2.5.6, 5.2.6; Appendices 5.2D, 5.2F, and 5.2H	No	Protocol surveys were not conducted for western burrowing owl and golden eagle. Please follow survey protocol guidance from Page 2010 for golden eagle and California Burrowing Owl Consortium 1993 for western burrowing owl. Please provide an assessment of potential impacts to roosting and foraging habitat for bats.

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. 0 Date 8/17/2011

Technical Area: **Biological Resources** Project: Hidden Hills Solar Electric Generating System (HHSEGS) Technical Staff: A. Golden & J. Nishida

Project Manager: Mike Monasmith Docket: Docket Number 11-AFC-02 Technical Senior: Rick York

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (13) (D) (ii)	If cooling water is proposed to be taken directly from or discharged to a surface water feature source, seasonal aquatic resource studies and surveys shall be conducted. Aquatic resource survey data shall include, but is not limited to, fish trawls, ichthyoplankton and benthic sampling, and related temperature and water quality samples. For new projects or repower projects anticipating a change in cooling water flows, sampling protocols shall be provided to the Energy Commission staff for review and concurrence prior to the start of sampling. For repower projects not anticipating a change in cooling water flows, this information shall be provided in the form of the most recent federal Clean Water Act 316(b) impingement and entrainment impact study completed within five (5) years of the AFC filing date; and	Aquatic resource studies and surveys: Not applicable Aquatic resource survey data or impingement and entrainment impact study: Not applicable	N/A N/A	
Appendix B (g) (13) (D) (iii)	If the project or any related facilities could impact a jurisdictional or non-jurisdictional wetland, provide completed Army Corps of Engineers wetland delineation forms and/or determination of wetland status pursuant to Coastal Act requirements, name(s) and qualifications of biologist(s) completing the delineation, the results of the delineation and a table showing wetland acreage amounts to be impacted.	Impacts to jurisdictional or non-jurisdictional wetlands: Not applicable	N/A	
Appendix B (g) (13) (E)	Impacts discussion of the following:			

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. 0 Date 8/17/2011

Technical Area: **Biological Resources** Project: Hidden Hills Solar Electric Generating System (HHSEGS) Technical Staff: A. Golden & J. Nishida

Project Manager: Mike Monasmith Docket: Docket Number 11-AFC-02 Technical Senior: Rick York

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (13) (E) (i)	all impacts (direct, indirect, and cumulative) to biological resources from project site preparation, construction activities, plant operation, maintenance, and closure. Discussion shall also address sensitive species habitat impacts from cooling tower drift and air emissions;	Project site impacts: Section 5.2.7	No	Please provide a discussion of potential impacts to biological resources from plant closure. Please address the project's impacts to the following biological resources: special status plant species, Nelson's bighorn sheep spring foraging habitat, desert kit fox, golden eagle, special status bats, state waters, and the effects of the power tower and other structures to avian species.
		Air emission impacts on sensitive species habitat:	No	Please provide a discussion of potential impacts of dust and nitrogen deposition on sensitive species habitat.
Appendix B (g) (13) (E) (ii)	facilities that propose to take water directly from, and/or discharge water to surface water features, daytime and nighttime impacts from the intake and discharge of water during operation, water velocity at the intake screen, the intake field of influence, impingement, entrainment, and thermal discharge. Provide a discussion of the extent of the thermal plume, effluent chemicals, oxygen saturation, intake pump operations, and the volume and rate of cooling water flow at the intake and discharge location; and	Intake impacts: Not applicable	N/A	
		Thermal plume impacts: Not applicable	N/A	

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. 0 Date 8/17/2011
 Technical Area: **Biological Resources** Project: Hidden Hills Solar Electric Generating System (HHSEGS) Technical Staff: A. Golden & J. Nishida
 Project Manager: Mike Monasmith Docket: Docket Number 11-AFC-02 Technical Senior: Rick York

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (13) (E) (iii)	Methods to control biofouling and chemical concentrations, and temperatures that are currently being discharged or will be discharged to receiving waters.	Biofouling and chemical concentration controls: Not applicable Discharge temperatures: Not applicable	N/A N/A	
Appendix B (g) (13) (F)	A discussion of all feasible mitigation measures including, but not limited to the following:			
Appendix B (g) (13) (F) (i)	All measures proposed to avoid and/or reduce adverse impacts to biological resources;	Avoidance and minimization: Section 5.2.9	Yes	
Appendix B (g) (13) (F) (ii)	All off-site habitat mitigation and habitat improvement or compensation, and an identification of contacts for compensation habitat and management;	Habitat mitigation: Section 5.2.9.2.1 Contacts for compensation habitat:	No No	Only addresses desert tortoise. Please provide a discussion of the need for compensatory mitigation regarding western burrowing owl, special status plants, Nelson's bighorn sheep foraging habitat, desert kit fox, golden eagle foraging habitat, special status bats, and state waters. Please identify who was contacted regarding compensatory mitigation.
Appendix B (g) (13) (F) (iii)	Design features to better disperse or eliminate a thermal discharge;	Design features to eliminate thermal discharge: Not applicable	N/A	

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. 0 Date 8/17/2011
 Technical Area: **Biological Resources** Project: Hidden Hills Solar Electric Generating System (HHSEGS) Technical Staff: A. Golden & J. Nishida
 Project Manager: Mike Monasmith Docket: Docket Number 11-AFC-02 Technical Senior: Rick York

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (13) (F) (iv)	All measures proposed to avoid or minimize adverse impacts of cooling water intake. This shall include a Best Technology Available (BTA) discussion. If BTA is not being proposed, the rationale for not selecting BTA must be provided; and	Measures to minimize impacts of cooling water intake: Not applicable	N/A	
Appendix B (g) (13) (F) (v)	Educational programs to enhance employee awareness during construction and operation to protect biological resources.	Employee biological resource awareness training: Section 5.2.9.1	Yes	
Appendix B (g) (13) (G)	A discussion of compliance and monitoring programs to ensure the effectiveness of impact avoidance and mitigation measures incorporated into the project.	Monitoring compliance effectiveness:	No	Please provide a discussion of proposed mitigation effectiveness monitoring for desert tortoise, western burrowing owl, special status plants, Nelson's bighorn sheep foraging habitat, kit fox, golden eagle foraging habitat, special status bats, state waters, and impacts to avian species from the power tower and other structures.
Appendix B (g) (13) (H)	Submit copies of any preliminary correspondence between the project applicant and state and federal resource agencies regarding whether federal or state permits from other agencies such as the U. S. Fish and Wildlife Service (USFWS), the National Marine Fisheries Service (NMFS), the U.S. Army Corps of Engineers (USACE), the California Department of Fish and Game (CDFG), and the Regional Water Quality Control Board (RWCB) will be required for the proposed project.	Contact with state and federal agencies regarding permits: Table 5.2-16	No	Please contact CDFG regarding Lake and Streambed Alteration Agreement and 2081 permit and the Ventura Field Office for the USFWS regarding Section 7 consultation. Please provide a copy of any record of conversation and/or letter the applicant has sent to these agencies regarding the proposed project and any response to these communications.

Adequacy Issue: Adequate _____ Inadequate X **DATA ADEQUACY WORKSHEET** Revision No. 0 Date 8/17/2011

Technical Area: **Biological Resources** Project: Hidden Hills Solar Electric Generating System (HHSEGS) Technical Staff: A. Golden & J. Nishida

Project Manager: Mike Monasmith Docket: Docket Number 11-AFC-02 Technical Senior: Rick York

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (i) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, leases, and permits applicable to the proposed project, and a discussion of the applicability of, and conformance with each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed; and	Table identifying applicable biological resources laws, ordinances, regulations, and standards: Table 5.2-1	Yes	
Appendix B (i) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits, leases, and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	Tables identifying agencies with jurisdiction: Table 5.2-14	Yes	
Appendix B (i) (2)	The name, title, phone number, address (required), and email address (if known), of an official who was contacted within each agency, and also provide the name of the official who will serve as a contact person for Commission staff.	Agency contact information: Table 5.2-14	No	Please update Table 5.2-14 to include the CDFG and USFWS (Ventura Field Office) contacts.
Appendix B (i) (3)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.	Permit schedule: Table 5.2-16	Yes	

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. 0 Date 8/22/11
 Technical Area: Cultural Resources Project: Hidden Hills (HHSEGS) Technical Staff: Kathleen Forrest
 Project Manager: Mike Monasmith Docket: 11-AFC-2 Technical Senior: Shaelyn Strattan

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (1)	...provide a discussion of the existing site conditions, the expected direct, indirect and cumulative impacts due to the construction, operation and maintenance of the project, the measures proposed to mitigate adverse environmental impacts of the project, the effectiveness of the proposed measures, and any monitoring plans proposed to verify the effectiveness of the mitigation.	Section 5.3 Impacts 5.3.5, pp. 5.3-31–32 Mitigation 5.3.6, pp. 5.3-32–34	Yes	

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. 0 Date 8/22/11

Technical Area: Cultural Resources Project: Hidden Hills (HHSEGS) Technical Staff: Kathleen Forrest

Project Manager: Mike Monasmith Docket: 11-AFC-2 Technical Senior: Shaelyn Strattan

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (2) (A)	A summary of the ethnology, prehistory, and history of the region with emphasis on the area within no more than a 5-mile radius of the project location.	Section 5.3.3, pp. 5.3-9-21	No	<p>Prehistory: The synthesis of the general prehistory of the Mojave Desert as a whole is sufficient as a broad introduction to the archaeology of the project area, but is insufficient to underpin the development of any research model for the pedestrian survey of the project area or as a useful context to facilitate in the interpretation of the survey results. Using the Mojave Desert prehistory as a springboard and using the cultural resources technical reports and site forms that were gathered for the appendices of the AFC, please develop a discussion of the prehistoric archaeology of the immediate project area vicinity. Explain what the archaeology looks like on the ground in the vicinity of the project area.</p> <p>Ethnology: The prefilling meeting held on August 2 with the local Native American groups, specifically the Pahrump Band of Paiute and Las Vegas Paiute Tribe, clearly indicated a spiritual connection with the Pahrump Valley and the project site. The tribal members present indicated that different bands of Paiute have traditionally utilized the area, and the AFC indicates other groups were also utilizing the area. The ethnology needs to consider (a) the use of the area by each group individually; (b) how the different groups may have interrelated; (c) how the land was being used (resource identification and utilization) and what the physical manifestations of these uses may have been or are; and (d) the religious/spiritual significance of the project site and Pahrump Valley (immediate region) to the various peoples using it. The tribal members present also indicated that burials or cremations are present; a discussion of the local Native American traditions for the disposal of the dead and likely physical remains needs to be included. Additional discussion of how the project may impact the areas in proximity to, but outside the footprint of the project site, areas that have been used traditionally by the various groups, also needs to be included.</p>

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. 0 Date 8/22/11
 Technical Area: Cultural Resources Project: Hidden Hills (HHSEGS) Technical Staff: Kathleen Forrest
 Project Manager: Mike Monasmith Docket: 11-AFC-2 Technical Senior: Shaelyn Strattan

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (2) (B)	The results of a literature search to identify cultural resources within an area not less than a 1-mile radius around the project site and not less than one-quarter (0.25) mile on each side of the linear facilities. Identify any cultural resources listed pursuant to ordinance by a city or county, or recognized by any local historical or archaeological society or museum. Literature searches to identify the above cultural resources must be completed by, or under the direction of, individuals who meet the Secretary of the Interior's Professional Standards for the technical area addressed.	Literature search 5.3.3.6.1 pp. 5.3-22-24	Yes	Include discussion of any official listing or register of cultural resources, or contact with the county regarding this issue. Also include a discussion of the Old Spanish Trail Association's status and interpretation of the section of the Old Spanish Trail adjacent to the project area.
		Cultural resources listed pursuant to ordinance by a city or county, or recognized by any local historical or archaeological society or museum	No	
	Copies of California Department of Parks and Recreation (DPR) 523 forms (Title 14 CCR §4853) shall be provided for all cultural resources (ethnographic, architectural, historical, and archaeological) identified in the literature search as being 45 years or older or of exceptional importance as defined in the National Register Bulletin Guidelines, (36CFR60.4(g)). A copy of the USGS 7.5' quadrangle map of the literature search area delineating the areas of all past surveys and noting the California Historical Resources Information System (CHRIS) identifying number shall be provided. Copies also shall be provided of all technical reports whose survey coverage is wholly or partly within .25 mile of the area surveyed for the project under Section (g)(2)(C), or which report on any archaeological excavations or architectural surveys within the literature search area.	DPR forms Appendix 5.3B, Appendix B	Yes	
		USGS 7.5' quad map of literature search results Appendix 5.3B, Appendix C	Yes	
		Copies of technical reports Appendix 5.3C	Yes	

Project Manager: Mike Monasmith Docket:

11-AFC-2

Technical Senior: Shaelyn Strattan

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (2) (C)	<p>The results of new surveys or surveys less than 5 years old shall be provided if survey records of the area potentially affected by the project are more than five (5) years old. Surveys to identify new cultural resources must be completed by (or under the direction of) individuals who meet the Secretary of the Interior's Professional Standards for the technical area addressed.</p> <p>New pedestrian archaeological surveys shall be conducted inclusive of the project site and project linear facility routes, extending to no less than 200' around the project site, substations and staging areas, and to no less than 50' to either side of the right-of-way of project linear facility routes. New historic architecture field surveys in rural areas shall be conducted inclusive of the project site and the project linear facility routes, extending no less than .5 mile out from the proposed plant site and from the routes of all above-ground linear facilities. New historic architecture field surveys in urban and suburban areas shall be conducted inclusive of the project site, extending no less than one parcel's distance from all proposed plant site boundaries. New historic architecture field reconnaissance ("windshield survey") in urban and suburban areas shall be conducted along the routes of all linear facilities to identify, inventory, and characterize structures and districts that appear to be older than 45 years or that are exceptionally significant, whatever their age.</p> <p>A technical report of the results of the new surveys, conforming to the Archaeological Resource Management Report format (CA Office of Historic Preservation Feb 1990), which is incorporated by reference, shall be separately provided and submitted (under confidential cover if archaeological site locations are included).</p>	<p>New surveys 5.3.3.6.2</p> <p>New pedestrian archaeological surveys of project site 5.3.3.6.2, pp. 5.3-24–30</p> <p>Survey of project linear facility routes</p> <p>Historic architecture surveys</p> <p>Appendix 5.3B</p> <p>Page 30</p>	<p>Yes</p> <p>Yes</p> <p>N/A</p> <p>N/A</p> <p>No</p>	<p>Include the research design for the project, including the theoretical basis of the proposed research, a summary of the previous research, testable hypotheses/research goals, and discussion of the test implications of the expected archaeological information, as specified in ARMR (p.27). Also discuss the results of the investigations as they relate to specific research design items and general objectives.</p>
Hidden Hills SEGS				

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. 0 Date 8/22/11

Technical Area: Cultural Resources Project: Hidden Hills (HHSEGS) Technical Staff: Kathleen Forrest

Project Manager: Mike Monasmith Docket: 11-AFC-2 Technical Senior: Shaelyn Strattan

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (2) (C) cont.	Information included in the technical report shall also be provided in the Application for Certification, except that confidential information (archaeological sites or areas of religious significance) shall be submitted under a request for confidentiality pursuant to Title 20, California Code of Regulations, § 2501 et seq. At a minimum, <u>the technical report shall include the following:</u>	Information included in the technical report shall also be provided in the Application for Certification, except that confidential information Section 5.3	No	See items above (Appendix B (g) (2) (A); Appendix B (g) (2) (B); Appendix B (g) (2) (C))
Appendix B (g) (2) (C) (i)	The summary from Appendix B (g)(2)(A) and the literature search results from Appendix B (g)(2)(B);	Appendix 5.3B, Report of Findings and Archival Research	Yes	

Adequate Inadequate X

Cultural Resources Project:

Mike Monasmith Docket:

DATA ADEQUACY WORKSHEET

Revision No. 0 Date 8/22/11

Technical Staff: Kathleen Forrest

Technical Senior: Shaelyn Strattan

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (2) (C) (ii)	The survey procedures and methodology used to identify cultural resources and a discussion of the cultural resources identified by the survey;	Appendix 5.3B, Report of Findings and Field Survey	No	<p>It is not clearly evident in the cultural resources technical report or in the images of the cultural resources on the DPR 523 site forms how the term "desert pavement" has been defined or is being used. Staff has not traversed the project area as extensively as have the cultural resources consultants to the applicant, but on the three field visits that staff has made to the project area staff has not seen any examples of a classic desert pavement. Please identify the landforms that make up the area, the age and the depositional history of those landforms, and the character of the surficial attributes of the landforms, attributes such as desert pavements.</p> <p>Assuming that desert pavements do exist in the project area, research potential may, nonetheless, exist at these lithic extraction sites in terms of addressing research questions pertaining to modes of lithic procurement and patterns of regional settlement in the Mojave Desert (see, for instance, Giambastiani 2006, 2009; Giambastiani and Basgall 1999; and Giambastiani et al. 2009). The answers to such research questions would not necessarily rely on the presence of deeply buried/stratified deposits, but rather would rely on more intensive analyses of surface and relatively shallow subsurface lithic reduction materials. Each lithic extraction area or isolated Segregated Reduction Loci (SRL) feature may not necessarily have individual value in terms of contributions to Mojave Desert prehistory. They may have more significance when the implications from a lithic extraction area are examined within a group of similar sites, located either on a specific landform or across a series of comparable landscapes (broader, multiple-property resources such as archaeological districts or landscapes, or portions thereof).</p> <p>Discuss in detail why the sites on the project site, many of which are noted to have no additional research potential due to the presence of desert pavement, would or would not contribute to the research questions above. If the applicant decides</p>
Hidden Hills SEGGS		Page 32		

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. 0 Date 8/22/11

Technical Area: Cultural Resources Project: Hidden Hills (HHSEGS) Technical Staff: Kathleen Forrest

Project Manager: Mike Monasmith Docket: 11-AFC-2 Technical Senior: Shaelyn Strattan

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (2) (C) (iii)	Copies of all new and updated DPR 523(A) forms. If a cultural resource may be impacted by the project, also include the appropriate DPR 523 detail form for each such resource;	Appendix 5.3B, Appendix B	No	Include evaluations for each resource, including whether a resource is eligible for the California Register of Historical Resources (CRHR) or eligible for listing or listed in a local register, as stated in Section 15064.5 of the CEQA Guidelines. Include a discussion of how it does/doesn't meet each criteria and a discussion of the integrity of the resource. Also include the photographs noted in the included photograph logs.
Appendix B (g) (2) (C) (iv)	A map at a scale of 1:24,000 U.S. Geological Survey quadrangle depicting the locations of all previously known and newly identified cultural resources compiled through the research required by Appendix B (g)(2)(B) and Appendix B (g)(2)(C) (ii); and	Appendix 5.3B, Appendix A and Appendix 5.3E	Yes	
Appendix B (g) (2) (C) (v)	The names and qualifications of the cultural resources specialists who contributed to and were responsible for literature searches, surveys, and preparation of the technical report.	Appendix 5.3D	No	Include the resumes for Gabriel DuPree, Dan Ewers, Eric Peters, Dmitra Chase, Ryan Rolston, Kurt Lambert, Erica Maier, Eric Hall, Humphrey Calicher, Jesse Shelmine

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. 0 Date 8/22/11
 Technical Area: Cultural Resources Project: Hidden Hills (HHSEGS) Technical Staff: Kathleen Forrest
 Project Manager: Mike Monasmith Docket: 11-AFC-2 Technical Senior: Shaelyn Strattan

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (2) (D)	Provide a copy of your request to the Native American Heritage Commission (NAHC) for information on Native American sacred sites and lists of Native Americans interested in the project vicinity, and copies of any correspondence received from the NAHC. Notify the Native Americans on the NAHC list about the project, including a project description and map. Provide a copy of all correspondence sent to Native American individuals and groups listed by the NAHC and copies of all responses. Provide a written summary of any oral responses.	Appendix 5.3A	Yes	
Appendix B (g) (2) (E)	Include in the discussion of proposed mitigation measures required by subdivision (g)(1):			
Appendix B (g) (2) (E) (i)	A discussion of measures proposed to mitigate project impacts to known cultural resources;	N/A		
Appendix B (g) (2) (E) (ii)	A set of contingency measures proposed to mitigate potential impacts to previously unknown cultural resources and any unanticipated impacts to known cultural resources; and	Appendix 5.3B Management Considerations Section 5.3.6 pp. 5.3-32–34	Yes	
Appendix B (g) (2) (E) (iii)	Educational programs to enhance employee awareness during construction and operation to protect cultural resources.	Section 5.3.6.2, p. 5.3-32	No	Generally discuss educational programs to enhance awareness during <u>operation</u> to protect cultural resources, should any resources be discovered during construction.

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. 0 Date 8/22/11
 Technical Area: Cultural Resources Project: Hidden Hills (HHSEGS) Technical Staff: Kathleen Forrest
 Project Manager: Mike Monasmith Docket: 11-AFC-2 Technical Senior: Shaelyn Strattan

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (i) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, leases, and permits applicable to the proposed project, and a discussion of the applicability of, and conformance with each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed; and	Section 5.3.2, pp. 5.3-3-9	Yes	
Appendix B (i) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits, leases, and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	-	No	Include required table
Appendix B (i) (2)	The name, title, phone number, address (required), and email address (if known), of an official who was contacted within each agency, and also provide the name of the official who will serve as a contact person for Commission staff.	Section 5.3.7, table 5.3-8, p. 5.3-34	No	Include contacts at the local level

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. 0 Date 8/22/11
 Technical Area: Cultural Resources Project: Hidden Hills (HHSEGS) Technical Staff: Kathleen Forrest
 Project Manager: Mike Monasmith Docket: 11-AFC-2 Technical Senior: Shaelyn Strattan

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (i) (3)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.	Section 5.3.8, pp. 5.3-34–35	Yes	

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. 0 Date 8/22/2011

Technical Area: **Efficiency** Project: Hidden Hills Solar Electric Generating System (HHSEGS) Technical Staff: Shahab Koshmashrab

Project Manager: Mike Monasmith Docket: 11-AFC-2 Technical Senior: Shahab Koshmashrab

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (1)	...provide a discussion of the existing site conditions, the expected direct, indirect and cumulative impacts due to the construction, operation and maintenance of the project, the measures proposed to mitigate adverse environmental impacts of the project, the effectiveness of the proposed measures, and any monitoring plans proposed to verify the effectiveness of the mitigation.	§§ 1.1, 1.2, 2.1, 2.2, 2.3.2	Yes	
Appendix B (h) (4) (A)	Heat and mass balance diagrams for design conditions for each mode of operation.	Figure 2.2-3	Yes	
Appendix B (h) (4) (B)	Annual fuel consumption in BTUs for each mode of operation, including hot restarts and cold starts.	-	No	Please provide expected annual natural gas consumption in BTUs
Appendix B (h) (4) (C)	Annual net electrical energy produced in MWh for each mode of operation including starts and shutdowns.	-	No	Please provide expected annual net electrical energy produced in MWh for each mode of operation (i.e.; cloud cover when using natural gas, non-cloudy days when utilizing the sunlight)
Appendix B (h) (4) (D)	Number of hours the plant will be operated in each design condition in each year.	§ 2.2.12	Yes	
Appendix B (h) (4) (E)	If the project will be a cogeneration facility, calculations showing compliance with applicable efficiency and operating standards.	N/A	N/A	

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. 0 Date 8/22/2011
 Technical Area: **Efficiency** Project: Hidden Hills Solar Electric Generating System (HHSEGS) Technical Staff: Shahab Koshmashrab
 Project Manager: Mike Monasmith Docket: 11-AFC-2 Technical Senior: Shahab Koshmashrab

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (h) (4) (F)	A discussion of alternative generating technologies available for the project, including the projected efficiency of each, and an explanation why the chosen equipment was selected over these alternatives.	§§ 1.6, 6.0, 6.7	Yes	
Appendix B (i) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, leases, and permits applicable to the proposed project, and a discussion of the applicability of, and conformance with each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed; and	N/A	N/A	
Appendix B (i) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits, leases, and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	N/A	N/A	

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. 0 Date 8/22/2011
 Technical Area: **Efficiency** Project: Hidden Hills Solar Electric Generating System (HHSEGS) Technical Staff: Shahab Koshmashrab
 Project Manager: Mike Monasmith Docket: 11-AFC-2 Technical Senior: Shahab Koshmashrab

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (i) (2)	The name, title, phone number, address (required), and email address (if known), of an official who was contacted within each agency, and also provide the name of the official who will serve as a contact person for Commission staff.	N/A	N/A	
Appendix B (i) (3)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.	N/A	N/A	

Adequacy Issue: Adequate ☒ Inadequate ☐
 Technical Area: **Facility Design**
 Project Manager: Mike Monasmith

DATA ADEQUACY WORKSHEET

Project: Hidden Hills Solar Electric Generating System (HHSEGS)
 Docket: 11-AFC-2

Revision No. 0 Date 8/18/2011
 Technical Staff: Shahab Khoshmashrab
 Technical Senior: Shahab Khoshmashrab

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (h) (1) (A)	A description of the site conditions and investigations or studies conducted to determine the site conditions used as the basis for developing design criteria. The descriptions shall include, but not be limited to, seismic and other geologic hazards, adverse conditions that could affect the project's foundation, adverse meteorological and climatic conditions, and flooding hazards, if applicable.	§§ 1.1, 1.2, 1.5, 2.1, 2.2, 2.3.1, 2.4.2, 2.4.3, 5.4; Appendices 2A through 2G	Yes	
Appendix B (h) (1) (B)	A discussion of any measures proposed to improve adverse site conditions.	§ 5.4; Appendices 2A, 2B, 2G	Yes	
Appendix B (h) (1) (C)	A description of the proposed foundation types, design criteria (including derivation), analytical techniques, assumptions, loading conditions, and loading combinations to be used in the design of facility structures and major mechanical and electrical equipment	Appendices 2A, 2B, 2G	Yes	
Appendix B (h) (1) (D)	For each of the following facilities and/or systems, provide a description including drawings, dimensions, surface-area requirements, typical operating data, and performance and design criteria for protection from impacts due to adverse site conditions:	—	—	
Appendix B (h) (1) (D) (i)	The power generation system;	§§ 1.1, 1.2, 2.1, 2.2, 2.3.1	Yes	

Adequacy Issue: Adequate X Inadequate _____

Technical Area: **Facility Design**

Project Manager: Mike Monasmith

DATA ADEQUACY WORKSHEET

Project: Hidden Hills Solar Electric Generating System (HHSEGS)

Docket: 11-AFC-2

Revision No. 0 Date 8/18/2011

Technical Staff: Shahab Khoshmashrab

Technical Senior: Shahab Khoshmashrab

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (h) (1) (D) (ii)	The heat dissipation system;	§§ 1.1, 2.1, 2.2.5, 2.3.1; Appendix 2C	Yes	
Appendix B (h) (1) (D) (iii)	The cooling water supply system, and, where applicable, pre-plant treatment procedures;	§§ 1.9.5, 2.2.4;	Yes	
Appendix B (h) (1) (D) (iv)	The atmospheric emission control system;	§ 2.2.8	Yes	
Appendix B (h) (1) (D) (v)	The waste disposal system and on-site disposal sites;	§ 2.2.6	Yes	
Appendix B (h) (1) (D) (vi)	The noise emission abatement system;	§ 5.7	Yes	
Appendix B (h) (1) (D) (vii)	The geothermal resource conveyance and re-injection lines (if applicable);	N/A	N/A	
Appendix B (h) (1) (D) (viii)	Switchyards/transformer systems; and	§§ 1.1, 2.1, 2.2.2	Yes	
Appendix B (h) (1) (D) (ix)	Other significant facilities, structures, or system components proposed by the applicant.	N/A	N/A	

Adequacy Issue: Adequate X Inadequate _____

Technical Area: **Facility Design**

Project Manager: Mike Monasmith

DATA ADEQUACY WORKSHEET

Project: Hidden Hills Solar Electric Generating System (HHSEGS)

Docket: 11-AFC-2

Revision No. 0 Date 8/18/2011

Technical Staff: Shahab Khoshmashrab

Technical Senior: Shahab Khoshmashrab

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (i) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, leases, and permits applicable to the proposed project, and a discussion of the applicability of, and conformance with each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed; and	§ 2.6.1 Appendices 2A through 2G	Yes	
Appendix B (i) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits, leases, and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	§ 5.4.7	Yes	
Appendix B (i) (2)	The name, title, phone number, address (required), and email address (if known), of an official who was contacted within each agency, and also provide the name of the official who will serve as a contact person for Commission staff.	§ 5.4.7	Yes	
Appendix B (i) (3)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.	§ 5.4.8	N/A	

Adequacy Issue: Adequate ☒ Inadequate ☐

DATA ADEQUACY WORKSHEET

Revision No. 0 Date 8/22/2011

Technical Area: Geological Hazards

Project: Hidden Hills SEGS

Technical Staff: Casey Weaver

Project Manager: Mike Monasmith

Docket: 11-AFC-02

Technical Senior: Paul Marshall

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (1)	... provide a discussion of the existing site conditions, the expected direct, indirect and cumulative impacts due to the construction, operation and maintenance of the project, the measures proposed to mitigate adverse environmental impacts of the project, the effectiveness of the proposed measures, and any monitoring plans proposed to verify the effectiveness of the mitigation.	Sections 5.4.1, 5.4.3, and 5.4.5	Yes	
Appendix B (g) (17) (A)	A summary of the geology, seismicity, and geologic resources of the project site and related facilities including linear facilities.	Section 5.4.3	Yes	
Appendix B (g) (17) (B)	A map at a scale of 1:24,000 and description of all recognized stratigraphic units, geologic structures, and geomorphic features within two (2) miles of the project site and along proposed facilities. Include an analysis of the likelihood of ground rupture, seismic shaking, mass wasting and slope stability, liquefaction, subsidence, tsunami runup, and expansion or collapse of soil structures at the plant site. Describe known geologic hazards along or crossing linear facilities.	Section 5.4.3 and Figure 5.4-1	Yes	
Appendix B (g) (17) (C)	A map and description of geologic resources of recreational, commercial, or scientific value which may be affected by the project. Include a discussion of the techniques used to identify and evaluate these resources.	Section 5.4.3.5	Yes	

Adequacy Issue: Adequate ☒ Inadequate ☐

DATA ADEQUACY WORKSHEET

Revision No. 0 Date 8/22/2011

Technical Area: **Geological Hazards**

Project: Hidden Hills SEGS

Technical Staff: Casey Weaver

Project Manager: Mike Monasmith

Docket: 11-AFC-02

Technical Senior: Paul Marshall

Appendix B (i) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, leases, and permits applicable to the proposed project, and a discussion of the applicability of, and conformance with each. The table of matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed; and	Table 5.4-1, Section 5.4.2	Yes	
Appendix B (i) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits, leases, and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	Section 5.4.7	Yes	
Appendix B (i) (2)	The name, title, phone number, address (required), and email address (if known), of an official who was contacted within each agency, and also provide the name of the official who will serve as a contact person for Commission staff.	Section 5.4.8	Yes	
Appendix B (i) (3)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.	Section 5.4.8	Yes	

Adequacy Issue: Adequate X Inadequate

Technical Area: **Hazardous Materials Management**

Project Manager: Mike Monasmith

Project: Hidden Hills (SEGS)

Docket: 11-AFC-2

DATA ADEQUACY WORKSHEET

Revision No. 0 Date 8/23/11

Technical Staff: Rick Tyler

Technical Senior: Rick Tyler

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (e) (1)	A discussion of how facility closure will be accomplished in the event of premature or unexpected cessation of operations.	Section 2.5	Yes	.
Appendix B (g) (1)	...provide a discussion of the existing site conditions, the expected direct, indirect and cumulative impacts due to the construction, operation and maintenance of the project, the measures proposed to mitigate adverse environmental impacts of the project, the effectiveness of the proposed measures, and any monitoring plans proposed to verify the effectiveness of the mitigation.	Section 5.5	Yes	
Appendix B (g) (10) (A)	A list of all materials used or stored on-site which are hazardous or acutely hazardous, as defined in Title 22, California Code of Regulations, § 66261.20 et seq., and a discussion of the toxicity of each material.	Sections 5.5.4 Tables 5.5-2 through 5.5-3	Yes	
Appendix B (g) (10) (B)	A map at a scale of 1:24,000 depicting the location of schools, hospitals, day-care facilities, emergency response facilities and long-term health care facilities, within the area potentially affected by any release of hazardous materials.	Figure 5.9 -1	Yes	
Appendix B (g) (10) (C)	A discussion of the storage and handling system for each hazardous material used or stored at the site.	Sections 5.5.4	Yes	

Adequacy Issue: Adequate ☒ Inadequate ☐

Technical Area: **Hazardous Materials Management**

Project Manager: Mike Monasmith

Project: Hidden Hills (SEGS)

Docket: 11-AFC-2

DATA ADEQUACY WORKSHEET

Revision No. 0 Date 8/23/11

Technical Staff: Rick Tyler

Technical Senior: Rick Tyler

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (10) (D)	The protocol that will be used in modeling potential consequences of accidental releases that could result in off site impacts. Identify the model(s) to be used, a description of all input assumptions, including meteorological conditions. The results of the modeling analysis can be submitted after the AFC is complete.	N.A. No regulated substances, no chemicals posing potential for off site impact	Yes	
Appendix B (g) (10) (E)	A discussion of whether a risk management plan (Health and Safety Code § 25531 et seq.) will be required, and if so, the requirements that will likely be incorporated into the plan.	Section 5.5.2.2.3	Yes	
Appendix B (g) (10) (F)	A discussion of measures proposed to reduce the risk of any release of hazardous materials.	Section 5.5	Yes	
Appendix B (g) (10) (G)	A discussion of the fire and explosion risks associated with the project.	Section 5.5.4.3	Yes	
Appendix B (i) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, leases, and permits applicable to the proposed project, and a discussion of the applicability of, and conformance with each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed; and	Section 5.5.2 Table 5.5-1	Yes	

Adequacy Issue: Adequate ☒ Inadequate ☐

Technical Area: **Hazardous Materials Management**

Project Manager: Mike Monasmith

Project: Hidden Hills (SEGS)

Docket: 11-AFC-2

DATA ADEQUACY WORKSHEET

Revision No. 0 Date 8/23/11

Technical Staff: Rick Tyler

Technical Senior: Rick Tyler

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (i) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits, leases, and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	Sections 5.15.5 Pages 20-22	Yes	
Appendix B (i) (2)	The name, title, phone number, address (required), and email address (if known), of an official who was contacted within each agency, and also provide the name of the official who will serve as a contact person for Commission staff.	Section 5.5.7 Table 5.5-1	Yes	
Appendix B (i) (3)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.	Section 5.5.8 Table 5.5-6	Yes	

Adequacy Issue: Adequate _____ Inadequate X
 Technical Area: Land Use
 Project Manager: Mike Monasmith

Project: Hidden Hills SEGS
 Docket: 11-AFC-2

DATA ADEQUACY WORKSHEET

Revision No. 0 Date 8/15/11
 Technical Staff: Christina Snow
 Technical Senior: Amanda Stennick

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (1)	...provide a discussion of the existing site conditions, the expected direct, indirect and cumulative impacts due to the construction, operation and maintenance of the project, the measures proposed to mitigate adverse environmental impacts of the project, the effectiveness of the proposed measures, and any monitoring plans proposed to verify the effectiveness of the mitigation.	Pg 5.6-7, 5.6-8, 5.6-10, 5.6-13 through 5.6-16 Section 5.6.3, 5.6.6 & 5.6.7	Yes	
Appendix B (g) (3) (A)	A discussion of existing land uses and current zoning at the site, land uses and land use patterns within one mile of the proposed site and within one-quarter mile of any project-related linear facilities. Include:	Pg 5.6-7 through 5.6-8 Section 5.6.3	Yes	
Appendix B (g) (3) (A) (i)	An identification of residential, commercial, industrial, recreational, scenic, agricultural, natural resource protection, natural resource extraction, educational, religious, cultural, and historic areas, and any other area of unique land uses;	Pg 5.6-8 Section 5.6.3.2.3	Yes	
Appendix B (g) (3) (A) (ii)	A discussion of any recent or proposed zone changes and/or general plan amendments; noticed by an elected or appointed board, commission, or similar entity at the state or local level;	Pg 5.6-9 to 5.6-10 Section 5.6.4	Yes	

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. 0 Date 8/15/11
 Technical Area: Land Use Project: Hidden Hills SEGS Technical Staff: Christina Snow
 Project Manager: Mike Monasmith Docket: 11-AFC-2 Technical Senior: Amanda Stennick

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (3) (A) (iii)	Identification of all discretionary reviews by public agencies initiated or completed within 18 months prior to filing the application for those changes or developments identified in subsection (g)(3)(A)(ii); and	Pg. 5.6-10 Section 5.6.5	Yes	
Appendix B (g) (3) (A) (iv)	Legible maps of the areas identified in subsection (g)(3)(A) potentially affected by the project, on which existing land uses, jurisdictional boundaries, general plan designations, specific plan designations, and zoning have been clearly delineated.	Figure 5.6-1 & 5.6-2	Yes	
Appendix B (g) (3) (B)	A discussion of the compatibility of the proposed project with present and expected land uses, and conformity with any long-range land use plans adopted by any federal, state, regional, or local planning agencies. The discussion shall identify the need, if any, for land use decisions by another public agency or as part of the commission's decision that would be necessary to make the project conform to adopted federal, state, regional, or local coastal plans, land use plans, or zoning ordinances. Examples of land use decisions include: general plan amendments, zoning changes, lot line adjustments, parcel mergers, subdivision maps, Agricultural Land Conservation Act contracts cancellation, and Airport Land Use Plan consistency determinations.	Pgs 5.6-11 through 5.6-13 Section 5.6.6.2.1	Yes	

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. 0 Date 8/15/11

Technical Area: Land Use Project: Hidden Hills SEGS Technical Staff: Christina Snow

Project Manager: Mike Monasmith Docket: 11-AFC-2 Technical Senior: Amanda Stennick

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (3) (C)	A discussion of the legal status of the parcel(s) on which the project is proposed. If the proposed site consists of more than one legal parcel, describe the method and timetable for merging or otherwise combining those parcels so that the proposed project, excluding linears and temporary laydown or staging area, will be located on a single legal parcel. The merger need not occur prior to a decision on the Application but must be completed prior to the start of construction.	Page 2-3 Pg. 5-6-11 Section 2.1.1	No	The AFC lists assessor's parcel numbers and there is mention of the applicant's proposed merger/subdivision or reversion to acreage map but there is no discussion of the method or timetable of the merger/reversion to acreage or how many parcels would be involved. Please provide a discussion of the legal status of the parcel(s) on which the project is proposed. Please describe the method and timetable for merging or otherwise combining those parcels so that the proposed project, excluding linears and temporary laydown or staging area, will be located on a single legal parcel.
Appendix B (g) (3) (D)	A map at a scale of 1:24,000 and written description of agricultural land uses found within all areas affected by the proposed project. The description shall include:	No Agricultural Lands	N/A	
Appendix B (g) (3) (D) (i)	Crop types, irrigation systems, and any special cultivation practices;	No Agricultural Lands	N/A	
Appendix B (g) (3) (D) (ii)	Whether farmland affected by the project is prime, of statewide importance, or unique as defined by the California Department of Conservation; and	No Agricultural Lands	N/A	

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. 0 Date 8/15/11
 Technical Area: Land Use Project: Hidden Hills SEGS Technical Staff: Christina Snow
 Project Manager: Mike Monasmith Docket: 11-AFC-2 Technical Senior: Amanda Stennick

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (3) (D) (iii)	Direct, indirect, and cumulative effects on agricultural land uses. If the proposed site or related facilities are subject to an Agricultural Land Conservation contract, provide a written copy and a discussion of the status of the expiration or canceling of such contract.	No Agricultural Lands	N/A	
Appendix B (i) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, leases, and permits applicable to the proposed project, and a discussion of the applicability of, and conformance with each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed; and	Pg 5.6-5 through 5.6-7 Section 5.6.2, Table 5.6-2	Yes	
Appendix B (i) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits, leases, and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	Pg. 5.6-3 Section 5.6.2, Table 5.6-1	Yes	

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. 0 Date 8/15/11
 Technical Area: Land Use Project: Hidden Hills SEGS Technical Staff: Christina Snow
 Project Manager: Mike Monasmith Docket: 11-AFC-2 Technical Senior: Amanda Stennick

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (i) (2)	The name, title, phone number, address (required), and email address (if known), of an official who was contacted within each agency, and also provide the name of the official who will serve as a contact person for Commission staff.	Pg 5.6-16 Section 5.6.9, Table 5.6-6	Yes	
Appendix B (i) (3)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.	Not Applicable	N/A	

Adequacy Issue:	Adequate <u> X </u> Inadequate <u> </u>	DATA ADEQUACY WORKSHEET		Revision No. <u> 0 </u>	Date <u> 8/23/2011 </u>
Technical Area:	Noise	Project:	Hidden Hills Solar Electric Generating System (HHSEGS)	Technical Staff:	Shahab Khoshmashrab
Project Manager:	Mike Monasmith	Docket:	11-AFC-2	Technical Senior:	Shahab Khoshmashrab

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (1)	...provide a discussion of the existing site conditions, the expected direct, indirect and cumulative impacts due to the construction, operation and maintenance of the project, the measures proposed to mitigate adverse environmental impacts of the project, the effectiveness of the proposed measures, and any monitoring plans proposed to verify the effectiveness of the mitigation.	§§ 5.7.1, 5.7.4, 5.7.5, 5.7.6, 5.7.7	Yes	
Appendix B (g) (4) (A)	A land use map which identifies residences, hospitals, libraries, schools, places of worship, or other facilities where quiet is an important attribute of the environment within the area impacted by the proposed project. The area potentially impacted by the proposed project is that area where, during either construction or operation, there is a potential increase of 5 dBA or more, over existing background levels.	Figures 5.6-1, 5.7-1	Yes	

Adequacy Issue: Adequate X Inadequate _____

Technical Area: **Noise**

Project Manager: Mike Monasmith

DATA ADEQUACY WORKSHEET

Project: Hidden Hills Solar Electric Generating System (HHSEGS)

Docket: 11-AFC-2

Revision No. 0 Date 8/23/2011

Technical Staff: Shahab Khoshmashrab

Technical Senior: Shahab Khoshmashrab

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (4) (B)	A description of the ambient noise levels at those sites identified under subsection (g)(4)(A) which the applicant believes provide a representative characterization of the ambient noise levels in the project vicinity, and a discussion of the general atmospheric conditions, including temperature, humidity, and the presence of wind and rain at the time of the measurements. The existing noise levels shall be determined by taking noise measurements for a minimum of 25 consecutive hours at a minimum of one site. Other sites may be monitored for a lesser duration at the applicant's discretion, preferably during the same 25-hour period. The results of the noise level measurements shall be reported as hourly averages in Leq (equivalent sound or noise level), Ldn (day-night sound or noise level) or CNEL (Community Noise Equivalent Level) in units of dBA. The L10, L50, and L90 values (noise levels exceeded 10 percent, 50 percent, and 90 percent of the time, respectively) shall also be reported in units of dBA.	§ 5.7.4.1	Yes	
Appendix B (g) (4) (C)	A description of the major noise sources of the project, including the range of noise levels and the tonal and frequency characteristics of the noise emitted.	§§ 5.7.4, 5.7.5 Tables 5.7-7, 5.7-8	Yes	

Adequacy Issue:	Adequate <u> X </u> Inadequate <u> </u>	DATA ADEQUACY WORKSHEET	Revision No. <u> 0 </u>	Date <u> 8/23/2011 </u>
Technical Area:	Noise	Project: <u>Hidden Hills Solar Electric Generating System (HHSEGS)</u>	Technical Staff:	<u>Shahab Khoshmashrab</u>
Project Manager:	<u>Mike Monasmith</u>	Docket: <u>11-AFC-2</u>	Technical Senior:	<u>Shahab Khoshmashrab</u>

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (4) (D)	An estimate of the project noise levels, during both construction and operation, at residences, hospitals, libraries, schools, places of worship or other facilities where quiet is an important attribute of the environment, within the area impacted by the proposed project.	§§ 5.7.5, 5.7.5.2, 5.7.5.3, 5.7.5.3.2	Yes	
Appendix B (g) (4) (E)	An estimate of the project noise levels within the project site boundary during both construction and operation and the impact to the workers at the site due to the estimated noise levels.	§§ 5.7.5.2, 5.7.5.3	Yes	
Appendix B (g) (4) (F)	The audible noise from existing switchyards and overhead transmission lines that would be affected by the project and estimates of the future audible noise levels that would result from existing and proposed switchyards and transmission lines. Noise levels shall be calculated at the property boundary for switchyards and at the edge of the rights-of-way for transmission lines.	§ 5.7.5.3.6	Yes	

Adequacy Issue: Adequate X Inadequate _____

Technical Area: **Noise**

Project Manager: Mike Monasmith

DATA ADEQUACY WORKSHEET

Project: Hidden Hills Solar Electric Generating System (HHSEGS)

Docket: 11-AFC-2

Revision No. 0 Date 8/23/2011

Technical Staff: Shahab Khoshmashrab

Technical Senior: Shahab Khoshmashrab

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (i) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, leases, and permits applicable to the proposed project, and a discussion of the applicability of, and conformance with each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed; and	§ 5.7.2	Yes	
Appendix B (i) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits, leases, and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	§ 5.7.8	Yes	
Appendix B (i) (2)	The name, title, phone number, address (required), and email address (if known), of an official who was contacted within each agency, and also provide the name of the official who will serve as a contact person for Commission staff.	§ 5.7.8	Yes	
Appendix B (i) (3)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.	§ 5.7.9	Yes	

Adequacy Issue: Adequate X Inadequate DATA ADEQUACY WORKSHEET Revision No.: 0 Date: 8/22/2011

Technical Area: PALEONTOLOGY Project: Hidden Hills SEGS Technical Staff: Casey Weaver
 Project Manager: Mike Monasmith Docket: 11-AFC-02 Technical Senior: Paul Marshall

Appendix B (g) (1)	...provide a discussion of the existing site conditions, the expected direct, indirect and cumulative impacts due to the construction, operation and maintenance of the project, the measures proposed to mitigate adverse environmental impacts of the project, the effectiveness of the proposed measures, and any monitoring plans proposed to verify the effectiveness of the mitigation.	Sections 5.8.1, 5.8.2, 5.8.3, 5.8.4, 5.8.5 and 5.8.6	Yes	
Appendix B (g) (16) (A)	Identification of the physiographic province and a brief summary of the geologic setting, formations, and stratigraphy of the project area. The size of the paleontological study area may vary depending on the depositional history of the region.	Section 5.8.3	Yes	
Appendix B (g) (16) (B)	A discussion of the sensitivity of the project area described in subsection (g)(16)(A) and the presence and significance of any known paleontologic localities or other paleontologic resources within or adjacent to the project. Include a discussion of sensitivity for each geologic unit identified on the most recent geologic map at a scale of 1:24,000. Provide rationale as to why the sensitivity was assigned.	Section 5.8.3.5 and 5.8.4 Appendix 5.8B	Yes	
Appendix B (g) (16) (C)	A summary of all local museums, literature searches and field surveys used to provide information about paleontologic resources in the project area described in subsection (g)(16)(A). Identify the dates of the surveys, methods used in completing the surveys, and the names and qualifications of the individuals conducting the surveys.	Section 5.8.3.4 Appendix 5.8A	Yes	
Appendix B (g) (16) (D)	Information on the specific location of known paleontologic resources, survey reports, locality records, and maps at a scale of 1:24,000, showing occurrences of fossil, finds if known, within a one-mile radius of the project and related facilities shall be included in a separate appendix to the Application and submitted to the Commission under a request for confidentiality, pursuant to Title 20, California Code of Regulations, s 2501 et seq.	Section 5.8.3.4.2	Yes	

Adequacy Issue: Adequate ☒ Inadequate ☐ DATA ADEQUACY WORKSHEET Revision No.: 0 Date: 8/22/2011

Technical Area: **PALEONTOLOGY** Project: Hidden Hills SEGS Technical Staff: Casey Weaver
 Project Manager: Mike Monasmith Docket: 11-AFC-02 Technical Senior: Paul Marshall

Appendix B (g) (16) (E)	A discussion of any educational programs proposed to enhance awareness of potential impacts to paleontological resources by employees, measures proposed for mitigation of impacts to known paleontologic resources, and a set of contingency measures for mitigation of potential impacts to currently unknown paleontologic resources.	Section 5.8.6	Yes	
Appendix B (i) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, leases, and permits applicable to the proposed project, and a discussion of the applicability of, and conformance with each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed; and	Section 5.8.2 Table 5.8-1	Yes	
v (i) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits, leases, and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	Section 5.8.2 Tables 5.8-1	Yes	
Appendix B (i) (2)	The name, title, phone number, address (required), and email address (if known), of an official who was contacted within each agency, and also provide the name of the official who will serve as a contact person for Commission staff.	Section 5.8.7 Appendix 5.8A	Yes	
Appendix B (i) (3)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.	Section 5.8.8	Yes	

Adequacy Issue: Adequate ☒ Inadequate ☐

DATA ADEQUACY WORKSHEET

Revision No. 0 Date 08/23/2011

Technical Area: **Project Overview**

Project: Hidden Hills SEGS

Technical Staff: Mike Monasmith

Project Manager: Mike Monasmith

Docket: 11-AFC-2

Technical Senior: Chris Davis

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Cal. Code Regs., tit. 20, § 1704, (a) (3) (A)	Descriptions of all significant assumptions, methodologies, and computational methods used in arriving at conclusions in the document.		N/A	Please see the individual technical areas for a determination regarding the adequacy of this item.
Cal. Code Regs., tit. 20, § 1704, (a) (3) (B)	Descriptions, including methodologies and findings, of all major studies or research efforts undertaken and relied upon to provide information for the document; and a description of ongoing research of significance to the project (including expected completion dates; and		N/A	Please see the individual technical areas for a determination regarding the adequacy of this item.
Cal. Code Regs., tit. 20, § 1704, (a) (3) (C)	A list of all literature relied upon or referenced in the documents, along with brief discussions of the relevance of each such reference		N/A	Please see the individual technical areas for a determination regarding the adequacy of this item.
Cal. Code Regs., tit. 20, § 1704, (a) (4)	Each principal subject area covered in a notice or application shall be set forth in a separate chapter or section, each of which shall identify the person or persons responsible for its preparation.	Sections 3, 4 and 5	Yes	
Appendix B (a) (1) (A)	A general description of the proposed site and related facilities, including the location of the site or transmission routes, the type, size and capacity of the generating or transmission facilities, fuel characteristics, fuel supply routes and facilities, water supply routes and facilities, pollution control systems, and other general characteristics.	Section 2.1-2.2 Pages 2-2 to 2-17	Yes	

Adequacy Issue: Adequate ☒ Inadequate ☐

DATA ADEQUACY WORKSHEET

Revision No. 0 Date 08/23/2011

Technical Area: **Project Overview**

Project: Hidden Hills SEGS

Technical Staff: Mike Monasmith

Project Manager: Mike Monasmith

Docket: 11-AFC-2

Technical Senior: Chris Davis

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (a) (1) (B)	Identification of the location of the proposed site and related facilities by section, township, range, county and assessor's parcel numbers.	Pages 2-2 and 2-3 Section 2.1.1	Yes	
Appendix B (a) (1) (C)	A description of and maps depicting the region, the vicinity, and the site and its immediate surroundings.	Figures 2.1-1 and 2.1-2	Yes	
Appendix B (a) (1) (D)	A full-page color photographic reproduction depicting the visual appearance of the site prior to construction, and a full-page color simulation or artist's rendering of the site and all project components at the site, after construction.	Figures 1.5-2 and 1.5-3	Yes	
Appendix B (a) (1) (E)	In an appendix to the application, a list of current assessor's parcel numbers and owners' names and addresses for all parcels within 500 feet of the proposed transmission line and other linear facilities, and within 1000 feet of the proposed powerplant and related facilities.	Appendix A-1	Yes	
Appendix B (a) (2)	Project Schedule: Proposed dates of initiation and completion of construction, initial start-up, and full-scale operation of the proposed facilities.	Pages 2-17 and 2-18	Yes	

Adequacy Issue: Adequate ☒ Inadequate ☐

DATA ADEQUACY WORKSHEET

Revision No. 0 Date 08/23/2011

Technical Area: **Project Overview**

Project: Hidden Hills SEGS

Technical Staff: Mike Monasmith

Project Manager: Mike Monasmith

Docket: 11-AFC-2

Technical Senior: Chris Davis

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (a) (3) (A)	A list of all owners and operators of the site(s), the power plant facilities, and, if applicable, thermal host, the geothermal leasehold, the geothermal resource conveyance lines, and the geothermal re-injection system, and a description of their legal interest in these facilities.	Page 2-5 and 2-6	Yes	
Appendix B (a) (3) (B)	A list of all owners and operators of the proposed electric transmission facilities.	Section 2.1.2.5	Yes	
Appendix B (a) (3) (C)	A description of the legal relationship between the applicant and each of the persons or entities specified in subsections (a)(3)(A) and (B).	Appendix 1A	Yes	
Appendix B (b) (1)	In a section entitled, "Generation Facility Description, Design, and Operation" provide the following information:			
Appendix B (b) (1) (A)	Maps at a scale of 1:24,000 (1" = 2000'), (or appropriate map scale agreed to by staff) along with an identification of the dedicated leaseholds by section, township, range, county, and county assessor's parcel number, showing the proposed final locations and layout of the power plant and all related facilities;	Appendix 1A	Yes	

Adequacy Issue: Adequate ☒ Inadequate ☐

DATA ADEQUACY WORKSHEET

Revision No. 0 Date 08/23/2011

Technical Area: **Project Overview**

Project: Hidden Hills SEGS

Technical Staff: Mike Monasmith

Project Manager: Mike Monasmith

Docket: 11-AFC-2

Technical Senior: Chris Davis

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (b) (1) (B)	Scale plan and elevation drawings depicting the relative size and location of the power plant and all related facilities to establish the accuracy of the photo simulations required in Sections (a)(1)(D) and (g)(6)(F);	Figures 2.2-2a and 2.2-2b	Yes	
Appendix B (b) (1) (C)	A detailed description of the design, construction and operation of the facilities, specifically including the power generation, cooling, water supply and treatment, waste handling and control, pollution control, fuel handling, and safety, emergency and auxiliary systems, and fuel types and fuel use scenarios; and	Pages 2-6 through 2-16	Yes	
Appendix B (b) (1) (D)	A description of how the site and related facilities were selected and the consideration given to engineering constraints, site geology, environmental impacts, water, waste and fuel constraints, electric transmission constraints, and any other factors considered by the applicant.	Section 1.5 Pages 1-4 and 1-5	Yes	
Appendix B (b) (2)	In a section entitled, "Transmission Lines Description, Design, and Operation" provide the following information:			

Adequacy Issue: Adequate ☒ Inadequate ☐

DATA ADEQUACY WORKSHEET

Revision No. 0 Date 08/23/2011

Technical Area: **Project Overview**

Project: Hidden Hills SEGS

Technical Staff: Mike Monasmith

Project Manager: Mike Monasmith

Docket: 11-AFC-2

Technical Senior: Chris Davis

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (b) (2) (A)	Maps at a scale of 1:24,000 (or appropriate map scale agreed to by staff) of each proposed transmission line route, showing the settled areas, parks, recreational areas, scenic areas, and existing transmission lines within one mile of the proposed route(s);		N/A	Transmission Routes across state line in Nevada, outside jurisdictional consideration
Appendix B (b) (2) (B)	A full-page color photographic reproduction depicting a representative above ground section of the transmission line route prior to construction and a full-page color photographic simulation of that section of the transmission line route after construction.		N/A	Transmission Routes across state line in Nevada, outside jurisdictional consideration
Appendix B (b) (2) (C)	A detailed description of the design, construction, and operation of any electric transmission facilities, such as power lines, substations, switchyards, or other transmission equipment, which will be constructed or modified to transmit electrical power from the proposed power plant to the load centers to be served by the facility. Such description shall include the width of rights-of-way and the physical and electrical characteristics of electrical transmission facilities such as towers, conductors, and insulators.	Figures 3.2-1 and 3.2-2	Yes	

Adequacy Issue: Adequate ☒ Inadequate ☐ DATA ADEQUACY WORKSHEET Revision No. 0 Date 08/23/2011

Technical Area: **Project Overview** Project: Hidden Hills SEGS Technical Staff: Mike Monasmith

Project Manager: Mike Monasmith Docket: 11-AFC-2 Technical Senior: Chris Davis

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (b) (2) (D)	A description of how the route and additional transmission facilities were selected, and the consideration given to engineering constraints, environmental impacts, resource conveyance constraints, and electric transmission constraints; and		N/A	Transmission Routes across state line in Nevada, outside jurisdictional consideration
Appendix B (e) (1)	A discussion of how facility closure will be accomplished in the event of premature or unexpected cessation of operations.	Pages 2-29 Section 2.5.1	Yes	

Adequacy Issue: Adequate ☒ Inadequate ☐

DATA ADEQUACY WORKSHEET

Revision No. 0 Date 8/26/2011

Technical Area: Public Health
Project Manager: Mike Monasmith

Project: Hidden Hills SEGS
Docket: 11-AFC-02

Technical Staff: Obed Odoemelam
Technical Senior: Gerry Bemis

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (1)	...provide a discussion of the existing site conditions, the expected direct, indirect and cumulative impacts due to the construction, operation and maintenance of the project, the measures proposed to mitigate adverse environmental impacts of the project, the effectiveness of the proposed measures, and any monitoring plans proposed to verify the effectiveness of the mitigation.	Section 2.0, pp.2-1, 2-6, Section 5.1-1, pp 5.9-1 and 5.9-2.	Yes	
Appendix B (g) (9) (A)	An assessment of the potential risk to human health from the project's hazardous air emissions using the Air Resources Board Hotspots Analysis and Reporting Program (HARP) (HSC §§44360-44366) or its successor and Approved Risk Assessment Health Values. These values should include the cancer potency values and noncancer reference exposure levels approved by the Office of Environmental Health Hazard Assessment (OEHHA Guidelines, Cal-EPA 2005).	Section 5.1, pp 5.1-61 and 5.1-62Section 5.9, pp. 5.9-6, through 5.9-15. Appendix 5.1-E.	Yes	
Appendix B (g) (9) (B)	A listing of the input data and output results, in both electronic and print formats, used to prepare the HARP health risk assessment.	Appendix 5.1H	Yes	
Appendix B (g) (9) (C)	Identification of available health studies through the local public health department concerning the potentially affected population(s) within a six-mile radius of the proposed power plant site related to respiratory illnesses, cancers or related diseases.	Section 5.9, p. 5.9-16. Appendix 5.1G.	Yes	

Adequacy Issue: Adequate ☒ Inadequate ☐

DATA ADEQUACY WORKSHEET

Revision No. 0 Date 8/26/2011

Technical Area: Public Health
Project Manager: Mike Monasmith

Project: Hidden Hills SEGS
Docket: 11-AFC-02

Technical Staff: Obed Odoemelam
Technical Senior: Gerry Bemis

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (9) (D)	A map showing sensitive receptors within the area exposed to the substances identified in subsection (g)(9)(A).	Appendix 5.1G-1	Yes	
Appendix B (g) (9) (E)	For purposes of this section, the following definitions apply:	Section 5.9, pp 5.9-12 through 5.9-14	Yes	
Appendix B (g) (9) (E) (i)	A sensitive receptor refers to infants and children, the elderly, and the chronically ill, and any other member of the general population who is more susceptible to the effects of the exposure than the population at large;	Section 5.9, pp. 5.9-12 through 5.9-14.	Yes	
Appendix B (g) (9) (E) (ii)	An acute exposure is one which occurs over a time period of less than or equal to one (1) hour; and	Section 5.9, pp 5.9-12 through 5.9-14	Yes	
Appendix B (g) (9) (E) (iii)	A chronic exposure is one which is greater than twelve (12) percent of a lifetime of seventy (70) years.	Section 5.9, pp 5.9-12 through 5.9-14.	Yes	
Appendix B (i) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, leases, and permits applicable to the proposed project, and a discussion of the applicability of, and conformance with each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed; and	Section 5.9, p. 5.9-4.	Yes	

Adequacy Issue: Adequate ☒ Inadequate

DATA ADEQUACY WORKSHEET

Revision No. 0 Date 8/26/2011

Technical Area: Public Health
Project Manager: Mike Monasmith

Project: Hidden Hills SEGS
Docket: 11-AFC-02

Technical Staff: Obed Odoemelam
Technical Senior: Gerry Bemis

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (i) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits, leases, and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	Section 5.9,p. 5.9-17.	Yes	
Appendix B (i) (2)	The name, title, phone number, address (required), and email address (if known), of an official who was contacted within each agency, and also provide the name of the official who will serve as a contact person for Commission staff.			
Appendix B (i) (3)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.			

Adequacy Issue: Adequate X Inadequate

Technical Area: **Reliability**

Project Manager: Mike Monasmith

DATA ADEQUACY WORKSHEET

Project: Hidden Hills Solar Electric Generating System (HHSEGS)

Docket: 11-AFC-2

Revision No. 0 Date 8/22/2011

Technical Staff: Shahab Khoshmashrab

Technical Senior: Shahab Koshmashrab

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (1)	...provide a discussion of the existing site conditions, the expected direct, indirect and cumulative impacts due to the construction, operation and maintenance of the project, the measures proposed to mitigate adverse environmental impacts of the project, the effectiveness of the proposed measures, and any monitoring plans proposed to verify the effectiveness of the mitigation.	§§ 1.1, 1.2, 2.1, 2.2, 2.3.2	Yes	
Appendix B (h) (3) (A)	A discussion of the sources and availability of the fuel or fuels to be used over the estimated service life of the facilities.	§§ 2.3.2.3, 4.0	Yes	
Appendix B (h) (3) (B)	A discussion of the anticipated service life and degree of reliability expected to be achieved by the proposed facilities based on a consideration of:	—	Yes	
Appendix B (h) (3) (B) (i)	Expected overall availability factor, and annual and lifetime capacity factors;	§ 2.3.2.1	Yes	
Appendix B (h) (3) (B) (ii)	The demonstrated or anticipated feasibility of the technologies, systems, components, and measures proposed to be employed in the facilities, including the power generation system, the heat dissipation system, the water supply system, the reinjection system, the atmospheric emission control system, resource conveyance lines, and the waste disposal system;	§§ 2.3.2, 2.3.2.1, 2.3.2.2	Yes	

Adequacy Issue: Adequate ☒ Inadequate ☐

Technical Area: **Reliability**

Project: Hidden Hills Solar Electric Generating System (HHSEGS)

DATA ADEQUACY WORKSHEET

Revision No. 0 Date 8/22/2011

Technical Staff: Shahab Khoshmashrab

Project Manager: Mike Monasmith

Docket: 11-AFC-2

Technical Senior: Shahab Koshmashrab

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (h) (3) (B) (iii)	Geologic and flood hazards, meteorologic conditions and climatic extremes, and cooling water availability;	§§ 2.3.1, 2.3.1.1, 2.3.2.3, 2.3.2.4	Yes	
Appendix B (h) (3) (B) (iv)	Special design features adopted by the applicant or resource supplier to ensure power plant reliability including equipment redundancy; and	§§ 2.3.2, 2.3.2.2, 5.4	Yes	
Appendix B (h) (3) (B) (v)	For technologies not previously installed and operated in California, the expected power plant maturation period.	N/A	N/A	
Appendix B (i) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, leases, and permits applicable to the proposed project, and a discussion of the applicability of, and conformance with each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed; and	N/A	N/A	
Appendix B (i) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits, leases, and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	N/A	N/A	

Adequacy Issue: Adequate ☒ Inadequate ☐

Technical Area: **Reliability**

Project Manager: Mike Monasmith

DATA ADEQUACY WORKSHEET

Project: Hidden Hills Solar Electric Generating System (HHSEGS)

Docket: 11-AFC-2

Revision No. 0 Date 8/22/2011

Technical Staff: Shahab Khoshmashrab

Technical Senior: Shahab Koshmashrab

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (i) (2)	The name, title, phone number, address (required), and email address (if known), of an official who was contacted within each agency, and also provide the name of the official who will serve as a contact person for Commission staff.	N/A	N/A	
Appendix B (i) (3)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.	N/A	N/A	

Adequacy Issue: Adequate **X** Inadequate

Technical Area: **Socioeconomics**

Project Manager: **Mike Monasmith**

Project: **Hidden Hills SEGS**

Docket: **11-AFC-2**

DATA ADEQUACY WORKSHEET

Revision No. **0** Date **8/16/11**

Technical Staff: **Lisa Worrall**

Technical Senior: **Amanda Stennick**

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (1)	...provide a discussion of the existing site conditions, the expected direct, indirect and cumulative impacts due to the construction, operation and maintenance of the project, the measures proposed to mitigate adverse environmental impacts of the project, the effectiveness of the proposed measures, and any monitoring plans proposed to verify the effectiveness of the mitigation.	Sect. 5.10-1, pg. 5.10-1 to 5.10-2. Sects. 5.10-3 to 5.10-7, pgs. 5.10-4 to 5.10-32, Tables 5.10-2 to 5.10-24.	Yes	
Appendix B (g) (7) (A)	A description of the socioeconomic circumstances of the vicinity and region affected by construction and operation of the project. Include:	Sect. 5.10.3, pgs. 5.10-4 to 5.10-18, Tables 5.10-2 to 5.10-15.	Yes	
Appendix B (g) (7) (A) (i)	The economic characteristics, including the economic base, fiscal resources, and a list of the applicable local agencies with taxing powers and their most recent and projected revenues;	Sect. 5.10.3.4, pg. 5.10-12 to 5.10-14, Tables 5.10-11, 5.10-12, and 5.10-13.	Yes	
Appendix B (g) (7) (A) (ii)	The social characteristics, including population and demographic and community trends;	Sect. 5.10.3.1, pg. 5.10-4 to 5.10-8.	Yes	
Appendix B (g) (7) (A) (iii)	Existing and projected unemployment rates;	Sect 5.10.3.3, pg. 5.10-10 to 5.10-11, Tables 5.10-9 and 5.10-10.	Yes	
Appendix B (g) (7) (A) (iv)	Availability of skilled workers by craft required for construction and operation of the project;	Sect. 5.10.4.3.1, pg. 5.10-22 to 5.10-23, Tables 5.10-18 and 5.10-19.	Yes	
Appendix B (g) (7) (A) (v)	Availability of temporary and permanent housing and current vacancy rate; and	Sect. 5.10.3.2, pg. 5.10-8 to 5.10-9. Sect. 5.10.4.3.3, pg. 5.10-24, Tables 5.10-6 and 5.10-7.	Yes	

Adequacy Issue: Adequate **X** Inadequate

Technical Area: **Socioeconomics**
 Project Manager: **Mike Monasmith**

Project: **Hidden Hills SEGS**
 Docket: **11-AFC-2**

DATA ADEQUACY WORKSHEET

Revision No. **0** Date **8/16/11**

Technical Staff: **Lisa Worrall**
 Technical Senior: **Amanda Stennick**

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (7) (A) (vi)	Capacities, existing and expected use levels, and planned expansion of utilities (gas, water and waste) and public services, including fire protection, law enforcement, emergency response, medical facilities, other assessment districts, and school districts. For projects outside metropolitan areas with a population of 500,000 or more, information for each school district shall include current enrollment and yearly expected enrollment by grade level groupings, excluding project-related changes for the duration of the project schedule.	Sect. 5.10.3.5, pg. 5.10-14 to 5.10-16, Table 5.10-14 and 5.10-15. Sect. 5.10.3.7, pg. 5.10- 18.	Yes	
Appendix B (g) (7) (B)	A discussion of the socioeconomic impacts caused by the construction and operation of the project (note year of estimate, model, if used, and appropriate sources), including:	Sects. 5.10.4.3 and 5.10.4.4, pgs. 5.10-19 to 5.10-31, Tables 5.10-16 to 5.10-24.	Yes	
Appendix B (g) (7) (B) (i)	An estimate of the number of workers to be employed each month by craft during construction, and for operations, an estimate of the number of permanent operations workers during a year;	Sect. 5.10.4.3.1, pg. 5.10-19 to 5.10-21, Table 5.10-16, Sect. 5.10.4.4.1, pg. 5.10-27, Table 5.10-21. Sect 5.10.4.4.4, pg. 5.10-28.	Yes	
Appendix B (g) (7) (B) (ii)	An estimate of the percentage of non-local workers who will relocate to the project area to work on the project;	Sect. 5.10.4.3.2, pg. 5.10-23. Sect. 5.10.4.4.2, pg. 5.10-28.	Yes	
Appendix B (g) (7) (B) (iii)	An estimate of the potential population increase caused directly and indirectly by the project;	Sect. 5.10.4.3.2, pg. 5.10-23. Sect. 5.10.4.4.2, pg. 5.10-28. Sect. 5.10.4.4.4, pg. 5.10-29.	Yes	

Adequacy Issue: Adequate **X** Inadequate

DATA ADEQUACY WORKSHEET

Revision No. 0 Date 8/16/11

Technical Area: **Socioeconomics**

Project: Hidden Hills SEGS

Technical Staff: Lisa Worrall

Project Manager: Mike Monasmith

Docket: 11-AFC-2

Technical Senior: Amanda Stennick

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (7) (B) (iv)	The potential impact of population increase on housing during the construction and operations phases;	Sect. 5.10.4.3.3, pg. 5.10-24. Sect. 5.10.4.4.3, pg. 5.10-28.	Yes	
Appendix B (g) (7) (B) (v)	The potential impacts, including additional costs, on utilities (gas, water, and waste) and public services, including fire, law enforcement, emergency response, medical facilities, other assessment districts, and school districts. Include response times to hospitals and for police, and emergency services. For projects outside metropolitan areas with a population of 500,000 or more, information on schools shall include project related enrollment changes by grade level groupings and associated facility and staffing impacts by school district during the construction and operating phases;	Sect. 5.10.4.3.7 to 5.10.4.3.9, pgs.5.10-26 to 5.10-5.10-27.	Yes	
Appendix B (g) (7) (B) (vi)	An estimate of applicable school impact fees;	Sect. 5.10.4.4.7, pg. 5.10-30.	Yes	
Appendix B (g) (7) (B) (vii)	An estimate of the total construction payroll and separate estimates of the total operation payroll for permanent and short-term (contract) operations employees;	Sect. 5.10.4.3.4, pg. 5.10-24. Sect. 5.10.4.3.6, pg. 5.10-26, Table 5.10-20. Sect. 5.10.4.4.6, pg. 5.10-29, Table 5.10-23.	Yes	
Appendix B (g) (7) (B) (viii)	An estimate of the expenditures for locally purchased materials for the construction and operation phases of the project;	Sect. 5.10.4.3.6, pg. 5.10-26, Table 5.10-20. Sect. 5.10.4.4.6, pg. 5.10-29, Table 5.10-23.	Yes	
Appendix B (g) (7) (B) (ix)	An estimate of the capital cost (plant and equipment) of the project;	Sect. 5.10-4.3.6, pg. 5.10-26, Table 5.10-20.	Yes	

Adequacy Issue: Adequate **X** Inadequate

Technical Area: **Socioeconomics**

Project Manager: **Mike Monasmith**

Project: **Hidden Hills SEGS**

Docket: **11-AFC-2**

DATA ADEQUACY WORKSHEET

Revision No. **0** Date **8/16/11**

Technical Staff: **Lisa Worrall**

Technical Senior: **Amanda Stennick**

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (7) (B) (x)	An estimate of sales taxes generated during construction and separately during an operational year of the project;	Sect. 5.10.4.3.6, pg. 5.10-26, Table 5.10-20. Sect. 5.10.4.4.5, pg. 5.10-29. Sect. 5.10.4.4.6, pg. 5.10-30, Table 5.10-24.	Yes	
Appendix B (g) (7) (B) (xi)	An estimate of property taxes generated during an operational year of the project; and	Sect. 5.10.4.4.5, pg. 5.10-29.	Yes	
Appendix B (g) (7) (B) (xii)	The expected direct, indirect, and induced income and employment effects due to construction, operation, and maintenance of the project.	Sects. 5.10.4.3.4, 5.10.4.3.5, and 5.10.4.3.6, pg. 5.10-24 to 5.10-26, Table 5.10-20. Sect 5.10.4.4.6, pg. 5.10-30, Table 5.10-24.	Yes	
Appendix B (i) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, leases, and permits applicable to the proposed project, and a discussion of the applicability of, and conformance with each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed; and	Sect. 5.10.2, pg. 5.10-2 to 5.10-4, Table 5.10-1.	Yes	

Adequacy Issue: Adequate **X** Inadequate

DATA ADEQUACY WORKSHEET

Revision No. 0 Date 8/16/11

Technical Area: **Socioeconomics**

Project: Hidden Hills SEGS

Technical Staff: Lisa Worrall

Project Manager: Mike Monasmith

Docket: 11-AFC-2

Technical Senior: Amanda Stennick

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (i) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits, leases, and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	Sect. 5.10.2, pg. 5.10-3, Table 5.10-1. Sect. 5.10-9, pg. 5.10-34.	Yes	
Appendix B (i) (2)	The name, title, phone number, address (required), and email address (if known), of an official who was contacted within each agency, and also provide the name of the official who will serve as a contact person for Commission staff.	Sect. 5.10.8, pg. 5.10-32 to 5.10-33, Table 5.10-25.	Yes	
Appendix B (i) (3)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.	Sect. 5.10-9, pg. 5.10-34.	Yes	

Adequacy Issue: Adequate **X** Inadequate _____ DATA ADEQUACY WORKSHEET Revision No.: _____ Date: August 22, 2011

Technical Area: **SOILS** Project: Hidden Hills SEGS Technical Staff: Mike Conway
 Project Manager: Mike Monasmith Docket: 11-AFC-02 Technical Senior: Paul Marshall

Siting Regulations	Information	AFC Page Number And Section Number	Adequate Yes Or No	Information Required To Make AFC Conform With Regulations
Appendix B (g) (1)	...provide a discussion of the existing site conditions, the expected direct, indirect and cumulative impacts due to the construction, operation and maintenance of the project, the measures proposed to mitigate adverse environmental impacts of the project, the effectiveness of the proposed measures, and any monitoring plans proposed to verify the effectiveness of the mitigation.	Section 5.11 page 4 5.11 page 6 5.11 page 15 5.11 page 14 5.11 page 8 5.11 page 15	Yes	
Appendix B (g) (15) (A)	A map at a scale of 1:24,000 and written description of soil types and all agricultural land uses that will be affected by the proposed project. The description shall include:	Map: Appendix 5.11-18 (last) 5.11 page 5	Yes	
Appendix B (g) (15) (A) (i)	The depth, texture, permeability, drainage, erosion hazard rating, and land capability class of the soil;	Section 5.11 page 8	Yes	
Appendix B (g) (15) (A) (ii)	An identification of other physical and chemical characteristics of the soil necessary to allow an evaluation of soil erodibility, permeability, re - vegetation potential, and cycling of pollutants in the soil-vegetation system;	Section 5.11 page 8	Yes	
Appendix B (g) (15) (A) (iii)	The location of any proposed fill disposal or fill procurement (borrow) sites; and	Section 5.11 page 10	Yes	
Appendix B (g) (15) (A) (iv)	The location of any contaminated soils that could be disturbed by project construction.	Section 5.14	Yes	
Appendix B (g) (15) (B)	An assessment of the effects of the proposed project on soil resources and agricultural land uses. This discussion shall include:	Section 5.11 page 10	Yes	
Appendix B (g) (15) (B) (i)	The quantification of accelerated soil loss due to wind and water erosion; and	Section 5.11 page 8 5.11 page 10	Yes	

Adequacy Issue: Adequate ☒ Inadequate ☐ DATA ADEQUACY WORKSHEET Revision No.: _____ Date: August 22, 2011

Technical Area: **SOILS** Project: Hidden Hills SEGS Technical Staff: Mike Conway

Project Manager: Mike Monasmith Docket: 11-AFC-02 Technical Senior: Paul Marshall

Siting Regulations	Information	AFC Page Number And Section Number	Adequate Yes Or No	Information Required To Make AFC Conform With Regulations
Appendix B (g) (15) (B) (ii)	The effect of power plant emissions on surrounding soil-vegetation systems.	Section 5.11 page 10	Yes	
Appendix B (i) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, leases, and permits applicable to the proposed project, and a discussion of the applicability of, and conformance with each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed; and	Section 5.11 page 2 5.11 page 3	Yes	
Appendix B (i) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits, leases, and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	Section 5.11 page 2	Yes	None
Appendix B (i) (2)	The name, title, phone number, address (required), and email address (if known), of an official who was contacted within each agency, and also provide the name of the official who will serve as a contact person for Commission staff.	Section 5.11 page 15	Yes	None
Appendix B (i) (3)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.	Section 5.11 page 15	Yes	None

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. _____ Date 8/19/11

Technical Area: **Traffic and Transportation** Project: Hidden Hills Solar Electric Generating System (HHSEGS) Technical Staff: _____

Project Manager: Mike Monasmith Docket: 11-AFC-2 Technical Senior: Candace M. Hill
David Flores

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (1)	...provide a discussion of the existing site conditions, the expected direct, indirect and cumulative impacts due to the construction, operation and maintenance of the project, the measures proposed to mitigate adverse environmental impacts of the project, the effectiveness of the proposed measures, and any monitoring plans proposed to verify the effectiveness of the mitigation.	Page 5.12-9; Section 5.12.3; Page 5.12-19-20; Section 5.12.4.3 and Section 5.12.5; Page 5.12-20-21; Section 5.12.6	Yes	
Appendix B (g) (5) (A)	A regional transportation setting, on topographic maps (scale of 1:250,000), identifying the project location and major transportation facilities. Include a reference to the transportation element of any applicable local or regional plan.	Figure 5.12-2	Yes	

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. _____ Date 8/19/11

Technical Area: **Traffic and Transportation** Project: Hidden Hills Solar Electric Generating System (HHSEGS) Technical Staff: _____

Project Manager: Mike Monasmith Docket: 11-AFC-2 Technical Senior: Candace M. Hill
David Flores

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (5) (B)	If the proposed project including any linear facility is to be located within 20,000 feet of an airport runway that is at least 3,200 feet in actual length, or 5,000 feet of a heliport (or planned or proposed airport runway or an airport runway under construction, that is the subject of a notice or proposal on file with the Federal Aviation Administration), discuss the project's compliance with the applicable sections of the current Federal Aviation Regulation Part 77 – Objects Affecting Navigable Airspace, specifically any potential to obstruct or impede air navigation generated by the project at operation; such as, a thermal plume, a visible water vapor plume, glare, electrical interference, or surface structure height. The discussion should include a map at a scale of 1:24,000 that displays the airport or airstrip runway configuration, the proposed power plant site and related facilities.	Page 5.12-11-12; Section 5.12.3.7 and Section 5.12.3.9.1	Yes	
Appendix B (g) (5) (C)	An identification, on topographic maps at a scale of 1:24,000, and a description of existing and planned roads, rail lines, (including light rail), bike trails, airports, bus routes serving the project vicinity, pipelines, and canals in the project area affected by or serving the proposed facility. For each road identified, include the following information, where applicable:	Figure 5.12-2	Yes	

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. _____ Date 8/19/11

Technical Area: **Traffic and Transportation** Project: Hidden Hills Solar Electric Generating System (HHSEGS) Technical Staff: _____

Project Manager: Mike Monasmith Docket: 11-AFC-2 Technical Senior: Candace M. Hill
David Flores

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (5) (C) (i)	Road classification and design capacity;	Page 5.12-9-10; Section 5.12.3.1	No	Please provide road classification and design capacity.
Appendix B (g) (5) (C) (ii)	Current daily average and peak traffic counts;	Figure 5.12-2 and Figure 5.12-3	Yes	
Appendix B (g) (5) (C) (iii)	Current and projected levels of service before project development, during construction, and during project operation;	Page 5.12-11; Section 5.12.3.3; Table 5.12-3; Page 5.12-19; Section 5.12.4.2.3; Table 5.12-8	Yes	
Appendix B (g) (5) (C) (iv)	Weight and load limitations;	None	No	Please provide weight and load limitations.
Appendix B (g) (5) (C) (v)	Estimated percentage of current traffic flows for passenger vehicles and trucks; and	Page 5.12-18; Section 5.12.4.2.2; Table 5.12-7	Yes	
Appendix B (g) (5) (C) (vi)	An identification of any road features affecting public safety.	Page 5.12-12; Section 5.12.3.8	No	Please provide an identification of any road features affecting public safety.
Appendix B (g) (5) (D)	An assessment of the construction and operation impacts of the proposed project on the transportation facilities identified in subsection (g)(5)(C). Also include anticipated project-specific traffic, estimated changes to daily average and peak traffic counts, levels of service, and traffic/truck mix, and the impact of construction of any facilities identified in subsection (g)(5)(C).	Page 5.12-14 through 5.12-19; Section 5.12.4.2	Yes	

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. _____ Date 8/19/11

Technical Area: **Traffic and Transportation** Project: Hidden Hills Solar Electric Generating System (HHSEGS) Technical Staff: _____

Project Manager: Mike Monasmith Docket: 11-AFC-2 Technical Senior: Candace M. Hill
David Flores

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (5) (E)	A discussion of project-related hazardous materials to be transported to or from the project during construction and operation of the project, including the types, estimated quantities, estimated number of trips, anticipated routes, means of transportation, and any transportation hazards associated with such transport.	Page 5.12-19-20; Section 5.12.4.3.1	No	Please provide a discussion of project-related hazardous materials to be transported to or from the project during construction and operation of the project, including the types, estimated quantities, estimated number of trips, anticipated routes, means of transportation, and any transportation hazards associated with such transport.
Appendix B (i) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, leases, and permits applicable to the proposed project, and a discussion of the applicability of, and conformance with each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed; and	Page 5.12-2 through 5.12-5; Section 5.12.2; Table 5.12-1	Yes	
Appendix B (i) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits, leases, and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	Page 5.12-5 through 5.12-9; Section 5.12.2.1 through 5.12.2.3	Yes	

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. _____ Date 8/19/11

Technical Area: **Traffic and Transportation** Project: Hidden Hills Solar Electric Generating System (HHSEGS) Technical Staff: _____

Project Manager: Mike Monasmith Docket: 11-AFC-2 Technical Senior: Candace M. Hill
David Flores

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (i) (2)	The name, title, phone number, address (required), and email address (if known), of an official who was contacted within each agency, and also provide the name of the official who will serve as a contact person for Commission staff.	Page 5.12-22; Section 5.12.7; Table 5.12-9	No	Please provide the name, title, phone number, address (required), and email address (if known), of an official who was contacted within each agency, and also provide the name of the official who will serve as a contact person for Commission staff.
Appendix B (i) (3)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.	Page 5.12-23; Section 5.12-8; Table 5.12-10	Yes	

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. 00 Date 8/17/2011

Technical Area: **Transmission System Design** Project: Hidden Hills Solar Electric Generating System (HHSEGS) Technical Staff: Sudath Edirisuriya

Project Manager: Mike Monasmith Docket: 11-AFC-2 Technical Senior: Mark Hesters

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (h) (2) (A)	A discussion of the need for the additional electric transmission lines, substations, or other equipment, the basis for selecting principal points of junction with the existing electric transmission system, and the capacity and voltage levels of the proposed lines, along with the basis for selection of the capacity and voltage levels.	Section 3.1,3.2 (Transmission System Engineering) Pages 3-1 to 3-6 Figure 3.2-1 (proposed Onsite gen-tie lines) Appendix 2D (Electrical Engineering Design criteria)	Yes	
Appendix B (h) (2) (B)	A discussion of the extent to which the proposed electric transmission facilities have been designed, planned, and routed to meet the transmission requirements created by additional generating facilities planned by the applicant or any other entity.	Section 3.1,3.2 (Transmission System Engineering) Pages 3-1 to 3-7 Figure 3.2-1 onsite gen-tie lines Appendix 2D (Electrical Engineering Design criteria)	Yes	

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. 00 Date 8/17/2011

Technical Area: **Transmission System Design** Project: Hidden Hills Solar Electric Generating System (HHSEGS) Technical Staff: Sudath Edirisuriya

Project Manager: Mike Monasmith Docket: 11-AFC-2 Technical Senior: Mark Hesters

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (b) (2) (C)	A detailed description of the design, construction, and operation of any electric transmission facilities, such as power lines, substations, switchyards, or other transmission equipment, which will be constructed or modified to transmit electrical power from the proposed power plant to the load centers to be served by the facility. Such description shall include the width of rights of way and the physical and electrical characteristics of electrical transmission facilities such as towers, conductors, and insulators.	Section 3.1,3.2 (Transmission System Engineering) Pages 3-1 to 3-7 Section 2.1.2.5 (Transmission line, Pages 2-5 and 2-7 Figure 3.2-1 onsite gen-tie lines Appendix 2D (Electrical Engineering Design criteria)	No	1. Provide a complete electrical one-line diagram (or resubmit Figure 3.2-2) of Hidden Hills Solar Electric Generating System plant 1 and 2 switchyard showing all equipment for generator interconnection with the onsite switchyard including any bus duct connectors or cables, 4.16 kV switchgear & breakers on the low side (13.8kV), generator step-up transformers, underground cables and overhead conductors with its configuration, buses, breakers and disconnect switches on the 230 kV side and their respective ratings. 2. Provide conductor current carrying capacity, size and type, 230 kV pole configuration and number of poles that would be required to construct the proposed 900 foot segment (within the California border) of the HHSEGS-El-Dorado 230kV double-circuit transmission lines.

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. 00 Date 8/17/2011

Technical Area: **Transmission System Design** Project: Hidden Hills Solar Electric Generating System (HHSEGS) Technical Staff: Sudath Edirisuriya

Project Manager: Mike Monasmith Docket: 11-AFC-2 Technical Senior: Mark Hesters

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (b) (2) (D)	A description of how the route and additional transmission facilities were selected, and the consideration given to engineering constraints, environmental impacts, resource conveyance constraints, and electric transmission constraints.	Section 3.1,3.2 (Transmission System Engineering) Pages 3-1 to 3-7 Figure 3.2-1 onsite gen-tie lines Figure 3.2-2 (proposed 230kV transmission line routing Hidden Hills Solar Electric Generating system 1 and 2) Appendix 2D (Electrical Engineering Design Criteria)	Yes	

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. 00 Date 8/17/2011

Technical Area: **Transmission System Design** Project: Hidden Hills Solar Electric Generating System (HHSEGS) Technical Staff: Sudath Edirisuriya

Project Manager: Mike Monasmith Docket: 11-AFC-2 Technical Senior: Mark Hesters

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (b) (2) (E)	<p>A completed System Impact Study or signed System Impact Study Agreement with the California Independent System Operator and proof of payment. When not connecting to the California Independent System Operator controlled grid, provide the executed System Impact Study agreement and proof of payment to the interconnecting utility.</p> <p>If the interconnection and operation of the proposed project will likely impact an transmission system that is not controlled by the interconnecting utility (or California Independent System Operator), provide evidence of a System Impact Study or agreement and proof of payment (when applicable) with/to the impacted transmission owner or provide evidence that there are no system impacts requiring mitigation.</p>	Appendix 3A (Generator Interconnection Study process Agreement)	Yes	
Appendix B (i) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, and permits applicable to the proposed project, and a discussion of the applicability of each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed;	<p>Section 3.4 (Applicable laws, ordinances, regulations, and Standards)</p> <p>Table 3.4-1 (Design and construction laws)</p>	No	Need to discuss the CPUC G.O 95 and 128 rules and how they are applicable in the construction of underground and overhead transmission lines.

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. 00 Date 8/17/2011

Technical Area: **Transmission System Design** Project: Hidden Hills Solar Electric Generating System (HHSEGS) Technical Staff: Sudath Edirisuriya

Project Manager: Mike Monasmith Docket: 11-AFC-2 Technical Senior: Mark Hesters

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (i) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	Section 3.4.5 and 3.4.2 Jurisdictional Agencies Table 3.4-7 (Jurisdictional Agencies for Transmission System Engineering related LORS)	Yes	
Appendix B (i) (2)	The name, title, phone number, and address, if known, of an official within each agency who will serve as a contact person for the agency, and also provide the name of the official who will serve as a contact person for Commission staff.	Appendix 1.0.B	Yes	
Appendix B (i) (3)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.	Section 3.2.3	No	Indicate when the project will receive preliminary approval from the California ISO, and when a copy of an updated Cluster study will be available and provided to the California Energy Commission.

Adequacy Issue: Adequate X Inadequate

Technical Area: **Trans Line Safety & Nuisance**

Project Manager: Alan Solomon

Project: Hidden Hills Solar

Docket: 09-AFC-6

DATA ADEQUACY WORKSHEET

Revision No. 0 Date 8/26/2011

Technical Staff: Obed Odoemelam

Technical Senior: Gerry Bemis

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (1)	...provide a discussion of the existing site conditions, the expected direct, indirect and cumulative impacts due to the construction, operation and maintenance of the project, the measures proposed to mitigate adverse environmental impacts of the project, the effectiveness of the proposed measures, and any monitoring plans proposed to verify the effectiveness of the mitigation.	Section 1, page 1-1. Section 2.0, pp. 2-1, and 2-5. Section 3.0, pp. 3-1 and 3-2.	Yes	
Appendix B (g) (18) (A)	The locations and a description of the existing switchyards and overhead and underground transmission lines that would be affected by the proposed project.	Section 2.0, p. 2-5. Section 3.0pp. 3-3 and 3-4.	Yes	
Appendix B (g) (18) (B)	An estimate of the existing electric and magnetic fields from the facilities listed in (A) above and the future electric and magnetic fields that would be created by the proposed project, calculated at the property boundary of the site and at the edge of the rights of way for any transmission line. Also provide an estimate of the radio and television interference that could result from the project.	Section 3.0, pp. 3-3 and 3-4.	Yes	

Adequacy Issue: Adequate ☒ Inadequate

Technical Area: **Trans Line Safety & Nuisance**

Project Manager: Alan Solomon

Project: Hidden Hills Solar

Docket: 09-AFC-6

DATA ADEQUACY WORKSHEET

Revision No. 0 Date 8/26/2011

Technical Staff: Obed Odoemelam

Technical Senior: Gerry Bemis

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (18) (C)	Specific measures proposed to mitigate identified impacts, including a description of measures proposed to eliminate or reduce radio and television interference, and all measures taken to reduce electric and magnetic field levels.	Section 3.0, p. 3-5.	Yes	
Appendix B (i) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, leases, and permits applicable to the proposed project, and a discussion of the applicability of, and conformance with each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed; and	Section 3.0, pp. 3-8 and 3-9.	Yes	
Appendix B (i) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits, leases, and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	Section 3.0, p.3-9.	Yes	

Adequacy Issue: Adequate ☒ Inadequate

Technical Area: **Trans Line Safety & Nuisance**

Project Manager: Alan Solomon

Project: Hidden Hills Solar

Docket: 09-AFC-6

DATA ADEQUACY WORKSHEET

Revision No. 0 Date 8/26/2011

Technical Staff: Obed Odoemelam

Technical Senior: Gerry Bemis

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (i) (2)	The name, title, phone number, address (required), and email address (if known), of an official who was contacted within each agency, and also provide the name of the official who will serve as a contact person for Commission staff.	Section 3.0, p.3-9.	Yes	
Appendix B (i) (3)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.	Section 5.12, p. 5.12-14.	Yes	

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. 0 Date 8/16/2011

Technical Area: **Visual Resources** Project: Hidden Hills Solar Electric Generating System (HHSEGS) Technical Staff: Melissa Mourkas

Project Manager: Mike Monasmith Docket: 11-AFC-02 Technical Senior: David Flores

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (1)	...provide a discussion of the existing site conditions, the expected direct, indirect and cumulative impacts due to the construction, operation and maintenance of the project, the measures proposed to mitigate adverse environmental impacts of the project, the effectiveness of the proposed measures, and any monitoring plans proposed to verify the effectiveness of the mitigation.	Section 5.13.4.4, pp. 5.13-29 to 32.	Yes	
Appendix B (g) (6) (A)	Descriptions of the existing visual setting of the vicinity of the proposed project site and the proposed routes for any project-related linear facilities. Include:	Section 5.13.3, pp. 5.13-5 to 7.	Yes	
Appendix B (g) (6) (A) (i)	Topographic maps at a scale of 1:24,000 that depict directions from which the project would be seen, the view areas most sensitive to the potential visual impacts of the project, and the locations where photographs were taken for (g)(6)(C); and	Figure 2.1-2, Figure 2.1-4 (Project Description); Figure 5.13-1 Landscape Context & KOP Locations.	Yes	

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. 0 Date 8/16/2011
 Technical Area: **Visual Resources** Project: Hidden Hills Solar Electric Generating System (HHSEGS) Technical Staff: Melissa Mourkas
 Project Manager: Mike Monasmith Docket: 11-AFC-02 Technical Senior: David Flores

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (6) (A) (ii)	Description of the existing visual properties of the topography, vegetation, and any modifications to the landscape as a result of human activities, including existing water vapor plumes, above-ground electrical transmission lines, and nighttime lighting levels in the project viewshed.	Section 5.13.3, pp. 5.13-5 to 7.	Yes	
Appendix B (g) (6) (B)	An assessment of the visual quality of those areas that would be affected by the proposed project. For projects proposed to be located within the coastal zone, the assessment should also describe how the proposed project would be sited to protect views to and along the ocean and scenic coastal areas, would minimize the alteration of natural land forms, would be visually compatible with the character of surrounding areas.	Section 5.13.3.5, pp. 5.13-9 to 16.	Yes	

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. 0 Date 8/16/2011
 Technical Area: **Visual Resources** Project: Hidden Hills Solar Electric Generating System (HHSEGS) Technical Staff: Melissa Mourkas
 Project Manager: Mike Monasmith Docket: 11-AFC-02 Technical Senior: David Flores

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (6) (C)	In consultation with Energy Commission staff, identify: i) any designated scenic roadways or scenic corridors and any visually sensitive areas that would be affected by the proposed project, including recreational and residential areas; and ii) the locations of the key observation points to represent the most critical viewing locations from which to conduct detailed analyses of the visual impacts of the proposed project. Indicate the approximate number of people using each of these sensitive areas and the estimated number of residences with views of the project. Also identify any major public roadways and trails of local importance that would be visually impacted by the project and indicate the types of travelers (e.g., local residents, recreationists, workers, commuters, etc.) and the approximate number of vehicles, bicyclists, and/or hikers per day.	Section 5.13.3.5, pp. 5.13-9 to 16.	Yes	
Appendix B (g) (6) (D)	A table providing the dimensions (height, length, and width, or diameter) and, proposed color(s), materials, finishes, patterns, and other proposed design characteristics of each major component visible from off the project site, including any project-related electrical transmission line and/or offsite aboveground pipelines and metering stations.	Table 5.13-4, pp. 5.13-20 to 21.	Yes	

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. 0 Date 8/16/2011
 Technical Area: **Visual Resources** Project: Hidden Hills Solar Electric Generating System (HHSEGS) Technical Staff: Melissa Mourkas
 Project Manager: Mike Monasmith Docket: 11-AFC-02 Technical Senior: David Flores

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (6) (E)	Provide the cooling tower and heat recovery steam generator (HRSG) exhaust design parameters that affect <u>visible plume formation</u> . For the cooling tower, data shall include heat rejection rate, exhaust temperature, exhaust mass flow rate, liquid to gas mass flow ratio, and, if the tower is plume-abated, moisture content (percent by weight) or plume-abated fogging curve(s). The parameters shall account for a range of ambient conditions (temperature and relative humidity) and proposed operating scenarios, such as duct firing and shutting down individual cells. For the heat recovery steam generator exhausts, data shall include moisture content (percent by weight), exhaust mass flow rate, and exhaust temperature. The parameters must correspond to full-load operating conditions at specified ambient conditions, and shall account for proposed operating scenarios, such as power augmentation (i.e., evaporative coolers, inlet foggers, or steam injection) and duct firing, or proposed HRSG visible plume abatement, such as the use of an economizer bypass. For simple-cycle projects, provide analogous data for the exhaust stack(s).	Section 5.13.4.2.2, p. 5.13-22.	Yes	

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. 0 Date 8/16/2011
 Technical Area: **Visual Resources** Project: Hidden Hills Solar Electric Generating System (HHSEGS) Technical Staff: Melissa Mourkas
 Project Manager: Mike Monasmith Docket: 11-AFC-02 Technical Senior: David Flores

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (6) (F)	Provide: i) full-page color photographic reproductions of the existing site, and ii) full-page color simulations of the proposed project at life-size scale when the picture is held 10 inches from the viewer's eyes, including any project-related electrical transmission lines, in the existing setting from each key observation point. If any landscaping is proposed to comply with zoning requirements or to mitigate visual impacts, include the landscaping in simulation(s) representing sensitive area views, depicting the landscaping five years after installation; and estimate the expected time until maturity is reached.	Figures 5.13-2 to 7.	Yes	
Appendix B (g) (6) (G)	An assessment of the visual impacts of the project, <u>including light, glare</u> , and any modeling of visible plumes. Include a description of the method and identify any computer model used to assess the impacts. Provide an estimate of the expected frequency and dimensions (height, length, and width) of the visible cooling tower and/or exhaust stack plumes. Provide the supporting assumptions, meteorological data, operating parameters, and calculations used.	Section 5.13.4.2.3, pp. 5.13-22 to 23.	Yes	

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. 0 Date 8/16/2011
 Technical Area: **Visual Resources** Project: Hidden Hills Solar Electric Generating System (HHSEGS) Technical Staff: Melissa Mourkas
 Project Manager: Mike Monasmith Docket: 11-AFC-02 Technical Senior: David Flores

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (6) (H)	If any landscaping is proposed to reduce the visual impacts of the project, provide a conceptual landscaping plan at a 1:40 scale (1"=40'). Include information on the type of plant species proposed, their size, quantity, and spacing at planting, expected heights at 5 years and maturity, and expected growth rates.	Section 5.13.4.2.5, p.5.13-24; Section 5.13.6, p. 5.13-32, Item # 4.	No	Please provide a conceptual landscaping plan at a 1:40 scale (1"=40'), as identified in the AFC to address visual impacts to viewers from Tecopa Road and the Charleston View residential area. Include information on the type of plant species proposed, their size, quantity, and spacing at planting, expected heights at 5 years and maturity, and expected growth rates.
Appendix B (i) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, leases, and permits applicable to the proposed project, and a discussion of the applicability of, and conformance with each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed; and	Table 5.13-1, p. 5.13-3; Table 5.13-2, p. 5.13-4; Table 5.13-3, p. 513-4.	Yes	
Appendix B (i) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits, leases, and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	Section 5.13.7, p. 5.13-33; Table 5.13-6, p. 5.13-33; Table 5.6-6, p. 5.6-16 (Land Use).	Yes	

Adequacy Issue: Adequate _____ Inadequate X DATA ADEQUACY WORKSHEET Revision No. 0 Date 8/16/2011
 Technical Area: **Visual Resources** Project: Hidden Hills Solar Electric Generating System (HHSEGS) Technical Staff: Melissa Mourkas
 Project Manager: Mike Monasmith Docket: 11-AFC-02 Technical Senior: David Flores

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (i) (2)	The name, title, phone number, address (required), and email address (if known), of an official who was contacted within each agency, and also provide the name of the official who will serve as a contact person for Commission staff.	Table 5.13-6, p 5.13-33.	Yes	
Appendix B (i) (3)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.	Section 5.13.8, p. 5.13-33.	Yes	

Adequacy Issue: Adequate X Inadequate

Technical Area: **Waste Management**

Project Manager: Mike Monosmith

Project: Hidden Hills SEGS

Docket: 11-AFC-2

DATA ADEQUACY WORKSHEET

Revision No. 0 Date 8/16/ 2011

Technical Staff: Ellie Townsend-Hough

Technical Senior: Paul Marshall

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (b) (1) (C)	A detailed description of the design, construction and operation of the facilities, specifically including the power generation, cooling, water supply and treatment, waste handling and control, pollution control, fuel handling, and safety, emergency and auxiliary systems, and fuel types and fuel use scenarios; and	Section 2.2, 2.4 Section 5.14	Yes	
Appendix B (e) (1)	A discussion of how facility closure will be accomplished in the event of premature or unexpected cessation of operations.	Section 2.5 Section 5.14.4.3.3	Yes	
Appendix B (g) (1)	...provide a discussion of the existing site conditions, the expected direct, indirect and cumulative impacts due to the construction, operation and maintenance of the project, the measures proposed to mitigate adverse environmental impacts of the project, the effectiveness of the proposed measures, and any monitoring plans proposed to verify the effectiveness of the mitigation.	Section 5.14.3 Appendix 5.14A Section 5.14.4.3 5.14.5 5.14.6	Yes	

Adequacy Issue: Adequate ☒ Inadequate

Technical Area: **Waste Management**

Project Manager: Mike Monosmith

Project:

Docket:

DATA ADEQUACY WORKSHEET

Revision No. 0 Date 8/16/ 2011

Technical Staff: Ellie Townsend-Hough

Technical Senior: Paul Marshall

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (12) (A)	A Phase I Environmental Site Assessment (ESA) for the proposed power plant site using methods prescribed by the American Society for Testing and Materials (ASTM) document entitled "Standard Practice for Environmental Site Assessments: Phase 1 Environmental Site Assessment Process" (Designation: E 1527-93, May 1993), which is incorporated by reference in its entirety; or an equivalent method agreed upon by the applicant and the CEC Staff that provides similar documentation of the potential level and extent of site contamination. The Phase I ESA shall have been completed no earlier than one year prior to the filing of the AFC.	Appendix 5.14A	Yes	
Appendix B (g) (12) (B)	A description of each waste stream estimated to be generated during project construction and operation, including origin, hazardous or nonhazardous classification pursuant to Title 22, California Code of Regulations, § 66261.20 et seq., chemical composition, estimated annual weight or volume generated, and estimated frequency of generation.	Table 5.14-2 Table 5.14-3	Yes	

Adequacy Issue: Adequate ☒ Inadequate

Technical Area: **Waste Management**

Project Manager: **Mike Monosmith**

Project:

Docket:

DATA ADEQUACY WORKSHEET

Hidden Hills SEGS

11-AFC-2

Revision No. 0 Date 8/16/ 2011

Technical Staff: Ellie Townsend-Hough

Technical Senior: Paul Marshall

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (12) (C)	A description of all waste disposal sites which may feasibly be used for disposal of project wastes. For each site, include the name, location, classification under Title 23, California Code of Regulations, § 2530 et seq., the daily or annual permitted capacity, daily or annual amounts of waste currently being accepted, the estimated closure date and remaining capacity, and a description of any enforcement action taken by local or state agencies due to waste disposal activities at the site.	Section 5.14.4.2 Table 5.14-4	Yes	
Appendix B (g) (12) (D)	A description of management methods for each waste stream, including methods used to minimize waste generation, length of on- and off-site waste storage, re-use and recycling opportunities, waste treatment methods used, and use of contractors for treatment.	Table 5.14-2 Table 5.14-3	Yes	
Appendix B (h) (1) (B)	A discussion of any measures proposed to improve adverse site conditions.	Section 5.14.4.3	Yes	
Appendix B (h) (1) (D) (v)	The waste disposal system and on-site disposal sites;	Section 5.14.4.3	Yes	
Appendix B (i) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, leases, and permits applicable to the proposed project, and a discussion of the applicability of, and conformance with each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed; and	Table 5.14-1	Yes	

Adequacy Issue: Adequate ☒ Inadequate

Technical Area: **Waste Management**

Project Manager: **Mike Monosmith**

Project:

Docket:

DATA ADEQUACY WORKSHEET

Revision No. 0 Date 8/16/ 2011

Technical Staff: Ellie Townsend-Hough

Technical Senior: Paul Marshall

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (i) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits, leases, and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	Table 5.14-1 Table 5.14-5 Table 5.14-6	Yes	
Appendix B (i) (2)	The name, title, phone number, address (required), and email address (if known), of an official who was contacted within each agency, and also provide the name of the official who will serve as a contact person for Commission staff.	Table 5.14-5 Table 5.14-6	Yes	
Appendix B (i) (3)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.	Table 5.14-6	Yes	

Adequacy Issue: Adequate _____ Inadequate **X** DATA ADEQUACY WORKSHEET Revision No.: _____ Date: 8/22/2011

Technical Area: **Water** Project: Hidden Hills SEGS Technical Staff: Mike Conway
 Project Manager: Mike Monasmith Docket: 11-AFC-02 Technical Senior: Paul Marshall

Siting Regulations	Information	AFC Page Number and Section Number	Adequate Yes or No	Information Required to Make AFC Conform with Regulations
Appendix B (g) (1)	...provide a discussion of the existing site conditions, the expected direct, indirect and cumulative impacts due to the construction, operation and maintenance of the project, the measures proposed to mitigate adverse environmental impacts of the project, the effectiveness of the proposed measures, and any monitoring plans proposed to verify the effectiveness of the mitigation.	Section 5.15 page 2 5.15 page 6 5.15 page 21	Yes	
Appendix B (g) (14) (A)	All the information required to apply for the following permits if applicable, including:			
Appendix B (g) (14) (A) (i)	Waste Discharge Requirements; National Pollutant Discharge Elimination System Permit; and/or a Section 401 Certification or Waiver from the appropriate Regional Water Quality Control Board (RWQCB);	Section 5.15 page 4	Yes	
Appendix B (g) (14) (A) (ii)	Construction and Industrial Waste Discharge and/or Industrial Pretreatment permits from wastewater treatment agencies;	Section 5.15 page 4	Yes	
Appendix B (g) (14) (A) (iii)	Nationwide Permits and/or Section 404 Permits from the U.S. Army Corps of Engineers; and	Section 5.15 page 4	Yes	
Appendix B (g) (14) (A) (iv)	Underground Injection Control Permit(s) from the U.S. Environmental Protection Agency, California Division of Oil and Gas, and RWQCB.	NA	NA	
Appendix B (g) (14) (B)	A detailed description of the hydrologic setting of the project. The information shall include a narrative discussion and on maps at a scale of 1:24,000 (or appropriate scale approved by staff), describing the chemical and physical characteristics of the following nearby water bodies that may be affected by the	Section 5.15 page 6 Map: Fig. 5.15.3 Appendix 5.15-A,C,E	Yes	

Adequacy Issue: Adequate _____ Inadequate **X** DATA ADEQUACY WORKSHEET Revision No.: _____ Date: 8/22/2011

Technical Area: **Water** Project: Hidden Hills SEGS Technical Staff: Mike Conway
 Project Manager: Mike Monasmith Docket: 11-AFC-02 Technical Senior: Paul Marshall

Siting Regulations	Information	AFC Page Number and Section Number	Adequate Yes or No	Information Required to Make AFC Conform with Regulations
	proposed project:			
Appendix B (g) (14) (B) (i)	Ground water bodies and related geologic structures;	Section 5.15 page 8	Yes	
Appendix B (g) (14) (B) (ii)	Surface water bodies;	Section 5.15 page 7	Yes	
Appendix B (g) (14) (B) (iii)	Water inundation zones, such as the 100-year flood plain and tsunami run-up zones;	Section 5.15 page 13	Yes	
Appendix B (g) (14) (B) (iv)	Flood control facilities (existing and proposed); and	Section 5.15 page 13	Yes	
Appendix B (g) (14) (B) (v)	Groundwater wells within ½ mile if the project will include pumping.	App. 5.15 page F	Yes	
Appendix B (g) (14) (C)	A description of the water to be used and discharged by the project. This information shall include:	Section 5.15 page 15 5.15- page 15 Figure 2.2-4	Yes	
Appendix B (g) (14) (C) (i)	Source(s) of the primary and back-up water supplies and the rationale for their selection;	Section 5.15 page 8	No	Provide a discussion of alternate water supplies. The AFC describes specifically how if allocated rights are exercised, the basin may not provide sustainable yield to users. No water supplies were identified that may be used as a backup if the proposed mitigation of retiring existing water rights is not feasible.
Appendix B (g) (14) (C) (ii)	The expected physical and chemical characteristics of the source and discharge water(s) including identification of both organic and inorganic constituents before and after any project-related treatment. For source waters with seasonal variation, provide seasonal ranges of the expected physical and	Section 5.15 page 10 Appendix 5.15-F,G	Yes	

Adequacy Issue: Adequate _____ Inadequate **X** DATA ADEQUACY WORKSHEET Revision No.: _____ Date: 8/22/2011

Technical Area: **Water** Project: Hidden Hills SEGS Technical Staff: Mike Conway
 Project Manager: Mike Monasmith Docket: 11-AFC-02 Technical Senior: Paul Marshall

Siting Regulations	Information	AFC Page Number and Section Number	Adequate Yes or No	Information Required to Make AFC Conform with Regulations
	chemical characteristics. Provide copies of background material used to create this description (e.g., laboratory analysis);			
Appendix B (g) (14) (C) (iii)	Average and maximum daily and annual water demand and waste water discharge for both the construction and operation phases of the project;	Section 5.15 page 15 Figure 2.2-4 2.2 page 11	Yes	
Appendix B (g) (14) (C) (iv)	A detailed description of all facilities to be used in water conveyance (from primary source to the power plant site), water treatment, and wastewater discharge. Include a water mass balance diagram;	Section 5.15 page 8 Section 2, Figure 2.2-3,4	Yes	
Appendix B (g) (14) (C) (v)	For all water supplies intended for industrial uses to be provided from public or private water purveyors, a letter of intent or will-serve letter indicating that the purveyor is willing to serve the project, has adequate supplies available for the life of the project, and any conditions or restrictions under which water will be provided. In the event that a will-serve letter or letter of intent can not be provided, identify the most likely water purveyor and discuss the necessary assurances from the water purveyor to serve the project;	NA		

Adequacy Issue: Adequate _____ Inadequate **X** DATA ADEQUACY WORKSHEET Revision No.: _____ Date: 8/22/2011

Technical Area: **Water** Project: Hidden Hills SEGS Technical Staff: Mike Conway
 Project Manager: Mike Monasmith Docket: 11-AFC-02 Technical Senior: Paul Marshall

Siting Regulations	Information	AFC Page Number and Section Number	Adequate Yes or No	Information Required to Make AFC Conform with Regulations
Appendix B (g) (14) (C) (vi)	For all water supplied which necessitates transfers and/or exchanges at any point, identify all parties and contracts/agreements involved, the primary source for the transfer and/or exchange water (e.g., surface water, groundwater), and provide the status of all appropriate agencies' approvals for the proposed use, environmental impact analysis on the specific transfers and/or exchanges required to obtain the proposed supplies, a copy of any agency regulations that govern the use of the water, and an explanation of how the project complies with the agency regulation(s);	NA	No	Provide contract or other assurance that mitigation for water use is possible.AFC clearly defines overdraft in the basin, without any specific mitigation. If agricultural land can be retired to offset project water use, an indication of location and viability is necessary.
Appendix B (g) (14) (C) (vii)	Provide water mass balance and heat balance diagrams for both average and maximum flows that include all process and/or ancillary water supplies and wastewater streams. Highlight any water conservation measures on the diagram and the amount that they reduce water demand; and	Section 5.15 page 8 Section 2, Figure 2.2-3,4	Yes	
Appendix B (g) (14) (C) (viii)	For all projects which have a discharge, provide a copy of the will-serve letter, permit or contract with the public or private entity that will be accepting the wastewater and contact storm water from the project. The letter, permit or contract if possible, shall identify the discharge volumes and the chemical or physical characteristics under which the wastewater and contact storm water will be accepted. In the event that a will-serve letter, permit, or contract cannot be provided, identify the most likely wastewater/storm water entity and discuss why the applicant was unable to secure the necessary assurances to serve the project's wastewater/storm water needs. Also, discuss the term of the wastewater service to the project,	NA		

Adequacy Issue: Adequate _____ Inadequate **X** DATA ADEQUACY WORKSHEET Revision No.: _____ Date: 8/22/2011

Technical Area: **Water** Project: Hidden Hills SEGS Technical Staff: Mike Conway
 Project Manager: Mike Monasmith Docket: 11-AFC-02 Technical Senior: Paul Marshall

Siting Regulations	Information	AFC Page Number and Section Number	Adequate Yes or No	Information Required to Make AFC Conform with Regulations
	whether the wastewater entity has adequate permit capacity for the volume of wastewater from the project and has adequate permit levels for the chemical/physical characteristics of the project's wastewater and storm water for the life of the project, and any issues or conditions/restrictions the wastewater entity may impose on the project.			
Appendix B (g) (14) (D)	Identify all project elements associated with stormwater drainage, including a description of the following:	Appendix 5.15-C	Yes	
Appendix B (g) (14) (D) (i)	Monthly and/or seasonal precipitation and stormwater runoff and drainage patterns for the proposed site and surrounding area that may be affected by the project's construction and operation;	Appendix 5.15-C	Yes	
Appendix B (g) (14) (D) (ii)	Drainage facilities and the design criteria used for the plant site and ancillary facilities, including but not limited to capacity of designed system, design storm, and estimated runoff;	Appendix 5.15-C	Yes	
Appendix B (g) (14) (D) (iii)	All assumptions and calculations used to calculate runoff and to estimate changes in flow rates between pre- and post construction; and	Appendix 5.15-C and E	Yes	
Appendix B (g) (14) (D) (iv)	A copy of applicable regional and local requirements regulating the drainage systems, and a discussion of how the project's drainage design complies with these requirements.	Appendix 5.15-C and E	Yes	
Appendix B (g) (14) (E)	An impacts analysis of the proposed project on water resources and a discussion of conformance with water-related LORS and policy. This discussion shall include:	Section 5.15 page 21	Yes	

Adequacy Issue: Adequate _____ Inadequate **X** DATA ADEQUACY WORKSHEET Revision No.: _____ Date: 8/22/2011

Technical Area: **Water** Project: Hidden Hills SEGS Technical Staff: Mike Conway
 Project Manager: Mike Monasmith Docket: 11-AFC-02 Technical Senior: Paul Marshall

Siting Regulations	Information	AFC Page Number and Section Number	Adequate Yes or No	Information Required to Make AFC Conform with Regulations
Appendix B (g) (14) (E) (i)	The effects of project demand on the water supply and other users of this source including, but not limited to, water availability for other uses during construction or after the power plant begins operation, consistency of the water use with applicable RWQCB basin plans or other applicable resource management plans, and any changes in the physical or chemical conditions of existing water supplies as a result of water use by the power plant;		No	Describe potential changes in groundwater quality due to project pumping. Basin water quality variation should be described both vertically within the aquifer and across its areal extent.
Appendix B (g) (14) (E) (ii)	If the project will pump groundwater, an estimation of aquifer drawdown based on a computer modeling study shall be conducted by a professional geologist and include the estimated drawdown on neighboring wells within 0.5 mile of the proposed well(s), any effects on the migration of groundwater contaminants, and the likelihood of any changes in existing physical or chemical conditions of groundwater resources shall be provided;	Appendix 5.15-F and G	Yes	
Appendix B (g) (14) (iii)	The effects of construction activities and plant operation on water quality and to what extent these effects could be mitigated by best management practices;	Section 5.15 page 14	Yes	
Appendix B (g) (14) (iv)	If not using a zero liquid discharge project design for cooling and process waters, include the effects of the proposed wastewater disposal method on receiving waters, the feasibility of using pre-treatment techniques to reduce impacts, and beneficial uses of the receiving waters. Include an explanation why the zero liquid discharge process is "environmentally undesirable," or "economically unsound;"	NA		

Adequacy Issue: Adequate _____ Inadequate **X** DATA ADEQUACY WORKSHEET Revision No.: _____ Date: 8/22/2011

Technical Area: **Water** Project: Hidden Hills SEGS Technical Staff: Mike Conway
 Project Manager: Mike Monasmith Docket: 11-AFC-02 Technical Senior: Paul Marshall

Siting Regulations	Information	AFC Page Number and Section Number	Adequate Yes or No	Information Required to Make AFC Conform with Regulations
Appendix B (g) (14) (v)	If using fresh water, include a discussion of the cumulative impacts, alternative water supply sources and alternative cooling technologies considered as part of the project design. Include an explanation of why alternative water and alternative cooling are supplies "environmentally undesirable," or "economically unsound";	Section 5.15 page 20 5.15 page18	Yes	
Appendix B (g) (14) (vi)	The effects of the project on the 100-year flood plain, flooding potential of adjacent lands or water bodies, or other water inundation zones ; and	Section 5.15 page 20	Yes	
Appendix B (g) (14) (vii)	All assumptions, evidence, references, and calculations used in the analysis to assess these effects.	Appendix 5.15C and E	Yes	

Adequacy Issue: Adequate _____ Inadequate **X** DATA ADEQUACY WORKSHEET Revision No.: _____ Date: 8/22/2011

Technical Area: **Water** Project: Hidden Hills SEGS Technical Staff: Mike Conway
 Project Manager: Mike Monasmith Docket: 11-AFC-02 Technical Senior: Paul Marshall

Siting Regulations	Information	AFC Page Number and Section Number	Adequate Yes or No	Information Required to Make AFC Conform with Regulations
Appendix B (i) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, leases, and permits applicable to the proposed project, and a discussion of the applicability of, and conformance with each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed; and	Section 5.15 page 2	Yes	
Appendix B (i) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits, leases, and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	Section 5.15 page 2	Yes	
Appendix B (i) (2)	The name, title, phone number, address (required), and email address (if known), of an official who was contacted within each agency, and also provide the name of the official who will serve as a contact person for Commission staff.	Section 5.15 page 22	Yes	
Appendix B (i) (3)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.	Section 5.15 page 23	Yes	

Adequacy Issue: Adequate ☒ Inadequate ☐

Technical Area: **Worker Safety**
 Project Manager: **Mike Monasmith**

Project: **Hidden Hills SEGS**
 Docket: **10-AFC-2**

DATA ADEQUACY WORKSHEET

Revision No. **0** Date **8/23/11**

Technical Staff: **Rick Tyler**
 Technical Senior: **Rick Tyler**

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (g) (1)	...provide a discussion of the existing site conditions, the expected direct, indirect and cumulative impacts due to the construction, operation and maintenance of the project, the measures proposed to mitigate adverse environmental impacts of the project, the effectiveness of the proposed measures, and any monitoring plans proposed to verify the effectiveness of the mitigation.	Section 5.16	Yes	
Appendix B (g) (11) (A)	A description of the safety training programs which will be required for construction and operation personnel.	Sections 5.16.4.3, 5.16.3.5	Yes	
Appendix B (g) (11) (B)	A complete description of the fuel handling system and the fire suppression system.	Section 5.16.4.3	Yes	
Appendix B (g) (11) (C)	Provide draft outlines of the Construction Health and Safety Program and the Operation Health and Safety Program, as follows:			
	Construction Health and Safety Program: * Injury and Illness Prevention Plan (8 Cal. Code Regs., § 1509);	Section 5.16.4.3	Yes	
	* Fire Protection and Prevention Plan (8 Cal. Code Regs., § 1920);	Section 5.16.4.3	Yes	
	* Personal Protective Equipment Program (8 Cal. Code Regs., §§ 1514-1522)	Section 5.16.4.3	Yes	
	Operation Health and Safety Program: * Injury and Illness Prevention Program (8 Cal. Code Regs., § 3203);	Section 5.16.4.3	Yes	

Adequacy Issue: Adequate ☒ Inadequate ☐

Technical Area: **Worker Safety**

Project Manager: **Mike Monasmith**

Project: **Hidden Hills SEGS**

Docket: **10-AFC-2**

DATA ADEQUACY WORKSHEET

Revision No. **0** Date **8/23/11**

Technical Staff: **Rick Tyler**

Technical Senior: **Rick Tyler**

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
	* Fire Prevention Plan (8 Cal. Code Regs., § 3221);	Section 5.16.4.3	Yes	
	* Emergency Action Plan (8 Cal. Code Regs., § 3220);	Section 5.16.4.3	Yes	
	Personal Protective Equipment Program (8 Cal. Code Regs., §§ 3401-3411).	Section 5.16.4.3	Yes	
Appendix B (i) (1) (A)	Tables which identify laws, regulations, ordinances, standards, adopted local, regional, state, and federal land use plans, leases, and permits applicable to the proposed project, and a discussion of the applicability of, and conformance with each. The table or matrix shall explicitly reference pages in the application wherein conformance, with each law or standard during both construction and operation of the facility is discussed; and	Section 5.16.2 Table 5.16-1, 5.16-2	Yes	
Appendix B (i) (1) (B)	Tables which identify each agency with jurisdiction to issue applicable permits, leases, and approvals or to enforce identified laws, regulations, standards, and adopted local, regional, state and federal land use plans, and agencies which would have permit approval or enforcement authority, but for the exclusive authority of the commission to certify sites and related facilities.	Section 5.16.6 Table 5.16-8	Yes	

Adequacy Issue: Adequate ☒ Inadequate ☐

Technical Area: **Worker Safety**

Project Manager: **Mike Monasmith**

Project: Hidden Hills SEGS

Docket: 10-AFC-2

DATA ADEQUACY WORKSHEET

Revision No. 0 Date 8/23/11

Technical Staff: Rick Tyler

Technical Senior: Rick Tyler

SITING REGULATIONS	INFORMATION	AFC PAGE NUMBER AND SECTION NUMBER	ADEQUATE YES OR NO	INFORMATION REQUIRED TO MAKE AFC CONFORM WITH REGULATIONS
Appendix B (i) (2)	The name, title, phone number, address (required), and email address (if known), of an official who was contacted within each agency, and also provide the name of the official who will serve as a contact person for Commission staff.	Section 5.16.5. Table 5.16-7	Yes	
Appendix B (i) (3)	A schedule indicating when permits outside the authority of the commission will be obtained and the steps the applicant has taken or plans to take to obtain such permits.	Section 5.16.6, 5.16.5 Table 5.16-7, 5.16-8	Yes	