

Theodore D. Schade  
Air Pollution Control Officer



## GREAT BASIN UNIFIED AIR POLLUTION CONTROL DISTRICT

157 Short Street, Bishop, California 93514-3537 www.gbuapcd.org

Tel: 760-872-8211 Fax: 760-872-6109 info@gbuapcd.org

May 9, 2012

**DOCKET**

**11-AFC-2**

DATE MAY 09 2012

RECD. MAY 09 2012

Mike Monasmith  
Senior Project Manager  
Systems Assessment & Facility Siting Division  
California Energy Commission  
1516 Ninth Street MS-15  
Sacramento, CA 95814-5112

**Re: Notice of Preliminary Determination of Compliance (PDOC)**  
**Facility: Hidden Hills Solar Electric Generating System (11-AFC-02)**  
**Location: Southeastern corner of Inyo County, CA**

Dear Mr. Monasmith:

Enclosed for your review and comment is the District's preliminary determination of compliance (PDOC) for the Hidden Hills Solar Electric Generating System (HHSEGS) Application for Certification, Docket № 11-AFC-02, that was submitted to the California Energy Commission (CEC) on August 5, 2011. Three applications were submitted to the Great Basin Unified Air Pollution Control District (District) for the project: Hidden Hills Solar 1 Power Plant (1604-00-11), Hidden Hills Solar 2 Power Plant (1605-00-11) and Common Area (1606-00-11). Equipment subject to District permitting include two 249 MMBtu natural gas fired auxiliary boilers, two 15 MMBtu nighttime preservation boilers, three diesel-fueled backup generators and three diesel-fueled fire pump engines in support of two 250 megawatt solar power plants.

The notice of preliminary decision for this project will be published two days from the date of this letter. Please submit your written comments on this project within the 30-day public comment period which begins on the date of publication of the public notice.

Thank you for your cooperation in this matter. If you have any questions regarding this matter, please contact Jon Becknell or myself at (760) 872-8211.

Sincerely,

Duane Ono  
Deputy Air Pollution Control Officer

Enclosures

Theodore D. Schade  
Air Pollution Control Officer



## GREAT BASIN UNIFIED AIR POLLUTION CONTROL DISTRICT

157 Short Street, Bishop, California 93514-3537 www.gbuapcd.org  
Tel: 760-872-8211 Fax: 760-872-6109 info@gbuapcd.org

---

May 9, 2012

John M. Woolard  
Chief Executive Officer  
BrightSource Energy, Inc.  
1999 Harrison Street  
Oakland, CA 94612

**Re: Notice of Preliminary Determination of Compliance (PDOC)**  
**Facility: Hidden Hills Solar Electric Generating System (11-AFC-02)**  
**Location: Southeastern corner of Inyo County, CA**

Dear Mr. Woolard:

Enclosed for your review and comment is the District's preliminary determination of compliance (PDOC) for the Hidden Hills Solar Electric Generating System (HHSEGS) Application for Certification, Docket № 11-AFC-02, that was submitted to the California Energy Commission (CEC) on August 5, 2011. Three applications were submitted to the Great Basin Unified Air Pollution Control District (District) for the project: Hidden Hills Solar 1 Power Plant (1604-00-11), Hidden Hills Solar 2 Power Plant (1605-00-11) and Common Area (1606-00-11). Equipment subject to District permitting include two 249 MMBtu natural gas fired auxiliary boilers, two 15 MMBtu nighttime preservation boilers, three diesel-fueled backup generators and three diesel-fueled fire pump engines in support of two 250 megawatt solar power plants.

The notice of preliminary decision for this project will be published two days from the date of this letter. Please submit your written comments on this project within the 30-day public comment period which begins on the date of publication of the public notice.

Thank you for your cooperation in this matter. If you have any questions regarding this matter, please contact Jon Becknell or myself at (760) 872-8211.

Sincerely,

Duane Ono  
Deputy Air Pollution Control Officer

Enclosures

Theodore D. Schade  
Air Pollution Control Officer



## GREAT BASIN UNIFIED AIR POLLUTION CONTROL DISTRICT

157 Short Street, Bishop, California 93514-3537 [www.gbuapcd.org](http://www.gbuapcd.org)  
Tel: 760-872-8211 Fax: 760-872-6109 [info@gbuapcd.org](mailto:info@gbuapcd.org)

---

May 9, 2012

Mike Tollstrup, Chief  
Project Assessment Branch  
Stationary Source Division  
California Air Resources Board  
P.O. Box 2815  
Sacramento, CA 95812-2815

**Re: Notice of Preliminary Determination of Compliance (PDOC)**  
**Facility: Hidden Hills Solar Electric Generating System (11-AFC-02)**  
**Location: Southeastern corner of Inyo County, CA**

Dear Mr. Tollstrup:

Enclosed for your review and comment is the District's preliminary determination of compliance (PDOC) for the Hidden Hills Solar Electric Generating System (HHSEGS) Application for Certification, Docket № 11-AFC-02, that was submitted to the California Energy Commission (CEC) on August 5, 2011. Three applications were submitted to the Great Basin Unified Air Pollution Control District (District) for the project: Hidden Hills Solar 1 Power Plant (1604-00-11), Hidden Hills Solar 2 Power Plant (1605-00-11) and Common Area (1606-00-11). Equipment subject to District permitting include two 249 MMBtu natural gas fired auxiliary boilers, two 15 MMBtu nighttime preservation boilers, three diesel-fueled backup generators and three diesel-fueled fire pump engines in support of two 250 megawatt solar power plants.

The notice of preliminary decision for this project will be published two days from the date of this letter. Please submit your written comments on this project within the 30-day public comment period which begins on the date of publication of the public notice.

Thank you for your cooperation in this matter. If you have any questions regarding this matter, please contact Jon Becknell or myself at (760) 872-8211.

Sincerely,

Duane Ono  
Deputy Air Pollution Control Officer

Enclosures

Theodore D. Schade  
Air Pollution Control Officer



## GREAT BASIN UNIFIED AIR POLLUTION CONTROL DISTRICT

157 Short Street, Bishop, California 93514-3537 www.gbuapcd.org  
Tel: 760-872-8211 Fax: 760-872-6109 info@gbuapcd.org

---

May 9, 2012

Gerardo C. Rios (AIR 3)  
Chief, Permits Office  
Air Division  
U.S. E.P.A. - Region IX  
75 Hawthorne Street  
San Francisco, CA 94105

**Re: Notice of Preliminary Determination of Compliance (PDOC)**  
**Facility: Hidden Hills Solar Electric Generating System (11-AFC-02)**  
**Location: Southeastern corner of Inyo County, CA**

Dear Mr. Rios:

Enclosed for your review and comment is the District's preliminary determination of compliance (PDOC) for the Hidden Hills Solar Electric Generating System (HHSEGS) Application for Certification, Docket No 11-AFC-02, that was submitted to the California Energy Commission (CEC) on August 5, 2011. Three applications were submitted to the Great Basin Unified Air Pollution Control District (District) for the project: Hidden Hills Solar 1 Power Plant (1604-00-11), Hidden Hills Solar 2 Power Plant (1605-00-11) and Common Area (1606-00-11). Equipment subject to District permitting include two 249 MMBtu natural gas fired auxiliary boilers, two 15 MMBtu nighttime preservation boilers, three diesel-fueled backup generators and three diesel-fueled fire pump engines in support of two 250 megawatt solar power plants.

The notice of preliminary decision for this project will be published two days from the date of this letter. Please submit your written comments on this project within the 30-day public comment period which begins on the date of publication of the public notice.

Thank you for your cooperation in this matter. If you have any questions regarding this matter, please contact Jon Becknell or myself at (760) 872-8211.

Sincerely,

Duane Ono  
Deputy Air Pollution Control Officer

Enclosures

**THE GREAT BASIN UNIFIED AIR POLLUTION CONTROL DISTRICT REQUESTS  
PUBLIC COMMENT ON A PRELIMINARY DETERMINATION OF COMPLIANCE  
FOR THE HIDDEN HILLS SOLAR ELECTRIC GENERATING SYSTEM**

Pursuant to District Rule 205, the Great Basin Unified Air Pollution Control District (District) solicits public comment on a proposed preliminary determination of compliance (PDOC) to be granted for the Hidden Hills Solar Electric Generating System (HHSEGS) project, comprised of two 250 megawatt solar power plants with equipment that is regulated as stationary sources of air pollutants, including natural gas-fired boilers and emergency diesel-fired engines. The HHSEGS project will be located in the southeastern corner of Inyo County just north of Charleston View (Calvada Springs) and Tecopa Road (Old Spanish Trail Highway).

The application, supporting documents, District analysis and proposed permit conditions are available for inspection at the District's office. Written comments must be postmarked or delivered to the District office by June 11, 2012. A public hearing to receive comments on this proposed decision may be requested by writing to the APCO. Submit comments to: **Great Basin Unified Air Pollution Control District, 157 Short Street, Suite 6, Bishop, California 93514.**

**PRELIMINARY DETERMINATION OF COMPLIANCE**  
**California Energy Commission Application for Certification № 11-AFC-02**  
**District ATC Permit Applications 1604-00-11, 1605-00-11, 1606-00-11**  
**Hidden Hills Solar 1 Power Plant, Hidden Hills Solar 2 Power Plant and Common Area**

Processed by: Jonathan Becknell  
Great Basin Unified Air Pollution Control District

May 8, 2012

Dates Application Materials Received:

Original: August 8, 2011: Single application for all facilities, including Application for Certification (AFC) for the Hidden Hills Solar Electric Generating System (HHSEGS) that was submitted to the California Energy Commission (CEC) on August 5, 2011. Application determined to be complete on September 9, 2011.

Supplemental: December 27, 2011: Revised District permit application forms submitted to reflect separate ownership of Hidden Hills Solar 1 Power Plant (1604-00-11), Hidden Hills Solar 2 Power Plant (1605-00-11) and Common Area (1606-00-11)

Revised: March 10, 2012: Boiler optimization, summary tables  
April 6, 2012: Boiler optimization, full documentation

Company Name: Hidden Hills Solar I, LLC      Certified Official: John M. Woolard, Chief Executive Officer of BrightSource Energy, Inc., sole member and manager of Hidden Hills Solar Holdings, LLC, which is sole member and manager of Hidden Hills Solar I, LLC

Company Name: Hidden Hills Solar II, LLC      Certified Official: John M. Woolard, Chief Executive Officer of BrightSource Energy, Inc., sole member and manager of Hidden Hills Solar Holdings, LLC, which is sole member and manager of Hidden Hills Solar II, LLC

Project Name: Hidden Hills Solar Electric Generating System  
Mailing Address: c/o BrightSource Energy, Inc.  
1999 Harrison Street, Oakland, CA 94612  
Phone: (510) 550-8464

Consultant: Nancy Matthews      CEC Contact: Jacquelyn Leyva  
Company Name: Sierra Research      Title: Air Resources Engineer  
Phone: (916) 273-5124      Phone: (916) 654-3846  
Email: NMatthews@sierraresearch.com      Email: jleyva@energy.state.ca.us

**PRELIMINARY DETERMINATION OF COMPLIANCE**  
**California Energy Commission Application for Certification № 11-AFC-02**  
**District ATC Permit Applications 1604-00-11, 1605-00-11, 1606-00-11**  
**Hidden Hills Solar 1 Power Plant, Hidden Hills Solar 2 Power Plant and Common Area**

**1. SCOPE OF DOCUMENT:**

The Great Basin Unified Air Pollution Control District (District) is the agency delegated authority to review the application materials and to issue permits containing conditions that will ensure the project's compliance with all applicable District, California Air Resources Board (ARB) and federal Environmental Protection Agency (EPA) air pollution control regulations. Compliance with these rules is considered the legal standard for protecting all persons from the detrimental effects of regulated air pollutants. The following is the District evaluation of the applicant's proposal. This evaluation has been carried out in accordance with the requirements of District Rule 209-A, focusing on the emission sources, calculations and methodologies that contribute to the potential air quality impacts to ensure that the proposed project will comply with all applicable standards, regulation, significance and health risk thresholds and limits.

**2. PROJECT DESCRIPTION:**

The Hidden Hills Solar Electric Generating System (HHSEGS) project consists of two independently owned and operated facilities, Hidden Hills Solar 1 Power Plant (Solar 1) and Hidden Hills Solar 2 Power Plant (Solar 2), and a Common Area that is jointly owned. The two solar power plants will focus the sun's energy on solar receiver steam generators (SRSGs) that convert water to steam. The steam will be used to drive turbines to generate a net 500 megawatts (MW) of commercially available electrical power. Each 250 MW power plant will have equipment that is regulated as stationary sources of air pollutants, including natural gas-fired boilers and emergency diesel-fired engines that are subject to permit conditions, plus other supporting ancillary equipment that is exempt from permitting.

**3. PROJECT LOCATION:**

The project will be located in Inyo County, California on private lands of approximately 3,277 acre (5.12 square mile) area, just north of Charleston View (Calvada Springs) and Tecopa Road (Old Spanish Trail Highway), bounded on the northeast by the California-Nevada border.

**4. EQUIPMENT SUBJECT TO PERMIT:**

Each power plant will have a 249 million Btu per hour natural gas fired boiler that will be used during periods of the solar-powered boiler startup and transient cloudy conditions. Each solar plant will also have a 15 million Btu per hour natural gas fired nighttime preservation boiler to maintain overnight temperatures in the SRSG system and improve system startup efficiency. The common area and both power plants will each have an emergency backup generator and fire pump, all powered by diesel-fueled reciprocating internal combustion engines.

**5. ANCILLARY EQUIPMENT:**

Each power plant will have a heliostat array with about 90,000 heliostats, a power block containing a Rankine-cycle non-reheat steam turbine, a solar receiver steam generator atop a

**PRELIMINARY DETERMINATION OF COMPLIANCE**  
**California Energy Commission Application for Certification № 11-AFC-02**  
**District ATC Permit Applications 1604-00-11, 1605-00-11, 1606-00-11**  
**Hidden Hills Solar 1 Power Plant, Hidden Hills Solar 2 Power Plant and Common Area**

750-foot tower, feed water heaters, a deaerator, an air-cooled condenser, a wet surface air cooler (with high efficiency drift eliminator), small oil-water separators and diesel fuel aboveground storage tanks. The heliostats, steam turbines, SRSG, feed water heaters, deaerators and air-cooled condensers are exempt from permitting because they have no air emissions. The wet surface air coolers are exempt from permit requirements per District Rule 201.D.4. The oil/water separators and diesel fuel storage tanks are exempt per District Rule 201.H.4.

**6. APPLICABLE RULES:**

**District Rules:**

200	Permits Required	Applies
209-A	Standards for Authority to Construct	Applies
	BACT	Does not Apply
	Offsets	Does not Apply
	Air Quality Impact Analysis	Applies
	Power Plants	Applies
210	Conditional Approval	Applies
216	NSR Requirements for Determining Impact on Air Quality	Applies
217	Additional Procedures for Issuing Permits to Operate for Sources Subject to Title V	Applies
222	Construction or Reconstruction of Major Sources of HAPS	Does not Apply
300	Permit Fees	Applies
301	Permit Fee Schedules	Applies
400	Ringelmann Chart	Applies
402	Nuisance	Applies
403	Breakdown	Applies
404-A	Particulate Matter	Applies
404-B	Oxides of Nitrogen	Applies
416	Sulfur Compounds And Nitrogen Oxides	Applies

**California Health & Safety Codes:**

42706	Report of Violation of Emission Standard	Applies
44321	List of Substances (AB-2588)	Applies

**California Code of Regulations:**

13 CCR §2423	Exhaust Emission Standards and Test Procedures--Heavy-Duty Off-Road Diesel Cycle Engines (Tiers)	Applies
17 CCR §93115	Airborne Toxic Control Measure (ATCM) for Stationary Compression Ignition (CI) Engines.	Applies

**Clean Air Act and Code of Federal Regulations:**

CAA Title I, Part C	Prevention of Significant Deterioration	Does not Apply
CAA Title I, Part A	§112.r - Prevention of Accidental Releases	Does not Apply
40 CFR §68.130	List of Substances for Accidental Release Prevention	Does not Apply
CAA Title IV	Acid Deposition Control	Applies
CAA Title V	Permits	Applies



**PRELIMINARY DETERMINATION OF COMPLIANCE**  
**California Energy Commission Application for Certification № 11-AFC-02**  
**District ATC Permit Applications 1604-00-11, 1605-00-11, 1606-00-11**  
**Hidden Hills Solar 1 Power Plant, Hidden Hills Solar 2 Power Plant and Common Area**

40 CFR 60 Subpart Db	New Source Performance Standards for Industrial-Commercial-Institutional Steam Generating Units	Applies to auxiliary boilers
40 CFR 60 Subpart Dc	New Source Performance Standards for Small Industrial-Commercial-Institutional Steam Generating Units	Applies to nighttime preservation boilers
40 CFR 60 Subpart IIII	Standards of Performance for Stationary Compression Ignition Internal Combustion Engines	Applies
40 CFR 63 Subpart ZZZZ	National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines	Applies

----- Compliance with applicable regulations is discussed in the following sections. -----

**7. POLLUTANT EMISSIONS ESTIMATES & LIMITS:**

**A. Emission Standards & Permit Limits**

All boiler burners will be rated as Low NO<sub>x</sub> (9 PPM or less) with flue gas recirculation. Best Available Control Technology (BACT) and offset requirements under District 209-A, Standards for Authority to Construct, § B.2, are not triggered because daily emissions of each pollutant will be limited to below the BACT and offset threshold of 250 lb/day. Compliance with emission limits will be enforced through hourly and daily emission limits; hourly, daily and annual fuel use limits; and a plant-wide NO<sub>x</sub> predictive emission monitoring system (PEMS). The specific manufacturers and models for the boilers are yet to be determined, but compliance with applicable requirements will be assured through the emissions limitations and the testing, monitoring, recordkeeping and reporting requirements specified in the attached Authorities to Construct (ATCs) 1604-00-11 and 1605-00-11.

The power plant emergency backup generators shall be powered by Tier 2, diesel-fueled, Caterpillar 3516C SCAC engines, 3,633 hp at 1,800 rpm, EPA Family ACPXL78.1T2E, CARB Executive Order U-R-001-0398-1, or equivalent CARB-certified engines that meet the current Tier standards for the given power range. The emergency fire pumps shall be powered by Tier 3, diesel-fueled, Cummins CFP7E-F30 engines, 200 hp at 2,100 rpm, EPA Family ACEXL-0409AAB, CARB Executive Order U-R-002-0516, or equivalent CARB-certified engines that meet the current Tier standards for the given power range. The engines will also be subject to the California Air Resources Board ATCM for Stationary Compression Ignition (CI) Engines in 17 CCR §93115. The engines will also meet the current Tier standards of 13 CCR, §2423 - Exhaust Emission Standards and Test Procedures: Heavy-Duty Off-Road Diesel Cycle Engines.

**Table 7.A-1: Power Plant Emission Limits per unit in pounds per hour (pounds per million Btu)**

Pollutant	Auxiliary Boilers	Nighttime Preservation Boilers	Emergency Backup Engines	Emergency Fire Pump Engines
NO <sub>x</sub> as NO <sub>2</sub>	2.74 (0.0110)	0.17 (0.0110)	38.4	1.3
CO	4.55 (0.0183)	0.55 (0.0366)	20.8	1.15
VOC as CH <sub>4</sub>	1.34 (0.0054)	0.08 (0.0053)	1.3	0.08
PM <sub>10</sub> /PM <sub>2.5</sub>	1.25 (N/A)	0.08 (N/A)	1.2	0.07
SO <sub>2</sub>	0.52 (0.0021)	0.03 (0.0021)	0.04	0.003

**PRELIMINARY DETERMINATION OF COMPLIANCE**  
**California Energy Commission Application for Certification № 11-AFC-02**  
**District ATC Permit Applications 1604-00-11, 1605-00-11, 1606-00-11**  
**Hidden Hills Solar 1 Power Plant, Hidden Hills Solar 2 Power Plant and Common Area**

The Common Area emergency backup generator shall be powered by a Tier 3, diesel-fueled, Caterpillar C9 ATAAC, 398 hp at 1,800 rpm, EPA Family ACPXL08.8ESX, CARB Executive Order U-R-001-0373, or an equivalent CARB-certified engine that meets the current Tier standards for the given power range. The engines shall meet the limits specified in the application and Condition 8 of the attached ATC 1606-00-11.

**Table 7.A-2: Common Area Emission Limits in pounds per hour**

<b>Pollutant</b>	<b>Emergency Backup Engine</b>	<b>Emergency Fire Pump Engine</b>
NOx as NO <sub>2</sub>	2.6	1.3
CO	2.28	1.15
VOC as CH <sub>4</sub>	0.15	0.08
PM <sub>10</sub> /PM <sub>2.5</sub>	0.13	0.07
SO <sub>2</sub>	0.004	0.003

The total plant-wide combined criteria pollutant emissions from the auxiliary and nighttime preservation boilers, emergency and fire pump engines shall not exceed the limits in Table 7.A-3.

**Table 7.A-3: Criteria Pollutant Emission Limits in pounds per day**

<b>Pollutant</b>	<b>All Fuel Burning Equipment</b>
NOx as NO <sub>2</sub>	116.0
CO	156.1
VOC as CH <sub>4</sub>	37.8
PM <sub>10</sub> /PM <sub>2.5</sub>	21.3
SO <sub>2</sub>	7.4

The above Tables 7.A-1 and 7.A-2 list the emission rate limits proposed by the applicant and accepted by the District for the stationary sources of criteria pollutants. These emission rates were input into dispersion modeling to determine the worst-case short-term (maximum 1-, 3- and 8-hour) ambient impacts for each pollutant for which there is state and/or federal ambient standard. Rather than limit the operating hours of the individual boilers on a daily, monthly or annual basis, the District also accepted the application's estimated hours of operation. From the estimates, daily and annual natural gas fuel limits were derived that will act as surrogate emission control limits for ensuring the 24-hour and annual impacts will be below the state and/or federal ambient standard standards. The total natural gas fuel consumption, expressed as heat input rates, shall not exceed 3,440 MMBtu/day or 746,400 MMBtu/year for combustion in the burners of all auxiliary and nighttime preservation boilers in the Solar 1 facility and the adjacent Solar 2 facility.

Hours of operation of the diesel-fueled emergency backup and fire pump engines are limited by the requirements of the California Code of Regulations, Title 17 (17 CCR) § 93115 - Airborne Toxic Control Measure for Stationary Compression Ignition (CI) Engines.

**PRELIMINARY DETERMINATION OF COMPLIANCE**  
**California Energy Commission Application for Certification № 11-AFC-02**  
**District ATC Permit Applications 1604-00-11, 1605-00-11, 1606-00-11**  
**Hidden Hills Solar 1 Power Plant, Hidden Hills Solar 2 Power Plant and Common Area**

**B. Boiler Criteria Pollutant Emissions**

Certified emissions from specific makes/models of the diesel engines were provided in the application materials and were accepted by the District (or other engines with equivalent or lesser emissions). The boilers will be required to meet low-NO<sub>x</sub> standards with a concentration of 9 parts per million on a dry volumetric basis (ppmvd, corrected to 3% O<sub>2</sub>). The District performed calculations to ensure that the emissions stated in the application, though not accompanied by manufacturer data, were reasonably representative from an engineering standpoint. The following example calculations are for the NO<sub>x</sub> emission rate from the auxiliary boilers. The other criteria pollutants were also checked similarly for the auxiliary and nighttime preservation boilers. With a given concentration, exhaust flow rate is necessary to calculate the mass flow rate in pounds per hour (lb/hr).

**Boiler Example Calculations:**

EPA's Appendix F to 40 CFR Part 75 - Conversion Procedures provides an exhaust flow estimate for natural gas combustion of 8,710 dry standard cubic feet per million Btu (dscf/MMBtu). With the auxiliary boiler rated fuel combustion of 249 MMBtu per hour:

$$\text{exhaust flow} = \frac{36,146 \text{ dscf}}{\text{min}} = \frac{249 \text{ MMBtu}}{\text{hr}} \times \frac{8,710 \text{ dscf}}{\text{MMBtu}} \times \frac{\text{hr}}{60 \text{ min}}$$

The application listed the exhaust flow (Q) as 72,426 actual cubic feet per minute (acf/min), which is reasonable, although conservatively overestimating flow and emissions, after adjusting to dry standard conditions with temperature (300 °F) and moisture (16.3%):

$$\text{exhaust flow} = \frac{42,115 \text{ dscf}}{\text{min}} = \frac{72,426 \text{ acf}}{\text{min}} \times \frac{528 \text{ }^{\circ}\text{R}}{(460 + 300) \text{ }^{\circ}\text{R}} \times (1 - 0.163)$$

$$\text{where, } Q_{\text{std}} \frac{\text{dscf}}{\text{min}} = Q \frac{\text{acf}}{\text{min}} \times \frac{T_{\text{std}} \text{ }^{\circ}\text{R}}{T \text{ }^{\circ}\text{R}} \times (1 - \% \text{ H}_2\text{O})$$

Then, calculating the auxiliary boiler NO<sub>x</sub> emission rate using the application's exhaust flow rate:

$$\begin{aligned} \text{NO}_x &= 9 \text{ ppmvd} \times \frac{10^{-6}}{\text{ppmvd}} \times \frac{46 \text{ g}}{\text{g(mol)}} \times \frac{2.596 \times 10^{-3} \text{ lb(mol)}}{\text{dscf}} \times \frac{42,115 \text{ dscf}}{\text{min}} \times \frac{60 \text{ min}}{\text{hr}} \\ &= 2.72 \frac{\text{lb}}{\text{hr}} \text{ (as NO}_2\text{)} \end{aligned}$$

where the NO<sub>2</sub> molecular weight = 46 and the conversion

$$\text{factor} = 2.596 \times 10^{-3} \frac{\text{lb(mol)}}{\text{dscf}} = \frac{\text{lb}}{453.6 \text{ g}} \times \frac{\text{g(mol)}}{22.414 \text{ l}} \times \frac{28.32 \text{ l}}{\text{dscf}} \times \frac{492.27 \text{ }^{\circ}\text{R}}{528.27 \text{ }^{\circ}\text{R}}$$

This result is essentially the same as the application's NO<sub>x</sub> emission rate of 2.74 lb/hr.

**PRELIMINARY DETERMINATION OF COMPLIANCE**  
**California Energy Commission Application for Certification № 11-AFC-02**  
**District ATC Permit Applications 1604-00-11, 1605-00-11, 1606-00-11**  
**Hidden Hills Solar 1 Power Plant, Hidden Hills Solar 2 Power Plant and Common Area**

**C. Non-criteria Pollutant Emissions from Boilers**

The District approves the use of the Ventura County APCD AB-2588 Combustion Emission Factors for Natural Gas Fired External Combustion Equipment to estimate boiler non-criteria pollutant emission rates. The document, published on May 17, 2001, is believed to be more reliable than the July 1998 EPA AP-42, Section 1.4 – Natural Gas Combustion. Table 7.C-1 below shows a summary of the Ventura County factors and the resulting emissions for each type of boiler.

**Table 7.C-1: Boiler Non-Criteria Pollutants**

Pollutant	Ventura County AB-2588 Emission Factors (lb/MMcf)		Auxiliary Boiler	Nighttime Boiler
	10-100 MMBtu/hr	>100 MMBtu/hr	249 MMBtu (lb/hr)	15 MMBtu (lb/hr)
propylene	5.30E-01	1.55E-02	3.79E-03	7.79E-03
HAPs				
acetaldehyde	3.10E-03	9.00E-04	2.20E-04	4.56E-05
Acrolein	2.70E-03	8.00E-04	1.95E-04	3.97E-05
Benzene	5.80E-03	1.70E-03	4.15E-04	8.53E-05
ethylbenzene	6.90E-03	2.00E-03	4.88E-04	1.01E-04
formaldehyde	1.23E-02	3.60E-03	8.79E-04	1.81E-04
Hexane	4.60E-03	1.30E-03	3.17E-04	6.76E-05
naphthalene	3.00E-04	3.00E-04	7.32E-05	4.41E-06
PAH's (excluding naphthalene)	1.00E-04	1.00E-04	2.44E-05	1.47E-06
Toluene	2.65E-02	7.80E-03	1.90E-03	3.90E-04
Xylenes	1.97E-02	5.80E-03	1.42E-03	2.90E-04

Total HAPs per boiler type (lb/hr):	5.93E-03	1.21E-03	
x 2 units each type (Solar 1 & 2):	1.19E-02	2.42E-03	= 1.43E-02 lb/hr
Annual HAPs with variable operating hours:	7.17E-03	5.82E-03	= 1.30E-02 ton/yr

**Example calculation for propylene from the auxiliary boiler with the Ventura County factor in pounds per million cubic feet of natural gas:**

$$\text{emission rate} = 3.79 \times 10^{-3} \frac{\text{lb}}{\text{hr}} = \frac{1.553 \times 10^{-2} \text{ lb}}{10^6 \text{ scf}} \times \frac{249 \times 10^6 \text{ Btu}}{\text{hr}} \times \frac{\text{scf}}{1,020 \text{ Btu}}$$

The total hazardous air pollutants (HAPs) are orders of magnitude below the major source thresholds of 25 tons per year (ton/yr) combined or 10 ton/yr per single HAP.

**PRELIMINARY DETERMINATION OF COMPLIANCE**  
**California Energy Commission Application for Certification № 11-AFC-02**  
**District ATC Permit Applications 1604-00-11, 1605-00-11, 1606-00-11**  
**Hidden Hills Solar 1 Power Plant, Hidden Hills Solar 2 Power Plant and Common Area**

**D. Emissions from Construction Activities**

The District does not directly regulate mobile equipment that is associated with construction activities. Instead, it enforces District Rule 401 which requires reasonable precautions be taken to prevent visible particulate matter from being airborne, under normal wind conditions, beyond the property from which the emission originates. Condition 30 of the attached ATCs 1604-00-11 and 1605-00-11 state that the staff conditions of certification required by the CEC for construction fugitive dust control shall be deemed by the District to be reasonable precautions under Rule 401. The District accepts the calculation methodologies used in the application to estimate emissions from construction activities in order to assess the modeled ambient impacts and health risk. The approach and the values derived appear to be both comprehensive and accurate. The mitigated emissions will not cause exceedances of the state or federal Ambient Air Quality Standards.

**8. COMPLIANCE WITH DISTRICT RULES**

The general prohibitory rules in Regulation IV applicable to the project include the following:

**Rule 400—Ringelmann Chart**

Prohibits visible emissions as dark as, or darker than, Ringelmann No. 1 for periods greater than three minutes in any hour.

The use of natural gas in the boilers and good combustion tuning practices will minimize the possibility of any visible emission exceedance.

The proposed diesel fired emergency engines will be required to meet the highest available off-road EPA Tier engine rating standards, and to only burn California diesel fuel, not to exceed 15 ppm sulfur content. Along with proper operation, and maintenance, the visible emissions from these engines are not expected to exceed the visible emission standards.

Furthermore, pursuant to this rule, Permit conditions for all combustion equipment shall prohibit visible emissions exceedances.

**Rule 402—Nuisance**

Prohibits the discharge from any source whatsoever such quantities of air contaminants or other material which cause injury, detriment, nuisance or annoyance to any considerable number of persons or to the public, or which endanger the comfort, repose, health or safety of any such persons or the public, or which cause, or have a natural tendency to cause, injury or damage to business or property.

The Hidden Hills facility shall not emit odorous pollutants, and is expected to comply with this rule.

**PRELIMINARY DETERMINATION OF COMPLIANCE**  
**California Energy Commission Application for Certification No 11-AFC-02**  
**District ATC Permit Applications 1604-00-11, 1605-00-11, 1606-00-11**  
**Hidden Hills Solar 1 Power Plant, Hidden Hills Solar 2 Power Plant and Common Area**

**Rule 403—Breakdown**

Defines breakdown conditions and describes procedures to be followed by the owner/operator and by the APCO in the event of occurrence of breakdown conditions.

Permit conditions shall set forth requirements for compliance with this rule.

**Rule 404-A—Particulate Matter**

Prohibits PM emissions in excess of the concentrations and emission rates shown in the rule.

The proposed PM emission limits for the boilers and engines will maintain PM emissions well below the limits of this rule.

**Rule 404-B—Oxides of Nitrogen**

Limits NO<sub>x</sub> emissions from combustion sources to 125 ppmvd @ 3% O<sub>2</sub>.

The proposed NO<sub>x</sub> emission limits for the boilers and engines will maintain NO<sub>x</sub> emissions well below the limits of this rule.

**Rule 416 – Sulfur Compounds and Nitrogen Oxides**

Limits SO<sub>2</sub> and NO<sub>x</sub> emissions from any single source to 0.2% by volume and 140 lb/hr, respectively.

The use of natural gas fuel and the proposed NO<sub>x</sub> emissions limits for the boilers and engines will maintain SO<sub>2</sub> and NO<sub>x</sub> emissions well below the limits of this rule.

**9. COMPLIANCE WITH BOILER NSPS**

**A. Emission Standards**

By having a heat input capacity greater than 100 MMBtu/hr but less than 250 MMBtu/hr, the auxiliary boilers are subject to the requirements of 40 CFR 60 Subpart Db – New Source Performance Standards (NSPS) for Industrial-Commercial-Institutional Steam Generating Units. The emission limits in the NSPS that apply to the boilers, 0.20 lb/MMBtu of NO<sub>x</sub> [40 CFR §60.44b(a)] and 0.20 lb/MMBtu SO<sub>2</sub> [40 CFR §60.42b(k)], are less rigorous than the emissions limits based on the boiler technology and approved by the District in Condition 10 of the attached ATCs 1604-00-11 and 1605-00-11.

The nighttime preservation boilers are subject to the requirements of 40 CFR 60 Subpart Dc – NSPS for Small Industrial-Commercial-Institutional Steam Generating Units. Because they will burn only natural gas, the boilers are not subject to the sulfur dioxide (SO<sub>2</sub>) emission limit.

**PRELIMINARY DETERMINATION OF COMPLIANCE**  
**California Energy Commission Application for Certification № 11-AFC-02**  
**District ATC Permit Applications 1604-00-11, 1605-00-11, 1606-00-11**  
**Hidden Hills Solar 1 Power Plant, Hidden Hills Solar 2 Power Plant and Common Area**

Because they will burn only natural gas, neither the auxiliary nor the nighttime boilers are subject to the particulate matter standards in their respective NSPS subparts. Testing, monitoring and recordkeeping will apply to all boilers.

**B. Continuous NO<sub>x</sub> Predictive Emission Monitoring**

Owners and operators of boilers greater than 250 MMBtu/hr heat input and subject to the NO<sub>x</sub> standard of this rule would have to demonstrate continuous compliance by use of a continuous emissions monitoring system (CEMS). Such a CEMS would be subject to all the requirements of 40 CFR 75. Because the auxiliary boilers are rated at 249 MMBtu/hr, the applicant has elected, under 40 CFR 60.48b(g), to use a continuous predictive emissions monitoring system (PEMS), specified in more detail in 40 CFR 60.49b(c) and §60.49b(g). During the required initial compliance testing, operating parameters will be monitored. The applicant is required to submit a PEMS plan detailing how these operating parameters will be monitored, recorded and utilized to continuously estimate NO<sub>x</sub> emissions with respect to the District permit limit. Condition 18 of the attached ATCs 1604-00-11 and 1605-00-11 specifies this requirement. The total combined NO<sub>x</sub> emissions from the auxiliary and nighttime preservation boilers, emergency and fire pump engines shall not exceed the limits in Table 7.A-3.

**C. Initial Compliance Testing**

In accordance with 40 CFR 60.45b, 60.46b and District Rule 108.2.b, initial testing for the all the boilers shall be performed in accordance with the methods specified in Condition 19 of the attached ATCs 1604-00-11 and 1605-00-11, or other District-approved methods:

- PM<sub>10</sub> emissions: EPA Method 5, Methods 201/202 or CARB Method 5
- NO<sub>x</sub> emissions: EPA Method 7, 7A, 7E
- SO<sub>2</sub> emissions: EPA Method 6, 6A, 6B or 6C
- CO emissions: EPA Method 10
- VOC emissions: EPA Method 25A

**10. COMPLIANCE WITH CLEAN AIR ACT'S TITLE IV AND TITLE V**

The auxiliary boilers, by providing steam to a steam turbine having a capacity greater than 25 megawatts of electrical output, trigger Title IV – Acid Deposition Control for this project. Title V permitting is thereby also required for the project. Requirements for these regulations will be addressed in separate Title V permits that will be submitted by the District to EPA Region 9.

**11. PSD CONSIDERATIONS**

For the purposes of Prevention of Significant Deterioration (PSD) applicability the three facilities, Solar 1, Solar 2 and Common Area, are combined though permitted separately.

- When combined, the two solar power plants' auxiliary boilers put the project into the first of the 28 listed categories, "Fossil fuel-fired steam electric plants of more than 250 million

**PRELIMINARY DETERMINATION OF COMPLIANCE**  
**California Energy Commission Application for Certification № 11-AFC-02**  
**District ATC Permit Applications 1604-00-11, 1605-00-11, 1606-00-11**  
**Hidden Hills Solar 1 Power Plant, Hidden Hills Solar 2 Power Plant and Common Area**

Btu/hr heat input.” This makes the PSD major source threshold for any regulated pollutant 100 tons per year (ton/yr). The highest regulated pollutant from the combined facilities is CO at 12.9 ton/yr. As of July 1, 2011, there is an additional greenhouse gas major source threshold of 100,000 ton/yr CO<sub>2</sub> equivalent (CO<sub>2</sub>e) emissions. The combined facilities’ CO<sub>2</sub>e, as revised in April 2012, is 44,394 ton/yr. The project is therefore not a PSD major source and is not subject to PSD review.

- The nearest Federal Class I Area boundary is the Domeland Wilderness 200 kilometers (km) to the west (double the 100 km distance at which a Class I area would have to be considered for visibility impacts). The closer Nopah Range Wilderness and Pahrump Valley Wilderness are not designated Class I areas.

## **12. DISPERSION MODELING**

Dispersion modeling of the ambient impact of criteria pollutants was performed in AERMOD to determine whether the proposed facility would cause or contribute to an exceedance of any Ambient Air Quality Standard (AAQS). All the modeling input parameters appear to be consistent with accepted modeling guidelines.

Impacts from project construction were modeled separately because of the shorter-term duration estimated at 29 months. Each of the project’s pollutant maximum impacts, when combined with its respective ambient background, was below the standards with the exception of the 24-hour state PM<sub>10</sub> standard. (See discussion below)

Various operating conditions were used, including normal, startup and hot standby, to model pollutant maximum operating impacts against the state CAAQS and federal NAAQS. The highest resultant concentration was selected from the various operating modes for each pollutant and averaging period to represent the project’s maximum impact. Each of the project’s pollutant maximum impacts, when combined with its respective ambient background, was below the standards with the exception of the 24-hour state PM<sub>10</sub> standard. (See discussion below)

The state 24-hour PM<sub>10</sub> standard of 50 µg/m<sup>3</sup> is exceeded by the highest 24-hour background concentration alone of 96 µg/m<sup>3</sup>. This highest PM<sub>10</sub> background concentration is not likely to occur at the same time as the highest project PM<sub>10</sub> impact because of the dust mitigation permit conditions.

## **13. SCREENING HEALTH RISK ANALYSIS**

By making use of the CARB/OEHHA-approved Hotspots Analysis and Reporting Program (HARP) (Version 1.4d) and the modeled maximum project impacts of each toxic non-criteria pollutant, the screening health risk analysis was conducted in accordance with the OEHHA’s “Air Toxics Hot Spots Program Guidance Manual for Preparation of Health Risk Assessments.” This methodology is conservative by design and yet the cancer risk at the point of maximum impact on the facility’s fence line was only 2.8 per million. At the nearest residential receptor, it was 0.5 per million. The acute and chronic hazard indices of 0.003 and 0.001, respectively, are



**PRELIMINARY DETERMINATION OF COMPLIANCE**  
**California Energy Commission Application for Certification № 11-AFC-02**  
**District ATC Permit Applications 1604-00-11, 1605-00-11, 1606-00-11**  
**Hidden Hills Solar 1 Power Plant, Hidden Hills Solar 2 Power Plant and Common Area**

orders of magnitude below the significance level of 1.0. These low results are to be expected because there are very low toxic emissions from natural gas combustion in the boilers and the most toxic substance is diesel particulate matter from the emergency backup and fire pump engines, which have very limited hours of operation.

**14. CEQA COMPLIANCE/CEC REVIEW**

Rule 209-A.E. establishes a procedure for coordinating GBUAPCD review of power plant projects with the California Energy Commission (CEC)'s environmental review process. Under this rule, the GBUAPCD reviews the Application for Certification (AFC) that is submitted to the CEC and conducts a Determination of Compliance review that is identical to that which would have been performed if an application for authority to construct had been received for the project. This Preliminary Determination of Compliance (PDOC) is the preliminary decision under Subsection B(1) of Rule 205. A Final Determination of Compliance shall be issued only after the PDOC is subjected to the public notice and comment requirements of Subsections B(2) through B(6) of Rule 205.\*

The CEC has the statutory responsibility for licensing thermal power plants 50 megawatts and larger and the plants' related facilities (such as transmission lines, fuel supply lines, water pipelines, etc). The Commission's siting process has been determined to be a certified regulatory program under the California Environmental Quality Act (CEQA) and the functional equivalent of preparing environmental impact reports. The Final Determination of Compliance shall be considered a District Authority to Construct for each of the facilities upon certification of the Project by the CEC.

\* Rule 209A.E contains an outdated reference to Subsection G(2) of Rule 209A, which does not exist. The correct reference is to Subsection B of Rule 205.

**15. COMPLIANCE (PERMIT CONDITIONS):**

Compliance with these regulations will be ensured by enforcement of the following conditions in the District Authorities to Construct, which will eventually be incorporated into the Permits to Operate.

**PRELIMINARY DETERMINATION OF COMPLIANCE**  
**California Energy Commission Application for Certification № 11-AFC-02**  
**District ATC Permit Applications 1604-00-11, 1605-00-11, 1606-00-11**  
**Hidden Hills Solar 1 Power Plant, Hidden Hills Solar 2 Power Plant and Common Area**

**ATCs 1604-00-11 and 1605-00-11**

**Solar 1 and Solar 2 (identical conditions, only equipment ID numbers differ):**

**REGULATED EQUIPMENT: 250 Megawatt Solar Power Plant with the following equipment:**

<b>ID №</b>	<b>Function</b>	<b>Make &amp; Model</b>	<b>Serial Number</b>	<b>Fuel Type</b>	<b>Fuel Use</b>
B1A	Auxiliary Boiler	TBD	TBD	Natural Gas	249 MMBtu/hr
B2A	Nighttime Preservation Boiler	TBD	TBD	Natural Gas	15 MMBtu/hr
EG1A	Backup Generator	Tier 2, Caterpillar 3516C, 3633 hp (or equivalent)	TBD	CARB Diesel	24 MMBtu/hr
FP1A	Fire Pump Engine	Tier 3, Cummins CFP7E-F30, 200 hp (or equivalent)	TBD	CARB Diesel	2 MMBtu/hr
<b>Total</b>					<b>290 MMBtu/hr</b>

**ANCILLARY EQUIPMENT:** A heliostat array with about 90,000 heliostats, a power block containing a Rankine-cycle non-reheat steam turbine, a solar receiver steam generator atop a 750-foot tower, feed water heaters, a deaerator, an air-cooled condenser, wet surface air cooler (with high efficiency drift eliminator), oil-water separator and diesel fuel aboveground storage tanks.

**EMISSIONS CONTROL:** Low NO<sub>x</sub> (9 PPM) boiler burners with flue gas recirculation, annual and daily NO<sub>x</sub> emission limits, hours of operation limits, and a plantwide NO<sub>x</sub> emission monitoring system.

**CONDITIONS:** This ATC is subject to the attached approval conditions.

**COMMENCEMENT OF CONSTRUCTION:** The permittee shall not begin actual on-site construction of the equipment authorized by this Authority to Construct until the lead agency satisfies the requirements of the California Environmental Quality Act (CEQA).

**A PERMIT TO OPERATE** the above equipment shall be issued only after an inspection to determine if the equipment has been constructed according to the approved plans and specifications and the equipment can be operated in compliance with all Rules and Regulations of the Great Basin Unified Air Pollution Control District. Notify the District at (760) 872-8211 when construction is complete and the equipment is ready for operation.

**GENERAL CONDITIONS**

**1. Facility Startup**

The permittee shall notify the District in writing when construction is complete and the equipment is ready for commissioning operations. Operation of this equipment shall be conducted in accordance with all data and specifications submitted with the application under which this ATC is issued unless otherwise noted. Notification shall be given to the District office by email, Postal Service delivery or telephone facsimile transmission at least 72 hours prior to equipment start-up. Operation of this equipment without a written Permit to Operate is a violation of District Rule 200 B, and can result in civil and criminal penalties under California Health & Safety Code (H&SC) § 42400.

**PRELIMINARY DETERMINATION OF COMPLIANCE**  
**California Energy Commission Application for Certification № 11-AFC-02**  
**District ATC Permit Applications 1604-00-11, 1605-00-11, 1606-00-11**  
**Hidden Hills Solar 1 Power Plant, Hidden Hills Solar 2 Power Plant and Common Area**

**2. Commissioning Period under Temporary Permit to Operate:**

Following a District inspection verifying that the facility is constructed in a manner consistent with the specifications in the application and with this Authority to Construct, a temporary Permit to Operate (TPO) shall be issued. The TPO shall be valid for the duration of the commissioning period defined below and until a Permit to Operate is issued or denied.

- A. Commissioning activities are defined as, but not limited to, all testing, adjustment, tuning, and calibration activities recommended by the equipment manufacturers and the construction contractor to ensure safe and reliable steady state operation of the boilers and associated control systems.
- B. The commissioning period shall commence when all mechanical, electrical, and control systems are installed and individual system startup has been completed, or when a boiler is first fired, whichever occurs first. The commissioning period shall terminate when the plant has completed initial source testing, completed final plant tuning, and is available for commercial operation.
- C. During the commissioning period, the owner or operator shall keep records of the natural gas fuel combusted in the boilers on hourly and daily basis. The natural gas fuel combusted during the commissioning period shall accrue towards the annual fuel use limit.

**3. Right-of-Entry**

The "Right of Entry", as defined by California H&SC § 41510 of Division 26, shall apply at all times with respect to the equipment and the Control System. Representatives of the Great Basin Unified Air Pollution Control District shall be permitted to enter the facility to inspect and copy any record required to be kept under the terms of this permit. District staff shall also be permitted to inspect any equipment, work practices, air emission-related activity or method dictated by this permit. If deemed necessary by the District to verify compliance with these conditions, the permittee shall within 7 days notice be available to open any sample extraction port, or exhaust outlet for the purpose of conducting source tests or to collect samples. In enforcing the terms of this permit, any cost incurred in collecting samples, source testing and laboratory analysis fees shall be the responsibility of the applicant. [District Rules 210 and 302 Analysis Fee]

**4. Copy of Permit Onsite**

A copy of the permit shall be maintained readily available at all times on the operating premises. [District Rule 200.D]

**5. Report Violation of Emission Standard**

Any violation of any emission standard to which the stationary source is required to comply, as indicated by the records of the monitoring device, shall be reported by the operator of the source to the district within 96 hours after such occurrence. The district shall, in turn, report the violation to the state board within five working days after receiving the report of the violation from the operator. [Cal H&S § 42706]

**PRELIMINARY DETERMINATION OF COMPLIANCE**  
**California Energy Commission Application for Certification № 11-AFC-02**  
**District ATC Permit Applications 1604-00-11, 1605-00-11, 1606-00-11**  
**Hidden Hills Solar 1 Power Plant, Hidden Hills Solar 2 Power Plant and Common Area**

**6. Severability Clause**

If any provision of this permit is found invalid, such finding shall not affect any remaining provisions. [District Rule 107]

**7. Right to Revise Permit**

The provisions of this permit may be modified by the District if it determines the stipulated conditions are inadequate. [District Rule 210.C]

**8. Breakdown (or Emergency) Reporting Conditions**

A breakdown condition means an unforeseeable failure or malfunction of: 1) any air pollution control equipment or related operating equipment which causes a violation of any emission limitation or restriction prescribed by this permit or District rules and regulations, or by State law, or 2) any in-stack continuous monitoring equipment.

- A. The permittee shall comply with the breakdown requirements of District Rule 403 (Breakdown), which shall include notifying the Air Pollution Control Officer of a breakdown condition within an hour of detection, unless it can be demonstrated that a longer reporting period is necessary -- not to exceed two (2) days.
- B. Notification shall identify the time, location, equipment involved, and to the extent possible the cause of the breakdown and steps taken to correct the breakdown condition.
- C. Within one (1) week after the breakdown occurrence, the permittee shall submit a written report to the Air Pollution Control Officer which includes: date of correction of the breakdown, determination of the cause of the breakdown, corrective measures to prevent a recurrence, an estimate of the emissions caused by the breakdown condition, and pictures of the failed equipment, if available.
- D. Breakdown conditions shall not persist longer than 24 hours or the end of the production run, whichever is sooner, except for continuous monitoring equipment, for which the period shall be ninety-six (96) hours, unless the permittee obtains an Emergency Variance pursuant to District Rule 617. [District Rule 403]

**FACILITY OPERATING CONDITIONS**

**9. Visible Emissions Opacity Limit**

Visible emissions from any source shall not exceed a Ringelmann 1 (20% opacity) for a period or periods aggregating more than three minutes in any one hour. [District Rule 400]

**10. Unit Emission Limits**

To demonstrate consistency with the ambient air quality modeling and the screening health risk assessment provided in the application for certification to the California Energy Commission, the pound per hour equipment emission rate limits in Table 1 shall apply. Except during the commissioning period, startup/shutdown conditions and standby conditions, the pound per million Btu limits shall also apply. Compliance with these lb/MMBtu limits will also ensure compliance with the limits in the applicable New Source Performance Standards (NSPS).

**PRELIMINARY DETERMINATION OF COMPLIANCE**  
**California Energy Commission Application for Certification № 11-AFC-02**  
**District ATC Permit Applications 1604-00-11, 1605-00-11, 1606-00-11**  
**Hidden Hills Solar 1 Power Plant, Hidden Hills Solar 2 Power Plant and Common Area**

**Table 1: Criteria pollutant emission limits per unit in pounds per hour (pounds per million Btu)**

Pollutant	Auxiliary Boiler	Nighttime Preservation Boiler	Emergency Backup Engine	Emergency Fire Pump Engine
NOx as NO <sub>2</sub>	2.74 (0.0110)	0.17 (0.0110)	38.4	1.3
CO	4.55 (0.0183)	0.55 (0.0366)	20.8	1.15
VOC as CH <sub>4</sub>	1.34 (0.0054)	0.08 (0.0053)	1.3	0.08
PM <sub>10</sub> /PM <sub>2.5</sub>	1.25 (N/A)	0.08 (N/A)	1.2	0.07
SO <sub>2</sub>	0.52 (0.0021)	0.03 (0.0021)	0.04	0.003

**11. Combined Plant-wide Daily Emission Limits**

- A. “Plant-wide” shall mean this Solar 1 Power Plant facility, GBUAPCD № 1604-00-11, plus the adjacent Solar 2 Power Plant and Common Area facilities (permitted separately, GBUAPCD № 1605-00-11 and 1606-00-11, respectively).
- B. The total plant-wide combined emissions from the auxiliary and nighttime preservation boilers, emergency and fire pump engines shall not exceed the limits in Table 2.

**Table 2: Criteria pollutant emission limits in pounds per day**

Pollutant	All Fuel Burning Equipment
NOx as NO <sub>2</sub>	116.0
CO	156.1
VOC as CH <sub>4</sub>	37.8
PM <sub>10</sub> /PM <sub>2.5</sub>	21.3
SO <sub>2</sub>	7.4

- C. Compliance demonstration with these plant-wide limits shall entail the monitoring, recordkeeping and reporting requirements specified later in this permit.
- D. Compliance with the NOx limit shall be demonstrated via the use of a plant-wide NOx Predictive Emission Monitoring System (PEMS), in accordance with Condition 18, that totals both power plants’ boiler emission rates.

**12. Boiler Fuel Use Limits**

The total natural gas fuel consumption, expressed as heat input rates, shall not exceed 3,440 MMBtu/day or 746,400 MMBtu/year for combustion in the burners of all auxiliary and nighttime preservation boilers in the Solar 1 facility plus the adjacent Solar 2 facility (permitted separately, GBUAPCD № 1605-05-11).

**13. Toxic Hot Spots Program (AB 2588)**

In lieu of an emissions inventory plan, the District accepts the screening health risk assessment provided in the application for certification to the California Energy Commission. The combined Solar 1 and Solar 2 facilities shall be categorized under AB 2588 as “Intermediate Level” and shall meet the reporting requirements under Section V of the Emission Inventory Criteria and Guidelines for the Air Toxics "Hot Spots" Program.

**PRELIMINARY DETERMINATION OF COMPLIANCE**  
**California Energy Commission Application for Certification № 11-AFC-02**  
**District ATC Permit Applications 1604-00-11, 1605-00-11, 1606-00-11**  
**Hidden Hills Solar 1 Power Plant, Hidden Hills Solar 2 Power Plant and Common Area**

**BOILER SPECIFICATIONS AND NSPS STANDARDS**

**14. Boiler Specifications**

Each 249 MMBtu/hr auxiliary boiler (Unit B1A) and each 15 MMBtu/hr nighttime preservation boiler (Unit B2A) shall be equipped with low-NOx burners, 9 ppmvd NOx at 3% O<sub>2</sub> or less at loads exceeding 25% maximum continuous rating (MCR), and flue gas recirculation (FGR). The boilers shall meet all specifications stated in the permit application, including stack dimensions and pollutant emission rates.

**15. New Source Performance Standards (NSPS) for Auxiliary Boiler**

Each auxiliary boiler shall comply with the requirements of 40 CFR 60 Subpart Db – NSPS for Industrial-Commercial-Institutional Steam Generating Units. The boiler shall meet the following emission standards at all times except during periods of startup, shutdown, or malfunction:

- NOx: 0.20 lb/MMBtu (30-day average) [40 CFR §60.44b(a)]
- SO<sub>2</sub>: 0.20 lb/MMBtu [40 CFR §60.42b(k)]

**16. New Source Performance Standards (NSPS) for Nighttime Preservation Boiler**

Each nighttime preservation boiler shall comply with the requirements of 40 CFR 60 Subpart Dc – NSPS for Small Industrial-Commercial-Institutional Steam Generating Units. The SO<sub>2</sub> emission limit in this subpart does not apply because the unit is rated below 30 MMBtu/hr.

**BOILER MONITORING CONDITIONS**

**17. Fuel Type and Flow Monitoring**

- A. The burners for the auxiliary and nighttime preservation boilers shall be fueled with natural gas that meets the standards of the California Public Utilities Commission (CPUC).
- B. Each boiler shall be equipped with a continuous flow monitoring system to measure and record fuel consumption in million standard cubic feet per hour (MMscf/hr).

**18. Boiler Predictive NOx Emission Rate Monitoring Plan**

- A. As an element of the PEMS required by Condition 11.D, the permittee shall estimate the boiler emissions by continuously monitoring parameters indicative of emissions and maintaining records of the amount of natural gas combusted. The permittee shall monitor the boiler operating conditions and predict NOx emission rates as specified in a plan that shall:
  - (1) Be submitted to the District within 360 days of initial startup in accordance with 40 CFR Subpart Db §60.49b(c) and §60.49b(g);
  - (2) Identify the specific operating conditions to be monitored and the relationship between these operating conditions and NOx emission rates (i.e., lb/MMBtu heat

**PRELIMINARY DETERMINATION OF COMPLIANCE**  
**California Energy Commission Application for Certification № 11-AFC-02**  
**District ATC Permit Applications 1604-00-11, 1605-00-11, 1606-00-11**  
**Hidden Hills Solar 1 Power Plant, Hidden Hills Solar 2 Power Plant and Common Area**

- input). Steam generating unit operating conditions include, but are not limited to, the degree of staged combustion (i.e., the ratio of primary air to secondary and/or tertiary air) and the level of excess air (i.e., flue gas O<sub>2</sub> level);
- (3) Include the data and information that the permittee used to identify the relationship between NO<sub>x</sub> emission rates and these operating conditions; and
  - (4) Identify how these operating conditions, including steam generating unit load, will be monitored on an hourly basis by the permittee during the period of operation of the affected facility; the quality assurance procedures or practices that will be employed to ensure that the data generated by monitoring these operating conditions will be representative and accurate; and the type and format of the records of these operating conditions, including steam generating unit load, that will be maintained by the permittee under 40 CFR §60.49b(g). [40 CFR Subpart Db §60.48b(d)]
- B. If the permittee elects to estimate NO<sub>x</sub> emissions from the Nighttime Preservation Boilers using the pound per hour emission limit in Table 1, then the Plan may require continuous monitoring of only operating hours and fuel use for the Nighttime Preservation Boilers.

**BOILER TESTING CONDITIONS**

**19. Initial Boiler Testing**

- Initial performance testing shall be completed on each auxiliary and nighttime preservation boiler to demonstrate compliance with the emission limits specified in Condition 10 at each boiler's maximum achievable production rate.
- A. The initial performance test is to be scheduled within 60 days after achieving the maximum continuous rating (MCR) at which the affected facility will be operated, but not later than 180 days after initial startup of the facility. [§60.45b and 60.46b]
  - B. The permittee shall provide safe and accessible sampling ports that comply with California Industrial Safety Orders and Uniform Building Code and 40 CFR 60, Appendix A, Test Method 1.
  - C. A test protocol must be submitted to the Air Pollution Control District not later than 30 days before the proposed test date. This test protocol shall be approved by the District before testing begins and shall include the following, or other District-approved methods:
    - (5) PM<sub>10</sub> emissions: EPA Method 5, Methods 201/202 or CARB Method 5
    - (6) NO<sub>x</sub> emissions: EPA Method 7, 7A, 7E
    - (7) SO<sub>2</sub> emissions: EPA Method 6, 6A, 6B or 6C
    - (8) CO emissions: EPA Method 10
    - (9) VOC emissions: EPA Method 25A
  - D. A copy of the test results shall be submitted to the District within 60 days following test completion. [District Rule 200.C, and Cal H&S Code § 44340]

**PRELIMINARY DETERMINATION OF COMPLIANCE**  
**California Energy Commission Application for Certification № 11-AFC-02**  
**District ATC Permit Applications 1604-00-11, 1605-00-11, 1606-00-11**  
**Hidden Hills Solar 1 Power Plant, Hidden Hills Solar 2 Power Plant and Common Area**

**DIESEL BACKUP GENERATOR AND FIRE PUMP ENGINE CONDITIONS**

**20. Emergency Backup Generator Engine**

Each emergency backup generator shall be powered by a Tier 2, diesel-fueled, Caterpillar 3516C SCAC, 3,633 hp at 1,800 rpm, EPA Family ACPXL78.1T2E, CARB Executive Order U-R-001-0398-1, or an equivalent CARB-certified engine that meets the current EPA Tier standards for the given power range.

**21. Emergency Fire Pump Engine**

Each emergency fire pump shall be powered by a Tier 3, diesel-fueled, Cummins CFP7E-F30, 200 hp at 2,100 rpm, EPA Family ACEXL0409AAB, CARB Executive Order U-R-002-0516, or an equivalent CARB-certified engine that meets the current EPA Tier standards for the given power range.

**22. Airborne Toxics Control Measure**

The permittee shall operate the diesel emergency backup generator and fire pump engines in compliance with the California Code of Regulations, Title 17 (17 CCR) § 93115.

**23. Particulate Matter Limit**

Each emergency engine shall not discharge into the atmosphere particulate matter in excess of 0.3 grains per dry standard cubic foot of exhaust gas. [Rule 404-A].

**24. CARB Diesel Fuel**

Each engine shall be fueled with CARB diesel fuel with 15 parts-per-million sulfur content by weight or less, or an alternative diesel fuel that meets the requirements of the Standard of Motor Vehicle Fuel found in Title 13, CCR (13 CCR) § 2281. The amount of sulfur dioxide exhausted to the atmosphere shall not exceed 0.2% by volume. The permittee shall keep records of the composition of purchased fuel. [District Rules 210 and 416; 17 CCR § 93115.5(a)(1)]

**25. Hour Meter Required**

A non-resettable totalizer elapsed time meter shall be installed and maintained on each engine to indicate the cumulative hours of engine operation. [District Rule 210.A, 17 CCR § 93115].

**26. Non-Emergency Use Limitation**

- A. Each emergency backup generator engine shall be allowed to operate up to 50 hours per year for maintenance and testing purposes. Operation of the engine beyond the 50 hours shall be allowed only by the events as defined in Condition 27 for what constitutes emergency use. [District Rule 210.A, 17 CCR § 93115.6(a)(3)(A)].
- B. Each fire pump engine shall not operate more than the number of hours (up to 30 hours per year) necessary to comply with the testing requirements of the National Fire Protection Association (NFPA). [District Rule 210.A, 17 CCR § 93115.6(a)(4)(A)].



**PRELIMINARY DETERMINATION OF COMPLIANCE**  
**California Energy Commission Application for Certification № 11-AFC-02**  
**District ATC Permit Applications 1604-00-11, 1605-00-11, 1606-00-11**  
**Hidden Hills Solar 1 Power Plant, Hidden Hills Solar 2 Power Plant and Common Area**

**27. What Constitutes Emergency Use**

Emergency use of the engines is not limited and is defined in 17 CCR § 93115 as providing electrical power or mechanical work during any of the following events and subject to the following conditions that:

- A. the failure or loss of all or part of normal electrical power service or normal natural gas supply to the facility:
  - (1) which is caused by any reason other than the enforcement of a contractual obligation the permittee has with a third party or any other party; and
  - (2) which is demonstrated by the permittee to the district APCO's satisfaction to have been beyond the reasonable control of the owner or operator;
- B. the failure of a facility's internal power distribution system:
  - (1) which is caused by any reason other than the enforcement of a contractual obligation the permittee has with a third party or any other party; and
  - (2) which is demonstrated by the permittee to the district APCO's satisfaction to have been beyond the reasonable control of the owner or operator.
- C. the pumping of water for fire suppression or protection;
- D. the pumping of water to maintain pressure in the water distribution system for the following reasons:
  - (1) a pipe break that substantially reduced water pressure; or
  - (2) high demand on the water supply system due to high use of water for fire suppression; or
  - (3) the breakdown of electric-powered pumping equipment at sewage treatment facilities or water delivery facilities.

[District Rule 210.A, 17 CCR § 93115].

**28. Required Records for Emergency Engines**

The permittee shall keep a monthly log of usage that shall list and document the nature of use for each of the following:

- A. emergency use hours of operation;
- B. maintenance and testing hours of operation;
- C. hours of operation for emission testing to show compliance with the applicable standard;
- D. initial start-up testing hours;
- E. hours of operation for all uses other than those specified above; and
- F. the fuel used.
  - (1) For engines operated exclusively on CARB Diesel Fuel, the owner or operator shall document the use of CARB Diesel Fuel through the retention of fuel purchase records indicating that the only fuel purchased for supply to an emergency standby engine was CARB Diesel Fuel; or

**PRELIMINARY DETERMINATION OF COMPLIANCE**  
**California Energy Commission Application for Certification № 11-AFC-02**  
**District ATC Permit Applications 1604-00-11, 1605-00-11, 1606-00-11**  
**Hidden Hills Solar 1 Power Plant, Hidden Hills Solar 2 Power Plant and Common Area**

- (2) For engines operated on any fuel other than CARB Diesel Fuel, fuel records demonstrating that the only fuel purchased and added to an emergency standby engine or engines, or to any fuel tank directly attached to an emergency standby engine or engines, meets the requirements of section 93115.5(b).

[District Rule 210.A, 17 CCR § 93115.10(g)(1)].

**29. Record Retention**

Log entries shall be retained for a minimum of 36 months from the date of entry. Log entries made within 24 months of the most recent entry shall be retained on-site, either at a central location or at the engine's location, and made immediately available to the District staff upon request. Log entries made from 25 to 36 months from most recent entry shall be made available to District staff within 5 working days from request. [Rule 210.A, 17 CCR § 93115.10(g)(2)].

**PARTICULATE MATTER MITIGATION CONDITIONS**

**30. Fugitive Dust Mitigation**

The permittee shall take reasonable precautions during construction activities to prevent visible particulate matter from being airborne, under normal wind conditions, beyond the HHSEGS property line, in accordance with the requirements for dust control in Rule 401.A. The District deems the California Energy Commission (CEC) staff conditions of certification (HHSEGS) AQ-SC1 through AQ-SC5 for construction and operation mitigation methods to be reasonable precautions under Rule 401. The permittee shall submit the Air Quality Construction Mitigation Plan, required by AQ-SC2 to the District after its approval by the CEC. The permittee shall make available to the District, upon request, copies of the CEC-required Monthly Compliance Report containing documentation of the actions taken to comply with these conditions.

**FACILITY RECORDKEEPING & REPORTING CONDITIONS**

**31. Natural Gas Heat Input Records**

Records for demonstrating compliance with the plant-wide natural gas combustion heat input, required by Condition 12, shall be presented in MMBtu/day, MMBtu/month and MMBtu per rolling 12-month period.

**32. Plant-wide Emission Records**

Emission records for the plant-wide NO<sub>x</sub> PEMS, required by Condition 11, shall be presented in pounds per hour (lb/hr), pounds per day (lb/day) and pounds per million Btu (lb/MMBtu) for each individual boiler in the Solar 1 and Solar 2 facilities. The sum total of NO<sub>x</sub> for all boilers shall be presented in pounds per day (lb/day) for each calendar day, midnight to midnight.

Data obtained to estimate boiler NO<sub>x</sub> emissions shall be presented as specified in the plant-wide NO<sub>x</sub> PEMS plan required by Condition 18.

**PRELIMINARY DETERMINATION OF COMPLIANCE**  
**California Energy Commission Application for Certification № 11-AFC-02**  
**District ATC Permit Applications 1604-00-11, 1605-00-11, 1606-00-11**  
**Hidden Hills Solar 1 Power Plant, Hidden Hills Solar 2 Power Plant and Common Area**

**33. Monitoring Record Retention**

Required recordkeeping information shall be retained by the permittee in a form suitable for inspection for a period of at least two (2) years from the end of the calendar year of the journal entry. [Rule 206.B, Cal H&S Code § 42705]

**34. Reporting of Monitoring Records**

All monitoring records shall be made immediately available to the District staff upon request.

**ATC 1606-00-11, Common Area**

**REGULATED EQUIPMENT:**

ID №	Function	Make & Model	Serial Number	Fuel Type	Fuel Use
EG1C	Backup Generator	Tier 3, Caterpillar C9 ATAAC, 398 hp (or equivalent)	TBD	CARB Diesel	2.7 MMBtu/hr
FP1C	Fire Pump Engine	Tier 3, Cummins CFP7E-F30, 200 hp (or equivalent)	TBD	CARB Diesel	1.6 MMBtu/hr
<b>Total</b>					<b>4.3 MMBtu/hr</b>

**ANCILLARY EQUIPMENT:** An administration, warehouse, and maintenance complex, and an onsite switchyard for the Hidden Hills Solar 1 and Hidden Hills Solar 2 power plants (permitted separately, GBUAPCD № 1604-00-11 and 1605-00-11, respectively).

**EMISSIONS CONTROL:** The two diesel-fueled engines are Tier 3 and are compliant with the California Air Resources Board ATCM for Stationary Compression Ignition Engines, CCR § 93115. The two engines' non-emergency hours of operation shall be limited.

**CONDITIONS:** This ATC is subject to the attached approval conditions.

**COMMENCEMENT OF CONSTRUCTION:** The permittee shall not begin actual on-site construction of the equipment authorized by this Authority to Construct until the lead agency satisfies the requirements of the California Environmental Quality Act (CEQA).

**A PERMIT TO OPERATE** the above equipment shall be issued only after an inspection to determine if the equipment has been constructed according to the approved plans and specifications and the equipment can be operated in compliance with all Rules and Regulations of the Great Basin Unified Air Pollution Control District. Notify the District at (760) 872-8211 when construction is complete and the equipment is ready for operation.

**GENERAL CONDITIONS**

**1. Facility Startup**

The permittee shall notify the District in writing when construction is complete and the equipment is ready for commissioning operations. Operation of this equipment shall be conducted in accordance with all data and specifications submitted with the application under

**PRELIMINARY DETERMINATION OF COMPLIANCE**  
**California Energy Commission Application for Certification № 11-AFC-02**  
**District ATC Permit Applications 1604-00-11, 1605-00-11, 1606-00-11**  
**Hidden Hills Solar 1 Power Plant, Hidden Hills Solar 2 Power Plant and Common Area**

which this ATC is issued unless otherwise noted. Notification shall be given to the District office by email, Postal Service delivery or telephone facsimile transmission at least 72 hours prior to equipment start-up. Operation of this equipment without a written Permit to Operate is a violation of District Rule 200 B, and can result in civil and criminal penalties under California Health & Safety Code (H&SC) § 42400.

**2. Right-of-Entry**

The "Right of Entry", as defined by California H&SC § 41510 of Division 26, shall apply at all times with respect to the equipment and the Control System. Representatives of the Great Basin Unified Air Pollution Control District shall be permitted to enter the facility to inspect and copy any record required to be kept under the terms of this permit. District staff shall also be permitted to inspect any equipment, work practices, air emission-related activity or method dictated by this permit. If deemed necessary by the District to verify compliance with these conditions, the permittee shall within 7 days notice be available to open any sample extraction port, or exhaust outlet for the purpose of conducting source tests or to collect samples. In enforcing the terms of this permit, any cost incurred in collecting samples, source testing and laboratory analysis fees shall be the responsibility of the applicant. [District Rules 210 and 302 Analysis Fee]

**3. Copy of Permit Onsite**

A copy of the permit shall be maintained readily available at all times on the operating premises. [District Rule 200.D]

**4. Report Violation of Emission Standard**

Any violation of any emission standard to which the stationary source is required to comply, as indicated by the records of the monitoring device, shall be reported by the operator of the source to the district within 96 hours after such occurrence. The district shall, in turn, report the violation to the state board within five working days after receiving the report of the violation from the operator. [Cal H&S § 42706]

**5. Severability Clause**

If any provision of this permit is found invalid, such finding shall not affect any remaining provisions. [District Rule 107]

**6. Right to Revise Permit**

The provisions of this permit may be modified by the District if it determines the stipulated conditions are inadequate. [District Rule 210.C]

**7. Breakdown (or Emergency) Reporting Conditions**

A breakdown condition means an unforeseeable failure or malfunction of: 1) any air pollution control equipment or related operating equipment which causes a violation of any emission limitation or restriction prescribed by this permit or District rules and regulations, or by State law, or 2) any in-stack continuous monitoring equipment.

A. The permittee shall comply with the breakdown requirements of District Rule 403 (Breakdown), which shall include notifying the Air Pollution Control Officer of a

**PRELIMINARY DETERMINATION OF COMPLIANCE**  
**California Energy Commission Application for Certification № 11-AFC-02**  
**District ATC Permit Applications 1604-00-11, 1605-00-11, 1606-00-11**  
**Hidden Hills Solar 1 Power Plant, Hidden Hills Solar 2 Power Plant and Common Area**

breakdown condition within an hour of detection, unless it can be demonstrated that a longer reporting period is necessary -- not to exceed two (2) days.

- B. Notification shall identify the time, location, equipment involved, and to the extent possible the cause of the breakdown and steps taken to correct the breakdown condition.
- C. Within one (1) week after the breakdown occurrence, the permittee shall submit a written report to the Air Pollution Control Officer which includes: date of correction of the breakdown, determination of the cause of the breakdown, corrective measures to prevent a recurrence, an estimate of the emissions caused by the breakdown condition, and pictures of the failed equipment, if available.
- D. Breakdown conditions shall not persist longer than 24 hours or the end of the production run, whichever is sooner, except for continuous monitoring equipment, for which the period shall be ninety-six (96) hours, unless the permittee obtains an Emergency Variance pursuant to District Rule 617. [District Rule 403]

**FACILITY OPERATING CONDITIONS**

**8. Unit Emission Limits**

To demonstrate consistency with the ambient air quality modeling and the screening health risk assessment provided in the application for certification to the California Energy Commission, the pound per hour equipment emission rate limits in Table 1 shall apply.

**Table 1: Common Area Emission Limits in pounds per hour**

<b>Pollutant</b>	<b>Emergency Backup Engines</b>	<b>Emergency Fire Pump Engines</b>
NOx as NO <sub>2</sub>	2.6	1.3
CO	2.28	1.15
VOC as CH <sub>4</sub>	0.15	0.08
PM <sub>10</sub> /PM <sub>2.5</sub>	0.13	0.07
SO <sub>2</sub>	0.004	0.003

**DIESEL BACKUP GENERATOR AND FIRE PUMP ENGINE CONDITIONS**

**9. Visible Emissions Opacity Limit**

Visible emissions from each engine shall not exceed a Ringelmann 1 (20% opacity) for a period or periods aggregating more than three minutes in any one hour. [District Rule 400]

**10. Emergency Backup Generator Engine**

The emergency backup generator (Unit EG1C) shall be powered by a Tier 3, diesel-fueled, Caterpillar C9 ATAAC, 398 hp at 1,800 rpm, EPA Family ACPXL08.8ESX, CARB Executive Order U-R-001-0373, or an equivalent CARB-certified engine that meets the current EPA Tier standards for the given power range.

**PRELIMINARY DETERMINATION OF COMPLIANCE**  
**California Energy Commission Application for Certification № 11-AFC-02**  
**District ATC Permit Applications 1604-00-11, 1605-00-11, 1606-00-11**  
**Hidden Hills Solar 1 Power Plant, Hidden Hills Solar 2 Power Plant and Common Area**

**11. Emergency Fire Pump Engine**

The emergency fire pump (Unit FP1C) shall be powered by a Tier 3, diesel-fueled, Cummins CFP7E-F30, 200 hp at 2,100 rpm, EPA Family ACEXL0409AAB, CARB Executive Order U-R-002-0516, or an equivalent CARB-certified engine that meets the current EPA Tier standards for the given power range.

**12. Airborne Toxics Control Measure**

The permittee shall operate the diesel emergency backup generator and fire pump engines in compliance with the California Code of Regulations, Title 17 (17 CCR) § 93115.

**13. Particulate Matter Limit**

Each emergency engine shall not discharge into the atmosphere particulate matter in excess of 0.3 grains per dry standard cubic foot of exhaust gas. [Rule 404-A].

**14. CARB Diesel Fuel**

Each engine shall be fueled with CARB diesel fuel with 15 parts-per-million sulfur content by weight or less, or an alternative diesel fuel that meets the requirements of the Standard of Motor Vehicle Fuel found in Title 13, CCR (13 CCR) § 2281. The amount of sulfur dioxide exhausted to the atmosphere shall not exceed 0.2% by volume. The permittee shall keep records of the composition of purchased fuel. [District Rules 210 and 416; 17 CCR § 93115.5(a)(1)]

**15. Hour Meter Required**

A non-resettable totalizer elapsed time meter shall be installed and maintained on each engine to indicate the cumulative hours of engine operation. [District Rule 210.A, 17 CCR § 93115].

**16. Non-Emergency Use Limitation**

- A. The emergency backup generator engine shall be allowed to operate up to 50 hours per year for maintenance and testing purposes. Operation of the engine beyond the 50 hours shall be allowed only by the events as defined in Condition 16 for what constitutes emergency use. [District Rule 210.A, 17 CCR § 93115.6(a)(3)(A)].
- B. The fire pump engine shall not operate more than the number of hours (up to 30 hours per year) necessary to comply with the testing requirements of the National Fire Protection Association (NFPA). [District Rule 210.A, 17 CCR § 93115.6(a)(4)(A)].

**17. What Constitutes Emergency Use**

Emergency use of the engines is not limited and is defined in 17 CCR § 93115 as providing electrical power or mechanical work during any of the following events and subject to the following conditions that:

- A. the failure or loss of all or part of normal electrical power service or normal natural gas supply to the facility:

**PRELIMINARY DETERMINATION OF COMPLIANCE**  
**California Energy Commission Application for Certification № 11-AFC-02**  
**District ATC Permit Applications 1604-00-11, 1605-00-11, 1606-00-11**  
**Hidden Hills Solar 1 Power Plant, Hidden Hills Solar 2 Power Plant and Common Area**

- (3) which is caused by any reason other than the enforcement of a contractual obligation the permittee has with a third party or any other party; and
- (4) which is demonstrated by the permittee to the district APCO's satisfaction to have been beyond the reasonable control of the owner or operator;
- B. the failure of a facility's internal power distribution system:
  - (3) which is caused by any reason other than the enforcement of a contractual obligation the permittee has with a third party or any other party; and
  - (4) which is demonstrated by the permittee to the district APCO's satisfaction to have been beyond the reasonable control of the owner or operator;
- C. the pumping of water for fire suppression or protection;
- D. the pumping of water to maintain pressure in the water distribution system for the following reasons:
  - (1) a pipe break that substantially reduces water pressure; or
  - (2) high demand on the water supply system due to high use of water for fire suppression; or
  - (3) the breakdown of electric-powered pumping equipment at sewage treatment facilities or water delivery facilities.

[District Rule 210.A, 17 CCR § 93115].

**18. Required Records for Emergency Engines**

The permittee shall keep a monthly log of usage that shall list and document the nature of use for each of the following:

- A. emergency use hours of operation;
- B. maintenance and testing hours of operation;
- C. hours of operation for emission testing to show compliance with the applicable standard;
- D. initial start-up testing hours;
- E. hours of operation for all uses other than those specified above; and
- F. the fuel used.
  - (1) For engines operated exclusively on CARB Diesel Fuel, the owner or operator shall document the use of CARB Diesel Fuel through the retention of fuel purchase records indicating that the only fuel purchased for supply to an emergency standby engine was CARB Diesel Fuel; or
  - (2) For engines operated on any fuel other than CARB Diesel Fuel, fuel records demonstrating that the only fuel purchased and added to an emergency standby engine or engines, or to any fuel tank directly attached to an emergency standby engine or engines, meets the requirements of section 93115.5(b).

[District Rule 210.A, 17 CCR § 93115.10(g)(1)].

**PRELIMINARY DETERMINATION OF COMPLIANCE**  
**California Energy Commission Application for Certification № 11-AFC-02**  
**District ATC Permit Applications 1604-00-11, 1605-00-11, 1606-00-11**  
**Hidden Hills Solar 1 Power Plant, Hidden Hills Solar 2 Power Plant and Common Area**

**19. Record Retention**

Log entries shall be retained for a minimum of 36 months from the date of entry. Log entries made within 24 months of the most recent entry shall be retained on-site, either at a central location or at the engine's location, and made immediately available to the District staff upon request. Log entries made from 25 to 36 months from most recent entry shall be made available to District staff within 5 working days from request. [Rule 210.A, 17 CCR § 93115.10(g)(2)].



**APPENDIX A: Responses to the Air Quality section of Cindy MacDonald's Preliminary Public Comments, Technical Analysis & Recommendations (Pages 1-35), Posted March 29, 2012 and Submitted directly to the Great Basin Unified Air Pollution Control District via Email on April 12, 2012.**

**1. AIR EMISSIONS LIMITATIONS**

**Question 1.1:** Where are the discussions specific to limitations and restrictions regarding the use of the boilers via air emissions?

**Response:** The applicant included proposed emissions and fuel use limitations in the application. The District will ensure compliance with the proposed limitations through hourly and daily emission limits; hourly, daily and annual fuel use limits; and a plant-wide NO<sub>x</sub> predictive emission monitoring system (PEMS). The District has included conditions in the draft Authorities to Construct that will impose these limitations and require testing, monitoring, recordkeeping and reporting requirements. Please see Section 7 of the District engineering evaluation and Conditions 10, 11, 12, 17, 18 and 19 of the draft ATC for the boilers. These conditions will also be included in the CEC license, should the project be approved by the CEC.

**Question 1.2:** Who is responsible for monitoring and enforcing these limitations and restrictions and how will this be accomplished in this remote area?

**Response:** The District will have primary authority for monitoring compliance with permit conditions. In addition, the CEC will have a Compliance Project Manager (CPM) who will be responsible for overseeing compliance with all conditions of the CEC license, including air quality conditions. As indicated in the response to Question 1.1, the Authorities to Construct (and the CEC license) will include testing, monitoring, recordkeeping and reporting requirements to demonstrate compliance with the permit requirements and limitations. Some of the reports are required to be submitted directly to the District and the CPM; other records must be maintained for a minimum of two years and made available to the District upon request.

**2. SF<sub>6</sub> MODELING PARAMETERS**

**Question 2.1:** What were the lbs. of SF<sub>6</sub> per circuit breaker used to create the emissions model analysis?

**Response:** First we must note that the District has no authority over greenhouse gas emissions (GHG). GHG emissions from stationary sources are regulated by EPA through the Prevention of Significant Deterioration (PSD) program.<sup>1</sup> The District has not been delegated the authority to implement the PSD program for sources within its jurisdiction, so PSD requirements for stationary sources within the GBUAPCD are implemented by EPA Region 9. The applicant's calculations demonstrate that GHG emissions from the project are well below the PSD applicability threshold.

Although the District has no authority over GHG emissions, we did review the applicant's calculations, and those calculations indicate that the highest value in the range referenced by the commenter, 208 pounds per circuit breaker, was used in the calculations.

---

<sup>1</sup> EPA has also proposed to adopt a new source performance standard (NSPS) relating to GHG emissions from certain stationary sources, but the NSPS has not yet been adopted.

**APPENDIX A: Responses to the Air Quality section of Cindy MacDonald's Preliminary Public Comments, Technical Analysis & Recommendations (Pages 1-35), Posted March 29, 2012 and Submitted directly to the Great Basin Unified Air Pollution Control District via Email on April 12, 2012.**

**Question 2.2:** Since the lbs. of SF<sub>6</sub> vary depending on the manufacture, what is the range of SF<sub>6</sub> emissions the HHSEGS can potentially emit, depending on the specifications of the manufacturers cited?

**Response:** The applicant used the high end of the ranges of SF<sub>6</sub> contents and leakage rates referenced by the commentor to calculate maximum potential SF<sub>6</sub> emissions of 2.0x10<sup>-3</sup> metric tons/yr from circuit breakers at the proposed project. Potential SF<sub>6</sub> emissions could theoretically be as low as zero.

**Question 2.3:** If each lb. of SF<sub>6</sub> is the equivalent of 11 tons of CO<sub>2</sub> as described by the EPA and the applicant estimates SF<sub>6</sub> requirements for the HHSEGS project are estimated to yield 48 metric tons of CO<sub>2</sub> p/year, does this indicate that only a little over 4 lbs. of SF<sub>6</sub> were modeled to derive the annual CO<sub>2</sub> yield? If not, why not? Please explain.

**Response:** Yes, the calculation of 4.4 lb/yr of SF<sub>6</sub> is consistent with the applicant's calculations.

**Question 2.4:** According to the EPA's conversion factor for each lb. of SF<sub>6</sub>, the site will store the equivalent of 2,200 tons of potential CO<sub>2</sub> emissions. What is the applicants CO<sub>2</sub> equivalent of 200 lbs. of the SF<sub>6</sub> that will be stored onsite? Please explain.

**Response:** All of the SF<sub>6</sub> at the project site will be contained within the circuit breakers, as indicated in Table 5.5-2 of the AFC—there will be no additional SF<sub>6</sub> stored at the site. As shown in Note 6 to Table 5.1B-13 of the AFC, the project will include 4 breakers that contain up to 208 lb of SF<sub>6</sub> each and 2 breakers that contain up to 24.2 lb of SF<sub>6</sub> each. Total SF<sub>6</sub> contained within the circuit breakers is 880.4 lb, calculated as follows:

$$(4 * 208 \text{ lb}) + (2 * 24.2 \text{ lb}) = 880.4 \text{ lb}$$

The quantity of SF<sub>6</sub> in Table 5.5-3 of the AFC should be shown as 880.4 lb. Converting this amount to CO<sub>2</sub> equivalents is not appropriate, since this equivalence occurs only when the SF<sub>6</sub> is released to the atmosphere, and not when it is stored.

**Question 2.5:** Does any of the SF<sub>6</sub> stored onsite have the potential to create emissions? If so, by what percent?

**Response:** Please see the responses to Questions 2.3, 2.4 and 2.6.

**Question 2.6:** While the NEMA leakage standard for new circuit breakers is 0.1%, will this percentage degrade over the life of the project? If so, by how much and what are the cumulative impacts of the projected degradation?

**Response:** The applicant assumed a leakage rate of 0.5% over the life of the project. This accounts for any degradation beyond the NEMA leakage standard.

**APPENDIX A: Responses to the Air Quality section of Cindy MacDonald's Preliminary Public Comments, Technical Analysis & Recommendations (Pages 1-35), Posted March 29, 2012 and Submitted directly to the Great Basin Unified Air Pollution Control District via Email on April 12, 2012.**

**Question 2.7:** While the applicant assumes an annual SF<sub>6</sub> leakage rate of 0.5%, based on the EPA approved permit for the Palmdale Hybrid Power plant, is it more realistic to assume an annual leakage rate of 10%? If not, why not?

**Response:** The applicant's assumed leakage rate of 0.5% is documented and appears to be conservative. As discussed above, the District has no authority over GHG emissions.

### **3. CONDENSATE/FLASH TANKS**

**Question 3.1:** Are air emissions specific to condensate and flash tanks included in the emissions evaluations for the HHSEGS? If so, where are they located?

**Response:** According to the applicant's documentation, the flash tanks will contain boiler blowdown, which will include steam that contains dissolved solids and silica. The water treatment chemicals will be in the form of dissolved solids. The tanks will not contain any volatile organic compounds and therefore are not regulated by the District.

**Question 3.2:** Prior to condensate being "flushed into the atmosphere", will the flash tanks vent any emissions? If so, what kind, how much and for how long?

**Response:** The flash tanks are not expected to vent any air pollutant emissions.

**Question 3.3:** What are the projected atmosphere emissions from the flashing process including kind of chemical, amount and duration?

**Response:** As indicated in the response to question 3.2 above, the flash tanks are not expected to vent any air pollutant emissions.

**Question 3.4:** Where are the flash tanks located at the project site?

**Response:** These tanks are too small to be seen on the plant layout figures. The flash tanks for the solar receiver steam generators are located next to each solar tower. The small flash tanks for the natural gas-fired boilers are located near the boilers.

### **4. THERMAL EVAPORATOR**

**Question 4.1:** Does the use of thermal evaporators result in additional emissions/pollutants dispensed into the air? If so, how much and what kinds of emissions?

**Response:** According to the applicant, the thermal evaporators will use a distillation process to recover water from the wastewater and will be heated using an electric heat source. The distillation is a closed-loop process so the thermal evaporators will not generate any air pollutants.

**APPENDIX A: Responses to the Air Quality section of Cindy MacDonald's Preliminary Public Comments, Technical Analysis & Recommendations (Pages 1-35), Posted March 29, 2012 and Submitted directly to the Great Basin Unified Air Pollution Control District via Email on April 12, 2012.**

**Question 4.2:** Are air emissions specific to the thermal evaporators included in the emissions evaluations for the HHSEGS? If so, where are they located?

**Response:** Please see the response to Question 4.1. The thermal distillation units will be located near the water treatment building at each power block.

## **5. PIGGING FACILITIES**

**Question 5.1:** Why are pigging facilities merely described as "possibly"?

**Response:** This question relates to the natural gas fuel system. Because the District rules exempt this type of equipment from permitting requirements (Rule 201 (d)(20): Equipment used exclusively to compress or hold dry natural gas), the District does not regulate this equipment. Potential environmental impacts of the fuel system are being evaluated by the CEC staff as part of their CEQA-equivalent review.

**Question 5.2:** What are the impacts of including pigging facilities at the HHSEGS site, i.e., construction, emissions, hazardous wastes, etc.?

**Response:** Emissions from construction of the onsite natural gas metering station were included in the evaluation of project construction emissions. With respect to hazardous waste and other environmental impacts, please see the response to Question 5.1 above.

## **6. EPA TOOLS: NATURAL GAS EMISSIONS**

**Question 6.1:** How many of the EPA Recommended Tools will the HHSEGS incorporate?

**Response:** This question relates to the natural gas fuel system. Because the District rules exempt this type of equipment from permitting requirements (Rule 201 (d)(20): Equipment used exclusively to compress or hold dry natural gas), the District does not regulate this equipment. Potential environmental impacts of the fuel system are being evaluated by the CEC staff as part of their CEQA-equivalent review.

**Question 6.2:** Are there places within the current design system that do not incorporate these tools that can be redesigned to incorporate them?

**Response:** Please see the response to Question 6.1 above.

**Question 6.3:** How will each portion of the HHSEGS system comply and/or compare to all applicable recommendations on this page?

**Response:** Please see the response to Question 6.1 above.

**APPENDIX A: Responses to the Air Quality section of Cindy MacDonald's Preliminary Public Comments, Technical Analysis & Recommendations (Pages 1-35), Posted March 29, 2012 and Submitted directly to the Great Basin Unified Air Pollution Control District via Email on April 12, 2012.**

## **7. DIESEL EXHAUST**

**Question 7.1:** Since Table 5.1F-2 specifically cites "Inyo County, CA" Tons Per Year, were the "offsite emissions" calculations site-specific to the Inyo County portion of the project or did they include emissions produced from the Nevada side as well?

**Response:** The District has authority over stationary sources of emissions within the GBUAPCD; we have no authority over emissions from mobile sources, such as exhaust emissions from worker travel or truck deliveries, or over emissions sources within Nevada. The offsite emissions calculations do not include emissions in Nevada.

**Question 7.2:** What are the diesel exhaust PM<sub>10</sub> concentrations in terms of daily and annual emissions?

**Response:** Although the District does not have authority over mobile sources of emissions, we did review the applicant's calculations of diesel exhaust PM<sub>10</sub> during construction. Diesel exhaust PM<sub>10</sub> emissions during construction is equivalent to the combustion portion of PM<sub>10</sub> shown in Tables 5.1F-1 and 5.1F-2 of the AFC: 15.2 pounds per day and 1.3 tons per year.

**Question 7.3:** If diesel exhaust PM<sub>10</sub> concentrations were included in the cumulative totals presented in Table 5.1F-2, what would the daily and annual cumulative emissions results be?

**Response:** As indicated in the response to Question 7.2, diesel exhaust PM<sub>10</sub> is included in the cumulative totals presented in Tables 5.1F-1 and 5.1F-2 of the AFC as the combustion portion of PM<sub>10</sub>. Therefore the daily and annual cumulative emissions are as presented in those tables.

**Question 7.4:** What were the parameters and inputs used to model the Health Risk of Diesel Exhaust to determine the applicants' conclusions, ie., areas of concentration, operations emissions, vehicular travel, mirror washing activities, etc.?

**Response:** With regard to diesel exhaust emissions from vehicular traffic, including mirror washing activities, please see the response to Question 7.1 above. Although the District does not have authority over mobile sources of emissions, we did review the applicant's description of the modeling analysis for construction emissions in Appendix F. The parameters and emission rates used to model vehicle exhaust emissions are described on page 5.1F-6 of the AFC (Dispersion Model).

Diesel exhaust will also be emitted by the emergency diesel generators and fire pump engines that will be part of the operational power plant equipment. The diesel particulate matter emissions from these diesel-fueled stationary engines were included in the applicant's screening health risk assessment. The parameters used in modeling those units are shown in Tables 5.1E-3 and 5.1E-5 of the AFC.

**APPENDIX A: Responses to the Air Quality section of Cindy MacDonald's Preliminary Public Comments, Technical Analysis & Recommendations (Pages 1-35), Posted March 29, 2012 and Submitted directly to the Great Basin Unified Air Pollution Control District via Email on April 12, 2012.**

**8. WORKER TRAVEL/TRUCK DELIVERIES: MAXIMUM DAILY EMISSIONS**

**Question 8.1:** How does the applicants' use of averages accurately represent "maximum" and "peak" emissions impacts during the construction phase of the HHSEGS?

**Response:** The District has authority over stationary sources of emissions within the GBUAPCD; we have no authority over emissions from mobile sources, such as exhaust emissions from worker travel or truck deliveries. However, the District did evaluate the applicant's calculations of fugitive dust emissions from construction activities and believes that the calculations are based on reasonable assumptions and produce a reasonable estimate of peak fugitive emissions and impacts during construction. For example, regarding peak daily emissions associated with worker travel during the construction phase of the project, the applicant's peak daily emissions calculations are based on 1,033 workers per day. This corresponds to the peak workforce estimate during the entire construction period (May 2014). The same is true for peak daily emissions associated with delivery truck emissions: the applicant's daily emission calculations are based on 384 truck deliveries occurring on a single day. This is clearly a peak daily number given that the total number of monthly truck deliveries range from 55 to 717 truck deliveries occurring during an entire month.

Annual emissions from worker and truck deliveries during the construction period are also based on the peak 12-month period. For example, the annual emissions for truck deliveries are based on a total of 6,151 deliveries per year. This represents the highest rolling 12-month total (May 2013 to April 2014) during the entire construction period. The same is true for annual emissions associated with worker travel—the calculation of annual worker travel emissions assumes 961 workers per day over a 12-month period. This represents the average number of workers per day occurring during the peak 12-month period (October 2013 to September 2014).

**Question 8.2:** Why is the applicant allowed to omit 2-3 days per month of emissions calculations for Worker Travel/Truck Deliveries?

**Response:** As discussed in the response to Question 8.1, the annual emissions are based on the peak number of workers and truck deliveries over a 12-month period. Therefore, the number of days per month is not a factor in these calculations.

**Question 8.3:** Were other emission calculations performed using 288 days in the year? If so, which ones?

**Response:** Because the District has no authority over mobile sources of emissions, the district has no information regarding other calculations of emissions from construction-related mobile source exhaust emissions. The 288 days per year referenced by the commentor is used by the applicant to convert annual emissions to g/sec emission rates for air quality dispersion modeling

**APPENDIX A: Responses to the Air Quality section of Cindy MacDonald's Preliminary Public Comments, Technical Analysis & Recommendations (Pages 1-35), Posted March 29, 2012 and Submitted directly to the Great Basin Unified Air Pollution Control District via Email on April 12, 2012.**

purposes. Given that construction work may not occur during some weekends over the course of a year, this number appears reasonable because it results in an average of 24 work days per month averaged over an entire year. This number does not appear to be directly used by the Applicant in other construction emission calculation.

**Question 8.4:** Has the use of "rolling averages" and other averages allowed the applicant to reduce maximum projected emissions in other calculations concerning actual impacts of the HHSEGS?

**Response:** As discussed in the responses to Question 8.1, the District believes that the construction calculations are based on reasonable assumptions and produce a reasonable estimate of peak fugitive emissions and impacts during construction. In addition, the District will ensure that the applicant's calculations of emissions from stationary sources represent maximum potential emissions from those sources. Emissions from the permitted stationary sources at the facility will be limited by the limitations and restrictions in the Authorities to Construct, so maximum emissions from those sources cannot exceed the emissions upon which the analyses in the application were based.

## **9. PRODUCE EXPOSURE PATHWAYS**

**Question 9.1:** Gardens were included in the applicant's own descriptions of the goals of the St. Theresa Mission, yet a health screening risk to local food production from the HHSEGS was not evaluated. Why not?

**Response:** The screening health risk assessment did not include the potential for exposure through the produce pathway because the applicant had no information to indicate that the gardens at St. Therese Mission would be producing food.

**Question 9.2:** What are going to be the impacts to local food production for residents in Charleston View?

**Response:** The District believes that the project will have no significant impacts on local food production for residents in Charleston View. The applicant's screening health risk assessment showed that the maximum potential cancer risk at any residential receptor is well below one in one million. The "Air Toxics Hot Spots Program Guidance Manual for Preparation of Health Risk Assessments,"<sup>2</sup> which is the regulatory guidance used for preparation of screening health risk assessments, indicates that the only substance potentially emitted from the proposed project that may have health effects through produce ingestion is PAHs (see Table 5.1 of the Hot Spots Guidance Manual). As shown in Table 5.1E-2R of the AFC, PAH emissions from the project will be orders of magnitude below the emissions of other noncriteria pollutants, so we believe

---

<sup>2</sup> Office of Environmental Health Hazard Assessment, "Air Toxics Hot Spots Program Risk Assessment Guidelines: The Air Toxics Hot Spots Program Guidance Manual for Preparation of Health Risk Assessments," August 2003, available at [http://oehha.ca.gov/air/hot\\_spots/pdf/HRAguidefinal.pdf](http://oehha.ca.gov/air/hot_spots/pdf/HRAguidefinal.pdf).

**APPENDIX A: Responses to the Air Quality section of Cindy MacDonald's Preliminary Public Comments, Technical Analysis & Recommendations (Pages 1-35), Posted March 29, 2012 and Submitted directly to the Great Basin Unified Air Pollution Control District via Email on April 12, 2012.**

that consideration of the produce ingestion pathway for PAHs will not affect our conclusion that emissions from the project will not pose a health risk to the community.

**10. PUBLIC NOTICE: AQIA TRIGGER LEVELS**

*Air Quality Impact Analysis (AQIA)*

**Question 10.1:** How will project emissions and trigger levels be monitored to provide public notice as there is no air quality monitoring station within the area?

**Response:** The reference from the application does not relate to monitored ambient air quality. The reference is instead to a requirement under Rule 209-A for providing public notice of intent to issue an Authority to Construct (that permits a project to have emissions exceed the AQIA trigger levels in Rule 216). The proposed HHSEGS project has estimated NO<sub>x</sub> emissions exceeding the AQIA trigger levels, so the District reviewed the air quality impact analysis prepared by the applicant. The analysis demonstrates that the maximum impacts from NO<sub>x</sub> are below the ambient air quality standards (AAQS). The District Air Pollution Control Officer (APCO) will be issuing a public notice, to be published in two local newspapers (the Pahrump Valley Times and the Inyo Register) regarding his intent to issue permits to the project.

**Question 10.2:** Will residents be dependent on the owners of the plant as the sole source of monitoring air quality?

**Response:** The Authorities to Construct and subsequent Permits to Operate will not require ambient monitoring at the facility because the maximum modeled impacts are below the AAQS. Permit conditions ensure compliance with these standards. With respect to monitored air quality, air pollution control agencies monitor ambient concentrations of criteria air pollutants and post those concentrations on their websites and through printed publications. All of that information will be available to the public. CARB posts air quality data for locations throughout California at <http://www.arb.ca.gov/aqmis2/aqmis2.php>.

**Question 10.3:** What method(s) will the GBUAPCD Air Pollution Control Officer use to notify the residents of Charleston View in the event the project exceeds air quality standards?

**Response:** Please see the response to Questions 10.1 and 10.2.

**Question 10.4:** Will the GBUAPCD Air Pollution Control Officer also be required to notify residents of Pahrump?

**Response:** Please see the response to Questions 10.1 and 10.2.

**Question 10.5:** What is the definition and specific parameters of "timely manner"?



**APPENDIX A: Responses to the Air Quality section of Cindy MacDonald's Preliminary Public Comments, Technical Analysis & Recommendations (Pages 1-35), Posted March 29, 2012 and Submitted directly to the Great Basin Unified Air Pollution Control District via Email on April 12, 2012.**

**Response:** In the cited instance, a “timely manner” means in accordance with the timeline provided the District’s rules. The District’s rules require the APCO to publish a notice in a newspaper of general circulation and to accept comments for 30 days after publication.

## **11. PSD CLASS I WILDERNESS AREAS**

**Question 11.1:** Why is the Maximum Allowable Class II significant impact levels provided but not Class I?

**Response:** As discussed in the Preliminary Determination of Compliance (Section 11, p. 10), the Pahrump Valley Wilderness is not a designated Class I area. Because there are no designated Class I areas within 100 km of the project, comparison of project impacts with Class I significant impact levels is not required.

## **12. PSD SIGNIFICANT THRESHOLD TRIGGERS**

**Question 12.1:** Why aren't CO<sub>2</sub> emissions included in the PSD Significant Thresholds in Table 5.1-1?

**Response:** CO<sub>2</sub> is included as part of greenhouse gases (GHG), which are shown in the cited table. GHG (which includes CO<sub>2</sub>, CH<sub>4</sub>, N<sub>2</sub>O, SF<sub>6</sub> and others) is shown in the table because GHG and not CO<sub>2</sub> is the regulated pollutant. CO<sub>2</sub> emissions are shown separately in Table 5.1B-13 of the AFC.

**Question 12.2:** Are the PSD Significant Emissions Threshold tpy in Table 5.1-1 listed as metric tpy, a "short" ton p/y, or are they CO<sub>2</sub> equivalents?

**Response:** The thresholds listed are all listed in short tons per year. GHG is defined in terms of CO<sub>2</sub> equivalence, so the GHG threshold shown in the table on a CO<sub>2</sub>e basis.

**Question 12.3:** Why are the PSD Significant Emissions Threshold trigger levels different in Table 5.1-1 versus Table 5.1-29?

**Response:** The trigger levels are different in the two tables because the tables are showing thresholds that apply for different purposes in the PSD program. Table 5.1-1 of the AFC shows PSD significant emissions thresholds, while Table 5.1-29 of the AFC shows PSD major source thresholds.

**Question 12.4:** Under what authority did changes to PSD Significant Emissions Threshold levels become effective as of July 1, 2011; federal, state, regional?

**Response:** The change to the GHG significant emissions threshold was made by a federal regulation.

**APPENDIX A: Responses to the Air Quality section of Cindy MacDonald's Preliminary Public Comments, Technical Analysis & Recommendations (Pages 1-35), Posted March 29, 2012 and Submitted directly to the Great Basin Unified Air Pollution Control District via Email on April 12, 2012.**

**Question 12.5:** Why did Table 5.1-28 provide metric tons p/y for Nitrous Oxide and Methane but only provided a formula for the SF<sub>6</sub> emissions?

**Response:** Table 5.1-28 of the AFC shows SF<sub>6</sub> emissions of 2.0x10<sup>-3</sup> metric tons per year.

### **13. INSUFFICIENT DATA: MODELING PARAMETERS**

**Question 13.1:** Why is annual SO<sub>2</sub> and CO data missing from 2010?

**Response:** At the time the AFC was prepared, the final, quality-assured annual SO<sub>2</sub> and 8-hour CO were not available from the Air Resources Board (ARB) iADAM website. The District reviewed the complete 2010 data to ensure that the background concentrations used in the AFC were conservative. The 2010 annual average SO<sub>2</sub> concentration at Trona and 8-hour average CO concentration at Barstow were 0.001 ppm (2.7 µg/m<sup>3</sup>) and 0.89 ppm (989 µg/m<sup>3</sup>), respectively—equal to or lower than the background concentrations that were used in the applicant's modeling analysis.

**Question 13.2:** With 2010 annual NO<sub>2</sub> data classified as "insufficient", was this where the applicant filled in "missing data" during the modeling analysis? If so, why are the 2010 NO<sub>2</sub> values still missing?

**Response:** No. The annual NO<sub>2</sub> concentrations shown in Table 5.1-34 of the AFC are annual averages of monitored concentrations measured at nearby, representative air quality monitoring stations, and these averages are calculated and reported by the ARB—they are not updated or recalculated by the applicant. The modeling analysis relies on hourly NO<sub>2</sub> data. The discussion of filling in missing data refers to using conservative hourly NO<sub>2</sub> concentrations to fill in individual missing hours of measured NO<sub>2</sub> concentrations, following District-approved procedures.

### **14. UPPER AIR DATA: REPRESENTATIVE MODELING**

**Question 14.1:** What section of the Clean Air Act and/or Code of Federal Regulations requires upper air data to meet a 90% completeness data threshold?

**Response:** Upper air data is part of the meteorological data set that is used in ambient air quality modeling. 40 CFR Part 51 Appendix W contains EPA's permit modeling guidance, and refers to a specific meteorological monitoring guidance document, "Meteorological Monitoring Guidance for Regulatory Modeling Applications."<sup>3</sup> The 90% completeness requirement appears in Section 5.3.2 of the guidance document (p. 5-4), and reads as follows:

---

<sup>3</sup> Publication No. EPA-454/R-99-005. Office of Air Quality Planning & Standards, Research Triangle Park, NC. (PB 2001-103606). Available at <http://www.epa.gov/scram001/>

**APPENDIX A: Responses to the Air Quality section of Cindy MacDonald's Preliminary Public Comments, Technical Analysis & Recommendations (Pages 1-35), Posted March 29, 2012 and Submitted directly to the Great Basin Unified Air Pollution Control District via Email on April 12, 2012.**

“Regulatory analyses for the short-term ambient air quality standards (1 to 24-hour averaging) involve the sequential application of a dispersion model to every hour in the analysis period (one to five years); such analyses require a meteorological record for every hour in the analysis period. Substitution for missing or invalid data is used to meet this requirement. Applicants in regulatory modeling analyses are allowed to substitute for up to 10 percent of the data; conversely, *the meteorological data base must be 90 percent complete (before substitution) in order to be acceptable for use in regulatory dispersion modeling.*” [emphasis added]

**Question 14.2:** What section of the Clean Air Act and/or Code of Federal Regulations requires upper data used for site-specific modeling purposes to be exclusively taken from the three years closest to the proposed project?

**Response:** Upper air data is part of the meteorological data set that is used in ambient air quality modeling. Both Appendix W and the meteorological monitoring guidance document cited above recommend the use of a five-year meteorological data set.

Appendix W:

8.3.1.2 Recommendations

a. Five years of representative meteorological data should be used when estimating concentrations with an air quality model. Consecutive years from the most recent, readily available 5-year period are preferred. The *meteorological data should be adequately representative*, and may be site specific or *from a nearby NWS station...*

b. *The use of 5 years of NWS meteorological data or at least 1 year of site specific data is required...* [emphasis added]

“Meteorological Monitoring Guidance for Regulatory Modeling Applications:”

**5.3.1 Length of Record**

The duration of a meteorological monitoring program should be set to ensure that worst-case meteorological conditions are adequately represented in the data base; the minimum duration for most dispersion modeling applications is one year. Recommendations on the length of record for regulatory dispersion modeling as published in The Guideline on Air Quality Models [1] are: *five years of National Weather Service (NWS) meteorological data* or at least one year of site-specific data. Consecutive years from the most recent, readily available 5-year period are preferred. [emphasis added]

**APPENDIX A: Responses to the Air Quality section of Cindy MacDonald's Preliminary Public Comments, Technical Analysis & Recommendations (Pages 1-35), Posted March 29, 2012 and Submitted directly to the Great Basin Unified Air Pollution Control District via Email on April 12, 2012.**

**15. PM<sub>10</sub>/PM<sub>2.5</sub> SUBSTITUTIONS**

**Question 15.1:** Is PM<sub>10</sub> and PM<sub>2.5</sub> data available from the Pahrump monitoring station that would satisfy a 90% data completeness threshold for EPA regulatory air quality monitoring standards for the years 2003-2010?

**Response:** PM<sub>2.5</sub> is not monitored at Pahrump; therefore no PM<sub>2.5</sub> data is available from Pahrump.

Data used to represent existing background concentrations is not required to meet a 90% completeness criterion. The 90% criterion is applicable only to the individual meteorological data elements that are used in ambient air quality modeling (such as surface and upper air wind speeds, wind directions, etc.). The applicant explained why PM<sub>10</sub> concentrations from Pahrump were not used to represent existing background concentrations at the project site. The District concurs in the applicant's assessment that PM<sub>10</sub> concentrations monitored at Jean better represent conditions in the project area than PM<sub>10</sub> concentrations monitored at Pahrump.

**Question 15.2:** Even though the southern end of Pahrump is cited as 4 miles away, no analysis, discussion or cumulative analysis was applied to HHSEGs impacts to Pahrump's air quality. Why?

**Response:** The ambient air quality impact analysis included receptors in California and Nevada, and the air quality impacts of the project reported in Table 5.1-36R of the AFC represent the highest modeled concentrations at any receptor. The highest PM<sub>10</sub> and PM<sub>2.5</sub> modeled impacts from the project are below the levels considered by EPA to be significant. Based on this, we conclude that the project will not have significant PM<sub>10</sub> or PM<sub>2.5</sub> impacts anywhere, including in Pahrump. Because there will be no significant impacts, the District determined that no additional analysis, discussion or cumulative analysis of impacts at Pahrump were necessary.

**16. FINAL GEOTECHNICAL ANALYSIS: ADDITIONAL AIR-QUALITY MODELING**

**Question 16.1:** Will the applicant remodel all PM<sub>10</sub> and PM<sub>2.5</sub> air quality and fugitive dust emission calculations after reviewing the final Geotechnical Report?

**Response:** The District does not intend to require remodeling of fugitive dust emissions. The draft Authorities to Construct include conditions that require mitigation of dust emissions, including the use of best practices to minimize fugitive dust emissions during construction and operation. The District believes these conditions will be adequate to ensure that fugitive dust emissions are minimized.

**17. SOIL LOSS. WIND EROSION: AFFECTED ACREAGE**

**Question 17.1:** What is the unnumbered/unnamed table in Appendix 5.11A soil loss calculations in reference too?

**APPENDIX A: Responses to the Air Quality section of Cindy MacDonald's Preliminary Public Comments, Technical Analysis & Recommendations (Pages 1-35), Posted March 29, 2012 and Submitted directly to the Great Basin Unified Air Pollution Control District via Email on April 12, 2012.**

**Response:** Soil loss and water erosion are not within the jurisdiction of the District. Soil loss and water erosion issues are being addressed by the CEC staff in the context of their CEQA-equivalent review.

**Question 17.2:** Why does this unnumbered/unnamed table have significantly less notes, project assumptions and description of input parameters than Table 5.11-3 for Water Erosion?

**Response:** Please see the response to Question 17.1.

**Question 17.3:** Why, in all modeling for soil loss calculations in Appendix 5.11A, did the applicant use the input of "dense grass, not harvested" as representing the No Project parameters when this fails to represent site-specific arid environmental conditions?

**Response:** Please see the response to Question 17.1.

**Question 17.4:** Why does the affected acreage total in Table 6 (412 acres) differ from the individual acreage breakdown in Table 5.11-3 and the unnumbered/unnamed table in the Soil Loss Calculation Appendix (418 acres)?

**Response:** Please see the response to Question 17.1. The District has relied on the emissions calculations and ambient air quality impact analysis in Appendix 5.1F of the AFC for conclusions regarding construction fugitive dust impacts, including PM<sub>2.5</sub> and PM<sub>10</sub> impacts. There is no longer an ambient air quality standard for Total Suspended Particulates.

**Question 17.5:** In what section of the applicants documents is the total suspended particles (TPS) modeled and what methods/input was used to determine Table 6's conclusions?

**Response:** Please see the responses to Questions 17.1 and 17.4.

**Question 17.6:** How does the total suspended particles calculated at tons p/year differ from soil loss estimates calculated as tons p/year?

**Response:** Please see the response to Question 17.1.

## **18. LEVEL 2 EMISSION FACTOR**

**Question 18.1:** What is the correct value assigned by the Midwest Research Institute, 0.11 tons/acre/month as stated in the URBEMIS software-or 0.011 tons/acre/month as used by the applicant?

**Response:** The correct value is 0.011 tons/acre/month, as used by the applicant. This is the Level 2 value shown in Table ES-2 of the 1996 Midwest Research Institute report, reproduced below. As indicated in the table, the Level 1 emission factor should be used if only the disturbed

**APPENDIX A: Responses to the Air Quality section of Cindy MacDonald's Preliminary Public Comments, Technical Analysis & Recommendations (Pages 1-35), Posted March 29, 2012 and Submitted directly to the Great Basin Unified Air Pollution Control District via Email on April 12, 2012.**

area and duration are known. However, the Level 2 emission factor was used since the applicant had specific data about other equipment operation, such as the activity for scrapers, graders, and other off-road equipment traveling on unpaved surfaces and roadways

**Table ES-2. Recommended Emission Factors**

Basis for emission factor	Recommended PM <sub>10</sub> construction emission factor	
Level 1—Only area and duration known	Apply	0.11 ton/acre-month (average conditions) 0.42 ton/acre-month (worst-case conditions)
Level 2—Area and amount of earthmoving known	Apply	0.011 ton/acre-month for each month of construction activity
	Plus	0.059 ton/1,000 yard <sup>3</sup> of on-site cut/fill 0.22 ton/1,000 yard <sup>3</sup> of off-site cut/fill
		These values are based on an assumption that one scraper can move 70,000 yard <sup>3</sup> of earth in one month and 35,000 yard <sup>3</sup> of material can be moved by truck in one month. If the on-/off-site fraction is not known, assume 100% on-site.
Level 3—More detailed information available on duration of earthmoving and other material movement.	Apply	0.13 lb/acre-work hr
	plus	49 lb/scraper-hr for on-site haulage <sup>a</sup> 94 lb/hr for off-site haulage <sup>b</sup>
Level 4—Detailed information on number of units and travel distances available	Apply	0.13 lb/acre-work hr
	plus	0.21 lb/ton-mile for on-site haulage 0.62 lb/ton-mile for off-site haulage <sup>b</sup>

<sup>a</sup> If the number of scrapers in use is not known, a default value of 4 may be used. In addition, if the actual capacity of earthmoving units is known, values given in the body of the report should be used.

<sup>b</sup> Factor for use with over-the-road trucks. If "off-highway" trucks are used haulage should be considered "on-site."

**19. ACRES: WINDBLOWN DUST EMISSIONS MODELING**

**Question 19.1:** Why is only 276,744 sq-ft or 6.35 acres used to calculate windblown PM10 dust emissions from active construction sites?

**Response:** The area used to calculate windblown dust emissions corresponds to the maximum expected disturbed area resulting from active construction activities. This area is significantly smaller than the total area that will be disturbed during all construction activities due to mitigation requirements to minimize the area of disturbance and to replace ground cover and stabilize disturbed surfaces to the extent feasible. Therefore, it was estimated that 276,744 square feet (or 6.35 acres) would be actively disturbed at any one time. This value was calculated from the total disturbed area (3,202 acres) divided by the total months of expected

**APPENDIX A: Responses to the Air Quality section of Cindy MacDonald's Preliminary Public Comments, Technical Analysis & Recommendations (Pages 1-35), Posted March 29, 2012 and Submitted directly to the Great Basin Unified Air Pollution Control District via Email on April 12, 2012.**

active surface disturbance (21 months) and the total number of working days per month during expected active surface disturbance (24 days).

**Question 19.2:** Why do the windblown dust values never change in the PM<sub>10</sub> analysis, despite increases in construction activities over the course of the construction phase of the project?

**Response:** The windblown dust emissions are proportional to the total area of active disturbance and are not directly related to the level of other construction activities. As discussed in the response to Question 19.1, this value was estimated at 6.35 acres disturbed at any time throughout the life of the project. The level of other construction activities during the various phases of construction may be estimated by the level of off-road and on-road vehicle use. Fugitive dust emission from these vehicles are calculated separately and added to the windblown dust emissions. Therefore, months with higher off-road and on-road vehicle use will result in higher total dust emissions. However, increased vehicle activity and travel on unpaved surfaces does not suggest an increased active area of surface disturbance. Rather, increased vehicle activity simply represents more VMT within the active disturbed area, which is assumed to remain constant.

**Question 19.3:** Is the value assigned by the applicant for windblown dust PM<sub>10</sub> emissions (2.51E-06) the same as the 0.11 tons/acre/month value cited by the Midwest Research Institute?

**Response:** The controlled PM<sub>10</sub> emission factor of 2.51 E-6 lbs PM<sub>10</sub>/sf of active construction area is neither equivalent to, nor based on, an emission factor of 0.11 tons/acre-month. The emission factor of 0.11 tons/acre-month is the Level 1 emission factor reported by Midwest Research Institute. As explained under the response to Question 18.1, the Level 2 emission factor of 0.011 tons/acre-month was used by the applicant, in addition to additional fugitive dust emissions calculated from off-road and on-road vehicle travel on unpaved surfaces and roads. The emission factor of 2.51 E-6 lbs PM<sub>10</sub>/sf of active construction area is equivalent to 0.011 tons PM<sub>10</sub>/acre-month (0.73 lbs PM<sub>10</sub>/acre-day or 1.68 E-5 lbs PM<sub>10</sub>/sf-day) after applying an 85 percent control factor for watering and other soil stabilization measures.

**Question 19.4:** Does the 0.11 tons/acre/month value translate into 10 lbs p/day? If so, how is this applied to dust emission calculations for active construction areas at the HHSEGS project site?

**Response:** As explained in the response to question 19.3, the HHSEGS construction analysis did not rely on an emission factor of 0.11 tons/acre-month.

**Question 19.5:** In calculating disturbed acreage and emissions factors, has the applicant factored in perimeter disturbance areas that extend beyond the buildings, heliostat placement, electrical trenching, etc.? If so, by what factors?

**Response:** Construction of the project will not require mass grading of the entire solar field—this type of activity will be reserved only for the power blocks and common area. Nevertheless, the active construction areas were estimated to be nearly the entire project site area—an area

**APPENDIX A: Responses to the Air Quality section of Cindy MacDonald's Preliminary Public Comments, Technical Analysis & Recommendations (Pages 1-35), Posted March 29, 2012 and Submitted directly to the Great Basin Unified Air Pollution Control District via Email on April 12, 2012.**

larger than the building areas, heliostat placement areas, and areas of onsite trenching. The total disturbed area from construction activities was assumed to be 3,202 acres, consisting of 1,482 acres for Solar Plant 1, 1,509 acres for Solar Plant 2, 108 acres of temporary construction areas, and 103 acres of common area. It is noted that the final site area used in the AFC document was 3,277 acres—or 2.3 percent larger than the area used for windblown dust emission factors, but nonetheless accounting for perimeter areas. However, as noted in the answer to Question 19.1, only a fraction of the total site area will be actively disturbed at any one time, with the remainder of the area stabilized to prevent wind erosion.

## **20. WORKER TRAVEL/TRUCK DELIVERIES: DUST EMISSIONS**

**Question 20.2:** Is there an analysis for PM<sub>10</sub> and PM<sub>2.5</sub> dust emissions for Delivery Trucks? If so, where is it located?

**Response:** For the most part, trucks delivering power plant components are not anticipated to travel on unpaved roads or surfaces, and therefore will not significantly contribute to onsite PM<sub>10</sub> or PM<sub>2.5</sub> emissions. Rather, delivery trucks are expected to remain on the internal paved roads and surfaces within the project boundaries and deliver their loads to those areas. From those paved areas, the power plant components will be transported to their installation locations via (largely off-road) vehicles for which PM<sub>10</sub> and PM<sub>2.5</sub> emissions were calculated in the analysis. These fugitive PM<sub>10</sub> and PM<sub>2.5</sub> emissions are shown in Tables 5.1F-1 and 5.1F-2 of the AFC. It is noted that certain “on-road” vehicles were also accounted for in this analysis (as operating on unpaved surfaces). These on-road vehicles include up to 20 transmix trucks, one semi-truck/tractor, up to three water trucks, and up to six pickup trucks.

## **21. AWD GATORS/ATV DUST EMISSIONS**

**Question 21.1:** What is an "AWD Gator" and what function will it perform during the HHSEGS construction phase of the project?

**Response:** The term “Gator” refers to a small, lightweight, utility vehicle, with the “AWD” designating that the vehicles are all-wheel drive. This type of vehicle is most commonly used on golf courses, for landscaping, and for internal transport on large campuses. These vehicles are expected to be used at the project in much the same way—to deliver personnel, light tools, and small quantities of materials to various locations internal to the project area.

**Question 21.2:** If the John Deere "Gator" is what the applicant is referencing in their construction equipment, why are there no dust emissions calculations included in their impact analysis?

**Response:** Similar to delivery vehicles, the utility vehicles are not expected to operate excessively on active disturbed surfaces, and therefore would not contribute significantly to onsite fugitive PM<sub>10</sub> and PM<sub>2.5</sub> emissions. Rather, these vehicles will operate mainly on paved,



**APPENDIX A: Responses to the Air Quality section of Cindy MacDonald's Preliminary Public Comments, Technical Analysis & Recommendations (Pages 1-35), Posted March 29, 2012 and Submitted directly to the Great Basin Unified Air Pollution Control District via Email on April 12, 2012.**

improved, and stabilized surfaces. Their emissions are accounted for under Fugitive Dust in Tables 5.1F-1 and 5.1F-2 of the AFC.

**Question 21.3:** If the AWD Gator is not an ATV, where has the applicant listed and calculated impacts from ATV use at the HHSEGS project site, including estimated acreage disturbances and PM<sub>10</sub> and PM<sub>2.5</sub> dust emissions?

**Response:** As stated in the answer to the previous question, the Gator vehicles are utility vehicles that will operate internally to deliver personnel, light tools, and small quantities of material to various locations internal to the project. These utility vehicles are not engaged in activities that create additional active construction or disturbed areas beyond those already accounted for in the analysis and shown in Tables 5.1F-1 and 5.1F-2 of the AFC.

## **22. FUGITIVE DUST: CUMULATIVE IMPACTS**

**Question 22.1:** Was an air dispersion model performed that incorporated fugitive dust and emissions impacts occurring within the HHSEGS project site combined with impacts at the fenceline? If not, why not?

**Response:** Yes, the ambient air quality impact analyses evaluated the impacts of all on-site activities and emissions to off-site air quality. The construction impacts analysis included exhaust emissions from the construction equipment, mechanically generated fugitive dust emissions (from the activities of the construction equipment, such as grading, excavation and travel), and windblown fugitive dust. The air quality impact analysis for the operational phase of the project included the boilers, the engines, the wet surface air coolers, and both exhaust and fugitive dust emissions from activities of the mirror washing machines. These project impacts were then added to background concentrations to estimate total impacts; the results are shown in the AFC at Table 5.1-38.

## **23. FUGITIVE DUST CONTROL: WATER TRUCK MODELING**

**Question 23.1:** If the water trucks will only be operational 10 hours a day, what happens with dust emissions during the other 14 hours water is not being applied?

**Response:** The analysis assumes that up to three water trucks will each operate up to 10 hours per day (for a total of 30 truck-hours/day) during all phases of the project when disturbed active construction areas will occur. The water trucks were assumed to travel a combined 90 miles per day while performing their intended function. Operation of the water trucks is not limited to ten consecutive hours of simultaneous operation. Rather, operation of the trucks will be staggered, and likewise, will be intermittent throughout the construction day to ensure that the actively disturbed areas will be adequately wetted to minimize fugitive dust emissions.

**APPENDIX A: Responses to the Air Quality section of Cindy MacDonald's Preliminary Public Comments, Technical Analysis & Recommendations (Pages 1-35), Posted March 29, 2012 and Submitted directly to the Great Basin Unified Air Pollution Control District via Email on April 12, 2012.**

**Question 23.2:** To determine dust emissions, was the equation that used water applications every 6 hours applied to a 24-hour period or was it only for the 10 hours the water trucks will actually be operational?

**Response:** The watering frequency is expected to be once every six hours (during a 24-hour period) rather than once every six hours during a 10-hour period of consecutive operation. The latter would equate to only one watering event per calendar day, which is a much lower level of control than what is assumed in the analysis.

**Question 23.3:** Water trucks will only be operational for 10 hours. If water is only applied every 6 hours, is it reasonable to assume that the water trucks will only apply water once on an exposed area during their shift?

**Response:** Water trucks will be available for operation, as needed on a continuous basis, and not only during a consecutive ten-hour period during a 24-hour calendar day. Therefore, it is incorrect to assume that water will be applied only once per shift. As previously stated, water will be applied, as needed, on average of once every six hours. The watering frequency may be more frequent if activities and conditions dictate. Watering will be reduced during wet periods, during calm periods, and during periods of minimal surface disturbance.

## **24. FUGITIVE DUST CONTROL: INADEQUATE IMPACT ANALYSIS**

**Question 24.1:** Since Bright Source is farther along in the construction phase of the Ivanpah SEGS, has the demands of its construction yielded any more specific plans, product information and safety data regarding similar mitigation measures to be utilized for fugitive dust control and soil erosion at the Ivanpah site?

**Response:** As discussed in the response to Question 17.1, the question of soil erosion control is outside the jurisdiction of the District and will be addressed by the CEC in their CEQA-equivalent review. The District is proposing to adopt by reference the CEC's mitigation measures for fugitive dust control at HHSEGS (see Condition 30 of the draft ATC). These mitigation measures are expected to be essentially identical to the construction fugitive dust mitigation measures imposed by the CEC in their license for the Ivanpah SEGS project (and other, similar projects located in desert areas). The District understands from the CEC staff that these conditions have been successful in minimizing fugitive dust emissions from construction activities at Ivanpah and other desert solar projects. Typical fugitive dust mitigation conditions are as follows:

The following fugitive dust mitigation measures shall be included in the Air Quality Construction Mitigation Plan (AQCMP) prepared by the applicant ...

- a) The main access roads through the facility to the power block areas will be either paved or stabilized using soil binders, or equivalent methods, to provide a stabilized surface that is similar for the purposes of dust control to paving, that

**APPENDIX A: Responses to the Air Quality section of Cindy MacDonald's Preliminary Public Comments, Technical Analysis & Recommendations (Pages 1-35), Posted March 29, 2012 and Submitted directly to the Great Basin Unified Air Pollution Control District via Email on April 12, 2012.**

may or may not include a crushed rock (gravel or similar material with fines removed) top layer, prior to initiating construction in the main power block area, and delivery areas for operations materials (chemicals, replacement parts, etc.) will be paved prior to taking initial deliveries.

b) All unpaved construction roads and unpaved operational site roads, as they are being constructed, shall be stabilized with a non-toxic soil stabilizer or soil weighting agent that can be determined to be both as efficient or more efficient for fugitive dust control as ARB approved soil stabilizers, and shall not increase any other environmental impacts including loss of vegetation. All other disturbed areas in the project and linear construction sites shall be watered as frequently as necessary during grading; and after active construction activities shall be stabilized with a non-toxic soil stabilizer or soil weighting agent, or alternative approved soil stabilizing methods, in order to comply with the dust mitigation objectives of Condition of Certification AQ-SC4. The frequency of watering can be reduced or eliminated during periods of precipitation.

c) No vehicle shall exceed 10 miles per hour on unpaved areas within the construction site, with the exception that vehicles may travel up to 25 miles per hour on stabilized unpaved roads as long as such speeds do not create visible dust emissions.

d) Visible speed limit signs shall be posted at the construction site entrances.

e) All construction equipment vehicle tires shall be inspected and washed as necessary to be cleaned free of dirt prior to entering paved roadways.

f) Gravel ramps of at least 20 feet in length must be provided at the tire washing/cleaning station.

g) All unpaved exits from the construction site shall be graveled or treated to prevent track-out to public roadways.

h) All construction vehicles shall enter the construction site through the treated entrance roadways, unless an alternative route has been submitted to and approved by the CPM and BLM Authorized Officer.

i) Construction areas adjacent to any paved roadway below the grade of the surrounding construction area or otherwise directly impacted by sediment from site drainage shall be provided with sandbags or other equivalently effective measures to prevent run-off to roadways, or other similar run-off control measures as specified in the Storm Water Pollution Prevention Plan (SWPPP), only when such SWPPP measures are necessary so that this condition does not conflict with the requirements of the SWPPP.

**APPENDIX A: Responses to the Air Quality section of Cindy MacDonald's Preliminary Public Comments, Technical Analysis & Recommendations (Pages 1-35), Posted March 29, 2012 and Submitted directly to the Great Basin Unified Air Pollution Control District via Email on April 12, 2012.**

j) All paved roads within the construction site shall be swept daily or as needed (less during periods of precipitation) on days when construction activity occurs to prevent the accumulation of dirt and debris.

k) At least the first 500 feet of any paved public roadway exiting the construction site or exiting other unpaved roads en route from the construction site or construction staging areas shall be swept as needed (less during periods of precipitation) on days when construction activity occurs or on any other day when dirt or runoff resulting from the construction site activities is visible on the public paved roadways.

l) All soil storage piles and disturbed areas that remain inactive for longer than 10 days shall be covered, or shall be treated with appropriate dust suppressant compounds.

m) All vehicles that are used to transport solid bulk material on public roadways and that have potential to cause visible emissions shall be provided with a cover, or the materials shall be sufficiently wetted and loaded onto the trucks in a manner to provide at least one foot of freeboard.

n) Wind erosion control techniques (such as windbreaks, water, chemical dust suppressants, and/or vegetation) shall be used on all construction areas that may be disturbed. Any windbreaks installed to comply with this condition shall remain in place until the soil is stabilized or permanently covered with vegetation.



## GREAT BASIN UNIFIED AIR POLLUTION CONTROL DISTRICT

157 Short Street, Bishop, California 93514-3537 www.gbuapcd.org

Tel: 760-872-8211 Fax: 760-872-6109 info@gbuapcd.org

### **AUTHORITY TO CONSTRUCT 1604-00-11 HIDDEN HILLS SOLAR 1 POWER PLANT**

**GRANTED TO:**

Hidden Hills Solar I, LLC, a wholly owned subsidiary of  
Hidden Hills Solar Holdings, LLC, a wholly owned  
subsidiary of BrightSource Energy, Inc.  
1999 Harrison Street  
Oakland, CA 94612

**EQUIPMENT ADDRESS:**

1,483-acre area, just north of Charleston  
View (Calvada Springs) and Tecopa Road  
(Old Spanish Trail Highway)  
Inyo County, CA, bounded on the NE by the  
CA-NV border

**THIS AUTHORITY TO CONSTRUCT (ATC) IS NOT A PERMIT TO OPERATE AND WILL  
EXPIRE FIVE YEARS FROM THE DATE GRANTED!**

**REGULATED EQUIPMENT: 250 Megawatt Solar Power Plant with the following equipment:**

ID No	Function	Make & Model	Serial Number	Fuel Type	Fuel Use
B1A	Auxiliary Boiler	TBD	TBD	Natural Gas	249 MMBtu/hr
B2A	Nighttime Preservation Boiler	TBD	TBD	Natural Gas	15 MMBtu/hr
EG1A	Backup Generator	Tier 2, Caterpillar 3516C, 3633 hp (or equivalent)	TBD	CARB Diesel	24 MMBtu/hr
FP1A	Fire Pump Engine	Tier 3, Cummins CFP7E-F30, 200 hp (or equivalent)	TBD	CARB Diesel	2 MMBtu/hr
<b>Total</b>					<b>290 MMBtu/hr</b>

**ANCILLARY EQUIPMENT:** A heliostat array with about 90,000 heliostats, a power block containing a Rankine-cycle non-reheat steam turbine, a solar receiver steam generator atop a 750-foot tower, feed water heaters, a deaerator, an air-cooled condenser, wet surface air cooler (with high efficiency drift eliminator), oil-water separator and diesel fuel aboveground storage tanks.

**EMISSIONS CONTROL:** Low NOx (9 PPM) boiler burners with flue gas recirculation, annual and daily NOx emission limits, hours of operation limits, and a plantwide NOx emission monitoring system.

**CONDITIONS:** This ATC is subject to the attached approval conditions.

**COMMENCEMENT OF CONSTRUCTION:** The permittee shall not begin actual on-site construction of the equipment authorized by this Authority to Construct until the lead agency satisfies the requirements of the California Environmental Quality Act (CEQA).

**A PERMIT TO OPERATE** the above equipment shall be issued only after an inspection to determine if the equipment has been constructed according to the approved plans and specifications and the equipment can be operated in compliance with all Rules and Regulations of the Great Basin Unified Air Pollution Control District. Notify the District at (760) 872-8211 when construction is complete and the equipment is ready for operation.

Duane Ono  
Deputy Air Pollution Control Officer

Date Granted

# CONDITIONAL APPROVAL ATC 1604-00-11

## HIDDEN HILLS SOLAR 1 POWER PLANT

### GENERAL CONDITIONS

#### **1. Facility Startup**

The permittee shall notify the District in writing when construction is complete and the equipment is ready for commissioning operations. Operation of this equipment shall be conducted in accordance with all data and specifications submitted with the application under which this ATC is issued unless otherwise noted. Notification shall be given to the District office by email, Postal Service delivery or telephone facsimile transmission at least 72 hours prior to equipment start-up. Operation of this equipment without a written Permit to Operate is a violation of District Rule 200 B, and can result in civil and criminal penalties under California Health & Safety Code (H&SC) § 42400.

#### **2. Commissioning Period under Temporary Permit to Operate:**

Following a District inspection verifying that the facility is constructed in a manner consistent with the specifications in the application and with this Authority to Construct, a temporary Permit to Operate (TPO) shall be issued. The TPO shall be valid for the duration of the commissioning period defined below and until a Permit to Operate is issued or denied.

- A. Commissioning activities are defined as, but not limited to, all testing, adjustment, tuning, and calibration activities recommended by the equipment manufacturers and the construction contractor to ensure safe and reliable steady state operation of the boilers and associated control systems.
- B. The commissioning period shall commence when all mechanical, electrical, and control systems are installed and individual system startup has been completed, or when a boiler is first fired, whichever occurs first. The commissioning period shall terminate when the plant has completed initial source testing, completed final plant tuning, and is available for commercial operation.
- C. During the commissioning period, the owner or operator shall keep records of the natural gas fuel combusted in the boilers on hourly and daily basis. The natural gas fuel combusted during the commissioning period shall accrue towards the annual fuel use limit.

#### **3. Right-of-Entry**

The "Right of Entry", as defined by California H&SC § 41510 of Division 26, shall apply at all times with respect to the equipment and the Control System. Representatives of the Great Basin Unified Air Pollution Control District shall be permitted to enter the facility to inspect and copy any record required to be kept under the terms of this permit. District staff shall also be permitted to inspect any equipment, work practices, air emission-related activity or method dictated by this permit. If deemed necessary by the District to verify compliance with these conditions, the permittee shall within 7 days notice be available to open any sample extraction port, or exhaust outlet for the purpose of conducting source tests or to collect samples. In enforcing the terms of this permit, any cost incurred in collecting samples, source testing and laboratory analysis fees shall be the responsibility of the applicant. [District Rules 210 and 302 Analysis Fee]

# CONDITIONAL APPROVAL ATC 1604-00-11

## HIDDEN HILLS SOLAR 1 POWER PLANT

### 4. Copy of Permit Onsite

A copy of the permit shall be maintained readily available at all times on the operating premises. [District Rule 200.D]

### 5. Report Violation of Emission Standard

Any violation of any emission standard to which the stationary source is required to comply, as indicated by the records of the monitoring device, shall be reported by the operator of the source to the district within 96 hours after such occurrence. The district shall, in turn, report the violation to the state board within five working days after receiving the report of the violation from the operator. [Cal H&S § 42706]

### 6. Severability Clause

If any provision of this permit is found invalid, such finding shall not affect any remaining provisions. [District Rule 107]

### 7. Right to Revise Permit

The provisions of this permit may be modified by the District if it determines the stipulated conditions are inadequate. [District Rule 210.C]

### 8. Breakdown (or Emergency) Reporting Conditions

A breakdown condition means an unforeseeable failure or malfunction of: 1) any air pollution control equipment or related operating equipment which causes a violation of any emission limitation or restriction prescribed by this permit or District rules and regulations, or by State law, or 2) any in-stack continuous monitoring equipment.

- A. The permittee shall comply with the breakdown requirements of District Rule 403 (Breakdown), which shall include notifying the Air Pollution Control Officer of a breakdown condition within an hour of detection, unless it can be demonstrated that a longer reporting period is necessary -- not to exceed two (2) days.
- B. Notification shall identify the time, location, equipment involved, and to the extent possible the cause of the breakdown and steps taken to correct the breakdown condition.
- C. Within one (1) week after the breakdown occurrence, the permittee shall submit a written report to the Air Pollution Control Officer which includes: date of correction of the breakdown, determination of the cause of the breakdown, corrective measures to prevent a recurrence, an estimate of the emissions caused by the breakdown condition, and pictures of the failed equipment, if available.
- D. Breakdown conditions shall not persist longer than 24 hours or the end of the production run, whichever is sooner, except for continuous monitoring equipment, for which the period shall be ninety-six (96) hours, unless the permittee obtains an Emergency Variance pursuant to District Rule 617. [District Rule 403]

## FACILITY OPERATING CONDITIONS

### 9. Visible Emissions Opacity Limit

Visible emissions from any source shall not exceed a Ringelmann 1 (20% opacity) for a period or periods aggregating more than three minutes in any one hour. [District Rule 400]

# CONDITIONAL APPROVAL ATC 1604-00-11

## HIDDEN HILLS SOLAR 1 POWER PLANT

### 10. Unit Emission Limits

To demonstrate consistency with the ambient air quality modeling and the screening health risk assessment provided in the application for certification to the California Energy Commission, the pound per hour equipment emission rate limits in Table 1 shall apply. Except during the commissioning period, startup/shutdown conditions and standby conditions, the pound per million Btu limits shall also apply. Compliance with these lb/MMBtu limits will also ensure compliance with the limits in the applicable New Source Performance Standards (NSPS).

**Table 1: Criteria Pollutant Emission Limits in pounds per hour (pounds per million Btu)**

Pollutant	Auxiliary Boiler	Nighttime Preservation Boiler	Emergency Backup Engine	Emergency Fire Pump Engine
NO <sub>x</sub> as NO <sub>2</sub>	2.74 (0.0110)	0.17 (0.0110)	38.4	1.3
CO	4.55 (0.0183)	0.55 (0.0366)	20.8	1.15
VOC as CH <sub>4</sub>	1.34 (0.0054)	0.08 (0.0053)	1.3	0.08
PM <sub>10</sub> /PM <sub>2.5</sub>	1.25 (N/A)	0.08 (N/A)	1.2	0.07
SO <sub>2</sub>	0.52 (0.0021)	0.03 (0.0021)	0.04	0.003

### 11. Combined Plant-wide Daily Emission Limits

- A. "Plant-wide" shall mean this Solar 1 power plant facility, GBUAPCD No 1604-00-11, plus the adjacent Solar 2 power plant and common area facilities (permitted separately, GBUAPCD No 1605-00-11 and 1606-00-11, respectively).
- B. The total plant-wide combined emissions from the auxiliary and nighttime preservation boilers, emergency and fire pump engines shall not exceed the limits in Table 2.

**Table 2: Criteria Pollutant Emission Limits in pounds per day**

Pollutant	All Fuel Burning Equipment
NO <sub>x</sub> as NO <sub>2</sub>	116.0
CO	156.1
VOC as CH <sub>4</sub>	37.8
PM <sub>10</sub> /PM <sub>2.5</sub>	21.3
SO <sub>2</sub>	7.4

- C. Compliance demonstration with these plant-wide limits shall entail the monitoring, recordkeeping and reporting condition requirements specified later in this permit.
- D. Compliance with the NO<sub>x</sub> limit shall be demonstrated via the use of a plant-wide NO<sub>x</sub> Predictive Emission Monitoring System (PEMS), in accordance with Condition 18, that totals both power plants' boiler emission rates.

### 12. Boiler Fuel Use Limits

The total natural gas fuel consumption, expressed as heat input rates, shall not exceed 3,440 MMBtu/day or 746,400 MMBtu/year for combustion in the burners of all auxiliary and nighttime preservation boilers in the Solar 1 facility plus the adjacent Solar 2 facility (permitted separately, GBUAPCD No 1605-05-11).



# CONDITIONAL APPROVAL ATC 1604-00-11

## HIDDEN HILLS SOLAR 1 POWER PLANT

### 13. Toxic Hot Spots Program (AB 2588)

In lieu of an emissions inventory plan, the District accepts the screening health risk assessment provided in the application for certification to the California Energy Commission. The combined Solar 1 and Solar 2 facilities shall be categorized under AB 2588 as "Intermediate Level" and shall meet the reporting requirements under Section V of the Emission Inventory Criteria and Guidelines for the Air Toxics "Hot Spots" Program.

## **BOILER SPECIFICATIONS AND NSPS STANDARDS**

### 14. Boiler Specifications

One 249 MMBtu/hr auxiliary boiler (Unit B1A) and one 15 MMBtu/hr nighttime preservation boiler (Unit B2A) shall be equipped with low-NO<sub>x</sub> burners, 9 ppmvd NO<sub>x</sub> at 3% O<sub>2</sub> or less at loads exceeding 25% maximum continuous rating (MCR), and flue gas recirculation (FGR). The boilers shall meet all specifications stated in the permit application, including stack dimensions and pollutant emission rates.

### 15. New Source Performance Standards (NSPS) for Auxiliary Boiler

The auxiliary boiler shall comply with the requirements of 40 CFR 60 Subpart Db – NSPS for Industrial-Commercial-Institutional Steam Generating Units. The boiler shall meet the following emission standards at all times except during periods of startup, shutdown, or malfunction:

- NO<sub>x</sub>: 0.20 lb/MMBtu (30-day average) [40 CFR §60.44b(a)]
- SO<sub>2</sub>: 0.20 lb/MMBtu [40 CFR §60.42b(k)]

### 16. New Source Performance Standards (NSPS) for Nighttime Preservation Boiler

The nighttime preservation boiler shall comply with the requirements of 40 CFR 60 Subpart Dc – NSPS for Small Industrial-Commercial-Institutional Steam Generating Units. The SO<sub>2</sub> emission limit in this subpart does not apply because the unit is rated below 30 MMBtu/hr.

## **BOILER MONITORING CONDITIONS**

### 17. Fuel Type and Flow Monitoring

- A. The burners for the auxiliary and nighttime preservation boilers shall be fueled with natural gas that meets the standards of the California Public Utilities Commission (CPUC).
- B. Each boiler shall be equipped with a continuous flow monitoring system to measure and record fuel consumption in million standard cubic feet per hour (MMscf/hr).

### 18. Boiler Predictive NO<sub>x</sub> Emission Rate Monitoring Plan

- A. As an element of the PEMS required by Condition 11.D, the permittee shall estimate the boiler emissions by continuously monitoring parameters indicative of emissions and maintaining records of the amount of natural gas combusted. The permittee shall monitor the boiler operating conditions and predict NO<sub>x</sub> emission rates as specified in a plan that shall:

# **CONDITIONAL APPROVAL ATC 1604-00-11**

## **HIDDEN HILLS SOLAR 1 POWER PLANT**

- (1) Be submitted to the District within 360 days of initial startup in accordance with 40 CFR Subpart Db §60.49b(c) and §60.49b(g);
  - (2) Identify the specific operating conditions to be monitored and the relationship between these operating conditions and NO<sub>x</sub> emission rates (i.e., lb/MMBtu heat input). Steam generating unit operating conditions include, but are not limited to, the degree of staged combustion (i.e., the ratio of primary air to secondary and/or tertiary air) and the level of excess air (i.e., flue gas O<sub>2</sub> level);
  - (3) Include the data and information that the permittee used to identify the relationship between NO<sub>x</sub> emission rates and these operating conditions; and
  - (4) Identify how these operating conditions, including steam generating unit load, will be monitored on an hourly basis by the permittee during the period of operation of the affected facility; the quality assurance procedures or practices that will be employed to ensure that the data generated by monitoring these operating conditions will be representative and accurate; and the type and format of the records of these operating conditions, including steam generating unit load, that will be maintained by the permittee under 40 CFR §60.49b(g). [40 CFR Subpart Db §60.48b(d)]
- B. If the permittee elects to estimate NO<sub>x</sub> emissions from the Nighttime Preservation Boilers using the pound per hour emission limit in Table 1, then the Plan may require continuous monitoring of only operating hours and fuel use for the Nighttime Preservation Boilers.

### **BOILER TESTING CONDITIONS**

#### **19. Initial Boiler Testing**

Initial performance testing shall be completed on each auxiliary and nighttime preservation boiler to demonstrate compliance with the emission limits specified in Condition 10 at each boiler's maximum achievable production rate.

- A. The initial performance test is to be scheduled within 60 days after achieving the maximum continuous rating (MCR) at which the affected facility will be operated, but not later than 180 days after initial startup of the facility. [§60.45b and 60.46b]
- B. The permittee shall provide safe and accessible sampling ports that comply with California Industrial Safety Orders and Uniform Building Code and 40 CFR 60, Appendix A, Test Method 1.
- C. A test protocol must be submitted to the Air Pollution Control District not later than 30 days before the proposed test date. This test protocol shall be approved by the District before testing begins and shall include the following, or other District-approved methods:
  - (5) PM<sub>10</sub> emissions: EPA Method 5, Methods 201/202 or CARB Method 5
  - (6) NO<sub>x</sub> emissions: EPA Method 7, 7A, 7E
  - (7) SO<sub>2</sub> emissions: EPA Method 6, 6A, 6B or 6C
  - (8) CO emissions: EPA Method 10
  - (9) VOC emissions: EPA Method 25A
- D. A copy of the test results shall be submitted to the District within 60 days following test completion. [District Rule 200.C, and Cal H&S Code § 44340]

**CONDITIONAL APPROVAL ATC 1604-00-11**  
**HIDDEN HILLS SOLAR 1 POWER PLANT**

DRAFT

# CONDITIONAL APPROVAL ATC 1604-00-11

## HIDDEN HILLS SOLAR 1 POWER PLANT

### DIESEL BACKUP GENERATOR AND FIRE PUMP ENGINE CONDITIONS

#### **20. Emergency Backup Generator Engine**

The emergency backup generator (Unit EG1A) shall be powered by a Tier 2, diesel-fueled, Caterpillar 3516C SCAC, 3633 hp at 1,800 rpm, EPA Family ACPXL78.1T2E, CARB Executive Order U-R-001-0398-1, or an equivalent CARB-certified engine that meets the current EPA Tier standards for the given power range.

#### **21. Emergency Fire Pump Engine**

The emergency fire pump (Unit FP1A) shall be powered by a Tier 3, diesel-fueled, Cummins CFP7E-F30, 200 hp at 2,100 rpm, EPA Family ACEXL0409AAB, CARB Executive Order U-R-002-0516, or an equivalent CARB-certified engine that meets the current EPA Tier standards for the given power range.

#### **22. Airborne Toxics Control Measure**

The permittee shall operate the diesel emergency backup generator and fire pump engines in compliance with the California Code of Regulations, Title 17 (17 CCR) § 93115.

#### **23. Particulate Matter Limit**

Each emergency engine shall not discharge into the atmosphere particulate matter in excess of 0.3 grains per dry standard cubic foot of exhaust gas. [Rule 404-A].

#### **24. CARB Diesel Fuel**

Each engine shall be fueled with CARB diesel fuel with 15 parts-per-million sulfur content by weight or less, or an alternative diesel fuel that meets the requirements of the Standard of Motor Vehicle Fuel found in Title 13, CCR (13 CCR) § 2281. The amount of sulfur dioxide exhausted to the atmosphere shall not exceed 0.2% by volume. The permittee shall keep records of the composition of purchased fuel. [District Rules 210 and 416; 17 CCR § 93115.5(a)(1)]

#### **25. Hour Meter Required**

A non-resettable totalizer elapsed time meter shall be installed and maintained on each engine to indicate the cumulative hours of engine operation. [District Rule 210.A, 17 CCR § 93115].

#### **26. Non-Emergency Use Limitation**

- A. The emergency backup generator engine shall be allowed to operate up to 50 hours per year for maintenance and testing purposes. Operation of the engine beyond the 50 hours shall be allowed only by the events as defined in Condition 27 for what constitutes emergency use. [District Rule 210.A, 17 CCR § 93115.6(a)(3)(A)].
- B. The fire pump engine shall not operate more than the number of hours (up to 30 hours per year) necessary to comply with the testing requirements of the National Fire Protection Association (NFPA). [District Rule 210.A, 17 CCR § 93115.6(a)(4)(A)].

#### **27. What Constitutes Emergency Use**

Emergency use of the engines is not limited and is defined in 17 CCR § 93115 as providing electrical power or mechanical work during any of the following events and subject to the following conditions that:

**CONDITIONAL APPROVAL ATC 1604-00-11**  
**HIDDEN HILLS SOLAR 1 POWER PLANT**

- A. the failure or loss of all or part of normal electrical power service or normal natural gas supply to the facility:
  - (1) which is caused by any reason other than the enforcement of a contractual obligation the permittee has with a third party or any other party; and
  - (2) which is demonstrated by the permittee to the district APCO's satisfaction to have been beyond the reasonable control of the owner or operator;
- B. the failure of a facility's internal power distribution system:
  - (1) which is caused by any reason other than the enforcement of a contractual obligation the permittee has with a third party or any other party; and
  - (2) which is demonstrated by the permittee to the district APCO's satisfaction to have been beyond the reasonable control of the owner or operator.
- C. the pumping of water for fire suppression or protection;
- D. the pumping of water to maintain pressure in the water distribution system for the following reasons:
  - (1) a pipe break that substantially reduced water pressure; or
  - (2) high demand on the water supply system due to high use of water for fire suppression; or
  - (3) the breakdown of electric-powered pumping equipment at sewage treatment facilities or water delivery facilities.

[District Rule 210.A, 17 CCR § 93115].

**28. Required Records for Emergency Engines**

The permittee shall keep a monthly log of usage that shall list and document the nature of use for each of the following:

- A. emergency use hours of operation;
- B. maintenance and testing hours of operation;
- C. hours of operation for emission testing to show compliance with the applicable standard;
- D. initial start-up testing hours;
- E. hours of operation for all uses other than those specified above; and
- F. the fuel used.
  - (1) For engines operated exclusively on CARB Diesel Fuel, the owner or operator shall document the use of CARB Diesel Fuel through the retention of fuel purchase records indicating that the only fuel purchased for supply to an emergency standby engine was CARB Diesel Fuel; or
  - (2) For engines operated on any fuel other than CARB Diesel Fuel, fuel records demonstrating that the only fuel purchased and added to an emergency standby engine or engines, or to any fuel tank directly attached to an emergency standby engine or engines, meets the requirements of section 93115.5(b).

[District Rule 210.A, 17 CCR § 93115.10(g)(1)].

# CONDITIONAL APPROVAL ATC 1604-00-11

## HIDDEN HILLS SOLAR 1 POWER PLANT

### 29. Record Retention

Log entries shall be retained for a minimum of 36 months from the date of entry. Log entries made within 24 months of the most recent entry shall be retained on-site, either at a central location or at the engine's location, and made immediately available to the District staff upon request. Log entries made from 25 to 36 months from most recent entry shall be made available to District staff within 5 working days from request. [Rule 210.A, 17 CCR § 93115.10(g)(2)].

## PARTICULATE MATTER MITIGATION CONDITIONS

### 30. Construction-Related Particulate Matter Mitigation

The permittee shall take reasonable precautions during construction activities to prevent visible particulate matter from being airborne, under normal wind conditions, beyond the HHSEGS property line, in accordance with the requirements for dust control in Rule 401.A. The District deems the California Energy Commission (CEC) staff conditions of certification (HHSEGS) AQ-SC1 through AQ-SC5 for construction and operation mitigation methods to be reasonable precautions under Rule 401. The permittee shall submit the Air Quality Construction Mitigation Plan, required by AQ-SC2 to the District after its approval by the CEC. The permittee shall make available to the District, upon request, copies of the CEC-required Monthly Compliance Report containing documentation of the actions taken to comply with these conditions.

## FACILITY RECORDKEEPING & REPORTING CONDITIONS

### 31. Natural Gas Heat Input Records

Records for plant-wide natural gas combustion heat input, required by Condition 12, shall be presented in MMBtu/day, MMBtu/month and MMBtu per rolling 12-month period.

### 32. Plant-wide Emission Records

Emission records for the plant-wide NO<sub>x</sub> PEMS, required by Condition 11, shall be presented in pounds per hour (lb/hr), pounds per day (lb/day) and pounds per million Btu (lb/MMBtu) for each individual boiler in the Solar 1 and Solar 2 facilities. The sum total of NO<sub>x</sub> for all boilers shall be presented in pounds per day (lb/day) for each calendar day, midnight to midnight. Data obtained to estimate boiler NO<sub>x</sub> emissions shall be presented as specified in the plant-wide NO<sub>x</sub> PEMS plan required by Condition 18.

### 33. Monitoring Record Retention

Required recordkeeping information shall be retained by the permittee in a form suitable for inspection for a period of at least two (2) years from the end of the calendar year of the journal entry. [Rule 206.B, Cal H&S Code § 42705]

### 34. Reporting of Monitoring Records

All monitoring records shall be made immediately available to the District staff upon request.



**GREAT BASIN UNIFIED AIR POLLUTION CONTROL DISTRICT**  
157 Short Street, Bishop, California 93514-3537 www.gbuapcd.org  
Tel: 760-872-8211 Fax: 760-872-6109 info@gbuapcd.org

**AUTHORITY TO CONSTRUCT 1605-00-11**  
**HIDDEN HILLS SOLAR 2 POWER PLANT**

**GRANTED TO:**

Hidden Hills Solar II, LLC, a wholly owned subsidiary of  
Hidden Hills Solar Holdings, LLC, a wholly owned  
subsidiary of BrightSource Energy, Inc.  
1999 Harrison Street  
Oakland, CA 94612

**EQUIPMENT ADDRESS:**

1,510-acre area, just north of Charleston  
View (Calvada Springs) and Tecopa Road  
(Old Spanish Trail Highway)  
Inyo County, CA, bounded on the NE by the  
CA-NV border

**THIS AUTHORITY TO CONSTRUCT (ATC) IS NOT A PERMIT TO OPERATE AND WILL  
EXPIRE FIVE YEARS FROM THE DATE GRANTED!**

**REGULATED EQUIPMENT: 250 Megawatt Solar Power Plant with the following equipment:**

ID No	Function	Make & Model	Serial Number	Fuel Type	Fuel Use
B1B	Auxiliary Boiler	TBD	TBD	Natural Gas	249 MMBtu/hr
B2B	Nighttime Preservation Boiler	TBD	TBD	Natural Gas	15 MMBtu/hr
EG1B	Backup Generator	Tier 2, Caterpillar 3516C, 3633 hp (or equivalent)	TBD	CARB Diesel	24 MMBtu/hr
FP1B	Fire Pump Engine	Tier 3, Cummins CFP7E-F30, 200 hp (or equivalent)	TBD	CARB Diesel	2 MMBtu/hr
<b>Total</b>					<b>290 MMBtu/hr</b>

**ANCILLARY EQUIPMENT:** A heliostat array with about 90,000 heliostats, a power block containing a Rankine-cycle non-reheat steam turbine, a solar receiver steam generator atop a 750-foot tower, feed water heaters, a deaerator, an air-cooled condenser, wet surface air cooler (with high efficiency drift eliminator), oil-water separator and diesel fuel aboveground storage tanks.

**EMISSIONS CONTROL:** Low NOx (9 PPM) boiler burners with flue gas recirculation, annual and daily NOx emission limits, hours of operation limits, and a plantwide NOx emission monitoring system.

**CONDITIONS:** This ATC is subject to the attached approval conditions.

**COMMENCEMENT OF CONSTRUCTION:** The permittee shall not begin actual on-site construction of the equipment authorized by this Authority to Construct until the lead agency satisfies the requirements of the California Environmental Quality Act (CEQA).

**A PERMIT TO OPERATE** the above equipment shall be issued only after an inspection to determine if the equipment has been constructed according to the approved plans and specifications and the equipment can be operated in compliance with all Rules and Regulations of the Great Basin Unified Air Pollution Control District. Notify the District at (760) 872-8211 when construction is complete and the equipment is ready for operation.

\_\_\_\_\_  
Duane Ono  
Deputy Air Pollution Control Officer

\_\_\_\_\_  
Date Granted

# CONDITIONAL APPROVAL ATC 1605-00-11

## HIDDEN HILLS SOLAR 2 POWER PLANT

### GENERAL CONDITIONS

#### **1. Facility Startup**

The permittee shall notify the District in writing when construction is complete and the equipment is ready for commissioning operations. Operation of this equipment shall be conducted in accordance with all data and specifications submitted with the application under which this ATC is issued unless otherwise noted. Notification shall be given to the District office by email, Postal Service delivery or telephone facsimile transmission at least 72 hours prior to equipment start-up. Operation of this equipment without a written Permit to Operate is a violation of District Rule 200 B, and can result in civil and criminal penalties under California Health & Safety Code (H&SC) § 42400.

#### **2. Commissioning Period under Temporary Permit to Operate:**

Following a District inspection verifying that the facility is constructed in a manner consistent with the specifications in the application and with this Authority to Construct, a temporary Permit to Operate (TPO) shall be issued. The TPO shall be valid for the duration of the commissioning period defined below and until a Permit to Operate is issued or denied.

- A. Commissioning activities are defined as, but not limited to, all testing, adjustment, tuning, and calibration activities recommended by the equipment manufacturers and the construction contractor to ensure safe and reliable steady state operation of the boilers and associated control systems.
- B. The commissioning period shall commence when all mechanical, electrical, and control systems are installed and individual system startup has been completed, or when a boiler is first fired, whichever occurs first. The commissioning period shall terminate when the plant has completed initial source testing, completed final plant tuning, and is available for commercial operation.
- C. During the commissioning period, the owner or operator shall keep records of the natural gas fuel combusted in the boilers on hourly and daily basis. The natural gas fuel combusted during the commissioning period shall accrue towards the annual fuel use limit.

#### **3. Right-of-Entry**

The "Right of Entry", as defined by California H&SC § 41510 of Division 26, shall apply at all times with respect to the equipment and the Control System. Representatives of the Great Basin Unified Air Pollution Control District shall be permitted to enter the facility to inspect and copy any record required to be kept under the terms of this permit. District staff shall also be permitted to inspect any equipment, work practices, air emission-related activity or method dictated by this permit. If deemed necessary by the District to verify compliance with these conditions, the permittee shall within 7 days notice be available to open any sample extraction port, or exhaust outlet for the purpose of conducting source tests or to collect samples. In enforcing the terms of this permit, any cost incurred in collecting samples, source testing and laboratory analysis fees shall be the responsibility of the applicant. [District Rules 210 and 302 Analysis Fee]



# CONDITIONAL APPROVAL ATC 1605-00-11

## HIDDEN HILLS SOLAR 2 POWER PLANT

### 4. Copy of Permit Onsite

A copy of the permit shall be maintained readily available at all times on the operating premises. [District Rule 200.D]

### 5. Report Violation of Emission Standard

Any violation of any emission standard to which the stationary source is required to comply, as indicated by the records of the monitoring device, shall be reported by the operator of the source to the district within 96 hours after such occurrence. The district shall, in turn, report the violation to the state board within five working days after receiving the report of the violation from the operator. [Cal H&S § 42706]

### 6. Severability Clause

If any provision of this permit is found invalid, such finding shall not affect any remaining provisions. [District Rule 107]

### 7. Right to Revise Permit

The provisions of this permit may be modified by the District if it determines the stipulated conditions are inadequate. [District Rule 210.C]

### 8. Breakdown (or Emergency) Reporting Conditions

A breakdown condition means an unforeseeable failure or malfunction of: 1) any air pollution control equipment or related operating equipment which causes a violation of any emission limitation or restriction prescribed by this permit or District rules and regulations, or by State law, or 2) any in-stack continuous monitoring equipment.

- A. The permittee shall comply with the breakdown requirements of District Rule 403 (Breakdown), which shall include notifying the Air Pollution Control Officer of a breakdown condition within an hour of detection, unless it can be demonstrated that a longer reporting period is necessary -- not to exceed two (2) days.
- B. Notification shall identify the time, location, equipment involved, and to the extent possible the cause of the breakdown and steps taken to correct the breakdown condition.
- C. Within one (1) week after the breakdown occurrence, the permittee shall submit a written report to the Air Pollution Control Officer which includes: date of correction of the breakdown, determination of the cause of the breakdown, corrective measures to prevent a recurrence, an estimate of the emissions caused by the breakdown condition, and pictures of the failed equipment, if available.
- D. Breakdown conditions shall not persist longer than 24 hours or the end of the production run, whichever is sooner, except for continuous monitoring equipment, for which the period shall be ninety-six (96) hours, unless the permittee obtains an Emergency Variance pursuant to District Rule 617. [District Rule 403]

## FACILITY OPERATING CONDITIONS

### 9. Visible Emissions Opacity Limit

Visible emissions from any source shall not exceed a Ringelmann 1 (20% opacity) for a period or periods aggregating more than three minutes in any one hour. [District Rule 400]

# CONDITIONAL APPROVAL ATC 1605-00-11

## HIDDEN HILLS SOLAR 2 POWER PLANT

### 10. Unit Emission Limits

To demonstrate consistency with the ambient air quality modeling and the screening health risk assessment provided in the application for certification to the California Energy Commission, the pound per hour equipment emission rate limits in Table 1 shall apply. Except during the commissioning period, startup/shutdown conditions and standby conditions, the pound per million Btu limits shall also apply. Compliance with these lb/MMBtu limits will also ensure compliance with the limits in the applicable New Source Performance Standards (NSPS).

**Table 1: Criteria Pollutant Emission Limits in pounds per hour (pounds per million Btu)**

Pollutant	Auxiliary Boiler	Nighttime Preservation Boiler	Emergency Backup Engine	Emergency Fire Pump Engine
NOx as NO <sub>2</sub>	2.74 (0.0110)	0.17 (0.0110)	38.4	1.3
CO	4.55 (0.0183)	0.55 (0.0366)	20.8	1.15
VOC as CH <sub>4</sub>	1.34 (0.0054)	0.08 (0.0053)	1.3	0.08
PM <sub>10</sub> /PM <sub>2.5</sub>	1.25 (N/A)	0.08 (N/A)	1.2	0.07
SO <sub>2</sub>	0.52 (0.0021)	0.03 (0.0021)	0.04	0.003

### 11. Combined Plant-wide Daily Emission Limits

- A. "Plant-wide" shall mean this Solar 2 power plant facility, GBUAPCD No 1605-00-11, plus the adjacent Solar 1 power plant and common area facilities (permitted separately, GBUAPCD No 1604-00-11 and 1606-00-11, respectively).
- B. The total plant-wide combined emissions from the auxiliary and nighttime preservation boilers, emergency and fire pump engines shall not exceed the limits in Table 2.

**Table 2: Criteria Pollutant Emission Limits in pounds per day**

Pollutant	All Fuel Burning Equipment
NOx as NO <sub>2</sub>	116.0
CO	156.1
VOC as CH <sub>4</sub>	37.8
PM <sub>10</sub> /PM <sub>2.5</sub>	21.3
SO <sub>2</sub>	7.4

- C. Compliance demonstration with these plant-wide limits shall entail the monitoring, recordkeeping and reporting condition requirements specified later in this permit.
- D. Compliance with the NOx limit shall be demonstrated via the use of a plant-wide NOx Predictive Emission Monitoring System (PEMS), in accordance with Condition 18, that totals both power plants' boiler emission rates.

### 12. Boiler Fuel Use Limits

The total natural gas fuel consumption, expressed as heat input rates, shall not exceed 3,440 MMBtu/day or 746,400 MMBtu/year for combustion in the burners of all auxiliary and nighttime preservation boilers in the Solar 2 facility plus the adjacent Solar 1 facility (permitted separately, GBUAPCD No 1604-05-11).

# CONDITIONAL APPROVAL ATC 1605-00-11

## HIDDEN HILLS SOLAR 2 POWER PLANT

### 13. Toxic Hot Spots Program (AB 2588)

In lieu of an emissions inventory plan, the District accepts the screening health risk assessment provided in the application for certification to the California Energy Commission. The combined Solar 1 and Solar 2 facilities shall be categorized under AB 2588 as "Intermediate Level" and shall meet the reporting requirements under Section V of the Emission Inventory Criteria and Guidelines for the Air Toxics "Hot Spots" Program.

## **BOILER SPECIFICATIONS AND NSPS STANDARDS**

### 14. Boiler Specifications

One 249 MMBtu/hr auxiliary boiler (Unit B1B) and one 15 MMBtu/hr nighttime preservation boiler (Unit B2B) shall be equipped with low-NO<sub>x</sub> burners, 9 ppmvd NO<sub>x</sub> at 3% O<sub>2</sub> or less at loads exceeding 25% maximum continuous rating (MCR), and flue gas recirculation (FGR). The boilers shall meet all specifications stated in the permit application, including stack dimensions and pollutant emission rates.

### 15. New Source Performance Standards (NSPS) for Auxiliary Boiler

The auxiliary boiler shall comply with the requirements of 40 CFR 60 Subpart Db – NSPS for Industrial-Commercial-Institutional Steam Generating Units. The boiler shall meet the following emission standards at all times except during periods of startup, shutdown, or malfunction:

- NO<sub>x</sub>: 0.20 lb/MMBtu (30-day average) [40 CFR §60.44b(a)]
- SO<sub>2</sub>: 0.20 lb/MMBtu [40 CFR §60.42b(k)]

### 16. New Source Performance Standards (NSPS) for Nighttime Preservation Boiler

The nighttime preservation boiler shall comply with the requirements of 40 CFR 60 Subpart Dc – NSPS for Small Industrial-Commercial-Institutional Steam Generating Units. The SO<sub>2</sub> emission limit in this subpart does not apply because the unit is rated below 30 MMBtu/hr.

## **BOILER MONITORING CONDITIONS**

### 17. Fuel Type and Flow Monitoring

- A. The burners for the auxiliary and nighttime preservation boilers shall be fueled with natural gas that meets the standards of the California Public Utilities Commission (CPUC).
- B. Each boiler shall be equipped with a continuous flow monitoring system to measure and record fuel consumption in million standard cubic feet per hour (MMscf/hr).

### 18. Auxiliary Boiler Predictive NO<sub>x</sub> Emission Rate Monitoring Plan

As an element of the PEMS required by Condition 11.D, the permittee shall estimate the auxiliary boiler emissions by continuously monitoring parameters indicative of emissions and maintaining records of the amount of natural gas combusted. The permittee shall monitor the auxiliary boiler operating conditions and predict NO<sub>x</sub> emission rates as specified in a plan that shall:

## **CONDITIONAL APPROVAL ATC 1605-00-11**

### **HIDDEN HILLS SOLAR 2 POWER PLANT**

- A. Be submitted to the District within 360 days of initial startup in accordance with 40 CFR Subpart Db §60.49b(c) and §60.49b(g);
- B. Identify the specific operating conditions to be monitored and the relationship between these operating conditions and NO<sub>x</sub> emission rates (i.e., lb/MMBtu heat input). Steam generating unit operating conditions include, but are not limited to, the degree of staged combustion (i.e., the ratio of primary air to secondary and/or tertiary air) and the level of excess air (i.e., flue gas O<sub>2</sub> level);
- C. Include the data and information that the permittee used to identify the relationship between NO<sub>x</sub> emission rates and these operating conditions; and
- D. Identify how these operating conditions, including steam generating unit load, will be monitored on an hourly basis by the permittee during the period of operation of the affected facility; the quality assurance procedures or practices that will be employed to ensure that the data generated by monitoring these operating conditions will be representative and accurate; and the type and format of the records of these operating conditions, including steam generating unit load, that will be maintained by the permittee under 40 CFR §60.49b(g). [40 CFR Subpart Db §60.48b(d)]

#### **BOILER TESTING CONDITIONS**

##### **19. Initial Boiler Testing**

Initial performance testing shall be completed on each auxiliary and nighttime preservation boiler to demonstrate compliance with the emission limits specified in Condition 10 at each boiler's maximum achievable production rate.

- A. The initial performance test is to be scheduled within 60 days after achieving the maximum continuous rating (MCR) at which the affected facility will be operated, but not later than 180 days after initial startup of the facility. [§60.48Da(f)]
- B. The permittee shall provide safe and accessible sampling ports that comply with California Industrial Safety Orders and Uniform Building Code and 40 CFR 60, Appendix A, Test Method 1.
- C. A test protocol must be submitted to the Air Pollution Control District not later than 30 days before the proposed test date. This test protocol shall be approved by the District before testing begins and shall include the following, or other District-approved methods:
  - (1) PM<sub>10</sub> emissions: EPA Method 5, Methods 201/202 or CARB Method 5
  - (2) NO<sub>x</sub> emissions: EPA Method 7, 7A, 7E
  - (3) SO<sub>2</sub> emissions: EPA Method 6, 6A, 6B or 6C
  - (4) CO emissions: EPA Method 10
  - (5) VOC emissions: EPA Method 25A
- D. A copy of the test results shall be submitted to the District within 60 days following test completion. [District Rule 200.C, and Cal H&S Code § 44340]

# CONDITIONAL APPROVAL ATC 1605-00-11

## HIDDEN HILLS SOLAR 2 POWER PLANT

### DIESEL BACKUP GENERATOR AND FIRE PUMP ENGINE CONDITIONS

#### **20. Emergency Backup Generator Engine**

The emergency backup generator (Unit EG1B) shall be powered by a Tier 2, diesel-fueled, Caterpillar 3516C SCAC, 3633 hp at 1,800 rpm, EPA Family ACPXL78.1T2E, CARB Executive Order U-R-001-0398-1, or an equivalent CARB-certified engine that meets the current EPA Tier standards for the given power range.

#### **21. Emergency Fire Pump Engine**

The emergency fire pump (Unit FP1B) shall be powered by a Tier 3, diesel-fueled, Cummins CFP7E-F30, 200 hp at 2,100 rpm, EPA Family ACEXL0409AAB, CARB Executive Order U-R-002-0516, or an equivalent CARB-certified engine that meets the current EPA Tier standards for the given power range.

#### **22. Airborne Toxics Control Measure**

The permittee shall operate the diesel emergency backup generator and fire pump engines in compliance with the California Code of Regulations, Title 17 (17 CCR) § 93115.

#### **23. Particulate Matter Limit**

Each emergency engine shall not discharge into the atmosphere particulate matter in excess of 0.3 grains per dry standard cubic foot of exhaust gas. [Rule 404-A].

#### **24. CARB Diesel Fuel**

Each engine shall be fueled with CARB diesel fuel with 15 parts-per-million sulfur content by weight or less, or an alternative diesel fuel that meets the requirements of the Standard of Motor Vehicle Fuel found in Title 13, CCR (13 CCR) § 2281. The amount of sulfur dioxide exhausted to the atmosphere shall not exceed 0.2% by volume. The permittee shall keep records of the composition of purchased fuel. [District Rules 210 and 416; 17 CCR § 93115.5(a)(1)]

#### **25. Hour Meter Required**

A non-resettable totalizer elapsed time meter shall be installed and maintained on each engine to indicate the cumulative hours of engine operation. [District Rule 210.A, 17 CCR § 93115].

#### **26. Non-Emergency Use Limitation**

- A. The emergency backup generator engine shall be allowed to operate up to 50 hours per year for maintenance and testing purposes. Operation of the engine beyond the 50 hours shall be allowed only by the events as defined in Condition 27 for what constitutes emergency use. [District Rule 210.A, 17 CCR § 93115.6(a)(3)(A)].
- B. The fire pump engine shall not operate more than the number of hours (up to 30 hours per year) necessary to comply with the testing requirements of the National Fire Protection Association (NFPA). [District Rule 210.A, 17 CCR § 93115.6(a)(4)(A)].

#### **27. What Constitutes Emergency Use**

Emergency use of the engines is not limited and is defined in 17 CCR § 93115 as providing electrical power or mechanical work during any of the following events and subject to the following conditions that:

**CONDITIONAL APPROVAL ATC 1605-00-11**  
**HIDDEN HILLS SOLAR 2 POWER PLANT**

- A. the failure or loss of all or part of normal electrical power service or normal natural gas supply to the facility:
  - (1) which is caused by any reason other than the enforcement of a contractual obligation the permittee has with a third party or any other party; and
  - (2) which is demonstrated by the permittee to the district APCO's satisfaction to have been beyond the reasonable control of the owner or operator;
- B. the failure of a facility's internal power distribution system:
  - (1) which is caused by any reason other than the enforcement of a contractual obligation the permittee has with a third party or any other party; and
  - (2) which is demonstrated by the permittee to the district APCO's satisfaction to have been beyond the reasonable control of the owner or operator.
- C. the pumping of water for fire suppression or protection;
- D. the pumping of water to maintain pressure in the water distribution system for the following reasons:
  - (1) a pipe break that substantially reduced water pressure; or
  - (2) high demand on the water supply system due to high use of water for fire suppression; or
  - (3) the breakdown of electric-powered pumping equipment at sewage treatment facilities or water delivery facilities.

[District Rule 210.A, 17 CCR § 93115].

**28. Required Records for Emergency Engines**

The permittee shall keep a monthly log of usage that shall list and document the nature of use for each of the following:

- A. emergency use hours of operation;
- B. maintenance and testing hours of operation;
- C. hours of operation for emission testing to show compliance with the applicable standard;
- D. initial start-up testing hours;
- E. hours of operation for all uses other than those specified above; and
- F. the fuel used.
  - (1) For engines operated exclusively on CARB Diesel Fuel, the owner or operator shall document the use of CARB Diesel Fuel through the retention of fuel purchase records indicating that the only fuel purchased for supply to an emergency standby engine was CARB Diesel Fuel; or
  - (2) For engines operated on any fuel other than CARB Diesel Fuel, fuel records demonstrating that the only fuel purchased and added to an emergency standby engine or engines, or to any fuel tank directly attached to an emergency standby engine or engines, meets the requirements of section 93115.5(b).

[District Rule 210.A, 17 CCR § 93115.10(g)(1)].

# CONDITIONAL APPROVAL ATC 1605-00-11

## HIDDEN HILLS SOLAR 2 POWER PLANT

### **29. Record Retention**

Log entries shall be retained for a minimum of 36 months from the date of entry. Log entries made within 24 months of the most recent entry shall be retained on-site, either at a central location or at the engine's location, and made immediately available to the District staff upon request. Log entries made from 25 to 36 months from most recent entry shall be made available to District staff within 5 working days from request. [Rule 210.A, 17 CCR § 93115.10(g)(2)].

## **PARTICULATE MATTER MITIGATION CONDITIONS**

### **30. Construction-Related Particulate Matter Mitigation**

The permittee shall take reasonable precautions during construction activities to prevent visible particulate matter from being airborne, under normal wind conditions, beyond the HHSEGS property line, in accordance with the requirements for dust control in Rule 401.A. The District deems the California Energy Commission (CEC) staff conditions of certification (HHSEGS) AQ-SC1 through AQ-SC5 for construction and operation mitigation methods to be reasonable precautions under Rule 401. The permittee shall submit the Air Quality Construction Mitigation Plan, required by AQ-SC2 to the District after its approval by the CEC. The permittee shall make available to the District, upon request, copies of the CEC-required Monthly Compliance Report containing documentation of the actions taken to comply with these conditions.

## **FACILITY RECORDKEEPING & REPORTING CONDITIONS**

### **31. Natural Gas Heat Input Records**

Records for plant-wide natural gas combustion heat input, required by Condition 12, shall be presented in MMBtu/day, MMBtu/month and MMBtu per rolling 12-month period.

### **32. Plant-wide Emission Records**

Emission records for the plant-wide NO<sub>x</sub> PEMS, required by Condition 11, shall be presented in pounds per hour (lb/hr), pounds per day (lb/day) and pounds per million Btu (lb/MMBtu) for each individual boiler in the Solar 1 and Solar 2 facilities. The sum total of NO<sub>x</sub> for all boilers shall be presented in pounds per day (lb/day) for each calendar day, midnight to midnight. Data obtained to estimate boiler NO<sub>x</sub> emissions shall be presented as specified in the plant-wide NO<sub>x</sub> PEMS plan required by Condition 18.

### **33. Monitoring Record Retention**

Required recordkeeping information shall be retained by the permittee in a form suitable for inspection for a period of at least two (2) years from the end of the calendar year of the journal entry. [Rule 206.B, Cal H&S Code § 42705]

### **34. Reporting of Monitoring Records**

All monitoring records shall be made immediately available to the District staff upon request.



## GREAT BASIN UNIFIED AIR POLLUTION CONTROL DISTRICT

157 Short Street, Bishop, California 93514-3537 www.gbuapcd.org  
Tel: 760-872-8211 Fax: 760-872-6109 info@gbuapcd.org

### **AUTHORITY TO CONSTRUCT 1606-00-11 HIDDEN HILLS COMMON AREA**

**GRANTED TO:**

Hidden Hills Solar I, LLC and Hidden Hills Solar II, LLC,  
wholly owned subsidiaries of Hidden Hills Solar Holdings, LLC,  
wholly owned subsidiary of BrightSource Energy, Inc.  
1999 Harrison Street  
Oakland, CA 94612

**EQUIPMENT ADDRESS:**

103-acre area, just north of Charleston  
View (Calvada Springs) and Tecopa  
Road (Old Spanish Trail Highway)  
Inyo County, CA, bounded on the NE  
by the CA-NV border

**THIS AUTHORITY TO CONSTRUCT (ATC) IS NOT A PERMIT TO OPERATE AND WILL  
EXPIRE FIVE YEARS FROM THE DATE GRANTED!**

**REGULATED EQUIPMENT:**

ID No	Function	Make & Model	Serial Number	Fuel Type	Fuel Use
EG1C	Backup Generator	Tier 3, Caterpillar C9 ATAAC, 398 hp (or equivalent)	TBD	CARB Diesel	2.7 MMBtu/hr
FP1C	Fire Pump Engine	Tier 3, Cummins CFP7E-F30, 200 hp (or equivalent)	TBD	CARB Diesel	1.6 MMBtu/hr
<b>Total</b>					<b>4.3 MMBtu/hr</b>

**ANCILLARY EQUIPMENT:** An administration, warehouse, and maintenance complex, and an onsite switchyard for the Hidden Hills Solar I, LLC and Solar II, LLC power plants (permitted separately, GBUAPCD No 1604-00-11 and 1605-00-11, respectively).

**EMISSIONS CONTROL:** The two diesel-fueled engines are Tier 3 and are compliant with the California Air Resources Board ATCM for Stationary Compression Ignition Engines, CCR § 93115. The two engines' non-emergency hours of operation shall be limited.

**CONDITIONS:** This ATC is subject to the attached approval conditions.

**COMMENCEMENT OF CONSTRUCTION:** The permittee shall not begin actual on-site construction of the equipment authorized by this Authority to Construct until the lead agency satisfies the requirements of the California Environmental Quality Act (CEQA).

**A PERMIT TO OPERATE** the above equipment shall be issued only after an inspection to determine if the equipment has been constructed according to the approved plans and specifications and the equipment can be operated in compliance with all Rules and Regulations of the Great Basin Unified Air Pollution Control District. Notify the District at (760) 872-8211 when construction is complete and the equipment is ready for operation.

\_\_\_\_\_  
Duane Ono  
Deputy Air Pollution Control Officer

\_\_\_\_\_  
Date Granted



# CONDITIONAL APPROVAL ATC 1606-00-11

## HIDDEN HILLS COMMON AREA

### GENERAL CONDITIONS

#### 1) **Facility Startup**

The permittee shall notify the District in writing when construction is complete and the equipment is ready for commissioning operations. Operation of this equipment shall be conducted in accordance with all data and specifications submitted with the application under which this ATC is issued unless otherwise noted. Notification shall be given to the District office by email, Postal Service delivery or telephone facsimile transmission at least 72 hours prior to equipment start-up. Operation of this equipment without a written Permit to Operate is a violation of District Rule 200 B, and can result in civil and criminal penalties under California Health & Safety Code (H&SC) § 42400.

#### 2) **Right-of-Entry**

The "Right of Entry", as defined by California H&SC § 41510 of Division 26, shall apply at all times with respect to the equipment and the Control System. Representatives of the Great Basin Unified Air Pollution Control District shall be permitted to enter the facility to inspect and copy any record required to be kept under the terms of this permit. District staff shall also be permitted to inspect any equipment, work practices, air emission-related activity or method dictated by this permit. If deemed necessary by the District to verify compliance with these conditions, the permittee shall within 7 days notice be available to open any sample extraction port, or exhaust outlet for the purpose of conducting source tests or to collect samples. In enforcing the terms of this permit, any cost incurred in collecting samples, source testing and laboratory analysis fees shall be the responsibility of the applicant. [District Rules 210 and 302 Analysis Fee]

#### 3) **Copy of Permit Onsite**

A copy of the permit shall be maintained readily available at all times on the operating premises. [District Rule 200.D]

#### 4) **Report Violation of Emission Standard**

Any violation of any emission standard to which the stationary source is required to comply, as indicated by the records of the monitoring device, shall be reported by the operator of the source to the district within 96 hours after such occurrence. The district shall, in turn, report the violation to the state board within five working days after receiving the report of the violation from the operator. [Cal H&S § 42706]

#### 5) **Severability Clause**

If any provision of this permit is found invalid, such finding shall not affect any remaining provisions. [District Rule 107]

#### 6) **Right to Revise Permit**

The provisions of this permit may be modified by the District if it determines the stipulated conditions are inadequate. [District Rule 210.C]

#### 7) **Breakdown (or Emergency) Reporting Conditions**

A breakdown condition means an unforeseeable failure or malfunction of: 1) any air pollution

# CONDITIONAL APPROVAL ATC 1606-00-11

## HIDDEN HILLS COMMON AREA

control equipment or related operating equipment which causes a violation of any emission limitation or restriction prescribed by this permit or District rules and regulations, or by State law, or 2) any in-stack continuous monitoring equipment.

- A. The permittee shall comply with the breakdown requirements of District Rule 403 (Breakdown), which shall include notifying the Air Pollution Control Officer of a breakdown condition within an hour of detection, unless it can be demonstrated that a longer reporting period is necessary -- not to exceed two (2) days.
- B. Notification shall identify the time, location, equipment involved, and to the extent possible the cause of the breakdown and steps taken to correct the breakdown condition.
- C. Within one (1) week after the breakdown occurrence, the permittee shall submit a written report to the Air Pollution Control Officer which includes: date of correction of the breakdown, determination of the cause of the breakdown, corrective measures to prevent a recurrence, an estimate of the emissions caused by the breakdown condition, and pictures of the failed equipment, if available.
- D. Breakdown conditions shall not persist longer than 24 hours or the end of the production run, whichever is sooner, except for continuous monitoring equipment, for which the period shall be ninety-six (96) hours, unless the permittee obtains an Emergency Variance pursuant to District Rule 617. [District Rule 403]

### **FACILITY OPERATING CONDITIONS**

#### **8) Unit Emission Limits**

To demonstrate consistency with the ambient air quality modeling and the screening health risk assessment provided in the application for certification to the California Energy Commission, the pound per hour equipment emission rate limits in Table 1 shall apply.

**Table 1: Common Area Emission Limits in pounds per hour**

<b>Pollutant</b>	<b>Emergency Backup Engines</b>	<b>Emergency Fire Pump Engines</b>
NOx as NO <sub>2</sub>	2.6	1.3
CO	2.28	1.15
VOC as CH <sub>4</sub>	0.15	0.08
PM <sub>10</sub> /PM <sub>2.5</sub>	0.13	0.07
SO <sub>2</sub>	0.004	0.003

### **DIESEL BACKUP GENERATOR AND FIRE PUMP ENGINE CONDITIONS**

#### **9) Visible Emissions Opacity Limit**

Visible emissions from each engine shall not exceed a Ringelmann 1 (20% opacity) for a period or periods aggregating more than three minutes in any one hour. [District Rule 400]

#### **10) Emergency Backup Generator Engine**

The emergency backup generator (Unit EG1C) shall be powered by a Tier 3, diesel-fueled, Caterpillar C9 ATAAC, 398 hp at 1,800 rpm, EPA Family ACPXL08.8ESX, CARB Executive

# **CONDITIONAL APPROVAL ATC 1606-00-11**

## **HIDDEN HILLS COMMON AREA**

Order U-R-001-0373, or an equivalent CARB-certified engine that meets the current EPA Tier standards for the given power range.

### **11) Emergency Fire Pump Engine**

The emergency fire pump (Unit FP1C) shall be powered by a Tier 3, diesel-fueled, Cummins CFP7E-F30, 200 hp at 2,100 rpm, EPA Family ACEXL0409AAB, CARB Executive Order U-R-002-0516, or an equivalent CARB-certified engine that meets the current EPA Tier standards for the given power range.

### **12) Airborne Toxics Control Measure**

The permittee shall operate the diesel emergency backup generator and fire pump engines in compliance with the California Code of Regulations, Title 17 (17 CCR) § 93115.

### **13) Particulate Matter Limit**

Each emergency engine shall not discharge into the atmosphere particulate matter in excess of 0.3 grains per dry standard cubic foot of exhaust gas. [Rule 404-A].

### **14) CARB Diesel Fuel**

Each engine shall be fueled with CARB diesel fuel with 15 parts-per-million sulfur content by weight or less, or an alternative diesel fuel that meets the requirements of the Standard of Motor Vehicle Fuel found in Title 13, CCR (13 CCR) § 2281. The amount of sulfur dioxide exhausted to the atmosphere shall not exceed 0.2% by volume. The permittee shall keep records of the composition of purchased fuel. [District Rules 210 and 416; 17 CCR § 93115.5(a)(1)]

### **15) Hour Meter Required**

A non-resettable totalizer elapsed time meter shall be installed and maintained on each engine to indicate the cumulative hours of engine operation. [District Rule 210.A, 17 CCR § 93115].

### **16) Non-Emergency Use Limitation**

- A. The emergency backup generator engine shall be allowed to operate up to 50 hours per year for maintenance and testing purposes. Operation of the engine beyond the 50 hours shall be allowed only by the events as defined in Condition 16 for what constitutes emergency use. [District Rule 210.A, 17 CCR § 93115.6(a)(3)(A)].
- B. The fire pump engine shall not operate more than the number of hours (up to 30 hours per year) necessary to comply with the testing requirements of the National Fire Protection Association (NFPA). [District Rule 210.A, 17 CCR § 93115.6(a)(4)(A)].

### **17) What Constitutes Emergency Use**

Emergency use of the engines is not limited and is defined in 17 CCR § 93115 as providing electrical power or mechanical work during any of the following events and subject to the following conditions that:

- A. the failure or loss of all or part of normal electrical power service or normal natural gas supply to the facility:
  - (1) which is caused by any reason other than the enforcement of a contractual obligation the permittee has with a third party or any other party; and

## **CONDITIONAL APPROVAL ATC 1606-00-11**

### **HIDDEN HILLS COMMON AREA**

- (2) which is demonstrated by the permittee to the district APCO's satisfaction to have been beyond the reasonable control of the owner or operator;
  - B. the failure of a facility's internal power distribution system:
    - (1) which is caused by any reason other than the enforcement of a contractual obligation the permittee has with a third party or any other party; and
    - (2) which is demonstrated by the permittee to the district APCO's satisfaction to have been beyond the reasonable control of the owner or operator;
  - C. the pumping of water for fire suppression or protection;
  - D. the pumping of water to maintain pressure in the water distribution system for the following reasons:
    - (1) a pipe break that substantially reduces water pressure; or
    - (2) high demand on the water supply system due to high use of water for fire suppression; or
    - (3) the breakdown of electric-powered pumping equipment at sewage treatment facilities or water delivery facilities.
- [District Rule 210.A, 17 CCR § 93115].

#### **18) Required Records for Emergency Engines**

The permittee shall keep a monthly log of usage that shall list and document the nature of use for each of the following:

- A. emergency use hours of operation;
- B. maintenance and testing hours of operation;
- C. hours of operation for emission testing to show compliance with the applicable standard;
- D. initial start-up testing hours;
- E. hours of operation for all uses other than those specified above; and
- F. the fuel used.
  - (1) For engines operated exclusively on CARB Diesel Fuel, the owner or operator shall document the use of CARB Diesel Fuel through the retention of fuel purchase records indicating that the only fuel purchased for supply to an emergency standby engine was CARB Diesel Fuel; or
  - (2) For engines operated on any fuel other than CARB Diesel Fuel, fuel records demonstrating that the only fuel purchased and added to an emergency standby engine or engines, or to any fuel tank directly attached to an emergency standby engine or engines, meets the requirements of section 93115.5(b).

[District Rule 210.A, 17 CCR § 93115.10(g)(1)].

#### **19) Record Retention**

Log entries shall be retained for a minimum of 36 months from the date of entry. Log entries made within 24 months of the most recent entry shall be retained on-site, either at a central location or at the engine's location, and made immediately available to the District staff upon request. Log entries made from 25 to 36 months from most recent entry shall be made available to District staff within 5 working days from request. [Rule 210.A, 17 CCR § 93115.10(g)(2)].