

# CALIFORNIA ENERGY COMMISSION

REPORT OF CONVERSATION Page 1 of 2

## DOCKET

11-AFC-3

DATE APR 17 2012

RECD. APR 19 2012



### Siting, Transmission, and Environmental Protection Division

FILE: 11-AFC-3

PROJECT TITLE: Quail Brush Generation Project

<input type="checkbox"/> Telephone	Email	<input type="checkbox"/> Meeting Location:
NAME: Lisa Worrall	DATE: April 17, 2012	TIME: 4:24 PM
WITH: Sarah McCall, Tetra Tech		
SUBJECT: Additional information on project security during construction and operation		

The following information was forwarded to me from Sarah McCall with Tetra Tech, in response to my inquiry for more information about security during plant construction and operation. The following information was sent to Sarah from Mark Chaffee with Congentrix:

From: Chaffee, Mark [MarkChaffee@Cogentrix.com]  
To: McCall, Sarah  
Cc: Farmer, Connie; McDonald, Barry; Ella Gannon; Ziebart, Lori; Collins, John; Neff, Rick

RE: Quail Brush Construction and Operation Security Plans

Sarah,

Regarding Operational Security:

1. Facility will be enclosed by a chain link security fence. The fence will be 8-feet in height (7-foot fabric with 1-foot of 3 strand barb wire).
2. Secured entrance (motorized cantilevered gate) where the access road meets the facility perimeter fencing.
3. The facility will be staffed 24 hours a day, 7 days a week.
4. Video surveillance will be provided and monitored at the control room.
5. Access to the facility will be by key card, or call box, at the entrance gate.
6. Signage will be installed as required by the authorities having jurisdiction.

Regarding Construction Security:

1. Project site and laydown area security are contractually the responsibility of the EPC contractor.
2. EPC contractor will provide security personnel, equipment, and systems to secure the project.
3. A badging system will be implemented to identify all contractor and subcontractor personnel.
4. A storage and material control plan will be implemented to insure the accurate tracking of all purchased materials.
5. Signage will be installed as required by the authorities having jurisdiction.

# CALIFORNIA ENERGY COMMISSION



REPORT OF CONVERSATION Page 2 of 2

Best regards, Mark Chaffee

Mark R. Chaffee, P.E | Chief Civil/Structural Engineer | Cogentrix Energy, LLC  
9405 Arrowpoint Blvd. | Charlotte, NC 28273 | Direct: (704) 672-2851 | Cell: (704) 560-8136

<b>cc:</b> Rick Tyler, CEC Worker Health & Safety and Fire Protection Specialist and Hazardous Materials Specialist	<b>Signed:</b> LW
	<b>Name:</b> Lisa Worrall