



TETRA TECH EC, INC.

February 27, 2013

Mr. Eric Solorio  
California Energy Commission  
Docket No. 11-AFC-3  
1516 9<sup>th</sup> St.  
Sacramento, CA 95814

California Energy Commission

**DOCKETED**  
**11-AFC-03**

TN # 69714

FEB. 27 2013

**Cogentrix Quail Brush Generation Project - Docket Number 11-AFC-3, Quail Brush Generation Project Revised 1-Hour NO<sub>2</sub> Modeling Assessment and Modeling Files**

Docket Clerk:

Pursuant to the provisions of Title 20, California Code of Regulation, and on behalf of Quail Brush Genco, LLC, a wholly owned subsidiary of Cogentrix Energy, LLC, Tetra Tech hereby submits the *Quail Brush Generation Project Revised 1-Hour NO<sub>2</sub> Modeling Assessment and Modeling Files* for the Quail Brush Power Project (11-AFC-3). The Quail Brush Generation Project is a 100 megawatt natural gas fired electric generation peaking facility to be located in the City of San Diego, California. As specific computer software is needed to open and run the modeling files, the Applicant is not serving each party with the CD but is filing with the Docket Unit and will provide a copy of the CD upon request.

If you have any questions regarding this submittal, please contact Rick Neff at (704) 525-3800 or me at (303) 980-3653.

Sincerely,

Constance E. Farmer  
Project Manager/Tetra Tech

TETRA TECH EC, INC.



**BEFORE THE ENERGY RESOURCES CONSERVATION AND DEVELOPMENT  
COMMISSION OF THE STATE OF CALIFORNIA  
1516 NINTH STREET, SACRAMENTO, CA 95814  
1-800-822-6228 – WWW.ENERGY.CA.GOV**

***APPLICATION FOR CERTIFICATION FOR THE  
QUAIL BRUSH GENERATION PROJECT***

Docket No. 11-AFC-03

**PROOF OF SERVICE  
(Revised 02/12/2013)**

**SERVICE LIST:**

**APPLICANT**

Cogentrix Energy, LLC  
C. Richard "Rick" Neff, Vice President  
Environmental, Health & Safety  
John Collins, VP Development  
Lori Ziebart, Project Manager  
Quail Brush Generation Project  
9405 Arrowpoint Boulevard  
Charlotte, NC 28273  
rickneff@cogentrix.com  
johncollins@cogentrix.com  
loriziebart@cogentrix.com

**APPLICANT'S CONSULTANTS**

Tetra Tech EC, Inc.  
Connie Farmer  
Sr. Environmental Project Manager  
Sarah McCall  
Sr. Environmental Planner  
143 Union Boulevard, Suite 1010  
Lakewood, CO 80228  
connie.farmer@tetrattech.com  
sarah.mccall@tetrattech.com

Tetra Tech EC, Inc.  
Barry McDonald  
VP Solar Energy Development  
17885 Von Karman Avenue, Ste. 500  
Irvine, CA 92614-6213  
barry.mcdonald@tetrattech.com

**APPLICANT'S COUNSEL**

Ella Foley Gannon  
Camarin Madigan  
Bingham McCutchen LLP  
Three Embarcadero Center  
San Francisco, CA 94111-4067  
ella.gannon@bingham.com  
camarin.madigan@bingham.com

**INTERVENORS**

Roslind Varghese  
9360 Leticia Drive  
Santee, CA 92071  
roslindv@gmail.com

Rudy Reyes  
8655 Graves Avenue, #117  
Santee, CA 92071  
rreyes2777@hotmail.com

Dorian S. Houser  
7951 Shantung Drive  
Santee, CA 92071  
dhouser@cox.net

Kevin Brewster  
8502 Mesa Heights Road  
Santee, CA 92071  
lzpup@yahoo.com

Helping Hand Tools  
Mr. Rob Simpson, CEO  
1901 First Avenue, Suite 219  
San Diego, CA 92101  
rob@redwoodrob.com

Sierra Club, San Diego Chapter  
c/o Law Office of Robert W. Wright  
Robert W. Wright  
716 Castro Street  
Solana Beach, CA 92075  
bob.wright@mac.com

**INTERVENORS (Cont'd.)**

Sunset Greens  
Homeowners Association  
c/o Briggs Law Corporation  
Cory J. Briggs  
Isabel E. O'Donnell  
99 East "C" Street, Suite 111  
Upland, CA 91786  
cory@briggslawcorp.com  
isabel@briggslawcorp.com

HomeFed Fanita Rancho, LLC  
c/o Allen Matkins Leck Gamble  
Mallory & Natsis LLP  
Jeffrey A. Chine  
Heather S. Riley  
501 West Broadway, 15<sup>th</sup> Floor  
San Diego, CA 92101  
jchine@allenmatkins.com  
hriley@allenmatkins.com  
jkaup@allenmatkins.com  
vhoy@allenmatkins.com

Preserve Wild Santee  
Van Collinsworth  
9222 Lake Canyon Road  
Santee, CA 92071  
savefanita@cox.net

Center for Biological Diversity  
John Buse  
Aruna Prabhala  
351 California Street, Suite 600  
San Francisco, CA 94104  
jbuse@biologicaldiversity.org  
aprabhala@biologicaldiversity.org

**INTERVENORS (Cont'd.)**

California Pilots Association  
Andy Wilson  
31438 Greenbrier Lane  
Hayward, CA 94544  
andy.wilson@calpilots.org

**INTERESTED AGENCIES**

California ISO  
e-recipient@caiso.com

City of Santee  
Department of Development Services  
Melanie Kush, Director of Planning  
10601 Magnolia Avenue, Bldg. 4  
Santee, CA 92071  
mkush@ci.santee.ca.us

City of San Diego  
Development Services Dept.  
Morris E. Dye  
1222 First Avenue, MS 501  
San Diego, CA 92101  
mdye@sandiego.gov

County of San Diego  
Department of Planning & Land Use  
Mindy Fogg  
Land Use Environmental Planner  
Advance Planning  
5510 Overland Avenue, Suite 310  
San Diego, CA 92123  
mindy.fogg@sdcounty.ca.gov

**ENERGY COMMISSION STAFF**

Eric Solorio  
Project Manager  
eric.solorio@energy.ca.gov

Stephen Adams  
Staff Counsel  
stephen.adams@energy.ca.gov

**ENERGY COMMISSION –  
PUBLIC ADVISER**

\*Blake Roberts  
Assistant Public Adviser  
publicadviser@energy.ca.gov

**COMMISSION DOCKET UNIT**

California Energy Commission  
– Docket Unit  
Attn: Docket No. 11-AFC-03  
1516 Ninth Street, MS-4  
Sacramento, CA 95814-5512  
docket@energy.ca.gov

**OTHER ENERGY COMMISSION  
PARTICIPANTS (LISTED FOR  
CONVENIENCE ONLY):**

*After docketing, the Docket Unit will  
provide a copy to the persons listed  
below. Do not send copies of  
documents to these persons unless  
specifically directed to do so.*

KAREN DOUGLAS  
Commissioner and Presiding Member

ANDREW McALLISTER  
Commissioner and Associate Member

Raoul Renaud  
Hearing Adviser

Galen Lemei  
Adviser to Commissioner Douglas

Jennifer Nelson  
Adviser to Commissioner Douglas

David Hungerford  
Adviser to Commissioner McAllister

Patrick Saxton  
Adviser to Commissioner McAllister

Eileen Allen  
Commissioners' Technical  
Adviser for Facility Siting

Declaration of Service

I, Constance Farmer, declare that on February 27, 2013, I served and filed copies of the attached Revised 1-Hour NO2 Modeling Assessment, Cogentrix Quail Brush Generation Project, City of San Diego, San Diego County, California (11-AFC-03). This document is accompanied by the most recent Proof of Service, which I copied from the web page for this project at: <http://www.energy.ca.gov/sitingcases/quailbrush/index.html>.

The document has been sent to the other persons on the Service List above in the following manner:

*(Check one)*

**For service to all other parties and filing with the Docket Unit at the Energy Commission:**

- I e-mailed the document to all e-mail addresses on the Service List above and personally delivered it or deposited it in the US mail with first class postage to those parties noted above as "hard copy required"; **OR**
- Instead of e-mailing the document, I personally delivered it or deposited it in the US mail with first class postage to all of the persons on the Service List for whom a mailing address is given.

I declare under penalty of perjury under the laws of the State of California that the foregoing is true and correct, and that I am over the age of 18 years.

Dated: February 27, 2013



# REVISED 1-HOUR NO<sub>2</sub> MODELING ASSESSMENT

For the:

## QUAIL BRUSH GENERATION PROJECT

Prepared for:

Quail Brush Genco, LLC.  
9405 Arrowpoint Boulevard  
Charlotte, NC 28273

Prepared by:

Atmospheric Dynamics, Inc.  
Torres 3 SW of Mountain View  
P.O. Box 5907  
Carmel-by-the-Sea, CA. 93921-5907



**ATMOSPHERIC DYNAMICS, INC**  
Meteorological & Air Quality Modeling

**February 2013**

## Revised Quail Brush Generation Project 1-Hour NO<sub>2</sub> Startup Air Quality Impact Assessment

This report describes the Quail Brush Generation Project (QBG) air quality modeling results for the comparison to the Federal 1-hour standard of 188  $\mu\text{g}/\text{m}^3$ . Potential air quality impacts were evaluated based on air quality dispersion modeling, as described herein. With the exception of the binary data files, all input and output modeling files are contained on a CD-ROM disk provided with this report. The modeling analyses were performed using the techniques and methods outlined by the EPA in the June 2010 "Guidance Concerning the Implementation of the 1-hour NO<sub>2</sub> NAAQS for the Prevention of Significant Deterioration Program" (EPA, June 2010).

### DISPERSION MODELING

For modeling the potential impact of QBG in terrain that is both below and above stack top (defined as simple terrain when the terrain is below stack top and complex terrain when it is above stack top), the USEPA guideline model AERMOD (version 12345) was used with the Plume Volume Molar Ratio Method for comparison with the Federal 1-hour NO<sub>2</sub> standard. The meteorological and receptor data sets used in this revised analysis were based on the data used in the October 2012 assessment.

The purpose of the revised AERMOD modeling analysis was to evaluate compliance with the federal 1-hour NO<sub>2</sub> air quality standard. As discussed with CEC Staff, the modeled 98<sup>th</sup> percentile daily average 1-hour NO<sub>2</sub> modeled concentration was added to the seasonal monitored background NO<sub>2</sub> concentrations in order to determine the total modeled impact.

Two operating profiles were assessed for compliance with the 1-hour NO<sub>2</sub> standard: (1) six engines starting up in the same hour with the other five engines nonoperational and (2) six engines starting up in the same hour with the other five engines at full operational load. In both cases, the heaters are fully operational. The stack parameters were those used in the October 2012 application.

The worst case cold startup emissions along with the assumptions on the NO<sub>2</sub>/NO<sub>x</sub> ratios were modified with this submittal and are based upon the following procedures:

1. Only six (6) engines may start-up at any one-time (1-hour time frame).
2. Per the most recent analysis of applicable NO<sub>2</sub>/NO<sub>x</sub> ratios, QBG has proposed to use the following ratios for the following time periods:
  - a. 25% for the cold startup period of 25 minutes for each engine.
  - b. 18.5% for the remaining 35 minutes in the startup hour for each engine.
  - c. These changes result in a weighted start-up hour NO<sub>2</sub>/NO<sub>x</sub> ratio of 21.2%.
3. QBG has reduced, per item 3 above, the cold start-up time from 30 to 25 minutes. This reduction amounts to a 17% reduction in the cold start-up time.
4. QBG has approved a reduction in the cold start-up NO<sub>x</sub> emissions of 10%, which decreases the pound/event value from 8.82 lbs to 7.94 lbs of NO<sub>x</sub>.



5. The pound per hour NO<sub>x</sub> emission rate used in the assessment becomes 8.7091 lb/hr or 1.09735 g/s per engine for a startup hour. Thus, each engine in startup represents 25 minutes in startup mode and 35 minutes at 100 percent base load.
6. For all other operations hours, including warm start hours, the previously established NO<sub>2</sub>/NO<sub>x</sub> ratio of 18.5% will apply.

The previous worst-case hour included a shutdown, but this case was removed from the analysis as the engines will not startup, run and then shut down during any one-hour period. The updated emissions for all engines are provided as an attachment at the end of this document.

The worst case NO<sub>2</sub> facility configuration, eleven engines at 100% load for 70°F ambient temperatures (Case I), was modeled with AERMOD. The modeling options and inputs were the same as the previous modeled, namely:

- Seasonal NO<sub>2</sub> background data for 2008-2010 (third-highest seasonal value for each hour, with the NO<sub>2</sub> data first processed in accordance with the guidance contained in the CAPCOA Guidance Document “Modeling Compliance of The Federal 1-Hour NO<sub>2</sub> NAAQS” dated October 27, 2011) from the Kearny Mesa site were used to assess compliance with the NAAQS based on the 5-year average of the annual 8<sup>th</sup> highest daily 1-hour maxima.

Receptor and source base elevations were determined from the USGS National Elevation Dataset (NED) data in the GeoTIFF format at a horizontal resolution of 1/3 arc-second (approximate 10 meter spacing). Because of the format of the NED data, all coordinates (both sources and receptors) were referenced to UTM North American Datum 1983 (NAD83, Zone 11). Elevation locations in the NED dataset were interpolated by AERMAP to the UTM locations appropriate for the receptor grid spacings shown below.

The receptor grids used in the modeling analysis are presented in Figure 1.

### **PLUME VOLUME MOLAR RATIO METHOD**


As with one of the existing techniques called the Ozone Limiting Method (OLM), the Plume Volume Molar Ratio Method (PVMRM) approach limits the conversion of NO to NO<sub>2</sub> based on the amount of ambient ozone available. The OLM involves an initial comparison of the estimated maximum NO<sub>x</sub> concentration and the ambient ozone concentration to determine which is the limiting factor to NO<sub>2</sub> formation. If the ozone concentration is greater than the maximum NO<sub>x</sub> concentration, total conversion is assumed. If the NO<sub>x</sub> concentration is greater than the ozone concentration, the formation of NO<sub>2</sub> is limited by the ambient ozone concentration. In this case, the NO<sub>2</sub> concentration is set equal to the ozone concentration plus a correction factor that accounts for in-stack and near-stack thermal conversion. However, the PVMRM approach limits the conversion based on the amount of ozone within the volume of the plume. With PVMRM, the NO<sub>2</sub>/NO<sub>x</sub> conversion ratio is coupled with the dispersion of the plume. The PVMRM approach also incorporates a technique for merging plumes from nearby sources for purposes of calculating the NO<sub>2</sub>/NO<sub>x</sub> ratios.



The PVMRM was used with concurrent hourly 1-hour ozone concentrations to calculate the 1-hour NO<sub>2</sub> concentrations using the AERMOD PVMRM subroutine. Ozone data from the Overland Avenue Monitoring Station for the same period as the meteorological data (2003-2007) were used for the PVMRM analyses. Missing ozone data for periods of 1 hour were interpolated from the monitoring data before/after the missing period. Missing data for longer periods were replaced with data from nearest ozone monitoring station.

As stated above, seasonal background NO<sub>2</sub> data was added to the modeled concentrations to produce a combined impact for comparison with the Federal 1-hour NO<sub>2</sub> standard.

**Figure 1 Receptor Grids used in AERMOD for the Revised 1-hour NO<sub>2</sub> Analysis**





**AERMOD MODELING RESULTS**

In order to determine which of the six (6) engines in startup mode would produce the largest impact, a series of screening runs were performed with various combinations of engines in startup and in base load operation. It was determined that the worst-case impacts would occur for the case where five (5) of the engines were at 100 percent load and the remaining six (6) were in startup. The engines are clustered into two groups, with one of the groups of six (6) engines on the western side and five (5) engines in the eastern side. Six engine startups of beginning on the western side and rotating towards the east were assessed. It became apparent that the eastern engines always produce the largest impacts for the 1-hour NO<sub>2</sub> standard. Thus, the worst case 1-hour NO<sub>2</sub> results are based on the five (5) engines starting up on the eastern cluster with one (1) engine starting up in the western grouping. The remaining five (5) engines are at 100 percent load.

The revised 1-hour NO<sub>2</sub> impacts are compared below to the AAQS. Maximum impacts for both NAAQS/CAAQS occurred on the high resolution receptor grids, so no additional refined receptor grids were necessary. Figure 1 identifies the location of the maximum 1-hour NO<sub>2</sub> impact. As can be seen in Table 1, the facility will comply with applicable state/California and Federal/ National NO<sub>2</sub> standards.

**Table 1 Comparison of NO<sub>2</sub> Air Quality Impacts to the AAQS**

Pollutant	Avg. Period	Maximum Concentration (µg/m <sup>3</sup> )	Background (µg/m <sup>3</sup> )	Total (µg/m <sup>3</sup> )	Ambient Air Quality CAAQS/NAAQS	
					(µg/m <sup>3</sup> )	(µg/m <sup>3</sup> )
<b>STARTUP QBGP CONDITIONS:</b>						
NO <sub>2</sub>	1-hour Federal	180.232	-	180.23	-	188
	1-hour State	314.044	-	314.04	339	-

Notes: Background concentrations included by AERMOD for 1-hour NO<sub>2</sub> impacts.

**CONCLUSION**

The results of the revised startup modeling analysis for NO<sub>2</sub> demonstrates that the proposed project will safely comply with the federal 1-hour ambient air quality standard for NO<sub>2</sub>.



Table F.1-1 (Revised 02-26-13)

**Maximum Hourly, Daily, and Annual Emissions Calculations**

Number of Identical Engines: 11

**Full Load Case**

**Input data per unit:**

Operation hrs/day	Annual Op hrs	Avg # of Cold Startups day	Avg # of Warm Startups day	Cold Startup Time hrs	Warm Startup Time hrs	Shutdown Time hrs	Cold Starts yr	Warm Starts yr	Estimated Shutdowns yr	Max Estimated Shutdowns day
24	4032	1	1	0.416	0.25	0.1417	300	100	400	2

	Cold Startup Emissions lbs/event	Warm Startup Emissions lbs/event	Shutdown Emissions lbs/event	Steady State Emissions lbs/hr (100% Load)	Total Cold Start hrs/yr	Total Warm Start hrs/yr	Total Shutdown hrs/yr	Annual Steady State Non SU/SD hrs/yr	Total Annual Emissions Cold Starts lbs/yr	Total Annual Emissions Warm Starts lbs/yr	Total Annual Emissions Shutdowns lbs/yr
NOx	7.94	2.43	0.2	1.317	124.8	25	56.68	3825.52	2382.0	243.0	80.0
CO	12.57	1.322	0.31	1.564					3771.0	132.2	124.0
VOC	6.614	1.764	0.34	1.584					1984.2	176.4	136.0
SOx	0.137	0.07	0.05	0.256					41.1	7.0	20.0
PM10	1.54	1.54	0.35	1.379					462.0	154.0	140.0
PM2.5	1.54	1.54	0.35	1.379					462.0	154.0	140.0

- SU/SD emissions data and times derived from: Wartsila Emissions Data Sheet, DBAB715360, 2-27-11.
- Cold start (CS): engine will reach steady state in 10 minutes and controls (SCR and CO Cat) will be fully operational in 30 minutes.
- Warm start (WS): engine will reach steady state in 10 minutes and controls (SCR and CO Cat) will be fully operational in 15 minutes.
- A warm start is defined as a start initiated within 2-6 hours after the engine has been shutdown, or when the emissions control system is at a temperature of no less than 270 C (518 F).
- Shutdown time is optimally 8.5 minutes per Wartsila.
- Cold start w/o shutdown = 0.416 hrs steady state = 0.584 hrs
- Warm start w/o shutdown = 0.25 hrs steady state = 0.75 hrs
- Shut down = 0.1417 hrs steady state = 0.8583 hrs
- Steady state (SS) emissions values derived from Cogentrix/Wartsila.
- SO2 emissions include S to SO2 from lube oil burn-off from cylinder sleeves.

**Maximum Estimated Hourly Emissions  
1 Hour Period**

	NOx lbs/hr	CO lbs/hr	VOC lbs/hr	SOx lbs/hr	PM10 lbs/hr	PM2.5 lbs/hr	
<b>Scenario 1</b>	8.71	13.48	7.54	0.29	2.35	2.35	1 Engine
<i>Cold Start w/Steady State (5 Engines)</i>	43.55	67.42	37.70	1.43	11.73	11.73	5 Engines
<i>Cold Start w/Steady State (6 Engines)</i>	52.25	80.90	45.23	1.72	14.07	14.07	6 Engines
<b>Scenario 2</b>	3.42	2.50	2.95	0.26	2.57	2.57	1 Engine
<i>Warm Start w/Steady State</i>	37.60	27.45	32.47	2.88	28.32	28.32	All Engines
<b>Scenario 3</b>	8.91	13.79	7.88	0.34	2.70	2.70	1 Engine
<i>Cold Start, Steady State, Shutdown</i>	***	98.00	151.73	86.67	3.70	29.65	All Engines
<b>Scenario 4</b>	3.62	2.81	3.29	0.31	2.92	2.92	1 Engine
<i>Warm Start, Steady State, Shutdown</i>	***	39.80	30.86	36.21	3.43	32.17	All Engines
<b>Scenario 5</b>	1.33	1.65	1.70	0.27	1.53	1.53	1 Engine
<i>Steady State w/Shutdown</i>	14.63	18.18	18.70	2.97	16.87	16.87	All Engines
<b>Scenario 6</b>	1.32	1.56	1.58	0.26	1.38	1.38	1 Engine
<i>Steady State</i>	14.49	17.20	17.42	2.82	15.17	15.17	All Engines

\*\*\* cannot occur, once SU is finalized, the unit(s) must run for 2 hours prior to a SD

<b>Maximum Estimated Daily Emissions 24 Hr Period Run Day</b>	NOx lbs/day	CO lbs/day	VOC lbs/day	SOx lbs/day	PM10 lbs/day	PM2.5 lbs/day	
<b>Scenario 1</b>	39.20	49.77	44.31	6.22	34.41	34.41	<i>1 Engine</i>
<i>Cold Start, Steady State, Shutdown</i>	431.20	547.42	487.42	68.47	378.54	378.54	All Engines
<b>Scenario 2</b>	33.91	38.78	39.72	6.20	34.64	34.64	<i>1 Engine</i>
<i>Warm Start, Steady State, Shutdown</i>	373.00	426.55	436.96	68.20	381.05	381.05	All Engines
<b>Scenario 3</b>	31.61	37.54	38.02	6.14	33.10	33.10	<i>1 Engine</i>
<i>Steady State</i>	347.69	412.90	418.18	67.58	364.06	364.06	All Engines
<b>Scenario 4</b>							<i>1 Engine</i>
*****							All Engines

<b>Maximum Estimated Daily Emissions 16 Hr Period Run Day</b>	NOx lbs/day	CO lbs/day	VOC lbs/day	SOx lbs/day	PM10 lbs/day	PM2.5 lbs/day	
<b>Scenario 1</b>	28.66	37.25	31.64	4.18	23.38	23.38	<i>1 Engine</i>
<i>Cold Start, Steady State, Shutdown</i>	315.31	409.79	348.03	45.94	257.18	257.18	All Engines
<b>Scenario 2</b>	23.37	26.27	27.05	4.15	23.61	23.61	<i>1 Engine</i>
<i>Warm Start, Steady State, Shutdown</i>	257.10	288.92	297.57	45.67	259.70	259.70	All Engines
<b>Scenario 3</b>	21.07	25.02	25.34	4.10	22.06	22.06	<i>1 Engine</i>
<i>Steady State</i>	231.79	275.26	278.78	45.06	242.70	242.70	All Engines
<b>Scenario 4</b>							<i>1 Engine</i>
*****							All Engines

<b>Maximum Estimated Daily Emissions 8 Hr Period Run Day</b>	NOx lbs/day	CO lbs/day	VOC lbs/day	SOx lbs/day	PM10 lbs/day	PM2.5 lbs/day	
<b>Scenario 1</b>	18.13	24.74	18.97	2.13	12.35	12.35	<i>1 Engine</i>
<i>Cold Start, Steady State, Shutdown</i>	199.41	272.16	208.64	23.41	135.83	135.83	All Engines
<b>Scenario 2</b>	12.84	13.75	14.38	2.10	12.58	12.58	<i>1 Engine</i>
<i>Warm Start, Steady State, Shutdown</i>	141.20	151.28	158.18	23.14	138.35	138.35	All Engines
<b>Scenario 3</b>	10.54	12.51	12.67	2.05	11.03	11.03	<i>1 Engine</i>
<i>Steady State</i>	115.90	137.63	139.39	22.53	121.35	121.35	All Engines
<b>Scenario 4</b>							<i>1 Engine</i>
*****							All Engines

**Other Misc Scenarios -based on run hour type**

(CS-cold start hour, WS-warm start hour, SD-shutdown hour, SS-steady state hour)

	NOx lbs/day	CO lbs/day	VOC lbs/day	SOx lbs/day	PM10 lbs/day	PM2.5 lbs/day	
<i>a - CS, SS, SD, WS, SS, SD (total ops period 12 hrs)</i>	25.32	31.80	26.56	3.14	19.02	19.02	<i>1 Engine</i>
	278.56	349.75	292.18	34.50	209.21	209.21	All Engines

*b - 3 CSs, 1 WS, 4 SDs, SS (total ops period 24 hrs)*

	55.94	74.58	57.71	6.30	37.81	37.81	<i>1 Engine</i>
	615.33	820.37	634.82	69.26	415.90	415.90	All Engines

Maximum Estimated Annual Emissions		NOx	CO	VOC	SOx	PM10	PM2.5
		lbs/yr	lbs/yr	lbs/yr	lbs/yr	lbs/yr	lbs/yr
<b>Ops Scenario</b>							
Cold Startups		2382.0	3771.0	1984.2	41.1	462.0	462.0
Warm Startups		243.0	132.2	176.4	7.0	154.0	154.0
Shutdowns		80.0	124.0	136.0	20.0	140.0	140.0
Steady State		5038.2	5983.1	6059.6	979.3	5275.4	5275.4
	1 Engine Totals, lbs/yr:	7743.2	10010.3	8356.2	1047.4	6031.4	6031.4
	1 Engine Totals, tons/yr:	3.87	5.01	4.18	0.52	3.02	3.02
		NOx	CO	VOC	SOx	PM10	PM2.5
		tpy	tpy	tpy	tpy	tpy	tpy
<b>Total Tons/Yr All Engines:</b>		<b>42.59</b>	<b>55.06</b>	<b>45.96</b>	<b>5.76</b>	<b>33.17</b>	<b>33.17</b>

EPA	PSD Significant Emissions Rates, TPY:	40	100	40	40	15	10
SDAPCD	Air Agency Offset Trigger Levels, TPY:	50	100	50	100	100	100

**GHG Emissions Estimates**

CCAR, General Reporting Protocol, Version 3.1, January 2009, Table C.6.

Fuel:	Natural Gas	1 short ton = 2000 lbs, 1 metric ton = 2200 lbs.						
Btu/scf:	1019	HHV						
Heat Rate:	80.18	mmbtu/hr						
Fuel Rate:	0.0787	mmscf/hr						
<i>Emissions Factors</i>		<i>Emissions</i>	lbs/hr	lbs/year	short tons/yr	IPCC SAR Values	CO2e short tons/yr	
CO2	116.954	lbs/mmbtu	9.38E+03	3.78E+07	1.89E+04	1	1.89E+04	
CH4	0.01301	lbs/mmbtu	1.04E+00	4.21E+03	2.10E+00	21	4.42E+01	
N2O	0.0002205	lbs/mmbtu	1.77E-02	7.13E+01	3.56E-02	310	1.10E+01	
					Total CO2e:	18960	short TPY	1 Engine
					Total CO2e:	208560	short TPY	All Engines
					Total CO2e:	17236	metric TPY	1 Engine
<b>PSD Triggered for GHGs:</b>			Yes		<b>Total CO2e:</b>	<b>189600</b>	<b>metric TPY</b>	<b>All Engines</b>

## 75% Load Evaluation

### Maximum Hourly, Daily Emissions Calculations

Number of Identical Engines: 11

#### Input data per unit:

Operation hrs/day	Annual Op hrs	Avg # of Cold Startups day	Avg # of Warm Startups day	Cold Startup Time hrs	Warm Startup Time hrs	Shutdown Time hrs	Cold Starts yr	Warm Starts yr	Estimated Shutdowns yr	Max Estimated Shutdowns day
24	4032	1	1	0.416	0.25	0.1417	300	100	400	2

	Cold Startup Emissions lbs/event	Warm Startup Emissions lbs/event	Shutdown Emissions lbs/event	Steady State Emissions lbs/hr
	7.94	2.43	0.2	1.11
NOx	12.57	1.322	0.31	1.48
CO	6.614	1.764	0.34	1.541
VOC	0.137	0.07	0.05	0.256
SOx	1.54	1.54	0.35	1.372
PM10	1.54	1.54	0.35	1.372
PM2.5				

- SU/SD emissions data and times derived from: Wartsila Emissions Data Sheet, DBAB715360, 2-27-11.
- Cold start (CS): engine will reach steady state in 10 minutes and controls (SCR and CO Cat) will be fully operational in 25 minutes.
- Warm start (WS): engine will reach steady state in 10 minutes and controls (SCR and CO Cat) will be fully operational in 15 minutes.
- A warm start is defined as a start initiated within 2-6 hours after the engine has been shutdown, or when the emissions control system is at a temperature of no less than 270 C (518 F).
- Shutdown time is optimally 8.5 minutes per Wartsila.
- Cold start w/o shutdown = 0.416 hrs steady state = 0.584 hrs
- Warm start w/o shutdown = 0.25 hrs steady state = 0.75 hrs
- Shut down = 0.1417 hrs steady state = 0.8583 hrs
- Steady state (SS) emissions values derived from Cogentrix/Wartsila.
- SO2 emissions include S to SO2 from lube oil burn-off from cylinder sleeves.

#### Maximum Estimated Hourly Emissions

##### 1 Hour Period

	NOx lbs/hr	CO lbs/hr	VOC lbs/hr	SOx lbs/hr	PM10 lbs/hr	PM2.5 lbs/hr	
<b>Scenario 1</b>	8.59	13.43	7.51	0.29	2.34	2.34	1 Engine
<i>Cold Start w/Steady State (5 Engines)</i>	42.94	67.17	37.57	1.43	11.71	11.71	5 Engines
<i>Cold Start w/Steady State (6 Engines)</i>	51.53	80.61	45.08	1.72	14.05	14.05	6 Engines
<b>Scenario 2</b>	3.26	2.43	2.92	0.26	2.57	2.57	1 Engine
<i>Warm Start w/Steady State</i>	35.89	26.75	32.12	2.88	28.26	28.26	All Engines
<b>Scenario 3</b>	8.79	13.74	7.85	0.34	2.69	2.69	1 Engine
<i>Cold Start, Steady State, Shutdown</i>	***	96.67	151.19	86.39	3.70	29.60	All Engines
<b>Scenario 4</b>	3.46	2.74	3.26	0.31	2.92	2.92	1 Engine
<i>Warm Start, Steady State, Shutdown</i>	***	38.09	30.16	35.86	3.43	32.11	All Engines
<b>Scenario 5</b>	1.15	1.58	1.66	0.27	1.53	1.53	1 Engine
<i>Steady State w/Shutdown</i>	12.68	17.38	18.29	2.97	16.80	16.80	All Engines
<b>Scenario 6</b>	1.11	1.48	1.54	0.26	1.37	1.37	1 Engine
<i>Steady State</i>	12.21	16.28	16.95	2.82	15.09	15.09	All Engines

\*\*\* cannot occur, once SU is finalized, the unit(s) must run for 2 hours prior to a SD

<b>Maximum Estimated Daily Emissions 24 Hr Period Run Day</b>	NOx lbs/day	CO lbs/day	VOC lbs/day	SOx lbs/day	PM10 lbs/day	PM2.5 lbs/day	
<b>Scenario 1</b>	34.32	47.78	43.30	6.22	34.25	34.25	1 Engine
<i>Cold Start, Steady State, Shutdown</i>	377.50	525.63	476.27	68.47	376.72	376.72	All Engines
<b>Scenario 2</b>	28.99	36.78	38.70	6.20	34.48	34.48	1 Engine
<i>Warm Start, Steady State, Shutdown</i>	318.92	404.60	425.73	68.20	379.23	379.23	All Engines
<b>Scenario 3</b>	26.64	35.52	36.98	6.14	32.93	32.93	1 Engine
<i>Steady State</i>	293.04	390.72	406.82	67.58	362.21	362.21	All Engines
<b>Scenario 4</b>							1 Engine
*****							All Engines

<b>Maximum Estimated Daily Emissions 16 Hr Period Run Day</b>	NOx lbs/day	CO lbs/day	VOC lbs/day	SOx lbs/day	PM10 lbs/day	PM2.5 lbs/day	
<b>Scenario 1</b>	25.44	35.94	30.97	4.18	23.27	23.27	1 Engine
<i>Cold Start, Steady State, Shutdown</i>	279.82	395.39	340.66	45.94	255.98	255.98	All Engines
<b>Scenario 2</b>	20.11	24.94	26.37	4.15	23.50	23.50	1 Engine
<i>Warm Start, Steady State, Shutdown</i>	221.24	274.36	290.12	45.67	258.49	258.49	All Engines
<b>Scenario 3</b>	17.76	23.68	24.66	4.10	21.95	21.95	1 Engine
<i>Steady State</i>	195.36	260.48	271.22	45.06	241.47	241.47	All Engines
<b>Scenario 4</b>							1 Engine
*****							All Engines

<b>Maximum Estimated Daily Emissions 8 Hr Period Run Day</b>	NOx lbs/day	CO lbs/day	VOC lbs/day	SOx lbs/day	PM10 lbs/day	PM2.5 lbs/day	
<b>Scenario 1</b>	16.56	24.10	18.64	2.13	12.30	12.30	1 Engine
<i>Cold Start, Steady State, Shutdown</i>	182.14	265.15	205.05	23.41	135.25	135.25	All Engines
<b>Scenario 2</b>	11.23	13.10	14.05	2.10	12.52	12.52	1 Engine
<i>Warm Start, Steady State, Shutdown</i>	123.56	144.12	154.51	23.14	137.75	137.75	All Engines
<b>Scenario 3</b>	8.88	11.84	12.33	2.05	10.98	10.98	1 Engine
<i>Steady State</i>	97.68	130.24	135.61	22.53	120.74	120.74	All Engines
<b>Scenario 4</b>							1 Engine
*****							All Engines

**Other Misc Scenarios -based on run hour type**

(CS-cold start hour, WS-warm start hour, SD-shutdown hour, SS-steady state hour)

	NOx lbs/day	CO lbs/day	VOC lbs/day	SOx lbs/day	PM10 lbs/day	PM2.5 lbs/day	
<i>a - CS, SS, SD, WS, SS, SD (total ops period 12 hrs)</i>	23.04	30.87	26.09	3.14	18.94	18.94	1 Engine
	253.40	339.54	286.96	34.50	208.36	208.36	All Engines
<i>b - 3 CSs, 1 WS, 4 SDs, SS (total ops period 24 hrs)</i>	51.40	72.74	56.77	6.30	37.66	37.66	1 Engine
	565.38	800.10	624.45	69.26	414.21	414.21	All Engines

## 50% Load Evaluation

### Maximum Hourly, Daily Emissions Calculations

Number of Identical Engines: 11

#### Input data per unit:

Operation hrs/day	Annual Op hrs	Avg # of Cold Startups day	Avg # of Warm Startups day	Cold Startup Time hrs	Warm Startup Time hrs	Shutdown Time hrs	Cold Starts yr	Warm Starts yr	Estimated Shutdowns yr	Max Estimated Shutdowns day
24	4032	1	1	0.416	0.25	0.1417	300	100	400	2

	Cold Startup Emissions lbs/event	Warm Startup Emissions lbs/event	Shutdown Emissions lbs/event	Steady State Emissions lbs/hr
				<b>(50% Load)</b>
NOx	7.94	2.43	0.2	0.921
CO	12.57	1.322	0.31	1.494
VOC	6.614	1.764	0.34	1.504
SOx	0.137	0.07	0.05	0.256
PM10	1.54	1.54	0.35	1.361
PM2.5	1.54	1.54	0.35	1.361

- SU/SD emissions data and times derived from: Wartsila Emissions Data Sheet, DBAB715360, 2-27-11.
- Cold start (CS): engine will reach steady state in 10 minutes and controls (SCR and CO Cat) will be fully operational in 30 minutes.
- Warm start (WS): engine will reach steady state in 10 minutes and controls (SCR and CO Cat) will be fully operational in 15 minutes.
- A warm start is defined as a start initiated within 2-6 hours after the engine has been shutdown, or when the emissions control system is at a temperature of no less than 270 C (518 F).
- Shutdown time is optimally 8.5 minutes per Wartsila.
- Cold start w/o shutdown = 0.416 hrs steady state = 0.584 hrs
- Warm start w/o shutdown = 0.25 hrs steady state = 0.75 hrs
- Shut down = 0.1417 hrs steady state = 0.8583 hrs
- Steady state (SS) emissions values derived from Cogentrix/Wartsila.
- SO2 emissions include S to SO2 from lube oil burn-off from cylinder sleeves.

#### Maximum Estimated Hourly Emissions

##### 1 Hour Period

	NOx lbs/hr	CO lbs/hr	VOC lbs/hr	SOx lbs/hr	PM10 lbs/hr	PM2.5 lbs/hr	
<b>Scenario 1</b>	8.48	13.44	7.49	0.29	2.33	2.33	1 Engine
Cold Start w/Steady State (5 Engines)	42.39	67.21	37.46	1.43	11.67	11.67	5 Engines
Cold Start w/Steady State (6 Engines)	50.87	80.65	44.95	1.72	14.01	14.01	6 Engines
<b>Scenario 2</b>	3.12	2.44	2.89	0.26	2.56	2.56	1 Engine
Warm Start w/Steady State	34.33	26.87	31.81	2.88	28.17	28.17	All Engines
<b>Scenario 3</b>	8.68	13.75	7.83	0.34	2.68	2.68	1 Engine
Cold Start, Steady State, Shutdown	***	95.46	151.28	86.16	3.70	29.53	All Engines
<b>Scenario 4</b>	3.32	2.75	3.23	0.31	2.91	2.91	1 Engine
Warm Start, Steady State, Shutdown	***	36.53	30.28	35.55	3.43	32.02	All Engines
<b>Scenario 5</b>	0.99	1.59	1.63	0.27	1.52	1.52	1 Engine
Steady State w/Shutdown	10.90	17.52	17.94	2.97	16.70	16.70	All Engines
<b>Scenario 6</b>	0.92	1.49	1.50	0.26	1.36	1.36	1 Engine
Steady State	10.13	16.43	16.54	2.82	14.97	14.97	All Engines

\*\*\* cannot occur, once SU is finalized, the unit(s) must run for 2 hours prior to a SD

<b>Maximum Estimated Daily Emissions 24 Hr Period Run Day</b>	NOx lbs/day	CO lbs/day	VOC lbs/day	SOx lbs/day	PM10 lbs/day	PM2.5 lbs/day	
<b>Scenario 1</b>	29.86	48.11	42.42	6.22	33.99	33.99	1 Engine
<i>Cold Start, Steady State, Shutdown</i>	328.47	529.26	466.67	68.47	373.87	373.87	All Engines
<b>Scenario 2</b>	24.50	37.11	37.82	6.20	34.21	34.21	1 Engine
<i>Warm Start, Steady State, Shutdown</i>	269.54	408.26	416.06	68.20	376.35	376.35	All Engines
<b>Scenario 3</b>	22.10	35.86	36.10	6.14	32.66	32.66	1 Engine
<i>Steady State</i>	243.14	394.42	397.06	67.58	359.30	359.30	All Engines
<b>Scenario 4</b>							1 Engine
*****							All Engines

<b>Maximum Estimated Daily Emissions 16 Hr Period Run Day</b>	NOx lbs/day	CO lbs/day	VOC lbs/day	SOx lbs/day	PM10 lbs/day	PM2.5 lbs/day	
<b>Scenario 1</b>	22.49	36.16	30.39	4.18	23.10	23.10	1 Engine
<i>Cold Start, Steady State, Shutdown</i>	247.42	397.79	334.32	45.94	254.10	254.10	All Engines
<b>Scenario 2</b>	17.14	25.16	25.79	4.15	23.33	23.33	1 Engine
<i>Warm Start, Steady State, Shutdown</i>	188.49	276.79	283.71	45.67	256.58	256.58	All Engines
<b>Scenario 3</b>	14.74	23.90	24.06	4.10	21.78	21.78	1 Engine
<i>Steady State</i>	162.10	262.94	264.70	45.06	239.54	239.54	All Engines
<b>Scenario 4</b>							1 Engine
*****							All Engines

<b>Maximum Estimated Daily Emissions 8 Hr Period Run Day</b>	NOx lbs/day	CO lbs/day	VOC lbs/day	SOx lbs/day	PM10 lbs/day	PM2.5 lbs/day	
<b>Scenario 1</b>	15.12	24.21	18.36	2.13	12.21	12.21	1 Engine
<i>Cold Start, Steady State, Shutdown</i>	166.37	266.32	201.96	23.41	134.33	134.33	All Engines
<b>Scenario 2</b>	9.77	13.21	13.76	2.10	12.44	12.44	1 Engine
<i>Warm Start, Steady State, Shutdown</i>	107.45	145.32	151.36	23.14	136.82	136.82	All Engines
<b>Scenario 3</b>	7.37	11.95	12.03	2.05	10.89	10.89	1 Engine
<i>Steady State</i>	81.05	131.47	132.35	22.53	119.77	119.77	All Engines
<b>Scenario 4</b>							1 Engine
*****							All Engines

**Other Misc Scenarios -based on run hour type**

(CS-cold start hour, WS-warm start hour, SD-shutdown hour, SS-steady state hour)

	NOx lbs/day	CO lbs/day	VOC lbs/day	SOx lbs/day	PM10 lbs/day	PM2.5 lbs/day	
<i>a - CS, SS, SD, WS, SS, SD (total ops period 12 hrs)</i>	20.95	31.02	25.68	3.14	18.82	18.82	1 Engine
	230.42	341.24	282.46	34.50	207.02	207.02	All Engines

*b - 3 CSs, 1 WS, 4 SDs, SS (total ops period 24 hrs)*

	47.25	73.04	55.96	6.30	37.41	37.41	1 Engine
	519.78	803.48	615.52	69.26	411.55	411.55	All Engines