

## CALIFORNIA ENERGY COMMISSION

1516 NINTH STREET  
SACRAMENTO, CA 95814-5112

<b>DOCKET</b> <b>08-AFC-10</b>
DATE <u>SEP 22 2008</u>
RECD. <u>SEP 22 2008</u>

September 22, 2008

Dear Librarian:

**DOCUMENT HANDLING FOR THE LODI ENERGY CENTER PROJECT APPLICATION FOR CERTIFICATION (08-AFC-10)**

On September 10, 2008, Northern California Power Agency (NCPA) submitted an Application for Certification (AFC) to the California Energy Commission to construct and operate an electrical generating plant in the City of Lodi, San Joaquin County, California. The Lodi Energy Center (LEC) would be a combined-cycle nominal 255-megawatt (MW) power generation facility.

The proposed project would be located on 4.4 acres of land owned and incorporated by the City of Lodi, 6 miles west of the Lodi city center, located near Interstate-5 (I-5) approximately 1.7 miles south of State Route 12. On the east side of the site is the City of Lodi's White Slough Water Pollution Control Facility (WPCF). The WPCF's treatment and holding ponds are located to the north; an existing generating plant (49-MW NCPA Combustion Turbine Project #2) is located to the west with a 230-kV Pacific and Gas Electric overhead electrical transmission line aligned further to the west, and the San Joaquin County Mosquito and Vector Control facility is to the south. The proposed project would also be located near the city of Stockton which is approximately 2 miles south. The project site is currently undeveloped and used for equipment storage during upgrades to the WPCF.

If approved, construction of the project would begin in the first quarter of 2010 and would last for 24 months. Pre-operational testing of the power plant would begin in the fourth quarter with full-scale commercial operation commencing by first quarter 2012.


The Energy Commission's siting process is open to the public and incorporates the input of the public as well as local, state, and federal agencies. To facilitate public participation in our review process, the Energy Commission has sent copies of the AFC to libraries in the project area, and to libraries in Eureka, San Francisco, Sacramento, Fresno, Los Angeles, and San Diego.

Please make the enclosed AFC available for those who may wish to be informed about the project. We request that you not allow the AFC or any of its contents be removed from the library. To increase accessibility of the document, we ask, if possible, that you cross reference it as a general reference work under the title and author categories, as well as under such subjects as "Energy Commission," "electricity," "energy/generation," "power plant siting," or any other relevant subject.

Thank you for your cooperation. If you have any questions, please contact Rod Jones, Energy Commission Project Manager, at (916) 654-5191, or by email at

[rjones@energy.state.ca.us](mailto:rjones@energy.state.ca.us), or April Albright, Project Secretary, at (916) 653-1640, or by e-mail at [AEsau@energy.state.ca.us](mailto:AEsau@energy.state.ca.us).

Sincerely,

A handwritten signature in black ink, appearing to read "Eileen Allen". The signature is fluid and cursive, with the first name "Eileen" written in a larger, more prominent script than the last name "Allen".

Eileen Allen, Manager  
Energy Facilities Siting and Compliance Office

Enclosure

**CALIFORNIA ENERGY COMMISSION**

1516 NINTH STREET  
SACRAMENTO, CA 95814-5512  
www.energy.ca.gov



September 22, 2008

**To: MEMBERS OF THE PUBLIC**

**PUBLIC PARTICIPATION IN THE REVIEW OF THE LODI ENERGY CENTER PROJECT (08-AFC-10)**

On September 10, 2008, Northern California Power Agency (NCPA) submitted an Application for Certification (AFC) to the California Energy Commission to construct and operate an electrical generating plant in the City of Lodi, San Joaquin County, California. The Lodi Energy Center (LEC) would be a combined-cycle nominal 255-megawatt (MW) power generation facility.

**Project Location**

The proposed project would be located on 4.4 acres of land owned and incorporated by the City of Lodi, 6 miles west of the Lodi city center, located near Interstate-5 (I-5) approximately 1.7 miles south of State Route 12. On the east side of the site is the City of Lodi's White Slough Water Pollution Control Facility (WPCF). The WPCF's treatment and holding ponds are located to the north; an existing generating plant (49-MW NCPA Combustion Turbine Project #2) is located to the west with a 230-kV Pacific and Gas Electric overhead electrical transmission line aligned further to the west, and the San Joaquin County Mosquito and Vector Control facility is to the south. The proposed project would also be located near the city of Stockton which is approximately 2 miles south. The project site is currently undeveloped and used for equipment storage during upgrades to the WPCF.

**Project Description**

Highlights of the Project are as follows:

- The proposed project is a 255 MW nominal, natural gas-fired, combined-cycle generating plant with a "Rapid Response" General Electric Frame 7FA combustion turbine-generator (CTG), a single condensing steam turbine generator (STG), a deaerating surface condenser; a 7-cell mechanical draft cooling tower; and associated support equipment.
- The CTG is equipped with an evaporative cooler on the inlet air system and dry low nitrogen oxide (NO<sub>x</sub>) combustors.
- The heat recovery steam generator (HRSG) would be a horizontal, natural circulation type, equipped with duct burners. The emission reduction system includes a selective catalytic reduction (SCR) unit to control nitrogen oxide (NO<sub>x</sub>) stack emissions and an oxidation catalyst to control carbon monoxide (CO) emissions.

- A small auxiliary boiler would provide steam needed to achieve reduced start times through the CTG "Rapid Response" system.
- The LEC would receive recycled water provided by the City of Lodi's WPCF. The project would access this water through an existing 48-inch diameter pipeline in the utility corridor connecting the LEC and the WPCF.
- Cooling tower blowdown water will be disposed of using a new Class I underground injection well (UIW). As a result, no process wastewater would be discharged from the plant.
- A new approximately 520-foot, 230-kilovolt (kV) line would be constructed to transmit the plant output to the electrical grid via the existing 230-kV switchyard adjacent to the existing plant.
- A new 2.5 mile-long gas line would be built parallel to the existing natural gas pipeline for serving NCPA's Combustion Turbine Project #2 (CTP #2) facility; it would provide fuel gas to the site.
- A new onsite potable water well would be built.
- Onsite interconnection to an existing recycled water pipeline and an existing sanitary sewer pipeline would also be included in the proposed project.

**Shared facilities between LEC and the existing plant**

Some of the existing facilities at the existing plant would be shared with the proposed project, most notably the infrastructure:

- The anhydrous ammonia system, including both the 12,000-gallon storage tank and unloading facilities.
- The 230-kilovolt (kV) switchyard and grid interconnection.
- The fire systems, including fire water storage tanks and diesel-fired emergency fire pump.
- The domestic water systems, including eye wash stations and emergency showers.
- An existing Class I UIW (to be used for backup only).

In addition, the following facilities would be modified or built as part of the proposed project and shared with the CTP #2 plant:

- The administration building, including the control room, office space, maintenance shop and communications systems.
- The warehouse facilities.
- The gas metering station for the existing plant would be relocated to accommodate the proposed LEC plant and would be shared by both facilities.
- Note: The commercial cooling tower for the existing plant would be relocated to accommodate the proposed LEC plant, but would not be shared by both facilities.

If approved, construction of the project would begin in the first quarter of 2010 and would last for 24 months. Pre-operational testing of the power plant would begin in the fourth quarter with full-scale commercial operation commencing by first quarter 2012.

### **Energy Commission's Facility Certification Process**

The Energy Commission is responsible for reviewing and ultimately approving or denying applications for all thermal electric power plants, 50 MW and greater, proposed for construction in California. The Energy Commission's facility certification process carefully examines public health and safety, environmental impacts and engineering aspects of proposed power plants and all related facilities such as electric transmission lines and natural gas and water pipelines. The Energy Commission is the lead agency under the California Environmental Quality Act (CEQA), but through its certified regulatory program produces several environmental and decision documents rather than an Environmental Impact Report.

As part of our review process, the staff of the Energy Commission works closely with local, state and federal agencies to ensure that all laws, ordinances, regulations and standards are addressed in the final decision of the California Energy Commission. The first step in the review process is for the Energy Commission staff to determine whether or not the AFC contains all the information required by our regulations. When the AFC is deemed data adequate, we will begin the data discovery and issue analysis phases. At that time a detailed examination of the issues will occur.

### **Public Participation**

Over the coming months, the Energy Commission will conduct a number of public workshops and hearings to determine whether the proposed project should be approved for construction and operation and under what set of conditions. The workshops will provide the public as well as local, state and federal agencies the opportunity to participate in reviewing the proposed project. The Energy Commission will issue notices for these workshops and hearings at least ten days prior to the meeting. If you are not currently receiving these notices and want to be placed on the mailing list, please contact April Albright, Project Secretary, at (916) 653-1640, or by email at [AEsau@energy.state.ca.us](mailto:AEsau@energy.state.ca.us).

September 22, 2008

Page 4

If you desire information about participating in the Energy Commission's review of the proposed project, please contact Elena Miller, the Energy Commission's Public Adviser, at (916) 654-4489, or toll free in California at (800) 822-6228, or by email at [pao@energy.state.ca.us](mailto:pao@energy.state.ca.us). Technical or project schedule questions should be directed to Rod Jones, Energy Commission Project Manager, at (916) 654-5191 or by email at [rjones@energy.state.ca.us](mailto:rjones@energy.state.ca.us).

**Note: Please retain this letter behind the front cover of the AFC. Thank You.**