

From: "Margaret Lagorio [EH]" <MLagorio@sjcehd.com>
To: <rjones@energy.state.ca.us>
Date: 9/30/2008 9:21 AM
Subject: The Lodi Energy Center Project (08-AFC-10)

Mr. Jones,

The San Joaquin County Ordinance Code requires that permits be obtained from the San Joaquin County Environmental Health Department (EHD) for installation of any wells in the County. The construction of the wells must meet the San Joaquin County Well Standards as well as the California Well Standards. Therefore, the proposed Class 1 underground injection well (UIW) and the new potable water well must be installed under permit and inspection of the EHD. The EHD has been in contact with USEPA on requirements for the UIW. Please continue to keep our agency informed on this project. Thank you.

Margaret Lagorio, REHS
Program Coordinator Unit IV
600 E. Main Street
Stockton, CA 95202
(209) 468-3449

DOCKET 08-AFC-10
DATE <u>SEP 30 2008</u>
RECD. <u>OCT 01 2008</u>