



**San Joaquin County
Environmental Health Department
600 East Main Street
Stockton, California 95202-3029**

DIRECTOR
Donna Heran, REHS

PROGRAM COORDINATORS
Robert McClellon, REHS
Jeff Carruesco, REHS, RDI
Kasey Foley, REHS

**Website: www.sjgov.org/ehd
Phone: (209) 468-3420
Fax: (209) 464-0138**

January 22, 2010

DOCKET	
08-AFC-10	
DATE	JAN 22 2010
RECD.	JAN 22 2010

Rod Jones, LEC Project Manager
California Energy Commission
1516 Ninth Street
Sacramento, CA 95814-5512

Subject: Lodi Energy Center Project Order Docket No. 08-AFC-10

The San Joaquin County Environmental Health Department (EHD) is supportive of this project in regards to the provision of full public services. The EHD requests the following comments be added to the above project for consideration:

1. Construct a water well under permit and inspection of the EHD prior to occupancy. Should the number of non-resident individuals exceed 24 for at least 60 days per year, or the number of service connections exceeds four, a yearly permit to operate a public water system will be required by the EHD (San Joaquin County Development Title, Section 9-1120.2 and 9-1115.9.).

The supplier must possess adequate financial, managerial, and technical capability to assure delivery of pure, wholesome, and potable drinking water in accordance with San Joaquin County Development Title, Sections 9-1120.2 and 9-1115.9 and C.C.R., Title 22, and Health and Safety Code, Section 116525 through 116570.

2. A reduced pressure backflow device shall be installed to protect the potable water from contamination by the tertiary treated recycled water, if the two distribution systems are inter-connected. The device shall be installed, maintained, and tested, as per Title 17 of the California Code of Regulations.
3. Plant primary on-site waste/wash water to be collected and/or stored in underground storage tanks or sumps, shall be subject to permit and inspection by the EHD. Submittal of three (3) sets of detailed underground storage tank plans to the EHD for review and approval prior to beginning construction. A review fee of \$840 is required at the time of submittal.
4. If hazardous material(s) is stored on site, applicant must register with San Joaquin County Office of Emergency Services.
5. If any quantity of hazardous waste is generated, a hazardous waste generator permit must be obtained from the Environmental Health Department. The applicant must also obtain an EPA Identification Number, and comply with all applicable regulations.

If you have any questions, please contact me, at (209) 468-0331.

Rodney Estrada, REHS
Lead Senior

RE:ej