

DOCKETED

Docket Number:	09-AFC-08C
Project Title:	Genesis Solar Energy Project
TN #:	206940
Document Title:	Genesis Solar, LLC's Petition to Amend for Spare Main GSU Transformer
Description:	Petition to Amend (PTA) for Genesis Solar Energy Project (GSEP) to store spare main transformer on site
Filer:	Eric Veerkamp
Organization:	Nextera Energy Resources
Submitter Role:	Applicant
Submission Date:	12/11/2015 4:06:16 PM
Docketed Date:	12/11/2015



November 18, 2015

Genesis Solar, LLC
11995 Wiley's Well Road
Blythe, CA 92225

California Energy Commission
Compliance Project Manager
1516 9th Street, MS 2000
Sacramento, California 95814

RE: Request for Spare GSU Transformer for Genesis Solar, LLC.

Dear Mr. Veerkamp:

Genesis Solar, LLC is requesting a review of the attached information to install a spare GSU Transformer on site. Our proposal is to install the spare transformer on site to eliminate long lead and transit time and prevent the plant from producing expected power to the customer due to delays. We submit that having this spare unit on site will increase plant reliability and expected electrical power to the customer. Please contact me with any questions.

Thank you,

Charlyn Mosley

Charlyn Mosley
SR PGD Environmental Specialist



November 17, 2015

Eric Veerkamp
California Energy Commission
Siting, Transmission & Environmental Protection Division
1516 Ninth Street, MS-2000
Sacramento, CA 95814-5515

Dear Mr. Veerkamp,

The Genesis Solar, LLC facility operates under Conditions of Certification from the California Energy Commission (CEC). This submittal is intended to support the CEC's review and approval of the proposed modification and CEC's determination of whether any changes to our Conditions of Certification are necessary as the Genesis Solar, LLC facility request the addition to facilitate a spare transformer on site. Pursuant to Section 1769 please review the following statements that address the statutes of said section.

A request for an amendment to the Conditions of Certification for Genesis Solar, LLC (09-AFC-8) located at 11995 Wiley's Well Road, Blythe, CA 92225 follows,

1. (1.a) Description of the proposed modification: NextEra Energy is proposing to construct a foundation and containment structure for storage of a spare main power transformer to be located at the North end of the Well "O" area in the commons. In order to improve the plants' reliability we are purchasing a spare main transformer to be ready and available on site in the event of failure of one of the existing main power transformers. This would allow us to minimize any plant downtime in the event of such a failure. The foundation and containment structure will be approximately 34' X 30' in size and will include lightning protection as well as connection to the existing grounding grid. The foundation and containment structure would be constructed in compliance with existing laws, ordinances, regulations and statutes. As per the attached excerpt of Section 1769, this corresponds to Item 1.A under project modifications.
2. (1.b) As per the excerpt of section 1769, item1.B, this request is to approve this minor amendment respectfully as expeditiously as is possible to allow for final containment design work and construction to be completed prior to the expected transformer delivery in the 4rd Quarter 2015. All applicable permits will be obtained for this project.
3. (1.c) As per the excerpt of Section 1769, item 1.C, proposed modifications based on information not available prior to certification: The modification is based on information that was not available at the time of certification. Plans to acquire a spare main transformer were not included in the planning stages of the pre-operations/post operations discussions.
4. (1.d) To ensure reliability and reduce down time, which would affect the consumers, this equipment is vital for the customer supply in the event a power outage occurs due to main transformer failure. The lead time and transportation time to ship a backup transformer to our

- facility would take weeks. Equipping the site with a backup main transformer eliminates lead time and increases site efficiency during critical transformer failure.
5. (1.e) Environmental Impacts; The proposed project will not result in any significant adverse environmental impacts. No mitigation will be required since there will be no additional environmental impact.
- A) Air quality:** minimal short-term air quality impacts are possible during construction of the foundations, power and control electrical wiring. Minor dust emissions and vehicle exhaust are possible. NextEra Energy will mitigate dust emissions using standard dust control practices, including watering. Further, our practice is to ensure that minimal vehicle idling occurs, thereby minimizing vehicle exhaust. Furthermore, all equipment used on site is required to be in proper working order, including properly tuned engines. We believe these measures, coupled with the short-term nature of the construction, will result in air emissions that are not significant.
- B) Noise:** No significant noise impacts will result from the proposed project. Based on our knowledge of practices for construction of this type, no activities associated with the project have the potential to generate significant noise levels at or beyond the facility boundary.
- C) Cultural resources:** No adverse impacts on cultural resources (archeological or paleontological) will result from the proposed project. During CEC review of the original project, a complete paleontological survey was conducted on the proposed site. The supporting documentation is available in the project files on site if necessary. No cultural resources were identified within the area of the proposed project location. Furthermore, excavation, grading and other construction activities in the vicinity of the currently proposed project were carried out during the original construction of the project. Therefore, the area has already been disturbed, and no cultural resources were discovered during construction of the existing plant.
- D) Biological resources:** No adverse impacts on biological resources will result from the proposed project. During CEC review of the original project a complete biological survey was conducted on the overall project. As part of our normal contractor orientation program, NextEra Energy awareness training and information on the possible presence and the proper response to wildlife sightings, per our existing Conditions of Certification.
- E) Visual impacts:** No significant adverse visual impacts will result from the proposed project. The construction is in a location that is shielded visually by other existing structures and equipment at the site, minimizing incremental visual impacts and rendering the proposed project insignificant with regard to the existing project profile.
- F) Hazardous materials:** The proposed project will not result in any potential adverse environmental impacts associated with hazardous materials use. The transformer will contain oil but will not be energized except for low voltage for periodic cycling of cooling fans. The containment will be designed to comply with all spill containment requirements, will be inspected daily and will have provisions for removal of any rainwater accumulation.
- G) Water Resources:** The proposed project will not result in any significant adverse impact to water resources.
6. (1.f) All applicable laws, ordinances, regulations and standards will be adhered to. Proper applications, fees and certifications will be obtained prior to construction.


7. Socioeconomics: The daily local work force will average 10 for the construction of the foundation and containment for a period of approximately one week. Additionally, there will be a crew of approximately 10 people to unload and set the transformer on the foundation over a period of two days. The project is currently out for bid to local companies. These companies generally utilize the local labor force from Riverside County to include the city of Blythe and surrounding area.
8. Transportation: For the foundation and containment structure, about 4 trucks will be used to haul concrete and rebar for foundations across a period of one week and about 3 trucks and one large capacity crane will set the transformer on the foundation during a period of two days. This will have little adverse impact to traffic. The Transformer will be transported from SEGS, in the high desert by Performance Transport. The dimensions of the haul are 16' 1" on the trailer, taking one (1) day to transport. Performance Transport will accommodate the permits, pilots and any other incidentals for the haul.
9. (1.g and h)Effect on the public: This minor amendment will not affect the public since this change does not change the operation of the facility. Per excerpt 1.I and 1.F, Genesis Solar, LLC's location has no residences, schools or farmlands within 20 miles of the site boundaries. Due the remote location of the site, there are no potential effects to the public. Consistent with the overall intent of the Decision, the proposed modification is a minor amendment to the original Certification of Conditions and is consistent with the overall intent of the Decision. The property surrounding the area is owned by the BLM.

Should you have any questions or require additional information please contact me at (760) 921-1401, or (760) 831-2651.

Respectfully,

Charlyn Mosley

Charlyn Mosley
Sr. PGD Environmental Specialist



REMARKS

1	1	1
2	2	2
3	3	3
4	4	4
5	5	5
6	6	6
7	7	7
8	8	8
9	9	9
10	10	10
11	11	11
12	12	12
13	13	13
14	14	14
15	15	15
16	16	16
17	17	17
18	18	18
19	19	19
20	20	20

TRANSFORMER #2 SITE PREPARATION
GENESIS SOLAR, SON-7209
11985 Minn's Well Road
Blythe, Ca. 92225

FOUNDATION DETAILS

NOT USED

INSTRUMENTS OF SERVICE

DISCLAIMER


DESERT ENGINEERS

GENESIS SOLAR LLC


SPARE 150 MVA TRANSFORMER SITE PREPARATION AND FOUNDATION

SGN-7209

11995 WILEY'S WELL ROAD
BLYTHE, CALIFORNIA 92225



SITE/FACILITY PLAN



VICINITY MAP

SCOPE OF WORK STATEMENT:
THIS APPENDIX CONSIST OF THE FOLLOWING WORK TO BE PERFORMED ACCORDING TO
WORK PLANS AND SPECIFICATIONS. PRIVATE POWER FEED TO NEW TRADE TO 60 MVA
SUBSTATION, 150 MVA SPARE PANEL DESIGN, TRANSFORMER FOUNDATION
DESIGN & CONSTRUCTION.

PROJECT ADDRESS:

11995 WILEY'S WELL ROAD
BLYTHE, CALIFORNIA 92225

OWNER

GENESIS SOLAR LLC
PO BOX 1410
11995 WILEY'S WELL ROAD
BLYTHE, CALIFORNIA 92225
TELEPHONE: (760) 861-1411

ENGINEERING CONTACTS

DESERT ENGINEERS
PO BOX 1410
11995 WILEY'S WELL ROAD
BLYTHE, CALIFORNIA 92225
(760)449-1850
STRUCTURAL ENGINEER - RON PETERS, PE
ELECTRICAL ENGINEER - BRUCE GOTTLIEB, PE
MECHANICAL ENGINEER - JEFFREY HURVITZ, PE

SHEET INDEX

T-1.0	PROJECT TITLE SHEET
	GENERAL NOTES
	FOUNDATION PLANS & DETAILS
	FOUNDATION DETAILS
	DETAIL SCHEDULES AND ONE LINE DRAWINGS
	SITE PLAN - ELECTRICAL

APPLICABLE CODES

THE WORK SHOWN ON THESE DRAWINGS SHALL BE USED FOR CONSTRUCTION.

APPLICABLE CODES
2013 CALIFORNIA BUILDING CODE (CODE) TITLE 24 PART 3
2013 CALIFORNIA ELECTRICAL CODE (CODE) TITLE 24 PART 4
2013 CALIFORNIA MECHANICAL CODE (CODE) TITLE 24 PART 5
2013 CALIFORNIA FIRE CODE (CODE) TITLE 24 PART 9

NO.	REMARKS	DATE




DESERT ENGINEERS
CONTRACT ENGINEERS
GENERAL ELECTRICAL, MECHANICAL, FOUNDATION,
STRUCTURAL, MECHANICAL, ELECTRICAL, PLANT SERVICES
11995 WILEY'S WELL ROAD
BLYTHE, CALIFORNIA 92225
http://deserteng.com

SPARE 150 MVA TRANSFORMER SITE PREPARATION GENESIS SOLAR SGN-7209	
11995 Wiley's Well Road Blythe, Ca. 92225	
DRAWN BY DATE 08/13/15	
SCALE JOB NO. SHEET	
T-1.0 OF SHEET 1	

Dennis
Hurwitz

760-449-1850
FAX 760-449-1851
E-mail: dennis@deserteng.com



B.G. STRUCTURAL ENGINEERING

BRIAN GOTTLIEB - CIVIL ENGINEER - Lic. No. C33047
75-175 Merle Drive, Suite 200
Palm Desert, CA 92211
(760) 568-3553 (760) 568-5681 Fax

Genesis Solar Energy Center - Transformer 2 Foundation

Desert Engineers
75401 Painted Desert Drive
Indian Wells, CA 92210

Job Number: 800.1915

August 12, 2015



VALID ONLY IF SIGNED
IN RED

Dennis
Hurvitz

Digitally signed by Dennis Hurvitz
DN: cn=Dennis Hurvitz, o=Desert
Engineers, ou=Desert Engineers,
email=Dennis@desertengineers.co
m, c=US
Reason: I am the author of this
document
Date: 2015.08.13 10:16:15 -07'00'

Sheet Index

<u>Containment Sump Design & Retaining Wall</u>	1 – 4
<u>Transformer Pad, Pedestal, and Anchorage Design</u>	5 – 19
<u>Electrical Circuit Box Column & Footing Design</u>	20 – 27
<u>Lighting Protection Poles Footing Design & Mfgr Spec Sheets</u>	28 – 32
<u>Small Transformer Anchorage & Footing Design</u>	33 – 38
<u>Bollard Column & Footing Design</u>	39 – 43

Genesis Solar Energy Center

Secondary Containment Calculation
Transformer-2

Containment Sump:

Width = **28.666 ft**
Length = **34.666 ft**
Gross Area = **994 sq ft**
Generator Pedestal Width = **11 ft**
Generator Pedestal Width = **19 ft**
Net Containment Sump Area= **785 sq ft**

Volumes:

Transformer Oil Volume	12,470 gallons	=	1667 cf
24-hour, 25-year storm	170 cf / 1000 sf	=	169 cf
Fire Flow	3 gallons/sq ft	=	399 cf

Total required retention: 110% Oil_Volume + GreatestOf(Rainfall or Fire_Flow)

Total Required Sump Volume = **2232 cf**
Depth of Sump = **2.845 ft.**



B.G Structural Engineering, Inc.
75-175 Merle Drive, Suite 200
Palm Desert, CA 92211
760-568-3553 Voice
760-568-5681 Fax

Project Title: Genesis Solar Energy Center - Transformer #2 2
Engineer: BG
Project Descr: Project ID: 800.1915

Printed: 12 AUG 2015, 4:24PM

File : s:\EC6-DA~1\805ADF~1.EC6

ENERCALC, INC. 1983-2015, Build:6.15.7.30, Ver:6.15.7.30

Licensee : BG STRUCTURAL ENGINEERING INC.

Point Load on Slab

Lic. #: KW-06008402

Description : Containment Slab Check

Code References

Calculations per ACI 318-11, IBC 2012, CBC 2013, ASCE 7-10

Load Combinations Used : IBC 2012

Analytical Values

d - Slab Thickness	12.0 in	Ks - Soil Modulus of Subgrade Reaction	40.0 pci
FS - Reqd Factor of Safety	3.0 : 1	Ec - Concrete Elastic Modulus	3,122.0 ksi
		Fc - Concrete Compressive Strength	4.50 ksi
		ν - Poisson's Ratio	0.150
		ϕ - LRFD Reduction Factor	0.850
		Min. Adjacent Load Distance	87.347 in

Analysis Formulas

$$P_n = 1.72 [(K_s R_1 / E_c) 10,000 + 3.6] F_r d^2$$

K_s = Soil modulus of subgrade reaction

R_1 = 50% plate average dimension = $\sqrt{P_l W_{id} * P_l L_{en}} / 2$

E_c = Concrete elastic modulus

F_r - Concrete modulus of rupture = $7.5 * \sqrt{f'_c}$

d - Slab Thickness

$$\text{Min Adjacent Column Distance} = 1.5 * [E_c d^3 / (12 * (1 - \nu^2) K_s)]^{1/4}$$

E_c = Concrete elastic modulus

d - Slab Thickness

ν - Poisson's ratio

K_s = Soil modulus of subgrade reaction



Load & Capacity Table

Load ID	Applied Concentrated Load on Plate - (kip)						Governing Ld Comb	P_u (kip)	Phi*P_n (kip)	Check
	Plate Wid (in)	Plate Len (in)	R1 (in)	D	Lr	L				
Service Load	24.00	24.00	12.00	4.00		2.00	+1.20D+0.50Lr+1.60L	8.0	544.2	Pass, FS=68.02 >= 3

RetainPro 10 (c) 1987-2014, Build 10.14.8.26
 License : KW-06064200
 License To :

Cantilevered Retaining Wall Design

Code: CBC 2013, ACI 318-11, ACI 530-11

Criteria		Soil Data		
Retained Height	= 0.00 ft	Allow Soil Bearing	= 2,000.0 psf	
Wall height above soil	= 3.00 ft	Equivalent Fluid Pressure Method		
Slope Behind Wall	= 0.00 : 1	Heel Active Pressure	= 35.0 psf/ft	
Height of Soil over Toe	= 6.00 in		=	
Water height over heel	= 0.0 ft	Passive Pressure	= 250.0 psf/ft	
		Soil Density, Heel	= 110.00pcf	
		Soil Density, Toe	= 0.00pcf	
		Footing Soil Friction	= 0.350	
		Soil height to ignore for passive pressure	= 12.00 in	
Surcharge Loads		Lateral Load Applied to Stem		
Surcharge Over Heel	= 0.0 psf	Lateral Load	= 0.0 #/ft	
Used To Resist Sliding & Overturning		...Height to Top	= 0.00 ft	
Surcharge Over Toe	= 0.0 psf	...Height to Bottom	= 0.00 ft	
Used for Sliding & Overturning		The above lateral load has been increased by a factor of	= 1.00	
		Wind on Exposed Stem	= 0.0 psf	
		F_p / W_p Weight Multiplier	= 0.305 g	
		Added seismic base force	= 48.0 lbs	
Axial Load Applied to Stem		Adjacent Footing Load		
Axial Dead Load	= 0.0 lbs	Adjacent Footing Load	= 0.0 lbs	
Axial Live Load	= 0.0 lbs	Footing Width	= 0.00 ft	
Axial Load Eccentricity	= 0.0 in	Eccentricity	= 0.00 in	
Stem Weight Seismic Load		Wall to Ftg CL Dist	= 0.00 ft	
		Footing Type	Line Load	
		Base Above/Below Soil	= 0.0 ft	
		at Back of Wall		
		Poisson's Ratio	= 0.300	
Design Summary		Stem Construction		Top Stem
Wall Stability Ratios		Design Height Above Ftg	ft = 0.00	Stem OK
Overturning	= 4.17 OK	Wall Material Above "H"	= Concrete	
Sliding	= 5.59 OK	Thickness	= 6.00	
Total Bearing Load	= 600 lbs	Rebar Size	= # 4	
...resultant ecc.	= 7.02 in	Rebar Spacing	= 18.00	
Soil Pressure @ Toe	= 601 psf OK	Rebar Placed at	= Center	
Soil Pressure @ Heel	= 0 psf OK			
Allowable	= 2,000 psf			
Soil Pressure Less Than Allowable				
ACI Factored @ Toe	= 722 psf			
ACI Factored @ Heel	= 0 psf			
Footing Shear @ Toe	= 0.0 psi OK			
Footing Shear @ Heel	= 0.4 psi OK			
Allowable	= 75.0 psi			
Sliding Calcs (Vertical Component NOT Used)				
Lateral Sliding Force	= 65.5 lbs			
less 100% Passive Force	= - 156.3 lbs			
less 100% Friction Force	= - 210.0 lbs			
Added Force Req'd	= 0.0 lbs OK			
....for 1.5 : 1 Stability	= 0.0 lbs OK			
Load Factors		Masonry Data		Hook embedment reduced by stress ratio
Building Code	CBC 2013, ACI	f'm	psl =	
Dead Load	1.200	Fs	psl =	
Live Load	1.600	Solid Grouting	=	
Earth, H	1.600			
Wind, W	1.000			
Seismic, E	1.000	Modular Ratio 'n'	=	
		Short Term Factor	=	
		Eqvl. Solid Thick.	=	
		Masonry Block Type	= Medium Weight	
		Masonry Design Method	= ASD	
Concrete Data				
		f'c	psi = 2,500.0	
		Fy	psi = 60,000.0	

RetainPro 10 (c) 1987-2014, Build 10.14.8.26
 License : KW-06054200
 License To :

Cantilevered Retaining Wall Design

Code: CBC 2013, ACI 318-11, ACI 530-11

Footing Dimensions & Strengths

Toe Width	=	0.00 ft
Heel Width	=	2.50
Total Footing Width	=	2.50
Footing Thickness	=	12.00 in
Key Width	=	12.00 in
Key Depth	=	0.00 in
Key Distance from Toe	=	0.92 ft
f'c = 2,500 psi	Fy =	60,000 psi
Footing Concrete Density	=	150.00 pcf
Min. As %	=	0.0018
Cover @ Top	2.00	@ Btm = 3.00 in

Footing Design Results

	Toe	Heel
Factored Pressure	= 722	0 psf
Mu' : Upward	= 0	202 ft#
Mu' : Downward	= 0	360 ft#
Mu: Design	= 0	158 ft#
Actual 1-Way Shear	= 0.00	0.39 psi
Allow 1-Way Shear	= 0.00	75.00 psi
Toe Reinforcing	= None Spec'd	
Heel Reinforcing	= None Spec'd	
Key Reinforcing	= None Spec'd	
Other Acceptable Sizes & Spacings		
Toe: Not req'd, Mu < S * Fr		
Heel: Not req'd, Mu < S * Fr		
Key: Not req'd, Mu < S * Fr		


Summary of Overturning & Resisting Forces & Moments

ItemOVERTURNING.....		RESISTING.....			
	Force lbs	Distance ft	Moment ft-#	Force lbs	Distance ft	Moment ft-#	
Heel Active Pressure	= 17.5	0.33	5.8	Soil Over Heel	= 0.0	1.50	0.0
Surcharge over Heel	=			Sloped Soil Over Heel	=		
Surcharge Over Toe	=			Surcharge Over Heel	=		
Adjacent Footing Load	=			Adjacent Footing Load	=		
Added Lateral Load	=			Axial Dead Load on Stem	=		
Load @ Stem Above Soil	=			* Axial Live Load on Stem	=		
Seismic Stem Self Wt	48.0	2.50	120.1	Soil Over Toe	=		
Total	65.5	O.T.M.	125.9	Surcharge Over Toe	=		
	=	=		Stem Weight(s)	= 225.0	0.25	56.3
Resisting/Overturning Ratio	= 4.17			Earth @ Stem Transitions	=		
Vertical Loads used for Soil Pressure =	600.0	lbs		Footing Weight	= 375.0	1.25	468.8
				Key Weight	=	1.42	
				Vert. Component	=		
				Total = 600.0 lbs R.M.= 525.0			

If seismic is included, the OTM and sliding ratios
 be 1.1 per section 1807.2.3 of IBC 2009 or IBC 201

* Axial live load NOT included in total displayed, or used for overturning resistance, but is included for soil pressure calculation.


Genesis Solar Energy Center
Transformer-2 Foundation and
Containment



<u>WEIGHTS</u>	
TOTAL	326 284 lbs / 148 000 kg
OIL (47 200 litres / 12 470 gallons)	92 590 lbs / 42 000 kg
UNTANKING	143 300 lbs / 65 000 kg
SHIPPING WITHOUT OIL	185 188 lbs / 84 000 kg


Genesis Solar Energy Center
Transformer-2 Foundation and
Containment

BASE DETAIL
(for sliding on greased plates or on rollers)




Genesis Solar Energy Center

Transformer-2 Foundation and Containment




Genesis Solar Energy Center

Transformer-2 Foundation and Containment



Genesis Solar Energy Center
Transformer-2 Foundation and
Containment



Home » Latitude and Longitude of a Point

To find the latitude and longitude of a point Click on the map, Drag the marker, or enter the...

 Address:

Map Center: [Get Address](#) - [Land Plat Size](#) - [Street View](#) - [Area Photographs](#)

Try out 3D Google Earth. Google Earth gives you a 3D look of the area around the center of the map, which is usually your last click point, and includes latitude, longitude and elevation information.

Latitude and Longitude of a Point



<input type="button" value="Clear / Reset"/> <input type="button" value="Remove Last Blue Marker"/> <input type="button" value="Center Red Marker"/>	<p>Show Point from Latitude and Longitude</p> <p>Use this if you know the latitude and longitude coordinates of a point and want to see where on the map the point is.</p> <p>Use: + for N Lat or E Long - for S Lat or W Long.</p> <p>Example: +40.689060 -74.044636</p> <p>Note: Your entry should not have any embedded spaces.</p> <p>Decimal Deg. Latitude: <input type="text"/></p> <p>Decimal Deg. Longitude: <input type="text"/></p> <p><input type="button" value="Show Point"/></p> <hr/> <p>Example: +34 40 50.12 for 34N 40' 50.12"</p> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 33%;">Latitude:</td> <td style="width: 33%; text-align: center;">Degrees <input type="text"/></td> <td style="width: 33%; text-align: center;">Minutes <input type="text"/></td> </tr> <tr> <td>Longitude:</td> <td style="text-align: center;">Seconds <input type="text"/></td> <td style="text-align: center;">Degrees <input type="text"/></td> </tr> <tr> <td></td> <td style="text-align: center;">Minutes <input type="text"/></td> <td style="text-align: center;">Seconds <input type="text"/></td> </tr> </table> <p><input type="button" value="Show Point"/></p>	Latitude:	Degrees <input type="text"/>	Minutes <input type="text"/>	Longitude:	Seconds <input type="text"/>	Degrees <input type="text"/>		Minutes <input type="text"/>	Seconds <input type="text"/>
Latitude:	Degrees <input type="text"/>	Minutes <input type="text"/>								
Longitude:	Seconds <input type="text"/>	Degrees <input type="text"/>								
	Minutes <input type="text"/>	Seconds <input type="text"/>								

USGS Design Maps Summary Report

User-Specified Input


Report Title Genesis Solar Project

Building Code Reference Document ASCE 7-10 Standard
(which utilizes USGS hazard data available in 2008)

Site Coordinates 33.66627°N, 114.99633°W

Site Soil Classification Site Class C – "Very Dense Soil and Soft Rock"



Risk Category IV (e.g. essential facilities)



USGS-Provided Output

$$\begin{array}{lll} S_s = 0.534 \text{ g} & S_{Ms} = 0.634 \text{ g} & S_{Ds} = 0.423 \text{ g} \\ S_1 = 0.252 \text{ g} & S_{M1} = 0.390 \text{ g} & S_{D1} = 0.260 \text{ g} \end{array}$$

For information on how the SS and S1 values above have been calculated from probabilistic (risk-targeted) and deterministic ground motions in the direction of maximum horizontal response, please return to the application and select the "2009 NEHRP" building code reference document.



For PGA_M , T_L , C_{RS} , and C_{RL} values, please [view the detailed report](#).

Equipment Forces

2013 CBC

Seismic Forces:

$$F_p = ((0.4a_p S_{DS} I_p)/R_p) * (1+2z/h) * W_p$$

Per ASCE7-10 Eq. 13.3-1

$$F_{p\min} = 0.3 S_{DS} I_p W_p$$

Per ASCE7-10 Eq. 13.3-3

$$F_{p\max} = 1.6 S_{DS} I_p W_p$$

Per ASCE7-10 Eq. 13.3-2

$$S_{DS} = \mathbf{0.423}$$

$$F_p \min = 0.190 W_p$$

$$I_p = 1.50$$

$$F_p \max = 1.015 W_p$$

Unit = Transformer

$$W_p = 326,284 \text{ lbs.}$$

$$z = 3 \text{ ft.}$$

$$h = 3 \text{ ft.}$$

$$a_p = 1.0$$

$$R_p = 2.5$$

$$F_p = 0.305 W_p$$

$$F_p \text{ WSD} = 0.218 W_p$$

$$F_p \text{ WSD} = 70,981 \text{ lbs.}$$

$$h = 7.217 \text{ ft.}$$

$$d = 8.858 \text{ ft.}$$

$$\text{Seismic OTM} = 512,244 \text{ 'lbs.}$$

$$\text{RM} = 1,445,166 \text{ 'lbs.}$$

$$\text{Seismic F.S.} = \mathbf{2.82}$$

$$\text{Net uplift} = -105,316 \text{ lbs. } \underline{\text{No net uplift}}$$

$$\text{Net Shear} = 70,981 \text{ lbs.}$$

$$\# \text{ of anchors per side} = 2$$

$$\text{Shear per Anchor group} = 35,490 \text{ lbs. } 49,687 \text{ 'lbs. (Strength level force)}$$

USE: (2)-1-1/2" Ø F1554 (105 ksi) threaded rod anchors at each corner
 (with 24" min. embedment, typical)

Genesis Solar Energy Center

Transformer-2 Foundation and
Containment

Transformer Footing Design

Transformer design wgt. = 326,284 lbs.

Seismic coeff.= 0.218

Transformer Seismic Shear = 70.98 K

H (C.G.) = 10.217 ft

Pedestal Height = 3 ft.

Pedestal width = 11 ft.

Pedestal length = 19 ft.

Pedestal volume = 627.00 cf

Pedestal wgt. = 94,050 lbs.

Seismic coeff.= 0.218

Pedestal Seismic Shear = 20.46 K

H (C.G.) = 1.500 ft

Total weight = 420,334 lbs.

Total Seismic Shear = 91.44 K

Moment about pedestal base= 755.9 K-ft.

(See attached footing analysis and Design calculations)


**Company : BG Structural Engineering
Designer : KDC
Job Number : 800.1915**

Pedestal Footing -Biaxial


July 29, 2015

Checked By: _____


Sketch



Details



Bottom Rebar Plan



Pedestal Rebar Plan

Geometry, Materials and Criteria

Length	: 25 ft	eX : 0 in	Gross Allow. Bearing	: 3000 psf (gross)	Steel fy	: 60 ksi
Width	: 17 ft	eZ : 0 in	Concrete Weight	: 145 pcf	Minimum Steel	: .0018
Thickness	: 30 in	pX : 132 in	Concrete f'c	: 4.5 ksi	Maximum Steel	: .0075
Height	: 36 in	pZ : 228 in	Design Code	: ACI 318-05		
Footing Top Bar Cover	: 3.5 in	Overturning Safety Factor	: 1.5	Phi for Flexure	: 0.9	
Footing Bottom Bar Cover	: 3.5 in	Coefficient of Friction	: 0.35	Phi for Shear	: 0.75	
Pedestal Longitudinal Bar Cover	: 1.5 in	Passive Resistance of Soil	: 25 k	Phi for Bearing	: 0.65	

Company : BG Structural Engineering
 Designer : KDC
 Job Number : 800.1915

July 29, 2015

Pedestal Footing -Biaxial

Checked By: _____

Loads

	P (k)	Vx (k)	Vz (k)	Mx (k-ft)	Mz (k-ft)	Overburden (psf)
DL	420.334					0
EL		91.44	91.44	-755.9	755.9	



+P
A



+Vx
D



+Vz
C



+Mx
D C



+Mz
A D




+Over

Soil Bearing

Description	Categories and Factors	Gross Allow.(psf)	Max Bearing (psf)	Max/Allowable Ratio
ASCE 2.4.1-1	1DL	3000	1565.44 (A)	.522
ASCE 2.4.1-2	1DL+1LL	3000	1565.44 (A)	.522
ASCE 2.4.1-3a	1DL+1WL	3000	1565.44 (A)	.522
ASCE 2.4.1-3b	1DL+.7EL	3000	2794.81 (A)	.932
ASCE 2.4.1-3c	1DL+.75LL+.75WL	3000	1565.44 (A)	.522
ASCE 2.4.1-3d	1DL+.75LL+.7EL	3000	2794.81 (A)	.932
ASCE 2.4.1-4	.6DL+1WL	3000	939.263 (A)	.313
ASCE 2.4.1-5	.6DL+.7EL	3000	2182.75 (A)	.728



1DL	1DL+1LL	1DL+1WL	1DL+.7EL
QA: 1565.44 psf	QA: 1565.44 psf	QA: 1565.44 psf	QA: 2794.81 psf
QB: 1565.44 psf	QB: 1565.44 psf	QB: 1565.44 psf	QB: 1799.61 psf
QC: 1565.44 psf	QC: 1565.44 psf	QC: 1565.44 psf	QC: 336.064 psf
QD: 1565.44 psf	QD: 1565.44 psf	QD: 1565.44 psf	QD: 1331.27 psf
NAZ: -1 in	NAZ: -1 in	NAZ: -1 in	NAZ: 842.481 in
NAX: -1 in	NAX: -1 in	NAX: -1 in	NAX: 389.563 in



1DL+.75LL+.7EL	.6DL+1WL	.6DL+.7EL
QA: 2794.81 psf	QA: 939.263 psf	QA: 2182.75 psf
QB: 1799.61 psf	QB: 939.263 psf	QB: 1170.58 psf
QC: 336.064 psf	QC: 939.263 psf	QC: 0 psf
QD: 1331.27 psf	QD: 939.263 psf	QD: 701.269 psf
NAZ: 842.481 in	NAZ: -1 in	NAZ: 646.95 in
NAX: 389.563 in	NAX: -1 in	NAX: 300.565 in

Footing Flexure Design (Bottom Bars)

Description	Categories and Factors	Mu-XX (k-ft)	Z Dir As (in ²)	Mu-ZZ (k-ft)	X Dir As (in ²)
ACI-99 9-1	1.4DL+1.7LL	128.835	1.1	189.463	1.618
ACI-99 9-2	1.05DL+1.275LL+1.275WL	96.626	.825	142.097	1.213
ACI-99 9-3	.9DL+1.3WL	82.822	.707	121.798	1.04
IBC 16-5	1.2DL+1LL+1EL	160.46	1.371	266.167	2.275
IBC 16-6	.9DL+1EL	133.14	1.137	225.993	1.931

Company : BG Structural Engineering
 Designer : KDC
 Job Number : 800.1915

July 29, 2015

Pedestal Footing -Biaxial

Checked By: _____

Footing Shear Check

Two Way (Punching) Vc: 4704.74 k One Way (X Dir. Cut) Vc 713.317 k One Way (Z Dir. Cut) Vc: 1049 k

Description	Categories and Factors	Punching		X Dir. Cut		Z Dir. Cut	
		Vu(k)	Vu/Vc	Vu(k)	Vu/Vc	Vu(k)	Vu/Vc
ACI-99 9-1	1.4DL+1.7LL	246.094	.07	23.709	.044	34.866	.044
ACI-99 9-2	1.05DL+1.275LL+1.275WL	184.571	.052	17.782	.033	26.15	.033
ACI-99 9-3	.9DL+1.3WL	158.203	.045	15.242	.028	22.414	.028
IBC 16-5	1.2DL+1LL+1EL	210.938	.06	29.998	.056	50.474	.064
IBC 16-6	.9DL+1EL	158.947	.045	24.975	.047	43.091	.055

Pedestal Design

Shear Check Results (Envelope):

Shear Along X Direction Vc: 3963.24 k Vs: 476.991 k Vu: 91.44 k Vu/Vc: .027 Ø: .75
Shear Along Z Direction Vc: 3994.63 k Vs: 830.42 k Vu: 91.44 k Vu/Vc: .025

Pedestal Ties: #5 @ 10 in

Bending Check Results (Envelope):

Phi :.9	Parame Beta :.65
Pu :0 k Mux :-1030.22 k-ft	Muz: 1030.22 k-ft
Pn :0 k Mnz :1144.69 k-ft	Mnz: 1144.69 k-ft
Mnox:699.048 k-ft	Mnoz :404.712 k-ft
Pedestal Bars: #5 % Steel: .004	

Compression Development Length Pedestal Bars (Envelope):

Lreq.: 11.25 in Lpro.: 24.125 in Lreq./Lpro.: .466

Concrete Bearing Check (Vertical Loads Only)

Bearing Bc : 164158 k

Description	Categories and Factors	Bearing Bu (k)	Bearing Bu/Vc
ACI-99 9-1	1.4DL+1.7LL	931.436	.009
ACI-99 9-2	1.05DL+1.275LL+1.275WL	698.577	.007
ACI-99 9-3	.9DL+1.3WL	598.78	.006
IBC 16-5	1.2DL+1LL+1EL	798.374	.007
IBC 16-6	.9DL+1EL	598.78	.006

Overturning Check (Service)

Description	Categories and Factors	Mo-XX (k-ft)	Ms-XX (k-ft)	Mo-ZZ (k-ft)	Ms-ZZ (k-ft)	OSF-XX	OSF-ZZ
ASCE 2.4.1-1	1DL	0	8316.39	0	5655.15	NA	NA
ASCE 2.4.1-2	1DL+1LL	0	8316.39	0	5655.15	NA	NA
ASCE 2.4.1-3a	1DL+1WL	0	8316.39	0	5655.15	NA	NA
ASCE 2.4.1-3b	1DL+.7EL	881.174	8316.39	881.174	5655.15	9.438	6.418
ASCE 2.4.1-3c	1DL+.75LL+.75WL	0	8316.39	0	5655.15	NA	NA
ASCE 2.4.1-3d	1DL+.75LL+.7EL	881.174	8316.39	881.174	5655.15	9.438	6.418
ASCE 2.4.1-4	.6DL+1WL	0	4989.84	0	3393.09	NA	NA
ASCE 2.4.1-5	.6DL+.7EL	881.174	4989.84	881.174	3393.09	5.663	3.851

Mo-XX: Governing Overturning Moment about AD or BC

Ms-XX: Governing Stabilizing Moment about AD or BC

OSF-XX: Ratio of Ms-XX to Mo-XX

Company : BG Structural Engineering
 Designer : KDC
 Job Number : 800.1915

Pedestal Footing -Biaxial

July 29, 2015

Checked By: _____


Sliding Check (Service)

Description	Categories and Factors	Va-XX (k)	Vr-XX (k)	Va-ZZ (k)	Vr-ZZ (k)	SR-XX	SR-ZZ
ASCE 2.4.1-1	1DL	0	233.109	0	233.109	NA	NA
ASCE 2.4.1-2	1DL+1LL	0	233.109	0	233.109	NA	NA
ASCE 2.4.1-3a	1DL+1WL	0	233.109	0	233.109	NA	NA
ASCE 2.4.1-3b	1DL+.7EL	64.008	233.109	64.008	233.109	3.642	3.642
ASCE 2.4.1-3c	1DL+.75LL+.75WL	0	233.109	0	233.109	NA	NA
ASCE 2.4.1-3d	1DL+.75LL+.7EL	64.008	233.109	64.008	233.109	3.642	3.642
ASCE 2.4.1-4	.6DL+1WL	0	139.965	0	139.965	NA	NA
ASCE 2.4.1-5	.6DL+.7EL	64.008	139.965	64.008	139.965	2.187	2.187

Va-XX: Applied Lateral Force to Cause Sliding Along XX Axis

Vr-XX: Resisting Lateral Force Against Sliding Along XX Axis

SR-XX: Ratio of Vr-XX to Va-XX

Untitled Calculation - Click to Edit		ACI Appendix D - Anchorage to Concrete
Model		
Anchor Bolt 1-1/2" Threaded Rod Square $f_{uta} = 105.00$ ksi Embed Depth 24" Anchors Welded to Base Plate	Concrete ACI Chapter 9 $f'c = 4.50$ ksi thickness = 36" Seismic Provisions Apply	Loads Tension = 0.00 kips Shear X = 49.70 kips Shear Y = 49.70 kips
Tension Steel Bars Cross Failure Plane (D.5.2.9)	Shear X Steel No. 4 or greater between anchor and edge (D.6.2.7)	Shear Y Steel No. 4 or greater between anchor and edge (D.6.2.7)
 <p>Drawing Not to Scale</p>		
<input checked="" type="checkbox"/> Design OK		X Interaction = 0.25 Y Interaction = 0.40
<input checked="" type="checkbox"/> Tensile Capacity $\phi P_n = 101$ kips <i>Breakout Controls</i>		<input checked="" type="checkbox"/> Shear X Capacity $\phi V_{nx} = 115$ kips <i>Bolt Shear Controls</i>
<input checked="" type="checkbox"/> Shear Y Capacity $\phi V_{ny} = 86.1$ kips <i>Breakout Controls</i>		

Tension Calcs**Bolt Tension (D.5.1) = 222 kips**

$$\begin{aligned}\phi N_{sa} &= \phi n A_{se} f_{uta} \\ \phi &= 0.75, n = 2, A_{se} = 1.41 \text{ in}^2 \\ f_{uta} &= 105 \text{ ksi}\end{aligned}$$

Concrete Breakout (D.5.2) = 101 kips

$$\begin{aligned}\phi N_{cb} &= \phi A_{nc}/A_{co} \psi_{ec} \psi_{ed} \psi_c \psi_{cp} N_b \\ \phi &= 0.7, A_{nc} = 5.38e+3 \text{ in}^2, A_{co} = 5.18e+3 \text{ in}^2 \\ \psi_{ec} &= 1.0, \psi_{ed} = 0.867, \psi_c = 1.0 \\ \psi_{cp} &= 1.0, N_b = 214 \text{ kips}, h_{ef} = 24.0 \text{ in}, k_c = 24\end{aligned}$$

Pullout (D.5.3) = 125 kips

$$\begin{aligned}\phi N_{pn} &= \phi \psi_c N_p \\ \phi &= 0.7, \psi_c = 1.0, N_p = 119 \text{ kips} \\ A_{brg} &= 3.295 \text{ in}^2\end{aligned}$$

Side-Face Blowout (D.5.4) = N/A

$$\begin{aligned}\phi N_{sb} &= \phi (1+s/(6 c_{a1})) 160 c_{a1} \sqrt{A_{rg} f_c} \\ \phi &= 0.7, c_{a1} = 20.0\end{aligned}$$

Shear Calcs**X-Direction****Bolt Shear (D.6.1) = 115 kips**

$$\begin{aligned}\phi V_{sa} &= \phi n A_{se} f_{uta} \\ \phi &= 0.65, n = 2, A_{se} = 1.41 \text{ in}^2 \\ f_{uta} &= 105 \text{ ksi}\end{aligned}$$

Y-Direction**Bolt Shear (D.6.1) = 115 kips**

$$\begin{aligned}\phi V_{sa} &= \phi n A_{se} f_{uta} \\ \phi &= 0.65, n = 2, A_{se} = 1.41 \text{ in}^2 \\ f_{uta} &= 105 \text{ ksi}\end{aligned}$$

Concrete Breakout (D.6.2) = 153 kips

$$\begin{aligned}\phi V_{cb} &= \phi A_{vc}/A_{co} \psi_{ec} \psi_{ed} \psi_c V_b \\ \phi &= 0.7, A_{vc} = 4.18e+3 \text{ in}^2, A_{co} = 6.48e+4 \text{ in}^2 \\ \psi_{ec} &= 1.0, \psi_{ed} = 0.733, \psi_c = 1.0 \\ \psi_h &= 1.0, V_b = 1.15e+3 \text{ kips}, c_{a1} = 120 \text{ in}\end{aligned}$$

Concrete Breakout (D.6.2) = 86.1 kips

$$\begin{aligned}\phi V_{cb} &= \phi A_{vc}/A_{co} \psi_{ec} \psi_{ed} \psi_c V_b \\ \phi &= 0.7, A_{vc} = 3.46e+3 \text{ in}^2, A_{co} = 2.59e+3 \text{ in}^2 \\ \psi_{ec} &= 1.0, \psi_{ed} = 1.00, \psi_c = 1.0 \\ \psi_{sh} &= 1.0, V_b = 102 \text{ kips}, c_{a1} = 24.0 \text{ in}\end{aligned}$$

Concrete Pryout (D.6.3) = 202 kips

$$\begin{aligned}\phi V_{cp} &= \phi k_{cp} N_{cb} \\ \phi &= 0.7, k_{cp} = 2.00\end{aligned}$$

Concrete Pryout (D.6.3) = 202 kips

$$\begin{aligned}\phi V_{cp} &= \phi k_{cp} N_{cb} \\ \phi &= 0.7, k_{cp} = 2.00\end{aligned}$$

PROJECT	Genesis Solar Energy Ctr Transformer #2 Foundation
ITEM	Column For Electrical Boxes

B.G. STRUCTURAL ENGINEERING

SHEET NO.	20
JOB NO.	800.1915
DATE	Aug. 2015
ENGINEER	BG

Column / Foundation Design

WIND SPEED = 160 PSF (EXPOSURE C @ 127 MPH)

ELECTRICAL CIRCUIT BOXES (DEAD LOAD)

LARGE CIRCUIT BOX : 40# +/- 40# GOVERNS
SMALL CIRCUIT BOX : 21# +/- 21# DEAD


WIND LOAD

GOVERNING AREA : 2'-0" x 2'-0" (LARGE CIRCUIT BOX)

$$P_{WIND} = (160 \text{ PSF}) (2') (2') = 64 \text{#} \approx \text{GOVERN'S } P_{WIND}$$


$$\rightarrow P_{DEAD} = 40 \text{#} \text{ @ 4 ANCHOR POINTS}$$

$$\rightarrow P_{WIND} = 64 \text{#} \text{ @ 4 ANCHOR POINTS}$$



\rightarrow SE HSS 2.875 x 0.250
PIPE COLUMN

\rightarrow SE 16" Ø x 3'-0" DEEP
CONC FTG w/ (4) #4 VERT
#3 TIES @ 8' OC



B.G Structural Engineering, Inc.
75-175 Merle Drive, Suite 200
Palm Desert, CA 92211
760-568-3553 Voice
760-568-5681 Fax

Project Title: Genesis Solar Energy Center - Transformer #2 21
Engineer: BG
Project Descr:
Project ID: 800.1915

Printed: 6 AUG 2015, 8:54AM

File = s:\EC6-DA-1\805\ADF-1\EC6

ENERCALC, INC. 1983-2015, Build 6.15.7.30, Ver. 6.15.7.30

Licensee : BG STRUCTURAL ENGINEERING INC

Steel Column

Lic. #: KW.06008402

Description : Column C1

Code References

Calculations per AISI 360-10, IBC 2012, CBC 2013, ASCE 7-10

Load Combinations Used : IBC 2012

General Information

Steel Section Name : HSS 2.875x0.250
Analysis Method : Allowable Strength
Steel Stress Grade
Fy : Steel Yield 42.0 ksi
E : Elastic Bending Modulus 29,000.0 ksi
Load Combination : IBC 2012

Overall Column Height 6.50 ft
Top & Bottom Fixity Top Free, Bottom Fixed
Brace condition for deflection (buckling) along columns :
X-X (width) axis : Unbraced Length for X-X Axis buckling = 6.5 ft, K = 2.1
Y-Y (depth) axis : Unbraced Length for Y-Y Axis buckling = 6.5 ft, K = 2.1

Applied Loads

Service loads entered. Load Factors will be applied for calculations.

Column self weight included : 45.60 lbs * Dead Load Factor

AXIAL LOADS . . .

Axial Load at 6.50 ft, D = 0.0250 k

BENDING LOADS . . .

Lat. Point Load at 6.0 ft creating Mx-x, D = 0.0450, W = 0.0450 k

Lat. Point Load at 4.330 ft creating Mx-x, D = 0.0450, W = 0.0450 k

DEFLECTION CHECK:

$$\Delta_{ALL} = 0.025(6.5)(12) = 1.95"$$

$$\Delta_{ALL} = 1.95" \gg \Delta_{ACT} = 0.323" \checkmark OK$$

DESIGN SUMMARY

Bending & Shear Check Results

PASS Max. Axial+Bending Stress Ratio =

0.2214 : 1

Maximum SERVICE Load Reactions ..

Load Combination

+D+0.60W+H

Top along X-X 0.0 k

Location of max.above base

0.0 ft

Bottom along X-X 0.0 k

At maximum location values are ...

Top along Y-Y 0.0 k

Pa : Axial

0.07060 k

Bottom along Y-Y 0.1440 k

Pn / Omega : Allowable

9.513 k

Ma-x : Applied

-0.7438 k-ft

Maximum SERVICE Load Deflections ...

Mn-x / Omega : Allowable

3.416 k-ft

Along Y-Y 0.3225 ln at 6.50ft above base

Ma-y : Applied

0.0 k-ft

for load combination : +D+0.60W+H

Mn-y / Omega : Allowable

3.416 k-ft

Along X-X 0.0 ln at 0.0ft above base

for load combination :

PASS Maximum Shear Stress Ratio =

0.009889 : 1

Load Combination

+D+0.60W+H

Location of max.above base

0.0 ft

At maximum location values are ...

Va : Applied

0.1440 k

Vn / Omega : Allowable

14.562 k

Load Combination Results

Load Combination	Maximum Axial + Bending Stress Ratios			Maximum Shear Ratios		
	Stress Ratio	Status	Location	Stress Ratio	Status	Location
+D+H	0.140	PASS	0.00 ft	0.006	PASS	0.00 ft
+D+L+H	0.140	PASS	0.00 ft	0.006	PASS	0.00 ft
+D+Lr+H	0.140	PASS	0.00 ft	0.006	PASS	0.00 ft
+D+S+H	0.140	PASS	0.00 ft	0.006	PASS	0.00 ft
+D+0.750Lr+0.750L+H	0.140	PASS	0.00 ft	0.006	PASS	0.00 ft
+D+0.750L+0.750S+H	0.140	PASS	0.00 ft	0.006	PASS	0.00 ft
+D+0.60W+H	0.221	PASS	0.00 ft	0.010	PASS	0.00 ft
+D+0.70E+H	0.140	PASS	0.00 ft	0.006	PASS	0.00 ft
+D+0.750Lr+0.750L+0.450W+H	0.201	PASS	0.00 ft	0.009	PASS	0.00 ft
+D+0.750L+0.750S+0.450W+H	0.201	PASS	0.00 ft	0.009	PASS	0.00 ft
+D+0.750L+0.750S+0.5250E+H	0.140	PASS	0.00 ft	0.006	PASS	0.00 ft
+0.60D+0.60W+0.60H	0.166	PASS	0.00 ft	0.007	PASS	0.00 ft
+0.60D+0.70E+0.60H	0.084	PASS	0.00 ft	0.004	PASS	0.00 ft



B.G Structural Engineering, Inc.
75-175 Merle Drive, Suite 200
Palm Desert, CA 92211
760-568-3553 Voice
760-568-5681 Fax

Project Title: Genesis Solar Energy Center - Transformer #2 22
Engineer: BG
Project Descr:

Printed: 5 AUG 2015, 8:54AM

File = s:\EC6-DA-11805ADF-1.EC6

ENERCALC, INC. 1983-2016, Build 6.16.7.30, Ver.6.16.7.30

Licensee : BG STRUCTURAL ENGINEERING INC.

Steel Column

Lic.# : KW_06008402

Description : Column C1

Maximum Reactions

Note: Only non-zero reactions are listed.


Load Combination	X-X Axis Reaction		Y-Y Axis Reaction		Axial Reaction @ Base
	@ Base	@ Top	@ Base	@ Top	
+D+H		k		-0.090	k 0.071 k
+D+L+H		k		-0.090	k 0.071 k
+D+Lr+H		k		-0.090	k 0.071 k
+D+S+H		k		-0.090	k 0.071 k
+D+0.750Lr+0.750L+H		k		-0.090	k 0.071 k
+D+0.750L+0.750S+H		k		-0.090	k 0.071 k
+D+0.60W+H		k		-0.144	k 0.071 k
+D+0.70E+H		k		-0.090	k 0.071 k
+D+0.750Lr+0.750L+0.450W+H		k		-0.131	k 0.071 k
+D+0.750L+0.750S+0.450W+H		k		-0.131	k 0.071 k
+D+0.750L+0.750S+0.5250E+H		k		-0.090	k 0.071 k
+0.60D+0.60W+0.60H		k		-0.108	k 0.042 k
+0.60D+0.70E+0.60H		k		-0.054	k 0.042 k
D Only		k		-0.090	k 0.071 k
Lr Only		k			k
L Only		k			k
S Only		k			k
W Only		k		-0.090	k
E Only		k			k
H Only		k			k

Maximum Deflections for Load Combinations

Load Combination	Max. X-X Deflection		Distance		Max. Y-Y Deflection		Distance	
	in	ft	in	ft	in	ft	in	ft
+D+H	0.0000	in	0.000	ft	0.202	in	6.500	ft
+D+L+H	0.0000	in	0.000	ft	0.202	in	6.500	ft
+D+Lr+H	0.0000	in	0.000	ft	0.202	in	6.500	ft
+D+S+H	0.0000	in	0.000	ft	0.202	in	6.500	ft
+D+0.750Lr+0.750L+H	0.0000	in	0.000	ft	0.202	in	6.500	ft
+D+0.750L+0.750S+H	0.0000	in	0.000	ft	0.202	in	6.500	ft
+D+0.60W+H	0.0000	in	0.000	ft	0.323	in	6.500	ft
+D+0.70E+H	0.0000	in	0.000	ft	0.202	in	6.500	ft
+D+0.750Lr+0.750L+0.450W+H	0.0000	in	0.000	ft	0.292	in	6.500	ft
+D+0.750L+0.750S+0.450W+H	0.0000	in	0.000	ft	0.292	in	6.500	ft
+D+0.750L+0.750S+0.5250E+H	0.0000	in	0.000	ft	0.202	in	6.500	ft
+0.60D+0.60W+0.60H	0.0000	in	0.000	ft	0.242	in	6.500	ft
+0.60D+0.70E+0.60H	0.0000	in	0.000	ft	0.121	in	6.500	ft
D Only	0.0000	in	0.000	ft	0.202	in	6.500	ft
Lr Only	0.0000	in	0.000	ft	0.000	in	0.000	ft
L Only	0.0000	in	0.000	ft	0.000	in	0.000	ft
S Only	0.0000	in	0.000	ft	0.000	in	0.000	ft
W Only	0.0000	in	0.000	ft	0.202	in	6.500	ft
E Only	0.0000	in	0.000	ft	0.000	in	0.000	ft
H Only	0.0000	in	0.000	ft	0.000	in	0.000	ft

Steel Section Properties :

HSS 2.875x0.250



B.G Structural Engineering, Inc.
75-175 Merle Drive, Suite 200
Palm Desert, CA 92211
760-568-3553 Voice
760-568-5681 Fax

Project Title: Genesis Solar Energy Center - Transformer #2 23
Engineer: BG
Project Descr:

Printed: 5 AUG 2015, 8:54AM

File = s:\EC6-DA-1\805ADF-1.EC6

ENERCALC, INC. 1983-2015, Build:6.16.7.30, Ver:6.15.7.30

Licensee : BG STRUCTURAL ENGINEERING INC.



Steel Column

Lic. #: KW-06008402

Description : Column C1

Steel Section Properties : HSS 2.875x0.250

Depth	=	2.875 in	I _{xx}	=	1.70 in ⁴	J	=	3.400 in ⁴
			S _{xx}	=	1.18 in ³			
Diameter	=	2.875 in	R _{xx}	=	0.938 in			
Wall Thick	=	0.250 in	Z _x	=	1.630 in ³			
Area	=	1.930 in ²	I _{yy}	=	1.700 in ⁴	C	=	2.370 in ³
Weight	=	7.015 lbf	S _{yy}	=	1.180 in ³			
			R _{yy}	=	0.938 in			
Y _{cg}	=	0.000 in						



Loads are total entered value. Arrows do not reflect absolute direction.



B.G Structural Engineering, Inc.
75-175 Merle Drive, Suite 200
Palm Desert, CA 92211
760-568-3553 Voice
760-568-5681 Fax

Project Title: Genesis Solar Energy Center - Transformer #2 24
Engineer: BG
Project Descr: Project ID: 800.1915

Printed: 5 AUG 2015, 8:54AM

File = s:\EC6-DA-1\805\ADF-1\EC6

ENERCALC, INC, 1983-2015, Build:6.16.7.30, Ver:6.16.7.30

Licensee : BG STRUCTURAL ENGINEERING INC.

Pole Footing Embedded in Soil

Lic. #: KW-06008402

Description : Foundation @ Column C1

Code References

Calculations per IBC 2012 1807.3, CBC 2013, ASCE 7-10

Load Combinations Used : IBC 2012

General Information


Pole Footing Shape	Circular
Footing Diameter	18.0 in
Calculate Min. Depth for Allowable Pressures	
No Lateral Restraint at Ground Surface	
Allow Passive	250.0 psf
Max Passive	3,000.0 psf

Controlling Values

Governing Load Combination:	+D+0.60W+H
Lateral Load	0.1440 k
Moment	0.7439 k-ft
NO Ground Surface Restraint	
Pressures at 1/3 Depth	
Actual	235.502 psf
Allowable	236.925 psf

Minimum Required Depth 2.875 ft

Footing Base Area 1.767 ft^2
Maximum Soil Pressure 0.01415 ksf



Applied Loads

Lateral Concentrated Load	Lateral Distributed Load		Vertical Load
D : Dead Load 0.090 k		k/ft	0.0250 k
Lr : Roof Live k		k/ft	k
L : Live k		k/ft	k
S : Snow k		k/ft	k
W : Wind 0.090 k		k/ft	k
E : Earthquake k		k/ft	k
H : Lateral Earth k		k/ft	k
Load distance above ground surface 5.166 ft	TOP of Load above ground surface ft		
	BOTTOM of Load above ground surface ft		

Load Combination Results

Load Combination	Forces @ Ground Surface	Required Depth - (ft)	Pressure at 1/3 Depth	Soil Increase Factor
	Loads - (k)	Moments - (ft-k)	Actual - (psf)	Allow. - (psf)
+D+H	0.090	0.465	198.0	198.7
+D+L+H	0.090	0.465	198.0	198.7
+D+Lr+H	0.090	0.465	198.0	198.7
+D+S+H	0.090	0.465	198.0	198.7
+D+0.750Lr+0.750L+H	0.090	0.465	198.0	198.7
+D+0.750L+0.750S+H	0.090	0.465	198.0	198.7
+D+0.60W+H	0.144	0.744	235.5	236.9
+D+0.70E+H	0.090	0.465	198.0	198.7
+D+0.750Lr+0.750L+0.450W+H	0.131	0.674	227.8	227.9



B.G Structural Engineering, Inc.
75-175 Merle Drive, Suite 200
Palm Desert, CA 92211
760-568-3553 Voice
760-568-5681 Fax

Project Title: Genesis Solar Energy Center - Transformer #2 25
Engineer: BG
Project Descr: Project ID: 800.1915

Printed: 5 AUG 2015, 8:54AM

File = s1EC6-DA-11805ADF-1-EC6

ENERCALC, INC. 1983-2015, Build 6.16.7.30, Ver. 6.16.7.30

Licensee : BG STRUCTURAL ENGINEERING INC.

Pole Footing Embedded in Soil

Lic. #: KW.06008402


Description : Foundation @ Column C1

+D+0.750L+0.750S+0.450W+H	0.131	0.674	2.75	227.8	227.9	1.000
+D+0.750L+0.750S+0.5250E+H	0.090	0.465	2.50	198.0	198.7	1.000
+0.60D+0.60W+0.60H	0.108	0.558	2.63	211.2	212.9	1.000
+0.60D+0.70E+0.60H	0.054	0.279	2.00	163.7	164.9	1.000



UNISTRUT[®]

P1000[®] & P1001 Channels

P1000[®]






UNISTRUT
P1000



Wt/100 Ft: 189 Lbs (281 kg/100 m)
Allowable Moment 5,070 In-Lbs (570 N·m)
12 Gauge Nominal Thickness .105" (2.7mm)

P1001

GR HG PG PL



Wt/100 Ft: 378 Lbs (562 kg/100 m)
Allowable Moment 14,360 In-Lbs (1,620 N·m)
12 Gauge Nominal Thickness .105" (2.7mm)

P1000 DS


P1000 H3

GR HG PG PL

P1000 HS

GR HG PG PL

Slots are 2 3/4" (69.9) x 7/8" (22.2)
3 1/2" (88.9) on Center



Pipe Clamps can be
Mounted on Both Sides

Wt/100 Ft: 173 Lbs (257 kg/100 m)

Wt/100 Ft: 175 Lbs (260 kg/100 m)

Wt/100 Ft: 185 Lbs (275 kg/100 m)

P1000 KO

GR PG


P1000 SL

GR HG PG PL

P1000 T


GR HG PG PL

7/8" (22.2) Knockouts
6" (152.4) on Center




Wt/100 Ft: 190 Lbs (283 kg/100 m)

Slots are
3" (76.2) x 1 3/8" (10.3)
4" (101.6) on Center



Wt/100 Ft: 185 Lbs (275 kg/100 m)

Slots are
1 1/8" (28.6) x 7/8" (14.3)
2" (50.8) on Center



Wt/100 Ft: 185 Lbs (275 kg/100 m)

CHANNEL NUTS (REFER TO PAGES 73,74 FOR DETAILS)

SEE PAGE 73,74



P1006-0832
P1006-1024
P1006-1420
P1007
P1008
P1009
P1010



P1008T
P1008T1420
P1010T



P1012
P1023
P1024S



P1024
P1012S
P1023S



P3006-0832
P3006-1024
P3006-1420
P3007
P3008
P3009
P3010



P3016-0632
P3016-0832
P3016-1024
P3016-1420

Channel Finishes: PL, GR, HG, PG, ZD; Standard Lengths: 10' & 20'

P1000 & P1001 Channels

UNISTRUT®

P1000 - BEAM LOADING

Span In	Max. Allowable Uniform Load Lbs	Defl. at Uniform Load In	Uniform Loading at Deflection		
			Span/180 Lbs	Span/240 Lbs	Span/360 Lbs
24	1,690	0.06	1,690	1,690	1,690
36	1,130	0.13	1,130	1,130	900
48	850	0.22	850	760	500
60	680	0.35	650	480	320
72	560	0.50	450	340	220
84	480	0.68	330	250	160
96	420	0.89	250	190	130
108	380	1.14	200	150	100
120	340	1.40	160	120	80
144	280	2.00	110	80	60
168	240	2.72	80	60	40
192	210	3.55	60	50	NR
216	190	4.58	50	40	NR
240	170	5.62	40	NR	NR

P1000
5-10"
Span

P1001 - BEAM LOADING

Span In	Max. Allowable Uniform Load Lbs	Defl. at Uniform Load In	Uniform Loading at Deflection		
			Span/180 Lbs	Span/240 Lbs	Span/360 Lbs
24	3,500*	0.02	3,500*	3,500*	3,500*
36	3,190	0.07	3,190	3,190	3,190
48	2,390	0.13	2,390	2,390	2,390
60	1,910	0.20	1,910	1,910	1,620
72	1,600	0.28	1,600	1,600	1,130
84	1,370	0.39	1,370	1,240	830
96	1,200	0.51	1,200	950	630
108	1,060	0.64	1,000	750	500
120	960	0.79	810	610	410
144	800	1.14	560	420	280
168	680	1.53	410	310	210
192	600	2.02	320	240	160
216	530	2.54	250	190	130
240	480	3.16	200	150	100

P1000 - COLUMN LOADING

Unbraced Height In	Max. Allowable Load at Slot Face Lbs	Maximum Column Load Applied at C.G.			
		K = 0.65 Lbs	K = 0.80 Lbs	K = 1.0 Lbs	K = 1.2 Lbs
24	3,550	10,740	9,890	8,770	7,740
36	3,190	8,910	7,740	6,390	5,310
48	2,770	7,260	6,010	4,890	3,800
60	2,380	5,910	4,690	3,830	2,960
72	2,080	4,840	3,800	2,960	2,400
84	1,860	4,040	3,200	2,480	1,980
96	1,670	3,480	2,750	2,110	1,660
108	1,510	3,050	2,400	1,810	**
120	1,380	2,700	2,110	**	**
144	1,150	2,180	1,660	**	**

P1001 - COLUMN LOADING

Unbraced Height In	Max. Allowable Load at Slot Face Lbs	Maximum Column Load Applied at C.G.			
		K = 0.65 Lbs	K = 0.80 Lbs	K = 1.0 Lbs	K = 1.2 Lbs
24	6,430	24,280	23,610	22,700	21,820
36	6,290	22,810	21,820	20,650	19,670
48	6,160	21,410	20,300	18,670	16,160
60	6,000	20,210	18,870	15,520	12,390
72	5,620	18,970	16,180	12,390	8,950
84	5,170	16,950	13,630	9,470	6,580
96	4,690	14,890	11,190	7,260	5,040
108	4,170	12,850	8,950	5,730	3,980
120	3,690	10,900	7,250	4,640	**
144	2,930	7,630	5,040	**	**

P1000/P1001 - ELEMENTS OF SECTION

Parameter	P1000	P1001
Area of Section	0.655	1n ²
Axis 1-1		1.111 In ²
Moment of Inertia (I)	0.185	In ⁴
Section Modulus (S)	0.202	In ³
Radius of Gyration (r)	0.577	In
Axis 2-2		0.914 In
Moment of Inertia (I)	0.236	In ⁴
Section Modulus (S)	0.290	In ³
Radius of Gyration (r)	0.651	In

Notes:

- * Load limited by spot weld shear.
- ** KL/r > 200
- NR = Not Recommended.
- 1. Beam loads are given in total uniform load (W Lbs) not uniform load (w lbs/ft or w lbs/in).
- 2. Beam loads are based on a simple span and assumed to be adequately laterally braced. Unbraced spans can reduce beam load carrying capacity. Refer to Page 62 for reduction factors for unbraced lengths.
- 3. For pierced channel, multiply beam loads by the following factor:

"KO" Series.....95%	"T" Series85%
"HS" Series90%	"SL" Series85%
"H3" Series.....90%	"DS" Series.....70%
- 4. Deduct channel weight from the beam loads.
- 5. For concentrated midspan point loads, multiply beam loads by 50% and the corresponding deflection by 80%. For other load conditions refer to page 18.
- 6. All beam loads are for bending about Axis 1-1.

PROJECT
Genesis Solar Energy Ctr
Transformer #2 Foundation

ITEM
Footing @ Lighting
Protection Pole

B.G. STRUCTURAL ENGINEERING

SHEET NO. 28
JOB NO. 800.1915
DATE Aug. 2015
ENGINEER BG

BASIC WIND SPEED = 127 MPH (EXPOSURE C)

USE $P_{WIND} = 18.0 \text{ PSF}$ @ LIGHTING PROTECTION POLE

WIND LOADS & RESULTS

$$\textcircled{A} (39' \times \frac{1}{12}) = 22.75 \text{ FT}^2 \times 19.5' = 444 \text{ FT}^3$$

$$\textcircled{B} TR^2 = 12.0 \text{ FT}^2 \times 1.5' = 19 \text{ FT}^3$$

$$\text{TOTALS: } 39.25 \text{ FT}^2 \quad 463 \text{ FT}^3$$

$$h' = \frac{463 \text{ FT}^3}{39.25 \text{ FT}^2} = 11.25'$$


$$F_{WIND} = (18.0 \text{ PSF} \times 11.25') = \underline{\underline{630 \text{ lbs}}}$$

$$P_{POLE} = 500 \text{ lbs}$$

$$F_{EQ} = (.342)(500 \text{ lbs}) = 172 \text{ lbs}$$

$$H = 11.25' + 3' = \underline{\underline{14.25'}}$$

LIGHTING
PROTECTION
POLE BY
OTHERS



USE 24" ϕ x 5'-0" DEEP CONC FG

w/(5)-#5 VERT & #3 TIES @ 8" OC



B.G Structural Engineering, Inc.
75-175 Merle Drive, Suite 200
Palm Desert, CA 92211
760-568-3553 Voice
760-568-5681 Fax

Project Title: Genesis Solar Energy Center - Transformer #2 29
Engineer: BG
Project Descr: Project ID: 800.1915

Printed: 12 AUG 2015, 3:06PM

File #: IEC8-DA-1805ADF-1.EC6

ENERCALC, INC. 1983-2015, Build 6.15.7.30, Ver 6.15.7.30

Licensee : BG STRUCTURAL ENGINEERING INC.

Pole Footing Embedded in Soil

Lic. #: KW06008402

Description : Footing @ Lighting Protection Pole

Code References

Calculations per IBC 2012 1807.3, CBC 2013, ASCE 7-10

Load Combinations Used : IBC 2012

General Information

Pole Footing Shape	Circular
Footing Diameter	24.0 in
Calculate Min. Depth for Allowable Pressures	
No Lateral Restraint at Ground Surface	
Allow Passive	250.0 psf
Max Passive	1,500.0 psf

Controlling Values

Governing Load Combination : +D+0.60W+H

Lateral Load	0.3810 k
Moment	6.191 k-ft

NO Ground Surface Restraint

Pressures at 1/3 Depth

Actual	412.178 psf
Allowable	412.566 psf

Minimum Required Depth


5.0 ft

Footing Base Area

3.142 ft²

Maximum Soil Pressure

0.1592 ks



Applied Loads

Lateral Concentrated Load	Lateral Distributed Load		Vertical Load
D : Dead Load	0.0 k	0.0 k/ft	0.0 k
Lr : Roof Live	0.0 k	0.0 k/ft	0.0 k
L : Live	0.0 k	0.0 k/ft	0.0 k
S : Snow	0.0 k	0.0 k/ft	0.0 k
W : Wind	0.6350 k	0.0 k/ft	0.0 k
E : Earthquake	0.0 k	0.0 k/ft	0.0 k
H : Lateral Earth	0.0 k	0.0 k/ft	0.0 k
Load distance above ground surface	TOP of Load above ground surface		
16.250 ft	0.0 ft		
	BOTTOM of Load above ground surface		
	0.0 ft		

Load Combination Results

Load Combination	Forces @ Ground Surface	Required Depth (ft)	Pressure at 1/3 Depth (psf)	Soil Increase Factor
	Loads - (k)	Moments - (ft-k)	Actual - (psf)	Allow - (psf)
+D+H	0.000	0.000	0.13	0.0
+D+L+H	0.000	0.000	0.13	0.0
+D+Lr+H	0.000	0.000	0.13	0.0
+D+S+H	0.000	0.000	0.13	0.0
+D+0.750Lr+0.750L+H	0.000	0.000	0.13	0.0
+D+0.750L+0.750S+H	0.000	0.000	0.13	0.0
+D+0.60W+H	0.381	6.191	5.00	412.2
+D+0.70E+H	0.000	0.000	0.13	0.0
+D+0.750Lr+0.750L+0.450W+H	0.286	4.643	4.50	372.0



B.G Structural Engineering, Inc.
75-175 Merle Drive, Suite 200
Palm Desert, CA 92211
760-568-3553 Voice
760-568-5681 Fax

Project Title: Genesis Solar Energy Center - Transformer #2 30
Engineer: BG Project ID: 800.1915
Project Descr:

Printed: 12 AUG 2015, 3:06PM

File = s:IEC6-DA-1805ADF-1.IEC6

ENERCALC, INC. 1983-2015, Build:6.15.7.30, Ver:6.15.7.30


Licensee : BG STRUCTURAL ENGINEERING INC.

Pole Footing Embedded in Soil

Lic. #: KW.06008402

Description : Footing @ Lighting Protection Pole

+D+0.750L+0.750S+0.450W+H	0.286	4.643	4.50	372.0	372.0	1.000
+D+0.750L+0.750S+0.5250E+H	0.000	0.000	0.13	0.0	0.0	1.000
+0.60D+0.60W+0.60H	0.381	6.191	5.00	412.2	412.6	1.000
+0.60D+0.70E+0.60H	0.000	0.000	0.13	0.0	0.0	1.000



STS SQUARE TAPERED STEEL

Catalog #		Type
Project		
Comments		Date
Prepared by		

FEATURES

- ASTM Grade steel base plate with ASTM A366 base cover
- Hand hole assembly 3" x 5" on STS poles
- 20'-50' mounting heights
- Drilled or tenon (specify)


ORDERING INFORMATION

SAMPLE NUMBER: STS5A20SF21XE

Product Family	Shaft Size ¹ (Inches) ¹	Wall Thickness (Inches)	Mounting Height (Feet)	Base Type	Finish	Mounting Type	Number and Location of Arms ²	Arm Lengths (Feet)	Options (Add as Suffix)
STS-Square Tapered Steel	5=5" 6=6" 7=7" 8=8" 9=9" Steel; 6-3/4" Aluminum	A=0.120" D=0.180"	20=20' 25=25' 30=30' 35=35' 39=39' 45=45' 50=50'	S=Square Steel Base	F=Dark Bronze G=Galvanized Steel J=Summit White K=Carbon Bronze L=Dark Platinum P=Primer Powder Coat R=Hartford Green S=Silver T=Graphite Metallic V=Grey W=White X=Custom Color Y=Black	2=2-3/8" O.D. Tenon (4" Long) 3=3-1/2" O.D. Tenon (5" Long) 4=4" O.D. Tenon (6" Long) 5=5" O.D. Tenon (4" Long) 6=2-3/8" O.D. Tenon (6" Long) 7=4" O.D. Tenon (10" Long) A=Type A Drilling C=Type C Drilling E=Type E Drilling F=Type F Drilling G=Type G Drilling J=Type J Drilling K=Type K Drilling M=Type M Drilling R=Type R Drilling Z=Type Z Drilling	1=Single 2=2 at 180° 3=Triple ³ 4=4 at 90° 5=2 at 90° X=None	X=None	A=1/2" Tapped Hub (Specify location desired) B=3/4" Tapped Hub (Specify location desired) C=Convenience Outlet ³ E=GFCI Convenience Outlet ³ G=Ground Lug H=Additional Hand Hole ⁴ L=Drilled for Bumper Glitter V=Vibration Damper

NOTES: 1. All shaft sizes nominal. 2. Square poles are 3 at 80°, round poles are 3 at 120°. 3. Outlet is located 4" above base and on same side of pole as hand hole, unless specified otherwise. Receptacle not included, provision only. 4. Additional hand hole is located 12" below pole top and 90° from standard hand hole location, unless otherwise specified.

DIMENSIONS



WARNING: The use of unauthorized accessories such as banners, signs, cameras or pennants for which the pole was not designed voids the pole warranty from Eaton's Cooper Lighting business and may result in pole failure causing serious injury or property damage. Upon request, Eaton's Cooper Lighting business will supply information regarding total loading capacity. The pole warranty from Eaton's Cooper Lighting business is void unless poles are used and installed as a complete pole/luminaire combination. This warranty specifically excludes failure as the result of a third party act or omission, misuse, unanticipated uses, fatigue failure or similar phenomena resulting from induced vibration, harmonic oscillation or resonance associated with movement of air currents around the product.

Specifications and dimensions subject to change without notice. Consult your Eaton's Cooper Lighting business representative or visit www.cooperlighting.com for available options, accessories and ordering information.

Effective Projected Area (At Pole Top)

Mounting Height (Feet)	Catalog Number	Wall Thickness (Inches)	Base Square (Inches)	Bolt Circle Diameter (Inches)	Anchor Bolt Projection (Inches)	Shaft Diameter at Base ³ (Inches)	Shaft Taper (Inches/Feet)	Anchor Bolt Diameter x Length x Hook (Inches)	Net Weight (Pounds)	Maximum Effective Projected Area (Square Feet) ⁴				Max. Fixture Load Includes Bracket (Pounds)
MH			S	BC	BP	B		D x AB x H		70 mph	80 mph	90 mph	100 mph	
20	STS5A20S	0.120	10-3/4	10-3/4	4	5.25	0.11	1 x 36 x 4	155	--	--	--	--	
25	STS6A25S	0.120	11-1/2	12	4-1/8	6.00	0.11	1 x 36 x 4	205	--	--	--	--	
30	STS6A30S	0.120	11-7/8	12-1/2	4-1/8	6.41	0.11	1 x 36 x 4	260	--	--	--	--	
30	STS7D30S	0.180	12-5/8	13-1/2	4-1/2	7.13	0.11	1 x 36 x 4	431	--	--	--	--	
35	STS7A35S	0.120	12-1/4	13	4-1/8	6.81	0.11	1 x 36 x 4	305	--	--	--	--	
35	STS7D35S	0.180	12-5/8	13-1/2	4-1/2	7.13	0.11	1 x 36 x 4	475	--	--	--	--	
39	STS7A39S	0.120	12-5/8	13-1/2	4-1/8	7.18	0.11	1 x 36 x 4	345	--	--	--	--	
39	STS7D39S	0.180	12-5/8	13-1/2	4-1/2	7.13	0.11	1 x 36 x 4	500	--	--	--	--	
45	STS8D45S	0.180	13-3/8	14-1/2	4-1/2	7.88	0.11	1 x 36 x 4	620	--	--	--	--	
50	STS9D50S	0.180	15-1/2	16	5	8.81	0.11	1-1/4 x 42 x 6	780	--	--	--	--	

Effective Projected Area (Two Feet Above Pole Top)

Mounting Height (Feet)	Catalog Number	Wall Thickness (Inches)	Base Square (Inches)	Bolt Circle Diameter (Inches)	Anchor Bolt Projection (Inches)	Shaft Diameter at Base ³ (Inches)	Shaft Taper (Inches/Feet)	Anchor Bolt Diameter x Length x Hook (Inches)	Net Weight (Pounds)	Maximum Effective Projected Area (Square Feet) ⁴				Max. Fixture Load Includes Bracket (Pounds)
MH			S	BC	BP	B		D x AB x H		70 mph	80 mph	90 mph	100 mph	
20	STS5A20S	0.120	10-3/4	10-3/4	4	5.25	0.11	1 x 36 x 4	155	--	--	--	--	
25	STS6A25S	0.120	11-1/2	12	4-1/8	6.00	0.11	1 x 36 x 4	205	--	--	--	--	
30	STS6A30S	0.120	11-7/8	12-1/2	4-1/8	6.41	0.11	1 x 36 x 4	260	--	--	--	--	
30	STS7D30S	0.180	12-5/8	13-1/2	4-1/2	7.13	0.11	1 x 36 x 4	431	--	--	--	--	
35	STS7A35S	0.120	12-1/4	13	4-1/8	6.81	0.11	1 x 36 x 4	305	--	--	--	--	
35	STS7D35S	0.180	12-5/8	13-1/2	4-1/2	7.13	0.11	1 x 36 x 4	475	--	--	--	--	
39	STS7A39S	0.120	12-5/8	13-1/2	4-1/8	7.18	0.11	1 x 36 x 4	345	--	--	--	--	
39	STS7D39S	0.180	12-5/8	13-1/2	4-1/2	7.13	0.11	1 x 36 x 4	500	--	--	--	--	
45	STS8D45S	0.180	13-3/8	14-1/2	4-1/2	7.88	0.11	1 x 36 x 4	620	--	--	--	--	
50	STS9D50S	0.180	15-1/2	16	5	8.81	0.11	1-1/4 x 42 x 6	780	--	--	--	--	

NOTES:

1. Catalog number includes pole with hardware kit. Anchor bolts not included. Before installing, make sure proper anchor bolts and templates are obtained from Eaton's Cooper Lighting business.

2. Tenon size or machining for rectangular arms must be specified. Hand hole position relative to drill location.

3. Shaft size, base square, anchor bolts and projections may vary slightly. All dimensions nominal.

4. EPAs based on shaft properties with wind normal to flat. EPAs calculated using base wind velocity as indicated plus 30% gust factor.

Equipment Forces - 800.1915 Genesis Solar - Transformer 2
2013 CBC (Small Transformer)

$$F_p = ((0.4a_p S_{DS} l_p)/R_p) * (1+2z/h)^* W_p \quad \text{Per ASCE7-10 Eq. 13.3-1}$$

$$F_{p\min} = 0.3S_{DS}l_pW_p \quad \text{Per ASCE7-10 Eq. 13.3-3}$$

$$F_{p\max} = 1.6S_{DS}l_pW_p \quad \text{Per ASCE7-10 Eq. 13.3-2}$$

$$S_{DS} = 0.423$$

$$F_p \min = 0.190 W_p$$

$$l_p = 1.5$$

$$F_p \max = 1.015 W_p$$

Unit = Transformer

$$W_p = 250 \text{ lbs.}$$

$$z = 0.25 \text{ ft.}$$

$$h = 0.25 \text{ ft.}$$

$$a_p = 1$$

$$R_p = 2.5$$

$$F_p = 0.305 W_p$$

$$F_p \text{ WSD} = 0.218 W_p$$

$$F_p \text{ WSD} = 54 \text{ lbs.}$$

$$h = 2.67$$

$$d = 1 \text{ ft.}$$

$$M = 145 \text{ lbs.}$$

$$T=C = 145 \text{ lbs.}$$

→ USE SIMPSON STRONG-BOLT:

1/2" ϕ STRONG BOLT [$h_{nom} = 3"$]

(SEE SIMPSON ANCHOR DESIGN ATTACHED)



**Anchor Designer™
Software**
Version 2.4.5673.4

Company:	BG Structural Engineering	Date:	8/12/2015
Engineer:	SC	Page:	1/5
Project:	800.1915 Genesis Solar - Transformer 2		
Address:	75-175 Merle Drive, Suite 200		
Phone:			
E-mail:			

1. Project Information

Customer company:
Customer contact name:
Customer e-mail:
Comment:

Project description:
Location:
Fastening description:

2. Input Data & Anchor Parameters

General

Design method: ACI 318-11
Units: Imperial units

Anchor Information:

Anchor type: Torque controlled expansion anchor
Material: Carbon Steel
Diameter (inch): 0.500
Nominal Embedment depth (inch): 3.000
Effective Embedment depth, h_{ef} (inch): 2.500
Code report: ICC-ES ESR-1771
Anchor category: 1
Anchor ductility: Yes
 h_{min} (inch): 4.83
 c_{ac} (inch): 8.75
 C_{min} (Inch): 4.00
 S_{min} (inch): 4.00

Base Material

Concrete: Normal-weight
Concrete thickness, h (inch): 20.50
State: Cracked
Compressive strength, f_c (psi): 4500
 $\Psi_{e,v}$: 1.0
Reinforcement condition: B tension, B shear
Supplemental reinforcement: Not applicable
Reinforcement provided at corners: No
Do not evaluate concrete breakout in tension: No
Do not evaluate concrete breakout in shear: No
Ignore 6do requirement: Not applicable
Build-up grout pad: No


Base Plate

Length x Width x Thickness (inch): 3.50 x 3.50 x 0.00

Load and Geometry

Load factor source: ACI 318 Section 9.2
Load combination: not set
Seismic design: No
Anchors subjected to sustained tension: Not applicable
Apply entire shear load at front row: No
Anchors only resisting wind and/or seismic loads: No

<Figure 1>






Anchor Designer™
Software
Version 2.4.5673.4

Company:	BG Structural Engineering	Date:	8/12/2015
Engineer:	SC	Page:	2/5
Project:	800,1915 Genesis Solar - Transformer 2		
Address:	75-175 Merle Drive, Suite 200		
Phone:			
E-mail:			


<Figure 2>



Recommended Anchor

Anchor Name: Strong-Bolt® (Discontinued) - 1/2"Ø Strong-Bolt, hnom:3" (76mm)

Code Report: ICC-ES ESR-1771





Anchor Designer™
Software
Version 2.4.5673.4

Company:	BG Structural Engineering	Date:	8/12/2015
Engineer:	SC	Page:	3/5
Project:	800.1915 Genesis Solar - Transformer 2		
Address:	75-175 Merle Drive, Suite 200		
Phone:			
E-mail:			

3. Resulting Anchor Forces

Anchor	Tension load, N_{ua} (lb)	Shear load x, V_{uax} (lb)	Shear load y, V_{uay} (lb)	Shear load combined, $\sqrt{(V_{uax})^2 + (V_{uay})^2}$ (lb)
1	250.0	145.0	0.0	145.0
Sum	250.0	145.0	0.0	145.0

Maximum concrete compression strain (%): 0.00

<Figure 3>

Maximum concrete compression stress (psi): 0

Resultant tension force (lb): 250


Resultant compression force (lb): 0

Eccentricity of resultant tension forces in x-axis, e'_{Nx} (inch): 0.00

Eccentricity of resultant tension forces in y-axis, e'_{Ny} (inch): 0.00

Eccentricity of resultant shear forces in x-axis, e'_{Vx} (inch): 0.00

Eccentricity of resultant shear forces in y-axis, e'_{Vy} (inch): 0.00



4. Steel Strength of Anchor in Tension (Sec. D.5.1)

N_{sa} (lb)	ϕ	ϕN_{sa} (lb)
13500	0.75	10125

5. Concrete Breakout Strength of Anchor in Tension (Sec. D.5.2)

$$N_b = k_c \lambda_a \sqrt{f'_c h_{et}}^{1.5} \text{ (Eq. D-6)}$$

k_c	λ_a	f'_c (psi)	h_{et} (in)	N_b (lb)
17.0	1.00	4500	2.500	4508

$$\phi N_{cb} = \phi (A_{Nc}/A_{Nco}) \Psi_{ed,N} \Psi_{c,N} \Psi_{cp,N} N_b \text{ (Sec. D.4.1 & Eq. D-3)}$$

A_{Nc} (in²)	A_{Nco} (in²)	$\Psi_{ed,N}$	$\Psi_{c,N}$	$\Psi_{cp,N}$	N_b (lb)	ϕ	ϕN_{cb} (lb)
56.25	56.25	1.000	1.00	1.000	4508	0.65	2930

6. Pullout Strength of Anchor in Tension (Sec. D.5.3)

$$\phi N_{pn} = \phi \Psi_{c,P} \lambda_a N_p (f'_c / 2,500)^n \text{ (Sec. D.4.1, Eq. D-13 & Code Report)}$$

$\Psi_{c,P}$	λ_a	N_p (lb)	f'_c (psi)	n	ϕ	ϕN_{pn} (lb)
1.0	1.00	2895	4500	0.50	0.65	2525



Anchor Designer™
Software
Version 2.4.5673.4

Company:	BG Structural Engineering	Date:	8/12/2015
Engineer:	SC	Page:	4/5
Project:	800.1915 Genesis Solar - Transformer 2		
Address:	75-175 Merle Drive, Suite 200		
Phone:			
E-mail:			

8. Steel Strength of Anchor in Shear (Sec. D.6.1)

V _{sa} (lb)	ϕ _{grout}	ϕ	ϕ _{grout} ϕV _{sa} (lb)
5280	1.0	0.65	3432

9. Concrete Breakout Strength of Anchor in Shear (Sec. D.6.2)

Shear perpendicular to edge in x-direction:

$$V_{bx} = \min[7(l_e/d_a)^{0.2}\sqrt{d_a\lambda_a/f'_c c_{at}^{1.5}}, 9\lambda_a\sqrt{f'_c c_{at}}^{1.5}] \text{ (Eq. D-33 & Eq. D-34)}$$

l _e (in)	d _a (in)	λ _a	f' _c (psi)	c _{at} (in)	V _{bx} (lb)
2.50	0.50	1.00	4500	6.00	6733

$$\phi V_{cbx} = \phi (A_{vc}/A_{vco}) \Psi_{ed,V} \Psi_{c,V} \Psi_{h,V} V_{bx} \text{ (Sec. D.4.1 & Eq. D-30)}$$

A _{vc} (in ²)	A _{vco} (in ²)	Ψ _{ed,V}	Ψ _{c,V}	Ψ _{h,V}	V _{bx} (lb)	ϕ	ϕV _{cbx} (lb)
162.00	162.00	1.000	1.000	1.000	6733	0.70	4713

Shear parallel to edge in x-direction:

$$V_{by} = \min[7(l_e/d_a)^{0.2}\sqrt{d_a\lambda_a/f'_c c_{at}^{1.5}}, 9\lambda_a\sqrt{f'_c c_{at}}^{1.5}] \text{ (Eq. D-33 & Eq. D-34)}$$

l _e (in)	d _a (in)	λ _a	f' _c (psi)	c _{at} (in)	V _{by} (lb)
2.50	0.50	1.00	4500	9.00	12369

$$\phi V_{cbx} = \phi (2)(A_{vc}/A_{vco}) \Psi_{ed,V} \Psi_{c,V} \Psi_{h,V} V_{by} \text{ (Sec. D.4.1 & Eq. D-30)}$$

A _{vc} (in ²)	A _{vco} (in ²)	Ψ _{ed,V}	Ψ _{c,V}	Ψ _{h,V}	V _{by} (lb)	ϕ	ϕV _{cbx} (lb)
243.00	364.50	1.000	1.000	1.000	12369	0.70	11545

10. Concrete Pryout Strength of Anchor in Shear (Sec. D.6.3)

$$\phi V_{cp} = \phi k_{cp} N_{cb} = \phi k_{cp}(A_{vc}/A_{vco}) \Psi_{ed,N} \Psi_{c,N} \Psi_{h,N} N_b \text{ (Eq. D-40)}$$

k _{cp}	A _{vc} (in ²)	A _{vco} (in ²)	Ψ _{ed,N}	Ψ _{c,N}	Ψ _{h,N}	N _b (lb)	ϕ	ϕV _{cp} (lb)
2.0	56.25	56.25	1.000	1.000	1.000	4508	0.70	6311

11. Results

Interaction of Tensile and Shear Forces (Sec. D.7)

Tension	Factored Load, N _{ua} (lb)	Design Strength, ϕN _n (lb)	Ratio	Status
Steel	250	10125	0.02	Pass
Concrete breakout	250	2930	0.09	Pass
Pullout	250	2525	0.10	Pass (Governs)
Shear	Factored Load, V _{ua} (lb)	Design Strength, ϕV _n (lb)	Ratio	Status
Steel	145	3432	0.04	Pass (Governs)
T Concrete breakout x+	145	4713	0.03	Pass
Concrete breakout y+	145	11545	0.01	Pass
Pryout	145	6311	0.02	Pass
Interaction check	N _{ua} /ϕN _n	V _{ua} /ϕV _n	Combined Ratio	Permissible
Sec. D.7.1	0.10	0.00	9.9 %	1.0
				Status
				Pass

1/2"Ø Strong-Bolt, hnom:3" (76mm) meets the selected design criteria.



Anchor Designer™
Software
Version 2.4.5673.4

Company:	BG Structural Engineering	Date:	8/12/2015
Engineer:	SC	Page:	5/5
Project:	800.1915 Genesis Solar - Transformer 2		
Address:	75-175 Merle Drive, Suite 200		
Phone:			
E-mail:			

12. Warnings

- Designer must exercise own judgement to determine if this design is suitable.
- Refer to manufacturer's product literature for hole cleaning and installation instructions.



B.G Structural Engineering, Inc.
75-175 Merle Drive, Suite 200
Palm Desert, CA 92211
760-568-3553 Voice
760-568-5681 Fax

Project Title: Genesis Solar Energy Center - Transformer #2 39
Engineer: BG
Project Descr: Project ID: 800.1915

Printed: 12 AUG 2015, 4:45PM

File = s:\EC6-DA~1\805ADF~1.EC6
ENERCALC, INC. 1983-2015, Build:6.15.7.30, Ver:6.15.7.30

Licensee: BG STRUCTURAL ENGINEERING INC

Steel Column

Lic.# : KW-06008402

Description : Column C2 (Bollard Column)

Code References

Calculations per AISC 360-10, IBC 2012, CBC 2013, ASCE 7-10

Load Combinations Used : 2006IBC&ASCE7-05

General Information

Steel Section Name : HSS 6x0.375
Analysis Method : Allowable Strength
Steel Stress Grade
Fy : Steel Yield 42.0 ksi
E : Elastic Bending Modulus 29,000.0 ksi
Load Combination : 2006IBC&ASCE7-05

Overall Column Height 4.0 ft
Top & Bottom Fixity Top Free, Bottom Fixed
Brace condition for deflection (buckling) along columns :
X-X (width) axis : Unbraced Length for X-X Axis buckling = 4 ft, K = 2.1
Y-Y (depth) axis : Unbraced Length for Y-Y Axis buckling = 4 ft, K = 2.1

Applied Loads

Column self weight included : 90.198 lbs * Dead Load Factor
BENDING LOADS ...
Lat. Point Load at 2.670 ft creating Mx-x, D = 6.0 k

Service loads entered. Load Factors will be applied for calculations.

DEFLECTION CHECK:

$$\Delta_{ALL} = 0.025(4)(12) = 1.20"$$

$$\Delta_{ALL} = 1.20" \gg \Delta_{ACT} = .159" \checkmark$$

DESIGN SUMMARY

Bending & Shear Check Results

PASS Max. Axial+Bending Stress Ratio =		0.6828 : 1	Maximum SERVICE Load Reactions ..	
Load Combination		D Only	Top along X-X	0.0 k
Location of max.above base		0.0 ft	Bottom along X-X	0.0 k
At maximum location values are ...			Top along Y-Y	0.0 k
Pa : Axial		0.09020 k	Bottom along Y-Y	6.0 k
Pn / Omega : Allowable		133.404 k		
Ma-x : Applied		-16.020 k-ft		
Mn-x / Omega : Allowable		23.473 k-ft	Maximum SERVICE Load Deflections ...	
Ma-y : Applied		0.0 k-ft	Along Y-Y 0.1591 in at	4.0ft above base
Mn-y / Omega : Allowable		23.473 k-ft	for load combination :D Only	
			Along X-X 0.0 in at	0.0ft above base
			for load combination :	
PASS Maximum Shear Stress Ratio =		0.1283 : 1		
Load Combination		D Only		
Location of max.above base		0.0 ft		
At maximum location values are ...				
Va : Applied		6.0 k		
Vn / Omega : Allowable		46.778 k		

Load Combination Results

Load Combination	Maximum Axial + Bending Stress Ratios			Maximum Shear Ratios		
	Stress Ratio	Status	Location	Stress Ratio	Status	Location
D Only	0.683	PASS	0.00 ft	0.128	PASS	0.00 ft
+D+L+H	0.683	PASS	0.00 ft	0.128	PASS	0.00 ft
+D+Lr+H	0.683	PASS	0.00 ft	0.128	PASS	0.00 ft
+D+S+H	0.683	PASS	0.00 ft	0.128	PASS	0.00 ft
+D+0.750Lr+0.750L+H	0.683	PASS	0.00 ft	0.128	PASS	0.00 ft
+D+0.750L+0.750S+H	0.683	PASS	0.00 ft	0.128	PASS	0.00 ft
+D+W+H	0.683	PASS	0.00 ft	0.128	PASS	0.00 ft
+D+0.70E+H	0.683	PASS	0.00 ft	0.128	PASS	0.00 ft
+D+0.750Lr+0.750L+0.750W+H	0.683	PASS	0.00 ft	0.128	PASS	0.00 ft
+D+0.750L+0.750S+0.750W+H	0.683	PASS	0.00 ft	0.128	PASS	0.00 ft
+D+0.750Lr+0.750L+0.5250E+H	0.683	PASS	0.00 ft	0.128	PASS	0.00 ft
+D+0.750L+0.750S+0.5250E+H	0.683	PASS	0.00 ft	0.128	PASS	0.00 ft
+0.60D+W+H	0.410	PASS	0.00 ft	0.077	PASS	0.00 ft
+0.60D+0.70E+H	0.410	PASS	0.00 ft	0.077	PASS	0.00 ft



B.G Structural Engineering, Inc.
75-175 Merle Drive, Suite 200
Palm Desert, CA 92211
760-568-3553 Voice
760-568-5681 Fax

Project Title: Genesis Solar Energy Center - Transformer #2 40
Engineer: BG
Project Descr: Project ID: 800.1915

Printed: 12 AUG 2015, 4:45PM

File = s:\EC6\DA-1\805\ADF-1.EC6

ENERCALC, INC. 1983-2015; Build:6.16.7.30, Ver:6.15.7.30

Licensee: BG STRUCTURAL ENGINEERING INC.

Steel Column

Lic. #: KW-06008402

Description: Column C2 (Bollard Column)

Maximum Reactions


Note: Only non-zero reactions are listed.

Load Combination	X-X Axis Reaction		Y-Y Axis Reaction		Axial Reaction @ Base
	@ Base	@ Top	@ Base	@ Top	
D Only		k	-6.000	k	0.090 k
+D+L+H		k	-6.000	k	0.090 k
+D+Lr+H		k	-6.000	k	0.090 k
+D+S+H		k	-6.000	k	0.090 k
+D+0.750Lr+0.750L+H		k	-6.000	k	0.090 k
+D+0.750L+0.750S+H		k	-6.000	k	0.090 k
+D+W+H		k	-6.000	k	0.090 k
+D+0.70E+H		k	-6.000	k	0.090 k
+D+0.750Lr+0.750L+0.750W+H		k	-6.000	k	0.090 k
+D+0.750L+0.750S+0.750W+H		k	-6.000	k	0.090 k
+D+0.750Lr+0.750L+0.5250E+H		k	-6.000	k	0.090 k
+D+0.750L+0.750S+0.5250E+H		k	-6.000	k	0.090 k
+0.60D+W+H		k	-3.600	k	0.054 k
+0.60D+0.70E+H		k	-3.600	k	0.054 k
D Only		k	-6.000	k	0.090 k
Lr Only		k		k	k
L Only		k		k	k
S Only		k		k	k
W Only		k		k	k
E Only		k		k	k
H Only		k		k	k

Maximum Deflections for Load Combinations

Load Combination	Max. X-X Deflection	Distance	Max. Y-Y Deflection	Distance
D Only	0.0000	in	0.000	ft
+D+L+H	0.0000	in	0.000	ft
+D+Lr+H	0.0000	in	0.000	ft
+D+S+H	0.0000	in	0.000	ft
+D+0.750Lr+0.750L+H	0.0000	in	0.000	ft
+D+0.750L+0.750S+H	0.0000	in	0.000	ft
+D+W+H	0.0000	in	0.000	ft
+D+0.70E+H	0.0000	in	0.000	ft
+D+0.750Lr+0.750L+0.750W+H	0.0000	in	0.000	ft
+D+0.750L+0.750S+0.750W+H	0.0000	in	0.000	ft
+D+0.750Lr+0.750L+0.5250E+H	0.0000	in	0.000	ft
+D+0.750L+0.750S+0.5250E+H	0.0000	in	0.000	ft
+0.60D+W+H	0.0000	in	0.000	ft
+0.60D+0.70E+H	0.0000	in	0.000	ft
D Only	0.0000	in	0.000	ft
Lr Only	0.0000	in	0.000	ft
L Only	0.0000	in	0.000	ft
S Only	0.0000	in	0.000	ft
W Only	0.0000	in	0.000	ft
E Only	0.0000	in	0.000	ft
H Only	0.0000	in	0.000	ft

Steel Section Properties : HSS 6x0.375



B.G Structural Engineering, Inc.
75-175 Merle Drive, Suite 200
Palm Desert, CA 92211
760-568-3553 Voice
760-568-5681 Fax

Project Title: Genesis Solar Energy Center - Transformer #2 41
Engineer: BG
Project Descr: Project ID: 800,1915

Printed: 12 AUG 2016, 4:45PM

File = s:\EC6-DA-1805\ADF-1.EC6

ENERCALC, INC. 1983-2016, Build 6.15.7.30, Ver 6.15.7.30

Licensee: BG STRUCTURAL ENGINEERING INC


Steel Column

Lic. #: KW-06008402

Description : Column C2 (Bollard Column)

Steel Section Properties : HSS 6x0.375

Depth	=	6.000 in	I _{xx}	=	24.80 in ⁴	J	=	49.700 in ⁴
			S _{xx}	=	8.28 in ³			
Diameter	=	6.000 in	R _{xx}	=	2.000 in			
Wall Thick	=	0.375 in	Z _x	=	11.200 in ³			
Area	=	6.200 in ²	I _{yy}	=	24.800 in ⁴	C	=	16.600 in ³
Weight	=	22.550 plf	S _{yy}	=	8.280 in ³			
			R _{yy}	=	2.000 in			
Ycg	=	0.000 in						





B.G Structural Engineering, Inc.
75-175 Merle Drive, Suite 200
Palm Desert, CA 92211
760-568-3553 Voice
760-568-5681 Fax

Project Title: Genesis Solar Energy Center - Transformer #2 **42**
Engineer: BG
Project ID: 800.1915

Printed: 12 AUG 2015, 4:45PM

File = s:\EC6-DA~1\805ADF-1.EC6

ENERCALC, INC. 1983-2015, Build:6.15.7.30, Ver:6.15.7.30

Licensee : BG STRUCTURAL ENGINEERING, INC.

Pole Footing Embedded in Soil

Lic. #: KW-06008402

Description : Foundation @ Column C2 (Bollard Column)


Code References

Calculations per IBC 2012 1807.3, CBC 2013, ASCE 7-10

Load Combinations Used : IBC 2012

General Information

Pole Footing Shape	Circular
Footing Diameter	36.0 in
Calculate Min. Depth for Allowable Pressures	
No Lateral Restraint at Ground Surface	
Allow Passive	250.0 psf
Max Passive	3,000.0 psf



Controlling Values

Governing Load Combination : +D+H

Lateral Load	6.0 k
Moment	16,020 k-ft
NO Ground Surface Restraint	
Pressures at 1/3 Depth	
Actual	721.80 psf
Allowable	721.85 psf

Minimum Required Depth	8.750 ft
------------------------	----------

Footing Base Area	7.069 ft^2
Maximum Soil Pressure	0.01698 ksf

Applied Loads

Lateral Concentrated Load	Lateral Distributed Load		Vertical Load
D : Dead Load	6.0 k	k/ft	0.120 k
Lr : Roof Live	k	k/ft	k
L : Live	k	k/ft	k
S : Snow	k	k/ft	k
W : Wind	k	k/ft	k
E : Earthquake	k	k/ft	k
H : Lateral Earth	k	k/ft	k
Load distance above ground surface	2.670 ft	TOP of Load above ground surface ft	
		BOTTOM of Load above ground surface ft	

Load Combination Results

Load Combination	Forces @ Ground Surface	Required Depth	Pressure at 1/3 Depth	Soil Increase Factor
	Loads - (k)	Moments - (ft-k)	Actual - (psf)	Allow - (psf)
+D+H	6.000	16,020	721.8	721.9
+D+L+H	6.000	16,020	721.8	721.9
+D+Lr+H	6.000	16,020	721.8	721.9
+D+S+H	6.000	16,020	721.8	721.9
+D+0.750Lr+0.750L+H	6.000	16,020	721.8	721.9
+D+0.750L+0.750S+H	6.000	16,020	721.8	721.9
+D+0.60W+H	6.000	16,020	721.8	721.9
+D+0.70E+H	6.000	16,020	721.8	721.9
+D+0.750Lr+0.750L+0.450W+H	6.000	16,020	721.8	721.9



B.G Structural Engineering, Inc.
75-175 Merle Drive, Suite 200
Palm Desert, CA 92211
760-568-3553 Voice
760-568-5681 Fax

Project Title: Genesis Solar Energy Center - Transformer #2 **43**
Engineer: BG
Project Descr: Project ID: 800.1915

Printed: 12 AUG 2015, 4:45PM

File #: s:\EC6-DA~1\805\ADF-1.EC6
ENERCALC, INC. 1983-2015, Build:6.15.7.30, Ver:6.15.7.30

Licensee : BG STRUCTURAL ENGINEERING, INC.

Pole Footing Embedded in Soil

Lic. #: KW-06008402

Description : Foundation @ Column C2 (Bollard Column)


+D+0.750L+0.750S+0.450W+H	6.000	16,020	8.75	721.8	721.9	1,000
+D+0.750L+0.750S+0.5250E+H	6.000	16,020	8.75	721.8	721.9	1,000
+0.60D+0.60W+0.60H	3,600	9,612	7.00	575.7	577.2	1,000
+0.60D+0.70E+0.60H	3,600	9,612	7.00	575.7	577.2	1,000

GENERAL NOTES FOR UNDERGROUND CONDUITS


1. IF DRILLED TO THE EXPOSED DEBRIS INSIDE PODCAST OR DIPS, REMOVE LARGE STONES FROM
PODCAST AND FAMILY DOME LOCATE PODCAST IN THE SPACED POSITION BEFORE CONCRETE
AND CONDUIT IS LAYED.
 2. EASIFLEX SHALL BE SET UP OR TAINT SHAPED INTO PLACE, FILLED TIGHTLY IN THE TOP AND RESTORE
SURFACE TO ITS ORIGINAL CONDITION. REPAIR EXCESS DAMAGE, CONDUIT DUCT SLEEVES SHALL NOT
EXCEED A LENGTH OF 24 INCHES AS SHOWN ON DRAWINGS, DEPENDING ON CONDITIONS OF
SPECIFIC LOCATIONS.
 3. ROD GROoved STEEL CONDUIT SHALL BE INSTALLED WHERE UNDERGROUND CONDUIT LIES UP TO
THE DIRT BANK, UNLESS OTHERWISE SPECIFIED. REFER TO THE ELECTRICAL INSTALLATION DETAIL
FOR THIS REQUIREMENT.
 4. UNLESS OTHERWIS SPECIFIED ON DRAWINGS, ESTIMATE ALL STUMPS & ROCKS ABOVE THE
CONCRETE FLOOR AND REMOVE.
 5. CONDUIT LEADERS IN THE DIRT GROoved CONDUIT FOR SEPARATE, WITH A MINIMUM DIAMETER OF 12 INCHES
ON TOP, BOTTOM, AND SIDES OF CONDUIT. THE TOP SURFACE OF CONCRETE SHALE IS SEPARATED WITH
FIRE CLOTH, AND MUST BE MULCH OR BETTER BEFORE INSTALLING SET.
 6. MAKE UNDERGROUND DRAINS ATTACHED WITH 18 INCHES WIDE, DEEPERABLE, BURROW TIE
PLATE AND 18 INCHES THICK, APPROXIMATELY 12 INCHES FROM THE DIRT BANK THAT BOUNDARY
WALLS, ELECTRICAL, PLUMBING, AND AIR CONDITIONING CONDUITS.
 7. WHEN CONDUIT SLEEVES ARE SET IN THE EXPOSED EQUIPMENT, THE EXCAVATOR SHALL KEEF
THE EQUIPMENT OPERATED AND INSTRUCTIONS TO AVOID MISMANAGEMENT OF STUMPS AND DREDGED
MATERIAL.
 8. ALL UNDERGROUND CONDUIT SHALL BE PROOF TESTED AT 100% OF AN APPROVED SUBSTANTIVE,
EXCEPT AS SPECIFIED HEREIN OR IN THE DRAWINGS. ELEMENTS ARE RECOMMENDED TO BE
TESTED AT 100% OF AN APPROVED SUBSTANTIVE.

SPECIFIC NOTES:


- 10) BOND FISHING WIRE TO EXTERIOR GROUND AND (ENDS) WITH #10/0 BARE SOLID COPPER TANED WIRE
 - 11) #14/16" COPPER GROUNDS REED. SEE DETAIL "W" ON SHEET E10
 - 12) EXISTING GROUNDS OR GROUNDS SHALL BE DRAINED 10'-15' FEET FROM THESE COPPER PROTECTION #10/0 BARE SOLID COPPER TANED WIRE. GROUNDS SHALL NOT BE LOCATED WITHIN 10'-15' FEET FROM ANY FOUNDATION, ROAD TO THE SITE, ESTATE OR ESTATE IN FIELD.
 - 13) BOND NEW ESR TO THE EXISTING SITE FOR #10/0 BARE SOLID COPPER CONDUCTOR SUBJECT TO FIELD COORDINATION
 - 14) BOND NEW ESR TO THE EXISTING SITE FOR #10/0 BARE SOLID COPPER TANED WIRE.
 - 15) PROVIDE #10/0 BARE SOLID COPPER AIR RELAY FOR LIGHTNING PROTECTION. PROVIDE ALL RELAY PARTS, ADAPTERS AND MOUNTING HARDWARE. MOUNT ON THE TOP OF THE ROLL. PREVIOUS COMPANY PROVIDED A #10/0 BARE SOLID COPPER AIR RELAY. THE LEAD LIGHTNING PROTECTOR SHALL BE OF THOMSON COMPANY OR APPROVED EQUAL.
 - 16) BOND TRANSFORMER TO THE ESR WITH #10/0 BARE SOLID COPPER TANED WIRE.
 - 17) PROVIDE 15'X15' HIGH POLY SPANNED STEEL COOPER INDUSTRIES STI-70-395-40, OR EQUAL. SEE DETAIL "H"
 - 18) LOCATE EXISTING 2" X 2" STC-202, INTROPS, AND EXTEND TO THE NEW TRANSFORMER LOCATION. PULL IN ALL NEW WIRES IN THE NEW AND EXISTING COLUMNS. SUBJECT TO FIELD COORDINATION.
 - 19) STAY OUT 12' UNDERGROUND POWER CONDUIT AT THE LOCATION OF THE TRANSFORMER. PROVIDE CONDUIT SUPPORTS. COORDINATE WITH THE LOCAL UTILITY COMPANY ON THE ONE LINE DRAWINGS.
 - 20) STAY OUT 12' UNDERGROUND POWER CONDUIT AT THE LOCATION OF THE TRANSFORMER. PROVIDE CONDUIT SUPPORTS. COORDINATE WITH THE LOCAL UTILITY COMPANY ON THE ONE LINE DRAWINGS.




Dennls
Hurvitz



ENLARGED TRANSFORMER PLAN





Digital Signal Processing
for Communications, includes
Encryption, Non-Linear Electronics,
and Digital Communications
by Dennis Huryvitz
Bryant is the author of the
documented
title IEEML1994267 4730