



**California Regional Water Quality Control Board
Lahontan Region**



Linda S. Adams
Secretary for
Environmental Protection

Victorville Office
14440 Civic Drive, Suite 200, Victorville, California 92392
(760) 241-6583 • Fax (760) 241-7308
<http://www.waterboards.ca.gov/lahontan>

Arnold Schwarzenegger
Governor

April 30, 2008

File: Environmental Doc Review
Kern County

DOCKET 08-AFC-2	
DATE	APR 30 2008
RECD.	MAY 07 2008

Mr. Bill Pfanner
Energy Facilities Siting and Compliance
California Energy Commission
1516 Ninth Street
Sacramento, CA 95814-5512
Fax (661) 862-86

COMMENTS ON THE PROPOSED BEACON SOLAR ENERGY PROJECT CONSISTING OF A CONCENTRATED SOLAR ELECTRIC GENERATING FACILITY, ON APPROXIMATELY 2,012-ACRE SITE IN EASTERN KERN COUNTY, ALONG THE CALIFORNIA SR-14 CORRIDOR, FOUR MILES NORTH-NORTHWEST OF CALIFORNIA CITY

Please refer to the items checked for staff comments on the above-referenced project:

- [X] The site plan for this project does not specifically identify features for the post-construction period that will control stormwater on-site or prevent pollutants from non-point sources from entering and degrading surface or ground waters. The foremost method of reducing impacts to watersheds from urban development is "Low Impact Development" (LID), the goals of which are maintaining a landscape functionally equivalent to predevelopment hydrologic conditions and minimal generation of nonpoint source pollutants. LID results in less surface runoff and potentially less impacts to receiving waters. Principles of LID include:
- Maintaining natural drainage paths and landscape features to slow and filter runoff and maximize groundwater recharge,
 - Reducing the impervious cover created by development and the associated transportation network, and
 - Managing runoff as close to the source as possible.

We understand that LID development practices that would maintain aquatic values could also reduce local infrastructure requirements and maintenance costs, and could benefit air quality, open space, and habitat. Planning tools to implement the above principles and manuals are available to provide specific guidance regarding LID.

We request you require these principles to be incorporated into the proposed project design. We request natural drainage patterns be maintained to the extent feasible. Future development plans should consider the following items:

- [X] If the project involves land disturbance more than 1.0 acre in area, then the project requires development of a Stormwater Pollution Prevention Plan and
- a NPDES General Construction Stormwater Permit and/or
 - a NPDES General Industrial Stormwater Permit

- [X] The proposal does not provide specific information on how impacts to surface Waters of the State and/or Waters of the U.S. will be mitigated. These surface waters include, but are not limited to, drainages, streams, washes, ponds, pools or wetlands. Waters of the State or Waters of the U.S. may be permanent or intermittent. Waters of the State may include waters determined to be isolated or otherwise non-jurisdictional by the Army Corps of Engineers. The Environmental Document needs to quantify these impacts. Discuss purpose of project, need for surface water disturbance, and alternatives (avoidance, minimize disturbances and mitigation). Mitigation must be identified in the environmental document including timing of construction.


Mitigation must replace functions and values of wetlands lost. For more information see the Lahontan Region Basin Plan
http://www.waterboards.ca.gov/lahontan/BPlan/BPlan_Index.htm.

[X] Other

- Please include both pre-construction and post construction stormwater management and best management practices (BMP) as part of planning process.
- Please consider designs that minimize impervious surface, such as permeable surface parking areas, directing runoff onto vegetated areas using curb cuts and rock swales, etc., and infiltrating runoff as close to the source as possible to avoid forming erosion channels. Design features should be incorporated to ensure that runoff is not concentrated by the proposed project. The project must incorporate measures to ensure that stormwater generated by the project is managed on-site both pre-and post construction. Please show on plan drawings the on-site stormwater control measures.
- Please consider development features that span the drainage channels or allow for broad crossings. Design features of future development should be incorporated to ensure that runoff is not concentrated by the proposed project, thereby causing downstream erosion.
- If the proposed project impacts and alters drainages, then we request that the project to be designed such that it would maintain existing drainage features and patterns to the extend feasible. Please inform project proponent to consult with Army Corps of Engineers, Department of Fish and Game, and the Water Board prior to issuing a grading permit.

If you have any questions, please contact me at (760) 241-7376, or e-mail me at mhakakian@waterboards.ca.gov

Sincerely,



Mack Hakakian, PG
Engineering Geologist

MH/rc/CEQA comments/Kern County Beacon Solar Energy Project

California Environmental Protection Agency