

CALIFORNIA ENERGY COMMISSION
REPORT OF CONVERSATION Page 1 of 1



**Energy Facilities Siting and
 Environmental Protection
 Division**

FILE: 08-AFC-5

PROJECT TITLE: Imperial Solar

<input checked="" type="checkbox"/> Telephone	(714) 433-7622	<input type="checkbox"/> Meeting Location:	
NAME:	Rick Tyler Sr. Mechanical Engineer Worker Safety/Fire	DATE:	June 11, 2010
		TIME:	~3pm
WITH:	Tariq Hussain URS		
SUBJECT:	Design description of hydrogen generation, storage, handling System at Imperial Valley Solar		

I talked with Tariq about problems with description of the distributed hydrogen system. He stated that hydrogen would not be compressed to a liquid form. He stated that the 9 by 30 foot tank would be operated at a much lower pressure than would be associated with liquid hydrogen. If the tank would have stored liquid it would require cryogenic storage that was not described. This description was used by staff to prepare testimony. This description is not consistent with the applicants May 5 2010 supplemental AFC filing.

DOCKET	
08-AFC-5	
DATE	JUN 11 2010
RECD.	JUL 21 2010

cc: Rick Tyler, CEC Siting Division	Prepared by: Rick Tyler
--	--------------------------------