

California Energy Commission

**DOCKETED**  
**00-AFC-14C**

TN 70442

APR 23 2013

# EL SEGUNDO ENERGY CENTER PETITION TO AMEND (00-AFC-14C)



SUBMITTED BY


**EL SEGUNDO ENERGY CENTER LLC**



WITH TECHNICAL ASSISTANCE FROM

**CH2MHILL®**

APRIL 2013



# EL SEGUNDO ENERGY CENTER PETITION TO AMEND (00-AFC-14C)

SUBMITTED BY  
EL SEGUNDO ENERGY CENTER LLC



WITH TECHNICAL ASSISTANCE FROM  
**CH2MHILL**®

APRIL 2013



# Contents

---

| Section  | Page       |
|--|------------|
| <b>Acronyms and Abbreviations</b> .....  | <b>xi</b>  |
| <b>1.0 Executive Summary</b> .....   | <b>1-1</b> |
| 1.1 Project Overview .....   | 1-1        |
| 1.2 Overview of Proposed Changes.....  | 1-2        |
| 1.3 Project Location .....   | 1-3        |
| 1.4 Project History and Overview of PTA Request .....                          | 1-4        |
| 1.5 June 2007 PTA.....   | 1-4        |
| 1.6 April 2012 PTA COC Revisions for Ammonia Use and Facility Name Change..... | 1-4        |
| 1.7 Consistency of 2013 Amendment with License.....                            | 1-5        |
| 1.8 Necessity of Proposed Change .....   | 1-5        |
| 1.9 Cumulative Impacts .....   | 1-5        |
| 1.10 Compliance with Laws, Regulations, Ordinances and Standards .....         | 1-5        |
| 1.11 Document Organization.....  | 1-6        |
| 1.12 Schedule .....  | 1-6        |
| 1.13 Necessity for the Proposed Modifications .....                            | 1-6        |
| 1.14 Project Ownership .....   | 1-7        |
| 1.15 Recommendations and Conclusions.....                                      | 1-7        |
| <b>2.0 Project Description</b> .....   | <b>2-1</b> |
| 2.1 Introduction .....   | 2-1        |
| 2.1.1 Ongoing Construction.....  | 2-2        |
| 2.1.2 Project Location.....  | 2-2        |
| 2.1.3 Topography.....  | 2-2        |
| 2.1.4 Geologic Setting and Seismology.....                                     | 2-3        |
| 2.2 Facility Design .....  | 2-3        |
| 2.2.1 Equipment Technology.....  | 2-3        |
| 2.2.2 Equipment Layout.....  | 2-6        |
| 2.2.3 Site Access .....  | 2-7        |
| 2.2.4 Electric Transmission .....  | 2-7        |
| 2.2.5 Fuel Gas System.....   | 2-7        |
| 2.2.6 Capacity Factor .....  | 2-8        |
| 2.2.7 Efficiency and Reliability.....  | 2-8        |
| 2.2.8 Benefits.....  | 2-8        |
| 2.3 Water Requirements and Demand.....   | 2-9        |
| 2.4 Waste Management .....   | 2-12       |
| 2.4.1 Management and Disposal of Hazardous Materials and Hazardous Wastes..... | 2-17       |
| 2.4.2 Hazardous Materials Handling.....  | 2-20       |
| 2.4.3 Hazardous Wastes .....   | 2-20       |
| 2.4.4 Wastewater .....   | 2-20       |
| 2.5 Site Drainage.....   | 2-22       |
| 2.6 Air Emission Characteristics.....  | 2-22       |
| 2.6.1 Emissions Control and Monitoring Equipment.....                          | 2-22       |
| 2.6.2 NO <sub>x</sub> Emissions .....  | 2-23       |
| 2.6.3 CO Emissions.....  | 2-23       |
| 2.6.4 VOC Emissions .....  | 2-24       |
| 2.6.5 Particulates .....   | 2-24       |
| 2.6.6 Emission Monitoring.....   | 2-24       |
| 2.7 Fire Protection .....  | 2-24       |

|            |  |            |
|------------|--|------------|
| 2.8        | Construction .....   | 2-25       |
| 2.8.1      | Construction Schedule and Workforce.....                           | 2-26       |
| 2.8.2      | Construction Plans.....  | 2-28       |
| 2.8.3      | Mobilization.....  | 2-29       |
| 2.8.4      | Oversize Equipment Delivery.....                                   | 2-34       |
| 2.8.5      | Construction Office Facilities.....                                | 2-34       |
| 2.8.6      | Construction Laydown and Parking.....                              | 2-34       |
| 2.8.7      | Emergency Facilities .....   | 2-35       |
| 2.8.8      | Construction Utilities.....  | 2-35       |
| 2.8.9      | Site Services.....   | 2-35       |
| 2.8.10     | Construction Materials and Equipment .....                         | 2-35       |
| 2.8.11     | Construction Sequence and Schedule .....                           | 2-36       |
| 2.9        | Facility Operation.....  | 2-37       |
| 2.9.1      | Power Plant Facility .....   | 2-37       |
| 2.9.2      | Operation with Seasonal Variation in Ambient Temperature.....      | 2-37       |
| 2.9.3      | Annual Operating Practices .....                                   | 2-37       |
| 2.9.4      | Facility Controls .....  | 2-37       |
| 2.9.5      | Reliability and Redundancy .....                                   | 2-38       |
| 2.9.6      | Utilities.....   | 2-38       |
| 2.10       | Facility Closure.....  | 2-39       |
| <b>3.0</b> | <b>Environmental Analysis .....</b>                                | <b>3-1</b> |
| 3.1        | Air Quality.....   | 3-1        |
| 3.1.1      | Introduction.....  | 3-1        |
| 3.1.2      | Affected Environment .....   | 3-2        |
| 3.1.3      | LORS Compliance.....   | 3-11       |
| 3.1.4      | Environmental Consequences .....                                   | 3-23       |
| 3.1.5      | Cumulative Air Quality Impacts.....                                | 3-42       |
| 3.1.6      | Consistency with Laws, Ordinances, Regulations, and Standards..... | 3-45       |
| 3.1.7      | Mitigation Measures.....   | 3-54       |
| 3.1.8      | Permits Required and Permit Schedule.....                          | 3-55       |
| 3.1.9      | References .....   | 3-56       |
| 3.2        | Biological Resources .....   | 3-59       |
| 3.2.1      | Amendment Overview.....  | 3-59       |
| 3.2.2      | Affected Environment .....   | 3-59       |
| 3.2.3      | Environmental Analysis .....                                       | 3-62       |
| 3.2.4      | Cumulative Impacts .....   | 3-63       |
| 3.2.5      | Laws, Ordinances, Regulations and Standards.....                   | 3-63       |
| 3.2.6      | Conditions of Certification.....                                   | 3-63       |
| 3.3        | Cultural Resources.....  | 3-71       |
| 3.3.1      | Amendment Overview.....  | 3-71       |
| 3.3.2      | Affected Environment .....   | 3-71       |
| 3.3.3      | Environmental Analysis .....                                       | 3-72       |
| 3.3.4      | Cumulative Impacts .....   | 3-72       |
| 3.3.5      | Laws, Ordinances, Regulations and Standards.....                   | 3-72       |
| 3.3.6      | Conditions of Certification.....                                   | 3-72       |
| 3.4        | Geology and Paleontology.....                                      | 3-79       |
| 3.4.1      | Amendment Overview.....  | 3-79       |
| 3.4.2      | Affected Environment .....   | 3-79       |
| 3.4.3      | Environmental Analysis .....                                       | 3-80       |
| 3.4.4      | Cumulative Impacts .....   | 3-80       |
| 3.4.5      | Laws, Ordinances, Regulations and Standards.....                   | 3-80       |

|      |        |   |       |
|------|--------|---|-------|
|      | 3.4.6  | Conditions of Certification.....                  | 3-80  |
| 3.5  |        | Hazardous Materials.....                          | 3-89  |
|      | 3.5.1  | Amendment Overview.....                           | 3-89  |
|      | 3.5.2  | Affected Environment .....                        | 3-89  |
|      | 3.5.3  | Cumulative Impacts .....                          | 3-90  |
|      | 3.5.4  | Laws, Ordinances, Regulations, and Standards..... | 3-90  |
|      | 3.5.5  | Conditions of Certification.....                  | 3-91  |
| 3.6  |        | Land Use .....                                    | 3-93  |
|      | 3.6.1  | Amendment Overview.....                           | 3-93  |
|      | 3.6.2  | Affected Environment .....                        | 3-93  |
|      | 3.6.3  | ESEC Amendments.....                              | 3-94  |
|      | 3.6.4  | Environmental Analysis .....                      | 3-95  |
|      | 3.6.5  | Cumulative Impacts .....                          | 3-95  |
|      | 3.6.6  | Laws, Ordinances, Regulations, and Standards..... | 3-96  |
|      | 3.6.7  | Conditions of Certification.....                  | 3-96  |
| 3.7  |        | Noise and Vibration .....                         | 3-103 |
|      | 3.7.1  | Amendment Overview.....                           | 3-103 |
|      | 3.7.2  | Affected Environment .....                        | 3-103 |
|      | 3.7.3  | ESEC Amendments.....                              | 3-103 |
|      | 3.7.4  | Environmental Analysis .....                      | 3-104 |
|      | 3.7.5  | Cumulative Impacts .....                          | 3-104 |
|      | 3.7.6  | Laws, Ordinances, Regulations, and Standards..... | 3-104 |
|      | 3.7.7  | Conditions of Certification.....                  | 3-105 |
| 3.8  |        | Public Health.....                                | 3-111 |
|      | 3.8.1  | Affected Environment .....                        | 3-111 |
|      | 3.8.2  | Environmental Consequences .....                  | 3-112 |
|      | 3.8.3  | Cumulative Impacts .....                          | 3-115 |
|      | 3.8.4  | Conclusions and Recommendations.....              | 3-115 |
|      | 3.8.5  | References .....                                  | 3-115 |
| 3.9  |        | Socioeconomics .....                              | 3-117 |
|      | 3.9.1  | Amendment Overview.....                           | 3-117 |
|      | 3.9.2  | Affected Environment .....                        | 3-117 |
|      | 3.9.3  | Environmental Analysis .....                      | 3-117 |
|      | 3.9.4  | Cumulative Impacts .....                          | 3-119 |
|      | 3.9.5  | Laws, Ordinances, Regulations, and Standards..... | 3-119 |
|      | 3.9.6  | Conditions of Certification.....                  | 3-119 |
| 3.10 |        | Soil and Water Resources.....                     | 3-121 |
|      | 3.10.1 | Amendment Overview.....                           | 3-121 |
|      | 3.10.2 | Affected Environment .....                        | 3-121 |
|      | 3.10.3 | Environmental Analysis .....                      | 3-121 |
|      | 3.10.4 | Cumulative Impacts .....                          | 3-122 |
|      | 3.10.5 | Laws, Ordinances, Regulations and Standards.....  | 3-122 |
|      | 3.10.6 | Conditions of Certification.....                  | 3-122 |
| 3.11 |        | Traffic and Transportation.....                   | 3-127 |
|      | 3.11.1 | Amendment Overview.....                           | 3-127 |
|      | 3.11.2 | Affected Environment .....                        | 3-127 |
|      | 3.11.3 | Environmental Analysis .....                      | 3-132 |
|      | 3.11.4 | Cumulative Impacts .....                          | 3-134 |
|      | 3.11.5 | Laws, Ordinances, Regulations, and Standards..... | 3-134 |
|      | 3.11.6 | Conditions of Certification.....                  | 3-134 |
|      | 3.11.7 | References .....                                  | 3-136 |

|            |  |            |
|------------|--|------------|
| 3.12       | Visual Resources .....                           | 3-143      |
| 3.12.1     | Amendment Overview.....                          | 3-143      |
| 3.12.2     | Affected Environment .....                       | 3-143      |
| 3.12.3     | Environmental Analysis .....                     | 3-144      |
| 3.12.4     | Cumulative Impacts .....                         | 3-148      |
| 3.12.5     | Laws, Ordinances, Regulations and Standards..... | 3-148      |
| 3.12.6     | Conditions of Certification.....                 | 3-148      |
| 3.12.7     | References Cited or Consulted .....              | 3-156      |
| 3.13       | Waste Management .....                           | 3-171      |
| 3.13.1     | Amendment Overview.....                          | 3-172      |
| 3.13.2     | Affected Environment .....                       | 3-171      |
| 3.13.3     | Environmental Analysis .....                     | 3-171      |
| 3.13.4     | Cumulative Impacts .....                         | 3-172      |
| 3.13.5     | Laws, Ordinances, Regulations and Standards..... | 3-172      |
| 3.13.6     | Conditions of Certification.....                 | 3-172      |
| 3.14       | Worker Health and Safety .....                   | 3-175      |
| 3.14.1     | Amendment Overview.....                          | 3-175      |
| 3.14.2     | Affected Environment .....                       | 3-175      |
| 3.14.3     | Environmental Analysis .....                     | 3-175      |
| 3.14.4     | Cumulative Impacts .....                         | 3-177      |
| 3.14.5     | Laws, Ordinances, Regulations and Standards..... | 3-177      |
| 3.14.6     | Conditions of Certification.....                 | 3-177      |
| <b>4.0</b> | <b>Potential Effects on the Public.....</b>      | <b>4-1</b> |
| 4.1        | Potential Effects on the Public.....             | 4-1        |
| <b>5.0</b> | <b>List of Property Owners .....</b>             | <b>5-1</b> |
| 5.1        | List of Property Owners.....                     | 5-1        |
| <b>6.0</b> | <b>Potential Effects on Property Owners.....</b> | <b>6-1</b> |
| 6.1        | Potential Effects on Property Owners .....       | 6-1        |

**Appendices**

|        |   |
|--------|---|
| 3.1A–H | Air Quality Technical Information           |
| 3.1A   | Emissions Calculations and Support Data     |
| 3.1B   | Modeling Support Data                       |
| 3.1C   | Modeling Protocol                           |
| 3.1D   | Construction Emissions and Support Data     |
| 3.1E   | Commissioning Emissions and Support Data    |
| 3.1F   | Best Available Control Technology Analysis  |
| 3.1G   | Offset/Mitigation Support Data              |
| 3.1H   | Cumulative Impacts Analysis Emission Data   |
| 3.8A   | Public Health Calculations and Support Data |

**Tables**

|        |  |
|--------|--|
| 1-1    | Technical Sections with New or Modified Conditions of Certification  |
| 1-2A   | Unit Output Ratings (gross and net MW)   |
| 1-2B   | Retirement/Replacement Summary   |
| 2-1    | Dimensions of Significant Structures   |
| 2-2    | GE Fast-Start Gas Turbine Specifications   |
| 2-3    | Trent 60 Gas Turbine Specifications (Per Turbine)  |
| 2-4    | Auxiliary Boiler   |
| 2-5    | Daily Water Supply Requirements  |
| 2-6    | Expected Water Supply Quality  |
| 2-7    | Annual Water Use by Source   |
| 2-8    | Daily Water Supply Requirements  |
| 2-9    | Existing and Projected Water Use   |
| 2-10   | Estimated Quantities of Asbestos-containing Materials  |
| 2-11   | Asbestos-containing Materials  |
| 2-12   | Summary of Construction Waste Streams and Management Methods   |
| 2-13   | Operating Waste Streams and Management Methods   |
| 2-14   | Hazardous Materials and Wastes Usage and Storage during Construction and Operations                                |
| 2-15   | Expected Process Waste Characterization  |
| 2-16   | Estimated Liquid Process Wastewater Volumes to Discharge   |
| 2-17   | Anticipated Chemical Usage and Storage   |
| 2-18   | Excavation Requirements  |
| 2-19   | Project Labor Needs and Available Labor by Craft/Skill   |
| 2-20   | Construction Staffing Schedule   |
| 2-21   | Demolition Equipment Usage   |
| 2-22   | Schedule of Truck Deliveries/Demolition Materials (Excluding Heavy Equipment Deliveries)                           |
| 2-23   | Heavy Equipment Delivery Schedule  |
| 2-24   | Construction Equipment Usage   |
| 2-25   | Construction Schedule for Truck Deliveries of Equipment (Excluding Heavy Equipment Deliveries)                     |
| 3.1-1  | Average Temperatures and Precipitation at Los Angeles Airport, Los Angeles County (1971-2000)                      |
| 3.1-2  | National and California Ambient Air Quality Standards  |
| 3.1-3  | Ozone Levels at LAX Station, Los Angeles Westchester Parkway (ppm)   |
| 3.1-4  | Nitrogen Dioxide Levels At LAX Station, Los Angeles Westchester Parkway (ppm)                                      |
| 3.1-5  | Carbon Monoxide Levels at LAX Station, Los Angeles Westchester Parkway (ppm)                                       |
| 3.1-6  | Sulfur Dioxide Levels at LAX Station, Los Angeles Westchester Parkway (ppm)  |
| 3.1-7  | Particulate Matter (PM <sub>10</sub> ) Levels at LAX Station, Los Angeles Westchester Parkway (µg/m <sup>3</sup> ) |
| 3.1-8  | Particulate Matter (PM <sub>2.5</sub> ) Levels at North Long Beach (µg/m <sup>3</sup> )                            |
| 3.1-9  | Lead Levels at Los Angeles North Main Street Station (ng/m <sup>3</sup> )  |
| 3.1-10 | PSD Significant Emission Thresholds  |
| 3.1-11 | PSD Increments and Significant Impact Levels   |
| 3.1-12 | Laws, Ordinances, Regulations, and Standards   |
| 3.1-13 | Maximum Daily Construction Emissions, Pounds per Day—Month 19 (Combustion), Month 6 (Fugitive Dust)                |
| 3.1-14 | Maximum Annual Construction Emissions, Tons per Year   |
| 3.1-15 | Commissioning Emissions  |
| 3.1-16 | Maximum Emission Rates—Combustion Turbines   |
| 3.1-17 | El Segundo Power Facility Modification—Turbine Startup/Shutdown Emissions  |
| 3.1-18 | Emission Summary (Maximum for Each Averaging Period)   |



**Tables, cont.**

|        |  |
|--------|--|
| 3.1-19 | Non-Criteria Pollutant Emission Totals for Modeling  |
| 3.1-20 | Project Greenhouse Gas Emissions   |
| 3.1-21 | Construction Greenhouse Gas Emissions  |
| 3.1-22 | Modeled Maximum Impacts During Construction  |
| 3.1-23 | Modeled Maximum Impacts During Commissioning   |
| 3.1-24 | NO <sub>2</sub> /NO <sub>x</sub> Ratios Used in Refined Modeling   |
| 3.1-25 | Modeling Results for New Units (µg/m <sup>3</sup> )  |
| 3.1-26 | Modeling Results for Entire Facility (µg/m <sup>3</sup> )  |
| 3.1-27 | Maximum Background Concentrations, 2009 – 2011 (µg/m <sup>3</sup> )  |
| 3.1-28 | Modeled Maximum Impacts for New Units (µg/m <sup>3</sup> )   |
| 3.1-29 | Modeled Maximum Impact for Entire Facility (µg/m <sup>3</sup> )  |
| 3.1-30 | Comparison of Modeled Maximum Project Impacts with PSD SILS and Preconstruction Monitoring Thresholds (µg/m <sup>3</sup> ) |
| 3.1-31 | Comparison of Modeled Project Impacts with District Significant Change Thresholds (µg/m <sup>3</sup> )                     |
| 3.1-32 | Comparison of Project Emissions to Regional Precursor Emissions in 2010: Annual Basis*                                     |
| 3.1-33 | PSD Significant Emission Thresholds  |
| 3.1-34 | Compliance with 40 CFR 60 Subpart KKKK   |
| 3.1-35 | Applicability of BACT Requirements Under NSR   |
| 3.1-36 | Summary of Proposed BACT   |
| 3.1-37 | ESPFM Offset Requirements  |
| 3.2-1  | Summary of Changes/Additions of Potentially Occurring Special Status Species in the Project Area (USGS Venice quad)        |
| 3.8-1  | Maximum Onsite Construction DPM Emissions  |
| 3.8-2  | HARP Modeling Results – Maximum Impacts  |
| 3.11-1 | Comparison of Study Intersection LOS from 2000 to 2011   |
| 3.11-2 | Area Bike Routes   |
| 3.11-3 | Roadways Traveled Per Parking Lot Location   |
| 5-1    | Property Owners within 1,000 Feet of the Project   |

**Figures**

|      |   |
|------|---|
| 1-1  | Vicinity Map  |
| 1-2a | Site Plan – Sheet 1   |
| 1-2b | Site Plan – Sheet 2   |
| 2-1  | Existing El Segundo Energy Center                                   |
| 2-2  | Existing Topography   |
| 2-3a | Grading Plan – Key Plan   |
| 2-3b | Grading Plan – Sheet 1  |
| 2-3c | Grading Plan – Sheet 2  |
| 2-3d | Grading Plan – Profiles and Sections                                |
| 2-4  | GE 1x1 7FA CC Fast Process Flow Diagram – Heat & Material Balance   |
| 2-5  | Rolls Royce Trent 60 Process Flow Diagram - Heat & Material Balance |
| 2-6  | Existing Equipment/Processes to be Removed                          |
| 2-7  | Existing and Proposed Site Access                                   |

**Figures, cont.**

|        |  |
|--------|--|
| 2-8    | Process Flow Diagram - Water Balance Diagram - Maximum Ambient Temperature |
| 2-9    | Process Flow Diagram - Water Balance Diagram - Average Ambient Temperature |
| 2-10   | Construction Laydown Areas   |
| 3.2-1  | CNDDDB Results within 2 Miles  |
| 3.11-1 | Regional Road Network  |
| 3.11-2 | Local Road Network   |
| 3.11-3 | Study Intersections  |
| 3.12-1 | Key Observation Point Locations  |
| 3.12-2 | View from Key Observation Point 1  |
| 3.12-3 | View from Key Observation Point 2  |
| 3.12-4 | View from Key Observation Point 3  |
| 3.12-5 | View from Key Observation Point 7  |
| 3.12-6 | View from Key Observation Point 8  |
| 3.12-7 | View from Key Observation Point 10   |



# Acronyms and Abbreviations

---

|                   |  |
|-------------------|--|
| °F                | Fahrenheit   |
| µg/m <sup>3</sup> | micrograms per cubic meter   |
| ACM               | asbestos-containing materials                                      |
| AFC               | Application for Certification                                      |
| AFY               | acre-feet per year   |
| APCD              | air pollution control district                                     |
| ARMR              | Archaeological Resource Management Report                          |
| BMP               | Best Management Practice   |
| BRMIMP            | Biological Resources Mitigation Implementation and Monitoring Plan |
| CAA               | Clean Air Act  |
| CAAQS             | California Ambient Air Quality Standards                           |
| CAISO             | California Independent System Operator                             |
| CalEEMod          | California Emissions Estimator Model                               |
| CAM               | Compliance Assurance Monitoring                                    |
| CARB              | California Air Resources Board                                     |
| CBO               | Chief Building Official  |
| CCR               | California Code of Regulations                                     |
| CCS               | carbon control and capture system                                  |
| CEC               | California Energy Commission                                       |
| CEM               | continuous emission monitoring                                     |
| CESFD             | City of El Segundo Fire Department                                 |
| CFR               | Code of Federal Regulations  |
| CHRIS             | California Historic Resource Information System                    |
| CMBFD             | City of Manhattan Beach Fire Department                            |
| CNDDB             | California Natural Diversity Database                              |
| CNPS              | California Native Plant Society                                    |
| CO                | carbon monoxide  |
| CO <sub>2</sub>   | carbon dioxide   |
| COC               | Condition of Certification   |
| CPUC              | California Public Utilities Commission                             |
| CRHR              | California Register of Historic Resources                          |
| CRM               | cultural resource monitor  |
| CRMMP             | Cultural Resources Monitoring and Mitigation Plan                  |

|          |  |
|----------|--|
| CRR      | Cultural Resource Report                       |
| CRS      | Cultural Resources Specialist                  |
| CSS      | Construction Safety Supervisor                 |
| CT       | Combustion Turbine                             |
| CTG      | combustion turbine generator                   |
| DCS      | digital control and monitoring system          |
| DESC     | Drainage, Erosion, and Sediment Control Plan   |
| DLE      | dry low emission                               |
| DLN/DLE  | dry low-NO <sub>x</sub> /dry low emissions     |
| DOC      | Determination of Compliance                    |
| DPM      | diesel particulate matter                      |
| EPA      | U.S. Environmental Protection Agency           |
| EPS      | Emissions Performance Standard                 |
| ERC      | emission reduction credits                     |
| ESEC     | El Segundo Energy Center                       |
| ESEC LLC | El Segundo Energy Center LLC                   |
| ESGS     | El Segundo Generating Station                  |
| ESPFM    | Segundo Power Facility Modification            |
| ESPR     | El Segundo Power Redevelopment Project         |
| FAA      | Federal Aviation Administration                |
| FDOC     | Final Determination of Compliance              |
| GEP      | Good Engineering Practices                     |
| GHG      | greenhouse gas                                 |
| GTG      | gas turbine generator                          |
| H&SC     | Health & Safety Code                           |
| HAPs     | hazardous air pollutants                       |
| HARP     | CARB's Hotspots Analysis and Reporting Program |
| HMI      | Human Machine Interface                        |
| HOV      | Occupancy Vehicle                              |
| HRA      | health risk assessment                         |
| HRSR     | heat recovery steam generator                  |
| I/O      | input/output                                   |
| ISI      | Inlet Spray Inter-Cooling                      |
| KOP      | Key Observation Point                          |
| L50      | ambient median noise level                     |

---

|                   |  |
|-------------------|--|
| LAER              | lowest achievable emission rate                          |
| LAMTA             | Los Angeles County Metropolitan Transportation Authority |
| LARWQCB           | Los Angeles Regional Water Quality Control Board         |
| LAX               | Los Angeles International Airport                        |
| LGIA              | Large Generator Interconnect Agreement                   |
| LORS              | laws, ordinances, regulations, and standards             |
| LOS               | level of service   |
| MCR               | Monthly Compliance Report                                |
| MEI               | Maximum Exposed Individual                               |
| MEIR              | existing Residential receptor                            |
| MLLW              | mean lower low water                                     |
| msl               | mean sea level   |
| MW                | megawatts  |
| NAAQS             | Ambient Air Quality Standards                            |
| NAD83             | UTM North American Datum 1983                            |
| NANSR             | Nonattainment New Source Review                          |
| NED               | National Elevation Dataset                               |
| NESHAPS           | National Emission Standards for Hazardous Air Pollutants |
| NFPA              | National Fire Protection Association                     |
| NH <sub>3</sub>   | ammonia  |
| NO <sub>2</sub>   | nitrogen dioxide   |
| NO <sub>x</sub>   | oxides of nitrogen                                       |
| NPDES             | National Pollutant Discharge Elimination System          |
| NRG               | NRG Energy, Inc  |
| NSPS              | Standards of Performance for New Stationary Sources      |
| NSR               | New Source Review  |
| O <sub>3</sub>    | ozone  |
| OEHHA             | Office of Environmental Health Hazard Assessment         |
| PAH               | polycyclic aromatic hydrocarbon                          |
| PDOC              | Preliminary Determination of Compliance                  |
| PM <sub>10</sub>  | particulate matter less than 10 microns in diameter      |
| PM <sub>2.5</sub> | particulate matter less than 2.5 microns in diameter     |
| PMI               | point of maximum impact                                  |
| ppm               | parts per million  |
| PRM               | Paleontological Resource Monitors                        |

|                 |  |
|-----------------|--|
| PRMMP           | Paleontological Resources Monitoring and Mitigation Plan |
| PRR             | Paleontological Resources Report                         |
| PRS             | Paleontological Resource Specialist                      |
| PSD             | Prevention of Significant Deterioration                  |
| PTA             | Petition to Amend  |
| PTC             | Permit to Construct                                      |
| PTO             | Permit to Operate  |
| RBM             | Regulated Building Materials                             |
| REL             | Reference Exposure Level                                 |
| RMP             | Risk Management Plan                                     |
| RO              | reverse osmosis  |
| ROU             | receptor-output  |
| RPS             | Renewable Portfolio Standard                             |
| SCAQMD          | South Coast Air Quality Management District              |
| SCE             | Southern California Edison                               |
| scf             | standard cubic feet                                      |
| SCR             | selective catalytic reduction system                     |
| SCRTD           | Southern California Rapid Transit District               |
| SHPO            | State Historic Preservation Officer                      |
| SIL             | significance impact level                                |
| SIP             | State Implementation Plan                                |
| SO <sub>2</sub> | sulfur dioxide   |
| SoCalGas        | Southern California Gas                                  |
| SOx             | sulfur oxides  |
| STG             | steam turbine generator                                  |
| SUSMP           | Standard Urban Stormwater Mitigation Plan                |
| SVP             | Society of Vertebrate Paleontologists                    |
| SWPPP           | Storm Water Pollution Prevention Plan                    |
| SWRCB           | State Water Resources Control Board                      |
| TAC             | toxic air contaminants                                   |
| T-BACT          | Toxics Best Available Control Technology                 |
| THI             | total hazard index                                       |
| TPY             | Ton(s) per year  |
| TSP             | total suspended particulate                              |
| USC             | United States Code                                       |

|       |  |
|-------|--|
| USFWS | U.S. Fish and Wildlife Service         |
| USGS  | U.S. Geological Survey                 |
| VOC   | volatile organic compounds             |
| VOC   | Volatile organic compounds             |
| WEAP  | Worker Environmental Awareness Program |
| WPCD  | Water Pollution Control Drawing        |





# Executive Summary

---

## 1.1 Project Overview

El Segundo Energy Center LLC (ESEC LLC), the Project Owner, a wholly owned subsidiary of NRG Energy, Inc (NRG), proposes to modify the El Segundo Energy Center (ESEC), 00-AFC-14C, Final Decision to make substantial changes to the ESEC. Chief among these changes is the replacement of two once-through-cooled boiler units, Units 3 and 4, with modern and efficient, dry-cooled, natural-gas-fired combustion gas turbine units. This change will eliminate the use of ocean water for once-through cooling at the facility. The proposed changes will also upgrade and improve the ESEC's existing and approved site infrastructure, and provide fast start and dispatch flexibility capabilities to support southern California grid load balancing and renewable energy integration, and implement improvements to coastal access.

Specific changes proposed through this Petition to Amend (PTA) include:

- Shutdown and demolition of Units 3 and 4
- Removal and remediation of existing ESEC retention basins
- Change in location for the permitted (but not yet constructed) administration building to a lower elevation
- Construction of a new, combined administration, maintenance, and operations support building
- Modifications to existing site access
- Improvements to beach access

The following new major equipment will be installed:

- One NRG fast start combined-cycle unit (CC Fast™), rated at 325 megawatts (MW) net, incorporating a General Electric 7FA.05 natural gas turbine
- Two Rolls Royce Trent 60 DLE ISI, rated at 55 MW/unit net, consisting of advanced aeroderivative simple-cycle gas turbines
- One Cleaver Brooks 36 MMBtu/hr auxiliary boiler

Table 1-1 lists the technical areas addressed in this PTA and those areas where the Project Owner is requesting changes to the 00-AFC-14C Final Decision, including subsequent amendments, and the Conditions of Certification (COC) that are currently in effect. The details of the proposed changes to the COCs can be found in the appropriate technical areas in this PTA.

The environmental analysis in Section 3.0 concludes that the proposed changes to the ESEC will not create or cause any unmitigated significant environmental impacts nor create any issues regarding compliance with applicable laws, ordinances, regulations, and standards (LORS).

**TABLE 1-1**  
**Technical Sections with New or Modified Conditions of Certification**

| Technical Area                        | New or Revised COCs | Technical Area                  | New or Revised COCs |
|---------------------------------------|---------------------|---------------------------------|---------------------|
| Air Quality                           | Yes                 | Traffic and Transportation      | No                  |
| Biological Resources                  | Yes                 | Visual Resources                | Yes                 |
| Cultural Resources                    | Yes                 | Waste Management                | No                  |
| Hazardous Materials Management        | No                  | Worker Safety/Fire Protection   | No                  |
| Land Use                              | Yes                 | Facility Design                 | Yes                 |
| Noise and Vibration                   | No                  | Geology and Paleontology        | Yes                 |
| Public Health                         | Yes                 | Power Plant Efficiency          | Yes                 |
| Soil and Water Resources              | Yes                 | Power Plant Reliability         | Yes                 |
| Socioeconomic Resources               | No                  | Transmission System Engineering | Yes                 |
| Transmission Line Safety and Nuisance | No                  |                                 |                     |

## 1.2 Overview of Proposed Changes

ESEC LLC has proposed the El Segundo Power Facility Modification (ESPFM) as the modification of the licensed ESEC. This PTA describes the respective modifications and additions to the ESEC. The ESPFM will provide fast-start and dispatch flexibility capabilities through the installation Units 9, 10, 11, and 12, adding approximately 435 MW (net) / 449 MW (gross) of new generation to the existing 560 MW (net) / 573 MW (gross) ESEC, identified as Units 5 through 8. Operation of Units 5 through 8 and proposed Units 9 through 12 will result in a total generating capacity of approximately 995 MW (net) / 1,022 MW (gross). The net rated energy that would be transmitted from the ESEC as proposed by this PTA is 995 MW, consistent with the Large Generator Interconnect Agreements (LGIA) filed with the California Independent System Operator (CAISO) for ESEC and ESPFM. The net rated capacity of previously retired Units 1 and 2 (demolished and retired as part of 00-AFC-14) and Units 3 and 4 (proposed for demolition and retirement as part of this PTA) is 1,020 MW; gross generation of Units 1 through 4 has been approximately 1,052 MW. Table 1-2A lists the gross and net generating capacities of Units 1 through 12. This table is being presented to identify turbine ratings which reflect differences in total megawatts generated as a result of presenting the gross or net outputs. Table 1-2B summarizes the demolition, retirement, and replacement generating capacity associated with the removal of Units 1 through 4 and the installation of Units 5 through 12.

These additions are subject to the California Energy Commission's (CEC) Siting Regulations Section 1769 requirements. The ESPFM includes a combination of advanced, efficient simple-cycle units and an advanced combined-cycle train with the overall thermal efficiency and low emissions of traditional combined-cycle units with fast-start capabilities similar to peaking units. These units will significantly reduce the amount of startup emissions to deliver electricity to the grid, and the installation of dry-cooling will eliminate the intake and discharge of ocean water required for once-through-cooling.

The timing for implementation of the ESEC (00-AFC-14C) will result in shut-down of Unit 3 within 90 days of first-fire of Unit 5, or by June 30, 2013, and shutdown of Unit 4 in mid-2015 to coincide with the State of California's once-through-cooling policy for El Segundo Generating Station with a stated compliance obligation of December 31, 2015. Commencement of demolition of Units 3 and 4 is planned for the end of 2015. Construction of the proposed ESPFM is anticipated to commence by mid-2016, after Units 3 and 4 are removed, and conclude in 2018 to meet a projected on-line date of summer 2018. The existing cessation of generation from Units 3 and 4, followed by their demolition, and proposed ESPFM construction, operation, and generation are subject to an approved power purchase agreement.

TABLE 1-2A  
Unit Output Ratings (gross and net MW)

| Prior Total: Units 1–4 |             |             | Units 5–8    |            |            | Units 9–12   |              |            | New Total    |               |            |
|------------------------|-------------|-------------|--------------|------------|------------|--------------|--------------|------------|--------------|---------------|------------|
| Unit                   | Gross       | Net         | Unit         | Gross      | Net        | Unit         | Gross        | Net        | Unit         | Gross         | Net        |
| 1                      | 183         | 175         | 5&6          | 286.5      | 280        | 9&10         | 334          | 325        | 5&6          | 286.5         | 280        |
| 2                      | 183         | 175         | 7&8          | 286.5      | 280        | 11           | 57.4         | 55         | 7&8          | 286.5         | 280        |
| 3                      | 343         | 335         |              |            |            | 12           | 57.4         | 55         | 9&10         | 334           | 325        |
| 4                      | 343         | 335         |              |            |            |              |              |            | 11           | 57.4          | 55         |
|                        |             |             |              |            |            |              |              |            | 12           | 57.4          | 55         |
| <b>Total</b>           | <b>1052</b> | <b>1020</b> | <b>Total</b> | <b>573</b> | <b>560</b> | <b>Total</b> | <b>448.8</b> | <b>435</b> | <b>Total</b> | <b>1021.8</b> | <b>995</b> |

TABLE 1-2B  
Retirement/Replacement Summary

| Retired/To Be Retired | Capacity                          | Cycle        | Replacement/Capacity  |
|-----------------------|-----------------------------------|--------------|---|
| Units 1 and 2         | 175 MW/each for a total of 350 MW | Steam Boiler | Units 5 and 6 and Units 7 and 8 as two trains of combined cycle = 573 MW gross                    |
| Unit 3*               | 335 MW                            | Steam Boiler |   |
| Unit 4                | 335 MW                            | Steam Boiler | Units 9 and 10 as combined cycle and Units 11 and 12 as advanced gas turbines = 435 MW net rating |
| <b>TOTAL</b>          | <b>Retired: 1,020 MW (net)</b>    |              | <b>New: 1,022 MW (gross)</b>  |

\*The installation of Units 5, 6, 7, and 8 (gross 573 MW) required the use of the combined 350 MW from Units 1 and 2, and 223 MW of the 335 MW available from Unit 3. The remaining 112 MW associated with the total MW capacity of Unit 3 will be used to meet the installed capacity for Units 9, 10, 11, and 12 (435 MW net / 449 MW gross). Nominal rating of ESPFM is approximately 440 MW.

Due to the nominal ratings of the turbines, adding the MW together, the facility is less than 1,020 MW (573 MW + 440 MW). For planning purposes, ESEC LLC has assumed that it is a MW – MW replacement project.

## 1.3 Project Location

The El Segundo Generating Station (ESGS; the site of the facility), as originally named by the former owner Southern California Edison (SCE), is a natural-gas-fired electric power generating station located at 301 Vista Del Mar Boulevard in El Segundo, California. Figure 1-1 provides a location map and Figures 1-2a and 1.2b provide a site layout map. The site is located at the southernmost city limit of El Segundo on the coast of the Pacific Ocean between Dockweiler State Beach and the city of Manhattan Beach. It is located less than a 0.25 mile south of the Los Angeles Department of Water and Power's Scattergood power plant and 0.5 mile south of the City of Los Angeles' Hyperion Wastewater Treatment Plant. The Chevron El Segundo refinery is located across Vista Del Mar. The city of Manhattan Beach is immediately to the south. The ESGS is located approximately 2.5 miles southwest of the Los Angeles International Airport and west of the San Diego Freeway (I-405) on the eastern shore of Santa Monica Bay. The site is bordered by Vista Del Mar and the Chevron refinery to the east, 45th Street in the city of Manhattan Beach on the south, Santa Monica Bay on the west, and the Chevron Marine Terminal on the north. Electricity generated from the 33-acre site is transmitted to the adjoining SCE switchyard that is physically within the fenced boundary of the facility.

## 1.4 Project History and Overview of PTA Request

On December 21, 2000, the predecessor project owner (a joint venture that included NRG Energy) to ESEC LLC filed an Application for Certification (AFC) seeking approval from the CEC to replace the existing ESGS Units 1 and 2 with a 630-MW natural-gas-fired combined-cycle electric generation facility. The AFC included demolition and removal of existing Units 1 and 2 and replacement with two combustion turbines and one steam turbine (designated Units 5, 6, and 7) in the footprint of Units 1 and 2. The project owner proposed to use the existing steam-cycle heat rejection system, which used cooling water from Santa Monica Bay for the new equipment.

## 1.5 June 2007 PTA

Subsequent to the issuance of the CEC Final Decision in February 2005, on June 18, 2007, the project owner (by this time a wholly owned subsidiary of NRG Energy) submitted a PTA requesting the addition of new state-of-the-art Rapid Response Combined Cycle (R2C2) technology that was not available during the original proceedings for 00-AFC-14. R2C2 technology provides extremely fast starts and can achieve thermal efficiency of combined-cycle units while significantly reducing startup emissions delivering electricity more quickly to the grid. This new technology eliminated the need for once-through cooling by replacing these units with air-cooled condensers. The R2C2 technology also eliminated the need for wastewater discharge to the ocean or to a publicly owned treatment plant. Other modifications included in the 2007 PTA included changes in the method and route for oversize equipment delivery; modification of the plant entrance road to allow for oversize equipment delivery and improved plant access; and modifications to the construction laydown areas. The project owner was also changed in August 2008 to El Segundo Energy Center LLC.

In June 2008, the CEC issued its Staff Assessment Report, and in October 2008 issued its Addendum I Staff Assessment Report. The CEC analysis in the respective staff assessment reports noted legal challenges to the availability of South Coast Air Quality Management District (SCAQMD) -provided air emission offsets through SCAQMD Rules 1304 and 1315, which corresponding delayed the CEC and SCAQMD from completing their approvals of the June 2007 PTA. Regulatory and legislative resolution in January 2010 enabled SCAQMD to issue permits that relied on air emission offsets through application of Rules 1304 and 1315. Processing of the June 2007 PTA resumed in 2010, during which ESEC LLC filed a PTA Supplement to expand the scope of the June 2007 PTA request to include the permanent shutdown and closure-in-place of Unit 3 to ensure the necessary air emission offsets; the PTA Supplement was supported by additional analysis of the requested modification and the potential effects on environmental resources as compared to the previous evaluations (CEC Final Decision [00-AFC-14], 2007 PTA, June 2008 CEC Staff Assessment Report, and October 2008 Addendum I Staff Assessment Report). The expanded PTA Supplement also included proposed changes to the approved COCs. As part of this request, Unit 3 was proposed to be maintained cosmetically and structurally to ensure that it did not become an eyesore or a safety hazard. In addition, the natural gas supply was proposed to be permanently disconnected and hazardous materials storage and use associated with Unit 3 operations (e.g., lube oil, ammonia for air emissions control) was to be eliminated and/or permanently disconnected. The shutdown of Unit 3 would have also resulted in a reduction of ammonia consumption and deliveries, but would not reduce storage quantity. This Amendment was approved by the CEC on June 30, 2010.

## 1.6 April 2012 PTA COC Revisions for Ammonia Use and Facility Name Change

Subsequent to the PTA Supplement described above, and in order to effectuate the changes in ammonia usage and facility name, on April 17, 2012, ESEC LLC submitted a PTA requesting to modify the range of ammonia injection rates, eliminate a venturi scrubber, eliminate the ammonia supply pipeline from Chevron, and change the project name. These changes were approved by the CEC on August 9, 2012, and the facility name was changed to the El Segundo Energy Center (ESEC).

## 1.7 Consistency of 2013 Amendment with License

With this 2013 PTA, ESEC LLC requests to decommission, demolish, and remove existing Units 3 and 4 (currently generating up to 670 MW net) and add fast-start and dispatch flexibility capabilities through the addition of one NRG rapid response 1 x 1, 325 MW net (334 MW gross) combined cycle unit (“CC Fast” incorporating one General Electric [GE] 7FA.05 natural gas turbine and one steam turbine, operating in combined-cycle mode), plus two advanced simple-cycle aeroderivative gas turbines (55 MW net / 58 MW gross each). In addition, new generation would also include an auxiliary boiler rated at 36 MMBtu/hr integrated into the CC Fast operation. The new generating units will be fitted with best available control technology (BACT). For the gas turbines, BACT will include dry low-NOx combustors, selective catalytic reduction (SCR), an oxidation catalyst, and will use clean-burning natural gas fuel. The Trent 60 units will include multiple compressors and intercooling for improved efficiency and to support reduced air emissions. The ESPFM layout is shown in Figures 1-2a and 1-2b.

Section 1769(a)(1)(D) of the CEC Siting Regulations requires a discussion of the amendment’s consistency with the requisite LORS and whether the additions are based on new information that changes or undermines the assumptions, rationale, findings, or other bases of the CEC Final Decision for 00-AFC-14. If the project is no longer consistent with the license, an explanation of why the additions should be permitted must be provided. The following sections address the required explanation, rationale, and LORS compliance analysis for the proposed ESPFM. Proposed changes to the existing COCs are discussed as part of the impacts analyses in Section 3.0. In completing the environmental analysis required to comply with Section 1769, the Project Owner requests that relevant information from the 00-AFC-14 and subsequent PTAs proceedings be incorporated by reference [CCR 1704 (a) (2)].

## 1.8 Necessity of Proposed Change

Sections 1769(a)(1)(B) and 1769(a)(1)(C) of the CEC Siting Regulations require a discussion of the necessity for the proposed changes to the project and whether this modification is based on information known by the petitioner during the certification proceeding. The purpose of this 2013 PTA is to decommission, demolish, and add fast-start and dispatch flexibility capabilities through the installation of 435 MW net / 449 MW gross of more efficient generating units. This PTA proposes the replacement of steam boilers scheduled to retire by December 31, 2015, to meet the State’s once-through-cooling policy compliance deadline for El Segundo Generating Station. This new generation at this location is critical to meet in-basin needs pending shutdown of other once-through-cooling units in the Los Angeles Basin, and the need for fast-start generation to integrate renewable generation in the Los Angeles Basin.

## 1.9 Cumulative Impacts

Each issue area discussion in Section 3.0 addresses the cumulative environmental effects from the proposed ESPFM. This discussion concludes that implementation of the ESPFM will not result in significant, unmitigated cumulative impacts, and the assumptions or conclusions made in the CEC Final Decision (00-AFC-14) will not change.

## 1.10 Compliance with Laws, Regulations, Ordinances and Standards

The CEC Final Decision (00-AFC-14) concluded that the El Segundo Power Replacement Project complied with all applicable LORS. As discussed in detail in Section 3.0, the proposed ESPFM will not affect the ability to comply with all applicable LORS.

## 1.11 Document Organization

Pursuant to Section 1769 of the CEC Siting Regulations, the environmental analysis conducted for the ESPFM relies upon relevant information from the 00-AFC-14 proceedings to describe unchanged baseline conditions and project components and includes the following sections.

|               |   |
|---------------|---|
| Section 1.0   | Introduction  |
| Section 2.0   | Project Description   |
| Section 3.0   | Environmental Analysis: updates to baseline conditions, evaluation of potential environmental impacts as compared to the CEC Final Decision (00-AFC-14), subsequent PTAs, current LORS, revisions to COCs, and references to updated technical data to support the environmental analyses |
| Section 4.0   | Potential Effects on the Public   |
| Section 5.0   | List of Property Owners   |
| Section 6.0   | Potential Effects on Property Owners  |
| Appendix 3.1A | Air Quality Technical Information   |
| Appendix 3.8A | Public Health Technical Information   |

## 1.12 Schedule

The proposed schedule for this 2013 ESEC PTA is as follows:

- March 2013: Project Owner files application for a Permit to Construct, and for a Prevention of Significant Deterioration (PSD) Permit, with SCAQMD
- April 2013: Project Owner files 2013 ESEC PTA with CEC
- April 2013: Project Owner submits air emission modeling and health risk assessment modeling to SCAQMD to support application processing
- May – October 2013: CEC Staff reviews PTA and issues data requests and holds public workshops, if needed.
- November 2013: Project Owner receives Preliminary Determination of Compliance (PDOC) from SCAQMD and conducts Title V Public Workshop
- February 2014: Project Owner receives CEC Staff Assessment Report
- April 2014: Project Owner receives Final Determination of Compliance (FDOC) from SCAQMD
- June 2014: CEC Staff and Siting Committee Hearings
- July 2014: CEC Issues Final Staff Assessment
- August 2014: CEC Board Meeting to hear 2013 PTA
- September 2014: Title V Major Modification approval and NPDES final approval 2014 concurrent with CEC approvals, to incorporate Units 9 through 12 in the Title V Facility Permit and include process water discharge changes in the facility NPDES Permit

## 1.13 Necessity for the Proposed Modifications

The modifications proposed in this 2013 PTA are necessary to:

1. Maximize use of limited existing air offsets by replacing older generating equipment with new low-emission combustion turbine equipment that will significantly reduce air pollutant emissions as compared to the boilers they are replacing, pursuant to SQAQMD Rule 1304.

2. Redevelop brownfield site in close proximity to existing infrastructure.
3. Install air-cooled condenser and eliminate need for once-through ocean water cooling process.
4. Remove existing once-through cooling process at ESGs as a means to meet the State's once-through cooling policy, consistent with ESGs's stated OTC Implementation Plan to retire Units 3 and 4 by December 31, 2015, and replace the generation via Track 1 compliance path.
5. Provide grid stability to accommodate increased renewable energy generation by adding dispatch capabilities to accommodate planned and unplanned grid outages in response to excessive demands and natural disasters.
6. Incorporate visual elements into facility design consistent with the ESEC license and subsequent PTAs related to 00-AFC-14C that considers community input.
7. Integrate community-defined site improvements, including improvements to pedestrian/bicycle use of bike path, landscaping and frontage improvements.
8. Improve fire, emergency, public safety, and environmental protections through installation and operation of new more efficient generating units.
9. Improve public access through implementation of existing COCs LAND- 9 through LAND-11.

## 1.14 Project Ownership

The Project Owner for the ESPFM is El Segundo Energy Center LLC (referred to herein as project owner or ESEC LLC). ESEC LLC is a wholly owned subsidiary of NRG Energy, Inc.

## 1.15 Recommendations and Conclusions

Based on the analysis included in this 2013 PTA, all direct, indirect, and cumulative impacts of the ESPFM on health, safety, and the environment will remain less than significant with the amended COCs from 00-AFC-14C, and the proposed additions will further reduce potential impacts in technical areas as compared to the CEC Final Decision (00-AFC-14).









**FIGURE 1-1**  
**Vicinity Map**

El Segundo Power Facility Modification  
 April 2013 Petition to Amend 00-AFC-14  
 El Segundo, California











# Project Description

---

## 2.1 Introduction

El Segundo Energy Center LLC (ESEC LLC), the project owner, a wholly owned subsidiary of NRG Energy, Inc (NRG), proposes to modify the El Segundo Energy Center (ESEC), 00-AFC-14C, Final Decision to make substantial changes to ESEC. Chief among these changes is the replacement of two once-through-cooled boiler units, Units 3 and 4, with modern and efficient, dry-cooled, natural-gas-fired combustion gas turbine units. This change will eliminate the use of ocean water for once-through cooling at the facility. The proposed changes will also upgrade and improve ESEC's existing and approved site infrastructure, and provide fast start and dispatch flexibility capabilities to support southern California grid load balancing and renewable energy integration, and implement improvements to coastal access.

Specific changes proposed through this Petition to Amend (PTA) include:

- Shutdown and demolition of Units 3 and 4
- Removal and remediation of existing ESEC retention basins
- Change in location for the permitted (but not yet constructed) administration building to a lower elevation
- Construction of a new, combined administration, maintenance, and operations support building
- Modifications to existing site access
- Improvements to beach access along the facility's southern property boundary

The following new major equipment will be installed:

- One NRG fast start combined-cycle unit ("CC Fast"), rated at 325 MW net, incorporating a General Electric 7FA.05 natural gas turbine
- Two Rolls Royce Trent 60 DLE ISI, rated at 55 MW/unit net, consisting of advanced aeroderivative simple-cycle gas turbines
- One Cleaver Brooks 36 MMBtu/hr auxiliary boiler

This upgrade, called the El Segundo Power Facility Modification (ESPFM), requires a PTA because the ability to employ this technology was not possible during the AFC process as a result of engineering and SCQAMD rule constraints. Recent changes to SCAQMD air emission regulations now facilitate the ability for the project owner to request these upgrades and maintain compliance with air emission limits.

The CC Fast generating unit is capable of fast starts—comparable to peaking units—and has the overall thermal efficiency and low emissions of combined-cycle units. The advanced Trent 60 generating units are capable of fast starts and provide dispatch flexibility. When combined, this configuration would significantly reduce startup emissions and enable greater capacity and faster delivery of electricity to the to the southern California grid.

The ESPFM will provide fast-start and dispatch flexibility capabilities through the installation Units 9, 10, 11, and 12, adding approximately 435 MW (net) / 449 MW (gross) of new generation to the existing 560 MW (net) / 573 MW (gross) ESEC, identified as Units 5 through 8. Operation of Units 5 through 8 and proposed Units 9 through 12 will result in a total generating capacity of approximately 995 MW (net) / 1,022 MW (gross). The net rated energy that would be transmitted from ESEC as proposed by this PTA is 995 MW, consistent with the LGIAs filed with the CAISO for ESEC and ESPFM. As shown in Tables 1-2A and 1-2B, the net rated capacity of previously retired Units 1 and 2 (demolished and retired as part of 00-AFC-14) and Units 3 and 4 (proposed for demolition and retirement as part of this PTA) is 1020 MW; gross generation of Units 1 through 4 has been approximately 1052 MW.

The timing for Implementation of the ESEC (00-AFC-14C) will result in shut-down of Unit 3 within 90 days of first-fire of Unit 5, or by June 30, 2013, and shutdown of Unit 4 in mid-2015 to coincide with the State of California's



once-through-cooling policy for El Segundo Generating Station (ESGS) with a stated compliance obligation of December 31, 2015. Commencement of demolition of Units 3 and 4 is planned for the end of 2015. Construction of the proposed ESPFM is anticipated to commence by mid-2016, after Units 3 and 4 are removed, and conclude in 2018 to meet a projected on-line date of summer 2018. The existing cessation of generation from Units 3 and 4, followed by their demolition, and proposed ESPFM construction, operation, and generation are subject to an approved power purchase agreement.

### 2.1.1 Ongoing Construction

The project owner is currently completing construction of the ESEC project consistent with the 2005 CEC Final Decision and the subsequent amendments. The approved ESEC facilities are shown in Figure 2-1, and additional information is provided in Section 2.8.11

### 2.1.2 Project Location

ESGS is an existing 1950s natural-gas-fired electric power generating station, originally owned by Southern California Edison (SCE) until 1998; it is located at 301 Vista Del Mar Boulevard in El Segundo, California. Figure 1-1 provides a location map and Figure 1-2 provides a site layout map. The site is located at the southernmost city limit of the city of El Segundo on the coast of the Pacific Ocean between Dockweiler State Beach and the city of Manhattan Beach. ESGS is approximately 2.5 miles southwest of the Los Angeles International Airport and west of the San Diego Freeway (I-405) on the eastern shore of Santa Monica Bay. It is located less than 0.25 mile south of the Los Angeles Department of Water and Power's Scattergood Generating Station, and approximately 0.5 mile south of the City of Los Angeles' Hyperion Wastewater Treatment Plant. The power plant site is bordered by Vista Del Mar and the Chevron refinery to the east, 45th Street in the city of Manhattan Beach on the south, Santa Monica Bay on the west, and the Chevron Marine Terminal on the north. ESGS consists of approximately 33 acres surrounded by an 8-foot-high chain link fence topped with barbed wire. The electricity generated from steam boiler Units 3 and 4 and the ESEC (upon completion) is transmitted to the adjoining SCE switchyard that is physically within the fenced boundary of ESGS and is itself surrounded by its own fencing.

The site is located at Township 3 South, Range 15 West, on the Venice U.S. Geological Survey (USGS) quadrangle map. There is no applicable USGS section number. The site includes three parcels. Existing Units 3 and 4 are located on APN 4138-029-002, a parcel approximately 24.7 acres in size. The existing SCE substation is located on APN 4138-029-800, a parcel approximately 2.25 acres in size, owned by SCE. A list of existing property owners within 1,000 feet of the ESPFM is included in Section 5.0.

The eastern portion of the site consists of a cut slope approximately 70 feet high that descends from Vista Del Mar Boulevard and the existing main entrance gate to the lower elevation of the power blocks. Predominant existing structures include; power blocks with steam boiler Units 3 and 4 and ESEC Units 5 through 8, ocean water intake/outfall structure, administration office trailers, temporary construction trailers, paved roadways and parking areas, transformers, and the retention basin. The power blocks contain the turbines, generators, operator control room, turbine lube oil system, air pollution control devices, multi-level steel boiler structures, and multiple electrical transformers.

### 2.1.3 Topography

As shown in Figure 2-2, the northern end of the site has been developed with ESEC Units 5 through 8 and the adjacent Units 3 and 4, which exist at varying elevations of 18 feet to 20 feet mean lower low water (MLLW). Units 3 and 4 reside at the proposed ESPFM location. The existing topography at the south end of the site slopes downward from the entrance road to the retention basin and existing fuel oil tank area at a 1.5 to 1 slope. Elevations vary from a high point at the gatehouse of 90 feet above mean sea level (msl) down to 39 feet msl at the fuel tank area and 20 feet msl at the retention basin area. The existing fuel oil tank area is level and is surrounded by an earthen containment berm.

The final grade for the new power block area, as shown in Figure 2-3, will be similar to the existing grade. The power block complex will be at a level elevation of 20 feet msl and the top of pavement will slope down at the drop inlet locations to 18 feet msl. The final grade for the fuel oil tank area, as shown in Figure 2-3, will be similar

to the existing topography with grades sloping from 40 feet msl down to new drop inlets at 38 feet msl. The existing earthen berm will remain unchanged except that a portion of the berm along the west side will be removed to allow road access into the tank area. A new administration/maintenance building is proposed to be located at the northern portion of the tank farm area in proximity of the current location of the retention basin. Excavated soils from the northern portion of the tank farm area are proposed to be used for road fill during construction of the access road.

## 2.1.4 Geologic Setting and Seismology

The geology, seismic setting, and soil conditions at the site are summarized herein and discussed in detail in Section 5.3 of the AFC (00-AFC-14); incorporated herein by reference). The site is located in the southwestern portion of the Los Angeles Structural Basin, which forms the transition between the northern portion of the Peninsular Ranges Physiographic Province and the southern portion of the Transverse Ranges Physiographic Province of California. The Peninsular Range Province is characterized by northwest-trending mountains and valleys formed largely by a system of active right-lateral, strike-slip faults with a similar trend. The Transverse Range Province is characterized by east-west-trending mountains and intervening valleys that were formed by a series of east-west-trending fold belts and active left-lateral reverse and thrust faults. Over geologic time, the site has been influenced by fluvial, marine, and littoral depositional processes as sea levels have risen and fallen and as tectonic forces have changed the regional landscape. The site is underlain by a thick, interbedded sequence of Quaternary clays, silts, sands, and gravels. These quaternary deposits are underlain by Tertiary sedimentary rocks, including claystones, siltstones, and sandstones. Schist and gneissic basement rocks lie beneath the sedimentary rocks at depths of about 6,700 feet.

## 2.2 Facility Design

### 2.2.1 Equipment Technology

The CC-Fast technology includes a one on one (1x1) rapid start air-cooled combined-cycle gas turbine plant designed in-house by NRG in collaboration with GE for peaking and intermediate duty service. Table 2-1 includes the dimensions of each of the major components of the new generating systems. The combination of these turbines and auxiliary boiler was designed specifically for load balancing and providing firming capacity in support of renewable such as wind and solar.

The CC-Fast plant uses a GE 7FA platform and includes the following power block components:

- One NRG fast start combined-cycle unit (CC Fast), rated at 325 MW net, incorporating a General Electric 7FA.05 natural gas combustion turbine generator (CTG) designed to achieve 75 percent of base load output in 10 minutes
- Two-pressure duct-fired heat recovery steam generator (HRSG) designed for rapid startup with conventional SCR/carbon monoxide (CO) catalysts
  - One Heller dry cooling tower system

In addition to the CC Fast technology, the project owner is also proposing to additional peaking capacity and load balancing that includes:

- Two Rolls Royce Trent 60 DLE ISI, rated at 55 MW/unit net, consisting of advanced aeroderivative simple-cycle gas turbines
- One single-case non-reheat axial exhaust admission condensing steam turbine generator (STG) designed for non-traditional elevated condensing pressure to minimize cooling system size
- One Cleaver Brooks 36 MMBtu/hr auxiliary boiler consisting of a direct contact spray condenser and a mechanically induced draft dry-cooling tower

While these packages do not operate in combined-cycle mode, they use Inlet Spray Inter-Cooling (ISI) systems to increase output and improve efficiency. Tables 2-2 through 2-4 list the components specifications (GE, Trent 60,

and auxiliary boiler) and Figures 2-4 and 2-5 show a conceptual diagram of the system. These units are designed with a modular concept to allow for quick installation and ease of maintenance in the field. Each module is fully assembled and tested before shipment. The gas turbine base plate holds the required oil system to allow installation, testing, and flushing in a shop environment. This greatly reduces site installation time. The control system is designed to allow for easy site installation by using remote input/output (I/O) technology to decrease the number of interconnect cables between the unit control panel and the equipment skids. All train control systems are then accessed by a Human Machine Interface (HMI), which will be located in the main control room. Due to the Trent 60's aircraft engine lineage, maintenance of the engine can be accomplished quickly and easily. The Trent engine is designed to facilitate quick turnarounds. The advantage of using a Trent engine is that it can be split into interchangeable modules for increased generation flexibility. These modules include:

- Low-pressure compressor
- Intermediate and high-pressure compressors and turbines
- Low-pressure turbine

Operating with dry low emission (DLE) technology, the Trent 60 engine is designed to comply with stringent environmental requirements. DLE uses eight radial staged combustors to accomplish operational flexibility in part load operations while still maintaining oxides of nitrogen (NO<sub>x</sub>) and CO emissions limits. Each engine is designed to produce 52 MW of power. Each of the three proposed CTGs will be equipped with dry low-NO<sub>x</sub> combustors, an SCR system for the control of NO<sub>x</sub> emissions, and an oxidation catalyst for the control of CO. The existing 20,000-gallon ammonia (NH<sub>3</sub>) storage tank at the facility (storing 29 percent aqueous ammonia) will be used to supply aqueous ammonia to the CTG SCR systems.

The CC Fast unit requires a source of steam while off-line in order to utilize its fast start capability. The steam keeps the system in a state of readiness, reducing the startup time. Steam will be provided by a 36 MMBtu/hr auxiliary boiler, which will be fully integrated into the CC Fast. Specifications for the auxiliary boiler are shown in Table 2-4.

TABLE 2-1  
Dimensions of Significant Structures

| Structure                     | Dimensions (FT) |        |       |
|-------------------------------|-----------------|--------|-------|
|                               | Height          | Length | Width |
| <b>NEW STRUCTURES</b>         |                 |        |       |
| <b>Combined Cycle Turbine</b> |                 |        |       |
| Combustion Turbines           | 25              | 102    | 23    |
| HRSOs (New), Tier 1           | 80.0            | 107    | 35    |
| CTG Inlet                     | 70              | 51     | 27    |
| <b>Simple Cycle Turbines</b>  |                 |        |       |
| Trent60 CTG x 2               | 15              | 104    | 31    |
| CTG to Stack Transition x2    | 35              | 48     | 36    |
| <b>Other equipment</b>        |                 |        |       |
| Main Aux Transformer          | 30              | 42     | 26    |
| Fin-Fan Cooler                | 29              | 93     | 44    |
| Elect Room                    | 10              | 44     | 17    |
| Steam Transformer             | 30              | 42     | 26    |
| Steam Turbine                 | 20              | 100    | 32    |
| Cooling Tower                 | 67              | 232    | 53    |

TABLE 2-1  
Dimensions of Significant Structures

| Structure   | Dimensions (FT) |        |       |
|---|-----------------|--------|-------|
|   | Height          | Length | Width |
| <b>EXISTING STRUCTURES</b>                            |                 |        |       |
| <b>Combined Cycle Turbine Associated Structure x2</b> |                 |        |       |
| Tier 1  | 32              | 233    | 32    |
| Tier 2  | 76              | 46     | 36    |
| Tier 3  | 88              | 98     | 23    |
| Air Cooled Heat Exchanger X2                          | 26              | 138    | 85    |
| Steam Turbine Generator X2                            | 29              | 61     | 22    |

Note: Table B-1 NRG El Segundo building dimensions used for air quality modeling.

TABLE 2-2  
GE Fast-Start Gas Turbine Specifications

| Parameter                         | Specification   |
|-----------------------------------|---|
| Manufacturer/Refurbishing Company | GE  |
| Model                             | 7FA.05 10-minute start  |
| Fuel Type                         | California Public Utilities Commission (CPUC) Quality Natural Gas |
| Natural Gas Heating Value         | 1,030 MMBtu/scf   |
| Gas Turbine Heat Input (HHV)      | 2,168 MMBtu/hr at 41°F ambient (peak load)                        |
| Duct Burner Heat Input (HHV)      | 268 MMBtu/hr at 41°F ambient (peak load)                          |
| Fuel Consumption                  | 2.365 MMscf/hr*   |
| HRSO Exhaust Flow                 | 859,000 DSCFM at 41°F ambient (peak load)                         |
| HRSO Exhaust Temperature          | 219°F at 41°F ambient (peak load)                                 |
| Gas Turbine Power Generation      | 222 MW (nominal - gross)  |
| Steam Turbine Power Generation    | 112 MW (nominal - gross)  |
| Total Power Generation            | Up to 334 MW (nominal – gross)                                    |

\*Represents maximum possible fuel consumption of the CTG, based on 2436 MMBTU/hr heat input and 1,030 MMBtu/scf fuel heat content.

TABLE 2-3  
**Trent 60 Gas Turbine Specifications (Per Turbine)**

| Parameter                         | Specifications                            |
|-----------------------------------|---|
| Manufacturer/Refurbishing Company | Rolls Royce                               |
| Model                             | Trent 60                                  |
| Fuel Type                         | CPUC Quality Natural Gas                  |
| Natural Gas Heating Value         | 1,030 MMBtu/scf                           |
| Gas Turbine Heat Input (HHV)      | 516 MMBtu/hr at 78°F ambient (peak load)  |
| Fuel Consumption                  | 0.500 MMscf/hr*                           |
| Gas Turbine Exhaust Flow          | 257,000 DSCFM at 78°F ambient (peak load) |
| Gas Turbine Exhaust Temperature   | 809°F at 78°F ambient (peak load)         |
| Gas Turbine Power Generation      | 57.4 MW (nominal - gross)                 |

\*Represents the maximum possible fuel consumption of the CTG, based on 516 MMBTU/hr heat input and 1,030 MMBTU/scf fuel heat content

TABLE 2-4  
**Auxiliary Boiler**

| Parameter                         | Specifications           |
|-----------------------------------|--------------------------|
| Manufacturer/Refurbishing Company | Cleaver Brooks           |
| Model                             | D-Type, Model NB-100D-40 |
| Fuel Type                         | Natural Gas              |
| Natural Gas Heating Value         | 1,030 MMBtu/scf          |
| Heat Input (HHV)                  | 36 MMBtu/hr              |
| Fuel Consumption                  | 0.035 MMscf/hr           |
| Exhaust Flow                      | 6,100 DSCFM              |
| Exhaust Temperature               | 300°F                    |

## 2.2.2 Equipment Layout

The proposed site layout is shown on Figure 1-2. This figure shows the new features integrated into the site features that will remain following the implementation of activities approved as part of the CEC Final Decision (00-AFC-14). The new equipment and processes to be installed include:

### 1x1 Fast Start Combined-cycle Unit

- GE 7FA.05 gas turbine generator
- Heat recovery steam generator
- Catalytic oxidation system for CO reduction
- Selective catalytic reduction system for NOx reduction
- Steam turbine generator
- Condenser
- Dry cooling tower

- Closed cooling water coolers
- Stack
- Auxiliary boiler
- Generator step-up transformer

#### Two Simple-cycle Units

- Two Rolls Royce Trent 60 gas turbine generators
- Two catalytic oxidation systems for CO reduction
- Two selective catalytic reduction systems for NOx reduction
- Two stacks
- Two generator step-up transformers

The overall layout of the new ESPFM units under this 2013 PTA will be located in the same general area of the facility as previously permitted ESEC. Figure 2-6 shows the equipment/processes to be removed with the shutdown and removal of Units 3 and 4 to make room for the new natural-gas-fired generating units. The following equipment and processes will be removed:

- Boilers and steam lines
- Steam turbine generators
- Condenser systems including condensate lines, air ejectors, condensate pumps, condensers
- Inlet and outlet circulating water lines for each unit
- Boiler feedwater system including lines, pumps and heaters
- Compressed air system including dryers
- Lube oil systems
- Fire water system
- Flue gas ducting
- Stacks
- Unit electrical systems
- Unit control systems
- Transformers and switchgear

### 2.2.3 Site Access

Entrance to the site is from Vista Del Mar Boulevard through a locked gate, which is monitored by a security officer and closed-circuit video surveillance camera 24 hours a day. Site access is shown in Figure 2-7.

### 2.2.4 Electric Transmission

Implementation of the new ESPFM power generation will not affect the approved transmission system. Consistent with the current purchase power agreement with SCE, from SCE's El Segundo 230-kV substation, electricity will be transmitted to users via the existing transmission and distribution network. No new towers will need to be constructed or replaced inside or outside of the site boundaries.

### 2.2.5 Fuel Gas System

Natural gas will continue to enter the ESEC at the existing metering station location to support the ESPFM. Natural gas for the new Units 9, 11 and 12 and the auxiliary boiler will be metered separately and proceed through a new natural gas compression station. Natural gas from the metering station will enter the compression station at a pressure at about 350 psig, near ambient temperature. The natural gas will have entrained liquid and solid particles removed prior to being compressed to 450 psig for the GE CC Fast gas turbine generator and 850 psig for the Trent 60 gas turbine generators. The compressed natural gas will then be filtered and continue to the gas turbine fuel systems. The 7FA.05 includes a performance fuel gas heater; the Trent 60 units do not. The fuel gas heaters will heat the natural gas from approximately 245°F to approximately 365°F using high-pressure economizer bleed from the HRSG as the heating medium. For start-up, steam from the auxiliary boiler will be used

as the gas fuel heating medium until economizer bleed has reached the necessary temperature. From the fuel gas heaters, the natural gas will proceed to the combustion fuel system inlet. Gas compressor discharge cooling of the natural gas, if required for start-up and recirculation, will be provided using ambient air fin fan coolers. A key advantage of this system is the use of existing ESEC natural gas supply pipelines. No modifications to the Southern California Gas (SoCalGas) system will be required to meet the ESPFM demand.

## 2.2.6 Capacity Factor

Operation of the CC Fast unit is forecasted to be up to 60 percent capacity factor annually, including up to 200 startups per year and 200 shutdowns per year. The Rolls Royce Trent 60 peaker units are forecasted to be up to 55 percent capacity factor annually, including 480 hours per year for startups and shutdowns per peaking unit.

An LGIA exists between ESEC LLC, SoCalGas, and the CAISO. The LGIA provides the platform from which electrical interconnection needs and issues are to be addressed and managed.

The LGIA for replacement of Units 3 and 4 with Units 9–12 is currently going through the CAISO Cluster 4 review process. It is expected that the LGIA will be modified to incorporate the modifications concurrent with CEC processing of this PTA. The project owner will provide updates, as necessary, regarding the status of modifying the agreement to accept the new power.

## 2.2.7 Efficiency and Reliability

Operation of the CC Fast unit and advanced Rolls Royce Trent 60 peaker units offers several advantages as compared to conventional technologies. This design solves the slow startup limitation associated with conventional combined-cycle facilities in intermediate-duty applications. During conventional combined-cycle startup, which can typically be 3 hours for a warm or hot start and 6 hours for a cold start, the gas turbine generator is operated well below its optimal performance point in terms of thermal and air emissions performance while the bottoming cycle warms up. In contrast, the CC Fast configuration can deliver 75 percent of gas turbine base load output within 10 minutes of unit startup (hot, warm, or cold HRSG/STG conditions) and 100 percent within 12 minutes, and can achieve full combined-cycle gas turbine output within 45 minutes for hot starts, 85 minutes for warm starts, and 125 minutes for cold starts. This faster startup time allows the gas turbine generators to achieve maximum efficiency more quickly and provides the following operational benefits:

- Reduced air emissions (gas turbine generators reach optimal emissions performance faster)
- Reduced start up fuel consumption
- Reduced steam loss associated with steam seal warming during start up
- Improved heat rate
- Minimal water consumption
- Flexible siting options

## 2.2.8 Benefits

The benefits of the ESPFM are significant and include the following advantages:

- Use of CC Fast technology, as compared to other similar technologies (e.g., Siemens Flex Plant 10), will result in lower installed costs per kilowatt, improved heat rate, minimal water consumption, and optimal flexible siting.
- Rapid starting capability supports wind and solar renewable generation by providing reliable localized generation that can quickly respond should wind or solar resources not be available during peak electrical demand periods.
- Significant improvement in the visual aesthetics associated with new components integrated into the facility will be realized.
- Facility will use existing transmission, natural gas facilities, power plant labor, and infrastructure.
- Facility will use state-of-the-art BACT pollution controls.

- Changes will provide much needed, highly efficient, additional power supply in the western SCE load center.
- Project owner is committed to improving access to the recreational bike path from the southern portion of the property.

## 2.3 Water Requirements and Demand

Water usage for the CC Fast and Rolls Royce Trent 60 peaker unit systems will be less than previously required for Units 3 and 4 because during startup venting associated with steam seal warming is reduced. Water usage in the 7FA.05 is comparable to other F-Class gas turbines equipped with inlet evaporative cooling. Water usage for the Trent 60 units is comparable to other intercooled aeroderivative gas turbines (e.g., GE LM 6000 SPRINT). The expected daily and annual water use and water quality for the ESPFM is listed in Tables 2-5 and 2-6, respectively. The water supply requirements also include domestic uses and miscellaneous plant uses. The conventional media-type evaporative cooling will be used to lower the temperature of the GE CC Fast inlet air. A Caldwell wet compression system will be used to reduce compressor work and lower the temperature of the Trent 60 units high-pressure compressor discharge air at ambient temperatures above approximately 45°F.

TABLE 2-5  
Daily Water Supply Requirements<sup>a</sup>

| Water Source   | Average Usage <sup>b</sup> | Peak Usage <sup>c</sup> |
|--|----------------------------|-------------------------|
| <b>City of El Segundo (Metropolitan Water District of Southern California)</b> |                            |                         |
| Potable Water  | 750 gal/day                | 750 gal/day             |
| Plant and Equipment Drains   | 25,000 gal/day             | 25,000 gal/day          |
| Makeup to Evaporative Cooler   | 44,000 gal/day             | 85,000 gal/day          |
| Quench Water   | 23,000 gal/day             | 33,000 gal/day          |
| Total City Water   | 93,000 gal/day             | 144,000 gal/day         |
| <b>West Basin Municipal Water District</b>                                     |                            |                         |
| Makeup to HRSG Cycle   | 64,000 gal/day             | 100,000 gal/day         |
| Combustion Turbine (CT) Steam Injection  | 0 gal/day                  | 340,000 gal/day         |
| Total Reclaim Water  | 64,000 gal/day             | 440,000 gal/day         |

<sup>a</sup>Based on Table 3.4-1 from 00-AFC-14.

<sup>b</sup>Daily average based on 59°F average annual ambient temperature, not firing the HRSGs, no steam injection to the CT, evaporative coolers on, assumed for 24-hour day.

<sup>c</sup>Daily average for peak load operation based on 83°F ambient temperature, the HRSGs fired, 12 hours of steam injection to the CT, evaporative coolers on, assumed for 24 hour day.

TABLE 2-6  
Expected Water Supply Quality

| Constituent                       | West Basin Municipal |                |          |
|-----------------------------------|----------------------|----------------|----------|
|                                   | City of El Segundo   | Water District | Seawater |
| Calcium                           | 46                   | 0.06           | 400      |
| Magnesium                         | 19                   | 0.03           | 1,100    |
| Sodium                            | 59                   | 4.8            | 11,000   |
| Potassium                         | 3                    | 0.34           | 380      |
| M-Alkalinity as CaCO <sub>3</sub> | 100                  | 14             | NR       |
| Sulfate                           | 129                  | ND             | 1,900    |
| Chloride                          | 60                   | 2.7            | 19,000   |
| Nitrate (as N)                    | 0                    | 0.13           | 0.59     |



TABLE 2-6  
**Expected Water Supply Quality**

| Constituent | City of El Segundo | West Basin Municipal Water District | Seawater |
|-------------|--------------------|-------------------------------------|----------|
| Fluoride    | 0.20               | 0.10                                | 0.7      |
| Aluminum    | 0.08               | ND                                  | 0.1      |
| Silica      | NR                 | 0.14                                | 0.01–7.0 |
| TDS         | 440                | 25                                  | 33,000   |
| PH          | 8.2                | 7.4                                 | 7.7-8.3  |
| TSS         | NR                 | ND                                  | 3.0      |
| BOD5        | NR                 | NR                                  | 1.0      |
| COD         | NR                 | NR                                  | 49       |

ND = Not Detected; NR = Not Reported

Based upon Table 3.4-3 from 00-AFC-14

(mg/L as ions, except as noted)

Similar to the permitted ESEC project design water, water will be supplied from two sources: potable water from the cities of El Segundo and Manhattan Beach (Metropolitan Water District of Southern California) and California State Title 22 reclaim water from West Basin Municipal Water District (West Basin). The ESPFM will use water from the West Basin for potable use and fire emergencies. The Title 22 reclaim water, first-pass reverse osmosis (RO) product water received from the District will be used as the supply to the cycle makeup treatment system as well as makeup to the inlet cooling. Title 22 reclaim water, irrigation quality, will be blended with the single-pass RO product water for use in the gas turbine inlet cooling. The proposed plant design will utilize two air-to-air heat exchangers for thermal cycle heat rejection. Seawater will no longer be used for heat rejection.

The average and peak annual use from city potable and reclaim water supply comparisons from the previously permitted and proposed plant design are listed in Table 2-7. The average quality of city water, reclaim water, and seawater supplies is listed in Table 2-6. Water use of the three sources is shown on the water balance diagrams (Figures 2-8 and 2-9).

TABLE 2-7  
**Annual Water Use by Source**

| Water Source  | Annual, Average (AFY)             |                       | Annual, Maximum (AFY)                   |                       |
|---|-----------------------------------|-----------------------|---|-----------------------|
|   | Previously Permitted <sup>a</sup> | Proposed <sup>b</sup> | Previously Permitted <sup>c</sup>       | Proposed <sup>d</sup> |
| Cities of El Segundo and Manhattan Beach (Metropolitan Water District of Southern California) | 97                                | 0.72                  | 104                                     | 0.84                  |
| West Basin Municipal Water District <sup>e</sup>  | 112 <sup>e,f</sup>                | 118                   | 120 <sup>e,f</sup>                      | 137                   |
| Seawater  | 200,000 (U4 only)                 | 0                     | 399,000 (U3 and 4 intake structure 002) | 0                     |

<sup>a</sup> Annual average is estimated as the daily average x 365 days x 93 percent.

<sup>b</sup> Annual average is estimated as the daily average usage (Table 3.4-1) x 313 days.

<sup>c</sup> Annual maximum is estimated as the daily average x 365 days x 100 percent.

<sup>d</sup> Annual maximum is estimated as the daily average usage (Table 3.4-1) x 365 days.

<sup>e</sup> Annual average reclaim water demand is estimated as the peak daily use x 42 days + the average daily use x 23 days the quantity x 93 percent.

<sup>f</sup> Annual maximum reclaim water demand is estimated as the peak daily use x 42 days + the average daily use x 323 days the quantity x 100 percent.

Information based on Table 3.4.2 from 00-AFC-14

AFY = acre-feet per year

Reclaim single-pass RO product water will be treated onsite by portable cycle make-up treatment equipment, which will be regenerated offsite, to supply demineralized make-up water to the steam cycle, and the combustion turbines for steam injection power augmentation.

Reclaim single-pass RO water will be directed from West Basin via the new 10-inch line to a storage tank prior to the cycle makeup treatment system. This system will include a permanently installed forwarding pump and mobile demineralization equipment that will be regenerated offsite. Demineralized water produced by the cycle makeup treatment system will be stored in a demineralized water storage tank. The design and location of the new 10-inch water line will be consistent with the CEC Final Decision (00-AFC-14).

The water characteristics and average and peak daily use for each process utilizing city potable or reclaim water supply is listed in Table 2-8, which also compare existing conditions to proposed conditions. Table 2-9 provides existing and projected water use.

TABLE 2-8  
**Daily Water Supply Requirements**

| Water Source   | Daily Average Usage               |                       | Daily Peak Usage                  |                       |
|--|-----------------------------------|-----------------------|-----------------------------------|-----------------------|
|  | Previously Permitted <sup>a</sup> | Proposed <sup>b</sup> | Previously Permitted <sup>c</sup> | Proposed <sup>d</sup> |
| <b>Cities of El Segundo and Manhattan Beach (Metropolitan Water District of Southern California)</b> |                                   |                       |                                   |                       |
| Potable Water – Sanitary <sup>e</sup>  | 50                                | 750                   | 750                               | 750                   |
| Plant and Equipment Drains   |                                   | 0                     | 25,000                            | 0                     |
| Makeup to Evaporative Cooler   |                                   | 0                     | 85,000                            | 0                     |
| Quench   | 23,000                            | 0                     | 33,000                            | 0                     |
| Total City Water (Potable)   | 92,750                            | 750                   | 143,750                           | 750                   |
| <b>West Basin Municipal Water District Title 22 Reclaim Water</b>                                    |                                   |                       |                                   |                       |
| Single-Pass RO Quality Water   |                                   |                       |                                   |                       |
| Single-pass RO Makeup to HRSGs and Evaporative Coolers, and Misc. Steam Losses                       | 64,000                            | 15,360                | 440,000                           | 529,920               |
| <b>Irrigation Quality</b>  |                                   |                       |                                   |                       |
| Makeup to Evaporative Cooler <sup>f</sup>  | 0                                 | 19,200                | 0                                 | 48,000                |
| Total Title 22 West Basin Water Demand (RO and Irrigation Quality)                                   |                                   | 34,000                | 440,000                           | 577,920               |
| <b>Seawater</b>  |                                   |                       |                                   |                       |
| Once-Through Cooling Water   |                                   | 0                     | 200,000,000 (for U4)              | 0                     |

<sup>a</sup>Daily average based on 59°F average annual ambient temperature, not firing the HRSGs, no steam injection to the CT, evaporative coolers on, assumed for 24-hour day.

<sup>b</sup>Daily average usage is based on 83°F DBT, 47% RH, HRSGs in use; power augmentation, water injection to CTs, and evaporative coolers on, 16-hour/day operation.

<sup>c</sup>Daily average for peak load operation based on 83°F ambient temperature, the HRSGs fired, 12 hours of steam injection to the CT, evaporative coolers on, assumed for 24 hour day.

<sup>d</sup>Daily peak usage is based on 83°F DBT, 47% RH, HRSGs in use; power augmentation, injection to CTs, and evaporative coolers on, 16 hour/day operation.

<sup>e</sup>Daily potable water consumption is based on 24 hours @ 0.52 gpm.

<sup>f</sup>Make up to evaporative coolers is mixed Reclaimed Single Pass RO water and Irrigation Quality water.

Units = gallons per day

TABLE 2-9  
Existing and Projected Water Use

| Units   | Existing             |                                     |                       | Proposed             |                                     |                     |                |
|---|----------------------|-------------------------------------|-----------------------|----------------------|-------------------------------------|---------------------|----------------|
|   | Cooling<br>(mgd-max) | Reclaimed<br>(no R.O.)<br>(gpd-avg) | Potable*<br>(gpd-avg) | Cooling<br>(mgd-max) | Reclaimed<br>(no R.O.)<br>(gpd-avg) | Average (gpd)       |                |
|   |                      |                                     |                       |                      |                                     | Reclaimed<br>(R.O.) | Potable        |
| 1 & 2 (abandoned)   | 0                    | 0                                   | 0                     | —                    | —                                   | —                   | —              |
| 3 & 4 (U3 retired for ESEC and U4 retired for ESPFM)        | 200                  | Minimal                             | 129,998               | 0                    | 0                                   | 0                   | 0              |
| 5 -8  | —                    | —                                   | —                     | —                    | —                                   | 64,000              | 93,000         |
| 6 & 8 (need to make sure this is ESEC values from 2007 PTA) | —                    | —                                   | —                     | 0                    | Minimal                             |                     |                |
| <b>Total</b>  | <b>605</b>           | <b>85,936</b>                       | <b>179,938</b>        | <b>605</b>           | <b>85,936</b>                       | <b>64,000</b>       | <b>222,998</b> |

\*Volumes estimated based on relative capacity utilization of 13.1% for Units 1&2 and 34.1% for Units 3&4 applied to total average volume utilized.

Information based on Table 5.5-1 from 00-AFC-14

The existing 6-inch line at the site carrying the Title 22 irrigation water will be used for supplying both the approved ESEC and proposed ESPFM requirements for irrigation water. No proposed changes are needed for the planned reclaim or potable water line interconnections as referenced in the CEC Final Decision (00-AFC-14).

## 2.4 Waste Management

Waste management volumes and disposal sites are consistent with the information included in the 00-AFC-14 Final Decision. The decommissioning, demolishing, and replacing the existing Units 3 and 4 steam boiler plants with new natural-gas-fired electrical generating capacity will result in the generation of nonhazardous and small quantities of hazardous wastes. A summary of the construction waste streams and management is presented in Tables 2-10 through 2-12. For the purpose of this discussion, construction includes site preparation, demolition, and new facility construction.

TABLE 2-10  
Estimated Quantities of Asbestos-containing Materials

| Component/Item/Area   | Level | ACM (Y/N) | Type                             | Est. Quantity                  | Additional Samples |
|---|-------|-----------|----------------------------------|--------------------------------|--------------------|
| <b>Steam Generator and Auxiliary Equipment (above turbine deck)</b> |       |           |                                  |                                |                    |
| Boiler, Piping & Ducting  | 7     | No        | Blue bands (abated)              | N/A                            | 3-9                |
| Stack   | 7 up  | Yes       | Painted Coating (peeling w/lead) | 14'x 110' =<br><b>1,540 SF</b> | 3                  |
| Air Ejectors  | 3     | Yes       | Cal/mag and mud                  | 50 LF 6"-12" diam.             | -                  |
| De-aerator, recirc. tank, storage tank, flash tank                  | 3     | No        | N/A                              | N/A                            | -                  |
| Burning cleaning station  | 3     | Yes       | Transite panels/putty            | <b>900 SF</b>                  | -                  |
| Elevator shaft  | G-7   | Yes       | Transite panels/putty            | <b>54'x 140' = 7,560 SF</b>    | -                  |
| Chart recorder shack  | 6     | Yes       | Transite panels/putty            | <b>633 SF</b>                  | -                  |

TABLE 2-10  
Estimated Quantities of Asbestos-containing Materials

| Component/Item/Area   | Level | ACM (Y/N)      | Type  | Est. Quantity   | Additional Samples |
|---|-------|----------------|---|---|--------------------|
| Penthouse   | 7     | Unknown/assume | Blocks and spray-applied                    | <b>36'x 36' x 20' inaccessible space</b>  | 6                  |
| Air pre-heaters   | 3     | No             | N/A   | N/A   | —                  |
| Control room (1st, 2nd & roof)                                      | 3–5   | Yes/assume     | SCT(2), ACT/M(2), floors(4), tar/gravel, PM | 25'x 60' CMU building w/2 floors<br><b>SCT/ACT–3,000 SF</b><br><b>Floors–3,000 SF</b><br><b>Roof–1,500 SF</b> | 48                 |
| <b>Steam Generator and Auxiliary Equipment (below turbine deck)</b> |       |                |   |   |                    |
| Boiler - lower dead air space (internal)                            | 2     | Yes            | Block (deteriorated)                        | <b>Unknown 2(5'x 60'x 15' inaccessible space)</b>   | —                  |
| Gas recirc. fan & ducts   | G     | Yes-confirm    | Mud & wire                                  | 2 each (30'x 30' x 40')= <b>7,200 SF</b>  | 3                  |
| Blowdown tank   | G     | No             | N/A   | N/A   | —                  |
| <b>Draft System</b>   |       |                |   |   |                    |
| Forced draft fans   | G     | No             | N/A   | N/A   | —                  |
| Induced draft fans (N&S)  | G-2   | Yes            | Mud & cloth (wire?)                         | 2 each (20'x 30'x 30')= <b>3,600 SF</b>   | —                  |
| Induced draft ducts (N&S)   | G-2   | Yes            | Mud & cloth (wire?)                         | 2 each (30'x 15'x 30')= <b>9,000 SF</b>   | —                  |
| Air pre-heaters (N&S)   | 2     | Yes            | Mud & cloth (wire?)                         | 2 each (25'x 15'x10')= <b>3,750 SF</b>  | —                  |
| <b>Fuel System</b>  |       |                |   |   |                    |
| Fuel gas piping, oil piping, oil heaters, oil pumps                 | G     | No             | Blue bands (abated)                         | N/A   | —                  |
| Reboiler  | G     | No             | Bare metal                                  | N/A   | —                  |
| <b>Condensate and Feedwater System</b>                              |       |                |   |   |                    |
| 1st point feedwater heaters (E&W)                                   | 2     | Yes            | Mud & wire                                  | 2(30'x 15.7') + 2(19.62')= <b>981.24 SF</b>   | —                  |
| 2nd point feedwater heaters (E&W)                                   | 2     | Yes            | Mud & wire                                  | 2(30'x 15.7') + 2(19.62')= <b>981.24 SF</b>   | —                  |
| 3rd point feedwater heater  | 2     | Unknown/assume | Mud & wire                                  | (25'x 15.7') + (19.62')= <b>412.12 SF</b>   | 3                  |
| 4th point feedwater heater  | 2     | Unknown/assume | Mud & wire                                  | (25'x 15.7') + (19.62')= <b>412.12 SF</b>   | 3                  |
| Evaporator condenser (1 per unit)                                   | 2     | Yes            | Mud & wire                                  | (20'x 12.56') + (12.56')= <b>263.76 SF</b>  | —                  |
| Boiler feed pumps (inside barrel housing)                           | G     | Unknown/assume | Unknown                                     | 5 @ 80 SF each= <b>400 SF</b>   | 3                  |
| Condensate booster pumps  | G     | No insulation  | N/A   | N/A   | —                  |

TABLE 2-10  
Estimated Quantities of Asbestos-containing Materials

| Component/Item/Area                       | Level   | ACM (Y/N)            | Type  | Est. Quantity  | Additional Samples |
|---|---------|----------------------|---|--|--------------------|
| <b>Turbine (above and below the deck)</b> |         |                      |   |  |                    |
| Turbine housing                           | 3       | Unknown (not likely) | Sound deadener (hard spray-on)                                | Unknown  | 5                  |
| Other areas                               | 2-3     | Not likely-confirm   | Blankets  | N/A  | 3                  |
| <b>Chemical Lab and Locker Room</b>       |         |                      |   |  |                    |
| Counter tops                              | G       | Unknown/assume       | Possible Resin  | <b>40 SF</b>   | 3                  |
| Ceiling tiles                             | G       | Unknown/assume       | 1'x 1'/M, 2'x 4'  | <b>400 SF</b>  | 6                  |
| Flooring                                  | G       | Unknown/assume       | 9"x 9"/M, 12"x 12"/M  | <b>400 SF</b>  | 12                 |
| <b>Exterior</b>                           |         |                      |   |  |                    |
| Wall plaster                              | G       | Unknown/assume       | 3 coat on lath  | <b>5,000 SF</b>  | 5                  |
| Exterior wall vents- north and west       | G       | Yes                  | Transite panels   | <b>1,770 SF</b>  | —                  |
| <b>Maintenance Shop and Warehouse</b>     |         |                      |   |  |                    |
| Miscellaneous                             | G       | Unknown              | 1'x 1' ACT/M (2), 2'x 4' SCT, WB/JC, HP, roofing, pen. mastic | <b>ESTIMATED<br/>SCT/ACT-4,000 SF<br/>WB/JC-5,000SF<br/>HP-5,000 SF<br/>Roof-10,000 SF</b> | 27                 |
| <b>Fuel Oil Tank Area</b>                 |         |                      |   |  |                    |
| Tank siding                               | 35'–40' | Yes                  | Transit panels  | 1 @ 16,000   | —                  |
| Displacement oil heater                   | G       | Unknown/not likely   | Insulation  | Unknown  | 6                  |
| Displacement oil tank                     | G       | No                   | Bare metal  | N/A  | —                  |

Note: Information based on Table 5.14-2 from 00-AFC-14  
Based on quantities encountered as part of demolition of Units 1 and 2

TABLE 2-11  
Asbestos-containing Materials

| Component/Item/Area   | Level | ACM (Y/N) | Type                             | Est. Quantity             | Samples |
|---|-------|-----------|----------------------------------|---------------------------|---------|
| <b>Steam Generator and Auxiliary Equipment (above turbine deck)</b> |       |           |                                  |                           |         |
| Boiler, Piping & Ducting  | 7     | No        | Blue bands (abated)              | N/A                       | 3–9     |
| Stack   | 7 up  | Yes       | Painted Coating (peeling w/lead) | 14'x 110'=1,540 SF        | 3       |
| Air Ejectors  | 3     | Yes       | Cal/mag and mud                  | <b>50 LF 6"-12" diam.</b> | —       |
| De-aerator, recirc. tank, storage tank, flash tank                  | 3     | No        | N/A                              | N/A                       | —       |
| Burning cleaning station  | 3     | Yes       | Transite panels/putty            | <b>900 SF</b>             | —       |
| Chart recorder shack  | 6     | Yes       | Transite panels/putty            | <b>633 SF</b>             | —       |

TABLE 2-11  
Asbestos-containing Materials

| Component/Item/Area   | Level | ACM (Y/N)            | Type                           | Est. Quantity                               | Samples |
|---|-------|----------------------|--------------------------------|---|---------|
| Penthouse   | 7     | Unknown/assume       | Blocks and spray-applied       | Unknown (36'x 36' x 20' inaccessible space) | 6       |
| Air pre-heaters   | 3     | No                   | N/A                            | N/A   | —       |
| <b>Steam Generator and Auxiliary Equipment (below turbine deck)</b> |       |                      |                                |   |         |
| Boiler - lower dead air space (internal)                            | 2     | Yes                  | Block (deteriorated)           | Unknown (25'x 60'x15' inaccessible space)   | —       |
| Gas recirc. fan & ducts   | G     | Yes-confirm          | Mud & wire                     | 2 each (30'x 30' x 40')=7,200 SF            | 3       |
| Blowdown tank   | G     | No                   | N/A                            | N/A   | —       |
| <b>Draft System</b>   |       |                      |                                |   |         |
| Forced draft fans   | G     | No                   | N/A                            | N/A   | —       |
| Induced draft fans (N&S)  | G-2   | Yes                  | Mud & cloth (wire?)            | 2 each (20'x 30'x 30')=3,600 SF             | —       |
| Induced draft ducts (N&S)   | G-2   | Yes                  | Mud & cloth (wire?)            | 2 each (30'x 15'x 30')=9,000 SF             | —       |
| Air pre-heaters (N&S)   | 2     | Yes                  | Mud & cloth (wire?)            | 2 each (25'x 15'x10')=3,750 SF              | —       |
| <b>Fuel System</b>  |       |                      |                                |   |         |
| Fuel gas piping, oil piping, oil heaters, oil pumps                 | G     | No                   | Blue bands (abated)            | N/A   | —       |
| Reboiler  | G     | No                   | Bare metal                     | N/A   | —       |
| <b>Condensate and Feedwater System</b>                              |       |                      |                                |   |         |
| 1st point feedwater heaters (E&W)                                   | 2     | Yes                  | Mud & wire                     | 2(30'x 15.7') + 2(19.62')=981.24 SF         | —       |
| 2nd point feedwater heaters (E&W)                                   | 2     | Yes                  | Mud & wire                     | 2(30'x 15.7') + 2(19.62')=981.24 SF         | —       |
| 3rd point feedwater heater  | 2     | Unknown/assume       | Mud & wire                     | (25'x 15.7') + (19.62')=412.12 SF           | 3       |
| 4th point feedwater heater  | 2     | Unknown/assume       | Mud & wire                     | (25'x 15.7') + (19.62')=412.12 SF           | 3       |
| Evaporator condenser (1 per unit)                                   | 2     | Yes                  | Mud & wire                     | (20'x 12.56') + (12.56')=263.76 SF          | —       |
| Boiler feed pumps (inside barrel housing)                           | G     | Unknown/assume       | Unknown                        | 5 @ 80 SF each=400 SF                       | 3       |
| Condensate booster pumps  | G     | No insulation        | N/A                            | N/A   | —       |
| <b>Turbine (above and below the deck)</b>                           |       |                      |                                |   |         |
| Turbine housing   | 3     | Unknown (not likely) | Sound deadener (hard spray-on) | Unknown                                     | 5       |
| Other areas   | 2-3   | Not likely-confirm   | Blankets                       | N/A   | 3       |

TABLE 2-11  
Asbestos-containing Materials

| Component/Item/Area                                      | Level | ACM (Y/N) | Type            | Est. Quantity                                 | Samples |
|--|-------|-----------|-----------------|---|---------|
| <b>Exterior</b>  |       |           |                 |   |         |
| Auxiliary piping from Unit 2 to 3 under crossover bridge | G     | Yes       | Pipe insulation | May not be impacted; no quantity at this time | —       |

Information based on Table 5.14-3 from 00-AFC-14)

Nonhazardous solid wastes during construction include debris and other materials requiring removal during site grading and excavation, excess concrete, lumber, scrap metal, empty nonhazardous chemical containers, and office materials. All nonhazardous wastes will be recycled to the greatest extent practical and the remainder removed on a regular basis by a certified waste handling contractor. These materials are listed in Table 2-12.

TABLE 2-12  
Summary of Construction Waste Streams and Management Methods<sup>a</sup>

| Waste Stream   | Waste Classification                          | Amount  | Treatment  |
|--|---|---|--|
| Scrap wood, steel, glass, plastic, paper, calcium, silicate insulation, mineral wood insulation, asphalt, concrete | Nonhazardous                                  | 20-40 cu yd/wk  | Waste disposal facility  |
| Empty hazardous material containers – drums  | Recyclable<br>Hazardous                       | 1 cu yd/wk  | Recondition or recycle   |
| Used and waste lube oil during CT and ST lube oil flushes  | Recyclable<br>Hazardous                       | <55 gallons per flush period, approximately 3 week duration | Recycle  |
| Oil absorbent mats from CT and ST lube oil flushes and normal construction   | Nonhazardous                                  | 1,000 sq. ft. per month, as needed                          | Waste disposal facility or laundry (permitted to wash rags)                      |
| Oily rags generated during normal construction activities lube oil flushes   | Nonhazardous                                  | 3-4 55 gallon drums a month                                 | Waste disposal facility or laundry (permitted to wash rags)                      |
| Spent batteries; lead acid   | Hazardous                                     | 2 batteries/year  | Recycle  |
| Spent batteries; alkaline type, Sizes AAA, AA, C and D   | Hazardous<br>Recyclable                       | 60 batteries/month  | Recycle  |
| HRS&G and Preboiler piping cleaning waste  | Hazardous                                     | 200,000 gal per cleaning                                    | Hazardous waste disposal facility or recycle                                     |
| Used oil from oil/water separator  | Recyclable<br>Hazardous <sup>b</sup>          | <1,000 gal per year   | Recycle  |
| Sanitary Waste-Portable Chemical Toilets and Construction Office Holding Tanks                                     | Sanitary                                      | 600 gpd   | Pumped by licensed contractors and transported to sanitary water treatment plant |
| Construction waste water from dewatering operations  | Nonhazardous                                  | 65 million gallons  | Carbon absorption and discharge under NPDES permit                               |
| Granular Activated Carbon  | Nonhazardous<br>Recyclable                    | Exchange 40,000 pounds of carbon per week (4 vessels)       | Regenerated by the carbon supplier at their waste disposal facility              |
| Soil   | Nonhazardous<br>Recyclable<br>Hazardous (TBD) | 20,000 cubic yards  | Soil recycling facility or class I or III facility                               |

<sup>a</sup>All numbers are estimates.

<sup>b</sup>Under California regulations

(Information based on Table 5.14-4 from 00-AFC-14)

Operation of the facility will also generate wastes resulting from processes, routine facility maintenance, and office activities. The operating waste streams and management methods are summarized in Table 2-13. All nonhazardous wastes during operation of the facility will be recycled to the greatest extent practical and the remainder removed on a regular basis by a certified waste handling contractor.

TABLE 2-13  
Operating Waste Streams and Management Methods<sup>a</sup>

| Waste Stream                                      | Waste Classification                 | Amount   | Treatment  |
|---|--------------------------------------|--|--|
| Used hydraulic fluids, oils, grease, oily filters | Recyclable<br>Hazardous              | < 5 gallons/day  | Recycle  |
| Spent batteries; lead acid                        | Recyclable<br>Hazardous              | 2 batteries/year   | Recycle  |
| SCR catalyst                                      | Recyclable<br>Hazardous              | 50 cubic meters every 3 to 5 years                                   | Recycle  |
| Oxidation Catalyst (CO)                           | Recyclable<br>Hazardous              | 50 cubic meters every 3 to 5 years                                   | Recycle  |
| Used oil from oil/water separator                 | Recyclable<br>Hazardous <sup>b</sup> | 50 gallons/year  | Recycle  |
| Oily rags   | Nonhazardous                         | 55 gallons/2months   | Laundry (permitted to wash oil rags)                           |
| CTG used air filters                              | Nonhazardous                         | <1,000 filters   | Recycle  |
| CTG water wash                                    | Nonhazardous                         | 7,200 gallons/year   | Waste disposal facility  |
| HRSG periodic operational chemical cleaning       | Hazardous                            | 50,000 gallons per HRSG cleaning (Approx. 2 cleanings every 5 years) | Hazardous waste disposal facility (by licensed subcontractors) |

<sup>a</sup>All numbers are estimates.

<sup>b</sup>Under California regulations.

Information based on Table 5.14-5 from 00-AFC-14)

## 2.4.1 Management and Disposal of Hazardous Materials and Hazardous Wastes

Consistent with the current operations at the ESEC, the ESPFM will also use the same aqueous ammonia line to deliver ammonia to the site. A variety of chemicals will be stored and used during construction and operation of the facility. A list of chemicals anticipated to be used is provided in Table 2-14. The storage, handling, and use of these chemicals will be conducted in accordance with all applicable LORS.

TABLE 2-14  
Hazardous Materials and Wastes Usage and Storage during Construction and Operations\*

| Material                             | Purpose and Location                                      | Usage/Day   | Maximum Stored | Storage Type         |
|--------------------------------------|---|-------------|----------------|----------------------|
| A300- low hazard corrosion inhibitor | South of Unit 4 boiler                                    | 75 gal.     | 100 gal.       | Steel drum, tote bin |
| Acetylene (C2H2) 99.80%              | Southwest of warehouse                                    | 3,530 cu ft | 10,950 cu ft   | Cylinder             |
| Ammonium Bicarbonate                 | South of Unit 4 boiler                                    | 400 lb.     | 600 lb.        | Bag                  |
| Ammonium bifluoride NH4HF2           | Chemical cleaning of HRSG                                 | As needed   | Temporary only | Portable vessel      |
| Aqua ammonia (29.4%)                 | South of Unit 4 boiler                                    | 600 gal.    | 1,000 gal.     | Steel drum, tote bin |
| Aqueous ammonia (29%) NH4(OH)        | NOx emissions control.<br>Top of hill and other locations | 15,000 gal. | 20,000 gal.    | Underground tank     |



**TABLE 2-14  
Hazardous Materials and Wastes Usage and Storage during Construction and Operations\***

| Material   | Purpose and Location   | Usage/Day    | Maximum Stored | Storage Type                  |
|--|--|--------------|----------------|-------------------------------|
| Argon  | Warehouse, south side and other locations                              | 850 cu ft    | 1,410 cu ft    | Cylinder                      |
| Asbestos Containing Debris                         | Hazardous waste storage area and accumulation areas                    | 2,000 lb.    | 15,000 lb.     | Steel drum                    |
| Bleach   | North of Units 3, 4; southwest of Units 5 and 7                        | 1,500 gal.   | 2,600 gal.     | Aboveground tank              |
| Calgon C-9 Corrosion Inhibitor                     | Chemical storage room, chemical feed areas                             | 250 lb.      | 600 lb.        | Plastic/Nonmetallic Drum      |
| Calgon H-510 Microbiocide                          | Chemical storage room, chemical feed areas                             | 250 lb.      | 600 lb.        | Plastic/Nonmetallic Drum      |
| Cardox –carbon dioxide                             | Unit 7 2nd level west side   | 3 tons       | 5 tons         | Tank inside building          |
| ChelClean 665 Chelating Agent                      | South of Unit 4 boiler   | 50,000 lb.   | 89,000 lb.     | Poly tank                     |
| Citric acid  | Chemical cleaning of HRSG, feedwater systems                           | As needed    | Temporary only | Portable vessel               |
| CuSol Solvent Waste                                | South of Unit 4  | 100,000 gal. | 180,000 gal.   | Tank wagon                    |
| Dielectric Solvent                                 | Unit 7 Aux. bay southwest corner; Unit 4 Aux. bay south end.           | 110 gal.     | 330 gal.       | Steel drum                    |
| Diesel fuel  | Warehouse, southwest side  | 110 gal.     | 165 gal.       | Steel drum                    |
| Di-, tri-sodium phosphate solution                 | Boiler water pH/scale control  | 5 lb.        | 800 gal        | Portable vessel               |
| EDTA chelant                                       | Chemical cleaning of HRSG, feedwater systems                           | As needed    | Temporary only | Portable vessel               |
| Elimin-ox - Oxygen scavenger                       | Feedwater oxygen control. Under Unit 3 boiler and Unit 5 chemical area | 500 gal.     | 800 gal.       | Tote bin                      |
| EPA Protocol Mix (1.0% O <sub>2</sub> )            | Warehouse, southwest side  | 282 cu ft    | 564 cu ft      | Cylinder                      |
| EPA Protocol Mix (Nitric Oxide/Nitrogen[12.75ppm]) | Warehouse, southwest side  | 564 cu ft    | 1,410 cu ft    | Cylinder                      |
| EPA Protocol Mix (17% O <sub>2</sub> )             | Warehouse, southwest side  | 564 cu ft    | 1,410 cu ft    | Cylinder                      |
| Flammable Gas Mixture#1                            | Warehouse, south side  | 846 cu ft    | 1,410 cu ft    | Cylinder                      |
| Flammable Gas Mixture#2                            | Warehouse, southwest side  | 846 cu ft    | 1,410 cu ft    | Cylinder                      |
| Flammable Gas Mixture#3                            | Warehouse, south side  | 846 cu ft    | 1,410 cu ft    | Cylinder                      |
| Flammable Gas Mixture#4                            | Warehouse, southwest side  | 846 cu ft    | 1,410 cu ft    | Cylinder                      |
| Flammable Gas Mixture#5 (72% Methane)              | Warehouse, south side  | 846 cu ft    | 1,410 cu ft    | Cylinder                      |
| Helium   | Warehouse southwest side   | 282 cu ft    | 846 cu ft      | Cylinder                      |
| Hydrazine (N <sub>2</sub> H <sub>4</sub> ) 35%     | Unit 3 Turbine Deck, Unit 5 Heater Deck                                | 500 gallons  | 850 gallons    | Tote bin                      |
| Hydrochloric acid HCl                              | Chemical cleaning of HRSG  | As needed    | Temporary only | Portable vessel               |
| Hydrogen   | Unit 3 northwest side, ground level                                    | 30,000 cu ft | 40,000 cu ft   | Cylinder                      |
| Hydrogen   | Generator cooling.   | 8,000 cu ft  | 70,000 cu ft   | Tank, carbon steel            |
| Lubricating Oil                                    | Unit 5 ground floor; southwest Unit 7, Unit 3 & 4 ground floor.        | 27,800 gal   | 40,500 gal     | Aboveground tank, steel drum. |

**TABLE 2-14  
Hazardous Materials and Wastes Usage and Storage during Construction and Operations\***

| Material  | Purpose and Location   | Usage/Day     | Maximum Stored                | Storage Type                  |
|---|--|---------------|-------------------------------|-------------------------------|
| Mineral Spirits                                     | Paint shack  | 20 gallons    | 50 gallons                    | Can                           |
| Mineral Oil   | Transformers at Units 1, 2, 3, and 4                                     | 87,800 gal    | 88,000 gal                    | Transformers                  |
| Nalco 350-corrosion inhibitor                       | Under Unit 3 boiler and Unit 5 chemical area                             | 500 gal.      | 800 gal.                      | Tote bin                      |
| Nalco 356-corrosion inhibitor                       | Under Unit 3 boiler and Unit 5 chemical area                             | 500 gal.      | 800 gal.                      | Tote bin                      |
| Nalco BT 3000                                       | Boiler water treatment. Under Unit 3 boiler and Unit 5 chemical area     | 500 gal.      | 800 gal.                      | Tote bin                      |
| Nalco EG 5010                                       | Boiler alkalinity control. Under Unit 3 boiler and Unit 5 chemical area. | 500 gal.      | 800 gal.                      | Tote bin                      |
| Neutralizing amine solution                         | Feedwater pH control   | 5 lb.         | 800 gal                       | Portable vessel               |
| Nitrogen  | Unit 3 north side  | 106,000 cu ft | 141,265 cu ft                 | Aboveground tank, cylinder    |
| Non-RCRA Hazardous Waste Silicone Grease and Debris | Hazardous waste storage area and accumulation area                       | 55 lb.        | 110 lb.                       | Steel drum                    |
| Oil Contaminated Soil/Solids                        | Hazardous waste storage area and accumulation area                       | 220 lb.       | 1,100 lb.                     | Steel drum                    |
| Oxides of Nitrogen Mix (Nitric Acid 34 PPM)         | Warehouse, southwest side  | 564 cu ft     | 1,410 cu ft                   | Cylinder                      |
| Oxides of Nitrogen Mix(Nitric Oxide 59.50 PPM)      | Warehouse, southwest side  | 564 cu ft     | 1,128 cu ft                   | Cylinder                      |
| Oxides of Nitrogen Mix(Nitric Oxide 125 PPM)        | Warehouse, southwest side  | 846 cu ft     | 1,410 cu ft                   | Cylinder                      |
| Oxidizer  | South of Unit 4 boiler   | 30,000 cu ft  | 45,000 cu ft                  | Cylinder trailer              |
| Oxygen scavenger solution                           | Feedwater oxygen control   | 2.5 lb.       | 800 gal.                      | Portable vessel               |
| Oxygen Mix (8.5% O2)                                | Warehouse, southwest side  | 564 cu ft     | 1,410 cu ft                   | Cylinder                      |
| Oxygen – gaseous oxygen                             | Warehouse, south side  | 1,128 cu ft   | 3,666 cu ft                   | Cylinder                      |
| Paint   | Paint shack  | 25 gallons    | 100 gallons                   | Can                           |
| Propane   | Warehouse, southwest side  | 200 gal.      | 400 gal.                      | Cylinder                      |
| Selig Formula 229 Degreaser                         | Unit 7 Aux. bay southwest corner; Unit 4 Aux. bay south end.             | 110 gal.      | 110 gal.                      | Steel drum                    |
| Sodium Hypochlorite 12.5% wt NaOCl                  | Southwest of Units 5&7, North of Units 3&4                               | 1500 gal.     | 2,600 gal.                    | Aboveground storage tank      |
| Sodium nitrite NaNO <sub>2</sub>                    | Chemical cleaning of HRSG  | As needed     | Temporary only                | Portable vessel               |
| Sulfuric acid for station Batteries                 | Electrical/ctrl bldg. Combustion turbine/miscellaneous                   | As needed     | 600 gal<br>732 gal<br>100 gal | Battery<br>Battery<br>Battery |
| Waste Hydrazine and Debris                          | Hazardous waste storage area and accumulation area                       | 55 lb.        | 110 lb.                       | Steel drum                    |
| Waste Lubricating Oil                               | Hazardous waste storage area and accumulation area                       | 220 lb.       | 550 lb.                       | Steel drum                    |

**TABLE 2-14  
Hazardous Materials and Wastes Usage and Storage during Construction and Operations\***

| Material   | Purpose and Location                               | Usage/Day | Maximum Stored | Storage Type |
|--|--|-----------|----------------|--------------|
| Waste Mineral Oil for Transformers                 | Hazardous waste storage area and accumulation area | 110 lb.   | 330 lb.        | Steel drum   |
| Waste Oil & Solvent                                | Hazardous waste storage area and accumulation area | 450 lb.   | 1350 lb.       | Steel drum   |
| Waste Paint & Thinner                              | Hazardous waste storage area and accumulation area | 55 lb.    | 110 lb.        | Steel drum   |
| Waste Paint Chips and Debris (with Benzene & Lead) | Near Paint shack and hazardous waste storage area  | 110 gal.  | 165 gal.       | Steel drum   |
| Waste Paint Solids/Sludge                          | Hazardous waste storage area and accumulation area | 55 gal.   | 165 gal.       | Steel drum   |
| Waste Solvent and Debris                           | Hazardous waste storage area and accumulation area | 55 lb.    | 110 lb.        | Steel drum   |

\*Reference: NRG, 2000 Business Plan Update, November.

Information based on Table 5.15-2 from 00-AFC-14)

## 2.4.2 Hazardous Materials Handling

Hazardous materials handling volumes and disposal sites are consistent with the information included in the CEC Final Decision (00-AFC-14) and are listed in Table 2-14.

## 2.4.3 Hazardous Wastes

Water removed from excavations during site preparation and construction will be processed through carbon filters. Used carbon filters constitute hazardous waste and will be sent to the manufacturer for processing and/or recycling as appropriate. Small quantities of hazardous wastes will possibly be generated over the course of construction. These may include waste paint, spent construction solvents, and spent welding materials. All hazardous wastes generated during facility construction and operation will be handled and disposed of in accordance with applicable LORS. Hazardous wastes will be either recycled or disposed of in a licensed Class I disposal facility, as appropriate. Managed and disposed of properly, these wastes will not cause significant environmental or health and safety impacts. Some hazardous wastes are generated, including spent catalyst from the SCR and CO systems, used oils from equipment maintenance, and oil-contaminated materials such as spent oil filters, rags, or other cleanup materials. Spent catalyst (approximately 50 cubic meters) is returned to the manufacturer on the order of every 3 to 8 years for metals reclamation and/or disposal. Used oil generated will be recycled, and oil or heavy metal contaminated materials (e.g., filters) requiring disposal will be disposed of in a Class I waste disposal facility.

## 2.4.4 Wastewater

Process wastewaters from the CC Fast system will consist of HRSG and inlet evaporative cooler blowdowns. In addition, wastewater will be generated during off-line water washing of the 7FA.05 and Trent 60 compressors. HRSG and evaporative cooler blowdown streams will be recycled back to the single-pass RO water storage tank, partly for reprocessing by the mobile demineralizers and partly for reuse as make-up to the inlet coolers. Off-line water wash effluent will be impounded and disposed of at an appropriately licensed offsite facility. Waste streams will be sampled in accordance with the existing monitoring and reporting program to ensure that the chemistry of the process waste is within the limits of the discharge permits. While process wastewater from the CC Fast and Rolls Royce Trent 60 peaker unit system will be recycled when possible, wastewater will be disposed of offsite as necessary if the water cannot be recycled and processed in a manner to meet the CC Fast and Rolls Royce Trent 60 peaker unit system water quality objectives. No process wastewater will be discharged from the facility via the

existing retention basin or either outfall structure. The dissolved and suspended solids captured in the demineralizer beds will be removed via regeneration process offsite. Plant drains that conveyed plant wastes from Units 3 and 4 to the retention basin will be removed. Table 2-15 lists the process water characteristics.

TABLE 2-15  
Expected Process Waste Characterization\*

| Constituent                        | Circulating Water Discharge | Existing Retention Basin Effluent | Combined Waste to Outfall 002 | Sanitary Waste to Sewer |
|------------------------------------|-----------------------------|-----------------------------------|-------------------------------|-------------------------|
| Calcium                            | 400                         | 43                                | 400                           | 50                      |
| Magnesium                          | 1,100                       | 18                                | 1,100                         | 20                      |
| Sodium                             | 11,000                      | 57                                | 11,000                        | 60                      |
| Potassium                          | 380                         | 3                                 | 380                           | 3                       |
| M-Alkalinity, as CaCO <sub>3</sub> | NR                          | 97                                | NR                            | 100                     |
| Sulfate                            | 1,900                       | 123                               | 1,900                         | 130                     |
| Chloride                           | 19,000                      | 58                                | 19,000                        | 60                      |
| Nitrate                            | 0.59                        | 0                                 | 0.59                          | 0                       |
| Fluoride                           | 0.7                         | 0.18                              | 0.7                           | 0.20                    |
| Aluminum                           | 0.1                         | 0.06                              | 0.1                           | 0.08                    |
| Silica                             | 0.01-7.0                    | 1                                 | 0.01-7.0                      | NR                      |
| TDS                                | 33,000                      | 420                               | 33,000                        | 440                     |
| pH                                 | 7.7-8.3                     | 8.1                               | 7.7-8.3                       | 8.2                     |
| TSS                                | 3.0                         | <1                                | 3.0                           | 500                     |
| Phosphate                          | NR                          | 4                                 | 0                             | NR                      |
| Ammonia                            | NR                          | 0                                 | 0                             | 5                       |
| Oil and grease                     | NR                          | 0                                 | 0                             | NR                      |
| BOD <sub>5</sub>                   | 1.0                         | ND                                | 1.0                           | 400                     |
| COD                                | 49                          | ND                                | 49                            | 100                     |

\*All numbers are approximate

NR = Not Reported

Information based on Table 5.5-22 from 00-AFC-14

mg/L as ions, except as noted

Sanitary wastewater, including eyewash station water and shower water, will be directed to the City of Manhattan Beach Municipal Sanitary Sewer in accordance with the City Public Works Department's discharge requirements and in accordance with existing COCs from the amended 00-AFC-14 Final Decision. Estimated volumes of the facility's liquid wastewater discharge remains unchanged and are shown in Table 2-16. The ESPFM is proposed as a zero-liquid-discharge facility where only stormwater and sanitary effluent will leave the site.

TABLE 2-16  
**Estimated Liquid Process Wastewater Volumes to Discharge**

| Waste Stream                                       | Source  | Quantity/Day <sup>a</sup>         |                  |
|--|---|-----------------------------------|------------------|
|  |   | Previously Permitted <sup>b</sup> | Proposed         |
| Circulating Water Return (U4 only)                 | Condenser   | 200,000,000                       | 0                |
| Stormwater Oil Water Separators Effluent           | Plant and equipment drains, area precipitation runoff | 3,100                             | 3,100            |
| Existing Retention Basin                           | Effluent HRSG, oil water separator effluent           | 80,000                            | 0                |
| Total Effluent to Outfall 002                      | Circulating water and oil water separator effluent    | 201,000,000                       | 0                |
| Total Sanitary Effluent to City Sewer <sup>b</sup> | Sanitary drains system                                | 750 <sup>c</sup>                  | 750 <sup>c</sup> |

<sup>a</sup> All numbers are approximate based on peak discharge conditions.

<sup>b</sup> Assumes 6 gallons per minute, 24 hour day.

<sup>c</sup> Assumes an average daily flow of 0.52 gpm total from all sanitary waste streams.

Units = Gallons per day

## 2.5 Site Drainage

Stormwater generated during construction will be discharged under an existing Construction Stormwater National Pollutant Discharge Elimination System discharge permit obtained in compliance with existing COCs. Future site stormwater in the area of Units 5–8, following their construction, will be collected in yard drains that will route stormwater to an oil/water separator prior to discharge at Outfall 002.

## 2.6 Air Emission Characteristics

The CC Fast and Rolls Royce Trent 60 peaker units incorporate dry low NO<sub>x</sub> combustion systems. In this combustion system, NO<sub>x</sub> control is achieved without use of water or steam injection. As described above, the CC Fast and Rolls Royce Trent 60 peaker unit fast-start capability allows the gas turbine generators to reach their optimum air emissions performance operating levels faster, which significantly reduces startup emissions.

As discussed previously, the proposed ESPFM includes the installation of one GE fast-start combined cycle gas turbine and two advanced Trent 60 simple cycle turbines. Each unit will be equipped with an inlet air filter and an inlet air-cooling system. Tables 2-2, 2-3, and 2-4 list the technical specifications for new generation. The HRSG for the CC Fast combined-cycle gas unit, and the exhaust ducts for the two Trent 60 simple-cycle gas turbines, will be equipped with air emissions controls equipment including SCR system for NO<sub>x</sub> control and an oxidation catalyst for CO control. A continuous emission monitoring (CEM) system (CEM) will also be included.

A more detailed review of the emission levels for the amended project is included in Section 3.1, Air Quality.

### 2.6.1 Emissions Control and Monitoring Equipment

This section describes the emissions controls and CEMS equipment. The combustion and post-combustion emission control technologies presented below will optimize emissions reductions consistent with normal operational practices. The ESPFM will use dry low-NO<sub>x</sub> combustion combined with catalyst technology to control NO<sub>x</sub> and CO emissions. Combustion design with clean fuels will be used to minimize emissions of other pollutants. Table 2-17 identifies the anticipated chemical usage required to operate the various environmental control systems.

TABLE 2-17  
Anticipated Chemical Usage and Storage\*

| Material   | Purpose                                      | Usage/Day  | Maximum Amount Stored | Storage Type            |
|--|--|------------|-----------------------|-------------------------|
| Neutralizing amine solution                              | Feedwater pH control                         | 5 lb       | 800 gal               | Portable vessel         |
| Oxygen scavenger solution                                | Feedwater oxygen control                     | 2.5 lb     | 800 gal               | Portable vessel         |
| Di-, tri-sodium phosphate solution                       | Boiler water pH/scale control                | 5 lb       | 800 gal               | Portable vessel         |
| Aqueous ammonia (approximately 29%) NH <sub>4</sub> (OH) | NOx emissions control                        | 1,500 gal  | 20,000 gal            | Existing tank           |
| Hydrochloric acid HCl                                    | Chemical cleaning of HRSG                    | As needed  | Temporary only        | Portable vessel         |
| Ammonium bifluoride NH <sub>4</sub> HF <sub>2</sub>      | Chemical cleaning of HRSG                    | As needed  | Temporary only        | Portable vessel         |
| Citric acid  | Chemical cleaning of HRSG, feedwater systems | As needed  | Temporary only        | Portable vessel         |
| EDTA chelant   | Chemical cleaning of HRSG, feedwater systems | As needed  | Temporary only        | Portable vessel         |
| Sodium hypochlorite                                      | Biofouling Control in                        | 13 gal     | 360 gal               | Portable vessel         |
| NaOCl (12.5%)  | Circulating Water                            |            |                       |                         |
| Sodium nitrite NaNO <sub>2</sub>                         | Chemical cleaning of HRSG                    | As needed  | Temporary only        | Portable vessel         |
| Sulfuric acid for station                                | Electrical/ctrl building                     | 0          | 600 gal               | Battery                 |
| Sulfur hexafluoride                                      | Circuit Breakers                             | As needed. |                       | Compressed gas cylinder |
| Batteries  | Combustion turbine                           | 0          | 732 gal               | Battery                 |
|  | Miscellaneous                                | 0          | 100 gal               | Battery                 |
| Hydrogen   | Generator cooling                            | 800 cu ft  | 70,000 cu ft          | Tank, C.S.              |

\*All numbers are approximate.

Information based on Table 3.4-8 from 00-AFC-14

## 2.6.2 NO<sub>x</sub> Emissions

Dry low-NO<sub>x</sub> combustor systems will be provided to control the NO<sub>x</sub> concentration in the CTGs' exhaust gas. This combustion emission control technology reduces peak flame temperature for natural-gas-fired units by staging combustors and premixing fuel with air prior to combustion in the primary zone. A selective catalytic reduction system (SCR) in the HRSG for the combined cycle unit, and in the exhaust ducts for the two Trent 60 simple cycle gas turbines, will provide further reduction of NO<sub>x</sub>. This is an add-on control technology in which ammonia will be injected into the exhaust gas stream in the presence of a catalyst bed to combine with NO<sub>x</sub> in a reduction reaction forming nitrogen and water. For this reaction to proceed satisfactorily, the exhaust gas temperature must be maintained between 450°F and 850°F. The SCR equipment will include a reactor chamber, catalyst modules, ammonia storage system, ammonia vaporization and injection system, and monitoring equipment and sensors. The reactor chamber would be located in an appropriate zone of the HRSG where the catalyst will be the most effective at all loads. The ammonia injection is located upstream of the catalyst. SCR is a commercially available, demonstrated control technology currently employed on several combined cycle combustion turbine projects capable of very low NO<sub>x</sub> emissions (< 2.5 ppmvd).

## 2.6.3 CO Emissions

Combustor designs lower CO emissions concurrently with NO<sub>x</sub> emissions. To further reduce CO emissions, an oxidation catalyst will be used. An oxidation catalyst consists of a noble metal catalyst section incorporated into the combustion turbine exhaust. The catalyst promotes oxidation of CO to carbon dioxide (CO<sub>2</sub>) at much lower temperatures (650°F to 1150°F) than possible for oxidation without the catalyst. The control efficiency is primarily a function of gas residence time and can exceed 90 percent.

## 2.6.4 VOC Emissions

Volatile organic compounds (VOCs) include all unburned hydrocarbons except methane. VOC emissions are low due to proper combustion controls in the combustion turbine. No other controls are required for VOC control.

## 2.6.5 Particulates

Particulate emissions are minimized through the use of natural gas. In addition, inlet air filtration is used to minimize airborne particulate ingestion into the combustion turbine. Particulate emission from combustion of natural gas is minimal as compared to other types of fossil fuels.

## 2.6.6 Emission Monitoring

The project will install a continuous CEM system, which will sample, analyze, and record the concentration of CO, NOx, and oxygen/carbon dioxide in the flue gas. The system generates a log of emissions data and provides alarm signals to the control room when the level of emissions exceeds pre-selected limits. Continuous compliance with the NOx and CO emission limits will be demonstrated with the CEM system based on the applicable averaging time designated.

## 2.7 Fire Protection

The fire protection systems limit personnel injury, loss of life, property loss, and plant downtime due to fire. The existing firewater system has been upgraded significantly as part of the ESEC project; the location of the existing fire/service water storage tank and associated electric motor-driven firewater pump will not change. The firewater supply and pumping system will provide the code required quantity of fire-fighting water to yard hydrants, hose stations, and water spray and sprinkler systems. Two sources of firewater will be provided. The primary source will be the existing fire/service water storage tank and the secondary source will be the water main line from the City of Manhattan Beach. The fire/service water storage tank has capacity reserved for firewater use only, in accordance with NFPA 13. A 100 percent capacity, electric motor-driven pump takes suction from the fire/service water storage tank. A 100 percent capacity diesel engine-driven pump will take suction from the city water line and will operate as the backup pump to the electric motor-driven pump. Both pumps are capable of supplying maximum water demand for any automatic sprinkler system plus water for fire hydrants and hose stations.

The new firewater distribution system required for Units 5, 6, 7 and 8, proposed Units 9, 10, 11 and 12, the new administration building, maintenance shop, and warehouse will be incorporated into the existing firewater distribution system. The performance of the existing firewater distribution system will not be changed with the addition of the new loop and new services. A new fire main loop will be installed around Units 5, 6, 7 and 8. This loop will connect into the existing fire main loop currently serving Units 3 and 4, the switchyard, and the existing fuel oil storage tank area.

The firewater system will have sectionalizing valves so that a failure in any part of the system can be isolated while allowing the remainder of the system to function properly. Fire hydrants with hose houses will be spaced at approximately 250-foot intervals around the fire loop. The hydrants will be located and the hose houses equipped in accordance with NFPA 24 and local fire codes. Valves requiring periodic testing will be accessible. An electric motor-driven jockey pump will maintain water pressure in the firewater distribution headers. During fire conditions, the electric motor-driven fire pump will start automatically when pressure in the firewater distribution header drops. The motor-driven pump will take suction under a positive head from the fire/service water storage tank. Once started, the pump will continue to run until manually stopped. Discharge from the pump will be connected to the underground yard loop.

Fixed fire protection systems will be provided for the steam turbine bearings and lube oil equipment and station transformers. Sprinkler and fixed spray systems will be designed and installed in accordance with NFPA 13 and NFPA 15, respectively.

In addition to the fixed fire protection system, portable CO<sub>2</sub> and dry chemical extinguishers will be located throughout the plant (including the switchgear rooms), with size, rating, and spacing in accordance with NFPA 10. Handcart CO<sub>2</sub> extinguishers will also be provided in the turbine area as necessary for specific hazards.

Local building fire alarms will be provided in accordance with NFPA 72. All materials will be free of asbestos and will meet the fire and smoke rating requirements of NFPA 255.

Access to the ESEC will be improved as part of the ESPFM. The changed location for the administration/maintenance building, within the existing tank farm area, will enable improved access for facility and emergency services personnel, and visitors. This improvement will alleviate the current access routing that requires looping through the northern portion of the site from the site entrance. The improved access will go straight from the site entrance to the new location of administration/maintenance building.

## 2.8 Construction

Construction activities to support the decommissioning, demolition, and removal of existing Units 3 and 4 and the addition of ESPFM changes as described previously, will involve excavation from demolition activities as well as offsite hauling of demolition wastes, grading and construction of foundations, and site equipment installation. Figures 2-3a–2-3d show the project grading plan. Following the removal of Units 3 and 4, similar to the excavation that occurred with the removal of Units 1 and 2, the project owner intends to overexcavate the area to a uniform level that would enable the installation all of the underground piping and conduit prior to backfilling the area. A summary of estimated land disturbance is included in Table 2-18.

TABLE 2-18  
Excavation Requirements

| Excavation<br>(cubic yards) | Admin/O&M Building Access Road | Admin/O&M Building | Gas Compressor |
|-----------------------------|--------------------------------|--------------------|----------------|
| Cut                         | 227                            | 7703               | 889            |
| Fill                        | 7377                           |                    |                |
| Net                         | -7150                          |                    |                |

Following completion of site preparation activities, construction and startup of the ESEC from site mobilization to commercial operation is expected to take a minimum of 20 months, as shown in Table 2-19. Construction of the facility is expected to accommodate concurrent efforts to minimize site constraints. The overall sequence of construction and startup includes construction foundations, installing major piping and equipment, connecting major site interfaces, erecting major structures, and startup/testing. The schedule and staffing requirements are described in the following sections by major components.



TABLE 2-19  
**Project Labor Needs and Available Labor by Craft/Skill**

| Craft                          | Total Number of Workers in Los Angeles County 1997 <sup>a</sup> | Total Number of Workers in Los Angeles County Available 2004 <sup>b</sup> | Maximum Number of Workers Needed for the Project <sup>c</sup> | Average Number of Workers Needed for the Project | California OES Code <sup>d</sup> |
|--------------------------------|---|---|---|--|----------------------------------|
| Specialized Insulation Workers | 140   | 150   | 27  | 9  | 87802                            |
| Boilermakers/ironworkers       | 29,010  | 31,640  | 70  | 50   | 89100                            |
| Bricklayers/Masons             | 1,480   | 1,870   | 5   | 2  | 87302                            |
| Carpenters                     | 16,870  | 20,200  | 64  | 26.5   | 87102                            |
| Electricians                   | 11,680  | 13,570  | 55  | 28   | 87202                            |
| Laborers                       | 13,810  | 16,640  | 64  | 32   | 98300                            |
| Millwrights                    | 680   | 780   | 16  | 8  | 85123                            |
| Operating Engineers            | 6,900   | 8,190   | 25  | 12   | 95099                            |
| Painters                       | 8,350   | 9,730   | 7   | 2  | 87400                            |
| Pipefitters/Sprinklerfitters   | 6,950   | 8,020   | 111   | 47   | 87502                            |
| Plasterers                     | 8,350   | 9,730   | 26  | 1  | 87400                            |
| Sheetmetal workers             | 4,700   | 5,180   | 16  | 6  | 89132                            |
| Surveyors                      | 630   | 440   | 11  | 4  | 22311                            |
| Field Staff                    | 5,130   | 6,130   | 53  | 34   | 15017                            |
| Teamsters                      | 25,040  | 30,550  | 8   | 3  | 97102                            |

<sup>a</sup>Data from the State of California, Employment Development Department, Labor Market Information, Table 6, Occupational Employment Projections 1997 – 2004. Total workers calculated from the 1995 EDD estimated workforce for Los Angeles County. (EDD, 2000).

<sup>b</sup>Data from the State of California, Employment Development Department, Labor Market Information, Table 6, Occupational Employment Projections 1997 – 2004. Total workers calculated from the 1995 EDD estimated workforce.

<sup>c</sup>The maximum number of workers by each craft would be needed at different points in time during project construction. for Los Angeles County. (EDD, 2000).

<sup>d</sup>California OES Code for EDD Occupational Employment Project Data. Codes correlate to the craft/skill noted in this table.

Information based on Table 5.10-7 from 00-AFC-14.

## 2.8.1 Construction Schedule and Workforce

The construction and startup schedule is based on a double-shift through the site preparation period and the construction of the major equipment foundations and pedestals. This will be followed by a single-shift, 5-day workweek basis. Overtime and additional shift work may be used to maintain or enhance the construction schedule. Table 2-20 lists the projected total construction craft manpower by month for the ESEC. An estimated peak of 422 craft and professional personnel is anticipated in month 11 following construction mobilization.

TABLE 2-20  
Construction Staffing Schedule

| Month After Construction Mobilization | 1         | 2         | 3          | 4          | 5          | 6          | 7          | 8          | 9          | 10         | 11         | 12         | 13         | 14         | 15         | 16         | 17         | 18         | 19        | 20        |
|---------------------------------------|-----------|-----------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|-----------|-----------|
| <b>Generating Facility</b>            |           |           |            |            |            |            |            |            |            |            |            |            |            |            |            |            |            |            |           |           |
| Insulation Workers                    |           |           |            |            |            |            |            |            |            | 5          | 10         | 17         | 19         | 27         | 27         | 25         | 25         | 9          | 8         | 6         |
| Boilermakers                          |           |           |            |            | 8          | 11         | 24         | 26         | 31         | 31         | 31         | 28         | 26         | 24         | 15         | 15         | 5          | 5          | 4         | 4         |
| Bricklayers and Masons                |           |           | 1          | 1          | 3          | 5          | 3          | 3          | 3          | 2          | 2          | 1          | 1          | 1          | 1          | 1          | 1          | 1          | 1         |           |
| Carpenters                            | 12        | 15        | 28         | 40         | 50         | 64         | 39         | 42         | 38         | 34         | 29         | 25         | 25         | 23         | 18         | 15         | 10         | 5          | 5         | 4         |
| Electricians                          | 4         | 4         | 13         | 13         | 24         | 20         | 24         | 34         | 37         | 42         | 47         | 52         | 55         | 52         | 44         | 33         | 26         | 13         | 8         | 6         |
| Ironworkers                           | 3         | 8         | 11         | 19         | 24         | 21         | 53         | 36         | 39         | 36         | 33         | 26         | 21         | 15         | 13         | 10         | 10         | 5          | 5         |           |
| Laborers                              | 16        | 23        | 38         | 48         | 54         | 64         | 37         | 40         | 42         | 39         | 39         | 37         | 37         | 29         | 29         | 21         | 18         | 10         | 8         | 6         |
| Millwrights                           |           |           |            | 5          | 5          | 12         | 7          | 10         | 14         | 14         | 16         | 13         | 13         | 10         | 10         | 9          | 9          | 4          | 4         | 2         |
| Operating Engineers                   | 4         | 7         | 11         | 9          | 9          | 13         | 13         | 16         | 17         | 18         | 19         | 19         | 19         | 15         | 14         | 12         | 8          | 5          | 3         | 2         |
| Plasterers                            |           |           |            |            |            |            |            | 1          | 1          | 3          | 3          | 5          | 4          | 5          | 2          | 2          |            |            |           |           |
| Painters                              |           |           |            |            |            |            |            | 1          | 1          | 3          | 3          | 5          | 4          | 5          | 5          | 5          | 5          | 5          | 4         | 2         |
| Pipefitters                           | 4         | 9         | 16         | 20         | 31         | 31         | 40         | 53         | 56         | 87         | 93         | 101        | 102        | 81         | 72         | 30         | 27         | 24         | 15        | 3         |
| Sheetmetal Workers                    |           |           |            |            |            |            |            |            | 3          | 5          | 8          | 10         | 10         | 13         | 15         | 16         | 14         | 13         | 5         | 2         |
| Sprinklerfitters                      |           |           |            |            |            |            |            | 1          | 1          | 1          | 1          | 2          | 3          | 5          | 9          | 8          | 8          | 5          | 1         |           |
| Teamsters                             | 2         | 2         | 2          | 2          | 2          | 2          | 2          | 2          | 2          | 2          | 2          | 2          | 2          | 2          | 2          | 2          | 1          | 1          | 1         | 1         |
| Surveyors                             | 2         | 2         | 4          | 7          | 7          | 9          | 4          | 4          | 4          | 4          | 4          | 4          | 4          | 4          | 3          | 3          | 1          | 1          |           |           |
| <b>Manual Staff Subtotal</b>          | <b>47</b> | <b>70</b> | <b>124</b> | <b>164</b> | <b>217</b> | <b>252</b> | <b>246</b> | <b>269</b> | <b>289</b> | <b>326</b> | <b>340</b> | <b>347</b> | <b>345</b> | <b>311</b> | <b>279</b> | <b>207</b> | <b>168</b> | <b>106</b> | <b>72</b> | <b>38</b> |
| Contractor Staff                      | 5         | 13        | 24         | 37         | 48         | 48         | 35         | 37         | 45         | 45         | 49         | 49         | 47         | 44         | 41         | 34         | 30         | 13         | 11        | 6         |
| <b>Subtotal</b>                       | <b>52</b> | <b>83</b> | <b>148</b> | <b>201</b> | <b>265</b> | <b>300</b> | <b>281</b> | <b>306</b> | <b>334</b> | <b>371</b> | <b>389</b> | <b>396</b> | <b>392</b> | <b>355</b> | <b>320</b> | <b>241</b> | <b>198</b> | <b>119</b> | <b>83</b> | <b>44</b> |
| <b>Pipelines</b>                      |           |           |            |            |            |            |            |            |            |            |            |            |            |            |            |            |            |            |           |           |
| Carpenters                            |           |           |            |            |            |            |            |            |            | 3          | 3          | 3          |            |            |            |            |            |            |           |           |
| Electricians                          |           |           |            |            |            |            |            |            |            |            | 2          | 2          |            |            |            |            |            |            |           |           |
| Laborers                              |           |           |            |            |            |            |            |            | 7          | 8          | 8          | 7          |            |            |            |            |            |            |           |           |
| Operating Engineers                   |           |           |            |            |            |            |            |            | 2          | 6          | 6          | 2          |            |            |            |            |            |            |           |           |
| Painters                              |           |           |            |            |            |            |            |            |            |            |            | 2          |            |            |            |            |            |            |           |           |
| Pipefitters                           |           |           |            |            |            |            |            |            |            | 2          | 2          | 2          |            |            |            |            |            |            |           |           |
| Surveyors                             | 2         | 2         |            |            |            |            | 2          | 2          | 2          | 2          | 2          | 2          |            |            |            |            |            |            |           |           |
| Teamsters                             |           |           |            |            |            |            |            |            | 2          | 6          | 6          | 4          |            |            |            |            |            |            |           |           |

TABLE 2-20

**Construction Staffing Schedule**

| Month After Construction Mobilization | 1         | 2         | 3          | 4          | 5          | 6          | 7          | 8          | 9          | 10         | 11         | 12         | 13         | 14         | 15         | 16         | 17         | 18         | 19        | 20        |
|---------------------------------------|-----------|-----------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|-----------|-----------|
| Manual Staff Subtotal                 | 2         | 2         |            |            |            |            | 2          | 2          | 13         | 27         | 29         | 24         |            |            |            |            |            |            |           |           |
| Contractor Staff                      | 1         | 1         |            |            |            |            | 1          | 1          | 2          | 4          | 4          | 2          |            |            |            |            |            |            |           |           |
| Subtotal                              | 3         | 3         |            |            |            |            | 3          | 3          | 15         | 31         | 33         | 26         |            |            |            |            |            |            |           |           |
| <b>TOTAL</b>                          | <b>55</b> | <b>86</b> | <b>148</b> | <b>201</b> | <b>265</b> | <b>300</b> | <b>284</b> | <b>309</b> | <b>349</b> | <b>402</b> | <b>422</b> | <b>422</b> | <b>392</b> | <b>355</b> | <b>320</b> | <b>241</b> | <b>198</b> | <b>119</b> | <b>83</b> | <b>44</b> |

Information based on Table 3.9-1 from 00-AFC-14.

## 2.8.2 Construction Plans

The construction staging and laydown area, as well as the construction worker parking area, will be at the locations indicated in Figure 2-10. A general contractor will be selected for the design, procurement, and construction of the facility. The general contractor for specialty work portions, as needed, will select subcontractors. Table 2-21 lists the demolition equipment required.

TABLE 2-21

**Demolition Equipment Usage**

| Demolition Schedule After Notice to Proceed | Equipment: Average Number/Day/Month |           |           |           |           |           |
|---|-------------------------------------|-----------|-----------|-----------|-----------|-----------|
|   | 1                                   | 2         | 3         | 4         | 5         | 6         |
| Crawler Excavator w/Breaker                 | 1                                   |           |           | 3         | 3         |           |
| Crawler Excavator w/Grapple                 | 1                                   | 1         | 1         | 1         | 1         |           |
| Crawler Excavator w/Shear                   |                                     | 2         | 3         |           |           |           |
| Crawler Excavator w/Pulverizer              | 1                                   |           |           | 2         | 2         |           |
| Skid Steel Loader                           | 2                                   | 2         | 2         | 2         | 2         | 2         |
| Track Loader                                | 1                                   | 2         | 2         | 2         | 2         |           |
| Rubber Tire Loader                          | 1                                   | 1         | 1         | 1         | 1         | 2         |
| Water Truck                                 | 1                                   | 1         | 1         | 1         | 1         | 1         |
| Stomper                                     |                                     |           |           | 1         |           |           |
| Hydro-Crane                                 |                                     | 2         | 2         |           |           |           |
| Crawler Crane                               |                                     | 2         | 2         |           |           |           |
| Portable Crusher                            |                                     |           |           |           |           | 1         |
| Bottom Dumps                                |                                     |           |           | 5         |           | 15        |
| Ten Wheeler with Dump Bins                  | 1                                   | 1         | 1         | 1         | 1         | 1         |
| Semi-End Dumps                              | 3                                   | 7         | 7         | 5         | 5         | 3         |
| Tractor/Trailer                             | 1                                   | 1         | 1         | 1         | 1         | 1         |
| <b>Total</b>                                | <b>13</b>                           | <b>22</b> | <b>23</b> | <b>25</b> | <b>19</b> | <b>26</b> |

Information based on Table 3.8-2 from 00-AFC-14.

## 2.8.3 Mobilization

The general contractor will mobilize within 6 months after full notice to proceed. The initial efforts will include site work, establishing site grading and storm water control, and establishing the laydown areas and construction parking. Tables 2-22 through 2-25 include information related to construction schedule and equipment usage.

TABLE 2-22

**Schedule of Truck Deliveries/Demolition Materials (Excluding Heavy Equipment Deliveries)**

| Months After Notice to Proceed | Total Number Of Trips Per Month |           |            |            |            |           |
|--------------------------------|---------------------------------|-----------|------------|------------|------------|-----------|
|                                | 1                               | 2         | 3          | 4          | 5          | 6         |
| Equipment Services             | 2                               | 4         | 4          | 3          | 2          | 1         |
| Oxygen & Propane               | 10                              | 25        | 15         | 15         | 10         | 6         |
| Diesel Fuel                    | 8                               | 25        | 25         | 25         | 15         | 10        |
| Drinking Water                 | 4                               | 4         | 4          | 4          | 4          | 4         |
| First Aid Supplied             | 1                               | 1         | 1          | 1          | 1          | 1         |
| Small Tools & Supplies         | 4                               | 4         | 4          | 4          | 2          | 2         |
| Trench Plate                   | 2                               | 1         |            | 3          |            |           |
| <b>Subtotal</b>                | <b>31</b>                       | <b>64</b> | <b>53</b>  | <b>55</b>  | <b>34</b>  | <b>24</b> |
| <b>Average Daily</b>           | <b>1.5</b>                      | <b>3</b>  | <b>2.5</b> | <b>2.5</b> | <b>1.5</b> | <b>1</b>  |

Information based on Table 3.8-3 from 00-AFC-14.

TABLE 2-23

**Heavy Equipment Delivery Schedule**

| Months After Notice to Proceed          | Number of Mobilizations & Demobilizations per Month |            |            |            |            |           |
|---|---|------------|------------|------------|------------|-----------|
|   | 1   | 2          | 3          | 4          | 5          | 6         |
| Excavator                               | 4   |            |            | 2          |            | 6         |
| Skid Steer Loader                       | 1   | 1          | 1          |            | 1          | 2         |
| Track Loader                            | 1   | 1          |            |            |            | 2         |
| Rubber Tired Loader                     | 1   |            |            |            | 1          | 4         |
| Water Truck                             | 1   |            |            |            |            | 1         |
| Stomper                                 |   |            |            | 1          | 1          |           |
| Cranes                                  |   | 4          |            | 4          |            |           |
| Portable Crusher                        |   |            |            |            |            | 2         |
| <b>Total Heavy Equipment Deliveries</b> | <b>8</b>  | <b>7</b>   | <b>1</b>   | <b>7</b>   | <b>3</b>   | <b>17</b> |
| <b>Average per day</b>                  | <b>0.4</b>  | <b>0.3</b> | <b>0.1</b> | <b>0.3</b> | <b>0.1</b> | <b>1</b>  |

Information based on Table 3.8-4 from 00-AFC-14.

**TABLE 2-24  
Construction Equipment Usage**

| Construction Schedule - Month After Mobilization                                     | 1 | 2 | 3 | 4 | 5 | 6 | 7  | 8  | 9  | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 |
|--|---|---|---|---|---|---|----|----|----|----|----|----|----|----|----|----|----|----|----|----|
| <b>Generating Facility</b>   |   |   |   |   |   |   |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| <b>Air Compressors</b>   |   |   |   |   |   |   |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| Ingersoll Rand, diesel, 185 cfm, 75%, 8 hrs/day, 5 days/wk                           |   | 3 | 3 | 5 | 5 | 8 | 11 | 13 | 16 | 16 | 16 | 16 | 16 | 10 | 10 | 9  | 3  | 1  |    |    |
| <b>Paving Equipment</b>  |   |   |   |   |   |   |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| Asphalt paver, Cat, AP-800B, diesel, 102 hp, 85%, 8 hrs/day, 5 days/wk               |   |   |   |   |   |   |    |    |    |    |    |    |    |    |    | 2  | 2  | 2  | 2  |    |
| <b>Compactors</b>  |   |   |   |   |   |   |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| Cat, CS-563, diesel, 145 hp 65%, 8hrs/day, 5 days/wk                                 | 1 | 1 | 1 | 1 | 1 | 1 | 1  | 1  | 1  | 1  | 1  | 1  | 1  |    |    | 1  | 1  | 1  | 1  |    |
| <b>Portable Compression Equipment</b>  |   |   |   |   |   |   |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| Multiquip, Jumping Jack, MRT-80L, gas/oil, 2 cycle, 3.3 hp, 60%, 8hrs/day, 5 days/wk | 1 | 1 | 2 | 2 | 2 | 2 | 2  | 2  | 2  | 2  | 2  | 1  | 1  |    |    | 1  | 1  | 1  | 1  |    |
| Multiquip, Plate Compactor, MVC-62H, gasoline, 4.6 hp, 60%, 8 hrs/day, 5 days/wk     |   | 1 | 1 | 2 | 2 | 2 | 2  | 2  | 2  | 2  | 1  | 1  | 1  |    |    | 1  | 1  | 1  | 1  |    |
| <b>Concrete Vibrators</b>  |   |   |   |   |   |   |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| North Rock, flex shaft vibrator, electric, 15 amps, 50%, 8hrs/day, 5 days/wk         |   | 2 | 2 | 5 | 5 | 6 | 6  | 6  | 6  | 6  | 5  | 5  | 4  | 2  | 2  |    |    |    |    |    |
| <b>Light Towers</b>  |   |   |   |   |   |   |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| Magnum, Nightbuster 5000, 440000lumen, 6000W, 15.5 hp, 70%, 10 hrs/day, 5 days/wk    | 2 | 2 | 2 | 2 | 2 | 2 | 2  |    |    |    |    |    |    |    |    |    |    |    |    |    |
| <b>Dozer</b>   |   |   |   |   |   |   |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| Cat, D8U, diesel, 285 hp, 70%, 8 hrs/day, 5 days/wk                                  | 1 | 1 | 2 | 2 | 2 | 2 | 2  | 2  | 1  | 1  | 1  | 1  | 1  |    |    | 1  | 1  | 1  | 1  |    |
| <b>Excavator, Backhoe</b>  |   |   |   |   |   |   |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| Cat, 312, diesel 84 hp, 75%, 8 hrs/day, 5 days/wk                                    | 1 | 1 | 2 | 2 | 2 | 2 | 2  | 2  | 2  | 2  | 1  | 1  | 1  | 1  | 1  | 1  | 1  | 1  | 1  | 1  |
| <b>Excavator, Loader</b>   |   |   |   |   |   |   |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| Cat, 936 F, diesel, 200 hp, 80%, 8 hrs/day, 5 days/wk                                | 1 | 1 | 1 | 1 | 1 | 1 |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| Cat, 938 F, diesel, 140 hp, 80%, 8 hrs/day, 5 days/wk                                | 1 | 1 | 2 | 2 | 1 | 1 |    |    |    |    |    |    |    |    |    |    |    |    |    |    |

TABLE 2-24  
Construction Equipment Usage

| Construction Schedule - Month After Mobilization                        | 1 | 2 | 3  | 4  | 5  | 6  | 7  | 8  | 9  | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 |
|---|---|---|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|
| Excavator, Motor Grader   |   |   |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| Cat, 140G, diesel, 150 hp, 90%, 8hrs/day, 5 days/wk                     | 1 | 1 | 1  | 1  | 1  | 1  |    |    |    |    |    |    |    |    |    | 1  | 1  | 1  | 1  |    |
| Cranes, 225 Ton   |   |   |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| Manitowoc, 4100W, diesel, 350 hp, 70%, 8 hrs/day, 5 days/wk             |   |   |    |    |    | 1  | 1  | 1  | 1  | 1  | 1  | 1  | 1  |    |    |    |    |    |    |    |
| Cranes, 150 Ton   |   |   |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| Manitowoc, diesel, 250 hp, 70%, 8 hrs/day, 5 days/wk                    |   |   |    |    |    | 1  | 1  | 1  | 1  | 1  | 1  | 1  | 1  |    |    |    |    |    |    |    |
| Cranes, 40 Ton  |   |   | 1  | 1  | 2  | 2  | 2  | 2  | 2  | 2  | 2  | 2  | 2  | 2  | 1  | 1  |    |    |    |    |
| Grove, RT700B, diesel, 185 hp, 50%, 8 hrs/day, 5 days/wk                |   |   |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| Cranes, 20 Ton  |   | 1 | 1  | 3  | 3  | 4  | 4  | 4  | 4  | 4  | 3  | 3  | 3  | 2  | 2  | 1  | 1  |    |    |    |
| Grove, RT400, diesel, 185 hp, 50%, 8 hrs/day, 5 days/wk                 |   |   |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| Water Trucks  |   |   |    | 1  | 1  | 1  | 1  | 1  | 1  | 1  | 1  | 1  | 1  | 1  | 1  | 1  |    |    |    |    |
| International, diesel, 600 gal, 50%, 8hrs/day, 5days/wk                 |   |   |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| Welders   |   | 1 | 1  | 1  | 1  | 1  | 1  | 1  | 1  | 1  | 1  | 1  | 1  | 1  | 1  | 1  |    |    |    |    |
| Multiquip, GA 3600, gasoline, 7.5 hp, 70%, 8 hrs/day, 5 days/wk         |   |   |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| Multiquip, BLW-300SS, diesel, 23 hp, 75%, 8 hrs/day, 5 days/wk          |   | 1 | 3  | 4  | 8  | 8  | 9  | 15 | 16 | 20 | 20 | 20 | 20 | 20 | 15 | 14 | 7  | 3  | 3  | 2  |
| Trucks, Fuel/Lube   |   |   | 1  | 1  | 1  | 3  | 3  | 5  | 5  | 6  | 6  | 6  | 6  | 6  | 4  | 3  | 1  |    |    |    |
| International, diesel, 210 hp, 50%, 8 hrs/day, 5 days/wk                |   |   |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| Trucks, Large   |   | 1 | 1  | 1  | 1  | 1  | 1  | 1  | 1  | 1  | 1  | 1  | 1  | 1  | 1  | 1  |    |    |    |    |
| Cat, D200, articulated truck, diesel, 180 hp, 65%, 8 hrs/day, 5 days/wk |   |   |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| Ford flatbed, diesel, 180 hp, 80%, 8 hrs/day, 5 days/wk                 | 1 | 1 | 3  | 3  | 3  | 3  | 3  | 3  | 3  | 3  | 3  | 2  | 2  |    |    |    |    |    |    |    |
| Radios  | 3 | 3 | 4  | 4  | 4  | 4  | 4  | 4  | 4  | 4  | 4  | 4  | 4  | 4  | 4  | 3  | 3  | 2  | 1  |    |
| Hand held radios  |   |   |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| Tanks, Fuel/Lube  | 4 | 9 | 16 | 20 | 23 | 23 | 26 | 26 | 26 | 31 | 31 | 32 | 31 | 29 | 23 | 21 | 16 | 8  | 8  | 4  |
| 750 gallons each  |   |   |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |

TABLE 2-24  
Construction Equipment Usage

| Construction Schedule - Month After Mobilization                                    | 1         | 2         | 3         | 4         | 5         | 6         | 7         | 8         | 9         | 10         | 11         | 12         | 13         | 14        | 15        | 16        | 17        | 18        | 19        | 20       |
|---|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|------------|------------|------------|------------|-----------|-----------|-----------|-----------|-----------|-----------|----------|
| Truck, Concrete Pump  |           | 1         | 1         | 2         | 2         | 2         | 2         | 2         | 2         | 2          | 2          | 2          | 2          | 2         | 2         | 2         | 1         | 1         |           |          |
| International, diesel, 190 hp, 60%, 8/5   |           |           |           |           |           |           |           |           |           |            |            |            |            |           |           |           |           |           |           |          |
| <b>Subtotal</b>   |           | 1         | 2         | 3         | 3         | 3         | 3         | 3         | 3         | 3          | 3          | 3          | 3          | 2         | 1         | 1         |           |           |           |          |
| <b>Water Supply Pipeline</b>  | <b>17</b> | <b>34</b> | <b>53</b> | <b>69</b> | <b>76</b> | <b>84</b> | <b>88</b> | <b>96</b> | <b>99</b> | <b>109</b> | <b>105</b> | <b>104</b> | <b>102</b> | <b>83</b> | <b>68</b> | <b>66</b> | <b>40</b> | <b>23</b> | <b>20</b> | <b>6</b> |
| Air Compressors   |           |           |           |           |           |           |           |           |           |            |            |            |            |           |           |           |           |           |           |          |
| Ingersol-Rand diesel, 185 cfm, 76%, 8 hrs/day, 5 days/wk                            |           |           |           |           |           |           |           |           |           |            |            |            |            |           |           |           |           |           |           |          |
| Compactors  |           |           |           |           |           |           |           |           | 1         | 1          | 1          | 1          |            |           |           |           |           |           |           |          |
| Cat, CS-563, diesel, 145 hp 65%, 8 hrs/day, 5 days/wk                               |           |           |           |           |           |           |           |           |           |            |            |            |            |           |           |           |           |           |           |          |
| Portable Compression Equipment  |           |           |           |           |           |           |           |           | 1         | 1          | 1          | 1          |            |           |           |           |           |           |           |          |
| Multiquip, Jumping Jack, MRT-80L, gas/oil, 2 cycle, 3.3 hp, 60%, 8hrs/day, 5days/wk |           |           |           |           |           |           |           |           |           |            |            |            |            |           |           |           |           |           |           |          |
| Multiquip, Plate Compactor, MVC-62H, gasoline, 4.6 hp, 60%, 8 hrs/day, 5 days/wk    |           |           |           |           |           |           |           |           | 1         | 1          | 1          | 1          |            |           |           |           |           |           |           |          |
| Concrete Vibrators  |           |           |           |           |           |           |           |           | 2         | 2          | 2          | 2          |            |           |           |           |           |           |           |          |
| North Rock, flex shaft vibrator, electric, 15 amps, 50%, 8 hrs/day, 5 days/wk       |           |           |           |           |           |           |           |           |           |            |            |            |            |           |           |           |           |           |           |          |
| Dozer   |           |           |           |           |           |           |           |           |           |            | 1          | 1          |            |           |           |           |           |           |           |          |
| Cat, D6U, diesel 265hp, 70%, 8 hrs/day, 5 days/wk                                   |           |           |           |           |           |           |           |           |           |            |            |            |            |           |           |           |           |           |           |          |
| Excavator, Backhoe  |           |           |           |           |           |           |           |           | 1         | 1          | 1          | 1          |            |           |           |           |           |           |           |          |
| Cat, 312, diesel, 84 hp, 75%, 8 hrs/day, 5 days/wk                                  |           |           |           |           |           |           |           |           |           |            |            |            |            |           |           |           |           |           |           |          |
| Excavator, Loader   |           |           |           |           |           |           |           |           | 1         | 1          | 1          | 1          |            |           |           |           |           |           |           |          |
| Cat, 900F, diesel, 150 hp, 75%, 8 hrs/day, 5 days/wk                                |           |           |           |           |           |           |           |           |           |            |            |            |            |           |           |           |           |           |           |          |
| Paving Equipment  |           |           |           |           |           |           |           |           | 1         | 1          | 1          | 1          |            |           |           |           |           |           |           |          |
| Asphalt paver, Cat, AP-800B, diesel, 102 hp, 85%, 8 hrs/day, 5days/wk               |           |           |           |           |           |           |           |           |           |            |            |            |            |           |           |           |           |           |           |          |
| Excavator, Motor Grader   |           |           |           |           |           |           |           |           |           |            | 1          | 1          |            |           |           |           |           |           |           |          |
| Cat, 140G, diesel, 150 hp, 90%, 8 hrs/day, 5 days/wk                                |           |           |           |           |           |           |           |           |           |            |            |            |            |           |           |           |           |           |           |          |

TABLE 2-24  
Construction Equipment Usage

| Construction Schedule - Month After Mobilization         | 1         | 2         | 3         | 4         | 5         | 6         | 7         | 8         | 9          | 10         | 11         | 12         | 13         | 14        | 15        | 16        | 17        | 18        | 19        | 20       |
|--|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|------------|------------|------------|------------|------------|-----------|-----------|-----------|-----------|-----------|-----------|----------|
| Cranes, 40 Ton   |           |           |           |           |           |           |           |           | 1          | 1          | 1          | 1          |            |           |           |           |           |           |           |          |
| Grove, RT700B, diesel, 185 hp, 50%, 8 hrs/day, 5 days/wk |           |           |           |           |           |           |           |           |            |            |            |            |            |           |           |           |           |           |           |          |
| Cranes, 20 Ton   |           |           |           |           |           |           |           |           | 1          | 1          | 1          | 1          |            |           |           |           |           |           |           |          |
| Grove, RT400, diesel, 185 hp, 50%, 8 hrs/day, 5 days/wk  |           |           |           |           |           |           |           |           |            |            |            |            |            |           |           |           |           |           |           |          |
| Water Trucks   |           |           |           |           |           |           |           |           |            |            |            | 1          |            |           |           |           |           |           |           |          |
| International, diesel, 500 hp, 50%, 8 hrs/day, 5 days/wk |           |           |           |           |           |           |           |           |            |            |            |            |            |           |           |           |           |           |           |          |
| Trucks, Fuel/Lube  |           |           |           |           |           |           |           |           | 1          | 1          | 1          | 1          |            |           |           |           |           |           |           |          |
| International, diesel, 210 hp, 50%, 8 hrs/day, 5 days/wk |           |           |           |           |           |           |           |           |            |            |            |            |            |           |           |           |           |           |           |          |
| Radios   |           |           |           |           |           |           |           |           | 1          | 1          | 1          | 1          |            |           |           |           |           |           |           |          |
| Hand held radios   |           |           |           |           |           |           |           |           |            |            |            |            |            |           |           |           |           |           |           |          |
| <b>Subtotal</b>  | 3         | 3         |           |           |           |           |           |           | 3          | 4          | 4          | 3          |            |           |           |           |           |           |           |          |
| <b>TOTAL</b>   | 3         | 3         |           |           |           |           |           |           | 15         | 16         | 18         | 18         |            |           |           |           |           |           |           |          |
|  | <b>20</b> | <b>37</b> | <b>53</b> | <b>69</b> | <b>76</b> | <b>84</b> | <b>88</b> | <b>96</b> | <b>114</b> | <b>125</b> | <b>123</b> | <b>122</b> | <b>102</b> | <b>83</b> | <b>68</b> | <b>66</b> | <b>40</b> | <b>23</b> | <b>20</b> | <b>6</b> |

Information based on Table 3.9-2 from 00-AFC-14.

TABLE 2-25  
Construction Schedule for Truck Deliveries of Equipment  
(Excluding Heavy Equipment Deliveries)

| Month After Construction Mobilization | 1  | 2   | 3   | 4   | 5   | 6   | 7  | 8  | 9  | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 |
|---------------------------------------|----|-----|-----|-----|-----|-----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|
| <b>Equipment and Materials</b>        |    |     |     |     |     |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| <b>Generating Facility</b>            |    |     |     |     |     |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| Heat Recovery Steam Generators        |    |     |     |     |     | 5   | 20 | 30 | 39 | 44 | 34 | 34 | 25 | 14 | 10 |    |    |    |    |    |
| Combustion Turbine/Generator          |    |     |     |     |     | 5   | 13 | 25 | 32 | 34 | 29 | 19 | 10 | 10 |    |    |    |    |    |    |
| Steam Turbine/Generator               |    |     |     |     |     |     |    | 3  | 5  | 8  | 10 | 7  | 7  | 3  | 3  |    |    |    |    |    |
| Mechanical Equipment                  |    | 5   | 5   | 16  | 16  | 32  | 32 | 54 | 54 | 53 | 53 | 32 | 26 | 13 | 5  | 3  |    |    |    |    |
| Electrical Equipment and Materials    | 3  | 3   | 8   | 8   | 11  | 16  | 16 | 32 | 32 | 32 | 43 | 37 | 27 | 16 | 16 | 5  | 5  |    |    |    |
| Piping, Supports & Valves             | 3  | 4   | 8   | 14  | 27  | 43  | 43 | 53 | 54 | 64 | 53 | 32 | 26 | 16 | 5  | 5  |    |    |    |    |
| Concrete and Rebar                    | 50 | 197 | 245 | 484 | 484 | 105 | 87 | 43 | 17 | 9  |    |    |    |    |    |    |    |    |    |    |



TABLE 2-25  
**Construction Schedule for Truck Deliveries of Equipment  
 (Excluding Heavy Equipment Deliveries)**

| Month After Construction Mobilization    | 1          | 2          | 3           | 4           | 5           | 6           | 7           | 8           | 9           | 10          | 11          | 12          | 13         | 14         | 15         | 16         | 17         | 18         | 19         | 20         |
|--|------------|------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|------------|------------|------------|------------|------------|------------|------------|------------|
| Miscellaneous Steel/Architectural        |            |            |             | 5           | 5           | 16          | 27          | 32          | 32          | 26          | 10          | 5           |            |            |            |            |            |            |            |            |
| Consumables/Supplies                     | 14         | 16         | 35          | 38          | 43          | 43          | 43          | 43          | 43          | 46          | 46          | 46          | 46         | 37         | 37         | 27         | 27         | 10         | 10         | 3          |
| Contractor Mobilization & Demobilization | 11         | 11         | 16          | 10          | 5           |             |             |             |             |             |             |             |            |            | 3          | 10         | 16         | 10         | 10         | 3          |
| Construction Equipment                   | 5          | 5          | 11          | 8           | 8           | 5           | 5           | 5           | 4           | 4           | 2           | 2           | 1          | 1          | 3          | 3          | 5          | 3          | 3          |            |
| <b>Subtotal</b>                          | <b>30</b>  | <b>88</b>  | <b>271</b>  | <b>327</b>  | <b>583</b>  | <b>602</b>  | <b>281</b>  | <b>291</b>  | <b>319</b>  | <b>309</b>  | <b>302</b>  | <b>275</b>  | <b>208</b> | <b>159</b> | <b>115</b> | <b>79</b>  | <b>61</b>  | <b>28</b>  | <b>23</b>  | <b>6</b>   |
| <b>Average Daily</b>                     | <b>1.4</b> | <b>4.2</b> | <b>12.9</b> | <b>15.6</b> | <b>27.8</b> | <b>28.7</b> | <b>13.4</b> | <b>13.9</b> | <b>15.2</b> | <b>14.7</b> | <b>14.4</b> | <b>13.1</b> | <b>9.9</b> | <b>7.6</b> | <b>5.5</b> | <b>3.8</b> | <b>2.9</b> | <b>1.3</b> | <b>1.1</b> | <b>0.3</b> |

#### Supply Pipeline

|                                    |  |  |  |  |  |  |  |            |            |            |            |            |            |  |  |  |  |  |  |  |
|------------------------------------|--|--|--|--|--|--|--|------------|------------|------------|------------|------------|------------|--|--|--|--|--|--|--|
| Electrical Equipment and Materials |  |  |  |  |  |  |  |            |            | 4          | 4          | 4          |            |  |  |  |  |  |  |  |
| Piping, Supports & Valves          |  |  |  |  |  |  |  |            | 10         | 12         | 10         | 4          |            |  |  |  |  |  |  |  |
| Concrete and Rebar                 |  |  |  |  |  |  |  |            | 12         | 23         | 4          | 4          |            |  |  |  |  |  |  |  |
| Miscellaneous Steel/Architectural  |  |  |  |  |  |  |  |            |            |            | 2          | 4          |            |  |  |  |  |  |  |  |
| Consumables/Supplies               |  |  |  |  |  |  |  |            | 8          | 12         | 12         | 4          |            |  |  |  |  |  |  |  |
| Construction Equipment             |  |  |  |  |  |  |  | 2          | 10         | 2          |            | 9          | 3          |  |  |  |  |  |  |  |
| <b>Subtotal</b>                    |  |  |  |  |  |  |  | <b>2</b>   | <b>40</b>  | <b>53</b>  | <b>32</b>  | <b>29</b>  | <b>3</b>   |  |  |  |  |  |  |  |
| <b>Average Daily</b>               |  |  |  |  |  |  |  | <b>0.1</b> | <b>1.9</b> | <b>2.5</b> | <b>1.5</b> | <b>1.4</b> | <b>0.1</b> |  |  |  |  |  |  |  |

Information based on Table 3.9-3 from 00-AFC-14.

### 2.8.4 Oversize Equipment Delivery

The delivery of equipment will use the routes identified in the 2007 and 2010 PTA and Supplement. No beach delivery is planned.

### 2.8.5 Construction Office Facilities

Construction offices will be set up in trailer or modular facilities on the ESGS property. These will be used to manage the day-to-day aspects of the construction efforts of the owner, engineer, contractor, and subcontractors. Temporary water, power, communication, and sanitary facilities will be established to service the construction offices, as needed.

### 2.8.6 Construction Laydown and Parking

Areas will be established within the site boundary, as well as at a location near the site. The laydown areas are the same as those identified in the 00-AFC-14 Final Decision. The offsite laydown and parking area is approximately 12 acres, of which 10 acres are usable, located at 777 W. 190th Street in the city of Gardena, near the 405 and 110 freeway interchange (Figure 2-1). This site is less than 10 miles southeast of ESGS and is readily accessible to approved traffic routes to the ESGS. The site has been used for construction laydown for the ESEC project since 2011 and will return to its prior use for commercial truck, RV, and automobile storage until ESPFM construction commences in 2016. The offsite laydown site is paved, lighted, and enclosed with a perimeter fence and has an

approximately 5,500 square foot industrial building on the property. Laydown and storage will be handled in three phases. Those items requiring long-term storage will be located at the offsite facility shown in Figure 2-10. Components scheduled to be placed into their final location will be staged onsite in the area of the currently abandoned fuel oil storage tanks at the south end of the property. Components located here will be temporary and on a revolving short-term basis. As construction logistics allow, some items will be located directly in the work area, which will be incorporated into the facility or its final location in the very near term.

A construction parking facility will be established onsite and/or at a location near the plant site as shown on Figure 2-1. This area will provide adequate parking space for construction personnel and visitors during construction. The area will be maintained for stability and safety. Construction workers will be transported to and from the established offsite location at the beginning and end of each work shift.

### 2.8.7 Emergency Facilities

Emergency services will be coordinated with the local fire department and hospital. The existing facility services will also be used as available and capable. An urgent care facility will be contacted to set up non-emergency physician referrals. First-aid kits will be provided around the site and regularly maintained. At least one person trained in first aid will be part of the construction staff. In addition, all foremen and supervisors will be given first-aid training. Fire extinguishers will be located throughout the site at strategic locations at all times during construction.

### 2.8.8 Construction Utilities

During construction, temporary utilities will be provided to the construction offices, laydown areas, and the project site. Temporary construction power will be supplied by strategically distributed utility-furnished power and by portable generators. Area lighting will be provided and located for safety and security. Construction water will be provided by available onsite sources and distributed to the construction area. Drinking water will be distributed daily. Average daily use of construction water is expected to be about 5,000 gallons. During hydrotest, water usage is estimated at 20,000 gallons per day. Used hydrotest water will be discharged through a General NPDES permit for hydrotest water. Portable toilets will be provided throughout the site.

### 2.8.9 Site Services

The following site services will also be provided, either by separate contract, or incorporated into individual construction subcontracts for the ESGs:

- Environmental health and safety training
- Site security
- Site first aid
- Construction testing (e.g., NDE, hydro, soil, concrete)
- Furnishing and servicing of sanitary facilities
- Trash collection and disposal
- Disposal of hazardous materials and waste in accordance with local, state, and federal regulations.

### 2.8.10 Construction Materials and Equipment

Construction equipment usage information is included in Tables 2-22 through 2-25. Truck deliveries will occur weekdays between 6:00 a.m. and 6:00 p.m. During the period of double shift work, it is expected that deliveries will also be required at other hours outside of the delivery times described herein to support the second shift activities. These deliveries are expected to be primarily concrete. Estimated average daily frequency of truck deliveries is shown in Table 2-22. Materials such as concrete, pipe, wire and cable, fuels, reinforcing steel, and small tools and consumables will be delivered to the site by truck. Most of the heavy equipment items will be transported by rail to the common shipping depot nearest to the site. Rail deliveries will be off-loaded and transported to the site by common carrier. Table 2-25 lists the projected delivery of major equipment components.

## 2.8.11 Construction Sequence and Schedule

Installation involves the following steps:

### Step 1: Decommissioning

- Environmental assessment
- Removal of asbestos and hazardous materials

### Step 2: Demolition and Offsite waste disposal

- Mobilize plant shutdown and demolition
- Demolition/heavy wrecking
- Pull Down Units 3 and 4 elevation 20 foot - 90 foot
- Demolish at grade and below grade concrete
- Crush onsite asphalt/concrete rubble
- Mass haul asphalt/concrete
- Demobilization.

### Step 3: Grading and Recontouring

- Cut and fill power block
- Cut and fill balance of site
- Final grading and paving

### Step 4: Foundation and Piping Installation

- Dry cooling tower foundations
- HRSG foundations
- Combustion turbine foundations
- Pipe rack foundations
- Steam turbine pedestal foundations
- Balance of plant foundations
- Underground utilities piping and electrical

### Step 5: Concrete and gravel installation prior to aboveground equipment installation

#### **CC Fast CTG Installation Steps**

- Erect HRSG
- Erect dry cooling tower
- Erect pipe rack steel
- Erect combustion turbine generator
- Install balance of plant equipment
- Erect steam turbine
- Install above ground piping
- Install electrical equipment and instrumentation & controls

#### **Rolls Royce Trent 60 Installation Steps**

Step 1: Install the main gas skid baseplate. (Includes all required engine lubrication and fuel systems as well as the remote I/O module)

Step 2: Install the gas turbine enclosure roof, ventilation system, and exhaust transition.

Step 3: Install air filter and support structure.

Step 4: Install auxiliary equipment skids.

Step 5: Install Trent 60 gas turbine.

Step 6: Install driven equipment which can be done concurrent with the other steps.

Commercial operation is expected in 2018. Total construction schedule is estimated to be approximately 18 to 20 months.

## 2.9 Facility Operation

This section discusses operation and maintenance procedures that would be continue to be undertaken by the project owner to ensure safe, reliable, and environmentally acceptable operation of the ESEC. Operation of the project is expected to require up to 50 full-time employees. Plant operations will be controlled from the existing operator's panel, located in the existing control room. A distributed control and information system (DCS) will provide modulating control, digital control, and monitoring and indicating functions for operation of the plant power block systems.

### 2.9.1 Power Plant Facility

The project includes decommissioning, demolishing, and replacing the existing Units 3 and 4 steam boiler plants with approximately 449 MW gross / 435 MW net of new natural-gas-fired electrical generating capacity. By removing Units 3 and 4, the need for once through ocean water cooling will be eliminated and the project will improve electricity generation by adding fast start and dispatch flexibility capabilities to support southern California grid load balancing.

### 2.9.2 Operation with Seasonal Variation in Ambient Temperature

Output from the combustion turbine generators (CTGs) is sensitive to the temperature and density of the ambient air taken into the CT inlet and used in the combustion process. Inlet cooling has been added to the CC Fast unit to reduce the inlet air temperatures when the CT is at base load and ambient temperatures exceed 59°F. Caldwell wet compression systems are fitted to the Trent 60 units to reduce compressor work and lower the temperature of the high-pressure compressor discharge air at ambient temperatures above approximately 45°F. This reduces the impact of ambient temperature on electrical output and efficiency during the summer peaks when the electrical customer's usage is at its highest.

### 2.9.3 Annual Operating Practices

Generally, the combined-cycle plant will be operated to provide its maximum electrical output throughout the year. To start the plant from a zero percent dispatched operating mode, power will be backfed through the 230-kV transmission lines to start the CTs. The turbine will be fired with natural gas. Once the turbine has been fired and brought to full speed, the CTG can be synchronized with the existing transmission grid. The STG is loaded sequentially after the CTG(s) is loaded. Planned maintenance will be coordinated to reduce the impact of having a unit shut down for maintenance and overhauls. Normally, this work will be planned during the winter periods when the need for electricity is reduced.

### 2.9.4 Facility Controls

Consistent with the installation of Units 5 through 8, the combined facility control system will consist of a state-of-the-art, integrated microprocessor-based distributed digital control and monitoring system (DCS). The DCS will provide for startup, shutdown, and control of plant operation limits, and will provide protection for the equipment. Interlock and logic systems will be provided via hard-wired relays, the DCS, or programmable controllers. Process switches (i.e., pressure, temperature, level, etc.) used for protective functions will be connected directly to the DCS and the protective system.

The facility controls will be designed with a high degree of automation in order to reduce the required actions performed by operating personnel. Where it is not beneficial, systems will not be automated. Through subsystem automation and DCS, the number of individual control switches and indicators that confront the operator will be greatly reduced, improving operations and safety.

The majority of the facility operation equipment will be located in the control room. The control room contains DCS-type control consoles and the auxiliary control panels. In addition, the control room contains the alarm, utility, and log printers.

Local control panels or stations will be furnished only where operator attention is required to set up a system for operation, or where the equipment requires intermittent attention during plant operation. Main control room indication and control will only be duplicated for those variables critical to plant availability.

#### **2.9.4.1 Communications Network**

Functionally distributed and redundant microprocessor-based subsystem controllers will communicate with the main control room via a redundant high-speed communications network.

The communications network will provide unit-wide data access for centralized operation and engineering functions, through DCS. Remote I/O capability will be provided to allow the DCS to interface with remote equipment and to reduce the quantity of long cable runs.

DCS functions and miscellaneous tasks include:

- Perform analog and digital plant control functions to accommodate a consistent operator interface for controlling the power plant equipment.
- Monitor both analog and digital signals to provide the operator/engineer with access to the data around the network.
- Perform alarm monitoring in the main control room for the entire plant.
- Provide graphic displays for all systems and equipment, including electrical systems and controller faceplates.
- Provide data logging and reporting via displays and printed reports.
- Provide long-term data storage of process history.

#### **2.9.5 Reliability and Redundancy**

Critical functions and parameters will have redundant sensors, controls, indicators, and alarms. The system will be designed such that critical controls and indications do not fail due to a failure in the control system implementation of redundancy logic. Control systems in general, and especially the protection system, will be designed according to stringent failure criteria.

Measurement redundancy will be provided for all critical plant parameters. DCS microprocessors will be fully redundant with automatic tracking and switchover capability in the event of a failure of the primary microprocessor. Two fully redundant data communications networks will be provided. The system will permit either network to be disconnected and reconnected while the system remains on-line and in control. The control system will incorporate on-line self-diagnostic features to verify proper operation of system hardware, software, and related support functions such as control power, field contact interrogating power, and the system modules in position.

#### **2.9.6 Utilities**

The West Basin Municipal Water District and the Cities of El Segundo and Manhattan Beach (Metropolitan Water District of Southern California) will own, operate, and maintain the reclaim water and city water supply pipelines, respectively. As owners of the offsite water supply pipelines and associated facilities, they will operate and maintain these lines in accordance with applicable regulations and their normal operating procedures.

Operation and maintenance of the natural gas pipeline will be performed by SoCalGas in accordance with applicable Federal Energy Regulatory Commission and Department of Transportation regulations. This existing pipeline will continue to receive periodic inspections as a part of SoCalGas' pipeline maintenance program. Sanitary waste will be discharged to the existing municipal sewer system operated by the City of Manhattan Beach Public Works Department. The connection to the system will be built, owned and operated by the Public

Works Department. Operation and maintenance of the pipeline will be performed in accordance with applicable regulations and industry standards.

## 2.10 Facility Closure

Facility closure can be either temporary or permanent. Facility closure can result from: 1) sudden and unexpected closure due to unplanned circumstances, such as a natural disaster or temporary fuel shortage; or 2) planned closure in an orderly manner, such as at the end of its useful economic or mechanical life or due to gradual obsolescence. The two types of closure are discussed in the following sections.

Temporary or unplanned closure can result from a number of unforeseen circumstances, ranging from natural disaster to economic forces. For a short-term unplanned closure, where there is no facility damage resulting in a hazardous substance release, the facility would be kept “as is,” ready to re-start operating when the unplanned closure event is rectified or ceases to restrict operations.


The planned life of the generation facility is 30 years. However, if the facility were economically viable at the end of the 30-year operating period, it could continue to operate for a much longer period of time. As power plant operators continuously upgrade their generation equipment, and maintain the equipment up to industry standards, there is every expectation that the generation facility will have value beyond its planned life.

At the time of facility closure, decommissioning will be completed in a manner that protects the health and safety of the public and is environmentally acceptable. Prior to a planned closure, the Owner will submit a specific decommissioning plan that will include the following:

- Identification, discussion, and scheduling of the proposed decommissioning activities for the power generating and other ancillary facilities.
- Description of measures taken to ensure safe shutdown and decommissioning of all equipment, including draining and cleaning of all fuel and chemical storage, and the removal of any hazardous waste.
- Identification of all applicable LORS in effect at the time of closure, and how decommissioning/closure will be accomplished in accordance with the LORS.
- Notification to federal, state, and local agencies, including the CEC.

Once land is used for industrial or commercial purposes, it rarely reverts back to its natural state. Reuse of the land will be encouraged in this case, as opposed to taking additional land for future industrial or commercial purposes. If the plant site is to return to its natural state, the specific decommissioning plan will include a discussion covering the removal of all aboveground and underground objects and material.





N 10900

NEW UNIT






005 8 N

000 6 N

000 6 N






C-SK-003


005 8 N

000 6 N




C-SK-002

000 6 N


















Profile-E1



**PROFILE LOOKING WEST @ E 4903**



**PROFILE LOOKING NORTH @ N 8518**




**ADMINISTRATION BUILDING ACCESS ROAD**









| Parameter                  | Units     | 41°F, 76% RH, 100% Load | 77.8°F, 49.6% RH, 100% Load |
|----------------------------|-----------|-------------------------|-----------------------------|
| Gross Power Output         | MW        | 57.7                    | 46.0                        |
| Gross Heat Rate (LHV)      | Btu/kW-Hr | 7,988                   | 8,428                       |
| 1 Water Flow (Evap Cooler) | lb/hr     | -                       | -                           |
| 2 Caldwell Wet Compression | lb/hr     | -                       | -                           |
| Water Flow (Demmin)        | lb/hr     | -                       | -                           |
| 3 Fuel Flow (Gas Turbine)  | lb/hr     | 22,327                  | 18,798                      |
| 4 Exhaust Flow             | lb/hr     | 1,315,800               | 1,121,040                   |
| Exhaust Temperature        | °F        | 799                     | 846                         |
| 5 Dilution Air Flow        | lb/hr     | 90,900                  | 160,100                     |
| 6 Stack Flow               | lb/hr     | 1,406,700               | 1,281,140                   |
| 6 Stack Temperature        | °F        | 750                     | 750                         |








Scale: 1" = 100'

MENT/PROCESSES  
E REMOVED FOR ESEC

MENT/PROCESSES  
E REMOVED FOR ESPFM
























Figure 9 (Excluding 4)



Detail B - Area 4




Detail C - Area 10



Detail A

Off-Site Laydown and Parking

-  Approved Laydown and Parking Areas
-  PTA Removed Laydown and Parking Areas

| Laydown and Parking Areas |                            | PARKING |
|---------------------------|----------------------------|---------|
| <b>1</b>                  | Kramer                     | ●       |
| <b>2</b>                  | Fedex                      | ●       |
| <b>3</b>                  | LAX-Perishing              | ●       |
| <b>4</b>                  | Marina del Rey Boat Launch | ●       |
| <b>5</b>                  | Dockweiler State Beach     | ●       |
| <b>6</b>                  | Hyperion                   | ●       |
| <b>7</b>                  | Grand Avenue               | ●       |
| <b>8</b>                  | Chevron Marine Terminal    | ●       |
| <b>9</b>                  | Power Plant Site           | ●       |
| <b>10</b>                 | 190th Street               | ●       |

FIGURE 2-10





# Environmental Analysis

---

## 3.1 Air Quality

As discussed in detail in Section 2.0, Project Description, this PTA proposes modifications to the ESEC that necessitate evaluation of environmental impacts and potential amendments to existing COCs. The proposed PTA is for decommissioning, demolishing, and replacing the existing Units 3 and 4 steam boiler plants with approximately 449 MW gross / 435 MW net of new natural-gas-fired electrical generating capacity, consisting of one combined-cycle train and two simple-cycle gas turbines. The air-cooled, combined-cycle train (CC Fast) will consist of a gas turbine generator (GTG, Unit 9), a heat recovery steam generator (HRSG), and one steam turbine generator (STG, Unit 10), rated at 325 MW net / 334 MW gross. The simple cycle turbines (Units 11 and 12) will consist of two air-cooled Trent 60 ISE advanced aeroderivative gas turbines, each rated at 55 MW net / 58 MW gross. The GE turbine will be supported by a small (36 MMBtu/hr) auxiliary boiler that will be incorporated into the operation of the CC Fast. Removal of existing Units 3 and 4 will eliminate the remaining once-through ocean water cooling system at the ESGS site. The ESPFM will improve electricity generation by adding fast-start and dispatch flexibility capability to support southern California grid load balancing. Total site capacity (including the new equipment previously permitted) will not exceed 1,020 MW net—the rated capacity of previously retired Units 1 and 2, plus the capacity of the soon-to-be-retired Unit 3 and operating Unit 4, which will also be retired as part of the ESPFM.

### 3.1.1 Introduction

ESEC LLC, the project owner, a wholly owned subsidiary of NRG Energy, Inc. proposes to upgrade the existing ESEC by decommissioning, demolishing, and replacing existing steam boiler Units 3 and 4 with approximately 449 MW gross / 435 MW net of natural-gas-fired electrical generating capacity. This project will be described as the El Segundo Power Facility Modification (ESPFM) project.

This section of the PTA describes existing air quality conditions; maximum potential impacts from the project; compliance with applicable LORS; and mitigation measures that keep project impacts below applicable thresholds of significance. The methodology and results of the air quality analysis used to assess potential impacts are also presented. The analysis has been conducted according to the CEC) power plant siting requirements and also addresses SCAQMD air permitting requirements.

The project will use the latest, most efficient generation technology to generate electricity in a manner that will minimize the amount of fuel needed, emissions of criteria pollutants, and potential effects on ambient air quality.

Other beneficial environmental aspects of the project that minimize adverse air quality impacts include the following:

- Clean-burning natural gas as fuel;
- SCR and combustion controls (dry low-NOx/dry low emissions [DLN/DLE] combustion) to reduce oxides of nitrogen (NOx) emissions;
- Oxidation catalysts to reduce emissions of carbon monoxide (CO) and hazardous air pollutants; and
- Appropriately sized stacks to reduce ground-level concentrations of exhaust constituents.

Details of the air quality assessment of the project are contained in the following subsections:

- Section 3.1.2, Affected Environment, describes the local environment surrounding the project site, including topography, climate, and existing air quality. The most representative meteorological data—including wind speed and direction, temperature, relative humidity, and precipitation—and the most representative recent ambient concentration measurements for criteria air pollutants are summarized.

- Section 3.1.3, Laws, Ordinances, Regulations, and Standards, describes applicable LORS pertaining to air quality aspects of the project.
- Section 3.1.4, Environmental Consequences, evaluates the maximum potential air quality impacts due to the project's emissions of NO<sub>x</sub>, CO, sulfur oxides (SO<sub>x</sub>), volatile organic compounds (VOC), particulate matter less than 10 microns in diameter (PM<sub>10</sub>), and particulate matter less than 2.5 microns in diameter (PM<sub>2.5</sub>). Emission estimates for these pollutants are presented for the construction phase of the project, as well as for operation of the installed equipment over a full range of operating modes, including commissioning, startups and shutdowns, maintenance activities, and normal operation with operable pollution control systems. A dispersion modeling analysis for nitrogen dioxide (NO<sub>2</sub>), CO, sulfur dioxide (SO<sub>2</sub>), PM<sub>10</sub>, and PM<sub>2.5</sub> is presented; the results show that the project would not cause or significantly contribute to exceedances of the California Ambient Air Quality Standards (CAAQS) or National Ambient Air Quality Standards (NAAQS). Emissions of greenhouse gases (GHG) from the project are also described.
- Section 3.1.5, Cumulative Air Quality Impacts, addresses the cumulative impacts of the project emissions with other potential new sources of air pollution in the area around the ESGS site.
- Section 3.1.6, Consistency with Laws, Ordinances, Regulations, and Standards, describes how the project will comply with applicable LORS pertaining to air quality aspects of the project. This section also provides an analysis of BACT for the proposed project and explains how the use of water injection with SCR and ammonia injection satisfies the SCAQMD NO<sub>x</sub> requirements for BACT for the turbines and how the use of an oxidation catalyst meets the corresponding CO BACT requirements.
- Section 3.1.7, Mitigation Measures, describes the project emission offsets strategy, including emission reduction credits (ERC) that are proposed to offset project emissions.
- Section 3.1.8, Permits Required and Permit Schedule, lists the air quality permits required for the project and provides a permit schedule for the project.
- Section 3.1.9, References, lists the references used to conduct the air quality assessment.

Some air quality data are presented in other sections of this PTA, including an evaluation of toxic air pollutants (see Section 3.8, Public Health) and information relating to the fuel characteristics, heat rate, and startup and operating limits of the project equipment (see Section 2.0, Project Description).

The District has required use of meteorological and ambient data for the period 2007 through 2009 for the purposes of this analysis, and has provided the data in files used to conduct the modeling. All results in this section are based on background data from that time period. The supplemental analysis in support of the Prevention of Significant Deterioration (PSD) application will be submitted at a later date, after receipt of additional data from the District, and will be based on the 5-year period from 2004 through 2008.

### 3.1.2 Affected Environment

This section describes the regional climate and meteorological conditions that influence the transport and dispersion of air pollutants, as well as the existing air quality within the project region. The data presented in this section are representative of the project site.

The ESEC project includes two 1x1 fast start air-cooled combined-cycle trains (Units 5 through 8)—and existing 670 MW natural-gas-fueled steam boiler Units 3 and 4 located on the ESGS site in El Segundo, California. Figures 1-1 and 1-2 show the project vicinity and site. The project site is at the southernmost city limit of the city of El Segundo on the coast of the Pacific Ocean between Dockweiler State Beach and the city of Manhattan Beach. The site address is 301 Vista Del Mar, El Segundo, approximately 2 miles south of the Los Angeles International Airport (LAX). It is located less than a 0.25 mile south of the Los Angeles Department of Water and Power's Scattergood Generating Station and 0.5 mile south of the City of Los Angeles' Hyperion Wastewater Treatment Plant. The Chevron El Segundo refinery is located across Vista Del Mar from the project site. The city of Manhattan Beach is immediately to the south.

### 3.1.2.1 Geography and Topography

The project is located in the coastal region of the South Coast basin, in the city of El Segundo in Los Angeles County. The site elevation is approximately 15 feet above sea level and the site is located directly on the coast, bordered by the Pacific Ocean, the coastline, and a portion of urban Los Angeles. The coastline runs north-northwest to south-southeast along the project boundary. Small bluffs (approximately 100 feet high) run north to south just east of the project boundary, with elevated terrain a significant distance from the project site (approximately 6 miles).

### 3.1.2.2 Meteorology and Climate

The general climate of California is typically dominated by the eastern Pacific high-pressure system centered off the coast of California. In the summer, this system results in low inversion layers with clear skies inland and typically early morning fog by the coast. In winter, this system promotes wind and rainstorms originating in the Gulf of Alaska and striking Northern California.

The large-scale wind flow pattern in the South Coast basin is a diurnal cycle driven by the differences in temperature between the land and the ocean as well as the mountainous terrain surrounding the basin. The Tehachapi and Temblor mountains separate the South Coast and San Joaquin Valley air basins. The San Bernardino, San Gabriel, and Santa Rosa mountains generally make up the eastern mountain range of the South Coast Air Basin. The Santa Monica and Santa Ana mountains make up the northern and southern (respectively) coastal mountain ranges of the South Coast Air Basin.

The nearest full-time meteorological monitoring station to the proposed project site is maintained by the SCAQMD and is located at LAX, approximately 2.5 miles northeast of the project site. Based on 5 years of data collection in 2007–2011, annual maximum ambient temperatures recorded at LAX range from 93 degrees Fahrenheit (°F) to 103°F. The South Coast basin receives most of its rainfall between November and April. LAX recorded an annual average of 12 inches during this period. The wind patterns near the project site are predominately from the west or northwest (approximately 30%). Calm conditions prevail from 10% to approximately 16% of the time. The mixing heights recorded at LAX in the morning range from 335 meters (1,100 feet) to greater than 1,000 meters (3,050 feet). The mixing heights recorded at LAX in the afternoon range from 510 meters (1,670 feet) to 1,200 meters (3,940 feet).

The nearest long-term meteorological station with available temperature and precipitation means and extremes is a National Weather Service Cooperative Network (COOP) station in Los Angeles County at LAX. The ESPFM project is located approximately 2.5 miles to the southwest of LAX weather station located at latitude 33°56.3'N, longitude 118°24.0'W. Data collected at this station over a 30-year period (1971–2000) are presented in Table 3.1-1. The hottest month, August, has an average maximum temperature of 76.7°F and an average minimum temperature of 64.5°F. The coldest month, January, has an average maximum temperature of 65.6°F and an average minimum temperature of 48.7°F.

TABLE 3.1-1

**Average Temperatures and Precipitation at Los Angeles Airport, Los Angeles County (1971-2000)**

|                                  | Jan  | Feb  | Mar  | Apr  | May  | Jun  | Jul  | Aug  | Sep  | Oct  | Nov  | Dec  | Year  |
|----------------------------------|------|------|------|------|------|------|------|------|------|------|------|------|-------|
| Average Maximum Temperature (°F) | 65.6 | 65.7 | 65.8 | 67.8 | 69.4 | 72.5 | 75.4 | 76.7 | 76.4 | 74.3 | 68   | 66.8 | 70.6  |
| Average Minimum Temperature (°F) | 48.7 | 50.1 | 51.4 | 53.7 | 56.9 | 60.1 | 63.3 | 64.5 | 63.4 | 59.3 | 51.2 | 48.6 | 56.1  |
| Precipitation (inches)           | 2.94 | 3.14 | 2.14 | 0.75 | 0.25 | 0.08 | 0.03 | 0.16 | 0.21 | 0.44 | 1.17 | 1.96 | 13.25 |

Source: Western Regional Climate Center (<http://www.wrcc.dri.edu/cgi-bin/cliMAIN.pl?calosa>)

### 3.1.2.3 Overview of Air Quality Standards

The U.S. Environmental Protection Agency (EPA) has established NAAQS for ozone (O<sub>3</sub>), NO<sub>2</sub>, CO, SO<sub>2</sub>, PM<sub>10</sub>, PM<sub>2.5</sub>, and airborne lead. Areas with ambient levels above these standards are designated by EPA as “nonattainment areas” subject to planning and pollution control requirements that are more stringent than standard requirements.

The California Air Resources Board (CARB) has established California ambient air quality standards for ozone, CO, NO<sub>2</sub>, SO<sub>2</sub>, sulfates, PM<sub>10</sub>, PM<sub>2.5</sub>, airborne lead, hydrogen sulfide, and vinyl chloride at levels designed to protect the most sensitive members of the population, particularly children, the elderly, and people who suffer from lung or heart diseases.

Both state and national air quality standards consist of two parts: an allowable concentration of a pollutant, and an averaging time over which the concentration is to be measured. Allowable concentrations are based on the results of studies of the effects of the pollutants on human health, crops and vegetation, and, in some cases, damage to paint and other materials. The averaging times are based on whether the damage caused by the pollutant is more likely to occur during exposures to a high concentration for a short time (one hour, for instance), or to a relatively lower average concentration over a longer period (8 hours, 24 hours, or 1 month). For some pollutants there is more than one air quality standard, reflecting both short-term and long-term effects.

Table 3.1-2 presents the NAAQS and California ambient air quality standards for selected pollutants. The California standards are generally set at concentrations lower than the federal standards and, in some cases, have shorter averaging periods.

### 3.1.2.4 Existing Air Quality

All ambient air quality data presented in this section were published by CARB on the ADAM website and/or by EPA on the AIRS data website. Ambient air concentrations of O<sub>3</sub>, NO<sub>2</sub>, SO<sub>2</sub>, CO, PM<sub>10</sub>, and PM<sub>2.5</sub> are recorded at monitoring stations throughout Los Angeles County. The project site is located in the coastal region of the South Coast basin, bordered by the Pacific Ocean, the coastline, and a portion of urban Los Angeles. The area surrounding to the north and east of the facility is heavily industrial; the ocean lies to the west. The closest residences are a group of residences to the south, located approximately 0.4 km from the project.

The closest air quality monitoring station to the project site is located in LAX approximately 2.5 miles northeast of the site. Therefore, data from the LAX monitoring station were used to represent background air pollutant concentrations for the vicinity of the project. Following District instructions, background data for the 2007 to 2009 time period were selected for the air modeling analysis for the ESPFM, although ten years of background data are presented below to characterize the existing conditions at the project site.

Ambient concentrations of O<sub>3</sub>, NO<sub>2</sub>, SO<sub>2</sub>, CO, and PM<sub>10</sub> are recorded at the LAX monitoring station located at 7201 W. Westchester Parkway, approximately 2.5 miles northeast of the project site. The closest station that monitors ambient PM<sub>2.5</sub> is at the North Long Beach monitoring station (located at 3648 N. Long Beach Blvd), approximately 15 miles southeast of the project site.

**Ozone (O<sub>3</sub>).** Ozone is not directly emitted from stationary or mobile sources, but is an end-product of complex reactions between VOC and NO<sub>x</sub> in the presence of ultraviolet solar radiation. VOC and NO<sub>x</sub> emissions from vehicles and stationary sources—combined with daytime wind flow patterns, mountain barriers, temperature inversions, and intense sunlight—generally result in the highest O<sub>3</sub> concentrations. For purposes of both state and federal air quality planning, the South Coast air basin is classified as a nonattainment area with respect to both state and national ambient standards for ozone. Table 3.1-3 shows the measured ozone levels at the LAX station during the period from 2002 to 2011. The 1 hour ozone CAAQS of 0.09 parts per million (ppm) was exceeded four times during the ten-year analysis period; it has not been exceeded at this monitoring station since 2004.

TABLE 3.1-2  
National and California Ambient Air Quality Standards

| Pollutant   | Averaging Time             | California Standards  |   | Federal Standards                                |                                      |   |
|---|----------------------------|---|---|--|--------------------------------------|---|
|   |                            | Concentration   | Method  | Primary  | Secondary                            | Method  |
| Ozone   | 1 Hour                     | 0.09 ppm<br>(180 µg/m <sup>3</sup> )  | Ultraviolet<br>Photometry                       | —  | Same as Primary<br>Standard          | Ultraviolet Photometry  |
|   | 8 Hour                     | 0.07 ppm<br>(137 µg/m <sup>3</sup> )  |   | 0.075 ppm<br>(147 µg/m <sup>3</sup> )            |                                      |   |
| Respirable<br>Particulate<br>Matter (PM <sub>10</sub> ) | 24 Hour                    | 50 µg/m <sup>3</sup>  | Gravimetric or<br>Beta Attenuation              | 150 µg/m <sup>3</sup>                            | Same as Primary<br>Standard          | Inertial Separation and<br>Gravimetric Analysis                         |
|   | Annual<br>Arithmetic Mean  | 20 µg/m <sup>3</sup>  |   | —  |                                      |   |
| Fine<br>Particulate<br>Matter<br>(PM <sub>2.5</sub> )   | 24 Hour                    | No Separate State Standard  |   | 35 µg/m <sup>3a</sup>                            | Same as Primary<br>Standard          | Inertial Separation and<br>Gravimetric Analysis                         |
|   | Annual<br>Arithmetic Mean  | 12 µg/m <sup>3</sup>  | Gravimetric or<br>Beta Attenuation              | 12.0 µg/m <sup>3</sup>                           |                                      |   |
| Carbon<br>Monoxide<br>(CO)                              | 1 Hour                     | 20 ppm<br>(23 mg/m <sup>3</sup> )   | Non-Dispersive<br>Infrared<br>Photometry (NDIR) | 35 ppm<br>(40 mg/m <sup>3</sup> )                | None                                 | Non-Dispersive Infrared<br>Photometry (NDIR)                            |
|   | 8 Hour                     | 9.0 ppm<br>(10 mg/m <sup>3</sup> )  |   | 9 ppm<br>(10 mg/m <sup>3</sup> )                 |                                      |   |
| Nitrogen<br>Dioxide (NO <sub>2</sub> )                  | 1 hour                     | 0.18 ppm<br>(339 µg/m <sup>3</sup> )  | Gas Phase Chemi-<br>luminescence                | 100 ppb <sup>b</sup><br>(188 µg/m <sup>3</sup> ) | Same as Primary<br>Standard          | Gas Phase<br>Chemiluminescence  |
|   | Annual<br>Arithmetic Mean  | 0.030 ppm<br>(57 µg/m <sup>3</sup> )  |   | 0.053 ppm<br>(100 µg/m <sup>3</sup> )            |                                      |   |
| Sulfur Dioxide<br>(SO <sub>2</sub> )                    | 1 Hour                     | 0.25 ppm<br>(655 µg/m <sup>3</sup> )  | Ultraviolet<br>Fluorescence                     | 75 ppb <sup>c</sup><br>(196 µg/m <sup>3</sup> )  | —                                    | Ultraviolet Fluorescence<br>Spectrophotometry<br>(Parasaniiline Method) |
|   | 3 Hour                     | —   |   | —  | 0.5 ppm<br>(1300 µg/m <sup>3</sup> ) |   |
|   | 24 Hour                    | 0.04 ppm<br>(105 µg/m <sup>3</sup> )  |   | —  | —                                    |   |
| Lead  | 30 Day Average             | 1.5 µg/m <sup>3</sup>   | Atomic Absorption                               | —  | —                                    | —   |
|   | Calendar Quarter           | —   |   | 1.5 µg/m <sup>3</sup>                            | —                                    | —   |
|   | Rolling 3-Month<br>Average | —   |   | 0.15 µg/m <sup>3</sup>                           | Same as Primary<br>Standard          | High Volume Sampler and<br>Atomic Absorption                            |
| Visibility<br>Reducing<br>Particles                     | 8 Hour                     | Extinction Coefficient of 0.23 per<br>kilometer—visibility of 10 miles or<br>more due to particles when relative<br>humidity is less than 70 percent.<br>Method: Beta Attenuation and<br>Transmittance through Filter Tape. |   | No Federal Standards                             |                                      |   |
| Sulfates  | 24 Hour                    | 25 µg/m <sup>3</sup>  | Ion<br>Chromatography                           | No Federal Standards                             |                                      |   |
| Hydrogen<br>Sulfide                                     | 1 Hour                     | 0.03 ppm<br>(42 µg/m <sup>3</sup> )   | Ultraviolet<br>Fluorescence                     | No Federal Standards                             |                                      |   |
| Vinyl Chloride  | 24 Hour                    | 0.01 ppm<br>(26 µg/m <sup>3</sup> )   | Gas<br>Chromatography                           | No Federal Standards                             |                                      |   |

<sup>a</sup>To attain this standard, the 3-year average of the 98<sup>th</sup> percentile of the daily concentrations must not exceed 35 µg/m<sup>3</sup>.

<sup>b</sup>To attain this standard, the 3-year average of the 98<sup>th</sup> percentile of the daily maximum 1-hour average must not exceed 100 ppb.

<sup>c</sup>To attain this standard, the 3-year average of the 99<sup>th</sup> percentiles of the daily maximum 1-hour average must not exceed 75 ppb.

Source: California Air Resources Board (6/7/12)

The federal 8-hour O<sub>3</sub>e NAAQS requires that the 3-year average of the fourth-highest values for individual years be maintained at or below 0.075 ppm. Therefore, the number of days in each year with maximum 8-hour concentrations above the standard in Table 3.1-3 does not equate to the number of violations. There have been no violations of state or federal ozone standards at this station since 2008.

O<sub>3</sub> data completeness at the LAX station averaged 94 percent over the period of 2004 to 2011.

TABLE 3.1-3  
Ozone Levels at LAX Station, Los Angeles Westchester Parkway (ppm)

| Los Angeles Westchester Parkway Station, Los Angeles County                   | 2002 | 2003 | 2004  | 2005  | 2006  | 2007  | 2008  | 2009  | 2010  | 2011  |
|---|------|------|-------|-------|-------|-------|-------|-------|-------|-------|
| Maximum 1-hour Average  | —    | —    | 0.120 | 0.086 | 0.084 | 0.087 | 0.086 | 0.077 | 0.089 | 0.078 |
| Number of Days Exceeding California 1-hour Standard (0.09 ppm)                | —    | —    | 4     | 0     | 0     | 0     | 0     | 0     | 0     | 0     |
| Number of Days Exceeding Old National 1-hour Standard (0.12 ppm) <sup>1</sup> | —    | —    | 0     | 0     | 0     | 0     | 0     | 0     | 0     | 0     |
| Maximum 8-hour Average  | —    | —    | 0.100 | 0.076 | 0.067 | 0.076 | 0.076 | 0.070 | 0.070 | 0.067 |
| Number of Days Exceeding California 8-hour Standard (0.07 ppm)                | —    | —    | 17    | 2     | 0     | 1     | 1     | 0     | 0     | 0     |
| Number of Days Exceeding National 8-hour Standard (0.075 ppm) <sup>2</sup>    | —    | —    | 11    | 1     | 0     | 0     | 0     | 0     | 0     | 0     |

Note: The Los Angeles Westchester Parkway Monitoring Station started operation in 2004. Measurements are not available for 2002 and 2003.

<sup>a</sup>EPA revoked the 1-hour ozone standard in all areas on June 15, 2005.

<sup>b</sup>To attain this standard, the 3-year average of the fourth-highest maximum 8-hour average ozone concentrations measured at each monitor within an area over each year must not exceed 0.075 ppm. (Effective May 27, 2008).

Source: CARB ADAM Website ([www.arb.ca.gov/adam/welcome.html](http://www.arb.ca.gov/adam/welcome.html)).

**Nitrogen Dioxide (NO<sub>2</sub>).** NO<sub>2</sub> is formed primarily from reactions in the atmosphere between NO (nitric oxide) and oxygen (O<sub>2</sub>) or ozone. NO is formed during high-temperature combustion processes, when the nitrogen and oxygen in the combustion air combine. Although NO is much less harmful than NO<sub>2</sub>, it can be converted to NO<sub>2</sub> in the atmosphere within a matter of hours, or even minutes, under certain conditions. The control of NO and NO<sub>2</sub> emissions is also important because of the role of both compounds in the atmospheric formation of O<sub>3</sub>.

Table 3.1-4 shows NO<sub>2</sub> levels recorded at the LAX station for the years 2002 through 2011.

The South Coast air basin is classified as a nonattainment area with respect to state ambient NO<sub>2</sub> standards but is in attainment with regard to the national ambient standards. During the period from 2004 to 2011, there were no violations of the CAAQS 1-hour standard (0.18 ppm) at the monitoring station in Los Angeles County. The highest 1-hour concentration recorded at the LAX station during the years 2004 to 2011 was 0.099 ppm in 2006. A new federal 1-hour NO<sub>2</sub> standard of 0.100 ppm became effective on April 12, 2010. To attain this standard, the 3-year average of the 98th percentile of the daily maximum 1-hour average at each monitor within South Coast air basin must not exceed 0.100 ppm. Table 3.1-4 also shows that there were no violations of the annual NAAQS (0.053 ppm) or annual CAAQS (0.030 ppm) at the LAX station during this period.

Data completeness for NO<sub>2</sub> concentrations at the LAX station averaged 87 percent for the 2004 through 2011 period.

TABLE 3.1-4  
**Nitrogen Dioxide Levels at LAX Station, Los Angeles Westchester Parkway (ppm)**

| Los Angeles Westchester Parkway Station, Los Angeles County | 2002 | 2003 | 2004         | 2005  | 2006  | 2007  | 2008  | 2009         | 2010  | 2011  |
|---|------|------|--------------|-------|-------|-------|-------|--------------|-------|-------|
| Maximum 1-hour Average                                      | —    | —    | 0.091        | 0.091 | 0.099 | 0.084 | 0.094 | 0.077        | 0.076 | 0.098 |
| Annual Average  | —    | —    | <sup>a</sup> | 0.013 | 0.015 | 0.014 | 0.014 | <sup>a</sup> | 0.012 | 0.013 |
| Days Over State Standard (0.18 ppm, 1-hour)                 | —    | —    | 0            | 0     | 0     | 0     | 0     | 0            | 0     | 0     |
| Days Over Federal Standard (0.100 ppm, 1 hour) <sup>b</sup> | —    | —    | N/A          | N/A   | N/A   | N/A   | N/A   | N/A          | N/A   | 0     |

Note: The Los Angeles Westchester Parkway Monitoring Station started operation in 2004. Measurements are not available for 2002 and 2003.

<sup>a</sup>There were insufficient (or no) data available to determine the value.

<sup>b</sup>The new federal 1-hour average NO<sub>2</sub> standard of 0.100 ppm was announced by EPA on February 9, 2010 and became effective April 12, 2010. To attain this standard, the 3-year average of the 98<sup>th</sup> percentile of the daily maximum 1-hour average values at each monitor must not exceed 100 ppb.

N/A = not applicable

Source: CARB ADAM Website ([www.arb.ca.gov/adam/welcome.html](http://www.arb.ca.gov/adam/welcome.html)).

**Carbon Monoxide (CO).** Carbon monoxide is a product of incomplete combustion and is emitted principally from automobiles and other mobile sources of pollution. It is also a product of combustion from stationary sources (both industrial and residential) burning fuels. Peak CO levels occur typically during winter months due to a combination of higher emission rates and stagnant weather conditions.

Table 3.1-5 shows the available data on maximum 1-hour and 8-hour average CO levels recorded at the LAX station during the period from 2002 to 2011. As indicated by this table, the maximum measured 1-hour average CO levels comply with the NAAQS and CAAQS (35.0 ppm and 20.0 ppm, respectively) and the maximum 8-hour values comply with the NAAQS and CAAQS of 9.0 ppm. The highest individual 1-hour and 8-hour CO concentrations at this station during the period from 2004 to 2011 were 3.7 ppm and 3.03 ppm, respectively, both recorded in 2004. For purposes of both state and federal air quality planning, the South Coast air basin is in attainment with regard to CO.

Data completeness for CO concentrations at the LAX station averaged 91 percent over this period.

TABLE 3.1-5  
**Carbon Monoxide Levels at LAX Station, Los Angeles Westchester Parkway (ppm)**

| Los Angeles Westchester Parkway Station, Los Angeles County | 2002 | 2003 | 2004 | 2005 | 2006 | 2007 | 2008 | 2009 | 2010 | 2011 |
|---|------|------|------|------|------|------|------|------|------|------|
| Maximum 1-hour Average                                      | —    | —    | 3.7  | 2.8  | 2.8  | 3.3  | *    | 2.6  | 2.6  | 2.3  |
| Maximum 8-hour Average                                      | —    | —    | 3.03 | 2.14 | 2.27 | 2.39 | 2.53 | 1.99 | 2.19 | 1.79 |
| Days Over the 8-hour California Standard (9 ppm)            | —    | —    | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0    |
| Days Over the 8-hour Federal Standard (9 ppm)               | —    | —    | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0    |

\*There were insufficient (or no) data available to determine the value.

Sources: CARB ADAM Website ([www.arb.ca.gov/adam/welcome.html](http://www.arb.ca.gov/adam/welcome.html)); EPA AIRS Website ([www.epa.gov/air/data/index.html](http://www.epa.gov/air/data/index.html))



**Sulfur Dioxide (SO<sub>2</sub>).** SO<sub>2</sub> is produced by the combustion of any sulfur-containing fuel. It is also emitted by chemical plants that treat or refine sulfur or sulfur-containing chemicals. Natural gas contains nearly negligible sulfur, whereas fuel oils may contain much larger amounts. Because of the complexity of the chemical reactions that convert SO<sub>2</sub> to other compounds (such as sulfates), peak concentrations of SO<sub>2</sub> occur at different times of the year in different parts of California, depending on local fuel characteristics, weather, and topography. The South Coast air basin is considered to be in attainment for SO<sub>2</sub> for purposes of state and federal air quality planning.

Table 3.1-6 shows the available data on maximum 1-hour, 24-hour, and annual average SO<sub>2</sub> levels recorded at the LAX station during the period from 2002 to 2011. As indicated by this table, the maximum measured 1-hour average SO<sub>2</sub> levels comply with the new NAAQS (75 ppb) and CAAQS (0.25 ppm), and the maximum 24-hour values comply with the NAAQS and CAAQS of 0.14 ppm and 0.04 ppm, respectively. The table also demonstrates compliance with the annual SO<sub>2</sub> NAAQS of 0.03 ppm. Note that the 24-hour and annual NAAQS for SO<sub>2</sub> have been superseded by the new 1-hour NAAQS, which became effective on August 23, 2010. SO<sub>2</sub> data completeness at the LAX station averaged 88 percent over the period of 2004 to 2011.

TABLE 3.1-6

**Sulfur Dioxide Levels at LAX Station, Los Angeles Westchester Parkway (ppm)**

| Los Angeles Westchester Parkway Station, Los Angeles County | 2002 | 2003 | 2004         | 2005  | 2006  | 2007  | 2008  | 2009         | 2010  | 2011  |
|---|------|------|--------------|-------|-------|-------|-------|--------------|-------|-------|
| Highest 1-hour average                                      | —    | —    | 0.024        | 0.040 | 0.021 | 0.019 | 0.021 | 0.022        | 0.026 | 0.012 |
| Highest 24-hour average                                     | —    | —    | 0.007        | 0.012 | 0.010 | 0.009 | 0.005 | 0.006        | 0.004 | 0.002 |
| Annual Average  | —    | —    | <sup>a</sup> | 0.005 | 0.002 | 0.002 | 0.001 | <sup>a</sup> | 0     | 0     |
| Days Over 1-hour State Standard (0.25 ppm)                  | —    | —    | 0            | 0     | 0     | 0     | 0     | 0            | 0     | 0     |
| Days Over 1-hour Federal Standard (75 ppb) <sup>b</sup>     | —    | —    | 0            | 0     | 0     | 0     | 0     | 0            | 0     | 0     |
| Days Over 24-hour State Standard (0.04 ppm)                 | —    | —    | 0            | 0     | 0     | 0     | 0     | 0            | 0     | 0     |

Note: The Los Angeles Westchester Parkway Monitoring Station started operation in 2004. Measurements are not available for 2002 and 2003.

<sup>a</sup>There were insufficient (or no) data available to determine the value.

<sup>b</sup>Final rule signed June 22, 2010, effective August 23, 2010. To attain this standard, the 3-year average of the 99th percentile of the daily maximum 1-hour average at each monitor within an area must not exceed 75 ppb.

Sources: CARB ADAM Website ([www.arb.ca.gov/adam/welcome.html](http://www.arb.ca.gov/adam/welcome.html)); EPA AIRS Website ([www.epa.gov/air/data/index.html](http://www.epa.gov/air/data/index.html))

**Respirable Particulate Matter (PM<sub>10</sub>).** Particulates in the air are caused by a combination of wind-blown fugitive dust; particles emitted from combustion sources and manufacturing processes; and organic, sulfate, and nitrate aerosols formed in the air from emitted hydrocarbons, sulfur oxides, and nitrogen oxides. Particulates with a diameter less than or equal to 10 microns are referred to as PM<sub>10</sub>, and are regulated because they can be inhaled, leading to health effects. Fine particulates, referred to as PM<sub>2.5</sub> and having a diameter equal to or less than 2.5 microns, are a subset of PM<sub>10</sub> that are also regulated. PM<sub>2.5</sub> standards are discussed later in this section.

Table 3.1-7 shows the maximum PM<sub>10</sub> levels recorded at the LAX monitoring station during the period from 2002 through 2011 and the arithmetic annual average concentrations for the same period. (The arithmetic annual average is simply the arithmetic mean of the daily observations.) PM<sub>10</sub> is monitored according to different protocols for evaluating compliance with the state and federal standards for this pollutant. Specifically, California uses a gravimetric or beta attenuation method, whereas compliance with federal standards is evaluated based on an inertial separation and gravimetric analysis. This accounts for the slightly differing 24-hour concentrations listed in Table 3.1-7 that represent data obtained by means of the state and federal samplers.

At the LAX station, the maximum 24-hour PM<sub>10</sub> levels exceed the CAAQS state standard of 50 micrograms per cubic meter ( $\mu\text{g}/\text{m}^3$ ) a few times per year. The maximum daily concentration recorded during the analysis period was  $128 \mu\text{g}/\text{m}^3$  (both state and federal samplers) in 2007. The maximum annual arithmetic mean concentration recorded at LAX was  $29.3 \mu\text{g}/\text{m}^3$ , also in 2007, which is above the state standard of  $20 \mu\text{g}/\text{m}^3$ . The federal annual PM<sub>10</sub> standard was revoked by the EPA in 2006. South Coast Air Basin attainment status for both the state and federal PM<sub>10</sub> standards are “nonattainment.”

PM<sub>10</sub> concentration data completeness at the LAX station averaged 87 percent for the period of 2004 to 2011.

TABLE 3.1-7

**Particulate Matter (PM<sub>10</sub>) Levels at LAX Station, Los Angeles Westchester Parkway ( $\mu\text{g}/\text{m}^3$ )**

| Los Angeles Westchester Parkway Station, Los Angeles County                          | 2002 | 2003 | 2004 | 2005 | 2006 | 2007  | 2008 | 2009 | 2010 | 2011 |
|--|------|------|------|------|------|-------|------|------|------|------|
| Maximum 24-hour Average (federal testing samplers)                                   | —    | —    | 47.0 | 44.0 | 45.0 | 128.0 | 50.0 | 52.0 | 37.0 | 41.0 |
| Maximum 24-hour Average (state testing samplers)                                     | —    | —    | 46.0 | 44.0 | 45.0 | 128.0 | 50.0 | 52.0 | 37.0 | 41.0 |
| Annual Arithmetic Mean <sup>a</sup>  | —    | —    | 21.5 | 22.9 | 23.5 | 29.3  | 25.6 | 25.6 | 20.6 | 21.7 |
| Estimated Number of Days Exceeding Federal Standard ( $150 \mu\text{g}/\text{m}^3$ ) | —    | —    | b    | b    | b    | b     | 0    | 0    | 0    | 0    |
| Estimated Number of Days Exceeding State Standard ( $50 \mu\text{g}/\text{m}^3$ )    | —    | —    | b    | b    | 0    | b     | 0    | 6.5  | b    | 0    |

Note: The Los Angeles Westchester Parkway Monitoring Station started operation in 2004. Measurements are not available for 2002 and 2003.

<sup>a</sup>On December 17, 2006, the annual PM<sub>10</sub> federal standard ( $50 \mu\text{g}/\text{m}^3$ ) was revoked.

<sup>b</sup>There were insufficient (or no) data available to determine the value.

Source: CARB ADAM Website ([www.arb.ca.gov/adam/welcome.html](http://www.arb.ca.gov/adam/welcome.html)).

**Fine Particulates (PM<sub>2.5</sub>).** Fine particulates result from fuel combustion in motor vehicles and industrial processes, residential and agricultural burning, and atmospheric reactions involving NO<sub>x</sub>, SO<sub>x</sub>, and organics. Fine particulates are referred to as PM<sub>2.5</sub> and have a diameter equal to or less than 2.5 microns. In 1997, EPA established annual and 24-hour NAAQS for PM<sub>2.5</sub> for the first time. The most recent revision to the standard regulating the 3-year average of the 98th percentile of 24-hour PM<sub>2.5</sub> concentrations ( $35 \mu\text{g}/\text{m}^3$ ) became effective on December 17, 2006.

The PM<sub>2.5</sub> data in Table 3.1-8 show that the national 24-hour average NAAQS of  $35 \mu\text{g}/\text{m}^3$  was exceeded 20 to 35 times per year during the 2002 and 2003 calendar years. The number and severity of exceedances of the NAAQS were reduced greatly from 2008 to 2011; in 2011, there were only two exceedances of the NAAQS. The maximum recorded 24-hour average value was  $48 \mu\text{g}/\text{m}^3$  in 2003. The annual PM<sub>2.5</sub> data are also presented in this table. The maximum annual arithmetic mean was  $19.5 \mu\text{g}/\text{m}^3$ , recorded in 2002, which is above both the national standard of  $12.0 \mu\text{g}/\text{m}^3$  and the California standard of  $12 \mu\text{g}/\text{m}^3$ . Annual average PM<sub>2.5</sub> concentrations have been below both state and federal standards since 2009. South Coast Air Basin attainment status for the state and federal PM<sub>2.5</sub> standards is “nonattainment.”

TABLE 3.1-8  
**Particulate Matter (PM<sub>2.5</sub>) Levels at North Long Beach (µg/m<sup>3</sup>)**

| North Long Beach Station,<br>Los Angeles County                             | 2002 | 2003 | 2004         | 2005         | 2006         | 2007 | 2008 | 2009 | 2010 | 2011 |
|---|------|------|--------------|--------------|--------------|------|------|------|------|------|
| 24-hour Average (federal only) <sup>a1</sup>                                | 54   | 48   | 46           | 45           | 41           | 39   | 38   | 38   | 33   | 30   |
| Annual Arithmetic Mean  | 19.5 | 18   | 17.9         | 15.9         | 14.1         | 14.6 | 14.1 | 12.8 | 10.4 | 11.3 |
| Estimated Number of Days Exceeding Federal Standard (35 µg/m <sup>3</sup> ) | 34.2 | 24.8 | <sup>b</sup> | <sup>b</sup> | <sup>b</sup> | 13.7 | 8.2  | 6    | 0    | 2    |

<sup>a</sup>EPA lowered the 24-hour standard from 65 µg/m<sup>3</sup> to 35 µg/m<sup>3</sup> on December 17, 2006. Compliance with this standard is based on the 3-year average of the 98<sup>th</sup> percentile daily concentrations.

<sup>b</sup>There were insufficient (or no) data available to determine the value.

Source: CARB ADAM Website ([www.arb.ca.gov/adam/welcome.html](http://www.arb.ca.gov/adam/welcome.html)).

**Airborne Lead (Pb).** Lead pollution has historically been emitted predominantly from the combustion of fuels. However, legislation in the early 1970s required a gradual reduction of the lead content of gasoline. Beginning with the introduction of unleaded gasoline in 1975, lead levels have been dramatically reduced throughout the U.S., and violations of the ambient standards for this pollutant have been virtually eliminated.

On October 15, 2008, EPA revised the federal ambient air quality standard for lead, lowering it from 1.5 µg/m<sup>3</sup> to 0.15 µg/m<sup>3</sup> for both the primary and the secondary standard. EPA determined that numerous health studies are now available that demonstrate health effects at much lower levels of lead than previously thought. EPA subsequently published the final rule in the Federal Register on November 12, 2008. This is the first time that the federal lead standard has been revised since it was first issued in 1978.

In addition to revising the level of the standard, EPA changed the averaging time from a quarterly average to a rolling three-month average. The level of the standard is “not to be exceeded” and is evaluated over a three-year period. Lead levels are measured as lead in total suspended particulate (TSP). The revised lead standard also includes new monitoring requirements.

As lead concentrations dropped dramatically and all areas of California attained the previous standard, most lead monitors were shut down by the early 1990s and resources deployed to other pollutants. As a result, insufficient monitoring data exist to determine designations, and most areas of the state are unclassifiable for the revised standard. Los Angeles County is the only county in the state that is nonattainment for lead ambient air quality standards, and it is nonattainment for both. The designation is not due to SCAQMD’s regional network lead monitors, but instead was based on source-oriented monitors near specific facilities.<sup>1</sup> SCAQMD has been collecting lead data at Los Angeles North Main Street Station since 1989.

The annual lead data are presented in Table 3.1-9. The annual mean was 0.022 µg/m<sup>3</sup> (22.2 ng/m<sup>3</sup>), recorded in 2002. The maximum recorded lead value was 0.22 µg/m<sup>3</sup> (220 ng/m<sup>3</sup>) in 2010, which is above both the national standard of 0.15 µg/m<sup>3</sup>. The attainment status for the federal lead standards is “nonattainment” for the Los Angeles County portion of the South Coast Air Basin.

<sup>1</sup> SCAQMD, *Revised Draft 2012 Lead State Implementation Plan Los Angeles County* (May 4, 2012), p. ES-3.

TABLE 3.1-9  
Lead Levels at Los Angeles North Main Street Station (ng/m<sup>3</sup>)

| North Main Street Station,<br>Los Angeles County | 2002 | 2003 | 2004 | 2005 | 2006 | 2007 | 2008 | 2009 | 2010 | 2011 |
|--|------|------|------|------|------|------|------|------|------|------|
| Annual Mean <sup>a</sup>                         | 22.2 | b    | b    | b    | b    | b    | b    | 12.2 | b    | b    |
| Annual Maximum                                   | 48   | 34   | b    | b    | b    | 43   | b    | 32   | 220  | 15   |
| Number of Observations                           | 29   | 5    | 0    | 0    | 0    | 18   | 0    | 30   | 12   | 12   |

<sup>a</sup>Means of monthly means. Means of monthly means are calculated by first determining the average of all measurements taken within a month at each site. Site means are then calculated by finding the average of the 12 monthly means for each site.

<sup>b</sup>There were insufficient (or no) data available to determine the value.

Source: CARB ADAM Website ([www.arb.ca.gov/adam/welcome.html](http://www.arb.ca.gov/adam/welcome.html)).

**Particulate Sulfates.** Sulfate compounds found in the lower atmosphere consist of both primary and secondary particles. Primary sulfate particles are directly emitted from open pit mines, dry lakebeds, and desert soils. Fuel combustion is another source of sulfates, both primary and secondary. Secondary sulfate particles are produced when oxides of sulfur (SO<sub>x</sub>) emissions are transformed into particles through physical and chemical processes in the atmosphere. Particles can be transported long distances. The South Coast Air Basin is in attainment with respect to the state ambient standard for sulfates; there is no federal standard.

**Other State-designated Criteria Pollutants.** Along with sulfates, California has designated hydrogen sulfide and visibility-reducing particles as criteria pollutants, in addition to the federal criteria pollutants. The South Coast Air Basin remains unclassified for both pollutants.

### 3.1.3 LORS Compliance

A summary of the applicable air quality LORS for the amended project is provided below. The analysis presented in Section 3.1.6 demonstrates that the amended project would comply with the LORS.

#### 3.1.3.1 Federal LORS

The EPA implements and enforces the requirements of many of the federal environmental laws. The federal Clean Air Act, as most recently amended in 1990, provides EPA with the legal authority to regulate air pollution from stationary sources such as the project. EPA has promulgated the following stationary source regulatory programs to implement the requirements of the 1990 Clean Air Act:

- Prevention of Significant Deterioration (PSD);
- Nonattainment New Source Review (NANSR);
- Standards of Performance for New Stationary Sources (NSPS);
- National Emission Standards for Hazardous Air Pollutants (NESHAPS);
- Title IV: Acid Deposition Control; and
- Title V: Operating Permits.

##### 3.1.3.1.1 Prevention of Significant Deterioration Program

**Authority:** Clean Air Act §160-169A, 42 USC §7470-7491; 40 CFR Parts 51 and 52

**Requirements:** Requires pre-construction review and permitting of new or modified major stationary sources of air pollution to prevent significant deterioration of ambient air quality. PSD applies to pollutants for which ambient concentrations do not exceed the corresponding NAAQS (i.e., attainment pollutants). The PSD program allows new sources of air pollution to be constructed, or existing sources to be modified, while preserving the existing ambient air quality levels, protecting public health and welfare, and protecting Class I areas (e.g., national parks and wilderness areas).

The PSD requirements apply to any project that is a new major stationary source or a major modification to an existing major stationary source. A major source is a listed facility (one of 28 PSD source categories listed in the federal Clean Air Act) that emits at least 100 TPY, or any other facility that emits at least 250 TPY.

Effective July 1, 2011, a stationary source that emits more than 100,000 TPY of GHGs is also considered to be a major stationary source.

A major modification is any project at a major stationary source that results in a significant increase in emissions of any PSD pollutant. A PSD pollutant is a criteria pollutant for which the area is not nonattainment for the federal ambient air quality standard (for SCAQMD, the PSD pollutants are SO<sub>2</sub>, NO<sub>x</sub>, CO, lead, and GHGs).

A significant increase for a PSD pollutant is an increase above the significant emission rate for that pollutant (Table 3.1-10). It is important to note that, once PSD is triggered by any pollutant, PSD requirements apply to any PSD pollutant with an emission increase above the significance level, regardless of whether the facility is major for that pollutant. For ESGS, the facility is major because of GHG emissions. PSD review applies to the project's significant increases of NO<sub>x</sub> and PM<sub>10</sub>, in addition to GHGs, even though the facility is not major for any of those pollutants.

EPA has delegated authority to the SCAQMD to implement the PSD program within the District's geographical boundaries. An application for a PSD permit was filed with the District on March 14, 2013.

TABLE 3.1-10  
PSD Significant Emission Thresholds

| Pollutant         | PSD Significant Emission Threshold (TPY)* |
|-------------------|---|
| SO <sub>2</sub>   | 40  |
| PM <sub>10</sub>  | 15  |
| PM <sub>2.5</sub> | 10  |
| NO <sub>x</sub>   | 40  |
| CO                | 100                                       |
| Lead              | 0.6                                       |
| GHGs              | 75,000                                    |

\*40 CFR 52.21 (b)(1)(23).

The principal requirements for the PSD program include the following:

- Emissions of pollutants that are subject to PSD review must be controlled using BACT.
- Air quality impacts, in combination with other increment-consuming sources, must not exceed maximum allowable incremental increases.
- Air quality impacts of all sources in the area plus ambient pollutant background levels cannot exceed NAAQS.
- Pre- and/or post-construction air quality monitoring may be required.
- The air quality impacts on soils, vegetation, and nearby PSD Class I areas (specific national parks and wilderness areas) must be evaluated. (Note: The ESGS is located in a Class II area.)

### ***Air Quality Monitoring***

At its discretion, the PSD permit issuer may require pre-construction and/or post-construction ambient air quality monitoring for PSD sources if representative monitoring data are not already available. Pre-construction monitoring data must be gathered over a one-year period to characterize local ambient air quality. Post-construction air quality monitoring data must be collected as deemed necessary by the PSD permit issuer to characterize the impacts of proposed project emissions on ambient air quality.

### **Best Available Control Technology**

BACT must be applied to any new or modified major source to minimize the emissions increase of those pollutants exceeding the PSD emission thresholds. EPA defines BACT as an emissions limitation based on the maximum degree of reduction for each subject pollutant, considering energy, environmental, and economic impacts, that is achievable through the application of available methods, systems, and techniques. BACT must be as stringent as any emission limit required by an applicable NSPS or NESHAP.

### **Air Quality Impact Analysis**

An air quality dispersion analysis must be conducted to evaluate impacts of significant emission increases from new or modified facilities on ambient air quality. PSD source emissions must not cause or contribute to an exceedance of any ambient air quality standard, and the increase in ambient air concentrations must not exceed the allowable increments shown in Table 3.1-11. Once PSD is triggered for the project, all pollutants with emission increases above the PSD significance thresholds are subject to this requirement.

TABLE 3.1-11  
PSD Increments and Significant Impact Levels

| Pollutant         | Averaging Time | SILs ( $\mu\text{g}/\text{m}^3$ ) <sup>a</sup> | Maximum Allowable Class II Increments <sup>b</sup> |
|-------------------|----------------|--|--|
| SO <sub>2</sub>   | Annual         | 1.0  | 20   |
|                   | 24-hr          | 5  | 91   |
|                   | 3-hr           | 25   | 512  |
|                   | 1-hr           | 7.8 <sup>c</sup>                               | No 1-hr increment                                  |
| PM <sub>10</sub>  | Annual         | 1.0  | 17   |
|                   | 24-hr          | 5  | 30   |
| PM <sub>2.5</sub> | Annual         | 0.3  | 4  |
|                   | 24-hr          | 1.2  | 9  |
| NO <sub>2</sub>   | Annual         | 1.0  | 25   |
|                   | 1-hr           | 7.5 <sup>c</sup>                               | No 1-hr increment                                  |
| CO                | 8-hr           | 500  | No CO increments                                   |
|                   | 1-hr           | 2,000  |  |

<sup>a</sup>40 CFR 51.165 (b)(2).

<sup>b</sup>40 CFR 52.21 (c)

<sup>c</sup>EPA has not yet defined significance impact levels (SILs) for one-hour NO<sub>2</sub> or SO<sub>2</sub> impacts. However, EPA has suggested that, until SILs have been promulgated, values of 4 ppb (7.5  $\mu\text{g}/\text{m}^3$ ) for NO<sub>2</sub> and 3 ppb (7.8  $\mu\text{g}/\text{m}^3$ ) for SO<sub>2</sub> may be used. These values will be used in this analysis wherever a SIL would be used for NO<sub>2</sub> or SO<sub>2</sub>.

### **Protection of Class I Areas**

The potential increase in ambient air quality concentrations for attainment pollutants (i.e., NO<sub>2</sub>, PM<sub>10</sub>, or SO<sub>2</sub>) within Class I areas closer than approximately 100 km may need to be quantified if the new or modified PSD source were to have a sufficiently large emission increase as evaluated by the Class I area Federal Land Managers. In such a case, a Class I visibility impact analysis would also be performed.

### **Growth, Visibility, Soils, and Vegetation Impacts**

Impairment to visibility, soils, and vegetation resulting from PSD source emissions as well as associated commercial, residential, industrial, and other growth must be analyzed. This analysis includes cumulative impacts to local ambient air quality.

**Administering Agency:** SCAQMD, with EPA Region 9 oversight.

### 3.1.3.1.2 Nonattainment New Source Review

**Authority:** Clean Air Act §171-193, 42 USC §7501 et seq.; 40 CFR Parts 51 and 52

**Requirement:** Requires pre-construction review and permitting of new or modified major stationary sources of air pollution to allow industrial growth without interfering with the attainment and maintenance of ambient quality standards. In general, this program is implemented at the local level with EPA oversight.

- Emissions must be controlled to the lowest achievable emission rate (LAER).
- Sufficient offsetting emissions reductions must be obtained following the requirements in the regulations to continue reasonable further progress toward attainment of applicable NAAQS.
- The owner or operator of the new facility has demonstrated that major stationary sources owned or operated by the same entity in California are in compliance or on schedule for compliance with applicable emissions limitations in this rule.
- The administrator must find that the implementation plan has been adequately implemented.
- An analysis of alternatives must show that the benefits of the proposed source significantly outweigh any environmental and social costs.

Nonattainment new source review jurisdiction has been delegated to the SCAQMD for all pollutants and is discussed further under local LORS section below.

**Administering Agency:** SCAQMD, with EPA Region 9 oversight.

### 3.1.3.1.3 National Standards of Performance for New Stationary Sources

**Authority:** Clean Air Act §111, 42 USC §7411; 40 CFR Part 60

**Requirements:** Establishes national standards of performance to limit the emissions of criteria pollutants (air pollutants for which EPA has established NAAQS) from new or reconstructed facilities in specific source categories. Applicability of these regulations depends on equipment size, process rate, and date of construction. The project is subject to the following NSPS:

Subpart KKKK, Standards of Performance for Stationary Gas Turbines (constructed after February 18, 2005) is applicable to the gas turbines. Subpart KKKK limits NO<sub>x</sub> and SO<sub>2</sub> emissions from new gas turbines based on power output. The limits for gas turbines greater than 30 MW which are applicable to the proposed project's gas turbines are 0.39 lb NO<sub>x</sub> per MW-hr and 0.58 lb SO<sub>2</sub> per MW-hr. These standards are enforced at the local level with federal and state oversight.

**Administering Agency:** SCAQMD, with EPA Region 9 and CARB oversight.

### 3.1.3.1.4 National Emission Standards for Hazardous Air Pollutants

**Authority:** Clean Air Act §112, 42 USC §7412

**Requirements:** Establishes national emission standards to limit emissions of hazardous air pollutants (HAPs, or air pollutants identified by EPA as causing or contributing to the adverse health effects of air pollution but for which NAAQS have not been established) from facilities in specific source categories. These standards are implemented at the local level with federal oversight. Only the NESHAP for combustion turbines, which limits formaldehyde emissions from turbines, is potentially applicable to the proposed project.

**Administering Agency:** SCAQMD, with EPA Region 9 oversight.

### 3.1.3.1.5 Acid Rain Program

**Authority:** Clean Air Act §401 (Title IV), 42 USC §7651

**Requirement:** Requires the monitoring and reporting of emissions of acidic compounds and their precursors from combustion equipment owned by a utility. The principal source of these compounds is the combustion of fossil fuels. Therefore, Title IV established national standards to monitor, record, and, in some cases, limit SO<sub>2</sub> and NO<sub>x</sub>

emissions from electrical power generating facilities. These standards are implemented at the local level with federal oversight. SCAQMD has received delegation authority to implement Title IV.

**Administering Agency:** SCAQMD, with EPA Region 9 oversight.

### 3.1.3.1.6 Title V Operating Permits Program

**Authority:** Clean Air Act §501 (Title V), 42 USC §7661

**Requirements:** Requires the issuance of operating permits that identify all applicable federal performance, operating, monitoring, recordkeeping, and reporting requirements. Title V applies to major facilities, Phase II acid rain facilities, subject solid waste incinerator facilities, and any facility listed by EPA as requiring a Title V permit. SCAQMD has received delegation authority for this program.

**Administering Agency:** SCAQMD, with EPA Region IX oversight.

### 3.1.3.1.7 Compliance Assurance Monitoring (CAM)

**Authority:** 40 CFR 64 Compliance Assurance Monitoring (CAM)

**Requirements:** Requires compliance monitoring at emission units at major stationary sources that are required to obtain a Title V permit, and that use control equipment to achieve a specified emission limit. The rule is intended to provide "reasonable assurance" that the control systems are operating properly to maintain compliance with the emission limits. CAM is usually implemented through the Title V permit. None of the sources proposed for this project are affected by CAM.

**Administering Agency:** SCAQMD, with EPA Region IX oversight.

## 3.1.3.2 State LORS

The California Air Resources Board (CARB) was created in 1968 by the Mulford-Carrell Air Resources Act, through the merger of two other state agencies. CARB's primary responsibilities are to develop, adopt, implement, and enforce the state's motor vehicle pollution control program; to administer and coordinate the state's air pollution research program; to adopt and update, as necessary, the state's ambient air quality standards; to review the operations of the local air pollution control districts; and to review and coordinate preparation of the SIP for achievement of the federal ambient air quality standards. CARB has implemented the following state or federal stationary source regulatory programs in accordance with the requirements of the federal Clean Air Act and California Health & Safety Code (H&SC):

- State Implementation Plan (SIP);
- California Clean Air Act;
- Nuisance Regulation;
- Toxic Air Contaminant Program;
- Air Toxics "Hot Spots" Act;
- CEC and CARB Memorandum of Understanding; and
- California Climate Change Regulatory Program.

### 3.1.3.2.1 State Implementation Plan

**Authority:** Health & Safety Code (H&SC) §39500 et seq.

**Requirements:** Required by the federal Clean Air Act, the SIP must demonstrate the means by which all areas of the state will attain and maintain NAAQS within the federally mandated deadlines. CARB reviews and coordinates preparation of the SIP. Local districts must adopt new rules (and/or revise existing rules) and demonstrate that the resulting emission reductions, in conjunction with reductions in mobile source emissions, will result in the attainment of NAAQS. The relevant SCAQMD Rules and Regulations that have also been incorporated into the SIP are discussed with the local LORS.

**Administering Agency:** SCAQMD, with CARB and EPA Region 9 oversight.



### 3.1.3.2.2 California Clean Air Act

**Authority:** H&SC §40910 – 40930

**Requirements:** Established in 1989, the California Clean Air Act requires local districts to attain and maintain both national and state ambient air quality standards at the “earliest practicable date.” Local districts must prepare air quality plans demonstrating the means by which the ambient air quality standards will be attained and maintained. The SCAQMD Air Quality Plan is discussed with the local LORS.

**Administering Agency:** SCAQMD, with CARB oversight.

### 3.1.3.2.3 Nuisance Regulation

**Authority:** CA Health & Safety Code §41700

**Requirements:** Provides that “no person shall discharge from any source whatsoever such quantities of air contaminants or other material which causes injury, detriment, nuisance, or annoyance to any considerable number of persons or to the public or which endanger the comfort, repose, health, or safety of any such persons or the public, or which cause, or have a natural tendency to cause injury or damage to business or property.”

**Administering Agency:** SCAQMD and CARB

### 3.1.3.2.4 Toxic Air Contaminant Program

**Authority:** H&SC §39650 – 39675

**Requirements:** Established in 1983, the Toxic Air Contaminant Identification and Control Act created a two-step process to identify toxic air contaminants and control their emissions. CARB identifies and prioritizes the pollutants to be considered for identification as toxic air contaminants, and also assesses the potential for human exposure to a substance; the Office of Environmental Health Hazard Assessment (OEHHA) evaluates the corresponding health effects. Both agencies collaborate in the preparation of a risk assessment report, which concludes whether a substance poses a significant health risk and should be identified as a toxic air contaminant. In 1993, the Legislature amended the program to identify the 187 federal hazardous air pollutants as toxic air contaminants. CARB reviews the emission sources of an identified toxic air contaminant and, if necessary, develops air toxics control measures to reduce the emissions.

**Administering Agency:** SCAQMD and CARB

### 3.1.3.2.5 Air Toxic “Hot Spots” Act

**Authority:** H& SC §44300-44384; 17 CCR §93300-93347

**Requirements:** Established in 1987, the Air Toxics “Hot Spots” Information and Assessment Act (also known as AB 2588) supplements the toxic air contaminant program, by requiring the development of a statewide inventory of air toxics emissions from stationary sources. The program requires affected facilities to prepare (1) an emissions inventory plan that identifies relevant air toxics and sources of air toxics emissions; (2) an emissions inventory report quantifying air toxics emissions; and (3) a health risk assessment, if necessary, to characterize the health risks to the exposed public. Facilities whose air toxics emissions are deemed to pose a significant health risk must issue notices to the exposed population. In 1992, the Legislature amended the program to further require facilities whose air toxics emissions are deemed to pose a significant health risk to implement risk management plans to reduce the associated health risks. This program is implemented at the local level with state oversight.

**Administering Agency:** SCAQMD and CARB

### 3.1.3.2.6 CEC and CARB Memorandum of Understanding

**Authority:** CA Pub. Res. Code §25523(a); 20 CCR §1752, 1752.5, 2300-2309 and Div. 2, Chap. 5, Art. 1, Appendix B, Part (k)

**Requirements:** Provides for the inclusion of requirements in the CEC's decision on an application for certification to assure protection of environmental quality. The PTA is required to include information concerning air quality protection.

**Administering Agency:** California Energy Commission

### 3.1.3.2.7 California Climate Change Regulatory Program

**Authority:** Stats. 2006, Ch. 488 and CA Health & Safety Code § 38500-38599

**Requirements:** The State of California adopted the Global Warming Solutions Act of 2006 (Assembly Bill [AB] 32) on September 27, 2006, which requires sources within the state to reduce carbon emissions by approximately 25% by the year 2020. Pursuant to this statutory authority, CARB has adopted regulations to limit GHG emissions from electric power plants and other specific source categories. In addition, CARB has adopted regulations requiring the calculation and reporting of GHG emissions from subject facilities.

The PTA is required to include the project's emission rates of greenhouse gases (CO<sub>2</sub>, CH<sub>4</sub>, N<sub>2</sub>O, and SF<sub>6</sub>) from the stack, cooling towers, fuels and materials handling processes, delivery and storage systems, and from all on-site secondary emission sources.

On January 25, 2007, the PUC and CEC jointly adopted an interim Greenhouse Gas Emissions Performance Standard (EPS) in an effort to help mitigate climate change. The EPS is a facility-based emissions standard requiring that all new long-term commitments for baseload generation to serve California consumers be with power plants that have emissions no greater than a combined-cycle gas turbine plant. That level is established at 1,100 pounds of CO<sub>2</sub> per megawatt-hour.

**Administering Agencies:** CARB and CEC.

### 3.1.3.3 Local LORS

When the state's air pollution statutes were reorganized in the mid-1960s, local air pollution control districts (APCDs) were required to be established in each county of the state (H&SC §4000 et seq.). There are three different types of districts: county, regional, and unified. In addition, special air quality management districts (AQMDs), with more comprehensive authority over non-vehicular sources as well as transportation and other regional planning responsibilities, have been established by the Legislature for several regions in California, (H&SC §40200 et seq.).

Air pollution control districts and air quality management districts in California have principal responsibility for the following activities:

- Developing plans for meeting the state and federal ambient air quality standard;
- Developing control measures for non-vehicular sources of air pollution necessary to achieve and maintain both state and federal air quality standards;
- Implementing permit programs established for the construction, modification, and operation of sources of air pollution; and
- Enforcing air pollution statutes and regulations governing non-vehicular sources; and for developing employer-based trip reduction programs.

Each level of government has adopted specific regulations that limit emissions from stationary combustion sources, several of which are applicable to this project. An application for a Determination of Compliance and Permit to Construct was filed with SCAQMD on March 15, 2013.

#### 3.1.3.3.1 South Coast Air Quality Management District Rules and Regulations

**Authority:** CA Health & Safety Code §40001

**Requirements:** Prohibit emissions and other discharges (such as smoke and odors) from specific sources of air pollution in excess of specified levels.

**Administering Agency:** SCAQMD, with CARB oversight.

### ***Permits Required***

Under Regulation II, Rule 201, Permit to Construct (PTC), SCAQMD administers the air quality regulatory program for the construction, alteration, replacement, and operation of new power plants. As part of the PTA process, the project will be required to obtain a preconstruction Determination of Compliance (DOC) from the District. The District's permitting process allows the District to review new and modified air pollution sources to ensure compliance with all applicable prohibitory rules and to ensure that appropriate emission controls are used. Projects that are reviewed under the CEC PTA process must obtain a final DOC and PTC from the local air district (in this case, SCAQMD) prior to construction of the new power plant. The PTC remains in effect until the application for a Permit to Operate (PTO) is granted, denied, or canceled. Once the project commences operations and demonstrates compliance with the PTC, SCAQMD will issue a PTO. The PTO specifies conditions that the facility must meet to comply with all applicable air quality rules, regulations, and standards.

### ***New Source Review Requirements***

The District's New Source Review (NSR) rule (Regulation XIII, New Source Review) and Rule 2005 (New Source Review for RECLAIM) establish the criteria for siting new and modified emission sources; these rules are applicable to the proposed project. SCAQMD has been delegated authority for NSR rule development and enforcement. There are three basic requirements within the NSR rules. First, BACT and Lowest Achievable Emission Rate (LAER) requirements must be applied to any new source with potential emissions above specified threshold quantities. Second, all potential emission increases of nonattainment pollutants or precursors from the proposed source above specified thresholds must be offset by real, quantifiable, surplus, permanent, and enforceable emission decreases in the form of ERCs. Third, an ambient air quality impact analysis must be conducted to confirm that the project does not cause or contribute to a violation of a national or California AAQS or jeopardize public health.

### ***Federal PSD Requirements***

The District implements federal PSD requirements through two regulatory mechanisms. For all pollutants other than GHGs, the District implements the provisions of EPA regulations in 40 CFR 52.21, and 40 CFR 124, pursuant to a delegation agreement with EPA. For GHGs, District Rule 1714 has been approved by EPA into the State Implementation Plan; the SCAQMD implements the PSD program for GHG through the approval into the SIP of this rule. Rule 1714 incorporates by reference the provisions of 40 CFR 52.21 as those relate to GHGs; consequently, the substantive federal PSD requirements, as implemented by the SCAQMD, are found in 40 CFR 52.21.

### ***New Source Review Requirements for Air Toxics***

The SCAQMD's Rule 1401 (New Source Review for Air Toxics) describes the requirements, procedures, and standards for evaluating the potential impact of toxic air contaminants (TAC) from new sources and modifications to existing sources. The rule also requires a demonstration that the source will not exceed the health risk thresholds in Section (d) of the rule.

### ***New Source Performance Standards***

The SCAQMD's New Source Performance Standards (Regulation IX, Standards of Performance for New Stationary Sources) incorporates the federal NSPS from 40 CFR Part 60. The applicability and requirements of the New Source Performance Standards are discussed above under the federal regulations section.

### ***Federal Programs and Permits***

The federal Title IV acid rain program requirement and Title V operational permit requirements are in SCAQMD's Regulation XXXI (Acid Rain Permit Program) and Regulation XXX (Title V Permits). The applicability and requirements of these programs and permits are discussed above under the federal regulations section.

### **Public Notification**

Because the proposed ESPFM project emissions will exceed the trigger levels in Rule 212(g), public notice is required and the project owner expects that the Air Pollution Control Officer will provide this notice in a timely manner.

### **Permit Fees**

The SCAQMD requirements regarding permit fees are specified in Regulation III. This regulation establishes the filing and permit review fees for specific types of new sources, as well as annual renewal fees and penalty fees for existing sources.

### **Prohibitions**

The SCAQMD prohibitions for specific types of sources and pollutants are addressed in Regulation IV. The prohibitory rules that apply to the proposed ESPFM project are listed below.

- Rule 401 – Visible Emissions: This rule prohibits any source from discharging any emissions of any air contaminant opacity of more than 20% (Ringelmann No.1) for a period or periods aggregating more than 3 minutes in any period of 60 consecutive minutes.
- Rule 402 – Nuisance: This rule prohibits the discharge from a facility of air contaminants that cause injury, detriment, nuisance, or annoyance to the public, or cause damage to business or property.
- Rule 403 – Fugitive Dust: The purpose of this rule is to reduce the amount of particulate matter entrained in the ambient air as a result of man-made fugitive dust sources by requiring actions to prevent, reduce, or mitigate fugitive dust emissions. The provisions of this rule apply to any activity or man-made condition capable of generating fugitive dust. This rule prohibits emissions of fugitive dust beyond the property line of the emission source.
- Rule 407 – Liquid and Gaseous Air Contaminants: This rule limits CO emissions to 2,000 ppmvd and SO<sub>2</sub> emissions to 500 ppmvd, averaged over 15 minutes.
- Rule 409 – Combustion Contaminants: This rule restricts the discharge of combustion contaminants (i.e., carbon-containing particulate matter) from the combustion of fuel to 0.23 grams per cubic meter (0.1 grain per cubic foot) of gas, calculated to 12% CO<sub>2</sub>, averaged over 15 minutes.
- Rule 431.1 – Sulfur Content of Fuels: This rule prohibits any stationary source to use any gaseous fuel containing more than 16 ppmv sulfur compounds calculated as H<sub>2</sub>S.
- Rule 474 – Fuel Burning Equipment-Oxides of Nitrogen: This Rule does not apply because the CTG is subject to NOx RECLAIM requirements.
- Rule 475 – Electric Power Generating Equipment: This rule applies to power generating equipment rated greater than 10 MW installed after May 7, 1976. Requirements specify that the equipment must comply with a PM<sub>10</sub> mass emission limit of 11 lbs/hr or a PM<sub>10</sub> concentration limit of 0.01 grains/dscf. Compliance is demonstrated if either the mass emission limit or the concentration limit is met.
- Rule 476 – Steam Generating Equipment: Superseded by NOx RECLAIM.

All applicable LORS are summarized in Table 3.1-12.

TABLE 3.1-12  
**Laws, Ordinances, Regulations, and Standards**

| LORS   | Purpose  | Regulating Agency          | Permit or Approval  | Schedule and Status of Permit                                      | Conformance (Section) |
|--|--|----------------------------|---|--|-----------------------|
| <b>Federal</b>   |  |                            |   |  |                       |
| Clean Air Act (CAA) §160-169A and implementing regulations, Title 42 United States Code (USC) §7470-7491 (42 USC 7470-7491), Title 40 Code of Federal Regulations (CFR) Parts 51 & 52 (40 CFR 51 & 52) (Prevention of Significant Deterioration Program) | Requires prevention of significant deterioration (PSD) review and facility permitting for construction of new or modified major stationary sources of air pollution. PSD review applies to pollutants for which ambient concentrations are lower than NAAQS. | SCAQMD with EPA oversight  | Issues PSD Permit with conditions limiting emissions                      | Agency approval to be obtained before start of construction        | §3.1.6.1              |
| CAA §171-193, 42 USC §7501 et seq. (New Source Review)   | Requires new source review (NSR) facility permitting for construction or modification of specified stationary sources. NSR applies to pollutants for which ambient concentration levels are higher than NAAQS.   | SCAQMD with EPA oversight  | After project review, issues FDOC/ATC with conditions limiting emissions. | Agency approval to be obtained before start of construction        | §3.1.6.1              |
| CAA §401 (Title IV), 42 USC §7651 (Acid Rain Program)  | Requires quantification of NO <sub>2</sub> and SO <sub>2</sub> emissions, and requires operator to hold allowances.  | SCAQMD with EPA oversight  | Issues Acid Rain permit after review of application                       | Application to be submitted 18 months prior to start of operation. | §3.1.6.1              |
| CAA §501 (Title V), 42 USC §7661 (Federal Operating Permits Program)   | Establishes comprehensive permit program for major stationary sources.   | SCAQMD with EPA oversight  | Issues Title V permit after review of application                         | Application to be submitted 12 months after start of operation.    | §3.1.6.1              |
| CAA §111, 42 USC §7411, 40 CFR Part 60 (New Source Performance Standards [NSPS])   | Establishes national standards of performance for new stationary sources.  | SCAQMD with EPA oversight  | After project review, issues FDOC/ATC with conditions limiting emissions. | Agency approval to be obtained before start of construction        | §3.1.6.1              |
| CAA §112, 42 USC §7412, 40 CFR Part 63 (National Emission Standards for Hazardous Air Pollutants [NESHAPs])  | Establishes national emission standards for hazardous air pollutants.  | SCAQMD with EPA oversight  | After project review, issues FDOC/ATC with conditions limiting emissions. | Agency approval to be obtained before start of construction        | §3.1.6.1              |
| <b>State</b>   |  |                            |   |  |                       |
| California Health & Safety Code (H&SC) §41700 (Nuisance Regulation)  | Prohibits discharge of such quantities of air contaminants that cause injury, detriment, nuisance, or annoyance  | SCAQMD with CARB oversight | After project review, issues FDOC/ATC with conditions limiting emissions. | Agency approval to be obtained before start of construction        | §3.1.6.2              |
| H&SC §44300-44384; California Code of Regulations (CCR) §93300-93347 (Toxic "Hot Spots" Act)   | Requires preparation and biennial updating of facility emission inventory of hazardous substances; risk assessments.   | SCAQMD with CARB oversight | After project review, issues FDOC/ATC with conditions limiting emissions. | Agency approval to be obtained before start of construction        | §3.1.6.2              |

TABLE 3.1-12  
**Laws, Ordinances, Regulations, and Standards**

| LORS   | Purpose   | Regulating Agency          | Permit or Approval  | Schedule and Status of Permit                               | Conformance (Section) |
|--|---|----------------------------|---|---|-----------------------|
| California Public Resources Code §25523(a); 20 CCR §1752, 2300-2309 (CEC & CARB Memorandum of Understanding) | Requires that CEC's decision on PTA include requirements to assure protection of environmental quality; PTA required to address air quality protection. | CEC                        | After project review, issues conditions of certification that includes the conditions in the FDOC |   | §3.1.6.2              |
| Global Warming Solutions Act and other GHG reduction measures  | Minimize emissions of GHG from all sources in CA; operator must purchase and surrender GHG allowances   | CEC and CARB               | After project review, CEC issues conditions of certification requiring reporting of GHG emissions |   | §3.1.6.2              |
| <b>Local</b>   |   |                            |   |   |                       |
| California Health & Safety Code (H&SC) §40001 (Air pollution--general)                                       | Prohibit emissions and other discharges (such as smoke and odors) from specific sources of air pollution in excess of specified levels.                 | SCAQMD with CARB oversight | After project review, issues FDOC/ATC with conditions limiting emissions.                         | Agency approval to be obtained before start of construction | §3.1.6.3              |
| SCAQMD Regulation II, Rule 201 (Permits required)  | Administers air quality regulation program for power plants   | SCAQMD with CARB oversight | After project review, issues FDOC/ATC with conditions limiting emissions.                         | Agency approval to be obtained before start of construction | §3.1.6.3              |
| SCAQMD Regulation XIII (New Source Review)   | Establishes criteria for siting new and modified emission sources.  | SCAQMD with CARB oversight | After project review, issues FDOC/ATC with conditions limiting emissions.                         | Agency approval to be obtained before start of construction | §3.1.6.3              |
| SCAQMD Regulation XVII (Prevention of Significant Deterioration)   | Establishes criteria for siting new and modified emission sources.  | SCAQMD with CARB oversight | After project review, issues FDOC/ATC with conditions limiting emissions.                         | Agency approval to be obtained before start of construction | §3.1.6.1              |
| SCAQMD Rule 1401 (Toxic Air Contaminants New Source Review)  | Establishes procedures for review and control of toxic air contaminants from new sources  | SCAQMD with CARB oversight | After project review, issues FDOC/ATC with conditions limiting emissions.                         | Agency approval to be obtained before start of construction | §3.1.6.3              |
| SCAQMD Regulation IX, Standards of Performance for New Stationary Sources                                    | Incorporates federal NSPS standards.  | SCAQMD with CARB oversight | After project review, issues FDOC/ATC with conditions limiting emissions.                         | Agency approval to be obtained before start of construction | §3.1.6.3              |
| SCAQMD Regulation XXX and XXXI (Federal permits)   | Implements Acid Rain and Title V permit programs  | SCAQMD with EPA oversight  | After project review, issues FDOC/ATC with conditions limiting emissions.                         | Agency approval to be obtained before start of construction | §3.1.6.3              |

TABLE 3.1-12  
**Laws, Ordinances, Regulations, and Standards**

| LORS   | Purpose   | Regulating Agency          | Permit or Approval  | Schedule and Status of Permit                               | Conformance (Section) |
|--|---|----------------------------|---|---|-----------------------|
| SCAQMD Rule 212  | Public Notification Requirement   | SCAQMD with CARB oversight | After project review, issues FDOC/ATC with conditions limiting emissions. | Agency approval to be obtained before start of construction | §3.1.6.3              |
| SCAQMD Regulation III (Permit Fees)  | Permit fees   | SCAQMD                     |   | Payment of fees required at time of application             | §3.1.6.3              |
| SCAQMD Rule 401 (Visible Emissions)  | Prohibits visible emissions above certain levels.   | SCAQMD with CARB oversight | After project review, issues FDOC/ATC with conditions limiting emissions. | Agency approval to be obtained before start of construction | §3.1.6.3              |
| SCAQMD Rule 402 (Nuisance )  | Prohibit emissions and other discharges (such as smoke and odors) from specific sources of air pollution in excess of specified levels. | SCAQMD with CARB oversight | After project review, issues FDOC/ATC with conditions limiting emissions. | Agency approval to be obtained before start of construction | §3.1.6.3              |
| SCAQMD Rule 403 (Fugitive Dust)  | Limits emissions of particulate matter  | SCAQMD with CARB oversight | After project review, issues FDOC/ATC with conditions limiting emissions. | Agency approval to be obtained before start of construction | §3.1.6.3              |
| SCAQMD Rules 407 and 409(Liquid and Gaseous Air Contaminants, Combustion Contaminants) | Limits CO, SO <sub>2</sub> , and PM in exhaust  | SCAQMD with CARB oversight | After project review, issues FDOC/ATC with conditions limiting emissions. | Agency approval to be obtained before start of construction | §3.1.6.3              |
| SCAQMD Rule 431.1 (Fuel Sulfur)  | Limits sulfur content of fuel   | SCAQMD with CARB oversight | After project review, issues FDOC/ATC with conditions limiting emissions. | Agency approval to be obtained before start of construction | §3.1.6.3              |
| SCAQMD Rule 475 (Electric Power Generating Equipment)                                  | Limits PM <sub>10</sub> emissions from power generating equipment   | SCAQMD with CARB oversight | After project review, issues FDOC/ATC with conditions limiting emissions. | Agency approval to be obtained before start of construction | §3.1.6.3              |

### 3.1.4 Environmental Consequences

This section evaluates the potential air quality impacts of the project. Project impacts would be considered significant if emissions from the project cause or contribute to a violation of an ambient air quality standard. A project causes or contributes to a violation of an ambient air quality standard if it has a non-de minimis impact at a time and location where a violation of an ambient air quality standard occurs.

Project operating emissions of nonattainment pollutants and their precursors will be offset to ensure that the project will result in no net regional increase in annual emissions of nonattainment pollutants. Emissions estimates for all aspects of both construction and operation of the project are presented in this subsection. Dispersion modeling was conducted to determine project impacts on ambient air quality, and those results are also presented in this section, along with a discussion of dispersion model selection and the selection of model input data (i.e., emissions scenarios and release parameters, building wake effects, meteorological data, and receptor locations). Documentation that the project will comply with applicable local, state, and federal air quality regulatory requirements is also provided.

#### 3.1.4.1 Construction Emissions

Emissions during the construction phase of the project have been estimated, including an assessment of emissions from vehicle and equipment exhaust and the fugitive dust generated from vehicle movement and material handling. A dispersion modeling analysis was conducted based on these emissions. A detailed analysis of the construction emissions and associated ambient impacts is included in Appendix 3.1D. The results of the analysis indicate that the maximum construction impacts will be below the state and federal standards for all the criteria pollutants emitted. The best available emission control techniques will be used. The project construction impacts are not unusual in comparison to most construction sites; construction sites that use good dust suppression techniques and low-emitting vehicles typically do not cause violations of air quality standards.

The primary emission sources during construction will include exhaust from construction equipment and vehicles and fugitive dust generated in areas disturbed by grading, excavating, and erection of facility structures. The projected construction schedule has a duration of 18 to 20 months, during which different areas within the proposed site and a nearby temporary laydown area will be disturbed. Estimated land disturbance for major construction activities is summarized in Section 2.0, Project Description.

Construction equipment and vehicle exhaust emissions were estimated using equipment lists and construction scheduling information provided by the project design engineering firm, which are presented in Section 2.0, Project Description, and Appendix 3.1D. The California Emissions Estimator Model (CalEEMod) was used to generate equipment-specific emission factors for all criteria pollutants for diesel-fueled construction equipment and for on-road vehicles. CalEEMod was developed in collaboration with California's air districts (including SCAQMD), and utilizes CARB's EMFAC model (for on-road emission sources), and OFFROAD model (for off-road emission sources). For this project, the latest emission factors from EMFAC2011 were input into CalEEMod, as well as project-specific mitigation options. Assumptions used in calculating project construction emissions included a 20-month construction period; 5 construction days per week; and a single-shift, 8-hour workday (except during the grading phase, where 6 construction days per week was assumed). The list of fueled equipment needed during each month of the construction effort (see Appendix 3.1D) served as the basis for estimating pollutant emissions throughout the term of construction and helped to identify the periods of probable maximum short-term emissions.

Fugitive dust emissions resulting from on-site soil disturbances were estimated using CalEEMod which, in turn, uses EPA AP-42 emission factors for construction activities, including bulldozing and dirt-pushing, travel on paved and unpaved roads, material handling, and wind erosion to storage of aggregate materials. For traveling on unpaved surfaces at the project site and temporary construction area activities, a combined dust control efficiency of 61 percent was assumed to be achieved by the mitigation measures of frequent watering and limiting speeds to 15 miles per hour.



Emissions from on-road delivery trucks and worker commute trips were estimated using CalEEMod (using EMFAC2011 emission factors), with the trip generation information presented in Section 2. Construction workers were assumed to commute to the proposed project site from locations within the greater Los Angeles area.

The short-term maximum emissions were calculated using Month 19 for construction equipment and Month 6 for fugitive dust. Activities in month 19 include building and facility construction. Activities in Month 6 are primarily grading and other site preparation activities. Annual emissions were based on the worst 12 consecutive months of the construction period, which were Months 4-15 of the 20-month schedule.

Maximum daily construction emissions are shown in Table 3.1-13. Maximum annual construction emissions are shown in Table 3.1-14.

TABLE 3.1-13

**Maximum Daily Construction Emissions, Pounds per Day—Month 19 (Combustion), Month 6 (Fugitive Dust)**

|   | NOx        | CO         | VOC       | SOx      | PM <sub>10</sub> | PM <sub>2.5</sub> |
|---|------------|------------|-----------|----------|------------------|-------------------|
| <b>Onsite</b>                                       |            |            |           |          |                  |                   |
| Construction Equipment                              | 206        | 218        | 32        | 0.4      | 13               | 13                |
| Fugitive Dust                                       | —          | —          | —         | —        | 206              | 218               |
| <b>Offsite</b>                                      |            |            |           |          |                  |                   |
| Worker Travel, Truck Deliveries,<br>Rail Deliveries | 89         | 321        | 30        | 1        | 6                | 93                |
| <b>Total</b>  | <b>295</b> | <b>539</b> | <b>63</b> | <b>1</b> | <b>24</b>        | <b>115</b>        |

TABLE 3.1-14

**Maximum Annual Construction Emissions, Tons per Year**

|                                 | NOx         | CO          | VOC        | SOx        | PM <sub>2.5</sub> | PM <sub>10</sub> |
|---------------------------------|-------------|-------------|------------|------------|-------------------|------------------|
| <b>Onsite</b>                   |             |             |            |            |                   |                  |
| Construction Equipment          | 19.8        | 23.5        | 3.1        | 0.0        | 1.5               | 1.5              |
| Fugitive Dust                   | —           | —           | —          | —          | 0.2               | 0.4              |
| <b>Offsite</b>                  |             |             |            |            |                   |                  |
| Worker Travel, Truck Deliveries | 8.1         | 30.3        | 2.6        | 0.0        | 0.5               | 7.5              |
| <b>Total</b>                    | <b>28.0</b> | <b>53.8</b> | <b>5.7</b> | <b>0.0</b> | <b>2.2</b>        | <b>9.4</b>       |

### 3.1.4.2 Emitting Units

Key operating parameters are summarized below. Additional information relating to the fuel characteristics, heat rate, and startup and operating limits of ESPFM may be found in Section 2.0, Facility Description, and Appendix 3.1A–H.

- GE 7FA Fast Start Combined-Cycle Unit, 325 MW (net)
  - 5,456 hours per year normal operation including 200 startup/shutdown cycles
  - Fueled exclusively with natural gas
- Rolls Royce Trent 60 Simple-Cycle Unit, 55 MW (net) (two units)
  - 4,800 hours per year normal operation including 480 startup/shutdown cycles (each)

- Fueled exclusively with natural gas
- Auxiliary Boiler, 36 MMBtu/Hr (Nominal)
  - Up to 8,760 hours per year at 25% load
  - Fueled exclusively with natural gas

### 3.1.4.3 Turbine Commissioning

Gas turbine commissioning consists of no-load, partial-load, and full-load testing performed immediately after construction for the purposes of optimizing turbo machinery and gas turbine combustors, and optimizing and testing of the SCR systems. Several parameters—such as gas turbine load, degree of combustor tuning, and degree of SCR control—may be varied simultaneously during testing. Emissions during the commissioning year may be higher than those during a non-commissioning year for some pollutants due to the fact that the combustors may not be optimally tuned and the SCR systems may be only partially operational or not operational at all. The commissioning schedule will comprise several phases in which each of the CTGs will be operated at various loads; the degree of SCR and oxidation catalyst system control may vary during these periods as well. It will be assumed that the commissioning of the units will be simultaneous to address the worst-case scenario.

Average commissioning emission rates for each turbine are shown in Table 3.1-15, and details of the commissioning schedule and associated emissions for each turbine are presented in Appendix 3.1E.

TABLE 3.1-15  
**Commissioning Emissions**

| Unit                    | Duration (Hours) | Average Pollutant Emission Rates |            |             |                         |                          |
|-------------------------|------------------|----------------------------------|------------|-------------|-------------------------|--------------------------|
|                         |                  | NO <sub>x</sub> (lb/hr)          | CO (lb/hr) | VOC (lb/hr) | SO <sub>2</sub> (lb/hr) | PM <sub>10</sub> (lb/hr) |
| GE Turbine (Unit 9)     | 415              | 30.1                             | 314.1      | 16.8        | 1.4                     | 9.4                      |
| Trent Turbine (Unit 11) | 121              | 44.1                             | 116.7      | 10.0        | 0.4                     | 7.9                      |
| Trent Turbine (Unit 12) | 121              | 44.1                             | 116.7      | 10.0        | 0.4                     | 7.9                      |

### 3.1.4.4 Operational Emissions

The emission sources of the project will be the three combustion turbine generators (CTGs), the duct burner for the combined cycle unit, and the auxiliary boiler, all of which will burn exclusively natural gas fuel. Maximum annual operational emissions from the combined cycle unit were based on 5,056 hours of full load operation, plus 200 hours including a startup, plus 200 hours including a shutdown. Maximum annual operational emissions from each simple cycle unit were based on 3,840 hours of full load operation, plus 480 hours including a startup, plus 480 hours including a shutdown.

Criteria pollutant emissions from the gas turbines are summarized in Table 3.1-16. Emissions of NO<sub>x</sub>, CO, and VOC from the CTGs were calculated from emission exhaust concentration limits (expressed as ppmv @ 15 percent O<sub>2</sub>) and the exhaust flow rates from vendor performance data. The proposed NO<sub>x</sub> emission limits of 2.0 ppmv (for the combined cycle unit) and 2.5 ppmv (for the simple cycle units) reflect the application of SCR. The proposed VOC emission limit of 2.0 ppmv reflects the use of good combustion practices. The proposed CO emission limits of 2.0 ppmv (for the combined cycle unit) and 4.0 ppmv (for the simple cycle units) reflect the expected performance of the oxidation catalyst.

Maximum hourly PM<sub>10</sub> emissions reflect expected turbine performance, based on emission limits from similar installations. For regulatory purposes, all of the particulate matter emitted from the fuel burning equipment is assumed to be less than 2.5 microns in diameter. All references to PM<sub>10</sub> from project sources include PM<sub>2.5</sub> as well, even though some fraction of PM<sub>10</sub> emissions are likely to be larger than 2.5 microns in size.

SO<sub>2</sub> emissions were calculated from the heat input (in MMBtu) and an SO<sub>2</sub> emission factor (in lb/MMBtu). Hourly SO<sub>2</sub> emissions were calculated based on the proposed maximum allowable fuel sulfur content of 0.75 grain per

100 standard cubic feet (scf). Annual SO<sub>2</sub> emissions were calculated based on the expected annual average fuel sulfur content of 0.25 grain per 100 standard cubic feet (scf).

TABLE 3.1-16

**Maximum Emission Rates—Combustion Turbines**

| Pollutant  | ppmv @ 15% O <sub>2</sub> | lb/MMBtu | lb/hr |
|--|---------------------------|----------|-------|
| <b>Unit 9 (GE Turbine plus duct burner)</b>      |                           |          |       |
| NO <sub>x</sub>                                  | 2.0                       | 0.0074   | 17.9  |
| SO <sub>2</sub> <sup>a</sup>                     | 0.4                       | 0.0021   | 1.7   |
| CO   | 2.0                       | 0.0045   | 10.9  |
| VOC  | 2.0                       | 0.0026   | 6.2   |
| PM <sub>10</sub> /PM <sub>2.5</sub> <sup>b</sup> | —                         | —        | 9.5   |
| <b>Trent Combustion Turbines (each)</b>          |                           |          |       |
| NO <sub>x</sub>                                  | 2.5                       | 0.0092   | 4.8   |
| SO <sub>2</sub> <sup>a</sup>                     | 0.4                       | 0.0021   | 1.1   |
| CO   | 4.0                       | 0.0090   | 4.6   |
| VOC  | 2.0                       | 0.0026   | 1.3   |
| PM <sub>10</sub> /PM <sub>2.5</sub> <sup>b</sup> | —                         | —        | 5.0   |

Note: NO<sub>x</sub>, CO, VOC, and PM<sub>10</sub> emission rates exclude startups and shutdowns (see Table 3.1-17).

<sup>a</sup>Based on maximum natural gas sulfur content of 0.75 gr/100 scf. See text.

<sup>b</sup>Includes front and back half.

Combustion turbine performance was evaluated for a number of operating scenarios with different turbine loads (ranging from 50% load to 100% load), and ambient temperatures ranging from a low of 41°F to a high of 90°F. The maximum hourly emissions for all criteria pollutants from a turbine during normal operations are expected to occur under the conditions with the highest firing rate: 100% load, use of evaporative cooling, and 41°F ambient temperature (for the GE Turbine); and 100% load and 78°F ambient temperature (for the Trent Turbines).

**Start-Up and Shutdown Emissions**

GE Turbine: Two types of startups have been identified for the GE turbines: fast start and traditional. The principal difference between the two is the amount of time needed to bring the gas turbine to full operating load. Because the turbines will reach full load more quickly under fast start conditions, the oxidation and SCR catalysts will reach operating temperature more quickly as well. SO<sub>2</sub> and PM emissions are essentially the same for both startup types; thus, the differences between the two types of startups, from an emissions standpoint, are that the traditional startup takes longer (60 minutes instead of the 30 minutes for a fast start), and has higher VOC, CO, and NO<sub>x</sub> emissions.

The project owner expects that there will be up to 200 startup hours per year for the GE CTG. During a fast CTG startup, there are approximately 30 minutes with elevated emissions (emissions higher than during normal operation). Consequently, the hourly emission rates during CTG startups are based on 30 minutes of elevated emissions followed by 30 minutes of normal operating emission levels (for fast starts) and, as a worst case, 60 minutes of elevated emissions for a traditional start. In addition, there will be up to 200 shutdown hours per year. During a CTG shutdown, there are approximately 30 minutes with elevated emissions (emissions higher than during normal operation). Consequently, the hourly emission rates during CTG shutdowns are based on 30 minutes of normal operating emission levels followed by 30 minutes of elevated emission levels.

The detailed CTG startup hourly emission calculations are shown in Appendix 3.1A. The project owner expects that there could be as many as two startup hours and two shutdown hours per day. During start-up/shutdown operations, the CTG is assumed to operate at elevated NO<sub>x</sub> and CO concentration rates due to the phased-in effectiveness of the DLN combustors, SCR systems, and oxidation catalysts.

Trent Turbines: The project owner expects that there will be up to 480 startup hours per year for each Trent CTG. During a Trent CTG startup, there are approximately 30 minutes with elevated emissions (emissions higher than during normal operation). Consequently, the hourly emission rates during Trent CTG startups are based on 30 minutes of elevated emissions followed by 30 minutes of normal operating emission levels. In addition, there will be up to 480 shutdown hours per year per turbine. During a Trent CTG shutdown, there are approximately 20 minutes with elevated emissions (emissions higher than during normal operation). Consequently, the hourly emission rates during Trent CTG shutdowns are based on 40 minutes of normal operating emission levels followed by 20 minutes of elevated emission levels. For the Trent turbines, periodically there could be an hour when both a startup and a shutdown occur. For this hour, there would be 30 minutes of elevated emissions due to the startup, 10 minutes of normal operation emissions, followed by 20 minutes of elevated emissions due to a shutdown. While this situation is expected to occur very infrequently, from an hourly emission standpoint this would represent worst-case hourly emissions, and as such it is evaluated in the ambient air impact analysis for the proposed project.

The detailed CTG startup hourly emission calculations are shown in 3.1-17. The project owner expects that there could be as many as four startup hours and four shutdown hours per day per Trent CTG. During start-up/shutdown operations, the Trent CTG is assumed to operate at elevated NO<sub>x</sub> and CO concentration rates due to the phased-in effectiveness of the DLE combustors, SCR systems, and oxidation catalysts.

TABLE 3.1-17

**El Segundo Power Facility Modification—Turbine Startup/Shutdown Emissions**

| Mode                         | Time (minutes) | Total Emissions Per Event (pounds) |      |     |     |
|------------------------------|----------------|------------------------------------|------|-----|-----|
|                              |                | NO <sub>x</sub>                    | CO   | VOC | PM  |
| <b>GE Turbine</b>            |                |                                    |      |     |     |
| Startup (fast start)         | 30             | 36                                 | 153  | 14  | 5   |
| Startup (traditional)        | 60             | 62                                 | 291  | 23  | 5   |
| Shutdown                     | 30             | 29                                 | 317  | 32  | 2   |
| <b>Trent Turbines (each)</b> |                |                                    |      |     |     |
| Startup                      | 30             | 28.0                               | 87.5 | 6.7 | 3.8 |
| Shutdown                     | 20             | 7.1                                | 60.0 | 4.7 | 2.2 |

The maximum expected emissions for each averaging period were used in the compliance demonstration modeling, and are summarized in Table 3.1-18.

TABLE 3.1-18  
Emission Summary (Maximum for Each Averaging Period)

| Equipment                     | NOx                       |               | SOx                       |               | CO                        |               | VOC                       |               | PM <sub>10</sub>          |               |              |              |
|-------------------------------|---------------------------|---------------|---------------------------|---------------|---------------------------|---------------|---------------------------|---------------|---------------------------|---------------|--------------|--------------|
|                               | Max<br>lb/hr <sup>a</sup> | Max<br>lb/day | Max<br>lb/hr <sup>a</sup> | Max<br>lb/day | Max<br>lb/hr <sup>a</sup> | Max<br>lb/day | Max<br>lb/hr <sup>a</sup> | Max<br>lb/day | Max<br>lb/hr <sup>a</sup> | Max<br>lb/day | Total<br>TPY | Total<br>TPY |
| Unit 9 <sup>b</sup>           | 62.3                      | 559.1         | 5.1                       | 124.8         | 322.0                     | 1322.8        | 34.6                      | 240.7         | 9.5                       | 237.5         | 21.1         | 25.9         |
| Unit 11 <sup>c</sup>          | 30.4                      | 238.6         | 1.1                       | 23.9          | 89.8                      | 685.6         | 7.4                       | 72.9          | 5.0                       | 120.0         | 5.6          | 12.0         |
| Unit 12 <sup>c</sup>          | 30.4                      | 238.6         | 1.1                       | 23.9          | 89.8                      | 685.6         | 7.4                       | 72.9          | 5.0                       | 120.0         | 5.6          | 12.0         |
| Auxiliary Boiler <sup>d</sup> | 0.1                       | 2.4           | 0.0                       | 0.4           | 0.3                       | 8.0           | 0.0                       | 0.9           | 0.3                       | 1.6           | 0.2          | 0.3          |

<sup>a</sup>Maximum hourly turbine emissions based on startup emissions for NOx, shutdown emissions for CO, and worst case normal operations for other pollutants. See Appendix 3.1A, Table 3.1A-22 and 3.1A-24 for calculation of hourly emissions during startup/shutdown.

<sup>b</sup>Annual emissions based on 5,456 hours of operations including 200 startup and shutdown events.

<sup>c</sup>Annual emissions based on 4,800 hours of operations including 480 startup and shutdown events.

<sup>d</sup>Annual emissions based on 8,760 hours of operations at 25% load.

### 3.1.4.5 Non-Criteria Pollutant Emissions

A health risk assessment was performed to determine the potential for public health impacts of non-criteria pollutants emitted by the project. Emissions are summarized in Table 3.1-19. The health risk assessment itself is presented in Section 3.8, Public Health.

TABLE 3.1-19  
Non-Criteria Pollutant Emission Totals for Modeling

| Pollutant                               | Emissions, lb/hr |                    |            | Total, TPY |
|---|------------------|--------------------|------------|------------|
|   | Unit 9           | Units 11/12 (each) | Aux Boiler |            |
| <b>Turbines</b>                         |                  |                    |            |            |
| Ammonia                                 | 1.34E+01         | 1.99E+00           |            | 61.77      |
| Propylene                               | 1.82E+00         | 3.86E-01           | 1.85E-02   | 6.91       |
| <b>Hazardous Air Pollutants (HAPs)</b>  |                  |                    |            |            |
| Acetaldehyde                            | 9.65E-02         | 2.04E-02           | 1.08E-04   | 0.36       |
| Acrolein                                | 1.54E-02         | 3.27E-03           | 9.44E-05   | 0.06       |
| Benzene                                 | 2.90E-02         | 6.13E-03           | 2.03E-04   | 0.11       |
| 1,3-Butadiene                           | 1.04E-03         | 2.20E-04           |            | 0.00       |
| Ethylbenzene                            | 7.72E-02         | 1.64E-02           | 2.41E-04   | 0.29       |
| Formaldehyde                            | 8.69E-01         | 1.84E-01           | 4.30E-04   | 3.25       |
| Hexane, n-                              | 6.13E-01         | 1.30E-01           | 1.61E-04   | 2.29       |
| Naphthalene                             | 3.14E-03         | 6.64E-04           | 1.05E-05   | 0.01       |
| <i>PAHs (listed individually below)</i> | N/A              | N/A                | 1.40E-05   |            |
| Anthracene                              | 8.00E-05         | 1.69E-05           |            | 0.00       |
| Benzo(a)anthracene                      | 5.35E-05         | 1.13E-05           |            | 0.00       |
| Benzo(a)pyrene                          | 3.29E-05         | 6.96E-06           |            | 0.00       |
| Benzo(b)fluoranthrene                   | 2.67E-05         | 5.66E-06           |            | 0.00       |
| Benzo(k)fluoranthrene                   | 2.60E-05         | 5.51E-06           |            | 0.00       |
| Chrysene                                | 5.96E-05         | 1.26E-05           |            | 0.00       |
| Dibenz(a,h)anthracene                   | 5.56E-05         | 1.18E-05           |            | 0.00       |
| Indeno(1,2,3-cd)pyrene                  | 5.56E-05         | 1.18E-05           |            | 0.00       |
| Propylene oxide                         | 7.00E-02         | 1.48E-02           |            | 0.26       |
| Toluene                                 | 3.14E-01         | 6.64E-02           | 9.26E-04   | 1.17       |
| Xylene                                  | 1.54E-01         | 3.27E-02           | 6.89E-04   | 0.58       |
| <b>Total HAPs*</b>                      |                  |                    |            | 8.39       |

\*Ammonia and propylene are not HAPs so are not included in this total.

### 3.1.4.6 Greenhouse Gas Emissions

Potential maximum annual GHG emissions for the operational ESPFM were calculated using the calculation methods and emission factors from the USEPA GHG Reporting Regulation.<sup>2</sup> Table 3.1-20 presents the estimated GHG emissions due to project operations as carbon dioxide equivalent [CO<sub>2</sub>e]. Emissions of methane, nitrous oxide, and sulfur hexafluoride have been converted to carbon dioxide equivalents using GHG warming potentials of 21, 310, and 23,900 respectively. The estimated emissions include the combustion emissions for the three turbines. They also include sulfur hexafluoride leakage emissions from three switchyard circuit breakers.

<sup>2</sup> 40 CFR 98 Subpart C, Tables C-1 and C-2.

One-time GHG emissions from construction activities are presented in Table 3.1-21.

Appendix 3.1-A presents supporting technical information and calculation spreadsheets used to develop emissions data for the various scenarios of the operational project.

TABLE 3.1-20

**Project Greenhouse Gas Emissions**

| Unit | CO <sub>2</sub><br>metric tons/year | CH <sub>4</sub><br>metric tons/year | N <sub>2</sub> O<br>metric tons/year | SF <sub>6</sub><br>metric tons/year | CO <sub>2</sub> eq<br>metric tons/yr* | CO <sub>2</sub><br>metric tons/MWh |
|------|-------------------------------------|-------------------------------------|--------------------------------------|-------------------------------------|---------------------------------------|------------------------------------|
| CTGs | 967,315                             | 18                                  | 2                                    | <1                                  | 968,264                               | 0.407                              |

\*Includes CH<sub>4</sub>, N<sub>2</sub>O, and SF<sub>6</sub>.

TABLE 3.1-21

**Construction Greenhouse Gas Emissions**

| Unit             | CO <sub>2</sub> , metric tons | CH <sub>4</sub> , metric tons | N <sub>2</sub> O, metric tons | CO <sub>2</sub> eq, metric tons |
|------------------|-------------------------------|-------------------------------|-------------------------------|---------------------------------|
| Offroad Fuel Use | 78                            | 3.19E-03                      | 6.38E-04                      | 5,874                           |
| Worker Travel    | 307                           | 1.30E-02                      | 2.60E-03                      | 6,548                           |
| Truck Deliveries | 81                            | 3.34E-03                      | 6.68E-04                      | 1,101                           |
| <b>Total</b>     | <b>466</b>                    | <b>1.95E-02</b>               | <b>3.91E-03</b>               | <b>13,524</b>                   |

### 3.1.4.7 Air Dispersion Modeling

An assessment of impacts from the ESPFM on ambient air quality has been conducted using EPA-approved air quality dispersion models, following the modeling protocol submitted to the agencies in November 2012 (See Appendix 3.1C) and subsequent discussions with District staff. These models are based on various mathematical descriptions of atmospheric diffusion and dispersion processes in which a pollutant source impact can be calculated over a given area.

The impact analysis was used to determine the worst-case ground-level impacts of the project. The results were compared with established state and federal ambient air quality standards and PSD significance levels. If the standards are not exceeded under worst-case conditions then it is inferred that, in the operation of the facility, no exceedances are expected under any conditions. In accordance with the air quality impact analysis guidelines developed by EPA (40 CFR Part 51, Appendix W: Guideline on Air Quality Models) and CARB (Reference Document for California Statewide Modeling Guideline, April 1989), the ground-level impact analysis includes the following assessments:

- Impacts in simple, intermediate, and complex terrain;
- Aerodynamic effects (downwash) due to nearby building(s) and structures; and
- Impacts from inversion breakup (fumigation).

Simple, intermediate, and complex terrain impacts were assessed for all meteorological conditions that would limit the amount of final plume rise. Plume impaction on elevated terrain, such as on the slope of a nearby hill, can cause high ground-level concentrations, especially under stable atmospheric conditions. Another dispersion condition that can cause high ground-level pollutant concentrations is caused by building downwash. Building downwash can occur when wind speeds are high and a building or structure is in close proximity to the emission stack. This can result in building wake effects where the plume is drawn down toward the ground by the lower pressure region that exists in the lee side (downwind) of the building or structure.

Fumigation conditions occur when the plume is emitted into a low-lying layer of stable air (inversion) that then becomes unstable, resulting in a rapid mixing of pollutants towards the ground. The low mixing height that results

from this condition allows little diffusion of the stack plume before it is carried downwind to the ground. Although fumigation conditions rarely last as long as an hour, relatively high ground-level concentrations may be reached during that period. Fumigation tends to occur under clear skies and light winds, and is more prevalent in the summer.

The basic model equation used in this analysis assumes that the concentrations of emissions within a plume can be characterized by a Gaussian distribution about the centerline of the plume. Concentrations at any location downwind of a point source such as a stack can be determined from the following equation:

$$C(x, y, z, H) = \left( \frac{Q}{2\pi\sigma_y\sigma_z u} \right) * (e^{-1/2(y/\sigma_y)^2}) * ([e^{-1/2(z-H/\sigma_z)^2}] + [e^{-1/2(z+H/\sigma_z)^2}])$$

Where:

$C$  = the concentration in the air of the substance or pollutant in question

$Q$  = the pollutant emission rate

$\sigma_y, \sigma_z$  = the horizontal and vertical dispersion coefficients, respectively, at downwind distance  $x$

$u$  = the wind speed at the height of the plume center

$x, y, z$  = the variables that define the 3-dimensional Cartesian coordinate system used; the downwind, crosswind, and vertical distances from the base of the stack

$H$  = the height of the plume above the stack base (the sum of the height of the stack and the vertical distance that the plume rises due to the momentum and/or buoyancy of the plume)

Gaussian dispersion models are approved by EPA for regulatory use and are based on conservative assumptions (i.e., the models tend to overpredict actual impacts by assuming steady-state conditions, no pollutant loss through conservation of mass, no chemical reactions, etc.). The EPA models were used to determine if ambient air quality standards would be exceeded, and whether a more accurate and sophisticated modeling procedure would be warranted to make the impact determination. The following sections describe:

- Screening modeling procedures;
- Refined air quality impact analysis;
- Existing ambient pollutant concentrations and preconstruction monitoring;
- Results of the ambient air quality modeling analyses; and
- PSD increment consumption.

#### 3.1.4.8 Model Selection

The screening and refined air quality impact analyses were performed using the American Meteorological Society/EPA Regulatory Model Improvement Committee (AERMIC) model, also known as AERMOD (current version 12345). The AERMOD model is a steady-state, multiple-source, Gaussian dispersion model designed for use with stack emission sources situated in terrain where ground elevations can exceed the stack heights of the emission sources (i.e., complex terrain).<sup>3</sup> The model is capable of estimating concentrations for a wide range of averaging times (from 1 hour to 1 year). Inputs required by the AERMOD model include the following:

- Model options;
- Meteorological data;
- Source data; and
- Receptor data.

Model options refer to user selections that account for conditions specific to the area being modeled or to the emissions source that needs to be examined. Examples of model options include use of site-specific vertical

<sup>3</sup> AERMOD was adopted in November 2005 as a guideline model by EPA as a replacement for ISCST3. AERMOD incorporates an improved downwash algorithm as compared to ISCST3 (Federal Register, November 9, 2005; Volume 70, Number 216, Pages 68218-68261).



profiles of wind speed and temperature; consideration of stack and building wake effects; and time-dependent exponential decay of pollutants. The model supplies recommended default options for the user for some of these parameters.

AERMOD uses hourly meteorological data to characterize plume dispersion. The representativeness of the data is dependent on the proximity of the meteorological monitoring site to the area under consideration, the complexity of the terrain, the exposure of the meteorological monitoring site, and the period of time during which the data are collected. The District provided a meteorological data set appropriate for use with AERMOD. The data set combined surface meteorological data (e.g., wind speed and direction, temperature) from the District's LAX Airport monitoring station and upper air data from the Marine Corps Air Station Miramar (MCAS Miramar) in San Diego.

#### 3.1.4.9 Good Engineering Practice Stack Height Analysis

For the purposes of modeling, a stack height beyond what is required by Good Engineering Practices (GEP) is not allowed (40 CFR Part 60 §51.164). However, this requirement does not place a limit on the actual constructed height of a stack. GEP as used in modeling analyses is the height necessary to ensure that emissions from the stack do not result in excessive concentrations of any air pollutant in the immediate vicinity of the source as a result of atmospheric downwash, eddies, or wakes that may be created by the source itself, nearby structures, or nearby terrain obstacles. In addition, the GEP stack height modeling restriction assures that any required regulatory control measure is not compromised by the effect of that portion of the stack that exceeds the GEP height. The EPA guidance ("Guideline for Determination of Good Engineering Practice Stack Height," Revised 6/85) for determining GEP stack height indicates that GEP is the greater of 65 meters or  $H_g$ , where  $H_g$  is calculated as follows:

$$H_g = H + 1.5L$$

Where:

$H_g$  = Good Engineering Practice stack height, measured from the ground-level elevation at the base of the stack

H = height of nearby structure(s) measured from the ground-level elevation at the base of the stack

L = lesser dimension, height or maximum projected width, of nearby structure(s)

The turbine stack heights, at 100 feet, are less than the GEP limit of 65 meters (213 feet). Stack heights therefore do not need to be adjusted for GEP.

#### 3.1.4.10 Receptor Grid Selection and Coverage

Receptor and source base elevations were determined from USGS National Elevation Dataset (NED) data in the GeoTIFF format at a horizontal resolution of 1 arc-second (approximately 30 meters). All coordinates were referenced to UTM North American Datum 1983 (NAD83), Zone 11. The AERMOD receptor elevations were interpolated among the DEM nodes according to standard AERMAP procedure. For determining concentrations in elevated terrain, the AERMAP terrain preprocessor receptor-output (ROU) file option was chosen; hills were not imported into AERMOD for CTDM-like processing.

Cartesian coordinate receptor grids were used to provide adequate spatial coverage surrounding the project area for assessing ground-level pollution concentrations, to identify the extent of significant impacts, and to identify maximum impact locations. A 250-meter resolution coarse receptor grid was developed and extended outwards at least 10 km (or more as necessary to calculate the significant impact area). For the full impact analyses, a nested grid was developed to fully represent the maximum impact area(s). This grid has 25-meter resolution along the facility fence-line in a single tier of receptors composed of four segments extending out to 100 meters from the fence line, 100-meter resolution from 100 meters to 1,000 meters from the fence line, and 250-meter spacing out to at least 10 km from the most distant source modeled, not to exceed 50 km from the project site. Additional refined receptor grids with 25-meter resolution were placed around the maximum first-high and maximum second-high coarse grid impacts and extended out 1,000 meters in all directions. Concentrations within the facility

fenceline were not calculated. To simplify post-processing requirements, the PSD analyses did not include the receptor locations at which the significant impact levels were not exceeded for subject pollutants.

The regions imported in Geographical Coordinates for the USGS National Elevation Dataset (NED) data are bounded as follows:

South West corner: UTM Zone 11 (NAD 83) 356,500.0 m, 3,741,600.0 m; and  
North East corner: UTM Zone 11 (NAD 83) 379,800.0 m, 3,764,700.0 m.

#### 3.1.4.11 Meteorological Data Selection

The District provided a 5-year meteorological dataset (2005 through 2009) already processed by AERMET to generate AERMOD-compatible meteorological data for air dispersion modeling. The surface meteorological data were recorded at the District's LAX Airport monitoring station, and the upper air data were recorded at the MCAS Miramar (No. 03190). EPA defines the term "on-site data" to mean data that would be representative of atmospheric dispersion conditions at the source and at locations where the source may have a significant impact on air quality. Representativeness has been defined in the PSD Monitoring Guideline as data that characterize the air quality for the general area in which the proposed project would be constructed and operated. The meteorological data requirement originates in the Clean Air Act at Section 165(e)(1), which requires an analysis "of the ambient air quality at the proposed site and in areas which may be affected by emissions from such facility for each pollutant subject to regulation under [the Act] which will be emitted from such facility."

This requirement and EPA's guidance on the use of on-site monitoring data are also outlined in the *On-Site Meteorological Program Guidance for Regulatory Modeling Applications*.<sup>4</sup> The representativeness of the data depends on (a) the proximity of the meteorological monitoring site to the area under consideration, (b) the complexity of the topography of the area, (c) the exposure of the meteorological sensors, and (d) the period of time during which the data are collected. The District has determined, and the project owner concurs, that the District's LAX meteorological data are representative of conditions at the project site.

Representativeness is best evaluated when sites are climatologically similar, as are the project site and the LAX meteorological monitoring station. The LAX International meteorological monitoring station is in close proximity to the proposed project site (distance between the two locations is approximately 5 km with no significant intervening terrain features), and the same large-scale topographic features located to the east and north that influence the meteorological data monitoring station also influence the proposed project site in the same manner.

Upper air meteorological data are taken from soundings obtained at the Marine Corps Air Station at Miramar, California. No other upper air meteorological monitoring stations are located in the South Coast Air Basin. The next closest upper air station in California is located at Oakland International Airport.

#### 3.1.4.12 Ambient Background Data Selection

Background ambient air quality data for the project area from the monitoring site most representative of the conditions that exist at the proposed project site were used to represent regional background concentrations. The District has determined that the LAX monitoring station provides the most representative ambient air quality background data for PM<sub>10</sub>, NO<sub>2</sub>, SO<sub>2</sub>, O<sub>3</sub>, and CO. The North Long Beach Station is the nearest for PM<sub>2.5</sub> observations.

The District has selected the 3-year period 2009–2011 for use in demonstrating compliance with District requirements; the same 3-year period is used to address CEC requirements.

Processed data files were obtained from the District. Data for periods of time with invalid data were replaced by the District using data substitution procedures consistent with EPA guidance. Data substitution ensures that there will be no gaps in the data. This will prevent exclusion of modeled high impact hours because of missing monitoring data.

---

<sup>4</sup> EPA, *Supplement A to the Guideline on Air Quality Models (Revised)*, 1987.

### 3.1.4.13 Construction Impacts

Section 3.1.4.1 describes the development of project emissions estimates over the planned 20-month construction period. An Excel workbook was created to estimate pollutant emissions from construction activities. Emissions from worker commuter trips to and from the project site and heavy trucks delivering materials to and from the site during specific construction activities were also included (see Appendix 3.1D).

Worst-case modeling was conducted for short-term averaging times using all combustion emissions from all construction equipment from Month 19 and dust emissions from activities in Month 6 (see Tables 3.1-13 and 3.1-14). Annual emissions were based on Months 4–15.

Based on information provided by the engineering design contractor and the emission estimates in Appendix 3.1D, the peak month in terms of air pollutant emissions is expected to be the 19th month of construction. All construction activities were assumed to occur during an 8-hour work day. The annual emissions were modeled for Months 4–15 after a determination that this consecutive 12-month period will have a higher level of construction activity, as well as higher exhaust and dust emissions, than any other over the entire construction period. The modeling was performed with no downwash. The emission sources for the construction site were grouped into two categories: exhaust emissions and construction dust emissions. The exhaust and construction dust emissions were modeled as four volume sources with a vertical dimension of 6 meters.

The PVMRM option of AERMOD was used to account for the role of ambient ozone levels on the atmospheric conversion rate of NO<sub>x</sub> emissions (initially mostly in the form of nitric oxide) to NO<sub>2</sub> (the pollutant addressed by ambient standards). Hourly ozone measurements at the LAX Airport monitoring station during the same three years of the meteorological input data set were used to support the PVMRM calculations.

Modeling results are shown in Table 3.1-22.

TABLE 3.1-22

#### Modeled Maximum Impacts During Construction

| Pollutant         | Averaging Period | Maximum Predicted Impact ( $\mu\text{g}/\text{m}^3$ ) | Maximum Background Concentration ( $\mu\text{g}/\text{m}^3$ ) | Total Concentration <sup>a</sup> ( $\mu\text{g}/\text{m}^3$ ) | NAAQS ( $\mu\text{g}/\text{m}^3$ ) | CAAQS ( $\mu\text{g}/\text{m}^3$ ) |
|-------------------|------------------|---|---|---|------------------------------------|------------------------------------|
| NO <sub>2</sub>   | 1-hr             | 225.7   | 184.2   | 276.4 <sup>b</sup>  | —                                  | 339                                |
|                   | Fed. 1-hour      | 225.7   | 129.7 <sup>b</sup>  | 263.5 <sup>d</sup>  | 188                                | —                                  |
|                   | Annual           | 28.2  | 24.5  | 52.7  | 100                                | 57                                 |
| SO <sub>2</sub>   | 1-hr             | 1.3   | 67.6  | 68.9  | 196                                | 655                                |
|                   | 3-hr             | 0.9   | 41.6  | 42.5  | 1300                               | —                                  |
|                   | 24-hr            | 0.4   | 15.8  | 16.2  | —                                  | 105                                |
| CO                | 1-hr             | 707   | 3,250   | 3,957   | 40,000                             | 23,000                             |
|                   | 8-hr             | 339   | 2,433   | 2,772   | 10,000                             | 20,000                             |
| PM <sub>10</sub>  | 24-hr            | 19  | 52  | 71  | 150                                | 50                                 |
|                   | Annual           | 3.6   | 25.6  | 29.2  | —                                  | 20                                 |
| PM <sub>2.5</sub> | 24-hr            |   | 30  | 50.1  | 35                                 | —                                  |
|                   | Annual           |   | 12.8  | 16.0  | 12.0                               | 12                                 |

<sup>a</sup>The total concentration shown in this table is the sum of the maximum predicted impact and the maximum measured background concentration. Because the maximum impact will not occur at the same time as the maximum background concentration, the actual maximum combined impact will be lower.

<sup>b</sup>Background concentration for Federal 1-hour standard is 3-year average of 98<sup>th</sup> percentile of daily maximum 1-hour average concentration.

<sup>c</sup>Total Concentration for 1-hr NO<sub>2</sub> is the highest value of the sum of the modeled impact plus the corresponding ambient background concentration for that time of day.

<sup>d</sup>Total concentration for Fed. 1-hour NO<sub>x</sub> is the highest eight-highest value of the daily maximum of the sum of the modeled impact plus the corresponding ambient background concentration for that time of day.

Because the federal one-hour NO<sub>2</sub> standard and federal 24-hour PM<sub>2.5</sub> standard are statistically-based, and require averaging the concentrations over three years, the NO<sub>2</sub> impacts during the single year of construction would not be likely to cause a new violation of the federal one-hour NO<sub>2</sub> standard. Because construction is

expected to last only 20 months, construction impacts would be much lower during the second year and zero during the third year of a compliance assessment with the federal one-hour NO<sub>2</sub> standard.

Table 3.1-22 shows that worst-case background concentrations of PM<sub>10</sub> are already above the state standards. Table 3.1-22 also shows that worst-case background concentrations of PM<sub>2.5</sub> are already above the state and federal annual standards.

The project's construction emissions will result in potentially significant impacts for PM<sub>10</sub> and PM<sub>2.5</sub>. Mitigation measures to be used to minimize emissions during construction are described in detail in Appendix 3.1D. As discussed in Section 3.1.7, emission offsets will be provided prior to the commencement of construction that will fully mitigate these impacts.

Table 3.1-22 shows that construction emissions will not cause new exceedances of any other state or federal air quality standards.

### 3.1.4.14 Commissioning Impacts

Air quality impacts during the commissioning period were determined using the emission rates in Appendix 3.1E. One-hour average NO<sub>2</sub> impacts during commissioning were modeled using AERMOD\_PVMRM and concurrent LAX ozone data. Modeled impacts are shown in Table 3.1-23.

TABLE 3.1-23  
Modeled Maximum Impacts During Commissioning

| Pollutant         | Averaging Period | Maximum Predicted Impact (µg/m <sup>3</sup> ) | Background Concentration (µg/m <sup>3</sup> ) | Total Concentration <sup>a</sup> (µg/m <sup>3</sup> ) | NAAQS (µg/m <sup>3</sup> ) | CAAQS (µg/m <sup>3</sup> ) |
|-------------------|------------------|---|---|---|----------------------------|----------------------------|
| NO <sub>2</sub>   | 1-hr             | 66.1  | 184.2   | 250.3   | —                          | 339                        |
|                   | Fed. 1-hour      | <sup>b</sup>                                  | 129.7 <sup>d</sup>                            | —   | 188                        | —                          |
|                   | Annual           | <sup>c</sup>                                  | 24.5  | —   | 100                        | 57                         |
| SO <sub>2</sub>   | 1-hr             | <sup>c</sup>                                  | 67.6  | —   | 196                        | 655                        |
|                   | 3-hr             | <sup>c</sup>                                  | 41.6  | —   | 1300                       | —                          |
|                   | 24-hr            | <sup>c</sup>                                  | 15.8  | —   | —                          | 105                        |
| CO                | 1-hr             | 797.4   | 3,250   | 4,047   | 40,000                     | 23,000                     |
|                   | 8-hr             | 654.9   | 2,433   | 3,088   | 10,000                     | 20,000                     |
| PM <sub>10</sub>  | 24-hr            | 1.8   | 52  | 54  | 150                        | 50                         |
|                   | Annual           | <sup>c</sup>                                  | 25.6  | —   | —                          | NA                         |
| PM <sub>2.5</sub> | 24-hr            | 1.8   | 30  | 32  | 35                         | —                          |
|                   | Annual           | <sup>c</sup>                                  | 12.8  | —   | NA                         | NA                         |

<sup>a</sup>The total concentration shown in this table is the sum of the maximum predicted impact and the maximum measured background concentration. Because the maximum impact will not occur at the same time as the maximum background concentration, the actual maximum combined impact will be lower.

<sup>b</sup>Not applicable, because commissioning is a once in a lifetime event and is thus not applicable to the form of the 1-hr NO<sub>2</sub> NAAQS.

<sup>c</sup>Not applicable, because emissions for this pollutant/averaging period are not elevated above normal levels during commissioning.

<sup>d</sup>Background concentration for Federal 1-hour standard is 3-year average of 98<sup>th</sup> percentile of daily maximum 1-hour average concentration.

Table 3.1-23 shows that commissioning emissions will not cause new exceedances of any state or federal air quality standards (because commissioning is a temporary activity lasting a few weeks at most, the annual standards are not applicable). The table shows that worst-case background concentrations of PM<sub>10</sub> are already above the state standard, although they are below the federal standard. However, the project's 24-hour PM<sub>10</sub> impacts are lower than the federal significance threshold of 5 µg/m<sup>3</sup> (see Table 3.1-12). This means that the project's commissioning emissions will not contribute significantly to existing concentrations.

The project's commissioning emissions will not result in potentially significant air quality impacts.

### 3.1.4.15 Normal Operations Impact Analysis

#### Screening Modeling Analysis

To ensure the impacts analyzed were for maximum emission levels and worst-case dispersion conditions, a screening procedure was used to determine the inputs to the impact modeling for the new gas turbines. The screening procedure is used to identify the CTG operating conditions that would result in the maximum impacts on a pollutant-specific basis. The operating conditions examined in this screening analysis, along with their exhaust and emission characteristics, are shown in Appendix 3.1B, Table 3.1B-1. These operating conditions represent CTG operation at maximum, average, and minimum ambient temperatures, and at full load and minimum load (50 percent).

Ambient impacts for each of the operating cases were modeled using EPA's AERMOD model and three years of meteorological data, as described above. The results of the unit impact analysis are presented in Appendix 3.1B, Table 3.1B-2. The analysis showed that, except for PM<sub>10</sub>, impacts for all pollutants and averaging periods were highest under cold temperature, peak load operating conditions for the GE turbine, and mild temperature, base load operating conditions for the Trent turbines; for PM<sub>10</sub>, impacts were highest under cold temperature, low load operating conditions for the GE turbine, and under hot temperature, low load conditions for the Trent turbines.

#### Refined Analysis

The screening modeling analysis described above was used to determine which CTG operating parameters (emission rates and stack parameters) would be used in the subsequent refined analyses. Maximum modeled impacts from the gas turbines occur under different meteorological conditions and thus the worst-case conditions for both turbine types cannot occur simultaneously. However, the refined analysis assumed worst-case ambient conditions for both turbine types to ensure that the analysis was extremely conservative.

The techniques used in modeling one-hour average NO<sub>2</sub> concentrations were described in detail in the modeling protocol (See Appendix 3.1C) and as refined through additional conversations with and comments from the District staff. Compliance with the federal one-hour average NO<sub>2</sub> standard is demonstrated using Tier 9 of the options described in the protocol: the five-year average of the sum of the modeled 98<sup>th</sup> percentile value for each year and the Seasonal Hour-Of-Day (defined as the three-year average of the third-highest concentrations for each hour of the day and season). The seasonal hour-of-day values were provided by the District.

NO<sub>2</sub>/NO<sub>x</sub> ratios for the gas turbines were also reviewed and approved by the District. The ratios and their sources are summarized below in Table 3.1-24.

TABLE 3.1-24  
NO<sub>2</sub>/NO<sub>x</sub> Ratios Used in Refined Modeling

| Unit(s)                             | Operating Condition   | NO <sub>2</sub> /NO <sub>x</sub> Ratio | Reference   |
|-------------------------------------|-----------------------|--|---|
| GE turbine<br>(Unit 9)              | Normal                | 0.30                                   | GE  |
|                                     | startup/commissioning | 0.45                                   |   |
| Trent turbines<br>(Units 11 and 12) | Normal                | 0.13                                   | EPA's approved ratio for the Pio Pico Energy Center |
|                                     | startup/commissioning | 0.24                                   |   |

Listed below are the operating assumptions used in developing the stack parameters and emission rates for each emissions unit and averaging period for the refined modeling analysis.

*1-hour, 3-hour, 24-hour and annual averages (except PM<sub>10</sub>/PM<sub>2.5</sub>)*

- GE turbine at peak load, cold temperature; Trent turbines at base load, mild temperature
- Auxiliary boiler in operation at 25% load, annual averaging period only

### 24-hour and annual averages, $PM_{10}/PM_{2.5}$

- GE turbine at low load, cold temperature; Trent turbines at low load, hot temperature
- Auxiliary boiler in operation at 25% load, annual averaging period only

Because the gas turbines are expected to start up frequently, normal one-hour average operation was modeled assuming that one or more gas turbines would be in startup. Three startup scenarios were evaluated for the one-hour averaging period: Unit 9 in startup and Units 11 and 12 in normal operation; Units 11 and 12 in startup with Unit 9 in normal operation; and all three units in startup. The 8-hour averaging period was assumed to include one hour of startup for each of the three new gas turbines. Emission rates used for this scenario were based on expected maximum NO<sub>x</sub> and CO emission rates during gas turbine startups and shutdowns. Gas turbine exhaust parameters for minimum load operation were used to characterize gas turbine exhaust during startups/shutdowns. The modeling inputs used for this analysis are shown in Appendix 3.1B, Table 3.1B-3. The results of this analysis are shown below in Table 3.1-25.

TABLE 3.1-25

#### Modeling Results for New Units ( $\mu\text{g}/\text{m}^3$ )

| Pollutant                           | Averaging Period            | Normal Operation   | Fumigation–Inversion | Fumigation–Shoreline | Commissioning     |
|-------------------------------------|-----------------------------|--------------------|----------------------|----------------------|-------------------|
| NO <sub>2</sub>                     | 1-hr                        | 25.1 <sup>a</sup>  | 2.7                  | 16.9                 | 66.1 <sup>d</sup> |
|                                     | 98 <sup>th</sup> percentile | 23.1 <sup>a</sup>  | —                    | —                    |                   |
|                                     | Annual                      | 0.5                | b                    | b                    | c                 |
| SO <sub>2</sub>                     | 1-hr                        | 1.2                | 1.0                  | 4.5                  |                   |
|                                     | 3-hr                        | 0.8                | 0.9                  | 2.3                  | c                 |
|                                     | 24-hr                       | 0.3                | 0.4                  | 0.4                  |                   |
| CO                                  | 1-hr                        | 109.0 <sup>a</sup> | 2.0                  | 12.4                 | 797.4             |
|                                     | 8-hr                        | 12.2 <sup>a</sup>  | 1.3                  | 2.6                  | 654.9             |
| PM <sub>10</sub> /PM <sub>2.5</sub> | 24-hr                       | 1.2                | 1.1                  | 1.4                  | 1.8               |
|                                     | Annual                      | 0.3                | b                    | b                    | c                 |

<sup>a</sup>One-hour average NO<sub>2</sub> and CO and 8-hour average CO reflect startup impacts.

<sup>b</sup>Not applicable, because inversion breakup is a short-term phenomenon and as such is evaluated only for short-term averaging periods.

<sup>c</sup>Not applicable, because emissions are not elevated above normal levels during commissioning for this pollutant/averaging period.

<sup>d</sup>Commissioning not included in evaluation of compliance with federal 1-hour standard because commissioning is a once in a lifetime event and is thus not applicable to the form of the 1-hr NO<sub>2</sub> NAAQS.

### 3.1.4.16 Specialized Modeling Analyses.

**Fumigation Modeling.** Fumigation occurs when a stable layer of air lies a short distance above the release point of a plume and unstable air lies below. Under these conditions, an exhaust plume may be drawn to the ground, causing high ground-level pollutant concentrations. Although fumigation conditions rarely last as long as one hour, relatively high ground-level concentrations may be reached during that time. For this analysis, fumigation was assumed to occur for up to 90 minutes, per EPA guidance.

The SCREEN3 model was used to evaluate maximum ground-level concentrations for short-term averaging periods (24 hours or less). Although this modeling analysis is not required by SCAQMD regulations, guidance from the EPA was followed in evaluating fumigation impacts. The results of this analysis are shown in Table 3.1-25. The modeling files for this analysis are included in the modeling CD.

**Gas Turbine Commissioning.** There are several high-emissions scenarios possible during the gas turbine commissioning period. Maximum hourly emissions occur during the period prior to oxidation catalyst/SCR system installation, when the combustor is being tuned. During this commissioning phase, NO<sub>x</sub> emissions will be high because the SCR system is not installed/functioning and because the combustor will not be tuned for optimum performance. CO emissions will also be high because the oxidation catalyst system is not installed/functioning and

because the combustor performance will not be optimized. Commissioning activities and expected emissions are shown in detail in Appendix 3.1E. Gas turbine exhaust parameters for minimum load operation were used to characterize gas turbine exhaust during commissioning activities. The maximum hourly NO<sub>x</sub> and CO emission rates during the commissioning period were also used for this modeling analysis. It was assumed that any auxiliary boiler operation during the highest-emitting gas turbine commissioning activities would be minimal so the auxiliary boiler is not included in the impact assessment for commissioning. The modeling inputs used for this analysis are shown in Appendix 3.1B, Table 3.1B-4. The results of this analysis are shown in Table 3.1-25. The modeling files for this analysis are included in the modeling CD.

**Results of the Ambient Air Quality Modeling Analyses for New Units.** The maximum impacts for the new gas turbines and auxiliary boiler—calculated from the refined, fumigation, startup/shutdown, and commissioning modeling analyses described above—are summarized in Table 3.1-25. The modeling files for this analysis are included in the modeling CD.

**Results of the Ambient Air Quality Modeling Analyses for Entire Facility.** The maximum impacts for the new gas turbines and auxiliary boiler, along with the maximum impacts for the gas turbine Units 5 and 7, are summarized in Table 3.1-26. Maximum impacts for all pollutants occur under commissioning conditions. However, commissioning is not included in the evaluation of compliance with the federal 1-hour NO<sub>2</sub> standard because that standard is based on a three-year averaging period and commissioning will not continue for three years.

The modeling inputs used to characterize the emissions from Units 5 and 7 under normal operating conditions and under startup conditions are shown in Appendix 3.1B, Tables 3.1B-5 and 3.1B-6, respectively. The modeling files for this analysis are included in the modeling CD.

TABLE 3.1-26  
Modeling Results for Entire Facility ( $\mu\text{g}/\text{m}^3$ )

| Pollutant                           | Averaging Period            | Maximum Modeled Concentration, $\mu\text{g}/\text{m}^3$ |                   |                    |
|-------------------------------------|-----------------------------|---|-------------------|--------------------|
|                                     |                             | Units 9, 11 and 12                                      | Units 5 and 7     | All Units          |
| NO <sub>2</sub>                     | 1-hr                        | 66.1 <sup>a</sup>                                       | 21.0 <sup>c</sup> | 67.3 <sup>d</sup>  |
|                                     | 98 <sup>th</sup> percentile | 23.1 <sup>c</sup>                                       | 17.9 <sup>c</sup> | 63.9 <sup>c</sup>  |
|                                     | Annual                      | 0.5   | 0.1               | 0.6                |
| SO <sub>2</sub>                     | 1-hr                        | 4.5 <sup>b</sup>  | 3.1 <sup>b</sup>  | 7.5 <sup>b</sup>   |
|                                     | 3-hr                        | 2.3 <sup>b</sup>  | 0.8 <sup>b</sup>  | 3.1 <sup>b</sup>   |
|                                     | 24-hr                       | 0.4 <sup>b</sup>  | 0.1 <sup>b</sup>  | 0.5 <sup>b</sup>   |
| CO                                  | 1-hr                        | 797.5 <sup>a</sup>                                      | 51.5 <sup>c</sup> | 849.0 <sup>d</sup> |
|                                     | 8-hr                        | 654.9 <sup>a</sup>                                      | 37.8 <sup>c</sup> | 692.7 <sup>d</sup> |
| PM <sub>10</sub> /PM <sub>2.5</sub> | 24-hr                       | 1.8 <sup>a</sup>  | 0.4 <sup>d</sup>  | 2.2 <sup>d</sup>   |
|                                     | Annual                      | 0.3   | 0.1               | 0.4                |

<sup>a</sup> Maximum impacts occur under commissioning conditions.

<sup>b</sup> Maximum impacts occur under shoreline fumigation conditions.

<sup>c</sup> Reported impacts reflect startup conditions.

<sup>d</sup> Units 9, 11 and 12 in commissioning, Units 5 and 7 in startup. No auxiliary boiler operation assumed; see text.

**Ambient Air Quality Impact Analyses for New Units and Entire Facility.** To determine a project's air quality impacts, the modeled concentrations are added to the maximum background ambient air concentrations and then compared to the applicable ambient air quality standards. To determine the background ambient air concentrations for a project site, it is necessary to review data collected at nearby monitoring stations. Background ambient air quality data for the project area from the monitoring site most representative of the conditions that exist at the proposed project site were used to represent regional background concentrations. The District has approved the use of background data from the LAX monitoring station (Westchester Parkway) as

representative of background ambient air quality for PM<sub>10</sub>, NO<sub>2</sub>, SO<sub>2</sub> and CO in the project area. The North Long Beach Station is the nearest representative monitoring station for PM<sub>2.5</sub> observations.

The District has approved the three-year period 2009-2011 for use in demonstrating compliance with District requirements; the same 3-year period is used to address CEC requirements. Maximum monitored background concentrations for each year and over the three-year period are summarized in Table 3.1-27.

TABLE 3.1-27  
Maximum Background Concentrations, 2009 – 2011 (µg/m<sup>3</sup>)

| Pollutant                      | Averaging Period         | 2009  | 2010  | 2011  | Maximum |
|--------------------------------|--------------------------|-------|-------|-------|---------|
| NO <sub>2</sub> <sup>a</sup>   | 1-hour                   | 144.8 | 142.9 | 184.2 | 184.2   |
|                                | Fed. 1-hour <sup>c</sup> | 129.7 | 114.7 | 122.2 | 129.7   |
|                                | Annual                   | —     | 22.6  | 24.5  | 24.5    |
| SO <sub>2</sub> <sup>a</sup>   | 1-hour                   | 57.2  | 67.6  | 31.2  | 67.6    |
|                                | Fed. 1-hour <sup>d</sup> | 31.2  | 41.6  | 20.8  | 41.6    |
|                                | 24-hour                  | 15.8  | 10.5  | 5.3   | 15.8    |
| CO <sup>a</sup>                | 1-hour                   | 3,250 | 3,250 | 2,875 | 3,250   |
|                                | 8-hour                   | 2,211 | 2,433 | 3,377 | 2,433   |
| PM <sub>10</sub> <sup>a</sup>  | 24-hour                  | 52    | 37    | 41    | 52      |
|                                | Annual                   | 25.6  | 20.6  | 21.7  | 25.6    |
| PM <sub>2.5</sub> <sup>b</sup> | 24-hour <sup>e</sup>     | 34    | 28    | 28    | 30      |
|                                | Annual                   | 12.8  | 10.4  | 11.3  | 12.8    |

<sup>a</sup>LAX (Westchester Parkway) monitoring station.

<sup>b</sup>North Long Beach monitoring station.

<sup>c</sup>Federal 1-hour NO<sub>2</sub> is shown as the 98<sup>th</sup> percentile as that is the basis of the federal standard.

<sup>d</sup>Federal 1-hour SO<sub>2</sub> is shown as the 99<sup>th</sup> percentile as that is the basis of the federal standard.

<sup>e</sup>PM<sub>2.5</sub> 24-hr average concentrations shown are 98<sup>th</sup> percentile values rather than highest values because compliance with the standard is based on 98<sup>th</sup> percentile readings. Maximum value is 3-year average of the 98<sup>th</sup> percentile values.

Source: Background concentration data obtained from CARB ADAM Air Quality Data Statistics (<http://www.arb.ca.gov/adam/welcome.html>) and EPA AirData ([http://www.epa.gov/airdata/ad\\_rep\\_mon.html](http://www.epa.gov/airdata/ad_rep_mon.html))

Maximum ground-level impacts due to operation of the new gas turbines and auxiliary boiler were shown above in Table 3.1-27. These maximum modeled concentrations are combined with background ambient concentrations and compared with the state and federal ambient air quality standards in Table 3.1-28. The results indicate that the proposed new units will not cause or contribute to violations of any state or federal air quality standards, with the exception of the state PM<sub>10</sub> standard and state and federal PM<sub>2.5</sub> standards. For these pollutants, existing concentrations already exceed the applicable standards.



TABLE 3.1-28  
**Modeled Maximum Impacts for New Units ( $\mu\text{g}/\text{m}^3$ )**

| Pollutant         | Averaging Period            | Maximum Impact     | Background         | Total Impact       | State Standard | Federal Standard |
|-------------------|-----------------------------|--------------------|--------------------|--------------------|----------------|------------------|
| NO <sub>2</sub>   | 1-hr                        | 66.1 <sup>a</sup>  | 184.2              | 250.3              | 339            | —                |
|                   | 98 <sup>th</sup> percentile | 23.1 <sup>c</sup>  | 109.6 <sup>c</sup> | 120.7 <sup>f</sup> | —              | 188              |
|                   | Annual                      | 0.5                | 24.5               | 25.0               | 57             | 100              |
| SO <sub>2</sub>   | 1-hr                        | 4.5 <sup>b</sup>   | 67.6               | 72.1               | 655            | 196              |
|                   | 3-hr                        | 2.3 <sup>b</sup>   | 67.6 <sup>d</sup>  | 69.9               | —              | 1300             |
|                   | 24-hr                       | 0.4 <sup>b</sup>   | 15.8               | 16.2               | 105            | —                |
| CO                | 1-hr                        | 797.5 <sup>a</sup> | 3,250              | 4,048              | 23,000         | 40,000           |
|                   | 8-hr                        | 654.9 <sup>a</sup> | 2,433              | 3,088              | 10,000         | 10,000           |
| PM <sub>10</sub>  | 24-hr <sup>e</sup>          | 1.8 <sup>a</sup>   | 52                 | 53.8               | 50             | 150              |
|                   | Annual                      | 0.3                | 25.6               | 25.9               | 20             | —                |
| PM <sub>2.5</sub> | 24-hr                       | 1.8 <sup>a</sup>   | 30 <sup>e</sup>    | 31.8               | —              | 35               |
|                   | Annual                      | 0.3                | 12.8               | 13.1               | 12             | 12.0             |

<sup>a</sup>Maximum impacts occur under commissioning conditions.

<sup>b</sup>Maximum impacts occur under fumigation conditions.

<sup>c</sup>Maximum impacts occur under startup conditions; background value is seasonal hour-of-day. See text.

<sup>d</sup>CARB no longer publishes 3-hour average SO<sub>2</sub> concentrations, so 1-hour average background is used as conservative estimate of 3-hour average background.

<sup>e</sup>Background concentration reflects 3-year average of the 98<sup>th</sup> percentile values based on form of standard. See 3.1-28

<sup>f</sup>Total impact is the five-year average of the sum of the modeled 98<sup>th</sup> percentile value for each year and the Seasonal Hour-Of-Day background (defined as the three-year average of the third-highest concentrations for each hour of the day and season), so values do not add directly.

Maximum ground-level impacts due to operation of the new units (gas turbine Units 9, 11 and 12 and the auxiliary boiler) in combination with gas turbine Units 5 and 7 are shown in Table 3.1-26. As with the analysis above, these maximum modeled concentrations are combined with background ambient concentrations and compared with the state and federal ambient air quality standards in Table 3.1-29. The results indicate that the proposed project will not cause or contribute to violations of any state or federal air quality standards, with the exception of the state PM<sub>10</sub> standard and state and federal PM<sub>2.5</sub> standards. For these pollutants, existing concentrations already exceed the applicable standards.

TABLE 3.1-29  
**Modeled Maximum Impact for Entire Facility ( $\mu\text{g}/\text{m}^3$ )**

| Pollutant         | Averaging Period            | Maximum Impact     | Background        | Total Impact | State Standard | Federal Standard |
|-------------------|-----------------------------|--------------------|-------------------|--------------|----------------|------------------|
| NO <sub>2</sub>   | 1-hr                        | 67.3 <sup>a</sup>  | 184.2             | 252.0        | 339            | —                |
|                   | 98 <sup>th</sup> percentile | 63.9 <sup>b</sup>  | 129.7             | 150.6        | —              | 188              |
|                   | Annual                      | 0.6                | 24.5              | 25.1         | 57             | 100              |
| SO <sub>2</sub>   | 1-hr                        | 7.5 <sup>c</sup>   | 67.6              | 75.1         | 655            | 196              |
|                   | 3-hr                        | 3.1 <sup>c</sup>   | 67.6 <sup>d</sup> | 70.7         | —              | 1300             |
|                   | 24-hr                       | 0.5 <sup>c</sup>   | 15.8              | 16.3         | 105            | —                |
| CO                | 1-hr                        | 849.0 <sup>a</sup> | 3,250             | 4,099        | 23,000         | 40,000           |
|                   | 8-hr                        | 692.7 <sup>a</sup> | 2,433             | 3,126        | 10,000         | 10,000           |
| PM <sub>10</sub>  | 24-hr <sup>e</sup>          | 2.2 <sup>a</sup>   | 52                | 54.2         | 50             | 150              |
|                   | Annual                      | 0.4                | 25.6              | 26.0         | 20             | —                |
| PM <sub>2.5</sub> | 24-hr                       | 2.2 <sup>a</sup>   | 30 <sup>e</sup>   | 32.2         | —              | 35               |
|                   | Annual                      | 0.4                | 12.8              | 13.2         | 12             | 12               |

<sup>a</sup> Units 9, 11 and 12 in commissioning, Units 5 and 7 in startup. No auxiliary boiler operation assumed; see text.

<sup>b</sup> Reported impacts reflect startup conditions.

<sup>c</sup> Maximum impacts occur under shoreline fumigation conditions.

<sup>d</sup> CARB no longer publishes 3-hour average SO<sub>2</sub> concentrations, so 1-hour average background is used as conservative estimate of 3-hour average background.

<sup>e</sup> Background concentration reflects 3-year average of the 98<sup>th</sup> percentile values based on form of standard. See 3.1-28.

### Additional Requirements

Because the project is subject to PSD review for NO<sub>2</sub> and CO (see Table 3.1-32), the project ambient air quality impacts must be below the PSD significant impact levels and applicable preconstruction monitoring thresholds for these pollutants or an increments analysis and/or preconstruction monitoring may be required. In addition, because PM<sub>10</sub> background concentrations are above state standards, maximum modeled PM10 impacts from each unit must be below the significant change thresholds in Table A-2 of SCAQMD Rule 1303. Compliance with these additional ambient impact requirements is shown below in Tables 3.1-30 and 3.1-31 below. These results show that the annual NO<sub>2</sub> and all CO emissions impacts are below the PSD SILs and preconstruction monitoring thresholds, and the PM<sub>10</sub> impacts are below the District significant change thresholds. However, the one-hour NO<sub>2</sub> impacts exceed the applicable NO<sub>2</sub> PSD SIL, so an increments analysis will be required. A separate protocol will be prepared for the NO<sub>2</sub> increments analysis.

TABLE 3.1-30  
**Comparison of Modeled Maximum Project Impacts with PSD SILs and Preconstruction Monitoring Thresholds ( $\mu\text{g}/\text{m}^3$ )**

| Pollutant       | Averaging Period | Maximum Impact | PSD SIL | PSD Preconstruction Monitoring Threshold |
|-----------------|------------------|----------------|---------|--|
| NO <sub>2</sub> | 1-hr             | 23.1*          | 7.5     | n/a                                      |
|                 | Annual           | 0.5            | 1.0     | 14                                       |
| CO              | 1-hr             | 109.0          | 2000    | n/a                                      |
|                 | 8-hr             | 12.2           | 500     | 575                                      |

\*Reported results reflect startup conditions.

TABLE 3.1-31

**Comparison of Modeled Project Impacts with District Significant Change Thresholds ( $\mu\text{g}/\text{m}^3$ )**

| Equipment        | 24-hour Average $\text{PM}_{10}$ Concentration | 24-hour Average $\text{PM}_{10}$ Significance Level | Annual $\text{PM}_{10}$ Concentration | Annual $\text{PM}_{10}$ Significance Level | Compliance (Yes/No) |
|------------------|--|---|---------------------------------------|--|---------------------|
| Unit 9           | 0.79*  | 2.5   | 0.23                                  | 1.0  | Yes                 |
| Unit 11          | 0.66*  | 2.5   | 0.24                                  | 1.0  | Yes                 |
| Unit 12          | 0.66*  | 2.5   | 0.24                                  | 1.0  | Yes                 |
| Auxiliary Boiler | 0.3  | 2.5   | 0.09                                  | 1.0  | Yes                 |

\*Maximum impacts occur under commissioning conditions.

### 3.1.5 Cumulative Air Quality Impacts

Two types of cumulative air quality impact analyses are often conducted in association with power plant projects: a CEQA analysis and a PSD analysis.

A CEQA cumulative impacts analysis examines potential cumulative air quality impacts that may result from the project and other reasonably foreseeable projects. Such an analysis is generally required only when project impacts are significant. To ensure that potential cumulative impacts of the project and other nearby projects are adequately considered, a cumulative impacts analysis has been conducted in accordance with the protocol included as Appendix 3.1C. The analysis demonstrates that the project will not cause or contribute to any significant cumulative air quality impacts.

The second type of cumulative impact analysis is part of the PSD review process, and is designed to ensure that industrial facilities that have the potential to cause locally elevated concentrations of air contaminants are adequately considered when determining the project's potential to cause or contribute to a violation of a federal air quality standard.

#### 3.1.5.1 Nearby Sources

##### 3.1.5.1.1 CEQA Cumulative Impacts Analysis

The CEC requires an analysis to determine the cumulative impacts of the project and other projects within a 6-mile radius that have received construction permits, but are not yet operational or that are in the permitting process or can be expected to be so in the near future. The District provided a list of such projects (see Appendix 3.1H).

The District's Facility Information Detail (FIND) database was used to identify additional information about the nearby projects on the District's list. All of the projects listed by the District were eliminated from further review for one or more of the reasons listed below.

- Source emissions of both  $\text{NO}_x$  and  $\text{PM}$  below 5 TPY
- Project was change of ownership
- Project was administrative
- Project was change of conditions—associated emission increase below 5 TPY

##### 3.1.5.1.2 PSD Cumulative Analysis

The project's impact area (the geographical area where modeling indicates that project impacts may exceed the  $\text{NO}_x$  SIL of  $7.5 \mu\text{g}/\text{cu m}$ ) is a small, nearly circular area 1.5 km in radius centered on the turbine stacks. Half this circle is in the ocean; the other half extends halfway into the neighboring refinery (encompassing the tank farm, and just reaching the process units 1.5 km to the east); and just extending to include the Scattergood Generating Station.

Because of the size of the compliance margin (the difference between the facility impact, as shown in Table 3.1-29, and the federal standard), the impact gradient of the Scattergood Generating Station within the ESPFM's impact area is not expected to be significant enough to justify cumulative modeling.

### 3.1.5.2 Regional Impacts

Regional impacts are evaluated by assessing the project's contribution to regional emissions. Although the relative importance of VOC and NO<sub>x</sub> emissions in ozone formation differs from region to region and from day to day, state law requires reductions in emissions of both precursors to reduce overall ozone levels. The change in the sum of emissions of these pollutants, equally weighted, provides a rough estimate of the impact of the project on regional ozone levels. Similarly, a comparison of the emissions of PM<sub>10</sub> and PM<sub>2.5</sub> precursor emissions from the project with regional PM<sub>10</sub> and PM<sub>2.5</sub> precursor emissions provides an estimate of the impact of the project on regional PM<sub>10</sub> and PM<sub>2.5</sub> levels.

Table 3.1-32 summarizes these comparisons. The project's emissions are compared with regional emissions in 2010. South Coast Air Basin emissions projections for 2010 were taken from CARB's web-based emission inventory projection software.

TABLE 3.1-32

#### Comparison of Project Emissions to Regional Precursor Emissions in 2010: Annual Basis\*

##### Ozone Precursors – Annual Basis

|   |         |
|---|---------|
| Total South Coast Air Basin Ozone Precursors, tons/year | 522,388 |
| Total Project Ozone Precursor Emission, tons/year       | 127     |
| Ratio of Project to Basin Ozone Precursor Emissions     | 0.0002  |

##### PM<sub>10</sub> Precursors – Annual Basis

|  |         |
|--|---------|
| Total South Coast Air Basin PM <sub>10</sub> Precursors, tons/year | 416,210 |
| Total Project PM <sub>10</sub> Precursor Emissions, tons/year      | 151     |
| Ratio of Project to Basin PM <sub>10</sub> Precursor Emissions     | 0.0004  |

##### PM<sub>2.5</sub> Precursors – Annual Basis

|   |         |
|---|---------|
| Total South Coast Air Basin PM <sub>2.5</sub> Precursors, tons/year | 350,327 |
| Total Project PM <sub>2.5</sub> Precursor Emissions, tons/year      | 151     |
| Ratio of Project to Basin PM <sub>2.5</sub> Precursor Emissions     | 0.0004  |

\*Basin-wide emissions calculated as 365 times daily emissions

### 3.1.5.3 Greenhouse Gas Cumulative Effects Analysis

In the absence of established thresholds of significance or methodologies for assessing impacts, this analysis of GHG emission impacts consists of quantifying project-related GHG emissions, determining their significance in comparison to the goals of AB 32, and discussing the potential impacts of climate change within the state as well as strategies for minimizing those impacts.

As the CEC's 2009 Integrated Energy Policy Report<sup>5</sup> noted:

*The Energy Commission's 'Framework for Evaluating Greenhouse Gas Implications of Natural Gas-Fired Power Plants in California' found that as California's integrated electricity system evolves to meet GHG emissions reduction targets, the operational characteristics associated with increasing renewable generation will increase the need for flexible generation to maintain grid reliability. The report asserts that natural gas-fired power plants are generally well-suited for this role and that California cannot simply replace all natural gas fired power plants with renewable energy without endangering the safety and reliability of the electric system. The report acknowledges that California will need to modernize its natural gas generating fleet to reduce environmental impacts, however. Overall, the report found that the future*

<sup>5</sup> CEC-100-2009-003-CMF, December 5, 2007, accessed at <http://www.energy.ca.gov/2009publications/CEC-100-2009-003/CEC-100-2009-003-CMF.PDF>

*of natural gas plants will likely fill five auxiliary roles: 1) intermittent generation support, 2) local capacity requirements, 3) grid operations support, 4) extreme load and system emergencies support, and 5) general energy support. The question remains as to the quantity, type, and location of natural gas-fired generation to fill remaining electricity needs once preferred resource targets are achieved. (p. 110)*

Most renewable energy facilities such as wind and solar are “intermittent resources,” meaning these resources are not available to generate in all hours and thus have limited operating capacity. For example, intermittent resources can be limited by meteorological conditions on an hourly, daily, and seasonal basis. Further, most renewable resources have no ability to provide regulation—the ability to ramp up and down quickly at the system operator’s direction to ensure electric system reliability. In addition, the availability of intermittent resources is often unrelated to the load profile they serve. For example, some photovoltaic resources reach peak production around 12:00 noon, while the electrical demand sometimes peaks between 5:00 p.m. and 7:00 p.m.

“Firming” involves the use of fast-starting, flexible generation that is always available under all operating conditions to ramp up or ramp down, as necessary, to balance load and generation. Firming power is the cornerstone of system reliability. Thus, in the context of the California Environmental Quality Act, the CEC’s Integrated Energy Policy Report, and other state GHG policy documents, the project would not be expected to cause a significant cumulative impact with respect to GHGs. Instead, the project supports the State’s strategy to reduce fuel use and GHG emissions. Furthermore, even though it is possible to quantify how many gross GHG emissions are attributable to a project, the displacement by the project of emissions from less efficient generating resources makes it difficult to determine whether this will result in a net increase of these emissions, and, if so, by how much. Therefore, it would be speculative to conclude that any given project results in a cumulatively significant adverse impact resulting from GHG emissions.

The project can be operated without the limitations affecting intermittent renewable resources. The project will provide fast-starting, flexible generating resources that will supplement and support intermittent renewable resources without affecting electric system reliability. Accordingly, as a fast-starting, flexible generating resource, ESPFM will enhance the reliability of existing and future intermittent renewable resources and thus further California’s RPS and GHG goals.

As directed by SB 97, the Resources Agency adopted Amendments to the CEQA Guidelines for greenhouse gas emissions (GHG CEQA Guidance) on December 30, 2009. On March 18, 2010, those amendments became effective.

The GHG CEQA Guidance included the following elements:

- Quantification of GHG emissions;
- Determination of whether the project may increase or decrease GHG emissions as compared to existing environmental setting;
- Determination of whether the project emissions exceed a threshold of significance determined by the lead agency;
- The extent to which the project complies with state, regional, or local plans for reduction or mitigation of GHGs; and
- Mitigation measures.

Certain GHG reduction strategies will require increases in natural gas consumption; for example, some fraction of electric generation from coal-fired power plants will need to be replaced by natural gas fired generation. As the 2007 IEPR and a 2009 CEC Siting Committee Report<sup>6</sup> acknowledged, “new gas-fired power plants are more efficient than older power plants, and they displace these older facilities in the dispatch order.” The CEC’s 2009

<sup>6</sup> CEC-700-2009-004, “Committee Guidance on Fulfilling California Environmental Quality Act Responsibilities for Greenhouse Gas Impacts In Power Plant Siting Applications,” March 2009.

Framework report<sup>7</sup> further discussed the role of new gas-fired power plants in displacing GHG emissions, and furthering the State's efforts to reduce GHG emissions. The 2009 Framework report concludes that as California expands renewable energy generation to achieve its GHG emissions reduction goals, it cannot simply retire natural-gas fired power plants: rather, new natural-gas fired power plants may be needed.

Net GHG emissions for the integrated electric system will decline when new gas-fired power plants are added that (1) serve load growth or capacity needs more efficiently than the existing fleet; (2) improve the overall efficiency of the electric system; and/or (3) permit increased penetration of renewable generation.<sup>8</sup> Because of its location and operational characteristics, ESPFM will contribute to the reduction of GHG emissions because it will achieve all of these goals.

In the Presiding Member's Proposed Decision for the Avenal Energy Project (CEC-800-2009-006-PMPD), the Committee has established a three-part test to ensure that new natural gas fired power plants approved by the CEC will support the goals and policies of AB 32 and the related parts of California's GHG framework. The elements of this test are listed below.

- (1) The project must not increase the overall system heat rate for natural gas plants.
- (2) The project must not interfere with generation from existing renewable facilities nor with the integration of new renewable generation.
- (3) Taking into account the factors listed in (1) and (2), the project must reduce system-wide GHG emissions and support the goals and policies of AB 32.

As a fast-starting, highly efficient facility, ESPFM will meet all three of these criteria. The proposed combined cycle unit would have a net heat rate of approximately 7,670 Btu/kWh (HHV), which leads to an estimated GHG emission rate of 0.407 MT CO<sub>2</sub>/MWh. The project's capability for fast response will provide firming capability that will support the integration of new renewable generation. By displacing older, less efficient units, the project will reduce system-wide GHG emissions.

### 3.1.6 Consistency with Laws, Ordinances, Regulations, and Standards

This section considers consistency separately for federal, state, and local requirements.

#### 3.1.6.1 Consistency with Federal Requirements

##### 3.1.6.1.1 Prevention of Significant Deterioration Program

The PSD requirements apply, on a pollutant-specific basis, to any project that is a new major stationary source or a major modification to an existing major stationary source. A major source is a listed facility (one of 28 PSD source categories listed in the federal Clean Air Act) that emits at least 100 TPY, or any other facility that emits at least 250 TPY. PSD also applies to a stationary source that emits more than 100,000 TPY of greenhouse gases (GHGs). ESGS is an existing major stationary source.

The project will be a major modification because emissions of some pollutants will exceed the PSD significant emission threshold. Table 3.1-33 shows the pollutants that will trigger PSD review.

<sup>7</sup> CEC-700-2009-009, "Framework for Evaluating Greenhouse Gas Implications of Natural Gas-Fired Power Plants in California," May 2009.

<sup>8</sup> Ibid.

TABLE 3.1-33  
PSD Significant Emission Thresholds

| Pollutant         | PSD Significant Emission Threshold (TPY) <sup>a</sup> | Project Emissions (TPY) | Significant? (Y/N) |
|-------------------|---|-------------------------|--------------------|
| SO <sub>2</sub>   | 40  | 6.5                     | N                  |
| PM <sub>10</sub>  | 15  | 51.1                    | N/A <sup>b</sup>   |
| PM <sub>2.5</sub> | 10  | 51.1                    | N/A <sup>b</sup>   |
| NO <sub>2</sub>   | 40  | 93.5                    | Y                  |
| CO                | 100   | 176.0                   | Y                  |
| GHGs              | 75,000  | 968,000                 | Y                  |
| Lead              | 0.6   | 0.0                     | N                  |

<sup>a</sup>40 CFR 51.165 (a)(1)(xxvii)

<sup>b</sup>The project area is a federal nonattainment area for these pollutants; PSD review does not apply.

PSD permits for major sources in the SCAQMD are issued by the District.

The PSD requirements for the subject pollutants are outlined below.

- Emissions of the PSD pollutants that trigger PSD review (NO<sub>x</sub>, CO and GHGs) will be controlled using BACT.
- Air quality impacts in combination with other increment-consuming sources must not exceed maximum allowable incremental increases for NO<sub>2</sub>.
- Air quality impacts of all sources in the area plus ambient pollutant background levels cannot exceed NAAQS.
- Pre- and/or post-construction air quality monitoring may be required.
- The air quality impacts on soils, vegetation, and nearby PSD Class I areas (specific national parks and wilderness areas) must be evaluated. (Note: The ESGS is located in a Class II area.)

#### 3.1.6.1.2 Nonattainment New Source Review

Nonattainment New Source Review jurisdiction has been delegated to the SCAQMD for all pollutants and is discussed further under local requirement conformance section below.

#### 3.1.6.1.3 National Standards of Performance for New Stationary Sources

Establishes national standards of performance to limit the emissions of criteria pollutants (air pollutants for which EPA has established NAAQS) from new or reconstructed facilities in specific source categories. Applicability of these regulations depends on equipment size, process rate, and date of construction. The proposed project will be subject to Subpart KKKK, Standards of Performance for Stationary Gas Turbines (constructed after February 18, 2005). This new source performance standard applies to gas turbines with a heat input in excess of 1 MMBtu/hr that commence construction after February 18, 2005, and is therefore applicable to the proposed project's gas turbines. Subpart KKKK limits NO<sub>x</sub> and SO<sub>2</sub> emissions from new gas turbines based on power output. The limits for gas turbines greater than 30 MW are 0.39 lb NO<sub>x</sub> per MW-hr and 0.58 lb SO<sub>2</sub> per MW-hr. The emission limits of proposed for this project are well below the Subpart KKKK limits, as shown in Table 3.1-34.

TABLE 3.1-34  
**Compliance with 40 CFR 60 Subpart KKKK**

| Pollutant          | Proposed Permit Limits |       |                | Subpart KKKK Limit, lb/MW-hr |
|--------------------|------------------------|-------|----------------|------------------------------|
|                    | ppmc                   | lb/hr | lb/MW-hr (max) |                              |
| <b>Unit 9</b>      |                        |       |                |                              |
| SO <sub>2</sub>    | 0.42                   | 5.0   | 0.017          | 0.58                         |
| NO <sub>2</sub>    | 2.0                    | 17.9  | 0.058          | 0.39                         |
| <b>Units 11/12</b> |                        |       |                |                              |
| SO <sub>2</sub>    | 0.42                   | 3.3   | 0.026          | 0.58                         |
| NO <sub>2</sub>    | 2.5                    | 4.8   | 0.11           | 0.39                         |

Compliance with the NSPS limits must be demonstrated through an initial performance test. Because the proposed project's gas turbines will be equipped with a continuous NOx emissions monitor, ongoing annual performance testing will not be required under the NSPS.

These standards are enforced at the local level with federal and state oversight.

#### 3.1.6.1.4 National Emission Standards for Hazardous Air Pollutants

Establishes national emission standards to limit emissions of hazardous air pollutants (HAPs, or air pollutants identified by EPA as causing or contributing to the adverse health effects of air pollution but for which NAAQS have not been established) from facilities in specific source categories. These standards are implemented at the local level with federal oversight. Only 40 CFR 63 Subpart YYY, the NESHAP for combustion turbines, which limits formaldehyde emissions from turbines located at major sources of HAPs, is potentially applicable to the proposed project.

The sources added by ESPFM have a PTE of 3.2 TPY of formaldehyde, and 8.4 TPY of total HAPS (see Table 3.1-19). When existing Units 5 and 7 operate after implementation of ESPFM there will be a combined PTE of 4.1 TPY of formaldehyde, and 10.4 TPY of total HAPS (Appendix M, *Application for a Determination of Compliance and Permit to Construct for the El Segundo Power Redevelopment Project* (June 2007)). Total post-project emissions of formaldehyde will be 7.3 TPY, and total HAPS will be 18.8 TPY. Therefore, the ESEC is not and will not be, a major source of HAPS and therefore this NESHAP is not applicable to the proposed ESPFM.

#### 3.1.6.1.5 Acid Rain Program

Requires the monitoring and reporting of emissions of acidic compounds and their precursors from combustion equipment owned by a utility. The principal source of these compounds is the combustion of fossil fuels. Therefore, Title IV established national standards to monitor, record, and, in some cases, limit SO<sub>2</sub> and NOx emissions from electrical power generating facilities. These standards are implemented at the local level with federal oversight. SCAQMD has received delegation authority to implement Title IV. ESPFM will comply with the acid rain program requirements and will file an acid rain permit application in accordance with the deadlines in SCAQMD Regulation XXXI.

#### 3.1.6.1.6 Title V Operating Permits Program

Requires the issuance of operating permits that identify all applicable federal performance, operating, monitoring, recordkeeping, and reporting requirements. Title V applies to major facilities, Phase II acid rain facilities, subject solid waste incinerator facilities, and any facility listed by EPA as requiring a Title V permit. SCAQMD has received delegation authority for this program. An application for an amendment to the facility Title V permit was filed on March 14, 2013.



### 3.1.6.2 Consistency with State Requirements

As discussed in Section 3.1.3.2, state law established local air pollution control districts and air quality management districts with the principal responsibility for regulating emissions from stationary sources. The proposed project is under the local jurisdiction of the SCAQMD; therefore, compliance with SCAQMD regulations will assure compliance with state air quality requirements.

#### 3.1.6.2.1 California Clean Air Act

AB 2595, the California Clean Air Act (CAA), was enacted by the California Legislature and became law in January 1989. The CAA requires the local air pollution control districts to attain and maintain both the federal and state ambient air quality standards at the “earliest practicable date.” The CAA contains several milestones for local districts and CARB. SCAQMD was required to submit to CARB an air quality plan, with updates as necessary, defining the program for meeting the required emission reduction milestones in the South Coast Air Basin.

Air quality plans must demonstrate attainment of the state ambient air quality standards and must result in a five percent annual reduction in emissions of nonattainment pollutants (ozone, PM10, PM2.5, and associated precursors) in a given district (H&SC §40914). A local district may adopt additional stationary source control measures or transportation control measures, revise existing source-specific or new source review rules, or expand its vehicle inspection and maintenance program (H&SC §40918) as part of the plan. District air quality plans specify the development and adoption of more stringent regulations to achieve the requirements of the Act. The applicable regulations that will apply to the project are included in the discussion of District prohibitory rules in Section 3.1.6.3.

#### 3.1.6.2.2 Greenhouse Gas Initiatives

In 2006, California enacted the California Global Warming Solutions Act of 2006 (AB 32). It requires the California Air Resources Board (CARB) to adopt standards that will reduce statewide GHG emissions to statewide GHG emissions levels in 1990, with such reductions to be achieved by 2020. To achieve this, CARB has a mandate to define the 1990 emissions level and achieve the maximum technologically feasible and cost-effective GHG emission reductions.

CARB adopted early action GHG reduction measures in October 2007 and established statewide emissions caps by economic “sectors” in 2008. CARB has adopted rules requiring quantification and reporting of GHG emissions. Finally, CARB has implemented a GHG Cap and Trade program, requiring facilities to purchase and surrender carbon allowances.

SB 1368, also enacted in 2006, and regulations adopted by the CEC and the Public Utilities Commission pursuant to the bill, prohibits utilities from entering into long-term commitments with any baseload facilities that exceed the Emission Performance Standard of 0.50 metric tonnes of CO<sub>2</sub> per megawatt-hour (1,100 pounds CO<sub>2</sub>/MWh). Specifically, the Emission Performance Standard (EPS) applies to base load power from new power plants, new investments in existing power plants, and new or renewed contracts with terms of 5 years or more, including contracts with power plants located outside of California.

The ESPFM CO<sub>2</sub> emission rate of 0.407 MT/MWh would meet the Emission Performance Standard of 0.50 MT/MWh.

#### *GHG Emissions During Project Construction*

Construction of the proposed power plant will involve the use of fuel-consuming equipment for construction and transportation and will produce greenhouse gas emissions. GHG emissions during construction are provided in Appendix 3.1D.

These small GHG emissions increases from construction activities will not be significant. The construction period is only about 20 months long, and the emissions will be intermittent during that period. Additionally, the mitigation measures proposed for the project (such as limiting idling times) will minimize GHG emissions during the construction phase of the project.

### *GHG Emissions During Project Operation*

In the absence of established thresholds of significance or methodologies for assessing impacts, this analysis of GHG emission impacts consists of quantifying project-related GHG emissions, determining their significance in comparison to the goals of AB 32, and discussing the potential impacts of climate change within the state as well as strategies for minimizing those impacts.

As the CEC's 2007 Integrated Energy Policy Report noted:

New natural gas-fueled electricity generation technologies offer efficiency, environmental, and other benefits to California, specifically by reducing the amount of natural gas used—and with less natural gas burned, fewer greenhouse gas emissions. Older combustion and steam turbines use outdated technology that makes them less fuel- and cost-efficient than newer, cleaner plants... The 2003 and 2005 IEPs noted that the state could help reduce natural gas consumption for electric generation by taking steps to retire older, less efficient natural gas power plants and replace or repower them with new, more efficient power plants. ( CEC-100-2007-008-CMF, December 5, 2007, p. 184)

The California Public Utilities Commission (CPUC) and CEC joint recommendations to CARB state that renewable integration will be a “cornerstone” of emission reductions. (*Final Opinion and Recommendation on Greenhouse Gas Regulatory Strategies*) Similarly, the CARB AB 32 scoping plan anticipates the implementation of a 33 percent Renewable Portfolio Standard (RPS) and includes the RPS as an emission reduction measure. (CARB, *Final AB 32 Scoping Plan*, December 2008).

Most renewable energy facilities such as wind and solar are “intermittent resources,” meaning these resources are not available to generate in all hours and thus have limited operating capacity. For example, intermittent resources can be limited by meteorological conditions on an hourly, daily, and seasonal basis. Further, most renewable resources have no ability to provide regulation, the ability to ramp up and down quickly at the system operator's direction to ensure electric system reliability. In addition, the availability of intermittent resources is often unrelated to the load profile they serve. For example, some photovoltaic resources reach peak production around 12:00 noon while the electric system typically peaks between 5:00 p.m. and 7:00 p.m.

The proposed turbines can be operated without the limitations affecting intermittent renewable resources. The proposed turbines will provide fast-starting, flexible generating resources that will assist SCE to firm intermittent renewable resources and thus integrate renewable resources into SCE's generation portfolio without affecting electric system reliability. The project will allow SCE to take advantage of renewable resources that are out on the market, but are volatile, from a system operations perspective, and require significant, flexible resources to firm its power for system reliability. Accordingly, as a fast-starting, flexible generating resource, the project will enhance the reliability of existing and future intermittent renewable resources and thus further SCE's RPS and GHG goals.

The project will help provide “firming” sources for SCE's existing and future intermittent renewable resources in support of SCE's RPS and GHG goals. “Firming” involves the use of fast-starting, flexible generation that is always available under all operating conditions to ramp up or ramp down, as necessary, to balance load and generation. Firming power is the cornerstone of system reliability. Thus, in the context of CEQA, the CEC's Integrated Energy Policy Report, and other state GHG policy documents, the project would not be expected to cause a significant cumulative impact. Instead, the project supports the state's strategy to reduce fuel use and GHG emissions. Further, even though it is possible to quantify how many gross GHG emissions are attributable to a project, it is difficult to determine whether this will result in a net increase of these emissions, and, if so, by how much. Therefore, it would be speculative to conclude that any given project results in a cumulatively significant adverse impact resulting from GHG emissions.

At this time, neither the state nor the AQMD has adopted thresholds of significance or methodologies for analyzing GHG emission impacts under CEQA. In the absence of adopted guidelines, projects may be judged on whether they will hinder the emission-reduction goals of AB 32.

Certain GHG reduction strategies will require increases in natural gas consumption; for example, some fraction of electric generation from coal-fired power plants will need to be replaced by natural gas-fired generation. Even though GHG emissions from a specific project can be quantified, it is difficult to determine whether operation of the project itself would result in a net increase or decrease of GHG emissions, much less to quantify the impact. Therefore, it would be speculative to conclude that any particular electricity generation project will result in a cumulatively significant adverse impact resulting from GHG emissions.

### 3.1.6.3 Consistency with Local Requirements

The SCAQMD has been delegated responsibility for implementing local, state, and federal air quality regulations in the South Coast Air Basin. The proposed project is subject to District regulations that apply to new stationary sources, to the prohibitory regulations that specify emission standards for individual equipment categories, and to the requirements for evaluation of impacts from non-criteria pollutants. Facility compliance with applicable District requirements is evaluated below.

#### 3.1.6.3.1 New Source Review Requirements

The SCAQMD's New Source Review (NSR) rule (Regulation XIII, New Source Review) establishes the criteria for siting new and modified emission sources; this rule is applicable to the proposed project. There are three basic requirements within the NSR rules. First, BACT and Lowest Achievable Emission Rate (LAER) requirements must be applied to any new emission unit with potential emissions above specified threshold quantities. Second, all potential emission increases of nonattainment pollutants or precursors from the proposed source above specified thresholds must be offset by real, quantifiable, surplus, permanent, and enforceable emission decreases in the form of ERCs. Third, an ambient air quality impact analysis must be conducted to confirm that the project does not cause or contribute to a violation of a national or California AAQS or jeopardize public health.

#### 3.1.6.3.2 BACT

A comparison of potential emissions with the BACT thresholds in SCAQMD Rule 1303 is presented in Table 3.1-35. This table shows that the proposed gas turbines are required to use best available control technology (BACT) for NO<sub>x</sub>, VOC, SO<sub>2</sub> and PM<sub>10</sub>. Emissions from the proposed auxiliary boiler are below the BACT threshold in the District's NSR rule.

TABLE 3.1-35  
Applicability of BACT Requirements Under NSR

| Pollutant                                    | BACT Threshold, lb/day | Unit Emissions, lb/day | BACT Required? |
|--|------------------------|------------------------|----------------|
| <b>Gas Turbine, Unit 9</b>                   |                        |                        |                |
| NO <sub>x</sub>                              | 0                      | 559.1                  | Yes            |
| VOC  | 0                      | 240.7                  | Yes            |
| SO <sub>2</sub>                              | 0                      | 124.8                  | Yes            |
| PM <sub>10</sub>                             | 0                      | 237.5                  | Yes            |
| <b>Gas Turbines, Units 11 &amp; 12, each</b> |                        |                        |                |
| NO <sub>x</sub>                              | 0                      | 238.6                  | Yes            |
| VOC  | 0                      | 72.9                   | Yes            |
| SO <sub>2</sub>                              | 0                      | 23.9                   | Yes            |
| PM <sub>10</sub>                             | 0                      | 120.0                  | Yes            |
| <b>Auxiliary Boiler</b>                      |                        |                        |                |
| NO <sub>x</sub>                              | 0                      | 2.4                    | Yes            |
| VOC  | 0                      | 0.9                    | Yes            |
| SO <sub>2</sub>                              | 0                      | 0.4                    | Yes            |
| PM <sub>10</sub>                             | 0                      | 1.6                    | Yes            |

A detailed BACT analysis was conducted to evaluate available control options for the proposed gas turbines under both PSD and NSR requirements; the analysis is presented in Appendix 3.1F. A summary of the proposed BACT is provided in Table 3.1-36.

TABLE 3.1-36  
Summary of Proposed BACT

| Pollutant  | Control Technology   | Concentration                                |
|--|--|--|
| NO <sub>x</sub> , GE Turbine                     | Water injection and SCR and non-use of carbon control and capture system (CCS) | 2.0 ppmvd @ 15% O <sub>2</sub> (1-hr avg)    |
| NO <sub>x</sub> , Trent Turbines                 | Water injection and SCR and non-use of carbon control and capture system (CCS) | 2.5 ppmvd @ 15% O <sub>2</sub> (1-hr avg)    |
| NO <sub>x</sub> , Auxiliary Boiler               | Ultra-Low-NO <sub>x</sub> burner and FGR                                       | 9 ppmvd @ 3% O <sub>2</sub> (15-minute avg)  |
| CO, GE Turbine                                   | Catalytic Oxidation  | 2.0 ppmvd @ 15% O <sub>2</sub> (1-hr avg)    |
| CO, Trent Turbines                               | Catalytic Oxidation  | 4.0 ppmvd @ 15% O <sub>2</sub> (1-hr avg)    |
| CO, Auxiliary Boiler                             | Good combustion practices  | 50 ppmvd @ 3% O <sub>2</sub> (15-minute avg) |
| VOC, Turbines                                    | Good combustion practices  | 2.0 ppmvd @ 15% O <sub>2</sub> (1-hr avg)    |
| VOC, Auxiliary Boiler                            | Good combustion practices  | NA   |
| SO <sub>2</sub> , combustion                     | Pipeline Natural Gas   | NA   |
| PM <sub>10</sub> /PM <sub>2.5</sub> , combustion | Pipeline Natural Gas   | NA   |
| GHGs, GE turbine                                 | Efficient combined-cycle gas turbine   | NA   |
| GHGs, Trent Turbines                             | Efficient simple-cycle gas turbine   | NA   |

### 3.1.6.3.3 Offsets

The project is exempt from District offset requirement of 1303(b)(2) because Rule 1304(a)(2) applies to this project. Rule 1304(a)(2) exempts affected sources from the modeling requirement of Rule 1303(b)(1) and the offset requirement of Rule 1303(b)(2).

The modeling requirement of Rule 1303(b)(1) and the offset requirement of Rule 1303(b)(2) do not apply to certain sources, including “replacement of electric utility steam boiler(s) with combined cycle gas turbine(s), intercooled, chemically recuperated gas turbines, other advanced gas turbine(s); solar, geothermal, or wind energy or other equipment, to the extent that such equipment will allow compliance with Rule 1135 or Regulation XX rules. The new equipment must have a maximum electrical power rating (in megawatts) that does not allow basinwide electricity generating capacity on a per-utility basis to increase. If there is an increase in basin-wide capacity, only the increased capacity must be offset.”

The project is comprised of three turbines and an auxiliary boiler. The Trent turbines are advanced gas turbines, using an Inlet Spray Intercooling system to reduce ambient inlet temperature and decrease the energy required for compression<sup>9</sup>; and the GE turbine is a combined cycle turbine. The auxiliary boiler is a necessary adjunct to the GE turbine, providing it with the fast-start capability necessary to allow an efficient combined-cycle unit to start up as rapidly as is necessary for this project. By shortening the turbine startup period, during which the SCR system does not reduce emissions to complying levels, the boiler is “other equipment, to the extent that such equipment will allow compliance with Rule 1135 or other Regulation XX rules.”

<sup>9</sup> Because of advanced design features, the Trent turbines have a heat rate of approximately 9,000 BTU/kWh (HHV), which is lower than then 9,400 – 10,000 BTU/kWh range for traditional simple-cycle designs.

The three turbines have a combined capacity of no more than 447 MW. They will replace the existing Unit 4 (335 MW), plus the 112 MW remaining for Unit 3 following the previously approved ESPR Project. The project will not allow basinwide electricity generating capacity on a per-utility basis to increase. The project therefore qualifies for the exemption.

CEC policies require nonattainment pollutants, and their precursors, be offset at a 1:1 ratio, or otherwise mitigated in an equivalent way. This requirement will be met through RECLAIM credits (for NOx), and through District-provided offsets (for other nonattainment pollutants), as discussed below.

#### **3.1.6.3.4 Air Quality Impact Analysis**

Under the SCAQMD new source review regulations, an air quality impact analysis must be performed to confirm that the emission increases for a project will not interfere with the attainment or maintenance of an applicable ambient air quality standard or cause additional violations of a standard anywhere the standard is already exceeded. The modeling results presented in Section 3.1.4.16 show that the proposed project will not interfere with the attainment or maintenance of the applicable air quality standards or cause additional violations of any standards.

#### **3.1.6.3.5 New Source Review Requirements for Air Toxics**

The SCAQMD's New Source Review (NSR) rule for air toxics (Regulation XIV, Rule 1401, New Source Review of Toxic Air Contaminants) describes the requirements, procedures, and standards for evaluating the potential impact of toxic air contaminants (TAC) from new sources and modifications to existing sources. The rule also requires a demonstration that the source will not exceed the applicable health risk thresholds. ESPFM will comply with the requirements of this rule. An air toxics health risk assessment consistent with SCAQMD requirements under Rule 1401 is provided in Section 3.8 of this PTA, Public Health and Safety.

#### **3.1.6.3.6 New Source Performance Standards**

The District's New Source Performance Standards (Regulation X, Standards of Performance for New Stationary Sources) incorporates the federal NSPS from 40 CFR Part 60. The applicability and requirements of and compliance with the New Source Performance Standards are discussed above under the federal regulations section.

#### **3.1.6.3.7 Federal Programs and Permits**

The federal Title IV acid rain program requirement and Title V operational permit requirements are in SCAQMD's Rule XXXI (Acid Rain Permit Program) and Regulation XXX (Title V Permits). The applicability and requirements of and compliance with these programs and permits are discussed above under the federal regulations section.

#### **3.1.6.3.8 Public Notification**

Because the proposed ESPFM project emissions will exceed the trigger levels in Rule 212(g), public notice is required and the project owner expects that the Air Pollution Control Officer will provide this notice in a timely manner.

#### **3.1.6.3.9 Permit Fees**

The SCAQMD requirements regarding permit fees are specified in Regulation III. This regulation establishes the filing and permit review fees for specific types of new sources, as well as annual renewal fees and penalty fees for existing sources. The project owner has paid the application filing fees, and will pay other applicable fees in accordance with these requirements.

#### **3.1.6.3.10 Prohibitions**

The SCAQMD prohibitions for specific types of sources and pollutants are addressed in Regulation IV. The prohibition rules that apply to the proposed ESPFM project are listed below.

**RULE 401-Visible Emissions**

This rule limits visible emissions to an opacity of less than 20% (No.1 on the Ringelmann Chart, as published by the U.S. Bureau of Mines). With the use of natural gas, DLN and DLE combustors, and SCR systems, it is unlikely that there will be visible emissions following the early stages of the commissioning period. However, in the unlikely event that visible emissions do occur, anything greater than 20% opacity is not expected to last for greater than three minutes. During normal operation, no visible emissions are expected. The small package boiler will burn only natural gas, and is unlikely to cause visible emissions. Therefore, based on the above and on experience with other CTGs, compliance with this rule is expected.

**RULE 402-Nuisance**

This rule requires that a person not discharge from any source whatsoever such quantities of air contaminants or other material that cause injury, detriment, nuisance, or annoyance to any considerable number of persons or to the public; or that cause, or have a natural tendency to cause, injury or damage to business or property. The new CTGs will be operated with natural gas, DLN and DLE combustors, and SCR systems to comply with BACT and are not expected to create a public nuisance based on experience with similar CTGs. The small package boiler will burn only natural gas, and is unlikely to create a public nuisance. Therefore, compliance with Rule 402 is expected.

**RULE 403-Fugitive Dust**

The purpose of this rule is to reduce the amount of particulate matter entrained in the ambient air as a result of man-made fugitive dust sources by requiring actions to prevent, reduce, or mitigate fugitive dust emissions. The provisions of this rule apply to any activity or man-made condition capable of generating fugitive dust. This rule prohibits emissions of fugitive dust beyond the property line of the emission source. The project owner will be taking steps to prevent and/or reduce or mitigate fugitive dust emissions from the project site. Such measures include covering loose material on haul vehicles, watering, and using chemical stabilizers when necessary. The installation and operation of the CTGs and boiler are expected to comply with this rule.

**RULE 407-Liquid and Gaseous Air Contaminants**

This rule limits CO emissions to 2,000 ppmvd and SO<sub>2</sub> emissions to 500 ppmvd, averaged over 15 minutes. For CO, the GE and Trent CTGs will be required to meet BACT limits for CO of 2.0 and 4.0 ppmvd at 15% O<sub>2</sub>, 1-hr average, respectively, and will be conditioned as such. The boiler will be required to meet a limit of 50 ppm. For SO<sub>2</sub>, equipment that complies with Rule 431.1 is exempt from the SO<sub>2</sub> limit in Rule 407. The project owner will be required to comply with Rule 431.1, and thus the SO<sub>2</sub> limit in Rule 407 will not apply. Accordingly, compliance is expected.

**RULE 409-Combustion Contaminants**

This rule restricts the discharge of contaminants from the combustion of fuel to 0.23 grams per cubic meter (0.1 grain per cubic foot) of gas, calculated to 12% CO<sub>2</sub>, averaged over 15 minutes. The equipment is expected to meet this limit based on the calculations shown below.

GE Turbine

|                                      |   |  |
|--------------------------------------|---|--|
| Estimated exhaust gas                | = | 543,892 DSCFM = 32.6 mmscf/hr (90°F, low load) |
| Maximum PM <sub>10</sub> Emissions   | = | 9.5 lb/hr                                      |
| Estimated CO <sub>2</sub> in exhaust | = | 3%   |

$$\text{Grain Loading} = \frac{(9.5 \text{ lb/hr})(7000 \text{ gr/lb})}{32.6 \text{ EE}6 \text{ scf/hr}} \times \frac{12}{3} = 0.0082 \text{ gr/dscf} \ll 0.1 \text{ gr/dscf}$$

### Trent 60 Turbines

Estimated exhaust gas = 174,000 DSCFM = 10.4 mmscf/hr (90°F, low load)  
 Maximum PM<sub>10</sub> Emissions = 5.0 lb/hr  
 Estimated CO<sub>2</sub> in exhaust = 3%

$$\text{Grain Loading} = \frac{(5.0 \text{ lb/hr})(7000 \text{ gr/lb})}{10.4 \text{ EE6 scf/hr}} \times \frac{12}{3} = 0.013 \text{ gr/dscf} \ll 0.1 \text{ gr/dscf}$$

### Auxiliary Boiler

Estimated exhaust gas = 6,100 DSCFM = 0.37 mmscf/hr (full load)  
 Maximum PM<sub>10</sub> Emissions = 0.3 lb/hr  
 Estimated CO<sub>2</sub> in exhaust = 12%

$$\text{Grain Loading} = \frac{(0.3 \text{ lb/hr})(7000 \text{ gr/lb})}{0.37 \text{ EE6 scf/hr}} \times \frac{12}{12} = 0.006 \text{ gr/dscf} \ll 0.1 \text{ gr/dscf}$$

#### ***RULE 431.1-Sulfur Content of Gaseous Fuels***

The facility will use pipeline-quality natural gas that will comply with the 16 ppmv sulfur limit, calculated as H<sub>2</sub>S, specified in this rule. Natural gas supplied by the Gas Company also has a sulfur content of less than 0.75 gr/100 scf on a short-term basis and 0.25 gr/100scf on a long-term basis, which is equivalent to a sulfur concentration ranging from approximately 12 to 4 ppmv. Accordingly, compliance is expected.

#### ***RULE 474-Fuel Burning Equipment-Oxides of Nitrogen***

Superseded by NO<sub>x</sub> RECLAIM.<sup>10</sup>

#### ***RULE 475-Electric Power Generating Equipment***

This rule applies to power-generating equipment rated greater than 10 MW installed after May 7, 1976. Requirements specify that the equipment must comply with a PM<sub>10</sub> mass emission limit of 11 lbs/hr or a PM<sub>10</sub> concentration limit of 0.01 grains/dscf. Compliance is demonstrated if either the mass emission limit or the concentration limit is met. The PM<sub>10</sub> mass emissions from the GE CTG are estimated to be 9.5 lbs/hr. The estimated grain loading is less than 0.01 grain/dscf (see calculations under Rule 409 analysis). The PM<sub>10</sub> mass emissions from each Trent 60 CTG are estimated to be 5 lbs/hr. The estimated grain loading is less than 0.01 grain/dscf (see calculations under Rule 409 analysis). Therefore, compliance is expected. Compliance will be verified through performance tests.

#### ***RULE 476-Steam Generating Equipment***

Superseded by NO<sub>x</sub> RECLAIM.<sup>11</sup>

### **3.1.7 Mitigation Measures**

Mitigation will be provided for project emissions in the form of offsets and the installation of BACT, as required under SCAQMD regulations. The cumulative air quality impacts analysis described in Section 3.1.5 shows that the project will not result in significant cumulative impacts.

As discussed in Section 3.1.6.3, the project's sources will be subject to RECLAIM. Under RECLAIM, NO<sub>x</sub> offsets are provided on an ongoing basis at a 1:1 ratio.

<sup>10</sup> SCAQMD Rule 2001(j).

<sup>11</sup> SCAQMD Rule 2001(j).

The project is exempt from District offset requirements under Rule 1304(b). This regulation is intended to provide incentives to replace existing electric utility boilers with combined cycle and advanced turbine units. Under this program, the District determines the creditable emission reductions associated with the replaced boilers, and places them in the District's internal emission offset bank; the District then provides offsets required by the project from the bank. The amount of offsets provided from District offset accounts is the same as would have been provided by the project owner that did not qualify for the exemption; all emission increases of VOC, SO<sub>x</sub>, and PM<sub>10</sub> will be offset under this program.

Additionally, it is the CEC's policy to require mitigation for the full amounts of all nonattainment pollutants and their precursors at a ratio of at least 1:1. Accordingly, the full project emissions of NO<sub>x</sub>, VOC, PM<sub>10</sub>, PM<sub>2.5</sub>, and SO<sub>2</sub> will be mitigated. Mitigation for CO will not be required because of the current attainment designation of the SCAQMD air basin for this pollutant.

Table 3.1-37 summarizes the offset requirements applicable to the project.

As discussed above, the project's GHG impacts are not significant. GHG regulatory offset requirements will be addressed through acquisition of allowances under CARB's Cap-and-Trade program.

TABLE 3.1-37  
ESPFM Offset Requirements

| Pollutant        | Project Emissions (TPY) | District Offset Requirements (TPY)       | CEC Mitigation Requirements (TPY) |
|------------------|-------------------------|--|-----------------------------------|
| NO <sub>x</sub>  | 93.5                    | RECLAIM                                  | RECLAIM                           |
| CO               | 2702.1                  | —  | —                                 |
| VOC              | 33.0                    |  | 33.0                              |
| SO <sub>2</sub>  | 6.5                     | Fully offset from SCAQMD's Internal Bank | 6.5                               |
| PM <sub>10</sub> | 51.1                    |  | 51.1                              |
| GHGs             | 968,000                 | —  | Cap & Trade Allowances            |

### 3.1.8 Permits Required and Permit Schedule

Under Regulation II of its Rules and Regulations, SCAQMD regulates the construction, alteration, replacement, and operation of new stationary emissions sources and modifications to existing sources. As part of the application review process, the District's Air Pollution Control Officer will conduct a Determination of Compliance (DOC) review upon receipt of the PTA for the proposed ESPFM project. This DOC for the project will be provided by SCAQMD as part of the CEC review to confirm that the project will meet all of the District's rules and regulations. A preliminary DOC (PDOC) is expected within approximately 180 days after acceptance of the application is complete. The PDOC will be circulated for public comment, and a final DOC (FDOC) will be issued by the SCAQMD after comment has been considered and addressed. Upon receiving CEC's final license, the SCAQMD will be responsible for issuing a Permit to Construct (PTC) and Permit to Operate (PTO) for ESPFM. This permitting process allows the SCAQMD to adequately review new and modified air pollution sources to ensure compliance with all applicable prohibitory rules and to ensure that appropriate emission controls will be used. A PTC allows for the construction of the air pollution source and remains in effect until the PTO application is granted, denied, or canceled. Once the project has completed construction and commences operations, SCAQMD will require verification that ESPFM conforms to the PTC application and, following such verification, will issue a PTO. The PTO specifies conditions that the air pollution source must meet to comply with all air quality standards and regulations.

The SCAQMD has also received delegation from EPA to administer the federal Title IV and Title V programs for sources within its jurisdiction. The project will be subject to acid rain program requirements. The District's permit program is an integrated program; the ATC is also the amended Title V permit.



EPA has delegated authority to the SCAQMD to issue PSD permits. The PTC, when issued, will serve as the PSD permit as well.

### 3.1.9 References

- Auer, Jr., A.H. 1978. "Correlation of Land Use and Cover with Meteorological Anomalies." *Journal of Applied Meteorology*. 17: 636-643.
- California Air Resources Board. 2007. Off-Road Mobile Source Emission Factors, Off-Road Emissions Inventory Program.
- California Air Resources Board. 2013. ADAM Website ([www.arb.ca.gov/adam/welcome.html](http://www.arb.ca.gov/adam/welcome.html)). November.
- California Energy Commission. 1997. "Regulations Pertaining to the Rules of Practice and Procedure and Plant Site Certification." Title 20, California Code of Regulations. Chapters 1, 2, and 5.
- California Energy Commission. 2006. Rules of Practice and Procedure and Power Plant Site Certification Regulations Revisions, 04-SIT-2, December 14, 2006.
- California Energy Commission. 2007. 2007 Integrated Energy Policy Report – Scenario Analysis of California's Electricity System. [http://www.energy.ca.gov/2007\\_energypolicy/documents/index.html](http://www.energy.ca.gov/2007_energypolicy/documents/index.html).
- California Energy Commission. 2009. Committee Report (08-GHG OII-01). Committee Guidance on Fulfilling California Environmental Quality Act Responsibilities for Greenhouse Gas Impacts in Power Plant Siting Applications. March 2009. [http://www.energy.ca.gov/ghg\\_powerplants/documents/index.html](http://www.energy.ca.gov/ghg_powerplants/documents/index.html).
- California Energy Commission. 2009. Framework for Evaluating Greenhouse Gas Implications of Natural Gas-Fired Power Plants in California, CEC-700-2009-009-F, Prepared by: MRW and Associates. December 2009.
- California Energy Commission. 2009. Final Commission Decision for the Avenal Energy Plant (CEC-800-2009-006-CMF), December 2009.
- San Joaquin Valley Air Pollution Control District. April 2010. Modeling Procedure to Address the New Federal 1 Hour NO<sub>2</sub> Standard.
- Shaw Environmental Inc. 2007. Petition to Amend Final Commission Decision for the El Segundo Power Redevelopment Project. June.
- Sierra Research. 2012. Air Dispersion Modeling and Health Risk Assessment Protocol for the El Segundo Energy Center Facility Modification, El Segundo, California, November 2012.
- South Coast Air Quality Management District. 1993. CEQA Air Quality Handbook. April 1993.
- U.S. Environmental Protection Agency. 1985. Guideline for Determination of Good Engineering Stack Height (Technical Support Document for the Stack Height Regulation) (Revised), EPA-450/4-80-023R. Office of Air Quality Planning and Standards, U.S. Environmental Protection Agency, Research Triangle Park, North Carolina. June 1985.
- U.S. Environmental Protection Agency. 1992a. Screening Procedures for Estimating the Air Quality Impact of Stationary Sources, Revised. EPA-454/R-92-019. October 1992.
- U.S. Environmental Protection Agency. 1995a. Building Profile Input Program-Prime. Version 98086.
- U.S. Environmental Protection Agency. 1995b. Screen3 Model User's Guide. EPA-454/B-95-004. September 1995.
- U.S. Environmental Protection Agency. 1995c. User's Guide to the Building Profile Input Program (Revised), EPA-454/R-93-038, Office of Air Quality Planning and Standards, U.S. Environmental Protection Agency, Research Triangle Park, North Carolina. February.
- U.S. Environmental Protection Agency. 2000. Meteorological Monitoring Guidance for Regulatory Modeling Applications. February 2000.
- U.S. Environmental Protection Agency. 2003. Guideline on Air Quality Models. 40 CFR51 Appendix W. July 1, 2003 Edition.

- U.S. Environmental Protection Agency. 2004. User's Guide for the AMS/EPA Regulatory Model-AERMOD. (EPA-454/B-03-001). September 2004.
- U.S. Environmental Protection Agency. 2005. AERMOD Implementation Guide. September 2005.
- U.S. Environmental Protection Agency. 2006a. Addendum to User's Guide for the AMS/EPA Regulatory Model-AERMOD. December 2006.
- U.S. Environmental Protection Agency. 2006b. EPA AirData.
- U.S. Environmental Protection Agency. 2008a. AERMOD Implementation Guide. January 2008.
- U.S. Environmental Protection Agency. 2008b. AERSURFACE User's Guide. January 2008.
- U.S. Environmental Protection Agency. 2010a. Notice Regarding Modeling for New Hourly NO<sub>2</sub> NAAQS. February.
- U.S. Environmental Protection Agency. 2010b. EPA AIRS Website ([www.epa.gov/air/data/index.htm](http://www.epa.gov/air/data/index.htm)). November.
- Western Regional Climate Center. 2007. Desert Research Institute, Las Vegas, NV (<http://www.wrcc.dri.edu>).



## 3.2 Biological Resources

This section describes and evaluates potential effects the proposed changes may have on biological resources. Compliance with applicable LORS is also addressed.

### 3.2.1 Amendment Overview

As discussed in detail in Section 2.0, Project Description, this PTA proposes modifications to the ESEC that necessitate evaluation of environmental impacts and potential amendments to existing COCs. The proposed PTA is for decommissioning, demolishing, and replacing the existing Units 3 and 4 steam boiler plants with approximately 449 MW gross / 435 MW net of new natural-gas-fired electrical generating capacity, consisting of one combined-cycle train and two simple-cycle gas turbines. The air-cooled, combined-cycle train (CC Fast) will consist of a GTG (Unit 9), a an HRSG, and one STG (Unit 10), rated at 325 MW net. The simple cycle turbines (Units 11 and 12) will consist of two air-cooled Trent 60 ISE advanced aeroderivative gas turbines, each rated at 55 MW net / 58 MW gross. The GE turbine will be supported by a small (36 MMBtu/hr) auxiliary boiler that will be incorporated into the operation of the CC Fast. Removal of existing Units 3 and 4 will eliminate the remaining once-through ocean water cooling system at the ESGS site. The ESPFM will improve electricity generation by adding fast-start and dispatch flexibility capability to support southern California grid load balancing. Total site capacity (including the new equipment previously permitted) will not exceed 1,020 MW net—the rated capacity of previously retired Units 1 and 2, plus the capacity of the soon-to-be-retired Unit 3 and operating Unit 4, which will also be retired as part of the ESPFM.

### 3.2.2 Affected Environment

#### 3.2.2.1 ESEC Amendments

The proposed ESPFM will result in modifications to the ESEC license (00-AFC-14C). Decommissioning, demolishing, and removing existing Units 3 and 4 and replacing them with new Units 9, 10, 11 and 12 will not result in new impacts to biological resources beyond those identified in the CEC's amended license for 00-AFC-14C and as described in Section 2.0. It is anticipated that demolition of Units 3 and 4 and construction of Units 9–12 will require grading and excavation activities similar to the demolition of Units 1 and 2 and construction activities associated with Units 5 through 8 and their supporting equipment and structures. For the most part, subsurface activities are expected to occur in areas of the site that have been previously disturbed as part of historical power plant operations at the site, including the most current subsurface activities required for the demolition of Units 1 and 2 and construction of Units 5 through 8.

In addition, CH2M HILL staff (Jennifer Scholl, Senior Technical Consultant) participated in two site visits on January 24, 2013, and February 19, 2013. During these visits, CH2M HILL staff, accompanied by NRG representatives, walked areas of the site not currently impacted by construction activities and it was noted that only minimal vegetation presently exists within the facility since most of the facility is either paved, graveled, or under construction. While there is some vegetation growing on the slope along the northern plant boundary and along the eastern fence line, this vegetation consists of non-native species (ice plant, evergreens, and ornamental shrubs, etc.), which are not considered species or habitat requiring protection. As part of the installation of Units 5 through 8, perimeter landscaping will be installed in accordance with VISUAL and LAND COCs. The resource protection measures included in existing COCs BIO-6 through BIO-12 and BIO-14 are adequate to address potential impacts to biological resources from implementation of the ESPFM. The following is a brief description of the existing biological resources COCs:

- **BIO-6** Designated Biologist
- **BIO-7** Designated Biologist Duties
- **BIO-8** Designated Biologist
- **BIO-9** Biological Resources Mitigation Implementation and Monitoring Plan
- **BIO-10** Worker Environmental Awareness Program
- **BIO-11** U.S. Army Corps of Engineers Permit

- **BIO-12** USFWS Biological Opinion
- **BIO-14** Facility Closure

ESEC LLC will continue to comply with the requirements set forth in these COCs.

To determine the impacts of the proposed ESPFM modifications on aquatic and terrestrial resources at the ESGS site, past biological resource surveys conducted for the 2007 ESPR Dry Cooling Amendment (Shaw 2007, AECOM 2010) were reviewed together with updated species lists generated from queries of the California Natural Diversity Database (CNDDDB), California Native Plant Society (CNPS), and U.S. Fish and Wildlife Service (USFWS). Table 3.2-1 presents an updated comparison of special-status species that potentially occur at the site compared to those with potential to occur at the site in 2007 (CNDDDB 2011, USFWS 2013, CNPS 2013). Sixteen additional species were identified as potentially occurring in the project area during the information review. Figure 3.2-1 shows the results of the queries related to the ESPFM. In addition, CH2M HILL staff conducted a site reconnaissance on January 24, 2013, and February 19, 2013, to assess current conditions including wildlife habitat, special-status species, and wetlands. No new habitats, wetlands, or special-status species were observed during the reconnaissance survey.

TABLE 3.2-1

**Summary of Changes/Additions of Potentially Occurring Special Status Species in the Project Area (USGS Venice quad)**

| Scientific Name   | 2007<br>Fed/State<br>Status | 2013<br>Fed/State<br>Status | Comments   | Suitable Habitat (Y/N) |
|---|-----------------------------|-----------------------------|--|------------------------|
| <b>Wildlife</b>   |                             |                             |  |                        |
| <u>American badger</u><br><i>Taxidea taxus</i>                                  | N/A                         | —/CSC                       | New addition from 2011 CNDDDB search.  | N                      |
| <u>pocketed free-tailed bat</u><br><i>Nyctinomops femorosaccus</i>              | —/S2S3                      | —/CSC                       |  | N                      |
| <u>Big free-tailed bat</u><br><i>Nyctinomops macrotis</i>                       | N/A                         | —/CSC                       | New addition from 2011 CNDDDB search.  | N                      |
| <u>Pallid bat</u><br><i>Antrozous pallidus</i>                                  | N/A                         | —/CSC                       | New addition from 2011 CNDDDB search.  | N                      |
| <u>Western mastiff bat</u><br><i>Eumops perotis californicus</i>                | N/A                         | —/CSC                       | New addition from 2011 CNDDDB search.<br>Unlikely to roost in project area.  | Unlikely               |
| <u>Pacific pocket mouse</u><br><i>Perognathus longimembris pacificus</i>        | FE/CSC                      | FE/CSC                      | Not included in AFC. Extirpated.   | N                      |
| <u>South Coast marsh vole</u><br><i>Microtus californicus stephensi</i>         | N/A                         | —/CSC                       | New addition from 2011 CNDDDB search.  | N                      |
| <u>Southern California saltmarsh shrew</u><br><i>Sorex ornatus salicornicus</i> | N/A                         | —/CSC                       | New addition from 2011 CNDDDB search.  | N                      |
| <u>western snowy plover</u><br><i>Charadrius alexandrius nivosus</i>            | FT/—                        | FT/CSC                      | New state status. Still extirpated from the project area.  | N                      |
| <u>California least tern</u><br><i>Sterna antillarum browni</i>                 | FE/SE                       | FE/SE, FP                   | New status as state fully protected.   | N                      |
| <u>California brown pelican</u><br><i>Pelecanus occidentalis californicus</i>   | FE/SE                       | —/—,FP                      | De-listed by state and federal. Now fully protected in CA. Not included in AFC, presumed extant. Roost at Marina del Rey breakwater is 2 <sup>nd</sup> largest in southern CA. | Y                      |
| <u>Light-footed clapper rail</u><br><i>Rallus longirostris levipes</i>          | N/A                         | FE/SE, FP                   | New addition from 2013 USFWS list.   | N                      |

TABLE 3.2-1  
**Summary of Changes/Additions of Potentially Occurring Special Status Species in the Project Area (USGS Venice quad)**

| Scientific Name   | 2007<br>Fed/State<br>Status | 2013<br>Fed/State<br>Status | Comments                               | Suitable Habitat (Y/N) |
|---|-----------------------------|-----------------------------|--|------------------------|
| <u>Burrowing owl</u><br><i>Athene cunicularia</i>                             | N/A                         | —/CSC                       | New addition from 2011 CNDDDB search.  | N                      |
| <u>Least Bell's vireo</u><br><i>Vireo bellii pusillus</i>                     | N/A                         | FE/SE                       | New addition from 2013 USFWS list.     | N                      |
| <u>Southwestern willow flycatcher</u><br><i>Empidonax traillii extimus</i>    | N/A                         | FE/SE                       | New addition from 2013 USFWS list.     | N                      |
| tricolored blackbird<br><i>Agelaius tricolor</i>                              | —/CSC                       | —/CSC                       |  | N                      |
| coastal California gnatcatcher<br><i>Poliophtila californica californica</i>  | FT/CSC                      | FE/CSC                      | Now listed as federally endangered.    | N                      |
| Belding's savannah sparrow<br><i>Passerculus sandwichensis beldingi</i>       | —/SE                        | —/SE                        |  | N                      |
| Coast (San Diego) horned lizard<br><i>Phrynosoma coronatum [=blainvillii]</i> | —/CSC,<br>S3S4              | —/CSC                       |  | N                      |
| <u>Silvery legless lizard</u><br><i>Anniella pulchra pulchra</i>              | N/A                         | —/CSC                       | New addition from 2011 CNDDDB search.  | N                      |
| <u>Western pond turtle</u><br><i>Emys marmorata</i>                           | N/A                         | —/CSC                       | New addition from 2011 CNDDDB search.  | N                      |
| <u>California red-legged frog</u><br><i>Rana draytonii</i>                    | N/A                         | FE/CE                       | New addition from 2013 USFWS list.     | N                      |
| Mohave tui chub<br><i>Gila bicolor mohavensis</i>                             | FE/SE                       | FE/SE,FP                    | Now fully protected in CA. Extirpated. | N                      |
| sandy beach tiger beetle<br><i>Cicindela hirticollis gravida</i>              | —/S1                        | —/S1                        | Extirpated.                            | N                      |
| monarch butterfly<br><i>Danaus plexippus</i>                                  | —/S3                        | —/S3                        | Still presumed extant.                 | Y                      |
| Palos Verdes blue butterfly<br><i>Glaucopsyche lygdamus palosverdesensis</i>  | FE/S1                       | FE/S1                       | Possibly extirpated.                   | N                      |
| <u>Riverside fairy shrimp</u><br><i>Streptocephalus wootoni</i>               | N/A                         | FE/—                        | New addition from 2013 USFWS list.     | N                      |
| <u>Vernal pool fairy shrimp</u><br><i>Branchinecta lynchi</i>                 | N/A                         | FT/—                        | New addition from 2013 USFWS list.     | N                      |
| <b>Plants</b>   |                             |                             |  |                        |
| Coastal dunes milk-vetch<br><i>Astragalus tener</i> var. <i>titi</i>          | --/CNPS<br>1B.1             | FE/CNPS<br>1B.1             | Now listed as federally endangered.    | N                      |
| Parish's brittle scale<br><i>Atriplex parishii</i>                            | --/CNPS<br>1B.1             | --/CNPS<br>1B.1             |  | N                      |
| South Coast salt scale<br><i>Atriplex pacifica</i>                            | --/CNPS<br>1B.2             | --/CNPS<br>1B.2             |  | N                      |

TABLE 3.2-1  
**Summary of Changes/Additions of Potentially Occurring Special Status Species in the Project Area (USGS Venice quad)**

| Scientific Name   | 2007<br>Fed/State<br>Status | 2013<br>Fed/State<br>Status | Comments  | Suitable Habitat (Y/N) |
|---|-----------------------------|-----------------------------|---|------------------------|
| Davidson's saltscare<br><i>Atriplex serenana</i> var. <i>davidsonii</i>       | --/CNPS<br>1B.2             | --/CNPS<br>1B.2             |   | N                      |
| southern tarplant<br><i>Centromadia parryi</i> ssp. <i>australis</i>          | --/CNPS<br>1B.1             | --/CNPS<br>1B.1             |   | N                      |
| Coulter's goldfields<br><i>Lasthenia glabrata</i> ssp. <i>coulteri</i>        | --/CNPS<br>1B.1             | --/CNPS<br>1B.1             |   | N                      |
| salt marsh bird's-beak<br><i>Cordylanthus maritimus</i> ssp. <i>maritimus</i> | --/S2.1                     | <u>FE/CE, 1B.2</u>          | New state and federal status.                         | N                      |
| <u>Mud nama</u><br><i>Nama stenocarpum</i>                                    | N/A                         | <u>--/CNPS 2.2</u>          | New addition from 2011 CNPS inventory.                | N                      |
| prostrate navarretia<br><i>Navarretia prostrata</i>                           | --/S2.1                     | <u>--/CNPS 1B.1</u>         | New status.   | N                      |
| coast woolly-heads<br><i>Nemacaulis denudata</i> var. <i>denudata</i>         | --/CNPS<br>1B.2             | --/CNPS<br>1B.2             |   | N                      |
| California Orcutt grass<br><i>Orcuttia californica</i>                        | --/CNPS<br>1B.1             | <u>FE/CE, CNPS 1B.1</u>     | Now listed as state candidate and federal endangered. | N                      |
| Lyon's pentachaeta<br><i>Pentachaeta lyonii</i>                               | --/S1.1                     | <u>FE/CE, CNPS 1B.1</u>     | Now listed as state candidate and federal endangered. | N                      |
| Brand's phacellia<br><i>Phacelia stellaris</i>                                | --/S1.1,<br>CNPS 1B.1       | FC/CNPS<br>1B.1             | Now listed as federal candidate.                      | N                      |
| estuary seablite<br><i>Suaeda esteroa</i>                                     | --/CNPS<br>1B.2             | --/CNPS<br>1B.2             |   | N                      |
| San Bernardino aster<br><i>Symphyotrichum defoliatum</i>                      | --/CNPS<br>1B.2             | --/CNPS<br>1B.2             |   | N                      |

Notes: CSC – California State Species of Concern, FC – Federal Candidate, FE – Federal Endangered, FT – Federal Threatened, SE – California State Candidate as Endangered, SE – California State Endangered, ST – California State Threatened, CNPS – California Native Plant Society ranking.

### 3.2.3 Environmental Analysis

As discussed in Section 2.0, Project Description, the demolition and removal of Units 3 and 4 and the installation and operation of new gas turbine Units 9, 11, and 12 and steam turbine Unit 10 will result in similar grading, excavation, foundation, and underground infrastructure activities as were required for the previous demolition of Units 1 and 2 and the previous construction of Units 5 through 8 and their supporting equipment and structures. For the most part, subsurface activities required for ESPFM will to occur in areas of the site that have been previously disturbed as part of historical power plant operations, including the areas recently excavated for demolition of Units 1 and 2 and construction of Units 5 through 8, and therefore, impacts beyond those described in 00-AFC-14 (and the previous PTAs) are not anticipated. During the site visits conducted on January 24, 2013 and February 19, 2013, CH2M HILL staff, noted that only minimal vegetation presently exists within the facility since most of the facility is either paved, graveled, or under construction. While there is some vegetation growing on the slope along the northern plant boundary and along the eastern fence line, this vegetation consists of non-native species (ice plant, evergreens, and ornamental shrubs. etc) and is not considered species or habitat requiring protection. Therefore, the ESPFM will not result in the permanent alteration of any existing sensitive habitat and impacts to special-status species are not expected to occur, including the 16 additional species, listed

in Table 3.2-1, and identified during the updated information review and as observed during recent site visits in January and February 2013. Therefore, the resource protection measures included in existing COCs BIO-6 through BIO-12 and BIO-14 are adequate to address potential impacts to biological resources and the ESPFM demolition and construction activities will be conducted in accordance with these COCs and applicable LORS.

### 3.2.3.1 Offsite Construction Laydown and Construction Worker Parking Areas

The preferred offsite laydown area, located at 777 W. 190th Street in the City of Gardena, was incorporated into ESEC in the 2010 PTA decision and will continue to be used for ESPFM. Construction laydown and parking areas will also be established within the ESGS site boundary, as well as at offsite areas identified in the CEC Final Decision and shown on Figure 2-10. The 190th Street area is less than ten miles southeast of the ESGS and is easily accessible to the I-405 and I-110 North freeways from Vermont Avenue and 190th Street as well as to ESEC-approved traffic/truck routes. This site, zoned M2, commercial, has approximately ten usable acres and includes a 5,500 square-foot industrial building. The approximately 12.1-acre site paved with asphalt has nightlighting and includes a perimeter security fence. No site preparation other than minor clean-up is required prior to use. Therefore, subsurface ground disturbance is not required and no biological resource impacts will result from using offsite construction laydown and parking areas. The existing COCs ensure that construction-related activities at the approved laydown areas will comply with appropriate biological resource protection plans.

### 3.2.4 Cumulative Impacts

The proposed ESPFM covered under this PTA will result in similar subsurface activities as was required for the previous demolition of Units 1 and 2 and construction of Units 5 through 8 and their supporting equipment and structures. ESPFM subsurface demolition and construction activities are expected to occur in areas of the ESGS site that have been previously disturbed as part of historical power plant operations at the site and impacts beyond those described in 00-AFC-14 (and the previous PTAs) are not anticipated. The proposed project changes will not result in any significant cumulative impacts to biological resources beyond those addressed in the CEC Final Decision and subsequent amendments. The cumulative impacts to biological resources, which were identified by CEC staff as part of the previously permitted project, focused on potential cumulative impacts associated with once-through cooling. The proposed elimination of once-through cooling associated with the ESPFM presents a net benefit to marine biological resources and eliminates the previously permitted project's main contribution to cumulative impacts on biological resources. In addition, the removal of beach delivery option eliminates potential impacts to nearshore habitats and species.

Therefore, the resource protection measures included in existing COCs BIO-6 through BIO-12 and BIO-14 are adequate to address potential impacts to biological resources and therefore will not result in any significant cumulative impacts beyond those addressed in the CEC Final Decision for 00-AFC-14.

### 3.2.5 Laws, Ordinances, Regulations and Standards

The CEC Final Decision found the project to be in compliance with applicable biology LORS. As described in this PTA, the proposed ESPFM is consistent with applicable biology-related LORS and the Amendment will not alter the assumptions or conclusions in the CEC Final Decision and no additional or revised LORS compliance requirements have been identified.

### 3.2.6 Conditions of Certification

Existing COCs BIO-6 through BIO-12 and BIO-14 are adequate to address ESPFM without being amended, with the exception of the minor changes below that focus on the single fuel tank being removed as part of this PTA. These COCs are provided below.

**BIO-6 Designated Biologist:** The project owner shall submit the resume, including contact information, of the proposed Designated Biologist to the CPM for approval.

**Verification:** The project owner shall submit the specified information at least 60 days prior to the start of any site mobilization related to the beach front or the beach delivery system. These site and related facility activities shall not commence until an approved Designated Biologist is available to be on site.



The Designated Biologist must meet the following minimum qualifications:

- Bachelor's Degree in biological sciences, zoology, botany, ecology, or a closely related field;
- Three years of experience in field biology or current certification of a of a nationally recognized biological society, such as The Ecological Society of America or The Wildlife Society; and
- At least one year of field experience with biological resources found in or near the project area.

If a Designated Biologist needs to be replaced, then the specified information of the proposed replacement must be submitted to the CPM at least ten working days prior to the termination or release of the preceding Designated Biologist.

**BIO-7 Designated Biologist Duties:** The Designated Biologist shall perform the following during any ~~beach front or the beach delivery system~~ site mobilization, ground disturbance, grading, construction, operation and closure activities:

1. Advise the project owner's Construction/Operation Manager, supervising construction and operations engineer on the implementation of the biological resources Conditions of Certification;
2. Be available to supervise or conduct mitigation, monitoring, and other biological resources compliance efforts, particularly in areas requiring avoidance or containing sensitive biological resources, such as special status species or their habitat;
3. Clearly mark sensitive biological resource areas and inspect these areas at appropriate intervals for compliance with regulatory terms and conditions;
4. Notify the project owner and the CPM of any non-compliance with any biological resources Condition of Certification; and
5. Respond directly to inquiries of the CPM regarding biological resource issues.

**Verification:** The Designated Biologist shall maintain written records of the tasks described above, and summaries of these records shall be submitted in the Monthly Compliance Reports.

As necessary during project operation, the Designated Biologist shall submit record summaries in the Annual Compliance Report.

**BIO-8 Designated Biologist Authority:** The project owner's Construction/Operation Manager shall act on the advice of the Designated Biologist to ensure conformance with the biological resources Conditions of Certification.

If required by the Designated Biologist, the project owner's Construction/ Operation Manager shall halt all site mobilization, ground disturbance, grading, construction, and operation activities in areas specified by the Designated Biologist.

The Designated Biologist shall:

1. Require a halt to all activities in any area when determined that there would be adverse impact to biological resources if the activities continued;
2. Inform the project owner and the Construction/Operation Manager when to resume activities; and
3. Notify the CPM if there is a halt of any activities due to conflicts with biological resources, and advise the CPM of any corrective actions that have been taken, or will be instituted, as a result of the halt.

**Verification:** The Designated Biologist must notify the CPM immediately (and no later than the following morning of the incident, or Monday morning in the case of a weekend) of any non-compliance or a halt of any site mobilization, ground disturbance grading, construction and operation activities. The project owner shall notify the CPM of the circumstances and actions being taken to resolve the problem.

Whenever corrective action is taken by the project owner, a determination of success or failure will be made by the CPM within five working days after receipt of notice that corrective action is completed, or the project owner will be notified by the CPM that coordination with other agencies will require additional time before a determination can be made.

**BIO-9 Biological Resources Mitigation Implementation and Monitoring Plan:** The project owner shall submit to the CPM for review and approval a copy of the final Biological Resources Mitigation Implementation and Monitoring Plan (BRMIMP) and, once approved, shall implement the measures identified in the plan. ~~The BRMIMP shall apply to beach delivery activities only.~~

The BRMIMP shall include:

1. All new Biological Resource conditions included in the Energy Commission's Final Decision as amended;
2. All biological resources mitigation, monitoring, and compliance measures proposed and agreed to by the project owner;
3. A list and a map of locations of all sensitive biological resources to be impacted, avoided, or mitigated by project construction and operation;
4. A list of all terms and conditions set forth by USACE permits and necessary state LARWQCB certifications, should these become necessary throughout the life of the project;
5. Detailed descriptions of all measures that will be implemented to avoid and/or minimize impacts to sensitive species and reduce habitat disturbance;
6. All locations, on a map of suitable scale, of areas requiring temporary protection and avoidance during construction;
7. Duration for each type of monitoring and a description of monitoring methodologies and frequency;
8. Performance standards to be used to help decide if/when proposed mitigation is or is not successful;
9. All performance standards and remedial measures to be implemented if performance standards are not met;
10. A discussion of biological resource-related facility closure measures;
11. A process for proposing plan modifications to the CPM and appropriate agencies for review and approval;
12. A copy of any State or USFWS Biological Opinion or NMFS consultation, and incorporation of all terms and conditions into the final BRMIMP, should a biological opinion become necessary any time throughout the life of the project; and
- ~~13. Protocols for dealing with wildlife that gain access the barges, beach delivery ramp, and other project features whereby their well being could be at risk; and~~
13. Vegetation restoration that provides for planting seacliff buckwheat (*Eriogonum parviflorum*), eradication of ice plant (*Carpobrotus chilensis*), and is coordinated with Visual Resources landscaping requirements.

**Verification:** At least 30 days prior to start of any site mobilization ~~activities related to the beach front or the beach delivery system~~, the project owner shall provide the CPM with the final version of the BRMIMP for this project, and the CPM will determine the plans acceptability. The project owner shall notify the CPM five (5) working days before implementing any CPM approved modifications to the BRMIMP.

Within 30 days after completion of project construction, the project owner shall provide to the CPM for review and approval, a written report identifying which items of the BRMIMP have been completed, a summary of all modifications to mitigation measures made during the project's construction phase, and which mitigation and monitoring plan items are still outstanding.

**BIO-10 Worker Environmental Awareness Program:** The project owner shall develop and implement a CPM approved Worker Environmental Awareness Program in which each of its employees, as well as employees of contractors and subcontractors who work on the project site or related facilities during construction and operation, are informed about sensitive biological resources associated with the project. The training may be presented on electronic media in the form of a video recording.

The Worker Environmental Awareness Program must:

1. Be developed by the Designated Biologist and consist of an on-site or training center presentation in which supporting written material may be made available to all participants;
2. Discuss the locations and types of sensitive biological resources on the project site and adjacent areas;
3. Present the reasons for protecting these resources;
4. Present the meaning of various temporary and/or permanent habitat protection measures; and
5. Identify whom to contact if there are further comments and questions about the material discussed in the program.

The specific program can be administered by a competent individual(s) acceptable to the Designated Biologist. Each participant in the on-site Worker Environmental Awareness Program shall sign a statement declaring that the individual understands and shall abide by the guidelines set forth in the program materials. The person administering the program shall also sign each statement.

**Verification:** No less than 30 days prior to the start of any site mobilization activities ~~related to the beach front or the beach delivery system~~, the project owner shall provide copies of the Worker Environmental Awareness Program and all supporting written materials prepared by the Designated Biologist and the name and qualifications of the person(s) administering the program to the CPM for approval. The project owner shall state in the Monthly Compliance Report the number of persons who have completed the training in the prior month and keep record of all persons who have completed the training to date. The signed statements for the construction phase shall be kept on file by the project owner and made available for examination by the CPM for a period of at least six months after the start of commercial operation. During project operation, signed statements for active project operational personnel shall be kept on file for the duration of their employment and for six months after their termination.

**BIO-11 U.S. Army Corps of Engineers Permit:** The project owner shall acquire any USACE permit required and incorporate its terms and conditions into the BRMIMP.

**Verification:** No less than 30 days prior to the start of any site mobilization activities related to the beach front or the beach delivery system, the project owner shall submit to the CPM a copy of the USACE permit required to construct any project related features. Permit terms and conditions will be incorporated into the BRMIMP.

**BIO-12 USFWS Biological Opinion:** If formal or informal consultation between the USFWS and USACE occurs, the project owner shall incorporate into the BRMIMP any resulting biological resources recommendations.

**Verification:** No less than 30 days prior to the start of any site mobilization ~~activities related to the beach front or the beach delivery system~~, the project owner must provide the CPM with a copy of the USFWS recommendations. All terms and conditions resulting from the consultation will be incorporated into the BRMIMP.

**BIO-13 Los Angeles Regional Water Quality Control Board Certification:** The project owner will acquire and implement the terms and conditions of a Los Angeles Regional Water Quality Control Board Section 401 State Clean Water Act certification pertaining to the project.

**Verification:** No less than 30 days prior to the start of any site mobilization activities ~~related to the beach front or the beach delivery system~~, the project owner will provide the CPM with a copy of the final Regional Water Quality Control Board certification. The terms and conditions of the certification will be incorporated into the project's BRMIMP.

**BIO-14 Facility Closure:** The project owner will incorporate into the planned permanent or unexpected permanent closure plan measures that address the local biological resources. The biological resource facility closure measures will also be incorporated into the project BRMIMP.

**Verification:** At least 12 months (or a mutually agreed upon time) prior to the commencement of closure activities, the project owner shall address all biological resource-related issues associated with facility closure in a Biological Resources Element. The Biological Resources Element will be incorporated into the Facility Closure Plan, and include a complete discussion of the local biological resources and proposed facility closure mitigation measures.






**LEGEND**

|  |           |
|--|-----------|
|  | EI S      |
|  | Proj      |
|  | CNDDDB    |
|  | Special-S |
|  | Bea       |
|  | Coa       |
|  | Cou       |
|  | EI S      |
|  | Orca      |
|  | Pac       |
|  | Pro       |
|  | Special-S |
|  | Sou       |

Source: Ca





## 3.3 Cultural Resources

This section describes and evaluates potential effects the proposed changes may have on cultural resources. Compliance with applicable LORS is also addressed.

### 3.3.1 Amendment Overview

As discussed in detail in Section 2.0, Project Description, this PTA proposes modifications to the ESEC that necessitate evaluation of environmental impacts and potential amendments to existing COCs. The proposed PTA is for decommissioning, demolishing, and replacing the existing Units 3 and 4 steam boiler plants with approximately 449 MW gross / 435 MW net of new natural-gas-fired electrical generating capacity, consisting of one combined-cycle train and two simple-cycle gas turbines. The air-cooled, combined-cycle train (CC Fast) will consist of a GTG (Unit 9), a an HRSG, and one STG (Unit 10), rated at 325 MW net. The simple cycle turbines (Units 11 and 12) will consist of two air-cooled Trent 60 ISE advanced aeroderivative gas turbines, each rated at 55 MW net / 58 MW gross. The GE turbine will be supported by a small (36 MMBtu/hr) auxiliary boiler that will be incorporated into the operation of the CC Fast. Removal of existing Units 3 and 4 will eliminate the remaining once-through ocean water cooling system at the ESGS site. The ESPFM will improve electricity generation by adding fast-start and dispatch flexibility capability to support southern California grid load balancing. Total site capacity (including the new equipment previously permitted) will not exceed 1,020 MW net—the rated capacity of previously retired Units 1 and 2, plus the capacity of the soon-to-be-retired Unit 3 and operating Unit 4, which will also be retired as part of the ESPFM.

### 3.3.2 Affected Environment

#### 3.3.2.1 ESEC Amendments

The proposed ESPFM will result in modifications to the ESEC license (00-AFC-14C). Decommissioning, demolishing, and removing existing Units 3 and 4 and replacing them with new Units 9, 10, 11 and 12 will not result in new impacts to cultural resources beyond those identified in the CEC's amended license for 00-AFC-14C and as described in Section 2.0. It is anticipated that demolition of Units 3 and 4 and construction of Units 9–12 will require grading and excavation activities similar to the demolition of Units 1 and 2 and construction activities associated with Units 5 through 8 and their supporting equipment and structures. Demolition of Units 1 and 2, construction of Units 5 through 8, and construction of balance of plant facilities (entrance road modification, transmission tower installation, 45th Street berm construction and neighboring tank farm area grading, and demineralization water treatment and storage) has resulted in the investigation of subsurface soil for cultural resources in substantially the entire facility, with the exception of the Units 3 and 4 powerblock area and SCE switchyard. It is anticipated that the cultural resource observations beneath Units 3 and 4, if discovered, will not be significant based on the extensive inspection by the Cultural Resource Specialist and Monitors during the ESEC construction. The resource protection measures included in existing COCs CUL-1 through CUL-7 are adequate to address potential impacts to cultural resources during construction. The following is a brief description of the cultural resources existing COCs:

- **CUL-1** Designated Cultural Resources Specialist
- **CUL-2** Project Maps Showing Ground Disturbance
- **CUL-3** Cultural Resources Monitoring and Mitigation Plan
- **CUL-4** Cultural Resources Report
- **CUL-5** Worker Environmental Awareness Program
- **CUL-6** Cultural Resources Monitoring
- **CUL-7** Designated Cultural Resource Specialist Authority
- **CUL-8** Water Pipeline Realignment

ESEC LLC will continue to comply with the requirements set forth in these COCs.



### 3.3.3 Environmental Analysis

As discussed in Section 2.0, Project Description, the demolition and removal of Units 3 and 4 and the installation and operation of new Units 9 through 12 will result in similar grading, excavation, foundation, and underground infrastructure activities as were required for the demolition of Units 1 and 2 and the construction of Units 5 through 8. Furthermore, because subsurface activities required for ESPFM are expected to occur in areas of the ESGS site that have been previously disturbed as part of historical power plant operations at the site, including the most current subsurface activities required for the demolition of Units 1 and 2 and construction of Units 5 through 8, no impacts beyond those described in 00-AFC-14 are anticipated. Therefore, the resource protection measures included in existing COCs CUL-1 through CUL-7 are adequate to address potential impacts to cultural resources and the demolition and construction activities will be conducted in accordance with these COCs and all applicable LORS.

#### 3.3.3.1 Offsite Construction Laydown and Construction Worker Parking Areas

The preferred offsite laydown area, located at 777 W. 190th Street in the City of Gardena, was incorporated into ESEC in the 2010 PTA decision and will continue to be used for ESPFM. Construction laydown and parking areas will also be established within the ESGS site boundary, as well as at offsite areas identified in the CEC Final Decision and shown on Figure 2-10. The 190th Street area is less than ten miles southeast of the ESGS and is easily accessible to the I-405 and I-110 North freeways from Vermont Avenue and 190th Street as well as to ESEC-approved traffic/truck routes. This site, zoned M2, commercial, has approximately ten usable acres and includes a 5,500 square-foot industrial building. The approximately 12.1-acre site paved with asphalt has nightlighting and includes a perimeter security fence. No site preparation other than minor clean-up is required prior to use. The existing COCs ensure that construction-related activities at the approved laydown areas will comply with appropriate cultural resource protection plans and no cultural resource impacts will result from using offsite construction laydown and parking areas.

#### 3.3.4 Cumulative Impacts

The proposed ESPFM covered under this PTA will result in similar subsurface activities required for the previous demolition of Units 1 and 2 and previous construction of Units 5 through 8 and their supporting equipment and structures. ESPFM subsurface demolition and construction activities are expected to occur in areas of the ESGS site that have been previously disturbed as part of historical power plant operations at the site and impacts beyond those described in 00-AFC-14 are not anticipated. Therefore, the resource protection measures included in existing COCs CUL-1 through CUL-7 are adequate to address potential impacts to cultural resources and therefore will not result in any significant cumulative impacts beyond those addressed in the CEC Final Decision for 00-AFC-14.

#### 3.3.5 Laws, Ordinances, Regulations and Standards

The CEC Final Decision found the project to be in compliance with applicable cultural resources LORS. As described in this Amendment, the proposed ESPFM is consistent with applicable cultural-related LORS and the Amendment will not alter the assumptions or conclusions in the CEC Final Decision and no additional or revised LORS compliance requirements have been identified.

#### 3.3.6 Conditions of Certification

Existing COCs CUL-1 through CUL-7 are adequate to address ESPFM without being amended, with the exception of the minor changes below that focus on the single fuel tank being removed, construction of the offsite reclaimed water line, and any references to work or delivery on the beach as part of this PTA. These COCs are provided below.

**CUL-1 Designated Cultural Resources Specialist:** Prior to the start of ground disturbance, the project owner shall submit the resume of the proposed Cultural Resources Specialist (CRS), and one alternate CRS, if an alternate is proposed, to the CPM for review and approval. The CRS will be responsible for implementation of all cultural

resources conditions of certification and may obtain qualified cultural resource monitors (CRMs) to monitor as necessary on the project.

The resume for the CRS and alternate, shall include information that demonstrates that the minimum qualifications specified in the U.S. Secretary of Interior Guidelines, as published by the CFR 36, CFR Part 61 are met. In addition, the CRS shall have the following qualifications:

- a. The technical specialty of the CRS shall be appropriate to the needs of the project and shall include, a background in anthropology, archaeology, history, architectural history or a related field;
- b. At least three years of archaeological or historic, as appropriate, resource mitigation and field experience in California; and

The resume shall include the names and phone numbers of contacts familiar with the work of the CRS on referenced projects and demonstrate that the CRS has the appropriate education and experience to accomplish the cultural resource tasks that must be addressed during ground disturbance, grading, construction and operation. In lieu of the above requirements, the resume shall demonstrate to the satisfaction of the CPM, that the proposed CRS or alternate has the appropriate training and background to effectively implement the conditions of certification.

CRMs shall meet the following qualifications:

- a. A BS or BA degree in anthropology, archaeology, historic archaeology or a related field and one year experience monitoring in California; or
- b. An AS or AA in anthropology, archaeology, historic archaeology or a related field and four years experience monitoring in California; or
- c. Enrollment in upper division classes pursuing a degree in the fields of anthropology, archaeology, historic archaeology or a related field and two years of monitoring experience in California.

The project owner shall ensure that the CRS completes any monitoring, mitigation and curation activities necessary; fulfills all the requirements of these conditions of certification; ensures that the CRS obtains technical specialists, and CRMs, if needed; and that the CRS evaluates any cultural resources that are newly discovered or that may be affected in an unanticipated manner for eligibility to the California Register of Historic Resources (CRHR).

**Verification:** The project owner shall submit the subject qualifications at least 45 days prior to the start of ground disturbance. At least 10 days prior to a termination or release of the CRS, the project owner shall submit the resume of the proposed replacement CRS. At least 20 days prior to ground disturbance, the CRS shall submit written notification identifying anticipated CRMs for the project stating they meet the minimum qualifications required by this condition. If additional CRMs are needed later, the CRS shall submit written notice one week prior to any new CRMs beginning work.

**CUL-2 Project Maps Showing Ground Disturbance:** Prior to the start of ground disturbance, the project owner shall provide the CRS and the CPM with maps and drawings showing the footprint of the power plant and all linear facilities. Maps will include the appropriate USGS quadrangles and a map at an appropriate scale (e.g., 1:2000 or 1" = 200') for plotting individual artifacts. If the CRS requests enlargements or strip maps for linear facility routes, the project owner shall provide copies to the CRS and CPM.

If the footprint of the power plant or linear facilities changes, the project owner shall provide maps and drawings reflecting these changes, to the CRS and the CPM for approval. Maps shall identify all areas of the project where ground disturbance is anticipated.

If construction of the project will proceed in phases, maps and drawings, not previously submitted, shall be submitted prior to the start of each phase. Written notification identifying the proposed schedule of each project phase shall be provided to the CRS and CPM.

At a minimum, the CRS shall consult weekly with the project construction manager to confirm area(s) to be worked during the next week, until ground disturbance is completed.

The project owner shall notify the CRS and CPM of any changes to the scheduling of the construction phases.

**Verification:** The project owner shall submit the subject maps and drawings at least 40 days prior to the start of ground disturbance.

If there are changes to any project related footprint, revised maps and drawings shall be provided at least 15 days prior to start of ground disturbance for those changes.

If project construction is phased, the project owner shall submit the subject maps and drawings 15 days prior to each phase.

A current schedule of anticipated project activity shall be provided to the CRS on a weekly basis during ground disturbance and also provided in each Monthly Compliance Report (MCR).

The project owner shall provide written notice of any changes to scheduling of construction phases within 5 days of identifying the changes. A copy of the current schedule of anticipated project activities shall be submitted in each MCR.

**CUL-3 Cultural Resources Monitoring and Mitigation Plan:** Prior to the start of ground disturbance, the project owner shall submit the Cultural Resources Monitoring and Mitigation Plan (CRMMP), as prepared by the CRS, to the CPM for approval. The CRMMP shall identify general and specific measures to minimize potential impacts to sensitive cultural resources. Copies of the CRMMP shall reside with the CRS, alternate CRS, each monitor, and the project owner's on-site manager. No ground disturbance shall occur prior to CPM approval of the CRMMP, unless specifically approved by the CPM.

The CRMMP shall include, but not be limited to, the following elements and measures.

1. The following statement shall be added to the Introduction: Any discussion, summary, or paraphrasing of the conditions in this CRMMP is intended as general guidance and as an aid to the user in understanding the conditions and their implementation. If there appears to be a discrepancy between the conditions and the way in which they have been summarized described, or interpreted in the CRMMP, the conditions, as written in the Final Decision, supersede any interpretation of the Conditions in the CRMMP. The cultural resources conditions of certification are attached as an appendix to this CRMMP.
2. A proposed general research design that includes a discussion of research questions and testable hypotheses applicable to the project area. A refined research design will be prepared for any resource where data recovery is required.
3. Specification of the implementation sequence and the estimated time frames needed to accomplish all project-related tasks during ground disturbance, construction, and post-construction analysis phases of the project.
4. Identification of the person(s) expected to perform each of the tasks, their responsibilities; and the reporting relationships between project construction management and the mitigation and monitoring team.
5. A discussion of the inclusion of Native American observers or monitors, the procedures to be used to select them, and their role and responsibilities.
6. A discussion of all avoidance measures such as flagging or fencing, to prohibit or otherwise restrict access to sensitive resource areas that are to be avoided during construction and/or operation, and identification of areas where these measures are to be implemented. The discussion shall address how these measures will be implemented prior to the start of construction and how long they will be needed to protect the resources from project-related effects.

7. A discussion of the requirement that all cultural resources encountered will be recorded on a DPR form 523 and mapped (may include photos). In addition, all archaeological materials collected as a result of the archaeological investigations (survey, testing, data recovery) shall be curated in accordance with The State Historical Resources Commission's "Guidelines for the Curation of Archaeological Collections," into a retrievable storage collection in a public repository or museum. The public repository or museum must meet the standards and requirements for the curation of cultural resources set forth at Title 36 of the Federal Code of Regulations, Part 79.
8. A discussion of any requirements, specifications, or funding needed for curation of the materials to be delivered for curation and how requirements, specifications and funding will be met. The name and phone number of the contact person at the institution. Include a statement in the discussion of requirements that the project owner will pay all curation fees and that any agreements concerning curation will be retained and available for audit for the life of the project.
9. A discussion of the availability and the designated specialist's access to equipment and supplies necessary for site mapping, photographing, and recovering any cultural resource materials encountered during construction.
10. A discussion of the proposed Cultural Resource Report (CRR) which shall be prepared according to Archaeological Resource Management Report (ARMR) Guidelines.

**Verification:** The project owner shall submit the subject CRMMP at least 30 days prior to the start of ground disturbance. Per ARMR Guidelines the author's name shall appear on the title page of the CRMMP. Ground disturbance activities may not commence until the CRMMP is approved. At least 30 days prior to ground disturbance, a letter shall be provided to the CPM indicating that the project owner will pay curation fees for any materials collected as a result of the archaeological investigations (survey, testing, data recovery).

**CUL-4 Cultural Resources Report:** The project owner shall submit the Cultural Resources Report (CRR) to the CPM for approval. The CRR shall report on all field activities including dates, times and locations, findings, samplings and analysis. All survey reports, DPR 523 forms and additional research reports not previously submitted to the California Historic Resource Information System (CHRIS) shall be included as an appendix to the CRR.

**Verification:** The project owner shall submit the subject CRR within 90 days after completion of ground disturbance (including landscaping). Within 10 days after CPM approval, the project owner shall provide documentation to the CPM that copies of the CRR have been provided to the curating institution (if archaeological materials were collected), the State Historic Preservation Officer (SHPO) and the CHRIS.

**CUL-5 Worker Environmental Awareness Program:** Worker Environmental Awareness Program (WEAP) shall be provided, on a weekly basis, to all new employees starting prior to and for the duration of, ground disturbance.

The training may be presented in the form of a video. The training shall include:

1. A discussion of applicable laws and penalties under the law;
2. Samples or visuals of artifacts that might be found in the project vicinity;
3. Information that the CRS, alternate CRS, and CRMs have the authority to halt construction to the degree necessary, as determined by the CRS, in the event of a discovery or unanticipated impact to a cultural resource;
4. Instruction that employees are to halt work on their own in the vicinity of a potential cultural resources find, and shall contact their supervisor and the CRS or CRM; redirection of work will be determined by the construction supervisor and the CRS;
5. An informational brochure that identifies reporting procedures in the event of a discovery;
6. An acknowledgement form signed by each worker indicating that they have received the training; and
7. A sticker that shall be placed on hard hats indicating that environmental training has been completed.

**Verification:** The project owner shall provide in the Monthly Compliance Report the WEAP Certification of Completion form of persons who have completed the training in the prior month and a running total of all persons who have completed training to date.

**CUL-6 Cultural Resources Monitoring:** The CRS, alternate CRS, or monitors shall monitor ground disturbance full time in the vicinity of the project site, linear facilities and ground disturbance at laydown areas or other ancillary areas to ensure there are no impacts to undiscovered resources and to ensure that known resources are not impacted in an unanticipated manner. In the event that the CRS determines that full-time monitoring is not necessary in certain locations, a letter or e-mail providing a detailed justification for the decision to reduce the level of monitoring shall be provided to the CPM for review and approval prior to any reduction in monitoring.

CRMs shall keep a daily log of any monitoring or cultural resource activities and the CRS shall prepare a weekly summary report on the progress or status of cultural resources-related activities. The CRS may informally discuss cultural resource monitoring and mitigation activities with Energy Commission technical staff.

The CRS shall notify the project owner and the CPM, by telephone or e-mail, of any incidents of non-compliance with any cultural resources conditions of certification within 24 hours of becoming aware of the situation. The CRS shall also recommend corrective action to resolve the problem or achieve compliance with the conditions of certification. Cultural resources monitoring activities are the responsibility of the CRS. Any interference with monitoring activities, removal of a monitor from duties assigned by the CRS or direction to a monitor to relocate monitoring activities by anyone other than the CRS shall be considered non-compliance with these conditions of certification.

A Native American monitor shall be obtained to monitor ground disturbance in areas where Native American artifacts may be discovered. Informational lists of concerned Native Americans and Guidelines for monitoring shall be obtained from the Native American Heritage Commission. Preference in selecting a monitor shall be given to Native Americans with traditional ties to the area that will be monitored.

**Verification:**

1. During the ground disturbance phases of the project, if the CRS wishes to reduce the level of monitoring occurring at the project, a letter identifying the area(s) where the CRS recommends the reduction and justifying the reductions in monitoring shall be submitted to the CPM for review and approval.
2. During the ground disturbance phases of the project, the project owner shall include in the MCR to the CPM copies of the weekly summary reports prepared by the CRS regarding project-related cultural resources monitoring. Copies of daily logs shall be retained onsite and made available for audit by the CPM.
3. Within 24 hours of recognition of a non-compliance issue, the CRS shall notify the CPM by telephone of the problem and of steps being taken to resolve the problem. The telephone call shall be followed by an e-mail or fax detailing the non-compliance issue and the measures necessary to achieve resolution of the issue. Daily logs shall include forms detailing any instances of non-compliance with conditions of certification. In the event of a non-compliance issue, a report written no sooner than two weeks after resolution of the issue that describes the issue, resolution of the issue and the effectiveness or the resolution measures, shall be provided in the next MCR.
4. One week prior to ground disturbance in areas where there is a potential to discover Native American artifacts, the project owner shall send notification to the CPM identifying the person(s) retained to conduct Native American monitoring. If efforts to obtain the services of a qualified Native American monitor are unsuccessful, the project owner shall immediately inform the CPM who will initiate a resolution process.

**CUL-7 Designated Cultural Resource Specialist Authority:** The CRS, alternate CRS and the CRMs shall have the authority to halt construction if previously unknown cultural resource sites or materials are encountered, or if known resources may be impacted in a previously unanticipated manner. Redirection of ground disturbance shall be accomplished under the direction of the construction supervisor.

If such resources are found or impacts can be anticipated, the halting or redirection of construction shall remain in effect until all of the following have occurred:

1. The CRS has notified the project owner, and the CPM has been notified within 24 hours of the find description and the work stoppage;
2. The CRS, the project owner, and the CPM have conferred and determined what, if any, data recovery or other mitigation is needed;
3. Any necessary data recovery and mitigation has been completed.

**Verification:** At least 30 days prior to the start of ground disturbance, the project owner shall provide the CPM with a letter confirming that the CRS, alternate CRS and CRMs have the authority to halt construction activities in the vicinity of a cultural resource find, and that the CRS or project owner will notify the CPM immediately (no later than the following morning of the incident or Monday morning in the case of a weekend) of any halt of construction activities, including the circumstance and proposed mitigation measures. The project owner shall provide the CRS with a copy of the letter granting the authority to halt.

~~**CUL-8 Water Pipeline Realignment:** The route for the water lines shall extend down Grand Avenue to Eucalyptus St. to El Segundo Blvd, which is within the water pipeline study area, bordered by El Segundo Blvd., Loma Vista St., Grand Ave. and Eucalyptus St. (Applicant has conducted a cultural resources assessment in the pipeline study area and within the area defined as the proposed project). If the water lines and associated pipelines are to be located anywhere but in an area originally defined as part of the proposed project, a cultural resource assessment shall be conducted prior to any ground disturbance. The cultural resource assessment shall consist of a records search and a pedestrian survey. This approach gives equal emphasis to prehistoric and historic resources and an evaluation of significance. A Native American monitor from a group with historic ties to the affected area shall be retained as part of the cultural resources team during any surveys or subsurface investigation.~~

~~**Verification:** Forty days prior to the start of any ground disturbance or project site preparation at the newly identified location of the waterlines and associated pipelines, the project owner shall submit the following for approval by the CPM: (1) the results of the records search and the results of the survey; (2) an evaluation, including site records, of all cultural resources within or adjacent to the project Area of Potential Effects; and (3) the information shall also include the name and tribal affiliation of the Native American monitor.~~



## 3.4 Geology and Paleontology

This section describes and evaluates potential effects the proposed changes may have on geology and paleontology resources. Compliance with applicable LORS is also addressed.

### 3.4.1 Amendment Overview

As discussed in detail in Section 2.0, Project Description, this PTA proposes modifications to the ESEC that necessitate evaluation of environmental impacts and potential amendments to existing COCs. The proposed PTA is for decommissioning, demolishing, and replacing the existing Units 3 and 4 steam boiler plants with approximately 449 MW gross / 435 MW net of new natural-gas-fired electrical generating capacity, consisting of one combined-cycle train and two simple-cycle gas turbines. The air-cooled, combined-cycle train (CC Fast) will consist of a GTG (Unit 9), a an HRSG, and one STG (Unit 10), rated at 325 MW net. The simple cycle turbines (Units 11 and 12) will consist of two air-cooled Trent 60 ISE advanced aeroderivative gas turbines, each rated at 55 MW net / 58 MW gross. The GE turbine will be supported by a small (36 MMBtu/hr) auxiliary boiler that will be incorporated into the operation of the CC Fast. Removal of existing Units 3 and 4 will eliminate the remaining once-through ocean water cooling system at the ESGS site. The ESPFM will improve electricity generation by adding fast-start and dispatch flexibility capability to support southern California grid load balancing. Total site capacity (including the new equipment previously permitted) will not exceed 1,020 MW net—the rated capacity of previously retired Units 1 and 2, plus the capacity of the soon-to-be-retired Unit 3 and operating Unit 4, which will also be retired as part of the ESPFM.

### 3.4.2 Affected Environment

#### 3.4.2.1 ESEC Amendments

The proposed ESPFM will result in modifications to the ESEC license (00-AFC-14C). Decommissioning, demolishing, and removing existing Units 3 and 4 and replacing them with new Units 9, 10, 11, and 12 will not result in new impacts to geology and paleontology resources beyond those identified in the CEC's amended license for 00-AFC-14C and as described in Section 2.0. It is anticipated that demolition of Units 3 and 4 and construction of Units 9–12 will require grading and excavation activities similar to the demolition of Units 1 and 2 and construction activities associated with Units 5 through 8 and their supporting equipment and structures. Demolition of Units 1 and 2, construction of Units 5 through 8, and construction of balance of plant facilities (entrance road modification, transmission tower installation, 45th Street berm construction and neighboring tank farm area grading, and demineralization water treatment and storage) has resulted in the investigation of subsurface soil for paleontological resources in substantially the entire facility, with the exception of the Units 3 and 4 powerblock area and SCE switchyard. It is anticipated that the paleontological resource observations beneath Units 3 and 4, if discovered, will not be significant based on the extensive inspection by the paleontological resource specialist and monitors during the ESEC construction. The resource protection measures included in existing COCs GEO-1 through GEO-6 and PAL-1 through PAL-7 are adequate to address potential impacts to geology and paleontology resources. The following is a brief description of the geology and paleontology existing COCs:

**GEO-1:** Engineering Geologist/Geotechnical Engineer

**GEO-2:** Liquefaction Analysis

**GEO-3:** Slope Stability Analysis

**GEO-4:** Coastal or Geotechnical

**GEO-5:** Building Code Compliance

**GEO-6:** Seawall Design

**PAL-1:** Paleontological Resource Specialist (PRS)

**PAL-2:** Paleontology Resource Maps

**PAL-3:** Paleontological Resources Monitoring and Mitigation Plan (PRMMP)

**PAL-4:** Worker Environmental Awareness Program (WEAP)

**PAL-5:** Resource Monitoring



**PAL-6:** Curation Agreement

**PAL-7:** Paleontological Resources Report (PRR)

ESEC LLC will continue to comply with the requirements set forth in these COCs.

### 3.4.3 Environmental Analysis

As discussed in Section 2.0, Project Description, the demolition and removal of Units 3 and 4 and the installation and operation of new Units 9, 10, 11, and 12 will result in similar grading, excavation, foundation, and underground infrastructure activities as was required for the demolition of Units 1 and 2 and the construction of Units 5 through 8. Further, because subsurface activities required for ESPFM are expected to occur in areas of the site that have been previously disturbed as part of historical power plant operations at the site, including the most current subsurface activities required for the demolition of Units 1 and 2 and construction of Units 5 through 8, no impacts beyond those described in 00-AFC-14 are anticipated. Therefore, the resource protection measures included in existing COCs GEO-1 through GEO-6 and PAL-1 through PAL-7 are adequate to address potential impacts to geology and paleontology resources and the ESPFM demolition and construction activities will be conducted in accordance with these CECs all applicable LORS.

#### 3.4.3.1 Offsite Construction Laydown and Construction Worker Parking Areas

The preferred offsite laydown area, located at 777 W. 190th Street in the City of Gardena, was incorporated into ESEC in the 2010 PTA decision and will continue to be used for ESPFM. Construction laydown and parking areas will also be established within the ESGS site boundary, as well as at offsite areas identified in the CEC Final Decision and shown on Figure 2-10. The 190th Street area is less than ten miles southeast of the ESGS and is easily accessible to the I-405 and I-110 North freeways from Vermont Avenue and 190th Street as well as to ESEC-approved traffic/truck routes. This site, zoned M2, commercial, has approximately ten usable acres and includes a 5,500 square-foot industrial building. The approximately 12.1-acre site paved with asphalt has nightlighting and includes a perimeter security fence. No site preparation other than minor clean-up is required prior to use. The existing COCs ensure that construction-related activities at the approved laydown areas will comply with appropriate geology and paleontology resource protection plans and no geology or paleontology resource impacts will result from using offsite construction laydown and parking areas.

### 3.4.4 Cumulative Impacts

The proposed ESPFM covered under this PTA will result in similar subsurface activities required for the demolition of Units 1 and 2 and construction of Units 5 through 8. ESPFM subsurface demolition and construction activities are expected to occur in areas of the ESGS site that have been previously disturbed as part of historical power plant operations at the site and impacts beyond those described in 00-AFC-14 are not anticipated. Therefore, the resource protection measures included in existing COCs GEO-1 through GEO-6 and PAL-1 through PAL-7 are adequate to address potential impacts to geology and paleontology resources and therefore will not result in any significant cumulative impacts beyond those addressed in the CEC Final Decision for 00-AFC-14.

### 3.4.5 Laws, Ordinances, Regulations and Standards

The CEC Final Decision found the project to be in compliance with applicable geology and paleontology LORS. As described in this PTA, the proposed ESPFM is consistent with applicable geology and paleontology-related LORS and the Amendment will not alter the assumptions or conclusions in the CEC Final Decision and no additional or revised LORS compliance requirements have been identified.

### 3.4.6 Conditions of Certification

Existing COCs existing are adequate to address ESPFM, with the exception of the minor changes below that focus on the new entrance road. In addition, those COCs for which compliance has been demonstrated as part of 00-AFC-14C have been deleted and updates to regulatory standards are reflected as proposed changes. These COCs are provided below.

**GEO-1:** Prior to the start of construction, the project owner shall assign to the project an engineering geologist(s) and a geotechnical engineer(s) certified by the State of California, to carry out the duties required by the 2010 ~~2001~~ edition of the California Building Code (CBC) Appendix Chapter 33, Section 3309.4. The certified engineering geologist(s) and geotechnical engineer(s) assigned must be approved by the CBO and submitted to the Compliance Project Manager (CPM) for concurrence.

**Verification:** At least 30 days (or a lesser number of days mutually agreed to by the project owner and the CPM) prior to the start of construction, the project owner shall submit to the CBO for approval the resume and license number(s) of the certified engineering geologist(s) and geotechnical engineer(s) assigned to the project. The submittal should include a statement that CPM concurrence is needed. The CBO and CPM will approve or disapprove of the engineering geologist(s) and geotechnical engineer(s) and will notify the project owner of its findings within 15 days of receipt of the submittal. If the engineering geologist(s) and geotechnical engineer(s) are subsequently replaced, the project owner shall submit for approval the resume(s) and license number(s) of the newly assigned individual(s) to the CBO and CPM. The CBO and CPM will approve or disapprove of the engineering geologist(s) and geotechnical engineer(s) and will notify the project owner of the findings within 15 days of receipt of the notice of personnel change.

**GEO-2:** Prior to the initiation of ground disturbance, the owner shall have a liquefaction analysis conducted for the power plant site and adjacent existing cut slope to the east. The liquefaction analysis shall be implemented by following the recommended procedures contained in *Recommended Procedures for Implementation of California Division of Mines and Geology Special Publication 117, Guidelines for Analyzing and Mitigating Liquefaction Hazards in California* dated March 1999. (The document is available through the Southern California Earthquake Center at the University of Southern California.)

**Verification:** The project owner shall include in the application for a grading permit (see Condition of Certification GEO-5) a report of the liquefaction analysis and a summary of how the results of this analysis were incorporated into the project foundation and grading plan design for the CBO's review and comment. A copy of the liquefaction analysis and summary of incorporated results shall be sent to the CPM prior to grading.

**GEO-3:** Prior to completion of the final design of the project, the owner shall have a slope stability analysis conducted for the existing cut slope east of Units 1 and 2 and 3 and 4. The analysis shall consider both static and earthquake conditions, as well as the effects of any liquefaction of the foundation soils. Since cohesionless soils may be present, the proposed 1.5:1 perimeter excavation should also be evaluated for stability, but only for static conditions.

**Verification:** The project owner shall include in the application for a grading permit (see Condition of Certification GEO-5 below) a report of the slope stability analysis and a summary of how the results of this analysis were incorporated into the project foundation and grading plan for the CBO's review and comment. A copy of the CBO's comments shall be sent to the CPM prior to grading.

**GEO-4:** Applicant shall designate and use a Coastal or Geotechnical Engineer, or geologist familiar with geomorphology, to conduct a shoreline monitoring program and assess erosion on the beach area and at the foot of the revetment on an annual basis for at least ten years. Applicant shall report such results to the CPM and California Coastal Commission annually. (Readers' note: Compliance with this COC is being implemented as part of ESEC and is not necessary to apply to ESPFM).

A detailed baseline survey is required, along with some historical research including air photos, a summary of past beach nourishment and shoreline damage. Sand sampling and testing shall be conducted. A series of onshore/offshore shore-normal transects every few hundred feet shall be conducted 4 times per year. Annually, photos from set positions can be taken (e.g. from the groin and from a high elevation in the plant). Shoreline response during and after a major storm will be documented.

After ten continuous years of monitoring, the owner shall prepare and submit a final report. The final report will serve as the annual report for year ten and will include a summary of findings over the 10-year period. Based on the ten-year summary report, the final report will include recommendations for either:

- a. Continued monitoring on an annual basis in accordance with the established protocol if there is evidence of an adverse shoreline erosion condition;
- b. Modifications to the monitoring program and continuation of the program, if modifications are warranted to increase, decrease, otherwise adjust the type and frequency of data collected; or,
- c. Suspension of monitoring due to absence of an adverse shoreline erosion condition related to construction and operation of the ESPR.

**Verification:** At least thirty days prior to commencing construction, the Applicant shall designate the geologist and submit for approval the resumes of the engineer or geologist to the CBO and CPM. The engineer or geologist shall be experienced in shoreline monitoring, and understand coastal processes. Applicant shall submit as part of its annual compliance report the results of the assessment. Applicant shall also, at that time, forward the results to the California Coastal Commission and the City of El Segundo with a copy of the transmittal letter to the CPM. During the first 3 years following commencement of construction, the Applicant shall submit the above mentioned quarterly reports. The tenth annual report shall contain the final report.

**GEO-5:** The assigned engineering geologist(s) shall carry out the duties required by the ~~2010~~ 1998 CBC, Appendix Chapter 33, Section 3309.4 Engineered Grading Requirements, and Section 3318.1 – Final Reports. Those duties are:

- a. Prepare the Engineering Geology Report. This report shall accompany the Plans and Specifications when applying to the CBO for the grading permit.
- b. Monitor geologic conditions during construction.
- c. Prepare the Final Engineering Geology Report.

The *Engineering Geology Report* required by the ~~2010~~1998-CBC Appendix Chapter 33, Section 3309.3 Grading Designation, shall include an adequate description of the geology of the site, conclusions, and recommendations regarding the effect of geologic conditions on the proposed development, and an opinion on the adequacy of the site for the intended use as affected by geologic factors.

The *Final Engineering Geology Report* to be completed after completion of grading, as required by the ~~2010~~ 1998 CBC Appendix Chapter 33, Section 3318.1, shall contain the following: A final description of the geology of the site and any new information disclosed during grading; and the effect of same on recommendations incorporated in the approved grading plan. The engineering geologist shall submit a statement that, to the best of his or her knowledge, the work within their area of responsibility is in accordance with the approved Engineering Geology Report and applicable provisions of this chapter.

**Verification:**

1. Within 15 days after submittal of the application(s) for grading permit(s) to the CBO, the project owner shall submit a signed statement to the CPM stating that the Engineering Geology Report has been submitted to the CBO as a supplement to the plans and specifications and that the recommendations contained in the report are incorporated into the plans and specifications.
2. Within 90 days following completion of the final grading, the project owner shall submit copies of the Final Engineering Geology Report required by the 1998 CBC Appendix Chapter 33, Section 3318 Completion of Work, to the CBO and to the CPM.

**GEO-6:** The design for additional seawall or perimeter wall, including any necessary modifications to the existing seawall, shall be performed by a coastal engineer, geotechnical engineer, or engineering geologist, familiar with coastal processes and in accordance with the requirements of the California Coastal Commission Procedural Memo #19 (July 29, 1992).

If additional seawall is installed, performance of the seawall, with respect to shoreline erosion, will need to be addressed and verified in the shoreline monitoring program described under GEO-4. The wall should be textured and colored appropriately to minimize visual impacts.

**Verification:** Once a seawall design plan is available, the Applicant shall obtain approval of the design and construction methods from the CBO who will forward all approved plans and comments to the CPM. The CPM shall then forward this information to the Coastal Commission and the City of El Segundo.

**PAL-1:** The project owner shall provide the CPM with the resume and qualifications of its Paleontological Resource Specialist (PRS) and Paleontological Resource Monitors (PRMs) for review and approval. If the approved PRS or one of the PRMs is replaced prior to completion of project mitigation and report, the project owner shall obtain CPM approval of the replacement.

The resume shall include the names and phone numbers of contacts. The resume shall also demonstrate to the satisfaction of the CPM, the appropriate education and experience to accomplish the required paleontological resource tasks.

As determined by the CPM, the PRS shall meet the minimum qualifications for a vertebrate paleontologist as described in the Society of Vertebrate Paleontologists (SVP) guidelines of 1995. The experience of the PRS shall include the following:

- a. Institutional affiliations or appropriate credentials and college degree;
- b. Ability to recognize and recover fossils in the field;
- c. Local geological and biostratigraphic expertise;
- d. Proficiency in identifying vertebrate and invertebrate fossils;
- e. Publications in scientific journals; and
- f. The PRS shall have at least three years of paleontological resource mitigation and field experience in California, and at least one year of experience leading paleontological resource mitigation and field activities.

The PRS shall obtain qualified paleontological resource monitors to monitor as necessary on the project. Paleontological resource monitors (PRMs) shall have the equivalent of the following qualifications:

- a. BS or BA degree in geology or paleontology and one year experience monitoring in California; or
- b. AS or AA in geology, paleontology or biology and four years experience monitoring in California; or
- c. Enrollment in upper division classes pursuing a degree in the fields of geology or paleontology and two years of monitoring experience in California.

**Verification:** At least 60 days prior to the start of ground disturbance, the project owner shall submit a resume and statement of availability of its designated PRS for on-site work. At least 20 days prior to ground disturbance, the PRS or project owner shall provide a letter with resumes naming anticipated monitors for the project and stating that the identified monitors meet the minimum qualifications for paleontological resource monitoring required by the condition. If additional monitors are obtained during the project, the PRS shall provide additional letters and resumes to the CPM for approval. The letter shall be provided to the CPM no later than one week prior to the monitor beginning on-site duties.

Prior to the termination or release of a PRS, the project owner shall submit the resume of the proposed new PRS to the CPM for review and approval.

**PAL-2:** The project owner shall provide to the PRS and the CPM, for approval, maps and drawings showing the footprint of the power plant and all linear facilities. Maps shall identify all areas of the project where ground disturbance is anticipated. If the PRS requests enlargements or strip maps for linear facility routes, the project owner shall provide copies to the PRS and CPM. The site grading plan and the plan and profile drawings for the utility lines would normally be acceptable for this purpose. The plan drawings should show the location, depth, and extent of all ground disturbances and can be 1 inch = 40 feet to 1 inch = 100 feet range. If the footprint of the power plant or linear facility changes, the project owner shall provide maps and drawings reflecting these changes to the PRS and CPM.

If construction of the project will proceed in phases, maps and drawings may be submitted prior to the start of each phase. A letter identifying the proposed schedule of each project phase shall be provided to the PRS and CPM. Prior to work commencing on affected phases, the project owner shall notify the PRS and CPM of any construction phase scheduling changes.

At a minimum, the PRS shall consult weekly with the project superintendent or construction field manager to confirm area(s) to be worked during the next week, until ground disturbance is completed.

**Verification:**

1. At least 30 days prior to the start of ground disturbance, the project owner shall provide the maps and drawings.
2. If there are changes to the footprint of the project, revised maps and drawings shall be provided at least 15 days prior to the start of ground disturbance.
3. If there are changes to the scheduling of the construction phases, the project owner shall submit a letter to the CPM within 5 days of identifying the changes.

**PAL-3:** The PRS shall prepare, and the project owner shall submit to the CPM for review and approval, a Paleontological Resources Monitoring and Mitigation Plan (PRMMP) to identify general and specific measures to minimize potential impacts to significant paleontological resources. Approval of the PRMMP by the CPM shall occur prior to any ground disturbance. The PRMMP shall function as the formal guide for monitoring, collecting and sampling activities and may be modified with CPM approval.

This document shall be used as a basis for discussion in the event that on-site decisions or changes are proposed. Copies of the PRMMP shall reside with the PRS, each monitor, the project owner's on-site manager, and the CPM.

The PRMMP shall be developed in accordance with the guidelines of the Society of the Vertebrate Paleontologists (SVP, 1995) and shall include, but not be limited to, the following:

1. Assurance that the performance and sequence of project-related tasks, such as any literature searches, pre-construction surveys, worker environmental training, fieldwork, flagging or staking; construction monitoring; mapping and data recovery; fossil preparation and recovery; identification and inventory; preparation of final reports; and transmittal of materials for curation will be performed according to the PRMMP procedures;
2. Identification of the person(s) expected to assist with each of the tasks identified within the PRMMP and all conditions for certification;
3. A thorough discussion of the anticipated geologic units expected to be encountered, the location and depth of the units relative to the project when known, and the known sensitivity of those units based on the occurrence of fossils either in that unit or in correlative units;
4. An explanation of why, how, and how much sampling is expected to take place and in what units. Include descriptions of different sampling procedures that shall be used for fine-grained and coarse-grained beds;
5. A discussion of the locations of where the monitoring of project construction activities is deemed necessary, and a proposed schedule for the monitoring;
6. A discussion of the procedures to be followed in the event of a significant fossil discovery, including notifications;
7. A discussion of equipment and supplies necessary for recovery of fossil materials and any specialized equipment needed to prepare, remove, load, transport, and analyze large-sized fossils or extensive fossil deposits;
8. Procedures for inventory, preparation, and delivery for curation into a retrievable storage collection in a public repository or museum, which meets the Society of Vertebrate Paleontologists standards and requirements for the curation of paleontological resources; and
9. Identification of the institution that has agreed to receive any data and fossil materials recovered, requirements or specifications for materials delivered for curation and how they will be met, and the name and phone number of the contact person at the institution; and,
10. A copy of the paleontological conditions of certification.

**Verification:** At least thirty (30) days prior to ground disturbance, the project owner shall provide a copy of the PRMMP to the CPM. The PRMMP shall include an affidavit of authorship by the PRS, and acceptance of the project owner evidenced by a signature.

**PAL-4 Employee Awareness Training Program:** Prior to ground disturbance and for the duration of construction, the project owner and the PRS shall prepare and conduct weekly CPM-approved training for all project managers, construction supervisors and workers who operate ground disturbing equipment or tools. Workers to be involved in ground disturbing activities in sensitive units shall not operate equipment prior to receiving worker training. The training program may be combined with other training programs prepared for cultural and biological resources, hazardous materials, or any other areas of interest or concern.

The Worker Environmental Awareness Program (WEAP) shall address the potential to encounter paleontological resources in the field, the sensitivity and importance of these resources, and the legal obligations to preserve and protect such resources. In-person training shall be provided for each new employee involved with ground disturbing activities, while these activities are occurring in highly sensitive geologic units, as detailed in the PRMMP. The in-person training shall occur within four days following a new hire for highly sensitive sites and as established by the PRMMP for sites of moderate, low, and zero sensitivity. Provisions will be made to provide the WEAP training to workers not fluent in English.

The training shall include:

1. A discussion of applicable laws and penalties under the law;
2. For training in locations of high sensitivity, the PRS shall provide good quality photographs or physical examples of vertebrate fossils that may be expected in the area;
3. Information that the PRS or PRM has the authority to halt or redirect construction in the event of a discovery or unanticipated impact to a paleontological resource;
4. Instruction that employees are to halt or redirect work in the vicinity of a find and to contact their supervisor and the PRS or PRM;
5. An informational brochure that identifies reporting procedures in the event of a discovery;
6. A Certification of Completion of WEAP form signed by each worker indicating that they have received the training; and
7. A sticker that shall be placed on hard hats indicating that environmental training has been completed.

**Verification:**

- a. At least 30 days prior to ground disturbance, the project owner shall submit the proposed WEAP including the brochure with the set of reporting procedures the workers are to follow.
- b. At least 30 days prior to ground disturbance, the project owner shall submit the script and final video to the CPM for approval if the project owner is planning on using a video for interim training.
- c. If an alternate paleontological trainer is requested by the owner, the resume and qualifications of the trainer shall be submitted to the CPM for review and approval. Alternate trainers shall not conduct training prior to CPM authorization.
- d. The project owner shall provide in the Monthly Compliance Report the WEAP copies of the Certification of Completion forms with the names of those trained, and the trainer, for each training offered that month. The Monthly Compliance Report shall also include a running total of all persons who have completed the training to date.

**PAL-5:** The PRS and PRM(s) shall monitor consistent with the PRMMP, all construction related grading, excavation, trenching, and auguring in areas where potentially fossil bearing materials have been identified. In the event that the PRS determines full time monitoring is not necessary in locations that were identified as potentially fossil-bearing in the PRMMP, the PRS shall notify and seek the concurrence of the CPM.

The PRS and PRM(s) shall have the authority to halt or redirect construction if paleontological resources are encountered. The project owner shall ensure that there is no interference with monitoring activities unless directed by the PRS. Monitoring activities shall be conducted as follows:

1. Any change of monitoring different from the accepted schedule presented in the PRMMP shall be proposed in a letter from the PRS and the project owner to the CPM prior to the change in monitoring. The letter shall include the justification for the change in monitoring and submitted to the CPM for review and approval.
2. PRM(s) shall keep a daily log of monitoring of paleontological resource activities. The PRS may informally discuss paleontological resource monitoring and mitigation activities with the CPM at any time.
3. The PRS shall immediately notify the project owner and the CPM of any incidents of non-compliance with any paleontological resources conditions of certification. The PRS shall recommend corrective action to resolve the issues or achieve compliance with the conditions of certification.
4. For any significant paleontological resources encountered, either the project owner or the PRS shall notify the CPM immediately (no later than the following morning after the find, or Monday morning in the case of a weekend) of any halt of construction activities.

**Verification:** The PRS shall prepare a summary of the monitoring and other paleontological activities that will be placed in the Monthly Compliance Reports. The summary will include the name(s) of PRS or monitor(s) active during the month; general descriptions of training and construction activities and general locations of excavations, grading, etc. A section of the report will include the geologic units or subunits encountered; descriptions of sampling within each unit; and a list of fossils identified in the field. A final section of the report will address any issues or concerns about the project relating to paleontologic monitoring including any incidents of non-compliance and any changes to the monitoring plan that have been approved by the CPM. If no monitoring took place during the month, the project shall include a justification in summary as to why monitoring was not conducted.

The PRS shall submit the summary of monitoring and paleontological activities in the Monthly Compliance Report.

**PAL-6:** The project owner, through the designated PRS, shall ensure the recovery, preparation for analysis, analysis, identification and inventory, the preparation for curation, and the delivery for curation of all significant paleontological resource materials encountered and collected during the monitoring, data recovery, mapping, and mitigation activities related to the project.

**Verification:** The project owner shall maintain in their compliance file copies of signed contracts or agreements with the designated PRS and other qualified research specialists. The project owner shall maintain these files for a period of three years after completion and approval of the CPM-approved PRR. The project owner shall be responsible to pay curation fees for fossils collected and curated as a result of paleontological monitoring and mitigation.

**PAL-7:** The project owner shall ensure preparation of a Paleontological Resources Report (PRR) by the designated PRS. The PRR shall be prepared following completion of the ground disturbing activities. The PRR shall include an analysis of the recovered fossil materials and related information and submitted to the CPM for review and approval.

The report shall include, but not be limited to, a description and inventory of recovered fossil materials; a map showing the location of paleontological resources encountered; determinations of sensitivity and significance; and a statement by the PRS that project impacts to paleontological resources have been mitigated.

**Verification:** Within ninety (90) days after completion of ground disturbing activities, including landscaping, the project owner shall submit the Paleontological Resources Report under confidential cover.

---

**Certification of Completion of Worker Environmental Awareness Program**  
**~~El Segundo Power Redevelopment Project~~ El Segundo Power Facility Modification (00-AFC-14C)**

This is to certify these individuals have completed a mandatory California Energy Commission approved Worker Environmental Awareness Program (WEAP). The WEAP includes pertinent information on Cultural, Paleontology and Biology Resources for all personnel (i.e. construction supervisors, crews and plant operators) working on-site or at related facilities. By signing below, the participant indicates that they understand and shall abide by the guidelines set forth in the Program materials. Please include this completed form in your Monthly Compliance Report.





## 3.5 Hazardous Materials

This section describes and evaluates potential effects the proposed changes may have on hazardous materials storage and handling. Compliance with applicable LORS is also addressed.

### 3.5.1 Amendment Overview

As discussed in detail in Section 2.0, Project Description, this PTA proposes modifications to the ESEC that necessitate evaluation of environmental impacts and potential amendments to existing COCs. The proposed PTA is for decommissioning, demolishing, and replacing the existing Units 3 and 4 steam boiler plants with approximately 449 MW gross / 435 MW net of new natural-gas-fired electrical generating capacity, consisting of one combined-cycle train and two simple-cycle gas turbines. The air-cooled, combined-cycle train (CC Fast) will consist of a GTG (Unit 9), a an HRSG, and one STG (Unit 10), rated at 325 MW net. The simple cycle turbines (Units 11 and 12) will consist of two air-cooled Trent 60 ISE advanced aeroderivative gas turbines, each rated at 55 MW net / 58 MW gross. The GE turbine will be supported by a small (36 MMBtu/hr) auxiliary boiler that will be incorporated into the operation of the CC Fast. Removal of existing Units 3 and 4 will eliminate the remaining once-through ocean water cooling system at the ESGS site. The ESPFM will improve electricity generation by adding fast-start and dispatch flexibility capability to support southern California grid load balancing. Total site capacity (including the new equipment previously permitted) will not exceed 1,020 MW net—the rated capacity of previously retired Units 1 and 2, plus the capacity of the soon-to-be-retired Unit 3 and operating Unit 4, which will also be retired as part of the ESPFM.

### 3.5.2 Affected Environment

#### 3.5.2.1 ESEC Amendments

The proposed ESPFM will result in modifications to the EI ESEC license (00-AFC-14C). Decommissioning, demolishing, and removing existing Units 3 and 4 and replacing them with new Units 9, 10, 11, and 12 will not employ any new hazardous materials or generate new or additional wastes from those identified in the CEC's amended license for 00-AFC-14 and described in Section 2.0. Implementation of the ESPFM will require lower amounts of hazardous materials such as hydrazine; chlorine, a neutralizing amine to control dissolved oxygen and pH in the feed water; and sodium phosphate because these chemicals are associated with once-through cooling and are therefore no longer required. The elimination of once-through cooling also eliminates the need for chlorine to control biological growth. However, consistent with the current operating conditions at the ESGS site, the demolition and removal of Units 3 and 4 and the installation and operation of new Units 9, 10, 11, and 12 may result in minimal changes to the frequency of aqueous ammonia deliveries.

The ESPFM adds oxygenated treatment to support the air-cooled condenser. Oxygenated treatment reduces iron corrosion and transport to the HRSG. In addition, ammonia is required for pH control of the feed water as well as a peroxide solution to maintain oxygen concentrations in the condensate and feed water. While there is a potential for the ESPFM to result in changes in the frequency of ammonia deliveries, system upgrades and changes in operating conditions will not be required. Because of this change in treatment systems, the need for an oxygen scavenger (hydrazine) and neutralizing amine to control dissolved oxygen and pH in the feed water, as well as the use of sodium phosphate in the HRSG boiler water to control pH will be eliminated.

Implementation of new Units 9, 10, 11, and 12 will employ air-cooled condensers used for steam turbine exhaust stream heat rejection, which will rely on a mixed-bed resin system for treatment of make-up water for the water/steam cycle. The mixed-bed resin system is not regulated by the U.S. Department of Transportation when shipped domestically by land; however, it is listed an "immediate health hazard" under SARA Title III, and is considered a hazardous chemical as defined by OSHA Hazard Communication Standard, 29 CFR 1910.1200.

The Hazardous Materials Management Program subject to the approved COCs HAZMAT -1 through HAZMAT -3 is adequate to address any new potential impacts of the ESPFM. The following is a brief description of the areas covered by each existing COC:

- **HAZ-1** Hazardous Materials Inventory
- **HAZ-2** Business Plan Revision
- **HAZ-3** Risk Management Plan Revisions

ESEC LLC has implemented standard operating procedures that require that all hazardous materials storage, handling, use, and disposal be maintained to reflect current site conditions. As such, ESEC LLC will continue to comply with the requirements set forth in these COCs and will provide updates regarding the location of project components and implementation of onsite hazardous materials management programs, as necessary.

### 3.5.2.2 Hazardous Materials Storage and Use

The demolition and removal of Units 3 and 4 and the installation and operation of new Units 9, 10, 11, and 12 will result in minimal changes to the existing aqueous ammonia system as described in Section 2.0. There is a potential for the ESPFM to result in changes in the frequency of aqueous ammonia deliveries; however, system upgrades and changes in operating conditions will not be required. In addition, as described in Section 2.0, a variety of chemicals will be stored and used during construction and operation of the facility. The storage, handling, and use of these chemicals will be conducted in accordance with all applicable LORS and existing COCs. In addition, the removal of Units 3 and 4 and subsequent discontinuation of the once-through cooling system eliminates the need to store and use chlorine for biological growth control. The elimination of chlorine use will result in lower potential hazardous material handling impacts. Therefore, implementation of the ESPFM will result in lower potential for impacts from hazardous materials storage and use and implementation of existing mitigated by conformance with the requirements included in COCs HAZ-1 through HAZ-3.

### 3.5.2.3 Offsite Laydown and Parking Areas

The preferred offsite laydown area, located at 777 W. 190th Street in the City of Gardena, was incorporated into ESEC in the 2010 PTA decision and will continue to be used for ESPFM. Construction laydown and parking areas will also be established within the ESGS site boundary, as well as at offsite areas identified in the CEC Final Decision and shown on Figure 2-10. The 190th Street area is less than ten miles southeast of the ESGS and is easily accessible to the I-405 and I-110 North freeways from Vermont Avenue and 190th Street as well as to ESEC-approved traffic/truck routes. This site, zoned M2, commercial, has approximately ten usable acres and includes a 5,500 square-foot industrial building. The approximately 12.1-acre site paved with asphalt has nightlighting and includes a perimeter security fence. No site preparation other than minor clean-up is required prior to use. The existing COCs ensure that construction-related activities at the approved laydown areas will comply with appropriate hazardous materials storage and handling requirements and are adequate to address any potential impacts.

## 3.5.3 Cumulative Impacts

The proposed ESPFM covered under this PTA will require less hazardous materials and, therefore, will not result in any significant cumulative impacts from hazardous materials storage, use, or disposal beyond those addressed in the CEC's Final Decision (00-AFC-14).

## 3.5.4 Laws, Ordinances, Regulations, and Standards

The CEC Final Decision found the project to be in compliance with all applicable LORS. As described in this PTA, the proposed ESPFM is consistent with applicable hazardous materials handling-related LORS and the Amendment will not alter the assumptions or conclusions made in the CEC's Final Decision and no additional or revised LORS compliance have been identified.

### 3.5.5 Conditions of Certification

Existing COCs HAZ-1 through HAZ-3 are adequate to address the ESPFM without being amended with the exception of changing the identified Unit numbers and entity names. These COCs are provided below.

**HAZ-1 Hazardous Materials Inventory:** The project owner shall obtain the advance approval of the CPM if the facility intends to store, handle, use or move (or combination of these activities) a material, in quantities that exceed those specified in Title 40, CFR Part 355, Subpart J section 355.50.

**Verification:** The project owner shall provide to the CPM, in the Annual Compliance Report, a list of those hazardous materials designated as regulated substances as set forth in Title 40, CFR Part 355, Subpart J section 355.50. The list shall also include maximum quantities of these substances at the facility. Copies of the list should also be provided to the City of El Segundo Fire Department (CESFD) and the City of Manhattan Beach Fire Department (CMBFD).

**HAZ-2 Business Plan Revision:** The project owner shall update its existing Business Plan.

**Verification:** At least 45 days prior to the start-up of the ESPFM ~~ESPR~~ project Units 9, 10, 11, and 12 ~~5, 6 and 7~~, the owner shall undertake a hazardous materials floor plan exercise for each shift at the plant with the CESFD and provide a copy of the revised Business Plan, commented on by the CESFD, to the CPM. A copy of the revised Plan shall also be provided to the CMBFD.

**HAZ-3 Risk Management Plan Revision:** The project owner shall revise the existing CalARP Program Risk Management Plan (RMP). Similarly, the project owner shall also revise its existing RMP pursuant to the USEPA RMP Program. Both RMPs shall be expanded to include discussions to prevent and control the accidental release of ammonia from the pipeline. Those discussions shall elaborate on the various safety devices selected for the pipeline including double sleeve construction, provisions for backup safety devices, protective shut-in actions, emergency support systems, monitoring programs and personnel training, as a minimum. The shut-in actions shall include responses to pipeline overpressures and also leaks. Backup safety devices to be considered for the pipeline shall include sprinklers, sprays, deluge systems or equivalent systems. Special emphasis shall be placed on the deployment of such devices in the vicinity of the overpass at Vista Del Mar Boulevard in order to eliminate any vulnerabilities at that location.

**Verification:** At least 45 days prior to start-up of Units 9, 10, 11, and 12 ~~5, 6 and 7~~, the project owner shall furnish a final copy of each updated RMP to the CPM, CESFD and CMBFD. An initial draft of the CalARP RMP shall be provided to the CPM and the CESFD for review and comments. The final CalARP RMP shall be approved by the CPM. Similarly, an initial draft of the USEPA RMP shall be provided to the CPM and the CESFD for review and comments, at the time it is submitted to the USEPA for review. The final copy of the USEPA RMP shall reflect recommendations of the CPM and the CESFD.



## 3.6 Land Use

This section describes and evaluates potential effects the proposed changes may have on land uses. Land uses in the vicinity of the ESGS site were reviewed to assess whether there have been any changes since the CEC Final Decision in 2005 and the subsequent PTAs. Compliance with applicable LORS is also addressed.

### 3.6.1 Amendment Overview

As discussed in detail in Section 2.0, Project Description, this PTA proposes modifications to the ESEC that necessitate evaluation of environmental impacts and potential amendments to existing COCs. The proposed PTA is for decommissioning, demolishing, and replacing the existing Units 3 and 4 steam boiler plants with approximately 449 MW gross / 435 MW net of new natural-gas-fired electrical generating capacity, consisting of one combined-cycle train and two simple-cycle gas turbines. The air-cooled, combined-cycle train (CC Fast) will consist of a GTG (Unit 9), a an HRSG, and one STG (Unit 10), rated at 325 MW net. The simple cycle turbines (Units 11 and 12) will consist of two air-cooled Trent 60 ISE advanced aeroderivative gas turbines, each rated at 55 MW net / 58 MW gross. The GE turbine will be supported by a small (36 MMBtu/hr) auxiliary boiler that will be incorporated into the operation of the CC Fast. Removal of existing Units 3 and 4 will eliminate the remaining once-through ocean water cooling system at the ESGS site. The ESPFM will improve electricity generation by adding fast-start and dispatch flexibility capability to support southern California grid load balancing. Total site capacity (including the new equipment previously permitted) will not exceed 1,020 MW net—the rated capacity of previously retired Units 1 and 2, plus the capacity of the soon-to-be-retired Unit 3 and operating Unit 4, which will also be retired as part of the ESPFM.

### 3.6.2 Affected Environment

The ESPFM land use study area is bounded by the Pacific Ocean to the west and an area extending 1 mile from the site boundary. The project site is close to industrial, residential, commercial and open space uses. The ESGS site is consistent with existing and planned land uses as well as city zoning designations at and around the site. The recently released City of El Segundo Specific Plan, which specifies current zoning requirements for the downtown area of El Segundo (north of El Segundo Boulevard to Mariposa Avenue), did not impact the current zoning of the site.

Land uses in the vicinity of the ESGS site include the Chevron Marine Terminal to the north, where crude oil is offloaded from an underwater pipeline and transferred to the Chevron Oil Refinery, the largest refinery on the west coast; Hyperion Wastewater Treatment Plant, the largest wastewater treatment facility in the Los Angeles metropolitan area; and the Los Angeles Department of Water and Power Scattergood Generating Station, which is an 818 MW net electricity generating station with three generating units and a once-through cooling water system. North of the Chevron Refinery are residences in the City of El Segundo. Dockweiler State Beach is located to the northwest of the plant site. Los Angeles International Airport (LAX) is located approximately 2.5 miles north of the site. Residences and commercial uses within the City of Manhattan Beach, including a Manhattan Beach State Park are located south of the site. El Segundo City Beach and Santa Monica Bay (Pacific Ocean) are located west of the site.

The ESGS site is located within the City of El Segundo's designated coastal zone. This portion of the City's coastal zone consists of a narrow ribbon of land approximately 0.8 mile in length and 200 yards in width, for a total area of approximately 50 acres. The majority of this portion of the El Segundo's coastal zone is industrially developed, as described above, in addition to a narrow shoreline and small retail service station. The narrow sandy beach west of ESGS and Chevron Terminal is publicly owned by the California State Lands Commission and is maintained by the County of Los Angeles (City of El Segundo, 1992). The County of Los Angeles maintains a bicycle path (South Bay Bike Trail) that runs along this narrow shoreline and connects with County bike paths in the city of Los Angeles to the north and the city of Manhattan Beach to the south. Public access to the beach is provided north of ESGS through Dockweiler State Beach. No designated scenic resources are identified within the study area. Operation of the existing facility, ESGS, subject to the CEC Final Decision 00-AFC-14 and subsequent amendments complies with Coastal Act Section 50260 which encourages use of existing coastal dependent industrial sites within the

coastal zone. No major changes to the land use designations in the vicinity of the ESGS site have occurred since preparation of 00-AFC-14 and the subsequent PTAs.

### 3.6.3 ESEC Amendments

The proposed ESPFM will result in modifications to the ESEC license (00-AFC-14C). Decommissioning, demolishing, and removing existing Units 3 and 4 and replacing them with new Units 9, 10, 11, and 12 will not result in new land use impacts above those identified in the CEC's amended license for 00-AFC-14 and as described in Section 2.0. Implementing the project changes proposed in the PTA, including the decommissioning, demolishing, and removing existing Units 3 and 4; installing Units 9, 10, 11, and 12; and constructing a new combined use administrative building will not result in increases in land use impacts from those identified in the CEC's amended license for 00-AFC-14C.

There are currently 14 COCs that apply to these ESEC modifications described in this PTA. Of these conditions, several require minor changes to ensure that the work to implement the project changes is properly regulated and that no significant adverse environmental impacts occur. Proposed changes are explained. Several COCs were never used or are no longer applicable. As such, project owner proposes that they be deleted. The following list of existing COCs also includes the rationale for changes to appropriately address mitigating potential impacts associated with implementation of the ESPFM.

**LAND-1 Conformance with Local Jurisdiction Requirements – Proposed Change:** Ongoing compliance with this COC is recommended for the changes proposed by this PTA. Project owner proposes a minor change to this CEC to specify the requirements listed in this COC remain in effect for the ESPFM.

**LAND-2 Confirmation of Staging Areas – Proposed Change:** Ongoing compliance with this COC is recommended for the changes proposed by this PTA. Project owner proposes a minor change to this CEC to specify the requirements listed in this COC remain in effect for the ESPFM. Offsite staging and laydown is planned to accommodate ESPFM changes.

**LAND-3 Exhaust Stack FAA Marking/Lighting – No Change:** This COC is written such that ongoing compliance is required for all new exhaust stacks at ESEC. Thus, it is already written in a manner that will require it be complied with for the ESPFM changes.

**LAND-4 Sewer Line Construction – No Changes – Proposed Deletion:** This COC relates to the construction of a sewer pipeline interconnection. There are no proposed sewer pipeline or connection plans as part of the ESPFM and therefore, consideration of deleting this COC is warranted.

**LAND-5 Notification of Use of Abandoned Fuel Tank Farm (Parcel 2) – No Change:** This COC is written such that ongoing compliance is required in the event that Parcel 2 is used to accommodate ESPFM components and therefore, should remain in effect.

**LAND-6 Use of Parcel 2 Abandoned fuel storage tank area – No Change :** This COC is written such that ongoing compliance is required in the event that the abandoned storage tank area is used to accommodate ESPFM components and therefore, should remain in effect.

**LAND-7 Final Grading and Drainage Plans – Proposed Change:** Ongoing compliance with this COC is recommended for the changes proposed by this PTA. Project owner proposes a minor change to this CEC to specify the requirements listed in this COC remain in effect for the ESPFM.

**LAND-8 California State Lands Commission Lease – No Changes:** This COC relates to use of lands subject to leases from the State Lands Commission. With the proposed changes in the PTA, once-through cooling and other direct power plant relations to State Lands will terminate. Further, the beach delivery option was never selected and therefore this condition has not become applicable and is now outdated and not required. Nonetheless, ESEC LLC will provide the relevant copy of the lease to the CEC

**LAND-9 Perimeter Landscaping – No Change:** The proposed changes to ESEC in the PTA do not necessitate any changes to perimeter landscaping and public use. For that reason, this condition does not require any changes for the PTA.

**LAND-10 Bikeway Construction Notifications – Proposed Change:** This COC contains language related to the beach delivery option that was never implemented. The condition has proven useful regarding any needed interruptions to the bike path. For that reason, rather than proposing deletion since beach delivery was not selected, project owner proposes slightly amending the condition to make it generally applicable when bike path must be blocked.

**LAND-11 Bikeway Restoration – No Change:** This COC should continue to be adhered to if and when the project is obligated to disturb the conditions of the bike path. The condition is written now to be generally applicable.

**LAND-12 Beach Restoration- Proposed Deletion:** This COC was proposed specifically and only in case the beach delivery option was selected. Since that option was not selected to construct Units 5, 6, 7 and 8, this condition was never implemented and never will be. Thus, it should be deleted.

**LAND-13 California State Lands Commission Lease – Proposed Deletion:** This COC was proposed specifically and only in case the beach delivery option was selected. Since that option was not selected to construct Units 5, 6, 7 and 8, this COC was never implemented and never will be. Thus, it should be deleted.

**LAND-14 Emergency Service Vehicle and Equipment Passage – Proposed Deletion:** This COC was proposed specifically and only in case the beach delivery option was selected. Since that option was not selected to construct Units 5, 6, 7 and 8, this COC was never implemented and never will be. Thus, it should be deleted.

ESEC LLC will continue to comply with the requirements set forth in these COCs.

### 3.6.4 Environmental Analysis

As discussed in Section 2.0, Project Description, the demolition and removal of Units 3 and 4 and the installation and operation of new Units 9, 10, 11, and 12 will result in similar grading, excavation, foundation, and underground infrastructure activities as were required for the demolition of Units 1 and 2 and the construction of Units 5 through 8. Furthermore, because subsurface activities required for the ESPFM are expected to occur in areas of the site that have been previously disturbed as part of historical power plant operations at the site, including the most current subsurface activities required for the demolition of Units 1 and 2 and construction of Units 5 through 8, no impacts beyond those described in 00-AFC-14 are anticipated. Therefore, the resource protection measures included in existing COCs LAND-1 through LAND-3 and LAND-5 through LAND-11 are adequate to address potential land use impacts, and the ESPFM demolition and construction activities will be conducted in accordance with these COCs all applicable LORS.

#### 3.6.4.1 Offsite Construction Laydown and Construction Worker Parking Areas

The preferred offsite laydown area, located at 777 W. 190th Street in the City of Gardena, was incorporated into ESEC in the 2010 PTA decision and will continue to be used for ESPFM. Construction laydown and parking areas will also be established within the ESGS site boundary, as well as at offsite areas identified in the CEC Final Decision and shown on Figure 2-10. The 190th Street area is less than ten miles southeast of the ESGS and is easily accessible to the I-405 and I-110 North freeways from Vermont Avenue and 190th Street as well as to ESEC-approved traffic/truck routes. This site, zoned M2, commercial, has approximately ten usable acres and includes a 5,500 square-foot industrial building. The approximately 12.1-acre site paved with asphalt has nightlighting and includes a perimeter security fence. No site preparation other than minor clean-up is required prior to use. The intended use of this site for construction laydown and parking is consistent with the current use of the property and is not in conflict with surrounding properties and businesses. Furthermore, the existing COCs ensure that land use-related activities at the laydown areas will comply with existing land use plans and policies.

### 3.6.5 Cumulative Impacts

The proposed project changes will not result in any significant cumulative impacts to land use beyond those addressed in the CEC Final Decision (00-AFC-14). As part of preparation of this PTA, the relevant planning agencies were contacted and confirmed that there are no planned actions that would interfere with maintaining the land use conformance of ESPFM and, therefore, there will be no cumulative impacts. The project owner will continue to work closely with Los Angeles County and local cities to monitor and anticipate any future community



organized events such as charity walks, bike rides, or clean-ups to minimize the impact of disruption of the bike path from construction or operation of the ESPFM.

### 3.6.6 Laws, Ordinances, Regulations, and Standards

The CEC Final Decision found the project to be in compliance with all applicable LORS. As described in this PTA, the proposed ESPFM is consistent with applicable land use-related LORS and the Amendment will not alter the assumptions or conclusions made in the CEC's Final Decision and no additional or revised LORS compliance have been identified.

### 3.6.7 Conditions of Certification

Land use impacts are subject to approved COCs LAND-1 through LAND-3 and LAND-5 through LAND-11 are adequate to address any new potential impacts of ESPFM. COCs LAND-4 and LAND 12 through LAND-14 are specific to components that have been fully implemented subject to the CEC FINAL Decision (00-AFC-14). The analysis concludes that only revisions to the COCs, removing those where compliance has been completed, set forth in the previously permitted project are necessary and no new COCs are required. These COCs are provided below.

Proposed changes to the land use COCs are provided below using strikethrough (~~text~~) to show text proposed for deletion and underlining (text) to show text proposed to be added. Several conditions require slight adjustment to facilitate the proposed changes to the facility and ensure that ESEC continues to have no significant adverse impacts.

**LAND-1** Conformance with Local Jurisdiction Requirements – **Proposed Change**

**LAND-2** Confirmation of Staging Areas – **Proposed Change**

**LAND-3** Exhaust Stack FAA Marking/Lighting – **No Change**

**LAND-4** Sewer Line Construction – **No Change**

**LAND-5** Notification of Use of Abandoned Fuel Tank Farm (Parcel 2) – **No Changes**

**LAND-6** Use of Parcel 2 Abandoned fuel storage tank area – **No Changes**

**LAND-7** Final Grading and Drainage Plans – **Proposed Change**

**LAND-8** California State Lands Commission Lease – **No Change**

**LAND-9** Perimeter Landscaping – **No Change**

**LAND-10** Bikeway Construction Notifications – **Proposed Change**

**LAND-11** Bikeway Restoration – **No Change**

**LAND-12** Beach Restoration - **Proposed Deletion**

**LAND-13** California State Lands Commission Lease – **Proposed Deletion**

**LAND-14** Emergency Service Vehicle and Equipment Passage – **No Change**

The rationale for these changes was provided in section 3.6.3 above. The proposed changes to the land use COCs are:

**LAND-1:** The project owner shall ensure that the project and its associated facilities are in compliance with the affected local jurisdiction's applicable adopted county or municipal code requirements for the project site's development (e.g., setbacks, zone district requirements, design criteria, height, sign requirements, etc.). The project owner shall also ensure the same local jurisdictional requirement compliance for the ESPFM changes.

The project owner shall submit to the applicable city/county planning department for review and comment, a development plan showing site dimensions, design and exterior elevation(s) and any other item(s) that may be required by the local jurisdiction's planning department to conduct a ministerial review of the project and its associated facilities in accordance with the jurisdiction's site development requirements. The city/county planning department shall have 60 calendar days to review the plan(s) and provide written comments to the project owner. The project owner shall provide a copy of the city/county planning department's written comments and a copy of the development plan to the CPM.

**Verification:** At least 90 calendar days prior to the site mobilization on the power plant project site and its associated facilities, and also for the ESPFM changes, the project owner shall submit the proposed development plan to the affected jurisdiction for review and comment. The project owner shall provide any comment letters received from the local jurisdiction along with the proposed development plan to the CPM for review and approval.

**LAND-2:** The project owner shall identify the secured lay down/staging area(s) for the project prior to site mobilization and shall also identify the secured lay down/staging area(s) for the ESPFM changes. The project owner shall provide a plot plan and location map showing the lay down/staging area(s) to the affected local jurisdiction(s) planning department(s) (i.e. County of Los Angeles, the City of El Segundo, City of Manhattan Beach, etc.) and to the Executive Director of the California Coastal Commission if located within the State designated Coastal Zone for review and comment. The local jurisdiction(s) and the Executive Director (if applicable) shall have 60 calendar days to review the lay down/staging area(s) and provide written comments to the project owner. The project owner shall provide a copy of the local jurisdiction's and the Executive Director's (if applicable) written comments and a copy of the secure lay down/staging area(s) to the CPM for review and approval.

**Verification:** The project owner shall provide a copy of the lay down/staging area(s) to the affected local jurisdiction and the Executive Director of the California Coastal Commission (if applicable) for written comment. At least 30 days prior to the start of site mobilization, the project owner shall provide any plan(s), map(s) showing the secured laydown and staging area(s) along with any comment letters from the local jurisdiction and the California Coastal Commission to the CPM for review and approval.

**LAND-3:** The project owner shall provide appropriate evidence of compliance with Federal Aviation Administration (FAA) regulations regarding the marking and/or lighting of the project's new exhaust stacks.

**Verification:** Pursuant to the schedule contained in Condition of Certification TRANS-6, the project owner shall submit copies of the FAA Form 7460-1 with copies of the FAA response to Form 7460-1 to the CPM.

**LAND-4:** The project owner shall either bore the proposed sewer line under 45th Street in the City of Manhattan Beach or use conventional excavation techniques using steel cover plates to allow traffic to have access to the Strand parking lot at all times. The time period necessary to complete the 45th Street sewer excavation/trenching and connection shall be kept to a minimum. The Applicant shall obtain the required encroachment permit(s) from the local government of jurisdiction(s). The sewer line shall be constructed during the off-peak season of September to May. (Readers' note: Compliance with this COC is being implemented as part of ESEC and is not necessary to apply to ESPFM).

**Verification:** The project owner shall submit to the City of Manhattan Beach Public Works Department an encroachment permit application for their review and approval and to the CPM for final approval. The permit application shall include a description of the method that would be used to complete any excavations in 45th Street. The application shall include the proposed time to begin and complete the sewer line connection. Also, the permit application shall illustrate how the construction crew and traffic control will ensure that access to the parking lot is not disrupted.

The project owner shall monitor the construction of the sewer line in the 45th Street right-of-way at all times and promptly notify the City of Manhattan Beach Public Works Department and CPM of any difficulties experienced.

Prior to any ground disturbance within the 45th Street public right-of-way a copy of the City of Manhattan Beach approved/issued encroachment permit shall be submitted to the CPM. The CPM or City of Manhattan Beach designated representative may conduct random site visits to verify compliance, and the CPM may temporarily stop construction to ensure access is maintained.

**LAND-5:** The project owner shall provide written notification to the CPM when any plans for use of the abandoned fuel tank farm area (Parcel 2) are developed and indicate whether the project owner believes such plans are subject to the Energy Commission's permitting authority in accordance to the Warren-Alquist Act. The written notification shall include a description of the development and an analysis of which agency has proper

jurisdiction over the development according to the enacted laws, ordinances and standards in effect at the time such development is to be proposed.

**Verification:** The project owner shall provide written notification to the planning departments of the City of El Segundo and the City of Manhattan Beach and to the Executive Director of the California Coastal Commission who shall have 30 calendar days to provide written comments to the CPM to review. At least 60 days prior to submitting any applications to any other agency for development of the abandoned fuel tank farm area (Parcel 2); the project owner shall provide a copy of the written notification to the CPM. The project owner shall also provide copies of the written notification sent to the Cities of El Segundo, Manhattan Beach and to the Executive Director of the California Coastal Commission to the CPM.

**LAND-6:** The abandoned fuel storage tanks on Parcel 2 shall be removed prior to the start of commercial operation of the new generating units. Any site remediation and/or soil restoration activities required by appropriate authorities shall be completed following tank removal. (Readers' note: Compliance with this COC is being implemented as part of ESEC and is not necessary to apply to ESPFM).

Following site remediation, the tank farm area shall be paved and landscaped in accordance with the landscape plan submitted and approved pursuant to condition of certification, VIS-2. The tank farm uses will be restricted to parking in the designated parking areas and approved uses in the paved area south of the designated parking area. Approved uses include temporary equipment staging and overflow parking during maintenance evolutions. The paved area shall not be used for permanent storage of vehicles, equipment or materials.

**Verification:** The project owner shall submit a detailed schedule for the removal of the fuel storage tanks, site remediation and/or soil restoration to the CPM for review and approval prior to the start of construction.

**LAND-7:** The project owner shall provide copies of final grading and drainage plans to the planning departments of the Cities of El Segundo and Manhattan Beach. This requirements shall also apply to the ESPFM changes

**Verification:** Pursuant to the schedule contained in Condition of Certification CIVIL-1 the project owner shall also submit copies of the proposed drainage structures and grading plan to the City of El Segundo planning department and the City of Manhattan Beach planning department concurrent with their submittal to the Chief Building Official (CBO) and CPM.

~~**LAND-8:** The project owner shall maintain lease rights for the tideland and submerged land owned by the State of California leased via the California State Lands Commission.~~

~~Project owner shall provide copies to the CPM of all new or amended leases and all relevant correspondence between the project owner and the State Lands Commission regarding lease terms.~~

~~**Verification:** The project owner shall provide the CPM with a copy of submitted lease applications filed with the State Lands Commission and other relevant correspondence. The project owner shall submit to the CPM a copy of all new or amended lease agreements with the California State Lands Commission.~~

**LAND-9:** The project owner shall provide copies of the final perimeter landscape plan(s) to the CPM. The landscape plans shall identify the area to be designated for public use, subject to restrictions for security and public safety as determined by the CPM. The project owner shall install public park-type benches within the public use area along the west property line of the ESGS property.

**Verification:** The public park-type benches shall be installed pursuant to the schedule contained in Condition of Certification VIS-2. Within 14 days after completion of the public use area, the project owner shall contact the CPM to request a final inspection.

**LAND-10:** The project owner shall not prohibit public access and use of the Los Angeles County maintained Class 1 bicycle trail known as the "Marvin Braude Bikeway" (bikeway) ~~during beach delivery activities~~ except as stipulated below for the project:

- A. Prior to the start of pre-construction activity involving the bikeway, the project owner shall contact the Los Angeles County Department of Public Works and provide for its review a schedule for bike trail closure and

trail use interruption, the detour route, the location of delineators or barricades to channelize individuals past the work site, and the placement of public signage (e.g., construction warning signs).

- B. Prior to the first closure of the bikeway to perform necessary project pre- construction or construction activity, the project owner shall:
- a. Provide the final schedule and timing of bike trail closures to the Department of Public Works Construction Division and Bikeway Coordinator, and CPM.
  - b. Provide a detour plan to the Department of Public Works Construction Division, Bikeway Coordinator and CPM showing a safe bicycle route around the project site for bicyclists.
  - c. Provide the Department of Public Works Construction Division and Bikeway Coordinator 30-calendar days to review and provide written comments to the project owner on a. and b. above.
  - d. Provide to the CPM a copy of the transmittal letter submitted to the Department of Public Works Construction Division and Bikeway Coordinator requesting their review of the items identified in a. and b. above.
  - e. Provide to the CPM a copy of the Department of Public Works Construction Division and Bikeway Coordinator written comments on the items identified in a. and b. above for approval.
  - f. Notify the Bikeway Coordinator within 24-hours after any reopening of the bikeway.
- C. If the bikeway's existing width must be reduced in size to perform necessary project construction activity, the project owner shall provide the following:
- Eight (8) feet of bicycle trail width shall be maintained around the project site to the greatest extent possible. The project owner shall post construction signs warning "CONSTRUCTION AHEAD" and "BIKEWAY NARROWS" in advance of the project site on all approaches along with delineators and barricades for channelization.
- If a minimum of eight feet of paved bicycle trail cannot be provided, construction signs warning "CONSTRUCTION AHEAD" and "WALK BIKE" shall be posted in advance of the project site on all approaches. Where bicyclists are instructed to walk their bikes, flagmen shall be present at all approaches. Delineators or barricades shall also be placed to channelize pedestrians past the work site.
- Vertical clearance to obstructions across the clear width of the bicycle trail shall be a minimum of 8 feet.
- D. Required public signage shall be posted at least 14-calendar days prior to the start of pre-construction activity involving the bikeway. The Department of Public Works Construction Division and Bikeway Coordinator, and the CPM shall be notified that signage has been installed within 24-hours after posting.
- E. To the extent feasible, the project owner shall make the bicycle trail open to the public on weekends and holidays. The bicycle trail shall be completely free of obstructions including barricades, swept clean, and have a minimum of eight-feet of vertical clearance with a two-foot wide shoulder. If a two-foot wide shoulder cannot be maintained, the project owner shall provide warning signage.
- F. Within 48-hours after receiving a bicycle related trail complaint specific to the project's bikeway pre-construction and construction activities, the project owner shall provide the CPM with a complaint resolution form report as specified in the Compliance General Conditions and a written explanation of the resolution to the complaint.

**Verification:** At least 30 days prior to start of pre-construction activity involving the bikeway, the project owner is to contact the Los Angeles County Department of Public Works Construction Division and Bikeway Coordinator.

The project owner is to provide to the CPM a copy of the transmittal letter submitted to the Department of Public Works Construction Division and the Bikeway Coordinator requesting their review.

The project owner is to provide to the CPM a copy of the written comments provided by the Department of Public Works Construction Division and the Bikeway Coordinator on the scheduled for bike trail closure and trail use interruption, the detour route, the installation of public signage and notification.

**LAND-11 Bikeway Restoration:** The project owner shall complete restoration or repair of bicycle trail pavement (including striping) to the bikeway's preconstruction condition consistent with the schedule established for the completion of the seawall pursuant to Condition of Certification VIS-3 found in the visual resources section of the Commission Decision dated February 2, 2005.

The project owner shall contact the Los Angeles County Department of Public Works Construction Division and the CPM for a site inspection after the project owner has restored/repared the bicycle trail to its pre-construction condition.

If upon completion of the site inspection by the Los Angeles County Department of Public Works Construction Division and the CPM, the CPM notifies the project owner that additional restoration/repair is needed; within 30 days of receiving the notification the project owner shall complete the specified work.

**Verification:** The project owner is to notify the Los Angeles County Department of Public Works Construction Division and the CPM upon completion of the restoration/repair of the bicycle trail that it is ready for inspection.

**LAND-12 Beach Restoration** The project owner shall remove all evidence of the project's beach delivery area structures and equipment (e.g., beach ramp, safety/security fencing, dozers, etc.), and restore the beach surface area to its original condition or better condition, including the replacement of any sand, vegetation, or paving that was removed to permit the project's beach delivery phase where project development does not preclude it.

The project owner shall record in video format the beach delivery laydown area prior to pre-construction activity and after the restoration completed. The project owner shall submit copies of both the pre- and post-video recordings to the CPM.

The project owner shall complete surface restoration of the beach area within 60 calendar days after the start of commercial operation. The project owner shall notify the CPM within seven days after completion of surface restoration that the beach area is ready for inspection. If the CPM notifies the project owner that additional surface restoration is needed after the site inspection, within 30 days of receiving that notification the project owner shall complete the specified work.

**Verification:** At least 15 days prior to the start of pre-construction on the beach, the project owner is to video the beach delivery laydown area and provide a copy of it to the CPM.

The project owner is to notify the CPM within seven days after completion of the beach restoration that it is ready for inspection and provide the CPM with a video/DVD showing the restored beach area.

**LAND-13 California State Lands Commission Lease:** Prior to the start of the project's pre-construction activity on the beach, the project owner shall provide the CPM a copy of their executed lease or equivalent land use document with the California State Lands Commission permitting barge anchorage, and the storage and transfer of oversized power plant equipment (e.g., steam turbine generators, heat recovery steam generators, air-cooled condensers) to the project site.

**Verification:** At least 15 days prior to the start of pre-construction activity on the beach, the project owner is to provide the CPM a copy of their executed lease or equivalent land use document with the California State Lands Commission.

**LAND-14 Emergency Service Vehicle and Equipment Passage:** The project owner shall allow the Los Angeles County Department of Beaches and Harbors, Facilities and Property Management Division, and the Los Angeles County Fire Department, Lifeguard Division, heavy equipment and emergency services vehicle passage through the project's beach delivery area, and the Marvin Braude Bikeway to respond to beach related emergencies (e.g.; oil spills, sewage spillage fouling the shoreline, beach erosion, high tides, mammal rescue), and to conduct lifesaving operations and paramedic services.

Prior to the start of pre-construction activity on the beach, if the project owner cannot provide heavy equipment/emergency services vehicle passage, the project owner may submit to the CPM for approval an alternative option that provides for the movement of heavy equipment and emergency services vehicles that has

been reviewed by the Chief of Facilities and Property Management Division for the Los Angeles County Department of Beaches and Harbors and the Chief Lifeguard of the Los Angeles County Fire Department.

If the CPM determines that the heavy equipment/emergency services vehicle passage or the alternative option requires a revision, the project owner shall revise the heavy equipment/emergency services vehicle passage or alternative option and submit it to the CPM for approval.

The heavy equipment/emergency services vehicle passage or alternative option shall remain in effect until the beach ramp and fencing prohibiting passage of heavy equipment and emergency service vehicles through the project's beach delivery area are cleared from the beach.

**Verification:** At least 30 calendar days prior to the start of the project's pre-construction activity on the beach, the project owner is to contact the Chief of Facilities and Property Management Division for the Los Angeles County Department of Beaches and Harbors, and the Chief Lifeguard of the Los Angeles County Fire Department to formalize the heavy equipment/emergency services vehicles passage or alternative option. At least 10 days prior to the start of pre-construction activity on the beach, the project owner is to provide to the CPM a map showing the agreed upon heavy equipment/emergency services vehicle passage or alternative option.



## 3.7 Noise and Vibration

This section describes and evaluates potential effects the proposed changes may have on noise setting. Noise receptors and sources in the vicinity of the ESGS site were reviewed to assess whether there have been any changes since the CEC Final Decision in 2005 and the subsequent PTAs. Compliance with applicable LORS is also addressed.

### 3.7.1 Amendment Overview

As discussed in detail in Section 2.0, Project Description, this PTA proposes modifications to the ESEC that necessitate evaluation of environmental impacts and potential amendments to existing COCs. The proposed PTA is for decommissioning, demolishing, and replacing the existing Units 3 and 4 steam boiler plants with approximately 449 MW gross / 435 MW net of new natural-gas-fired electrical generating capacity, consisting of one combined-cycle train and two simple-cycle gas turbines. The air-cooled, combined-cycle train (CC Fast) will consist of a GTG (Unit 9), a HRSG, and one STG (Unit 10), rated at 325 MW net. The simple cycle turbines (Units 11 and 12) will consist of two air-cooled Trent 60 ISE advanced aeroderivative gas turbines, each rated at 55 MW net / 58 MW gross. The GE turbine will be supported by a small (36 MMBtu/hr) auxiliary boiler that will be incorporated into the operation of the CC Fast. Removal of existing Units 3 and 4 will eliminate the remaining once-through ocean water cooling system at the ESGS site. The ESPFM will improve electricity generation by adding fast-start and dispatch flexibility capability to support southern California grid load balancing. Total site capacity (including the new equipment previously permitted) will not exceed 1,020 MW net—the rated capacity of previously retired Units 1 and 2, plus the capacity of the soon-to-be-retired Unit 3 and operating Unit 4, which will also be retired as part of the ESPFM.

### 3.7.2 Affected Environment

The ESPFM noise and vibration study area is the same as described in the 00-AFC-14. The recently released City of El Segundo Specific Plan, which specifies current zoning requirements for the downtown area of El Segundo (north of El Segundo Boulevard to Mariposa Avenue), did not impact the current zoning of the ESGS. Land uses in the vicinity of the ESGS site include the Chevron Marine Terminal to the north, where crude oil is offloaded from an underwater pipeline and transferred to the Chevron Oil Refinery, the largest refinery on the west coast; Hyperion Wastewater Treatment Plant, the largest wastewater treatment facility in the Los Angeles metropolitan area; and the Los Angeles Department of Water and Power Scattergood Generating Station, which is an 818 MW net electricity generating station with three generating units and a once-through ocean water cooling system. North of the Chevron Refinery are residences in the city of El Segundo. Dockweiler State Beach is located to the northwest of the plant site. Los Angeles International Airport (LAX) is located approximately 2.5 miles north of the site. Residences and commercial uses within the city of Manhattan Beach, including the Manhattan Beach State Park are located south of the ESGS site. El Segundo City Beach and Santa Monica Bay (Pacific Ocean) are located west of the ESGS site.

The County of Los Angeles maintains the bicycle path (South Bay Bike Trail) that runs along this narrow shoreline and connects with County bike paths in the city of Los Angeles to the north and the city of Manhattan Beach to the south. Public access to the beach is provided north of the ESGS site through Dockweiler State Beach. Operation of the existing facility, ESGS, is subject to the CEC Final Decision 00-AFC-14. Existing COC NOISE-6 required additional preconstruction community noise monitoring to further document existing sound levels. This monitoring was conducted during the months of August, September, and October 2003 and filed with the CEC as required by NOISE-6.

### 3.7.3 ESEC Amendments

The proposed ESPFM will result in modifications to the ESEC license (00-AFC-14C). Decommissioning, demolishing, and removing existing Units 3 and 4 and replacing them with new Units 9, 10, 11, and 12 will not result in new noise impacts beyond those identified in the CEC's amended license for 00-AFC-14C and as described in Section 2.0. The following is a brief description of the areas covered by the existing COCs:



- **NOISE-1** Neighboring Property Owner Notification
- **NOISE-2** Noise Complaint Resolution Process
- **NOISE-3** Occupational Noise Control Program
- **NOISE-4** Low-Pressure Steam Blows
- **NOISE-5** Steam Blow Notification
- **NOISE-6** Operational Noise Limits
- **NOISE-7** Occupational Noise Survey
- **NOISE-8** Construction Noise Limits
- **NOISE-9** Vibration Limits
- **NOISE-10** Loudspeaker Restrictions

ESEC LLC will continue to comply with the requirements set forth in these COCs.

### 3.7.4 Environmental Analysis

As discussed in Section 2.0, Project Description, the demolition and removal of Units 3 and 4 and the installation and operation of new Units 9 through 12 will result in similar grading, excavation, foundation, and underground infrastructure activities as were required for the demolition of Units 1 and 2 and the construction of Units 5 through 8. ESPFM demolition, construction, and operations will be conducted in accordance with the existing COCs.

#### 3.7.4.1 Offsite Construction Laydown and Construction Worker Parking Areas

The preferred offsite laydown area, located at 777 W. 190th Street in the City of Gardena, was incorporated into ESEC in the 2010 PTA decision and will continue to be used for ESPFM. Construction laydown and parking areas will also be established within the ESGS site boundary, as well as at offsite areas identified in the CEC Final Decision and shown on Figure 2-10. The 190th Street area is less than ten miles southeast of the ESGS and is easily accessible to the I-405 and I-110 North freeways from Vermont Avenue and 190th Street as well as to ESEC-approved traffic/truck routes. This site, zoned M2, commercial, has approximately ten usable acres and includes a 5,500 square-foot industrial building. The approximately 12.1-acre site paved with asphalt has nightlighting and includes a perimeter security fence. No site preparation other than minor clean-up is required prior to use. The use of this site for construction laydown and parking is consistent with the current use of the property and is not in conflict with surrounding properties and businesses. The existing COCs ensure that construction-related noise impacts from using this offsite storage and parking area complies with existing noise regulations.

### 3.7.5 Cumulative Impacts

The proposed ESPFM will not result in any significant cumulative noise impacts beyond those addressed in the CEC Final Decision (00-AFC-14). As part of preparation of this PTA, the relevant planning agencies were contacted and confirmed that there are no planned actions that would interfere with maintaining conformance of the ESPFM with noise regulations and, therefore, there will be no cumulative impacts. The project owner will continue to work closely with the cities of El Segundo, Manhattan Beach, and Los Angeles, and Los Angeles County to monitor and anticipate any future community organized events such as charity walks, bike rides, or clean-ups to minimize potential noise impacts to bike path users from construction or operation of the project.

### 3.7.6 Laws, Ordinances, Regulations, and Standards

The CEC's 2005 Decision and 2010 Amended Decision found the ESEC project and its predecessor ESPR project to be in compliance with all applicable LORS. As described in this PTA, the proposed ESPFM will comply with the existing COCs established by the CEC's Final Decision and the Amendment will not alter the assumptions or conclusions in the CEC Final Decision and no additional or revised LORS compliance have been identified.

### 3.7.7 Conditions of Certification

The ESPFM will comply with the existing COCs NOISE-1 through NOISE-10 established by CEC Final Decision (00-AFC-14). These COCs are provided below. A minor change is noted in ~~strikeout~~ in NOISE-6 given the required preconstruction noise monitoring requirement was satisfied in 2003.

**NOISE-1 Property Owner Notification:** At least 15 days prior to site mobilization, the project owner shall notify all residents, property owners, and business owners within one-half mile of the site, and the City of Manhattan Beach, the City of El Segundo, and L.A. County Lifeguard Headquarters, by mail and/or other effective means, of the commencement of project construction. At the same time, the project owner shall establish and disseminate a 24-hour “hotline” telephone number for use by the public to report any undesirable noise conditions associated with the construction of the project. This telephone number shall also be posted at the project site during construction in a manner visible to passersby. This telephone number shall be maintained until the project has been operational for at least one year. The telephone shall be located in an area that is likely to be staffed, and, if the telephone is not staffed 24 hours per day, the project owner shall include an automatic answering feature, with date and time stamp recording, to answer calls when the phone is unattended.

**Verification:** The project owner shall transmit to the CPM in the first Monthly Construction Report following site mobilization, a statement, signed by the project manager, attesting that the above notification has been performed, and describing the method of that notification. This statement shall also attest that the telephone number has been established and posted at the site.

**NOISE-2 Documentation of Noise Complaints:** Throughout the construction and operation of the project, the project owner shall document, investigate, evaluate, and attempt to resolve all project-related noise complaints as soon as possible.

- The project owner shall establish and disseminate a 24-hour “hotline” telephone number for use by the public to report any undesirable noise conditions associated with the project. The telephone shall be located in an area that is likely to be staffed, and, if the telephone is not staffed 24 hours per day, the project owner shall include an automatic answering feature, with date and time stamp recording, to answer calls when the phone is unattended.
- The project owner shall designate a noise monitoring officer for each construction shift, and for the daytime shift after the plant is placed into service. The noise monitoring officer shall be trained in the use of a sound level meter, and shall be empowered to halt any construction activities causing or likely to cause a violation of the COCs herein. The noise monitoring officer shall carry at all times an operable portable electronic device (such as telephone or pager) to receive any incoming “hotline” call.
- The noise monitoring officer shall log each noise complaint on a CPM-approved complaint form and shall attempt to resolve the complaint.
- For construction noise complaints received outside of the construction hours and days allowed as described by COC NOISE-8, the noise monitoring officer shall take immediate steps to determine whether power plant construction is causing the noise and, if so, to reduce the noise level of that activity or take other appropriate action to remedy the complaint as quickly as possible (not to exceed one hour) in order to comply with the COCs.
- For construction noise complaints, the noise monitoring officer shall contact the complainant within the hour, if requested by the complainant, with information on the status and resolution of the complaint.
- In the event of construction noise complaints for two consecutive periods outside of which construction is specifically allowed by NOISE-8, either from a single affected residence, from multiple residences, or businesses, the project owner shall monitor noise levels at the receptor(s) for no less than the following two consecutive periods.
- The noise monitoring officer, as appropriate, shall measure site fence-line noise levels, and/or measure noise levels at the complainant’s property line, to assure compliance.

- The project owner shall attempt to contact the person(s) making a plant operations noise complaint within 24 hours, and shall conduct an investigation to determine the source of noise related to the complaint.
- If the noise is related to plant operations, the project owner shall take all feasible measures to reduce the noise at its source as soon as possible.
- If the noise complaint is not resolved to the satisfaction of the complainant, including the time frame for resolution, the noise monitoring officer shall provide the Commission's toll free compliance telephone number (1-800-858-0784 unless otherwise specified by the CPM).
- Within 24 hours of receiving a noise complaint, the project owner shall file a copy of the Noise Complaint Resolution Form, or similar instrument approved by the CPM, with the City of El Segundo and City of Manhattan Beach, and with the CPM, documenting the complaint. If mitigation is required to resolve a complaint, and the complaint is not resolved within a 3-day period, the project owner shall submit a progress report and a proposed mitigation schedule, subject to the approval of the CPM, to the CPM and the affected City within 5 days of receiving the complaint.
- Following resolution of the noise complaint, the project owner shall submit an updated Noise Complaint Resolution Form and a report to the CPM and the affected City documenting the complaint and the actions taken. The report shall include: a complaint summary, including final results of noise reduction efforts; and if obtainable, a signed statement by the complainant stating that the noise problem is resolved to the complainant's satisfaction.

**Verification:** The project owner shall provide to the CPM, in the applicable Monthly and/or Annual Compliance Report, a listing of noise complaints received in that time period, and the status of resolution of each complaint, including all those which have not yet been resolved.

**NOISE-3 Noise Control Program:** Prior to site mobilization, the project owner shall submit to the CPM for review and approval a noise control program. The noise control program shall be used to reduce employee exposure to high noise levels during construction and also to comply with applicable OSHA and Cal-OSHA standards.

**Verification:** At least 30 days prior to site mobilization, the project owner shall submit to the CPM the above referenced program for review and approval. The project owner shall make the program available to OSHA upon request.

**NOISE-4 Use of Low-Pressure Steam Blows:** A low-pressure continuous steam blow or other equivalent low-pressure process shall be employed. Prior to site mobilization, the project owner shall submit a description of this process, with expected noise levels and projected hours of execution, to the CPM, who shall review the proposal with the objective of ensuring that the resulting noise level does not exceed the nighttime ambient hourly L50 value determined in NOISE-6 plus 5 decibels at the nearest residential property line. Project owner shall strive to avoid nighttime steam blows. If nighttime low pressure steam blows are unavoidable, these low pressure steam blows shall not exceed nighttime ambient hourly L50 value determined in NOISE-6 plus 2 decibels at the nearest residential property line during the hours 6:00 p.m. to 7:30 a.m. Copies of the process description and predicted noise levels shall be provided to the Cities of Manhattan Beach and El Segundo.

**Verification:** At least 15 days prior to any low-pressure continuous steam blow, the project owner shall submit to the CPM drawings or other information describing the steam blow process, including the noise levels expected and the projected time schedule for execution of the process.

**NOISE-5 Steam Blow Notification:** At least 15 days prior to the first steam blow(s), the project owner shall notify the Cities of El Segundo and Manhattan Beach, L.A. County Lifeguard Headquarters, and all residents, property owners and business owners within one mile of the site of the planned steam blow activity, and shall make the notification available to other area residents in an appropriate manner. The notification may be in the form of letters to the area residences, telephone calls, fliers and/or other effective means. The notification shall include a description of the purpose and nature of the steam blow(s), the proposed schedule, the expected noise levels and potential hazards associated with them, the "hotline" phone number where people register complaints, and the explanation that it is a one-time operation and not a part of normal plant operations.

**Verification:** Within 5 days of notifying these entities, the project owner shall send a letter to the CPM confirming that there has been appropriate notification to the residents, property owners, Cities and businesses of the planned steam blow activities, including a description of the method(s) of that notification.

**NOISE-6 Compliance with Noise Standards:** The project design and implementation shall include appropriate noise mitigation measures adequate to ensure that the project will not cause resultant noise levels to exceed the ambient median noise level (L50) at residential receivers by 2 decibels or more, and that the noise due to plant operations will otherwise comply with the noise standards of the El Segundo and Manhattan Beach Municipal Codes. No new pure tone components may be introduced. No single piece of equipment shall be allowed to stand out as a source of noise. Steam relief valves shall be adequately muffled.

A. Determine the ambient noise level (L50) at Residential Receivers. Prior to site mobilization, the project owner shall prepare and submit to the City of El Segundo and City of Manhattan Beach for review and comment, and to the CPM for review and approval, a Pre-Construction Noise Survey Plan. This plan will indicate the survey procedure and methodology for establishing the ambient noise level at nearby residential receivers. At a minimum, the plan will include the following:

- The project owner will conduct a 30-day continuous community noise survey at a residential receptor (on 45th Street in Manhattan Beach), selected by the CPM in cooperation with the City of Manhattan Beach. This pre-construction survey shall be conducted during the period of June 1 to September 30. Hourly Leq, L50 and L90 values shall be measured.
- Existing ESGS Units 3 and 4 shall be operating normally during the course of the survey, and the levels of plant operation will be documented during the survey. The plan will establish a range of acceptable (“normal”) operating conditions suitable for the purposes of these studies.
- A simultaneous control measurement will be conducted within the project boundary. The site shall be selected to ensure that the dominant noise source will be the surf, requiring a clear line of sight to the surf. A location near the southwest project site corner is preferred to minimize the potential for noise from the existing power plant to influence the surf noise measurements. Wave height and other surf conditions, and any unusual environmental conditions occurring during the survey period shall be documented.
- For each of the days of noise data collected at each receptor, the arithmetic average median noise level (L50) shall be computed for the quietest consecutive 4-hour period. The resultant average median noise levels shall then be averaged arithmetically to calculate the relationship between surf noise levels and ambient noise levels along the northern side of the El Porto Community.
- If the initial 30-day measurement data, in the judgment of the CPM in consultation with the City of Manhattan Beach, fail to demonstrate a consistent relationship of surf and ambient noise levels, the measurement will be repeated until a consistent relationship can be established.

Following approval of the Survey Plan, and prior to site mobilization, the project owner shall implement the survey and present the results in a Pre-Construction Noise Survey Report to the Cities of El Segundo and Manhattan Beach and to the CPM. The Report will include a discussion of the ambient noise level taking into consideration all relevant factors, such as plant operating conditions, surf and wind conditions.

B. Conduct post-construction survey. As soon as feasible, within the time frame described below and after Units 5, 6, ~~and 7~~, 8, 9, 10, 11 and 12 first achieve a sustained output of 80 percent or greater of rated capacity, the project owner shall conduct short-term survey noise measurements at monitoring sites ST-1, ST-2, ST-3 and ST-12 (as described in the AFC, Section 5.12, Figure 5.12-3, as amended May 4, 2001). “In addition, the Applicant shall conduct a 30-day community noise survey at the same receptor locations used for the 30-day noise measurement cited in Section A above.”

The post-project community noise survey shall be conducted between June 1 and September 30, using the methods described in Item A. above. The post construction survey shall also include measurement of one-third octave band sound pressure levels at each of the above locations to ensure that no new pure tone

noise components have been introduced. If environmental conditions prevent completion of the post-construction community noise survey in a timely manner, then the survey shall be completed as soon as conditions allow.

Following the post-construction survey, the project owner shall present the results in a Post-Construction Noise Survey Report to the Cities of El Segundo and Manhattan Beach and to the CPM. The Report will include a discussion of the relationships between surf and ambient noise levels.

- C. Implement Tank Removal Noise Mitigation if Required. Mitigation measures shall be implemented to reduce noise levels to a level of compliance if the results from the post-construction noise survey at the residential receptor location indicate that the ambient median noise level (L50) has increased by 2 decibels or more due to facility operation, as determined by the relationship between surf and ambient noise levels obtained from the pre-construction survey. The project owner shall present the proposed mitigation measures to the Cities of El Segundo and Manhattan Beach and to the CPM.
- D. Implement Pure Tone Mitigation if Required. If a facility-related pure tone is found to be present at any of the above monitoring sites, mitigation measures shall be implemented to eliminate the pure tone. For the purpose of this condition, the State of California's Model Community Noise Control Ordinance defines a pure tone. The project owner shall present the proposed mitigation measures to the Cities of El Segundo and Manhattan Beach and to the CPM.
- E. Implement Plant Noise Mitigation if Required. If the results of noise measurements at ST-1, or ST-12 indicate that the ambient noise level has increased by more than 5 decibels due to facility operation, as compared with the baseline noise measurements conducted on July 20 and 21, 2000, the owner will implement mitigation measures to reduce the noise at those locations to comply with the Municipal Code of the City of El Segundo. The project owner shall present the proposed mitigation measures to the Cities of El Segundo and Manhattan Beach and to the CPM.

**Verification:**

The pre-construction survey was completed in 2003, in accordance with the following requirements:

Pre-Construction Survey and Determination of Ambient Noise Level.

- a) At least 60 days prior to site mobilization, the project owner shall provide the Pre-Construction Noise Monitoring Survey Plan to the CPM for review and approval.
- b) Within 30 days of completion of the survey, the project owner shall provide to the CPM for review and approval the results of the pre-construction noise survey.

Post-construction Survey. Within 45 days after completing the post-construction surveys, the project owner shall submit a summary report of the survey to the CPM. Included in the report will be a description of any additional mitigation measures necessary to achieve compliance with the above listed noise limits, and a schedule, subject to CPM approval, for implementing these measures.


Mitigation Implementation. If mitigation is required, then upon completion of installation of these measures, the project owner shall submit to the CPM a summary report of a new noise survey, performed as described in paragraph B and showing compliance with this condition.

**NOISE-7 Occupational Noise Survey:** Within 30 days of the project first achieving a sustained output of 80 percent or greater of rated capacity, the project owner shall conduct an occupational noise survey to identify the noise hazardous areas in the facility. The survey shall be conducted by a qualified person in accordance with the provisions of Title 8, California Code of Regulations, sections 5095-5099 (Article 105) and Title 29, Code of Federal Regulations, section 1910.95. The survey results shall be used to determine the magnitude of employee noise exposure. The project owner shall prepare a report of the survey results and, if necessary, identify proposed mitigation measures that will be employed to comply with the applicable California and federal regulations.

**Verification:** Within 30 days after completing the survey, the project owner shall submit the noise survey report, including proposed mitigation measures, to the CPM for review and approval. The project owner shall make the report available to OSHA and Cal-OSHA upon request.

**NOISE-8 Construction/Demolition Schedule:** Heavy equipment operation and noisy construction or demolition work shall be restricted beginning at site mobilization as described below. No pure tones are allowed outside of the hours of 7:30 A.M. to 6:00 P.M. Monday-Friday, and 9:00 A.M. to 6:00 P.M. Saturday. Haul trucks and other engine-powered equipment shall be equipped with adequate mufflers. Haul trucks shall be operated in accordance with posted speed limits. Truck engine exhaust brake use shall be limited to emergencies.

Tank Farm Area: Noise levels at any residential property line due to tank farm construction or demolition shall be limited to the average daytime hourly ambient L50 value plus 5 dBA, or 65 dBA L50, whichever is lower for continuous noise. For intermittent noise (up to 30 minutes in one hour) the maximum noise levels shall be ambient L50 plus 10 dBA). Haul trucks and other engine-powered equipment shall be equipped with adequate mufflers. Haul trucks shall be operated in accordance with posted speed limits. Truck engine exhaust brake use shall be limited to emergencies. The use of the tank farm area is divided into four phases. For each phase the following restrictions shall be observed. Construction activity outside the hours described will not be allowed in the area south of the southern tank, which shall be termed the nighttime exclusion area, shown below:



**Other Areas of the Project Site:** The noise standards for construction and demolition occurring at the rest of the project site (with the exception of the tank farm area) shall be:

- 65 dBA hourly L50 at any residential receptor during the hours of 7:30 A.M. to 6:00 P.M. Monday-Friday, and 9:00 A.M. to 6:00 P.M. Saturday.
- The ambient hourly L50 value plus 2 dBA at any residential receptor at any other time.

Ambient noise levels shall be determined from the pre-construction survey conducted pursuant to NOISE-6.

**Verification:** The project owner shall transmit to the CPM in the first Monthly Construction Report a statement acknowledging that the above restrictions will be observed throughout the construction of the project.

**NOISE-9 Operational Noise Vibration Monitoring:** The project design and implementation shall ensure that site mobilization, demolition, construction, or operation of the power plant will not cause vibration at any sensitive receptor to exceed a peak particle velocity of 0.003 in/sec, or to cause vibration which is perceptible without use of instruments to any reasonable person of normal sensitivity.

The noise monitoring officer designated pursuant to COC NOISE-1 shall log each construction vibration complaint on a CPM-approved complaint form and attempt to resolve the complaint. For construction vibration complaints received outside of the construction hours or days allowed as described by COC NOISE-8, the noise monitoring officer shall take immediate steps to determine whether power plant construction is causing the vibration and, if so, to reduce the vibration level of that activity as quickly as possible (not to exceed one hour) in order to comply with the COCs. The noise monitoring officer, as appropriate, shall measure site fence-line vibration levels to assure compliance. If the vibration complaint is not resolved to the satisfaction of the complainant, including a time frame for resolution, the noise monitoring officer shall provide the Commission's toll free compliance telephone number (1-800-858-0784, unless otherwise specified by the CPM).

In the event of construction-related vibration complaints either from a single affected residence, from multiple residences, or businesses, the project owner shall monitor vibration at the receptor(s) for no less than the following two days of construction.

Within 24 hours of receiving a complaint for vibration, the project owner shall file a copy of the Noise Complaint Resolution Form, or similar instrument approved by the CPM, with the City of El Segundo and/or City of Manhattan Beach, and with the CPM.

If mitigation is required to resolve a complaint, and the complaint is not resolved within a 3-day period, the project owner shall submit a progress report and a proposed mitigation schedule, subject to the approval of the CPM, to the CPM and the affected City within 5 days of receiving the complaint. The project owner shall submit an updated Noise Complaint Resolution Form to the CPM and the affected City when the mitigation is finally implemented.

**Verification:** The project owner shall provide, in the applicable Monthly and/or Annual Compliance Report, a listing of vibration complaints received in that time period, and the status of resolution of each complaint, including all those which have not yet been resolved.

**NOISE-10 Emergency Loudspeaker ~~Restrictions Testing~~:** The loudspeaker system shall be used only for testing and emergencies.

**Verification:** The project owner shall transmit to the CPM in the first Monthly Construction Report a statement acknowledging that the above restrictions will be observed throughout the construction and operation of the project.

## 3.8 Public Health

As discussed in detail in Section 2.0, Project Description, this PTA proposes modifications to ESEC that necessitate evaluation of environmental impacts and potential amendments to existing COCs. The proposed amendment is for decommissioning, demolishing, and replacing existing Units 3 and 4 steam boiler plants with approximately 449 MW gross / 435 MW net of new natural-gas-fired electrical generating capacity, consisting of one combined-cycle train and two simple-cycle gas turbines. The air-cooled, combined-cycle train (CC Fast) will consist of a GTG (Unit 9), an HRSG, and one STG (Unit 10), rated at 325 MW net. The simple-cycle turbines (Units 11 and 12) will consist of two air-cooled Trent 60 ISE advanced aeroderivative gas turbines, each rated at 55 MW net / 58 MW gross. Removal of existing Units 3 and 4 will eliminate the remaining once-through ocean water cooling system at the ESEC. The ESPFM will improve electricity generation by adding fast start and dispatch flexibility to support southern California grid load balancing. Total site capacity (including the new equipment previously permitted and the ESPFM) will not exceed 1,020 MW net—the rated capacity of previously retired Units 1 and 2, plus the capacity of the soon-to-be-retired Units 3 and operating Unit 4, which will also be retired.

This section describes and evaluates potential effects the proposed changes may have on public health. Compliance with applicable LORS is also addressed.

As part of this evaluation, a screening health risk assessment has been performed in accordance with guidance established by OEHHA,<sup>12</sup> CARB,<sup>13</sup> and the SCAQMD.<sup>14</sup> The results of this risk assessment demonstrate that the potential impacts of the project will be below public health-related thresholds of significance. Beneficial aspects of the project regarding protection of public health include those listed below.

- Use of clean-burning natural gas fuel
- Low-sulfur content of the natural gas, which reduces sulfate fine particulate and SO<sub>2</sub> generation
- Highly efficient combustion gas turbine technology to minimize the amount of fuel and associated combustion emissions needed to produce electricity
- Water injection and SCR technology to control NO<sub>x</sub> emissions
- Oxidation catalyst technology to control CO emissions, and to reduce emissions of various TACs
- Optimized stack height to reduce ground-level concentrations of exhaust pollutants below public health-related significance thresholds

These project features will ensure that the public health impacts of the project will be minimized.

Impacts associated with the project's emissions of criteria pollutants (i.e., pollutants for which federal or California AAQS have been promulgated) are described in Section 3.1, Air Quality. Potential public exposure to accidental releases of hazardous materials on the project site during operation is addressed in Section 3.5, Hazardous Materials Management. To ensure worker safety during operations and construction, safe work practices will be followed (see Section 3.14, Worker Safety and Fire Protection).

### 3.8.1 Affected Environment

#### 3.8.1.1 ESEC Amendments

The proposed ESPFM will result in modifications to the ESEC license (00-AFC-14C). Decommissioning, demolishing, and removing existing Units 3 and 4 and replacing them with new Units 9, 10, 11, and 12 will not result in new

<sup>12</sup> OEHHA. Air Toxics Hot Spots Program Risk Assessment Guidelines, The Air Toxics Hot Spots Program Guidance Manual for Preparation of Health Risk Assessments, April 2005.

<sup>13</sup> CARB. Consolidated Table of OEHHA/CARB-Approved Risk Assessment Health Values, February 2009, at <http://www.arb.ca.gov/toxics/healthval/healthval.htm>.

<sup>14</sup> SCAQMD, *Supplemental Guidelines for Preparing Risk Assessments for the Air toxics "Hot Spots" Information and Assessment Act (AB2588)*, June 2011



public health impacts above those identified in the CEC's amended license for 00-AFC-14C and as described in Section 2.0.

The CEC defines sensitive receptors as infants and children, the elderly, the chronically ill, and any other members of the general population who are more susceptible to the effects of exposure to environmental contaminants than the population at large. For the purposes of this analysis, sensitive receptors are defined as the locations occupied by groups of individuals who may be more susceptible to health risks from a chemical exposure: schools (public and private), day-care facilities, convalescent/nursing homes, retirement homes, health clinics, and hospitals. Because sensitive individuals may be located at any residential site, risk-based standards apply to existing residences and places where residences may be built without a change in zoning as well as sensitive receptors. If project impacts are protective of sensitive individuals at the point of maximum impact, they are protective at all locations. Identification of sensitive receptors is typically done to ensure that notice of possible impacts is provided to the community.

The area surrounding to the north and east of the facility is heavily industrial; the ocean lies to the west. There are no sensitive receptors within the area impacted by the project. The closest residences are a group of residences to the south, located approximately 0.4 km from the project.

### 3.8.2 Environmental Consequences

This section describes the evaluation of potential public health risks due to construction and operation of the proposed project and the methodology and results of the HRA. A significant impact is defined as a maximum incremental cancer risk greater than 10 in 1 million, a chronic total hazard index (THI) greater than 1.0, or an acute THI greater than 1.0. Also, uncertainties in the HRA are discussed and other potential health impacts of the project are described.

#### 3.8.2.1 Construction Impacts

Demolition of the old boilers and construction of the new equipment is expected to take approximately 20 months. No significant public health effects are expected during construction. Strict construction practices that incorporate safety and compliance with applicable LORS will be followed. In addition, mitigation measures to reduce air emissions from construction impacts will be implemented as described in Section 3.1.

Temporary air emissions from construction are presented in detail in Appendix 3.1D, followed by a criteria pollutant air dispersion analysis that demonstrates ambient air quality standards will not be exceeded by construction of the project. The principal toxic air contaminant during construction is diesel particulate matter (DPM) from combustion of diesel fuel in construction equipment (e.g., cranes, dozers, excavators, graders, front-end loaders, backhoes). DPM emissions from on-site construction are summarized in Table 3.8-1.

TABLE 3.8-1  
Maximum Onsite Construction DPM Emissions

| Emitting Activity      | Pounds per Day | Tons per Year |
|------------------------|----------------|---------------|
| Construction Equipment | 13.4           | 1.5           |

Ambient air modeling for PM<sub>10</sub>, PM<sub>2.5</sub>, CO, SO<sub>2</sub> and NO<sub>2</sub> was performed as described in Section 3.1 and Appendix 3.1D. Construction-related emissions are temporary and localized, resulting in no long-term significant health impacts to the public.

Small quantities of hazardous waste may be generated during construction. Hazardous waste management plans will be in place so the potential for public exposure is minimal. (Refer to Section 3.13, Waste Management, for more information.) No acutely hazardous materials will be used or stored onsite during construction (see Section 3.5, Hazardous Materials Management). To ensure worker safety during construction, safe work practices will be followed (see Section 3.14, Worker Safety and Fire Protection).

### 3.8.2.2 Operations Impacts

Project emissions to the air will consist of combustion by-products from the natural gas-fired turbines. These pollutants include certain volatile organic compounds and polycyclic aromatic hydrocarbons (PAHs) from the combustion of natural gas, and ammonia from the SCR NO<sub>x</sub> control systems. These pollutants are listed in Table 3.1-20, and the detailed emission summaries and calculations are presented in Appendix 3.87A. After dispersion to ground level, inhalation is the main pathway by which air pollutants can potentially cause public health impacts. Other pathways—including ingestion of soil, fish, and drinking water, and dermal absorption—are also evaluated for potential exposure. As discussed below, these health risks are not significant.

### 3.8.2.3 Public Health Impact Assessment Approach

#### 3.8.2.3.1 Significance Criteria

Cancer risk is the probability or chance of contracting cancer over a human life span (assumed to be 70 years). Carcinogens are assumed to have no threshold below which there would be no human health impact. In other words, any exposure to a carcinogen is assumed to have some probability of causing cancer; the lower the exposure, the lower the cancer risk (i.e., a linear, no-threshold model). Under state and SCAQMD regulations, an incremental cancer risk greater than 10-in-one million due to a project is considered to be a significant impact on public health if the emitting units are determined by the District to be using Toxics Best Available Control Technology (T-BACT). The 10-in-one-million risk level is also used by the Air Toxics “Hot Spots” (AB 2588) program and California’s Proposition 65 as the public notification level for air toxic emissions from existing sources.

Non-cancer health effects can be either long-term (chronic) or short-term (acute). In determining potential non-cancer health risks from air toxics, it is assumed there is a dose of the TAC below which there would be no impact on human health. The air concentration corresponding to this dose is called the Reference Exposure Level (REL). A non-cancer health risk is measured in terms of a health hazard quotient, which is the calculated maximum exposure (concentration) of each TAC divided by its REL. Health hazard quotients for TACs affecting the same target organ are typically summed with the resulting totals expressed as health hazard indices for each organ system. A health hazard index of less than 1.0 is considered to be a less-than-significant health risk.

Chronic toxicity is defined as adverse health effects from prolonged chemical exposure, caused by chemicals accumulating in the body. Because chemical accumulation to toxic levels typically occurs slowly, symptoms of chronic effects usually do not appear until long after exposure commences. The lowest no-effect chronic exposure level for a noncarcinogenic air toxic is the chronic REL. Below this threshold, the body is capable of eliminating or detoxifying the chemical rapidly enough to prevent its accumulation. The chronic hazard index was calculated using the hazard quotients calculated with annual concentrations.

Acute toxicity is defined as adverse health effects caused by a brief chemical exposure of no more than 24 hours. For most chemicals, the air concentration required to produce acute effects is higher than the level required to produce chronic effects because the duration of exposure is shorter. Because acute toxicity is predominantly manifested in the upper respiratory system at threshold exposures, all acute health hazard quotients are typically summed to calculate the acute health hazard index. The maximum one-hour average concentration of each TAC with acute health effects is divided by the TAC’s acute REL to obtain a health hazard index for health effects caused by relatively high, short-term exposure to air toxics. An additional conservative procedure in this health risk assessment is that the health hazard quotients for all TACs having potential acute impacts were summed regardless of target organ. This method leads to an upper bound assessment.

#### 3.8.2.3.2 Methodology

District Rule 1401 requires a health risk assessment (HRA). The potential human health risks posed by the project’s emissions were assessed using procedures consistent with the *Supplemental Guidelines for Preparing Risk Assessments for the Air toxics “Hot Spots” Information and Assessment Act (AB2588)* (SCAQMD, June 2011),<sup>15</sup>

<sup>15</sup> SCAQMD, *Supplemental Guidelines for Preparing Risk Assessments for the Air toxics “Hot Spots” Information and Assessment Act (AB2588)*, June 2011

Office of Environmental Health Hazard Assessment (OEHHA) Air Toxics Hot Spots Program Risk Assessment Guidelines (Cal-EPA/OEHHA, 2003),<sup>16</sup> and guidance from SCAQMD staff. The SCAQMD and OEHHA guidelines were developed to provide risk assessment procedures, as required under the Air Toxics Hot Spots Information and Assessment Act of 1987, Assembly Bill 2588 (Health and Safety Code Sections 44360 et seq.). The Hot Spots law established a statewide program to inventory air toxics emissions from individual facilities, as well as guidance for execution of risk assessments and requirements for public notification of potential health risks.

Air dispersion modeling combined the project emissions with site-specific terrain and meteorological conditions to analyze short-term and long-term concentrations in the air for use in the health risk assessment. The EPA-recommended air dispersion model, AERMOD, was used along with three years (2007–2009) of compatible meteorological data from the LAX meteorological monitoring station assembled and provided by the staff of the SCAQMD. The meteorological data combined surface measurements made at LAX with upper air data from MCAS Miramar. Because HARP is built on a previous EPA-approved air dispersion model, Industrial Source Complex Short Term, Version 3 (ISCST3), the CARB HARP On-Ramp was used to integrate the air dispersion modeling output from the required air dispersion mode, AERMOD, with the risk calculations in the HARP risk module.<sup>17</sup>

The HRA modeling was prepared using CARB's Hotspots Analysis and Reporting Program (HARP) computer program (Version 1.4c, August 2010). The HARP model was used to assess cancer risk as well as non-cancer chronic and acute health hazards. The HRA includes the three following pathways: inhalation, dermal absorption, and soil ingestion.

Health risks were evaluated for a hypothetical Maximum Exposed Individual (MEI) located at the point of maximum impact (PMI). The cancer risk to the MEI at the PMI is referred to as the Maximum Incremental Cancer Risk, or MICR. Human health risks associated with emissions from the project are unlikely to be higher at any other location than the PMI. If there is no significant impact associated with concentrations in air at the PMI location, it is inferred that there would not be significant impacts in any other location. Health risks were also evaluated for a hypothetical Maximum Exposed Individual at an existing Residential receptor (MEIR), an individual assumed to be located at the existing residence where the highest concentrations of air pollutants associated with facility emissions are predicted to occur. The PMI (and thus the MICR) is not necessarily associated with actual exposure because in many cases the PMI is in an uninhabited area. Therefore, the MICR is generally higher than the MEIR. Both the MICR and the MEIR are residential risks and are based on 24 hour per day, 365 day per year, 70-year lifetime exposure. Because this is a screening analysis, the MEIR is assessed at the PMI.

Health risks are also assessed for the hypothetical Maximum Exposed Individual at an existing Worker receptor, or MEIW. This assessment reflects potential workplace risks, which are lower than residential risks because of lower exposure. Workplace risks reflect 8 hour per day, 245 day per year, 40-year exposure. Because this is a screening analysis, the MEIW risk is assessed at the PMI (the most conservative assumption).

The inhalation cancer potency factors and RELs used to characterize health risks associated with modeled concentrations in air are taken from the *Consolidated Table of OEHHA/CARB Approved Risk Assessment Health Values* (CARB, October 18, 2010) and are presented in Table 3.8-2.

---

<sup>16</sup> Office of Environmental Health Hazard Analysis, *Air Toxics Hot Spots Program Guidance Manual for Preparation of Health Risk Assessments*, August 2003.

<sup>17</sup> HARP On-Ramp Version 1, accessed at <http://www.arb.ca.gov/toxics/harp/downloads.htm>.

TABLE 3.8-2  
HARP Modeling Results – Maximum Impacts

| Risk Parameter <sup>a</sup>   | Residential <sup>b</sup> | Commercial            | Rule 1401 Requirements  | Compliance (Yes/No) |
|---|--------------------------|-----------------------|-------------------------|---------------------|
| <b>New Units (Units 9, 11 and 12 and Auxiliary Boiler)</b>                  |                          |                       |                         |                     |
| MICR  | $0.17 \times 10^{-6}$    | $0.03 \times 10^{-6}$ | $\leq 1 \times 10^{-6}$ | Yes                 |
| HIA (Case 1) <sup>c</sup>   | $5.1 \times 10^{-3}$     | —                     | $\leq 1.0$              | Yes                 |
| HIA (Case 2) <sup>c</sup>   | $4.7 \times 10^{-3}$     | —                     | $\leq 1.0$              | Yes                 |
| HIC   | $2.9 \times 10^{-3}$     | —                     | $\leq 1.0$              | Yes                 |
| <b>Units 5 and 7</b>  |                          |                       |                         |                     |
| MICR  | $0.13 \times 10^{-6}$    | $0.02 \times 10^{-6}$ | $\leq 1 \times 10^{-6}$ | Yes                 |
| HIA (Case 1) <sup>c</sup>   | $5.1 \times 10^{-3}$     | —                     | $\leq 1.0$              | Yes                 |
| HIA (Case 2) <sup>c</sup>   | $5.1 \times 10^{-3}$     | —                     | $\leq 1.0$              | Yes                 |
| HIC   | $3.1 \times 10^{-3}$     | —                     | $\leq 1.0$              | Yes                 |
| <b>Facilitywide Impacts (Units 5, 7, 9, 11 and 12 and Auxiliary Boiler)</b> |                          |                       |                         |                     |
| MICR  | $0.25 \times 10^{-6}$    | $0.05 \times 10^{-6}$ | $\leq 1 \times 10^{-6}$ | Yes                 |
| HIA (Case 1) <sup>c</sup>   | $1.0 \times 10^{-2}$     | —                     | $\leq 1.0$              | Yes                 |
| HIA (Case 2) <sup>c</sup>   | $0.8 \times 10^{-2}$     | —                     | $\leq 1.0$              | Yes                 |
| HIC   | $5.7 \times 10^{-3}$     | —                     | $\leq 1.0$              | Yes                 |

<sup>a</sup> MICR: Maximum individual cancer risk; HIA: acute hazard index; HIC: chronic hazard index.

<sup>b</sup> Residential impacts for MICR; maximum impact for other health risks.

<sup>c</sup> Acute impact modeling scenarios: Case 1: All gas turbines in operation, auxiliary boiler not operating; Case 2: Units 11 and 12 and auxiliary boiler operating, Unit 9 not operating.

### 3.8.3 Cumulative Impacts

Cumulative impacts from the existing sources at the facility (Units 5 and 7) as well as the new sources associated with the project were evaluated, and are presented in Table 3.8-2. All facility impacts are below District significance thresholds.

### 3.8.4 Conclusions and Recommendations

The project will meet all requirements of the District's risk management rule, and will not result in a significant public health impact.

### 3.8.5 References

California Air Resources Board. 2010. Consolidated table of OEHHA/ARB approved risk assessment health values. (<http://arbis.arb.ca.gov/toxics/healthval/contable.pdf>). October 18.

California Air Resources Board. HARP Model, Version 1.4c, <http://www.arb.ca.gov/toxics/harp/harp.htm>.

California Air Resources Board. HARP On-Ramp, Version 1, <http://www.arb.ca.gov/toxics/harp/downloads.htm>.

English, P., R. Neutra, et al. 1999. "Examining associations between childhood asthma and traffic flow using a geographic information system." *Environ Health Perspect* 107(9): 761-7.

English, Paul B., Julie Von Behren, Martha Harnly, and Raymond R Neutra. 1998. "Childhood asthma along the United States/ Mexico border: Hospitalizations and air quality in two California counties." *Rev Panam Salud Publica* [online]. 1998, vol.3, n.6, pp. 392-399. ISSN 1020-4989. doi: 10.1590/S1020-49891998000600005.

National Institute of Environmental Health Sciences. 1999. "Environmental Health Institute report concludes evidence is 'weak' that EMFs cause cancer." Press release. National Institute of Environmental Health Sciences, National Institutes of Health.

Office of Environmental Health Hazard Assessment. 2003. Air Toxics Hot Spots Program Risk Assessment Guidelines, The Air Toxics Hot Spots Program Guidance Manual for Preparation of Health Risk Assessments, California Environmental Protection Agency. August.

Office of Environmental Health Hazard Assessment. 2009. Air Toxics Hot Spots Program Risk Assessment Guidelines Part II: Technical Support Document for Cancer Potency Factors, California Environmental Protection Agency. May.

Ostro, B., Lindsey Roth, et al. 2009. "The Effects of Fine Particle Components on Respiratory Hospital Admissions in Children." *Environmental Health Perspectives* 117(3): 475-480.

Shaw Environmental Inc. 2007. Petition to Amend Final Commission Decision for the El Segundo Power Redevelopment Project. June.

South Coast Air Quality Management District. 2011. Supplemental Guidelines for Preparing Risk Assessments for the Air toxics "Hot Spots" Information and Assessment Act (AB2588). June.

## 3.9 Socioeconomics

This section describes and evaluates potential effects the proposed ESPFM may have on socioeconomic conditions since the CEC Final Decision in 2005 and the subsequent PTAs. Compliance with applicable LORS is also addressed.

### 3.9.1 Amendment Overview

As discussed in detail in Section 2.0, Project Description, this PTA proposes modifications to the ESEC that necessitate evaluation of environmental impacts and potential amendments to existing COCs. The proposed PTA is for decommissioning, demolishing, and replacing the existing Units 3 and 4 steam boiler plants with approximately 449 MW gross / 435 MW net of new natural-gas-fired electrical generating capacity, consisting of one combined-cycle train and two simple-cycle gas turbines. The air-cooled, combined-cycle train (CC Fast) will consist of a GTG (Unit 9), a an HRSG, and one STG (Unit 10), rated at 325 MW net. The simple cycle turbines (Units 11 and 12) will consist of two air-cooled Trent 60 ISE advanced aeroderivative gas turbines, each rated at 55 MW net / 58 MW gross. The GE turbine will be supported by a small (36 MMBtu/hr) auxiliary boiler that will be incorporated into the operation of the CC Fast. Removal of existing Units 3 and 4 will eliminate the remaining once-through ocean water cooling system at the ESGS site. The ESPFM will improve electricity generation by adding fast-start and dispatch flexibility capability to support southern California grid load balancing. Total site capacity (including the new equipment previously permitted) will not exceed 1,020 MW net—the rated capacity of previously retired Units 1 and 2, plus the capacity of the soon-to-be-retired Unit 3 and operating Unit 4, which will also be retired as part of the ESPFM.

### 3.9.2 Affected Environment

#### 3.9.2.1 ESEC Amendments

The proposed ESPFM will result in modifications to the ESEC license (00-AFC-14C). Decommissioning, demolishing, and removing existing Units 3 and 4 and replacing them with new Units 9, 10, 11, and 12 will not result in new socioeconomic impacts above those identified in the CEC's amended license for 00-AFC-14C and as described in Section 2.0.

The ESPFM socioeconomic study area is bounded by the Pacific Ocean to the west, Interstate 105 to the north, Aviation Boulevard to the east, and Rosecrans Avenue to the south. No major changes to the socioeconomic conditions have occurred since preparation of 00-AFC-14 and the subsequent PTAs.

The following is a brief description of the areas covered by each existing COC:

- **SOCIO-1:** City of El Segundo Development Mitigation Fees
- **SOCIO-2:** Fiscal Impact Analysis

ESEC LLC has implemented reporting requirements to document socioeconomic requirements identified in the existing COCs. As such, the project owner will continue to comply with the requirements set forth in these COCs and will provide updates regarding the demolition and construction-related socioeconomic reporting requirements, as necessary.

### 3.9.3 Environmental Analysis

The capital cost for the ESEC pursuant to the 2005 CEC license for 00-AFC-14 and subsequent amendments was estimated to be approximately \$350 to \$400 million. The addition of the proposed ESPFM to the capital cost of the project is expected to be approximately \$420 to \$500 million, which is 20% to 25% higher than the cost for ESEC due to increases in labor and the material costs since the filing of 00-AFC-14. However, the cost increases are consistent with project cost escalations throughout the United States. Demolishing Units 3 and 4 and eliminating once-through cooling through the implementation of dry cooling technology associated with the implementation of Units 9, 10, 11, and 12 ensures long-term regulatory feasibility and economic viability for the ESEC project.

Overall, implementation of the ESEC, including the additional of ESPFM, will have a de minimus impact on employment, housing, or schools, as the required construction labor force for ESPFM will be reduced by

approximately 12% from that for ESEC, and projected permanent employee numbers remain unchanged from estimates provided in 00-AFC-14. In addition, utilities and public services will not be significantly impacted by the proposed addition of ESPFM to the ESEC project.

Environmental justice impacts are also not expected because the proposed addition of ESPFM to the ESEC project does not result in any significant unmitigated adverse environmental or public health impacts above what was analyzed as part of the 00-AFC-14 proceedings. Any potential air quality, public health, and hazardous materials handling impacts to the public will continue to be mitigated to less than significant levels through the existing and proposed modifications to COCs (modifications proposed for Air Quality and Public Health COCs).

### 3.9.3.1 Project Capital Costs and Tax Revenue

The capital cost estimate for ESEC included in 00-AFC-14 was approximately \$350 to \$400 million, in 2000 dollars. The capital cost of the addition of ESPFM to the ESEC is approximately 20 to 25% higher (\$420 to \$500M) due to increases in labor and the cost of materials since the original AFC was filed in 2000. These cost increases are consistent with power plant demolition and construction project cost escalations throughout the United States.

In the Final Decision (00-AFC-14), it was estimated that the project would result in a net property value improvement of \$250 million. The improvement value of the proposed addition of ESPFM to the ESEC project is comparable, but will need to be adjusted to reflect 2013 dollars. Overall, the proposed ESPFM addition of highly efficient fast start and dispatch flexibility combined-cycle generation technology to the ESEC project presents an economic benefit as compared to the continued operation of Units 3 and 4. The sustained improvement value of the proposed addition of ESPFM to the ESEC project is intrinsically related to the overall long-term financial viability of the ESEC project and its amendments. Financial viability and improvement value of the ESEC project will be strengthened when regulatory risks, such as once-through cooling for Units 3 and 4, are eliminated and replaced with an air-cooled design. Consistent with the COCs for 00-AFC-14, the City of El Segundo, Los Angeles County, and the El Segundo Unified School District will receive increased tax revenues based on the improved and reassessed property value. In addition, franchise fees to the City of El Segundo for natural gas for ESPFM will be based upon comparable capital improvements as those assessed for the demolition of Units 1 and 2 and the implementation of Units 5 through 8, based on similar projected volumes of gas usage, when considered on the unit of energy produced for ESPFM.

### 3.9.3.2 Construction and Operations

The conversion to the fast start combined-cycle generation technology and advanced peaking generation will reduce the volume of local labor required for construction of ESPFM as compared to the previous ESEC peak of 422 construction workers, over 20 months, with an estimated total labor requirement of 4,995 man-months. The proposed addition of ESPFM to the ESEC project will have a peak of 337 construction workers over an 18-month period, with an estimated total construction labor requirement of 4,364 man-months. The ESPFM net reduction in construction labor as compared to ESEC is 631 man-months, representing a 12% labor reduction as compared to the ESEC. The reduction in labor is primarily related to delivery of pre-assembled primary components associated with the CC Fast and Trent units.

The construction payroll of the ESEC project was estimated to be between \$60 and \$65 million. This estimated range was developed in calendar year 2000 and labor needs were projected for the period between calendar years 2002 and 2003. Based on a nominal rate of escalation of 3.5% per annum the original construction payroll range for ESEC would equate to approximately \$74 to \$80 million. The estimated construction payroll of the proposed addition of ESPFM to the ESEC project is between \$94 and \$98 million in escalated to 2015 through 2018 at an increase of 3.5% per year. The ESPFM will have similar temporary benefits as the ESEC project (00-AFC-14), providing the City of El Segundo and adjacent areas with an increase in local jobs and commercial activity during the construction.

The 00-AFC-14 proceedings disclosed operation payroll originally estimated at approximately \$1.6 million per year using the projected first year of operation in 2004. Adjusting for inflation, the actual expected operational cost as was disclosed during the 00-AFC-14 proceedings is \$2.2 million using an anticipated first full year of operation in 2013. For the addition of ESPFM to the project, the anticipated first full year of operation of ESEC's Units 9, 10, 11

and 12 is now projected to be 2018. Adjusting for inflation the estimated payroll is projected to be approximately \$2.5 million per year.

### **3.9.3.3 Utilities and Public Services**

The addition of the ESPFM to the ESEC project will not increase demands on utilities or public services associated with the change in technology as compared to the impacts identified as part of 00-AFC-14 proceedings. The proposed ESPRM fast start and dispatch flexibility combined-cycle generation technology will require increased deliveries of reclaimed water from West Basin Municipal Water District as compared to the ESEC project, but West Basin has stated it will be able to provide the project with sufficient supplies. It is also expected that potable water supply from the City of El Segundo and sanitary sewer service by City of Manhattan Beach will remain unchanged from the requirements evaluated in 00-AFC-14. The addition of ESPFM to the ESEC project will not increase impacts on fire or police protection or hospital services, as the scale of project construction and operation is similar, or slightly decreased, as is the case for labor needs and construction phase duration. The addition of ESPFM to the ESEC project will have a de minimus impact on employment, housing, or schools, as the required construction labor force for the addition of ESPFM will be a reduction of approximately 12% of the construction labor for the ESEC project, and projected permanent employee numbers for the ESEC project remain unchanged with the addition of ESPFM from estimates evaluated in 00-AFC-14.

### **3.9.3.4 Offsite Construction Laydown and Construction Worker Parking Areas**

The preferred offsite laydown area, located at 777 W. 190th Street in the City of Gardena, was incorporated into ESEC in the 2010 PTA decision and will continue to be used for ESPFM. Construction laydown and parking areas will also be established within the ESGs site boundary, as well as at offsite areas identified in the CEC Final Decision and shown on Figure 2-10. The 190th Street area is less than ten miles southeast of the ESGs and is easily accessible to the I-405 and I-110 North freeways from Vermont Avenue and 190th Street as well as to ESEC-approved traffic/truck routes. This site, zoned M2, commercial, has approximately ten usable acres and includes a 5,500 square-foot industrial building. The approximately 12.1-acre site paved with asphalt has nightlighting and includes a perimeter security fence. No site preparation other than minor clean-up is required prior to use. The existing COCs ensure that construction-related socioeconomic impacts associated with offsite storage and parking complies with socioeconomic requirements.

## **3.9.4 Cumulative Impacts**

The proposed ESEC project changes will not result in any significant cumulative socioeconomic impacts beyond those addressed in the CEC Final Decision.

## **3.9.5 Laws, Ordinances, Regulations, and Standards**

The CEC Final Decision (00-AFC-14) found the project to be in compliance with all applicable LORS. As described in this PTA, the proposed addition of ESPFM to the ESEC project is consistent with applicable socioeconomic-related LORS and will not alter the assumptions or conclusions made in the CEC Final Decision and therefore, no additional or revised LORS compliance have been identified.

## **3.9.6 Conditions of Certification**

The socioeconomic requirements subject to approved COCs SOCIO-1 and SOCIO-2 are adequate to address any new potential impacts from the addition ESPFM to the ESEC project. The analysis concludes that no modifications to the COCs set forth in the previously permitted project (00-AFC-14) are necessary and no new COCs are required. These COCs are provided below.



**SOCIO-1 City of El Segundo Development Mitigation Fees:** Prior to the start of commercial operations of new generating units ~~the ESEC project~~, the project owner shall pay the City of El Segundo the following one-time fees (the following fees are based on the fees established by the City of El Segundo for the ESEC project; the fees established by the City of El Segundo for the addition of ESPFM will be confirmed with the City of El Segundo by the CEC CPM):

- Police service mitigation fee of \$0.11 per gross square foot of building area;
- Fire service mitigation fee of \$0.14 per gross square foot of building area;
- Library service mitigation fee of \$0.03 per gross square foot of building area;
- Traffic mitigation fee for new development, in an amount to be determined by the City of El Segundo Public Works Director upon receipt of a Traffic Mitigation Fee Determination Form.

The gross square foot of building area and the amount of the one-time fees shall be determined by the City of El Segundo at the time the project owner submits the site plans.

**Verification:** Prior to the start of commercial operation, the project owner shall submit verification to the CPM that payment of any required public service mitigation fees have been submitted to the City of El Segundo. The project owner shall provide proof of payment of the Traffic Mitigation Fee in the next Monthly Compliance Report following payment.

**SOCIO-2 Fiscal Impact Analysis:** Prior to any ground disturbance activities, the project owner shall prepare a fiscal impact analysis for the project that includes analysis of the actual revenues and costs associated with the project. The revenue analysis shall include an analysis of the total property tax, franchise tax, utility user tax, sales and use tax, business license fees, building permit fees, and other revenues generated by the facility as identified in the City of El Segundo's Fiscal Impact Model. The cost analysis shall include a discussion of the cost to City services (i.e., police, fire, public works) for ongoing service to the project. The fiscal impact analysis shall compare the revenue and costs over a minimum period of five years following the start of commercial operations.

**Verification:** At least 30 days prior to any ground disturbance activities, the project owner shall transmit the analysis to the City of El Segundo for review and comment and to the Energy Commission Compliance Project Manager (CPM) for review and approval.

## 3.10 Soil and Water Resources

This section describes and evaluates potential effects the proposed ESPFM may have on soil and water resources since the CEC Final Decision in 2005 and the subsequent PTAs. Compliance with applicable LORS is also addressed.

### 3.10.1 Amendment Overview

As discussed in detail in Section 2.0, Project Description, this PTA proposes modifications to the ESEC that necessitate evaluation of environmental impacts and potential amendments to existing COCs. The proposed PTA is for decommissioning, demolishing, and replacing the existing Units 3 and 4 steam boiler plants with approximately 449 MW gross / 435 MW net of new natural-gas-fired electrical generating capacity, consisting of one combined-cycle train and two simple-cycle gas turbines. The air-cooled, combined-cycle train (CC Fast) will consist of a GTG (Unit 9), a an HRSG, and one STG (Unit 10), rated at 325 MW net. The simple cycle turbines (Units 11 and 12) will consist of two air-cooled Trent 60 ISE advanced aeroderivative gas turbines, each rated at 55 MW net / 58 MW gross. The GE turbine will be supported by a small (36 MMBtu/hr) auxiliary boiler that will be incorporated into the operation of the CC Fast. Removal of existing Units 3 and 4 will eliminate the remaining once-through ocean water cooling system at the ESGS site. The ESPFM will improve electricity generation by adding fast-start and dispatch flexibility capability to support southern California grid load balancing. Total site capacity (including the new equipment previously permitted) will not exceed 1,020 MW net—the rated capacity of previously retired Units 1 and 2, plus the capacity of the soon-to-be-retired Unit 3 and operating Unit 4, which will also be retired as part of the ESPFM.

### 3.10.2 Affected Environment

#### 3.10.2.1 ESEC Amendments

The proposed ESPFM will result in modifications to the ESEC license (00-AFC-14C). Decommissioning, demolishing, and removing existing Units 3 and 4 and replacing them with new Units 9, 10, 11, and 12 will not result in new soil and water resource impacts beyond those identified in the CEC's amended license for 00-AFC-14 and as described in Section 2.0. It is anticipated that demolition of Units 3 and 4 and construction of Units 9, 10, 11, and 12 will require grading and excavation activities similar to the demolition of Units 1 and 2 and foundation and underground infrastructure completed during construction of Units 5 through 8 and their supporting equipment and structures. For the most part, subsurface activities are expected to occur in areas of the ESGS site that have been previously disturbed as part of historical power plant operations at the site, including the most current subsurface activities required for the demolition of Units 1 and 2 and construction of Units 5 through 8. The resource protection measures included in existing COCs WATER QUALITY-7 through WATER QUALITY-10 and WATER RES-3 through WATER RES-5 are adequate to address potential impacts to soil and water. The following is a brief description of the soil and water resources existing COCs:

- **WATER QUALITY-7** NPDES Permit for Storm Water Discharges During Construction
- **WATER QUALITY-8** Drainage, Erosion, and Sediment Control Plan (DESC)
- **WATER QUALITY-9** NPDES Permit for Storm Water Discharges During Operation
- **WATER QUALITY-10** Ballast Water Management Plan
- **WATER RES-3** Recycled Water Purchase Agreement
- **WATER RES-4** Potable Water Supply Agreement
- **WATER RES-5** Potable Water Meter Installation and Water Use Summary Report

El Segundo Energy Center LLC (ESEC LLC), the project owner, a wholly owned subsidiary of NRG Energy, Inc. will continue to comply with the requirements set forth in these COCs.

### 3.10.3 Environmental Analysis

As discussed in Section 2.0, Project Description, the demolition and removal of Units 3 and 4 and the installation and operation of new Units 9, 10, 11, and 12 will result in similar grading, excavation, foundation, and underground infrastructure activities as was required for the demolition of Units 1 and 2 and the construction of

Units 5 through 8. Further, because for the most part, subsurface activities required for construction of Units 9, 10, 11, and 12 are expected to occur in areas of the ESGS site that have been previously disturbed as part of historical power plant operations at the site, including the most current subsurface activities required for the demolition of Units 1 and 2 and construction of Units 5 through 8, no impacts beyond those described in 00-AFC-14 are anticipated. Therefore, the resource protection measures included in existing COCs WATER QUALITY-7 through WATER QUALITY-10 and WATER RES-3 through WATER RES-5 are adequate to address potential impacts to soil and water resources from the addition of the ESPFM to the ESEC, and demolition and construction activities for Units 9, 10, 11, and 12 will be conducted in accordance with these COCs and all applicable LORS.

### 3.10.3.1 Offsite Construction Laydown and Construction Worker Parking Areas

The preferred offsite laydown area, located at 777 W. 190th Street in the City of Gardena, was incorporated into ESEC in the 2010 PTA decision and will continue to be used for ESPFM. Construction laydown and parking areas will also be established within the ESGS site boundary, as well as at offsite areas identified in the CEC Final Decision and shown on Figure 2-10. The 190th Street area is less than ten miles southeast of the ESGS and is easily accessible to the I-405 and I-110 North freeways from Vermont Avenue and 190th Street as well as to ESEC-approved traffic/truck routes. This site, zoned M2, commercial, has approximately ten usable acres and includes a 5,500 square-foot industrial building. The approximately 12.1-acre site paved with asphalt has nightlighting and includes a perimeter security fence. No site preparation other than minor clean-up is required prior to use. Since subsurface ground disturbance is not required and no soil and water resource impacts will result from using offsite construction laydown and parking areas, the existing COCs ensure that construction-related impacts associated with offsite storage and parking complies with soil and water resource protection plans.

### 3.10.4 Cumulative Impacts

The proposed ESPFM covered under this PTA will result in similar subsurface activities as was required for the previous demolition of Units 1 and 2 and construction of Units 5 through 8 and their supporting equipment and structures. ESPFM subsurface demolition and construction activities are expected to occur in areas of the ESGS site that have been previously disturbed as part of historical power plant operations at the site and impacts beyond those described in 00-AFC-14 (and the previous PTAs) are not anticipated. The resource protection measures included in existing COCs WATER QUALITY-7 through WATER QUALITY-10 and WATER RES-3 through WATER RES-5 are adequate to address potential impacts from the addition of ESPFM to ESEC to soil and water resources; therefore, the addition of ESPFM to ESEC will not result in any significant cumulative impacts beyond those addressed in the CEC Final Decision for 00-AFC-14.

### 3.10.5 Laws, Ordinances, Regulations and Standards

The CEC Final Decision found the project to be in compliance with applicable soil and water resource LORS. As described in this PTA, the proposed addition of ESPFM is consistent with applicable soil and water resource-related LORS and the Amendment will not alter the assumptions or conclusions in the CEC Final Decision and no additional or revised LORS compliance requirements have been identified.

### 3.10.6 Conditions of Certification

Existing COCs WATER QUALITY-7 through WATER QUALITY-9 and WATER RES-3 through WATER RES-5 are adequate to address the addition of ESPFM to ESEC without being amended, with the exception of the minor changes below that focus on the ESEC beach delivery of components, which was not implemented for ESEC, and which is not being considered as part of this PTA for the addition of ESPFM. These COCs are provided below.

**WATER QUALITY-7 NPDES Permit for Storm Water Discharges During Construction:** The project owner shall comply with the requirements of the State Water Resources Control Board's (SWRCB) National Pollutant Discharge Elimination System (NPDES) Permit for Storm Water Discharges Associated with Construction Activity (Water Quality Order 99-08-DWQ and any other subsequent orders). The project owner shall develop and implement a Storm Water Pollution Prevention Plan (Construction SWPPP) for the construction of the ESPRP site, laydown areas including El Segundo Beach, and all linear facilities. The Construction SWPPP shall be reviewed and approved by the City of El Segundo (City) and shall be in compliance with the City's Standard Urban Stormwater

Mitigation Plan (SUSMP) per the requirements of the Los Angeles Regional Water Quality Control Board (LARWQCB) NPDES Permit No. CAS0004001 and the City's Ordinance No. 1348 and Chapter 7 of Title 5 of the municipal code.

**Verification:** Prior to site mobilization, demolition, and/or construction related ground disturbing activities, including those activities associated with the beach delivery and linear facilities, the project owner shall submit to the CPM a copy of the Construction SWPPP that includes the requirements of the City's SUSMP and retain a copy on-site. The project owner shall submit copies to the CPM of all correspondence between the project owner and the City, the LARWQCB, and the SWRCB regarding the City's SUSMP and the Construction SWPPP within 10 days of its receipt or submittal. This information shall include copies of the Notice of Intent and Notice of Termination for the project.

**WATER QUALITY-8 Drainage, Erosion, and Sediment Control Plan (DESCP):** Prior to soil disturbing activities, the project owner shall obtain CPM approval for a site-specific Drainage, Erosion, and Sediment Control Plan (DESCP) that addresses all project elements ~~including those activities related to delivery of equipment from the beach.~~ The DESCPC shall be revised to address specific soil disturbing and soil stabilizing activities associated with pre-construction, construction, and post-construction activities. ~~of the ESPRP.~~

The DESCPC shall be consistent with the grading and drainage plan as required by condition of certification CIVIL-1 and may incorporate by reference any Storm Water Pollution Prevention Plan (SWPPP) developed in conjunction with state or municipal NPDES permits. The DESCPC shall contain elements A through I below:

- A. Vicinity Map - Map(s) at a minimum scale 1"=100' shall be provided indicating the location of all project elements with depictions of all significant geographic features including swales, storm drains, and sensitive areas.
- B. Site Delineation - All areas subject to soil disturbance for the ESPRP (project site, lay down area, all linear facilities, landscaping areas, and any other project elements) shall be delineated showing boundary lines of all construction areas and the location of all existing and proposed structures, pipelines, roads, and drainage facilities.
- C. Watercourses and Critical Areas - The DESCPC shall show the location of all nearby watercourses including swales, storm drains, and drainage ditches. The DESCPC shall indicate the proximity of those features to the ESPRP construction, lay down, and landscape areas and all transmission and pipeline construction corridors.
- D. Drainage Map - The DESCPC shall provide topographic site map(s) at a minimum scale 1"=100' showing all existing, interim, and proposed drainage systems and drainage area boundaries. On the map, spot elevations and contours shall be extended off-site for a minimum distance of 100 feet.
- E. Drainage Narrative - The DESCPC shall include a narrative of the drainage measures to be taken to protect the site and downstream facilities and include the summary pages from the hydrologic analysis prepared by a professional engineer/erosion control specialist. The narrative shall state the watershed size(s) in acres used in the calculation of drainage control measures and text included that justifies their selection. The hydrologic analysis should be used to support the selection of Best Management Practices (BMPs) and structural controls to divert off-site and on-site drainage around or through the ~~ESPRP~~ construction and laydown areas.
- F. Clearing and Grading Plans - The DESCPC shall provide a delineation of all areas to be cleared of vegetation and areas to be preserved. The plan shall provide elevations, slopes, locations, and extent of all proposed grading as shown by contours, cross sections or other means. The locations of any disposal areas, fills, or other special features will also be shown. Illustrate existing and proposed topography tying in proposed contours with existing topography.
- G. Clearing and Grading Narrative - The DESCPC shall include a table with the quantities of material excavated or filled for the site and all project elements ~~of the ESPRP~~ (project site, lay down areas, transmission corridors, and pipeline corridors) to include those materials removed from the site due to demolition, whether such excavations or fill is temporary or permanent, and the amount of such material to be imported or exported.

The table shall distinguish whether such excavations or fill is temporary or permanent and the amount of material to be imported or exported.

- H. Best Management Practices - The DESC shall identify on a Water Pollution Control Drawing(s) (WPCD) the location of the site specific BMPs to be employed during each phase of construction (initial grading/demolition, excavation and construction, and final grading/stabilization). Treatment control BMPs used during construction should enable testing of stormwater runoff prior to discharge to the stormwater system. BMPs shall include measures designed to prevent wind and water erosion in areas with existing soil contamination.
- I. Best Management Practices Narrative - The DESC shall show the location (as identified on the WPCD), timing, and maintenance schedule of all erosion and sediment control BMPs to be used prior to grading/demolition, project excavation and construction, and final grading/stabilization (accomplished by the submittal of DESC revisions). Text with supporting calculation shall be included for each project specific BMP. Separate BMP implementation schedules shall be provided for each project element.

**Verification:** No later than 90 days prior to the start of grading or excavation activities associated with any project element of the ESRP, the project owner shall submit a copy of the DESC to the City of El Segundo (City) for review and comment. No later than 60 days prior to the start of grading or excavation activities associated with any project element of the ESRP, the project owner shall submit the DESC and the City's comments to the CPM for review and approval. The CPM shall consider comments received from the City on the DESC before issuing approval.

The DESC shall be revised and a revision submitted to the CPM for project excavation/construction and final grading/stabilization prior to the soil disturbing activities associated with these stages of construction. The DESC shall be consistent with the grading and drainage plan as required by condition of certification CIVIL-1 and relevant portions of the DESC shall clearly show approval by the Chief Building Official. The DESC shall be consistent with the Stormwater Pollution Prevention Plan (SWPPP) developed in accordance with the General Construction Permit (Water Quality Order 99-08-DWQ and any other subsequent orders) and the project's Standard Urban Stormwater Mitigation Plan developed in accordance with the LARWQCB NPDES Permit No. CAS0004001 and the City's Ordinance No. 1348 and Chapter 7 of Title 5 of the municipal code.

In the monthly compliance report, the project owner shall provide a narrative describing the effectiveness of the drainage, erosion and sediment control measures; the results of monitoring and maintenance activities, including any BMP inspection reports; and the dates of any dewatering activities.

**WATER QUALITY-9 NPDES Permit for Storm Water Discharges During Operation:** The project owner shall comply with the requirements of the Individual and/or General NPDES Permit for Storm Water Discharges Associated with Industrial Activity. The project owner shall develop and implement a Storm Water Pollution Prevention Plan (Industrial SWPPP) for the operation of the ESRP. The Industrial SWPPP shall be reviewed and approved by the City of El Segundo (City) and shall be in compliance with the City of El Segundo's (City) Standard Urban Stormwater Mitigation Plan (SUSMP) per the requirements of the Los Angeles Regional Water Quality Control Board (LARWQCB) NPDES Permit No. CAS0004001 and the City's Ordinance No. 1348 and Chapter 7 of Title 5 of the municipal code.

**Verification:** The project owner shall submit to the CPM a copy of the Industrial SWPPP that includes the requirements of the City's SUSMP prior to commercial operation and retain a copy on-site. The project owner shall submit to the CPM copies of all correspondence between the project owner and the City, the LARWQCB, and the SWRCB regarding the City's SUSMP and the Individual and/or General NPDES Permit for Storm Water Discharges Associated with Industrial Activity within 10 days of its receipt or submittal. The Industrial SWPPP shall include a copy of the Notice of Intent for the project.

~~**WATER QUALITY-10 Ballast Water Management Plan:** The project owner shall ensure that each barge operator develops and implements a Ballast Water Management Plan in accordance with CCR Title 2, Division 3, Chapter 1, Article 4.6. The project owner shall ensure that the ballast water holding tanks are certified clean and uncontaminated by the California State Lands Commission prior to taking on local ballast water.~~

**Verification:** ~~No later than 90 days prior to grounding of any barge associated with the delivery of ESPRP equipment over El Segundo Beach, the project owner shall provide the State Lands Commission with a copy of the Ballast Water Management Plan that is in compliance with Title 2, Division 3, Chapter 1, Article 4.6 for review and comment. At least 60 days prior to grounding of any barge associated with the delivery of ESPRP equipment over El Segundo Beach, the project owner shall provide the CPM for review and approval, a copy of the Ballast Water Management Plan that has been reviewed by the State Lands Commission.~~

**WATER RES-3 Recycled Water Purchase Agreement:** The project owner shall provide the CPM a copy of the executed and final recycled water purchase agreement (agreement) with West Basin Municipal Water District (WBMWD) for the long-term supply (30-35 years) of tertiary treated recycled water to the ESPRP. The agreement shall specify a minimum delivery rate of 602-Qom. The agreement shall specify all terms and costs for the delivery and use of recycled water by ESPRP. The shall not connect to WBMWD's new 10-inch recycled water pipeline without the final agreement in place and submitted to the CPM. The project owner shall comply with the requirements of Title 22 and Title 17 of the California Code of Regulations.

**Verification:** No later than 60 days prior to the delivery of single pass reverse osmosis recycled water from the new 10-inch pipeline, the project owner shall submit two copies of the final and executed recycled water purchase agreement for the supply and on-site use of recycled water at the ESPRP. The project owner shall submit to the CPM a copy of the cross connection inspection and approval report from the Los Angeles County Health Department prior to the delivery of recycled water from the new 10-inch recycled water pipeline.

**WATER RES-4 Potable Water Supply Agreement:** The project owner shall use potable water supplied by the City of El Segundo (City) for potable and sanitary purposes only during construction of the ESPRP ESEC. Potable water shall not be used for any construction activity that is suitable for non-potable water use. In the event of a recycled water delivery interruption, potable water may be used as an emergency back-up supply for plant operation.

Prior to completion of the 14-inch potable water pipeline, the project owner shall provide the CPM with a copy of an executed and final Potable Water Supply Agreement (agreement) for the long-term supply (30–35 years) of potable water. The agreement shall specify a minimum delivery rate of 602-gpm in order to meet ESPRP ESEC's operation requirements in the event of a recycled water interruption. The project owner shall not use more than 4-AFY of potable water as an emergency backup source for ESPRP operation.

**Verification:** No later than 30 days prior to completion of the 14-inch potable water pipeline, the project owner shall submit to the CPM two copies of the executed and final Potable Water Supply Agreement (agreement). The project owner shall submit to the CPM any water quality monitoring reports required by the City in the annual compliance report. The project owner shall notify the CPM of any violations of the agreement terms and conditions, the actions taken or planned to bring the project back into compliance with the agreement, and the date compliance was reestablished.

**WATER RES-5 Potable Water Meter Installation and Water Use Summary Report:** The project owner shall use potable water supplied by the City of El Segundo (City) and recycled water supplied by the West Basin Municipal Water District (WBMWD) during ESPRP operation. Prior to the use of water from any source for ESPRP operation, the project owner shall install and maintain metering devices as part of the potable and recycled water supply and distribution systems. The metering devices shall be in operation for the life of the project. The project owner shall prepare an annual Water Use Summary that includes the monthly range and monthly average of daily potable and recycled water usage in gallons per day on a monthly basis and in acre-feet on an annual basis. For subsequent years, the annual Water Use Summary shall also include the yearly range and yearly average water use, by source, for the project. The annual Water Use Summary shall be submitted to the CPM as part of the annual compliance report.

**Verification:** At least 60 days prior to ESPRP commercial operation, the project owner shall submit to the CPM evidence that metering devices have been installed and are operational on the potable and recycled water supply and distribution systems. The project owner shall submit a Water Use Summary report to the CPM in the annual compliance report. The report shall disaggregate potable water supplied by the City and recycled water supplied

by WBMWD for ESEC ~~ESPP~~ industrial and landscape irrigation use. The project owner shall provide a report on the servicing, testing and calibration of the metering devices in the annual compliance report.

## 3.11 Traffic and Transportation

This section describes and evaluates potential effects the proposed changes may have on traffic and transportation. Traffic data and intersection level of service (LOS) identified in 00-AFC-14 were reviewed along with recent transportation impact studies conducted by various parties and jurisdictions for the area to assess whether traffic conditions in the study area have changed significantly since the CEC Final Decision in 2005 and the subsequent PTAs. Compliance with applicable LORS is also addressed.

### 3.11.1 Amendment Overview

As discussed in detail in Section 2.0, Project Description, this PTA proposes modifications to the ESEC that necessitate evaluation of environmental impacts and potential amendments to existing COCs. The proposed PTA is for decommissioning, demolishing, and replacing the existing Units 3 and 4 steam boiler plants with approximately 449 MW gross / 435 MW net of new natural-gas-fired electrical generating capacity, consisting of one combined-cycle train and two simple-cycle gas turbines. The air-cooled, combined-cycle train (CC Fast) will consist of a GTG (Unit 9), a HRSG, and one STG (Unit 10), rated at 325 MW net. The simple cycle turbines (Units 11 and 12) will consist of two air-cooled Trent 60 ISE advanced aeroderivative gas turbines, each rated at 55 MW net / 58 MW gross. The GE turbine will be supported by a small (36 MMBtu/hr) auxiliary boiler that will be incorporated into the operation of the CC Fast. Removal of existing Units 3 and 4 will eliminate the remaining once-through ocean water cooling system at the ESGS site. The ESPFM will improve electricity generation by adding fast-start and dispatch flexibility capability to support southern California grid load balancing. Total site capacity (including the new equipment previously permitted) will not exceed 1,020 MW net—the rated capacity of previously retired Units 1 and 2, plus the capacity of the soon-to-be-retired Unit 3 and operating Unit 4, which will also be retired as part of the ESPFM.

### 3.11.2 Affected Environment

The ESPFM traffic study area is bounded by the Pacific Ocean to the west, Interstate 105 to the north, Aviation Boulevard to the east, and Rosecrans Avenue to the south. No major changes to the existing transportation infrastructure have occurred since preparation of 00-AFC-14 and the subsequent PTAs. The surrounding regional and local roadway networks are shown in Figures 3.11-1 and 3.11-2 and described below.

#### 3.11.2.1 ESEC Amendments

The proposed ESPFM will result in modifications to the ESEC license (00-AFC-14C). Decommissioning, demolishing, and removing existing Units 3 and 4 and replacing them with new Units 9, 10, 11, and 12 will not result in new traffic and transportation impacts above those identified in the CEC's amended license for 00-AFC-14 and as described in Section 2.0.

As described in Section 3.4 and 3.13, implementation of the ESPFM will generate and use similar amounts of hazardous materials and subsequent similar truck trips traveling to and from the site as was generated by the removal of Units 1 and 2 and the construction of Units 5 through 8.

The following is a brief description of the areas covered by each existing COC:

- TRANS-1** Overweight & Oversize Vehicles
- TRANS-2** Encroachment Permits
- TRANS-3** Licensed Hazardous Materials Haulers
- TRANS-4** Off-Site Parking and Staging Plan
- TRANS-5** Traffic Control Plan
- TRANS-6** Aircraft Hazard Markings
- TRANS-7** Roadway Repairs

ESEC LLC has implemented standard operating procedures which require that traffic and transportation procedures be maintained to reflect current site conditions. As such, the project owner will continue to comply



with the requirements set forth in these COCs and will provide updates regarding the demolition and construction-related traffic as well as ongoing operational traffic and transportation procedures, as necessary.

### 3.11.2.2 Surrounding Road Network

Land uses in the project vicinity are a mixture of industrial and open space, with some residential and commercial uses. The nearest port facilities are the ports of Los Angeles and Long Beach, approximately 10 miles to the south. Commercial and passenger rail facilities are located approximately 2 miles east of the project site.

**Interstate 405 (I-405) (San Diego Freeway)**, located about 4 miles east of the project site, is a north-south freeway providing regional access to the coastal communities on the west side of Los Angeles. I-405 has four lanes in each direction, not including the auxiliary lanes. A High Occupancy Vehicle (HOV) lane is provided between Century Boulevard and Vermont Avenue.

**Interstate 105 (I-105) (Glenn M. Anderson Freeway)**, located about 2 miles north of the project site, is an east-west freeway extending from Sepulveda Boulevard on the west to the San Gabriel Freeway (I-605) on the east. I-105 provides three mixed flow lanes and one HOV lane in each direction, for a total of eight lanes. The Los Angeles County Metropolitan Transportation Authority (LAMTA) operates the Metro Green Line commuter rail service, located in the center median of the freeway. The Green Line's airport station is located at Aviation Boulevard.

**Aviation Boulevard** is a major arterial, four-lane divided roadway, providing north-south access through the cities of El Segundo and Manhattan Beach.

**El Segundo Boulevard** is an east-west secondary arterial from Vista Del Mar on the west to Sepulveda Boulevard on the east. It is considered a major arterial east of Sepulveda Boulevard. El Segundo Boulevard is approximately one mile from the project site, and connects traffic from collector streets on the west side of El Segundo to the I-405 and the regional freeway system. The City of El Segundo General Plan identifies El Segundo Boulevard as truck route.

**Grand Avenue** is an east-west secondary arterial, four-lane undivided roadway from Vista Del Mar on the west to Sepulveda Boulevard. East of Sepulveda Boulevard, Grand Avenue is a six-lane divided roadway.

**Imperial Highway** is an east-west secondary arterial, four-lane divided roadway from Main Street on the west to Sepulveda Boulevard. East of Sepulveda Boulevard, Imperial Highway is a six-lane divided roadway.

**Main Street** is a north-south collector road, four-lane undivided roadway from north of Grand Avenue to El Segundo Boulevard.

**Rosecrans Avenue** is an east-west major arterial, five-lane divided roadway with three westbound lanes and two eastbound lanes from the westerly boundary of Manhattan Beach to Sepulveda Boulevard. East of Sepulveda Boulevard, Rosecrans Avenue is a six-lane divided roadway. Rosecrans Avenue borders the southerly perimeter of the Chevron Refinery.

**Sepulveda Boulevard** is a north-south eight-lane divided major arterial providing connections to I-405 north of Los Angeles International Airport (LAX) via Howard Hughes Parkway, and to I-105 south of LAX. Sepulveda Boulevard provides access to communities north of LAX (such as Culver City and Westchester) as well as the South Bay communities. Sepulveda Boulevard is designated State Route 1 (SR-1) from Lincoln Boulevard on the north to Pacific Coast Highway on the south.

**Vista Del Mar** is a north-south secondary arterial, four-lane undivided roadway, and is designated a truck route. Vista Del Mar bounds the easterly perimeter of the project site. Access to the plant site is provided via Vista Del Mar at the southern end of the ESGS.

### 3.11.2.3 Existing Traffic Conditions

The AFC (00-AFC-14) evaluated intersection operations based on LOS for existing and existing plus ESEC construction conditions. LOS is a measure of vehicle delay (i.e., the average amount of time a vehicle must wait before proceeding through an intersection). LOS is identified by a letter designation from A to F, with A as the

optimum operating LOS and F designating service as very poor. The City of El Segundo and California Department of Transportation (Caltrans) goal for peak hour intersection operation is LOS D or better.

Based on the locations of the construction worker parking lots and the laydown areas, the following intersections were analyzed for the AM and PM peak hours as part of 00-AFC-14, subsequent PTAs, and this PTA:

1. Vista Del Mar/Grand Avenue
2. Vista Del Mar/El Segundo Generating Station Driveway
3. Vista Del Mar/45<sup>th</sup> Street
4. Vista Del Mar/Rosecrans Avenue
5. Pershing Drive/Imperial Highway
6. Main Street/Grand Avenue
7. Main Street/El Segundo Boulevard
8. Sepulveda Boulevard/Imperial Highway
9. Sepulveda Boulevard/Grand Avenue
10. Sepulveda Boulevard/El Segundo Boulevard
11. Sepulveda Boulevard/Rosecrans Avenue
12. Aviation Boulevard/El Segundo Boulevard
13. Aviation Boulevard/Rosecrans Avenue

The intersection locations are presented in Figure 3.11-3. As part of this ESPFM PTA, traffic data and intersection LOS from the 00-AFC-14, subsequent PTAs and recent transportation impact studies conducted for the area were reviewed to assess whether traffic conditions in the study area have changed significantly since the preparation of the 00-AFC-14. A comparison of the intersection LOS (for locations where data is available) is presented in Table 3.11-1.

### 3.11.2.4 Other Transportation Facilities

#### 3.11.2.4.1 Bus Routes

Existing bus routes, commuter and freight rail lines, airports, bike lanes, truck routes, and pedestrian walking streets exist within the project area, similar to that depicted in the CEC Final Decision and in subsequent PTAs. Bus service in the El Segundo area is provided by: Los Angeles County Metropolitan Transportation Authority (LACMTA or MTA), Torrance Transit System, Santa Monica Municipal Bus Line, Municipal Area Express, and Westchester Shuttle System. Access to the project site via public transit service is provided through the following bus routes:

- I-105 (Bus Routes 220 and 439) to Vista Del Mar;
- Grand Avenue (Bus routes 124, 125 and 439) to Highland Avenue;
- Highland Avenue (Bus routes 438, 125 and 439) connecting Grand Avenue and Rosecrans Avenue; and
- Rosecrans Avenue (Bus route 125) connecting to Aviation Boulevard.

Fixed bus routes are assigned along these routes and are operated by the Southern California Rapid Transit District (SCRTD) and a Dial-a-Ride service operated by the City of El Segundo. Bus route 438 along Vista Del Mar and Highland Avenue is a privately operated line.

Additional bus routes within the project study area include Routes 225, 226, 232, 1, 2, 3, and 8. None of these routes pass directly by ESGS, but each contributes to the regional public access to the project vicinity.

TABLE 3.11-1  
Comparison of Study Intersection LOS from 2000 to 2011

| Study Intersection                                   | Year 2000 <sup>a</sup>     |              | Year 2007 <sup>b</sup> |                 | Year 2009 <sup>c</sup> |               | Year 2011 <sup>d</sup> |              |
|--|----------------------------|--------------|------------------------|-----------------|------------------------|---------------|------------------------|--------------|
|  | AM Peak Hour               | PM Peak Hour | AM Peak Hour           | PM Peak Hour    | AM Peak Hour           | PM Peak Hour  | AM Peak Hour           | PM Peak Hour |
|  | Vista Del Mar/Grand Avenue | C            | B                      | 9.7 – A         | 7.6 – A                | N/A           | N/A                    | N/A          |
| Vista Del Mar/El Segundo Generating Station Driveway | N/A                        | N/A          | 9.9 – A                | <b>58.0 – F</b> | N/A                    | N/A           | N/A                    | N/A          |
| Vista Del Mar/45 <sup>th</sup> Street                | C                          | B            | 5.1 – A                | 4.5 – A         | N/A                    | N/A           | N/A                    | N/A          |
| Vista Del Mar/Rosecrans Avenue                       | F                          | E            | 28.9 – C               | 28.9 – C        | N/A                    | N/A           | N/A                    | N/A          |
| Pershing Drive/Imperial Highway                      | B                          | B            | <b>22.3 – C</b>        | 15.7 – B        | N/A                    | N/A           | N/A                    | N/A          |
| Main Street/Grand Avenue                             | N/A                        | N/A          | 14.4 – B               | 13.9 – B        | .326/A                 | .398/A        | N/A                    | N/A          |
| Main Street/El Segundo Boulevard                     | N/A                        | N/A          | 10.1 – B               | 11.4 – B        | N/A                    | N/A           | N/A                    | N/A          |
| Sepulveda Boulevard/Imperial Highway                 | D                          | F            | 25.6 – C               | 28.1 – C        | 34.8/D                 | 27.0/C        | 30.6/C                 | 51.9/D       |
| Sepulveda Boulevard/Grand Avenue                     | N/A                        | N/A          | 34.3 – C               | 29.7 – C        | 21.0/C                 | <b>28.7/D</b> | N/A                    | N/A          |
| Sepulveda Boulevard/El Segundo Boulevard             | E                          | F            | 35.2 – D               | 136.2 – F       | 24.3/C                 | 32.5/D        | N/A                    | N/A          |
| Sepulveda Boulevard/Rosecrans Avenue                 | F                          | F            | 27.2 – C               | 75.3 – E        | N/A                    | N/A           | N/A                    | N/A          |
| Aviation Boulevard/El Segundo Boulevard              | D                          | C            | 53.8 – D               | <b>79.9 – E</b> | N/A                    | N/A           | N/A                    | N/A          |
| Aviation Boulevard/Rosecrans Avenue                  | F                          | F            | 24.9 – C               | 28.0 – C        | N/A                    | N/A           | N/A                    | N/A          |

<sup>a</sup>Application for Certification (AFC), El Segundo Power Redevelopment (ESPR), filed with the California Energy Commission (CEC), August 2000 (prepared by URS Corporation).

<sup>b</sup>PTA. Final Commission Decision for the El Segundo Power Redevelopment Project (Shaw Environmental Inc., June 2007)

<sup>c</sup>El Segundo Aquatics Site Feasibility Alternatives Project DEIR, Volume II Appendices (Rincon, April 2011)

<sup>d</sup>540 East Imperial Avenue Specific Plan Traffic Impact Analysis (Kimley Horn and Associates, Inc, June 2011)

N/A = Current data not available for this location

### 3.11.2.4.2 Commercial Rail

The **Burlington Northern-Santa Fe (BNSF) and Union Pacific** railroads operate active freight spur tracks in the project vicinity. The BNSF line joins the Union Pacific line approximately 1.5 miles from the project site. The westerly terminus of the Union Pacific line is approximately 0.5 mile northeast of the project site within the Chevron Refinery. The BNSF and Union Pacific lines may be utilized for transporting construction materials during project construction.

### 3.11.2.4.3 Passenger Rail

**Amtrak** – Amtrak’s intercity passenger rail system serves Los Angeles Union Station, in downtown Los Angeles, with statewide and nationwide service. Commuter rail and rapid transit services other than Amtrak that operate within the region are the Metro Blue and Green Lines.

**MTA Metro Green Line** – The MTA’s Metro Green Line is a light rail line, running east-west through Los Angeles County, serving the communities of Norwalk, Downey, Lynwood, Watts, Inglewood, Lennox, El Segundo, Manhattan Beach, and Redondo Beach. The Metro Green Line proceeds westerly near Studebaker Road in Norwalk and travels for about 17 miles along the median of the I-105 Freeway. The line transitions southerly from the freeway structure after the Aviation station. The Green Line continues south along an exclusive elevated right-of-way, ending its run at Marine Avenue in northeastern Redondo Beach.

**A Park and Ride** facility, located approximately 2.5 miles east of the project site at El Segundo Boulevard and Nash Street, serves commuters utilizing the Metro Green Line.

**MTA Metro Blue Line** – The MTA’s Metro Blue Line, a light rail transit system, runs from 7th Street in downtown Los Angeles, through the communities of Vernon, Huntington Park, South Gate, Watts, Compton, Carson, and Long Beach. At the Imperial/Wilmington station, passengers may transfer to the Metro Green Line, which continues toward Norwalk or El Segundo.

### 3.11.2.4.4 Bicycle and Pedestrian Circulation

Table 3.11-2 (Area Bike Routes) summarizes bike routes in the area by Class.

TABLE 3.11-2

#### Area Bike Routes

| Adjacent to/on                                     | Class*    |
|--|-----------|
| Imperial Highway (Vista Del Mar to Hillcrest)      | I         |
| Imperial Highway (Hillcrest to Sepulveda)          | II or III |
| Imperial Highway (Sepulveda to I-405)              | II        |
| Vista Del Mar (along beach)                        | I         |
| Grand Avenue (Vista Del Mar to Loma Vista)         | I         |
| Grand Avenue (Loma Vista to Douglas)               | III       |
| El Segundo Boulevard (Vista Del Mar to Loma Vista) | I         |
| El Segundo Boulevard (Loma Vista to Aviation)      | II or III |
| Rosecrans (Vista Del Mar to Sepulveda)             | II or III |
| Rosecrans (Sepulveda to I-405)                     | III       |
| Sepulveda (Rosecrans to Grand)                     | I or III  |
| Sepulveda (Grand to Imperial Hwy)                  | III       |

\*Bicycle facilities are typically categorized into three classes: Class I, Class II, and Class III. Class I facilities are bike paths or trails with an exclusive right-of-way (ROW) for bicycles separate from vehicles. Class II facilities are bike lanes with an exclusive ROW for bicycles designated by roadway striping and signs. Class III facilities are bike routes signed for shared travel with motorized vehicles, without any striping.

Source: City of El Segundo, General Plan, 2004.

#### **3.11.2.4.5 Movement of Goods**

The City of El Segundo has designated truck routes on streets where vehicles in excess of three tons may travel. Existing truck routes are provided with appropriate signage to guide truck traffic through the City. Truck routes that provide access to and from the ESGS site include Vista Del Mar, Imperial Highway, Grand Avenue and Sepulveda Boulevard. The City's truck routes follow the arterial street system.

### **3.11.3 Environmental Analysis**

In general, the LOS included in the 00-AFC-14 provides the most conservative calculation of intersection operations. Four of the study intersections were either not analyzed in 00-AFC-14 or the LOS was found to be worse based on more recent traffic counts. These intersections are shown in bold in Table 3.11-1 and discussed below.

The Vista Del Mar/ESGS driveway was evaluated in 2007 only and was found to be operating at LOS F during the PM peak hour. Improvements have been made to the ESGS driveway since 00-AFC-14 to improve ingress/egress to the site and operate at an acceptable LOS.

The Pershing Drive/Imperial Highway intersection was determined to be operating at LOS B during the AM peak hour in 2000. Based on traffic counts from 2007, the intersection was found to be operating at LOS C during the AM peak hour.

The Sepulveda Boulevard/Grand Avenue intersection was not included in 00-AFC-14. Based on traffic counts from 2009, the intersection is currently operating at LOS C during the AM peak hour and LOS D during the PM peak hour.

Finally, during the PM peak hour, the Aviation Boulevard/El Segundo Boulevard intersection was determined to be operating at LOS C in 2000 and LOS E in 2007.

#### **3.11.3.1 Construction Project Trip Generation**

Consistent with the 00-AFC-14 and subsequent PTAs, traffic impacts associated with the peak construction period have been conservatively evaluated. Implementation of the ESPFM will require a result in similar construction schedule and activities as was previously analyzed in 00-AFC-14. As a result, it is assumed that the traffic generated from the ESPFM (workforce trips, daily truck deliveries, and heavy equipment delivery) would be similar to the estimate used in 00-AFC-14. The project construction trips are discussed in further detail below.

##### **3.11.3.1.1 Workforce Trips**

The number of construction workers will fluctuate throughout the 20-month construction period, with the peak construction effort onsite occurring during Month 11, when 422 workers are projected. Based on this assumption, the ESPFM would generate a total of 844 daily auto trips, with 422 trips occurring during the morning peak hour and 422 trips occurring during the afternoon peak hour.

##### **3.11.3.1.2 Truck Trips**

The number of truck deliveries and heavy equipment deliveries is also assumed to be the same as 00-AFC-14 estimate. Truck deliveries will be spread throughout the day, beginning at approximately 6:00 AM and ending at approximately 6:00 PM. The truck trips will peak during Month 6 when 29 deliveries per day are expected.

##### **3.11.3.1.3 Oversize Equipment Delivery**

Most of the heavy machinery and items will be transported by rail to the common shipping depot nearest the project site, at the Chevron Refinery. These rail deliveries will be off-loaded and transported to the project site by common carrier. Some of these items may be delivered by ship and then transferred to by rail or carrier for delivery to the site. Heavy equipment will be delivered for only five months (Months 5 through 9). At the peak (Month 8) 19 deliveries per day are expected to the generating facility.

### 3.11.3.2 Construction Project Trip Distribution

Overall construction worker travel is similar to the levels identified in 00-AFC-14 for the previously permitted project. The workforce distribution is assumed to be as follows:

- 20 percent from north of the airport (84 employees);
- 25 percent from northeast of the airport (106 employees);
- 25 percent from the east (106 employees);
- 5 percent from El Segundo (20 employees); and
- 25 percent from south of the project site (106 employees).

Construction workforce parking will be established onsite and/or at an offsite construction laydown area near the ESGS site. Construction workers will be transported to and from the established offsite location at the beginning and end of each work shift. The off-site parking will likely be located at one of the lots previously identified in 00-AFC-14 and PTA, which include the following:

- Fed Ex site
- LAX Pershing site
- County/State Beaches
- W. 190th Street

Based on the location of the parking lots identified above, it is assumed that the following roadways would be used to reach the parking lots.

TABLE 3.11-3

#### Roadways Traveled Per Parking Lot Location

| Fed Ex Site          | LAX Pershing Site | County/State Beaches | W. 190th Street             |
|----------------------|-------------------|----------------------|-----------------------------|
| Sepulveda Boulevard  | Vista Del Mar     | Vista Del Mar        | I-110/I-405 interchange     |
| Aviation Boulevard   | Pershing Drive    | Imperial Highway     | W. 190 <sup>th</sup> Street |
| Nash Street          | Imperial Highway  | Rosecrans Avenue     |                             |
| El Segundo Boulevard | Rosecrans Avenue  |                      |                             |
| Mariposa Avenue      |                   |                      |                             |
| Grand Avenue         |                   |                      |                             |

The delivery of equipment will use the routes identified in the 2007 and 2010 PTA and Supplement. No beach delivery is planned.

### 3.11.3.3 Construction Project Traffic Impacts

As previously identified in the 00-AFC-14 and reflected in the CEC Final Decision, most of the traffic produced during AM and PM peak hours would be from construction workers arriving and departing the designated parking lots. A maximum of 844 daily trips and 422 peak hour trips is estimated during the peak construction period. Based on a review of the existing traffic conditions in the area, the study intersections are generally operating at a similar and in some cases, better LOS than previously estimated in 2000. Since the number of construction workforce trips and distribution patterns is assumed to be the same as was previously identified in 00-AFC-14, the proposed modifications would result in similar impacts as those identified in 00-AF-14. These volumes do not result in a significant adverse impact because the project would not reduce the LOS below the current daily LOS. In addition, these increases would be short-term, occurring only during the peak construction period. Furthermore, 00-FC-14 determined that the project-added trips would not cause the intersections to drop below their existing LOS. To minimize the temporary increase in traffic, the project will continue to implement the Conditions of Certification that were required for the previously permitted project.

The influx of construction vehicles and delivery trucks on the roadways from the ESPFM is minimal compared to existing truck traffic and will represent a negligible increase in truck traffic along the proposed routes of travel. At the peak, only 29 daily truck deliveries are anticipated. Therefore, the impact of construction-related truck traffic will not be significant.

Finally, no impacts to parking and other transportation facilities (transit, rail, etc.) are anticipated as a result of the project modifications. The construction workforce will use the designated off-site parking lot(s).

#### **3.11.3.3.1 Delivery Hazardous Materials Storage and Use**

The demolition and removal of Units 3 and 4 and the installation and operation of new Units 9–12 will result in minimal changes to the existing aqueous ammonia system as described in Sections 2.3 and 2.8.1. There is a potential for the ESPFM to result in changes in the frequency of aqueous ammonia deliveries; however, system upgrades and changes in operating conditions will not be required. In addition, as described in Section 2.8.1, a variety of chemicals will be stored and used during construction and operation of the facility. The removal of Units 3 and 4 and subsequent discontinuation of the once-through cooling system eliminates the need to store and use chlorine for biological growth control which will result in less truck delivery impacts. Therefore, implementation of the ESPFM will result in lower potential impacts from the delivery of hazardous materials and will be mitigated by conformance with the requirements included in COCs TRANS-3 and TRANS-5.

#### **3.11.3.3.2 Offsite Construction Laydown and Construction Worker Parking Areas**

The preferred offsite laydown area, located at 777 W. 190th Street in the City of Gardena, was incorporated into ESEC in the 2010 PTA decision and will continue to be used for ESPFM. Construction laydown and parking areas will also be established within the ESGS site boundary, as well as at offsite areas identified in the CEC Final Decision and shown on Figure 2-10. The 190th Street area is less than ten miles southeast of the ESGS and is easily accessible to the I-405 and I-110 North freeways from Vermont Avenue and 190th Street as well as to ESEC-approved traffic/truck routes. This site, zoned M2, commercial, has approximately ten usable acres and includes a 5,500 square-foot industrial building. The approximately 12.1-acre site paved with asphalt has nightlighting and includes a perimeter security fence. No site preparation other than minor clean-up is required prior to use. The existing COCs ensure that construction-related traffic activities at the approved laydown areas will comply with appropriate traffic management plans.

### **3.11.4 Cumulative Impacts**

The proposed project changes will not result in any significant cumulative impacts to traffic and transportation beyond those addressed in the CEC Final Decision.

### **3.11.5 Laws, Ordinances, Regulations, and Standards**

The CEC Final Decision found the project to be in compliance with all applicable LORS. As described in this PTA, the proposed ESPFM is consistent with applicable traffic and transportation-related LORS and the Amendment will not alter the assumptions or conclusions made in the CEC's Final Decision and no additional or revised LORS compliance have been identified.

### **3.11.6 Conditions of Certification**

The traffic and transportation requirements subject to approved COCs TRANS-1 through TRANS-7 are adequate to address any new potential impacts of ESPFM. The analysis concludes that no modifications to the COCs set forth in the previously permitted project are necessary and no new COCs are required. These COCs are provided below.

**TRANS-1 Overweight & Oversize Vehicles:** The project owner shall comply with Caltrans and other relevant jurisdictions limitations on vehicle sizes and weights. In addition, the project owner or its contractor shall obtain necessary transportation permits from Caltrans and all relevant jurisdictions for roadway use.

**Verification:** In the Monthly Compliance Reports, the project owner shall submit copies of any permits received during that reporting period. In addition, the project owner shall retain copies of these permits and supporting documentation in its compliance file for at least six months after the start of commercial operation.

**TRANS-2 Encroachment Permits:** The project owner or its contractor shall comply with Caltrans and other relevant jurisdictions limitations for encroachment into public rights-of-way and shall obtain necessary encroachment permits from Caltrans and all relevant jurisdictions.

**Verification:** In Monthly Compliance Reports, the project owner shall submit copies of permits received during the reporting period. In addition, the project owner shall retain copies of these permits and supporting documentation in its compliance file for at least six months after the start of commercial operation.

**TRANS-3 Licensed Hazardous Materials Haulers:** The project owner shall ensure that permits and/or licenses are secured from the California Highway Patrol and Caltrans for the transport of hazardous materials.

**Verification:** The project owner shall include in its Monthly Compliance Reports, copies of all permits/licenses acquired by the project owner and/or subcontractors concerning the transport of hazardous substances.

**TRANS-4 Off-Site Parking and Staging Plan:** During construction of the power plant and all related facilities, the project shall develop a parking and staging plan for all phases of project construction to enforce a policy that all project-related parking occurs on-site or in designated off-site parking areas.

**Verification:** At least 60 days prior to start of site mobilization, the project owner shall submit the plan to the City of El Segundo and other jurisdictions affected by site selection, such as the City and/or County of Los Angeles for review and comment, and to the CPM for review and approval.

**TRANS-5 Traffic Control Plan:** The project owner shall consult with the Cities of El Segundo, Manhattan Beach and Los Angeles, and prepare and submit to the CPM for approval a construction traffic control plan and implementation program which addresses the following issues:

- Timing of heavy equipment and building materials deliveries;
- Redirecting construction traffic with a flag person;
- Signing, lighting, and traffic control device placement if required;
- Need for construction work hours and arrival/departure times outside of peak traffic periods;
- Ensure access for emergency vehicles to the project site;
- Temporary travel lane closure;
- Access to adjacent residential and commercial property during the construction of all pipelines;
- Specify construction related haul routes; and
- Identify safety procedures for exiting and entering the site access gate.

**Verification:** At least 30 days prior to site mobilization, the project owner shall provide to the CPM a copy of the referenced documents.

**TRANS-6 Aircraft Hazard Markings:** The HRSG stacks shall have all the lighting and marking required by the Federal Aviation Authority (FAA) so that the stacks do not create a hazard to air navigation. The project owner shall submit to the FAA Form 7460-1, Notice of Proposed Construction or Alteration and supporting documents on how the project plans to comply with stack lighting and marking requirements imposed by the FAA.

**Verification:** At least 30 days prior to the start of construction, the project owner shall provide copies of the FAA Form 7460-1 with copies of the FAA response to Form 7460-1, to the CPM and the City of El Segundo Planning Department.

**TRANS-7 Roadway Repairs:** Following completion of project construction, the project owner shall repair any damage to the segment of Vista Del Mar and other roadways affected by construction activity along with the primary roadways identified in the traffic control plan for construction traffic to the road's pre-project construction condition. Prior to the start of construction, the project owner shall photograph, videotape or digitally record images of Vista Del Mar and the roadways that will be affected by pipeline construction and heavy construction traffic. The project owner shall provide the Compliance Project Manager (CPM), and the Cities of El Segundo, Manhattan Beach and Los Angeles with a copy of the images for the roadway segments under their jurisdiction. Also prior to start of construction, the project owner shall notify those cities about the schedule for project construction. The purpose of this notification is to postpone any planned roadway resurfacing and/or



improvement projects until after the project construction has taken place and to coordinate construction related activities associated with other projects.

**Verification:** Within 30 days after completion of the redevelopment project, the project owner shall meet with the CPM and the Cities of El Segundo, Manhattan Beach, and Los Angeles to determine and receive approval for the actions necessary and schedule to complete the repair of identified sections of public roadways to original or as near original condition as possible. Following completion of any regional road improvements, the project owner shall provide to the CPM a letter from the Cities of El Segundo, Manhattan Beach and Los Angeles if work occurred within their jurisdictional public right of way stating their satisfaction with the road improvements.

### 3.11.7 References

California Energy Commission. 2000. Rules of Practice and Procedure & Power Plant Site Certification Regulations, August 2000.

California Energy Commission. 2002a. EFS & EPD Traffic and Transportation, December 17, 2000

California Energy Commission. 2002b. Final Staff Assessment, El Segundo Power Redevelopment Project, 00-AFC-14, September 2002.

California Energy Commission. 2002c. Commission Decision, El Segundo Power Redevelopment Project, 00-AFC-14, February 2005.

California Energy Commission. 2007. PTA, Final Commission Decision for the El Segundo Power Redevelopment Project (Shaw Environmental Inc., June 2007)


City of El Segundo. El Segundo Circulation Element Update, Draft Environmental Impact Report. 2000.

City of El Segundo. 2004. El Segundo Circulation Element. September.

Kimley Horn and Associates, Inc. 2011. 540 East Imperial Avenue Specific Plan Traffic Impact Analysis. June.

Rincon. 2011. El Segundo Aquatics Site Feasibility Alternatives Project DEIR, Volume II Appendices. April.

Shaw Environmental Inc. 2007. Petition to Amend Final Commission Decision for the El Segundo Power Redevelopment Project. June.




**FIGURE 3.11-1**

**Regional Road Network**

El Segundo Power Facility Modification  
 April 2013 Petition to Amend 00-AFC-14  
 El Segundo, California






**FIGURE 3.11-2**

**Local Road Network**

El Segundo Power Facility Modification  
 April 2013 Petition to Amend 00-AFC-14  
 El Segundo, California





● STUDY INTERSECTIONS

**FIGURE 3.11-3**

**Study Intersections**

El Segundo Power Facility Modification  
 April 2013 Petition to Amend 00-AFC-14  
 El Segundo, California



## 3.12 Visual Resources

Visual resources are the natural and cultural features of the environment that can be seen and that contribute to the public's enjoyment of the environment. Visual resource or aesthetic impacts are generally defined in terms of a project's physical characteristics and potential visibility, and the extent that the project's presence would change the visual character and quality of the environment in which it would be located. This section describes and evaluates potential effects the proposed changes may have on visual resources. Compliance with applicable LORS is also addressed.

### 3.12.1 Amendment Overview

As discussed in detail in Section 2.0, Project Description, this PTA proposes modifications to the ESEC that necessitate evaluation of environmental impacts and potential amendments to existing COCs. The proposed PTA is for decommissioning, demolishing, and replacing the existing Units 3 and 4 steam boiler plants with approximately 449 MW gross / 435 MW net of new natural-gas-fired electrical generating capacity, consisting of one combined-cycle train and two simple-cycle gas turbines. The air-cooled, combined-cycle train (CC Fast) will consist of a GTG (Unit 9), a HRSG, and one STG (Unit 10), rated at 325 MW net. The simple cycle turbines (Units 11 and 12) will consist of two air-cooled Trent 60 ISE advanced aeroderivative gas turbines, each rated at 55 MW net / 58 MW gross. The GE turbine will be supported by a small (36 MMBtu/hr) auxiliary boiler that will be incorporated into the operation of the CC Fast. Removal of existing Units 3 and 4 will eliminate the remaining once-through ocean water cooling system at the ESGS site. The ESPFM will improve electricity generation by adding fast-start and dispatch flexibility capability to support southern California grid load balancing. Total site capacity (including the new equipment previously permitted) will not exceed 1,020 MW net—the rated capacity of previously retired Units 1 and 2, plus the capacity of the soon-to-be-retired Unit 3 and operating Unit 4, which will also be retired as part of the ESPFM.

### 3.12.2 Affected Environment

#### 3.12.2.1 ESEC Amendments

The proposed ESFPM will result in amendments to the ESEC license (00-AFC-14C). With respect to visual resources, the proposed modifications will result in alterations to the appearance of the licensed ESEC. To provide a basis for documenting and evaluating any changes to the environmental baseline for visual resources, the current views from each of the Key Observation Points (KOP) used in preparing previous AFC and 2007 PTA visual analyses were observed and photo-documented. Views from additional observation points were also photo-documented. Figure 3.12-1 is a map of the project area on an air photo base that illustrates the locations of KOPs 1, 2, 3, 7 and 8 from the AFC and 2007 PTA visual analyses, and KOP 10, which is a new view from The Strand, Manhattan Beach, selected for analysis of the proposed project. Figures 3.12-2 through 3.12-7 include images that depict the baseline conditions visible from each of the KOPs (the "a," or "baseline" image in each figure).

For this analysis, the appropriate baseline views are views of the ESEC site as it would appear at completion as approved in the original 2005 license and 2007 and 2010 amendments. Because development of the approved ESEC project is still underway, photos of the current views from each of the KOPs were amended to simulate the approved project features whose construction is near complete. The photos of the existing views toward the ESEC site were modified to include not only the completed changes to Units 5 and 7, but also the sea wall, landscaping, and other visual enhancement features required by the COCs in the 2005 license and the 2007 and 2010 amendments. The landscaping for the baseline was rendered to depict its appearance one year after completion. For this PTA, the landscaping with the ESPFM was rendered at year 5 after installation of the landscaping.

The ESEC's current visual resources conditions of certification assure that ESEC did not and will not cause any significant impacts to visual resources. The ESEC currently has nine COCs. Several conditions require slight adjustment to facilitate the proposed changes to the facility and ensure that ESEC continues to enhance and complement the community aesthetically. The project owner also proposes one new COC, Visual Resources



(VIS)-10, to ensure that onsite landscaping changes required for the proposed changes to the ESEC do not adversely affect the visual treatment provided for in the project. Below is a summary of the proposed treatment of the visual resources conditions of certification.

- **VIS-1 Facility Visual Enhancement Plan: *No changes*** to this condition, but to address changes to onsite landscaping, new condition VIS-10 is proposed.
- **VIS-2 Perimeter Screening and On-site Landscaping: *No changes*** to this condition, but to address changes to onsite landscaping, new condition VIS -10 is proposed.
- **VIS-3 Design Treatment of Seawall: *No changes*** to this condition, the proposed changes will not directly affect the seawall nor necessitate any modifications to the seawall.
- **VIS-4: *No longer in decision.*** Vis-4 was deleted by change to the ESEC final decision approved in 2008.
- **VIS-5 Structure Surface Painting: *Proposed change*** to this condition to address structure surface color selections for the new units and equipment.
- **VIS-6 Project Lighting: *Proposed change*** to this condition to apply the same lighting design standards required for Units 5, 6, 7, and 8, to the new proposed units and equipment. Note that there was a typographical error in this condition, wherein Unit 8 was not listed. This error is being corrected in the proposed change to this condition also.
- **VIS-7 Site Lighting: *No changes*** to this condition. VIS-7 required the project owner to change the lighting on or associated with Units 3 and 4 to ensure that the those lights did not cause significant impacts to the community when that lighting became more visible to the residents of the City of Manhattan Beach. The lighting changes were also completed as an overall project benefit, in that the ESEC project was reducing glare and excess lighting from the older areas of the facility that were not yet being modified by the project. The proposed changes in this PTA will remove all of that lighting and the proposed changes to VIS-6 will ensure that all new lighting meets the required standards and expectations for lighting at ESEC.
- **VIS-8 Construction Lighting: *Proposed change*** to this condition to apply the same construction lighting requirements required for the original construction to the construction proposed by this PTA.
- **VIS-9 Temporary Landscaping and 45th Street Berm: *No changes*** to this condition. VIS-9 was a one-time condition that required certain landscaping be accomplished earlier in the overall construction cycle.

### 3.12.3 Environmental Analysis

#### 3.12.3.1 Analysis Procedure

Visual analyses prepared for the ESEC for the original 2005 license and the license amendments issued in 2007 and 2010 determined that the visual effects of the ESEC project, with mitigation, would be less than significant. The goal of this analysis was to determine whether the ESPFM that would be permitted by the proposed amendment would alter the baseline conditions at the ESEC site in a way that would change this finding of less-than-significant impact. To make this determination, updated site reconnaissance and photography was conducted and visual simulations were prepared to depict the baseline conditions that would exist with completion of the approved ESEC facilities, and the visual conditions that would exist with implementation of the changes requested under the proposed amendment. A systematic comparison was then made of the simulations depicting the baseline views and the views that would exist with implementation of the changes to the ESEC project requested in the amendment. The goal of the comparison was to determine whether the changes brought about by the amendment would adversely affect the appearance of the site and create impacts that would exceed those of the approved ESEC project to the extent that they would be so substantial as to be significant. Comparisons were made of the visual conditions in the views from each KOP seen in the baseline and in the amendment simulations. In addition, an overall assessment was made of the visual changes that would be brought about by the amendment in terms of the four questions the California Environmental Quality Act Guidelines have established to determine the significance of visual impacts.

### 3.12.3.2 Assessment of Visual Effects from Key Observation Points

Nine KOPs have been identified and used as part of previous visual analyses. Five of these views— KOPs 1, 2, 3, 7, and 8— were deemed adequate for determination of visual impacts by CEC in the 2010 Final Revised Staff Analysis for the El Segundo Power Redevelopment Project. This analysis relies on these five established KOPs and an additional KOP—KOP 10, selected to represent an additional view from the south of the project site—to determine the visual effects of the currently proposed project. All KOPs are described in greater detail below.

Existing conditions described in this section were observed and documented during field work conducted in December 2012 and March 2013 by CH2M HILL staff. As previously noted, the photos of the existing conditions were modified to simulate in all previously approved features, including implementation of COCs to create appropriate baseline views. Visual effects of the project were assessed by comparing these images of the baseline views with simulated images that depict the views as they would appear with addition of the project features now being proposed

#### 3.12.3.2.1 KOP 1 – Dockweiler State Beach

Figure 5.13-2 depicts the views from KOP 1, which is located on Dockweiler State Beach in El Segundo, approximately 0.4 mile northwest of the northern edge of the ESEC site. Figure 5.13-2a is a view of the site under the baseline conditions, depicting Units 5 and 7 in their completed state, along with the sea wall and planting required as Conditions of Certification for Units 5 and 7. The existing Unit 3 and 4 stacks are visible to the right of the Unit 5 and 7 stacks. Figure 5.13-2b is a simulation of the KOP 1 view as it would appear with the modifications to the project site that would occur under the proposed amendment. The Unit 3 and 4 stacks would be removed. In their place, the stacks for proposed Units 11 and 12 would be visible to the immediate right of the Unit 5 and 7 stacks. From this viewpoint, the stack for Unit 9 would be behind the Unit 5 and 7 stacks. Small segments of the Unit 9 and 10 dry cooling tower will be seen extending from behind the left and right sides of the unit 5 and 7 HRSGs and the new air inlet units will be visible to the left of the sea wall, and slightly to the right of the dry cooling tower. In the view from this KOP, the Unit 3 and 4 steam boilers and turbines and associated stacks, would be replaced with lower profile generating units, a stack for Unit 9 that is similar to the Units 5 and 7 stacks, and two thinner and shorter stacks for Units 11 and 12. The effect of the changes that the proposed amendment would bring about would be to reduce the overall mass of the power generation facility on the site and to reduce its overall level of visual contrast with its setting.

#### 3.12.3.2.2 KOP 2 – View from Manhattan Beach

Figure 5.13-3 depicts the view from KOP 2, which is located on Manhattan Beach, approximately 0.1 mile south of the southwestern corner of the ESEC site. Figure 5.13-3a is a view of the site under the baseline conditions, depicting Units 5 and 7 and supporting ESEC structures in their completed state, the sea wall, and the 45<sup>th</sup> Street Berm and perimeter landscaping as required in the Conditions of Certification. The existing Unit 3 and 4 stacks are visible to the right of the Unit 5 and 7 stacks. Figure 5.13-3b is a simulation of the KOP 2 view as it would appear with the modifications to the project site that would occur under the proposed amendment. The Unit 3 and 4 stacks would be removed. In their place, the stacks for proposed Units 9, 11 and 12 would be visible. The Unit 9 stack is the same height as the Unit 5 and 7 stacks to the north. The Unit 11 and 12 stacks are located to the south of the new Unit 9 stack. Because one of these two stacks is located partially in front of the other in this view, they almost appear to be a single stack. Because these stacks are thinner than the Unit 3 and 4 stacks they replaced, and are separated from the Unit 5 and 7 stacks with an area of sky in between, the set of stacks on the site looks less massive than under baseline conditions. Two of the proposed dry cooling cells are partially visible in the area to the north of the Unit 9 stack. An additional low, rectangular gas compressor station will be partially visible to the left of the gas compressor station in front of Units 9, 11, and 12 that is a part of the baseline condition. A major change in this view will be removal of the Unit 3 and 4 steam boiler units, the large blue and gray assemblages of equipment visible to the right of the Unit 3 and 4 stacks in the baseline image. The effect of the changes brought about by the proposed amendment, particularly the removal of Unit 3 and 4 steam boiler equipment, will be to reduce the overall mass and profile of the power generation facility on the site, reduce the impact on the skyline, and bring about a noticeable reduction in the ESEC's overall level of visual contrast with its setting.

### 3.12.3.2.3 KOP 3 – View from Manhattan Beach

Figure 5.13-4a depicts the baseline view from KOP 3, which is located along Highland Avenue within a residential neighborhood of Manhattan Beach, approximately 0.1 mile southeast of the southeastern corner of the ESEC site. Units 5 and 7 are visible in their completed state, as well as the planting required as Conditions of Certification for development of Units 5 and 7. The existing Unit 3 and 4 stacks are visible to the left of the Unit 5 and 7 stacks. Figure 5.13-3b is a simulation of the KOP 3 view as it would appear with the modifications to the project site that would occur under the proposed amendment. Unit 3 and 4 stacks would be removed. In their place, the stacks for proposed Units 9, 11 and 12 would be visible. The unit 9 stack is the same height as Unit 5 and 7 stacks to the north. The Unit 11 and 12 stacks are located to the south of the new Unit 9 stack. Because one of these two stacks is located partially in front of the other in this view, they almost appear to be a single stack. A major change in this view will be removal of the Unit 3 and 4 steam boiler units, the large blue and gray assemblages of equipment visible to the right of the Unit 3 and 4 stacks in the baseline image. Removal of this large, bulky equipment will open up the views toward the ocean and the mountains in the distance. In this view, the effect of the changes brought about by the proposed amendment, particularly the removal of the Unit 3 and 4 steam boiler units, would be to reduce the overall mass and profile of the power generation facility on the site, open up the views toward the ocean and mountains behind it, and to bring about a noticeable reduction in the ESEC's overall level of visual contrast with its setting.

### 3.12.3.2.4 KOP 7 – Dockweiler Beach

Figure 5.13-5 depicts the view from KOP 7, which is located on a jetty along Dockweiler Beach in El Segundo, approximately 0.1 mile west of the northwest corner of the ESEC site. Figure 5.13-5a is a view of the site under the baseline conditions, depicting a corner of the Units 5 and 7 power block in its completed state, along with the sea wall and planting required as Conditions of Certification for development of Units 5 and 7. The existing Unit 3 and 4 stacks are visible in the center of the view, and the Unit 3 and 4 steam boiler units are visible to their left. Figure 5.13-5b is a simulation of the KOP 7 view as it would appear with the modifications to the project site that would occur under the proposed amendment. The Unit 3 and 4 stacks, steam boiler units, and other related equipment would be removed. In their place, the proposed dry cooling tower; stacks for Units 9, 11 and 12; air inlet units; and a new gas compressor station would be visible in the center of the view. In addition, the proposed low, rectangular administration building would be visible up against the bermed area on the right side of the view. In the view from this KOP, with the changes requested by the petition for amendment, the overall mass and profile of the power generation facility on the site would be noticeably reduced, and there would be a reduction in its overall level of visual contrast with its setting.

### 3.12.3.2.5 KOP 8 – Vista Del Mar

Figure 5.13-6a depicts the baseline view from KOP 8, which is located along Vista Del Mar in El Segundo, approximately 0.2 mile north of the northern edge of the ESEC site. Units 5 and 7 in their completed state are visible to right of the center of the view. The existing Unit 3 and 4 stacks and large, bulky steam boiler units are visible to the left of the Unit 5 and 7 stacks. Figure 5.13-6b is a simulation of the KOP 8 view as it would appear with the modifications to the project site that would occur under the proposed amendment. The Unit 3 and 4 stacks would be removed. In their place, the stacks for proposed Units 9, 11 and 12 would be visible. The Unit 9 stack is visible to the left of the Unit 5 and 7 stacks. The Unit 11 and 12 stacks are located to the left of the new Unit 9 stack. Because one of these two stacks is located partially in front of the other in this view, they almost appear to be a single stack. In addition, in this view, they are difficult to see because they are located behind a H-frame transmission line structure located along the western edge of Vista Del Mar. A major change in this view will be removal of the Unit 3 and 4 steam boiler units. Removal of this large, bulky equipment will reduce the overall mass and profile of the ESEC facility and open up the views from Vista del Mar. In this view, the overall effect of the changes brought about by the proposed amendment would be to open up views and bring about a noticeable reduction in ESEC's overall level of visual contrast with its setting.

### 3.12.3.2.6 KOP 10 – View from The Strand in Manhattan Beach

Figure 5.13-7a depicts the view from KOP 10, which is located along The Strand at 44<sup>th</sup> Street in Manhattan Beach, approximately 0.05 mile south of the southern edge of the ESEC site. In the baseline view, the rusty tank has been

removed and the landscaping installed in compliance with the ESPRP Conditions of Certification is visible, simulated to indicate its appearance one year after installation. Units 3 and 4 stacks are partially visible. In Figure 3.13-7b, the simulation representing the proposed facility modification outlined in this amendment, the trees and shrubs visible on the berm are those that will be planted in conformance with the Conditions of Certification for development of Units 5 and 7 as they would appear five years after planting. Figure 5.13-7b is a simulation of the KOP 10 view as it would appear with the modifications to the project site that would occur under the proposed amendment. Because of distance and topographic screening, none of the developed power facilities and administrative building proposed in this amendments will be visible. In this view, the overall effect of the changes requested by the amendment would be highly positive.

### 3.12.3.2.7 Offsite Laydown and Parking Area

This PTA incorporates the same offsite laydown area at 777 W. 190th Street in the City of Gardena that was used in construction of ESEC. The site is relatively flat, paved with asphalt, lighted and includes a perimeter security fence. No site preparation is necessary to use this offsite laydown and parking area. Because the laydown and parking area would be a temporary use during the construction phase of the project, it is not considered a source of any permanent effect to visual resources and is therefore not analyzed in this section.

### 3.12.3.3 Impact Significance

A discussion regarding whether the visual effects of the project would be significant pursuant to CEQA is provided below. The assessment of these impacts applies the criteria set forth in Appendix G of the CEQA Guidelines. The CEQA Guidelines define a “significant effect” on the environment to mean a “substantial, or potentially substantial, adverse change in any of the physical conditions within the area affected by the project, including objects of historic or aesthetic significance.” (14 CCR 15382) The four questions related to aesthetics that are posed for lead agencies and the answers to them are:

- **Would the project have a substantial adverse effect on a scenic vista?**

No. Because the overall effect of the changes brought about by the proposed amendment would be generally positive, the amendment will not create adverse effects on a scenic vista.

- **Would the project substantially damage scenic resources, including, but not limited to, trees, rock outcroppings, and historic buildings within a state scenic highway?**

No. This criterion is not applicable because the ESEC site does not lie within either the right-of-way or viewshed of a state scenic highway.

- **Would the project substantially degrade the existing visual character or quality of the site and its surroundings?**

No. As the evaluation of the changes to the views from each of the individual KOPs documents, the overall effect of the visual changes that will be brought about by the proposed amendment will be to improve the views of the site.

- **Would the project create a new source of substantial light and glare that would adversely affect day or nighttime views in the area?**

No. The modifications to the site proposed by the amendment would reduce the amount of night lighting visible within and emanating from the site. At present, the external scaffolding on the Unit 3 and 4 steam boiler units are illuminated by numerous bright bulbs that are readily visible in views from Dockweiler State Beach, Manhattan Beach, Manhattan Beach residential areas, and Vista Del Mar in El Segundo. With removal of the large, bulky combustion units and the bright points of light distributed across their surfaces, the total amount of lighting visible on the ESEC site will be visibly reduced. In addition, all lighting that will be installed on the Units 9, 10, 11, and 12 equipment will conform to Conditions of Certification VIS-7 and VIS-8, which will ensure that project lighting will be the minimal amount required for operations and safety, will be kept off when not in use, and will make use of fixtures that are hooded and directed downward and toward the area where the light is needed to minimize off-site light trespass and impacts on the night sky.

### 3.12.4 Cumulative Impacts

In its February 2005 decision approving the ESPRP, the Commission determined that:

“Cumulative impacts to visual resources would occur where project facilities or activities (such as construction) occupy the same field of view as other built facilities or impacted landscapes. It is also possible that a cumulative impact could occur if a viewer’s perception is that the general visual quality of an area is diminished by the proliferation of visible structures (or construction effects such as disturbed vegetation), even if the new structures are not within the same field of view as the existing structures. The significance of the cumulative impact would depend on the degree to which (1) the viewshed is altered; (2) visual access to scenic resources is impaired; (3) visual quality is diminished; or (4) the project’s visual contrast is increased.

In this case, the proposed project would minimally alter the viewshed. The most significant changes are enhancements: reduction in stack height, perimeter landscaping and fuel oil tank removal combined with a landscaped berm. Therefore, the cumulative visual effects of project structures on the view shed would not be significant. (California Energy Commission. 2005., p. 180)”.

The 2010 decision approving the amendment to the project determined that “...the proposed amendment would not result in a significant adverse visual impact”. The decision also found that, “The existing and proposed tree and shrub plantings around the project site will reduce the chiller system structure’s direct visual impact and contribution to cumulative visual impact to a less than significant level.” (California Energy Commission, 2010, p. 91.)

Because the changes to the approved ESEC license proposed by this amendment would further enhance the appearance of the site by reducing the mass of development on the site and by opening up views, its visual impacts would be generally positive and like the original ESPRP and ESEC Decision would not contribute to cumulative visual impacts to the ESEC site’s viewshed.

### 3.12.5 Laws, Ordinances, Regulations and Standards

The modifications proposed in this PTA are consistent with all applicable LORS. The LORS applicable to visual resources have not changed in the time since the 2010 Dry-Cooling PTA was certified by CEC. Proposed activities described in this PTA do not substantially differ from previously proposed activities in a way that would require additional, pre-existing LORS to apply to the project.

### 3.12.6 Conditions of Certification

Proposed changes to the visual resources conditions of certification are provided below using strikethrough (~~text~~) to show text proposed for deletion and underlining (text) to show text proposed to be added. New condition, VIS-10 is proposed in its entirety.

Several conditions require slight adjustment to facilitate the proposed changes to the facility and ensure that ESEC continues to enhance and complement the community aesthetically. Vis-10 is proposed to ensure that the onsite landscaping changes required for the proposed changes to ESEC do not adversely affect the visual treatment provided for in the project. The proposed changes to the visual conditions of certification are:

- **VIS-1:** Facility Visual Enhancement Plan – **No changes**
- **VIS-2:** Perimeter Screening and On-site landscaping – **No change**
- **VIS-3:** Design Treatment of Seawall – **No change**
- **VIS-4:** **No longer in decision.**
- **VIS-5:** Structure Surface Painting – **Proposed change**
- **VIS-6:** Project Lighting – **Proposed change**
- **VIS-7:** Site Lighting – **No change**
- **VIS-8:** Construction Lighting – **Proposed change**
- **VIS-9:** Temporary Landscaping and 45th Street Berm – **No change**
- **Vis-10:** Landscaping Changes- **New proposed condition**

The rationale for the proposed changes to the conditions of certification was provided in Section 3.12.2.1, above.

**VIS-1: Facility Visual Enhancement Plan.** Before starting construction, the project owner shall complete a comprehensive visual enhancement plan that includes landscaping, painting, lighting, and other measures that result in an overall enhancement of views of the facility from areas accessible to the public. The plan shall be made available for review and comment by the Executive Director of the Coastal Commission and for review and approval by the Energy Commission. The plan shall include:

- **Landscaping:** Where used to screen the facility, vegetation shall be selected and maintained to provide year-round screening (e.g., evergreen species). Preference shall be given to native species and/or species requiring little or no irrigation, or at a minimum, non-invasive species. To help native plant species succeed where efforts are made to establish them, non-native and aggressive ice plant should be removed to prevent it from out competing native dune vegetation due to its dense character and vigorous growth. Soils shall be tested, amended as needed or replaced to ensure plant survival.
- **Other structural screening:** Where berms, fencing, or other structural elements are selected as the primary method to screen the facility, the structures shall harmonize with the facility's setting on a public beach. If berms are used, they shall be vegetated and maintained with evergreen, native, and/or species requiring little or no irrigation. If fencing is used, it shall include a non-glare finish and be painted in a neutral color.

The Facility Visual Enhancement Plan shall include photographs showing existing conditions and simulated post-construction conditions from Key Observation Points (KOPs) around the facility (these may be the same KOPs that were used to develop the Staff Assessment). The plan shall also include anticipated costs for completing and maintaining the various visual enhancement measures and a detailed schedule for completing construction of these components.

**Seawall Design Plan:** Before starting construction, the project owner shall complete a plan of the seawall design for review and comment by the Executive Director of the Coastal Commission, the City of Manhattan Beach, and the City of El Segundo, and review and approval by the CPM. This plan shall include:

- **Final design:** The seawall along the west side of the facility shall be textured and finished in a neutral color harmonious with its location adjacent to a public bike path and beach. If painted, graffiti-resistant paint shall be used.
- **Landscaping:** Where used to enhance the seawall design, vegetation chosen shall be selected or maintained to provide year-round screening (e.g., evergreen species). Preference shall be given to native species and/or species requiring little or no irrigation.

This seawall design plan shall include photographs showing the existing conditions and simulated post-construction conditions from observation points along the bike path adjacent to the seawall, from the beach, and from other points where the seawall is highly visible. The plan shall also include anticipated costs for completing and maintaining the seawall and a schedule for construction.

**Verification:** At least 120 days prior to ground disturbance, the project owner shall submit the required Facility Visual Enhancement Plan and Seawall Design Plan to the Executive Director of the Coastal Commission and the Cities of Manhattan Beach and El Segundo for comment, and to the CPM for review and approval. If the CPM notifies the project owner that revisions of the submittal are needed before the CPM will approve the submittal, the project owner shall prepare and submit to the Coastal Commission staff, the Cities, and CPM a revised submittal.

**VIS-2 Perimeter screening and on-site landscaping:** The project owner shall prepare and implement an approved perimeter screening and on-site landscape plan.

Trees and landscaping along the eastern edge of the project site shall be designed to balance view corridors to the ocean with screening of the facility. The landscape plan shall be provided to the CPM for review and approval, and to the Executive Director of the California Coastal Commission, the City of El Segundo and the City of Manhattan Beach for review and comment. The CPM will consider timely comments from these parties, especially those

regarding the balance struck in the landscape plan between view corridor preservation and screening of project components, in determining whether to approve the plan.

The project owner shall establish a Landscape Committee to develop the final landscape plan that will be submitted to the CPM for review and approval, and other parties for review and comment. The Landscape Committee will be comprised of two voting members from the City of El Segundo, two voting members from the City of Manhattan Beach, and two members (one vote) representing the project owner. Energy Commission and Coastal Commission staff will participate on the Committee in an advisory role. The project owner shall submit to the CPM for review and approval a detailed schedule for the Landscape Committee meetings that will ensure that the final landscape plan is provided to the CPM in accordance with the timeline established in the condition.

The screening shall, at a minimum, utilize landscape opportunities on all four boundaries of the project site. Landscape screening shall include: (a) continuous tree canopies on the eastern roadside perimeter to enhance visual unity of the Vista del Mar road corridor, compatibility of the ~~ESPRP~~ project with its coastal setting, and at least partial long-term screening of upper portions of the HRSGs; (b) tree and shrub plantings along Vista del Mar to screen views of the structures, while preserving view corridors to the Bay; (c) plantings along 45th Street to provide long-term screening of the tank farm site; and (d) tree planting on the western site perimeter to screen upper planting on the path (west) side of all new concrete walls constructed along the existing bike path. The plan shall comply with City of El Segundo Zoning codes (Title 15, Chapter 2, Sec. 15-2-14) pertaining to on-site landscaping. The final landscape plan shall reflect the agreed upon removal of existing urea tanks on the west side of the project site.

Final plant selection shall be made in consultation with the Compliance Project Manager (CPM), Coastal Commission staff, and the Cities of Manhattan Beach and El Segundo. Suitable irrigation shall be installed to ensure survival and desired rate of growth. The landscape screening and irrigation system shall be monitored for a period of five years to ensure survival. During this period all dead plant material shall be replaced.

To achieve year-round screening, evergreen species shall be used. Spacing of trees shall be sufficiently dense to ensure substantial screening by the tree canopy at maturity.

Prior to the start of construction, the project owner shall submit a landscape plan to the representatives of California Exotic Pest Plant Council, The Executive Director of the California Coastal Commission and the Cities of Manhattan Beach and El Segundo for review and comment, and to the CPM for review and approval. The plan shall include, but not be limited to:

1. A detailed landscape, grading, and irrigation plan, at a reasonable scale, which includes a list of proposed tree, plant, and shrub species and installation sizes, and a discussion of both the suitability of the plants for the site conditions and mitigation objectives, and conformance with the specific provisions of the Coastal Commission decision, including its 1b and 2b specifying preference for native, non-invasive, and drought tolerant species. A list of potential plant species that would be both viable and non-invasive in this location shall be prepared by a qualified professional landscape architect familiar with local growing conditions, with the objective of providing the widest possible range of species from which to choose. The final planting plan shall include an all inclusive list of plants to be used in order to ensure exclusion of potentially invasive species.
2. A demonstration of how the screening conditions shall be met, including:
  - a) Evidence provided by a qualified landscape architect that the specified species are both viable and available;
  - b) Graphic documentation on the plan and through digital photo simulations of Bay view corridors and power plant screening which would exist from Vista del Mar and the residential area east of Highland that has views of the project site after project construction; and
  - c) A description of tall and short shrub planting zones along Vista del Mar, such that screening of the existing and proposed power plants is maximized, while the aforementioned Bay view corridors are retained.

3. Elevation views or visual simulations of the landscape screening at maturity, in order to show the extent of screening that the landscaping is expected to achieve from the west side of the project, from 45th Street and from Vista del Mar.
4. A detailed schedule for completion of the installation.
5. Maintenance procedures for the entire project site, including any needed irrigation and a plan for routine and regular debris removal as needed to preserve a neat and well-maintained appearance, for the life of the project.
6. A procedure for monitoring and replacement of all unsuccessful plantings for the life of the project.
7. A chart and key plan showing conformance with City of El Segundo landscape regulations.
8. Soil tests shall be performed on both on-site and imported soil where landscaping is to take place. Soil shall be amended on the basis of those tests if needed to ensure long-term viability of plantings.

The property owner shall meet the City of El Segundo's requirements for Vehicle Use Area (VUA) landscaping in the tank farm area by providing the required trees on the existing containment berm and other areas immediately adjacent to the portion of the tank farm area to be used for paved staging, not including the area to be striped for vehicle parking.

The Landscape Plan shall be consistent with the Landscape Concept Plan presented at Evidentiary Hearings, with modifications for VUA landscaping, revisions to depict the 45th Street landscape berm, and modifications to accord with item #2, above.

The project owner shall not implement the plan until the project owner receives written approval of the plan from the CPM.

**Verification:** At least 30 days prior to the first scheduled Landscape Committee meeting, the project owner shall submit the Committee schedule to the CPM for review and approval. At least 120 days prior to ground disturbance, the project owner shall submit the perimeter screening and onsite landscape plan to the Executive Director of the Coastal Commission and the Cities of Manhattan Beach and El Segundo for comment, and the CPM for review and approval. If the CPM notifies the project owner that revisions of the submittal are needed before the CPM will approve the submittal, the project owner shall prepare and submit to the Coastal Commission staff, the Cities, and the CPM a revised submittal.

The project owner shall implement the landscape plan prior to start of commercial operation. The project owner shall notify the CPM within seven days after completing installation of the landscape plan that the planting and irrigation system are ready for inspection.

The project owner shall report landscape maintenance activities, including replacement of dead vegetation, for the previous year of operation in the Annual Compliance Report.

**VIS-3 Design treatment of seawall:** The project owner shall construct the proposed seawall with architectural design treatment to reduce visual monotony, enhance design quality and interest, and discourage graffiti. Techniques may include pre-cast or cast-in-place texturing, split-faced concrete block, or other methods feasible to produce a textured surface.

Prior to the start of construction, the project owner shall submit a design plan for the seawall, consistent with the Landscape Concept Plan, to the Executive Director of the Coastal Commission and City of El Segundo for review and comment, and to the CPM for review and approval. The treatment plan shall include:

1. Specification, and 11" x 17" color elevations, of the treatment proposed for use on the seawall;
2. A detailed schedule for completion of construction; and,
3. A procedure to ensure proper maintenance, including graffiti removal, for the life of the project.
4. Seawall construction shall not commence until the design plan has been approved by the CPM.



**Verification:** At least 120 days prior to start of construction, the project owner shall submit the seawall design plan to the Executive Director of the Coastal Commission and City of El Segundo for review and comment and to the CPM for review and approval.

If the CPM notifies the project owner of any revisions that are needed before the CPM will approve the plan, the project owner shall submit a revised plan to the CPM.

Not less than 30 days prior to start of commercial operation, the project owner shall notify the CPM that the seawall is ready for inspection.

The project owner shall provide a status report regarding wall maintenance in the Annual Compliance Report.

~~**VIS-4 Architectural Screening of Power Plant:**~~ [REMOVED FROM SET OF COCs IN 2008; NO LONGER APPLICABLE TO PROJECT]

**VIS-5 Structure Surface Painting and Treatment:** Prior to the start of commercial operation, the project owner shall paint or treat project structures visible to the public, such that their colors minimize visual intrusion and contrast by blending with the landscape; their surfaces do not create glare; and they are consistent with local laws, ordinances, regulations, and standards.

Prior to the start of commercial operation of Units 9, 10, 11 and 12, the project owner shall paint or treat the structures visible to the public, such that their colors minimize visual intrusion and contrast by blending with the landscape; their surfaces do not create glare; and they are consistent with local laws, ordinances, regulations, and standards.

The project owner shall consult with representatives of the Cities of El Segundo and Manhattan Beach to determine if specific treatment or painting options that may improve the aesthetic appearance of the project are desired, and provide a report to the CPM.

Prior to the start of construction of the new Units, the project owner shall submit to the Executive Director of the Coastal Commission and the Cities of El Segundo and Manhattan Beach for review and comment, and to the CPM for review and approval, a specific treatment plan whose proper implementation will satisfy these requirements. The treatment plan shall include:

- a) Specification, and 11" x 17" color simulations at life size scale, of the treatment proposed for use on project structures, including structures treated during manufacture;
- b) A list of each major project structure, building, tank, transmission line tower and/or pole, and fencing/walls specifying the color(s) and finish proposed for each (colors must be identified by name and by vendor brand or a universal designation);
- c) Two sets of brochures and/or color chips for each proposed color;
- d) Samples of each proposed treatment and color on each material to which they would be applied that would be visible to the public;
- e) A detailed schedule for completion of the treatment; and
- f) A procedure to ensure proper treatment maintenance for the life of the project.

The project owner shall not specify to the vendors the treatment of any buildings or structures treated during manufacture, or perform the final treatment on any buildings or structures treated on-site, until the project owner receives notification of approval of the treatment plan by the CPM.

**Verification:** The project owner shall submit its proposed treatment plan at least 90 (ninety) days prior to ordering the first structures that are color treated during manufacture.

If revisions are required, the project owner shall provide the CPM with a revised plan within 30 (thirty) days of receiving notification that revisions are needed.

Prior to commercial operation, the project owner shall notify the CPM that all buildings and structures are ready for inspection.

The project owner shall provide a status report regarding treatment maintenance in the Annual Compliance Report.

**VIS-6 Project Lighting:** Prior to the start of commercial operation, the project owner shall design and install new permanent lighting for new generating units Units 5, 6, 7 and 8, such that light bulbs and reflectors are not visible from public viewing areas; lighting does not cause reflected glare; and illumination of the project, the vicinity, and the nighttime sky is minimized.

To meet these requirements the project owner shall ensure that:

- a) Lighting shall be designed so exterior light fixtures are hooded, with lights directed downward or toward the area to be illuminated and so that backscatter to the nighttime sky is minimized. The design of the lighting shall be such that the luminescence or light source is shielded to prevent light trespass outside the project boundary;
- b) All lighting shall be of minimum necessary brightness consistent with worker safety;
- c) Wherever feasible and safe, lighting shall be kept off when not in use; and
- d) A lighting complaint resolution form shall be used by plant operations to record all lighting complaints received and document the resolution of those complaints. All records of lighting complaints shall be kept in the on-site compliance file.

**Verification:** At least 60 days prior to ordering any permanent exterior lighting, the project owner shall submit to the CPM for review and comment written documentation describing the lighting control measures and fixtures, hoods, shields proposed for use, and incorporate the CPM's comments in lighting equipment orders.

Prior to the first turbine roll, the project owner shall notify the CPM that the lighting has been completed and is ready for inspection. If the CPM notifies the project owner that modifications to the lighting are needed to minimize impacts, within 30 days of receiving that notification the project owner shall implement the modifications and notify the CPM that the modifications have been completed.

The project owner shall report any lighting complaints and documentation of resolution in the Annual Compliance Report, accompanied by any lighting complaint resolution forms or that year.

**VIS-7 Site Lighting:** Prior to demolition of existing storage tanks, the project owner shall modify the Unit 3 and 4 new generating units permanent lighting, such that light bulbs and reflectors are not visible from public viewing areas; lighting does not cause reflected glare; and illumination of the project, the vicinity, and the nighttime sky is minimized. To meet these requirements the project owner shall ensure that:

- a) Lighting shall be designed so exterior light fixtures are hooded, with lights directed downward or toward the area to be illuminated and so that backscatter to the nighttime sky is minimized. The design of the lighting shall be such that the luminescence or light source is shielded to prevent light trespass outside the project boundary;
- b) All lighting shall be of minimum necessary brightness consistent with worker safety;
- c) The project owner shall implement where feasible and practical modifications of circuits in order to allow turning off specific lights when not in use; and
- d) A lighting complaint resolution form shall be used by plant operations to record all lighting complaints received and document the resolution of those complaints. All records of lighting complaints shall be kept in the on-site compliance file.

**Verification:** At least 60 days prior to ordering of any new permanent exterior lighting for the new generating units Units 3 and 4, the project owner shall submit to the CPM for review and comment written documentation

describing the lighting control measures and fixtures, hoods, shields proposed for use, and incorporate the CPM's comments in lighting equipment orders.

Prior to demolition of the tanks, the project owner shall notify the CPM that the lighting modifications to Unit 3 and 4 have been completed and are ready for inspection. If the PM notifies the project owner that modifications to the lighting are needed to minimize impacts, within 30 days of receiving that notification the project owner shall implement the modifications and notify the CPM that the modifications have been completed.

The project owner shall report any complaints about permanent lighting and provide documentation of resolution in the Annual Compliance Report, accompanied by any lighting complaint resolution forms for that year.

**VIS-8 Construction Lighting:** Prior to site mobilization, the project owner shall ensure that lighting for construction of the power plant is used in a manner that minimizes potential night lighting impacts, as follows:

- a) All lighting shall be of minimum necessary brightness consistent with worker safety.
- b) All fixed position lighting shall be shielded, hooded, and directed downward to minimize backscatter to the night sky and prevent light trespass (direct lighting extending outside the boundaries of the construction area).
- c) Wherever feasible and safe, lighting shall be kept off when not in use and motion detectors shall be employed.
- d) A lighting complaint resolution form shall be maintained by plant construction management, to record all lighting complaints received and to document the resolution of that complaint.
- e) All construction-related lighting shall be completely shielded or screened so as not to be visible to residents of 45th Street in Manhattan Beach. Construction lighting in the tank farm area shall be limited to the hours of 7:30 a.m. to 6:00 p.m. Monday through Friday and 9:00 a.m. to 6:00 p.m. Saturday, except as necessary for safety or security purposes.

**Verification:** Within seven days after the first use of construction lighting, the project owner shall notify the City of Manhattan Beach and the CPM that the lighting is ready for inspection.

If the CPM notifies the project owner that modifications to the lighting are needed to minimize impacts, within 15 days of receiving that notification the project owner shall implement the necessary modifications and notify the CPM that the modifications have been completed.

The project owner shall report any lighting complaints and documentation of resolution in the Monthly Compliance Report, accompanied by any lighting complaint resolution forms for that month.

**VIS-9 Temporary Landscaping and 45th Street Berm:** Temporary landscaping and 45th Street Berm. Temporary landscaping shall be installed prior to the start of ground disturbing activities at the site in those opportunity areas that do not create a hindrance to construction activities. Soils shall be tested, amended as needed or replaced to ensure plant survival. Temporary landscaping shall be maintained for the duration of construction, and shall be designed to the extent feasible to be retained permanently as part of the perimeter landscaping plan required in Condition of Certification VIS-2. Installation of the 45th Street berm shall be initiated concurrent with construction of the new tank farm access road.

Prior to start of ground disturbance, the project owner shall submit a temporary perimeter landscape plan and final berm plan to the Cities of Manhattan Beach and El Segundo and the Executive Director of the Coastal Commission for review and comment, and to the CPM for review and approval. The plans shall include, but not be limited to:

- a) A detailed landscape, grading and irrigation plan, at a reasonable scale, which includes an all-inclusive list of proposed tree, plant, and shrub species and installation sizes, and a discussion of the suitability of the plants for the site conditions and mitigation objectives. A list of potential plant species that would be viable and non-invasive in this location shall be prepared by a qualified professional landscape architect familiar with

local growing conditions, with the objective of providing the widest possible range of species from which to choose. The plan shall demonstrate how the screening shall be met, including:

- b) Elevation views or visual simulations of the landscape screening at one year's growth in order to show the extent of screening that the landscaping is expected to achieve from the west side of the project, 45th Street and from Vista del Mar.
- c) A detailed schedule for completion of the installation.
- d) Maintenance procedures for the entire project site, including any needed irrigation and a plan for routine and regular debris removal as needed to preserve a neat and well-maintained appearance, for the life of the project; and
- e) A procedure for monitoring and replacement of unsuccessful plantings.

The project owner shall not implement the plan until the project owner receives written approval from the CPM

**Verification:** At least 60 days prior to start of ground disturbance, the project owner shall submit the temporary perimeter landscape plan and final berm plan to representatives of California Exotic Pest Plant Council, the Executive Director of the Coastal Commission and Cities of Manhattan Beach and El Segundo for comment, and to the CPM for review and approval. If the CPM notifies the project owner that revisions of the submittal are needed before the CPM will approve the submittal, the project owner shall prepare and submit to the CPM a revised plan.

The project owner shall notify the CPM within seven days after completing installation of the 45th Street berm that the berm is ready for inspection. The project owner shall notify the CPM within seven days after completing installation of the temporary landscape screening that the planting and irrigation system are ready for inspection.

The project owner shall report landscape maintenance activities, including replacement of dead vegetation, for the previous month of construction in the Monthly Compliance Report.

**VIS-10 Updated Facility Visual Enhancement Plan:** Before starting construction of the ESPFM changes, the project owner shall update the Facility Visual Enhancement Plan originally prepared under condition of certification VIS-1. The update shall be made available for review and comment by the Executive Director of the Coastal Commission, the City of Manhattan Beach, the City of El Segundo and then be approved by the Compliance Project Manager.

The update shall include any changes to the landscaping, painting, lighting, and other measures provided for in the original Facility Visual Enhancement Plan as further specified below:

- **Landscaping:** The landscaping that was put in place under the ESEC shall be evaluated, and an identification made of ways it can be supplemented, if appropriate to provide additional screening of sensitive views toward the changed areas of the facility. To the extent that additional plantings should be found to be appropriate and effective in screening sensitive views of the changed facilities, the vegetation specified shall be selected and maintained to provide year-round screening (e.g., evergreen species). Preference shall be given to native species and/or species requiring little or no irrigation, or at a minimum, non-invasive species. To help native plant species succeed where efforts are made to establish them, non-native and aggressive ice plant should be removed to prevent it from out competing native dune vegetation due to its dense character and vigorous growth. Soils shall be tested, amended as needed or replaced to ensure plant survival.
- **Other structural screening:** The berms, fencing, or other structural elements implemented to screen the ESEC shall be evaluated, and an identification made of any areas where it would be appropriate to supplement them to provide additional screening of sensitive views toward the changed facilities. To the extent that additional structural screening should be found to be appropriate the structures shall harmonize with the facility's setting on a public beach. If any additional berms are found to be appropriate, they shall be vegetated and maintained with evergreen, native, and/or species requiring little or no irrigation. If fencing is used, it shall include a non-glare finish and be painted in a neutral color.

**Verification:** At least 120 days prior to ground disturbance, the project owner shall submit the required Updated Facility Visual Enhancement Plan to the Executive Director of the Coastal Commission and the Cities of Manhattan

Beach and El Segundo for comment, and to the CPM for review and approval. If the CPM notifies the project owner that revisions of the submittal are needed before the CPM will approve the submittal, the project owner shall prepare and submit to the Coastal Commission staff, the Cities, and CPM a revised submittal.

### **3.12.7 References Cited or Consulted**

California Department of Transportation. 2009. California Scenic Highway Program.  
[http://www.dot.ca.gov/hq/LandArch/scenic\\_highways/scenic\\_hwy.htm](http://www.dot.ca.gov/hq/LandArch/scenic_highways/scenic_hwy.htm)

California Energy Commission. 2005. Commission Decision. El Segundo Power Redevelopment Project, Application for Certification (00-AFC-14) Los Angeles County, California. CEC-800-2005-001-CMF.

California Energy Commission. 2010. Commission Decision to the Amendment. El Segundo Power Redevelopment Project. CEC-800-2010-015.

Shaw Environmental Inc. 2007. Petition to Amend Final Commission Decision for the El Segundo Power Redevelopment Project. June.





Chevron El Segundo Refinery

KOP 8

KOP 3

KOP 10

KOP 2

E EL SEGUNDO BLVD

ROSECRANS AVE

HIGHLAND AVE

OCEAN DR

THE STRAND

El Segundo  
Monitoring Station

El Segundo Bay







View looking south-southeast toward ESGS from Dockweiler Beach State Park in El Segundo. ESGS is visible in the center of the view, and Manhattan Beach is visible to the south of ESGS. Landscaping required as part of existing COCs for 00-AFC-14 is shown as it would appear 1 year after installation.









View looking north toward ESGS from Manhattan Beach State Park in Manhattan Beach. ESGS is visible in the center of the view. Landscaping required as part of existing plans for 00-AFC-14 is shown as it would appear 1 year after installation and is concentrated along the southern and southwestern edge of the project site.









View to the north-northwest toward ESGS from Highland Avenue, in Manhattan Beach. ESGS is visible in the center of this view from within a residential portion of Manhattan Beach near 43rd Street. Landscaping required as part of existing COCs for 00-AFC-14 is shown as it would appear 1 year after installation.










A. View to the southeast toward ESGS from a jetty at Dockweiler Beach in El Segundo. The southern area of ESGS is visible in this view, with the Chevron Refinery and City of Manhattan Beach visible as background. Landscaping required as part of existing COCs for the jetty is shown as it would appear 1 year after installation.



B. View from KOP 7 showing ESPFM. Landscaping improvements would appear 5 years after installation.







View looking south-southeast toward ESGS from Vista Del Mar in El Segundo. El Segundo Energy Center is visible in the center of the view from the roadway that runs along the eastern edge of the ESEC site. Landscaping required as part of existing COCs for 00-AFC-14 is shown as it would appear 1 year after installation.









View looking north toward ESGS from The Strand, near 44th Street, in Manhattan Beach. Views toward the center of ESGS are mostly obstructed by the 45th Street gate and landscaping required as part of existing COCs for 00-AFC-14, shown as it would appear 1 year after installation.





## 3.13 Waste Management

This section describes and evaluates potential effects the proposed ESPFM may have on waste management since the CEC Final Decision in 2005 and the subsequent PTAs. Compliance with applicable LORS is also addressed.

### 3.13.1 Amendment Overview

As discussed in detail in Section 2.0, Project Description, this PTA proposes modifications to the ESEC that necessitate evaluation of environmental impacts and potential amendments to existing COCs. The proposed PTA is for decommissioning, demolishing, and replacing the existing Units 3 and 4 steam boiler plants with approximately 449 MW gross / 435 MW net of new natural-gas-fired electrical generating capacity, consisting of one combined-cycle train and two simple-cycle gas turbines. The air-cooled, combined-cycle train (CC Fast) will consist of a GTG (Unit 9), a an HRSG, and one STG (Unit 10), rated at 325 MW net. The simple cycle turbines (Units 11 and 12) will consist of two air-cooled Trent 60 ISE advanced aeroderivative gas turbines, each rated at 55 MW net / 58 MW gross. The GE turbine will be supported by a small (36 MMBtu/hr) auxiliary boiler that will be incorporated into the operation of the CC Fast. Removal of existing Units 3 and 4 will eliminate the remaining once-through ocean water cooling system at the ESGS site. The ESPFM will improve electricity generation by adding fast-start and dispatch flexibility capability to support southern California grid load balancing. Total site capacity (including the new equipment previously permitted) will not exceed 1,020 MW net—the rated capacity of previously retired Units 1 and 2, plus the capacity of the soon-to-be-retired Unit 3 and operating Unit 4, which will also be retired as part of the ESPFM.

### 3.13.2 Affected Environment

#### 3.13.2.1 ESEC Amendments

The proposed ESPFM will result in modifications to the ESEC license (00-AFC-14C). Decommissioning, demolishing, and removing existing Units 3 and 4 and replacing them with new Units 9, 10, 11, and 12 will not result in new waste management impacts beyond those identified in the CEC's amended license for 00-AFC-14 and as described in Section 2.0. It is anticipated that demolition of Units 3 and 4 will generate similar types and quantities of waste as was generated during the demolition of Units 1 and 2. The waste management procedures are subject to the approved COCs WASTE- 1 through WASTE-8, which are adequate to handle the potential ESPFM waste management storage and disposal impacts. The following is a brief description of the waste management existing COCs:

- **WASTE-1** Generator Identification Number
- **WASTE -2** Waste Management Enforcement Action
- **WASTE-4** Registered Professional Engineer/Geologist
- **WASTE -5** Contaminated Soil Excavation
- **WASTE -6** Remedial Investigation Workplan
- **WASTE -7** Runoff Containment
- **WASTE -8** Hazardous Waste Survey

ESEC LLC) has implemented standard operating procedures that require that the existing waste management procedures be maintained to handle ESPFM requirements. As such, the project owner will continue to comply with the requirements set forth in these COCs and will provide updates regarding any changes in onsite waste storage and offsite delivery schedules, as necessary.

### 3.13.3 Environmental Analysis

As discussed in Section 2.8, Hazardous Materials Management, and consistent with the demolition, construction and future ESEC operating conditions at the ESGS site, the demolition and removal of Units 3 and 4 and the installation and operation of new Units 9, 10, 11, and 12 will result in similar amounts of excavation and truck trips associated with offsite disposal as well as similar construction and operation waste management requirements. Tables 2.8-1 through 2.8-4 list the types and amounts of wastes generated by construction,



demolition, and operation of the ESEC and construction and operation of the ESPFM is expected to generate similar types and amounts of solid waste. The storage and disposal of these waste products will be conducted in accordance with all applicable LORS and existing COCs. In addition, the removal of Units 3 and 4 and subsequent discontinuation of the once-through cooling system will eliminate the need to dispose of the waste products associated with the by-products generated from the cooling water process. Therefore, it is expected the operation of the ESPFM will result in similar waste generation, storage, and disposal needs. Waste management will continue to be mitigated by conformance with the requirements of COCs WASTE-1 through WASTE-8.

### 3.13.3.1 Offsite Construction Laydown and Construction Worker Parking Areas

The preferred offsite laydown area, located at 777 W. 190th Street in the City of Gardena, was incorporated into ESEC in the 2010 PTA decision and will continue to be used for ESPFM. Construction laydown and parking areas will also be established within the ESGS site boundary, as well as at offsite areas identified in the CEC Final Decision and shown on Figure 2-10. The 190th Street area is less than ten miles southeast of the ESGS and is easily accessible to the I-405 and I-110 North freeways from Vermont Avenue and 190th Street as well as to ESEC-approved traffic/truck routes. This site, zoned M2, commercial, has approximately ten usable acres and includes a 5,500 square-foot industrial building. The approximately 12.1-acre site paved with asphalt has nightlighting and includes a perimeter security fence. No site preparation other than minor clean-up is required prior to use. During the construction phase, the types of wastes that may be used or encountered at the construction laydown areas are expected to be limited to inert trash and debris. The existing COCs ensure that construction-related activities conducted at the laydown areas will comply with appropriate waste management procedures and plans.

### 3.13.4 Cumulative Impacts

The proposed ESPFM covered under this PTA will result in similar waste management impacts for the demolition of Units 3 and 4 and construction of Units 9 through 12 as the demolition of Units 1 and 2 and construction of Units 5 through 8 and, therefore, will not result in any significant cumulative impacts associated with the generation or disposal of wastes beyond those addressed in the CEC Final Decision for 00-AFC-14.

### 3.13.5 Laws, Ordinances, Regulations and Standards

The CEC Final Decision found the project to be in compliance with all applicable waste LORS. As described in this PTA, the proposed ESPFM is consistent with applicable waste management-related LORS and the Amendment will not alter the assumptions or conclusions in the CEC Final Decision for 00-AFC-14 and no additional or revised LORS compliance requirements have been identified.

### 3.13.6 Conditions of Certification

ESEC LLC's standard operating procedures require that all waste products be disposed consistent with COCs. As such, it will continue to comply with the requirements set forth in these COCs and will document the location and amounts of waste generated and disposed offsite. Previously approved COCs for Waste Management are sufficient in addressing waste storage and disposal requirements. Existing COCs WASTE-1 through WASTE-8 are adequate to address ESPFM without being amended, with the exception of the minor changes below that focus on the single fuel tank being removed as part of this PTA. These COCs are provided below.

**WASTE-1 Waste Generator Identification Number:** The project owner and, if necessary, its construction contractor, shall each obtain a hazardous waste generator identification number from the Department of Toxic Substances Control prior to generating any hazardous waste.

**Verification:** The project owner shall notify the CPM via the monthly compliance report of its receipt and keep a copy of the identification number on file at the project site.

**WASTE-3 Waste Management:** Upon becoming aware of any impending waste management-related enforcement action by any local, state, or federal authority, the project owner shall notify the CPM of any such action taken or proposed to be taken against the project itself, or against any waste hauler or disposal facility or treatment operator with which the owner contracts.

**Verification:** The project owner shall notify the CPM in writing within 10 days of becoming aware of an impending enforcement action. The CPM shall notify the project owner of any changes that will be required in the manner in which project-related wastes are managed.

**WASTE-3 Waste Management Plan:** Prior to the start of both site mobilization and project operation, the project owner shall prepare and submit to the CPM for review and approval, and to local agencies, if applicable, for review and comment, a waste management plan for all wastes generated during construction and operation of the facility, respectively. The plans shall contain, at a minimum, the following:

- A description of all waste streams, including projections of frequency, amounts generated and hazard classifications; and
- Methods of managing each waste, including storage, treatment methods and companies contracted with for treatment services, waste testing methods to assure correct classification, methods of transportation, disposal requirements and sites, and recycling and waste minimization/reduction plans.

**Verification:** No less than 30 days prior to the start of site mobilization, the project owner shall submit the demolition and construction waste management plan to and to local agencies, if applicable, for review and comment, and the CPM. The operation waste management plan shall be submitted no less than 30 days prior to the start of project operation. The project owner shall submit any required revisions within 20 days of notification by the CPM (or mutually agreed upon date). In the Annual Compliance Reports, the project owner shall document the actual waste management methods used during the year compared to planned management methods.

**WASTE-4 Registered Professional Engineer/Geologist:** The project owner shall have a Registered Professional Engineer or Geologist, with experience in remedial investigation and feasibility studies, available for consultation during soil excavation and grading activities. The Registered Professional Engineer or Geologist shall be given full authority to oversee any earth moving activities that have the potential to disturb contaminated soil.

**Verification:** At least 30 days prior to the start of site mobilization, the project owner shall submit the qualifications and experience of the Registered Professional Engineer or Geologist to the CPM for approval.

**WASTE-5 Contaminated Soil Excavation:** If potentially contaminated soil is unearthed during excavation at either the proposed site or linear facilities as evidenced by discoloration, odor, detection by handheld instruments, or other signs, the Registered Professional Engineer or Geologist shall inspect the site, determine the need for sampling to confirm the nature and extent of contamination, and file a written report to the project owner and CPM stating the recommended course of action. Depending on the nature and extent of contamination, the Registered Professional Engineer or Geologist shall have the authority to temporarily suspend construction activity at that location for the protection of workers or the public. If, in the opinion of the Registered Professional Engineer or Geologist, significant remediation may be required, the project owner shall contact representatives of the Los Angeles Regional Water Quality Control Board, the Glendale Regional Office of the California Department of Toxic Substances Control the CPM, and other local agencies, if applicable, for guidance and possible oversight.

**Verification:** The project owner shall submit any reports filed by the Registered Professional Engineer or Geologist to the CPM and the City of El Segundo Fire Department within 5 days of their receipt. The project owner shall notify the CPM within 24 hours of any orders issued to halt construction.

**WASTE-6 Remedial Investigation Workplan:** Before demolition of the existing Units 3 and 4 and any other support building or equipment, respectively, the project owner shall prepare a Remedial Investigation Workplan (RI Workplan). This plan shall include a detailed site characterization plan with soil and groundwater sampling and analysis to determine the extent and nature of contamination existing beneath these structures. The RI Workplan shall be provided to the Glendale Regional Office of the California Department of Toxic Substances Control, the Los Angeles Regional Water Quality Control, and the City of El Segundo Fire Department, and other local agencies, if applicable, for review and comment, and to the CEC CPM for review and approval. If contaminated soil or groundwater is found to exist, the project owner shall contact representatives of the above-named agencies for further guidance and possible oversight. In no event shall the project owner proceed with site preparation or construction activities at any location on the site where hazardous waste contamination is found to be present

until that location is either remediated or shown to pose an insignificant risk to humans and the environment as demonstrated to the satisfaction of the LARWQCB, DTSC, and the CPM.

**Verification:** At least sixty (60) days prior to commencement of fuel tanks demolition or structure demolition, respectively, the project owner shall provide the RI Workplan to the Glendale Regional Office of the California Department of Toxic Substances Control, the Los Angeles Regional Water Quality Control Board, the City of El Segundo Fire Department, other agencies, if applicable, and the CEC CPM. Within thirty (30) days of completion of the sampling and analysis and prior to the initiation of any construction activities, the project owner shall provide the results of the sampling and analysis to the Glendale Regional Office of the California Department of Toxic Substances Control, the Los Angeles Regional Water Quality Control Board, the City of El Segundo Fire Department, other agencies, if applicable, and the CPM for review and guidance on possible remediation.

**WASTE-7 Runoff Containment:** Before demolition of the fuel oil tanks, the existing generator buildings and any other building, the project owner shall ensure that the appropriate portion of the site is surrounded by a berm or other solid structures capable of containing any runoff from that portion of the site and preventing this runoff from leaving the site. In no event shall the project owner proceed with site preparation or construction activities at any location on the site where hazardous waste contamination is found to be present until that location has such containment in place to the satisfaction of the CPM.

**Verification:** At least thirty (30) days prior to commencement of site preparation activities, the project owner shall provide written plans on containment to the CPM for review and approval.

**WASTE-8 Hazardous Waste Survey:** Prior to modification or demolition of existing structures, the project owner shall complete and submit a survey of all Asbestos-Containing Materials (ACM) and Regulated Building Materials (RBM) that contain lead-based paint to the El Segundo Fire Department for review and comment and to the CPM for approval. After receiving approval, the project owner shall remove all ACM and RBM from the site prior to demolition.

**Verification:** No less than sixty (60) days prior to commencement of structure demolition, the project owner shall provide the survey to the El Segundo Fire Department for review and comment, and to the CPM for review and approval. The project owner shall inform the CPM, via the monthly compliance report, of the data when all ACM and RBM were removed from the site.

## 3.14 Worker Health and Safety

This section describes and evaluates potential effects the proposed changes may have on worker health and safety. Compliance with applicable LORS is also addressed.

### 3.14.1 Amendment Overview

As discussed in detail in Section 2.0, Project Description, this PTA proposes modifications to the ESEC that necessitate evaluation of environmental impacts and potential amendments to existing COCs. The proposed PTA is for decommissioning, demolishing, and replacing the existing Units 3 and 4 steam boiler plants with approximately 449 MW gross / 435 MW net of new natural-gas-fired electrical generating capacity, consisting of one combined-cycle train and two simple-cycle gas turbines. The air-cooled, combined-cycle train (CC Fast) will consist of a GTG (Unit 9), a an HRSG, and one STG (Unit 10), rated at 325 MW net. The simple cycle turbines (Units 11 and 12) will consist of two air-cooled Trent 60 ISE advanced aeroderivative gas turbines, each rated at 55 MW net / 58 MW gross. The GE turbine will be supported by a small (36 MMBtu/hr) auxiliary boiler that will be incorporated into the operation of the CC Fast. Removal of existing Units 3 and 4 will eliminate the remaining once-through ocean water cooling system at the ESGS site. The ESPFM will improve electricity generation by adding fast-start and dispatch flexibility capability to support southern California grid load balancing. Total site capacity (including the new equipment previously permitted) will not exceed 1,020 MW net—the rated capacity of previously retired Units 1 and 2, plus the capacity of the soon-to-be-retired Unit 3 and operating Unit 4, which will also be retired as part of the ESPFM.

### 3.14.2 Affected Environment

#### 3.14.2.1 ESEC Amendments

The proposed ESPFM will result in modifications to the ESEC license (00-AFC-14C). Decommissioning, demolishing, and removing existing Units 3 and 4 and replacing them with new Units 9, 10, 11, and 12 will not result in new worker safety impacts above those identified in the CEC's amended license for 00-AFC-14 and as described in Section 2.0. The ESPFM may result in minor changes in hazardous materials storage and use, hazardous waste generation, noise exposure, construction activities, fire protection, and emergency response and are addressed in more detail in each of the specific PTA sections. The Worker Safety and Health Program subject to the approved COCs WORKER SAFETY-1 through WORKER SAFETY-6 is adequate to address the potential impacts of ESPFM. The following is a brief description of the worker safety covered by each existing COC:

- WORKER SAFETY-1** Demolition-related plans and programs
- WORKER SAFETY-2** Operations and Maintenance Safety Plan
- WORKER SAFETY-3** Use of former tank area for storage – *Proposed deletion*
- WORKER SAFETY-4** Construction Safety Supervisor
- WORKER SAFETY-5** Chief Building Official (CBO) Payments
- WORKER SAFETY-6** Onsite AED

ESEC LLC has implemented standard operating procedures that require that all safety-related plans be maintained to reflect current site and emergency service conditions. As such, the project owner will continue to comply with the requirements set forth in these COCs and will provide updates regarding the location or project components, implementation of onsite safety systems/programs, and emergency response contacts, as necessary.

### 3.14.3 Environmental Analysis

#### 3.14.3.1 Hazardous Materials Storage and Use

As discussed in Section 3.4, Hazardous Materials Management, and consistent with the current operating conditions at the ESGS, the demolition and removal of Units 3 and 4 and the installation and operation of new Units 9, 10, 11, and 12 will result in minimal changes to the existing aqueous ammonia system as described in Sections 2.3 and 2.8.1. There is a potential for the ESPFM to result in changes in the frequency of aqueous ammonia deliveries; however, system upgrades and changes in operating conditions will not be required. In



addition, as described in Section 2.8.1, a variety of chemicals will be stored and used during construction and operation of the facility. Table 2.8.1-5 lists anticipated chemicals. The storage, handling, and use of these chemicals will be conducted in accordance with all applicable LORS and existing COCs. In addition, the removal of Units 3 and 4 and subsequent discontinuation of the once-through cooling system eliminates the need to store and use chlorine for biological growth control. The elimination of chlorine use will result in less potential impacts on worker health and safety. Therefore, implementation of the ESPFM will result in lower potential impacts to worker health and safety associated with hazardous materials storage and use. Worker safety risks associated with hazardous materials storage and use will continue to be mitigated by conformance with the requirements COC WORKER SAFETY-2.

### **3.14.3.2 Hazardous Wastes Generation and Disposal**

As discussed in Section 3.10, Soil and Water Resources, the removal of Units 3 and 4 and subsequent discontinuation of the once-through cooling and subsequent wastewater discharge requiring wastewater byproduct treatment and disposal lowers the amount of hazardous wastes generated. Wastewater generated from chemical cleaning of the HRSGs, combustion turbines, and compressors will continue to be collected and stored in holding tanks, profiled in accordance with the facility's hazardous waste management program and shipped offsite to a properly permitted facility for treatment and disposal or recycling. Therefore, implementation of the ESPFM will not result in any increase to the existing waste generation and storage and subsequently no increases in potential impacts to worker health and safety that cannot be mitigated by conformance with the requirements included in the Operations and Maintenance Safety and Health Program provided in COC WORKER SAFETY-2.

### **3.14.3.3 Noise**

As discussed in Section 3.7, Noise, consistent with the current operating conditions at the ESGS, the demolition and removal of Units 3 and 4 and the installation and operation of new Units 9, 10, 11, and 12 will not exceed the existing noise generation levels or require additional mitigation to maintain worker safety. The new air-cooled condenser system for ESPFM will be a new source of noise, however, it is anticipated that the operation of Units 9, 10, 11, and 12, will not result in worker exposure to increased noise levels. Worker safety issues associated with noise exposure would be mitigated through conformance with COC NOISE-7 which requires that an occupational noise survey be conducted to identify potential noise hazardous areas and, if necessary, develop additional mitigation measures in consultation with Cal/OSHA to reduce noise levels to prescribed limits.

### **3.14.3.4 Egress, Access and Worker Exposure to Hazards**

The new units subject to this Amendment will occupy a slightly larger footprint than the previously permitted units, but worker access and egress in the production area of the proposed new units is not substantially restricted, as compared with the previous design. A new access road between the power blocks improves worker access as compared with the current power block configuration. The demolition and removal of Units 3 and 4 and the installation and operation of new Units 9, 10, 11, and 12 will result in the net increase of one steam turbine generator. However, this additional component does not substantially increase the risk of worker exposure to an upset event, given the relative similarities in the previously permitted and the proposed generator technology. Worker safety risks will continue to be mitigated by the Operations and Maintenance Safety and Health Program provided for under COC WORKER SAFETY-2.

### **3.14.3.5 Construction**

The location and configuration of the new Units 9, 10, 11, and 12 will require less excavation than the excavation requirements for Units 5 through 8 for which the impacts were addressed in 00-AFC-14. While earthwork may result in worker exposure to contaminated soils, the reduction in the extent and depth of excavation will lower potential worker exposure to contaminated soils and groundwater. Therefore, potential worker safety risks associated with exposure to contaminated soils will continue to be mitigated through the implementation of existing COCs WORKER SAFETY-1 and WASTE-5.

### 3.14.3.6 Fire Protection

The demolition and removal of Units 3 and 4 and the installation and operation of new Units 9, 10, 11, and 12 will be incorporated into the existing dedicated fire protection equipment and systems operated in accordance with National Fire Protection Association (NFPA) standards and existing COCs. Therefore, potential worker safety fire risks continue to be mitigated through the implementation of existing COCs WORKER SAFETY-1 and WORKER SAFETY-2.

### 3.14.3.7 Offsite Laydown and Parking Areas

The preferred offsite laydown area, located at 777 W. 190th Street in the City of Gardena, was incorporated into ESEC in the 2010 PTA decision and will continue to be used for ESPFM. Construction laydown and parking areas will also be established within the ESGS site boundary, as well as at offsite areas identified in the CEC Final Decision and shown on Figure 2-10. The 190th Street area is less than ten miles southeast of the ESGS and is easily accessible to the I-405 and I-110 North freeways from Vermont Avenue and 190th Street as well as to ESEC-approved traffic/truck routes. This site, zoned M2, commercial, has approximately ten usable acres and includes a 5,500 square-foot industrial building. The approximately 12.1-acre site paved with asphalt has nightlighting and includes a perimeter security fence. No site preparation other than minor clean-up is required prior to use. Current site conditions do not pose a safety hazard to workers during parking or equipment staging and storage. During construction, workers will be exposed to hazards typical of equipment staging and heavy-haul transportation operations, including exposure to potential hazards such as slip/trip/fall, lacerations, hazardous materials and hazardous wastes, heavy construction equipment and vehicles, fire, noise, and elevated and overhead work. The potential hazards associated with this new laydown area are not different in type or scope than the hazards associated with previously permitted offsite laydown areas. Existing COC WORKER SAFETY-1 will ensure construction related activities conducted at laydown areas comply with all appropriate safety programs and plans. Therefore, implementation of ESPFM will not change impacts to worker health or safety associated with use of the laydown areas and the existing COCs are adequate to address any potential impacts.

## 3.14.4 Cumulative Impacts

The proposed ESPFM covered under this PTA will not result in any significant cumulative impacts to worker health and safety beyond those addressed in the CEC's Final Decision (00-AFC-14).

## 3.14.5 Laws, Ordinances, Regulations and Standards

The CEC Final Decision found the project to be in compliance with all applicable LORS. As described in this PTA, the proposed ESPFM is consistent with applicable worker safety-related LORS, and the Amendment will not alter the assumptions or conclusions made in the CEC's Final Commission Decision (Final Decision).

## 3.14.6 Conditions of Certification

Existing COCs WORKER SAFETY-1 through WORKER SAFETY-6 are adequate to address ESPFM without being amended. These COCs are provided below.

**WORKER SAFETY-1:** The project owner shall submit to the Compliance Project Manager (CPM) for approval, a copy of the Project Demolition and Construction Safety and Health Program containing the following:

- A Demolition and Construction Safety Program;
- A Demolition and Construction Personal Protective Equipment Program;
- A Demolition and Construction Exposure Monitoring Program;
- A Demolition and Construction Emergency Action Plan; and
- A Demolition and Construction Fire Protection and Prevention Plan.

The Safety Program, the Personal Protective Equipment Program, and the Exposure Monitoring Program shall be submitted to the CPM for review and comment concerning compliance of the program with all applicable Safety Orders. The Demolition and Construction Fire Protection and Prevention Plan and Emergency Action Plan shall be submitted to the City of El Segundo Fire Department for review and comment prior to submittal to the CPM.

The Demolition and Construction Fire Protection and Prevention Plan and Emergency Action Plan shall include the following:

1. Methods to maintain fire access roadways and submittal of a fire access layout plan for review by the El Segundo Fire Department and approval by the CPM.
2. Provision of a suitable replacement for the existing fire suppression water reservoir prior to demolishing the existing reservoir.
3. Provision of fire flow calculations to verify that the available water supply proposed will be adequate for emergency operations.
4. A requirement that all temporary fire mains and hydrants shall be adequately braced and tied-down to anticipate the effects of water hammer and that protection from vehicular impact is provided as necessary.

**Verification:** At least 30 days prior to site mobilization, the project owner shall submit to the CPM for review and approval a copy of the Project Demolition and Construction Safety and Health Program. The project owner shall provide a letter from the City of El Segundo Fire Department stating that they have reviewed and commented on the Demolition and Construction Fire Protection and Prevention Plan and Emergency Action Plan.

**WORKER SAFETY-2:** The project owner shall submit to the CPM for approval a copy of the Project Operations and Maintenance Safety and Health Program containing the following:

- An Operation Injury and Illness Prevention Plan;
- An Emergency Action Plan;
- Hazardous Materials Management Program;
- Operations and Maintenance Safety Program;
- Fire Protection and Prevention Program (8 CCR § 3221); and;
- Personal Protective Equipment Program (8 CCR §§ 3401-3411).

The Operation Injury and Illness Prevention Plan, Emergency Action Plan, and Personal Protective Equipment Program shall be submitted to the Cal/OSHA Consultation Service, for review and comment concerning compliance of the program with all applicable Safety Orders. The Operation Fire Protection Plan and the Emergency Action Plan shall also be submitted to the City of El Segundo Fire Department for review and comment.

The Project Operations Fire Protection and Prevention Plan and Emergency Action Plan shall address:

1. Provision of remote annunciation for all fire alarm and automatic suppression devices and the placement of remote annunciation at the security station on Vista Del Mar.
2. Provision of a complete fire alarm system and automatic fire sprinklers for the new administration building and any new control buildings.
3. A secondary entrance point for Fire Department operations along the northern boundary of the property.

**Verification:** At least 30 days prior to the start of operation, the project owner shall submit to the CPM and the City of El Segundo Fire Department a copy of the Project Operations and Maintenance Safety & Health Program.

~~**WORKER SAFETY-3:** Before using one of the fuel oil storage tanks as a clean soils storage area, the project owner shall ensure that the integrity of the floor has not been compromised by cracks or holes, the tanks have been thoroughly cleaned, no airborne hydrocarbons are present above the method detection level of a hand held PID hydrocarbon vapor detector, and that the earth-moving vehicles used are equipped with environmental cabs.~~

~~**Verification:** At least 30 days prior to the start of using the tanks as a storage area, the project owner shall submit to the CPM a report verifying the integrity of the floor, describing the results of the PID monitoring, and a statement that all earth-moving vehicles used are equipped with properly functioning environmental cabs.~~

**WORKER SAFETY-4** The project owner shall provide a site Construction Safety Supervisor (CSS) who, by way of training and/or experience, is knowledgeable of power plant construction activities and relevant laws, ordinances,

regulations, and standards, is capable of identifying workplace hazards relating to the construction activities, and has authority to take appropriate action to assure compliance and mitigate hazards. The CSS shall:

- Have over-all authority for coordination and implementation of all occupational safety and health practices, policies, and programs;
- Assure that the safety program for the project complies with Cal/OSHA & federal regulations related to power plant projects;
- Assure that all construction and commissioning workers and supervisors receive adequate safety training;
- Complete accident and safety-related incident investigations, emergency response reports for injuries, and inform the CPM of safety-related incidents; and
- Assure that all the plans identified in Worker Safety-1 and-2 are implemented.

**Verification:** At least thirty (30) days prior to the start of project mobilization, the project owner shall submit to the CPM the name and contact information for the Construction Safety Supervisor (CSS). The contact information of any replacement (CSS) shall be submitted to the CPM within one business day.

The CSS shall submit in the Monthly Compliance Report a monthly safety inspection report to include:

- Record of all employees trained for that month (all records shall be kept on site for the duration of the project);
- Summary report of safety management actions and safety-related incidents that occurred during the month;
- Report of any continuing or unresolved situations and incidents that may pose danger to life or health; and
- Report of accidents and injuries that occurred during the month.

**WORKER SAFETY-5** The project owner shall make payments to the Chief Building Official (CBO) for the services of a Safety Monitor based upon a reasonable fee schedule to be negotiated between the project owner and the CBO. Those services shall be in addition to other work performed by the CBO. The Safety Monitor shall be selected by and report directly to the CBO, and will be responsible for verifying that the Construction Safety Supervisor, as required in Worker Safety-4, implements all appropriate Cal/OSHA and Commission safety requirements. The Safety Monitor shall conduct on-site (including linear facilities) safety inspections at intervals necessary to fulfill those responsibilities.

**Verification:** Prior to the start of construction, the project owner shall provide proof of its agreement to fund the Safety Monitor services to the CPM for review and approval.

**WORKER SAFETY-6** The project owner shall ensure that a portable automatic cardiac defibrillator (also known as an automatic external defibrillator or AED) is located on site during construction and operations and shall implement a program to ensure that workers are properly trained in its use and that the equipment is properly maintained and functioning at all times. During construction and commissioning, the following persons shall be trained in its use and shall be on-site whenever the workers that they supervise are on-site: the Construction Project Manager or delegate, the Construction Safety Supervisor or delegate, and all shift foremen. During operations, all power plant employees shall be trained in its use. The training program shall be submitted to the CPM for review and approval.

**Verification:** At least thirty (30) days prior to the start of construction mobilization, the project owner shall submit to the CPM proof that a portable automatic cardiac defibrillator exists on site and a copy of the training and maintenance program for review and approval.



## SECTION 4.0

# Potential Effects on the Public

---

Consistent with the requirements of the CEC Siting Regulations Section 1769 (a)(1)(G), this section addresses the proposed Amendment's effects on the public.

Impacts to the public are anticipated to be similar or less than those analyzed during the previous license proceeding for the ESEC demolition of Units 1 and 2 and the construction and operation of Units 5 through 8. Implementation of the ESPFM will eliminate once-through cooling from ESGS and will eliminate ESGS's ocean discharge of industrial and sanitary wastewater reducing the amount of wastes to be discharged into the environment.



SECTION 5.0

# List of Property Owners

---

Consistent with the CEC Siting Regulations Section 1769(a)(1)(H), this section lists the property owners affected by the proposed modifications.





TABLE 5-1  
**Property Owners within 1,000 Feet of the Project**

| APN          | OWNER                                    | Address                     | City            | State | Zip   |
|--------------|--|-----------------------------|-----------------|-------|-------|
| 4138-029-004 | EL SEGUNDO POWER LLC                     | 211 CARNEGIE CTR            | PRINCETON       | NJ    | 8540  |
| 4138-029-800 | SO CALIF EDISON CO                       | 2244 WALNUT GROVE AVE #270  | ROSEMEAD        | CA    | 91770 |
| 4138-029-802 | EL SEGUNDO POWER LLC SBE 1110-19-1 PAR 1 | PO BOX 4777                 | HOUSTON         | TX    | 77210 |
| 4138-029-803 | EL SEGUNDO POWER LLC SBE 1110-19-1 PAR 2 | PO BOX 4777                 | HOUSTON         | TX    | 77210 |
| 4137-003-012 | SCOTT A FREGO                            | 318 GULL ST                 | MANHATTAN BEACH | CA    | 90266 |
| 4137-003-013 | 4116 HIGHLAND AVENUE LLC                 | 1001 6 <sup>TH</sup> ST 150 | MANHATTAN BEACH | CA    | 90266 |
| 4137-003-014 | 4117 CREST LLC                           | 2307 JOHN ST                | MANHATTAN BEACH | CA    | 90266 |
| 4137-003-015 | LORA LAVERTY                             | 26 E DIVISION ST            | CHICAGO         | IL    | 60610 |
| 4137-003-016 | LINDSAY L DENARDO                        | 317 MOONSTONE ST            | MANHATTAN BEACH | CA    | 90266 |
| 4137-003-017 | FRANKLIN J JAVIER                        | 4100 HIGHLAND AVE           | MANHATTAN BCH   | CA    | 90266 |
| 4137-003-018 | ROBERTA A & JOHN A BROWN                 | 4108 HIGHLAND AVE           | MANHATTAN BEACH | CA    | 90266 |
| 4137-003-019 | JENKINS ROBERT T CO TR                   | 471 CROCKER RD              | SACRAMENTO      | CA    | 95864 |
| 4137-003-020 | JACQUELINE BARTON                        | 6200 WILSHIRE BLVD #805     | LOS ANGELES     | CA    | 90048 |
| 4137-003-024 | GRADY T MONTS                            | 120 39TH ST                 | MANHATTAN BCH   | CA    | 90266 |
| 4137-003-025 | STOCK WILLIAM H CO TR                    | 4209 CREST DR               | MANHATTAN BEACH | CA    | 90266 |
| 4137-003-026 | JOSEPH T CLEES                           | 5740 N ECHO CANYON CIR      | PHOENIX         | AZ    | 85018 |
| 4137-003-027 | WILLIAM & ANGELA BARRICK                 | P.O. BOX 2762               | EL SEGUNDO      | CA    | 90245 |
| 4137-003-028 | HAE S YOUNG                              | P.O. BOX 3014               | REDONDO BEACH   | CA    | 90277 |
| 4137-003-029 | ALAN MEERSAND                            | 129 4TH ST                  | MANHATTAN BEACH | CA    | 90266 |
| 4137-004-005 | PETER H MEYERS                           | 225 17TH ST                 | MANHATTAN BEACH | CA    | 90266 |
| 4137-004-006 | PETER H MEYERS                           | 225 17TH ST                 | MANHATTAN BEACH | CA    | 90266 |
| 4137-004-007 | WANDA L ATKENSON                         | 4308 CREST DR               | MANHATTAN BEACH | CA    | 90266 |
| 4137-004-011 | HARRIS RICHARD G CO TR                   | 8235 BILLOWVISTA DR         | PLAYA DEL REY   | CA    | 90293 |
| 4137-004-012 | MARY N FERRERO                           | P.O. BOX 1283               | SOUTH PASADENA  | CA    | 91031 |

TABLE 5-1  
**Property Owners within 1,000 Feet of the Project**

| APN          | OWNER                          | Address                | City            | State | Zip   |
|--------------|--------------------------------|------------------------|-----------------|-------|-------|
| 4137-004-013 | SEAN E RYAN                    | 4416 HIGHLAND AVE      | MANHATTAN BEACH | CA    | 90266 |
| 4137-004-014 | MARGO OCHS                     | 4408 HIGHLAND AVE      | MANHATTAN BEACH | CA    | 90266 |
| 4137-004-018 | RYAN STEWART                   | 4407 CREST DR          | MANHATTAN BEACH | CA    | 90266 |
| 4137-004-019 | LUIS E TEJADA                  | 4401 CREST DRA         | MANHATTAN BEACH | CA    | 90266 |
| 4137-004-021 | JUDITH M SCHERPENBERG          | 318 45TH ST            | MANHATTAN BEACH | CA    | 90266 |
| 4137-004-022 | ANDREW C PHELPS                | 317 GULL ST            | MANHATTAN BEACH | CA    | 90266 |
| 4137-004-024 | NATHAN R & CHRISTINA S SCHMIDT | 309 GULL ST            | MANHATTAN BEACH | CA    | 90266 |
| 4137-004-025 | SAND SECTION PROPERTIES LLC    | 120 36TH ST            | MANHATTAN BEACH | CA    | 90266 |
| 4137-004-026 | JOHN M TURNER                  | 307 44TH STREET        | MANHATTAN BEACH | CA    | 90266 |
| 4137-004-027 | LINN STEPHEN CO TR             | 2616 N POINSETTIA AVE  | MANHATTAN BEACH | CA    | 90266 |
| 4137-004-038 | SHERRON L SYLVESTER            | 661 35TH ST            | MANHATTAN BCH   | CA    | 90266 |
| 4137-004-039 | RYAN STEWART                   | 4407 CREST DR          | MANHATTAN BEACH | CA    | 90266 |
| 4137-004-043 | VERONICA B CUSHMA              | P.O. BOX 2773          | LA JOLLA        | CA    | 92038 |
| 4137-004-044 | PATRIC J & JENNIFER MACHA      | 25906 PORTAFINO DR     | MISSION VIEJO   | CA    | 92691 |
| 4137-004-045 | JAN M MCDONALD TOMLINSON       | 4216 HIGHLAND AVE #C   | MANHATTAN BEACH | CA    | 90266 |
| 4137-004-046 | CHARLES W RALSTON              | 4216 HIGHLAND AVE #D   | MANHATTAN BEACH | CA    | 90266 |
| 4137-004-047 | RENEE M CROCE                  | 4216 HIGHLAND AVE #E   | MANHATTAN BCH   | CA    | 90266 |
| 4137-004-048 | ROBERT A & ELENA J CECCONI     | 4217 HIGHLAND AVE #F   | MANHATTAN BCH   | CA    | 90266 |
| 4137-004-049 | PETER CHAMBLISS                | 4216 HIGHLAND AVE #G   | MANHATTAN BEACH | CA    | 90266 |
| 4137-004-050 | RICHARD W WINZELER             | 4216 HIGHLAND AVE #H   | MANHATTAN BEACH | CA    | 90266 |
| 4137-004-051 | ROBERTO C MEDRANO              | P.O. BOX 487           | MANHATTAN BEACH | CA    | 90267 |
| 4137-004-052 | DAVIS JEFFREY A CO TR          | 820 MANHATTAN AVE #205 | MANHATTAN BCH   | CA    | 90266 |
| 4137-004-053 | ADAM J FEELEY                  | 477 ZUNI DR            | DEL MAR         | CA    | 92014 |
| 4137-004-054 | JERALD D COLMERY               | 4307 CREST DR          | MANHATTAN BEACH | CA    | 90266 |

TABLE 5-1  
Property Owners within 1,000 Feet of the Project

| APN          | OWNER                            | Address           | City            | State | Zip   |
|--------------|----------------------------------|-------------------|-----------------|-------|-------|
| 4137-004-056 | RICHARD G NICKELSON              | 4421 CREST DR     | MANHATTAN BCH   | CA    | 90266 |
| 4137-004-057 | JEFFREY M & MOMOKO N BUTTERWORTH | 4419 CREST DR     | MANHATTAN BEACH | CA    | 90266 |
| 4137-004-059 | MILLENNIUM RECORDS INC           | P.O. BOX 80533    | SAN MARINO      | CA    | 91118 |
| 4137-004-060 | STEVEN MARIN                     | 316 45TH ST       | MANHATTAN BEACH | CA    | 90266 |
| 4137-004-065 | SCOTT A FREGO                    | 318 GULL ST       | MANHATTAN BEACH | CA    | 90266 |
| 4137-004-066 | ALEN TERNIAN                     | 308 GULL ST       | MANHATTAN BEACH | CA    | 90266 |
| 4137-004-067 | ANDREW & KRISTIN LELCHUK         | 4321 CREST DR     | MANHATTAN BEACH | CA    | 90266 |
| 4137-004-068 | LEONARDO N RODRIGUEZ             | 4323 CREST DR     | MANHATTAN BEACH | CA    | 90266 |
| 4137-004-069 | SUN MOON KIM                     | 4320 HIGHLAND AVE | MANHATTAN BEACH | CA    | 90266 |
| 4137-004-070 | SHELLY & JAIME S SCHWARTZ        | 312 44TH ST       | MANHATTAN BEACH | CA    | 90266 |
| 4137-004-071 | ARTHUR J COHEN                   | 316 44TH ST       | MANHATTAN BEACH | CA    | 90266 |
| 4137-005-008 | HANY & MARY H BEKHIT             | 4419 HIGHLAND AVE | MANHATTAN BEACH | CA    | 90266 |
| 4137-005-009 | CYNTHIA ZACKO                    | 223 GULL ST       | MANHATTAN BEACH | CA    | 90266 |
| 4137-005-010 | CLAY & LEE M CLAUDINO            | P.O. BOX 3457     | MANHATTAN BEACH | CA    | 90266 |
| 4137-005-011 | JAMES A & MARIA T SNYDER         | 1001 6TH ST #150  | MANHATTAN BEACH | CA    | 90266 |
| 4137-005-012 | JARYL W CRAMTON                  | 3801 E HIGHWAY 66 | KINGMAN         | AZ    | 86401 |
| 4137-005-013 | ROSSO JOHN A CO TR               | 7509 W 89TH ST    | LOS ANGELES     | CA    | 90045 |
| 4137-005-014 | NINETY MPH LLC                   | 404 MANHATTAN AVE | MANHATTAN BEACH | CA    | 90266 |
| 4137-005-015 | JOSEPH H CHRISMAN                | 209 GULL ST       | MANHATTAN BEACH | CA    | 90266 |
| 4137-005-016 | ESTEBAN R MURILLO                | 228 38TH PL       | MANHATTAN BEACH | CA    | 90266 |
| 4137-005-017 | ESTEBAN R MURILLO                | 228 38TH PL       | MANHATTAN BEACH | CA    | 90266 |
| 4137-005-018 | PAMELYN SPRIGGS                  | 200 45TH ST       | MANHATTAN BEACH | CA    | 90266 |
| 4137-005-019 | AMIR E ETTKAL                    | 203 GULL ST       | MANHATTAN BEACH | CA    | 90266 |
| 4137-005-020 | CHRISTINE NAYLOR                 | P.O. BOX 2308     | MANHATTAN BCH   | CA    | 90267 |

TABLE 5-1  
**Property Owners within 1,000 Feet of the Project**

| APN          | OWNER                        | Address              | City            | State | Zip   |
|--------------|------------------------------|----------------------|-----------------|-------|-------|
| 4137-005-021 | EDWARD A GAVALDON            | 2512 PINE AVE        | MANHATTAN BCH   | CA    | 90266 |
| 4137-005-023 | KIKI WAXMAN                  | 120 45TH ST          | MANHATTAN BEACH | CA    | 90266 |
| 4137-005-024 | LARRY E & THERESA L HART     | 4852 AGNES AVE       | VALLEY VILLAGE  | CA    | 91607 |
| 4137-005-025 | JOHN A CASASANTE             | 1613 CHELSEA RD #331 | SAN MARINO      | CA    | 91108 |
| 4137-005-026 | JULIE A MANASFI              | 4202 BEEMAN AVE      | STUDIO CITY     | CA    | 91604 |
| 4137-005-027 | BARRY S & CHRISTINA H ROSS   | 4414 OCEAN DR        | MANHATTAN BEACH | CA    | 90266 |
| 4137-005-028 | ROBERT E PERKINS             | 4420 THE STRAND      | MANHATTAN BEACH | CA    | 90266 |
| 4137-005-029 | LYLE L & ELSIE R CRIPE       | 4421 OCEAN DR        | MANHATTAN BEACH | CA    | 90266 |
| 4137-005-030 | METROPOLITAN INVESTMENTS LLC | P.O. BOX 90855       | LOS ANGELES     | CA    | 90009 |
| 4137-005-031 | WAGNER BEACH PROPERTIES LLC  | 1015 S SCOFILLE      | OAK PARK        | IL    | 60304 |
| 4137-005-032 | GREGORY J & ELLEN J HUILL    | P.O. BOX 1327        | MANHATTAN BCH   | CA    | 90266 |
| 4137-005-034 | SILKE MALONEY                | 525 ALMER RD #307    | BURLINGAME      | CA    | 94010 |
| 4137-005-035 | JOHN R MULLEN                | 4403 OCEAN DR        | MANHATTAN BCH   | CA    | 90266 |
| 4137-005-036 | WAGNER BEACH PROPERTIES LLC  | 1015 S SCOFILLE      | OAK PARK        | IL    | 60304 |
| 4137-005-037 | 4400 OCEAN PROPERTIES LLC    | 1915 JAMESTOWN RD    | MORGANTON       | NC    | 28655 |
| 4137-005-038 | JEFF FREDERICK               | 116 GULL ST          | MANHATTAN BEACH | CA    | 90266 |
| 4137-005-039 | STEPHEN & ALLYSON GOLDSBY    | 121 44TH ST          | MANHATTAN BEACH | CA    | 90266 |
| 4137-005-040 | KATHLEEN G SMITH             | 121 10TH ST          | MANHATTAN BCH   | CA    | 90266 |
| 4137-005-041 | CHAN K OH                    | 2824 W PICO BLVD     | LOS ANGELES     | CA    | 90006 |
| 4137-005-042 | KYLE D WEINSHEIM             | 124 GULL ST          | MANHATTAN BEACH | CA    | 90266 |
| 4137-005-043 | MARY J MCCONNELL             | 129 44TH ST          | MANHATTAN BEACH | CA    | 90266 |
| 4137-005-044 | EMMETT E MILLER              | 212 38TH ST          | MANHATTAN BEACH | CA    | 90266 |
| 4137-005-045 | WILLIAM H & NANCY C KELLER   | 131 44TH ST          | MANHATTAN BEACH | CA    | 90266 |
| 4137-005-046 | CORT D ESCHERICH             | 200 GULL ST          | MANHATTAN BEACH | CA    | 90266 |

TABLE 5-1  
**Property Owners within 1,000 Feet of the Project**

| APN          | OWNER                       | Address                      | City              | State | Zip   |
|--------------|-----------------------------|------------------------------|-------------------|-------|-------|
| 4137-005-047 | SCOTT E & ALICE SADOWSKI    | 201 44TH ST                  | MANHATTAN BEACH   | CA    | 90266 |
| 4137-005-048 | PAUL T & MAMIE MANCE        | 6978 CREST RD                | RANCHO PALOS VERD | CA    | 90275 |
| 4137-005-049 | WALTER R ARMSTRONG          | 733 36TH ST                  | MANHATTAN BCH     | CA    | 90266 |
| 4137-005-050 | JAMES A LOWRY               | 213 44TH ST                  | MANHATTAN BEACH   | CA    | 90266 |
| 4137-005-051 | CHARLES J LOWRY             | 13200 PACIFIC PROMENADE #402 | PLAYA VISTA       | CA    | 90094 |
| 4137-005-052 | DANA M KENIRY               | 426 31ST ST                  | HERMOSA BEACH     | CA    | 90254 |
| 4137-005-053 | PERRY L HERWOOD             | P.O. BOX 3280                | MANHATTAN BEACH   | CA    | 90266 |
| 4137-005-054 | VICTOR G & MURIEL S SAVIKAS | 3009 BAYVIEW DR              | MANHATTAN BCH     | CA    | 90266 |
| 4137-005-055 | ANTON MILLA                 | 20600 MAIN ST SP84           | CARSON            | CA    | 90745 |
| 4137-005-056 | JOHN H & ROBBIE G ATKINSON  | 461 34TH ST                  | MANHATTAN BCH     | CA    | 90266 |
| 4137-005-057 | RALPH C TISDALE             | 604 27TH ST                  | MANHATTAN BEACH   | CA    | 90266 |
| 4137-005-058 | RALPH C TISDALE             | P.O. BOX 246                 | MANHATTAN BCH     | CA    | 90266 |
| 4137-005-060 | ANDREW L ELLIS              | 4404 THE STRAND              | MANHATTAN BEACH   | CA    | 90266 |
| 4137-005-061 | CHASE L & MARIA M LEAVITT   | 4712 ADMIRALTY WAY 561       | MARINA DEL REY    | CA    | 90292 |
| 4137-006-009 | SHERI A HUNT                | 226 44TH ST                  | MANHATTAN BEACH   | CA    | 90266 |
| 4137-006-010 | WAGNER BEACH PROPERTIES LLC | 1015 S SCOFILLE              | OAK PARK          | IL    | 60304 |
| 4137-006-011 | PERRY L HERWOOD             | P.O. BOX 3280                | MANHATTAN BEACH   | CA    | 90266 |
| 4137-006-012 | BRIAN & JOAN COCHRAN        | 36 MALAGA COVE PLZ           | PALOS VERDES ESTA | CA    | 90274 |
| 4137-006-013 | PERRY L HERWOOD             | P.O. BOX 3280                | MANHATTAN BEACH   | CA    | 90266 |
| 4137-006-014 | DANIEL M BROWN              | 3121 ALMA AVE                | MANHATTAN BEACH   | CA    | 90266 |
| 4137-006-015 | JEANETTE FERRERA            | 1706 BELMONT LN              | REDONDO BEACH     | CA    | 90278 |
| 4137-006-016 | PHILIP SOULE                | P.O. BOX 1626                | MANHATTAN BEACH   | CA    | 90267 |
| 4137-006-017 | BIG SKY HOLDINGS LLC        | 21515 HAWTHORNE BLVD 1250    | TORRANCE          | CA    | 90503 |
| 4137-006-018 | ZORAN & HELENE SAJOVIC      | 2105 W ST MARY BLVD          | LAFAYETTE         | LA    | 70506 |

TABLE 5-1  
**Property Owners within 1,000 Feet of the Project**

| APN          | OWNER                       | Address             | City            | State | Zip   |
|--------------|-----------------------------|---------------------|-----------------|-------|-------|
| 4137-006-019 | PERRY L HERWOOD             | P.O. BOX 3280       | MANHATTAN BEACH | CA    | 90266 |
| 4137-006-020 | PERRY L HERWOOD             | P.O. BOX 3280       | MANHATTAN BEACH | CA    | 90266 |
| 4137-006-021 | SANDRA L LEWIS              | 202 44TH ST         | MANHATTAN BCH   | CA    | 90266 |
| 4137-006-022 | MATTHEW A & MAUREEN A SIMON | 201 SHELL ST        | MANHATTAN BEACH | CA    | 90266 |
| 4137-006-023 | ANNE M MILLER               | 130 44TH ST         | MANHATTAN BEACH | CA    | 90266 |
| 4137-006-024 | DAVID S KARPMAN             | 127 SHELL ST        | MANHATTAN BEACH | CA    | 90266 |
| 4137-006-025 | JOHN E MYLREA               | 3621 ALMA AVE       | MANHATTAN BEACH | CA    | 90266 |
| 4137-006-026 | JOSEPH B & MELODY D BARNES  | P.O. BOX 2241       | MANHATTAN BEACH | CA    | 90267 |
| 4137-006-027 | MICHAEL KATZ                | 1726 WESTRIDGE RD   | LOS ANGELES     | CA    | 90049 |
| 4137-006-028 | P C ZAMANIGAN               | 121 SHELL ST        | MANHATTAN BEACH | CA    | 90266 |
| 4137-006-030 | ROSS & STEPHANIE S MITCHELL | 1412 FAYMONT AVE    | MANHATTAN BEACH | CA    | 90266 |
| 4137-006-031 | DOUGLAS L CROISSETTE        | 112 44TH ST         | MANHATTAN BEACH | CA    | 90266 |
| 4137-006-032 | DEBRA A BARNES              | 4321 OCEAN DR       | MANHATTAN BEACH | CA    | 90266 |
| 4137-006-033 | MICHAEL DOLEN               | 2030 IVAR AVE #106  | LOS ANGELES     | CA    | 90068 |
| 4137-006-034 | SINV STRAND LLC             | 23223 NORMANDIE AVE | TORRANCE        | CA    | 90501 |
| 4137-006-036 | PETER W BOONE               | 4308 THE STRAND     | MANHATTAN BEACH | CA    | 90266 |
| 4137-006-037 | HENRY V ALVAREZ             | 4304 THE STRAND     | MANHATTAN BEACH | CA    | 90266 |
| 4137-006-039 | WILLIAM W POWELL            | 4310 OCEAN DR       | MANHATTAN BEACH | CA    | 90266 |
| 4137-006-040 | C HAROLD KEASLER            | 3500 ALMA AVE       | MANHATTAN BCH   | CA    | 90266 |
| 4137-006-041 | SUSAN L HARRIS              | 121 43RD ST         | MANHATTAN BEACH | CA    | 90266 |
| 4137-006-042 | DAVID H BATE                | 112 SHELL ST        | MANHATTAN BEACH | CA    | 90266 |
| 4137-006-043 | ELENA BLOMGREN              | 120 SHELL ST        | MANHATTAN BEACH | CA    | 90266 |
| 4137-006-044 | SAM LIGHTBOURN              | 123 43RD ST         | MANHATTAN BEACH | CA    | 90266 |
| 4137-006-045 | DEBRA A SUARD               | 124 SHELL ST        | MANHATTAN BEACH | CA    | 90266 |

TABLE 5-1  
Property Owners within 1,000 Feet of the Project

| APN          | OWNER                      | Address               | City              | State | Zip   |
|--------------|----------------------------|-----------------------|-------------------|-------|-------|
| 4137-006-046 | SAM LIGHTBOURN             | 123 43RD ST           | MANHATTAN BEACH   | CA    | 90266 |
| 4137-006-047 | MICHAEL R STEARNS          | 128 SHELL ST          | MANHATTAN BEACH   | CA    | 90266 |
| 4137-006-049 | ELIX CORPORATION JAPAN     | 200 SHELL ST          | MANHATTAN BEACH   | CA    | 90266 |
| 4137-006-050 | ADAH DUNCAN                | 2820 THE STRAND       | MANHATTAN BEACH   | CA    | 90266 |
| 4137-006-051 | DUKE & SUSAN JONES         | 26329 MONTE VISTA AVE | LOMITA            | CA    | 90717 |
| 4137-006-052 | PATRICIA BALDIVIA          | 209 43RD ST           | MANHATTAN BEACH   | CA    | 90266 |
| 4137-006-053 | JOHN M & JAN M WEEKLEY     | 2440 CHELSEA RD       | PALOS VERDES ESTA | CA    | 90274 |
| 4137-006-054 | JOHNATHAN BIRNBAUM         | 211 43RD ST           | MANHATTAN BEACH   | CA    | 90266 |
| 4137-006-055 | DAMON GUIZOT               | 6412 VIA CANADA       | RCH PALOS VRD     | CA    | 90275 |
| 4137-006-056 | LOUIS J & ROBERTA D COMBS  | 2243 SILVERSTAR ST    | SIMI VALLEY       | CA    | 93065 |
| 4137-006-057 | GARY M & STEVIE FLEISHMAN  | 7510 W 85TH ST        | PLAYA DEL REY     | CA    | 90293 |
| 4137-006-058 | ARTHUR TAN                 | 223 43RD ST           | MANHATTAN BEACH   | CA    | 90266 |
| 4137-006-059 | BREN CONNER                | 7417 DUNFIELD AVE     | LOS ANGELES       | CA    | 90045 |
| 4137-006-060 | MICHAEL B & MARIAN A DAVIS | 227 43RD ST           | MANHATTAN BEACH   | CA    | 90266 |
| 4137-006-061 | ROBERT PULASKI             | 9645 SPYGLASS AVE #81 | DSRT HOT SPGS     | CA    | 92240 |
| 4137-006-062 | BRUCE H & BRENDA GREENBERG | P.O. BOX 3465         | MANHATTAN BEACH   | CA    | 90266 |
| 4137-006-063 | SEAN NEEL                  | 226 SHELL ST          | MANHATTAN BEACH   | CA    | 90266 |
| 4137-006-064 | DAVID G & HELEN J PAPKE    | P.O. BOX 449          | PHILO             | CA    | 95466 |
| 4137-006-065 | PAUL J & KAY B LUPO        | 700 TORRANCE BLVD     | REDONDO BEACH     | CA    | 90277 |
| 4137-006-069 | JOAN & PETER TANSAVATDI    | 4303 THE STRAND       | MANHATTAN BEACH   | CA    | 90266 |
| 4137-006-070 | GLENN E CUNNINGHAM         | 5310 PALI POINT LN    | LA CANADA         | CA    | 91011 |
| 4137-006-071 | JAMES W SAVELA             | 4300 THE STRAND       | MANHATTAN BEACH   | CA    | 90266 |
| 4137-006-072 | MARK M GALLON              | 4301 THE STRAND       | MANHATTAN BCH     | CA    | 90266 |
| 4137-006-073 | DONALD P JENNINGS          | P.O. BOX 625          | MANHATTAN BEACH   | CA    | 90267 |



TABLE 5-1  
**Property Owners within 1,000 Feet of the Project**

| APN          | OWNER                     | Address                  | City              | State | Zip   |
|--------------|---------------------------|--------------------------|-------------------|-------|-------|
| 4137-006-075 | WILLIAM N MORAN           | 229 SHELL ST #1          | MANHATTAN BCH     | CA    | 90266 |
| 4137-006-076 | WILLIAM MORAN             | 229 SHELL ST #2          | MANHATTAN BCH     | CA    | 90266 |
| 4137-006-077 | LEE S KOSBY               | 117 SHELL ST             | MANHATTAN BEACH   | CA    | 90266 |
| 4137-006-078 | JOHN F WHITLOCK           | 3000 HIGHLAND AVE        | MANHATTAN BCH     | CA    | 90266 |
| 4137-006-080 | DEEPAK & NANDINI CHOPRA   | 717 VIA LA CUESTA        | PALOS VERDES ESTA | CA    | 90274 |
| 4137-006-081 | DOMINIE & MARY E WHITE    | P.O. BOX 582510          | TULSA             | OK    | 74158 |
| 4137-006-082 | MARCIAL D SUAREZ          | 902 S DUNSMUIR AVE       | LOS ANGELES       | CA    | 90036 |
| 4137-006-083 | ROBERT W FRASER           | 201 43RD ST              | MANHATTAN BEACH   | CA    | 90266 |
| 4137-007-009 | WALTER ZURBRUGG           | P.O. BOX 91322           | LOS ANGELES       | CA    | 90009 |
| 4137-007-010 | DONALD & MARY L UHLE      | 232 43RD ST              | MANHATTAN BEACH   | CA    | 90266 |
| 4137-007-012 | BENJAMIN M GTUSHALL       | P.O. BOX 1180            | MANHATTAN BEACH   | CA    | 90267 |
| 4137-007-014 | JORDAN CRESSMAN           | 217 SEAVIEW ST           | MANHATTAN BEACH   | CA    | 90266 |
| 4137-007-015 | GLENN I SAITO             | 216 43RD ST              | MANHATTAN BEACH   | CA    | 90266 |
| 4137-007-016 | LAURA M WENGLIKOWSKI      | 213 SEAVIEW ST           | MANHATTAN BCH     | CA    | 90266 |
| 4137-007-017 | JOHNS MICHAEL G CO TR     | 3655 MCANANY WAY         | MALIBU            | CA    | 90265 |
| 4137-007-018 | ROBERT FURBER             | 208 43RD ST              | MANHATTAN BEACH   | CA    | 90266 |
| 4137-007-019 | STASYS J & JAN A JASAITIS | 204 43RD ST              | MANHATTAN BCH     | CA    | 90266 |
| 4137-007-020 | STASYS & JAN JASAITIS     | 204 43RD ST              | MANHATTAN BEACH   | CA    | 90266 |
| 4137-007-021 | JON S MELNYK              | 6627 GRULLA ST           | CARLSBAD          | CA    | 92009 |
| 4137-007-022 | SCOTT E ADAMSON           | 12021 WILSHIRE BLVD #292 | LOS ANGELES       | CA    | 90025 |
| 4137-007-023 | SCHEIDIG THOMAS CO TR     | 122 43RD ST              | MANHATTAN BEACH   | CA    | 90266 |
| 4137-007-024 | TAMMY J EVANS             | 56 VIA AMANTI            | NEWPORT COAST     | CA    | 92657 |
| 4137-007-028 | FRIEDMAN BRADLEY J CO TR  | 4216 THE STRAND          | MANHATTAN BEACH   | CA    | 90266 |
| 4137-007-030 | JOHN & AURORA DUGAN       | 126 NEPTUNE AVE          | HERMOSA BEACH     | CA    | 90254 |

TABLE 5-1  
**Property Owners within 1,000 Feet of the Project**

| APN          | OWNER                         | Address                       | City              | State | Zip   |
|--------------|-------------------------------|-------------------------------|-------------------|-------|-------|
| 4137-007-031 | SPATES RICHARD M CO TR        | 2532 VIA RIVERA               | PALOS VERDES ESTA | CA    | 90274 |
| 4137-007-032 | JOSEPH W DUKE                 | 4200 THE STRAND               | MANHATTAN BEACH   | CA    | 90266 |
| 4137-007-033 | FREDERICK A & KAREN R LORIG   | 1 SPUR LN                     | ROLLING HILLS     | CA    | 90274 |
| 4137-007-034 | DANA F WEINSTEIN              | 13460 GRANITE CREEK RD        | SAN DIEGO         | CA    | 92128 |
| 4137-007-035 | BRUCE H & JANE C LETVIN       | P.O. BOX 1064                 | MANHATTAN BEACH   | CA    | 90267 |
| 4137-007-036 | RICHARD E FARMER              | 116 SEAVIEW ST                | MANHATTAN BEACH   | CA    | 90266 |
| 4137-007-037 | DANIEL M & KELLY O WICKEMEYER | 117 42ND ST                   | MANHATTAN BEACH   | CA    | 90266 |
| 4137-007-038 | JEFFREY R TROTT               | 1888 CENTURY PARK E #900      | LOS ANGELES       | CA    | 90067 |
| 4137-007-039 | ROBERTA M AGE                 | 126 SEAVIEW ST                | MANHATTAN BEACH   | CA    | 90266 |
| 4137-007-040 | PAUL AND PILAR LLC            | 18881 VON KARMAN AVE #1175    | IRVINE            | CA    | 92612 |
| 4137-007-041 | JAI WOOK PARK                 | 130 SEAVIEW ST                | MANHATTAN BEACH   | CA    | 90266 |
| 4137-007-042 | JANET R & ROBERT H LONDON     | 129 42ND ST                   | MANHATTAN BEACH   | CA    | 90266 |
| 4137-007-043 | JAMES & ASHLEY SAVELA         | 4300 THE STRAND               | MANHATTAN BEACH   | CA    | 90266 |
| 4137-007-044 | MARY K DONAHOE                | 201 42ND ST                   | MANHATTAN BEACH   | CA    | 90266 |
| 4137-007-045 | HUNG T NGUYEN                 | 725 SIERRA ST                 | EL SEGUNDO        | CA    | 90245 |
| 4137-007-046 | STEPHEN F LORE                | 1543 ROSCOMARE RD             | LOS ANGELES       | CA    | 90077 |
| 4137-007-047 | KIRK W & JANETTE C BROWN      | 361 MAIN ST                   | EL SEGUNDO        | CA    | 90245 |
| 4137-007-048 | ANDREW ROTH                   | 10122 EMPYREAN WAY #101       | LOS ANGELES       | CA    | 90067 |
| 4137-007-049 | STEVEN D GILMOUR              | 300 W GLENOAKS BLVD #301      | GLENDALE          | CA    | 91202 |
| 4137-007-050 | JOSEPH R RADISICH             | 215 42ND ST                   | MANHATTAN BEACH   | CA    | 90266 |
| 4137-007-051 | MICHAEL J & MELINDA SAGGIANI  | 216 SEAVIEW ST                | MANHATTAN BEACH   | CA    | 90266 |
| 4137-007-052 | LYNDAMARIE TR                 | 5016 N PARKWAY CALABASAS #200 | CALABASAS         | CA    | 91302 |
| 4137-007-053 | CRAIG J MCMANIS               | 220 SEAVIEW ST                | MANHATTAN BEACH   | CA    | 90266 |
| 4137-007-054 | CHARLES & MARILYN MILAM       | 129 18TH ST                   | MANHATTAN BCH     | CA    | 90266 |

TABLE 5-1  
**Property Owners within 1,000 Feet of the Project**

| APN          | OWNER                       | Address             | City            | State | Zip   |
|--------------|-----------------------------|---------------------|-----------------|-------|-------|
| 4137-007-055 | KIRSTIE BARRETT             | 224 SEAVIEW ST      | MANHATTAN BEACH | CA    | 90266 |
| 4137-007-056 | JAMES WADE                  | 515 N PAULINA AVE   | REDONDO BEACH   | CA    | 90277 |
| 4137-007-057 | MYRON & ANNE KLAFTER        | 601 36TH ST         | MANHATTAN BCH   | CA    | 90266 |
| 4137-007-058 | XIVA LI                     | 135 RICHMOND ST     | EL SEGUNDO      | CA    | 90245 |
| 4137-007-059 | JARYL W CRAMTON             | 3801 E HIGHWAY 66   | KINGMAN         | AZ    | 86401 |
| 4137-007-060 | ANNE M KNOTT                | 319 BAYVIEW DR      | MANHATTAN BEACH | CA    | 90266 |
| 4137-007-063 | BARRY R TIETLER             | 1215 HIGHLAND AVE   | MANHATTAN BCH   | CA    | 90266 |
| 4137-007-064 | JASPER J & LAURA BLYSTONE   | P.O. BOX 5129       | PLAYA DEL REY   | CA    | 90296 |
| 4137-007-066 | BRIAN M OLSON               | 121 42ND ST         | MANHATTAN BEACH | CA    | 90266 |
| 4137-007-070 | DAVID A BEUGEN              | 4220 THE STRAND     | MANHATTAN BEACH | CA    | 90266 |
| 4137-007-071 | GREGORY W & JEANNE L MORGAN | 4230 THE STRAND     | MANHATTAN BEACH | CA    | 90266 |
| 4137-007-072 | SAMUEL W HO                 | 4220 OCEAN DR #1    | MANHATTAN BCH   | CA    | 90266 |
| 4137-007-073 | SARA E OBERLIES             | 957 LEAVENWORTH ST  | SAN FRANCISCO   | CA    | 94109 |
| 4137-007-074 | BRETT SILEO                 | 4216 OCEAN DR #3    | MANHATTAN BEACH | CA    | 90266 |
| 4137-007-075 | NICKOLAS A TOMASIC          | 4218 OCEAN DR       | MANHATTAN BEACH | CA    | 90266 |
| 4137-007-076 | WARREN B EADS               | 930 TAHOE BLVD #802 | INCLINE VILLAGE | NV    | 89451 |
| 4137-007-078 | JOHN CHUKA                  | 1215 HIGHLAND AVE   | MANHATTAN BCH   | CA    | 90266 |
| 4137-007-079 | JOHN CHUKA                  | 1215 HIGHLAND AVE   | MANHATTAN BCH   | CA    | 90266 |
| 4137-007-081 | RIAD & AUDREY DIMASHKIEH    | 4202 BEEMAN AVE     | STUDIO CITY     | CA    | 91604 |
| 4137-007-082 | RIAD & AUDREY DIMASHKIEH    | 4202 BEEMAN AVE     | STUDIO CITY     | CA    | 91604 |
| 4137-007-083 | RIAD & AUDREY DIMASHKIEH    | 4202 BEEMAN AVE     | STUDIO CITY     | CA    | 91604 |
| 4137-007-085 | JEFFREY E DAVIS             | 221 SEAVIEW ST      | MANHATTAN BEACH | CA    | 90266 |
| 4137-007-086 | SATISH S KADABA             | 220 43RD ST         | MANHATTAN BEACH | CA    | 90266 |
| 4137-007-088 | GRADY MICHAEL CO TR         | 228 43RD ST         | MANHATTAN BEACH | CA    | 90266 |

TABLE 5-1  
**Property Owners within 1,000 Feet of the Project**

| APN          | OWNER                         | Address              | City              | State | Zip   |
|--------------|-------------------------------|----------------------|-------------------|-------|-------|
| 4137-007-089 | JOSHUA T & KIMBERLY GRANT     | 88 WASHINGTON PL #3A | NEW YORK          | NY    | 10011 |
| 4137-008-001 | JOSE & ELIZABETH Y ALVAREZ    | 1503 GOODMAN AVE     | REDONDO BEACH     | CA    | 90278 |
| 4137-008-002 | RICHARD B & BETTY W PECHARICH | 661 W 30TH ST        | SAN PEDRO         | CA    | 90731 |
| 4137-008-004 | SUSAN M SWAN                  | 226 42ND ST          | MANHATTAN BEACH   | CA    | 90266 |
| 4137-008-005 | YASEMIN & JOHN VICKERY        | 15536 HAMNER DR      | LOS ANGELES       | CA    | 90077 |
| 4137-008-006 | J BLAKE SATHOFF               | 2315 NELSON AVE      | REDONDO BEACH     | CA    | 90278 |
| 4137-008-007 | HARLAN A & EDREN M HELVEY     | P.O. BOX 3400        | MANHATTAN BCH     | CA    | 90266 |
| 4137-008-008 | RICHARD D GERVAIS             | 216 42ND ST          | MANHATTAN BEACH   | CA    | 90266 |
| 4137-008-009 | CHARLES D & MARILYN S MILAM   | 129 18TH ST          | MANHATTAN BEACH   | CA    | 90266 |
| 4137-008-010 | HESHAM A & DALAL T KARAMA     | 30233 VIA RIVERA     | RANCHO PALOS VERD | CA    | 90275 |
| 4137-008-011 | PERRY L HERWOOD               | P.O. BOX 3280        | MANHATTAN BEACH   | CA    | 90266 |
| 4137-008-012 | AARON H CAPLAN                | 208 42ND ST          | MANHATTAN BEACH   | CA    | 90266 |
| 4137-008-013 | JEROME TAIN                   | 209 MOONSTONE ST     | MANHATTAN BEACH   | CA    | 90266 |
| 4137-008-014 | STEVEN A & TERESA MANGIAGI    | 2007 CIRCLE DR       | HERMOSA BEACH     | CA    | 90254 |
| 4137-008-015 | RAYMOND J & LAURA D RIBAR     | 318 THE STRAND       | HERMOSA BEACH     | CA    | 90254 |
| 4137-008-016 | MICHAEL W STURROCK            | 633 W 5TH ST #4000   | LOS ANGELES       | CA    | 90071 |
| 4137-008-017 | ROBERT D GALLMAN              | 201 MOONSTONE ST     | MANHATTAN BEACH   | CA    | 90266 |
| 4137-008-018 | G RODERICK SHERRIFFS          | 76194 HONEYSUCKLE DR | PALM DESERT       | CA    | 92211 |
| 4137-008-019 | LAURENCE & DARALEE S BARBERA  | 129 MOONSTONE ST     | MANHATTAN BEACH   | CA    | 90266 |
| 4137-008-020 | ERIC A WARD                   | 124 42ND ST          | MANHATTAN BEACH   | CA    | 90266 |
| 4137-008-021 | MICHAEL S ALLEN               | P.O. BOX 877         | MANHATTAN BEACH   | CA    | 90267 |
| 4137-008-022 | CHARLES & MARILYN MILAM       | 129 18TH ST          | MANHATTAN BCH     | CA    | 90266 |
| 4137-008-023 | MARY A STEWARD                | 121 MOONSTONE ST     | MANHATTAN BEACH   | CA    | 90266 |
| 4137-008-024 | MELVIN & MARGARET SCHEINMAN   | 3566 JACKSON ST      | SAN FRANCISCO     | CA    | 94118 |

TABLE 5-1  
**Property Owners within 1,000 Feet of the Project**

| APN          | OWNER                          | Address            | City              | State | Zip   |
|--------------|--------------------------------|--------------------|-------------------|-------|-------|
| 4137-008-025 | THOMAS C & KATHY R BERG        | 26621 HAWKHURST DR | RCH PALOS VRD     | CA    | 90275 |
| 4137-008-026 | PAUL J MARCHINI                | 2005 PASEO DEL SOL | PALOS VERDES ESTA | CA    | 90274 |
| 4137-008-027 | EUGENIA B TUKAJ GARMAN         | 4112 OCEAN DR      | MANHATTAN BEACH   | CA    | 90266 |
| 4137-008-028 | JACK R & BETTY A STEPHENS      | 4120 THE STRAND    | MANHATTAN BCH     | CA    | 90266 |
| 4137-008-029 | STEPHENS FAMILY PARTNERSHIP II | 4120 THE STRAND    | MANHATTAN BCH     | CA    | 90266 |
| 4137-008-031 | STUART H SACKLEY               | 4108 THE STRAND    | MANHATTAN BEACH   | CA    | 90266 |
| 4137-008-032 | LAREE BENNETT                  | 4104 THE STRAND    | MANHATTAN BEACH   | CA    | 90266 |
| 4137-008-034 | PEGGY H MALPEE                 | 117 41ST ST        | MANHATTAN BEACH   | CA    | 90266 |
| 4137-008-035 | PEGGY H MALPEE                 | 117 41ST ST        | MANHATTAN BEACH   | CA    | 90266 |
| 4137-008-037 | RICHARD A MARINO               | 121 41ST ST        | MANHATTAN BEACH   | CA    | 90266 |
| 4137-008-039 | THOMAS NEAL                    | 613 18TH ST        | MANHATTAN BEACH   | CA    | 90266 |
| 4137-008-040 | LISHAN T WORKENEH              | 124 MOONSTONE ST   | MANHATTAN BEACH   | CA    | 90266 |
| 4137-008-041 | HOWARD D NUNN                  | 129 41ST ST        | MANHATTAN BEACH   | CA    | 90266 |
| 4137-008-042 | JAMES R & JOYCE E KOSINSKI     | 128 MOONSTONE ST   | MANHATTAN BEACH   | CA    | 90266 |
| 4137-008-043 | H BERNARD & SOPHIE QUANTE      | 201 41ST ST        | MANHATTAN BEACH   | CA    | 90266 |
| 4137-008-044 | GREGORY J CHEREP               | 200 MOONSTONE ST   | MANHATTAN BEACH   | CA    | 90266 |
| 4137-008-045 | MICHAEL P ERNST                | 205 41ST ST        | MANHATTAN BEACH   | CA    | 90266 |
| 4137-008-046 | AARON M PERLMUTTER             | 1744 HERMOSA AVE   | HERMOSA BEACH     | CA    | 90254 |
| 4137-008-047 | THEODORE W RANDALL             | 209 41ST ST        | MANHATTAN BEACH   | CA    | 90266 |
| 4137-008-048 | RICHARD B & BETTY W PECHARICH  | 661 W 30TH ST      | SAN PEDRO         | CA    | 90731 |
| 4137-008-049 | DANTE T BOUTELL                | 416 20TH ST        | MANHATTAN BCH     | CA    | 90266 |
| 4137-008-050 | GUY B KATICH                   | P.O. BOX 3576      | MANHATTAN BEACH   | CA    | 90266 |
| 4137-008-051 | GREGORY S MORAN                | 219 41ST ST        | MANHATTAN BEACH   | CA    | 90266 |
| 4137-008-052 | SUZANNE R PERLES               | 216 MOONSTONE ST   | MANHATTAN BEACH   | CA    | 90266 |

TABLE 5-1  
**Property Owners within 1,000 Feet of the Project**

| APN          | OWNER                      | Address               | City            | State | Zip   |
|--------------|----------------------------|-----------------------|-----------------|-------|-------|
| 4137-008-053 | GREGORY K POUSSON          | P.O. BOX 2484         | REDONDO BEACH   | CA    | 90278 |
| 4137-008-054 | DANIEL GOETSCHEL           | 4975 MAYNARD ST       | SAN DIEGO       | CA    | 92122 |
| 4137-008-055 | RYAN C HERMANN             | 225 41ST ST           | MANHATTAN BEACH | CA    | 90266 |
| 4137-008-056 | DARIN S PUHL               | 319 MAIN ST           | EL SEGUNDO      | CA    | 90245 |
| 4137-008-057 | HA & TUYET V TRAN          | 1201 23RD ST          | MANHATTAN BEACH | CA    | 90266 |
| 4137-008-058 | HA & TUYET V TRAN          | 1201 23RD ST          | MANHATTAN BEACH | CA    | 90266 |
| 4137-008-059 | PEGGY H MALPEE             | 117 41ST ST           | MANHATTAN BEACH | CA    | 90266 |
| 4137-008-061 | SAMUEL J BRAITMAN          | 4102 THE STRAND       | MANHATTAN BCH   | CA    | 90266 |
| 4137-008-062 | SAMUEL J BRAITMAN          | 4102 THE STRAND       | MANHATTAN BEACH | CA    | 90266 |
| 4137-008-064 | WILLIAM F SCHINBINE        | 228 42ND ST           | MANHATTAN BEACH | CA    | 90266 |
| 4137-008-065 | SAMI REVAH                 | 229 MOONSTONE ST      | MANHATTAN BEACH | CA    | 90266 |
| 4137-008-067 | BRUCE D SIDLINGER          | P.O. BOX 3148         | MANHATTAN BEACH | CA    | 90266 |
| 4137-008-068 | BRUCE D SIDLINGER          | P.O. BOX 3148         | MANHATTAN BEACH | CA    | 90266 |
| 4137-009-011 | SUZANNE HARRIS             | 204 41ST ST           | MANHATTAN BEACH | CA    | 90266 |
| 4137-009-013 | SUZANNE HARRIS             | 204 41ST ST           | MANHATTAN BEACH | CA    | 90266 |
| 4137-009-015 | RUBIN CATHY L DECD EST OF  | P.O. BOX 288          | REDONDO BEACH   | CA    | 90277 |
| 4137-009-017 | RICHARD J & DONNA J PIAZZA | 2612 PINE AVE         | MANHATTAN BCH   | CA    | 90266 |
| 4137-009-019 | MICHELE MCGARRY            | 1262 BERYL ST PMB#41  | REDONDO BEACH   | CA    | 90277 |
| 4137-009-021 | JAMES M CHILDS             | 1304 PINE AVE         | MANHATTAN BCH   | CA    | 90266 |
| 4137-009-023 | GLADI M ADAMS              | 1122 W SUMMERLAND AVE | SAN PEDRO       | CA    | 90732 |
| 4137-009-025 | BRUCE K & SUSAN J JACKSON  | 4020 THE STRAND       | MANHATTAN BEACH | CA    | 90266 |
| 4137-009-026 | BERNICE K MATHEWS          | 1204 IRON ST          | SAINT LOUIS     | MO    | 63111 |
| 4137-013-900 | L A COUNTY                 | 500 W TEMPLE ST #754  | LOS ANGELES     | CA    | 90012 |
| 4137-013-902 | L A COUNTY                 | 500 W TEMPLE ST #754  | LOS ANGELES     | CA    | 90012 |

TABLE 5-1  
**Property Owners within 1,000 Feet of the Project**

| APN          | OWNER           | Address              | City        | State | Zip   |
|--------------|-----------------|----------------------|-------------|-------|-------|
| 4137-013-905 | L A COUNTY      | 500 W TEMPLE ST #754 | LOS ANGELES | CA    | 90012 |
| 4137-013-908 | L A COUNTY      | 500 W TEMPLE ST #754 | LOS ANGELES | CA    | 90012 |
| 4138-016-004 | CHEVRON USA INC | P O BOX 285          | HOUSTON     | TX    | 77001 |
| 4138-016-008 | CHEVRON USA INC | P O BOX 285          | HOUSTON     | TX    | 77001 |
| 4138-016-009 | CHEVRON USA INC | P O BOX 285          | HOUSTON     | TX    | 77001 |
| 4138-016-012 | CHEVRON USA INC | P O BOX 285          | HOUSTON     | TX    | 77001 |
| 4138-016-013 | CHEVRON USA INC | P O BOX 285          | HOUSTON     | TX    | 77001 |
| 4138-029-003 | CHEVRON USA INC | P O BOX 1392         | BAKERSFIELD | CA    | 93302 |

SECTION 6.0

## Potential Effects on Property Owners

---

Consistent with the CEC Siting Regulations Section 1769(a)(1)(I), this section addresses potential effects of the proposed Amendment on nearby property owners, the public, and parties in the application proceeding. Implementation of the ESPFM is expected to result in equal or less environmental impacts. The ESPFM will eliminate once-through cooling and ocean discharge of industrial and sanitary wastewater. Therefore, impacts to property owners are expected to be equal to or less than those analyzed during the 00-AFC-14 license proceeding. The operational impacts of the ESPFM will not result in significant unmitigated environmental.



**Appendices 3.1A–H**  
**Air Quality Technical Information**

---

**APPENDIX 3.1A – EMISSIONS CALCULATIONS AND SUPPORT DATA**

**Table 3.1A-1**  
**EI Segundo Power Facility Modification**  
**Operating Parameters for Gas Turbine (GE) (Performance Runs)**

| Case                           | Hot Peak  | Hot Base (cooler) | Hot Low   | Mild Peak | Mild Base (cooler) | Mild Low  | Cold Peak | Cold Base | Cold Low  |
|--------------------------------|-----------|-------------------|-----------|-----------|--------------------|-----------|-----------|-----------|-----------|
| CTG Gross Power, MW            | 205       | 205               | 195       | 211       | 211                | 204       | 222       | 222       | 100       |
| STG Gross Power, MW            | 100       | 81                | 79        | 105       | 84                 | 84        | 112       | 87        | 65        |
| Ambient Temp, F                | 90        | 90                | 90        | 78        | 78                 | 78        | 41        | 41        | 41        |
| Turbine Load, %                | 100%      | 100%              | 100%      | 100%      | 100%               | 100%      | 100%      | 100%      | 45%       |
| CTG Heat Input, MMBTU/Hr (HHV) | 2,055     | 2,055             | 1,965     | 2,093     | 2,093              | 2,035     | 2,168     | 2,168     | 1,319     |
| Duct Burner Input, MMBTU/hr    | 267       | 0                 | 0         | 265       | 0                  | 0         | 268       | 0         | 0         |
| Stack Flow, lb/hr              | 4,093,977 | 4,082,373         | 3,939,982 | 4,146,579 | 4,135,263          | 4,062,573 | 4,220,097 | 4,204,939 | 2,704,195 |
| Stack Flow, acfm               | 1,264,751 | 1,256,250         | 1,212,535 | 1,263,131 | 1,258,688          | 1,235,473 | 1,236,686 | 1,256,058 | 774,214   |
| Stack Flow, dscfm              | 818,617   | 822,927           | 801,780   | 835,112   | 839,430            | 829,672   | 859,239   | 862,804   | 556,803   |
| Stack Temp, F                  | 254       | 253               | 250       | 244       | 245                | 244       | 219       | 233       | 204       |
| Stack Exhaust, vol %           |           |                   |           |           |                    |           |           |           |           |
| O2 (dry)                       | 12.54%    | 13.54%            | 13.68%    | 12.57%    | 13.55%             | 13.67%    | 12.54%    | 13.50%    | 13.92%    |
| CO2 (dry)                      | 4.82%     | 4.25%             | 4.17%     | 4.80%     | 4.24%              | 4.18%     | 4.82%     | 4.28%     | 4.03%     |
| H2O                            | 11.60%    | 10.70%            | 9.41%     | 10.61%    | 9.73%              | 8.90%     | 9.06%     | 8.18%     | 7.78%     |

NOTE: Heat Input based on project design fuel heat content of 1030 MMBtu/SCF

**Table 3.1A-2**  
**EI Segundo Power Facility Modification**  
**Emissions and Operating Parameters for Gas Turbine (Trent, each) (Performance Runs)**

| Case                           | Hot Base (cooler) | Hot Base  | Hot Low | Mild Base (cooler) | Mild Base | Mild Low | Cold Base | Cold Low  |
|--------------------------------|-------------------|-----------|---------|--------------------|-----------|----------|-----------|-----------|
| CTG Gross Power, MW            | 55                | 42        | 23      | 57                 | 46        | 25       | 57        | 32        |
| Ambient Temp, F                | 90                | 90        | 90      | 78                 | 78        | 78       | 41        | 41        |
| Turbine Load, %                | 100%              | 100%      | 55%     | 100%               | 100%      | 55%      | 100%      | 55%       |
| CTG Heat Input, MMBTU/Hr (HHV) | 500               | 406       | 292     | 516                | 430       | 305      | 511       | 337       |
| Stack Flow, lb/hr              | 1,223,803         | 1,043,554 | 837,662 | 1,250,350          | 1,101,098 | 875,919  | 1,291,452 | 1,022,250 |
| Stack Flow, acfm               | 691,769           | 602,502   | 458,651 | 701,728            | 626,839   | 471,868  | 707,090   | 512,594   |
| Stack Flow, dscfm              | 249,644           | 215,287   | 173,672 | 256,795            | 227,986   | 182,304  | 269,368   | 214,934   |
| Stack Temp, F                  | 818               | 863       | 844     | 809                | 846       | 824      | 799       | 737       |
| Stack Exhaust, vol %           |                   |           |         |                    |           |          |           |           |
| O2 (dry)                       | 15.01%            | 15.36%    | 15.96%  | 14.99%             | 15.36%    | 15.99%   | 15.33%    | 16.29%    |
| CO2 (dry)                      | 3.42%             | 3.22%     | 2.87%   | 3.43%              | 3.22%     | 2.86%    | 3.23%     | 2.68%     |
| H2O                            | 9.38%             | 7.85%     | 7.27%   | 8.41%              | 7.32%     | 6.72%    | 6.23%     | 5.29%     |

NOTE: Heat Input based on project design fuel heat content of 1030 MMBtu/SCF

**Table 3.1A-3**  
**El Segundo Power Facility Modification**  
**Auxiliary Boiler**

| Device                           | Aux Boiler  |
|----------------------------------|-------------|
| Fuel                             | Natural Gas |
| Maximum Heat Input (MMBtu/hr)    | 36          |
| F-factor (dscf/MMBtu)            | 8,710       |
| F-factor (wscf/MMBtu)            | 10,610      |
| Reference O2                     | 3.0%        |
| Actual O2                        | 5.1%        |
| Exhaust Temperature (F)          | 300         |
| Exhaust Rate (dscfm @ 3% O2)     | 6,099       |
| Exhaust Rate (wacfm @ actual O2) | 8,414       |

| Pollutant | Emission Factors (lb/MMBtu) | Maximum Emissions (lb/hr) |
|-----------|-----------------------------|---------------------------|
| CO        | 0.0370                      | 1.3                       |
| NOx       | 0.0109                      | 0.4                       |
| PM10      | 0.0075                      | 0.3                       |
| SOx       | 0.0021                      | 0.1                       |
| VOC       | 0.0040                      | 0.1                       |

| Maximum Operating Hours |      | Emissions (lbs/day, lb/month, ton/yr) at 25% load <sup>1</sup> |      |      |      |      |
|-------------------------|------|--|------|------|------|------|
|                         |      | CO   | NOx  | VOC  | PM10 | SOx  |
| Daily                   | 24   | 8.0  | 2.4  | 0.9  | 1.6  | 0.4  |
| Monthly                 | 744  | 247.4  | 73.2 | 26.8 | 49.9 | 13.9 |
| Annual                  | 8760 | 1.5  | 0.4  | 0.2  | 0.3  | 0.1  |

Note 1: Boiler operates at 25% load when Unit 9 is not operating. Boiler does not operate at all when Unit 9 is operating, except for the first 20 minutes of startup, when it operates at 100% load. Daily, monthly, and annual emissions are calculated at 25% load.

**Table 3.1A-4**  
**El Segundo Power Facility Modification**  
**Turbine Startup/Shutdown Emissions**

| Mode                  | Time (minutes) | Total Emissions Per Event (pounds) |      |     |     |
|-----------------------|----------------|------------------------------------|------|-----|-----|
|                       |                | NOx                                | CO   | VOC | PM  |
| <b>GE Turbine</b>     |                |                                    |      |     |     |
| Startup (fast start)  | 30             | 36                                 | 153  | 14  | 5   |
| Startup (traditional) | 60             | 62                                 | 291  | 23  | 5   |
| Shutdown              | 30             | 29                                 | 317  | 32  | 2   |
| <b>Trent Turbine</b>  |                |                                    |      |     |     |
| Startup               | 30             | 28.0                               | 87.5 | 6.7 | 3.8 |
| Shutdown              | 20             | 7.1                                | 60.0 | 4.7 | 2.2 |

**Table 3.1A-5**  
**EI Segundo Power Facility Modification**  
**CO Emissions (GE Turbine) (District Methodology)**

| Operating Condition | Heat Input (MMBTU/hr) | Pollutant Conc. Uncontrolled (ppmvd) | Pollutant Conc. Controlled (ppmvd) | Molecular Weight (lbs/lb-mole) | Specific Molar Volume (dscf/lb-mole) | Dry Fuel Factor (dscf/MMBTU) | Emission Factor Uncontrolled (lb/MMBTU) | Emission Factor Controlled (lb/MMBTU) | Emission Rate Uncontrolled (lb/hr) | Emission Rate Controlled (lb/hr) |
|---------------------|-----------------------|--------------------------------------|------------------------------------|--------------------------------|--------------------------------------|------------------------------|---|---------------------------------------|------------------------------------|----------------------------------|
| Hot Peak            | 2,322                 | 4.0                                  | 2.0                                | 28                             | 385.3                                | 8,710                        | 0.0090                                  | 0.0045                                | 20.8                               | 10.4                             |
| Hot Base (cooler)   | 2,055                 | 4.0                                  | 2.0                                | 28                             | 385.3                                | 8,710                        | 0.0090                                  | 0.0045                                | 18.4                               | 9.2                              |
| Hot Base            | 1,965                 | 4.0                                  | 2.0                                | 28                             | 385.3                                | 8,710                        | 0.0090                                  | 0.0045                                | 17.6                               | 8.8                              |
| Hot Low             | 1,243                 | 4.0                                  | 2.0                                | 28                             | 385.3                                | 8,710                        | 0.0090                                  | 0.0045                                | 11.1                               | 5.6                              |
| Mild Peak           | 2,358                 | 4.0                                  | 2.0                                | 28                             | 385.3                                | 8,710                        | 0.0090                                  | 0.0045                                | 21.1                               | 10.6                             |
| Mild Base (cooler)  | 2,093                 | 4.0                                  | 2.0                                | 28                             | 385.3                                | 8,710                        | 0.0090                                  | 0.0045                                | 18.8                               | 9.4                              |
| Mild Base           | 2,035                 | 4.0                                  | 2.0                                | 28                             | 385.3                                | 8,710                        | 0.0090                                  | 0.0045                                | 18.3                               | 9.1                              |
| Mild Low            | 1,257                 | 4.0                                  | 2.0                                | 28                             | 385.3                                | 8,710                        | 0.0090                                  | 0.0045                                | 11.3                               | 5.6                              |
| Cold Peak           | 2,436                 | 4.0                                  | 2.0                                | 28                             | 385.3                                | 8,710                        | 0.0090                                  | 0.0045                                | 21.8                               | 10.9                             |
| Cold Base           | 2,168                 | 4.0                                  | 2.0                                | 28                             | 385.3                                | 8,710                        | 0.0090                                  | 0.0045                                | 19.4                               | 9.7                              |
| Cold Low            | 1,319                 | 4.0                                  | 2.0                                | 28                             | 385.3                                | 8,710                        | 0.0090                                  | 0.0045                                | 11.8                               | 5.9                              |
| <b>Average</b>      | <b>1,932</b>          |                                      |                                    |                                |                                      |                              |   |                                       | <b>17.3</b>                        | <b>8.7</b>                       |

NOTE: Heat Input based on project design fuel heat content of 1030 MMBtu/SCF

**Table 3.1A-6**  
**EI Segundo Power Facility Modification**  
**NOx Emissions (GE Turbine) (District Methodology)**

| Operating Condition | Heat Input (MMBTU/hr) | Pollutant Conc. Uncontrolled (ppmvd) | Pollutant Conc. Controlled (ppmvd) | Molecular Weight (lb/lb-mol) | Specific Molar Volume (dscf/lb-mole) | Dry Fuel Factor (dscf/MMBTU) | Emission Factor Uncontrolled (lb/MMBTU) | Emission Factor Controlled (lb/MMBTU) | Emission Rate Uncontrolled (lb/hr) | Emission Rate Controlled (lb/hr) |
|---------------------|-----------------------|--------------------------------------|------------------------------------|------------------------------|--------------------------------------|------------------------------|---|---------------------------------------|------------------------------------|----------------------------------|
| Hot Peak            | 2,322                 | 9.0                                  | 2.0                                | 46                           | 385.3                                | 8,710                        | 0.0332                                  | 0.0074                                | 77.0                               | 17.1                             |
| Hot Base (cooler)   | 2,055                 | 9.0                                  | 2.0                                | 46                           | 385.3                                | 8,710                        | 0.0332                                  | 0.0074                                | 68.1                               | 15.1                             |
| Hot Base            | 1,965                 | 9.0                                  | 2.0                                | 46                           | 385.3                                | 8,710                        | 0.0332                                  | 0.0074                                | 65.2                               | 14.5                             |
| Hot Low             | 1,243                 | 9.0                                  | 2.0                                | 46                           | 385.3                                | 8,710                        | 0.0332                                  | 0.0074                                | 41.2                               | 9.2                              |
| Mild Peak           | 2,358                 | 9.0                                  | 2.0                                | 46                           | 385.3                                | 8,710                        | 0.0332                                  | 0.0074                                | 78.2                               | 17.4                             |
| Mild Base (cooler)  | 2,093                 | 9.0                                  | 2.0                                | 46                           | 385.3                                | 8,710                        | 0.0332                                  | 0.0074                                | 69.4                               | 15.4                             |
| Mild Base           | 2,035                 | 9.0                                  | 2.0                                | 46                           | 385.3                                | 8,710                        | 0.0332                                  | 0.0074                                | 67.5                               | 15.0                             |
| Mild Low            | 1,257                 | 9.0                                  | 2.0                                | 46                           | 385.3                                | 8,710                        | 0.0332                                  | 0.0074                                | 41.7                               | 9.3                              |
| Cold Peak           | 2,436                 | 9.0                                  | 2.0                                | 46                           | 385.3                                | 8,710                        | 0.0332                                  | 0.0074                                | 80.8                               | 17.9                             |
| Cold Base           | 2,168                 | 9.0                                  | 2.0                                | 46                           | 385.3                                | 8,710                        | 0.0332                                  | 0.0074                                | 71.9                               | 16.0                             |
| Cold Low            | 1,319                 | 9.0                                  | 2.0                                | 46                           | 385.3                                | 8,710                        | 0.0332                                  | 0.0074                                | 43.7                               | 9.7                              |
| <b>Average</b>      | <b>1,932</b>          |                                      |                                    |                              |                                      |                              |   |                                       | <b>64.0</b>                        | <b>14.2</b>                      |

NOTE: Heat Input based on project design fuel heat content of 1030 MMBtu/SCF

**Table 3.1A-7**  
**EI Segundo Power Facility Modification**  
**VOC Emissions (GE Turbine) (District Methodology)**

| Operating Condition | Heat Input (MMBTU/hr) | Pollutant Conc. Uncontrolled (ppmvd) | Pollutant Conc. Controlled (ppmvd) | Molecular Weight (lb/lb-mol) | Specific Molar Volume (dscf/lb-mol) | Dry Fuel Factor (dscf/MMBTU) | Emission Factor Uncontrolled (lb/MMBTU) | Emission Factor Controlled (lb/MMBTU) | Emission Rate Uncontrolled (lb/hr) | Emission Rate Controlled (lb/hr) |
|---------------------|-----------------------|--------------------------------------|------------------------------------|------------------------------|-------------------------------------|------------------------------|---|---------------------------------------|------------------------------------|----------------------------------|
| Hot Peak            | 2,322                 | 2.0                                  | 2.0                                | 16                           | 385.3                               | 8,710                        | 0.0026                                  | 0.0026                                | 5.9                                | 5.9                              |
| Hot Base (cooler)   | 2,055                 | 2.0                                  | 2.0                                | 16                           | 385.3                               | 8,710                        | 0.0026                                  | 0.0026                                | 5.3                                | 5.3                              |
| Hot Base            | 1,965                 | 2.0                                  | 2.0                                | 16                           | 385.3                               | 8,710                        | 0.0026                                  | 0.0026                                | 5.0                                | 5.0                              |
| Hot Low             | 1,243                 | 2.0                                  | 2.0                                | 16                           | 385.3                               | 8,710                        | 0.0026                                  | 0.0026                                | 3.2                                | 3.2                              |
| Mild Peak           | 2,358                 | 2.0                                  | 2.0                                | 16                           | 385.3                               | 8,710                        | 0.0026                                  | 0.0026                                | 6.0                                | 6.0                              |
| Mild Base (cooler)  | 2,093                 | 2.0                                  | 2.0                                | 16                           | 385.3                               | 8,710                        | 0.0026                                  | 0.0026                                | 5.4                                | 5.4                              |
| Mild Base           | 2,035                 | 2.0                                  | 2.0                                | 16                           | 385.3                               | 8,710                        | 0.0026                                  | 0.0026                                | 5.2                                | 5.2                              |
| Mild Low            | 1,257                 | 2.0                                  | 2.0                                | 16                           | 385.3                               | 8,710                        | 0.0026                                  | 0.0026                                | 3.2                                | 3.2                              |
| Cold Peak           | 2,436                 | 2.0                                  | 2.0                                | 16                           | 385.3                               | 8,710                        | 0.0026                                  | 0.0026                                | 6.2                                | 6.2                              |
| Cold Base           | 2,168                 | 2.0                                  | 2.0                                | 16                           | 385.3                               | 8,710                        | 0.0026                                  | 0.0026                                | 5.6                                | 5.6                              |
| Cold Low            | 1,319                 | 2.0                                  | 2.0                                | 16                           | 385.3                               | 8,710                        | 0.0026                                  | 0.0026                                | 3.4                                | 3.4                              |
| <b>Average</b>      | <b>1,932</b>          |                                      |                                    |                              |                                     |                              |   |                                       | <b>5.0</b>                         | <b>5.0</b>                       |

NOTE: Heat Input based on project design fuel heat content of 1030 MMBtu/SCF

Table 3.1A-8

El Segundo Power Facility Modification

PM10 Emissions (GE Turbine) (District Methodology)

| Operating Condition | Heat Input (MMBTU/hr) | Emission Factor (lb/MMBTU) | Emission Rate Uncontrolled (lb/hr) | Emission Rate Controlled (lb/hr) |
|---------------------|-----------------------|----------------------------|------------------------------------|----------------------------------|
| Hot Peak            | 2,322                 | 0.0041                     | 9.5                                | 9.5                              |
| Hot Base (cooler)   | 2,055                 | 0.0046                     | 9.5                                | 9.5                              |
| Hot Base            | 1,965                 | 0.0048                     | 9.5                                | 9.5                              |
| Hot Low             | 1,243                 | 0.0076                     | 9.5                                | 9.5                              |
| Mild Peak           | 2,358                 | 0.0040                     | 9.5                                | 9.5                              |
| Mild Base (cooler)  | 2,093                 | 0.0045                     | 9.5                                | 9.5                              |
| Mild Base           | 2,035                 | 0.0047                     | 9.5                                | 9.5                              |
| Mild Low            | 1,257                 | 0.0076                     | 9.5                                | 9.5                              |
| Cold Peak           | 2,436                 | 0.0039                     | 9.5                                | 9.5                              |
| Cold Base           | 2,168                 | 0.0044                     | 9.5                                | 9.5                              |
| Cold Low            | 1,319                 | 0.0072                     | 9.5                                | 9.5                              |
| <b>Average</b>      | <b>1,932</b>          |                            | <b>9.5</b>                         | <b>9.5</b>                       |

NOTE: Heat Input based on project design fuel heat content of 1030 MMBtu/SCF



**Table 3.1A-9**  
**EI Segundo Power Facility Modification**  
**SOx Emissions (GE Turbine) (District Methodology)**

| Operating Condition | Heat Input (MMBTU/hr) | Short-Term Emission Factor <sup>1</sup> (lb/MMBTU) | Long-Term Emission Factor <sup>1</sup> (lb/MMBTU) | Short-Term                         |                                  | Long-Term                          |                                  |
|---------------------|-----------------------|--|---|------------------------------------|----------------------------------|------------------------------------|----------------------------------|
|                     |                       |  |   | Emission Rate Uncontrolled (lb/hr) | Emission Rate Controlled (lb/hr) | Emission Rate Uncontrolled (lb/hr) | Emission Rate Controlled (lb/hr) |
| Hot Peak            | 2,322                 | 0.00208  | 0.00069   | 4.8                                | 4.8                              | 1.6                                | 1.6                              |
| Hot Base (cooler)   | 2,055                 | 0.00208  | 0.00069   | 4.3                                | 4.3                              | 1.4                                | 1.4                              |
| Hot Base            | 1,965                 | 0.00208  | 0.00069   | 4.1                                | 4.1                              | 1.4                                | 1.4                              |
| Hot Low             | 1,243                 | 0.00208  | 0.00069   | 2.6                                | 2.6                              | 0.9                                | 0.9                              |
| Mild Peak           | 2,358                 | 0.00208  | 0.00069   | 4.9                                | 4.9                              | 1.6                                | 1.6                              |
| Mild Base (cooler)  | 2,093                 | 0.00208  | 0.00069   | 4.4                                | 4.4                              | 1.5                                | 1.5                              |
| Mild Base           | 2,035                 | 0.00208  | 0.00069   | 4.2                                | 4.2                              | 1.4                                | 1.4                              |
| Mild Low            | 1,257                 | 0.00208  | 0.00069   | 2.6                                | 2.6                              | 0.9                                | 0.9                              |
| Cold Peak           | 2,436                 | 0.00208  | 0.00069   | 5.1                                | 5.1                              | 1.7                                | 1.7                              |
| Cold Base           | 2,168                 | 0.00208  | 0.00069   | 4.5                                | 4.5                              | 1.5                                | 1.5                              |
| Cold Low            | 1,319                 | 0.00208  | 0.00069   | 2.7                                | 2.7                              | 0.9                                | 0.9                              |
| <b>Average</b>      | <b>1,932</b>          |  |   | <b>4.0</b>                         | <b>4.0</b>                       | <b>1.3</b>                         | <b>1.3</b>                       |

<sup>1</sup> Based on a maximum long-term sulfur content of 0.25 grains/100 scf fuel; 1,030 BTU/scf natural gas; and 7,000 grains/lb, and 1 mole S for 2 moles SO<sub>2</sub>

Based on maximum short-term sulfur content of 0.75 grains/100 scf fuel

SOX = (0.25 gr/100scf)(1 scf/1,030 BTU)(lb/7,000 gr)(2 mol SO<sub>2</sub>/1 mol S)(1,000,000 BTU/MMBTU) = 0.00069 lb/MMBTU

SOX = (0.75 gr/100scf)(1 scf/1,030 BTU)(lb/7,000 gr)(2 mol SO<sub>2</sub>/1 mol S)(1,000,000 BTU/MMBTU) = 0.00208 lb/MMBTU

NOTE: Heat Input based on project design fuel heat content of 1030 MMBtu/SCF

**Table 3.1A-10**  
**EI Segundo Power Facility Modification**  
**NH3 Emissions (GE Turbine) (District Methodology)**

| Operating Condition | Heat Input (MMBTU/hr) | Pollutant Conc. Controlled (ppmvd) | Molecular Weight (lb/lb-mol) | Specific Molar Volume (dscf/lb-mol) | Dry Fuel Factor (dscf/MMBTU) | Emission Factor (lb/MMBTU) | Emission Rate (lb/hr) |
|---------------------|-----------------------|------------------------------------|------------------------------|-------------------------------------|------------------------------|----------------------------|-----------------------|
| Hot Peak            | 2,322                 | 5                                  | 17                           | 385.3                               | 8,710                        | 0.0068                     | 15.8                  |
| Hot Base (cooler)   | 2,055                 | 5                                  | 17                           | 385.3                               | 8,710                        | 0.0068                     | 14.0                  |
| Hot Base            | 1,965                 | 5                                  | 17                           | 385.3                               | 8,710                        | 0.0068                     | 13.4                  |
| Hot Low             | 1,243                 | 5                                  | 17                           | 385.3                               | 8,710                        | 0.0068                     | 8.5                   |
| Mild Peak           | 2,358                 | 5                                  | 17                           | 385.3                               | 8,710                        | 0.0068                     | 16.0                  |
| Mild Base (cooler)  | 2,093                 | 5                                  | 17                           | 385.3                               | 8,710                        | 0.0068                     | 14.2                  |
| Mild Base           | 2,035                 | 5                                  | 17                           | 385.3                               | 8,710                        | 0.0068                     | 13.9                  |
| Mild Low            | 1,257                 | 5                                  | 17                           | 385.3                               | 8,710                        | 0.0068                     | 8.6                   |
| Cold Peak           | 2,436                 | 5                                  | 17                           | 385.3                               | 8,710                        | 0.0068                     | 16.6                  |
| Cold Base           | 2,168                 | 5                                  | 17                           | 385.3                               | 8,710                        | 0.0068                     | 14.8                  |
| Cold Low            | 1,319                 | 5                                  | 17                           | 385.3                               | 8,710                        | 0.0068                     | 9.0                   |
| <b>Average</b>      | <b>1,932</b>          |                                    |                              |                                     |                              |                            | <b>13.1</b>           |

NOTE: Heat Input based on project design fuel heat content of 1030 MMBtu/SCF

**Table 3.1A-11**  
**EI Segundo Power Facility Modification**  
**CO Emissions (Trent Turbine, Each)**

| Operating Condition | Heat Input (MMBTU/hr) | Pollutant Conc. Uncontrolled (ppmvd) | Molecular Weight (lbs/lb-mole) | Specific Molar Volume (dscf/lb-mole) | Dry Fuel Factor (dscf/MMBTU) | Emission Factor Uncontrolled (lb/MMBTU) | Emission Factor Controlled (lb/MMBTU) | Emission Rate Uncontrolled (lb/hr) | Emission Rate Controlled (lb/hr) |
|---------------------|-----------------------|--------------------------------------|--------------------------------|--------------------------------------|------------------------------|---|---------------------------------------|------------------------------------|----------------------------------|
| Hot Base (cooler)   | 500                   | 17.0                                 | 28                             | 385.3                                | 8,710                        | 0.0381                                  | 0.0090                                | 19.1                               | 4.5                              |
| Hot Base            | 406                   | 17.0                                 | 28                             | 385.3                                | 8,710                        | 0.0381                                  | 0.0090                                | 15.5                               | 3.6                              |
| Hot Low             | 292                   | 17.0                                 | 28                             | 385.3                                | 8,710                        | 0.0381                                  | 0.0090                                | 11.1                               | 2.6                              |
| Mild Base (cooler)  | 516                   | 17.0                                 | 28                             | 385.3                                | 8,710                        | 0.0381                                  | 0.0090                                | 19.7                               | 4.6                              |
| Mild Base           | 430                   | 17.0                                 | 28                             | 385.3                                | 8,710                        | 0.0381                                  | 0.0090                                | 16.4                               | 3.9                              |
| Mild Low            | 305                   | 17.0                                 | 28                             | 385.3                                | 8,710                        | 0.0381                                  | 0.0090                                | 11.6                               | 2.7                              |
| Cold Base           | 511                   | 17.0                                 | 28                             | 385.3                                | 8,710                        | 0.0381                                  | 0.0090                                | 19.5                               | 4.6                              |
| Cold Low            | 337                   | 17.0                                 | 28                             | 385.3                                | 8,710                        | 0.0381                                  | 0.0090                                | 12.9                               | 3.0                              |
| <b>Average</b>      | <b>412</b>            |                                      |                                |                                      |                              |   |                                       | <b>15.7</b>                        | <b>3.7</b>                       |

NOTE: Heat Input based on project design fuel heat content of 1030 MMBtu/SCF

**Table 3.1A-12**  
**EI Segundo Power Facility Modification**  
**NOx Emissions (Trent Turbine, Each)**

| Operating Condition | Heat Input (MMBTU/hr) | Pollutant Conc. Uncontrolled (ppmvd) | Pollutant Conc. Controlled (ppmvd) | Molecular Weight (lb/lb-mol) | Specific Molar Volume (dscf/lb-mole) | Dry Fuel Factor (dscf/MMBTU) | Emission Factor Uncontrolled (lb/MMBTU) | Emission Factor Controlled (lb/MMBTU) | Emission Rate Uncontrolled (lb/hr) | Emission Rate Controlled (lb/hr) |
|---------------------|-----------------------|--------------------------------------|------------------------------------|------------------------------|--------------------------------------|------------------------------|---|---------------------------------------|------------------------------------|----------------------------------|
| Hot Base (cooler)   | 500                   | 25.0                                 | 2.5                                | 46                           | 385.3                                | 8,710                        | 0.0921                                  | 0.0092                                | 46.1                               | 4.6                              |
| Hot Base            | 406                   | 25.0                                 | 2.5                                | 46                           | 385.3                                | 8,710                        | 0.0921                                  | 0.0092                                | 37.4                               | 3.7                              |
| Hot Low             | 292                   | 25.0                                 | 2.5                                | 46                           | 385.3                                | 8,710                        | 0.0921                                  | 0.0092                                | 26.9                               | 2.7                              |
| Mild Base (cooler)  | 516                   | 25.0                                 | 2.5                                | 46                           | 385.3                                | 8,710                        | 0.0921                                  | 0.0092                                | 47.5                               | 4.8                              |
| Mild Base           | 430                   | 25.0                                 | 2.5                                | 46                           | 385.3                                | 8,710                        | 0.0921                                  | 0.0092                                | 39.6                               | 4.0                              |
| Mild Low            | 305                   | 25.0                                 | 2.5                                | 46                           | 385.3                                | 8,710                        | 0.0921                                  | 0.0092                                | 28.1                               | 2.8                              |
| Cold Base           | 511                   | 25.0                                 | 2.5                                | 46                           | 385.3                                | 8,710                        | 0.0921                                  | 0.0092                                | 47.0                               | 4.7                              |
| Cold Low            | 337                   | 25.0                                 | 2.5                                | 46                           | 385.3                                | 8,710                        | 0.0921                                  | 0.0092                                | 31.1                               | 3.1                              |
| <b>Average</b>      | <b>412</b>            |                                      |                                    |                              |                                      |                              |   |                                       | <b>38.0</b>                        | <b>3.8</b>                       |

NOTE: Heat Input based on project design fuel heat content of 1030 MMBtu/SCF

**Table 3.1A-13**  
**EI Segundo Power Facility Modification**  
**VOC Emissions (Trent Turbine, Each)**

| Operating Condition | Heat Input (MMBTU/hr) | Pollutant Conc. Uncontrolled (ppmvd) | Pollutant Conc. Controlled (ppmvd) | Molecular Weight (lb/lb-mol) | Specific Molar Volume (dscf/lb-mol) | Dry Fuel Factor (dscf/MMBTU) | Emission Factor Uncontrolled (lb/MMBTU) | Emission Factor Controlled (lb/MMBTU) | Emission Rate Uncontrolled (lb/hr) | Emission Rate Controlled (lb/hr) |
|---------------------|-----------------------|--------------------------------------|------------------------------------|------------------------------|-------------------------------------|------------------------------|---|---------------------------------------|------------------------------------|----------------------------------|
| Hot Base (cooler)   | 500                   | 5.0                                  | 2.0                                | 16                           | 385.3                               | 8,710                        | 0.0064                                  | 0.0026                                | 3.2                                | 1.3                              |
| Hot Base            | 406                   | 5.0                                  | 2.0                                | 16                           | 385.3                               | 8,710                        | 0.0064                                  | 0.0026                                | 2.6                                | 1.0                              |
| Hot Low             | 292                   | 5.0                                  | 2.0                                | 16                           | 385.3                               | 8,710                        | 0.0064                                  | 0.0026                                | 1.9                                | 0.7                              |
| Mild Base (cooler)  | 516                   | 5.0                                  | 2.0                                | 16                           | 385.3                               | 8,710                        | 0.0064                                  | 0.0026                                | 3.3                                | 1.3                              |
| Mild Base           | 430                   | 5.0                                  | 2.0                                | 16                           | 385.3                               | 8,710                        | 0.0064                                  | 0.0026                                | 2.8                                | 1.1                              |
| Mild Low            | 305                   | 5.0                                  | 2.0                                | 16                           | 385.3                               | 8,710                        | 0.0064                                  | 0.0026                                | 2.0                                | 0.8                              |
| Cold Base           | 511                   | 5.0                                  | 2.0                                | 16                           | 385.3                               | 8,710                        | 0.0064                                  | 0.0026                                | 3.3                                | 1.3                              |
| Cold Low            | 337                   | 5.0                                  | 2.0                                | 16                           | 385.3                               | 8,710                        | 0.0064                                  | 0.0026                                | 2.2                                | 0.9                              |
| <b>Average</b>      | <b>412</b>            |                                      |                                    |                              |                                     |                              |   |                                       | <b>2.6</b>                         | <b>1.1</b>                       |

NOTE: Heat Input based on project design fuel heat content of 1030MMBtu/SCF

**Table 3.1A-14**  
**El Segundo Power Facility Modification**  
**PM10 Emissions (Trent Turbine, Each)**

| Operating Condition | Heat Input (MMBTU/hr) | Emission Factor (lb/MMBTU) | Emission Rate Uncontrolled (lb/hr) | Emission Rate Controlled (lb/hr) |
|---------------------|-----------------------|----------------------------|------------------------------------|----------------------------------|
| Hot Base (cooler)   | 500                   | 0.0100                     | 5.0                                | 5.0                              |
| Hot Base            | 406                   | 0.0123                     | 5.0                                | 5.0                              |
| Hot Low             | 292                   | 0.0171                     | 5.0                                | 5.0                              |
| Mild Base (cooler)  | 516                   | 0.0097                     | 5.0                                | 5.0                              |
| Mild Base           | 430                   | 0.0116                     | 5.0                                | 5.0                              |
| Mild Low            | 305                   | 0.0164                     | 5.0                                | 5.0                              |
| Cold Base           | 511                   | 0.0098                     | 5.0                                | 5.0                              |
| Cold Low            | 337                   | 0.0148                     | 5.0                                | 5.0                              |
| <b>Average</b>      | 412                   |                            | <b>5.0</b>                         | <b>5.0</b>                       |

NOTE: Heat Input based on project design fuel heat content of 1030 MMBtu/SCF

**Table 3.1A-15**  
**El Segundo Power Facility Modification**  
**SOx Emissions (Trent Turbine, Each)**

| Operating Condition | Heat Input (MMBTU/hr) | Short-Term Emission Factor <sup>1</sup> (lb/MMBTU) | Long-Term Emission Factor <sup>1</sup> (lb/MMBTU) | Short-Term                         |                                  | Long-Term                          |                                  |
|---------------------|-----------------------|--|---|------------------------------------|----------------------------------|------------------------------------|----------------------------------|
|                     |                       |  |   | Emission Rate Uncontrolled (lb/hr) | Emission Rate Controlled (lb/hr) | Emission Rate Uncontrolled (lb/hr) | Emission Rate Controlled (lb/hr) |
| Hot Base (cooler)   | 500                   | 0.00204  | 0.00068   | 1.0                                | 1.0                              | 0.3                                | 0.3                              |
| Hot Base            | 406                   | 0.00204  | 0.00068   | 0.8                                | 0.8                              | 0.3                                | 0.3                              |
| Hot Low             | 292                   | 0.00204  | 0.00068   | 0.6                                | 0.6                              | 0.2                                | 0.2                              |
| Mild Base (cooler)  | 516                   | 0.00204  | 0.00068   | 1.1                                | 1.1                              | 0.4                                | 0.4                              |
| Mild Base           | 430                   | 0.00204  | 0.00068   | 0.9                                | 0.9                              | 0.3                                | 0.3                              |
| Mild Low            | 305                   | 0.00204  | 0.00068   | 0.6                                | 0.6                              | 0.2                                | 0.2                              |
| Cold Base           | 511                   | 0.00204  | 0.00068   | 1.1                                | 1.1                              | 0.4                                | 0.4                              |
| Cold Low            | 337                   | 0.00204  | 0.00068   | 0.7                                | 0.7                              | 0.2                                | 0.2                              |
| <b>Average</b>      | 412                   |  |   | <b>0.9</b>                         | <b>0.9</b>                       | <b>0.3</b>                         | <b>0.3</b>                       |

NOTE: Heat Input based on project design fuel heat content of 1030 MMBtu/SCF

**Table 3.1A-16**  
**El Segundo Power Facility Modification**  
**NH3 Emissions (Trent Turbine, Each)**

| Operating Condition | Heat Input (MMBTU/hr) | Pollutant Conc. Controlled (ppmvd) | Molecular Weight (lb/lb-mol) | Specific Molar Volume (dscf/lb-mol) | Dry Fuel Factor (dscf/MMBTU) | Emission Factor (lb/MMBTU) | Emission Rate (lb/hr) |
|---------------------|-----------------------|------------------------------------|------------------------------|-------------------------------------|------------------------------|----------------------------|-----------------------|
| Hot Base (cooler)   | 500                   | 5                                  | 17                           | 385.3                               | 8,710                        | 0.0068                     | 3.4                   |
| Hot Base            | 406                   | 5                                  | 17                           | 385.3                               | 8,710                        | 0.0068                     | 2.8                   |
| Hot Low             | 292                   | 5                                  | 17                           | 385.3                               | 8,710                        | 0.0068                     | 2.0                   |
| Mild Base (cooler)  | 516                   | 5                                  | 17                           | 385.3                               | 8,710                        | 0.0068                     | 3.5                   |
| Mild Base           | 430                   | 5                                  | 17                           | 385.3                               | 8,710                        | 0.0068                     | 2.9                   |
| Mild Low            | 305                   | 5                                  | 17                           | 385.3                               | 8,710                        | 0.0068                     | 2.1                   |
| Cold Base           | 511                   | 5                                  | 17                           | 385.3                               | 8,710                        | 0.0068                     | 3.5                   |
| Cold Low            | 337                   | 5                                  | 17                           | 385.3                               | 8,710                        | 0.0068                     | 2.3                   |
| <b>Average</b>      | 412                   |                                    |                              |                                     |                              |                            | <b>2.8</b>            |

NOTE: Heat Input based on project design fuel heat content of 1030 MMBtu/SCF

Table 3.1A-17

Gas Turbine Daily Mass Emission Rates, lbs/day (Non-Commissioning Year)

| Unit 9            | Operating Hours per GT        | Maximum Hourly Emission Rate (lbs/hr)        |       |      |     |      |      | Maximum Daily Emissions (lbs/day)        |       |       |      |       |       |
|-------------------|-------------------------------|--|-------|------|-----|------|------|--|-------|-------|------|-------|-------|
|                   |                               | NOx  | CO    | VOC  | SOx | PM10 | NH3  | NOx                                      | CO    | VOC   | SOx  | PM10  | NH3   |
| Normal Operations | 21                            | 17.9   | 10.9  | 6.2  | 1.7 | 9.5  | 16.6 | 229.4                                    | 131.1 | 376.9 | 35.5 | 199.5 | 348.2 |
| Startup (fast)    | 1                             | 45.0   | 158.5 | 17.1 | 1.4 | 9.5  | 16.6 | 158.5                                    | 17.1  | 45.0  | 1.4  | 9.5   | 16.6  |
| Startup (trad)    | 1                             | 62.3   | 291.0 | 23.3 | 1.4 | 9.5  | 13.4 | 291.0                                    | 23.3  | 62.3  | 1.4  | 9.5   | 13.4  |
| Shutdown          | 2                             | 37.5   | 322.0 | 34.6 | 1.7 | 9.5  | 16.6 | 643.9                                    | 69.2  | 74.9  | 3.4  | 19.0  | 33.2  |
| Total =           |                               |  |       |      |     |      |      | 1322.8                                   | 240.7 | 559.1 | 41.6 | 237.5 | 411.3 |
| <b>Unit 11</b>    | <b>Operating Hours per GT</b> | <b>Maximum Hourly Emission Rate (lbs/hr)</b> |       |      |     |      |      | <b>Maximum Daily Emissions (lbs/day)</b> |       |       |      |       |       |
| Normal Operations | 16                            | 4.8  | 4.6   | 1.3  | 0.4 | 5.0  | 3.5  | 74.0                                     | 21.2  | 76.0  | 5.7  | 80.0  | 56.2  |
| Startup           | 4                             | 30.4   | 89.8  | 7.4  | 0.2 | 5.0  | 3.5  | 359.3                                    | 29.4  | 121.5 | 0.8  | 20.0  | 14.0  |
| Shutdown          | 4                             | 10.3   | 63.1  | 5.6  | 0.4 | 5.0  | 3.5  | 252.3                                    | 22.3  | 41.1  | 1.4  | 20.0  | 14.0  |
| Total =           |                               |  |       |      |     |      |      | 685.6                                    | 72.9  | 238.6 | 8.0  | 120.0 | 84.3  |
| <b>Unit 12</b>    | <b>Operating Hours per GT</b> | <b>Maximum Hourly Emission Rate (lbs/hr)</b> |       |      |     |      |      | <b>Maximum Daily Emissions (lbs/day)</b> |       |       |      |       |       |
| Normal Operations | 16                            | 4.8  | 4.6   | 1.3  | 0.4 | 5.0  | 3.5  | 74.0                                     | 21.2  | 76.0  | 5.7  | 80.0  | 56.2  |
| Startup           | 4                             | 30.4   | 89.8  | 7.4  | 0.2 | 5.0  | 3.5  | 359.3                                    | 29.4  | 121.5 | 0.8  | 20.0  | 14.0  |
| Shutdown          | 4                             | 10.3   | 63.1  | 5.6  | 0.4 | 5.0  | 3.5  | 252.3                                    | 22.3  | 41.1  | 1.4  | 20.0  | 14.0  |
| Total =           |                               |  |       |      |     |      |      | 685.6                                    | 72.9  | 238.6 | 8.0  | 120.0 | 84.3  |
|                   |                               | Facility Total                               |       |      |     |      |      |  |       |       |      |       |       |
|                   |                               | 1036.2                                       |       |      |     |      |      | 579.9                                    |       |       |      |       |       |

Note: Based on maximum 1-hour emissions

Table 3.1A-18

EI Segundo Power Facility Modification

Monthly Emissions - Non-Commissioning Year

|   | Hours<br>per<br>Month | CO<br>(lb/hr) | NOx<br>(lb/hr) | VOC<br>(lb/hr) | PM10<br>(lb/hr) | SOx<br>(lb/hr) | NH3<br>(lb/hr) | CO<br>(lb/month) | NOX<br>(lb/month) | VOC<br>(lb/month) | PM10<br>(lb/month) | SOx<br>(lb/month) | NH3<br>(lb/month) |
|---|-----------------------|---------------|----------------|----------------|-----------------|----------------|----------------|------------------|-------------------|-------------------|--------------------|-------------------|-------------------|
| Unit 9 Start-Up (Fast Start)              | 47                    | 158.5         | 45.0           | 17.1           | 9.5             | 1.4            | 13.4           | 7,448            | 2,114             | 802               | 447                | 64                | 629               |
| Unit 9 Start-Up (Traditional)             | 15                    | 291.0         | 62.3           | 23.3           | 9.5             | 1.4            | 13.4           | 4,365            | 934               | 349               | 143                | 20                | 201               |
| Unit 9 Normal Operations (1)              | 606                   | 10.9          | 17.9           | 6.2            | 9.5             | 1.7            | 16.6           | 6,620            | 10,876            | 3,783             | 5,757              | 1,024             | 10,049            |
| Unit 9 Shutdown                           | 62                    | 322.0         | 37.5           | 34.6           | 9.5             | 1.7            | 16.6           | 19,962           | 2,323             | 2,147             | 589                | 105               | 1,028             |
| <b>Unit 9 Totals</b>                      | <b>730</b>            |               |                |                |                 |                |                | <b>38,395</b>    | <b>16,247</b>     | <b>7,081</b>      | <b>6,935</b>       | <b>1,213</b>      | <b>11,906</b>     |
| Unit 11 Start-Up                          | 60                    | 89.8          | 30.4           | 7.4            | 5.0             | 0.2            | 3.5            | 5,389            | 1,823             | 442               | 300                | 12                | 211               |
| Unit 11 Normal Operations (1)             | 320                   | 4.6           | 4.8            | 1.3            | 5.0             | 0.4            | 3.5            | 1,481            | 1,520             | 423               | 1,600              | 115               | 1,124             |
| Unit 11 Shutdown                          | 60                    | 63.1          | 10.3           | 5.6            | 5.0             | 0.4            | 3.5            | 3,785            | 616               | 335               | 300                | 21                | 211               |
| <b>Unit 11 Totals</b>                     | <b>440</b>            |               |                |                |                 |                |                | <b>10,655</b>    | <b>3,959</b>      | <b>1,200</b>      | <b>2,200</b>       | <b>148</b>        | <b>1,545</b>      |
| Unit 12 Start-Up                          | 60                    | 89.8          | 30.4           | 7.4            | 5.0             | 0.2            | 3.5            | 5,389            | 1,823             | 442               | 300                | 12                | 211               |
| Unit 12 Normal Operations (1)             | 320                   | 4.6           | 4.8            | 1.3            | 5.0             | 0.4            | 3.5            | 1,481            | 1,520             | 423               | 1,600              | 115               | 1,124             |
| Unit 12 Shutdown                          | 60                    | 63.1          | 10.3           | 5.6            | 5.0             | 0.4            | 3.5            | 3,785            | 616               | 335               | 300                | 21                | 211               |
| <b>Unit 12 Totals</b>                     | <b>440</b>            |               |                |                |                 |                |                | <b>10,655</b>    | <b>3,959</b>      | <b>1,200</b>      | <b>2,200</b>       | <b>148</b>        | <b>1,545</b>      |
| <b>Total Monthly Emissions (lb/month)</b> |                       |               |                |                |                 |                |                | <b>59,704</b>    | <b>24,165</b>     | <b>9,480</b>      | <b>11,335</b>      | <b>1,510</b>      | <b>14,996</b>     |

**Table 3.1A-19**  
**El Segundo Power Facility Modification**  
**Annual Emissions - Non-Commissioning Year**

|  | Hours per Year | CO (lbs/hr) | NOx (lbs/hr) | VOC (lbs/hr) | PM10 (lbs/hr) | SOx (lbs/hr) | NH3 (lbs/hr) | CO (lbs/yr)    | NOx (lbs/yr)   | VOC (lbs/yr)  | PM10 (lbs/yr)  | SOx (lbs/yr)  | NH3 (lbs/yr)   |
|--|----------------|-------------|--------------|--------------|---------------|--------------|--------------|----------------|----------------|---------------|----------------|---------------|----------------|
| Unit 9 Start-Up (fast)                   | 150            | 158.5       | 45.0         | 17.1         | 9.5           | 1.4          | 13.4         | 23,769         | 6,746          | 2,561         | 1,425          | 204           | 2,007          |
| Unit 9 Start-Up (Traditional)            | 50             | 291.0       | 62.3         | 23.3         | 9.5           | 1.4          | 13.4         | 14,550         | 3,113          | 1,163         | 475            | 68            | 669            |
| Unit 9 Normal Operations                 | 5,056          | 10.9        | 17.9         | 6.2          | 9.5           | 1.7          | 16.6         | 55,234         | 90,742         | 31,562        | 48,032         | 8,544         | 83,838         |
| Unit 9 Shutdown                          | 200            | 322.0       | 37.5         | 34.6         | 9.5           | 1.7          | 16.6         | 64,392         | 7,495          | 6,924         | 1,900          | 338           | 3,316          |
| <b>Unit 9 Totals</b>                     | <b>5,456</b>   |             |              |              |               |              |              | <b>157,946</b> | <b>108,095</b> | <b>42,210</b> | <b>51,832</b>  | <b>9,155</b>  | <b>89,830</b>  |
| Unit 11 Start-Up                         | 480            | 89.8        | 30.4         | 7.4          | 5.0           | 0.2          | 3.5          | 43,111         | 14,580         | 3,533         | 2,400          | 97            | 1,686          |
| Unit 11 Normal Operations                | 3,840          | 4.6         | 4.8          | 1.3          | 5.0           | 0.4          | 3.5          | 17,768         | 18,244         | 5,077         | 19,200         | 1,374         | 13,485         |
| Unit 11 Shutdown                         | 480            | 63.1        | 10.3         | 5.6          | 5.0           | 0.4          | 3.5          | 30,281         | 4,928          | 2,679         | 2,400          | 172           | 1,686          |
| <b>Unit 11 Totals</b>                    | <b>4,800</b>   |             |              |              |               |              |              | <b>91,159</b>  | <b>37,753</b>  | <b>11,289</b> | <b>24,000</b>  | <b>1,643</b>  | <b>16,856</b>  |
| Unit 12 Start-Up                         | 480            | 89.8        | 30.4         | 7.4          | 5.0           | 0.2          | 3.5          | 43,111         | 14,580         | 3,533         | 2,400          | 97            | 1,686          |
| Unit 12 Normal Operations                | 3,840          | 4.6         | 4.8          | 1.3          | 5.0           | 0.4          | 3.5          | 17,768         | 18,244         | 5,077         | 19,200         | 1,374         | 13,485         |
| Unit 12 Shutdown                         | 480            | 63.1        | 10.3         | 5.6          | 5.0           | 0.4          | 3.5          | 30,281         | 4,928          | 2,679         | 2,400          | 172           | 1,686          |
| <b>Unit 12 Totals</b>                    | <b>4,800</b>   |             |              |              |               |              |              | <b>91,159</b>  | <b>37,753</b>  | <b>11,289</b> | <b>24,000</b>  | <b>1,643</b>  | <b>16,856</b>  |
| Aux Boiler (25% load)                    | 3,304          | 0.3         | 0.1          | 0.0          | 0.1           | 0.0          | 0.0          | 1,099          | 325            | 119           | 222            | 62            | 0              |
| Aux Boiler (100% load)                   | 33             | 1.3         | 0.4          | 0.1          | 0.3           | 0.1          | 0.0          | 44             | 13             | 5             | 9              | 2             | 0              |
| <b>Aux Boiler Totals</b>                 | <b>3,337</b>   |             |              |              |               |              |              | <b>1,143</b>   | <b>338</b>     | <b>124</b>    | <b>231</b>     | <b>64</b>     | <b>0</b>       |
| <b>Total Annual Emissions (lb/year)</b>  |                |             |              |              |               |              |              | <b>341,408</b> | <b>183,939</b> | <b>64,912</b> | <b>100,063</b> | <b>12,506</b> | <b>123,542</b> |
| <b>Total Annual Emissions (ton/year)</b> |                |             |              |              |               |              |              | <b>170.7</b>   | <b>92.0</b>    | <b>32.5</b>   | <b>50.0</b>    | <b>6.3</b>    | <b>61.8</b>    |



**Table 3.1A-20**  
**EI Segundo Power Facility Modification**  
**Greenhouse Gas Emissions**

| Unit             | Rated Capacity, MW | Operating Hours per year | Maximum Fuel Use, MMBtu/yr | Estimated Gross Annual MWh | Maximum Emissions, metric tonnes/yr |       |         | Estimated Emissions, metric tonnes/MWh |       |          |          |
|------------------|--------------------|--------------------------|----------------------------|----------------------------|-------------------------------------|-------|---------|--|-------|----------|----------|
|                  |                    |                          |                            |                            | CO2                                 | CH4   | N2O     | CO2                                    | CH4   | N2O      |          |
| Unit 9           | 334                | 5,456                    | 13,291,520                 | 1,822,304                  | 704,716                             | 13.29 | 1.33    | 0.00                                   | 0.387 | 7.29E-06 | 7.29E-07 |
| Unit 11          | 58                 | 4,800                    | 2,476,411                  | 278,400                    | 131,299                             | 2.48  | 0.25    | 0.00                                   | 0.472 | 8.90E-06 | 8.90E-07 |
| Unit 12          | 58                 | 4,800                    | 2,476,411                  | 278,400                    | 131,299                             | 2.48  | 0.25    | 0.00                                   | 0.472 | 8.90E-06 | 8.90E-07 |
| Auxiliary Boiler | 36 MMBH            | 3,304                    | 118,944                    | N/A                        | 6,306                               | 0.12  | 0.01    | 0.00                                   |       |          |          |
| Total            | --                 | --                       | 18,244,342                 | 2,379,104                  | 967,315                             | 18    | 2       | 0                                      | 0.407 | 7.67E-06 | 7.67E-07 |
| CO2eq            |                    |                          |                            |                            | 967,315                             | 383   | 566     | 0                                      |       |          |          |
|                  |                    |                          |                            |                            | TOTAL                               |       | 968,264 |  |       |          |          |
|                  |                    |                          |                            |                            |                                     |       | CO2eq   |  |       |          |          |

**Natural Gas GHG Emission Rates (Note 1)**

|                              | Emission Factors, kg/MMBtu |          |          |
|------------------------------|----------------------------|----------|----------|
|                              | CO2 (2)                    | CH4 (3)  | N2O (3)  |
| Natural Gas                  | 53.020                     | 1.00E-03 | 1.00E-04 |
| Global Warming Potential (4) | 1                          | 21       | 310      |
|                              |                            |          | 23,900   |

Note 1. Calculation methods and emission factors from 40 CFR 98 Subpart C

Note 2. Table C-1

Note 3. Table C-2.

Note 4. Table C-2

**Table 3.1A-21**

**El Segundo Power Facility Modification**

**Unit 9 Startup, Shutdown, Startup/Shutdown Hourly Emissions (GE Turbine)**

| Pollutant            | Startup Hour (Fast Start)    |                              | Startup Hour (Traditional)   |                              | Shutdown Hour                |                              |
|----------------------|------------------------------|------------------------------|------------------------------|------------------------------|------------------------------|------------------------------|
|                      | Max. Hour Emissions (lbs/hr) | Avg. Hour Emissions (lbs/hr) | Max. Hour Emissions (lbs/hr) | Avg. Hour Emissions (lbs/hr) | Max. Hour Emissions (lbs/hr) | Avg. Hour Emissions (lbs/hr) |
| CO                   | 158.5                        | 158.5                        | 291.0                        | 291.0                        | 322.0                        | 322.0                        |
| NOx                  | 45.0                         | 45.0                         | 62.3                         | 62.3                         | 37.5                         | 37.5                         |
| VOC                  | 17.1                         | 17.1                         | 23.3                         | 23.3                         | 34.6                         | 34.6                         |
| PM10 (1)             | 9.5                          | 9.5                          | 9.5                          | 9.5                          | 9.5                          | 9.5                          |
| SOx (1) (short-term) | 4.1                          | N/A                          | 4.1                          | N/A                          | 4.1                          | N/A                          |
| SOx (1) (long-term)  | N/A                          | 1.4                          | N/A                          | 1.4                          | N/A                          | 1.4                          |
| NH3                  | 13.4                         | 13.4                         | 13.4                         | 13.4                         | 13.4                         | 13.4                         |

Note 1. Start-ups/shutdowns do not significantly affect SOx, PM10, or NH3 emissions. Therefore, PM10, SOx, and NH3 during start-up are assumed to be equal to normal operation (average temp. peak load)

**Table 3.1A-22**

**El Segundo Power Facility Modification**

**Unit 9 CTG Hourly Emissions - Startup/Shutdown Emissions (GE Turbine)**

| CTG - Hourly Startup Emissions (Fast Start) |                |                        |                       |                        |                     |                    |                     |
|---|----------------|------------------------|-----------------------|------------------------|---------------------|--------------------|---------------------|
|   | Time (minutes) | NOx Emissions (lbs/hr) | CO Emissions (lbs/hr) | VOC Emissions (lbs/hr) | NOx Emissions (lbs) | CO Emissions (lbs) | VOC Emissions (lbs) |
| Maximum Startup Emissions                   | 30             | N/A                    | N/A                   | N/A                    | 36.0                | 153.0              | 14.0                |
| Maximum Normal Operation Emissions          | 30             | 17.9                   | 10.9                  | 6.2                    | 9.0                 | 5.5                | 3.1                 |
| Total =                                     |                |                        |                       |                        | 45.0                | 158.5              | 17.1                |

| CTG - Hourly Startup Emissions (Traditional Start) |                |                        |                       |                        |                     |                    |                     |
|--|----------------|------------------------|-----------------------|------------------------|---------------------|--------------------|---------------------|
|  | Time (minutes) | NOx Emissions (lbs/hr) | CO Emissions (lbs/hr) | VOC Emissions (lbs/hr) | NOx Emissions (lbs) | CO Emissions (lbs) | VOC Emissions (lbs) |
| Maximum Startup Emissions                          | 60             | N/A                    | N/A                   | N/A                    | 62.3                | 291.0              | 23.3                |
| Maximum Normal Operation Emissions                 | 0              | 17.9                   | 10.9                  | 6.2                    | 0.0                 | 0.0                | 0.0                 |
| Total =  |                |                        |                       |                        | 62.3                | 291.0              | 23.3                |

| CTG - Hourly Shutdown Emissions    |                |                        |                       |                        |                     |                    |                     |
|------------------------------------|----------------|------------------------|-----------------------|------------------------|---------------------|--------------------|---------------------|
|                                    | Time (minutes) | NOx Emissions (lbs/hr) | CO Emissions (lbs/hr) | VOC Emissions (lbs/hr) | NOx Emissions (lbs) | CO Emissions (lbs) | VOC Emissions (lbs) |
| Maximum Shutdown Emissions         | 30             | N/A                    | N/A                   | N/A                    | 28.5                | 316.5              | 31.5                |
| Maximum Normal Operation Emissions | 30             | 17.9                   | 10.9                  | 6.2                    | 9.0                 | 5.5                | 3.1                 |
| Total =                            |                |                        |                       |                        | 37.5                | 322.0              | 34.6                |

**Table 3.1A-23**

**El Segundo Power Facility Modification**

**Unit 11/12 Startup, Shutdown, Startup/Shutdown Hourly Emissions (Trent Turbine) (each)**

| Pollutant            | Startup Hour                 |                              | Shutdown Hour                |                              | Startup/Shutdown Hour        |                              |
|----------------------|------------------------------|------------------------------|------------------------------|------------------------------|------------------------------|------------------------------|
|                      | Max. Hour Emissions (lbs/hr) | Avg. Hour Emissions (lbs/hr) | Max. Hour Emissions (lbs/hr) | Avg. Hour Emissions (lbs/hr) | Max. Hour Emissions (lbs/hr) | Avg. Hour Emissions (lbs/hr) |
| CO                   | 89.8                         | 89.8                         | 63.1                         | 63.1                         | 148.3                        | 148.3                        |
| NOx                  | 30.4                         | 30.4                         | 10.3                         | 10.3                         | 35.9                         | 35.9                         |
| VOC                  | 7.4                          | 7.4                          | 5.6                          | 5.6                          | 11.6                         | 11.6                         |
| PM10 (1)             | 5.0                          | 5.0                          | 5.0                          | 5.0                          | 5.0                          | 5.0                          |
| SOx (1) (short-term) | 0.4                          | N/A                          | 0.4                          | N/A                          | 0.4                          | N/A                          |
| SOx (1) (long-term)  | N/A                          | 0.2                          | N/A                          | 0.2                          | N/A                          | 0.2                          |
| NH3                  | 3.5                          | 3.5                          | 3.5                          | 3.5                          | 3.5                          | 3.5                          |

Note 1. Start-ups/shutdowns do not significantly affect SOx, PM10, or NH3 emissions. Therefore, PM10, SOx, and NH3 during start-up are assumed to be equal to normal operation (average temp. peak)

**Table 3.1A-24**

**El Segundo Power Facility Modification**

**Unit 11/12 CTG Hourly Emissions - Startup/Shutdown Emissions (Trent Turbine) (each)**

| CTG - Hourly Startup Emissions (per GT) |                |                        |                       |                        |                     |                    |                     |
|---|----------------|------------------------|-----------------------|------------------------|---------------------|--------------------|---------------------|
|   | Time (minutes) | NOx Emissions (lbs/hr) | CO Emissions (lbs/hr) | VOC Emissions (lbs/hr) | NOx Emissions (lbs) | CO Emissions (lbs) | VOC Emissions (lbs) |
| Maximum Startup Emissions               | 30             | N/A                    | N/A                   | N/A                    | 28.0                | 87.5               | 6.7                 |
| Maximum Normal Operation Emissions      | 30             | 4.8                    | 4.6                   | 1.3                    | 2.4                 | 2.3                | 0.7                 |
| Total =                                 |                |                        |                       |                        | 30.4                | 89.8               | 7.4                 |

| CTG - Hourly Shutdown Emissions (per GT) |                |                        |                       |                        |                     |                    |                     |
|--|----------------|------------------------|-----------------------|------------------------|---------------------|--------------------|---------------------|
|  | Time (minutes) | NOx Emissions (lbs/hr) | CO Emissions (lbs/hr) | VOC Emissions (lbs/hr) | NOx Emissions (lbs) | CO Emissions (lbs) | VOC Emissions (lbs) |
| Maximum Shutdown Emissions               | 20             | N/A                    | N/A                   | N/A                    | 7.1                 | 60.0               | 4.7                 |
| Maximum Normal Operation Emissions       | 40             | 4.8                    | 4.6                   | 1.3                    | 3.2                 | 3.1                | 0.9                 |
| Total =                                  |                |                        |                       |                        | 10.3                | 63.1               | 5.6                 |

| CTG - Hourly Startup/Shutdown Emissions (per GT) |                |                        |                       |                        |                     |                    |                     |
|--|----------------|------------------------|-----------------------|------------------------|---------------------|--------------------|---------------------|
|  | Time (minutes) | NOx Emissions (lbs/hr) | CO Emissions (lbs/hr) | VOC Emissions (lbs/hr) | NOx Emissions (lbs) | CO Emissions (lbs) | VOC Emissions (lbs) |
| Maximum Startup Emissions                        | 30             | N/A                    | N/A                   | N/A                    | 28.0                | 87.5               | 6.7                 |
| Maximum Shutdown Emissions                       | 20             | N/A                    | N/A                   | N/A                    | 7.1                 | 60.0               | 4.7                 |
| Maximum Normal Operation Emissions               | 10             | 4.8                    | 4.6                   | 1.3                    | 0.8                 | 0.8                | 0.2                 |
| Total =  |                |                        |                       |                        | 35.9                | 148.3              | 11.6                |

Table 3.1A-25

EI Segundo Power Facility Modification  
Annual and Maximum Hourly Non-Criteria Pollutant Emissions For Unit 9

| Pollutant                       | Emission Factor(1)<br>lb/MMBtu | Emission Factor(2)<br>lb/MMscf | Unit 9 Max Firing Rate<br>MMBtu/hr | Natural Gas HHV<br>Btu/scf | Turbine Operating Hours<br>hrs/yr | Unit 9 Max Hourly Firing Rate<br>MMscf/hr | Unit 9 Annual Avg Firing Rate<br>MMscf/yr | Unit 9 Max. Hourly Emissions<br>lbs/hr | Unit 9 Annual Emissions<br>tons/yr | Hourly Emission Rate Per Turbine<br>g/sec | Annual Emission Rate Per Turbine<br>g/sec |
|---------------------------------|--------------------------------|--------------------------------|------------------------------------|----------------------------|-----------------------------------|---|---|--|------------------------------------|---|---|
| Ammonia                         | (3)                            | (3)                            | 2,436.1                            | 1,030                      | 5,406                             | 2.37                                      | 12,908                                    | 1.34E+01                               | 44.91                              | 1.69E+00                                  | 1.29E+00                                  |
| Propylene                       |                                | 7.71E-01                       | 2,436.1                            | 1,030                      | 5,406                             | 2.37                                      | 12,908                                    | 1.82E+00                               | 4.98                               | 2.30E-01                                  | 1.43E-01                                  |
| <b>Hazardous Air Pollutants</b> |                                |                                |                                    |                            |                                   |   |   |  |                                    |   |   |
| Acetaldehyde                    | 4.00E-05                       | 4.08E-02                       | 2,436.1                            | 1,030                      | 5,406                             | 2.37                                      | 12,908                                    | 9.65E-02                               | 0.26                               | 1.22E-02                                  | 7.58E-03                                  |
| Acrolein                        | 6.40E-06                       | 6.53E-03                       | 2,436.1                            | 1,030                      | 5,406                             | 2.37                                      | 12,908                                    | 1.54E-02                               | 0.04                               | 1.95E-03                                  | 1.21E-03                                  |
| Benzene                         | 1.20E-05                       | 1.22E-02                       | 2,436.1                            | 1,030                      | 5,406                             | 2.37                                      | 12,908                                    | 2.90E-02                               | 0.08                               | 3.65E-03                                  | 2.27E-03                                  |
| 1,3-Butadiene                   | 4.30E-07                       | 4.39E-04                       | 2,436.1                            | 1,030                      | 5,406                             | 2.37                                      | 12,908                                    | 1.04E-03                               | 0.00                               | 1.31E-04                                  | 8.14E-05                                  |
| Ethylbenzene                    | 3.20E-05                       | 3.26E-02                       | 2,436.1                            | 1,030                      | 5,406                             | 2.37                                      | 12,908                                    | 7.72E-02                               | 0.21                               | 9.73E-03                                  | 6.06E-03                                  |
| Formaldehyde                    | 3.60E-04                       | 3.67E-01                       | 2,436.1                            | 1,030                      | 5,406                             | 2.37                                      | 12,908                                    | 8.69E-01                               | 2.37                               | 1.09E-01                                  | 6.82E-02                                  |
| Hexane                          | --                             | 2.59E-01                       | 2,436.1                            | 1,030                      | 5,406                             | 2.37                                      | 12,908                                    | 6.13E-01                               | 1.67                               | 7.72E-02                                  | 4.81E-02                                  |
| Naphthalene                     | 1.30E-06                       | 1.33E-03                       | 2,436.1                            | 1,030                      | 5,406                             | 2.37                                      | 12,908                                    | 3.14E-03                               | 0.01                               | 3.95E-04                                  | 2.46E-04                                  |
| Anthracene                      | --                             | 3.38E-05                       | 2,436.1                            | 1,030                      | 5,406                             | 2.37                                      | 12,908                                    | 8.00E-05                               | 0.00                               | 1.01E-05                                  | 6.28E-06                                  |
| Benzo(a)anthracene              | --                             | 2.26E-05                       | 2,436.1                            | 1,030                      | 5,406                             | 2.37                                      | 12,908                                    | 5.35E-05                               | 0.00                               | 6.74E-06                                  | 4.20E-06                                  |
| Benzo(a)pyrene                  | --                             | 1.39E-05                       | 2,436.1                            | 1,030                      | 5,406                             | 2.37                                      | 12,908                                    | 3.29E-05                               | 0.00                               | 4.14E-06                                  | 2.58E-06                                  |
| Benzo(b)fluoranthrene           | --                             | 1.13E-05                       | 2,436.1                            | 1,030                      | 5,406                             | 2.37                                      | 12,908                                    | 2.67E-05                               | 0.00                               | 3.37E-06                                  | 2.10E-06                                  |
| Benzo(k)fluoranthrene           | --                             | 1.10E-05                       | 2,436.1                            | 1,030                      | 5,406                             | 2.37                                      | 12,908                                    | 2.60E-05                               | 0.00                               | 3.28E-06                                  | 2.04E-06                                  |
| Chrysene                        | --                             | 2.52E-05                       | 2,436.1                            | 1,030                      | 5,406                             | 2.37                                      | 12,908                                    | 5.96E-05                               | 0.00                               | 7.51E-06                                  | 4.68E-06                                  |
| Dibenz(a,h)anthracene           | --                             | 2.35E-05                       | 2,436.1                            | 1,030                      | 5,406                             | 2.37                                      | 12,908                                    | 5.56E-05                               | 0.00                               | 7.01E-06                                  | 4.36E-06                                  |
| Indeno(1,2,3-cd)pyrene          | --                             | 2.35E-05                       | 2,436.1                            | 1,030                      | 5,406                             | 2.37                                      | 12,908                                    | 5.56E-05                               | 0.00                               | 7.01E-06                                  | 4.36E-06                                  |
| Propylene oxide                 | 2.90E-05                       | 2.96E-02                       | 2,436.1                            | 1,030                      | 5,406                             | 2.37                                      | 12,908                                    | 7.00E-02                               | 0.19                               | 8.82E-03                                  | 5.49E-03                                  |
| Toluene                         | 1.30E-04                       | 1.33E-01                       | 2,436.1                            | 1,030                      | 5,406                             | 2.37                                      | 12,908                                    | 3.14E-01                               | 0.86                               | 3.95E-02                                  | 2.46E-02                                  |
| Xylene                          | 6.40E-05                       | 6.53E-02                       | 2,436.1                            | 1,030                      | 5,406                             | 2.37                                      | 12,908                                    | 1.54E-01                               | 0.42                               | 1.95E-02                                  | 1.21E-02                                  |

Note 1. All factors except PAHs, hexane, and propylene from AP-42, Table 3.1-3, 4/00. Individual PAHs, hexane and propylene are CATEF mean results as AP-42 does not include factors for these compounds.

Note 2. Emission factor converted to lb/MMSCF by multiplying factor in lb/MMBtu by EPA default heating value of 1020 BTU/scf.

Note 3. Based on 5 ppm ammonia slip from SCR system.

Table 3.1A-26

EI Segundo Power Facility Modification  
Annual and Maximum Hourly Non-Criteria Pollutant Emissions For Units 11/12

| Pollutant                       | Emission Factor(1) lb/MMBtu | Emission Factor(1) lb/MMscf | Unit 11/12 Max Firing Rate MMBtu/hr | Natural Gas HHV Btu/scf | Turbine Operating Hours hrs/yr | Unit 11/12 Max Hourly Firing Rate MMBtu/hr | Unit 11/12 Annual Avg Firing Rate MMBtu/yr | Unit 11/12 Max. Hourly Emissions lbs/hr (each) | Unit 11/12 Annual Emissions tons/yr (each) | Hourly Emission Rate Per Turbine g/sec (each) | Annual Emission Rate Per Turbine g/sec |
|---------------------------------|-----------------------------|-----------------------------|-------------------------------------|-------------------------|--------------------------------|--|--|--|--|---|--|
| Ammonia                         | (3)                         | (3)                         | 515.9                               | 1,030                   | 4,800                          | 0.50                                       | 2,405                                      | 1.99E+00                                       | 8.43                                       | 2.51E-01                                      | 2.42E-01                               |
| Propylene                       |                             | 7.71E-01                    | 515.9                               | 1,030                   | 4,800                          | 0.50                                       | 2,405                                      | 3.86E-01                                       | 0.93                                       | 4.87E-02                                      | 2.67E-02                               |
| <b>Hazardous Air Pollutants</b> |                             |                             |                                     |                         |                                |  |  |  |  |   |  |
| Acetaldehyde                    | 4.00E-05                    | 4.08E-02                    | 515.9                               | 1,030                   | 4,800                          | 0.50                                       | 2,405                                      | 2.04E-02                                       | 0.05                                       | 2.58E-03                                      | 1.41E-03                               |
| Acrolein                        | 6.40E-06                    | 6.53E-03                    | 515.9                               | 1,030                   | 4,800                          | 0.50                                       | 2,405                                      | 3.27E-03                                       | 0.01                                       | 4.12E-04                                      | 2.26E-04                               |
| Benzene                         | 1.20E-05                    | 1.22E-02                    | 515.9                               | 1,030                   | 4,800                          | 0.50                                       | 2,405                                      | 6.13E-03                                       | 0.01                                       | 7.73E-04                                      | 4.23E-04                               |
| 1,3-Butadiene                   | 4.30E-07                    | 4.39E-04                    | 515.9                               | 1,030                   | 4,800                          | 0.50                                       | 2,405                                      | 2.20E-04                                       | 0.00                                       | 2.77E-05                                      | 1.52E-05                               |
| Ethylbenzene                    | 3.20E-05                    | 3.26E-02                    | 515.9                               | 1,030                   | 4,800                          | 0.50                                       | 2,405                                      | 1.64E-02                                       | 0.04                                       | 2.06E-03                                      | 1.13E-03                               |
| Formaldehyde                    | 3.60E-04                    | 3.67E-01                    | 515.9                               | 1,030                   | 4,800                          | 0.50                                       | 2,405                                      | 1.84E-01                                       | 0.44                                       | 2.32E-02                                      | 1.27E-02                               |
| Hexane                          | --                          | 2.59E-01                    | 515.9                               | 1,030                   | 4,800                          | 0.50                                       | 2,405                                      | 1.30E-01                                       | 0.31                                       | 1.64E-02                                      | 8.96E-03                               |
| Naphthalene                     | 1.30E-06                    | 1.33E-03                    | 515.9                               | 1,030                   | 4,800                          | 0.50                                       | 2,405                                      | 6.64E-04                                       | 0.00                                       | 8.37E-05                                      | 4.59E-05                               |
| Anthracene                      | --                          | 3.38E-05                    | 515.9                               | 1,030                   | 4,800                          | 0.50                                       | 2,405                                      | 1.69E-05                                       | 0.00                                       | 2.13E-06                                      | 1.17E-06                               |
| Benzo(a)anthracene              | --                          | 2.26E-05                    | 515.9                               | 1,030                   | 4,800                          | 0.50                                       | 2,405                                      | 1.13E-05                                       | 0.00                                       | 1.43E-06                                      | 7.82E-07                               |
| Benzo(a)pyrene                  | --                          | 1.39E-05                    | 515.9                               | 1,030                   | 4,800                          | 0.50                                       | 2,405                                      | 6.96E-06                                       | 0.00                                       | 8.78E-07                                      | 4.81E-07                               |
| Benzo(b)fluoranthrene           | --                          | 1.13E-05                    | 515.9                               | 1,030                   | 4,800                          | 0.50                                       | 2,405                                      | 5.66E-06                                       | 0.00                                       | 7.13E-07                                      | 3.91E-07                               |
| Benzo(k)fluoranthrene           | --                          | 1.10E-05                    | 515.9                               | 1,030                   | 4,800                          | 0.50                                       | 2,405                                      | 5.51E-06                                       | 0.00                                       | 6.94E-07                                      | 3.81E-07                               |
| Chrysene                        | --                          | 2.52E-05                    | 515.9                               | 1,030                   | 4,800                          | 0.50                                       | 2,405                                      | 1.26E-05                                       | 0.00                                       | 1.59E-06                                      | 8.72E-07                               |
| Dibenz(a,h)anthracene           | --                          | 2.35E-05                    | 515.9                               | 1,030                   | 4,800                          | 0.50                                       | 2,405                                      | 1.18E-05                                       | 0.00                                       | 1.48E-06                                      | 8.13E-07                               |
| Indeno(1,2,3-cd)pyrene          | --                          | 2.35E-05                    | 515.9                               | 1,030                   | 4,800                          | 0.50                                       | 2,405                                      | 1.18E-05                                       | 0.00                                       | 1.48E-06                                      | 8.13E-07                               |
| Propylene oxide                 | 2.90E-05                    | 2.96E-02                    | 515.9                               | 1,030                   | 4,800                          | 0.50                                       | 2,405                                      | 1.48E-02                                       | 0.04                                       | 1.87E-03                                      | 1.02E-03                               |
| Toluene                         | 1.30E-04                    | 1.33E-01                    | 515.9                               | 1,030                   | 4,800                          | 0.50                                       | 2,405                                      | 6.64E-02                                       | 0.16                                       | 8.37E-03                                      | 4.59E-03                               |
| Xylene                          | 6.40E-05                    | 6.53E-02                    | 515.9                               | 1,030                   | 4,800                          | 0.50                                       | 2,405                                      | 3.27E-02                                       | 0.08                                       | 4.12E-03                                      | 2.26E-03                               |

Note 1. All factors except PAHs, hexane, and propylene from AP-42, Table 3.1-3, 4/00. Individual PAHs, hexane and propylene are CATEF mean results as AP-42 does not include factors for these compounds.

Note 2. Emission factor converted to lb/MMSCF by multiplying factor in lb/MMBtu by EPA default heating value of 1020 BTU/scf.

Note 3. Based on 5 ppm ammonia slip from SCR system.

**Table 3.1A-27**  
**El Segundo Power Facility Modification**  
**Annual and Maximum Hourly Non-Criteria Pollutant Emissions For Auxiliary Boiler**

| Pollutant                       | Emission Factor(1) lb/MMscf | Aux Boiler Max Firing Rate MMBtu/hr | Natural Gas HHV Btu/scf | Turbine Operating Hours hrs/yr | Aux Boiler Max Hourly Firing Rate MMscf/hr | Aux Boiler Annual Avg Firing Rate MMscf/yr | Aux Boiler Max. Hourly Emissions lbs/hr | Aux Boiler Annual Emissions tons/yr | Hourly Emission Rate g/sec | Annual Emission Rate g/sec |
|---------------------------------|-----------------------------|-------------------------------------|-------------------------|--------------------------------|--|--|---|-------------------------------------|----------------------------|----------------------------|
| Propylene                       | 5.30E-01                    | 36                                  | 1,030                   | 8,760                          | 0.03                                       | 306  | 1.85E-02                                | 0.08                                | 2.33E-03                   | 2.33E-03                   |
| <b>Hazardous Air Pollutants</b> |                             |                                     |                         |                                |  |  |   |                                     |                            |                            |
| Acetaldehyde                    | 3.10E-03                    | 36                                  | 1,030                   | 8,760                          | 0.03                                       | 306  | 1.08E-04                                | 0.00                                | 1.37E-05                   | 1.37E-05                   |
| Acrolein                        | 2.70E-03                    | 36                                  | 1,030                   | 8,760                          | 0.03                                       | 306  | 9.44E-05                                | 0.00                                | 1.19E-05                   | 1.19E-05                   |
| Benzene                         | 5.80E-03                    | 36                                  | 1,030                   | 8,760                          | 0.03                                       | 306  | 2.03E-04                                | 0.00                                | 2.55E-05                   | 2.55E-05                   |
| Ethylbenzene                    | 6.90E-03                    | 36                                  | 1,030                   | 8,760                          | 0.03                                       | 306  | 2.41E-04                                | 0.00                                | 3.04E-05                   | 3.04E-05                   |
| Formaldehyde                    | 1.23E-02                    | 36                                  | 1,030                   | 8,760                          | 0.03                                       | 306  | 4.30E-04                                | 0.00                                | 5.42E-05                   | 5.42E-05                   |
| Hexane                          | 4.60E-03                    | 36                                  | 1,030                   | 8,760                          | 0.03                                       | 306  | 1.61E-04                                | 0.00                                | 2.03E-05                   | 2.03E-05                   |
| Naphthalene                     | 3.00E-04                    | 36                                  | 1,030                   | 8,760                          | 0.03                                       | 306  | 1.05E-05                                | 0.00                                | 1.32E-06                   | 1.32E-06                   |
| PAHs (excluding Naphthalene)    | 4.00E-04                    | 36                                  | 1,030                   | 8,760                          | 0.03                                       | 306  | 1.40E-05                                | 0.00                                | 1.76E-06                   | 1.76E-06                   |
| Toluene                         | 2.65E-02                    | 36                                  | 1,030                   | 8,760                          | 0.03                                       | 306  | 9.26E-04                                | 0.00                                | 1.17E-04                   | 1.17E-04                   |
| Xylene                          | 1.97E-02                    | 36                                  | 1,030                   | 8,760                          | 0.03                                       | 306  | 6.89E-04                                | 0.00                                | 8.68E-05                   | 8.68E-05                   |

Note 1. From Ventura County APCD AB2588 Combustion Emission Factors (May 17, 2001) natural gas fired external combustion equipment 10-100 MMBtu/Hr.

**Table 3.1A-28  
Emission Factors**

| Emission Factors During Non-Commissioning Period |                |                            |                           |                     |               |                |                |                 |                |
|--|----------------|----------------------------|---------------------------|---------------------|---------------|----------------|----------------|-----------------|----------------|
| Operating Condition 3                            | Hours per Year | Hourly Fuel Use (MMBtu/hr) | Natural Gas HHV (Btu/scf) | Fuel Use (MMscf/yr) | CO (lbs/year) | NOX (lbs/year) | VOC (lbs/year) | PM10 (lbs/year) | SOX (lbs/year) |
| Unit 9 Start-Up (fast)                           | 150            | 1,257                      | 1,030                     | 183                 | 23,769        | 6,746          | 2,561          | 1,425           | 204            |
| Unit 9 Start-Up (traditional)                    | 50             | 1,257                      | 1,030                     | 61                  | 14,550        | 3,113          | 1,163          | 475             | 68             |
| Unit 9 Normal Operations                         | 5,056          | 2,055                      | 1,030                     | 10,089              | 55,234        | 90,742         | 31,562         | 48,032          | 8,544          |
| Unit 9 Shutdown                                  | 200            | 1,257                      | 1,030                     | 244                 | 64,392        | 7,495          | 6,924          | 1,900           | 338            |
| Unit 9 Totals                                    | 5,456          |                            |                           | 10,577              | 157,946       | 108,095        | 42,210         | 51,832          | 9,155          |
| Unit 11 Start-Up                                 | 480            | 516                        | 1,030                     | 240                 | 43,111        | 14,580         | 3,533          | 2,400           | 97             |
| Unit 11 Normal Operations                        | 3,840          | 516                        | 1,030                     | 1,924               | 17,768        | 18,244         | 5,077          | 19,200          | 1,374          |
| Unit 11 Shutdown                                 | 480            | 516                        | 1,030                     | 240                 | 30,281        | 4,928          | 2,679          | 2,400           | 172            |
| Unit 11 Totals                                   | 4,800          |                            |                           | 2,405               | 91,159        | 37,753         | 11,289         | 24,000          | 1,643          |
| Unit 12 Start-Up                                 | 480            | 516                        | 1,030                     | 240                 | 43,111        | 14,580         | 3,533          | 2,400           | 97             |
| Unit 12 Normal Operations                        | 3,840          | 516                        | 1,030                     | 1,924               | 17,768        | 18,244         | 5,077          | 19,200          | 1,374          |
| Unit 12 Shutdown                                 | 480            | 516                        | 1,030                     | 240                 | 30,281        | 4,928          | 2,679          | 2,400           | 172            |
| Unit 12 Totals                                   | 4,800          |                            |                           | 2,405               | 91,159        | 37,753         | 11,289         | 24,000          | 1,643          |
| Aux Boiler (25% load)                            | 3,304          | 9                          | 1,030                     | 29                  | 1,099         | 325            | 119            | 222             | 62             |
| Aux Boiler (100% load)                           | 33             | 36                         | 1,030                     | 1                   | 44            | 13             | 5              | 9               | 2              |
| Aux Boiler Totals                                | 3,337          |                            |                           | 30                  | 1,143         | 338            | 124            | 231             | 64             |

|                               | CO      | NOX     | VOC    | PM10   | SOX    |
|-------------------------------|---------|---------|--------|--------|--------|
| <b>Unit 9</b>                 |         |         |        |        |        |
| Annual Emissions (lbs/yr) =   | 157,946 | 108,095 | 42,210 | 51,832 | 9,155  |
| Annual Fuel Use (MMscf/yr) =  | 10,577  | 10,577  | 10,577 | 10,577 | 10,577 |
| Emission Factor (lbs/MMscf) = | 14.93   | 10.22   | 3.99   | 4.90   | 0.87   |
| <b>Unit 11</b>                |         |         |        |        |        |
| Annual Emissions (lbs/yr) =   | 91,159  | 37,753  | 11,289 | 24,000 | 1,643  |
| Annual Fuel Use (MMscf/yr) =  | 2,405   | 2,405   | 2,405  | 2,405  | 2,405  |
| Emission Factor (lbs/MMscf) = | 37.90   | 15.70   | 4.69   | 9.98   | 0.68   |
| <b>Unit 12</b>                |         |         |        |        |        |
| Annual Emissions (lbs/yr) =   | 91,159  | 37,753  | 11,289 | 24,000 | 1,643  |
| Annual Fuel Use (MMscf/yr) =  | 2,405   | 2,405   | 2,405  | 2,405  | 2,405  |
| Emission Factor (lbs/MMscf) = | 37.90   | 15.70   | 4.69   | 9.98   | 0.68   |
| <b>Aux Boiler</b>             |         |         |        |        |        |
| Annual Emissions (lbs/yr) =   | 1,143   | 338     | 124    | 231    | 64     |
| Annual Fuel Use (MMscf/yr) =  | 30      | 30      | 30     | 30     | 30     |
| Emission Factor (lbs/MMscf) = | 38.05   | 11.25   | 4.12   | 7.67   | 2.14   |

**APPENDIX 3.1B – MODELING SUPPORT DATA**



**Table 3.1B-1**

**El Segundo Power Facility Modification  
Screening Modeling Inputs  
Data For GE Turbine (Unit 9)**

| Case #  | Case               | Stack Height<br>meters | Stack Diam<br>meters | Stack flow<br>m3/sec | Stack Vel<br>m/sec | Stack Temp<br>deg K | NOx<br>g/sec | CO<br>g/sec | PM10<br>g/sec | SOx<br>g/sec |
|---------|--------------------|------------------------|----------------------|----------------------|--------------------|---------------------|--------------|-------------|---------------|--------------|
| Case 10 | Hot Peak           | 64.008                 | 6.096                | 596.975              | 20.451             | 396.594             | 2.1552       | 1.3119      | 1.1970        | 0.6088       |
| Case 11 | Hot Base (cooler)  | 64.008                 | 6.096                | 592.962              | 20.314             | 395.928             | 1.9073       | 1.1610      | 1.1970        | 0.5388       |
| Case 13 | Hot Base           | 64.008                 | 6.096                | 572.328              | 19.607             | 394.317             | 1.8243       | 1.1105      | 1.1970        | 0.5153       |
| Case 14 | Hot Low            | 64.008                 | 6.096                | 368.353              | 12.619             | 376.428             | 1.1538       | 0.7023      | 1.1970        | 0.3259       |
| Case 5  | Mild Peak          | 64.008                 | 6.096                | 596.210              | 20.425             | 391.150             | 2.1885       | 1.3322      | 1.1970        | 0.6182       |
| Case 6  | Mild Base (cooler) | 64.008                 | 6.096                | 594.113              | 20.353             | 391.594             | 1.9426       | 1.1825      | 1.1970        | 0.5488       |
| Case 8  | Mild Base          | 64.008                 | 6.096                | 583.156              | 19.978             | 390.706             | 1.8894       | 1.1501      | 1.1970        | 0.5337       |
| Case 9  | Mild Low           | 64.008                 | 6.096                | 362.250              | 12.410             | 371.261             | 1.1666       | 0.7101      | 1.1970        | 0.3295       |
| Case 1  | Cold Peak          | 64.008                 | 6.096                | 583.728              | 19.997             | 376.928             | 2.2614       | 1.3765      | 1.1970        | 0.6388       |
| Case 2  | Cold Base          | 64.008                 | 6.096                | 592.872              | 20.311             | 384.594             | 2.0124       | 1.2249      | 1.1970        | 0.5684       |
| Case 3  | Cold Low           | 64.008                 | 6.096                | 365.437              | 12.519             | 368.817             | 1.2241       | 0.7451      | 1.1970        | 0.3458       |

**Table 3.1B-2**

**El Segundo Power Facility Modification  
Screening Modeling Inputs  
Data For Trent Turbines (Unit 11 and Unit 12)**

| Case #     | Case               | Stack Height<br>meters | Stack Diam<br>meters | Stack flow<br>m3/sec | Stack Vel<br>m/sec | Stack Temp<br>deg K | NOx<br>g/sec | CO<br>g/sec | PM10<br>g/sec | SOx<br>g/sec |
|------------|--------------------|------------------------|----------------------|----------------------|--------------------|---------------------|--------------|-------------|---------------|--------------|
| Case 1a    | Hot Base (cooler)  | 45.72                  | 3.38328              | 326.521659           | 36.31526375        | 709.7611111         | 0.5802895    | 0.565151548 | 0.63          | 0.131134204  |
| Case 1b    | Hot Base           | 45.72                  | 3.38328              | 284.386978           | 31.62910589        | 734.5944444         | 0.4710548    | 0.458766451 | 0.63          | 0.106449276  |
| Case 2-55% | Hot Low            | 45.72                  | 3.38328              | 216.487571           | 24.07743257        | 724.4277778         | 0.3389895    | 0.330146268 | 0.63          | 0.07660506   |
| Case 3a    | Mild Base (cooler) | 45.72                  | 3.38328              | 331.222512           | 36.83808577        | 704.7611111         | 0.5986367    | 0.583020077 | 0.63          | 0.135280305  |
| Case 3b    | Mild Base          | 45.72                  | 3.38328              | 295.874061           | 32.90668248        | 725.0944444         | 0.4987218    | 0.485711632 | 0.63          | 0.112701466  |
| Case 4-55% | Mild Low           | 45.72                  | 3.38328              | 222.726475           | 24.77131448        | 713.3166667         | 0.3539693    | 0.344735359 | 0.63          | 0.07999022   |
| Case 5     | Cold Base          | 45.72                  | 3.38328              | 333.753433           | 37.11957114        | 699.0388889         | 0.5923906    | 0.576936957 | 0.63          | 0.133868816  |
| Case 6-55% | Cold Low           | 45.72                  | 3.38328              | 241.949436           | 26.90926422        | 664.5388889         | 0.3913099    | 0.38110186  | 0.63          | 0.088428474  |

**Table 3.1B-3**

**El Segundo Power Facility Modification  
Screening Modeling Impacts (ug/m3)  
GE Turbine (Unit 9)**

|         | Nox_1_HR           | SO2_1_HR | CO_1_HR | SO2_3_HR | CO_8_HR | SO2_24_HR | PM_24_Hr | NOx_Annual | SO2_Annual | PM_Annual |
|---------|--------------------|----------|---------|----------|---------|-----------|----------|------------|------------|-----------|
| Case 10 | Hot Peak           | 2.20     | 0.62    | 1.3      | 0.5     | 0.9       | 0.2      | 0.3116     | 0.2240     | 0.0633    |
| Case 11 | Hot Base (cooler)  | 1.95     | 0.55    | 1.2      | 0.4     | 0.8       | 0.1      | 0.3137     | 0.2002     | 0.0566    |
| Case 13 | Hot Base           | 1.90     | 0.54    | 1.2      | 0.4     | 0.8       | 0.1      | 0.3277     | 0.1998     | 0.0564    |
| Case 14 | Hot Low            | 1.58     | 0.45    | 1.0      | 0.4     | 0.8       | 0.2      | 0.5564     | 0.2091     | 0.0591    |
| Case 5  | Mild Peak          | 2.25     | 0.63    | 1.4      | 0.5     | 0.9       | 0.2      | 0.3202     | 0.2345     | 0.0662    |
| Case 6  | Mild Base (cooler) | 2.00     | 0.56    | 1.2      | 0.5     | 0.8       | 0.1      | 0.3205     | 0.2083     | 0.0588    |
| Case 8  | Mild Base          | 1.96     | 0.55    | 1.2      | 0.5     | 0.8       | 0.1      | 0.3281     | 0.2072     | 0.0585    |
| Case 9  | Mild Low           | 1.66     | 0.47    | 1.0      | 0.4     | 0.8       | 0.2      | 0.5849     | 0.2215     | 0.0626    |
| Case 1  | Cold Peak          | 2.39     | 0.68    | 1.5      | 0.6     | 1.0       | 0.2      | 0.3565     | 0.2689     | 0.0759    |
| Case 2  | Cold Base          | 2.09     | 0.59    | 1.3      | 0.5     | 0.9       | 0.2      | 0.3345     | 0.2249     | 0.0635    |
| Case 3  | Cold Low           | 1.75     | 0.49    | 1.1      | 0.5     | 0.9       | 0.2      | 0.5904     | 0.2344     | 0.0662    |

**Table 3.1B-4**

**El Segundo Power Facility Modification**

**Screening Modeling Impacts**

**Combined Impacts from the Two Trent Turbines (Unit 11 and Unit 12)**

|            | Nox_1_HR | SO2_1_HR | CO_1_HR | SO2_3_HR | CO_8_HR | SO2_24_HR | PM_24_Hr | NOx_Annual | SO2_Annual | PM_Annual |
|------------|----------|----------|---------|----------|---------|-----------|----------|------------|------------|-----------|
| Case 1a    | 1.70     | 0.38     | 1.65    | 0.28     | 0.94    | 0.086     | 0.414    | 0.136      | 0.033      | 0.16      |
| Case 1b    | 1.46     | 0.33     | 1.43    | 0.25     | 0.85    | 0.080     | 0.471    | 0.134      | 0.030      | 0.18      |
| Case 2-55% | 1.26     | 0.29     | 1.23    | 0.23     | 0.78    | 0.077     | 0.630    | 0.127      | 0.029      | 0.24      |
| Case 3a    | 1.74     | 0.39     | 1.69    | 0.28     | 0.96    | 0.088     | 0.409    | 0.148      | 0.033      | 0.16      |
| Case 3b    | 1.52     | 0.34     | 1.48    | 0.26     | 0.88    | 0.081     | 0.455    | 0.137      | 0.031      | 0.17      |
| Case 4-55% | 1.30     | 0.29     | 1.27    | 0.24     | 0.81    | 0.078     | 0.618    | 0.130      | 0.029      | 0.23      |
| Case 5     | 1.72     | 0.39     | 1.67    | 0.28     | 0.94    | 0.087     | 0.408    | 0.146      | 0.033      | 0.16      |
| Case 6-55% | 1.39     | 0.31     | 1.36    | 0.25     | 0.86    | 0.083     | 0.593    | 0.138      | 0.031      | 0.22      |

**Table 3.1B-5  
El Segundo Power Facility Modification  
Stack Parameters and Emission Rates for Refined Modeling**

Modeling: Hourly impacts (Unit 9 S/U)

| Case #  | Case                          | Stack Height<br>meters | Stack Diam<br>meters | Stack flow<br>m3/sec | Stack Vel<br>m/sec | Stack Temp<br>deg K | NOx<br>g/sec | CO<br>g/sec | PM10<br>g/sec | SOx<br>g/sec |
|---------|-------------------------------|------------------------|----------------------|----------------------|--------------------|---------------------|--------------|-------------|---------------|--------------|
| Unit 9  | SU                            | 64.0                   | 6.1                  | 362.25               | 12.410             | 371.261             | 10.3038      | 75.8568     | N/A           | 0.6388       |
| Unit 11 | Case 3a<br>Mild Base (cooler) | 45.7                   | 3.4                  | 331.22               | 36.838             | 704.761             | 0.5986       | 0.5830      | N/A           | 0.1353       |
| Unit 12 | Case 3a<br>Mild Base (cooler) | 45.7                   | 3.4                  | 331.22               | 36.838             | 704.761             | 0.5986       | 0.5830      | N/A           | 0.1353       |
| Boiler  | N/A                           | N/A                    | N/A                  | N/A                  | N/A                | N/A                 | N/A          | N/A         | N/A           | N/A          |

Modeling: Hourly impacts (Unit 11/12 S/U)

| Case #  | Case                | Stack Height<br>meters | Stack Diam<br>meters | Stack flow<br>m3/sec | Stack Vel<br>m/sec | Stack Temp<br>deg K | NOx<br>g/sec | CO<br>g/sec | PM10<br>g/sec | SOx<br>g/sec |
|---------|---------------------|------------------------|----------------------|----------------------|--------------------|---------------------|--------------|-------------|---------------|--------------|
| Unit 9  | Case 1<br>Cold Peak | 64.0                   | 6.1                  | 583.7                | 19.997             | 376.928             | 2.2614       | 1.3765      | N/A           | 0.6388       |
| Unit 11 | SU                  | 45.7                   | 3.4                  | 241.9                | 26.909             | 664.539             | 4.5224       | 18.6822     | N/A           | 0.1353       |
| Unit 12 | SU                  | 45.7                   | 3.4                  | 241.9                | 26.909             | 664.539             | 4.5224       | 18.6822     | N/A           | 0.1353       |
| Boiler  | N/A                 | N/A                    | N/A                  | N/A                  | N/A                | N/A                 | N/A          | N/A         | N/A           | N/A          |

Modeling: Hourly impacts (All units S/U)

| Case #  | Case | Stack Height<br>meters | Stack Diam<br>meters | Stack flow<br>m3/sec | Stack Vel<br>m/sec | Stack Temp<br>deg K | NOx<br>g/sec | CO<br>g/sec | PM10<br>g/sec | SOx<br>g/sec |
|---------|------|------------------------|----------------------|----------------------|--------------------|---------------------|--------------|-------------|---------------|--------------|
| Unit 9  | SU   | 64.0                   | 6.1                  | 362.25               | 12.410             | 371.261             | 10.3038      | 75.8568     | N/A           | 0.6388       |
| Unit 11 | SU   | 45.7                   | 3.4                  | 241.9                | 26.909             | 664.539             | 4.5224       | 18.6822     | N/A           | 0.1353       |
| Unit 12 | SU   | 45.7                   | 3.4                  | 241.9                | 26.909             | 664.539             | 4.5224       | 18.6822     | N/A           | 0.1353       |
| Boiler  | N/A  | N/A                    | N/A                  | N/A                  | N/A                | N/A                 | N/A          | N/A         | N/A           | N/A          |

Modeling: 3-hour, 8-hour, Daily impacts

| Case #  | Case                          | Stack Height<br>meters | Stack Diam<br>meters | Stack flow<br>m3/sec | Stack Vel<br>m/sec | Stack Temp<br>deg K | NOx<br>g/sec | CO<br>g/sec | PM10<br>g/sec | SOx<br>g/sec |
|---------|-------------------------------|------------------------|----------------------|----------------------|--------------------|---------------------|--------------|-------------|---------------|--------------|
| Unit 9  | Case 1<br>Cold Peak           | 64.0                   | 6.1                  | 583.7                | 19.997             | 376.928             | N/A          | 10.6865     | separate      | 0.6388       |
| Unit 11 | Case 3a<br>Mild Base (cooler) | 45.7                   | 3.4                  | 331.2                | 36.838             | 704.761             | N/A          | 2.8454      | separate      | 0.1353       |
| Unit 12 | Case 3a<br>Mild Base (cooler) | 45.7                   | 3.4                  | 331.2                | 36.838             | 704.761             | N/A          | 2.8454      | separate      | 0.1353       |
| Boiler  | N/A                           | N/A                    | N/A                  | N/A                  | N/A                | N/A                 | N/A          | N/A         | separate      | N/A          |

**Table 3.1B5 (cont.)**

Modeling: Daily impacts (PM10)

|         | Case #     | Case     | Stack Height<br>meters | Stack Diam<br>meters | Stack flow<br>m3/sec | Stack Vel<br>m/sec | Stack Temp<br>deg K | NOx<br>g/sec | CO<br>g/sec | PM10<br>g/sec | SOx<br>g/sec |
|---------|------------|----------|------------------------|----------------------|----------------------|--------------------|---------------------|--------------|-------------|---------------|--------------|
| Unit 9  | Case 3     | Cold Low | 64.0                   | 6.1                  | 365.4                | 12.519             | 368.817             | N/A          | N/A         | 1.1970        | N/A          |
| Unit 11 | Case 2-55% | Hot Low  | 45.7                   | 3.4                  | 216.5                | 24.077             | 724.428             | N/A          | N/A         | 0.6300        | N/A          |
| Unit 12 | Case 2-55% | Hot Low  | 45.7                   | 3.4                  | 216.5                | 24.077             | 724.428             | N/A          | N/A         | 0.6300        | N/A          |
| Boiler  | N/A        | N/A      | N/A                    | N/A                  | N/A                  | N/A                | N/A                 | N/A          | N/A         | N/A           | N/A          |

Modeling: Annual

|         | Case #  | Case               | Stack Height<br>meters | Stack Diam<br>meters | Stack flow<br>m3/sec | Stack Vel<br>m/sec | Stack Temp<br>deg K | NOx<br>g/sec | CO<br>g/sec | PM10<br>g/sec | SOx<br>g/sec |
|---------|---------|--------------------|------------------------|----------------------|----------------------|--------------------|---------------------|--------------|-------------|---------------|--------------|
| Unit 9  | Case 1  | Cold Peak          | 64.0                   | 6.1                  | 583.7                | 19.997             | 376.928             | 1.5527       | N/A         | N/A           | 0.1315       |
| Unit 11 | Case 3a | Mild Base (cooler) | 45.7                   | 3.4                  | 331.2                | 36.838             | 704.761             | 0.5423       | N/A         | N/A           | 0.0236       |
| Unit 12 | Case 3a | Mild Base (cooler) | 45.7                   | 3.4                  | 331.2                | 36.838             | 704.761             | 0.5423       | N/A         | N/A           | 0.0236       |
| Boiler  |         | 25% load           | 15.240                 | 0.610                | 1.434                | 4.912              | 394.261             | 0.0124       | N/A         | N/A           | 0.0084       |

Modeling: Annual (PM10)

|         | Case #     | Case     | Stack Height<br>meters | Stack Diam<br>meters | Stack flow<br>m3/sec | Stack Vel<br>m/sec | Stack Temp<br>deg K | NOx<br>g/sec | CO<br>g/sec | PM10<br>g/sec | SOx<br>g/sec |
|---------|------------|----------|------------------------|----------------------|----------------------|--------------------|---------------------|--------------|-------------|---------------|--------------|
| Unit 9  | Case 3     | Cold Low | 64.0                   | 6.1                  | 365.4                | 12.519             | 368.817             | N/A          | N/A         | 0.7441        | N/A          |
| Unit 11 | Case 2-55% | Hot Low  | 45.7                   | 3.4                  | 216.5                | 24.077             | 724.428             | N/A          | N/A         | 0.3499        | N/A          |
| Unit 12 | Case 2-55% | Hot Low  | 45.7                   | 3.4                  | 216.5                | 24.077             | 724.428             | N/A          | N/A         | 0.3499        | N/A          |
| Boiler  |            | 25% load | 15.2                   | 0.6                  | 1.4                  | 4.912              | 394.261             | N/A          | N/A         | 0.0024        | N/A          |



Table 3.1B-7

**El Segundo Power Facility Modification  
Emission Rates and Stack Parameters for Facilitywide Impact Modeling**

|  | Stack<br>Diam, m | Stack<br>Height, m | Temp,<br>deg K | Exhaust Flow,<br>m <sup>3</sup> /s | Exhaust<br>Velocity, m/s | Emission Rates, g/s |                 |        |                  |        |
|--|------------------|--------------------|----------------|------------------------------------|--------------------------|---------------------|-----------------|--------|------------------|--------|
|  |                  |                    |                |                                    |                          | NOx                 | SO <sub>2</sub> | CO     | PM <sub>10</sub> |        |
| <b>Averaging Period: One hour NOx</b>        |                  |                    |                |                                    |                          |                     |                 |        |                  |        |
| Unit 5                                       | 6.1              | 64.0               | 441            | 415.5                              | 14.2                     | 1.0573              | n/a             | n/a    | n/a              | n/a    |
| Unit 7                                       | 6.1              | 64.0               | 441            | 415.5                              | 14.2                     | 1.0573              | n/a             | n/a    | n/a              | n/a    |
| <b>Averaging Period: One hour CO and SOx</b> |                  |                    |                |                                    |                          |                     |                 |        |                  |        |
| Unit 5                                       | 6.1              | 64.0               | 441            | 415.5                              | 14.2                     | n/a                 | 0.2992          | 0.9654 | n/a              | n/a    |
| Unit 7                                       | 6.1              | 64.0               | 441            | 415.5                              | 14.2                     | n/a                 | 0.2992          | 0.9654 | n/a              | n/a    |
| <b>Averaging Period: Three hours SOx</b>     |                  |                    |                |                                    |                          |                     |                 |        |                  |        |
| Unit 5                                       | 6.1              | 64.0               | 441            | 415.5                              | 14.2                     | n/a                 | 0.2992          | n/a    | n/a              | n/a    |
| Unit 7                                       | 6.1              | 64.0               | 441            | 415.5                              | 14.2                     | n/a                 | 0.2992          | n/a    | n/a              | n/a    |
| <b>Averaging Period: Eight hours CO</b>      |                  |                    |                |                                    |                          |                     |                 |        |                  |        |
| Unit 5                                       | 6.1              | 64.0               | 441            | 415.5                              | 14.2                     | n/a                 | n/a             | 0.9654 | n/a              | n/a    |
| Unit 7                                       | 6.1              | 64.0               | 441            | 415.5                              | 14.2                     | n/a                 | n/a             | 0.9654 | n/a              | n/a    |
| <b>Averaging Period: 24-hour SOx</b>         |                  |                    |                |                                    |                          |                     |                 |        |                  |        |
| Unit 5                                       | 6.1              | 64.0               | 441            | 415.5                              | 14.2                     | n/a                 | 0.2992          | n/a    | n/a              | n/a    |
| Unit 7                                       | 6.1              | 64.0               | 441            | 415.5                              | 14.2                     | n/a                 | 0.2992          | n/a    | n/a              | n/a    |
| <b>Averaging Period: 24-hour PM10</b>        |                  |                    |                |                                    |                          |                     |                 |        |                  |        |
| Unit 5                                       | 6.1              | 64.0               | 441            | 415.5                              | 14.2                     | n/a                 | n/a             | n/a    | n/a              | 1.2600 |
| Unit 7                                       | 6.1              | 64.0               | 441            | 415.5                              | 14.2                     | n/a                 | n/a             | n/a    | n/a              | 1.2600 |
| <b>Averaging Period: Annual NOx and SOx</b>  |                  |                    |                |                                    |                          |                     |                 |        |                  |        |
| Unit 5                                       | 6.1              | 64.0               | 441            | 415.5                              | 14.2                     | 1.3085              | 0.1070          | n/a    | n/a              | n/a    |
| Unit 7                                       | 6.1              | 64.0               | 441            | 415.5                              | 14.2                     | 1.3085              | 0.1070          | n/a    | n/a              | n/a    |
| <b>Averaging Period: Annual PM10</b>         |                  |                    |                |                                    |                          |                     |                 |        |                  |        |
| Unit 5                                       | 6.1              | 64.0               | 441            | 415.5                              | 14.2                     | n/a                 | n/a             | n/a    | n/a              | 0.7455 |
| Unit 7                                       | 6.1              | 64.0               | 441            | 415.5                              | 14.2                     | n/a                 | n/a             | n/a    | n/a              | 0.7455 |

**Table 3.1B-8**


**El Segundo Power Facility Modification  
 Startup/Shutdown Inputs for Facilitywide Impact Modeling (Units 5 and 7)  
 Data For Each Turbine**

| <b>Operating Case</b> | <b>Stack Height meters</b> | <b>Stack Diam meters</b> | <b>Stack flow m<sup>3</sup>/sec</b> | <b>Stack Vel m/sec</b> | <b>Stack Temp deg K</b> |
|-----------------------|----------------------------|--------------------------|-------------------------------------|------------------------|-------------------------|
| Startup/Shutdown      | 64                         | 6.1                      | 415.55                              | 14.24                  | 440.93                  |

| <b>Operating Case</b> | <b>NOx g/sec</b> | <b>CO g/sec</b> |
|-----------------------|------------------|-----------------|
| Startup/Shutdown      | 11.48            | 103.73          |



## **APPENDIX 3.1C – MODELING PROTOCOL**



# **Air Dispersion Modeling and Health Risk Assessment Protocol**

## **El Segundo Energy Center – Facility Modification El Segundo, California**

Submitted to:

**South Coast Air Quality Management District  
(for an Application for Permit to Construct/Permit  
to Operate)**

**California Energy Commission  
(for a Petition to Amend)**

prepared for:

**NRG West**

November 2012

prepared by:

Sierra Research, Inc.  
1801 J Street  
Sacramento, California 95811  
(916) 444-6666

**Air Dispersion Modeling and Health Risk Assessment Protocol  
El Segundo Energy Center – Facility Modification  
El Segundo, California**

Submitted to:

South Coast Air Quality Management District  
(for an Application for Permit to Construct/Permit to Operate)

California Energy Commission  
(for a Petition to Amend)

November 2012

prepared by:

Sierra Research, Inc.  
1801 J Street  
Sacramento, California 95811  
(916) 444-6666

# **Air Dispersion Modeling and Health Risk Assessment Protocol El Segundo Energy Center – Facility Modification**

## Table of Contents

|   | <u>Page</u> |
|---|-------------|
| 1. INTRODUCTION .....   | 1           |
| 2. FACILITY DESCRIPTION AND SOURCE INFORMATION .....  | 2           |
| 3. DISPERSION MODEL PROCEDURES .....  | 5           |
| 3.1 AERMOD Modeling .....   | 5           |
| 3.2 Fumigation Modeling .....   | 7           |
| 3.3 Health Risk Modeling .....  | 7           |
| 3.4 Meteorological Data .....   | 8           |
| 3.5 Receptor Grids .....  | 10          |
| 3.6 Ambient Air Quality Impact Analyses (AQIA) .....  | 10          |
| 3.7 Background Ambient Air Quality Data .....   | 17          |
| 3.8 Health Risk Assessment .....  | 19          |
| 3.9 Construction Air Quality Impact Analysis .....  | 20          |
| 3.10 Cumulative Air Quality Impact Analysis .....   | 21          |
| 4. REPORTING .....  | 22          |
| 5. REFERENCES .....   | 23          |
|   |             |
| Appendix A – Information on CTSCREEN Model  |             |
| Appendix B – Proposed NO <sub>2</sub> :NO <sub>x</sub> Ratios for Modeling Compliance with One-Hour NO <sub>2</sub> Standards |             |
| Appendix C – Composite Quarterly and Annual Wind Roses for LAX Airport  |             |

List of Tables

|   | <u>Page</u> |
|---|-------------|
| Table 1 Significant Impact Levels for Air Quality Impacts in Class II Areas<br>( $\mu\text{g}/\text{m}^3$ ) ..... | 11          |
| Table 2 Significant Change in Air Quality Concentration ( $\mu\text{g}/\text{m}^3$ ) SCAQMD<br>Rule 1303 .....    | 12          |
| Table 3 Representative Background Ambient Air Quality Monitoring Stations.....                                    | 17          |

List of Figures

|  | <u>Page</u> |
|--|-------------|
| Figure 1 Location of the El Segundo Generating Station .....   | 3           |
| Figure 2 Immediate Vicinity of the El Segundo Generating Station and General<br>Location of the Project..... | 4           |
| Figure 3 Relative Locations of the Project and Monitoring Stations.....                                      | 9           |

## **1. INTRODUCTION**

This protocol describes the modeling procedures that will be used to determine the ambient air impacts from the El Segundo Energy Center – Facility Modification (also referred to herein as the Project). These procedures will be used in the ambient air quality impact assessment and screening health risk assessment that will be submitted to the South Coast Air Quality Management District (SCAQMD, or District) as part of an application for Determination of Compliance and Permit to Construct and to the California Energy Commission as part of a Petition to Amend.

###

## 2. FACILITY DESCRIPTION AND SOURCE INFORMATION

The El Segundo Energy Center – Facility Modification will replace the existing Unit 3 and 4 steam boiler plants with approximately 440 MW of new natural-gas fired turbine capacity at the existing El Segundo Generating Station. The new gas turbine capacity will include both a fast-start combined cycle unit and two advanced simple cycle units<sup>1</sup>, and will provide black-start capability for the entire Generating Station. The El Segundo Generating Station is located at 301 Vista Del Mar, El Segundo, California, situated approximately 2.5 miles southwest of the Los Angeles International Airport and west of the San Diego Freeway (I-405) on the eastern shore of Santa Monica Bay. The power plant site is bordered by Vista Del Mar and the Chevron refinery to the east, 45<sup>th</sup> Street in the City of Manhattan Beach on the south, Santa Monica Bay on the west, and Chevron Marine Terminal on the north. The facility site is approximately 33 acres in size. Figure 1 shows the general location of the power plant. Figure 2 shows the immediate vicinity of the El Segundo Generating Station.

New emissions units will include a black start Diesel generator and a supplemental cooling system,<sup>2</sup> in addition to the gas turbines described above. The new generating units will be fitted with Best Available Control Technology (BACT). For the gas turbines, BACT will include dry low-NOx combustors, selective catalytic reduction (SCR), an oxidation catalyst, and use of clean-burning natural gas fuel. The operating schedule of the new generating units will vary and may range from no operation during the winter months to potentially full-time operation (24 hours per day, 7 days per week) during the summer months. The modeling analysis will be performed for the worst-case (maximum expected equipment operation) operating hour, operating day, and operating year. The modeling analysis will include a complete description of the new equipment including the worst-case hourly, daily, and annual operating schedules used for the analysis.

Because of the relatively low applicability threshold for GHG emissions under the Prevention of Significant Deterioration (PSD) program, the proposed Project may be subject to PSD review for NO<sub>2</sub>, CO, and GHG emissions. The SCAQMD permit application will address applicable PSD modeling requirements based on the final determination of PSD applicability in the application documents.<sup>3</sup>


---

<sup>1</sup> The fast-start combined cycle combustion turbine/steam turbine will be referred to as Units 9 and 10 and the two advanced simple cycle units referred to as Units 11 and 12.

<sup>2</sup> Primary cooling for the gas turbines will be provided by an air-cooled condenser.

<sup>3</sup> While the SCAQMD has received delegation from EPA to implement PSD permitting for criteria air pollutants, the delegation does not yet extend to GHG. Therefore, a separate PSD permit application for GHG will need to be submitted to EPA Region 9 unless the GHG permit delegation process is completed before the permit application for the Project is filed with the SCAQMD.

**Figure 1**  
**Location of the El Segundo Generating Station**





**Figure 2**  
**Immediate Vicinity of the El Segundo Generating Station**  
**and General Location of the Project**



### 3. DISPERSION MODEL PROCEDURES

The air quality modeling analysis will follow the March 2009 U.S. Environmental Protection Agency (USEPA) AERMOD Implementation Guide, USEPA's "Guideline on Air Quality Models," and the South Coast Air Quality Management District's (SCAQMD's) "Guidance for Air Dispersion Modeling."<sup>4</sup>

#### 3.1 AERMOD Modeling

The following USEPA air dispersion models are proposed for use to quantify pollutant impacts on the surrounding environment based on the emission sources' operating parameters and their locations:

- American Meteorological Society/Environmental Protection Agency Regulatory Model Improvement Committee (AERMIC) model, also known as AERMOD (Version 12060);
- Building Profile Input Program – Plume Rise Model Enhancements (BPIP-PRIME, Version 04274); and
- SCREEN3 (Version 96043).

The main air dispersion modeling will be conducted with the latest version (Version 12060) of AERMOD, USEPA's preferred/recommended dispersion model for new source review and PSD air quality impact assessments. AERMOD can account for building downwash effects on dispersing plumes. Stack locations and heights and building locations and dimensions will be input to BPIP-PRIME. The first part of BPIP-PRIME determines and reports on whether a stack is being subjected to wake effects from a structure or structures. The second part calculates direction-specific building dimensions for each structure, which are used by AERMOD to evaluate wake effects. The BPIP-PRIME output is formatted for use in AERMOD input files.

AERMOD requires hourly meteorological data consisting of wind direction and speed (with reference height), temperature (with reference height), Monin-Obukhov length, surface roughness length, heights of the mechanically and convectively generated boundary layers, surface friction velocity, convective velocity scale, and vertical potential temperature gradient in the 500-meter layer above the planetary boundary layer.

---

<sup>4</sup>[http://www.aqmd.gov/smog/metdata/AERMOD\\_ModelingGuidance.html](http://www.aqmd.gov/smog/metdata/AERMOD_ModelingGuidance.html).

Standard AERMOD control parameters will be used, including stack tip downwash, non-screening mode, non-flat terrain, and sequential meteorological data check. The stack-tip downwash algorithm will be used to adjust the effective stack height downward following the methods of Briggs (1972) for cases where the stack exit velocity is less than 1.5 times the wind speed at stack top. The urban option will be used by invoking the URBANOPT option, based on the project's urban location.<sup>5</sup>

If more detailed evaluation of impacts at receptors in terrain above stack-top height is required, the screening version of the USEPA guideline Complex Terrain Dispersion Model PLUS (CTDMPLUS)—Complex Terrain Screening Model (CTSCREEN)—would be used. The CTSCREEN model is discussed in more detail in Appendix A.

### 3.1.1 Ambient Ratio Method and Ozone Limiting Method

Annual NO<sub>2</sub> concentrations will be calculated using the Ambient Ratio Method (ARM), adopted in Supplement C to the Guideline on Air Quality Models (USEPA, 1995). The Guideline allows a nationwide default of 75% for the conversion of nitric oxide (NO) to NO<sub>2</sub> on an annual basis and the calculation of NO<sub>2</sub>/NO<sub>x</sub> ratios.

If NO<sub>2</sub> concentrations need to be examined in more detail, the Ozone Limiting Method (OLM) (Cole and Summerhays, 1979), implemented through the “OLMGROUP ALL” option in AERMOD (USEPA, 2011a), will be used. AERMOD OLM will be used to calculate the NO<sub>2</sub> concentration based on the OLM method and hourly ozone data. Contemporaneous hourly ozone data collected at the nearby LAX monitoring station will be used in conjunction with OLM to calculate hourly NO<sub>2</sub> concentrations from modeled hourly NO<sub>x</sub> concentrations.

Part of the NO<sub>x</sub> in the exhaust is converted to NO<sub>2</sub> during and immediately after combustion. The remaining percentage of the NO<sub>x</sub> emissions is assumed to be NO. We will use EPA's new NO<sub>2</sub>/NO<sub>x</sub> In-Stack Ratio (ISR) database,<sup>6</sup> released on August 30, 2012, to determine the ISRs to be used in this analysis (see Appendix B).

As the exhaust leaves the stack and mixes with the ambient air, the NO reacts with ambient ozone (O<sub>3</sub>) to form NO<sub>2</sub> and molecular oxygen (O<sub>2</sub>). The OLM assumes that at any given receptor location, the amount of NO that is converted to NO<sub>2</sub> by this oxidation reaction is proportional to the ambient O<sub>3</sub> concentration. If the O<sub>3</sub> concentration is less than the NO concentration, the amount of NO<sub>2</sub> formed by this reaction is limited. However, if the O<sub>3</sub> concentration is greater than or equal to the NO concentration, all of the NO is assumed to be converted to NO<sub>2</sub>.

---

<sup>5</sup> The rural vs. urban option in AERMOD is primarily designed to set the fraction of incident heat flux that is transferred into the atmosphere. This fraction becomes important in urban areas having an appreciable “urban heat island” effect due to a large presence of land covered by concrete, asphalt, and buildings. Land use within 3 kilometers [km] of the facility is primarily classified as urban based on the Auer Method; therefore, AERMOD will be run in the “Urban” dispersion mode with a population input of 9,862,049, as defined for Los Angeles County in the District's modeling guidance.

<sup>6</sup> EPA NO<sub>2</sub> / NO<sub>x</sub> In-Stack Ratio (ISR) Data Base, [http://www.epa.gov/ttn/scram/no2\\_isr\\_database.htm](http://www.epa.gov/ttn/scram/no2_isr_database.htm).

A detailed discussion of OLM modeling and how OLM modeling results and monitored background NO<sub>2</sub> will be combined is provided in Sections 3.6.1.3 and 3.6.1.4.

### 3.1.2 PM<sub>2.5</sub>

PM<sub>2.5</sub> impacts will be modeled in accordance with USEPA guidance (USEPA, 2010a). A detailed discussion of how modeled PM<sub>2.5</sub> impacts will be evaluated is provided in Section 3.7.

## 3.2 Fumigation Modeling

The SCREEN3 model will be used to evaluate inversion breakup fumigation and shoreline fumigation impacts for short-term averaging periods (24 hours or less), as appropriate. The methodology in “Screening Procedures for Estimating the Air Quality Impact of Stationary Sources, Revised” (USEPA, 1992b) will be followed for these analyses. Combined impacts for all sources under fumigation conditions will be evaluated, based on USEPA modeling guidelines.

## 3.3 Health Risk Modeling

A health risk assessment (HRA) will be performed according to California Air Resources Board (CARB) guidance and SCAQMD’s Risk Assessment Procedures for Rule 1401 and 212. The HRA modeling will be prepared using CARB’s Hotspots Analysis and Reporting Program (HARP) computer program (Version 1.4f, May 2012) and AERMOD with the CARB “on-ramp.”<sup>7</sup> HARP will be used to assess cancer risk as well as non-cancer chronic and acute health hazards. Listed below are the risk assessment options that will be exercised in the modeling, in accordance with the SCAQMD’s Risk Assessment Procedures.

- *Deposition velocity – 0.02 m/sec*
- *Fraction of homegrown fruits and vegetables consumed – 5.2%*
- *For noncancer chronic risk estimates, the “Derived (OEHHA)” risk analysis method is used. In this approach, the two dominant (driving) exposure pathways use the high-end point-estimates of exposure, while the remaining exposure pathways use average point estimates.*
- *For cancer risk estimates, the “Derived (Adjusted)” risk analysis method is used. This method is identical to the “Derived (OEHHA)” method discussed above with one exception. The “Derived (Adjusted)” method uses the breathing rate at the 80th percentile of exposure rather than the high-end point-estimate when the inhalation pathway is one of the dominant exposure pathways.*

---

<sup>7</sup> HARP has not yet been revised to utilize AERMOD, but CARB has developed “on-ramp” software that allows HARP to incorporate AERMOD output files. Therefore, HARP is now compatible with AERMOD.

- *The cancer risk estimates, including the Derived equations (both OEHHA and Adjusted), are based on 70-year exposures.*
- *Pathways considered for residential exposure include inhalation, soil ingestion, dermal absorption, homegrown produce, and mother's milk.*
- *Pathways considered for worker exposure include inhalation, soil ingestion, and dermal absorption.*

### 3.4 Meteorological Data

The District has provided a five-year meteorological dataset (2005–2009) already processed in AERMET to generate AERMOD-compatible meteorological data for air dispersion modeling. The surface meteorological data were recorded at the LAX Airport, and the upper air data were recorded at the San Diego Miramar Station (No. 03190). Figure 3 below shows the relative locations of the project site and the meteorological monitoring station at LAX. Quarterly and annual composite wind roses for the 2005–2009 LAX meteorological dataset are included as Appendix C.


EPA defines the term “on-site data” to mean data that would be representative of atmospheric dispersion conditions at the source and at locations where the source may have a significant impact on air quality. Specifically, the meteorological data requirement originates in the Clean Air Act at Section 165(e)(1), which requires an analysis “of the ambient air quality at the proposed site and in areas which may be affected by emissions from such facility for each pollutant subject to regulation under [the Act] which will be emitted from such facility.”

This requirement and EPA’s guidance on the use of on-site monitoring data are also outlined in the “On-Site Meteorological Program Guidance for Regulatory Modeling Applications” (1987a). The representativeness of the data depends on (a) the proximity of the meteorological monitoring site to the area under consideration, (b) the complexity of the topography of the area, (c) the exposure of the meteorological sensors, and (d) the period of time during which the data are collected.

Representativeness has also been defined in “The Workshop on the Representativeness of Meteorological Observations” (Nappo et. al., 1982) as “the extent to which a set of measurements taken in a space-time domain reflects the actual conditions in the same or different space-time domain taken on a scale appropriate for a specific application.” Representativeness is best evaluated when sites are climatologically similar, as are the project site and the LAX meteorological monitoring station. Representativeness has additionally been defined in the PSD Monitoring Guideline (USEPA, 1987b) as data that characterize the air quality for the general area in which the proposed project would be constructed and operated. Because of the close proximity of the LAX meteorological data site to the proposed project site (distance between the two locations is approximately 5 km), the same large-scale topographic features that influence the meteorological data monitoring station also influence the proposed project site in the same manner.



**Figure 3**  
**Relative Locations of the Project and Monitoring Stations**



### 3.5 Receptor Grids

Receptor and source base elevations will be determined from USGS National Elevation Dataset (NED) data in the GeoTIFF format at a horizontal resolution of 1 arc-second (approximately 30 meters). All coordinates will be referenced to UTM North American Datum 1983 (NAD83), Zone 11. The AERMOD receptor elevations will be interpolated among the DEM nodes according to standard AERMAP procedure. For determining concentrations in elevated terrain, the AERMAP terrain preprocessor receptor-output (ROU) file option will be chosen.

Cartesian coordinate receptor grids will be used to provide adequate spatial coverage surrounding the project area for assessing ground-level pollution concentrations, to identify the extent of significant impacts, and to identify maximum impact locations. A 250-meter resolution coarse receptor grid will be developed and will extend outwards at least 10 km (or more if necessary to establish the significant impact area).

For the full impact analyses, a nested grid will be developed to fully represent the maximum impact area(s). The receptor grid will be constructed as follows:

1. One row of receptors spaced 25 meters apart along the facility's fence line;
2. Four tiers of receptors spaced 25 meters apart, extending 100 meters from the fence line;
3. Additional tiers of receptors spaced 100 meters apart, extending from 100 meters to 1,000 meters from the fence line; and
4. Additional tiers of receptors spaced 250 meters apart, out to at least 10 km from the most distant source modeled, not to exceed 50 km from the project site.

Additional refined receptor grids with 25-meter resolution will be placed around the maximum first-high or maximum second-high coarse grid impacts and extended out 1,000 meters in all directions. Concentrations within the facility fence line will not be calculated.

The Regions to be imported in Geographical Coordinates for the USGS National Elevation Dataset (NED) data are bounded as follows:

- South West corner: UTM Zone 11 (NAD 83) 356,500.0 m, 3,741,600.0 m; and
- North East corner: UTM Zone 11 (NAD 83) 379,800.0 m, 3,764,700.0 m.

### 3.6 Ambient Air Quality Impact Analyses (AQIA)

Emissions from the proposed Project will result from combustion of fuel in the turbines and black start generator and from the cooling system. These emission sources will be modeled as point sources. The expected emission rates will be based on vendor data and additional conservative assumptions of equipment performance.

The purpose of the ambient air quality impact analysis is to demonstrate compliance with applicable ambient air quality standards. Both USEPA and the District have regulations that prohibit construction of a project that will cause or contribute to violations of applicable standards.

According to EPA, if, for a given pollutant and averaging time, the project’s impact is below the Significant Impact Levels (SILs) shown in Table 1, the project’s impact is deemed to be *de minimis*, and no further analysis is required. SCAQMD’s Rule 1303 includes concentrations of NO<sub>2</sub>, CO, and PM<sub>10</sub> that are considered to be significant changes in air quality concentration for individual permit units. Based on discussions with District staff, if the background monitoring data collected during the past five years show levels below the federal/state air quality standards, there is no need to compare modeled impacts to these SCAQMD significance thresholds. Based on recent monitoring data, PM<sub>10</sub> is the only pollutant for which the Rule 1303 significance thresholds need to be analyzed in the SCAQMD. Also, the District staff allows these significance thresholds to be analyzed on a permit unit basis. Therefore, if maximum modeled PM<sub>10</sub> impacts from each permit unit do not exceed the concentrations shown in Table 2, the District will determine that the permit unit’s impact is not expected to cause or contribute to an exceedance of the most stringent federal or state PM<sub>10</sub> AAQS.

However, if the modeled impacts exceed any of the significance thresholds displayed in Tables 1 and 2,<sup>8</sup> the project has the potential to cause or contribute to a violation of the ambient air quality standard at the times and locations where the threshold is exceeded. In that case, the analysis must consider the contribution of other sources to the ambient concentration. If the analysis indicates that there will be a violation of an ambient air quality standard, and the project’s impact at the time and place of the violation is significant, then the project may not be approved unless the project’s impact is reduced.

| <b>Table 1</b>  |                         |                |               |               |                  |
|---|-------------------------|----------------|---------------|---------------|------------------|
| <b>Significant Impact Levels for Air Quality Impacts in Class II Areas (µg/m<sup>3</sup>)</b> |                         |                |               |               |                  |
| <b>Pollutant</b>  | <b>Averaging Period</b> |                |               |               |                  |
|   | <b>Annual</b>           | <b>24-hour</b> | <b>8-hour</b> | <b>3-hour</b> | <b>1-hour</b>    |
| NO <sub>2</sub>   | 1                       | --             | --            | --            | 7.5 <sup>9</sup> |
| SO <sub>2</sub>   | 1                       | 5              | --            | 25            | 7.8 <sup>9</sup> |
| CO  | --                      | --             | 500           | --            | 2000             |
| PM <sub>10</sub>  | 1                       | 5              | --            | --            | --               |
| PM <sub>2.5</sub>   | 0.3                     | 1.2            | --            | --            | --               |

<sup>8</sup> Table 1 concentrations apply to the entire project; Table 2 concentrations apply to each permit unit.

<sup>9</sup> EPA has not yet defined significance levels (SILs) for one-hour NO<sub>2</sub> and SO<sub>2</sub> impacts. However, EPA has suggested that, until SILs have been promulgated, interim values of 4 ppb (7.5 µg/m<sup>3</sup>) for NO<sub>2</sub> and 3 ppb (7.8 µg/m<sup>3</sup>) for SO<sub>2</sub> may be used (USEPA (2010c); USEPA (2010d)). These values will be used in this analysis as interim SILs.



| <b>Table 2</b>  |                         |                |               |               |               |
|---|-------------------------|----------------|---------------|---------------|---------------|
| <b>Significant Change in Air Quality Concentration (<math>\mu\text{g}/\text{m}^3</math>) SCAQMD Rule 1303</b> |                         |                |               |               |               |
| <b>Pollutant</b>  | <b>Averaging Period</b> |                |               |               |               |
|   | <b>Annual</b>           | <b>24-hour</b> | <b>8-hour</b> | <b>3-hour</b> | <b>1-hour</b> |
| PM <sub>10</sub>  | 1                       | 2.5            | --            | --            | --            |

An air quality impact analysis is required for certification by the CEC and to support the air quality impact analysis, PSD analysis, and screening health risk assessment that are required by the District. Each agency has its own criteria for preparation of the air quality impact analysis; however, the criteria used by the CEC and the District are similar enough that the same basic analysis, with some variations, will satisfy both.

### **3.6.1.1 Step 1: Project Impact**

The first step in the compliance demonstration is to determine, for each pollutant and averaging period, whether the proposed new equipment for the project has the potential to cause a significant ambient impact at any location, under any operating or meteorological conditions. As indicated in the NSR Workshop Manual,<sup>10</sup> “[i]f the significant net emissions increase from a proposed source would not result in a significant ambient impact anywhere, the application is usually not required to go beyond a preliminary analysis in order to make the necessary showing of compliance for a particular pollutant.” The EPA and SCAQMD significance levels for air quality impacts are shown in Tables 1 and 2, respectively. If the maximum modeled impact for any pollutant and averaging period is below the appropriate significance level in both tables, no further analysis is necessary.

Based on the following USEPA (2010e) guidance, no further analysis is necessary for any location where the modeled impacts from the project alone are below the significance thresholds.

*The primary purpose of the SILs is to identify a level of ambient impact that is sufficiently low relative to the NAAQS or increments that such impact can be considered trivial or de minimis. Hence, the EPA considers a source whose individual impact falls below a SIL to have a de minimis impact on air quality concentrations that already exist. Accordingly, a source that demonstrates that the projected ambient impact of its proposed emissions increase does not exceed the SIL for that pollutant at a location where a NAAQS or increment violation occurs is not considered to cause or contribute to that violation. In the same way, a source with a proposed emissions increase of a particular pollutant that will have a significant impact at some locations is not required to model at distances beyond the point where the impact of its proposed emissions is below the SILs for that*

<sup>10</sup> USEPA (1990), p. C.51.

*pollutant. When a proposed source's impact by itself is not considered to be "significant," EPA has long maintained that any further effort on the part of the applicant to complete a cumulative source impact analysis involving other source impacts would only yield information of trivial or no value with respect to the required evaluation of the proposed source or modification.*<sup>11</sup>

For PM<sub>2.5</sub>, the highest average of the maximum annual averages and of the 24-hour averages modeled over the five years of meteorological data will be compared with the SILs in Table 1 to determine whether the modeled PM<sub>2.5</sub> project impacts are significant.<sup>12</sup> For other pollutants, the highest modeled concentrations will be compared with the SILs. For pollutants with modeled project impacts below the significance thresholds, a summary table will show the maximum modeled project impacts plus background concentrations. Although this information is not required by federal modeling guidance, it will be provided as part of the CEQA analysis.

### **3.6.1.2 Step 2: Project Plus Background**

Pollutants/averaging periods that are not screened out in Step 1 are required to undergo a full air quality impact analysis. In Step 2, the ambient impacts of the project are modeled and added to background concentrations. The results are compared to the relevant state and federal ambient standards.

The second step of the compliance demonstration is required to show that the proposed new project, in conjunction with existing sources, will not cause or contribute to a violation of any ambient air quality standard. As discussed in more detail below, the impacts of existing sources are represented by the existing ambient air quality data collected at the monitoring stations shown in Table 2. In accordance with Section 8.2.1 of Appendix W to 40 CFR Part 51,

*Background concentrations are an essential part of the total air quality concentration to be considered in determining source impacts. Background air quality includes pollutant concentrations due to: (1) Natural sources; (2) nearby sources other than the one(s) currently under consideration; and (3) unidentified sources. Typically, air quality data should be used to establish background concentrations in the vicinity of the source(s) under consideration.*

For the proposed project, the only nearby sources proposed for inclusion are the emission units at El Segundo Generating Station that will be in operation at the time the Project is operational—that is, El Segundo Units 5 and 7. Because these units have not yet commenced operation, they are not reflected in the background data and will be modeled

---

<sup>11</sup> USEPA (2010e), p. 64891.

<sup>12</sup> USEPA (2010a), p. 6.

separately. The impact of natural sources and unidentified sources will be represented by ambient air quality monitoring data collected at the nearby monitoring stations. In this protocol, these impacts are characterized as part of the “regional background.”

If a Step 2 analysis is required, the modeled impacts from all Project sources (and, as discussed in to the preceding paragraph, other El Segundo Generating Station sources) will be added to the representative background concentration for a comparison with the National Ambient Air Quality Standard (NAAQS). In accordance with USEPA guidelines,<sup>13</sup> the highest second-highest modeled concentrations will be used to demonstrate compliance with the short-term federal standards (except for the statistically based federal one-hour NO<sub>2</sub> and SO<sub>2</sub>, and 24-hour PM<sub>2.5</sub>, standards) and the highest modeled concentration will be used to demonstrate compliance with the federal annual and all state standards. If the predicted total ground-level concentration is below the state or federal ambient air quality standard for each pollutant and averaging period, no further analysis is required for that pollutant and averaging period.

### **3.6.1.3 Compliance with Statistically Based Standards**

For the one-hour average federal NO<sub>2</sub> standard for the District and CEC analyses, the comparison of impacts with the new federal one-hour standard will be done in accordance with Appendix W of Part 51 of Title 40 of the CFR “Guideline on Air Quality Models” and the tiered process developed by “Modeling Compliance of the Federal 1-Hour NO<sub>2</sub> NAAQS” (CAPCOA guidance document, 2011).<sup>14</sup> Appendix W of Part 51 of Title 40 of the CFR “Guideline on Air Quality Models” has codified three methods that can be used to estimate NO<sub>2</sub> concentration (Tier 1 - Total Conversion, Tier 2 - Ambient Ratio Method or ARM, Tier 3 - Ozone Limiting Method or OLM). According to USEPA guidance,

*While the limited scope of the available field study data imposes limits on the ability to generalize conclusions regarding model performance, these preliminary results of hourly NO<sub>2</sub> predictions for Palau and New Mexico show generally good performance for the PVMRM and OLM/OLMGROUP ALL options in AERMOD. We believe that these additional model evaluation results lend further credence to the use of these Tier 3 options in AERMOD for estimating hourly NO<sub>2</sub> concentrations, and we recommend that their use should be generally accepted provided some reasonable demonstration can be made of the*

---

<sup>13</sup> USEPA (2005), 11.2.3.2 and 11.2.3.3

<sup>14</sup> “This modeling protocol is meant to define the stepwise approach necessary to satisfy the requirements in General Guidance for Implementing the 1-Hour NO<sub>2</sub> National Ambient Air Quality Standard in Prevention of Significant Deterioration Permits, Including an Interim NO<sub>2</sub> Significant Impact Level and the Applicability of Appendix W Modeling Guidance for 1-Hour NO<sub>2</sub> National Ambient Air Quality Standard. Nothing in this protocol should be taken as overriding guidance contained in those two memoranda, or Appendix W of Part 51 of Title 40 of the Code of Federal Regulations (40 CFR 51, Appendix W).” (SJVAPCD, 2010b)

*appropriateness of the key inputs for these options, the in-stack NO<sub>2</sub>/NO<sub>x</sub> ratio and the background ozone concentrations.*<sup>15</sup>

The in-stack NO<sub>2</sub>/NO<sub>x</sub> ratios will be developed from EPA's new NO<sub>2</sub>/NO<sub>x</sub> In-stack Ratio database.<sup>16</sup> Background ozone concentrations in the project area will be represented by five years of ozone data (2005-2009) collected at LAX concurrently with the meteorological data. The LAX ozone monitor is 5 km from the project and is most representative of the ambient conditions at the project. Based on these facts, we propose to use the Tier 3, "OLMGROUP ALL," option for modeling 1-hour NO<sub>2</sub> concentrations.

For demonstrating compliance with the statistically based federal one-hour NO<sub>2</sub> standard, CAPCOA's 2011 guidance document provides 11 progressively more sophisticated methods for combining modeled NO<sub>2</sub> concentrations with background (or monitored) NO<sub>2</sub>. These methods, outlined below, were developed to allow demonstration of compliance using the lowest amount of resources necessary. Each tier is a progressively more sophisticated and comprehensive analysis that reduces the level of conservatism without reducing the level of assurance of compliance.

1. Significant Impact Level (SIL) – no background required
2. Max modeled value + max monitored value
3. Max modeled value + 98<sup>th</sup> pctl monitored value
4. 8<sup>th</sup> highest modeled value + max monitored value
5. 8<sup>th</sup> highest modeled value + 98<sup>th</sup> pctl monitored value
6. (5 yr avg of 98<sup>th</sup> pctl modeled value) + max monitored value
7. (5 yr avg of 98<sup>th</sup> pctl of modeled value) + 98<sup>th</sup> pctl monitored value
8. 5 yr avg of 98<sup>th</sup> pctl of (modeled value + monthly hour-of-day – 1<sup>st</sup> high)
9. 5 yr avg of 98<sup>th</sup> pctl of (modeled value + seasonal hour-of-day – 3<sup>rd</sup> high)
10. 5 yr average of 98<sup>th</sup> pctl of (modeled value + annual hour-of-day - 8<sup>th</sup> high)
11. Paired-Sum: 5 yr avg of 98<sup>th</sup> pctl of (modeled value + background)

Applicable definitions are provided below.

- **Significant Impact Level (SIL)** is defined as a de minimis impact level below which a source is presumed not to cause or contribute to an exceedance of a NAAQS (see Table 1 above).
- **Max modeled value** is defined as the maximum concentration predicted by the model at any given receptor in any given year modeled.

---

<sup>15</sup> (March, 2011), "Additional Clarification Regarding Application of Appendix W Modeling Guidance for the 1-hour NO<sub>2</sub> National Ambient Air Quality Standard,"

[[http://www.epa.gov/ttn/scram/guidance/clarification/Additional\\_Clarifications\\_AppendixW\\_Hourly-NO2-NAAQS\\_FINAL\\_03-01-2011.pdf](http://www.epa.gov/ttn/scram/guidance/clarification/Additional_Clarifications_AppendixW_Hourly-NO2-NAAQS_FINAL_03-01-2011.pdf)] The Plume Volume Molar Ratio Method (PVMRM) is considered by EPA to be a Tier 3 screening method, similar to OLM.

<sup>16</sup> EPA NO<sub>2</sub> / NO<sub>x</sub> In-Stack Ratio (ISR) Data Base, [http://www.epa.gov/ttn/scram/no2\\_isr\\_database.htm](http://www.epa.gov/ttn/scram/no2_isr_database.htm)  
See Appendix B.

- **8<sup>th</sup> highest modeled value** is defined as the highest 8<sup>th</sup>-highest concentration derived by the model at any given receptor in any given year modeled.
- **5 yr avg of the 98<sup>th</sup> pctl** is defined as the highest of the average 8<sup>th</sup> highest (98<sup>th</sup> percentile) concentrations derived by the model across all receptors based on the length of the meteorological data period or the X years average of 98<sup>th</sup> percentile of the annual distribution of daily maximum one-hour concentrations across all receptors, where X is the number of years modeled. (In Appendix W, EPA recommends using five years of meteorological data from a representative National Weather Service site or one year of on-site data.)
- **Monthly hour-of-day** is defined as the three-year average of the 1<sup>st</sup> highest concentrations (Maximum Hourly) for each hour of the day Seasonal Hour-Of-Day is defined as the three-year average of the 3<sup>rd</sup> highest concentrations for each hour of the day and season
- **Annual hour-of-day** is defined as the three-year average of the 8<sup>th</sup> highest concentration for each hour of the day
- **Paired-Sum (5 yr avg of the 98<sup>th</sup> pctl)** is the merging of the modeled concentration with the monitored values paired together by month, day, and hour. The sum of the paired values are then processed to determine the X years average of 98<sup>th</sup> percentile of the annual distribution of daily maximum one-hour concentrations across all receptors, where X is the number of years modeled.

For the demonstration of compliance with the federal one-hour NO<sub>2</sub> standard, we will perform analyses at as many of the following tiers as are needed to demonstrate compliance with the state and federal ambient air quality standards: Tier 1, Tier 2, Tier 7, Tier 8, Tier 9, Tier 10, and Tier 11. Hourly NO<sub>2</sub> background data (for the same five years of meteorological data used for the modeling, 2005 to 2009) may also be used in order to refine the NAAQS analysis both spatially and temporally. Hourly NO<sub>2</sub> data from LAX monitor station will be acquired. This station is approximately 5 kilometers to the project site. A review of the area around this monitoring station shows that it is surrounded by a number of NO<sub>x</sub>-emitting facilities, including the proposed facility. Therefore, monitored concentrations at this location are considered to be representative of the project site (i.e., other than the other El Segundo Generating Station sources already discussed, no nearby sources will be explicitly modeled—their impacts are already reflected in the ambient monitoring data). In the event of missing hourly NO<sub>2</sub> data, the missing data procedures described in Section 3.7.1 will be followed to fill in gaps in the hourly NO<sub>2</sub> data.

The demonstration of compliance with the federal one-hour SO<sub>2</sub> standard will follow the same steps, except that it will utilize the 99<sup>th</sup> percentile predicted one-hour average SO<sub>2</sub> concentrations instead of the 98<sup>th</sup> percentile.

For the 24-hour average federal PM<sub>2.5</sub> standard for the District and CEC analyses, the comparison of impacts with the federal 24-hour average standard will be done in accordance with USEPA March 23, 2010 guidance (USEPA, 2010a). This guidance calls for basing the initial determination of compliance with the standard on the five-year average of the highest modeled annual and 24-hour averages, combined with background concentrations based on the form of the standards (the three-year average of the annual PM<sub>2.5</sub> concentrations and the three-year average of the 98th percentile 24-hour averages).<sup>17</sup> If a more detailed assessment of PM<sub>2.5</sub> impacts is required, a Tier 2 analysis will be performed. USEPA’s March 23, 2010 memo provides minimal guidance regarding this type of more detailed analysis, saying only “a Second Tier modeling analysis may be considered that would involve combining the monitored and modeled PM<sub>2.5</sub> concentrations on a seasonal or quarterly basis, and re-sorting the total impacts across the year to determine the cumulative design value.”<sup>18</sup> As no additional guidance has been provided, such an analysis would be discussed with the District and CEC staff prior to implementation.

#### 3.6.1.4 State One-Hour NO<sub>2</sub> Standard

Compliance with the state one-hour NO<sub>2</sub> standard will be demonstrated using OLM and the paired-sum approach described above, except that the analysis will use highest, rather than 98<sup>th</sup> percentile, concentrations, consistent with the form of the state standard.

### 3.7 Background Ambient Air Quality Data

Background ambient air quality data for the project area will be obtained from the monitoring sites most representative of the conditions that exist at the proposed project site. The LAX monitoring station is the nearest station with background data for PM<sub>10</sub>, NO<sub>2</sub>, SO<sub>2</sub>, O<sub>3</sub>, and CO; the North Long Beach Station is the nearest for PM<sub>2.5</sub> observations. Modeled concentrations will be added to these representative background concentrations to demonstrate compliance with the CAAQS and NAAQS.

Table 3 shows the monitoring stations we propose to use as they provide the most representative ambient air quality background data. Monitoring station locations are also shown in Figure 3.

| <b>Table 3<br/>Representative Background Ambient Air Quality Monitoring Stations</b> |                           |                                 |
|--|---------------------------|---------------------------------|
| <b>Pollutant(s)</b>  | <b>Monitoring Station</b> | <b>Distance to Project Site</b> |
| Ozone, PM <sub>10</sub> , SO <sub>2</sub> , NO <sub>2</sub> , CO                     | LAX                       | 5 km                            |
| PM <sub>2.5</sub>  | North Long Beach          | 24 km                           |

<sup>17</sup> USEPA (2010a), p. 9.

<sup>18</sup> USEPA (2010a), p. 8.

For annual NO<sub>2</sub>, 24-hour and annual SO<sub>2</sub>, and all PM<sub>10</sub> and CO averaging periods, the highest values monitored during the 2009-2011 period will be used to represent ambient background concentrations in the project area. The one-hour average NO<sub>2</sub> analyses will be performed as described above. Because the three-hour average statistic for SO<sub>2</sub> is no longer available from the USEPA or CARB's websites, one-hour average SO<sub>2</sub> concentrations will be used to represent three-hour average background concentrations for SO<sub>2</sub>. For analyses of federal 24-hour and annual PM<sub>2.5</sub> impacts, the three-year average of the 98th percentile 24-hour monitored levels for the period between 2007 and 2011 will be used to represent project background because these values correspond to the method used for determining compliance with the federal PM<sub>2.5</sub> standards and are consistent with the guidance cited above.

### 3.7.1 Missing Data Protocol

Using the OLM method to model project-generated one-hour NO<sub>2</sub> concentrations requires the use of ambient monitored O<sub>3</sub> concentrations. Because the OLM method uses the ambient ozone concentration for a particular hour to limit the conversion of NO to NO<sub>2</sub>, it is important to have ozone concentrations for every hour. It is also important that any missing hourly ozone concentrations be filled in with a value that does not underestimate the ozone concentration for that hour, to avoid underestimating the resulting NO<sub>2</sub> concentration. In addition, computation of total hourly NO<sub>2</sub> concentrations requires use of the ambient monitored hourly NO<sub>2</sub> concentrations from the nearest monitoring station. As is the case for the hourly ozone data, it is important to have a background NO<sub>2</sub> value for every hour that does not underestimate actual background.

As discussed above, background ambient O<sub>3</sub> and NO<sub>2</sub> concentrations for the project area will be obtained from the monitoring station at LAX. While these datasets exceed USEPA's 90% completeness criterion (that is, more than 90% of the data values are present for each month), there are still occasional missing values that must be filled in. To fill in these missing values, we propose to use the methods described in "Chapter 6, Gap Filling for Ozone and NO<sub>2</sub> Datasets, Modeling Compliance of the Federal 1-Hour NO<sub>2</sub> NAAQS" (California Air Pollution Control Officers Association [CAPCOA] guidance document, 2011). The CAPCOA guidance follows the procedure established by USEPA (Atkinson and Lee, 1992) for filling a single hour of missing meteorological data, but uses a somewhat different approach for filling in multi-hour data gaps.

For a single hour, it is widely accepted that the best method of gap filling is the use of a linear interpolation of the hour before and after the missing hour. This method is also known as the mean-before-after. To calculate a concentration for a single missing hour, we propose to add the concentrations for the hour before and after the missing hour and divide the sum by two (CAPCOA guidance, Section 6.1.1; Atkinson and Russell, 1992).

The proposed procedure to be used for filling in multi-hour data gaps is the "Monthly Hourly Concentration, Option 2" gap-filling method from Section 6.1.2.2 of the

CAPCOA guidance. The procedure for multiple hours of missing data is outlined below.<sup>19</sup>

1. For all periods with more than one hour missing, fill the missing hour with the maximum for that hour of day for a 30-day rolling period centered on the hour (i.e., for the 15 preceding days and the 15 succeeding days). Note that the 30-day rolling period will extend into the preceding and succeeding year at the start or end, respectively, of the calendar year.<sup>20</sup>
2. For hours not filled by step 1 (that is, if the data for that hour are missing for the entire 30-day rolling period), fill the missing data with the maximum concentration for the preceding or succeeding hour over the 30-day rolling period.
3. Any hours not filled by steps 1 and 2 are likely periods with more than a month of missing data for all hours. These situations are unlikely, and missing data will be filled on a case-by-case basis, following consultation with District and CEC staff.
4. For NO<sub>2</sub> File Only – Check all filled hours for which the filled concentration is higher than the maximum monitored concentration recorded for that day (for a complete day of missing data, the maximum monitored concentration is considered zero for purposes of this comparison). If the filled concentration is higher than the appropriate nth highest daily maximum monitored concentration for the calendar year for determining compliance with federal 1-hour standard (e.g., for 351 or more days of valid data, the 8th highest daily maximum is the appropriate value), then replace filled concentration with the appropriate nth highest daily maximum for the year to fill that hour. Note: This prevents the filling procedure from changing the nth highest daily maximum for the year.

### 3.8 Health Risk Assessment

A health risk assessment will be performed according to the Office of Environmental Health Hazard Analysis “Air Toxics Hot Spots Program Guidance Manual for Preparation of Health Risk Assessments” (OEHHA, 2003). The HRA modeling will be prepared using CARB’s Hotspots Analysis and Reporting Program (HARP) computer program (Version 1.4f, May 2012). The HARP model will be used to assess cancer risk as well as non-cancer chronic and acute health hazards.

The HARP model incorporates the ISCST3 model previously approved by USEPA. CARB offers a software program that allows AERMOD data to be imported into the HARP model, called HARP On-Ramp. The on-ramp will be used with most recent versions of AERMOD and HARP for the screening risk assessment.

---

<sup>19</sup> Section 6.1.1.2., option 2, CAPCOA guidance document (2011), available at

[http://www.valleyair.org/busind/pto/Tox\\_Resources/CAPCOANO2GuidanceDocument10-27-11.pdf](http://www.valleyair.org/busind/pto/Tox_Resources/CAPCOANO2GuidanceDocument10-27-11.pdf).

<sup>20</sup> Data from January 2012 will be used to fill in any missing data at the end of the 2011 calendar year.



### 3.9 Construction Air Quality Impact Analysis

The potential ambient impacts from air pollutant emissions during the construction of the project will be evaluated by air quality modeling that will account for the construction site location and the surrounding topography; the sources of emissions during construction, including vehicle and equipment exhaust emissions; and fugitive dust.

Types of Emission Sources – Construction of the project can be viewed as three main sequential phases: site preparation; construction of foundations; and installation of the gas turbines and associated equipment. The construction impacts analysis will include a schedule for construction operation activities. Site preparation includes site excavation, excavation of footings and foundations, and backfilling operations.

Fugitive dust emissions from the construction of the project result from the following activities:

- Excavation and grading at the construction site;
- Onsite travel on paved and unpaved roads and across the unpaved construction site;
- Aggregate and soil loading and unloading operations;
- Raw material transfer to and from material stockpiles; and
- Wind erosion of areas disturbed during construction activities.

Engine exhaust will be emitted from the following sources:

- Heavy equipment used for excavation, grading, and construction of onsite structures;
- Water trucks used to control construction dust emissions;
- Diesel- and gasoline-fueled welding machines, generators, air compressors, and water pumps;
- Gasoline-fueled pickup trucks and Diesel-fueled flatbed trucks used onsite to transport workers and materials around the construction site;
- Transport of mechanical and electrical equipment to the project site;
- Transport of rubble and debris from the site to an appropriate landfill; and
- Transport of raw materials to and from stockpiles.

Emissions from a peak activity day will be modeled. Annual average emissions over the construction period will also be calculated and modeled for comparison with annual standards.

Existing Ambient Levels – The background data discussed earlier will be used to represent existing ambient levels for the construction analysis as well as the analysis of the impacts of project operations.

Model Options – The AERMOD “OLMGROUP ALL” option will be used to estimate ambient impacts from construction emissions. The modeling options and meteorological data described above will be used for the modeling analysis. A 20% NO<sub>2</sub>/NO<sub>x</sub> fraction for Diesel construction equipment will be assumed (see Appendix B).

The construction site will be represented as both a set of volume sources and a separate set of area sources in the modeling analysis. Emissions will be divided into three categories: exhaust emissions, mechanically generated fugitive dust emissions, and wind-blown fugitive dust emissions. Exhaust emissions and mechanically generated fugitive dust emissions (e.g., dust from wheels of a scraper) will be modeled as volume sources with a height of 6 meters. Wind-blown fugitive dust emissions, sources at or near the ground that are at ambient temperature and have negligible vertical velocity, will be modeled as area sources with a release height of 0.5 meters.

Combustion Diesel PM<sub>10</sub> emission impacts from construction equipment will be evaluated to demonstrate that the cancer risk from construction activities will be below ten in one million at all receptors.

For the construction modeling analysis, the receptor grid will begin at the property boundary and will extend approximately one kilometer in all directions. The receptor grid will be laid out as follows:

1. One row of receptors spaced 25 meters apart along the facility’s fence line;
2. Four tiers of receptors spaced 25 meters apart, extending 100 meters from the fence line; and
3. Additional tiers of receptors spaced 60 meters apart, extending from 100 meters to 1,000 meters from the fenceline.

### 3.10 Cumulative Air Quality Impact Analysis

To address CEC requirements, a cumulative air quality modeling impacts analysis of the project’s typical operating mode will be performed in combination with other stationary source emissions sources within a six-mile radius that have received construction permits since January 1, 2011, or are in the permitting process. For each criteria pollutant, facilities having an emission increase of less than five tons per year are generally considered to be *de minimis*, and these facilities may be excluded from the cumulative impacts analysis after consultation with the CEC staff. Information on any recently constructed/permitted sources that might be appropriate for a cumulative air quality impact analysis (as defined above) will be requested from the South Coast AQMD.

Upon receipt of sufficient information from the local air agencies to allow air dispersion modeling of the recently constructed/permitted non-project sources to be included in the cumulative air quality impact analysis, AERMOD will be used in a procedure similar to that described earlier in this protocol.

###

## 4. REPORTING

The results of the criteria pollutant and TAC modeling will be integrated into the application documents, and will include the information listed below.

- Project Description – Site map and site plan along with descriptions of the emitting equipment and air pollution control systems.
- Model Options and Input – Model options, screening and refined source parameters, criteria pollutant and TAC emission rates, meteorological data, and receptor grids used for the modeling analyses.
- Air Dispersion Modeling – Dispersion modeling results will include the following:
  - Plot plan showing emission points, nearby buildings (including dimensions), cross-section lines, property lines, fence lines, roads, and UTM coordinates;
  - A table showing building heights used in the modeling analysis;
  - Summaries of maximum modeled impacts; and
  - Model input and output files, including BPIP-PRIME and meteorological files as well as hourly ozone and NO<sub>2</sub> files used in demonstrating compliance with the 1-hour NO<sub>2</sub> standard, in electronic format on a compact disc, together with a description (README file) of all filenames.
- HRA – The HRA will include the following:
  - Descriptions of the methodology and inputs to the construction and operation AERMOD runs;
  - Tables of TAC emission rates and health impacts;
  - Figures showing sensitive receptor locations; and
  - Model input and output files in electronic format on a compact disc, together with a description (README file) of all filenames.

###

## 5. REFERENCES

Atkinson, Dennis and Russell F. Lee (1992). "Procedures for Substituting Values for Missing NWS Meteorological Data for Use in Regulatory Air Quality Models."

<http://www.epa.gov/scram001/surface/missdata.txt>

Briggs, G.A. (1972). "Discussion on Chimney Plumes in Neutral and Stable Surroundings." *Atmos. Environ.* 6:507-510.

California Air Pollution Control Officers Association (CAPCOA) guidance document (2011). "Modeling Compliance of The Federal 1-Hour NO<sub>2</sub> NAAQS."

[http://www.valleyair.org/busind/pto/Tox\\_Resources/CAPCOANO2GuidanceDocument10-27-11.pdf](http://www.valleyair.org/busind/pto/Tox_Resources/CAPCOANO2GuidanceDocument10-27-11.pdf).

Cole, Henry S. and John E. Summerhays (1979). "A Review of Techniques Available for Estimating Short-Term NO<sub>2</sub> Concentrations," *Journal of the Air Pollution Control Association*, Volume 29, Number 8, pages 812-817, August 1979.

Nappo, C. J. et al. (1982). "The Workshop on the Representativeness of Meteorological Observations," June 1981, Boulder, Co. *Bull. Amer. Meteor. Soc.*, Vol. 63, No. 7, pp. 761-764. American Meteorological Society, Boston, MA.

Office of Environmental Health Hazard Analysis (OEHHA) (2003). "Air Toxics Hot Spots Program Guidance Manual for Preparation of Health Risk Assessments," August 2003.

San Joaquin Valley Air Pollution Control District (SJVAPCD) (2007). "Guidance for Air Dispersion Modeling."

[http://www.valleyair.org/busind/pto/Tox\\_Resources/Modeling%20Guidance%20W\\_O%20Pic.pdf](http://www.valleyair.org/busind/pto/Tox_Resources/Modeling%20Guidance%20W_O%20Pic.pdf)

South Coast Air Quality Management District (SCAQMD). "AQMD Modeling Guidance for AERMOD."

[http://www.aqmd.gov/smog/metdata/AERMOD\\_ModelingGuidance.html](http://www.aqmd.gov/smog/metdata/AERMOD_ModelingGuidance.html)

South Coast Air Quality Management District (SCAQMD) (2005). "Risk Assessment Procedures for Rule 1401 and 212"

<http://www.aqmd.gov/prdas/pdf/riskassessmentprocedures-v7.pdf>

U.S. Environmental Protection Agency (USEPA) (1985). “Guideline for Determination of Good Engineering Practice Stack Height,” (Technical Support Document for the Stack Height Regulations) - Revised. EPA-450/4-80-023R.

USEPA (1987a). “Ambient Monitoring Guidelines for Prevention of Significant Deterioration (PSD),” Office of Air Quality Planning and Standards, Research Triangle Park, NC, EPA-450/4-87-007, May 1987.

USEPA (1987b). “On-Site Meteorological Program Guidance for Regulatory Modeling Applications.”

USEPA (1987c). “Supplement A to the Guideline on Air Quality Models (Revised).”

USEPA (1990). “New Source Review Workshop Manual – Draft.” Office of Air Quality Planning and Standards, Research Triangle Park, NC.

USEPA (1992a). “Procedures for Substituting Values for Missing NWS Meteorological Data for Use in Regulatory Air Quality Models.” Office of Air Quality Planning and Standards, Research Triangle Park, NC. July 7, 1992.

USEPA (1992b). “Screening Procedures for Estimating the Air Quality Impact of Stationary Sources, Revised,” Report 454/R-92-019.

USEPA (1995). “Supplement C to the Guideline on Air Quality Models (revised).” Office of Air Quality Planning and Standards, Research Triangle Park, NC.

USEPA (1998). “Interagency Workgroup on Air Quality Modeling (IWAQM) Phase 2 Summary Report and Recommendations for Modeling Long-Range Transport Impacts,” Air Quality Modeling Group (MD-14), Research Triangle Park. National Park Service - Air Resource Division, Denver, Colorado. USDA Forest Service - Air Quality Program, Fort Collins, Colorado. U.S. Fish and Wildlife Service Air Quality Branch, Denver, Colorado.

USEPA (2000). “Meteorological Monitoring Guidance for Regulatory Modeling Applications,” EPA-454/R-99-005. Office of Air Quality Planning & Standards, Research Triangle Park, NC. (PB 2001-103606) [www.epa.gov/scram001/](http://www.epa.gov/scram001/)

USEPA (2005). 40 CFR Part 51, Appendix W. “Guideline on Air Quality Models,” Last update November 9, 2005.

USEPA (2008). “AERSURFACE Users Guide,” EPA-454/B-08-001. Office of Air Quality Planning and Standards, Research Triangle Park, NC. January 2008. [http://www.epa.gov/scram001/7thconf/aermod/aersurface\\_userguide.pdf](http://www.epa.gov/scram001/7thconf/aermod/aersurface_userguide.pdf)

USEPA (2009). Office of Air Quality Planning and Standards (OAQPS), AERMOD Implementation Workgroup, “AERMOD Implementation Guide,” Last Revised: March 19, 2009.

USEPA (2010a). OAQPS, Memo from Stephen D. Page, Director, to EPA Regional Modeling Contacts and others, “Modeling Procedures for Demonstrating Compliance with PM<sub>2.5</sub> NAAQS,” March 23, 2010.

USEPA (2010b). OAQPS, Memo from Tyler Fox, Leader, Air Quality Modeling Group, to EPA Regional Air Division Directors, “Applicability of Appendix W Modeling Guidance for the 1-hour NO<sub>2</sub> National Ambient Air Quality Standard,” June 28, 2010.

USEPA (2010c). OAQPS, Memo from Stephen D. Page, Director, to EPA Regional Air Division Directors, “Guidance Concerning the Implementation of the 1-hour NO<sub>2</sub> NAAQS for the Prevention of Significant Deterioration Program,” June 29, 2010.

USEPA (2010d). OAQPS, Memo from Stephen D. Page, Director, to EPA Regional Air Division Directors, “Guidance Concerning the Implementation of the 1-hour SO<sub>2</sub> NAAQS for the Prevention of Significant Deterioration Program,” August 23, 2010.

USEPA (2010e). 75 FR 64864, “Prevention of Significant Deterioration (PSD) for Particulate Matter Less Than 2.5 Micrometers (PM<sub>2.5</sub>)—Increments, Significant Impact Levels (SILs) and Significant Monitoring Concentration (SMC),” October 20, 2010.

USEPA (2011a). OAQPS, Memo from Tyler Fox, Leader, Air Quality Modeling Group, to EPA Regional Air Division Directors, “Additional Clarification Regarding Application of Appendix W Modeling Guidance for the 1-hour NO<sub>2</sub> National Ambient Air Quality Standard,” March 1, 2011.

USEPA (2011b). Technology Transfer Network, Support Center for Regulatory Atmospheric Modeling, Air Quality Models, AERMOD Release 11059 and latest guidance (Draft user’s guide addenda dated 3/4/11). <http://www.epa.gov/ttn/scram/>

USEPA (2012). EPA NO<sub>2</sub> / NO<sub>x</sub> In-Stack Ratio (ISR) Database, [http://www.epa.gov/ttn/scram/no2\\_isr\\_database.htm](http://www.epa.gov/ttn/scram/no2_isr_database.htm)

###

## Appendix A

### Information on CTSCREEN Model

#### The CTDMPLUS and CTSCREEN Models

Complex terrain impacts may need to be modeled with more accuracy than that provided by AERMOD. The use of more refined modeling techniques is specifically addressed in USEPA's Appendix W<sup>21</sup> modeling guidance, as follows:

*Since AERMOD treats dispersion in complex terrain, we have merged sections 4 and 5 of appendix W, as proposed in the April 2000 NPR [Notice of Proposed Rulemaking]. And while AERMOD produces acceptable regulatory design concentrations in complex terrain, it does not replace CTDMPLUS for detailed or receptor-oriented complex terrain analysis, as we have made clear in Guideline section 4.2.2. CTDMPLUS remains available for use in complex terrain. [p. 68225]*

#### *4.2.2 Refined Analytical Techniques*

*d. If the modeling application involves a well defined hill or ridge and a detailed dispersion analysis of the spatial pattern of plume impacts is of interest, CTDMPLUS, listed in Appendix A, is available. CTDMPLUS provides greater resolution of concentrations about the contour of the hill feature than does AERMOD through a different plume-terrain interaction algorithm. [p. 68233]*

CTSCREEN is the same basic model as CTDMPLUS, except that meteorological data are handled internally in a simplified manner. As discussed in the CTSCREEN users guide,<sup>22</sup>

*Since [CTDMPLUS] accounts for the three-dimensional nature of plume and terrain interaction, it requires detailed terrain and meteorological data that are representative of the modeling domain. Although the terrain data may be readily obtained from topographic maps and digitized for use in the CTDMPLUS, the required meteorological data may not be as readily available.*

*Since the meteorological input requirements of the CTDMPLUS can limit its application, the EPA's Complex-Terrain-Modeling, Technology-*

---

<sup>21</sup> 40 CFR 51 Subpart W, as amended November 9, 2005 at 70 FR 68218, "Revision to the Guideline on Air Quality Models: Adoption of a Preferred General Purpose (Flat and Complex Terrain) Dispersion Model and Other Revisions."

<sup>22</sup> USEPA, EPA-600/8-90-087, "User's Guide to CTDMPLUS: Volume 2. The Screening Mode (CTSCREEN)," October 1990.

*Transfer Workgroup developed a methodology to use the advanced techniques of CTDMPLUS in situations where on-site meteorological measurements are limited or unavailable. This approach uses CTDMPLUS in a “screening” mode--actual source and terrain characteristics are modeled with an extensive array of predetermined meteorological conditions.*

*This CTDMPLUS screening mode (CTSCREEN) serves several purposes in regulatory applications. When meteorological data are unavailable, CTSCREEN can be used to obtain conservative (safely above those of refined models), yet realistic, impact estimates for particular sources.*

Therefore, the use of the CTSCREEN version of CTDMPLUS is consistent with USEPA guidance.



## Appendix B

### Proposed NO<sub>2</sub>:NO<sub>x</sub> Ratios for Modeling Compliance with One-Hour NO<sub>2</sub> Standards

The use of the Tier 3 PVMRM and OLM options in AERMOD requires the specification of an in-stack ratio (ISR) of NO<sub>2</sub>/NO<sub>x</sub> for each NO<sub>x</sub> emissions source. The October 27, 2011 CAPCOA Guidance Document, titled “Modeling Compliance of The Federal 1-Hour NO<sub>2</sub> NAAQS,”<sup>23</sup> emphasized the importance of these in-stack ratios for the 1-hour NO<sub>2</sub> NAAQS, recommending that in-stack ratios used with either the OLM or PVMRM options be justified based on the specific application.

EPA OAQPS is in the process of creating a database of test results that support in-stack NO<sub>2</sub>:NO<sub>x</sub> ratios for specific source types. As discussed in Section 4.1 of the protocol, we are proposing to use EPA’s ISR database for the Project.

EPA’s ISR database is at [http://www.epa.gov/ttn/scram/no2\\_isr\\_database.htm](http://www.epa.gov/ttn/scram/no2_isr_database.htm). As of October 2012, the file NO2\_ISR\_database.xlsx, which is to provide the NO<sub>2</sub> ISR data that have been submitted via the formal collection initiated by OAQPS, contained no data. Therefore, we propose to use the data in the file NO2\_ISR\_alpha\_database.xlsx. According to the website, the “alpha” file “contains NO<sub>2</sub> ISR values collected by various Regional, State, and Local air permitting offices prior to the formal collection initiated by OAQPS. While this database contains a large number of entries, none fully satisfy the requirements for the formal collection effort.” However, in the absence of data submitted via the formal collection effort, the “alpha” data appear to be the best data available for determining NO<sub>2</sub>/NO<sub>x</sub> ISRs.

Following is a description of the procedures followed to obtain proposed NO<sub>2</sub>/NO<sub>x</sub> ratios from the ISR database for the equipment associated with the Project.

#### Natural Gas-Fired Gas Turbines

1. Make the spreadsheet sortable; filter “Equipment” for “combustion turbine 7FA+e,” “turbine,” “CT” and “blank” (blank equipment field included to avoid inadvertently eliminating any records that included data for gas turbines). This results in 112 listings, all of which are from Region 10. Eliminate records for equipment at the “CenterPoint Energy-- Dunn” site, as investigation shows that those units are RICE.
2. Using the “Fuel type” field, eliminate records for Diesel-fueled units.
3. Using the “Equipment make and model” field, eliminate records for Solar Centaur 4400 BHP turbines, since those turbines are much smaller than the turbines to be used for this project.

---

<sup>23</sup> Available at [http://www.valleyair.org/busind/pto/Tox\\_Resources/CAPCOANO2GuidanceDocument10-27-11.pdf](http://www.valleyair.org/busind/pto/Tox_Resources/CAPCOANO2GuidanceDocument10-27-11.pdf).

This leaves 104 records for 12 turbines: nine GE turbines and three Siemens turbines. For these records, the total NO<sub>x</sub> emissions concentrations range from 3 to 16.2 ppmc and the NO<sub>2</sub>/NO<sub>x</sub> ratio ranges from 1 to about 17%, with an average of 7%. The higher NO<sub>x</sub> emission rates and higher NO<sub>2</sub>/NO<sub>x</sub> ratios are associated with the Siemens turbine records that also indicate only DLN, and no SCR, NO<sub>x</sub> emissions control. Eliminating the DLN-only records leaves 41 records, with total NO<sub>x</sub> emissions ranging from 3.0 to 4.3 ppmc. NO<sub>2</sub>/NO<sub>x</sub> ratios range from 1 to 12%, with an average 1%; 39 of the records have ISRs of less than 1% while 2 of the records have ISRs of approximately 12%.

The CAPCOA 2011 NO<sub>2</sub> guidance recommends a NO<sub>2</sub>/NO<sub>x</sub> ratio of 9.1%. Based on the data described above, we propose to use a NO<sub>2</sub>/NO<sub>x</sub> ratio of 9.1% for the ISR for the gas turbines.

### Diesel Generators and Diesel Construction Equipment

1. Sort by fuel to select all Diesel, #2 Diesel, and blank fuel fields to eliminate natural gas, biogas, and waste gas-fueled engines, leaving 146 records.
2. Eliminate records for engines at AEL&P Lemon Creek, which are described as “2-stroke, medium speed engines” as the emergency engines and most construction engines are expected to be 4-stroke.
3. Eliminate any engines equipped with SCR—the engine associated with the Project will be a black start generator so will not have SCR, leaving 119 records. Construction Diesel engines will similarly not have SCR.
4. Eliminate records for engines at Centerpoint Energy Dunn, which are natural gas-fired compressor engines.
5. Eliminate records for water pumps, as water pumps have a different operating profile than the emergency and construction engines for this project.

The remaining 31 records are for marine vessel-mounted engines. Of these, 1 has an oxidation catalyst, 11 records are for Diesel particulate filter (DPF)-equipped engines, and the rest have no controls. The black start generator and the construction equipment associated with the Project are not expected to have oxidation catalysts, but are expected to have emission controls, so only the DPF-equipped engines are used for the analysis.

For the black start engine, we eliminated any tests at loads below 80%, as the engine will operate mainly for testing at or near full load.


The DPF-equipped engines range in size from 250 hp to 2710 kW (3634 hp). The NO<sub>2</sub>:NO<sub>x</sub> ratios range from 0.05 to 0.37, with an average of 0.155. The CAPCOA 2011 NO<sub>2</sub> guidance recommends a NO<sub>2</sub>/NO<sub>x</sub> ratio of 20%. Only one of the engines (two records) in the database has a ratio over 0.2: a 250 hp HPU (hydraulic power unit) engine. Without that engine, the average ratio is about 0.11. We are proposing to use

CAPCOA's recommended ratio of 20% as reasonable and conservative for the emergency Diesel generators.


For the construction Diesel engines, we included tests at all loads as those engines often run at lower loads. The NO<sub>2</sub>:NO<sub>x</sub> ratios range from 0.0058 to 0.4694, with an average of 0.11. Consistent with the ratio for the black start generator, we are proposing to use a NO<sub>2</sub>:NO<sub>x</sub> ratio of 20% for the construction equipment.




Second Quarter, 2005 – 2009




Third Quarter, 2005 – 2009



Fourth Quarter, 2005 – 2009



Annual, 2005 – 2009





**APPENDIX 3.1D – CONSTRUCTION EMISSIONS AND SUPPORT DATA**

## Construction Emissions

Emissions during the construction phase of the project have been estimated, and include an assessment of emissions from vehicle and equipment exhaust and the fugitive dust generated from material handling. A dispersion modeling analysis was conducted based on these emissions. The results of the analysis indicate that construction activities are not expected to cause or contribute to exceedances of state or federal standards for criteria pollutants. The best available emission control techniques will be used to minimize emissions during construction. The project construction impacts are not unusual in comparison to most construction sites; construction sites that use good dust suppression techniques and low-emitting vehicles typically do not cause violations of air quality standards.

The primary emission sources during construction will include exhaust from heavy construction equipment and vehicles, and fugitive dust generated in areas disturbed by grading, excavating, and erection of facility structures. The projected construction schedule has a duration of 20 months, during which different areas within the proposed site and a nearby temporary laydown area will be disturbed. Estimated land disturbance for major construction activities is summarized in Section 2.0, Project Description.

Combustion emissions during construction will result from the following:

- Exhaust from the diesel construction equipment used for site preparation, grading, excavation, trenching, and construction of onsite structures;
- Exhaust from water trucks used to control construction dust emissions;
- Exhaust from portable welding machines;
- Exhaust from pickup trucks and diesel trucks used to transport workers and materials around the construction site;
- Exhaust from diesel trucks used to deliver concrete, fuel, and construction supplies to the construction site including the heavy hauling of major components using truck and/or rail; and
- Exhaust from vehicles used by workers to commute to the construction site.

Fugitive dust emissions from the construction of the project will result from the following:

- Dust entrained during site preparation and grading/excavation at the construction site;
- Dust entrained during onsite travel on paved and unpaved surfaces;
- Dust entrained during aggregate and soil loading and unloading operations; and
- Wind erosion of areas disturbed during construction activities.

To determine the potential worst-case daily construction impacts, exhaust and dust emission rates have been evaluated for each source of emissions. Maximum short-term impacts are calculated based on the equipment mix expected during the second month of the construction schedule. Annual emissions are based on the equipment mix during the peak 12-month period out of the overall construction period.

## Available Mitigation Measures

Listed below are typical mitigation measures being proposed to control exhaust emissions from the diesel heavy equipment and potential emissions of fugitive dust during construction of the project.

- Unpaved roads and disturbed areas in the project construction site will be watered as frequently as necessary to prevent fugitive dust plumes. The frequency of watering can be reduced or eliminated during periods of precipitation.
- The vehicle speed limit will be 15 miles per hour within the construction site.
- The construction site entrances shall be posted with visible speed limit signs.
- Construction equipment vehicle tires will be inspected and washed as necessary to be cleaned free of dirt prior to entering paved roadways.
- Gravel ramps of at least 20 feet in length will be provided at the tire washing/cleaning station.
- Unpaved exits from the construction site will be graveled or treated to prevent track-out to public roadways.
- Construction vehicles will enter the construction site through the treated entrance roadways, unless an alternative route has been submitted to and approved by the Compliance Project Manager.
- Construction areas adjacent to any paved roadway will be provided with sandbags or other measures as specified in the Storm Water Pollution Prevention Plan (SWPPP) to prevent run-off to roadways.
- Paved roads within the construction site will be swept at least twice daily (or less during periods of precipitation) on days when construction activity occurs to prevent the accumulation of dirt and debris.
- At least the first 500 feet of any public roadway exiting from the construction site shall be swept at least twice daily (or less during periods of precipitation) on days when construction activity occurs or on any other day when dirt or runoff from the construction site is visible on public roadways.
- Soil storage piles and disturbed areas that remain inactive for longer than 10 days will be covered or treated with appropriate dust suppressant compounds.
- Vehicles used to transport solid bulk material on public roadways and having the potential to cause visible emissions will be provided with a cover, or the materials will be sufficiently wetted and loaded onto the trucks in a manner to provide at least one foot of freeboard.
- Wind erosion control techniques (such as windbreaks, water, chemical dust suppressants, and/or vegetation) will be used on all construction areas that may be disturbed. Any windbreaks installed to comply with this condition shall remain in place until the soil is stabilized or permanently covered with vegetation.

An on-site Air Quality Construction Mitigation Manager will be responsible for directing and documenting compliance with construction-related mitigation conditions.

**Table 3.1D-1**  
**Daily and Annual Construction Emissions**

| <b>Daily Construction Emissions (peak month)</b> |        |        |       |      |        |       |
|--|--------|--------|-------|------|--------|-------|
| <b>(lbs/day)</b>                                 |        |        |       |      |        |       |
|  | NOx    | CO     | VOC   | SOx  | PM10   | PM2.5 |
| Onsite   |        |        |       |      |        |       |
| Off-Road Equipment                               | 206.44 | 217.99 | 32.13 | 0.41 | 13.43  | 13.43 |
| Fugitive Dust                                    |        |        |       |      | 8.95   | 4.91  |
| Subtotal =                                       | 206.44 | 217.99 | 32.13 | 0.41 | 22.38  | 18.34 |
| Offsite  |        |        |       |      |        |       |
| Worker Travel                                    | 32.47  | 295.61 | 26.17 | 0.61 | 2.65   | 2.45  |
| Truck Emissions                                  | 45.91  | 20.17  | 3.35  | 0.08 | 1.73   | 1.59  |
| Hauling Deliveries                               | 10.62  | 5.56   | 0.97  | 0.02 | 0.44   | 0.40  |
| Worker Travel –Fugitive Dust                     |        |        |       |      | 74.53  | 1.10  |
| Truck –Fugitive Dust                             |        |        |       |      | 2.68   | 0.07  |
| Hauling –Fugitive Dust                           |        |        |       |      | 10.92  | 0.02  |
| Subtotal =                                       | 89.00  | 321.34 | 30.49 | 0.71 | 92.95  | 5.63  |
| Total =  | 295.44 | 539.33 | 62.62 | 1.12 | 115.33 | 23.97 |

| <b>Peak Annual Construction Emissions</b>  |       |       |      |      |       |      |
|--|-------|-------|------|------|-------|------|
| <b>(tons/yr, rolling 12-month maximum)</b> |       |       |      |      |       |      |
|  | NOx   | CO    | VOC  | SOx  | PM2.5 | PM10 |
| Onsite                                     |       |       |      |      |       |      |
| Construction Equipment                     | 19.81 | 23.47 | 3.12 | 0.01 | 1.50  | 1.50 |
| Fugitive Dust                              |       |       |      |      | 0.39  | 0.19 |
| Subtotal =                                 | 19.81 | 23.47 | 3.12 | 0.01 | 1.89  | 1.69 |
| Offsite                                    |       |       |      |      |       |      |
| Worker Travel                              | 2.65  | 27.65 | 2.16 | 0.02 | 0.25  | 0.24 |
| Truck Emissions                            | 4.55  | 2.13  | 0.37 | 0.00 | 0.01  | 0.17 |
| Hauling Deliveries                         | 0.94  | 0.50  | 0.09 | 0.00 | 0.01  | 0.01 |
| Worker Travel –Fugitive Dust               |       |       |      |      | 6.00  | 0.12 |
| Truck –Fugitive Dust                       |       |       |      |      | 0.26  | 0.00 |
| Hauling –Fugitive Dust                     |       |       |      |      | 0.81  | 0.00 |
| Subtotal =                                 | 8.14  | 30.28 | 2.62 | 0.02 | 7.34  | 0.54 |
| Total =                                    | 27.95 | 53.75 | 5.74 | 0.03 | 9.23  | 2.23 |

**Table 3.1D-2  
Modeled Emissions – Short-Term Impacts**

| <b>Short Term Impacts (24 hours and less)</b> |        |        |      |       |       |
|---|--------|--------|------|-------|-------|
|   | NOx    | CO     | SOx  | PM10  | PM2.5 |
| <b>TOTAL</b>                                  |        |        |      |       |       |
| Off Road Equipment (Combustion) (lbs/day)     | 206.44 | 217.99 | 0.41 | 13.43 | 13.43 |
| Off Road Equipment (Combustion) (hrs/day)     | 16     | 16     | 16   | 16    | 16    |
| Off Road Equipment (Combustion) (lbs/hr)      | 12.90  | 13.62  | 0.03 | 0.84  | 0.84  |
| Off Road Equipment (Combustion) (g/sec)       | 1.63   | 1.72   | 0.00 | 0.11  | 0.11  |
| Fugitive Dust (lbs/day)                       |        |        |      | 8.95  | 4.91  |
| Fugitive Dust (hrs/day)                       |        |        |      | 8     | 8     |
| Fugitive Dust (lbs/hr)                        |        |        |      | 1.12  | 0.61  |
| Fugitive Dust (g/sec)                         |        |        |      | 0.14  | 0.08  |

**Table 3.1D-3  
Modeled Emissions – Long-Term Impacts**

| <b>Long Term Impacts (annual)</b>         |       |       |      |      |       |
|---|-------|-------|------|------|-------|
|   | NOx   | CO    | SOx  | PM10 | PM2.5 |
| <b>TOTAL</b>                              |       |       |      |      |       |
| Off Road Equipment (Combustion) (tons/yr) | 19.81 | 23.47 | 0.01 | 1.50 | 1.50  |
| Off Road Equipment (Combustion) (days/yr) | 269   | 269   | 269  | 269  | 269   |
| Off Road Equipment (Combustion) (hrs/day) | 16    | 16    | 16   | 16   | 16    |
| Off Road Equipment (Combustion) (lbs/hr)  | 9.21  | 10.91 | 0.00 | 0.70 | 0.70  |
| Off Road Equipment (Combustion) (g/sec)   | 1.16  | 1.37  | 0.00 | 0.09 | 0.09  |
| Fugitive Dust (tons/yr)                   |       |       |      | 0.39 | 0.19  |
| Fugitive Dust(days/yr)                    |       |       |      | 269  | 269   |
| Fugitive Dust (hrs/day)                   |       |       |      | 16   | 16    |
| Fugitive Dust (lbs/hr)                    |       |       |      | 0.18 | 0.09  |
| Fugitive Dust (g/sec)                     |       |       |      | 0.02 | 0.01  |

**Table 3.1D-4  
Greenhouse Gas Emission Calculations**

| Construction GHG Emissions<br>(MT, Total for 20-month Construction Period) |          |      |      |          |
|--|----------|------|------|----------|
|  | CO2      | CH4  | N2O  | CO2e     |
| Off-Road Equipment   | 5863.51  | 0.52 | 0.00 | 5874.16  |
| Worker Travel  | 6541.29  | 0.34 | 0.00 | 6548.73  |
| Truck Emissions  | 964.14   | 0.00 | 0.00 | 964.54   |
| Hauling Emissions  | 136.88   | 0.00 | 0.00 | 136.97   |
| Total =  | 13505.82 | 0.86 | 0.00 | 13524.40 |



**Table 3.1D-5 (cont.)**

| Calendar Month     | Project Month                    | 2013   |        |        |        |        |        | 2014   |        |        |        |        |        |        |        |        |        |        |        | 2015   |        |       |
|--------------------|----------------------------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|-------|
|                    |                                  | July   | Aug    | Sep    | Oct    | Nov    | Dec    | Jan    | Feb    | Mar    | Apr    | May    | Jun    | July   | Aug    | Sep    | Oct    | Nov    | Dec    | Jan    | Feb    |       |
|                    |                                  | 1      | 2      | 3      | 4      | 5      | 6      | 7      | 8      | 9      | 10     | 11     | 12     | 13     | 14     | 15     | 16     | 17     | 18     | 19     | 20     |       |
| <b>CO2</b>         |                                  |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |       |
| Off-Road Equipment | (MT/month)                       | 85.13  | 87.64  | 186.97 | 510.73 | 339.14 | 357.21 | 313.58 | 289.29 | 310.06 | 314.95 | 303.13 | 274.90 | 286.45 | 252.12 | 264.12 | 243.75 | 299.10 | 338.31 | 441.84 | 365.09 |       |
| Hauling Emission   | (MT/month)                       | 13.66  | 13.66  | 13.66  | 19.30  | 15.01  | 15.73  | 16.48  | 14.33  | 15.05  | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   |       |
| Truck Emission     | (MT/month)                       | 58.68  | 78.58  | 75.01  | 89.55  | 86.24  | 96.19  | 73.41  | 63.83  | 67.02  | 47.75  | 44.94  | 40.21  | 35.24  | 32.17  | 22.47  | 20.55  | 15.32  | 8.81   | 5.62   | 2.55   |       |
| Worker Travel      | (MT/month)                       | 119.91 | 149.99 | 140.36 | 180.47 | 357.99 | 352.78 | 359.37 | 346.64 | 355.70 | 408.74 | 609.50 | 427.39 | 463.56 | 437.04 | 437.63 | 394.10 | 273.11 | 305.01 | 233.16 | 188.84 |       |
| Off-Road Equipment | Rolling 12-month total (MT/year) |        |        |        |        |        |        |        |        |        |        |        |        | 3,373  | 3,574  | 3,739  | 3,816  | 3,549  | 3,509  | 3,490  | 3,618  | 3,694 |
| Hauling Emission   | Rolling 12-month total (MT/year) |        |        |        |        |        |        |        |        |        |        |        |        | 137    | 123    | 110    | 96     | 77     | 62     | 46     | 29     | 15    |
| Truck Emission     | Rolling 12-month total (MT/year) |        |        |        |        |        |        |        |        |        |        |        |        | 821    | 798    | 752    | 699    | 630    | 559    | 472    | 404    | 343   |
| Worker Travel      | Rolling 12-month total (MT/year) |        |        |        |        |        |        |        |        |        |        |        |        | 3,809  | 4,152  | 4,440  | 4,737  | 4,950  | 4,866  | 4,818  | 4,692  | 4,534 |
| <b>CH4</b>         |                                  |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |       |
| Off-Road Equipment | (MT/month)                       | 0.01   | 0.01   | 0.02   | 0.04   | 0.03   | 0.03   | 0.03   | 0.03   | 0.03   | 0.03   | 0.03   | 0.02   | 0.03   | 0.02   | 0.02   | 0.02   | 0.03   | 0.03   | 0.03   | 0.03   |       |
| Hauling Emission   | (MT/month)                       | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   |       |
| Truck Emission     | (MT/month)                       | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   |       |
| Worker Travel      | (MT/month)                       | 0.01   | 0.01   | 0.01   | 0.01   | 0.02   | 0.02   | 0.02   | 0.02   | 0.02   | 0.02   | 0.03   | 0.02   | 0.02   | 0.02   | 0.02   | 0.02   | 0.01   | 0.02   | 0.01   | 0.01   |       |
| Off-Road Equipment | Rolling 12-month total (MT/year) |        |        |        |        |        |        |        |        |        |        |        |        | 0.31   | 0.33   | 0.34   | 0.34   | 0.32   | 0.32   | 0.32   | 0.32   | 0.32  |
| Hauling Emission   | Rolling 12-month total (MT/year) |        |        |        |        |        |        |        |        |        |        |        |        | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00  |
| Truck Emission     | Rolling 12-month total (MT/year) |        |        |        |        |        |        |        |        |        |        |        |        | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00  |
| Worker Travel      | Rolling 12-month total (MT/year) |        |        |        |        |        |        |        |        |        |        |        |        | 0.21   | 0.22   | 0.23   | 0.24   | 0.25   | 0.24   | 0.24   | 0.23   | 0.22  |
| <b>N2O</b>         |                                  |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |       |
| Off-Road Equipment | (MT/month)                       | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   |       |
| Hauling Emission   | (MT/month)                       | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   |       |
| Truck Emission     | (MT/month)                       | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   |       |
| Worker Travel      | (MT/month)                       | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   |       |
| Off-Road Equipment | Rolling 12-month total (MT/year) |        |        |        |        |        |        |        |        |        |        |        |        | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00  |
| Hauling Emission   | Rolling 12-month total (MT/year) |        |        |        |        |        |        |        |        |        |        |        |        | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00  |
| Truck Emission     | Rolling 12-month total (MT/year) |        |        |        |        |        |        |        |        |        |        |        |        | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00  |
| Worker Travel      | Rolling 12-month total (MT/year) |        |        |        |        |        |        |        |        |        |        |        |        | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00  |
| <b>CO2e</b>        |                                  |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |       |
| Off-Road Equipment | (MT/month)                       | 85.32  | 87.83  | 187.30 | 511.58 | 339.82 | 357.93 | 314.16 | 289.84 | 310.63 | 315.54 | 303.70 | 275.41 | 286.98 | 252.59 | 264.62 | 244.20 | 299.65 | 338.94 | 442.48 | 365.64 |       |
| Hauling Emission   | (MT/month)                       | 13.67  | 13.67  | 13.67  | 19.31  | 15.02  | 15.74  | 16.49  | 14.34  | 15.06  | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   |       |
| Truck Emission     | (MT/month)                       | 58.71  | 78.61  | 75.04  | 89.59  | 86.27  | 96.23  | 73.44  | 63.86  | 67.05  | 47.76  | 44.96  | 40.23  | 35.25  | 32.18  | 22.48  | 20.56  | 15.33  | 8.81   | 5.62   | 2.56   |       |
| Worker Travel      | (MT/month)                       | 120.05 | 150.17 | 140.53 | 180.68 | 358.42 | 353.20 | 359.78 | 347.03 | 356.10 | 409.20 | 610.19 | 427.87 | 464.08 | 437.53 | 438.12 | 394.55 | 273.42 | 305.36 | 233.41 | 189.04 |       |
| Off-Road Equipment | Rolling 12-month total (MT/year) |        |        |        |        |        |        |        |        |        |        |        |        | 3,379  | 3,581  | 3,745  | 3,823  | 3,555  | 3,515  | 3,496  | 3,625  | 3,700 |
| Hauling Emission   | Rolling 12-month total (MT/year) |        |        |        |        |        |        |        |        |        |        |        |        | 137    | 123    | 110    | 96     | 77     | 62     | 46     | 29     | 15    |
| Truck Emission     | Rolling 12-month total (MT/year) |        |        |        |        |        |        |        |        |        |        |        |        | 822    | 798    | 752    | 699    | 630    | 559    | 472    | 404    | 343   |
| Worker Travel      | Rolling 12-month total (MT/year) |        |        |        |        |        |        |        |        |        |        |        |        | 3,813  | 4,157  | 4,445  | 4,742  | 4,956  | 4,871  | 4,823  | 4,697  | 4,539 |



**Table 3.1D-6**  
**Daily Emission Calculations**

| Calendar Month           | 2013          |               |               |               |               |               | 2014          |               |               |               |               |               |               |               |               |               |               |               | 2015          |               |
|--------------------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|
|                          | July          | Aug           | Sep           | Oct           | Nov           | Dec           | Jan           | Feb           | Mar           | Apr           | May           | Jun           | July          | Aug           | Sep           | Oct           | Nov           | Dec           | Jan           | Feb           |
| Project Month            | 1             | 2             | 3             | 4             | 5             | 6             | 7             | 8             | 9             | 10            | 11            | 12            | 13            | 14            | 15            | 16            | 17            | 18            | 19            | 20            |
| <b>ROG (lbs/day)</b>     |               |               |               |               |               |               |               |               |               |               |               |               |               |               |               |               |               |               |               |               |
| Off-Road Equipment       | 5.96          | 6.51          | 14.17         | 30.97         | 21.10         | 22.18         | 22.28         | 23.89         | 24.13         | 23.44         | 22.60         | 21.43         | 20.37         | 19.67         | 19.67         | 17.48         | 24.36         | 23.98         | 32.13         | 30.73         |
| Hauling Emission         | 0.81          | 0.85          | 0.89          | 0.97          | 0.79          | 0.82          | 0.87          | 0.87          | 0.87          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          |
| Truck Emission           | 2.31          | 3.24          | 3.24          | 3.01          | 3.01          | 3.35          | 2.58          | 2.58          | 2.58          | 1.76          | 1.65          | 1.55          | 1.24          | 1.24          | 0.83          | 0.72          | 0.62          | 0.31          | 0.18          | 0.09          |
| Worker Travel            | 5.23          | 6.84          | 6.70          | 6.70          | 13.81         | 13.61         | 14.76         | 16.37         | 16.00         | 17.55         | 26.17         | 19.22         | 19.04         | 19.66         | 18.79         | 16.18         | 12.90         | 12.53         | 9.51          | 8.47          |
| <b>Total</b>             | <b>14.31</b>  | <b>17.44</b>  | <b>25.00</b>  | <b>41.65</b>  | <b>38.71</b>  | <b>39.96</b>  | <b>40.49</b>  | <b>43.71</b>  | <b>43.58</b>  | <b>42.75</b>  | <b>50.42</b>  | <b>42.20</b>  | <b>40.65</b>  | <b>40.57</b>  | <b>39.29</b>  | <b>34.38</b>  | <b>37.88</b>  | <b>36.82</b>  | <b>41.82</b>  | <b>39.29</b>  |
| <b>NOx (lbs/day)</b>     |               |               |               |               |               |               |               |               |               |               |               |               |               |               |               |               |               |               |               |               |
| Off-Road Equipment       | 38.22         | 41.51         | 91.24         | 194.20        | 135.02        | 142.03        | 142.01        | 151.68        | 153.83        | 149.31        | 143.88        | 136.50        | 129.79        | 125.26        | 125.26        | 111.06        | 155.46        | 152.98        | 206.44        | 189.90        |
| Hauling Emission         | 8.82          | 9.22          | 9.66          | 10.62         | 8.58          | 8.99          | 9.43          | 9.43          | 9.43          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          |
| Truck Emission           | 31.66         | 44.32         | 44.32         | 41.16         | 41.16         | 45.91         | 34.93         | 34.93         | 34.93         | 23.75         | 22.35         | 20.96         | 16.77         | 16.77         | 11.18         | 9.78          | 8.38          | 4.00          | 2.46          | 1.23          |
| Worker Travel            | 6.59          | 8.62          | 8.45          | 8.45          | 17.41         | 17.15         | 18.31         | 20.31         | 19.85         | 21.77         | 32.47         | 23.85         | 23.62         | 24.39         | 23.31         | 20.08         | 16.00         | 15.54         | 11.55         | 10.29         |
| <b>Total</b>             | <b>85.29</b>  | <b>103.67</b> | <b>153.67</b> | <b>254.43</b> | <b>202.17</b> | <b>214.08</b> | <b>204.68</b> | <b>216.35</b> | <b>218.04</b> | <b>194.83</b> | <b>198.70</b> | <b>181.31</b> | <b>170.18</b> | <b>166.42</b> | <b>159.75</b> | <b>140.92</b> | <b>179.84</b> | <b>172.71</b> | <b>220.45</b> | <b>201.42</b> |
| <b>CO (lbs/day)</b>      |               |               |               |               |               |               |               |               |               |               |               |               |               |               |               |               |               |               |               |               |
| Off-Road Equipment       | 41.49         | 45.54         | 98.60         | 200.69        | 142.74        | 152.71        | 171.74        | 183.67        | 191.08        | 184.64        | 181.14        | 172.99        | 163.85        | 157.41        | 157.41        | 141.29        | 191.34        | 187.81        | 217.99        | 199.85        |
| Hauling Emission         | 4.62          | 4.83          | 5.06          | 5.56          | 4.49          | 4.71          | 5.05          | 5.05          | 5.05          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          |
| Truck Emission           | 13.91         | 19.47         | 19.47         | 18.08         | 18.08         | 20.17         | 15.77         | 15.77         | 15.77         | 10.72         | 10.09         | 9.46          | 7.57          | 7.57          | 5.05          | 4.42          | 3.78          | 1.89          | 1.14          | 0.57          |
| Worker Travel            | 59.52         | 77.83         | 76.30         | 76.30         | 157.18        | 154.89        | 166.72        | 184.93        | 180.73        | 198.24        | 295.61        | 217.15        | 215.05        | 222.06        | 212.25        | 182.83        | 145.70        | 141.50        | 105.82        | 94.28         |
| <b>Total</b>             | <b>119.54</b> | <b>147.67</b> | <b>199.43</b> | <b>300.63</b> | <b>322.49</b> | <b>332.48</b> | <b>359.28</b> | <b>389.42</b> | <b>392.63</b> | <b>393.60</b> | <b>486.84</b> | <b>399.60</b> | <b>386.47</b> | <b>387.04</b> | <b>374.71</b> | <b>328.54</b> | <b>340.82</b> | <b>331.20</b> | <b>324.95</b> | <b>294.70</b> |
| <b>SO2 (lbs/day)</b>     |               |               |               |               |               |               |               |               |               |               |               |               |               |               |               |               |               |               |               |               |
| Off-Road Equipment       | 0.08          | 0.09          | 0.18          | 0.39          | 0.27          | 0.28          | 0.30          | 0.32          | 0.33          | 0.32          | 0.31          | 0.30          | 0.28          | 0.27          | 0.27          | 0.24          | 0.33          | 0.33          | 0.41          | 0.37          |
| Hauling Emission         | 0.01          | 0.01          | 0.01          | 0.02          | 0.01          | 0.01          | 0.02          | 0.02          | 0.02          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          |
| Truck Emission           | 0.05          | 0.07          | 0.07          | 0.07          | 0.07          | 0.08          | 0.07          | 0.07          | 0.07          | 0.05          | 0.04          | 0.04          | 0.03          | 0.03          | 0.02          | 0.02          | 0.02          | 0.01          | 0.01          | 0.00          |
| Worker Travel            | 0.11          | 0.15          | 0.14          | 0.14          | 0.30          | 0.29          | 0.34          | 0.38          | 0.37          | 0.41          | 0.61          | 0.45          | 0.44          | 0.46          | 0.44          | 0.38          | 0.30          | 0.29          | 0.24          | 0.21          |
| <b>Total</b>             | <b>0.25</b>   | <b>0.32</b>   | <b>0.40</b>   | <b>0.62</b>   | <b>0.65</b>   | <b>0.66</b>   | <b>0.73</b>   | <b>0.79</b>   | <b>0.79</b>   | <b>0.78</b>   | <b>0.96</b>   | <b>0.79</b>   | <b>0.75</b>   | <b>0.76</b>   | <b>0.73</b>   | <b>0.64</b>   | <b>0.65</b>   | <b>0.63</b>   | <b>0.66</b>   | <b>0.58</b>   |
| <b>PM10 (lbs/day)</b>    |               |               |               |               |               |               |               |               |               |               |               |               |               |               |               |               |               |               |               |               |
| Fugitive                 | 1.27          | 1.32          | 1.39          | 8.95          | 8.95          | 8.95          |               |               |               |               |               |               |               |               |               |               |               |               |               |               |
| Fugitive - Hauling       | 7.73          | 7.73          | 7.73          | 10.92         | 8.49          | 8.90          | 9.31          | 8.10          | 8.50          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          |
| Fugitive - Truck         | 1.85          | 2.59          | 2.59          | 2.40          | 2.40          | 2.68          | 2.31          | 2.31          | 2.31          | 1.57          | 1.48          | 1.39          | 1.11          | 1.11          | 0.74          | 0.65          | 0.55          | 0.28          | 0.18          | 0.09          |
| Fugitive - Worker Travel | 13.78         | 18.01         | 17.66         | 17.66         | 36.38         | 35.85         | 42.03         | 46.63         | 45.57         | 49.98         | 74.53         | 54.75         | 54.22         | 55.99         | 53.51         | 46.10         | 36.74         | 35.68         | 29.14         | 25.96         |
| <b>Total</b>             | <b>24.63</b>  | <b>29.65</b>  | <b>29.37</b>  | <b>39.93</b>  | <b>56.22</b>  | <b>56.38</b>  | <b>53.65</b>  | <b>57.04</b>  | <b>56.38</b>  | <b>51.55</b>  | <b>76.01</b>  | <b>56.14</b>  | <b>55.33</b>  | <b>57.10</b>  | <b>54.25</b>  | <b>46.75</b>  | <b>37.29</b>  | <b>35.96</b>  | <b>29.32</b>  | <b>26.05</b>  |
| Off-Road Equipment       | 2.59          | 2.92          | 6.02          | 11.94         | 8.98          | 9.58          | 11.00         | 11.97         | 12.25         | 11.87         | 11.67         | 11.11         | 10.51         | 10.13         | 10.13         | 9.18          | 12.19         | 11.99         | 13.43         | 12.30         |
| Hauling Emission         | 0.36          | 0.38          | 0.40          | 0.44          | 0.35          | 0.37          | 0.38          | 0.38          | 0.38          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          |
| Truck Emission           | 1.19          | 1.67          | 1.67          | 1.55          | 1.55          | 1.73          | 1.33          | 1.33          | 1.33          | 0.90          | 0.85          | 0.80          | 0.64          | 0.64          | 0.42          | 0.37          | 0.32          | 0.16          | 0.09          | 0.05          |
| Worker Travel            | 0.48          | 0.63          | 0.61          | 0.61          | 1.26          | 1.25          | 1.49          | 1.66          | 1.62          | 1.78          | 2.65          | 1.95          | 1.93          | 1.99          | 1.90          | 1.64          | 1.31          | 1.27          | 1.05          | 0.93          |
| <b>Total</b>             | <b>4.62</b>   | <b>5.60</b>   | <b>8.70</b>   | <b>14.54</b>  | <b>12.14</b>  | <b>12.93</b>  | <b>14.20</b>  | <b>15.34</b>  | <b>15.58</b>  | <b>14.55</b>  | <b>15.17</b>  | <b>13.86</b>  | <b>13.08</b>  | <b>12.76</b>  | <b>12.45</b>  | <b>11.19</b>  | <b>13.82</b>  | <b>13.42</b>  | <b>14.57</b>  | <b>13.28</b>  |
| Hauling Emission PM10    | 8.09          | 8.11          | 8.13          | 11.36         | 8.84          | 9.27          | 9.69          | 8.48          | 8.88          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          |
| Truck Emission PM10      | 3.04          | 4.26          | 4.26          | 3.95          | 3.95          | 4.41          | 3.64          | 3.64          | 3.64          | 2.47          | 2.33          | 2.19          | 1.75          | 1.75          | 1.16          | 1.02          | 0.87          | 0.44          | 0.27          | 0.14          |
| Worker Travel PM10       | 14.26         | 18.64         | 18.27         | 18.27         | 37.64         | 37.10         | 43.52         | 48.29         | 47.19         | 51.76         | 77.18         | 56.70         | 56.15         | 57.98         | 55.41         | 47.74         | 38.05         | 36.95         | 30.19         | 26.89         |
| <b>Total</b>             | <b>29.25</b>  | <b>35.25</b>  | <b>38.07</b>  | <b>54.47</b>  | <b>68.36</b>  | <b>69.31</b>  | <b>67.85</b>  | <b>72.38</b>  | <b>71.96</b>  | <b>66.10</b>  | <b>91.18</b>  | <b>70.00</b>  | <b>68.41</b>  | <b>69.86</b>  | <b>66.70</b>  | <b>57.94</b>  | <b>51.11</b>  | <b>49.38</b>  | <b>43.89</b>  | <b>39.33</b>  |
| <b>PM2.5 (lbs/day)</b>   |               |               |               |               |               |               |               |               |               |               |               |               |               |               |               |               |               |               |               |               |
| Fugitive                 | 0.00          | 0.00          | 0.00          | 4.91          | 4.91          | 4.91          |               |               |               |               |               |               |               |               |               |               |               |               |               |               |
| Fugitive - Hauling       | 0.01          | 0.02          | 0.02          | 0.02          | 0.01          | 0.01          | 0.02          | 0.02          | 0.02          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          |
| Fugitive - Truck         | 0.05          | 0.07          | 0.07          | 0.07          | 0.07          | 0.07          | 0.06          | 0.06          | 0.06          | 0.04          | 0.04          | 0.04          | 0.03          | 0.03          | 0.02          | 0.02          | 0.02          | 0.01          | 0.01          | 0.00          |
| Fugitive - Worker Travel | 0.20          | 0.27          | 0.26          | 0.26          | 0.54          | 0.53          | 0.62          | 0.69          | 0.67          | 0.74          | 1.10          | 0.81          | 0.80          | 0.83          | 0.79          | 0.68          | 0.54          | 0.53          | 0.43          | 0.38          |
| <b>Total</b>             | <b>0.26</b>   | <b>0.36</b>   | <b>0.35</b>   | <b>5.26</b>   | <b>5.53</b>   | <b>5.52</b>   | <b>0.70</b>   | <b>0.77</b>   | <b>0.75</b>   | <b>0.78</b>   | <b>1.14</b>   | <b>0.85</b>   | <b>0.83</b>   | <b>0.86</b>   | <b>0.81</b>   | <b>0.70</b>   | <b>0.56</b>   | <b>0.54</b>   | <b>0.44</b>   | <b>0.38</b>   |
| Off-Road Equipment       | 2.59          | 2.92          | 6.02          | 11.94         | 8.98          | 9.58          | 11.00         | 11.97         | 12.25         | 11.87         | 11.67         | 11.11         | 10.51         | 10.13         | 10.13         | 9.18          | 12.19         | 11.99         | 13.43         | 12.30         |
| Hauling Emission         | 0.33          | 0.35          | 0.37          | 0.40          | 0.33          | 0.34          | 0.35          | 0.35          | 0.35          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          |
| Truck Emission           | 1.10          | 1.53          | 1.53          | 1.42          | 1.42          | 1.59          | 1.22          | 1.22          | 1.22          | 0.83          | 0.78          | 0.73          | 0.59          | 0.59          | 0.39          | 0.34          | 0.29          | 0.15          | 0.09          | 0.04          |
| Worker Travel            | 0.44          | 0.58          | 0.57          | 0.57          | 1.17          | 1.15          | 1.38          | 1.54          | 1.50          | 1.65          | 2.45          | 1.80          | 1.79          | 1.84          | 1.76          | 1.52          | 1.21          | 1.17          | 0.97          | 0.87          |
| <b>Total</b>             | <b>4.46</b>   | <b>5.38</b>   | <b>8.49</b>   | <b>14.33</b>  | <b>11.90</b>  | <b>12.66</b>  | <b>13.95</b>  | <b>15.08</b>  | <b>15.32</b>  | <b>14.35</b>  | <b>14.90</b>  | <b>13.64</b>  | <b>12.89</b>  | <b>12.56</b>  | <b>12.28</b>  | <b>11.04</b>  | <b>13.69</b>  | <b>13.31</b>  | <b>14.49</b>  | <b>13.21</b>  |
| Hauling Emission PM2.5   | 0.34          | 0.37          | 0.39          | 0.42          | 0.34          | 0.35          | 0.37          | 0.37          | 0.37          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          | 0.00          |
| Truck Emission PM2.5     | 1.15          | 1.60          | 1.60          | 1.49          | 1.49          | 1.66          | 1.28          | 1.28          | 1.28          | 0.87          | 0.82          | 0.77          | 0.62          | 0.62          | 0.41          | 0.36          | 0.31          | 0.16          | 0.10          | 0.04          |
| Worker Travel PM2.5      | 0.64          | 0.85          | 0.83          | 0.83          | 1.71          | 1.68          | 2.00          | 2.23          | 2.17          | 2.39          | 3.55          | 2.61          | 2.59          | 2.67          | 2.55          | 2.20          | 1.75          | 1.70          | 1.40          | 1.25          |
| <b>Total</b>             | <b>4.72</b>   | <b>5.74</b>   | <b>8.84</b>   | <b>19.59</b>  | <b>17.43</b>  | <b>18.18</b>  | <b>14.65</b>  | <b>15.85</b>  | <b>16.07</b>  | <b>15.13</b>  | <b>16.04</b>  | <b>14.49</b>  | <b>13.72</b>  | <b>13.42</b>  | <b>13.09</b>  | <b>11.74</b>  | <b>14.25</b>  | <b>13.85</b>  | <b>14.93</b>  | <b>13.59</b>  |
| <b>CO2 (lbs/day)</b>     |               |               |               |               |               |               |               |               |               |               |               |               |               |               |               |               |               |               |               |               |
| Off-Road Equipment       | 8,163         | 8,785         | 19,634        | 41,714        | 28,765        | 30,297        | 30,066        | 31,897        | 32,560        | 31,570        | 30,385        | 28,867        |               |               |               |               |               |               |               |               |

**Table 3.1D-7**

**CalEEMod Input Data**

|                                  |                            |
|----------------------------------|----------------------------|
| <b>Project Name</b>              | ESECI                      |
| <b>District</b>                  | SCAQMD                     |
| <b>Wind Speed</b>                | 2.2 m/s                    |
| <b>Precipitation Frequency</b>   | 31 days/year               |
| <b>Climate Zone</b>              | 15                         |
| <b>Urbanization Level</b>        | Urban                      |
| <b>Expected Operational Year</b> | 2016                       |
| <b>Utility Company</b>           | Southern California Edison |
| <b>CO2 Intensity Factor</b>      | 641.26                     |
| <b>CH4 Intensity Factor</b>      | 0.029                      |
| <b>N2O Intensity Factor</b>      | 0.011                      |

**For 20-month Construction Schedule**

| CalEEMod Phase Name      | Phase Type            | Start Date | End Date   | # day/Week | Number of Days | Daily hours | Month |
|--------------------------|-----------------------|------------|------------|------------|----------------|-------------|-------|
| Demolition 1             | Demolition            | 2013/07/01 | 2013/07/31 | 5          | 23             | 8           | 1     |
| Demolition 2             | Demolition            | 2013/08/01 | 2013/08/31 | 5          | 22             | 8           | 2     |
| Demolition 3             | Demolition            | 2013/09/01 | 2013/09/30 | 5          | 25             | 8           | 3     |
| Site Grading 4           | Site Preparation      | 2013/10/01 | 2013/10/31 | 6          | 27             | 16          | 4     |
| Site Grading 5           | Site Preparation      | 2013/09/01 | 2013/09/30 | 6          | 25             | 16          | 5     |
| Site Grading 6           | Site Preparation      | 2013/10/01 | 2013/10/31 | 6          | 27             | 16          | 6     |
| Building Construction 7  | Building Construction | 2014/01/01 | 2014/01/31 | 5          | 23             | 8           | 7     |
| Building Construction 8  | Building Construction | 2014/02/01 | 2014/02/28 | 5          | 20             | 8           | 8     |
| Building Construction 9  | Building Construction | 2014/03/01 | 2014/03/31 | 5          | 21             | 8           | 9     |
| Building Construction 10 | Building Construction | 2014/04/01 | 2014/04/30 | 5          | 22             | 8           | 10    |
| Building Construction 11 | Building Construction | 2014/05/01 | 2014/05/31 | 5          | 22             | 8           | 11    |
| Building Construction 12 | Building Construction | 2014/06/01 | 2014/06/30 | 5          | 21             | 8           | 12    |
| Building Construction 13 | Building Construction | 2014/07/01 | 2014/07/31 | 5          | 23             | 8           | 13    |
| Building Construction 14 | Building Construction | 2014/08/01 | 2014/08/31 | 5          | 21             | 8           | 14    |
| Building Construction 15 | Building Construction | 2014/09/01 | 2014/09/30 | 5          | 22             | 8           | 15    |
| Building Construction 16 | Building Construction | 2014/10/01 | 2014/10/31 | 5          | 23             | 8           | 16    |
| Building Construction 17 | Building Construction | 2014/11/01 | 2014/11/30 | 5          | 20             | 8           | 17    |
| Building Construction 18 | Building Construction | 2014/12/01 | 2014/12/31 | 5          | 23             | 8           | 18    |
| Paving                   | Paving                | 2015/01/01 | 2015/01/31 | 5          | 21             | 8           | 19    |
| Architectural Coating    | Architectural Coating | 2015/02/01 | 2015/02/28 | 5          | 22             | 8           | 20    |





**Table 3.1D-10  
EMFAC Output**

| EMFAC2011 Emission                        |           | Region: South Coast AQMD |          | Calendar Year: 2013 |          | Vehicle Classification: EMFAC2007 Categories |          |          |          |          |          |          |          |  |  |  |  |  |  |
|---|-----------|--------------------------|----------|---------------------|----------|--|----------|----------|----------|----------|----------|----------|----------|--|--|--|--|--|--|
| Veh_Class                                 | LDA       | LDT1                     | LDT2     | MDV                 | LHD1     | LHD2   | MHD      | HHD      | OBUS     | UBUS     | MCY      | SBUS     | MH       |  |  |  |  |  |  |
| <b>EMFAC 2011 Emission Rates - Annual</b> |           |                          |          |                     |          |  |          |          |          |          |          |          |          |  |  |  |  |  |  |
| CH4_IDLEX (gms/trip)                      | 0         | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| CH4_RUNEX (gms/VMT)                       | 0.0064041 | 0.014393                 | 0.007113 | 0.009647            | 0.014114 | 0.011166                                     | 0.01758  | 0.019926 | 0.027492 | 0.036171 | 0.155926 | 0.029925 | 0.010471 |  |  |  |  |  |  |
| CH4_STREX (gms/trip)                      | 0         | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| CO_IDLEX (gms/trip)                       | 0         | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| CO_RUNEX (gms/VMT)                        | 2.1149861 | 5.082289                 | 2.863604 | 3.820193            | 3.929277 | 2.838538                                     | 4.194569 | 3.166295 | 7.958921 | 6.396781 | 28.90769 | 7.796711 | 7.467442 |  |  |  |  |  |  |
| CO_STREX (gms/trip)                       | 0         | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| CO2_IDLEX (gms/trip)                      | 0         | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| CO2_RUNEX (gms/VMT)                       | 371.79237 | 425.6814                 | 505.4595 | 638.7492            | 607.6722 | 581.8611                                     | 1038.268 | 1769.789 | 1138.004 | 2203.051 | 158.7879 | 1234.505 | 678.0106 |  |  |  |  |  |  |
| CO2_STREX (gms/trip)                      | 0         | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| NOX_IDLEX (gms/trip)                      | 0         | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| NOX_RUNEX (gms/VMT)                       | 0.1774866 | 0.444036                 | 0.33044  | 0.470929            | 2.178222 | 3.029517                                     | 5.419063 | 9.527669 | 7.064714 | 13.58459 | 1.302677 | 9.69994  | 2.080244 |  |  |  |  |  |  |
| NOX_STREX (gms/trip)                      | 0         | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| PM10_IDLEX (gms/trip)                     | 0         | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| PM10_PMBW (gms/VMT)                       | 0.03675   | 0.03675                  | 0.03675  | 0.03675             | 0.046265 | 0.062999                                     | 0.112047 | 0.060134 | 0.09098  | 0.677064 | 0.036746 | 0.575619 | 0.051331 |  |  |  |  |  |  |
| PM10_PMTW (gms/VMT)                       | 0.008     | 0.008                    | 0.008    | 0.008               | 0.008959 | 0.010003                                     | 0.011218 | 0.034781 | 0.010318 | 0.008    | 0.007999 | 0.011044 | 0.008623 |  |  |  |  |  |  |
| PM10_RUNEX (gms/VMT)                      | 0.0029933 | 0.00677                  | 0.002937 | 0.003139            | 0.010265 | 0.018791                                     | 0.159224 | 0.290476 | 0.159405 | 0.21437  | 0.001529 | 0.189875 | 0.034167 |  |  |  |  |  |  |
| PM10_STREX (gms/trip)                     | 0         | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| PM2.5_IDLEX (gms/trip)                    | 0         | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| PM2.5_PMBW (gms/VMT)                      | 0.01575   | 0.01575                  | 0.01575  | 0.01575             | 0.019828 | 0.027  | 0.04802  | 0.025772 | 0.038991 | 0.29017  | 0.015748 | 0.246694 | 0.021999 |  |  |  |  |  |  |
| PM2.5_PMTW (gms/VMT)                      | 0.002     | 0.002                    | 0.002    | 0.002               | 0.00224  | 0.002501                                     | 0.002805 | 0.008695 | 0.002579 | 0.002    | 0.002761 | 0.002156 | 0.002156 |  |  |  |  |  |  |
| PM2.5_RUNEX (gms/VMT)                     | 0.0027215 | 0.006175                 | 0.002683 | 0.002881            | 0.009443 | 0.017268                                     | 0.146438 | 0.267234 | 0.1466   | 0.197188 | 0.001206 | 0.174552 | 0.031352 |  |  |  |  |  |  |
| PM2.5_STREX (gms/trip)                    | 0         | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| ROG_DIURN (gms/trip)                      | 0         | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| ROG_HTSK (gms/trip)                       | 0         | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| ROG_IDLEX (gms/trip)                      | 0         | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| ROG_RESTL (gms/trip)                      | 0         | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| ROG_RUNEX (gms/VMT)                       | 0.1569633 | 0.352774                 | 0.17434  | 0.236449            | 0.345923 | 0.273679                                     | 0.430878 | 0.488395 | 0.673824 | 0.886556 | 3.821706 | 0.733456 | 0.256644 |  |  |  |  |  |  |
| ROG_RUNLS (gms/VMT)                       | 0.0022064 | 0.005189                 | 0.002212 | 0.002313            | 0.008802 | 0.016603                                     | 0.145193 | 0.262347 | 0.142678 | 0.197158 | 0.000659 | 0.166705 | 0.031333 |  |  |  |  |  |  |
| ROG_STREX (gms/trip)                      | 0         | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| SOX_IDLEX (gms/trip)                      | 0         | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| SOX_RUNEX (gms/VMT)                       | 0.0037473 | 0.004337                 | 0.005094 | 0.006442            | 0.006079 | 0.005737                                     | 0.010021 | 0.016905 | 0.011104 | 0.021175 | 0.002143 | 0.011975 | 0.006815 |  |  |  |  |  |  |
| SOX_STREX (gms/trip)                      | 0         | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| TOG_DIURN (gms/trip)                      | 0         | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| TOG_HTSK (gms/trip)                       | 0         | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| TOG_IDLEX (gms/trip)                      | 0         | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| TOG_RESTL (gms/trip)                      | 0         | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| TOG_RUNEX (gms/VMT)                       | 0.1779535 | 0.395911                 | 0.202392 | 0.277045            | 0.381748 | 0.303754                                     | 0.480022 | 0.555702 | 0.745834 | 0.985625 | 4.117167 | 0.815247 | 0.296722 |  |  |  |  |  |  |
| TOG_RUNLS (gms/VMT)                       | 0.0753128 | 0.228343                 | 0.10446  | 0.105847            | 0.146604 | 0.102687                                     | 0.065967 | 0.003057 | 0.133895 | 0.025105 | 0.535327 | 0.065888 | 0.018811 |  |  |  |  |  |  |
| TOG_STREX (gms/trip)                      | 0         | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |

*Methane (CH4) calculation method: Run EMFAC2011-LDV to calculate CH4 for those vehicle categories; Use CH4 = 0.0408 \* TOG = 0.058821 \* THC to calculate CH4 for EMFAC2011-HD categories. Running emissions for all pollutants and PM emissions from tire and brake wear were divided by the VMT of each respective vehicle class to derive emission factors in units of Since trip numbers reported in EMFAC for diesel emissions is unreliable, running emissions are adjusted to account also for the idling and startup emission, aggregated for both gasoline and diesel*

**Table 3.1D-10  
EMFAC Output (cont.)**

| EMFAC2011 Emission                        |            | Region: South Coast AQMD |          | Calendar Year: 2013 |          | Vehicle Classification: EMFAC2007 Categories |          |          |          |          |          |          |          |  |  |  |  |  |  |
|---|------------|--------------------------|----------|---------------------|----------|--|----------|----------|----------|----------|----------|----------|----------|--|--|--|--|--|--|
| Veh_Class                                 | DA         | LDT1                     | LDT2     | MDV                 | LHD1     | LHD2   | MHD      | HHD      | OBUS     | UBUS     | MCY      | SBUS     | MH       |  |  |  |  |  |  |
| <b>EMFAC 2011 Emission Rates - Summer</b> |            |                          |          |                     |          |  |          |          |          |          |          |          |          |  |  |  |  |  |  |
| CH4_IDLEX                                 | (gms/trip) | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| CH4_RUNEX                                 | (gms/VMT)  | 0.0069641                | 0.015917 | 0.007663            | 0.010169 | 0.013545                                     | 0.010746 | 0.016814 | 0.019741 | 0.025752 | 0.03641  | 0.164788 | 0.029538 |  |  |  |  |  |  |
| CH4_STREX                                 | (gms/trip) | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| CO_IDLEX                                  | (gms/trip) | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| CO_RUNEX                                  | (gms/VMT)  | 2.1457761                | 5.147307 | 2.914199            | 3.875278 | 3.601554                                     | 2.625732 | 3.835595 | 3.059351 | 6.993247 | 6.378591 | 27.92078 | 7.574027 |  |  |  |  |  |  |
| CO_STREX                                  | (gms/trip) | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| CO2_RUNEX                                 | (gms/VMT)  | 389.87975                | 445.2328 | 529.3177            | 669.3112 | 607.6722                                     | 581.8611 | 1038.922 | 1773.357 | 1139.62  | 2203.051 | 158.7879 | 1238.926 |  |  |  |  |  |  |
| CO2_STREX                                 | (gms/trip) | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| NOX_IDLEX                                 | (gms/trip) | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| NOX_RUNEX                                 | (gms/VMT)  | 0.159002                 | 0.394114 | 0.295514            | 0.421834 | 2.039017                                     | 2.856607 | 5.109537 | 9.049937 | 6.685318 | 12.79502 | 1.139109 | 9.218011 |  |  |  |  |  |  |
| NOX_STREX                                 | (gms/trip) | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| PM10_IDLEX                                | (gms/trip) | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| PM10_PMBW                                 | (gms/VMT)  | 0.03675                  | 0.03675  | 0.03675             | 0.046265 | 0.062999                                     | 0.112047 | 0.060134 | 0.09098  | 0.677064 | 0.036746 | 0.575619 | 0.051331 |  |  |  |  |  |  |
| PM10_PMTW                                 | (gms/VMT)  | 0.008                    | 0.008    | 0.008               | 0.008959 | 0.010003                                     | 0.011218 | 0.034781 | 0.010318 | 0.008    | 0.007999 | 0.011044 | 0.008623 |  |  |  |  |  |  |
| PM10_RUNEX                                | (gms/VMT)  | 0.0029933                | 0.00677  | 0.002937            | 0.003139 | 0.010265                                     | 0.018791 | 0.159075 | 0.290155 | 0.158838 | 0.21437  | 0.001529 | 0.18857  |  |  |  |  |  |  |
| PM10_STREX                                | (gms/trip) | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| PM2_5_IDLEX                               | (gms/trip) | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| PM2_5_PMBW                                | (gms/VMT)  | 0.01575                  | 0.01575  | 0.01575             | 0.019828 | 0.027  | 0.04802  | 0.025772 | 0.038991 | 0.29017  | 0.015748 | 0.246694 | 0.021999 |  |  |  |  |  |  |
| PM2_5_PMTW                                | (gms/VMT)  | 0.002                    | 0.002    | 0.002               | 0.00224  | 0.002501                                     | 0.002805 | 0.008695 | 0.002579 | 0.002    | 0.002    | 0.002761 | 0.002156 |  |  |  |  |  |  |
| PM2_5_RUNEX                               | (gms/VMT)  | 0.0027215                | 0.006175 | 0.002683            | 0.009443 | 0.017268                                     | 0.146301 | 0.266939 | 0.146078 | 0.197188 | 0.001206 | 0.173352 | 0.031352 |  |  |  |  |  |  |
| PM2_5_STREX                               | (gms/trip) | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| ROG_DIURN                                 | (gms/trip) | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| ROG_HTSK                                  | (gms/trip) | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| ROG_IDLEX                                 | (gms/trip) | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| ROG_RESTL                                 | (gms/trip) | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| ROG_RUNEX                                 | (gms/VMT)  | 0.1706881                | 0.390112 | 0.187817            | 0.249237 | 0.331977                                     | 0.263392 | 0.412097 | 0.483839 | 0.631165 | 0.892393 | 4.038927 | 0.723975 |  |  |  |  |  |  |
| ROG_RUNLS                                 | (gms/VMT)  | 0.0022064                | 0.005189 | 0.002212            | 0.002313 | 0.008802                                     | 0.016603 | 0.145193 | 0.262347 | 0.142678 | 0.197158 | 0.000659 | 0.166705 |  |  |  |  |  |  |
| ROG_STREX                                 | (gms/trip) | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| SOX_IDLEX                                 | (gms/trip) | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| SOX_RUNEX                                 | (gms/VMT)  | 0.0039282                | 0.004532 | 0.005333            | 0.006748 | 0.006073                                     | 0.010021 | 0.016938 | 0.011103 | 0.021175 | 0.002123 | 0.012014 | 0.006816 |  |  |  |  |  |  |
| SOX_STREX                                 | (gms/trip) | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| TOG_DIURN                                 | (gms/trip) | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| TOG_HTSK                                  | (gms/trip) | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| TOG_IDLEX                                 | (gms/trip) | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| TOG_RESTL                                 | (gms/trip) | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |
| TOG_RUNEX                                 | (gms/VMT)  | 0.1920735                | 0.433545 | 0.216475            | 0.290339 | 0.366706                                     | 0.292666 | 0.459808 | 0.550598 | 0.700048 | 0.991751 | 4.323996 | 0.804946 |  |  |  |  |  |  |
| TOG_RUNLS                                 | (gms/VMT)  | 0.0720826                | 0.214857 | 0.098148            | 0.10023  | 0.14382                                      | 0.100366 | 0.064699 | 0.003028 | 0.131253 | 0.02362  | 0.508437 | 0.060856 |  |  |  |  |  |  |
| TOG_STREX                                 | (gms/trip) | 0                        | 0        | 0                   | 0        | 0  | 0        | 0        | 0        | 0        | 0        | 0        | 0        |  |  |  |  |  |  |

Methane (CH4) calculation method: Run EMFAC2011-LDV to calculate CH4 for those vehicle categories; Use CH4 = 0.0408 \* TOG = 0.058821 \* THC to calculate CH4 for EMFAC2011-HD categories. Running emissions for all pollutants and PM emissions from tire and brake wear were divided by the VMT of each respective vehicle class to derive emission factors in units of Since trip numbers reported in EMFAC for diesel emissions is unreliable, running emissions are adjusted to account also for the idling and startup emission, aggregated for both gasoline and diesel

**Table 3.1D-10  
EMFAC Output (cont.)**

| Veh_Class                          | LDA       | LDT1     | LDTZ     | MDV      | LHD1     | LHD2     | MHD      | HHD      | OBUS     | UBUS     | MCY      | SBUS     | MH       |
|------------------------------------|-----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|
| EMFAC 2011 Emission Rates - Winter |           |          |          |          |          |          |          |          |          |          |          |          |          |
| CH4_IDLEX (gms/trip)               | 0         | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        |
| CH4_RUNEX (gms/VMT)                | 0.0066251 | 0.014878 | 0.007296 | 0.009788 | 0.014378 | 0.011381 | 0.017894 | 0.02013  | 0.027863 | 0.036164 | 0.159263 | 0.03019  | 0.010603 |
| CH4_STREX (gms/trip)               | 0         | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        |
| CO_IDLEX (gms/trip)                | 0         | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        |
| CO_RUNEX (gms/VMT)                 | 2.0826975 | 5.009002 | 2.818425 | 3.761276 | 3.949759 | 2.858022 | 4.275648 | 3.286081 | 8.120233 | 6.397682 | 28.81137 | 7.902465 | 7.443736 |
| CO_STREX (gms/trip)                | 0         | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        |
| CO2_IDLEX (gms/trip)               | 0         | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        |
| CO2_RUNEX (gms/VMT)                | 365.50806 | 419.0528 | 497.2435 | 628.3989 | 607.6722 | 581.8611 | 1037.363 | 1764.861 | 1135.774 | 2203.051 | 158.7879 | 1228.4   | 678.0106 |
| CO2_STREX (gms/trip)               | 0         | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        |
| NOX_IDLEX (gms/trip)               | 0         | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        |
| NOX_RUNEX (gms/VMT)                | 0.1737865 | 0.43396  | 0.323468 | 0.460983 | 2.151933 | 2.989843 | 5.326601 | 9.38302  | 6.950792 | 13.33742 | 1.275493 | 9.519693 | 2.041047 |
| NOX_STREX (gms/trip)               | 0         | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        |
| PM10_IDLEX (gms/trip)              | 0         | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        |
| PM10_PMBW (gms/VMT)                | 0.03675   | 0.03675  | 0.03675  | 0.03675  | 0.046265 | 0.062999 | 0.112047 | 0.060134 | 0.09098  | 0.677064 | 0.036746 | 0.575619 | 0.051331 |
| PM10_PMTW (gms/VMT)                | 0.008     | 0.008    | 0.008    | 0.008    | 0.008959 | 0.010003 | 0.011218 | 0.034781 | 0.010318 | 0.008    | 0.007999 | 0.011044 | 0.008623 |
| PM10_RUNEX (gms/VMT)               | 0.0029933 | 0.00677  | 0.002937 | 0.003139 | 0.010265 | 0.018791 | 0.15943  | 0.29092  | 0.160188 | 0.21437  | 0.001529 | 0.191677 | 0.034167 |
| PM10_STREX (gms/trip)              | 0         | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        |
| PM2_5_IDLEX (gms/trip)             | 0         | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        |
| PM2_5_PMBW (gms/VMT)               | 0.01575   | 0.01575  | 0.01575  | 0.01575  | 0.019828 | 0.027    | 0.04802  | 0.025772 | 0.038991 | 0.29017  | 0.015748 | 0.246694 | 0.021999 |
| PM2_5_PMTW (gms/VMT)               | 0.002     | 0.002    | 0.002    | 0.002    | 0.00224  | 0.002501 | 0.002805 | 0.008695 | 0.002579 | 0.002    | 0.002761 | 0.002156 | 0.002156 |
| PM2_5_RUNEX (gms/VMT)              | 0.0027215 | 0.006175 | 0.002683 | 0.002881 | 0.009443 | 0.017268 | 0.146628 | 0.267643 | 0.147321 | 0.197188 | 0.001206 | 0.17621  | 0.031352 |
| PM2_5_STREX (gms/trip)             | 0         | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        |
| ROG_DIURN (gms/trip)               | 0         | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        |
| ROG_HTSK (gms/trip)                | 0         | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        |
| ROG_IDLEX (gms/trip)               | 0         | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        |
| ROG_RESTL (gms/trip)               | 0         | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        |
| ROG_RUNEX (gms/VMT)                | 0.1623792 | 0.364662 | 0.178817 | 0.23991  | 0.352407 | 0.278956 | 0.438573 | 0.493338 | 0.682914 | 0.886382 | 3.903507 | 0.739944 | 0.25987  |
| ROG_RUNIS (gms/VMT)                | 0.0022064 | 0.005189 | 0.002212 | 0.002313 | 0.008802 | 0.016603 | 0.145193 | 0.262347 | 0.142678 | 0.197158 | 0.000659 | 0.166705 | 0.031333 |
| ROG_STREX (gms/trip)               | 0         | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        |
| SOX_IDLEX (gms/trip)               | 0         | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        |
| SOX_RUNEX (gms/VMT)                | 0.0036841 | 0.004269 | 0.005012 | 0.006338 | 0.006079 | 0.005738 | 0.010013 | 0.016858 | 0.011084 | 0.021175 | 0.002142 | 0.011917 | 0.006815 |
| SOX_STREX (gms/trip)               | 0         | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        |
| TOG_DIURN (gms/trip)               | 0         | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        |
| TOG_HTSK (gms/trip)                | 0         | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        |
| TOG_IDLEX (gms/trip)               | 0         | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        |
| TOG_RESTL (gms/trip)               | 0         | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        |
| TOG_RUNEX (gms/VMT)                | 0.1831502 | 0.407511 | 0.206562 | 0.280185 | 0.388319 | 0.309121 | 0.487969 | 0.561336 | 0.755487 | 0.985383 | 4.199993 | 0.822159 | 0.299904 |
| TOG_RUNLS (gms/VMT)                | 0.0845601 | 0.269575 | 0.122669 | 0.123278 | 0.158797 | 0.111551 | 0.071012 | 0.003247 | 0.142824 | 0.029133 | 0.615276 | 0.077574 | 0.019839 |
| TOG_STREX (gms/trip)               | 0         | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0        |

Methane (CH4) calculation method: Run EMFAC2011-LDV to calculate CH4 for those vehicle categories; Use CH4 = 0.0408 \* TOG = 0.058821 \* THC to calculate CH4 for EMFAC2011-HD categories.

Running emissions for all pollutants and PM emissions from tire and brake wear were divided by the VMT of each respective vehicle class to derive emission factors in units of Since trip numbers reported in EMFAC for diesel emissions is unreliable, running emissions are adjusted to account also for the idling and startup emission, aggregated for both gasoline and diesel

**APPENDIX 3.1E – COMMISSIONING EMISSIONS AND SUPPORT DATA**



**Table 3.1E-1**  
**EI Segundo Power Facility Modification**  
**Monthly Emissions - Commissioning Year**

|   | Hours per Month | CO (lbs/hr) | NOx (lbs/hr) | VOC (lbs/hr) | PM10 (lbs/hr) | SOx (lbs/hr) | NH3 (lbs/hr) | CO (lbs/month) | NOx (lbs/month) | VOC (lbs/month) | PM10 (lbs/month) | SOx (lbs/month) | NH3 (lbs/month) |
|---|-----------------|-------------|--------------|--------------|---------------|--------------|--------------|----------------|-----------------|-----------------|------------------|-----------------|-----------------|
| Unit 9 Commissioning (1)                  | 178             | 663.7       | 44.2         | 30.7         | 9.4           | 1.7          | 16.6         | 118,145        | 7,865           | 5,461           | 1,675            | 301             | 2,952           |
| Unit 9 Start-Up (Fast Start)              | 0               | 158.5       | 45.0         | 17.1         | 9.5           | 1.4          | 13.4         | 0              | 0               | 0               | 0                | 0               | 0               |
| Unit 9 Start-Up (Traditional)             | 0               | 291.0       | 62.3         | 23.3         | 9.5           | 1.4          | 13.4         | 0              | 0               | 0               | 0                | 0               | 0               |
| Unit 9 Normal Operation                   | 0               | 10.9        | 17.9         | 6.2          | 9.5           | 1.7          | 16.6         | 0              | 0               | 0               | 0                | 0               | 0               |
| Unit 9 Shutdown                           | 0               | 322.0       | 37.5         | 34.6         | 9.5           | 1.7          | 16.6         | 0              | 0               | 0               | 0                | 0               | 0               |
| <b>Unit 9 Totals</b>                      | <b>178</b>      |             |              |              |               |              |              | <b>118,145</b> | <b>7,865</b>    | <b>5,461</b>    | <b>1,675</b>     | <b>301</b>      | <b>2,952</b>    |
| Unit 11 Commissioning (2)                 | 121             | 116.7       | 44.1         | 10.0         | 7.9           | 0.4          | 3.5          | 14,120         | 5,331           | 1,208           | 962              | 43              | 425             |
| Unit 11 Start-Up                          | 60              | 89.8        | 30.4         | 7.4          | 5.0           | 0.2          | 3.5          | 5,389          | 1,823           | 442             | 300              | 12              | 211             |
| Unit 11 Normal Operation                  | 199             | 4.6         | 4.8          | 1.3          | 5.0           | 0.4          | 3.5          | 921            | 945             | 263             | 995              | 71              | 699             |
| Unit 11 Shutdown                          | 60              | 63.1        | 10.3         | 5.6          | 5.0           | 0.4          | 3.5          | 3,785          | 616             | 335             | 300              | 21              | 211             |
| <b>Unit 11 Totals</b>                     | <b>440</b>      |             |              |              |               |              |              | <b>24,214</b>  | <b>8,715</b>    | <b>2,248</b>    | <b>2,557</b>     | <b>148</b>      | <b>1,545</b>    |
| Unit 12 Commissioning (2)                 | 121             | 116.7       | 44.1         | 10.0         | 7.9           | 0.4          | 3.5          | 14,120         | 5,331           | 1,208           | 962              | 43              | 425             |
| Unit 12 Start-Up                          | 60              | 89.8        | 30.4         | 7.4          | 5.0           | 0.2          | 3.5          | 5,389          | 1,823           | 442             | 300              | 12              | 211             |
| Unit 12 Normal Operation                  | 199             | 4.6         | 4.8          | 1.3          | 5.0           | 0.4          | 3.5          | 921            | 945             | 263             | 995              | 71              | 699             |
| Unit 12 Shutdown                          | 60              | 63.1        | 10.3         | 5.6          | 5.0           | 0.4          | 3.5          | 3,785          | 616             | 335             | 300              | 21              | 211             |
| <b>Unit 12 Totals</b>                     | <b>440</b>      |             |              |              |               |              |              | <b>24,214</b>  | <b>8,715</b>    | <b>2,248</b>    | <b>2,557</b>     | <b>148</b>      | <b>1,545</b>    |
| <b>Total Monthly Emissions (lb/month)</b> |                 |             |              |              |               |              |              | <b>166,573</b> | <b>25,294</b>   | <b>9,956</b>    | <b>6,789</b>     | <b>597</b>      | <b>6,042</b>    |

Note 1: Based on highest 30 consecutive days of commissioning emissions for this unit

Note 2: Based on entire commissioning period for this unit

**Table 3.1E-2**  
**EI Segundo Power Facility Modification**  
**Annual Emissions - Commissioning Year**

|  | Hours per Year | CO (lbs/hr) | NOx (lbs/hr) | VOC (lbs/hr) | PM10 (lbs/hr) | SOx (lbs/hr) | NH3 (lbs/hr) | CO (lbs/yr)    | NOx (lbs/yr)   | VOC (lbs/yr)  | PM10 (lbs/yr)  | SOx (lbs/yr)  | NH3 (lbs/yr)   |
|--|----------------|-------------|--------------|--------------|---------------|--------------|--------------|----------------|----------------|---------------|----------------|---------------|----------------|
| Unit 9 Commissioning                     | 415            | 314.1       | 30.1         | 16.8         | 9.4           | 1.4          | 13.4         | 130,337        | 12,478         | 6,952         | 3,911          | 566           | 5,552          |
| Unit 9 Start-Up (Fast )                  | 150            | 158.5       | 45.0         | 17.1         | 9.5           | 1.4          | 13.4         | 23,769         | 6,746          | 2,561         | 1,425          | 204           | 2,007          |
| Unit 9 Start-Up (Trad )                  | 50             | 291.0       | 62.3         | 23.3         | 9.5           | 1.4          | 13.4         | 14,550         | 3,113          | 1,163         | 475            | 68            | 669            |
| Unit 9 Normal Operation                  | 4,641          | 10.9        | 17.9         | 6.2          | 9.5           | 1.7          | 16.6         | 50,701         | 83,294         | 1,764         | 44,090         | 7,843         | 76,956         |
| Unit 9 Shutdown                          | 200            | 322.0       | 37.5         | 34.6         | 9.5           | 1.7          | 16.6         | 64,392         | 7,495          | 6,924         | 1,900          | 338           | 3,316          |
| <b>Unit 9 Totals</b>                     | <b>5,456</b>   |             |              |              |               |              |              | <b>283,749</b> | <b>113,125</b> | <b>19,363</b> | <b>51,801</b>  | <b>9,019</b>  | <b>88,500</b>  |
| Unit 11 Commissioning                    | 121            | 116.7       | 44.1         | 10.0         | 7.9           | 0.4          | 3.5          | 14,120         | 5,331          | 1,208         | 962            | 43            | 425            |
| Unit 11 Start-Up                         | 480            | 89.8        | 30.4         | 7.4          | 5.0           | 0.2          | 3.5          | 43,111         | 14,580         | 3,533         | 2,400          | 97            | 1,686          |
| Unit 11 Normal Operation                 | 3,719          | 4.6         | 4.8          | 1.3          | 5.0           | 0.4          | 3.5          | 17,208         | 17,669         | 4,917         | 18,595         | 1,331         | 13,060         |
| Unit 11 Shutdown                         | 480            | 63.1        | 10.3         | 5.6          | 5.0           | 0.4          | 3.5          | 30,281         | 4,928          | 2,679         | 2,400          | 172           | 1,686          |
| <b>Unit 11 Totals</b>                    | <b>4,800</b>   |             |              |              |               |              |              | <b>104,719</b> | <b>42,509</b>  | <b>12,337</b> | <b>24,357</b>  | <b>1,643</b>  | <b>16,856</b>  |
| Unit 12 Commissioning                    | 121            | 116.7       | 44.1         | 10.0         | 7.9           | 0.4          | 3.5          | 14,120         | 5,331          | 1,208         | 962            | 43            | 425            |
| Unit 12 Start-Up                         | 480            | 89.8        | 30.4         | 7.4          | 5.0           | 0.2          | 3.5          | 43,111         | 14,580         | 3,533         | 2,400          | 97            | 1,686          |
| Unit 12 Normal Operation                 | 3,719          | 4.6         | 4.8          | 1.3          | 5.0           | 0.4          | 3.5          | 17,208         | 17,669         | 4,917         | 18,595         | 1,331         | 13,060         |
| Unit 12 Shutdown                         | 480            | 63.1        | 10.3         | 5.6          | 5.0           | 0.4          | 3.5          | 30,281         | 4,928          | 2,679         | 2,400          | 172           | 1,686          |
| <b>Unit 12 Totals</b>                    | <b>4,800</b>   |             |              |              |               |              |              | <b>104,719</b> | <b>42,509</b>  | <b>12,337</b> | <b>24,357</b>  | <b>1,643</b>  | <b>16,856</b>  |
| Aux Boiler (25% load)                    | 3,304          | 0.3         | 0.1          | 0.0          | 0.1           | 0.0          | 0.0          | 1,099          | 325            | 119           | 222            | 62            | 0              |
| Aux Boiler (100% load)                   | 33             | 1.3         | 0.4          | 0.1          | 0.3           | 0.1          | 0.0          | 44             | 13             | 5             | 9              | 2             | 0              |
| <b>Aux Boiler Totals</b>                 | <b>3,337</b>   |             |              |              |               |              |              | <b>1,143</b>   | <b>338</b>     | <b>124</b>    | <b>231</b>     | <b>64</b>     | <b>0</b>       |
| <b>Total Annual Emissions (lb/year)</b>  |                |             |              |              |               |              |              | <b>494,331</b> | <b>198,480</b> | <b>44,161</b> | <b>100,745</b> | <b>12,370</b> | <b>122,212</b> |
| <b>Total Annual Emissions (ton/year)</b> |                |             |              |              |               |              |              | <b>247.2</b>   | <b>99.2</b>    | <b>22.1</b>   | <b>50.4</b>    | <b>6.2</b>    | <b>61.1</b>    |

**Table 3.1E-3**

**El Segundo Power Facility Modification**

Commissioning Schedule for Units 9

| Dvr | Activity  | Duration (hr) | GT Load (%) | Modeling Load (%) | Startup/Shutdown Emissions (lbs) |      |     |    | Running Emissions (lbs) |       |       |      | Fuel Use |         |         |       | Total Emissions (lbs) |     |         |         | Fuel Use (lbs) |       |      |       | Calculated Hourly Emissions (lb/hr) |       |      |       |        |       |      |      |      |      |     |      |      |      |     |      |      |      |     |     |
|-----|---|---------------|-------------|-------------------|----------------------------------|------|-----|----|-------------------------|-------|-------|------|----------|---------|---------|-------|-----------------------|-----|---------|---------|----------------|-------|------|-------|-------------------------------------|-------|------|-------|--------|-------|------|------|------|------|-----|------|------|------|-----|------|------|------|-----|-----|
|     |   |               |             |                   | NOx                              | CO   | VOc | PM | NOx                     | CO    | VOc   | PM   | NOx      | CO      | VOc     | PM    | NOx                   | CO  | VOc     | PM      | NOx            | CO    | VOc  | PM    | NOx                                 | CO    | VOc  | PM    | NOx    | CO    | VOc  | PM   |      |      |     |      |      |      |     |      |      |      |     |     |
| 1   | GT Testing (F5NL, Excitation Test, Dummy Synch Checks)    | 8             | 0           | F5NL              | 6                                | 483  | 21  | 1  | 2474                    | 370   | 3008  | 1289 | 92       | 13752   | 376     | 30501 | 1310                  | 93  | 156236  | 47.0    | 3612.6         | 163.8 | 11.6 | 47.0  | 3612.6                              | 163.8 | 11.6 | 47.0  | 3612.6 | 163.8 | 11.6 |      |      |      |     |      |      |      |     |      |      |      |     |     |
| 2   | GT Testing @ 40% load                                     | 8             | 0-40        | 40                | 126                              | 3712 | 105 | 12 | 35229                   | 1475  | 13971 | 572  | 90       | 403519  | 1601    | 17683 | 677                   | 102 | 439048  | 200.1   | 2210.4         | 84.6  | 12.8 | 200.1 | 2210.4                              | 84.6  | 12.8 | 200.1 | 2210.4 | 84.6  | 12.8 |      |      |      |     |      |      |      |     |      |      |      |     |     |
| 3   | Steam Blow/HRS/S Tuning                                   | 12            | 0-25        | 25                | 69                               | 2648 | 77  | 8  | 19888                   | 1686  | 41064 | 892  | 136      | 462406  | 1755    | 43712 | 969                   | 144 | 482294  | 146.3   | 3642.7         | 80.8  | 12.0 | 146.3 | 3642.7                              | 80.8  | 12.0 | 146.3 | 3642.7 | 80.8  | 12.0 |      |      |      |     |      |      |      |     |      |      |      |     |     |
| 4   | Steam Blow/HRS/S Tuning                                   | 12            | 0-50        | 50                | 157                              | 3971 | 120 | 15 | 48447                   | 850   | 5176  | 593  | 96       | 697169  | 1007    | 9147  | 713                   | 111 | 745516  | 83.9    | 762.3          | 59.4  | 9.3  | 83.9  | 762.3                               | 59.4  | 9.3  | 83.9  | 762.3  | 59.4  | 9.3  |      |      |      |     |      |      |      |     |      |      |      |     |     |
| 5   | Steam Blow  | 12            | 0-50        | 50                | 157                              | 3971 | 120 | 15 | 48447                   | 850   | 5176  | 593  | 96       | 697169  | 1007    | 9147  | 713                   | 111 | 745516  | 83.9    | 762.3          | 59.4  | 9.3  | 83.9  | 762.3                               | 59.4  | 9.3  | 83.9  | 762.3  | 59.4  | 9.3  |      |      |      |     |      |      |      |     |      |      |      |     |     |
| 6   | Steam Blow restoration, install SCR/VO Catalyst           | 0             | 0           | 0                 | 0                                | 0    | 0   | 0  | 0                       | 0     | 0     | 0    | 0        | 0       | 0       | 0     | 0                     | 0   | 0       | 0       | 0              | 0     | 0    | 0     | 0                                   | 0     | 0    | 0     | 0      | 0     | 0    | 0    | 0    |      |     |      |      |      |     |      |      |      |     |     |
| 7   | Steam Blow restoration, install SCR/VO Catalyst           | 0             | 0           | 0                 | 0                                | 0    | 0   | 0  | 0                       | 0     | 0     | 0    | 0        | 0       | 0       | 0     | 0                     | 0   | 0       | 0       | 0              | 0     | 0    | 0     | 0                                   | 0     | 0    | 0     | 0      | 0     | 0    | 0    | 0    | 0    | 0   |      |      |      |     |      |      |      |     |     |
| 8   | Steam Blow restoration, install SCR/VO Catalyst           | 0             | 0           | 0                 | 0                                | 0    | 0   | 0  | 0                       | 0     | 0     | 0    | 0        | 0       | 0       | 0     | 0                     | 0   | 0       | 0       | 0              | 0     | 0    | 0     | 0                                   | 0     | 0    | 0     | 0      | 0     | 0    | 0    | 0    | 0    | 0   | 0    |      |      |     |      |      |      |     |     |
| 9   | Steam Blow restoration, install SCR/VO Catalyst           | 0             | 0           | 0                 | 0                                | 0    | 0   | 0  | 0                       | 0     | 0     | 0    | 0        | 0       | 0       | 0     | 0                     | 0   | 0       | 0       | 0              | 0     | 0    | 0     | 0                                   | 0     | 0    | 0     | 0      | 0     | 0    | 0    | 0    | 0    | 0   | 0    | 0    |      |     |      |      |      |     |     |
| 10  | Steam Blow restoration, install SCR/VO Catalyst           | 0             | 0           | 0                 | 0                                | 0    | 0   | 0  | 0                       | 0     | 0     | 0    | 0        | 0       | 0       | 0     | 0                     | 0   | 0       | 0       | 0              | 0     | 0    | 0     | 0                                   | 0     | 0    | 0     | 0      | 0     | 0    | 0    | 0    | 0    | 0   | 0    | 0    | 0    |     |      |      |      |     |     |
| 11  | Steam Blow restoration, install SCR/VO Catalyst           | 0             | 0           | 0                 | 0                                | 0    | 0   | 0  | 0                       | 0     | 0     | 0    | 0        | 0       | 0       | 0     | 0                     | 0   | 0       | 0       | 0              | 0     | 0    | 0     | 0                                   | 0     | 0    | 0     | 0      | 0     | 0    | 0    | 0    | 0    | 0   | 0    | 0    | 0    |     |      |      |      |     |     |
| 12  | Steam Blow restoration, install SCR/VO Catalyst           | 0             | 0           | 0                 | 0                                | 0    | 0   | 0  | 0                       | 0     | 0     | 0    | 0        | 0       | 0       | 0     | 0                     | 0   | 0       | 0       | 0              | 0     | 0    | 0     | 0                                   | 0     | 0    | 0     | 0      | 0     | 0    | 0    | 0    | 0    | 0   | 0    | 0    | 0    |     |      |      |      |     |     |
| 13  | Steam Blow restoration, install SCR/VO Catalyst           | 0             | 0           | 0                 | 0                                | 0    | 0   | 0  | 0                       | 0     | 0     | 0    | 0        | 0       | 0       | 0     | 0                     | 0   | 0       | 0       | 0              | 0     | 0    | 0     | 0                                   | 0     | 0    | 0     | 0      | 0     | 0    | 0    | 0    | 0    | 0   | 0    | 0    | 0    | 0   |      |      |      |     |     |
| 14  | Steam Blow restoration, install SCR/VO Catalyst           | 0             | 0           | 0                 | 0                                | 0    | 0   | 0  | 0                       | 0     | 0     | 0    | 0        | 0       | 0       | 0     | 0                     | 0   | 0       | 0       | 0              | 0     | 0    | 0     | 0                                   | 0     | 0    | 0     | 0      | 0     | 0    | 0    | 0    | 0    | 0   | 0    | 0    | 0    | 0   |      |      |      |     |     |
| 15  | Steam Blow restoration, install SCR/VO Catalyst           | 0             | 0           | 0                 | 0                                | 0    | 0   | 0  | 0                       | 0     | 0     | 0    | 0        | 0       | 0       | 0     | 0                     | 0   | 0       | 0       | 0              | 0     | 0    | 0     | 0                                   | 0     | 0    | 0     | 0      | 0     | 0    | 0    | 0    | 0    | 0   | 0    | 0    | 0    | 0   |      |      |      |     |     |
| 16  | Steam Blow restoration, install SCR/VO Catalyst           | 0             | 0           | 0                 | 0                                | 0    | 0   | 0  | 0                       | 0     | 0     | 0    | 0        | 0       | 0       | 0     | 0                     | 0   | 0       | 0       | 0              | 0     | 0    | 0     | 0                                   | 0     | 0    | 0     | 0      | 0     | 0    | 0    | 0    | 0    | 0   | 0    | 0    | 0    | 0   |      |      |      |     |     |
| 17  | Steam Blow restoration, install SCR/VO Catalyst           | 0             | 0           | 0                 | 0                                | 0    | 0   | 0  | 0                       | 0     | 0     | 0    | 0        | 0       | 0       | 0     | 0                     | 0   | 0       | 0       | 0              | 0     | 0    | 0     | 0                                   | 0     | 0    | 0     | 0      | 0     | 0    | 0    | 0    | 0    | 0   | 0    | 0    | 0    | 0   |      |      |      |     |     |
| 18  | Steam Blow restoration, install SCR/VO Catalyst           | 0             | 0           | 0                 | 0                                | 0    | 0   | 0  | 0                       | 0     | 0     | 0    | 0        | 0       | 0       | 0     | 0                     | 0   | 0       | 0       | 0              | 0     | 0    | 0     | 0                                   | 0     | 0    | 0     | 0      | 0     | 0    | 0    | 0    | 0    | 0   | 0    | 0    | 0    | 0   |      |      |      |     |     |
| 19  | Steam Blow restoration, install SCR/VO Catalyst           | 0             | 0           | 0                 | 0                                | 0    | 0   | 0  | 0                       | 0     | 0     | 0    | 0        | 0       | 0       | 0     | 0                     | 0   | 0       | 0       | 0              | 0     | 0    | 0     | 0                                   | 0     | 0    | 0     | 0      | 0     | 0    | 0    | 0    | 0    | 0   | 0    | 0    | 0    | 0   |      |      |      |     |     |
| 20  | Steam Blow restoration, install SCR/VO Catalyst           | 0             | 0           | 0                 | 0                                | 0    | 0   | 0  | 0                       | 0     | 0     | 0    | 0        | 0       | 0       | 0     | 0                     | 0   | 0       | 0       | 0              | 0     | 0    | 0     | 0                                   | 0     | 0    | 0     | 0      | 0     | 0    | 0    | 0    | 0    | 0   | 0    | 0    | 0    | 0   |      |      |      |     |     |
| 21  | Establish vacuum/BOP Tuning                               | 16            | 60          | 60                | 86                               | 805  | 73  | 9  | 32811                   | 153   | 104   | 63   | 128      | 1046636 | 239     | 908   | 136                   | 137 | 1079447 | 14.9    | 56.8           | 8.5   | 8.6  | 14.9  | 56.8                                | 8.5   | 8.6  | 14.9  | 56.8   | 8.5   | 8.6  | 14.9 | 56.8 | 8.5  | 8.6 | 14.9 | 56.8 | 8.5  | 8.6 |      |      |      |     |     |
| 22  | GT Load Test & Bypass Valve Tuning                        | 16            | 60          | 60                | 86                               | 805  | 73  | 9  | 32811                   | 153   | 104   | 63   | 128      | 1046636 | 239     | 908   | 136                   | 137 | 1079447 | 14.9    | 56.8           | 8.5   | 8.6  | 14.9  | 56.8                                | 8.5   | 8.6  | 14.9  | 56.8   | 8.5   | 8.6  | 14.9 | 56.8 | 8.5  | 8.6 | 14.9 | 56.8 | 8.5  | 8.6 |      |      |      |     |     |
| 23  | GT Load Test & Bypass Valve Tuning                        | 16            | 60          | 60                | 86                               | 805  | 73  | 9  | 32811                   | 153   | 104   | 63   | 128      | 1046636 | 239     | 908   | 136                   | 137 | 1079447 | 14.9    | 56.8           | 8.5   | 8.6  | 14.9  | 56.8                                | 8.5   | 8.6  | 14.9  | 56.8   | 8.5   | 8.6  | 14.9 | 56.8 | 8.5  | 8.6 | 14.9 | 56.8 | 8.5  | 8.6 |      |      |      |     |     |
| 24  | GT Load Test & Bypass Valve Tuning / Safety Valve Testing | 12            | 75          | 75                | 87                               | 805  | 74  | 10 | 41264                   | 135   | 36    | 18   | 96       | 919649  | 222     | 842   | 92                    | 106 | 960910  | 18.5    | 70.2           | 7.7   | 8.8  | 18.5  | 70.2                                | 7.7   | 8.8  | 18.5  | 70.2   | 7.7   | 8.8  | 18.5 | 70.2 | 7.7  | 8.8 | 18.5 | 70.2 | 7.7  | 8.8 |      |      |      |     |     |
| 25  | GT Base Load / Commissioning of Ammonia system            | 12            | 100         | 100               | 92                               | 806  | 74  | 13 | 71104                   | 169   | 46    | 23   | 104      | 1152480 | 260     | 852   | 97                    | 117 | 1233584 | 21.7    | 71.0           | 8.1   | 9.8  | 21.7  | 71.0                                | 8.1   | 9.8  | 21.7  | 71.0   | 8.1   | 9.8  | 21.7 | 71.0 | 8.1  | 9.8 | 21.7 | 71.0 | 8.1  | 9.8 |      |      |      |     |     |
| 26  | GT Load Test & Bypass Valve Tuning                        | 12            | 100         | 100               | 92                               | 806  | 74  | 13 | 71104                   | 169   | 46    | 23   | 104      | 1152480 | 260     | 852   | 97                    | 117 | 1233584 | 21.7    | 71.0           | 8.1   | 9.8  | 21.7  | 71.0                                | 8.1   | 9.8  | 21.7  | 71.0   | 8.1   | 9.8  | 21.7 | 71.0 | 8.1  | 9.8 | 21.7 | 71.0 | 8.1  | 9.8 |      |      |      |     |     |
| 27  | No Operation  | 0             | 0           | 0                 | 0                                | 0    | 0   | 0  | 0                       | 0     | 0     | 0    | 0        | 0       | 0       | 0     | 0                     | 0   | 0       | 0       | 0              | 0     | 0    | 0     | 0                                   | 0     | 0    | 0     | 0      | 0     | 0    | 0    | 0    | 0    | 0   | 0    | 0    | 0    | 0   |      |      |      |     |     |
| 28  | Install Emissions Test Equipment                          | 0             | 0           | 0                 | 0                                | 0    | 0   | 0  | 0                       | 0     | 0     | 0    | 0        | 0       | 0       | 0     | 0                     | 0   | 0       | 0       | 0              | 0     | 0    | 0     | 0                                   | 0     | 0    | 0     | 0      | 0     | 0    | 0    | 0    | 0    | 0   | 0    | 0    | 0    | 0   | 0    |      |      |     |     |
| 29  | Bypass Operation / STG Initial Roll & Trip Test           | 10            | 0-60        | 60                | 86                               | 805  | 73  | 9  | 32811                   | 96    | 65    | 39   | 80       | 654147  | 182     | 869   | 113                   | 89  | 686958  | 18.2    | 86.9           | 11.3  | 8.9  | 18.2  | 86.9                                | 11.3  | 8.9  | 18.2  | 86.9   | 11.3  | 8.9  | 18.2 | 86.9 | 11.3 | 8.9 | 18.2 | 86.9 | 11.3 | 8.9 | 18.2 | 86.9 | 11.3 | 8.9 |     |
| 30  | Bypass Operation / STG Load Test                          | 16            | 0-60        | 60                | 86                               | 805  | 73  | 9  | 32811                   | 153   | 104   | 63   | 128      | 1046636 | 239     | 908   | 136                   | 137 | 1079447 | 14.9    | 56.8           | 8.5   | 8.6  | 14.9  | 56.8                                | 8.5   | 8.6  | 14.9  | 56.8   | 8.5   | 8.6  | 14.9 | 56.8 | 8.5  | 8.6 | 14.9 | 56.8 | 8.5  | 8.6 | 14.9 | 56.8 | 8.5  | 8.6 |     |
| 31  | GT on Bypass / STG Load Test                              | 16            | 0-100       | 100               | 92                               | 806  | 74  | 13 | 71104                   | 225   | 61    | 31   | 139      | 1536640 | 317     | 867   | 105                   | 152 | 1607744 | 19.8    | 54.2           | 6.6   | 9.5  | 19.8  | 54.2                                | 6.6   | 9.5  | 19.8  | 54.2   | 6.6   | 9.5  | 19.8 | 54.2 | 6.6  | 9.5 | 19.8 | 54.2 | 6.6  | 9.5 | 19.8 | 54.2 | 6.6  | 9.5 |     |
| 32  | Combine Cycle testing / Drift Test                        | 24            | 0-100       | 100               | 100                              | 49   | 524 | 48 | 7                       | 36789 | 338   | 91   | 46       | 208     | 2304951 | 386   | 615                   | 93  | 215     | 2341750 | 16.1           | 25.6  | 3.9  | 9.0   | 16.1                                | 25.6  | 3.9  | 9.0   | 16.1   | 25.6  | 3.9  | 9.0  | 16.1 | 25.6 | 3.9 | 9.0  | 16.1 | 25.6 | 3.9 | 9.0  | 16.1 | 25.6 | 3.9 | 9.0 |
| 33  | Combine Cycle testing / Drift Test                        | 24            | 100         | 100               | 43                               | 282  | 27  | 6  | 34315                   | 338   | 91    | 46   | 208      | 2304951 | 386     | 615   | 93                    | 215 | 2341750 | 16.1    | 25.6           | 3.9   | 9.0  | 16.1  | 25.6                                | 3.9   | 9.0  | 16.1  | 25.6   | 3.9   | 9.0  | 16.1 | 25.6 | 3.9  | 9.0 | 16.1 | 25.6 | 3.9  | 9.0 | 16.1 | 25.6 | 3.9  | 9.0 |     |
| 34  | Emissions Tuning / Drift Test                             | 12            | 50-100      | 100               | 92                               | 806  | 74  | 13 | 71104                   | 169   | 46    | 23   | 104      | 1152480 | 260     | 852   | 97                    | 117 | 1233584 | 21.7    | 71.0           | 8.1   | 9.8  | 21.7  | 71.0                                | 8.1   | 9.8  | 21.7  | 71.0   | 8.1   | 9.8  | 21.7 | 71.0 | 8.1  | 9.8 | 21.7 | 71.0 | 8.1  | 9.8 | 21.7 | 71.0 | 8.1  | 9.8 |     |
| 35  | Emissions Tuning / Drift Test                             | 12            | 50-100      | 100               | 92                               | 806  | 74  | 13 | 71104                   | 169   | 46    | 23   | 104      | 1152480 | 260     | 852   | 97                    | 117 | 1233584 | 21.7    | 71.0           | 8.1   | 9.8  | 21.7  | 71.0                                | 8.1   | 9.8  | 21.7  | 71.0   | 8.1   | 9.8  | 21.7 | 71.0 | 8.1  | 9.8 | 21.7 | 71.0 | 8.1  | 9.8 | 21.7 | 71.0 | 8.1  | 9.8 |     |
| 36  | Pre-performance Testing / Drift Test                      | 12            |             |                   |                                  |      |     |    |                         |       |       |      |          |         |         |       |                       |     |         |         |                |       |      |       |                                     |       |      |       |        |       |      |      |      |      |     |      |      |      |     |      |      |      |     |     |

**Table 3.1E-4**

**EI Segundo Power Facility Modification**

Commissioning Schedule for Units 11 and 12

| Activity                               | Duration (hr) | GT Load (%) | Modeling Load (%) | No. of Starts | Startup/Shutdown Emissions (lbs) |               |            |            | Running Emissions (lbs) |              |              |            | Total Emissions (lbs) |                  |              |               | Fuel Use     |            |                  |                  | Calculated Hourly Emissions (lbs/hr) |            |           |           |    |
|--|---------------|-------------|-------------------|---------------|----------------------------------|---------------|------------|------------|-------------------------|--------------|--------------|------------|-----------------------|------------------|--------------|---------------|--------------|------------|------------------|------------------|--------------------------------------|------------|-----------|-----------|----|
|  |               |             |                   |               | NOx                              | CO            | VOC        | PM         | Fuel Use (lbs)          | NOx          | CO           | VOC        | PM                    | Fuel Use (lbs)   | NOx          | CO            | VOC          | PM         | Fuel Use (lbs)   | NOx              | CO                                   | VOC        | PM        | NOx       | CO |
| First Fire and Engine Idle Running     | 9             | 0           | FSNL              | 16            | 562                              | 2,360         | 182        | 96         | 125,195                 | 9            | 757          | 253        | 3                     | 165,013          | 571          | 3,117         | 435          | 99         | 294,208          | 63               | 346                                  | 48         | 11        |           |    |
| Synchronization of the unit            | 8             | 0           | FSNL              | 10            | 351                              | 1,475         | 114        | 60         | 78,247                  | 1            | 112          | 4          | 1                     | 150,234          | 352          | 1,587         | 118          | 61         | 228,481          | 44               | 198                                  | 15         | 8         |           |    |
| Tuning-Base-load Running               | 32            | 100         | 100               | 29            | 1,018                            | 4,278         | 331        | 174        | 226,916                 | 1,452        | 2,357        | 93         | 168                   | 600,935          | 2,470        | 6,635         | 424          | 342        | 827,851          | 77               | 207                                  | 13         | 11        |           |    |
| Commissioning of inlet fogging and ISI | 12            | 0-25        | 50                | 9             | 316                              | 1,328         | 103        | 54         | 70,422                  | 87           | 600          | 24         | 12                    | 225,351          | 403          | 1,927         | 126          | 66         | 295,773          | 34               | 161                                  | 11         | 5         |           |    |
| SCR tuning                             | 12            | 0-50        | 100               | 2             | 70                               | 295           | 23         | 12         | 15,649                  | 1,132        | 34           | 14         | 121                   | 225,351          | 1,202        | 329           | 37           | 133        | 241,000          | 100              | 27                                   | 3          | 11        |           |    |
| RATA Test                              | 12            | 50          | 100               | 1             | 35                               | 148           | 11         | 6          | 7,825                   | 57           | 24           | 10         | 61                    | 225,351          | 92           | 172           | 21           | 67         | 233,175          | 8                | 14                                   | 2          | 6         |           |    |
| Performance test                       | 12            | 50          | 100               | 1             | 35                               | 148           | 11         | 6          | 7,825                   | 57           | 24           | 10         | 61                    | 225,351          | 92           | 172           | 21           | 67         | 233,175          | 8                | 14                                   | 2          | 6         |           |    |
| 24-hr reliability test                 | 24            | 100         | 100               | 1             | 35                               | 148           | 11         | 6          | 7,825                   | 113          | 34           | 14         | 121                   | 450,701          | 148          | 181           | 25           | 127        | 458,526          | 6                | 8                                    | 1          | 5         |           |    |
| <b>Total =</b>                         | <b>121</b>    |             |                   |               | <b>2,422</b>                     | <b>10,178</b> | <b>787</b> | <b>414</b> | <b>539,903</b>          | <b>2,909</b> | <b>3,942</b> | <b>422</b> | <b>548</b>            | <b>2,272,286</b> | <b>5,331</b> | <b>14,120</b> | <b>1,208</b> | <b>962</b> | <b>2,812,189</b> | <b>44</b>        | <b>117</b>                           | <b>10</b>  | <b>8</b>  |           |    |
|  |               |             |                   |               |                                  |               |            |            |                         |              |              |            |                       |                  |              |               |              |            |                  | <b>Average =</b> | <b>100</b>                           | <b>346</b> | <b>48</b> | <b>11</b> |    |
|  |               |             |                   |               |                                  |               |            |            |                         |              |              |            |                       |                  |              |               |              |            |                  |                  | <b>Maximum =</b>                     |            |           |           |    |

**Table 3.1E-5**  
**El Segundo Power Facility Modification**  
**CTG - Emission Factors**

| <b>Emission Factors During the Commissioning Period</b> |           |            |            |
|---|-----------|------------|------------|
|   | <b>CO</b> | <b>NOX</b> | <b>VOC</b> |
| <b>Unit 9</b>   |           |            |            |
| Emissions (lbs) =                                       | 130,337   | 12,478     | 6,952      |
| Fuel Use (MMscf) =                                      | 796       | 796        | 796        |
| Emission Factor (lbs/MMscf) =                           | 163.71    | 15.67      | 8.73       |
| <b>Unit 11</b>  |           |            |            |
| Emissions (lbs) =                                       | 14,120    | 5,331      | 1,208      |
| Fuel Use (MMscf) =                                      | 63        | 63         | 63         |
| Emission Factor (lbs/MMscf) =                           | 225.88    | 85.28      | 19.33      |
| <b>Unit 12</b>  |           |            |            |
| Emissions (lbs) =                                       | 14,120    | 5,331      | 1,208      |
| Fuel Use (MMscf) =                                      | 63        | 63         | 63         |
| Emission Factor (lbs/MMscf) =                           | 225.88    | 85.28      | 19.33      |

**APPENDIX 3.1F – BEST AVAILABLE CONTROL TECHNOLOGY (BACT) ANALYSIS**

## **Evaluation of Best Available Control Technology**

El Segundo Power, LLC's facility modification is required to use best available control technology (BACT) on the combustion turbine generators (CTGs) and the auxiliary boiler for regulated pollutants, in accordance with the requirements of South Coast Air Quality Management District (SCAQMD, or District) rules and the federal Prevention of Significant Deterioration (PSD) requirements contained in District rules. For sources and pollutants subject to PSD, BACT is defined in SCAQMD Rule 1702(e):

*(e) Best Available Control Technology (BACT) means the most stringent emission limitation or control technique which:*

*(1) has been achieved in practice for such permit unit category or class of source. For permit units not located at a major stationary source, a specific limitation or control technique shall not apply if the owner or operator of the proposed sources demonstrates to the satisfaction of the Executive Officer that such limitation or control technique is not attainable for that permit unit; or*

*(2) is contained in any State Implementation Plan (SIP) approved by the Environmental Protection Agency (EPA) for such permit unit category or class of source. A specific limitation or control technique shall not apply if the owner or operator of the proposed source demonstrates to the satisfaction of the Executive Officer that such limitation or control technique is not presently achievable; or*

*(3) is any other emission control technique, including process and equipment changes of basic and control equipment, found by the Executive Officer to be technologically feasible and cost-effective for such class or category of sources or for a specific source. No emissions limitation or control technique, the application of which would result in emissions from a new or modified source in excess of the amount allowable under applicable new source performance standards specified in Regulation IX of these Rules and Regulations or promulgated by the EPA pursuant to Section III of the Clean Air Act, may be considered BACT.*

The regulated pollutants for which the federal PSD BACT requirement is applicable are nitrogen oxides (NO<sub>x</sub>), carbon monoxide (CO), and greenhouse gases (GHG).

BACT for nonattainment pollutants is defined in SCAQMD Rule 1302(h):

*(h) BEST AVAILABLE CONTROL TECHNOLOGY (BACT) means the most stringent emission limitation or control technique which:*

*(1) has been achieved in practice for such category or class of source; or*

*(2) is contained in any state implementation plan (SIP) approved by the United States Environmental Protection Agency (EPA) for such category or class of source. A specific limitation or control technique shall not apply if the owner or operator of the proposed source demonstrates to the satisfaction of the Executive Officer or designee that such limitation or control technique is not presently achievable; or*

*(3) is any other emission limitation or control technique, found by the Executive Officer or designee to be technologically feasible for such class or category of sources or for a specific source, and cost-effective as compared to measures as listed in the Air Quality Management Plan (AQMP) or rules adopted by the District Governing Board.*

The District NSR rules require BACT for NO<sub>x</sub>; sulfur dioxide (SO<sub>2</sub>); volatile organic compounds (VOC); particulate (PM<sub>10</sub> and PM<sub>2.5</sub>); and ammonia. The BACT analyses required under both New Source Review (NSR) and PSD programs are similar, and are presented here. The emission rates and control technologies determined to be BACT for this project are discussed in detail in the following sections. For the CTGs, separate determinations are provided for normal operation and startup/shutdown operation.

## Steps in a Top-Down BACT Analysis

### Step 1 – Identify All Possible Control Technologies

The first step in a top-down analysis is to identify, for the emissions unit and pollutant in question, all available control options. Available control options are those air pollution control technologies or techniques, including alternate basic equipment or processes, with a practical potential for application to the emissions unit in question. The control alternatives should include not only existing controls for the source category in question, but also, through technology transfer, controls applied to similar source categories and gas streams.

BACT must be at least as stringent as what has been achieved in practice (AIP) for a category or class of source. Additionally, EPA guidelines require that a technology that is determined to be AIP for one category of source be considered for transfer to other source categories. There are two types of potentially transferable control technologies: (1) exhaust stream controls, and (2) process controls and modifications. For the first type, technology transfer must be considered between source categories that produce similar exhaust streams. For the second type, technology transfer must be considered between source categories with similar processes.



Candidate control options that do not meet basic project requirements (i.e., alternative basic designs that “redefine the source”) are eliminated at this step.

#### Step 2 – Eliminate Technologically Infeasible Options

To be considered, the candidate control option must be technologically feasible for the application being reviewed.

#### Step 3 – Rank Remaining Control Options by Control Effectiveness

All feasible options are ranked in the order of decreasing control effectiveness for the pollutant under consideration. In some cases, a given control technology may be listed more than once, representing different levels of control (e.g., the use of SCR for control of NO<sub>x</sub> may be evaluated at 2 and 2.5 parts per million by volume, dry [ppmvd]). Any control option less stringent than what has been already achieved in practice for the category of source under review must also be eliminated at this step.

#### Step 4 – Evaluate Most Effective Control Technology Considering Environmental, Energy, and Cost Impacts

To be required as BACT, the candidate control option must be cost effective, considering energy, environmental, economic, and other costs. The most stringent control technology for control of one pollutant may have other undesirable environmental or economic impacts. The purpose of Step 4 is to either validate the suitability of the top control option or provide a clear justification as to why that option should not be selected as BACT.

Once all of the candidate control technologies have been ranked, and other impacts have been evaluated, the most stringent candidate control technology is deemed to be BACT, unless the other impacts are unacceptable.

#### Step 5 – Determine BACT/Present Conclusions

BACT is determined to be the most effective control technology subject to evaluation, and not rejected as infeasible or having unacceptable energy, environmental, or cost impacts.

### BACT for the Simple-Cycle CTGs: Normal Operations

#### **NO<sub>x</sub> EMISSIONS**

#### Step 1 – Identify All Possible Control Technologies

The emissions unit for which BACT is being considered is a nominal 60 MW gas turbine operating in simple cycle.

Potential control technologies were identified by searching the following sources for determinations pertaining to combustion gas turbines:

- SCAQMD BACT Guidelines;
- San Joaquin Valley Air Pollution Control District (SJVAPCD) BACT Clearinghouse;
- Bay Area Air Quality Management District (BAAQMD) BACT Guidelines;
- EPA Reasonably Available Control Technology (RACT)/BACT/ Lowest Achievable Emission Rate (LAER) Clearinghouse;
- Other district and state BACT Guidelines; and
- BACT/LAER requirements in New Source Review permits issued by a local air district<sup>1</sup> or other air pollution control agency.

Outlined below are the technologies for control of NO<sub>x</sub> that were identified.

- A Selective Catalytic Reduction (SCR) system capable of continuously complying with a limit of 2.5 ppmvd @15% oxygen (O<sub>2</sub>) (1-hour average).
- An EMx (formerly SCONO<sub>x</sub>) system capable of continuously complying with a limit of 2.5 ppmvd @15% O<sub>2</sub> (1-hour average).
- Alternative Basic Equipment:
  - Renewable Energy Source (e.g., solar, wind, etc.)
  - Combined-Cycle Turbine

It should be noted that the use of renewable energy in lieu of a simple-cycle gas turbine would “redefine the source.” Renewable energy facilities require significantly more land to construct, and need to be located in areas with very specific characteristics. Wind and solar facilities have power generation profiles that cannot match demand; conventional power plants are needed in order to follow demand. The capital costs for wind or solar facilities are substantially higher than for a comparable conventional facility, making financing of such a project significantly different. Because these technologies would redefine the source, they are eliminated in this step of the analysis. Even if they were not eliminated in Step 1, solar and wind facilities require much more land than is available at the project site, and renewable energy alternatives would be eliminated in Step 2 as technologically infeasible.

The use of a combined-cycle turbine instead of the proposed simple-cycle turbines would also redefine the project. The project already includes a combined-cycle turbine for that portion of the anticipated operating profile that would be well served by such equipment. The simple-cycle turbines are needed to effectively handle variable loads and provide black start capability.

---

<sup>1</sup> Any Air Quality Management District or Air Pollution Control District in California.

Step 2 – Eliminate Technologically Infeasible Options

*Exhaust Stream Controls*

The most recent NO<sub>x</sub> BACT listings for aeroderivative simple-cycle combustion turbines in this size range are summarized in Table 1. The most stringent NO<sub>x</sub> limit in these recent BACT determinations is a 2.5 ppm<sup>2</sup> limit averaged over a 1-hour averaging period, excluding startups and shutdowns. This level is achieved using dry low-NO<sub>x</sub> combustors and SCR.

**Table 1  
Recent NO<sub>x</sub> BACT Determinations for Simple-Cycle Combustion Turbines<sup>a</sup>**

| Facility                                   | District | NO <sub>x</sub> Limit <sup>b</sup> | Averaging Period | Control Method Used     | Date Permit Issued | Source                 |
|--|----------|------------------------------------|------------------|-------------------------|--------------------|------------------------|
| TID Almond 2 Power Plant                   | SJVAPCD  | 2.5 ppmvd                          | 1 hr             | Water injection and SCR | 2/16/2010          | FDOC                   |
| Miramar Energy Facility II                 | SDCAPCD  | 2.5 ppmvd                          | 3 hrs            | Water injection and SCR | 11/4/08            | ATC                    |
| Starwood Midway Firebaugh/Panoche          | SJVAPCD  | 2.5 ppmvd                          | 1 hr             | Water injection and SCR | 9/5/07 (FDOC)      | CEC Siting Div website |
| EIF Panoche                                | SJVAPCD  | 2.5 ppmvd                          | 1 hr             | Water injection and SCR | 7/13/07 (FDOC)     | CEC Siting Div website |
| San Francisco Electric Reliability Project | BAAQMD   | 2.5 ppmvd                          | 1 hr             | Water injection and SCR | 2/8/06 (FDOC)      | CEC Siting Div website |
| EI Colton                                  | SCAQMD   | 3.5 ppmvd                          | 3 hrs            | Water injection and SCR | 1/10/03            | SCAQMD website         |
| MID Ripon                                  | SJVAPCD  | 2.5 ppmvd                          | 3 hrs            | Water injection and SCR | 2004               | ATC                    |

Note:

- a. All projects listed here utilize GE LM6000-model units except Starwood Midway, which utilizes P&W FT8-3 SwiftPacs, and EIF Panoche, which uses GE LMS 100 CTGs.
- b. All concentrations expressed as parts per million by volume dry, corrected to 15% O<sub>2</sub>.

SCONox is a NO<sub>x</sub> reduction system produced by Goal Line Environmental Technologies. It is now distributed by EmeraChem as EMx. This system uses a single catalyst to oxidize both NO and CO, a second catalyst system to absorb NO<sub>2</sub>, and then a regeneration system to convert the NO<sub>2</sub> to N<sub>2</sub> and water vapor. The EMx system does

<sup>2</sup> All turbine/HRSG exhaust emissions concentrations shown are by volume, dry corrected to 15% O<sub>2</sub>.

not use ammonia as a reagent. The EMx process has been demonstrated in practice on smaller gas turbines, including Redding Electric Utility's (REU) Units 5 and 6, a 43-MW Alstom GTX100 and 45 MW Siemens SGT 800 combined-cycle gas turbines, respectively. While the technology has never been demonstrated on a gas turbine the size of the Trent 60 or on a simple-cycle gas turbine, the technology is considered by the manufacturer to be scalable.

The SCR system uses ammonia injection to reduce NOx emissions. SCR systems have been widely used in simple-cycle gas turbine applications of all sizes. The SCR process involves the injection of ammonia into the flue gas stream via an ammonia injection grid upstream of a reducing catalyst. The ammonia reacts with the NOx in the exhaust stream to form N<sub>2</sub> and water vapor. The catalyst does not require regeneration, but must be replaced periodically; typical SCR catalyst lifetimes are in excess of three years.

Either SCR or EMx technology is capable of achieving a NOx emission level of 2.5 ppmvd @ 15% O<sub>2</sub>. Neither has been demonstrated to consistently achieve lower emission levels in simple-cycle turbines in demand-response service.

#### Step 3 – Rank Remaining Control Technologies by Control Effectiveness

Both SCR and EMx technologies, each in combination with combustion controls, are capable of achieving a NOx emission level of 2.5 ppmvd @ 15% O<sub>2</sub>. They are therefore ranked together in terms of control effectiveness.

#### Step 4 – Evaluate the Most Effective Control Technology Considering Environmental, Energy, and Cost Impacts

The use of SCR will result in ammonia emissions due to an allowable ammonia slip limit of 5 ppmvd @ 15% O<sub>2</sub>. A health risk screening analysis of the proposed project using air dispersion modeling will be prepared to demonstrate the acute health hazard index and the chronic health hazard index each to be much less than 1, based on an ammonia slip limit of 5 ppmv @ 15% O<sub>2</sub>. In accordance with the District's Toxics program and currently accepted practice, a hazard index below 1.0 is not considered significant. Therefore, the toxic impact of the ammonia slip resulting from the use of SCR is deemed to be not significant, and is not a sufficient reason to eliminate SCR as a control alternative.

A second potential environmental impact that may result from the use of SCR involves the storage and transport of aqueous or anhydrous ammonia.<sup>3</sup> Although ammonia is toxic if swallowed or inhaled and can irritate or burn the skin, eyes, nose, or throat, it is a commonly used material that is typically handled safely and without incident. The project operator will be required to develop and maintain a Risk Management Plan (RMP) and to implement a Risk Management Program to prevent accidental releases of ammonia. The RMP provides information on the hazards of the substance handled at the facility and the programs in place to prevent and respond to accidental releases. The

---

<sup>3</sup> The Project proposes to use the less concentrated, safer aqueous form of ammonia.

accident prevention and emergency response requirements reflect existing safety regulations and proven industry safety codes and standards. Thus, the potential environmental impact due to aqueous ammonia use at the Project is minimal and does not justify the elimination of SCR as a control alternative.

Regeneration of the EMx catalyst is accomplished by passing hydrogen gas over an isolated catalyst module. The hydrogen gas is generated by reforming steam, so steam would be required. This would require the production of additional steam by the auxiliary boiler, or would decrease the plant electrical output by diverting steam produced by the combined cycle unit's HRSG from the steam turbine to the hydrogen reformer. In either case, there would be additional natural gas consumption, and increased emissions, per megawatt hour of electricity produced.

#### *“Achieved in Practice” Criteria*

SCAQMD has established formal criteria for determining when emission control technologies should be considered achieved in practice (AIP) for the purposes of BACT determinations. The criteria include the elements outlined below.

- **Commercial Availability:** At least one vendor must offer this equipment for regular or full-scale operation in the United States. A performance warranty or guarantee must be available with the purchase of the control technology, as well as parts and service.
- **Reliability:** All control technologies must have been installed and operated reliably for at least six months. If the operator did not require the basic equipment to operate daily, then the equipment must have at least 183 cumulative days of operation. During this period, the basic equipment must have operated (1) at a minimum of 50% design capacity; or (2) in a manner that is typical of the equipment in order to provide an expectation of continued reliability of the control technology.
- **Effectiveness:** The control technology must be verified to perform effectively over the range of operation expected for that type of equipment. If the control technology will be allowed to operate at lesser effectiveness during certain modes of operation, then those modes of operation must be identified. The verification shall be based on a performance test or tests, when possible, or other performance data.

Each of these criteria is discussed separately below for SCR and for EMx.

SCR Technology – SCR has been achieved in practice at numerous combustion turbine installations throughout the world. There are numerous aeroderivative simple-cycle gas turbine projects that limit NOx emissions to 2.5 ppm, as shown in Table 1. An evaluation of the proposed AIP criteria as applied to the achievement of 2.5 ppm, and to extremely low NOx levels (below 2.5 ppm) using SCR technology, is summarized below.

- **Commercial Availability:** Turbine-out NO<sub>x</sub> from aeroderivative gas turbines is generally 25 ppm. Achieving a controlled NO<sub>x</sub> limit below 2.5 ppm would require SCR technology to achieve reductions greater than 90 percent. Furthermore, because of the relatively high temperature of exhaust from simple-cycle turbines compared with combined-cycle units, there is a more limited selection of SCR technology available. Consequently, it is not clear that this criterion is satisfied for limits below 2.5 ppm for aeroderivative gas turbines. As shown in Table 1 above, this criterion is satisfied for aeroderivative gas turbines at a 2.5 ppm permit level.
- **Reliability:** SCR technology has been shown to be capable of achieving NO<sub>x</sub> levels consistent with a 2.5 ppm permit limit during extended, routine operations at several commercial power plants. There are no reported adverse effects of operation of the SCR system at these levels on overall plant operation or reliability. There has been no demonstration of operation at levels below 2.5 ppm during extended, routine operation of simple-cycle aeroderivative gas turbines; consequently, this criterion is not satisfied for NO<sub>x</sub> limits below 2.5 ppm.
- **Effectiveness:** SCR technology has been demonstrated to achieve NO<sub>x</sub> levels of 2.5 ppm with aeroderivative turbines, but not at lower limits for this generating technology. Short-term excursions have resulted in NO<sub>x</sub> concentrations above the permitted level of 2.5 ppm; however, these excursions have not been associated with diminished effectiveness of the SCR system. Rather, these excursions have been associated with SCR inlet NO<sub>x</sub> levels in excess of those for which the SCR system was designed. Consequently, this criterion is satisfied at a NO<sub>x</sub> limit of 2.5 ppm, but not at lower NO<sub>x</sub> limits.
- **Conclusion:** SCR technology capable of achieving NO<sub>x</sub> levels of 2.5 ppm is considered to be achieved in practice. The permit limits for the proposed project CTGs include a NO<sub>x</sub> limit of 2.5 ppm. This proposed limit is consistent with the available data. The AIP criteria are not met for SCR on simple-cycle aeroderivative gas turbines at NO<sub>x</sub> limits lower than 2.5 ppm.

EMx Technology – EMx has been demonstrated in service in five applications: the Sunlaw Federal cogeneration plant, the Wyeth BioPharma cogeneration facility, the Montefiore Medical Center cogeneration facility, the University of California San Diego facility, and the City of Redding Power Plant. The combustion turbines at these facilities are much smaller than for the proposed project turbine, and none of the existing installations are simple-cycle turbines. The largest installation of the EMx system is at the Redding Power Plant. The Redding Power Plant includes two combined-cycle combustion turbines—a 43 MW Alstom GTX100 with a permitted NO<sub>x</sub> emission rate of 2.5 ppm, and a 45 MW Siemens SGT 800 with a permitted NO<sub>x</sub> emission rate of 2.0 ppmvd.

A review of NOx continuous emissions monitoring (CEM) data obtained from the EPA's Acid Rain program website<sup>4</sup> indicates a mean NOx level for the Redding Unit 5 of less than 1.0 ppm during the period from 2002 to 2007. After the first year of operation, Unit 5 has experienced only a few hours of non-compliance per year (fewer than 0.1% of the annual operating hours exceed that plant's NOx permit limit of 2.5 ppm). The experience at the City of Redding Plant indicates the ability of the EMx system to control NOx emissions to levels of 2.5 ppm. These data do not indicate the ability to consistently achieve NOx levels below 2.0 ppm, notwithstanding the lower annual average emission rate. This is due to the cyclical nature of EMx NOx levels between plant shutdowns and scheduled catalyst cleanings. Redding Unit 6 started up on October 2011; there are not sufficient operating data available to draw conclusions regarding its performance.

Based on this information, the following paragraphs evaluate the proposed AIP criteria as applied to the achievement of low NOx levels (2.5 ppm) using EMx technology.

- Commercial availability: While a proposal has not been sought, presumably EmeraChem Power would offer standard commercial guarantees for the proposed project. Consequently, this criterion is expected to be satisfied. However, no EMx units are currently in operation on simple-cycle units.
- Reliability: As discussed above, based on a review of the CEM data for Redding Unit 5, the EMx system complied with the 2.5 ppm NOx permit limit but with a few hours each year of excess emissions (approximately 3% of annual operating hours following the first year, and approximately 2% following the second year, dropping to approximately 0.1% after 4 years). This level of performance was also associated with some significant operating and reliability issues. According to a June 23, 2005 letter from the Shasta County Air Quality Management District,<sup>5</sup> repairs to the EMx system began shortly after initial startup and have continued during several years of operation. Redesign of the EMx system was required due to a problem with the reformer reactor combustion production unit that led to sulfur poisoning of the catalyst, despite the sole use of low-sulfur, pipeline quality natural gas as the turbine fuel. In addition, the EMx system catalyst washings had to occur at a frequency several times higher than anticipated during the first three years of operation, which resulted in substantial downtime of the combustion turbine. Since the REU installation is the most representative of all of the EMx-equipped combustion turbine facilities for comparison to the proposed Project, the problems encountered at REU bring into question the reliability of the EMx system for the proposed project. In addition, the EMx unit has not been demonstrated in use in a simple cycle application.
- Effectiveness: The EMx system at REU Unit 5 has recently been able to demonstrate compliance with a NOx level of 2.0 ppm, and the new REU Unit 6 has been permitted with a 2.0 ppm NOx limit. However, there is not sufficient

---

<sup>4</sup> Available at <http://camddataandmaps.epa.gov/gdm/index.cfm?fuseaction=prepackaged.results>

<sup>5</sup> Letter dated June 23, 2005, from Shasta County Air Quality Management District to the Redding Electric Utility regarding Unit 5 demonstration of compliance with its NOx permit limit.

operating experience with REU Unit 6 to conclude that 2.0 ppm is reliably achieved in practice for EMx, and there are no EMx-equipped facilities on simple-cycle facilities in demand-response service. In addition, this is a combined cycle unit. Consequently, due to the lack of actual performance data, there is some question regarding the effectiveness of the EMx systems on simple-cycle, demand-response combustion turbine projects.

- Conclusion: EMx systems are capable of achieving NOx levels of 2.5 ppm and less. However, the operating history at the Redding Power Plant does not support a conclusion that this technology is achieved in practice for simple-cycle, demand-response turbines, based on SCAQMD guidelines.

#### *Summary of Achieved in Practice Evaluation*

SCR's capability to consistently achieve 2.5 ppmvd NOx (1-hour average) in large turbines has been demonstrated by numerous installations. EMx's ability to consistently achieve 2.5 ppmvd in large turbines has not been demonstrated, nor has the technology been demonstrated in simple-cycle, demand-response service. An emission level of 2.5 ppm NOx has therefore been achieved in practice, and any BACT determination must be at least as stringent as that.

#### *Technologically Feasible/Cost Effective Criterion*

No candidate technology with lower emission levels than those achieved in practice has been identified.

#### Step 5 – Determine BACT/Present Conclusions

BACT must be at least as stringent as the most stringent level achieved in practice, federal NSPS, or district prohibitory rule. Based upon the results of this analysis, the NOx BACT determination of 2.5 ppmvd @ 15% O<sub>2</sub> on a 1-hour average basis made for recently permitted simple-cycle turbine projects in SCAQMD and elsewhere reflects the most stringent NOx emission limit that has been achieved in practice. No more stringent level has been suggested as being technologically feasible. Therefore, BACT for NOx for this application is any technology capable of achieving 2.5 ppmvd @ 15% O<sub>2</sub> on a 1-hour average basis.

Both SCR and EMx are expected to achieve the proposed BACT NOx emission limit of 2.5 ppmvd @ 15% O<sub>2</sub> averaged over one hour. However, concerns remain regarding the long-term effectiveness of EMx as a control technology because the technology has not been demonstrated on the turbine used in this project, in a simple-cycle demand-response application. For this reason, SCR has been selected as the NOx control technology to be used for the Project.

The Project facility will be designed to meet a NOx level of 2.5 ppmvd @ 15% O<sub>2</sub> on a 1-hour average basis using SCR.



## CO EMISSIONS

### Step 1 – Identify All Possible Control Technologies

CO emitted from natural gas-fired turbines is the result of incomplete combustion of fuel. Use of an oxidation catalyst is generally considered BACT for CO. Alternative basic equipment—including renewable energy sources, such as solar and wind—was already discussed above (Step 1 for NO<sub>x</sub> BACT on the CTGs). For the same reasons, solar, wind and other renewable energy sources are rejected as CO BACT for this application.

### Step 2 – Eliminate Technologically Infeasible Options

The only technology under consideration is use of an oxidation catalyst in combination with combustion controls. This combination of technologies has been demonstrated to be feasible in many applications. No other technologies have been identified that are capable of achieving the same level of control. As a result, the goal of the rest of this analysis is to determine the appropriate emission limit that constitutes BACT for this application.

The California Air Resources Board's (CARB's) BACT guidance document for electric generating units rated at greater than 50 MW<sup>6</sup> indicates that BACT for the control of CO emissions for simple-cycle power plants is 6 ppmvd @ 15% O<sub>2</sub>.

The BAAQMD's BACT guidelines specify that, for natural gas-fired simple-cycle combustion gas turbines larger than 40 MW, a CO limit of 6 ppmvd @ 15% O<sub>2</sub> has been "achieved in practice."

The SJVAPCD's BACT guidelines contain a determination for gas turbines rated at larger than 47 MW with variable load and without heat recovery. The SJVAPCD concluded that a CO exhaust concentration of 0.024 lb/MMBtu (11 ppmvd @ 15% O<sub>2</sub>) constituted BACT that is considered technologically feasible.

A summary of recent CO BACT determinations is shown in Table 2.

Published prohibitory rules from the BAAQMD, Sacramento Metropolitan Air Quality Management District (SMAQMD), San Diego County Air Pollution Control District (SDCAPCD), SJVAPCD, and SCAQMD were reviewed to identify the CO standards that govern existing natural gas-fired simple-cycle combustion gas turbines. The SJVAPCD prohibitory rule is the only one that includes an emission limit for CO (200 ppmv @15% O<sub>2</sub>). The applicable NSPS (40 CFR 60 Subpart KKKK) does not include a CO limit.

---

<sup>6</sup> CARB, "Guidance for Power Plant Siting and Best Available Control Technology," September 1999.

**Table 2**  
**Recent CO BACT Determinations for Simple-Cycle Combustion Turbines<sup>a</sup>**

| Facility                                   | District | CO Limit <sup>b</sup> | Averaging Period | Control Method Used | Date Permit Issued | Source                 |
|--|----------|-----------------------|------------------|---------------------|--------------------|------------------------|
| TID Almond 2 Power Plant                   | SJVAPCD  | 4.0 ppmvd             | 3 hr             | Oxidation Catalyst  | 2/16/2010          | FDOC                   |
| Starwood Midway Firebaugh/Panoche          | SJVAPCD  | 6.0 ppmvd             | 3 hr             | Oxidation Catalyst  | 9/5/07 (FDOC)      | CEC Siting Div website |
| EIF Panoche                                | SJVAPCD  | 6.0 ppmvd             | 3 hr             | Oxidation Catalyst  | 7/13/07 (FDOC)     | CEC Siting Div website |
| San Francisco Electric Reliability Project | BAAQMD   | 4.0 ppmvd             | 3 hr             | Oxidation Catalyst  | 2/8/06 (FDOC)      | CEC Siting Div website |

Notes:

- a. All projects listed here utilize GE LM6000-model units except Starwood Midway, which utilizes P&W FT8-3 SwiftPacs and EIF Panoche, which uses GE LMS 100 CTGs.
- b. All concentrations expressed as parts per million by volume dry, corrected to 15% O<sub>2</sub>.

Step 3 – Rank Remaining Control Technologies by Control Effectiveness

The control technologies under consideration are ranked as follows:

- Oxidation catalyst unit capable of achieving 4 ppmvd @ 15% O<sub>2</sub>
- Oxidation catalyst unit capable of achieving 6 ppmvd @ 15% O<sub>2</sub>

Step 4 – Evaluate the Most Effective Control Technology Considering Environmental, Energy, and Cost Impacts

This step evaluates any source-specific environmental, energy, or economic impacts that demonstrate that the top alternative listed in the previous step is inappropriate as BACT.

The applicant has proposed to meet 4 ppmc limit on a 1-hour average basis. Because the applicant has proposed to use the highest ranked technology under consideration, the analysis ends at this step.

Step 5 – Determine BACT/Present Conclusions

BACT must be at least as stringent as the most stringent achieved in practice, required in a federal NSPS or district prohibitory rule, or considered technologically feasible. Based upon the results of this analysis, the CO emission limit of 4.0 ppmvd @ 15% O<sub>2</sub> is considered to be BACT for the proposed project.

## VOC EMISSIONS

### Step 1 – Identify All Possible Control Technologies

Most VOCs emitted from natural gas-fired turbines are the result of incomplete combustion of fuel. Therefore, most of the VOCs are methane and ethane, which are not effectively controlled by an oxidation catalyst. However, oxidation catalyst technology designed to control CO can also provide some degree of control of VOC emissions, especially the more complex and toxic compounds formed in the combustion process. Therefore, use of an oxidation catalyst is generally considered BACT for VOC.

Alternative basic equipment—including renewable energy sources, such as solar and wind—was already discussed above (Step 1 for NO<sub>x</sub> BACT on the CTGs). For the same reasons, solar, wind and other renewable energy sources are rejected as VOC BACT for this application.

### Step 2 – Eliminate Technologically Infeasible Options

The only technology under consideration is use of an oxidation catalyst in combination with combustion controls. This combination of technologies has been demonstrated to be feasible in many applications. No other technologies have been identified that are capable of achieving the same level of control. As a result, the goal of the rest of this analysis is to determine the appropriate emission limit that constitutes BACT for this application.

As shown in Table 3, CARB's BACT guidance document for electric generating units rated at greater than 50 MW<sup>7</sup> indicates that BACT for the control of VOC emissions for simple-cycle power plants is 2 ppmvd @ 15% O<sub>2</sub>.

**Table 3**  
**CARB BACT Guidance For Power Plants**

| Pollutant        | BACT   |
|------------------|--|
| Nitrogen Oxides  | 2.5 ppmv @ 15% O <sub>2</sub> (1-hour average)<br>2.0 ppmv @ 15% O <sub>2</sub> (3-hour average)           |
| Sulfur Dioxide   | Fuel sulfur limit of 1.0 grains/100 scf  |
| Carbon Monoxide  | Nonattainment areas: 6 ppmv @ 15% O <sub>2</sub> (3-hour average)<br>Attainment areas: District discretion |
| VOC              | 2 ppmv @ 15% O <sub>2</sub> (3-hour average)   |
| NH <sub>3</sub>  | 5 ppmv @ 15% O <sub>2</sub> (3-hour average)   |
| PM <sub>10</sub> | Fuel sulfur limit of 1.0 grains/100 scf  |

<sup>7</sup> CARB, "Guidance for Power Plant Siting and Best Available Control Technology," September 1999.

The BAAQMD's BACT guidelines do not include a BACT determination for simple-cycle turbines greater than 40 MW.

The SJVAPCD's BACT guidelines contain a determination for gas turbines rated at larger than 50 MW with variable load and without heat recovery. The SJVAPCD concluded that a VOC exhaust concentration of 0.007 lb/MMBtu (6 ppmvd @ 15% O<sub>2</sub>) constituted BACT that had been achieved in practice.

Published prohibitory rules from the BAAQMD, SMAQMD, SDCAPCD, SJVAPCD, and SCAQMD were reviewed to identify the VOC standards that govern existing natural gas-fired simple-cycle combustion gas turbines. None of the prohibitory rules for combustion gas turbines specify an emission limit for VOC. The applicable NSPS (40 CFR 60 Subpart KKKK) does not include a VOC limit.

This "top-down" VOC BACT analysis will consider the following VOC emission limitations:

- 2 ppmvd @ 15% O<sub>2</sub>

#### Step 3 – Rank Remaining Control Technologies by Control Effectiveness

The control technologies under consideration are ranked as follows:

- 2 ppmvd @ 15% O<sub>2</sub>

#### Step 4 – Evaluate the Most Effective Control Technology Considering Environmental, Energy, and Cost Impacts

This step evaluates any source-specific environmental, energy, or economic impacts that demonstrate that the top alternative listed in the previous step is inappropriate as BACT.

The applicant has proposed to meet a 2 ppmvd limit on a 1-hour average basis. This level meets BACT.

#### Step 5 – Determine BACT/Present Conclusions

BACT must be at least as stringent as the most stringent achieved in practice, required in a federal NSPS or district prohibitory rule, or considered technologically feasible. Based upon the results of this analysis, the VOC emission limits of 2.0 ppmvd @ 15% O<sub>2</sub> are considered to be BACT for the proposed project.

## **SULFUR OXIDE EMISSIONS**

### Step 1 – Identify All Possible Control Technologies

Natural gas fired combustion turbines have inherently low SO<sub>x</sub> emissions due to the small amount of sulfur present in the fuel. With typical pipeline quality natural gas sulfur contents well below 1 grain/100 scf, the SO<sub>x</sub> emissions for natural gas fired combustion turbines are orders of magnitude less than oil-fired turbines. Firing by natural gas, and the resulting control of SO<sub>x</sub> emissions, has been used by numerous combustion turbines throughout the world. Due to the prevalence of the use of natural gas to control SO<sub>x</sub> emissions from combustion turbines, only an abbreviated discussion of post-combustion controls will be addressed in this section.

Post-combustion SO<sub>x</sub> control systems include dry and wet scrubber systems. These types of systems are typically installed on high SO<sub>x</sub> emitting sources such as coal-fired power plants. Post-combustion control systems for combustion turbines also include ES<sub>x</sub> catalyst systems. These systems trap the sulfur in the exhaust stream on an ES<sub>x</sub> catalyst. During a regeneration process, the sulfur is removed from the ES<sub>x</sub> catalyst and is either reintroduced back into the exhaust stream or sent to a sulfur scrubbing system. If the sulfur removed from the ES<sub>x</sub> catalyst is reintroduced back into the exhaust stream, there is no SO<sub>x</sub> control associated with the system.

### Step 2 – Eliminate Technically Infeasible Options

All of the control options discussed above are technically feasible.

### Step 3 – Rank Remaining Control Technologies by Control Effectiveness

The typical SO<sub>x</sub> control level for a well-designed wet or dry scrubber installed on a coal fired boiler ranges from approximately 70% to 90%,<sup>8</sup> with some installations achieving even higher control levels. According to EmeraChem literature,<sup>9</sup> the ES<sub>x</sub> system is capable of removing approximately 95% of the SO<sub>x</sub> emissions from the exhaust stream of natural gas fired combustion turbines. With the sulfur scrubber option, during the regeneration cycle of the ES<sub>x</sub> system the sulfur captured on the ES<sub>x</sub> catalyst is sent to a sulfur scrubbing unit. A high-efficiency sulfur scrubbing unit would achieve a control level similar to that of the wet/dry scrubbers discussed above.

### Step 4 – Evaluate Most Effective Controls and Document Results

The use of low sulfur content pipeline natural gas has been achieved in practice at numerous combustion turbine installations throughout the world, and the use of this fuel minimizes SO<sub>x</sub> emissions. While it would be theoretically feasible to install some type of post-combustion control such as a dry/wet scrubber system or an ES<sub>x</sub> catalyst with a

---

<sup>8</sup> Air Pollution Control Manual, Air and Waste Management Association, Second Edition, page 206.

<sup>9</sup> High Performance EM<sub>x</sub> Emissions Control Technology for Fine Particles, NO<sub>x</sub>, CO, and VOCs from Combustion Turbines and Stationary IC Engines, by Steven DeCicco and Thomas Girdlestone, EmeraChem Power, June 2008, page 19.

sulfur scrubber on a natural gas fired turbine, due to the inherently low SO<sub>x</sub> emissions associated with the use of natural gas, these systems are not cost effective and regulatory agencies do not require them. Consequently, no further discussion of post-combustion SO<sub>x</sub> control is necessary.

#### Step 5 – Determine BACT/Present Conclusions

The SO<sub>x</sub> control method for the proposed ESPFM is the use of pipeline-quality natural gas. Consequently, the proposed project is consistent with BACT requirements.

### **PM/PM<sub>10</sub>/PM<sub>2.5</sub> EMISSIONS**

#### Step 1 – Identify All Possible Control Technologies

Alternative basic equipment—including renewable energy sources, such as solar and wind—has also been identified as a technology for the control of PM/PM<sub>10</sub>/PM<sub>2.5</sub> emissions. Such alternative basic equipment was already discussed above (Step 1 for NO<sub>x</sub> BACT on the CTGs/HRSGs). For the same reasons, solar, wind and other renewable energy sources are rejected as PM<sub>10</sub>/PM<sub>2.5</sub> BACT for this application.

#### *Achievable Controlled Levels and Available Control Options*

PM emissions from natural gas-fired turbines primarily result from carryover of noncombustible trace constituents in the fuel. PM emissions are minimized by using clean-burning pipeline quality natural gas with low sulfur content.

The CARB BACT Clearinghouse, as well as the BAAQMD and SJVAPCD BACT guidelines, identifies the use of natural gas as the primary fuel as “achieved in practice” for the control of PM<sub>10</sub> for combustion gas turbines.

CARB’s BACT guidance document for stationary gas turbines used for power plant configurations<sup>10</sup> indicates that BACT for the control of PM emissions is an emission limit corresponding to natural gas with a fuel sulfur content of no more than 1 grain/100 standard cubic foot.

Title 40 CFR Part 60 Subpart KKKK contains the applicable NSPS for combustion gas turbines. Subpart KKKK does not regulate PM<sub>10</sub> emissions.

Published prohibitory rules from the SCAQMD, SJVAPCD, SMAQMD, and SDCAPCD were reviewed to identify the PM<sub>10</sub> standards that govern natural gas-fired combustion gas turbines. These prohibitory rules do not regulate PM<sub>10</sub> emissions.

---

<sup>10</sup> Ibid, Table I-2.

### Step 2 – Eliminate Technologically Infeasible Options

As discussed above, solar, wind and other renewable energy alternatives are not considered technologically feasible for this application.

### Step 3 – Rank Remaining Control Technologies by Control Effectiveness

No control technology other than use of clean natural gas fuel has been identified for this application.

### Step 4 – Evaluate the Most Effective Control Technology Considering Environmental, Energy, and Cost Impacts

No control technology other than use of clean natural gas fuel has been identified for this application.

### Step 5 – Determine BACT/Present Conclusions

Based upon the results of this analysis, the use of natural gas as the primary fuel source constitutes BACT for PM<sub>10</sub> emissions from combustion gas turbines. Through the use of natural gas, the turbine is expected to be able to meet the proposed emission limit of 5.0 lbs/hr.

## **GHG EMISSIONS**

### Step 1 – Identify All Possible Control Technologies

EPA has indicated in its guidance on BACT for GHGs<sup>11</sup> that the following types of controls must be considered in determining BACT for GHGs:

- Inherently lower-emitting processes/practices/designs;
- Add-on controls; and
- Combinations of inherently lower emitting processes/practices/designs and add-on controls.<sup>12</sup>

EPA further acknowledges that the requirement to consider inherently lower-emitting processes/practices/designs does not require a fundamental redesign of the nature of the source. This indicates that lower-emitting process/practices/designs that do not achieve the goals, objectives, or purposes of the project may be considered technologically infeasible as BACT for a project.

---

<sup>11</sup> EPA, *PSD and Title V Permitting Guidance for Greenhouse Gases*, November 2010, p. 33

<sup>12</sup> *Ibid*, p.27.

The following control technologies were identified as potentially “available” for ESPFM:

- Renewable energy technology (solar or wind),
- Alternative generating technologies,
- Alternative fuels,
- Energy efficiency, and
- Carbon capture and storage.

### *Renewable Energy Technology*

These technologies, and the basis for eliminating them from the BACT analysis, are discussed above under the NO<sub>x</sub> BACT evaluation.

### Step 2 – Eliminate Technologically Infeasible Options

EPA considers a technology to be technically feasible if it has been demonstrated in practice on a similar facility, or is available and applicable to the source type under review. EPA considers a technology to be “available” where it can be obtained through commercial channels or is otherwise available within the common meaning of the term (e.g., it has been demonstrated in practice on a comparable, but not necessarily similar, facility). A technology is applicable if it may reasonably be expected to be successfully applied to the source type under review.

### *Alternative Fossil Fuel Generating Technologies*

Alternative fossil fuel generating technologies such as reciprocating internal combustion engines, boilers, and combined-cycle combustion turbines may be considered as potentially technologically feasible alternatives to the proposed use of simple-cycle combustion turbine technology. Reciprocating engine technology is generally well-suited to demand-response applications such as the proposed project, so can be considered technologically feasible for this application; boilers, on the other hand, have very high thermal inertia, so are not quick-starting or fast ramping. Boiler technology is generally used for baseload power and not for highly variable demand-response power applications. Because boiler technology cannot meet the objectives of the project, it is not considered a technologically feasible alternative. Combined-cycle gas turbines are available with fast startup capability that makes them more compatible with the dispatch and ramping requirements of peaking projects that are intended to back up renewables; in fact, a fast-start combined cycle unit is proposed as part of ESPFM. Therefore, combined-cycle gas turbine technology is potentially technologically feasible for the proposed project.

### *Alternative Fuels*

Biomass fuel can only be used with boiler technology and must be gasified for use in turbines. As discussed previously, boiler technology is not considered a technologically feasible alternative. Therefore, there are no alternative fuels that are considered technologically feasible without redefining the project.



### *Energy Efficiency*

There are two potential applications of energy efficiency as potential BACT for the proposed project: (1) demand-side management and similar electric load reduction programs to minimize or eliminate the need for the proposed project altogether; and (2) use of the most efficient generating technology that meets the objectives of the project.

Implementation of energy efficiency programs is beyond the scope of this project. The purpose of this project is to help meet the energy demands that will remain after utility energy efficiency programs are implemented.

Utilization of the most efficient generating technology that meets the objectives of the project is technologically feasible.

### *Carbon Capture and Storage*

Carbon capture and storage (CCS) technology may be considered to be “available” in the sense that commercial facilities have been built on a scale comparable to ESPFM (e.g., a natural gas processing operation<sup>13</sup> in Wyoming captures 3.6 million tonnes per year of CO<sub>2</sub>, compared to the 0.6 million tonnes per year that would be emitted from ESPFM). However, the technology cannot yet be considered “applicable.” The Interagency Task Force on Carbon Capture and Storage (ITF) found the following:

*it is unclear how transferable the experience with natural gas processing is to separation of power plant flue gases, given the significant differences in the chemical make-up of the two gas streams. In addition, integration of these technologies with the power cycle at generating plants present significant cost and operating issues that will need to be addressed.*<sup>14</sup>

CCS has not yet reached the licensing and commercial sales stage of development. It is an emerging technology that has had limited successful application on an industrial scale, and no successful applications on a comparably sized natural gas power plant. There are no CCS systems commercially available for natural gas power plants in the United States. The Department of Energy expects commercial deployment in 2025.<sup>15</sup> CCS does not appear to be commercially available for this application.

### Step 3 – Rank Remaining Control Technologies

Absent post-combustion removal or sequestration, CO<sub>2</sub> and other GHG emissions are a direct function of the amount of natural gas fuel burned. GHG emissions will be

---

<sup>13</sup> Interagency Task Force on Carbon Capture and Storage, *Report of the Interagency Task Force on Carbon Capture and Storage*, August 2010. p. 28.

<sup>14</sup> *Ibid.*

<sup>15</sup> 73 FR 44370

minimized by minimizing heat rate and maximizing generating efficiency. The remaining technologies are ranked by their overall heat rate for consideration as BACT for this project, as shown in Table 4.

CO<sub>2</sub> is not the byproduct of incomplete combustion or contaminants in the fuel supply. It is an essential product of the combustion of natural gas. Therefore, the only way to reduce the amount of CO<sub>2</sub> generated is to minimize the amount of fuel combustion required to produce the desired amount of electricity. This is achieved by operating the unit efficiently and conducting regular maintenance to ensure continued good combustion. Good combustion practices are a well-established and widely used technique to minimize emissions from combustion sources. Good combustion operation and maintenance will maintain the thermal efficiency of the selected generating technology and therefore must also be considered a component of BACT to minimize GHG emissions.

**Table 4**  
**Ranking of Potential Generating Technologies/Controls by Heat Rate**

| Technology                  | Heat Rate Range (HHV basis)              | Technologically Feasible for This Project? |
|-----------------------------|--|--|
| Renewable energy sources    | n/a                                      | No   |
| Biomass and other biofuels  | n/a                                      | No   |
| Demand-side management      | n/a                                      | No   |
| CCS                         | n/a                                      | Maybe                                      |
| Combined-cycle gas turbines | ~7000 to 8000 Btu/kWh <sup>a,b,c</sup>   | Yes  |
| Reciprocating IC engines    | ~7500 Btu/kWh <sup>d</sup>               | Yes  |
| Simple-cycle gas turbines   | ~9400 to 10,000 Btu/kWh <sup>a,b,c</sup> | Yes  |
| Boilers                     | >10,000 Btu/kWh <sup>a,b,c</sup>         | No   |

Notes:

- a. CEC FSA, Avenal Project. <http://www.energy.ca.gov/sitingcases/avenal/index.html>
- b. CEC FSA, TIC Almond 2 Power Plant Project. <http://www.energy.ca.gov/sitingcases/almond/index.html>
- c. CEC FSA, Carlsbad Energy Center Project. <http://www.energy.ca.gov/sitingcases/carlsbad/index.html>
- d. Wärtsilä, specifications for 16V34SG and 20V34SG gas engines. [www.wartsila.com](http://www.wartsila.com)

**Step 4 – Evaluate the Most Effective Control Technology Considering Environmental, Energy, and Cost Impacts**

*Combined-cycle gas turbines*

Combined-cycle gas turbines are inherently more efficient than simple-cycle gas turbines because they extract and use exhaust heat that would otherwise be wasted. A combined-cycle gas turbine is already proposed as part of this project, which will efficiently supply electricity. The proposed simple-cycle turbines supplement the combined-cycle unit by providing load-following capability and black start capability that cannot be provided by the combined cycle unit alone.

### *Reciprocating IC engines*

Reciprocating IC engines are fast-starting, but the largest natural gas-fired IC engine currently available is the approximately 9 MW Wärtsilä 20V34SG.<sup>16</sup> The nominal 115 MW size of the proposed simple-cycle component of the project would require 13 of these engines, which would result in a far more complex and expensive plant and control system. Furthermore, BACT for NO<sub>x</sub> from engines of this type was recently determined to be 5 ppm, so NO<sub>x</sub> emissions from a comparable reciprocating engine plant would be approximately twice the NO<sub>x</sub> emissions from the proposed simple-cycle gas turbine project. Therefore, reciprocating IC engine technology is not considered BACT for this project.

### *Carbon Capture and Storage*

CCS technology applicable to natural gas-fired projects refers to post-combustion capture. EPA's Interagency Task Force on Carbon Capture and Storage<sup>17</sup> found the following:

*Post-combustion CO<sub>2</sub> capture ... is challenging for the following reasons:*

- *A high volume of gas must be treated because the CO<sub>2</sub> is dilute (13 to 15 percent by volume in coal-fired systems, three to four percent in natural-gas-fired systems);*
- *The flue gas is at low pressure (near atmosphere);*
- *trace impurities (particulate matter [PM], sulfur oxides [SO<sub>x</sub>], nitrogen oxides [NO<sub>x</sub>], etc.) can degrade the CO<sub>2</sub> capture materials; and*
- *Compressing captured CO<sub>2</sub> from near atmospheric pressure to pipeline pressure (about 2,000 pounds per square inch absolute) requires a large auxiliary power load...Installing current amine post-combustion CO<sub>2</sub> capture technology on new conventional subcritical, supercritical, and ultra-supercritical coal-fired power plants would increase the COE by about 80 percent. Further, the large quantity of energy required to regenerate the amine solvent and compress the CO<sub>2</sub> to pipeline conditions would result in about a 30 percent energy penalty.*

The International Energy Agency estimates that “CCS can reduce CO<sub>2</sub> emissions from power plants...by more than 85%, and power plant efficiency by about 8-12 percentage points.”<sup>18</sup> Although this energy penalty is for coal-fired plants and is not directly applicable to natural gas firing, it is expected to be reasonably representative of the

---

<sup>16</sup> <http://powerservices.lakho.com/2009/05/19/largest-natural-gas-reciprocating-engine-plant/>

<sup>17</sup> EPA, “Report of the Interagency Task Force on Carbon Capture and Storage,” 2010, pp. 29-30  
<http://www.epa.gov/climatechange/downloads/CCS-Task-Force-Report-2010.pdf>

<sup>18</sup> IEA Energy Technology Essentials, December 2006. <http://www.iea.org/techno/essentials.htm>

energy penalty for a natural gas-fired system because the lower content of CO<sub>2</sub> in gas turbine exhaust would not necessarily result in an efficiency savings (separation is still required, and there are no data to suggest that the differences in CO<sub>2</sub> concentrations between coal exhaust and gas turbine exhaust would result in lower separation costs). Assuming a minimum 8% energy penalty for CCS, the project would have to generate 8% more electricity to provide energy for CCS without reducing the electricity supply provided by the facility. Criteria pollutant and GHG emissions would also be 8% higher. Considering the energy and emissions penalties, the cost, and the lack of commercial availability, CCS is not considered BACT for the proposed project.

#### Step 5 – Determine BACT/Present Conclusions

As shown in Table 4, simple-cycle gas turbines typically have heat rates that range between 9,000 and 10,000 Btu/kWh. ESPFM proposes to use a newer, more energy efficient simple-cycle turbine technology, the Trent 60, which incorporates intercooling to promote enhanced energy efficiency. The heat rate of the Trent 60 is approximately 9,000 Btu/kWh (HHV), at the low end of the range of heat rates shown above for typical simple-cycle gas turbines. The use of this highly efficient simple-cycle gas turbine technology, combined with good combustion operation and maintenance to maintain optimum efficiency, is determined to be BACT for GHG.

Recent BACT determinations for criteria pollutants from similar gas turbine projects are summarized in Tables 5 through 7.

**Table 5  
Simple-Cycle Gas Turbine BACT Determinations (EPA RBLC Clearinghouse)**

| Facility/Location                               | Date Permit Issued | Equipment/Rating                         | NOx Limit/Control Technology                       | CO Limit/Control Technology | VOC Limit/Control Technology |
|---|--------------------|--|--|-----------------------------|------------------------------|
| Shady Hills Generating Station<br>Pasco Co., FL | January 2010       | GE Frame 7FA<br>2 turbines, 340 MW total | 9.0 ppm<br>Dry low-NOx burners and water injection | 6.5 ppm (3 hour)            | No BACT determination        |
| Rawhide Energy Station<br>Larimer Co., CA       | June 2009          | GE Frame 7FA<br>1 turbine, 150 MW total  | 9.0 ppm<br>Dry low-NOx burners                     | No BACT determination       | No BACT determination        |
| TEC/Polk Power Energy Station<br>Polk Co., FL   | October 2007       | Unspecified<br>2 turbines, 330 MW total  | 9.0 ppm<br>Dry low-NOx burners                     | No BACT determination       | No BACT determination        |

**Table 6  
Summary of BACT Determinations (CARB BACT Clearinghouse)**

| Facility/District  | Permit No./Date | Equipment/Rating   | NOx Limit/Control Technology | CO Limit/Control Technology   | VOC Limit/Control Technology  |
|--|-----------------|--|------------------------------|-------------------------------|-------------------------------|
| CalPeak Power El Cajon<br>San Diego Co., CA                    | June 2001       | Pratt & Whitney<br>FT-8 DLN Twin Pac<br>2 turbines 49.5 MW total | 3.5 ppm<br>SCR               | 50 ppm<br>Oxidation catalyst  | 2.0 ppm<br>Oxidation catalyst |
| Indigo Energy Facility<br>Los Angeles Co., CA                  | July 2001       | LM6000 (Enhanced Sprint)<br>1 turbine, 45 MW total               | 5.0 ppm<br>SCR               | 6.0 ppm<br>Oxidation catalyst | 2.0 ppm<br>Oxidation catalyst |
| El Colton, LLC<br>San Bernardino Co., CA                       | January 2003    | LM6000 (Enhanced Sprint)<br>1 turbine, 48.7 MW total             | 3.5 ppm<br>SCR               | 6.0 ppm<br>Oxidation catalyst | 2.0 ppm<br>Oxidation catalyst |
| Lambie Energy Center<br>Solano Co., CA                         | December 2002   | GE LM6000 Sprint PC<br>1 turbine, 49.9 MW total                  | 2.5 ppm<br>SCR               | 6.0 ppm<br>Oxidation catalyst | 2.0 ppm<br>Oxidation catalyst |
| Los Angeles Dept. of<br>Water and Power<br>Los Angeles Co., CA | May 2001        | GE LM6000<br>1 turbine, 47.4 MW total                            | 5.0 ppm<br>SCR               | 6.0 ppm<br>Oxidation catalyst | 2.0 ppm<br>Oxidation catalyst |

**Table 7  
Summary of BACT Determinations (CEC Decisions)**

| Facility/District  | Decision Date | Equipment/Rating  | NOx Limit/ Control Technology                                   | CO Limit/Control Technology            | VOC Limit/Control Technology  |
|--|---------------|---|---|--|-------------------------------|
| TID Almond 2 Power Plant<br>Ceres, CA  | December 2010 | GE LM6000 Sprint<br>PG<br>3 turbines, 174 MW                      | 2.5 ppm<br>Ultra-low NOx<br>burners, water<br>injection and SCR | 4.0 ppm (3 hour)<br>Oxidation catalyst | 2.0 ppm<br>Oxidation catalyst |
| Canyon Power Plant<br>Orange Co., CA   | March 2010    | GE LM6000 Sprint PC<br>4 turbines, 200 MW<br>total                | 2.5 ppm<br>Ultra-low NOx<br>burners, water<br>injection and SCR | 4.0 ppm (3 hour)<br>Oxidation catalyst | 2.0 ppm<br>Oxidation catalyst |
| Starwood Power-Midway<br>Fresno Co., CA  | January 2008  | Pratt & Whitney FT8-<br>3 SwiftPac<br>2 turbines, 120 MW<br>total | 2.5 ppm<br>Water injection and<br>SCR                           | 6.0 ppm (3 hour)<br>Oxidation catalyst | 2.0 ppm<br>Oxidation catalyst |
| Panoche Energy Project<br>Fresno Co., CA   | December 2007 | GE LMS100<br>4 turbines, 400 MW<br>total                          | 2.5 ppm<br>Water injection and<br>SCR                           | 6.0 ppm (3 hour)<br>Oxidation catalyst | 2.0 ppm<br>Oxidation catalyst |
| San Francisco Electric<br>Reliability Project Power Plant<br>San Francisco Co., CA | October 2006  | GE LM6000 Sprint PC<br>3 turbines, 145 MW<br>total                | 2.5 ppm<br>Water injection and<br>SCR                           | 4.0 ppm (3 hour)<br>Oxidation catalyst | 2.0 ppm<br>Oxidation catalyst |
| Inland Empire Energy Center<br>Imperial County, CA                                 | October 2006  | GE LM6000 Sprint PC<br>2 turbines, 93 MW<br>total                 | 2.5 ppm<br>Dry low-NOx<br>burners and SCR                       | 6.0 ppm (3 hour)<br>Oxidation catalyst | 2.0 ppm<br>Oxidation catalyst |

## BACT for the Simple-Cycle CTGs: Startup/Shutdown

Startup and shutdown periods are a normal part of the operation of simple-cycle power plants such as ESPFM. BACT must also be applied during the startup and shutdown periods of gas turbine operation. The BACT limits discussed in the previous section apply to steady-state operation, when the turbines have reached stable operations and the emission control systems are fully operational.

### **NO<sub>x</sub> EMISSIONS**

#### Step 1 – Identify All Possible Control Technologies

The following technologies for control of NO<sub>x</sub> during startups and shutdowns have been identified:

- A Selective Catalytic Reduction (SCR) system capable of continuously complying with a limit of 2.5 ppmvd @15% O<sub>2</sub> (1-hour average);
- Fast-start technologies;
- Operating practices to minimize the duration of startup and shutdown.

The Trent turbine proposed for this project is controlled by SCR, which will operate at all times that the stack temperature is in the proper operating range.

#### Step 2 – Eliminate Technologically Infeasible Options

During gas turbine startup, there are equipment and process requirements that must be met in sequential order to protect the equipment.

For all turbine technologies, incomplete combustion at low loads results in higher CO and VOC emission rates. Furthermore, the post-combustion controls that are used to achieve additional emissions reductions (SCR and oxidation catalyst) require that specific exhaust temperature ranges be reached to be fully effective. The use of SCR to control NO<sub>x</sub> is not technically feasible when the surface of the SCR catalyst is below the manufacturer's recommended operating range. When catalyst surface temperatures are low, ammonia will not react completely with the NO<sub>x</sub>, resulting in excess NO<sub>x</sub> emissions or excess ammonia slip or both. The oxidation catalyst is not effective at controlling CO emissions when exhaust temperature is below the optimal temperature range. Therefore, exhaust gas controls used to achieve BACT for normal operations are not feasible control techniques during startups and shutdowns.

This “top-down” BACT analysis will consider the following NO<sub>x</sub> emission limitations:

- Operating practices to minimize emissions during startup and shutdown; and
- Design features to minimize the duration of startup and shutdown.

### Step 3 – Rank Remaining Control Technologies by Control Effectiveness

#### *Operating Practices to Minimize Emissions during Startup and Shutdown*

There are basic principles of operation, or Best Management Practices, that minimize emissions during startups and shutdowns. These Best Management Practices are outlined below.

- During a startup, bring the gas turbine to the minimum load necessary to achieve compliance with the applicable NO<sub>x</sub> and CO emission limits as quickly as possible, consistent with the equipment manufacturers' recommendations and safe operating practices.
- During a startup, initiate ammonia injection to the SCR system as soon as the SCR catalyst temperature and ammonia vaporization system have reached their minimum operating temperatures.
- During a shutdown, once the turbine reaches a load that is below the minimum load necessary to maintain compliance with the applicable NO<sub>x</sub> and CO emission limits, reduce the gas turbine load to zero as quickly as possible, consistent with the equipment manufacturers' recommendations and safe operating practices.
- During a shutdown, maintain ammonia injection to the SCR system as long as the SCR catalyst temperature and ammonia vaporization system remain above their minimum operating temperatures.

A key underlying consideration of these Best Management Practices is the overall safety of the plant staff by promoting operation within the limitations of the equipment and systems, and allowing for operator judgment and response times to respond to alarms and trips during the startup sequence.

#### *Design Features to Minimize the Duration of Startup and Shutdown*

An additional technique to reduce startup emissions is to minimize the amount of time the gas turbine spends in startup. The use of simple-cycle gas turbine technology inherently minimizes this time, in that simple-cycle gas turbines generally start up and shut down much more quickly than combined-cycle turbines.

### Step 4 – Evaluate the Most Effective Control Technology Considering Environmental, Energy, and Cost Impacts

Utilizing best operating practices to minimize emissions during startups and shutdowns has no adverse environmental or energy impacts, nor does it require additional capital expenditure.



The approach of reducing startup/shutdown duration has no adverse environmental or energy impacts, and the use of simple-cycle generating technology minimizes startup/shutdown duration.

#### Step 5 - Determine BACT/Present Conclusions

BACT for NO<sub>x</sub> during startups/shutdowns is the use of operating systems/practices that reduce the duration of startups and shutdowns to the greatest extent feasible, and the use of operational techniques to initiate ammonia injection as soon as possible during a startup. Therefore, BACT is determined to be the use of simple-cycle gas turbine technology and the application of operating systems/practices that minimize startup and shutdown durations, in combination with the use of operational techniques to initiate ammonia injection as soon as possible during a startup.

### **CO EMISSIONS**

#### Step 1 – Identify All Possible Control Technologies

The CO control technologies under consideration for startups and shutdowns are ranked as follows:

- Oxidation catalyst unit capable of achieving 4 ppmvd @ 15% O<sub>2</sub>
- Operating practices to minimize the duration of startup and shutdown

#### Step 2 – Eliminate Technologically Infeasible Options

None of the proposed alternatives is infeasible for this application.

#### Step 3 – Rank Remaining Control Technologies by Control Effectiveness

Ranking for the control technologies is as indicated in Step 1.

#### Step 4 – Evaluate the Most Effective Control Technology Considering Environmental, Energy, and Cost Impacts

Similar to the discussion above for NO<sub>x</sub>, CO emissions during startup and shutdown are minimized by minimizing the length of time that the turbine fires while the oxidation catalyst is not in its operating temperature range.

#### Step 5 – Determine BACT/Present Conclusions

BACT for CO during startups/shutdowns is the use of simple-cycle gas turbine technology and operating practices that reduce the duration of startups and shutdowns to the greatest extent feasible.

## **VOC EMISSIONS**

### Step 1 – Identify All Possible Control Technologies

The VOC control technologies under consideration for startups and shutdowns are ranked as follows:

- Operating practices to minimize the duration of startup and shutdown

### Step 2 – Eliminate Technologically Infeasible Options

None of the proposed alternatives is infeasible for this application.

### Step 3 – Rank Remaining Control Technologies by Control Effectiveness

Ranking for the control technologies is as indicated in Step 1.

### Step 4 – Evaluate the Most Effective Control Technology Considering Environmental, Energy, and Cost Impacts

VOC emissions during startup and shutdown are minimized by minimizing the length of time during startup and shutdown.

### Step 5 – Determine BACT/Present Conclusions

BACT for VOC during startups/shutdowns is the use of simple-cycle gas turbine technology and operating practices that reduce the duration of startups and shutdowns to the greatest extent feasible.

## **SULFUR OXIDE EMISSIONS**

### Step 1 – Identify All Possible Control Technologies

The SO<sub>x</sub> control technologies under consideration for startups and shutdowns are ranked as follows:

- Use of natural gas as a fuel
- Operating practices to minimize the duration of startup and shutdown

### Step 2 – Eliminate Technologically Infeasible Options

None of the proposed alternatives is infeasible for this application.

### Step 3 – Rank Remaining Control Technologies by Control Effectiveness

Ranking for the control technologies is as indicated in Step 1.

Step 4 – Evaluate the Most Effective Control Technology Considering Environmental, Energy, and Cost Impacts

SO<sub>x</sub> emissions during startup and shutdown are minimized by minimizing the length of time during startup and shutdown.

Step 5 – Determine BACT/Present Conclusions

BACT for SO<sub>x</sub> during startups/shutdowns is the use of simple-cycle gas turbine technology and operating practices that reduce the duration of startups and shutdowns to the greatest extent feasible.

**PM/PM<sub>10</sub>/PM<sub>2.5</sub> EMISSIONS**

Step 1 – Identify All Possible Control Technologies

The analysis for particulate is identical to the analysis for SO<sub>x</sub>.

Step 2 – Eliminate Technologically Infeasible Options

The analysis for particulate is identical to the analysis for SO<sub>x</sub>.

Step 3 – Rank Remaining Control Technologies by Control Effectiveness

The analysis for particulate is identical to the analysis for SO<sub>x</sub>.

Step 4 – Evaluate the Most Effective Control Technology Considering Environmental, Energy, and Cost Impacts

The analysis for particulate is identical to the analysis for SO<sub>x</sub>.

Step 5 – Determine BACT/Present Conclusions

BACT for particulate during startups/shutdowns is the use of simple-cycle gas turbine technology and operating practices that reduce the duration of startups and shutdowns to the greatest extent feasible.

**GHG EMISSIONS**

Step 1 – Identify All Possible Control Technologies

The GHG control technologies under consideration for startups and shutdowns are ranked as follows:

- Operating practices to minimize the duration of startup and shutdown

Step 2 – Eliminate Technologically Infeasible Options

None of the proposed alternatives is infeasible for this application.

Step 3 – Rank Remaining Control Technologies by Control Effectiveness

Ranking for the control technologies is as indicated in Step 1.

Step 4 – Evaluate the Most Effective Control Technology Considering Environmental, Energy, and Cost Impacts

GHG emissions during startup and shutdown are minimized by minimizing the length of time during startup and shutdown.

Step 5 – Determine BACT/Present Conclusions

BACT for GHG during startups/shutdowns is the use of simple-cycle gas turbine technology and operating practices that reduce the duration of startups and shutdowns to the greatest extent feasible.

**SUMMARY**

Proposed BACT determinations for the ESPFM simple-cycle gas turbines are summarized in Table 8.

**Table 8  
Proposed BACT Determinations for ESPFM Simple-Cycle Gas Turbines**

| Pollutant         | Proposed BACT Determination  |
|-------------------|--|
| Nitrogen Oxides   | Dry low-NOx combustors and SCR system, 2.5 ppmc <sup>a</sup> , 1-hour average, with excursions under specific conditions; no CCS |
| Sulfur Dioxide    | Natural gas fuel (sulfur content not to exceed 0.75 grain/100 scf short-term average, 0.25 grains/100 scf long-term average)     |
| Carbon Monoxide   | Good combustion practices and oxidation catalyst, 4.0 ppmc, 1-hour average   |
| VOC               | Good combustion practices, 2.0 ppmc, 1-hour average  |
| PM <sub>10</sub>  | Natural gas fuel, 5 PM <sub>10</sub> lbs/hr  |
| PM <sub>2.5</sub> | Natural gas fuel, 5 PM <sub>2.5</sub> lbs/hr   |
| GHGs              | Trent 60 simple-cycle gas turbine technology, good combustion practices  |
| Ammonia           | 5 ppm ammonia slip   |
| Startup/Shutdown  | Best operating practices to minimize startup/shutdown times and emissions  |

Note:

a. ppmc: parts per million by volume, corrected to 15% O<sub>2</sub>

## BACT for the Combined-Cycle CTG: Normal Operations

### **NO<sub>x</sub> EMISSIONS**

#### Step 1 – Identify All Possible Control Technologies

The emissions unit for which BACT is being considered is a nominal 210 MW gas turbine operating in combined cycle. Potential control technologies were identified by searching the following sources for determinations pertaining to combustion gas turbines:

- SCAQMD BACT Guidelines;
- SJVAPCD BACT Clearinghouse;
- BAAQMD BACT Guidelines;
- EPA RACT/BACT/ Lowest Achievable Emission Rate Clearinghouse;
- Other district and state BACT Guidelines; and
- BACT/LAER requirements in New Source Review permits issued by a local air district<sup>19</sup> or other air pollution control agency.

Technologies identified for control of NO<sub>x</sub> are listed below.

- Selective Catalytic Reduction (SCR) system capable of continuously complying with a limit of 2.0 ppmvd @15% oxygen (O<sub>2</sub>) (1-hour average)
- EMx (formerly SCONOx) system capable of continuously complying with a limit of 2.0 ppmvd @15% O<sub>2</sub> (1-hour average)
- Alternative Basic Equipment: renewable energy source (e.g., solar, wind, etc.)

Alternative basic equipment—including renewable energy sources, such as solar and wind—was already discussed above (Step 1 for NO<sub>x</sub> BACT for the simple-cycle CTGs). For the same reasons, solar, wind and other renewable energy sources are rejected as NO<sub>x</sub> BACT for this application.

#### Step 2 – Eliminate Technologically Infeasible Options

##### *Exhaust Stream Controls*

The most recent NO<sub>x</sub> BACT listings for industrial combined-cycle combustion turbines in this size range are summarized in Table 9. The most stringent NO<sub>x</sub> limit in these recent BACT determinations is a 2.0 ppm<sup>20</sup> limit averaged over a 1-hour averaging period, excluding startups and shutdowns. This level is achieved using dry low-NO<sub>x</sub> combustors and SCR.

---

<sup>19</sup> Any Air Quality Management District or Air Pollution Control District in California.

<sup>20</sup> All turbine/HRSG exhaust emissions concentrations shown are by volume, dry corrected to 15% O<sub>2</sub>.

**Table 9  
Recent NOx BACT Determinations for Combined-Cycle Combustion Turbines**

| Facility                    | District | NOx Limit <sup>a</sup> | Averaging Period | Control Method Used | Date Permit Issued | Source  |
|-----------------------------|----------|------------------------|------------------|---------------------|--------------------|---------|
| Inland Empire Energy Center | SCAQMD   | 2.0                    | 1-hour           | SCR                 | 2003               | CEC AFC |
| El Segundo                  | SCAQMD   | 2.0                    | 1-hour           | SCR                 | 2010               | CEC AFC |
| GWF Tracy                   | SJVAPCD  | 2.0                    | 1-hour           | SCR                 | 2010               | CEC AFC |
| Oakley Generating Station   | BAAQMD   | 2.0                    | 1-hour           | SCR                 | 2011               | CEC AFC |
| Watson Cogeneration         | SCAQMD   | 2.0                    | 1-hour           | SCR                 | 2012               | CEC AFC |

Note:

a. All concentrations expressed as parts per million by volume dry, corrected to 15% O<sub>2</sub>.

Either SCR or EMx technology is capable of achieving a NOx emission level of 2.0 ppmvd @ 15% O<sub>2</sub>. Neither has been demonstrated to consistently achieve lower emission levels in combined-cycle turbines. See the discussion of these two technologies in the BACT section for simple-cycle turbines.

Step 3 – Rank Remaining Control Technologies by Control Effectiveness

SCR (and arguably, EMx) is capable of achieving a NOx emission level of 2.0 ppmvd @ 15% O<sub>2</sub>. Both technologies are therefore ranked together.

Step 4 – Evaluate the Most Effective Control Technology Considering Environmental, Energy, and Cost Impacts

The comparison between SCR and EMx is the same for application to combined cycle as for simple cycle. Both are deemed capable of achieving 2.0 ppmvd NOx emission levels.

Step 5 – Determine BACT/Present Conclusions

BACT must be at least as stringent as the most stringent level achieved in practice, federal NSPS, or district prohibitory rule. Based upon the results of this analysis, the NOx BACT determination of 2.0 ppmvd @ 15% O<sub>2</sub> on a 1-hour average basis made for recently permitted combined-cycle turbine projects in SCAQMD and elsewhere reflects the most stringent NOx emission limit that has been achieved in practice. No more stringent level has been suggested as being technologically feasible. Therefore, BACT for NOx for this application is any technology capable of achieving 2.0 ppmvd @ 15% O<sub>2</sub> on a 1-hour average basis.

The Project facility will be designed to meet a NOx level of 2.0 ppmvd @ 15% O<sub>2</sub> on a 1-hour average basis using SCR.

## CO EMISSIONS

### Step 1 – Identify All Possible Control Technologies

CO emitted from natural gas-fired turbines is the result of incomplete combustion of fuel. Use of an oxidation catalyst is generally considered BACT for CO.

Alternative basic equipment—including renewable energy sources, such as solar and wind—was already discussed above (Step 1 for NO<sub>x</sub> BACT on the CTGs). For the same reasons, solar, wind and other renewable energy sources are rejected as CO BACT for this application.

### Step 2 – Eliminate Technologically Infeasible Options

The only technology under consideration is use of an oxidation catalyst in combination with combustion controls. This combination of technologies has been demonstrated to be feasible in many applications. No other technologies have been identified that are capable of achieving the same level of control. As a result, the goal of the remaining analysis is to determine the appropriate emission limit that constitutes BACT for this application.

CARB's BACT guidance document for electric generating units rated at greater than 50 MW indicates that BACT for the control of CO emissions from stationary gas turbines used for combined-cycle and cogeneration power plants is 6 ppmvd @ 15% O<sub>2</sub> (see Table 3).

The BAAQMD's BACT guidelines specify that, for natural gas-fired combined-cycle gas turbines larger than 40 MW, a CO limit of 4 ppmv @ 15% O<sub>2</sub> has been "achieved in practice."

The SJVAPCD's BACT guidelines contained determinations for gas turbines larger than 50 MW with uniform load and with heat recovery. The SJVAPCD concluded that a CO exhaust concentration of 6 ppmv @ 15% O<sub>2</sub> constituted BACT that had been achieved in practice, while 4.0 ppmv @ 15% O<sub>2</sub> is considered technologically feasible.

A summary of recent CO BACT determinations for large, combined-cycle gas turbines is shown in Table 10. Similar facilities using oxidation catalysts have been permitted at between 2.0 and 4.0 ppm CO.

Published prohibitory rules from the BAAQMD, SMAQMD, SDCAPCD, SJVAPCD, and SCAQMD were reviewed to identify the CO standards that govern existing natural gas-fired simple-cycle combustion gas turbines. Of the five prohibitory rules reviewed, the SJVAPCD prohibitory rule for combustion gas turbines is the only one that includes an emission limit for CO (200 ppmv @ 15% O<sub>2</sub>). The applicable NSPS (40 CFR 60 Subpart KKKK) does not include a CO limit.

**Table 10**  
**Recent CO BACT Determinations for Combined-Cycle Combustion Turbines**

| Facility                  | District | CO Limit <sup>a</sup> | Averaging Period | Control Method Used | Date Permit Issued | Source  |
|---------------------------|----------|-----------------------|------------------|---------------------|--------------------|---------|
| Inland Empire             | SCAQMD   | 4.0                   | 1-hour           | Oxidation Catalyst  | 2003               | CEC AFC |
| El Segundo                | SCAQMD   | 2.0                   | 1-hour           | Oxidation Catalyst  | 2010               | CEC AFC |
| Oakley Generating Station | BAAQMD   | 2.0                   | 1-hour           | Oxidation catalyst  | 2011               | CEC AFC |
| GWF Tracy                 | SJVAPCD  | 2.0                   | 1-hour           | Oxidation catalyst  | 2010               | CEC AFC |
| Watson Cogeneration       | SCAQMD   | 2.0                   | 1-hour           | Oxidation catalyst  | 2012               | CEC AFC |

Note:

a. All concentrations expressed as parts per million by volume dry, corrected to 15% O<sub>2</sub>.

Step 3 – Rank Remaining Control Technologies by Control Effectiveness

The control technologies under consideration are ranked as follows:

- Oxidation catalyst unit capable of achieving 2 ppmvd @ 15% O<sub>2</sub>

Step 4 – Evaluate the Most Effective Control Technology Considering Environmental, Energy, and Cost Impacts

This step evaluates any source-specific environmental, energy, or economic impacts that demonstrate that the top alternative listed in the previous step is inappropriate as BACT.

The applicant has proposed to meet 2 ppmc limit on a 1-hour average basis. Because the applicant has proposed to use the highest-ranked technology under consideration, the analysis ends at this step.

Step 5 – Determine BACT/Present Conclusions

BACT must be at least as stringent as the most stringent level achieved in practice, required in a federal NSPS or district prohibitory rule, or considered technologically feasible. The proposed CO emission limit of 2 ppmvd @ 15% O<sub>2</sub> on a 1-hour average basis is BACT for this source.



## VOC EMISSIONS

### Step 1 – Identify All Possible Control Technologies

Most VOCs emitted from natural gas-fired turbines are the result of incomplete combustion of fuel. Therefore, most of the VOCs are methane and ethane, which are not effectively controlled by an oxidation catalyst. However, oxidation catalyst technology designed to control CO can also provide some degree of control of VOC emissions, especially the more complex and toxic compounds formed in the combustion process.

Alternative basic equipment—including renewable energy sources, such as solar and wind—has also been identified as a technology for the control of VOC emissions.

### Step 2 – Eliminate Technologically Infeasible Options

The only technology under consideration is use of an oxidation catalyst in combination with combustion controls. This combination of technologies has been demonstrated to be feasible in many applications. No other technologies have been identified that are capable of achieving the same level of control. As a result, the goal of the remainder of this analysis is to determine the appropriate emission limit that constitutes BACT for this application.

CARB's BACT guidance document for electric generating units rated at greater than 50 MW<sup>21</sup> indicates that BACT for the control of VOC emissions for combined-cycle and cogeneration power plants is 2 ppmvd @ 15% O<sub>2</sub> (see Table 3).

The SJVAPCD's BACT guidelines contain a determination for gas turbines rated at larger than 50 MW with uniform load and without heat recovery. The SJVAPCD concluded that a VOC exhaust concentration of 2.0 ppmvd @ 15% O<sub>2</sub> constituted BACT that had been achieved in practice, while 0.6 to 1.3 ppmvd @ 15% O<sub>2</sub> is considered technologically feasible.

Published prohibitory rules from the BAAQMD, SMAQMD, SDCAPCD, SJVAPCD, and SCAQMD were reviewed to identify the VOC standards that govern existing natural gas-fired combined-cycle combustion gas turbines. None of the prohibitory rules for combustion gas turbines specify an emission limit for VOC. The applicable NSPS (40 CFR 60 Subpart KKKK) does not include a VOC limit.

This “top-down” VOC BACT analysis will consider the following VOC emission limitations:

- 0.6 ppmvd @ 15% O<sub>2</sub> (3-hour average);
- 1.3 ppmvd @ 15% O<sub>2</sub> (3-hour average); and
- 2 ppmvd @ 15% O<sub>2</sub> (1-hour average).

---

<sup>21</sup> CARB, “Guidance for Power Plant Siting and Best Available Control Technology,” September 1999.

Alternative basic equipment—including renewable energy sources, such as solar and wind—was already discussed above (Step 2 for NO<sub>x</sub> BACT on the CTG). For the same reasons, solar, wind and other renewable energy sources are rejected as VOC BACT for this application.

### Step 3 – Rank Remaining Control Technologies by Control Effectiveness

The control technologies under consideration are ranked as follows:

- Oxidation catalyst unit capable of achieving 0.6 ppmvd @ 15% O<sub>2</sub>
- Oxidation catalyst unit capable of achieving 1.3 ppmvd @ 15% O<sub>2</sub>
- Oxidation catalyst unit capable of achieving 2 ppmvd @ 15% O<sub>2</sub>

### Step 4 – Evaluate the Most Effective Control Technology Considering Environmental, Energy, and Cost Impacts

This step evaluates any source-specific environmental, energy, or economic impacts that demonstrate that the top alternative listed in the previous step is inappropriate as BACT.

#### *“Achieved in Practice” Criterion*

As discussed above, the SJVAPCD BACT guideline for large gas turbines without heat recovery suggests that VOC emission rates of between 0.6 and 1.3 ppm may be technologically feasible, based on two recently permitted projects. The Sunrise Power Company project used a 165 MW GE Frame 7FA gas turbine with dry low NO<sub>x</sub> (DLN) combustors for NO<sub>x</sub> control. The Tracy Peaker project used an 84 MW GE Frame 7EA gas turbine, also with a DLN combustor. Both the 7EA and the 7FA are industrial turbines.

Numerous projects have been permitted and have demonstrated continuous compliance with a 2 ppmc VOC limit, so 2 ppmc is considered achieved in practice for this generating technology.

#### *Technologically Feasible/Cost Effective Criterion*

As discussed above, a VOC limit of 2 ppmc has been achieved in practice for the CTG being considered for the Project. Lower VOC limits that may be technologically feasible for this class and category of source have not been identified. The 0.6 and 1.3 ppm limits identified in the SJVAPCD guideline were associated with turbines intended to operate under uniform load (i.e., baseload turbines). While much of the load-following requirements for ESP will be met by the simple-cycle Trent turbines, the combined-cycle turbine is also expected to be required to perform under variable load, and on occasion may go through two full startup/shutdown cycles on a single day. Because of this variable load, in order to ensure compliance at all times with a 1-hour limit, the applicant has proposed to meet a 2 ppmc limit on a 1-hour average basis.

### Step 5 – Determine BACT/Present Conclusions

BACT must be at least as stringent as the most stringent achieved in practice, required in a federal NSPS or district prohibitory rule, or considered technologically feasible. Based upon the results of this analysis, the VOC emission limits of 2.0 ppmvd @ 15% O<sub>2</sub> are considered to be BACT for the proposed project.

## **SULFUR OXIDE EMISSIONS**

### Step 1 – Identify All Possible Control Technologies

Natural gas fired combustion turbines have inherently low SO<sub>x</sub> emissions due to the small amount of sulfur present in the fuel. With typical pipeline quality natural gas sulfur contents well below 1 grain/100 scf, the SO<sub>x</sub> emissions for natural gas fired combustion turbines are orders of magnitude less than oil-fired turbines. Firing by natural gas and the resulting control of SO<sub>x</sub> emissions have been used by numerous combustion turbines throughout the world. Due to the prevalence of the use of natural gas to control SO<sub>x</sub> emissions from combustion turbines, only an abbreviated discussion of post-combustion controls will be addressed in this section.

Post-combustion SO<sub>x</sub> control systems include dry and wet scrubber systems. These types of systems are typically installed on high SO<sub>x</sub> emitting sources such as coal-fired power plants. Post-combustion control systems for combustion turbines also include ES<sub>x</sub> catalyst systems. These systems trap the sulfur in the exhaust stream on an ES<sub>x</sub> catalyst. During a regeneration process, the sulfur is removed from the ES<sub>x</sub> catalyst and is either reintroduced back into the exhaust stream or sent to a sulfur scrubbing system. If the sulfur removed from the ES<sub>x</sub> catalyst is reintroduced back into the exhaust stream, there is no SO<sub>x</sub> control associated with the system.

### Step 2 – Eliminate Technically Infeasible Options

All of the control options discussed above are technically feasible.

### Step 3 – Rank Remaining Control Technologies by Control Effectiveness

The typical SO<sub>x</sub> control level for a well-designed wet or dry scrubber installed on a coal fired boiler ranges from approximately 70% to 90%,<sup>22</sup> with some installations achieving even higher control levels. According to EmeraChem literature,<sup>23</sup> the ES<sub>x</sub> system is capable of removing approximately 95% of the SO<sub>x</sub> emissions from the exhaust stream of natural gas fired combustion turbines. With the sulfur scrubber option, during the regeneration cycle of the ES<sub>x</sub> system the sulfur captured on the ES<sub>x</sub> catalyst is sent to a

---

<sup>22</sup> Air Pollution Control Manual, Air and Waste Management Association, Second Edition, p. 206.

<sup>23</sup> “High Performance EM<sub>x</sub> Emissions Control Technology for Fine Particles, NO<sub>x</sub>, CO, and VOCs from Combustion Turbines and Stationary IC Engines,” Steven DeCicco and Thomas Girdlestone, EmeraChem Power, June 2008, p. 19.

sulfur scrubbing unit. A high-efficiency sulfur scrubbing unit would achieve a control level similar to that of the wet/dry scrubbers discussed above.

#### Step 4 – Evaluate the Most Effective Control Technology Considering Environmental, Energy, and Cost Impacts

The use of low sulfur content pipeline natural gas has been achieved in practice at numerous combustion turbine installations throughout the world, and the use of this fuel minimizes SO<sub>x</sub> emissions. While it would be theoretically feasible to install some type of post-combustion control—such as a dry/wet scrubber system or an ES<sub>x</sub> catalyst with a sulfur scrubber—on a natural gas fired turbine, these systems are not cost effective due to the inherently low SO<sub>x</sub> emissions associated with the use of natural gas, and regulatory agencies do not require them. Consequently, no further discussion of post-combustion SO<sub>x</sub> control is necessary.

#### Step 5 – Determine BACT/Present Conclusions

The SO<sub>x</sub> control method for the proposed ESPFM is the use of pipeline-quality natural gas. Consequently, the proposed project is consistent with BACT requirements.

### **PM/PM<sub>10</sub>/PM<sub>2.5</sub> EMISSIONS**

#### Step 1 – Identify All Possible Control Technologies

Alternative basic equipment—including renewable energy sources, such as solar and wind—has also been identified as a technology for the control of PM/PM<sub>10</sub>/PM<sub>2.5</sub> emissions. Such alternative basic equipment was already discussed above (Step 1 for NO<sub>x</sub> BACT on the CTG/HRSG). For the same reasons, solar, wind and other renewable energy sources are rejected as PM<sub>10</sub>/PM<sub>2.5</sub> BACT for this application.

#### *Achievable Controlled Levels and Available Control Options*

PM emissions from natural gas-fired turbines primarily result from carryover of noncombustible trace constituents in the fuel. PM emissions are minimized by using clean-burning pipeline quality natural gas with low sulfur content.

CARB's BACT Clearinghouse, as well as the BAAQMD and SJVAPCD BACT guidelines, identifies the use of natural gas as the primary fuel as "achieved in practice" for the control of PM<sub>10</sub> for combustion gas turbines.

CARB's BACT guidance document for stationary gas turbines used for power plant configurations<sup>24</sup> indicates that BACT for the control of PM emissions is an emission limit corresponding to natural gas with fuel sulfur content of no more than 1 grain/100 standard cubic foot.

---

<sup>24</sup> Ibid, Table I-2.

Title 40 CFR Part 60 Subpart KKKK contains the applicable NSPS for combustion gas turbines. Subpart KKKK does not regulate PM<sub>10</sub> emissions.

Published prohibitory rules from the SCAQMD, SJVAPCD, SMAQMD, and SDCAPCD were reviewed to identify the PM<sub>10</sub> standards that govern natural gas-fired combustion gas turbines. These prohibitory rules do not regulate PM<sub>10</sub> emissions.

#### Step 2 – Eliminate Technologically Infeasible Options

As discussed above, solar, wind, and other renewable energy alternatives are not considered technologically feasible for this application.

#### Step 3 – Rank Remaining Control Technologies by Control Effectiveness

No control technology other than the use of clean natural gas fuel has been identified for this application.

#### Step 4 – Evaluate the Most Effective Control Technology Considering Environmental, Energy, and Cost Impacts

No control technology other than the use of clean natural gas fuel has been identified for this application.

#### Step 5 – Determine BACT/Present Conclusions

Based upon the results of this analysis, the use of natural gas as the primary fuel source constitutes BACT for PM<sub>10</sub> emissions from combustion gas turbines. Through the use of natural gas, the turbine is expected to be able to meet the proposed emission limit of 9.5 lbs/hr.

## **GHG EMISSIONS**

#### Step 1 – Identify All Possible Control Technologies

EPA has indicated in its guidance on BACT for GHGs<sup>25</sup> that the following types of controls must be considered in determining BACT for GHGs:

- Inherently lower-emitting processes/practices/designs;
- Add-on controls; and
- Combinations of inherently lower emitting processes/practices/designs and add-on controls.<sup>26</sup>

---

<sup>25</sup> EPA, “PSD and Title V Permitting Guidance for Greenhouse Gases,” November 2010, p. 33

<sup>26</sup> Ibid., p.27.

EPA further acknowledges that the requirement to consider inherently lower-emitting processes/practices/designs does not require a fundamental redesign of the nature of the source. This indicates that lower-emitting process/practices/designs that do not achieve the goals, objectives, or purposes of the project may be considered technologically infeasible as BACT for a project.

The following control technologies were identified as potentially “available” for ESPFM:

- Alternative generating technologies;
- Alternative fuels;
- Energy efficiency; and
- Carbon capture and storage.

Alternative basic equipment—including renewable energy sources, such as solar and wind—was already discussed above (Step 1 for NO<sub>x</sub> BACT on the CTG). For the same reasons, solar, wind and other renewable energy sources are rejected as GHG BACT for this application.

#### Step 2 – Eliminate Technologically Infeasible Options

EPA considers a technology to be technically feasible if has been demonstrated in practice on a similar facility, or is available and applicable to the source type under review. EPA considers a technology to be “available” where it can be obtained through commercial channels or is otherwise available within the common meaning of the term (e.g., it has been demonstrated in practice on a comparable, but not necessarily similar, facility). A technology is applicable if it may reasonably be expected to be successfully applied to the source type under review.

#### *Alternative Fossil Fuel Generating Technologies*

Alternative fossil fuel generating technologies such as reciprocating internal combustion engines and boilers may be considered as potential technologically feasible alternatives to the proposed use of combined-cycle combustion turbine technology. Reciprocating engine technology is generally well-suited to demand-response applications such as the proposed project, so can be considered technologically feasible for this application. Boilers, on the other hand, have very high thermal inertia, so are not quick-starting or fast ramping. Boiler technology is generally used for baseload power, not for highly variable demand-response power applications. Because boiler technology cannot meet the objectives of the project, it is not considered a technologically feasible alternative.

#### *Alternative Fuels*

Biomass fuel can be used only with boiler technology and must be gasified for use in turbines. As discussed previously, boiler technology is not considered a technologically feasible alternative. Therefore, there are no alternative fuels that are considered technologically feasible without redefining the project.

### *Energy Efficiency*

There are two potential applications of energy efficiency as potential BACT for the proposed project: (1) demand-side management and similar electric load reduction programs to minimize or eliminate the need for the proposed project altogether; and (2) use of the most efficient generating technology that meets the objectives of the project.

Implementation of energy efficiency programs is beyond the scope of this project. The purpose of this project is to help meet the energy demands that will remain after utility energy efficiency programs are implemented.

Utilization of the most efficient generating technology that meets the objectives of the project is technologically feasible.

### *Carbon Capture and Storage*

CCS technology may be considered to be “available,” in the sense that commercial facilities have been built on a scale comparable to ESPFM (e.g., a natural gas processing operation<sup>27</sup> in Wyoming captures 3.6 million tonnes per year of CO<sub>2</sub>, compared to the 0.6 million tonnes per year that would be emitted from ESPFM); however, the technology cannot yet be considered “applicable.” The Interagency Task Force on Carbon Capture and Storage (ITF) found the following:

*it is unclear how transferable the experience with natural gas processing is to separation of power plant flue gases, given the significant differences in the chemical make-up of the two gas streams. In addition, integration of these technologies with the power cycle at generating plants present significant cost and operating issues that will need to be addressed.*<sup>28</sup>

CCS has not yet reached the licensing and commercial sales stage of development. It is an emerging technology that has had limited successful applications on an industrial scale, and no successful applications on a comparably sized natural gas power plant. There are no CCS systems commercially available for natural gas power plants in the United States, and the Department of Energy does not expect commercial deployment until 2025.<sup>29</sup> CCS does not appear to be commercially available for this application.

### Step 3 – Rank Remaining Control Technologies

Absent post-combustion removal or sequestration, CO<sub>2</sub> and other GHG emissions are a direct function of the amount of natural gas fuel burned. GHG emissions will be

---

<sup>27</sup> Interagency Task Force on Carbon Capture and Storage, *Report of the Interagency Task Force on Carbon Capture and Storage*, August 2010. p. 28.

<sup>28</sup> Ibid.

<sup>29</sup> 73 FR 44370

minimized by minimizing heat rate and maximizing generating efficiency. The remaining technologies are ranked by their overall heat rate for consideration as BACT for this project, as shown in Table 11.

**Table 11**  
**Ranking of Potential Generating Technologies/Controls by Heat Rate**

| Technology                  | Heat Rate Range (HHV basis)              | Technologically Feasible for This Project? |
|-----------------------------|--|--|
| Renewable energy sources    | n/a                                      | No   |
| Biomass and other biofuels  | n/a                                      | No   |
| Demand-side management      | n/a                                      | No   |
| CCS                         | n/a                                      | Maybe                                      |
| Combined-cycle gas turbines | ~7000 to 8000 Btu/kWh <sup>a,b,c</sup>   | Yes  |
| Reciprocating IC engines    | ~7500 Btu/kWh <sup>d</sup>               | Yes  |
| Simple-cycle gas turbines   | ~9400 to 10,000 Btu/kWh <sup>a,b,c</sup> | Yes  |
| Boilers                     | >10,000 Btu/kWh <sup>a,b,c</sup>         | No   |

Notes:

- a. CEC FSA, Avenal Project. <http://www.energy.ca.gov/sitingcases/avenal/index.html>
- b. CEC FSA, TIC Almond 2 Power Plant Project. <http://www.energy.ca.gov/sitingcases/almond/index.html>
- c. CEC FSA, Carlsbad Energy Center Project. <http://www.energy.ca.gov/sitingcases/carlsbad/index.html>
- d. Wärtsilä, specifications for 1V34SG and 20V34SG gas engines. [www.wartsila.com](http://www.wartsila.com)

CO<sub>2</sub> is not the byproduct of incomplete combustion or contaminants in the fuel supply—it is an essential product of the combustion of natural gas. Therefore, the only way to reduce the amount of CO<sub>2</sub> generated is to minimize the amount of fuel combustion required to produce the desired amount of electricity. This is achieved by operating the unit efficiently and conducting regular maintenance to ensure continued good combustion. Good combustion practices are a well-established and widely used technique to minimize emissions from combustion sources. Good combustion operation and maintenance will maintain the thermal efficiency of the selected generating technology and therefore must also be considered a component of BACT to minimize GHG emissions.

Step 4 – Evaluate the Most Effective Control Technology Considering Environmental, Energy, and Cost Impacts

*Combined-Cycle Gas Turbines*

Combined-cycle gas turbines are inherently more efficient than simple-cycle gas turbines because they extract and use exhaust heat that would otherwise be wasted.

A combined-cycle gas turbine is proposed as part of this project in order to efficiently provide the bulk of electricity production. The proposed simple-cycle turbines augment the combined-cycle unit by providing load-following capability and black start capability.



### *Reciprocating IC Engines*

Reciprocating IC engines are fast-starting, but the largest natural gas-fired IC engine currently available is the approximately 9 MW Wärtsilä 20V34SG.<sup>30</sup> The nominal 330 MW size of the proposed combined cycle portion of the project would require over 35 of these engines, which would result in a far more complex and expensive plant and control system. Furthermore, BACT for NO<sub>x</sub> from engines of this type was recently determined to be 5 ppm, so NO<sub>x</sub> emissions from a comparable reciprocating engine plant would be approximately twice the NO<sub>x</sub> emissions from the proposed simple-cycle gas turbine project. Therefore, reciprocating IC engine technology is not considered BACT for the project.

### *Carbon Capture and Storage*

CCS technology applicable to natural gas-fired projects refers to post-combustion capture. EPA's Interagency Task Force on Carbon Capture and Storage<sup>31</sup> found the following:

*Post-combustion CO<sub>2</sub> capture ... is challenging for the following reasons:*

- *A high volume of gas must be treated because the CO<sub>2</sub> is dilute (13 to 15 percent by volume in coal-fired systems, three to four percent in natural-gas-fired systems);*
- *The flue gas is at low pressure (near atmosphere);*
- *trace impurities (particulate matter [PM], sulfur oxides [SO<sub>x</sub>], nitrogen oxides [NO<sub>x</sub>], etc.) can degrade the CO<sub>2</sub> capture materials; and*
- *Compressing captured CO<sub>2</sub> from near atmospheric pressure to pipeline pressure (about 2,000 pounds per square inch absolute) requires a large auxiliary power load...Installing current amine post-combustion CO<sub>2</sub> capture technology on new conventional subcritical, supercritical, and ultra-supercritical coal-fired power plants would increase the COE by about 80 percent. Further, the large quantity of energy required to regenerate the amine solvent and compress the CO<sub>2</sub> to pipeline conditions would result in about a 30 percent energy penalty.*

The International Energy Agency estimates that “CCS can reduce CO<sub>2</sub> emissions from power plants...by more than 85%, and power plant efficiency by about 8-12 percentage points.”<sup>32</sup> Although this energy penalty is for coal-fired plants and is not directly applicable to natural gas firing, it is expected to be reasonably representative of the

---

<sup>30</sup> <http://powerservices.lakho.com/2009/05/19/largest-natural-gas-reciprocating-engine-plant/>

<sup>31</sup> EPA, “Report of the Interagency Task Force on Carbon Capture and Storage,” 2010, pp. 29-30  
<http://www.epa.gov/climatechange/downloads/CCS-Task-Force-Report-2010.pdf>

<sup>32</sup> IEA Energy Technology Essentials, December 2006. <http://www.iea.org/techno/essentials.htm>

energy penalty for a natural gas-fired system because the lower content of CO<sub>2</sub> in gas turbine exhaust would not necessarily result in an efficiency savings (separation is still required, and there are no data to suggest that the differences in CO<sub>2</sub> concentrations between coal exhaust and gas turbine exhaust would result in lower separation costs). Assuming a minimum 8% energy penalty for CCS, the project would have to generate 8% more electricity to provide energy for CCS without reducing the electricity supply provided by the facility. Criteria pollutant and GHG emissions would also be 8% higher. In light of the energy and emissions penalties, the cost, and the lack of commercial availability, CCS is not considered BACT for the proposed project.

#### Step 5 – Determine BACT/Present Conclusions

The use of this highly efficient combined-cycle gas turbine technology, combined with good combustion operation and maintenance to maintain optimum efficiency, is determined to be BACT for GHG.

#### **SUMMARY**

Recent BACT determinations for criteria pollutants from similar gas turbine projects are summarized in Tables 12 and 13.

**Table 12  
Combined-Cycle Gas Turbine BACT Determinations (EPA RBLC Clearinghouse)**

| Facility/Location                 | Date Permit Issued | Equipment/Rating                            | NOx Limit/Control Technology   | CO Limit/Control Technology | VOC Limit/Control Technology |
|-----------------------------------|--------------------|---|--------------------------------|-----------------------------|------------------------------|
| Warren County Power <sup>a</sup>  | December 2010      | Mitsubishi M501, 300 MW                     | 2.0 ppm                        | 2.4 ppm (1-hour)            | 1.6 ppm                      |
| Kleen Energy Systems <sup>b</sup> | December 2010      | Siemens SGT6-5000F 2 turbines, 580 MW total | 2.0 ppm Low NOx burner and SCR | 1.7 ppm (1-hour)            | 5 ppm (1-hour)               |
| Avenal/California                 | June 2011          | 2 turbines GE 7FA 180 MW each               | 2.0 ppm                        | 2.0 ppm                     | -N/A-                        |
| Thomas Ferguson Power Plant/Texas | September 2011     | 2 turbines GE 7FA, 195 MW each              | 2.0 ppm                        | 4.0 ppm                     | 2.0 ppm                      |
| Palmdale/California               | October 2011       | 2 turbines GE 7FA, 154 MW each              | 2.0 ppm                        | 1.5 ppm                     | -N/A-                        |
| Calhoun Port Authority/Texas      | September 2012     | GE 7FA, 195 MW                              | 2.0 ppm                        | 4.0 ppm                     | 2.0 ppm                      |
| Deer Park Energy Center/Texas     | September 2012     | Siemens 501F, 150 MW                        | 2.0 ppm                        | 4.0 ppm                     | 2.0 ppm                      |
| Channel Energy Center/Texas       | October 2012       | Siemens 501F, 150 MW                        | 2.0 ppm                        | 4.0 ppm                     | 2.0 ppm                      |

Notes:

- a. Facility not yet in operation
- b. Facility commenced operation in November 2011.

**Table 13  
Summary of BACT Determinations (CEC Decisions)**

| Facility/District         | Decision Date | NOx Limit/ Control Technology | CO Limit/Control Technology            | VOC Limit/Control Technology  |
|---------------------------|---------------|-------------------------------|--|-------------------------------|
| Inland Empire             | 2003          | 2.0 ppm<br>SCR                | 4.0 (1 hour)<br>Oxidation Catalyst     | 2.0 ppm<br>Oxidation catalyst |
| El Segundo                | 2010          | 2.0 ppm<br>SCR                | 2.0 ppm (1 hour)<br>Oxidation catalyst | 2.0 ppm<br>Oxidation catalyst |
| GWF Tracy                 | 2010          | 2.0 ppm<br>SCR                | 2.0 ppm (1 hour)<br>Oxidation catalyst | 2.0 ppm<br>Oxidation catalyst |
| Oakley Generating Station | 2011          | 2.0 ppm<br>SCR                | 2.0 ppm (1 hour)<br>Oxidation catalyst | 2.0 ppm<br>Oxidation catalyst |
| Watson Cogeneration       | 2012          | 2.0 ppm<br>SCR                | 2.0 ppm (1 hour)<br>Oxidation catalyst | 2.0 ppm<br>Oxidation catalyst |

## BACT for the Combined-Cycle CTG: Startup/Shutdown

Startup and shutdown periods are a normal part of the operation of combined-cycle power plants such as ESPFM. BACT must also be applied during the startup and shutdown periods of gas turbine operation. The BACT limits discussed in the previous section apply to steady-state operation, when the turbines have reached stable operations and the emission control systems are fully operational.

### **NO<sub>x</sub> EMISSIONS**

#### Step 1 – Identify All Possible Control Technologies

Listed below are the technologies identified for control of NO<sub>x</sub> during startups and shutdowns.

- Selective Catalytic Reduction (SCR) system capable of continuously complying with a limit of 2.5 ppmvd @15% O<sub>2</sub> (1-hour average)
- Fast-start technologies (i.e., Rapid Response)
- Operating practices to minimize the duration of startup and shutdown

The project will utilize all of these control techniques.

#### Step 2 – Eliminate Technologically Infeasible Options

During gas turbine startup, there are equipment and process requirements that must be met in sequential order to protect the equipment. In the case of combined-cycle turbine projects, many of these require holding the gas turbine at low loads, where operation is inefficient and emissions are relatively high, to allow the HRSG and steam turbine to warm up, and to establish steam turbine seals and condenser vacuum. In the case of combustion turbines with dry low NO<sub>x</sub> combustors, at low turbine loads the combustors are not yet operating in lean pre-mix mode so turbine NO<sub>x</sub> emission rates are also high during startup.

For all turbine technologies, incomplete combustion at low loads results in higher CO and VOC emission rates. Furthermore, the post-combustion controls that are used to achieve additional emissions reductions (SCR and oxidation catalyst) require that specific exhaust temperature ranges be reached to be fully effective. The use of SCR to control NO<sub>x</sub> is not technically feasible when the surface of the SCR catalyst is below the manufacturer's recommended operating range. When catalyst surface temperatures are low, ammonia will not react completely with the NO<sub>x</sub>, resulting in excess NO<sub>x</sub> emissions or excess ammonia slip or both. The oxidation catalyst is not effective at controlling CO emissions when exhaust temperature is below the optimal temperature range. Therefore, exhaust gas controls used to achieve BACT for normal operations are not feasible control techniques during startups and shutdowns.

This “top-down” BACT analysis will consider the following NOx emission limitations:

- Operating practices to minimize emissions during startup and shutdown; and
- Design features to minimize the duration of startup and shutdown.

### Step 3 – Rank Remaining Control Technologies by Control Effectiveness

#### *Operating Practices to Minimize Emissions during Startup and Shutdown*

There are basic principles of operation, or Best Management Practices, that minimize emissions during startups and shutdowns. These Best Management Practices are outlined below.

- During a startup, bring the gas turbine to the minimum load necessary to achieve compliance with the applicable NOx and CO emission limits as quickly as possible, consistent with the equipment manufacturers’ recommendations and safe operating practices.
- During a startup, initiate ammonia injection to the SCR system as soon as the SCR catalyst temperature and ammonia vaporization system have reached their minimum operating temperatures.
- During a shutdown, once the turbine reaches a load that is below the minimum load necessary to maintain compliance with the applicable NOx and CO emission limits, reduce the gas turbine load to zero as quickly as possible, consistent with the equipment manufacturers’ recommendations and safe operating practices.
- During a shutdown, maintain ammonia injection to the SCR system as long as the SCR catalyst temperature and ammonia vaporization system remain above their minimum operating temperatures.

A key underlying consideration of these Best Management Practices is the overall safety of the plant staff by promoting operation within the limitations of the equipment and systems, and allowing for operator judgment and response times to respond to alarms and trips during the startup sequence.

#### *Design Features to Minimize the Duration of Startup and Shutdown*

An additional technique to reduce startup emissions is to minimize the amount of time the gas turbine spends in startup. The proposed turbine is equipped with Fast Start technology, which is a suite of design features that maintains system components in a state of readiness to allow the gas turbine to ramp up to full load more quickly and bring the SCR and oxidation catalysts to operating temperature more quickly.

#### Step 4 – Evaluate the Most Effective Control Technology Considering Environmental, Energy, and Cost Impacts

Utilizing best operating practices to minimize emissions during startups and shutdowns has no adverse environmental or energy impacts, nor does it require additional capital expenditure.

The approach of reducing startup/shutdown duration has no adverse environmental or energy impacts, and the use of fast-start technology minimizes startup/shutdown duration.

#### Step 5 - Determine BACT/Present Conclusions

BACT for NO<sub>x</sub> during startups/shutdowns is the use of operating systems/practices that reduce the duration of startups and shutdowns to the greatest extent feasible, and the use of operational techniques to initiate ammonia injection as soon as possible during a startup. Therefore, BACT is determined to be the use of combined-cycle gas turbine technology and the application of operating systems/practices that minimize startup and shutdown durations, in combination with the use of operational techniques to initiate ammonia injection as soon as possible during a startup.

### **CO EMISSIONS**

#### Step 1 – Identify All Possible Control Technologies

The CO control technologies under consideration for startups and shutdowns are ranked as follows:

- Oxidation catalyst unit capable of achieving 2 ppmvd @ 15% O<sub>2</sub>
- Fast-start technologies
- Operating practices to minimize the duration of startup and shutdown

#### Step 2 – Eliminate Technologically Infeasible Options

None of the proposed alternatives is infeasible for this application.

#### Step 3 – Rank Remaining Control Technologies by Control Effectiveness

Ranking for the control technologies is as indicated in Step 1.

#### Step 4 – Evaluate the Most Effective Control Technology Considering Environmental, Energy, and Cost Impacts

Similar to the discussion above for NO<sub>x</sub>, CO emissions during startup and shutdown are minimized by minimizing the length of time that the turbine fires while the oxidation catalyst is not in its operating temperature range.

#### Step 5 – Determine BACT/Present Conclusions

BACT is determined to be the use of combined-cycle gas turbine technology and the application of operating systems/practices that minimize startup and shutdown durations.

### **VOC EMISSIONS**

#### Step 1 – Identify All Possible Control Technologies

The VOC control technologies under consideration for startups and shutdowns are ranked as follows:

- Fast-start technologies
- Operating practices to minimize the duration of startup and shutdown

#### Step 2 – Eliminate Technologically Infeasible Options

None of the proposed alternatives is infeasible for this application.

#### Step 3 – Rank Remaining Control Technologies by Control Effectiveness

Ranking for the control technologies is as indicated in Step 1.

#### Step 4 – Evaluate the Most Effective Control Technology Considering Environmental, Energy, and Cost Impacts

VOC emissions during startup and shutdown are minimized by minimizing the duration of startup and shutdown.

#### Step 5 – Determine BACT/Present Conclusions

BACT is determined to be the use of combined-cycle gas turbine technology and the application of operating systems/practices that minimize startup and shutdown durations.

### **SULFUR OXIDE EMISSIONS**

#### Step 1 – Identify All Possible Control Technologies

The SO<sub>x</sub> control technologies under consideration for startups and shutdowns are ranked as follows:

- Use of natural gas as a fuel
- Fast-start technologies
- Operating practices to minimize the duration of startup and shutdown



### Step 2 – Eliminate Technologically Infeasible Options

None of the proposed alternatives is infeasible for this application.

### Step 3 – Rank Remaining Control Technologies by Control Effectiveness

Ranking for the control technologies is as indicated in Step 1.

### Step 4 – Evaluate the Most Effective Control Technology Considering Environmental, Energy, and Cost Impacts

SO<sub>x</sub> emissions during startup and shutdown are minimized by minimizing the duration of startup and shutdown.

### Step 5 – Determine BACT/Present Conclusions

BACT is determined to be the use of combined-cycle gas turbine technology and the application of operating systems/practices that minimize startup and shutdown durations.

## **PM/PM<sub>10</sub>/PM<sub>2.5</sub> EMISSIONS**

### Step 1 – Identify All Possible Control Technologies

The PM control technologies under consideration for startups and shutdowns are ranked as follows:

- Use of natural gas as a fuel
- Fast-start technologies
- Operating practices to minimize the duration of startup and shutdown

### Step 2 – Eliminate Technologically Infeasible Options

None of the proposed alternatives is infeasible for this application.

### Step 3 – Rank Remaining Control Technologies by Control Effectiveness

Ranking for the control technologies is as indicated in Step 1.

### Step 4 – Evaluate the Most Effective Control Technology Considering Environmental, Energy, and Cost Impacts

PM emissions during startup and shutdown are minimized by minimizing the duration of startup and shutdown.

#### Step 5 – Determine BACT/Present Conclusions

BACT is determined to be the use of combined-cycle gas turbine technology and the application of operating systems/practices that minimize startup and shutdown durations.

### **GHG EMISSIONS**

#### Step 1 – Identify All Possible Control Technologies

The GHG control technologies under consideration for startups and shutdowns are ranked as follows:

- Use of natural gas as a fuel
- Fast-start technologies
- Operating practices to minimize the duration of startup and shutdown

#### Step 2 – Eliminate Technologically Infeasible Options

None of the proposed alternatives is infeasible for this application.

#### Step 3 – Rank Remaining Control Technologies by Control Effectiveness

Ranking for the control technologies is as indicated in Step 1.

#### Step 4 – Evaluate the Most Effective Control Technology Considering Environmental, Energy, and Cost Impacts

GHG emissions during startup and shutdown are minimized by minimizing the duration of startup and shutdown.

#### Step 5 – Determine BACT/Present Conclusions

BACT is determined to be the use of combined-cycle gas turbine technology and the application of operating systems/practices that minimize startup and shutdown durations.

### **SUMMARY**

Proposed BACT determinations for the ESPFM combined-cycle gas turbine are summarized in Table 14.

**Table 14**  
**Proposed BACT Determinations for ESPFM Combined-Cycle Gas Turbine**

| Pollutant         | Proposed BACT Determination  |
|-------------------|--|
| Nitrogen Oxides   | Dry low-NOx combustors and SCR system, 2.0 ppmc <sup>a</sup> , 1-hour average, with excursions under specific conditions; no CCS |
| Sulfur Dioxide    | Natural gas fuel (sulfur content not to exceed 0.75 grain/100 scf short-term average, 0.25 grains/100 scf long-term average)     |
| Carbon Monoxide   | Good combustion practices and oxidation catalyst, 2.0 ppmc, 1-hour average   |
| VOC               | Good combustion practices, 2.0 ppmc, 1-hour average  |
| PM <sub>10</sub>  | Natural gas fuel, 9.5 PM <sub>10</sub> lbs/hr  |
| PM <sub>2.5</sub> | Natural gas fuel, 9.5 PM <sub>2.5</sub> lbs/hr   |
| GHGs              | Combined-cycle gas turbine technology, good combustion practices   |
| Ammonia           | 5 ppm ammonia slip   |
| Startup/Shutdown  | GE Fast Start combined-cycle gas turbine technology, Best operating practices to minimize startup/shutdown times and emissions   |

Note:

a. ppmc: parts per million by volume, corrected to 15% O<sub>2</sub>

### BACT for the Auxiliary Boiler

The emissions unit for which BACT is being considered is a nominal 36 MMBtu/hr auxiliary boiler.

### **NO<sub>x</sub> EMISSIONS**

#### Step 1 – Identify All Possible Control Technologies

NO<sub>x</sub> is formed during combustion through two mechanisms: (1) thermal NO<sub>x</sub>, which is the oxidation of elemental nitrogen in combustion air; and (2) fuel NO<sub>x</sub>, which is the oxidation of fuel-bound nitrogen. Since natural gas is relatively free of fuel-bound nitrogen, the contribution of this second mechanism to the formation of NO<sub>x</sub> emissions in natural gas-fired equipment is minimal and thermal NO<sub>x</sub> is the chief source of NO<sub>x</sub> emissions. Thermal NO<sub>x</sub> formation is a function of residence time, oxygen level, and flame temperature, and can be minimized by controlling these elements in the design of the combustion equipment.

There are two basic means of controlling NO<sub>x</sub> emissions from boilers: combustion controls and post-combustion controls. Combustion controls act to reduce the formation of NO<sub>x</sub> during the combustion process, while post-combustion controls remove NO<sub>x</sub> from the exhaust stream. Combustion control technologies for this type of boiler application include low-NO<sub>x</sub> burners, flue gas recirculation (FGR), and staged

combustion. Post-combustion controls include SCR and selective non-catalytic reduction (SNCR). These are discussed below in order of most effective to least effective.

## Step 2 – Eliminate Technologically Infeasible Options

### *Selective Catalytic Reduction*

The effectiveness of an SCR system requires the catalyst, and thus the treated exhaust stream, to be within a certain temperature range for the NO<sub>x</sub> reduction reaction to take place. The auxiliary boiler will be operated to support the fast start turbine startup process. The majority of boiler operations are expected to be at low load, and even at full load the exhaust gas temperature is expected to be 300°F, which is below the minimum needed for effective SCR control. While there may be areas within the boiler itself within the correct temperature range, the wide range in boiler firing rate (25% of full load most of the time, 100% full load during turbine startup) will affect the temperature profile within the boiler; and there is difficulty in finding an appropriate place inside the boiler where ammonia could be injected and mixed properly. Therefore, this technology is not considered technically feasible for the auxiliary boiler in this application.

### *Selective Noncatalytic Reduction (SNCR)*

SNCR involves injection of ammonia or urea with proprietary conditions into the exhaust gas stream without a catalyst. SNCR technology requires gas temperatures in the range of 1200 to 2000°F. The exhaust temperature for the proposed auxiliary boiler is 300°F, well below the minimum SNCR operating temperature. While there may be areas within the boiler itself within the correct temperature range, the wide range in boiler firing rate (25% of full load most of the time, 100% full load during turbine startup) will affect the temperature profile within the boiler; and there is difficulty in finding an appropriate place inside the boiler where ammonia could be injected and mixed properly. Therefore, SNCR is not technically feasible for this application.

### *Ultra-Low NO<sub>x</sub> Burners with Flue Gas Recirculation*

Low-NO<sub>x</sub> burners with FGR are commonly used on industrial-sized package boilers such as the ESP auxiliary boiler. These burners minimize the formation of thermal NO<sub>x</sub> and FGR reduces the oxygen in the combustion zone to further reduce NO<sub>x</sub> formation. Ultra-low NO<sub>x</sub> burners with FGR can achieve NO<sub>x</sub> emission rates of 7 to 9 ppmvd @ 3% O<sub>2</sub> without post-combustion controls. A 9 ppm emission rate was recently accepted as BACT for the Colusa Generating Station auxiliary boiler and was considered the lowest technologically feasible emission rate for that particular application. A summary of the permitted emissions limits for other, similar boilers is provided in Table 15.

## Step 3 – Rank Remaining Control Technologies by Control Effectiveness

The only remaining control technology is ultra-low NO<sub>x</sub> burners with FGR.

#### Step 4 – Evaluate the Most Effective Control Technology Considering Environmental, Energy, and Cost Impacts

##### *District BACT Determinations*

The SJVAPCD's BACT determination for boilers in this size range with variable loads shows that less than 15 ppmc is considered achieved in practice while 9 ppm is considered technically feasible.

The BAAQMD has determined that 9 ppmc is achieved in practice, while 7 ppmc is considered technologically feasible. However, the BAAQMD BACT guideline indicates that SCR is needed to achieve 7 ppmc, and, as discussed above, SCR is not feasible for this application.

SCAQMD provides BACT information in the form of listings of recent BACT determinations.<sup>33</sup> The following NO<sub>x</sub> BACT levels are listed for boilers in the size range of the proposed boiler (36 MMBH):

- 39 MMBH, very low usage (1 day per month, 1 week per year): 9 ppm. (2004)
- 79 MMBH, 9ppm (1999)
- 49 MMBH, low usage (25% capacity, 2 weeks/quarter): 9 ppm (1999)
- 32 MMBH, steady state and 60% load: 7 ppm using SCR (1999)
- 24-33 MMBH, load following: 7 ppm using SCR (1999)
- 22 MMBH, load following: 9 ppm (2002)
- 21 MMBH, steady low load: 7 ppm using SCR (2003)

#### Step 5 – Determine BACT/Present Conclusions

BACT must be at least as stringent as the most stringent limit achieved in practice, federal NSPS, or district prohibitory rule. Based upon the results of this analysis, the proposed 9 ppm NO<sub>x</sub> limit represents BACT for this application.

---

<sup>33</sup> SCAQMD, BACT Guidelines—Overview (July 2006). p 1

**Table 15  
Recent NOx and CO BACT Determinations for Medium-Sized Auxiliary Boilers**

| Facility                                  | District/State | Heat Input Rating (MMBtu/hr HHV) | NOx Limit                    | CO Limit                     | Date Permit Issued | Source                  |
|---|----------------|----------------------------------|------------------------------|------------------------------|--------------------|-------------------------|
| Colusa Generating Station                 | EPA Region 9   | 44                               | 9 ppm                        | 50 ppm                       | May 2008           | CEC final decision      |
| Genentech                                 | BAAQMD         | 97                               | 9 ppm                        | 50 ppm                       | September 2005     | CARB BACT Clearinghouse |
| Medimmune, Inc                            | Maryland       | 29.4                             | 9 ppm                        | n/a                          | January 2008       | RBLC # MD-0037          |
| CPV Warren                                | Virginia       | 97                               | 0.011 lb/MMBtu <sup>a</sup>  | 0.036 lb/MMBtu <sup>c</sup>  | January 2008       | RBLC # VA-0308          |
| Minnesota Steel Industries                | Minnesota      | 99                               | 0.035 lb/MMBtu <sup>b</sup>  | 0.08 lb/MMBtu <sup>d</sup>   | September 2007     | RBLC # MN-0070          |
| Thyssenkrupp Steel and Stainless USA, LLC | Alabama        | 64.9                             | 0.035 lb/MMBtu <sup>b</sup>  | 0.040 lb/MMBtu <sup>c</sup>  | August 2007        | RBLC # AL-0230          |
| Daimler Chrysler Corporation              | Ohio           | 20.4                             | 0.0350 lb/MMBtu <sup>b</sup> | 0.0830 lb/MMBtu <sup>d</sup> | May 2007           | RBLC # OH-0309          |
| Kal Kan                                   | SCAQMD         | 78.6                             | 9 ppm                        | 400 ppm                      | October 1999       | Application 181183      |
| UCI Med Center                            | SCAQMD         | 48.6                             | 9 ppm                        | 50 ppm                       | September 1999     | Application 248532      |
| Coca Cola                                 | SCAQMD         | 32.5                             | 7 ppm                        | 50 ppm                       | December 1999      | Application 352348      |
| Children's Hospital                       | SCAQMD         | 24.2, 33.9                       | 7 ppm                        | 50 ppm                       | December 1999      | Application 347790      |
| Cosmetic Laboratories                     | SCAQMD         | 21.5                             | 9 ppm                        | 100 ppm                      | December 2002      | Application 385770      |
| La Corr Packaging                         | SCAQMD         | 21                               | 7 ppm                        | 50 ppm                       | September 2000     | Application 385770      |
| LA County Internal Services               | SCAQMD         | 39                               | 9 ppm                        | 50 ppm                       | May 2004           | Application 405470      |

Notes:

- Equivalent to approximately 9 ppmc NOx.
- RBLC record shows 0.0035 lb/MMBtu; however, based on rated heat input and hourly limit, this is believed to be a typographical error. This is equivalent to approximately 27 ppmc NOx.
- Equivalent to approximately 50 ppmc CO.
- Equivalent to approximately 100 ppmc CO.

## **CO EMISSIONS**

### Step 1 – Identify All Possible Control Technologies

CO emitted from boilers is the result of incomplete combustion of fuel. Use of good combustion practices to ensure complete combustion is generally considered BACT for CO.

### Step 2 – Eliminate Technologically Infeasible Options

The only technology under consideration is use of good combustion practices to ensure complete combustion.

### Step 3 – Rank Remaining Control Technologies by Control Effectiveness

The only technology under consideration is use of good combustion practices to ensure complete combustion.

### Step 4 – Evaluate the Most Effective Control Technology Considering Environmental, Energy, and Cost Impacts

SCAQMD staff have indicated that the current BACT level for CO from boilers at major sources is 50 ppm. Recent BACT determinations listed in Part B of the SCAQMD BACT Guidelines are shown in Table 15.

### Step 5 – Determine BACT/Present Conclusions

BACT must be at least as stringent as the most stringent level achieved in practice, required in a federal NSPS or district prohibitory rule, or considered technologically feasible. The proposed CO emission limit of 50 ppmvd @ 15% O<sub>2</sub> on a 15-minute average basis is BACT for this source.

## **VOC EMISSIONS**

### Step 1 – Identify All Possible Control Technologies

VOC emissions during natural gas combustion result from incomplete combustion of the fuel gas. VOC emissions are minimized by combustion practices that promote high combustion temperatures, long residence times at those temperatures, and turbulent mixing of fuel and combustion air. Since those practices tend to increase NO<sub>x</sub> emissions, the effectiveness of the NO<sub>x</sub> control system may affect the ability of the boiler to achieve low VOC emission rates.

### Step 2 – Eliminate Technologically Infeasible Options

No technologies have been eliminated at this step.

### Step 3 – Rank Remaining Control Technologies by Control Effectiveness

Only one technology has been identified.

### Step 4 – Evaluate the Most Effective Control Technology Considering Environmental, Energy, and Cost Impacts

#### *District BACT Determinations*

The SJVAPCD's BACT determination for boilers in this size range with variable loads shows that the use of natural gas fuel is considered to be BACT for VOCs.

The BAAQMD has determined that BACT for boilers in this size range is the use of good combustion practices for VOC control.

None of the SCAQMD determinations for BACT for boilers in this size range address VOC.

### Step 5 – Determine BACT/Present Conclusions

BACT must be at least as stringent as the most stringent limit achieved in practice, federal NSPS, or district prohibitory rule. Based upon the results of this analysis, the use of good combustion practices for VOC control is BACT for the auxiliary boiler.

## **SO<sub>2</sub> AND PM<sub>10</sub> EMISSIONS**

### Step 1 – Identify All Possible Control Technologies

SO<sub>2</sub> and PM<sub>10</sub> emissions from natural gas combustion result from sulfur and other impurities in the fuel. Emissions of these pollutants will be minimized through the use of low sulfur pipeline quality natural gas. There are no add-on control technologies that are effective in reducing SO<sub>2</sub> and PM<sub>10</sub> emissions from naturally low-emitting natural gas-fired boilers.

### Step 2 – Eliminate Technologically Infeasible Options

No technologies have been eliminated at this step.

### Step 3 – Rank Remaining Control Technologies by Control Effectiveness

Only one technology has been identified.



Step 4 – Evaluate the Most Effective Control Technology Considering Environmental, Energy, and Cost Impacts

*District BACT Determinations*

The SJVAPCD and BAAQMD BACT guidelines both indicate that the use of natural gas fuel is considered BACT for boilers.

Step 5 – Determine BACT/Present Conclusions

BACT must be at least as stringent as the most stringent limit achieved in practice, federal NSPS, or district prohibitory rule. Based upon the results of this analysis, the use of pipeline-quality natural gas is BACT for the auxiliary boiler.

**GHG EMISSIONS**

Step 1 – Identify All Possible Control Technologies

GHG emissions are a function of the amount of fuel fired. There are no add-on controls available for a unit this size. Use of an efficient boiler and minimization of use are the only methods available for minimizing GHG emissions from this source.

Step 2 – Eliminate Technologically Infeasible Options

No technologies have been eliminated at this step.

Step 3 – Rank Remaining Control Technologies by Control Effectiveness

Only one technology has been identified.

Step 4 – Evaluate the Most Effective Control Technology Considering Environmental, Energy, and Cost Impacts

The applicant proposes to utilize an efficient boiler and to minimize use.

Step 5 – Determine BACT/Present Conclusions

Use of an efficient boiler and minimization of use is BACT for GHG emissions from this source.

**SUMMARY**

Proposed BACT determinations for the ESPFM auxiliary boiler are summarized in Table 16.

**Table 16**  
**Proposed BACT Determinations for ESPFM Auxiliary Boiler**

| Pollutant         | Proposed BACT Determination  |
|-------------------|--|
| Nitrogen Oxides   | Ultra-Low-NOx burner and FGR, 9 ppmc <sup>a</sup> , 15-minute average  |
| Sulfur Dioxide    | Natural gas fuel (sulfur content not to exceed 0.75 grain/100 scf short-term average, 0.25 grains/100 scf long-term average) |
| Carbon Monoxide   | Good combustion practices, 50.0 ppmc, 15-minute average  |
| VOC               | Good combustion practices.   |
| PM <sub>10</sub>  | Natural gas fuel   |
| PM <sub>2.5</sub> | Natural gas fuel   |
| GHGs              | Efficient boiler operation, minimize fuel use  |

Note:

a. ppmc: parts per million by volume, corrected to 3% O<sub>2</sub>

**APPENDIX 3.1G – OFFSET/MITIGATION SUPPORT DATA**

**Table 3.1G-1**  
**El Segundo Power Facility Modification**  
**Operating Data for NOx RTC Calculations**

| <b>Data for Unit 9</b>                |                                       |
|---------------------------------------|---------------------------------------|
| <b>Operating Schedule (1st Year):</b> | <b>Operating Schedule (2nd Year):</b> |
| Startup hours = 200 hours/year        | Startup hours = 200 hours/year        |
| Shutdown hours = 200 hours/year       | Shutdown hours = 200 hours/year       |
| Normal Operations = 4,641 hours/year  | Normal Operations = 5,056 hours/year  |
| Commissioning Period = 415 hours/year | Commissioning Period = 0 hours/year   |

| <b>Data for Units 11 and 12 (each)</b> |                                       |
|--|---------------------------------------|
| <b>Operating Schedule (1st Year):</b>  | <b>Operating Schedule (2nd Year):</b> |
| Startup hours = 480 hours/year         | Startups = 480 hours/year             |
| Shutdown hours = 480 hours/year        | Shutdowns = 480 hours/year            |
| Normal Operations = 3,719 hours/year   | Normal Operations = 3,840 hours/year  |
| Commissioning Period = 121 hours/year  | Commissioning Period = 0 hours/year   |

| <b>Data for Auxiliary Boiler</b>                |   |
|---|---|
| <b>Operating Schedule (1st Year):</b>           | <b>Operating Schedule (2nd Year):</b>           |
| Normal Operations (25% load) = 3,304 hours/year | Normal Operations (25% load) = 3,304 hours/year |
| Normal Operations (100% load) = 33 hours/year   | Normal Operations (100% load) = 33 hours/year   |

**Table 3.1G-2**  
**El Segundo Power Facility Modification**  
**NOx RTC Calculations**

**1st Year NOx RTCs**

|                                    | Hours per Year | NOx (lb/hr) | NOx (lb/year)  |
|------------------------------------|----------------|-------------|----------------|
| <b>CTGs</b>                        |                |             |                |
| Unit 9 Startup (fast)              | 150            | 45.0        | 6,746          |
| Unit 9 Startup (trad)              | 50             | 62.3        | 3,113          |
| Unit 9 Shutdown                    | 200            | 37.5        | 7,495          |
| Unit 9 Normal Operation            | 4,641          | 17.9        | 83,294         |
| Unit 9 Commissioning               | 415            | 30.1        | 12,478         |
| Unit 11 Startup                    | 480            | 30.4        | 14,580         |
| Unit 11 Shutdown                   | 480            | 10.3        | 4,928          |
| Unit 11 Normal Operation           | 3,719          | 4.8         | 17,669         |
| Unit 11 Commissioning              | 121            | 44.1        | 5,331          |
| Unit 12 Startup                    | 480            | 30.4        | 14,580         |
| Unit 12 Shutdown                   | 480            | 10.3        | 4,928          |
| Unit 12 Normal Operation           | 3,719          | 4.8         | 17,669         |
| Unit 12 Commissioning              | 121            | 44.1        | 5,331          |
| <b>CTG Totals</b>                  |                |             | <b>198,142</b> |
| Aux Boiler (25% load)              | 3,304          | 0.10        | 325            |
| Aux Boiler (100% load)             | 33             | 0.39        | 13             |
| Total 1st Year Emissions (lb/year) |                |             | <b>198,480</b> |
| Offset Ratio                       |                |             | 1.00           |
| 1st year RTCs (lb/year)            |                |             | <b>198,480</b> |

**2nd Year NOx RTCs**

| Operating Condition 100            | Hours per Year | NOx (lb/hr) | NOx (lb/year) per device |
|------------------------------------|----------------|-------------|--------------------------|
| <b>CTGs</b>                        |                |             |                          |
| Unit 9 Startup (fast)              | 150            | 45.0        | 6,746                    |
| Unit 9 Startup (trad)              | 50             | 62.3        | 3,113                    |
| Unit 9 Shutdown                    | 200            | 37.5        | 7,495                    |
| Unit 9 Normal Operation            | 5,056          | 17.9        | 90,742                   |
| Unit 11 Startup                    | 480            | 30.4        | 14,580                   |
| Unit 11 Shutdown                   | 480            | 10.3        | 4,928                    |
| Unit 11 Normal Operation           | 3,840          | 4.8         | 18,244                   |
| Unit 12 Startup                    | 480            | 30.4        | 14,580                   |
| Unit 12 Shutdown                   | 480            | 10.3        | 4,928                    |
| Unit 12 Normal Operation           | 3,840          | 4.8         | 18,244                   |
| <b>CTG Totals</b>                  |                |             | <b>183,601</b>           |
| Aux Boiler (25% load)              | 3,304          | 0.10        | 325                      |
| Aux Boiler (100% load)             | 33             | 0.39        | 13                       |
| Total 2nd Year Emissions (lb/year) |                |             | <b>183,939</b>           |
| Offset Ratio                       |                |             | 1.00                     |
| 2nd year RTCs (lb/year)            |                |             | <b>183,939</b>           |

**APPENDIX 3.1H – CUMULATIVE IMPACTS ANALYSIS EMISSION DATA**

**Table 3.1H-1**  
**Public Information Provided by District—Permits Within 6 Miles of ESPFM**  
 (Period: 1/1/2011 to 12/11/2012)

| Facility ID | Facility Name                            | Emittent ID | Emission Amt (lbs/yr) | Appl Nbr | Equipment (BCAT) Description                          | loc Street Address        | loc City      |
|-------------|--|-------------|-----------------------|----------|---|---------------------------|---------------|
| 4735        | REDONDO BEACH CITY                       | NOX         | 187                   | 536527   | IC E (>500 HP) EM ELEC GEN DIESEL                     | 415 DIAMOND ST            | REDONDO BEACH |
| 4735        | REDONDO BEACH CITY                       | PM10        | 9.5                   | 536527   | IC E (>500 HP) EM ELEC GEN DIESEL                     | 415 DIAMOND ST            | REDONDO BEACH |
| 5259        | NEUTROGENA CORP                          | PM10        | 0                     | 535141   | PLASTIC/RESIN SIZE REDUCTION                          | 5755-60 W 96TH ST         | LOS ANGELES   |
| 8582        | SO CAL GAS CO/PLAYA DEL REY STORAGE FACI | NOX         | 29                    | 391138   | NATURAL GAS DEHYDRATION                               | 8141 GULANA AVE           | PLAYA DEL REY |
| 8582        | SO CAL GAS CO/PLAYA DEL REY STORAGE FACI | NOX         | 1048.32               | 407305   |   | 8141 GULANA AVE           | PLAYA DEL REY |
| 8582        | SO CAL GAS CO/PLAYA DEL REY STORAGE FACI | NOX         | 850                   | 391136   | HEATER/FURNACE (5-20 MMBTU/HR) NAT GAS                | 8141 GULANA AVE           | PLAYA DEL REY |
| 8582        | SO CAL GAS CO/PLAYA DEL REY STORAGE FACI | NOX         | 108501.12             | 539154   | IC E (>500 HP) N-EM STAT NAT GAS ONLY                 | 8141 GULANA AVE           | PLAYA DEL REY |
| 8582        | SO CAL GAS CO/PLAYA DEL REY STORAGE FACI | NOX         | 108501.12             | 539155   | IC E (>500 HP) N-EM STAT NAT GAS ONLY                 | 8141 GULANA AVE           | PLAYA DEL REY |
| 8582        | SO CAL GAS CO/PLAYA DEL REY STORAGE FACI | NOX         | 108501.12             | 539156   | IC E (>500 HP) N-EM STAT NAT GAS ONLY                 | 8141 GULANA AVE           | PLAYA DEL REY |
| 8582        | SO CAL GAS CO/PLAYA DEL REY STORAGE FACI | PM10        | 94                    | 407305   |   | 8141 GULANA AVE           | PLAYA DEL REY |
| 8582        | SO CAL GAS CO/PLAYA DEL REY STORAGE FACI | PM10        | 171                   | 391136   | HEATER/FURNACE (5-20 MMBTU/HR) NAT GAS                | 8141 GULANA AVE           | PLAYA DEL REY |
| 8582        | SO CAL GAS CO/PLAYA DEL REY STORAGE FACI | PM10        | 5853.12               | 539154   | IC E (>500 HP) N-EM STAT NAT GAS ONLY                 | 8141 GULANA AVE           | PLAYA DEL REY |
| 8582        | SO CAL GAS CO/PLAYA DEL REY STORAGE FACI | PM10        | 5853.12               | 539155   | IC E (>500 HP) N-EM STAT NAT GAS ONLY                 | 8141 GULANA AVE           | PLAYA DEL REY |
| 8582        | SO CAL GAS CO/PLAYA DEL REY STORAGE FACI | PM10        | 5853.12               | 539156   | IC E (>500 HP) N-EM STAT NAT GAS ONLY                 | 8141 GULANA AVE           | PLAYA DEL REY |
| 8648        | MERLE NORMAN COSMETICS INC               | PM10        | 0                     | 518313   |   | 9130 BELLANCA AVE         | LOS ANGELES   |
| 9755        | UNITED AIRLINES INC                      | NOX         | 72.6                  | 520595   | IC E (50-500 HP) EM FIRE FIGHT-DIESEL                 | 6010 & 6020 AVION DR      | LOS ANGELES   |
| 9755        | UNITED AIRLINES INC                      | NOX         | 483.6                 | 520588   | IC E (50-500 HP) EM ELEC GEN-DIESEL                   | 6010 & 6020 AVION DR      | LOS ANGELES   |
| 9755        | UNITED AIRLINES INC                      | NOX         | 537.5                 | 520589   | IC E (50-500 HP) N-EM PORT N-RENT DIESE               | 6010 & 6020 AVION DR      | LOS ANGELES   |
| 9755        | UNITED AIRLINES INC                      | NOX         | 426                   | 520591   | IC E (>500 HP) EM ELEC GEN DIESEL                     | 6010 & 6020 AVION DR      | LOS ANGELES   |
| 9755        | UNITED AIRLINES INC                      | NOX         | 7862.4                | 522810   | IC E (50-500 HP) N-EM PORT N-RENT DIESE               | 6010 & 6020 AVION DR      | LOS ANGELES   |
| 9755        | UNITED AIRLINES INC                      | PM          | 34.32                 | 520588   | IC E (50-500 HP) EM ELEC GEN-DIESEL                   | 6010 & 6020 AVION DR      | LOS ANGELES   |
| 9755        | UNITED AIRLINES INC                      | PM          | 6                     | 520591   | IC E (>500 HP) EM ELEC GEN DIESEL                     | 6010 & 6020 AVION DR      | LOS ANGELES   |
| 9755        | UNITED AIRLINES INC                      | PM10        | 17.16                 | 520593   | ABRASIVE BLASTING (CABINET/MACHINE/ROOM)              | 6010 & 6020 AVION DR      | LOS ANGELES   |
| 9755        | UNITED AIRLINES INC                      | PM10        | 5.2                   | 520595   | IC E (50-500 HP) EM FIRE FIGHT-DIESEL                 | 6010 & 6020 AVION DR      | LOS ANGELES   |
| 9755        | UNITED AIRLINES INC                      | PM10        | 10                    | 520589   | IC E (50-500 HP) N-EM PORT N-RENT DIESE               | 6010 & 6020 AVION DR      | LOS ANGELES   |
| 9755        | UNITED AIRLINES INC                      | PM10        | 116.48                | 522810   | IC E (50-500 HP) N-EM PORT N-RENT DIESE               | 6010 & 6020 AVION DR      | LOS ANGELES   |
| 10292       | THE AEROSPACE CORP UNIT NO.02            | NOX         | 436.8                 | 511302   | BOILER (<5 MMBTU/HR) NAT GAS ONLY                     | 2350 E EL SEGUNDO         | EL SEGUNDO    |
| 10292       | THE AEROSPACE CORP UNIT NO.02            | NOX         | 524.16                | 511300   | BOILER (5-20 MMBTU/HR) NAT GAS ONLY                   | 2350 E EL SEGUNDO         | EL SEGUNDO    |
| 10292       | THE AEROSPACE CORP UNIT NO.02            | NOX         | 524.16                | 511301   | BOILER (5-20 MMBTU/HR) NAT GAS ONLY                   | 2350 E EL SEGUNDO         | EL SEGUNDO    |
| 10292       | THE AEROSPACE CORP UNIT NO.02            | NOX         | 524.16                | 511303   | BOILER (<5 MMBTU/HR) NAT GAS ONLY                     | 2350 E EL SEGUNDO         | EL SEGUNDO    |
| 10292       | THE AEROSPACE CORP UNIT NO.02            | PM10        | 262.08                | 511302   | BOILER (<5 MMBTU/HR) NAT GAS ONLY                     | 2350 E EL SEGUNDO         | EL SEGUNDO    |
| 10292       | THE AEROSPACE CORP UNIT NO.02            | PM10        | 262.08                | 511303   | BOILER (5-20 MMBTU/HR) NAT GAS ONLY                   | 2350 E EL SEGUNDO         | EL SEGUNDO    |
| 10292       | THE AEROSPACE CORP UNIT NO.02            | PM10        | 349.44                | 511300   | BOILER (5-20 MMBTU/HR) NAT GAS ONLY                   | 2350 E EL SEGUNDO         | EL SEGUNDO    |
| 10292       | THE AEROSPACE CORP UNIT NO.02            | PM10        | 349.44                | 511301   | BOILER (5-20 MMBTU/HR) NAT GAS ONLY                   | 2350 E EL SEGUNDO         | EL SEGUNDO    |
| 13844       | CHROMPLATE COMPANY                       | PM10        | 0                     | 497471   |   | 1127 W HILLCREST BLVD     | INGLEWOOD     |
| 13844       | CHROMPLATE COMPANY                       | PM10        | 0                     | 498878   | TANK CHROME PLATING HEXAVALENT                        | 1127 W HILLCREST BLVD     | INGLEWOOD     |
| 13844       | CHROMPLATE COMPANY                       | PM10        | 0                     | 498879   | TANK CHROME PLATING HEXAVALENT                        | 1127 W HILLCREST BLVD     | INGLEWOOD     |
| 15660       | QUALITY EQUIP RENTALS                    | NOX         | 4.16                  | 513248   | SPACE HEATER,PORTABLE,<600,000BTU/HR,DIESEL/OIL FIRED | 711-717 N LA BREA AVE     | INGLEWOOD     |
| 15660       | QUALITY EQUIP RENTALS                    | NOX         | 4.16                  | 513249   | SPACE HEATER,PORTABLE,<600,000BTU/HR,DIESEL/OIL FIRED | 711-717 N LA BREA AVE     | INGLEWOOD     |
| 15660       | QUALITY EQUIP RENTALS                    | NOX         | 4.16                  | 513250   | SPACE HEATER,PORTABLE,<600,000BTU/HR,DIESEL/OIL FIRED | 711-717 N LA BREA AVE     | INGLEWOOD     |
| 15660       | QUALITY EQUIP RENTALS                    | NOX         | 4.16                  | 513251   | SPACE HEATER,PORTABLE,<600,000BTU/HR,DIESEL/OIL FIRED | 711-717 N LA BREA AVE     | INGLEWOOD     |
| 15660       | QUALITY EQUIP RENTALS                    | NOX         | 4.16                  | 513253   | SPACE HEATER,PORTABLE,<600,000BTU/HR,DIESEL/OIL FIRED | 711-717 N LA BREA AVE     | INGLEWOOD     |
| 15660       | QUALITY EQUIP RENTALS                    | PM10        | 4.16                  | 513248   | SPACE HEATER,PORTABLE,<600,000BTU/HR,DIESEL/OIL FIRED | 711-717 N LA BREA AVE     | INGLEWOOD     |
| 15660       | QUALITY EQUIP RENTALS                    | PM10        | 4.16                  | 513249   | SPACE HEATER,PORTABLE,<600,000BTU/HR,DIESEL/OIL FIRED | 711-717 N LA BREA AVE     | INGLEWOOD     |
| 15660       | QUALITY EQUIP RENTALS                    | PM10        | 4.16                  | 513250   | SPACE HEATER,PORTABLE,<600,000BTU/HR,DIESEL/OIL FIRED | 711-717 N LA BREA AVE     | INGLEWOOD     |
| 15660       | QUALITY EQUIP RENTALS                    | PM10        | 4.16                  | 513251   | SPACE HEATER,PORTABLE,<600,000BTU/HR,DIESEL/OIL FIRED | 711-717 N LA BREA AVE     | INGLEWOOD     |
| 15660       | QUALITY EQUIP RENTALS                    | PM10        | 4.16                  | 513253   | SPACE HEATER,PORTABLE,<600,000BTU/HR,DIESEL/OIL FIRED | 711-717 N LA BREA AVE     | INGLEWOOD     |
| 18294       | NORTHROP GRUMMAN CORP. AIRCRAFT DIV      | NOX         | 524.16                | 526639   | BOILER (5-20 MMBTU/HR) NAT GAS ONLY                   | ONE HORNET WAY M/S PA12M5 | EL SEGUNDO    |
| 18294       | NORTHROP GRUMMAN CORP. AIRCRAFT DIV      | NOX         | 5125.12               | 504172   | AUTOCLAVE   | ONE HORNET WAY M/S PA12M5 | EL SEGUNDO    |

Table 3.1H-1, cont.

| Facility ID | Facility Name                          | Emittent ID | Emission Amt (lbs/yr) | Appl Nbr | Equipment (BCAT) Description             | loc Street Address        | loc City    |
|-------------|--|-------------|-----------------------|----------|--|---------------------------|-------------|
| 18294       | NORTHROP GRUMMAN CORP. AIRCRAFT DIV    | PM10        | 174.72                | 502552   |  | ONE HORNET WAY M/S PA12W5 | EL SEGUNDO  |
| 18294       | NORTHROP GRUMMAN CORP. AIRCRAFT DIV    | PM10        | 174.72                | 502553   |  | ONE HORNET WAY M/S PA12W5 | EL SEGUNDO  |
| 18294       | NORTHROP GRUMMAN CORP. AIRCRAFT DIV    | PM10        | 349.44                | 528639   | BOILER (5-20 MMBTU/HR) NAT GAS ONLY      | ONE HORNET WAY M/S PA12W5 | EL SEGUNDO  |
| 18294       | NORTHROP GRUMMAN CORP. AIRCRAFT DIV    | PM10        | 990.08                | 504172   | AUTOCLAVE                                | ONE HORNET WAY M/S PA12W5 | EL SEGUNDO  |
| 20421       | BLUE DIAMOND INGLEWOOD ASPHALT CORP    | NOX         | 7913.88               | 511386   | ASPHALT BLENDING/BATCHING EQUIPMENT      | 441 W RAILROAD PL         | INGLEWOOD   |
| 20421       | BLUE DIAMOND INGLEWOOD ASPHALT CORP    | PM10        | 0                     | 523089   |  | 441 W RAILROAD PL         | INGLEWOOD   |
| 20421       | BLUE DIAMOND INGLEWOOD ASPHALT CORP    | PM10        | 1170.78               | 511386   | ASPHALT BLENDING/BATCHING EQUIPMENT      | 441 W RAILROAD PL         | INGLEWOOD   |
| 22312       | LA AIRPORT MARRIOTT HOTEL              | NOX         | 786.24                | 528696   | BOILER (5-20 MMBTU/HR) NAT GAS ONLY      | 5855 W CENTURY BLVD       | LOS ANGELES |
| 22312       | LA AIRPORT MARRIOTT HOTEL              | NOX         | 786.24                | 529722   | BOILER (5-20 MMBTU/HR) NAT GAS ONLY      | 5855 W CENTURY BLVD       | LOS ANGELES |
| 22312       | LA AIRPORT MARRIOTT HOTEL              | PM10        | 524.16                | 528696   | BOILER (5-20 MMBTU/HR) NAT GAS ONLY      | 5855 W CENTURY BLVD       | LOS ANGELES |
| 22312       | LA AIRPORT MARRIOTT HOTEL              | PM10        | 524.16                | 529722   | BOILER (5-20 MMBTU/HR) NAT GAS ONLY      | 5855 W CENTURY BLVD       | LOS ANGELES |
| 42278       | THE AEROSPACE CORP. UNIT NO.04         | NOX         | 121.5                 | 525189   | I C E (50-500 HP) EM ELEC GEN-DIESEL     | 300 S DOUGLAS ST BLDG A6B | EL SEGUNDO  |
| 42278       | THE AEROSPACE CORP. UNIT NO.04         | NOX         | 436.8                 | 511304   | BOILER (<5 MMBTU/HR) NAT GAS ONLY        | 300 S DOUGLAS ST BLDG A6B | EL SEGUNDO  |
| 42278       | THE AEROSPACE CORP. UNIT NO.04         | NOX         | 436.8                 | 511305   | BOILER (<5 MMBTU/HR) NAT GAS ONLY        | 300 S DOUGLAS ST BLDG A6B | EL SEGUNDO  |
| 42278       | THE AEROSPACE CORP. UNIT NO.04         | PM          | 3                     | 525189   | I C E (50-500 HP) EM ELEC GEN-DIESEL     | 300 S DOUGLAS ST BLDG A6B | EL SEGUNDO  |
| 42278       | THE AEROSPACE CORP. UNIT NO.04         | PM10        | 262.08                | 511304   | BOILER (<5 MMBTU/HR) NAT GAS ONLY        | 300 S DOUGLAS ST BLDG A6B | EL SEGUNDO  |
| 42278       | THE AEROSPACE CORP. UNIT NO.04         | PM10        | 262.08                | 511305   | BOILER (<5 MMBTU/HR) NAT GAS ONLY        | 300 S DOUGLAS ST BLDG A6B | EL SEGUNDO  |
| 44012       | GOODMAN FOOD PROD INC                  | NOX         | 832                   | 513194   | OVEN, COOKING OR CURING                  | 200 E BEACH AVE           | INGLEWOOD   |
| 44012       | GOODMAN FOOD PROD INC                  | NOX         | 832                   | 513196   | OVEN, COOKING OR CURING                  | 200 E BEACH AVE           | INGLEWOOD   |
| 44012       | GOODMAN FOOD PROD INC                  | NOX         | 1048.32               | 527297   | OVEN, COOKING OR CURING                  | 200 E BEACH AVE           | INGLEWOOD   |
| 44012       | GOODMAN FOOD PROD INC                  | NOX         | 1048.32               | 527305   | OVEN, COOKING OR CURING                  | 200 E BEACH AVE           | INGLEWOOD   |
| 44012       | GOODMAN FOOD PROD INC                  | PM10        | 0                     | 518643   |  | 200 E BEACH AVE           | INGLEWOOD   |
| 44012       | GOODMAN FOOD PROD INC                  | PM10        | 1539.2                | 513194   | OVEN, COOKING OR CURING                  | 200 E BEACH AVE           | INGLEWOOD   |
| 44012       | GOODMAN FOOD PROD INC                  | PM10        | 1539.2                | 513196   | OVEN, COOKING OR CURING                  | 200 E BEACH AVE           | INGLEWOOD   |
| 44012       | GOODMAN FOOD PROD INC                  | PM10        | 1592                  | 527297   | OVEN, COOKING OR CURING                  | 200 E BEACH AVE           | INGLEWOOD   |
| 44012       | GOODMAN FOOD PROD INC                  | PM10        | 1592                  | 527305   | OVEN, COOKING OR CURING                  | 200 E BEACH AVE           | INGLEWOOD   |
| 48634       | HAWTHORNE HOSPITAL                     | NOX         | 107.8                 | 520342   | I C E (50-500 HP) EM ELEC GEN-DIESEL     | 13300 S HAWTHORNE BLVD    | HAWTHORNE   |
| 48634       | HAWTHORNE HOSPITAL                     | PM10        | 7.2                   | 520342   | I C E (50-500 HP) EM ELEC GEN-DIESEL     | 13300 S HAWTHORNE BLVD    | HAWTHORNE   |
| 74693       | FEDERAL EXPRESS, LAX OPERATIONS        | NOX         | 250                   | 504947   |  | 7401 WORLD WEST WAY       | LOS ANGELES |
| 74693       | FEDERAL EXPRESS, LAX OPERATIONS        | NOX         | 250                   | 504948   |  | 7401 WORLD WEST WAY       | LOS ANGELES |
| 74693       | FEDERAL EXPRESS, LAX OPERATIONS        | NOX         | 250                   | 504946   |  | 7401 WORLD WEST WAY       | LOS ANGELES |
| 74693       | FEDERAL EXPRESS, LAX OPERATIONS        | PM          | 520                   | 504947   |  | 7401 WORLD WEST WAY       | LOS ANGELES |
| 74693       | FEDERAL EXPRESS, LAX OPERATIONS        | PM          | 520                   | 504948   |  | 7401 WORLD WEST WAY       | LOS ANGELES |
| 74693       | FEDERAL EXPRESS, LAX OPERATIONS        | PM10        | 260                   | 504946   |  | 7401 WORLD WEST WAY       | LOS ANGELES |
| 74693       | FEDERAL EXPRESS, LAX OPERATIONS        | PM10        | 260                   | 504948   |  | 7401 WORLD WEST WAY       | LOS ANGELES |
| 74693       | FEDERAL EXPRESS, LAX OPERATIONS        | PM10        | 260                   | 504946   |  | 7401 WORLD WEST WAY       | LOS ANGELES |
| 89127       | TRI-STAR ELECTRONICS INTERNATIONAL INC | PM10        | 0                     | 540020   |  | 2201 ROSECRANS AVE        | EL SEGUNDO  |
| 89127       | TRI-STAR ELECTRONICS INTERNATIONAL INC | PM10        | 0                     | 540023   | Waste Water Treating <20,000gpd,no toxic | 2201 ROSECRANS AVE        | EL SEGUNDO  |
| 89127       | TRI-STAR ELECTRONICS INTERNATIONAL INC | PM10        | 0                     | 540024   | MISC STRIPPING TANK                      | 2201 ROSECRANS AVE        | EL SEGUNDO  |
| 89127       | TRI-STAR ELECTRONICS INTERNATIONAL INC | PM10        | 320                   | 540025   | Tank, plating other                      | 2201 ROSECRANS AVE        | EL SEGUNDO  |
| 89127       | TRI-STAR ELECTRONICS INTERNATIONAL INC | PM10        | 686.4                 | 540021   | TANK, PRECIOUS METAL - PLATING           | 2201 ROSECRANS AVE        | EL SEGUNDO  |
| 94065       | WEST BASIN MUNICIPAL WATER DISTRICT    | PM10        | 0                     | 528579   |  | 1935 E HUGHES WAY         | EL SEGUNDO  |
| 94065       | WEST BASIN MUNICIPAL WATER DISTRICT    | PM10        | 0                     | 530556   |  | 1935 E HUGHES WAY         | EL SEGUNDO  |
| 94065       | WEST BASIN MUNICIPAL WATER DISTRICT    | PM10        | 4.6                   | 528578   | STORAGE SILO LIME & LIMESTONE            | 1935 E HUGHES WAY         | EL SEGUNDO  |
| 94065       | WEST BASIN MUNICIPAL WATER DISTRICT    | PM10        | 4.6                   | 530555   | STORAGE SILO LIME & LIMESTONE            | 1935 E HUGHES WAY         | EL SEGUNDO  |
| 101140      | JIM & JACK INC                         | NOX         | 353.6                 | 528906   |  | 1601 E GRAND AVE          | EL SEGUNDO  |
| 101140      | JIM & JACK INC                         | NOX         | 353.6                 | 528907   |  | 1601 E GRAND AVE          | EL SEGUNDO  |
| 101140      | JIM & JACK INC                         | NOX         | 780                   | 523909   |  | 1601 E GRAND AVE          | EL SEGUNDO  |
| 101140      | JIM & JACK INC                         | PM          | 0                     | 522519   |  | 1601 E GRAND AVE          | EL SEGUNDO  |
| 101140      | JIM & JACK INC                         | PM          | 0                     | 522520   |  | 1601 E GRAND AVE          | EL SEGUNDO  |



Table 3.1H-1, cont.

| Facility ID | Facility Name                            | Emittent ID | Emission Amt (lbs/yr) | Appl Nbr | Equipment (BCAT) Description             | loc Street Address     | loc City       |
|-------------|--|-------------|-----------------------|----------|--|------------------------|----------------|
| 101140      | JIM & JACK INC                           | PM          | 842.4                 | 523908   |  | 1601 E GRAND AVE       | EL SEGUNDO     |
| 101140      | JIM & JACK INC                           | PM10        | 0                     | 522519   |  | 1601 E GRAND AVE       | EL SEGUNDO     |
| 101140      | JIM & JACK INC                           | PM10        | 0                     | 522520   |  | 1601 E GRAND AVE       | EL SEGUNDO     |
| 101140      | JIM & JACK INC                           | PM10        | 405.6                 | 523908   |  | 1601 E GRAND AVE       | EL SEGUNDO     |
| 101140      | JIM & JACK INC                           | PM10        | 405.6                 | 523909   |  | 1601 E GRAND AVE       | EL SEGUNDO     |
| 104684      | ICC COLLISION CENTERS                    | NOX         | 1300                  | 518956   |  | 4210 DEL REY AVE       | MARINA DEL REY |
| 106674      | CITY OF CULVER CITY, BRADDOCK LIFT STATI | NOX         | 73.5                  | 523257   | I C E (50-500 HP) EM ELEC GEN-DIESEL     | 11285 BRADDOCK DR      | CULVER CITY    |
| 106674      | CITY OF CULVER CITY, BRADDOCK LIFT STATI | PM          | 3.5                   | 523257   | I C E (50-500 HP) EM ELEC GEN-DIESEL     | 11285 BRADDOCK DR      | CULVER CITY    |
| 114997      | RAYTHEON COMPANY                         | NOX         | 194                   | 535632   | I C E (50-500 HP) EM ELEC GEN-DIESEL     | 1970 E IMPERIAL HWY    | EL SEGUNDO     |
| 114997      | RAYTHEON COMPANY                         | NOX         | 648                   | 535633   | I C E (>500 HP) EM ELEC GEN-DIESEL       | 1970 E IMPERIAL HWY    | EL SEGUNDO     |
| 114997      | RAYTHEON COMPANY                         | PM10        | 8                     | 535632   | I C E (50-500 HP) EM ELEC GEN-DIESEL     | 1970 E IMPERIAL HWY    | EL SEGUNDO     |
| 114997      | RAYTHEON COMPANY                         | PM10        | 37.4                  | 535633   | I C E (>500 HP) EM ELEC GEN-DIESEL       | 1970 E IMPERIAL HWY    | EL SEGUNDO     |
| 115536      | AES REDONDO BEACH, LLC                   | NOX         | 5.72                  | 511883   | BOILER (< 2 mmBTU/HR) OIL FIRED          | 1100 N. HARBOR DR      | REDONDO BEACH  |
| 115536      | AES REDONDO BEACH, LLC                   | PM10        | 0.52                  | 511883   | BOILER (< 2 mmBTU/HR) OIL FIRED          | 1100 N. HARBOR DR      | REDONDO BEACH  |
| 115663      | EL SEGUNDO POWER, LLC                    | NOX         | 0                     | 464316   |  | 301 VISTA DEL MAR      | EL SEGUNDO     |
| 115663      | EL SEGUNDO POWER, LLC                    | PM10        | 0                     | 464316   |  | 301 VISTA DEL MAR      | EL SEGUNDO     |
| 135425      | SHERATON GATEWAY HOTEL- LAX              | NOX         | 960.96                | 530328   | BOILER (5-20 MMBTU/HR) NAT GAS ONLY      | 6101 W CENTURY BLVD    | LOS ANGELES    |
| 135425      | SHERATON GATEWAY HOTEL- LAX              | NOX         | 960.96                | 530446   | BOILER (5-20 MMBTU/HR) NAT GAS ONLY      | 6101 W CENTURY BLVD    | LOS ANGELES    |
| 135425      | SHERATON GATEWAY HOTEL- LAX              | PM10        | 698.88                | 530328   | BOILER (5-20 MMBTU/HR) NAT GAS ONLY      | 6101 W CENTURY BLVD    | LOS ANGELES    |
| 135425      | SHERATON GATEWAY HOTEL- LAX              | PM10        | 698.88                | 530446   | BOILER (5-20 MMBTU/HR) NAT GAS ONLY      | 6101 W CENTURY BLVD    | LOS ANGELES    |
| 145747      | CROWNE PLAZA HOTEL                       | NOX         | 0                     | 448297   | CHARBROILER - NATURAL GAS                | 300 N HARBOR DR        | REDONDO BEACH  |
| 145747      | CROWNE PLAZA HOTEL                       | PM10        | 0                     | 448297   | CHARBROILER - NATURAL GAS                | 300 N HARBOR DR        | REDONDO BEACH  |
| 145836      | American Apparel DYEING & FINISHING, INC | PM          | 0                     | 510300   |  | 12537 CERISE AVE       | HAWTHORNE      |
| 148236      | AIR LIQUIDE LARGE INDUSTRIES U.S., LP    | NOX         | 0                     | 457657   | HYDROGEN PRODUCTION PLANT                | 324 W EL SEGUNDO BLVD  | EL SEGUNDO     |
| 148236      | AIR LIQUIDE LARGE INDUSTRIES U.S., LP    | NOX         | 0                     | 457787   |  | 324 W EL SEGUNDO BLVD  | EL SEGUNDO     |
| 148236      | AIR LIQUIDE LARGE INDUSTRIES U.S., LP    | NOX         | 6204                  | 457788   |  | 324 W EL SEGUNDO BLVD  | EL SEGUNDO     |
| 148236      | AIR LIQUIDE LARGE INDUSTRIES U.S., LP    | NOX         | 44990.4               | 457785   | HEATER/FURNACE (>50 MMBTU/HR)PROCESS GAS | 324 W EL SEGUNDO BLVD  | EL SEGUNDO     |
| 148236      | AIR LIQUIDE LARGE INDUSTRIES U.S., LP    | PM10        | 0                     | 457657   | HYDROGEN PRODUCTION PLANT                | 324 W EL SEGUNDO BLVD  | EL SEGUNDO     |
| 148236      | AIR LIQUIDE LARGE INDUSTRIES U.S., LP    | PM10        | 0                     | 457787   |  | 324 W EL SEGUNDO BLVD  | EL SEGUNDO     |
| 148236      | AIR LIQUIDE LARGE INDUSTRIES U.S., LP    | PM10        | 87.36                 | 457788   |  | 324 W EL SEGUNDO BLVD  | EL SEGUNDO     |
| 148236      | AIR LIQUIDE LARGE INDUSTRIES U.S., LP    | PM10        | 43330.56              | 457785   | HEATER/FURNACE (>50 MMBTU/HR)PROCESS GAS | 324 W EL SEGUNDO BLVD  | EL SEGUNDO     |
| 148822      | CHEVRON CORPORATION                      | NOX         | 1310.4                | 520979   | SOIL TREAT VAPOR EXTRACT GASOLINE UNDER  | 3101 W EL SEGUNDO BLVD | HAWTHORNE      |
| 148822      | CHEVRON CORPORATION                      | PM10        | 87.36                 | 520979   | SOIL TREAT VAPOR EXTRACT GASOLINE UNDER  | 3101 W EL SEGUNDO BLVD | HAWTHORNE      |
| 151346      | CALIFORNIA PORTLAND CEMENT CO            | PM10        | 0                     | 543658   |  | 5299 W 111TH ST        | LOS ANGELES    |
| 151346      | CALIFORNIA PORTLAND CEMENT CO            | PM10        | 83.2                  | 513817   | STORAGE SILO CEMENT                      | 5299 W 111TH ST        | LOS ANGELES    |
| 151346      | CALIFORNIA PORTLAND CEMENT CO            | PM10        | 374.4                 | 529699   | CONCRETE BATCH EQUIPMENT                 | 5299 W 111TH ST        | LOS ANGELES    |
| 151346      | CALIFORNIA PORTLAND CEMENT CO            | PM10        | 2231                  | 511706   | STORAGE SILO CEMENT                      | 5299 W 111TH ST        | LOS ANGELES    |
| 154034      | CENTINELA HOSPITAL MEDICAL CENTER        | NOX         | 659                   | 527784   | I C E (>500 HP) EM ELEC GEN DIESEL       | 555 E HARDY ST         | INGLEWOOD      |
| 154034      | CENTINELA HOSPITAL MEDICAL CENTER        | NOX         | 659                   | 527785   | I C E (>500 HP) EM ELEC GEN DIESEL       | 555 E HARDY ST         | INGLEWOOD      |
| 154034      | CENTINELA HOSPITAL MEDICAL CENTER        | NOX         | 1223.04               | 531512   | BOILER (5-20 MMBTU/HR) NAT GAS ONLY      | 555 E HARDY ST         | INGLEWOOD      |
| 154034      | CENTINELA HOSPITAL MEDICAL CENTER        | NOX         | 1223.04               | 531513   | BOILER (5-20 MMBTU/HR) NAT GAS ONLY      | 555 E HARDY ST         | INGLEWOOD      |
| 154034      | CENTINELA HOSPITAL MEDICAL CENTER        | PM10        | 20                    | 527784   | I C E (>500 HP) EM ELEC GEN DIESEL       | 555 E HARDY ST         | INGLEWOOD      |
| 154034      | CENTINELA HOSPITAL MEDICAL CENTER        | PM10        | 20                    | 527785   | I C E (>500 HP) EM ELEC GEN DIESEL       | 555 E HARDY ST         | INGLEWOOD      |
| 154034      | CENTINELA HOSPITAL MEDICAL CENTER        | PM10        | 786.24                | 531512   | BOILER (5-20 MMBTU/HR) NAT GAS ONLY      | 555 E HARDY ST         | INGLEWOOD      |
| 154034      | CENTINELA HOSPITAL MEDICAL CENTER        | PM10        | 786.24                | 531513   | BOILER (5-20 MMBTU/HR) NAT GAS ONLY      | 555 E HARDY ST         | INGLEWOOD      |
| 155828      | GARRETT AVN. SVCS. LLC DBA STANDARD AERO | NOX         | 4193.28               | 483960   | JET ENGINE TEST FACILITY OTHER FUEL      | 6201 W IMPERIAL HWY    | LOS ANGELES    |
| 155828      | GARRETT AVN. SVCS. LLC DBA STANDARD AERO | NOX         | 18607.68              | 483951   | JET ENGINE TEST FACILITY OTHER FUEL      | 6201 W IMPERIAL HWY    | LOS ANGELES    |
| 155828      | GARRETT AVN. SVCS. LLC DBA STANDARD AERO | PM10        | 5                     | 486205   | Tank, plating other                      | 6201 W IMPERIAL HWY    | LOS ANGELES    |
| 155828      | GARRETT AVN. SVCS. LLC DBA STANDARD AERO | PM10        | 87.36                 | 526286   |  | 6201 W IMPERIAL HWY    | LOS ANGELES    |
| 155828      | GARRETT AVN. SVCS. LLC DBA STANDARD AERO | PM10        | 174.72                | 483952   |  | 6201 W IMPERIAL HWY    | LOS ANGELES    |
| 155828      | GARRETT AVN. SVCS. LLC DBA STANDARD AERO | PM10        | 174.72                | 483959   | ABRASIVE BLASTING (CABINET/MACHINE/ROOM) | 6201 W IMPERIAL HWY    | LOS ANGELES    |

Table 3.1H-1, cont.

| Facility ID | Facility Name                            | Emittent ID | Emission Amt (lbs/yr) | Appl Nbr | Equipment (BCAT) Description            | loc Street Address     | loc City       |
|-------------|--|-------------|-----------------------|----------|---|------------------------|----------------|
| 155828      | GARRETT AVN. SVCS. LLC DBA STANDARD AERO | PM10        | 174.72                | 483960   | JET ENGINE TEST FACILITY OTHER FUEL     | 6201 W IMPERIAL HWY    | LOS ANGELES    |
| 155828      | GARRETT AVN. SVCS. LLC DBA STANDARD AERO | PM10        | 262.08                | 483951   | JET ENGINE TEST FACILITY OTHER FUEL     | 6201 W IMPERIAL HWY    | LOS ANGELES    |
| 157262      | EQUINIX OPERATING CO INC                 | NOX         | 1315                  | 524076   | IC.E (>500 HP) EM ELEC GEN DIESEL       | 445 N DOUGLAS ST       | EL SEGUNDO     |
| 157262      | EQUINIX OPERATING CO INC                 | NOX         | 1315                  | 524079   | IC.E (>500 HP) EM ELEC GEN DIESEL       | 445 N DOUGLAS ST       | EL SEGUNDO     |
| 157262      | EQUINIX OPERATING CO INC                 | NOX         | 1315                  | 524080   | IC.E (>500 HP) EM ELEC GEN DIESEL       | 445 N DOUGLAS ST       | EL SEGUNDO     |
| 157262      | EQUINIX OPERATING CO INC                 | NOX         | 1315                  | 524082   | IC.E (>500 HP) EM ELEC GEN DIESEL       | 445 N DOUGLAS ST       | EL SEGUNDO     |
| 157262      | EQUINIX OPERATING CO INC                 | NOX         | 1315                  | 524084   | IC.E (>500 HP) EM ELEC GEN DIESEL       | 445 N DOUGLAS ST       | EL SEGUNDO     |
| 157262      | EQUINIX OPERATING CO INC                 | NOX         | 1315                  | 524085   | IC.E (>500 HP) EM ELEC GEN DIESEL       | 445 N DOUGLAS ST       | EL SEGUNDO     |
| 157262      | EQUINIX OPERATING CO INC                 | PM10        | 4                     | 524076   | IC.E (>500 HP) EM ELEC GEN DIESEL       | 445 N DOUGLAS ST       | EL SEGUNDO     |
| 157262      | EQUINIX OPERATING CO INC                 | PM10        | 4                     | 524078   | IC.E (>500 HP) EM ELEC GEN DIESEL       | 445 N DOUGLAS ST       | EL SEGUNDO     |
| 157262      | EQUINIX OPERATING CO INC                 | PM10        | 4                     | 524079   | IC.E (>500 HP) EM ELEC GEN DIESEL       | 445 N DOUGLAS ST       | EL SEGUNDO     |
| 157262      | EQUINIX OPERATING CO INC                 | PM10        | 4                     | 524080   | IC.E (>500 HP) EM ELEC GEN DIESEL       | 445 N DOUGLAS ST       | EL SEGUNDO     |
| 157262      | EQUINIX OPERATING CO INC                 | PM10        | 4                     | 524082   | IC.E (>500 HP) EM ELEC GEN DIESEL       | 445 N DOUGLAS ST       | EL SEGUNDO     |
| 157262      | EQUINIX OPERATING CO INC                 | PM10        | 4                     | 524084   | IC.E (>500 HP) EM ELEC GEN DIESEL       | 445 N DOUGLAS ST       | EL SEGUNDO     |
| 157262      | EQUINIX OPERATING CO INC                 | PM10        | 4                     | 524085   | IC.E (>500 HP) EM ELEC GEN DIESEL       | 445 N DOUGLAS ST       | EL SEGUNDO     |
| 159183      | ATC GROUP SERVICES, INC.                 | NOX         | 873.6                 | 515909   | SOIL TREAT VAPOR EXTRACT GASOLINE UNDER | 12806 S PRAIRIE AVE    | HAWTHORNE      |
| 159183      | ATC GROUP SERVICES, INC.                 | NOX         | 873.6                 | 515910   | SOIL TREAT VAPOR EXTRACT GASOLINE UNDER | 12806 S PRAIRIE AVE    | HAWTHORNE      |
| 159714      | NANO20                                   | PM          | 786.24                | 498456   |   | 750 LAIRPORT ST        | EL SEGUNDO     |
| 159714      | NANO20                                   | PM          | 174.72                | 498456   |   | 750 LAIRPORT ST        | EL SEGUNDO     |
| 159714      | NANO20                                   | PM10        | 174.72                | 498456   |   | 750 LAIRPORT ST        | EL SEGUNDO     |
| 159986      | FREEMAN MEDICAL BUILDING, LLC            | NOX         | 299.5                 | 499028   | IC.E (>500 HP) EM ELEC GEN DIESEL       | 301 PRAIRIE            | INGLEWOOD      |
| 159986      | FREEMAN MEDICAL BUILDING, LLC            | PM10        | 0.5                   | 499028   | IC.E (>500 HP) EM ELEC GEN DIESEL       | 301 PRAIRIE            | INGLEWOOD      |
| 161395      | ONE PERFECT LINE, LLC DBA SUPERBA COFFEE | NOX         | 45                    | 502462   | Coffee Roasting (50-90 lb capacity)     | 4040 DEL REY AVE # 6A  | MARINA DEL REY |
| 161395      | ONE PERFECT LINE, LLC DBA SUPERBA COFFEE | PM10        | 11.25                 | 502462   | Coffee Roasting (50-90 lb capacity)     | 4040 DEL REY AVE # 6A  | MARINA DEL REY |
| 163088      | ARKEMA INC.                              | NOX         | 524.16                | 516818   | BOILER (5-20 MMBTU/HR) NAT GAS ONLY     | 19206 HAWTHORNE BLVD   | TORRANCE       |
| 163088      | ARKEMA INC.                              | NOX         | 4717.44               | 509285   | PAINTS, REACTION                        | 19206 HAWTHORNE BLVD   | TORRANCE       |
| 163088      | ARKEMA INC.                              | PM10        | 87.36                 | 542097   | BOILER (5-20 MMBTU/HR) NAT GAS ONLY     | 19206 HAWTHORNE BLVD   | TORRANCE       |
| 163088      | ARKEMA INC.                              | PM10        | 349.44                | 516818   | BOILER (5-20 MMBTU/HR) NAT GAS ONLY     | 19206 HAWTHORNE BLVD   | TORRANCE       |
| 163088      | ARKEMA INC.                              | PM10        | 262.08                | 509285   |   | 19206 HAWTHORNE BLVD   | TORRANCE       |
| 165079      | HAMID                                    | NOX         | 250                   | 513664   |   | 8332 OSAGE AVE         | LOS ANGELES    |
| 165079      | HAMID                                    | NOX         | 250                   | 513663   |   | 8332 OSAGE AVE         | LOS ANGELES    |
| 165079      | HAMID                                    | PM          | 1100                  | 523923   |   | 8332 OSAGE AVE         | LOS ANGELES    |
| 165079      | HAMID                                    | PM          | 1100                  | 523927   |   | 8332 OSAGE AVE         | LOS ANGELES    |
| 165079      | HAMID                                    | PM          | 1100                  | 513664   |   | 8332 OSAGE AVE         | LOS ANGELES    |
| 165079      | HAMID                                    | PM10        | 560                   | 523923   |   | 8332 OSAGE AVE         | LOS ANGELES    |
| 165079      | HAMID                                    | PM10        | 560                   | 523927   |   | 8332 OSAGE AVE         | LOS ANGELES    |
| 165079      | HAMID                                    | PM10        | 560                   | 513664   |   | 8332 OSAGE AVE         | LOS ANGELES    |
| 165079      | HAMID                                    | PM10        | 560                   | 513663   |   | 8332 OSAGE AVE         | LOS ANGELES    |
| 165227      | AIRPORT COURTHOUSE, JCCI/AOC             | NOX         | 1900.5                | 514078   | IC.E (>500 HP) EM ELEC GEN DIESEL       | 11701 LA CIENEGA BLVD  | LOS ANGELES    |
| 165231      | INGLEWOOD COURTHOUSE, JCCI/AOC           | NOX         | 206.5                 | 525986   | IC.E (50-500 HP) EM FIRE FIGHT-DIESEL   | 1 E REGENT ST          | INGLEWOOD      |
| 165231      | INGLEWOOD COURTHOUSE, JCCI/AOC           | NOX         | 864                   | 514083   | IC.E (>500 HP) EM ELEC GEN DIESEL       | 1 E REGENT ST          | INGLEWOOD      |
| 165231      | INGLEWOOD COURTHOUSE, JCCI/AOC           | PM10        | 49.5                  | 514083   | IC.E (>500 HP) EM ELEC GEN DIESEL       | 1 E REGENT ST          | INGLEWOOD      |
| 166388      | DIGITAL 2280 EAST EL SEGUNDO, LLC        | NOX         | 1939.5                | 517117   | IC.E (>500 HP) EM ELEC GEN DIESEL       | 2280 E EL SEGUNDO BLVD | EL SEGUNDO     |
| 166388      | DIGITAL 2280 EAST EL SEGUNDO, LLC        | NOX         | 1939.5                | 517118   | IC.E (>500 HP) EM ELEC GEN DIESEL       | 2280 E EL SEGUNDO BLVD | EL SEGUNDO     |
| 166388      | DIGITAL 2280 EAST EL SEGUNDO, LLC        | NOX         | 1939.5                | 517119   | IC.E (>500 HP) EM ELEC GEN DIESEL       | 2280 E EL SEGUNDO BLVD | EL SEGUNDO     |
| 166388      | DIGITAL 2280 EAST EL SEGUNDO, LLC        | NOX         | 1939.5                | 517120   | IC.E (>500 HP) EM ELEC GEN DIESEL       | 2280 E EL SEGUNDO BLVD | EL SEGUNDO     |
| 166388      | DIGITAL 2280 EAST EL SEGUNDO, LLC        | NOX         | 1939.5                | 517121   | IC.E (>500 HP) EM ELEC GEN DIESEL       | 2280 E EL SEGUNDO BLVD | EL SEGUNDO     |
| 166388      | DIGITAL 2280 EAST EL SEGUNDO, LLC        | NOX         | 1939.5                | 517122   | IC.E (>500 HP) EM ELEC GEN DIESEL       | 2280 E EL SEGUNDO BLVD | EL SEGUNDO     |
| 166388      | DIGITAL 2280 EAST EL SEGUNDO, LLC        | NOX         | 1939.5                | 517123   | IC.E (>500 HP) EM ELEC GEN DIESEL       | 2280 E EL SEGUNDO BLVD | EL SEGUNDO     |

Table 3.1H-1, cont.

| Facility ID | Facility Name                            | Emittent ID | Emission Amt (lbs/yr) | Appl Nbr | Equipment (BCAT) Description         | loc Street Address     | loc City        |
|-------------|--|-------------|-----------------------|----------|--------------------------------------|------------------------|-----------------|
| 166388      | DIGITAL 2260 EAST EL SEGUNDO, LLC        | NOX         | 1939.5                | 517125   | I C E (>500 HP) EM ELEC GEN DIESEL   | 2260 E EL SEGUNDO BLVD | EL SEGUNDO      |
| 166388      | DIGITAL 2260 EAST EL SEGUNDO, LLC        | NOX         | 1939.5                | 517127   | I C E (>500 HP) EM ELEC GEN DIESEL   | 2260 E EL SEGUNDO BLVD | EL SEGUNDO      |
| 166388      | DIGITAL 2260 EAST EL SEGUNDO, LLC        | PM10        | 32.5                  | 517117   | I C E (>500 HP) EM ELEC GEN DIESEL   | 2260 E EL SEGUNDO BLVD | EL SEGUNDO      |
| 166388      | DIGITAL 2260 EAST EL SEGUNDO, LLC        | PM10        | 32.5                  | 517118   | I C E (>500 HP) EM ELEC GEN DIESEL   | 2260 E EL SEGUNDO BLVD | EL SEGUNDO      |
| 166388      | DIGITAL 2260 EAST EL SEGUNDO, LLC        | PM10        | 32.5                  | 517119   | I C E (>500 HP) EM ELEC GEN DIESEL   | 2260 E EL SEGUNDO BLVD | EL SEGUNDO      |
| 166388      | DIGITAL 2260 EAST EL SEGUNDO, LLC        | PM10        | 32.5                  | 517120   | I C E (>500 HP) EM ELEC GEN DIESEL   | 2260 E EL SEGUNDO BLVD | EL SEGUNDO      |
| 166388      | DIGITAL 2260 EAST EL SEGUNDO, LLC        | PM10        | 32.5                  | 517121   | I C E (>500 HP) EM ELEC GEN DIESEL   | 2260 E EL SEGUNDO BLVD | EL SEGUNDO      |
| 166388      | DIGITAL 2260 EAST EL SEGUNDO, LLC        | PM10        | 32.5                  | 517122   | I C E (>500 HP) EM ELEC GEN DIESEL   | 2260 E EL SEGUNDO BLVD | EL SEGUNDO      |
| 166388      | DIGITAL 2260 EAST EL SEGUNDO, LLC        | PM10        | 32.5                  | 517123   | I C E (>500 HP) EM ELEC GEN DIESEL   | 2260 E EL SEGUNDO BLVD | EL SEGUNDO      |
| 166388      | DIGITAL 2260 EAST EL SEGUNDO, LLC        | PM10        | 32.5                  | 517125   | I C E (>500 HP) EM ELEC GEN DIESEL   | 2260 E EL SEGUNDO BLVD | EL SEGUNDO      |
| 166388      | DIGITAL 2260 EAST EL SEGUNDO, LLC        | PM10        | 32.5                  | 517127   | I C E (>500 HP) EM ELEC GEN DIESEL   | 2260 E EL SEGUNDO BLVD | EL SEGUNDO      |
| 166607      | J & J AUTO BODY SHOP                     | PM          | 655.2                 | 518110   |                                      | 14120-24 CRENSHAW BLVD | GARDENA         |
| 166607      | J & J AUTO BODY SHOP                     | PM10        | 343.2                 | 518110   |                                      | 14120-24 CRENSHAW BLVD | GARDENA         |
| 166664      | EVEN KEEL INDUSTRIES LLC                 | PM          | 748.8                 | 519887   |                                      | 922 W HYDE PARK BLVD   | INGLEWOOD       |
| 166664      | EVEN KEEL INDUSTRIES LLC                 | PM10        | 374.4                 | 519887   |                                      | 922 W HYDE PARK BLVD   | INGLEWOOD       |
| 166890      | LIVING SPACES - REDONDO BEACH            | NOX         | 60                    | 519046   | I C E (50-500 HP) EM ELEC GEN-DIESEL | 1519 HAWTHORNE BLVD    | REDONDO BEACH   |
| 166890      | LIVING SPACES - REDONDO BEACH            | PM          | 2.5                   | 519046   | I C E (50-500 HP) EM ELEC GEN-DIESEL | 1519 HAWTHORNE BLVD    | REDONDO BEACH   |
| 167007      | COOPERSMITH INC                          | NOX         | 82.26                 | 519866   | I C E (50-500 HP) EM ELEC GEN-DIESEL | 525 DOUGLAS ST         | EL SEGUNDO      |
| 167007      | COOPERSMITH INC                          | PM10        | 5.09                  | 519866   | I C E (50-500 HP) EM ELEC GEN-DIESEL | 525 DOUGLAS ST         | EL SEGUNDO      |
| 167092      | EQUITY OFFICE PROPERTIES                 | NOX         | 110                   | 519637   | I C E (50-500 HP) EM ELEC GEN-DIESEL | 6880 PARK TERRACE DR   | LOS ANGELES     |
| 167092      | EQUITY OFFICE PROPERTIES                 | PM10        | 12                    | 519637   | I C E (50-500 HP) EM ELEC GEN-DIESEL | 6880 PARK TERRACE DR   | LOS ANGELES     |
| 167173      | EQUITY OFFICE PROPERTIES, TRIZAC 6100 HH | NOX         | 501                   | 520020   | I C E (50-500 HP) EM ELEC GEN-DIESEL | 6100 CENTER DR         | LOS ANGELES     |
| 167173      | EQUITY OFFICE PROPERTIES, TRIZAC 6100 HH | PM          | 29                    | 520020   | I C E (50-500 HP) EM ELEC GEN-DIESEL | 6100 CENTER DR         | LOS ANGELES     |
| 167187      | CENTURY 1ST AUTO BODY & PAINT, INC.      | PM          | 832                   | 520087   |                                      | 427 HINDRY             | INGLEWOOD       |
| 167187      | CENTURY 1ST AUTO BODY & PAINT, INC.      | PM10        | 416                   | 520087   |                                      | 427 HINDRY             | INGLEWOOD       |
| 167389      | PRECISION COACHCRAFT                     | NOX         | 80                    | 521129   |                                      | 7351 LA TIJERA BLVD    | LOS ANGELES     |
| 167389      | PRECISION COACHCRAFT                     | PM          | 1100                  | 521129   |                                      | 7351 LA TIJERA BLVD    | LOS ANGELES     |
| 167389      | PRECISION COACHCRAFT                     | PM10        | 560                   | 521129   |                                      | 7351 LA TIJERA BLVD    | LOS ANGELES     |
| 167598      | SPACE EXPLORATION TECHNOLOGIES           | NOX         | 174.72                | 536460   | OVEN, OTHER                          | 1 ROCKET RD            | HAWTHORNE       |
| 167598      | SPACE EXPLORATION TECHNOLOGIES           | NOX         | 436.8                 | 522262   | OVEN, PLASTIC/RESIN CURING           | 1 ROCKET RD            | HAWTHORNE       |
| 167598      | SPACE EXPLORATION TECHNOLOGIES           | NOX         | 611.52                | 533737   | OVEN, PLASTIC/RESIN CURING           | 1 ROCKET RD            | HAWTHORNE       |
| 167598      | SPACE EXPLORATION TECHNOLOGIES           | NOX         | 800.8                 | 522261   | OVEN, PLASTIC/RESIN CURING           | 1 ROCKET RD            | HAWTHORNE       |
| 167598      | SPACE EXPLORATION TECHNOLOGIES           | NOX         | 1135.68               | 529206   | OVEN, PLASTIC/RESIN CURING           | 1 ROCKET RD            | HAWTHORNE       |
| 167598      | SPACE EXPLORATION TECHNOLOGIES           | PM          | 0                     | 536460   | OVEN, OTHER                          | 1 ROCKET RD            | HAWTHORNE       |
| 167598      | SPACE EXPLORATION TECHNOLOGIES           | PM10        | 698.88                | 533737   | OVEN, OTHER                          | 1 ROCKET RD            | HAWTHORNE       |
| 167598      | SPACE EXPLORATION TECHNOLOGIES           | PM10        | 0                     | 536460   | OVEN, OTHER                          | 1 ROCKET RD            | HAWTHORNE       |
| 167598      | SPACE EXPLORATION TECHNOLOGIES           | PM10        | 349.44                | 533737   | OVEN, OTHER                          | 1 ROCKET RD            | HAWTHORNE       |
| 167598      | SPACE EXPLORATION TECHNOLOGIES           | PM10        | 262.08                | 529206   | OVEN, PLASTIC/RESIN CURING           | 1 ROCKET RD            | HAWTHORNE       |
| 167619      | CLEAN HARBORS ENVIRONMENTAL SERVICES     | NOX         | 357                   | 522968   | BOILER < 2MM BTU/HR OIL-FIRED DIESEL | 324 W EL SEGUNDO BLVD  | EL SEGUNDO      |
| 167619      | CLEAN HARBORS ENVIRONMENTAL SERVICES     | PM10        | 35                    | 522968   | BOILER < 2MM BTU/HR OIL-FIRED DIESEL | 324 W EL SEGUNDO BLVD  | EL SEGUNDO      |
| 167814      | TESLA MOTORS INC                         | NOX         | 83.2                  | 522849   |                                      | 3203 JACK NORTHROP AVE | HAWTHORNE       |
| 167843      | CUSTOM HOTEL LLC                         | NOX         | 94                    | 522948   | I C E (50-500 HP) EM ELEC GEN-DIESEL | 8639 LINCOLN BLVD      | LOS ANGELES     |
| 167843      | CUSTOM HOTEL LLC                         | PM10        | 2                     | 522948   | I C E (50-500 HP) EM ELEC GEN-DIESEL | 8639 LINCOLN BLVD      | LOS ANGELES     |
| 167899      | POWER COLLISION CENTER OF SOUTH BAY      | NOX         | 83.2                  | 523180   |                                      | 707 N SEPULVEDA BLVD   | MANHATTAN BEACH |
| 167899      | POWER COLLISION CENTER OF SOUTH BAY      | PM          | 332.8                 | 523182   |                                      | 707 N SEPULVEDA BLVD   | MANHATTAN BEACH |
| 167899      | POWER COLLISION CENTER OF SOUTH BAY      | PM          | 332.8                 | 523180   |                                      | 707 N SEPULVEDA BLVD   | MANHATTAN BEACH |
| 167899      | POWER COLLISION CENTER OF SOUTH BAY      | PM          | 332.8                 | 523181   |                                      | 707 N SEPULVEDA BLVD   | MANHATTAN BEACH |
| 167899      | POWER COLLISION CENTER OF SOUTH BAY      | PM10        | 166.4                 | 523182   |                                      | 707 N SEPULVEDA BLVD   | MANHATTAN BEACH |
| 167899      | POWER COLLISION CENTER OF SOUTH BAY      | PM10        | 166.4                 | 523180   |                                      | 707 N SEPULVEDA BLVD   | MANHATTAN BEACH |
| 167899      | POWER COLLISION CENTER OF SOUTH BAY      | PM10        | 166.4                 | 523181   |                                      | 707 N SEPULVEDA BLVD   | MANHATTAN BEACH |

Table 3.1H-1, cont.

| Facility ID | Facility Name                           | Emittent ID | Emission Amt (lbs/yr) | Appl Nbr | Equipment (BCAT) Description            | loc Street Address     | loc City       |
|-------------|---|-------------|-----------------------|----------|---|------------------------|----------------|
| 167921      | ASIANA AIRLINES                         | NOX         | 1756                  | 525108   | IC E (>500 HP) EM ELEC GEN DIESEL       | 5758 W CENTURY BLVD    | LOS ANGELES    |
| 167921      | ASIANA AIRLINES                         | PM10        | 30                    | 525108   | IC E (>500 HP) EM ELEC GEN DIESEL       | 5758 W CENTURY BLVD    | LOS ANGELES    |
| 168483      | CITY OF HAWTHORNE, CA WATER SERVICE CO. | PM10        | 4.61                  | 529481   | STORAGE TANK W/ VAPOR CONTROL, AMMONIA  | 12601 RAMONA AVE       | HAWTHORNE      |
| 168764      | 44 LA WESTSIDE LESSEE, LLC              | NOX         | 54.5                  | 527693   | IC E (50-500 HP) EM FIRE FIGHT-DIESEL   | 6333 BRISTOL           | CULVER CITY    |
| 168764      | 44 LA WESTSIDE LESSEE, LLC              | NOX         | 4.17                  | 527694   | IC E (50-500 HP) EM ELEC GEN-DIESEL     | 6333 BRISTOL           | CULVER CITY    |
| 168764      | 44 LA WESTSIDE LESSEE, LLC              | PM          | 0.18                  | 527694   | IC E (50-500 HP) EM ELEC GEN-DIESEL     | 6333 BRISTOL           | CULVER CITY    |
| 168764      | 44 LA WESTSIDE LESSEE, LLC              | PM10        | 2.5                   | 527693   | IC E (50-500 HP) EM FIRE FIGHT-DIESEL   | 6333 BRISTOL           | CULVER CITY    |
| 168811      | CLOUDBREAK, INGLEWOOD                   | NOX         | 49.21                 | 526259   | IC E (50-500 HP) EM ELEC GEN-DIESEL     | 725 HINDRY AVE         | INGLEWOOD      |
| 168811      | CLOUDBREAK, INGLEWOOD                   | PM10        | 2.31                  | 526259   | IC E (50-500 HP) EM ELEC GEN-DIESEL     | 725 HINDRY AVE         | INGLEWOOD      |
| 168866      | FIRST CHURCH OF GOD OF LOS ANGELES      | NOX         | 377                   | 527704   | IC E (>500 HP) EM ELEC GEN DIESEL       | 333 N PRAIRIE AVE      | INGLEWOOD      |
| 168866      | FIRST CHURCH OF GOD OF LOS ANGELES      | NOX         | 463                   | 527705   | IC E (>500 HP) EM ELEC GEN DIESEL       | 333 N PRAIRIE AVE      | INGLEWOOD      |
| 168866      | FIRST CHURCH OF GOD OF LOS ANGELES      | NOX         | 3425                  | 527701   | BOILER (5-20 MMBTU/HR) COMB GAS-DISTILL | 333 N PRAIRIE AVE      | INGLEWOOD      |
| 168866      | FIRST CHURCH OF GOD OF LOS ANGELES      | NOX         | 3425                  | 527702   | BOILER (5-20 MMBTU/HR) COMB GAS-DISTILL | 333 N PRAIRIE AVE      | INGLEWOOD      |
| 168866      | FIRST CHURCH OF GOD OF LOS ANGELES      | NOX         | 3425                  | 527703   | BOILER (5-20 MMBTU/HR) COMB GAS-DISTILL | 333 N PRAIRIE AVE      | INGLEWOOD      |
| 168866      | FIRST CHURCH OF GOD OF LOS ANGELES      | PM          | 15                    | 527705   | IC E (>500 HP) EM ELEC GEN DIESEL       | 333 N PRAIRIE AVE      | INGLEWOOD      |
| 168866      | FIRST CHURCH OF GOD OF LOS ANGELES      | PM10        | 8                     | 527704   | IC E (>500 HP) EM ELEC GEN DIESEL       | 333 N PRAIRIE AVE      | INGLEWOOD      |
| 168866      | FIRST CHURCH OF GOD OF LOS ANGELES      | PM10        | 683                   | 527701   | BOILER (5-20 MMBTU/HR) COMB GAS-DISTILL | 333 N PRAIRIE AVE      | INGLEWOOD      |
| 168866      | FIRST CHURCH OF GOD OF LOS ANGELES      | PM10        | 683                   | 527702   | BOILER (5-20 MMBTU/HR) COMB GAS-DISTILL | 333 N PRAIRIE AVE      | INGLEWOOD      |
| 168866      | FIRST CHURCH OF GOD OF LOS ANGELES      | PM10        | 683                   | 527703   | BOILER (5-20 MMBTU/HR) COMB GAS-DISTILL | 333 N PRAIRIE AVE      | INGLEWOOD      |
| 168983      | MARINA CARE CENTER                      | NOX         | 36.5                  | 526835   | IC E (50-500 HP) EM ELEC GEN-DIESEL     | 5240 SEPULVEDA BLVD    | CULVER CITY    |
| 168983      | MARINA CARE CENTER                      | PM          | 3                     | 526835   | IC E (50-500 HP) EM ELEC GEN-DIESEL     | 5240 SEPULVEDA BLVD    | CULVER CITY    |
| 168983      | MARINA CARE CENTER                      | PM10        | 3                     | 526835   | IC E (50-500 HP) EM ELEC GEN-DIESEL     | 5240 SEPULVEDA BLVD    | CULVER CITY    |
| 169168      | T5@ LOS ANGELES, LLC                    | NOX         | 244.5                 | 527576   | IC E (>500 HP) EM ELEC GEN DIESEL       | 444 N NASH ST          | EL SEGUNDO     |
| 169168      | T5@ LOS ANGELES, LLC                    | NOX         | 1481.5                | 527568   | IC E (>500 HP) EM ELEC GEN DIESEL       | 444 N NASH ST          | EL SEGUNDO     |
| 169168      | T5@ LOS ANGELES, LLC                    | NOX         | 1481.5                | 527569   | IC E (>500 HP) EM ELEC GEN DIESEL       | 444 N NASH ST          | EL SEGUNDO     |
| 169168      | T5@ LOS ANGELES, LLC                    | NOX         | 1481.5                | 527570   | IC E (>500 HP) EM ELEC GEN DIESEL       | 444 N NASH ST          | EL SEGUNDO     |
| 169168      | T5@ LOS ANGELES, LLC                    | NOX         | 1481.5                | 527571   | IC E (>500 HP) EM ELEC GEN DIESEL       | 444 N NASH ST          | EL SEGUNDO     |
| 169168      | T5@ LOS ANGELES, LLC                    | NOX         | 1481.5                | 527572   | IC E (>500 HP) EM ELEC GEN DIESEL       | 444 N NASH ST          | EL SEGUNDO     |
| 169168      | T5@ LOS ANGELES, LLC                    | NOX         | 1481.5                | 527574   | IC E (>500 HP) EM ELEC GEN DIESEL       | 444 N NASH ST          | EL SEGUNDO     |
| 169168      | T5@ LOS ANGELES, LLC                    | NOX         | 1481.5                | 527575   | IC E (>500 HP) EM ELEC GEN DIESEL       | 444 N NASH ST          | EL SEGUNDO     |
| 169168      | T5@ LOS ANGELES, LLC                    | NOX         | 1481.5                | 527577   | IC E (>500 HP) EM ELEC GEN DIESEL       | 444 N NASH ST          | EL SEGUNDO     |
| 169168      | T5@ LOS ANGELES, LLC                    | PM10        | 8                     | 527576   | IC E (>500 HP) EM ELEC GEN DIESEL       | 444 N NASH ST          | EL SEGUNDO     |
| 169168      | T5@ LOS ANGELES, LLC                    | PM10        | 19                    | 527568   | IC E (>500 HP) EM ELEC GEN DIESEL       | 444 N NASH ST          | EL SEGUNDO     |
| 169168      | T5@ LOS ANGELES, LLC                    | PM10        | 19                    | 527569   | IC E (>500 HP) EM ELEC GEN DIESEL       | 444 N NASH ST          | EL SEGUNDO     |
| 169168      | T5@ LOS ANGELES, LLC                    | PM10        | 19                    | 527570   | IC E (>500 HP) EM ELEC GEN DIESEL       | 444 N NASH ST          | EL SEGUNDO     |
| 169168      | T5@ LOS ANGELES, LLC                    | PM10        | 19                    | 527571   | IC E (>500 HP) EM ELEC GEN DIESEL       | 444 N NASH ST          | EL SEGUNDO     |
| 169168      | T5@ LOS ANGELES, LLC                    | PM10        | 19                    | 527572   | IC E (>500 HP) EM ELEC GEN DIESEL       | 444 N NASH ST          | EL SEGUNDO     |
| 169168      | T5@ LOS ANGELES, LLC                    | PM10        | 19                    | 527574   | IC E (>500 HP) EM ELEC GEN DIESEL       | 444 N NASH ST          | EL SEGUNDO     |
| 169168      | T5@ LOS ANGELES, LLC                    | PM10        | 19                    | 527575   | IC E (>500 HP) EM ELEC GEN DIESEL       | 444 N NASH ST          | EL SEGUNDO     |
| 169168      | T5@ LOS ANGELES, LLC                    | PM10        | 19                    | 527577   | IC E (>500 HP) EM ELEC GEN DIESEL       | 444 N NASH ST          | EL SEGUNDO     |
| 169247      | INTERNAP REDONDO BEACH                  | NOX         | 1348                  | 527985   | IC E (>500 HP) EM ELEC GEN DIESEL       | 3690 REDONDO BEACH AVE | REDONDO BEACH  |
| 169247      | INTERNAP REDONDO BEACH                  | NOX         | 1348                  | 528075   | IC E (>500 HP) EM ELEC GEN DIESEL       | 3690 REDONDO BEACH AVE | REDONDO BEACH  |
| 169247      | INTERNAP REDONDO BEACH                  | PM          | 40.5                  | 527985   | IC E (>500 HP) EM ELEC GEN DIESEL       | 3690 REDONDO BEACH AVE | REDONDO BEACH  |
| 169247      | INTERNAP REDONDO BEACH                  | PM          | 40.5                  | 528075   | IC E (>500 HP) EM ELEC GEN DIESEL       | 3690 REDONDO BEACH AVE | REDONDO BEACH  |
| 169249      | UDR MARINA POINTE LLC, MARINA POINTE    | NOX         | 87                    | 527946   | IC E (50-500 HP) EM ELEC GEN-DIESEL     | 13603 MARINA POINTE DR | MARINA DEL REY |
| 169249      | UDR MARINA POINTE LLC, MARINA POINTE    | PM10        | 1                     | 527946   | IC E (50-500 HP) EM ELEC GEN-DIESEL     | 13603 MARINA POINTE DR | MARINA DEL REY |
| 169382      | HANKEY INVESTMENT                       | NOX         | 701.5                 | 529323   | IC E (>500 HP) EM ELEC GEN-DIESEL       | 4503 GLENCOE AVE       | MARINA DEL REY |
| 169382      | HANKEY INVESTMENT                       | NOX         | 1266                  | 529324   | IC E (50-500 HP) EM ELEC GEN-DIESEL     | 4503 GLENCOE AVE       | MARINA DEL REY |
| 169382      | HANKEY INVESTMENT                       | PM10        | 7.5                   | 529323   | IC E (>500 HP) EM ELEC GEN DIESEL       | 4503 GLENCOE AVE       | MARINA DEL REY |
| 169382      | HANKEY INVESTMENT                       | PM10        | 20                    | 529324   | IC E (50-500 HP) EM ELEC GEN-DIESEL     | 4503 GLENCOE AVE       | MARINA DEL REY |
| 169616      | URS CORPORATION                         | NOX         | 1397.76               | 528801   | SOIL TREAT VAPOR EXTRACT GASOLINE UNDER | 3971 W ARTESIA BLVD    | TORRANCE       |

Table 3.1H-1, cont.

| Facility ID | Facility Name                           | Emittent ID | Emission Amt (lbs/yr) | Appl Nbr | Equipment (BCAT) Description             | loc Street Address          | loc City       |
|-------------|---|-------------|-----------------------|----------|--|-----------------------------|----------------|
| 169616      | URS CORPORATION                         | PM10        | 87.36                 | 528801   | SOIL TREAT VAPOR EXTRACT GASOLINE UNDER  | 3971 W ARTESIA BLVD         | TORRANCE       |
| 169618      | TWC, INC.                               | NOX         | 1079                  | 528952   | IC E (>500 HP) EM ELEC GEN DIESEL        | 2345 ALASKA AVE             | EL SEGUNDO     |
| 169618      | TWC, INC.                               | PM10        | 14                    | 528952   | IC E (>500 HP) EM ELEC GEN DIESEL        | 2345 ALASKA AVE             | EL SEGUNDO     |
| 169711      | PACIFIC-BIO MATERIAL MANAGEMENT, INC    | NOX         | 65.88                 | 529068   | IC E (50-500 HP) EM ELEC GEN-DIESEL      | 121 SHELDON ST              | EL SEGUNDO     |
| 169711      | PACIFIC-BIO MATERIAL MANAGEMENT, INC    | PM10        | 3.66                  | 529068   | IC E (50-500 HP) EM ELEC GEN-DIESEL      | 121 SHELDON ST              | EL SEGUNDO     |
| 169732      | MERCURY GSE RON SPIEGEL                 | PM          | 1123.2                | 529166   |  | 12519 CERISE AVE            | HAWTHORNE      |
| 169732      | MERCURY GSE RON SPIEGEL                 | PM10        | 561.6                 | 529166   |  | 12519 CERISE AVE            | HAWTHORNE      |
| 169795      | AUTO BODY PROS, INC                     | PM          | 1100                  | 529300   |  | 523 S HINDRY                | INGLEWOOD      |
| 169795      | AUTO BODY PROS, INC                     | PM10        | 560                   | 529300   |  | 523 S HINDRY                | INGLEWOOD      |
| 169902      | MARINA BUSINESS CENTER LLC              | NOX         | 1287.6                | 529689   | IC E (>500 HP) EM ELEC GEN DIESEL        | 4505 GLENCOE AVE            | MARINA DEL REY |
| 169902      | MARINA BUSINESS CENTER LLC              | NOX         | 1332.3                | 529670   | IC E (>500 HP) EM ELEC GEN DIESEL        | 4505 GLENCOE AVE            | MARINA DEL REY |
| 169902      | MARINA BUSINESS CENTER LLC              | NOX         | 1332.3                | 529671   | IC E (>500 HP) EM ELEC GEN DIESEL        | 4505 GLENCOE AVE            | MARINA DEL REY |
| 169902      | MARINA BUSINESS CENTER LLC              | PM10        | 69.6                  | 529689   | IC E (>500 HP) EM ELEC GEN DIESEL        | 4505 GLENCOE AVE            | MARINA DEL REY |
| 169902      | MARINA BUSINESS CENTER LLC              | PM10        | 74.1                  | 529670   | IC E (>500 HP) EM ELEC GEN DIESEL        | 4505 GLENCOE AVE            | MARINA DEL REY |
| 169902      | MARINA BUSINESS CENTER LLC              | PM10        | 74.1                  | 529671   | IC E (>500 HP) EM ELEC GEN DIESEL        | 4505 GLENCOE AVE            | MARINA DEL REY |
| 170227      | QUANTIMETRIX CORPORATION                | NOX         | 25.5                  | 531128   | IC E (50-500 HP) EM ELEC GEN-DIESEL      | 2005 MANHATTAN BEACH BLVD   | REDONDO BEACH  |
| 170227      | QUANTIMETRIX CORPORATION                | PM10        | 1.5                   | 531128   | IC E (50-500 HP) EM ELEC GEN-DIESEL      | 2005 MANHATTAN BEACH BLVD   | REDONDO BEACH  |
| 170570      | STAMPS.COM, INC.                        | NOX         | 576.11                | 532499   | IC E (>500 HP) EM ELEC GEN DIESEL        | 1990 E GRAND AVE            | EL SEGUNDO     |
| 170570      | STAMPS.COM, INC.                        | PM10        | 13.17                 | 532499   | IC E (>500 HP) EM ELEC GEN DIESEL        | 1990 E GRAND AVE            | EL SEGUNDO     |
| 171160      | AEG DIGITAL MEDIA LLC                   | NOX         | 372.6                 | 535722   | IC E (>500 HP) EM ELEC GEN DIESEL        | 12950 CULVER BLVD SUITE 200 | LOS ANGELES    |
| 171160      | AEG DIGITAL MEDIA LLC                   | PM10        | 17.1                  | 535722   | IC E (>500 HP) EM ELEC GEN-OIL           | 12950 CULVER BLVD SUITE 200 | LOS ANGELES    |
| 171246      | CIRCLE K STORES INC.                    | NOX         | 611.52                | 536037   | SOIL TREAT VAPOR EXTRACT GASOLINE UNDER  | 8307 S LA CIENEGA BLVD      | INGLEWOOD      |
| 171246      | CIRCLE K STORES INC.                    | PM10        | 0                     | 536037   | SOIL TREAT VAPOR EXTRACT GASOLINE UNDER  | 8307 S LA CIENEGA BLVD      | INGLEWOOD      |
| 171976      | CALIBER COLLISION CENTER                | NOX         | 208                   | 540828   |  | 737 N LA BREA AVE           | INGLEWOOD      |
| 171976      | CALIBER COLLISION CENTER                | NOX         | 228.8                 | 540829   |  | 737 N LA BREA AVE           | INGLEWOOD      |
| 171976      | CALIBER COLLISION CENTER                | NOX         | 228.8                 | 540830   |  | 737 N LA BREA AVE           | INGLEWOOD      |
| 171976      | CALIBER COLLISION CENTER                | PM          | 1019.2                | 540048   |  | 737 N LA BREA AVE           | INGLEWOOD      |
| 171976      | CALIBER COLLISION CENTER                | PM          | 1019.2                | 540049   |  | 737 N LA BREA AVE           | INGLEWOOD      |
| 171976      | CALIBER COLLISION CENTER                | PM10        | 495.2                 | 540048   |  | 737 N LA BREA AVE           | INGLEWOOD      |
| 171976      | CALIBER COLLISION CENTER                | PM10        | 495.2                 | 540049   |  | 737 N LA BREA AVE           | INGLEWOOD      |
| 171976      | CALIBER COLLISION CENTER                | PM10        | 20.8                  | 540828   |  | 737 N LA BREA AVE           | INGLEWOOD      |
| 171985      | ORCHARD SUPPLY HARDWARE                 | NOX         | 63.13                 | 540077   | IC E (50-500 HP) EM ELEC GEN-DIESEL      | 19330 HAWTHORNE BLVD        | TORRANCE       |
| 171985      | ORCHARD SUPPLY HARDWARE                 | PM10        | 1.99                  | 540077   | IC E (50-500 HP) EM ELEC GEN-DIESEL      | 19330 HAWTHORNE BLVD        | TORRANCE       |
| 172056      | LAX AUTO BODY, INC.                     | PM          | 1019.2                | 540481   |  | 3348 W EL SEGUNDO BLVD      | HAWTHORNE      |
| 172056      | LAX AUTO BODY, INC.                     | PM          | 1019.2                | 540486   |  | 3348 W EL SEGUNDO BLVD      | HAWTHORNE      |
| 172056      | LAX AUTO BODY, INC.                     | PM10        | 499.2                 | 540481   |  | 3348 W EL SEGUNDO BLVD      | HAWTHORNE      |
| 172056      | LAX AUTO BODY, INC.                     | PM10        | 499.2                 | 540486   |  | 3348 W EL SEGUNDO BLVD      | HAWTHORNE      |
| 172230      | DTV                                     | NOX         | 589                   | 541122   | IC E (>500 HP) EM ELEC GEN DIESEL        | 2260 E IMPERIAL HWY         | EL SEGUNDO     |
| 172230      | DTV                                     | PM10        | 2                     | 541122   | IC E (>500 HP) EM ELEC GEN DIESEL        | 2260 E IMPERIAL HWY         | EL SEGUNDO     |
| 172294      | EUROTECH USA                            | PM10        | 561.6                 | 541546   |  | 3940 W EL SEGUNDO BLVD      | HAWTHORNE      |
| 172907      | GROS INVESTMENTS LOS ANGELES PROPERTIES | NOX         | 103                   | 544240   | IC E (50-500 HP) EM ELEC GEN-DIESEL      | 5521 GROSEVENOR BLVD        | LOS ANGELES    |
| 172907      | GROS INVESTMENTS LOS ANGELES PROPERTIES | PM10        | 3                     | 544240   | IC E (50-500 HP) EM ELEC GEN-DIESEL      | 5521 GROSEVENOR BLVD        | LOS ANGELES    |
| 172992      | USDA - APHIS                            | NOX         | 132.5                 | 544741   | IC E (50-500 HP) EM ELEC GEN-DIESEL      | 222 KANSAS ST               | EL SEGUNDO     |
| 172992      | USDA - APHIS                            | PM10        | 4.5                   | 544741   | IC E (50-500 HP) EM ELEC GEN-DIESEL      | 222 KANSAS ST               | EL SEGUNDO     |
| 800030      | CHEVRON PRODUCTS CO.                    | NOX         | 0                     | 479168   |  | 324 W EL SEGUNDO BLVD       | EL SEGUNDO     |
| 800030      | CHEVRON PRODUCTS CO.                    | NOX         | 262.08                | 302807   | SOIL TREAT VAPOR EXTRACT GASOLINE UNDER  | 324 W EL SEGUNDO BLVD       | EL SEGUNDO     |
| 800030      | CHEVRON PRODUCTS CO.                    | NOX         | 2467                  | 526609   |  | 324 W EL SEGUNDO BLVD       | EL SEGUNDO     |
| 800030      | CHEVRON PRODUCTS CO.                    | NOX         | 35555.52              | 527112   | HEATER/FURNACE (>50 MMBTU/HR) PROC GAS   | 324 W EL SEGUNDO BLVD       | EL SEGUNDO     |
| 800030      | CHEVRON PRODUCTS CO.                    | NOX         | 48921.6               | 445727   | HEATER/FURNACE (>50 MMBTU/HR)PROCESS GAS | 324 W EL SEGUNDO BLVD       | EL SEGUNDO     |
| 800030      | CHEVRON PRODUCTS CO.                    | NOX         | 51771.12              | 345241   | HEATER/FURNACE (>50 MMBTU/HR)PROCESS GAS | 324 W EL SEGUNDO BLVD       | EL SEGUNDO     |
| 800030      | CHEVRON PRODUCTS CO.                    | NOX         | 53813.76              | 445728   | HEATER/FURNACE (>50 MMBTU/HR)PROCESS GAS | 324 W EL SEGUNDO BLVD       | EL SEGUNDO     |

Table 3.1H-1, cont.

| Facility ID | Facility Name                   | Emittent ID | Emission Amt (lbs/yr) | Appl Nbr | Equipment (BCAT) Description             | loc Street Address    | loc City    |
|-------------|---------------------------------|-------------|-----------------------|----------|--|-----------------------|-------------|
| 800030      | CHEVRON PRODUCTS CO.            | NOX         | 69975.36              | 526607   | TURBINE ENGINE (<=50 MW) NAT & PROC GAS  | 324 W EL SEGUNDO BLVD | EL SEGUNDO  |
| 800030      | CHEVRON PRODUCTS CO.            | NOX         | 13228.17              | 521770   |  | 324 W EL SEGUNDO BLVD | EL SEGUNDO  |
| 800030      | CHEVRON PRODUCTS CO.            | NOX         | 127807.68             | 345242   | HEATER/FURNACE (>50 MMBTU/HR)PROCESS GAS | 324 W EL SEGUNDO BLVD | EL SEGUNDO  |
| 800030      | CHEVRON PRODUCTS CO.            | NOX         | 57771.68              | 513694   | FLUID CATALYTIC CRACKING EQUIPMENT       | 324 W EL SEGUNDO BLVD | EL SEGUNDO  |
| 800030      | CHEVRON PRODUCTS CO.            | PM          | 15                    | 302807   | SOIL TREAT VAPOR EXTRACT GASOLINE UNDER  | 324 W EL SEGUNDO BLVD | EL SEGUNDO  |
| 800030      | CHEVRON PRODUCTS CO.            | PM          | 34419.84              | 345241   | HEATER/FURNACE (>50 MMBTU/HR)PROCESS GAS | 324 W EL SEGUNDO BLVD | EL SEGUNDO  |
| 800030      | CHEVRON PRODUCTS CO.            | PM          | 57133.44              | 345242   | HEATER/FURNACE (>50 MMBTU/HR)PROCESS GAS | 324 W EL SEGUNDO BLVD | EL SEGUNDO  |
| 800030      | CHEVRON PRODUCTS CO.            | PM10        | 285                   | 388733   | DELAYED COKING UNIT                      | 324 W EL SEGUNDO BLVD | EL SEGUNDO  |
| 800030      | CHEVRON PRODUCTS CO.            | PM10        | 285                   | 527431   | DELAYED COKING UNIT                      | 324 W EL SEGUNDO BLVD | EL SEGUNDO  |
| 800030      | CHEVRON PRODUCTS CO.            | PM10        | 142                   | 526609   |  | 324 W EL SEGUNDO BLVD | EL SEGUNDO  |
| 800030      | CHEVRON PRODUCTS CO.            | PM10        | 42806.4               | 527112   | HEATER/FURNACE (>50 MMBTU/HR) PROC GAS   | 324 W EL SEGUNDO BLVD | EL SEGUNDO  |
| 800030      | CHEVRON PRODUCTS CO.            | PM10        | 10657.92              | 445727   | HEATER/FURNACE (>50 MMBTU/HR)PROCESS GAS | 324 W EL SEGUNDO BLVD | EL SEGUNDO  |
| 800030      | CHEVRON PRODUCTS CO.            | PM10        | 11706.24              | 445728   | HEATER/FURNACE (>50 MMBTU/HR)PROCESS GAS | 324 W EL SEGUNDO BLVD | EL SEGUNDO  |
| 800030      | CHEVRON PRODUCTS CO.            | PM10        | 0                     | 526607   | TURBINE ENGINE (<=50 MW) NAT & PROC GAS  | 324 W EL SEGUNDO BLVD | EL SEGUNDO  |
| 800030      | CHEVRON PRODUCTS CO.            | PM10        | 128.06                | 521770   |  | 324 W EL SEGUNDO BLVD | EL SEGUNDO  |
| 800030      | CHEVRON PRODUCTS CO.            | PM10        | 94348.8               | 513694   | FLUID CATALYTIC CRACKING EQUIPMENT       | 324 W EL SEGUNDO BLVD | EL SEGUNDO  |
| 800196      | AMERICAN AIRLINES INC (EIS USE) | NOX         | 1520                  | 539710   | I C E (>500 HP) EM ELEC GEN DIESEL       | 7260 WORLD WAY WEST   | LOS ANGELES |
| 800196      | AMERICAN AIRLINES INC (EIS USE) | PM10        | 9                     | 539710   | I C E (>500 HP) EM ELEC GEN DIESEL       | 7260 WORLD WAY WEST   | LOS ANGELES |

**Table 3.1H-2  
Basis for Excluding Permit Applications from Cumulative Impact Analysis**

| Plant  | Facility Name                            | Source Description                                       | Basis for exclusion       |
|--------|--|--|---------------------------|
| 4735   | REDONDO BEACH CITY                       | I C E (>500 HP) EM ELEC GEN DIESEL                       | Emissions < 5 TPY         |
| 5259   | NEUTROGENA CORP                          | PLASTIC/RESIN SIZE REDUCTION                             | Emissions < 5 TPY         |
| 8582   | SO CAL GAS CO/PLAYA DEL REY STORAGE FACI | I C E (>500 HP) N-EM STAT NAT GAS ONLY                   | Emergency Engines         |
| 8648   | MERLE NORMAN COSMETICS INC               |  | Emissions < 5 TPY         |
| 9755   | UNITED AIRLINES INC                      | I C E (50-500 HP) EM FIRE FGHT-DIESEL                    | Emissions < 5 TPY         |
| 10292  | THE AEROSPACE CORP UNIT NO.02            | BOILER (<5 MMBTU/HR) NAT GAS ONLY                        | Emissions < 5 TPY         |
| 13844  | CHROMPLATE COMPANY                       |  | Emissions < 5 TPY         |
| 15660  | QUALITY EQUIP RENTALS                    | SPACE HEATER, PORTABLE, <600,000BTU/HR, DIESEL/OIL FIRED | Emissions < 5 TPY         |
| 18294  | NORTHROP GRUMMAN CORP, AIRCRAFT DIV      | BOILER (5-20 MMBTU/HR) NAT GAS ONLY                      | Emissions < 5 TPY         |
| 20421  | BLUE DIAMOND INGLEWOOD ASPHALT CORP      | ASPHALT BLENDING/BATCHING EQUIPMENT                      | Emissions < 5 TPY         |
| 22312  | LA AIRPORT MARRIOTT HOTEL                | BOILER (5-20 MMBTU/HR) NAT GAS ONLY                      | Emissions < 5 TPY         |
| 42278  | THE AEROSPACE CORP, UNIT NO.04           | I C E (50-500 HP) EM ELEC GEN-DIESEL                     | Emissions < 5 TPY         |
| 44012  | GOODMAN FOOD PROD INC                    | OVEN, COOKING OR CURING                                  | Emissions < 5 TPY         |
| 48634  | HAWTHORNE HOSPITAL                       | I C E (50-500 HP) EM ELEC GEN-DIESEL                     | Emissions < 5 TPY         |
| 74693  | FEDERAL EXPRESS, LAX OPERATIONS          |  | Emissions < 5 TPY         |
| 89127  | TRI-STAR ELECTRONICS INTERNATIONAL INC   |  | Emissions < 5 TPY         |
| 94065  | WEST BASIN MUNICIPAL WATER DISTRICT      | STORAGE SILO LIME & LIMESTONE                            | Emissions < 5 TPY         |
| 101140 | JIM & JACK INC                           |  | Emissions < 5 TPY         |
| 104664 | ICC COLLISION CENTERS                    |  | Emissions < 5 TPY         |
| 106674 | CITY OF CULVER CITY, BRADDOCK LIFT STATI | I C E (50-500 HP) EM ELEC GEN-DIESEL                     | Emissions < 5 TPY         |
| 114997 | RAYTHEON COMPANY                         | I C E (50-500 HP) EM ELEC GEN-DIESEL                     | Emissions < 5 TPY         |
| 115536 | AES REDONDO BEACH, LLC                   | BOILER (< 2 mmbTU/HR) OIL FIRED                          | Emissions < 5 TPY         |
| 115663 | EL SEGUNDO POWER, LLC                    |  | Emissions < 5 TPY         |
| 135425 | SHERATON GATEWAY HOTEL- LAX              | BOILER (5-20 MMBTU/HR) NAT GAS ONLY                      | Emissions < 5 TPY         |
| 145747 | CROWNE PLAZA HOTEL                       | CHARBROILER - NATURAL GAS                                | Emissions < 5 TPY         |
| 145836 | AMERICAN APPAREL DYEING & FINISHING, INC |  | Emissions < 5 TPY         |
| 148236 | AIR LIQUIDE LARGE INDUSTRIES U.S., LP    | HYDROGEN PRODUCTION PLANT                                | Emission increase < 5 TPY |
| 148822 | CHEVRON CORPORATION                      | SOIL TREAT VAPOR EXTRACT GASOLINE UNDER                  | Emissions < 5 TPY         |
| 151346 | CALIFORNIA PORTLAND CEMENT CO            |  | Emissions < 5 TPY         |
| 154034 | CENTINELA HOSPITAL MEDICAL CENTER        | I C E (>500 HP) EM ELEC GEN DIESEL                       | Emissions < 5 TPY         |
| 155828 | GARRETT AVN. SVCS. LLC DBA STANDARD AERO | JET ENGINE TEST FACILITY OTHER FUEL                      | Emission increase < 5 TPY |

**Table 3.1H-2, cont.**

| Plant  | Facility Name                            | Source Description                      | Basis for exclusion |
|--------|--|---|---------------------|
| 157262 | EQUINIX OPERATING CO INC                 | I C E (>500 HP) EM ELEC GEN DIESEL      | Emissions < 5 TPY   |
| 159183 | ATC GROUP SERVICES, INC.                 | SOIL TREAT VAPOR EXTRACT GASOLINE UNDER | Emissions < 5 TPY   |
| 159714 | NANO H2O                                 |   | Emissions < 5 TPY   |
| 159986 | FREEMAN MEDICAL BUILDING, LLC            | I C E (>500 HP) EM ELEC GEN DIESEL      | Emissions < 5 TPY   |
| 161395 | ONE PERFECT LINE, LLC DBA SUPERBA COFFEE | Coffee Roasting (50-90 lb capacity)     | Emissions < 5 TPY   |
| 163088 | ARKEMA INC.                              | BOILER (5-20 MMBTU/HR) NAT GAS ONLY     | Emissions < 5 TPY   |
| 165079 | HAMID                                    |   | Emissions < 5 TPY   |
| 165227 | AIRPORT COURTHOUSE, JCC/AOC              | I C E (>500 HP) EM ELEC GEN DIESEL      | Emissions < 5 TPY   |
| 165231 | INGLEWOOD COURTHOUSE, JCC/AOC            | I C E (50-500 HP) EM FIRE FGHT-DIESEL   | Emissions < 5 TPY   |
| 166388 | DIGITAL 2260 EAST EL SEGUNDO, LLC        | I C E (>500 HP) EM ELEC GEN DIESEL      | Emissions < 5 TPY   |
| 166607 | J & J AUTO BODY SHOP                     |   | Emissions < 5 TPY   |
| 166664 | EVEN KEEL INDUSTRIES LLC                 |   | Emissions < 5 TPY   |
| 166890 | LIVING SPACES - REDONDO BEACH            | I C E (50-500 HP) EM ELEC GEN-DIESEL    | Emissions < 5 TPY   |
| 167007 | COOPERSMITH INC                          | I C E (50-500 HP) EM ELEC GEN-DIESEL    | Emissions < 5 TPY   |
| 167092 | EQUITY OFFICE PROPERTIES                 | I C E (50-500 HP) EM ELEC GEN-DIESEL    | Emissions < 5 TPY   |
| 167187 | CENTURY 1ST AUTO BODY & PAINT, INC.      |   | Emissions < 5 TPY   |
| 167389 | PRECISION COACHCRAFT                     |   | Emissions < 5 TPY   |
| 167598 | SPACE EXPLORATION TECHNOLOGIES           | OVEN, OTHER                             | Emissions < 5 TPY   |
| 167619 | CLEAN HARBORS ENVIRONMENTAL SERVICES     | BOILER < 2MM BTU/HR OIL-FIRED DIESEL    | Emissions < 5 TPY   |
| 167814 | TESLA MOTORS INC                         |   | Emissions < 5 TPY   |
| 167843 | CUSTOM HOTEL LLC                         | I C E (50-500 HP) EM ELEC GEN-DIESEL    | Emissions < 5 TPY   |
| 167899 | POWER COLLISION CENTER OF SOUTH BAY      |   | Emissions < 5 TPY   |
| 167899 | POWER COLLISION CENTER OF SOUTH BAY      |   | Emissions < 5 TPY   |
| 167921 | ASIANA AIRLINES                          | I C E (>500 HP) EM ELEC GEN DIESEL      | Emissions < 5 TPY   |
| 168483 | CITY OF HAWTHORNE, CA WATER SERVICE CO.  | STORAGE TANK W/ VAPOR CONTROL AMMONIA   | Emissions < 5 TPY   |
| 168764 | 44 LA WESTSIDE LESSEE, LLC               | I C E (50-500 HP) EM FIRE FGHT-DIESEL   | Emissions < 5 TPY   |
| 168811 | CLOUDBREAK, INGLEWOOD                    | I C E (50-500 HP) EM ELEC GEN-DIESEL    | Emissions < 5 TPY   |
| 168886 | FIRST CHURCH OF GOD OF LOS ANGELES       | I C E (>500 HP) EM ELEC GEN DIESEL      | Change of Operator  |
| 168983 | MARINA CARE CENTER                       | I C E (50-500 HP) EM ELEC GEN-DIESEL    | Emissions < 5 TPY   |
| 169168 | T5@ LOS ANGELES, LLC                     | I C E (>500 HP) EM ELEC GEN DIESEL      | Emergency Engine    |
| 169247 | INTERNAP REDONDO BEACH                   | I C E (>500 HP) EM ELEC GEN DIESEL      | Emissions < 5 TPY   |
| 169249 | UDR MARINA POINTE LLC, MARINA POINTE     | I C E (50-500 HP) EM ELEC GEN-DIESEL    | Emissions < 5 TPY   |
| 169382 | HANKEY INVESTMENT                        | I C E (50-500 HP) EM ELEC GEN-DIESEL    | Emissions < 5 TPY   |



**Table 3.1H-2, cont.**

| Plant  | Facility Name                           | Source Description                      | Basis for exclusion       |
|--------|---|---|---------------------------|
| 169616 | URS CORPORATION                         | SOIL TREAT VAPOR EXTRACT GASOLINE UNDER | Emissions < 5 TPY         |
| 169618 | TWC, INC.                               | I C E (>500 HP) EM ELEC GEN DIESEL      | Emissions < 5 TPY         |
| 169711 | PACIFIC-BIO MATERIAL MANAGEMENT, INC    | I C E (50-500 HP) EM ELEC GEN-DIESEL    | Emissions < 5 TPY         |
| 169732 | MERCURY GSE RON SPIEGEL                 |   | Emissions < 5 TPY         |
| 169795 | AUTO BODY PROS, INC                     |   | Emissions < 5 TPY         |
| 169902 | MARINA BUSINESS CENTER LLC              | I C E (>500 HP) EM ELEC GEN DIESEL      | Emissions < 5 TPY         |
| 170227 | QUANTIMETRIX CORPORATION                | I C E (50-500 HP) EM ELEC GEN-DIESEL    | Emissions < 5 TPY         |
| 170570 | STAMPS.COM, INC.                        | I C E (>500 HP) EM ELEC GEN DIESEL      | Emissions < 5 TPY         |
| 171160 | AEG DIGITAL MEDIA LLC                   | I C E (>500 HP) EM ELEC GEN-OIL         | Emissions < 5 TPY         |
| 171246 | CIRCLE K STORES INC.                    | SOIL TREAT VAPOR EXTRACT GASOLINE UNDER | Emissions < 5 TPY         |
| 171985 | ORCHARD SUPPLY HARDWARE                 | I C E (50-500 HP) EM ELEC GEN-DIESEL    | Emissions < 5 TPY         |
| 172056 | LAX AUTO BODY, INC.                     |   | Emissions < 5 TPY         |
| 172230 | DTV                                     | I C E (>500 HP) EM ELEC GEN DIESEL      | Emissions < 5 TPY         |
| 172294 | EUROTECH USA                            |   | Emissions < 5 TPY         |
| 172907 | GROS INVESTMENTS LOS ANGELES PROPERTIES | I C E (50-500 HP) EM ELEC GEN-DIESEL    | Emissions < 5 TPY         |
| 172992 | USDA - APHIS                            | I C E (50-500 HP) EM ELEC GEN-DIESEL    | Emissions < 5 TPY         |
| 800030 | CHEVRON PRODUCTS CO.                    |   | Emission increase < 5 TPY |
| 800196 | AMERICAN AIRLINES INC (EIS USE)         | I C E (>500 HP) EM ELEC GEN DIESEL      | Emissions < 5 TPY         |

**Appendix 3.8A**  
**Public Health Calculations and Support Data**

---