

CALIFORNIA ENERGY COMMISSION

1516 NINTH STREET
SACRAMENTO, CA 95814-5512
www.energy.ca.gov



April 20, 2009

Mr. David Warner
Director of Permit Services
San Joaquin Valley Air Pollution Control District
1990 E. Gettysburg Avenue
Fresno, California 93726-0244

DOCKET**01-EP-7C**DATE April 20 2009RECD. April 20 2009**Re: Comments on Preliminary Determination of Compliance
Hanford Combined-Cycle Power Plant Project (01-EP-07C)**

Dear Mr. Warner,

Energy Commission staff has reviewed the San Joaquin Valley Air Pollution Control District's Preliminary Determination of Compliance (P DOC) and has the following comment for your consideration for inclusion in the Final Determination of Compliance (FDOC).

Comments on FDOC Conditions

Gas Turbine Conditions 37, 42-44 – VOC Annual Emission Limit Compliance
The District has used, as proposed by the applicant, an average VOC emission concentration (0.8 ppm) that is lower than the short-term maximum BACT VOC emission concentration limit (2.0 ppm) to determine the annual VOC emissions. Currently, the District conditions do not identify how compliance with the annual VOC emission limit, based on the lower concentration value, will be demonstrated. Staff believes that a notation should be added to the annual emission Condition 37 or the source test Condition(s) 42-44 should be provided to note that the annual source test data will be used to show compliance with the annual VOC limit specified in Condition 37.

If you have any questions, please contact Keith Golden of my staff at (916) 653-1643. Thank you for the opportunity to comment on the Hanford Combined-Cycle Power Plant Project Preliminary Determination of Compliance.

Sincerely,

RICK YORK, Acting Manager
Environmental Protection Office
Siting, Transmission and Environmental
Protection Division

cc: Docket
Ron Yasny
POS