



**DOCKET**

**06-AFC-5C**

DATE 9/29/2009

RECD. 9/29/2009

980 Ninth Street, Suite 1900  
Sacramento, California 95814  
main 916.447.0700  
fax 916.447.4781  
www.stoel.com

September 29, 2009

MELISSA A. FOSTER  
Direct (916) 319-4673  
mafoster@stoel.com

**VIA HAND DELIVERY**

Mr. Dale Rundquist, Compliance Project Manager  
California Energy Commission  
1516 Ninth Street  
Sacramento, CA 95814

**Re: Panoche Energy Center (06-AFC-5C)  
Report of Waste Discharge**

Dear Mr. Rundquist:

On behalf of Panoche Energy Center, LLC, please find enclosed for docketing the Report of Waste Discharge ("ROWD") for the Panoche Energy Center. The ROWD was submitted to the Central Valley Regional Water Quality Control Board on or about September 21, 2009.

Should you have any questions, please do not hesitate to contact me at (916) 447-0700.

Very truly yours,

A handwritten signature in black ink, appearing to read "Melissa A. Foster".

Melissa A. Foster

MAF:kjh

Enclosures

cc: Dave Jenkins, Apex Power Group (w/out enclosure)  
Maggie Fitzgerald, URS Corporation (w/out enclosure)

A thick orange vertical bar is located on the left side of the page, partially overlapping the text area.

**REPORT OF WASTE DISCHARGE  
Unlined Wastewater Surface Impoundments  
Panoche Energy Center  
Fresno County, California**

**Prepared for:  
Panoche Energy Center, LLC**

**September 21, 2009**

**URS Corporation – Fresno, California**



September 21, 2009

Douglas K. Patteson  
Senior Water Resource Control Engineer  
Regional Water Quality Control Board  
1685 "E" Street  
Fresno, California 93707

**Re: Report of Waste Discharge  
Unlined Wastewater Surface Impoundments  
Panoche Energy Center  
Fresno County, California**


Dear Mr. Patteson:

URS Corporation (URS) prepared the enclosed Report of Waste Discharge on behalf of Panoche Energy Center, LLC (PECL, Client). Appended to the report is the completed Form 200 signed by an authorized PECL representative.

We look forward to working with you in obtaining Waste Discharge Requirements from your Board for the project. A Petition to Amend is being submitted concurrently to the California Energy Commission (CEC) to propose amending the CEC's Final Decision to allow for use of the planned unlined wastewater surface impoundments.

Please do not hesitate to contact us if you have any questions or comments, or need any additional information.

Sincerely,  
**URS Corporation**

  
Stuart B. St. Clair, PE  
Project Civil Engineer



Margaret M. Fitzgerald  
Program Manager

Enclosure

**Distribution List:**

- Douglas Patteson, RWQCB (1 bound original, 1 bound copy)
- Dale Rundquist, CEC (1 bound copy)
- Don Burkard, PECL (1 bound copy)
- David Jenkins, Apex Power Group (1 bound copy)
- Maggie Fitzgerald, URS, Santa Ana (1 bound copy)
- URS Fresno File (1 bound copy, 1 unbound copy)

URS Corporation  
30 River Park Place West, Suite 180  
Fresno, CA 93720  
Tel: 559.256.1444  
Fax: 559.256.1478

## TABLE OF CONTENTS

	<u>Page</u>
TABLE OF CONTENTS.....	i
1.0 INTRODUCTION.....	1
2.0 BACKGROUND INFORMATION.....	3
2.1 SITE LOCATION AND DESCRIPTION .....	3
2.2 VICINITY TOPOGRAPHY AND GEOLOGY .....	3
2.3 SITE HYDROGEOLOGY .....	3
2.4 SITE HYDROLOGY .....	5
3.0 FACILITY DESCRIPTION.....	6
4.0 PROPOSED WASTE DISCHARGE .....	7
4.1 LOCATION .....	7
4.2 VOLUME.....	7
4.3 CHARACTER .....	7
5.0 UWSI DESIGN AND CONSTRUCTION .....	8
6.0 UWSI POND OPERATION.....	9
7.0 ANTIDegradation ANALYSIS.....	10

### FIGURE

- 1 General Project Vicinity
- 2 Aerial of Immediate Project Vicinity
- 3 Project Site Plan
- 4 Grading and Drainage Plan

### TABLES

- 1 Baseline & Predicted Groundwater Quality

### APPENDICES

- A Completed, Signed Form 200
- B Groundwater Laboratory Reports
- C Water Balance
- D Groundwater Modeling Figures

**REPORT OF WASTE DISCHARGE**  
**Unlined Wastewater Surface Impoundments**  
**Panoche Energy Center**  
**Fresno County, California**

---

**1.0 INTRODUCTION**

URS Corporation (URS) prepared this Report of Waste Discharge (ROWD) for Panoche Energy Center, LLC (PECL, Client). PECL operates the Panoche Energy Center (PEC), which is a 400-megawatt electric generation facility in an unincorporated area of western Fresno County, California (Figures 1 and 2). The California Energy Commission (CEC) approved the PEC project with conditions in the Final Commission Decision dated December 19, 2007, which is available along with other pertinent documents at <http://www.energy.ca.gov/sitingcases/panoche>. The PEC attained full commercial status on July 1, 2009.

Wastewater from the PEC is currently discharged to four, onsite, Class 1, non-hazardous, deep injection wells under Permit Number CA10600001 issued by the United States Environmental Protection Agency, Region IX (USEPA) under the Underground Injection Control (UIC) Program. Each of the injection wells extends to a total depth of greater than 6,800 feet below ground surface (bgs). The wastewater-discharge capacity of the four injection wells has been found insufficient to handle the plant's full-load wastewater flow rate. While it is not clear why the injection wells have not achieved their predicted and designed functionality, their condition cannot be assured and they must be presumed to be unreliable in the future.

Due to the above circumstances, PECL conducted a careful evaluation of alternatives and is now urgently seeking approval for modifications to its operational effluent system. Specifically, PECL proposes to construct and operate unlined wastewater surface impoundments (UWSI). The purpose of this ROWD is to apply to the Regional Water Quality Control Board, Central Valley Region (RWQCB) for Waste Discharge Requirements (WDR) for the UWSI. A completed Form 200, signed by an authorized PECL representative, is provided in Appendix A. PECL is concurrently submitting a Petition to Amend (PTA) to the CEC for the proposed modifications to allow a better, permanent means of wastewater disposal. The PTA includes an extensive evaluation of wastewater-disposal alternatives and the environmental impacts of the proposed UWSI.

This ROWD pertains only to the wastewater generated by the PEC facility. Storm water management during construction and operation of the facility is not addressed by this ROWD. As required by CEC Condition of Certification SOIL & WATER-1, PECL will comply with the requirements of the General National Pollutant Discharge Elimination System (NPDES) permit for discharges of storm water associated with construction activity, and will develop and implement a storm water pollution prevention plan (SWPPP) for the construction of the UWSI. As required by CEC Condition of Certification SOIL & WATER-3, PECL will comply with the requirements of the general NPDES permit for discharges of storm water associated with industrial activity, and will develop and implement a SWPPP for the operation of the facility.

The remainder of this ROWD is organized as follows:

- Background information is provided in Section 2.0.
- A description of the facility is provided in Section 3.0.
- A description of the proposed waste discharge is provided in Section 4.0.
- UWSI design and construction are provided in Section 5.0.
- Operation of the UWSI is discussed in Section 6.0.
- An antidegradation analysis is presented in Section 7.0.
- Figures, tables, and appendices appear after Section 7.0.

## **2.0 BACKGROUND INFORMATION**

Background information regarding the facility site is provided below. Much of this information was obtained from the Application for Certification that was submitted to the CEC in August 2006.

### **2.1 SITE LOCATION AND DESCRIPTION**

The PEC is situated on approximately 12.82 acres of land within a 128-acre parcel. The proposed UWSI would be located on an additional 9.18 acres of land, which are immediately south of the 12.8 acres and are within the same parcel. The PEC is in the unincorporated area of western Fresno County, about 13 miles southwest of the City of Mendota (Figures 1 and 2). The site is on the south side of West Panoche Road, about 2.5 miles northeast of Interstate Highway 5. The site is in the southwest quarter of Section 5, Township 15 South, Range 13 East, Mount Diablo Base and Meridian. The Assessor's Parcel Number for the site and the approximate latitude/longitude of the proposed UWSI are provided on the Form 200 in Appendix A.

The site is owned by PAO Investments, LLC (PAO). PECL has entered an agreement with PAO whereby PECL will purchase the site prior to construction of the UWSI.

7.18 acres of the proposed UWSI area were used as an equipment/materials laydown area during construction of the PEC. The additional 2 acres for the UWSI is existing pomegranate orchard that will be cleared. The existing Pacific Gas & Electric Co. (PG&E) electrical substation is immediately northeast of the site (Figure 2). East of the PG&E substation are three existing "peaking" power plants (Calpeak Panoche, Starwood Midway, and Wellhead). Otherwise, area land use is primarily cropland (e.g., pomegranates, almonds, vineyards) with a few rural residences and farm buildings. The nearest residence is located about 1.5 miles northeast of the PEC site.

### **2.2 VICINITY TOPOGRAPHY AND GEOLOGY**

The vicinity topography is generally flat, sloping gently downward to the northeast. The average ground surface elevation at the site is approximately 415 feet above mean sea level (amsl).

The site is located in the western San Joaquin Valley, which is part of California's Central Valley. The site is located southeast of Panoche Creek on the Panoche Creek alluvial fan. The site is situated on a thick section of Quaternary surficial sediments and older alluvium underlain by Tertiary sediments, Cretaceous marine deposits, and pre-Tertiary basement rocks.

### **2.3 SITE HYDROGEOLOGY**

The Corcoran Clay is an extensive diatomaceous-lacustrine clay deposit of low permeability that divides the groundwater flow system into an upper semiconfined aquifer and a lower confined aquifer. The vertical gradient between the two aquifers is typically downward. The lower confined aquifer typically has substantially better quality groundwater than the upper semiconfined aquifer.



The Corcoran Clay was encountered in an onsite, confined-aquifer, monitoring-well boring at the depth interval of approximately 650 to 760 feet bgs.

An onsite groundwater monitoring well (MW-4) was completed in July 2009 in the semi-confined aquifer with a screened interval extending from about 150 to 210 feet bgs. First-encountered groundwater was present at approximately 170 feet bgs. Four groundwater samples were collected from the well in July and August 2009 and analyzed for metals and minerals. Laboratory reports are provided in Appendix B. The analytical results are summarized on Table 1, along with applicable water quality objectives (WQOs) found in the Water Quality Control Plan for the Tulare Lake Basin (Basin Plan). The analytical results for the first-encountered groundwater indicate that many of the semi-confined aquifer background groundwater concentrations substantially exceed the municipal and/or agricultural WQOs in the Basin Plan.

For example, regarding municipal WQOs, the first-encountered groundwater contains:

- Nitrate concentration of about 393 milligrams per liter (mg/l), which is more than eight times the primary Maximum Contaminant Level (MCL) of 45 mg/l.
- Arsenic concentration of about 24 micrograms per liter (ug/l), which is more than twice the primary MCL of 10 ug/l.
- Selenium concentration of about 495 ug/l, which is more than nine times the primary MCL of 50 ug/l.
- TDS concentration of about 4,500 mg/l, which is more than four times the upper secondary MCL of 1,000 mg/l.
- Sulfate concentration of about 2,200 mg/l, which is more than four times the upper secondary MCL of 500 mg/l.

Regarding agricultural WQOs, the first encountered groundwater contains:

- TDS concentration of about 4,500 mg/l, which is more than twice the level of 2,000 mg/l, which is considered to be severely restricted for irrigation use (FAO Publication 29).
- Chloride concentration of about 403 mg/l, whereas the most sensitive crops show chloride impacts at a concentration of about 100 mg/l, and many crops, including grapes which are grown in the PEC vicinity, show impacts at a concentration of 250 mg/l.
- Boron concentration of about 3,230 ug/l, whereas the most sensitive crops, including grapes which are grown in the PEC vicinity, show boron impacts at concentrations of about 500 ug/l, and many crops show impacts at concentrations of 2,000 ug/l.
- Selenium concentration of about 495 ug/l, which is more than 24 times the FAO-recommended maximum irrigation-water concentration of 20 ug/l.

Thus, multiple constituents in the existing groundwater render the semi-confined aquifer unusable for municipal and agricultural purposes, unless the water is first treated to remove these constituents.

A few widely spaced irrigation wells are present in the general vicinity of PEC. Newer irrigation wells are supposed to be screened exclusively in the confined aquifer; older wells may be screened and/or



filter-packed across both aquifers. Local farmers use these wells when they are unable to obtain surface water for irrigation. The local farmers purposely do not have wells screened exclusively in the semi-confined aquifer, because groundwater from the semi-confined aquifer is detrimental to their crops.

Only two supply wells in the plant vicinity are known to be screened within the semi-confined aquifer. These are emergency backup supply wells for the Calpeak-Panoche and Starwood-Midway peaker power plants, located about 1,000 and 1,500 feet, respectively, northeast of PEC. The Starwood-Midway well is known to be screened from 400 to 500 feet bgs. The Calpeak-Panoche well is known to be 500 feet deep, and the top of the screen is assumed to be at a similar depth as the Starwood-Midway well, based on reported analytical results. Both of these plants have demineralizing water-treatment systems that would be used to treat the groundwater before use. The Calpeak-Panoche plant normally gets its source water by truck provided by a local farmer from either his surface water supply or his irrigation wells. The Starwood-Midway plant normally gets its source water by pipeline from a local farmer's surface water supply (sediment-filter backwash water).

## **2.4 SITE HYDROLOGY**

The climate in the site vicinity is semi-arid, with long, hot, dry summers and mild winters. The average annual precipitation at the Five Points SSW weather station, located about 35 miles south of the site, is 6.92 inches, based on 58 years of data. The 100-year, 24-hour precipitation event at the site is estimated to be approximately 2.5 inches.

The average annual evaporation at the Little Panoche Detention Dam, located about 15 miles northwest of the site is 111 inches, based on 8 years of data. The average annual evaporation at the Los Banos Detention Reservoir, located about 30 miles northwest of the site is 108 inches, based on 38 years of data.

Except for agricultural impoundments and canals, the nearest natural or man-made surface water bodies to the site are Panoche Creek, located about 1.8 miles northwest of the site, and the California Aqueduct located about 2.6 miles northeast of the site.

According to the Federal Emergency Management Agency (FEMA), the site is outside the 500-year flood zone.

Based on the results of onsite percolation testing and geotechnical engineering analysis, it appears that soils in the proposed UWSI area are capable of supporting a long-term percolation rate of approximately 2 inches per day.

### 3.0 FACILITY DESCRIPTION

PEC uses four inter-cooled, natural-gas-fired, combustion turbine generators (CTGs) to provide up to 400 megawatts of much-needed electricity to power-consumers in California. A site plan of the facility is provided as Figure 3. The CTGs employ the latest-generation technology, enabling greater efficiency of power production using less natural gas and producing substantially less NO<sub>x</sub> and greenhouse gas emissions than previous CTG designs. This technology, known as “inter-coolers,” reduces temperatures in the combustion passes in the CTG. The use of air-cooled inter-coolers was considered by PEC, but the water-cooled design was chosen due to its superior energy efficiency over the air-cooled design.

The PEC is designed for cyclic applications with 10-minute starts to provide clean, flexible power generation for peaking and intermediate needs. It enables the electrical grid’s reliance on renewable energy sources, namely, wind and solar, by meeting instantaneous variations in those sources’ electrical output. The plant is expected to operate up to 5,000 hours per year (in contrast to typical “peaking plants” that operate less than 500 hours per year). This level of power generation would supply enough electricity for roughly 300,000 homes and one million people in California.

PEC process water is provided from two on-site supply wells that are screened exclusively in the confined-aquifer zone below the Corcoran Clay. A water flow diagram is provided in Appendix C. Process water uses include fire-protection water, plant service water, sanitary water, cooling tower makeup, combustion turbine NO<sub>x</sub> injection (treated water), and combustion turbine inlet air evaporative cooler makeup (partly from treated water). Water treatment for a portion of the process water will consist of a two-stage, reverse osmosis (RO) system, followed by trailer-mounted demineralizers that are regenerated off-site. Almost all of the RO-reject water will result from treatment of water for use in highly reducing the NO<sub>x</sub> air emissions from the plant. To conserve water, reject from the second-stage RO unit will be recycled as influent to the first-stage unit.

## **4.0 PROPOSED WASTE DISCHARGE**

As shown in Appendix C, PEC wastewater will consist of approximately 74-percent cooling-tower blowdown, 25-percent RO reject, and 1-percent oil/water separator effluent (the influent to the oil/water separator is plant washdown water that is not treated in the RO system prior to use and ultrafiltration system backwash water). The location, volume, and character of the wastewater discharge are discussed below.

### **4.1 LOCATION**

The UWSI will be located immediately south of the CTGs and associated equipment (Figure 3). The approximate latitude and longitude of the UWSI are provided on the Form 200 in Appendix A.

### **4.2 VOLUME**

For 5,000 hours of operation, the plant is anticipated to produce at maximum approximately 387 acre-feet per year (afy) of wastewater that requires disposal. The second page of the Water Balance in Appendix C quantifies the plant's anticipated maximum water and wastewater flows. These flows assume that the plant would operate at full-load for the full 5,000 hours of operation. In practice, however, the plant would almost certainly not operate at full load for the full 5,000 hours. Therefore, the annual maximum wastewater volume of 387 afy is a very conservative upper estimate.

It is anticipated that the injection wells' discharge capacity will decrease with time. Therefore, PECL desires that the WDR allow for discharge of all of the plant's wastewater to the UWSI. Upon finalization of the WDR, PECL may decide to discontinue use of the injection wells, or may decide to keep the injection wells for use only as a backup option in case discharge to the UWSI is temporarily unavailable due to maintenance or other reasons.

### **4.3 CHARACTER**

The estimated quality of the wastewater to be discharged to the pond is provided on the final column (Stream V) of the third page of the Water Balance in Appendix C. The estimated TDS concentration for the wastewater is 4,247 mg/L. Estimated concentrations for specific constituents are provided in Appendix C.

## 5.0 UWSI DESIGN AND CONSTRUCTION

PECL proposes to use two smaller UWSI rather than a single large UWSI to afford good maintenance practices. A conceptual grading and drainage plan for the UWSI is provided as Figure 4. Wastewater collected in the plant's wastewater storage tank will be conveyed by a pipeline to the UWSI for evaporation and percolation. The overall depth of the UWSI will be approximately 6 feet. The pond will be constructed by a cut-and-fill operation using mechanical excavators. Where fill material is required at the edges of the pond, the fill material will be placed in layers of uniform, specified thickness and compacted to at least 85-percent of the maximum dry density as determined by American Society for Testing and Materials (ASTM) Standard D-1557. Field density tests during construction will verify that the compaction standard is met. Extra excavated soil that is not needed to raise the edges of the pond will be used as fill material to raise other areas of the site, or will be discarded appropriately offsite.

The areas of the two UWSI will be approximately 2.90 and 2.93 acres, respectively, for a combined area of approximately 5.83 acres (Figure 4). Based on a long-term percolation rate of 2 inches per day, this pond area should be capable of percolating up to approximately 355 afy. The maximum wastewater production is estimated at 387 afy. Assuming that at least 10-percent of the wastewater in the UWSI would evaporate, the sizes of the two proposed UWSI appear capable of handling the annual maximum wastewater volume.

According to the Federal Emergency Management Agency (FEMA), the site is outside the 500-year flood plain. The UWSI will be designed, operated, and maintained in conformance with Fresno County Ordinance Title 15, Flood Hazard Areas to ensure that in the event of a 100-year storm, the UWSI are not subjected to any flood damage, inundation, or washout.

## 6.0 UWSI OPERATION

Wastewater will be discharged to the UWSI relatively continuously during and after periods when PEC is generating electricity. The water level in the UWSI will be maintained at least two feet below the top of the UWSI at all times. If one of the UWSI requires maintenance, such as grading to restore percolation capacity, wastewater will be discharged only to the other UWSI until the one requiring maintenance has dried sufficiently.

## 7.0 ANTIDegradation ANALYSIS

PEC prepared this Antidegradation Analysis to evaluate the potential discharge to surface impoundments in light of State Water Resources Control Board (SWRCB) Resolution Number 68-16, Statement of Policy with Respect to Maintaining High Quality of Waters in California (Resolution). The Resolution directs that “existing high quality [water] will be maintained until it has been demonstrated to the State that any change will be consistent with maximum benefit to the people of the State, will not unreasonably affect present and anticipated beneficial use of such water and will not result in water quality less than that prescribed in [State] policies” (emphasis added). The Resolution also directs that any activities that result in discharges to “existing high quality waters” are required to use “the best practicable treatment or control of the discharge necessary to assure that (a) a pollution or nuisance will not occur and (b) the highest water quality consistent with maximum benefit to the people of the State will be maintained.”

The analysis herein demonstrates that groundwater in the upper semi-confined aquifer is not a “high quality” water and is not known to be used within several miles of the PEC facility, except for two emergency-backup supply wells. These wells serve two nearby peaking powerplants, but significant demineralization of the groundwater is needed prior to its use at those facilities. Vicinity irrigation wells are typically completed in the lower confined aquifer, because groundwater from the semi-confined aquifer is too salty for crops. PEC’s proposed discharge of the facility’s wastewater to two on-site, unlined surface impoundments will not unreasonably affect present or anticipated future beneficial uses of groundwater in the upper semi-confined aquifer.

### **Wastewater Disposal Alternatives**

Following is a summary of the wastewater disposal alternatives that are analyzed in greater detail in the PTA:

- Pumping or trucking wastewater to a publicly-owner wastewater treatment plant (WWTP)
- Discharging wastewater to a brine line to Pacific Ocean
- Adding injection wells
- Changing the production water source – (i.e., WWTP effluent, aqueduct water, agricultural irrigation tail water)
- Discharging to a nearby water body
- Regenerating deionizer systems offsite
- Zero liquid discharge (ZLD)
- Double-lined evaporation pond(s)
- Onsite unlined wastewater surface impoundments (UWSI)

Of these alternatives, the use of onsite UWSI was found to be feasible and to afford the best balance between minimizing environmental impacts and optimizing energy efficiency, reliability and availability.



## **Fate & Transport Analysis**

PEC performed vadose-zone geochemical modeling and groundwater modeling to estimate the potential impact of discharging the plant's wastewater to UWSI. The vadose-zone geochemical modeling used the PHREEQC software program to analyze potential geochemical reactions including complexation, cation-exchange, dissolution/precipitation, and oxidation-reduction processes. Chemical adsorption and desorption were not included in the model, because over the 20-year projected life of the project they would not likely be a substantial factor. Varied ranges of acidity (pH between 4.0 and 8.2) and oxidation-reduction potential (eH between 4 and 8 millivolts) were modeled.

The modeling results indicate that there may be some short-term dissolution of minerals from the vadose-zone materials into the percolating wastewater. However, the modeling indicates that, over the long term, such dissolution should be relatively minimal. The results also indicate that there are several solid phases which potentially may precipitate from the percolating wastewater within the vadose zone. However, the mineral concentrations in the wastewater are not great enough to assure to a reasonable likelihood that such precipitation will in fact occur. Based on these results, it was judged reasonably conservative to assume for the groundwater modeling that the percolated wastewater at the bottom of the vadose zone will have the same chemical concentrations as at the ground surface.

The groundwater modeling used the MODFLOW software program to estimate the steady-state groundwater flow condition with the added recharge from the surface impoundments. Hydrogeologic parameters published by USGS for the semi-confined aquifer in the plant vicinity were used in the model. The transport model MT3D was used to estimate the advective/dispersive transport of dissolved chemical constituents in the semi-confined aquifer for a 20-year period after the surface-impoundment recharge begins mixing in with groundwater. Groundwater modeling figures are provided in Appendix D. The first three pages of the groundwater modeling figures illustrate the model discretization, key parameters, and predicted steady-state potentiometric surface contours after recharge begins. The surface impoundments are predicted to cause a moderate mounding of groundwater with a maximum increase in the water-table elevation of about 32 feet directly below the center of the impoundments, decreasing to a 20-foot increase at the edge of the impoundment, and decreasing further moving laterally away from the impoundment.

The mixing of percolated wastewater and native groundwater in the semi-confined aquifer was modeled using TDS as an indicator parameter. Pages 4 and 5 of the groundwater modeling figures show a cross-section view and plan view, respectively, of predicted TDS concentrations in the semi-confined aquifer at a simulated time of 20 years after the surface-impoundment recharge begins mixing in with groundwater. Since the wastewater is predicted to have a lesser TDS concentration than the baseline groundwater, the simulated TDS concentrations within the volume of groundwater affected by the recharge are lesser than the baseline value by up to 5.6 percent. Similarly, several other constituents such as calcium, magnesium, chloride, and nitrate are also predicted to have lesser than baseline concentrations within the volume of affected groundwater. Thus, the discharge will substantially improve the groundwater quality for these constituents. Some constituents such as sodium, sulfate, and silica are predicted to have greater than baseline concentrations within the volume of affected groundwater. This volume after 20 years of discharge is predicted to extend about 5,800 feet downgradient of the surface impoundment and 240 feet vertically below the water table – this



prediction is highly conservative in that it assumes that the plant would operate for 5,000 hours at maximum load per year for 20 years. Predicted maximum concentrations within this volume of groundwater are presented in Column J of Table 1.

For modeling purposes, two hypothetical wells (Wells A and B) were placed in the model at the downgradient edge of the surface impoundment. Well A was screened in the model from a depth of 400 to 500 feet bgs, which is consistent with the only known supply wells in the semi-confined aquifer within the facility vicinity. Any future wells would likely be screened at a similar depth to take advantage of the better water quality and production in the lower portion of the semi-confined aquifer. To provide a more conservative estimate of potential impacts to future supply wells, Well B was screened in the model from a depth of 300 to 500 feet bgs. Page 6 of the groundwater modeling figures provides a time-concentration graph for predicted TDS concentrations in these two wells. The results indicate that the TDS concentration in Well A would be virtually unchanged after 20 years of the proposed discharge, and in Well B would decrease about 1 percent from 4,470 mg/l to about 4,420 mg/l.

### Analysis of Wastewater Constituents

Overall, the PEC discharge is predicted to cause a decrease in groundwater TDS concentrations and in concentrations of constituents such as calcium, magnesium, chloride, and nitrate. There are seven constituents, however, for which the predicted maximum concentrations within the volume of affected groundwater are greater than the baseline groundwater concentration and are also greater than the municipal and/or agricultural WQOs. These constituents are discussed in turn below:

- **Arsenic.** The background arsenic concentration is approximately 24 micrograms per liter (ug/l). The municipal WQO is 10 ug/l. The agricultural WQO is 100 ug/l. The predicted maximum groundwater concentration after PEC's proposed discharge is 94 ug/l. Since the background concentration is already greater than the municipal WQO, and since the discharge is not predicted to cause the groundwater concentration to exceed the agricultural WQO, the discharge will cause no further WQO exceedances. In terms of potential municipal uses, arsenic removal would be required even for the background groundwater. If the discharge occurred as proposed, the overall level of required water treatment would very likely decrease due to the substantial concentration decreases in other constituents such as nitrate and selenium.
- **Boron.** The background groundwater boron concentration is approximately 3,225 ug/l. There is no municipal WQO for boron, and the agricultural WQO based on actual crops in the PEC vicinity is 500 ug/l. The predicted maximum groundwater concentration of boron after PEC's proposed discharge is 10,600 ug/l. In terms of potential agricultural uses, boron removal would be required even for the background groundwater, because the background concentration of 3,225 ug/l is substantially greater than agricultural WQO of 500 ug/l. If the discharge occurred, the overall level of required water treatment would likely change very little because selenium is present in the background groundwater at a greater multiple of its agricultural WQO than would be the case for boron after discharge.

- **Fluoride.** The background fluoride concentration is approximately 0.07 mg/l. The municipal WQO is 2.0 mg/l. The agricultural WQO is 1.0 mg/l. The predicted maximum groundwater concentration after discharge is 1.24 mg/l. In terms of potential agricultural uses, if the discharge occurred, the overall level of required water treatment would likely change very little because another constituent, selenium, is present in the background groundwater at a greater multiple of its agricultural WQO than would be the case for fluoride after discharge.
- **Manganese.** The background manganese concentration is less than 10 ug/l. The municipal WQO is 50 ug/l, based on a secondary MCL due to taste and odor concerns, not on a primary MCL. The agricultural WQO is 200 ug/l. The predicted maximum groundwater concentration after discharge is 160 ug/l. In terms of potential municipal uses, if the discharge occurred, the overall level of required water treatment prior to municipal use would very likely decrease due to the substantial concentration decreases in other constituents such as nitrate and selenium.
- **Molybdenum.** The background molybdenum concentration is less than 10 ug/l. There is no municipal WQO. The agricultural WQO is 10 ug/l. The predicted maximum groundwater concentration after discharge is 154 ug/l in the affected portion of the semi-confined aquifer. In terms of potential agricultural uses, if the discharge occurred, the overall level of required water treatment would likely change very little because another constituent, selenium, is present in the background groundwater at a greater multiple of its agricultural WQO than would be the case for molybdenum after discharge.
- **Sodium.** The background sodium concentration is approximately 528 mg/l. There is no municipal WQO. The agricultural WQO is nominally 69 mg/l. The predicted maximum groundwater concentration after discharge is 1,330 mg/l. In terms of potential agricultural uses, if the discharge occurred, the overall level of required water treatment would likely change very little because another constituent, selenium, is present in the background groundwater at a greater multiple of its agricultural WQO than would be the case for sodium after discharge.
- **Sulfate.** The background sulfate concentration is approximately 2,200 mg/l. The municipal WQO is 500 mg/l. There is no agricultural WQO. The predicted maximum groundwater concentration after discharge is 2,380 mg/l. Since the background concentration is already greater than the municipal WQO, and since there is no agricultural WQO, the discharge will not cause further WQO exceedances. In terms of potential municipal uses, sulfate removal would be required even for the background groundwater. If the proposed discharge occurred, the overall level of required water treatment would very likely decrease due to the substantial concentration decreases in other constituents such as nitrate and selenium.

In summary, the discharge is predicted to cause only one new exceedance of a municipal WQO (for manganese, and that WQO is based only on a secondary MCL) and only two new exceedances of agricultural WQOs (for fluoride and molybdenum). The discharge is predicted to cause four other constituents (arsenic, boron, sodium, and sulfate) to exceed municipal or agricultural WQOs by a somewhat greater margin than the background groundwater already exceeds the WQOs. In terms of both potential municipal or agricultural uses, however, water treatment would be required even for the background groundwater. If the proposed discharge to UWSI occurred, the overall level of required

water treatment would likely change very little or actually decrease due to the substantial concentration decreases in other constituents such as TDS, chloride, nitrate, selenium, and strontium. Further, the scope of effect on new treatment requirements is limited by the fact that only a small portion of the aquifer is so affected.

## **Conclusions**

The PEC provides substantial benefits to power-consumers in California by employing very high-efficiency CTGs to produce much-needed electricity with significantly lower environmental impacts than previous-generation CTGs. The water-treatment system includes internal recycling to minimize the amount of source water required, and most of the treated water is devoted to NO<sub>x</sub> control.

Unfortunately, existing deep injection wells do not appear capable of handling the volume of wastewater that may be produced by the plant during peak operations. The only other alternative that appears reasonably feasible is discharge to on-site UWSI.

The groundwater in the semi-confined aquifer is of extremely poor quality with several minerals and metals at background concentrations that substantially exceed WQOs. Without treatment, this groundwater is unsuitable for beneficial uses. This is validated by the fact that this water source has not historically been used, nor is it presently used, for potable or agricultural purposes. The only two known supply wells in the plant vicinity that are screened in the semi-confined aquifer are screened relatively deep (400 to 500 feet bgs) to take advantage of somewhat-better water quality and production. Further, these wells are solely emergency backup supply wells connected to demineralizing water treatment systems at nearby peaking powerplants. Future supply wells screened in the semi-confined aquifer are considered unlikely given the poor groundwater quality, but if installed, would likely be screened relatively deep similar to these two existing wells.


The wastewater discharge to UWSI is unlikely to affect the usability of the groundwater. The baseline groundwater requires treatment for almost any conceivable use. The affected volume of groundwater will also require treatment for almost any conceivable use. However, treatment of the affected volume of groundwater will be easier than treatment of the baseline groundwater, because the affected volume will have a lower TDS concentration than the baseline groundwater.

Overall, the proposed discharge to two U would have - at worst - only a relatively minimal impact on the current and future usability of groundwater. The existing groundwater in the semi-confined aquifer is not a "high quality" water that is to be maintained under SWRCB Resolution Number 68-16. The proposed discharge would not unreasonably affect present and anticipated beneficial uses of the groundwater, because the groundwater will require treatment for almost any conceivable use regardless of whether the discharge occurs. If the discharge does occur, the level of required treatment will likely be less than without the proposed discharge, because the concentration of TDS and other constituents in the groundwater for which extensive treatment is required will be less than background levels of such constituents. Moreover, any potential minimal impact is overcome by the increased overall benefit to the people of California that the use of the two surface impoundments would provide.


Notwithstanding the foregoing, if the semi-confined aquifer is considered a “high quality water,” no treatment method exists to make salts disappear – any treatment method will only cause the salts to be concentrated into a smaller volume. However, the analysis summarized herein indicates that the proposed discharge would not create a condition of pollution or nuisance, and would maintain the highest water quality consistent with maximum benefit to the people of the State. The best practicable control method for the discharge appears to be a wastewater and groundwater monitoring program to verify the quantity/quality of the discharged wastewater and to assess whether impacts to groundwater are relatively similar to the predicted impacts.

Based on the information provided herein, any de minimus groundwater degradation from the proposed PEC unlined wastewater surface impoundments is in the best interest of, and is consistent with, the maximum benefit to the citizens of the State of California. Operation of PEC will supply a cleaner, more reliable electrical supply to the State during periods of intermediate and peak use, PEC provides increased employment in the area, and any groundwater degradation anticipated by constituents such as fluoride, manganese, and molybdenum is de minimus compared to the anticipated improvement of groundwater quality by constituents such as calcium, magnesium, chloride, and nitrate. Moreover, the proposed discharge will not unreasonably affect present and anticipated future beneficial uses of the upper semi-confined aquifer.





Chounet Ranch\* | Chaney Ranch\*  
Tumey Hills\* | Monocline Ridge\*



**Legend**  
 [Symbol] \* 7.5 Minute USGS Quad Index  
 Source: USGS Topographic Quadrangles (GlobeExplorer 2006)  
 1:24,000 (Chaney Ranch (1971), Chounet Ranch (1971),  
 Monocline Ridge (1971) and Tumey Hills (1971))








©Panoche Energy Center, LLC. All rights reserved. 2. Area of Immediate Project Vicinity





C:\panoche\_sdm\CDM\CDM\_August09\Figures 3 Project Site Plan.mxd



PANOCH ENERGY CENTER, LLC	Figure 3 PROJECT SITE PLAN	2009
---------------------------	----------------------------	------





C:\Projects\BANCARD\Appendix\Fig 4 Grading and Drainage Plan.mxd

A	B	C	D	E	F	G	H	I	J	K	L	M	
1	TABLE 1	BASELINE & PREDICTED GROUNDWATER QUALITY											
2	Panoche Energy Center												
3	26-Aug-09												
4	Panoche Energy Center*												
5	RWQCB Water Quality Objectives (WQOs)												
6	Receiving Groundwater Quality Estimates												
7	Parameter	Units	MW-4 7/16/09 (LF)	MW-4 7/16/09 (LF)	MW-4 8/7/09 (FF)	MW-4 8/7/09 (LF)	Average**	Municipal	Agricultural	Predicted Maximum Concentration in First Groundwater Downgradient of the Pond***	Concentration Greater Than Baseline Concentration?	Concentration Greater Than WQO(s) ?	Baseline Concentration Was Already Greater Than WQO(s) ?
8	Calcium	mg/L	360	380	440	440	405	n/a	n/a	48			
9	Magnesium	mg/L	280	300	340	340	313	n/a	n/a	12			
10	Sodium	mg/L	510	500	560	540	528	n/a	69	1,330	Yes	Yes	Yes
11	Potassium	mg/L	10	10	12	11	11	n/a	n/a	8.0			
12	Sulfate	mg/L	2,000	2,100	2,300	2,400	2,200	250 - 500	n/a	2,380	Yes	Yes	Yes
13	Chloride	mg/L	360	360	450	440	403	250 - 500	250	302			
14	Nitrate	mg/L	360	370	420	420	393	45	n/a	<10			
15	Silica (SiO2)	mg/L	45	47	47	45	46	n/a	n/a	157	Yes		
16	Bicarbonate (as CaCO3)	mg/L	130	140	130	130	133	n/a	n/a	150	Yes		
17	Total Dissolved Solids	mg/L	4,300	4,000	4,800	4,900	4,500	500 - 1,000	450 - 2,000	4,250			
18	pH	std.	7.9	7.9	7.9	7.9	7.9	6.5 - 8.5	6.5 - 8.4	8.0			
19	Fluoride	mg/L	0.26	0.32	0.32	0.30	0.30	2.0	1.0	1.24	Yes	Yes	
20	Ammonia	mg/L	<0.1	<0.1	0.12	<0.1	0.07	1.5	n/a	1.1	Yes	Yes	
21	Trace Metals -- Dissolved												
22	Aluminum	ug/L	<50	<50	<50	<50	<50	1,000	5,000	<50			
23	Antimony	ug/L	<2	<2	<2	<2	<2	6	n/a	<2			
24	Arsenic	ug/L	18	21	32	26	24	10	100	94	Yes	Yes	Yes
25	Barium	ug/L	<50	<50	<50	<50	<50	1,000	n/a	<50			
26	Beryllium	ug/L	<1	<1	<1	<1	<1	4	100	<1			
27	Boron	ug/L	3,200	3,300	3,200	3,225	3,225	n/a	500	10,600	Yes	Yes	Yes
28	Cadmium	ug/L	<1	<1	<1	<1	<1	5	10	<1			
29	Chromium -- Total	ug/L	21	20	19	14	19	50	100	<10			
30	Copper	ug/L	<50	<50	<50	<50	<50	1,000	200	<50			
31	Cyanide	ug/L	<20	<20	<10	<10	<15	150	n/a	<10			
32	Iron	ug/L	<50	<50	<50	<50	<50	300	5,000	238	Yes	Yes	
33	Lead	ug/L	<5	<5	<5	<5	<5	15	5,000	<5			
34	Manganese	ug/L	<10	<10	<10	<10	<10	50	200	160	Yes	Yes	
35	Mercury	ug/L	<0.4	<0.4	<0.4	<0.4	<0.4	2	n/a	<0.4			
36	Molybdenum	ug/L	<10	<10	<10	<10	<10	n/a	10	154	Yes	Yes	
37	Nickel	ug/L	<10	<10	18	12	10	100	200	<10			
38	Phosphorous -- Total	ug/L	<1000	<1000	<100	<100	<550	n/a	n/a	408	Yes	Yes	
39	Selenium -- Total	ug/L	370	390	700	520	495	50	20	11			
40	Silver	ug/L	<10	<10	<10	<10	<10	100	n/a	<10			
41	Strontium	ug/L	4,900	5,200	5,600	5,300	5,300	n/a	n/a	453			
42	Thallium	ug/L	<1	<1	<1	<1	<1	2	n/a	<1			
43	Tin	ug/L	<5	<5	<25	<5	<5	n/a	n/a	<5			
44	Titanium	ug/L	<50	<50	<50	<50	<50	n/a	n/a	<50			
45	Vanadium	ug/L	<10	<10	<10	<10	<10	50	100	<10			
46	Zinc	ug/L	<50	<50	<50	<50	<50	5,000	2,000	<50			
47	* Panoche Energy Center's baseline first-encountered groundwater monitoring results (screen from 150' to 210' bgs).												
48	** For averaging, non-detect results were replaced with 1/2 the laboratory reporting limit.												
49	*** Based on Kiewit's wastewater quality estimate that assumes non-detect source-water results are still non-detect after cycling up source water (further testing is in progress to verify this assumption).												
50	bgs = below ground surface												
51	FF = field filtered												
52	LF = laboratory filtered												

---

**APPENDIX A**

**Completed, Signed Form 200**

---



**APPLICATION/REPORT OF WASTE DISCHARGE  
GENERAL INFORMATION FORM FOR  
WASTE DISCHARGE REQUIREMENTS OR NPDES PERMIT**



**I. FACILITY INFORMATION**

**A. Facility:**

Name: Panoche Energy Center			
Address: 43883 West Panoche Road			
City: Firebaugh	County: Fresno	State: CA	Zip Code: 93622
Contact Person: Don Burkard		Telephone Number: 925-759-0457	

**B. Facility Owner:**

Name: Panoche Energy Center, LLC			Owner Type (Check One)	
Address: 43883 West Panoche Road			1. <input type="checkbox"/> Individual	2. <input checked="" type="checkbox"/> Corporation
City: Firebaugh	State: CA	Zip Code: 93622	3. <input type="checkbox"/> Governmental Agency	4. <input type="checkbox"/> Partnership
Contact Person: Don Burkard			5. <input type="checkbox"/> Other: _____	
		Telephone Number: 925-759-0457	Federal Tax ID: 20-55522298	

**C. Facility Operator (The agency or business, not the person):**

Name: Wood Group, LLC			Operator Type (Check One)	
Address: 43883 West Panoche Road			1. <input type="checkbox"/> Individual	2. <input checked="" type="checkbox"/> Corporation
City: Firebaugh	State: CA	Zip Code: 93622	3. <input type="checkbox"/> Governmental Agency	4. <input type="checkbox"/> Partnership
Contact Person: Roy Campbell			5. <input type="checkbox"/> Other: _____	
		Telephone Number: 559-659-2270		

**D. Owner of the Land:**

Name: PAO Investments, LLC			Owner Type (Check One)	
Address: 45499 West Panoche Road			1. <input type="checkbox"/> Individual	2. <input checked="" type="checkbox"/> Corporation
City: Firebaugh	State: CA	Zip Code: 93622	3. <input type="checkbox"/> Governmental Agency	4. <input type="checkbox"/> Partnership
Contact Person: Barry Baker			5. <input type="checkbox"/> Other: _____	
		Telephone Number: 559-659-3942		

**E. Address Where Legal Notice May Be Served:**

Address: 43883 West Panoche Road			
City: Firebaugh	State: CA	Zip Code: 93622	
Contact Person: Don Burkard		Telephone Number: 925-759-0457	

**F. Billing Address:**

Address: 43883 West Panoche Road			
City: Firebaugh	State: CA	Zip Code: 93622	
Contact Person: Don Burkard		Telephone Number: 925-759-0457	



**APPLICATION/REPORT OF WASTE DISCHARGE  
GENERAL INFORMATION FORM FOR  
WASTE DISCHARGE REQUIREMENTS OR NPDES PERMIT**



**II. TYPE OF DISCHARGE**

Check Type of Discharge(s) Described in this Application (A or B):

- A. WASTE DISCHARGE TO LAND**                       **B. WASTE DISCHARGE TO SURFACE WATER**

**Check all that apply:**

<input type="checkbox"/> Domestic/Municipal Wastewater Treatment and Disposal	<input type="checkbox"/> Animal Waste Solids	<input type="checkbox"/> Animal or Aquacultural Wastewater
<input checked="" type="checkbox"/> Cooling Water	<input type="checkbox"/> Land Treatment Unit	<input type="checkbox"/> Biosolids/Residual
<input type="checkbox"/> Mining	<input type="checkbox"/> Dredge Material Disposal	<input type="checkbox"/> Hazardous Waste (see instructions)
<input type="checkbox"/> Waste Pile	<input checked="" type="checkbox"/> Surface Impoundment	<input type="checkbox"/> Landfill (see instructions)
<input type="checkbox"/> Wastewater Reclamation	<input checked="" type="checkbox"/> Industrial Process Wastewater	<input type="checkbox"/> Storm Water
<input type="checkbox"/> Other, please describe: _____		

**III. LOCATION OF THE FACILITY**

Describe the physical location of the facility.

<p><b>1. Assessor's Parcel Number(s)</b> Facility: 027-060-78S Discharge Point: 027-060-78S</p>	<p><b>2. Latitude</b> Facility: 36.65126 degrees N Discharge Point: 35.65021 deg N</p>	<p><b>3. Longitude</b> Facility: 120.58412 degrees W Discharge Point: 120.58412 deg W</p>
---	--	---

**IV. REASON FOR FILING**

New Discharge or Facility                       Changes in Ownership/Operator (see instructions)

Change in Design or Operation                       Waste Discharge Requirements Update or NPDES Permit Reissuance

Change in Quantity/Type of Discharge                       Other: \_\_\_\_\_

**V. CALIFORNIA ENVIRONMENTAL QUALITY ACT (CEQA)**

Name of Lead Agency: California Energy Commission

Has a public agency determined that the proposed project is exempt from CEQA?     Yes                       No

If Yes, state the basis for the exemption and the name of the agency supplying the exemption on the line below.  
Basis for Exemption/Agency: \_\_\_\_\_

Has a "Notice of Determination" been filed under CEQA?                       Yes                       No

If Yes, enclose a copy of the CEQA document, Environmental Impact Report, or Negative Declaration. If no, identify the expected type of CEQA document and expected date of completion.

Expected CEQA Documents:

EIR                       Negative Declaration

Expected CEQA Completion Date: CEQA equiv. March 2010



APPLICATION/REPORT OF WASTE DISCHARGE  
GENERAL INFORMATION FORM FOR  
WASTE DISCHARGE REQUIREMENTS OR NPDES PERMIT



VI. OTHER REQUIRED INFORMATION

Please provide a COMPLETE characterization of your discharge. A complete characterization includes, but is not limited to, design and actual flows, a list of constituents and the discharge concentration of each constituent, a list of other appropriate waste discharge characteristics, a description and schematic drawing of all treatment processes, a description of any Best Management Practices (BMPs) used, and a description of disposal methods.

Also include a site map showing the location of the facility and, if you are submitting this application for an NPDES permit, identify the surface water to which you propose to discharge. Please try to limit your maps to a scale of 1:24,000 (7.5' USGS Quadrangle) or a street map, if more appropriate.

VII. OTHER

Attach additional sheets to explain any responses which need clarification. List attachments with titles and dates below:

Please see accompanying Report of Waste Discharge, dated September 21, 2009.

You will be notified by a representative of the RWQCB within 30 days of receipt of your application. The notice will state if your application is complete or if there is additional information you must submit to complete your Application/Report of Waste Discharge, pursuant to Division 7, Section 13260 of the California Water Code.

VIII. CERTIFICATION

"I certify under penalty of law that this document, including all attachments and supplemental information, were prepared under my direction and supervision in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment."

Print Name: DON BURKARD  
Signature: [Handwritten Signature]

Title: OPERATIONS MGR  
Date: 9-21-09

FOR OFFICE USE ONLY

Date Form 200 Received:	Letter to Discharger:	Fee Amount Received:	Check #:
-------------------------	-----------------------	----------------------	----------

---

**APPENDIX B**

**Groundwater Laboratory Reports**

---





1414 Stanislaus Street  
 Fresno, California 93706  
 (559) 497-2888  
 Fax (559) 485-6935

**Certificate of Analysis**  
**NELAP Certificate #04227CA**  
**ELAP Certificate #1180**

Jason Moore  
 URS Corporation  
 30 River Park Place West, Suite 180  
 Fresno, CA 93720

**BSK Submission #: 2009071303**

**BSK Sample ID #: 1137689**

Report Issue Date: 07/29/2009

Project ID: Project Desc: Panoche Energy Center

Submission Comments:

Sample Type: Liquid

Date Sampled: 07/16/2009

Sample Description: PEC-MW-4A

Time Sampled: 1229

Sample Comments:

Date Received: 07/16/2009

**Inorganics**

Analyte	Method	Result	Units	PQL	Dilution	DLR	Prep Date/Time	Analysis Date/Time
Aggressive Index		13			1	N/A	07/23/09	07/23/09
Alkalinity (as CaCO3)	SM 2320 B	130	mg/L	3.0	1	3.0	07/17/09	07/17/09
Aluminum (Al) - Dissolved	EPA 200.7	ND	mg/L	0.050	1	0.050	07/16/09	07/20/09
Ammonia (NH3-N)	SM 4500-NH3 G	ND	mg/L	0.1	1	0.10	07/20/09	07/20/09
Antimony (Sb) - Dissolved	EPA 200.8	ND	µg/L	2	1	2.0	07/16/09	07/21/09
Arsenic (As) - Dissolved	EPA 200.8	18	µg/L	2	1	2.0	07/16/09	07/21/09
Barium (Ba) - Dissolved	EPA 200.7	ND	mg/L	0.050	1	0.050	07/16/09	07/20/09
Beryllium (Be) - Dissolved	EPA 200.8	ND	µg/L	1.0	1	1.0	07/16/09	07/21/09
Bicarbonate (as CaCO3)	SM 2320 B	130	mg/L	3.0	1	3.0	07/17/09	07/17/09
Boron (B) - Dissolved	EPA 200.7	3.2	mg/L	0.10	1	0.10	07/16/09	07/20/09
Cadmium (Cd) - Dissolved	EPA 200.8	ND	µg/L	1.0	1	1.0	07/16/09	07/21/09
Calcium (Ca) - Dissolved	EPA 200.7	360	mg/L	0.10	1	0.10	07/16/09	07/20/09
Carbon Dioxide - Free	SM 4500-CO2 D	3.1	mg/L	1.0	1	1.0	07/23/09	07/23/09
Carbon Dioxide - Total	SM 4500-CO2 D	120	mg/L	1.0	1	1.0	07/23/09	07/23/09
Carbonate (as CaCO3)	SM 2320 B	ND	mg/L	1.0	1	1.0	07/17/09	07/17/09
Chloride (Cl)	EPA 300.0	360	mg/L	1.0	20	20	07/16/09	07/16/09
Chromium - Total (Cr) - Dissolved	EPA 200.8	21	µg/L	10	1	10	07/16/09	07/21/09
Conductivity - Specific (EC) @25°C	SM 2510 B	4900	µmho/cm	1.0	1	1.0	07/17/09	07/17/09
Copper (Cu) - Dissolved	EPA 200.7	ND	mg/L	0.050	1	0.050	07/16/09	07/20/09
Cyanide (CN)	SM 4500-CN-F	ND	mg/L	0.02	1	0.020	07/17/09	07/17/09
Fluoride	SM 4500-F C	0.26	mg/L	0.10	1	0.10	07/19/09	07/19/09
Hardness (as CaCO3)	SM 2340 B	2000	mg/L	1.0	1	1.0	07/23/09	07/23/09
Hydroxide (as CaCO3)	SM 2320 B	ND	mg/L	1.0	1	1.0	07/17/09	07/17/09
Iron (Fe)	EPA 200.7	ND	mg/L	0.050	1	0.050	07/27/09	07/27/09
Iron (Fe) - Dissolved	EPA 200.7	ND	mg/L	0.050	1	0.050	07/16/09	07/20/09
Langelier Index (Saturation Index)	SM 2330 B	5.6	-	-	1	N/A	07/23/09	07/23/09
Lead (Pb) - Dissolved	EPA 200.8	ND	µg/L	5.0	1	5.0	07/16/09	07/21/09
Magnesium (Mg) - Dissolved	EPA 200.7	280	mg/L	0.10	1	0.10	07/16/09	07/20/09
Manganese (Mn)	EPA 200.7	ND	mg/L	0.010	1	0.010	07/27/09	07/27/09
Manganese (Mn) - Dissolved	EPA 200.7	ND	mg/L	0.010	1	0.010	07/16/09	07/20/09

mg/L: Milligrams/Liter (ppm)  
 mg/Kg: Milligrams/Kilogram (ppm)  
 µg/L: Micrograms/Liter (ppb)  
 µg/Kg: Micrograms/Kilogram (ppb)  
 %Rec: Percent Recovered (surrogates)

PQL: Practical Quantitation Limit  
 DLR: Detection Limit for Reporting  
 : PQL x Dilution  
 ND: None Detected at DLR  
 pCi/L: Picocurie per Liter

H: Analyzed outside of hold time  
 P: Preliminary result  
 S: Suspect result. See Case Narrative for comments.  
 E: Analysis performed by External laboratory.  
 See External Laboratory Report attachments.  
 MDC: Min Detectable Concentration

Report Authentication Code: 1 82741 2707 1077 1078 1079 1080 1081 1082 1083 1084 1085 1086 1087 1088 1089 1090 1091 1092 1093 1094 1095 1096 1097 1098 1099 1100 1101 1102 1103 1104 1105 1106 1107 1108 1109 1110 1111 1112 1113 1114 1115 1116 1117 1118 1119 1120 1121 1122 1123 1124 1125 1126 1127 1128 1129 1130 1131 1132 1133 1134 1135 1136 1137 1138 1139 1140 1141 1142 1143 1144 1145 1146 1147 1148 1149 1150 1151 1152 1153 1154 1155 1156 1157 1158 1159 1160 1161 1162 1163 1164 1165 1166 1167 1168 1169 1170 1171 1172 1173 1174 1175 1176 1177 1178 1179 1180 1181 1182 1183 1184 1185 1186 1187 1188 1189 1190 1191 1192 1193 1194 1195 1196 1197 1198 1199 1200 1201 1202 1203 1204 1205 1206 1207 1208 1209 1210 1211 1212 1213 1214 1215 1216 1217 1218 1219 1220 1221 1222 1223 1224 1225 1226 1227 1228 1229 1230 1231 1232 1233 1234 1235 1236 1237 1238 1239 1240 1241 1242 1243 1244 1245 1246 1247 1248 1249 1250 1251 1252 1253 1254 1255 1256 1257 1258 1259 1260 1261 1262 1263 1264 1265 1266 1267 1268 1269 1270 1271 1272 1273 1274 1275 1276 1277 1278 1279 1280 1281 1282 1283 1284 1285 1286 1287 1288 1289 1290 1291 1292 1293 1294 1295 1296 1297 1298 1299 1300 1301 1302 1303 1304 1305 1306 1307 1308 1309 1310 1311 1312 1313 1314 1315 1316 1317 1318 1319 1320 1321 1322 1323 1324 1325 1326 1327 1328 1329 1330 1331 1332 1333 1334 1335 1336 1337 1338 1339 1340 1341 1342 1343 1344 1345 1346 1347 1348 1349 1350 1351 1352 1353 1354 1355 1356 1357 1358 1359 1360 1361 1362 1363 1364 1365 1366 1367 1368 1369 1370 1371 1372 1373 1374 1375 1376 1377 1378 1379 1380 1381 1382 1383 1384 1385 1386 1387 1388 1389 1390 1391 1392 1393 1394 1395 1396 1397 1398 1399 1400 1401 1402 1403 1404 1405 1406 1407 1408 1409 1410 1411 1412 1413 1414 1415 1416 1417 1418 1419 1420 1421 1422 1423 1424 1425 1426 1427 1428 1429 1430 1431 1432 1433 1434 1435 1436 1437 1438 1439 1440 1441 1442 1443 1444 1445 1446 1447 1448 1449 1450 1451 1452 1453 1454 1455 1456 1457 1458 1459 1460 1461 1462 1463 1464 1465 1466 1467 1468 1469 1470 1471 1472 1473 1474 1475 1476 1477 1478 1479 1480 1481 1482 1483 1484 1485 1486 1487 1488 1489 1490 1491 1492 1493 1494 1495 1496 1497 1498 1499 1500 1501 1502 1503 1504 1505 1506 1507 1508 1509 1510 1511 1512 1513 1514 1515 1516 1517 1518 1519 1520 1521 1522 1523 1524 1525 1526 1527 1528 1529 1530 1531 1532 1533 1534 1535 1536 1537 1538 1539 1540 1541 1542 1543 1544 1545 1546 1547 1548 1549 1550 1551 1552 1553 1554 1555 1556 1557 1558 1559 1560 1561 1562 1563 1564 1565 1566 1567 1568 1569 1570 1571 1572 1573 1574 1575 1576 1577 1578 1579 1580 1581 1582 1583 1584 1585 1586 1587 1588 1589 1590 1591 1592 1593 1594 1595 1596 1597 1598 1599 1600 1601 1602 1603 1604 1605 1606 1607 1608 1609 1610 1611 1612 1613 1614 1615 1616 1617 1618 1619 1620 1621 1622 1623 1624 1625 1626 1627 1628 1629 1630 1631 1632 1633 1634 1635 1636 1637 1638 1639 1640 1641 1642 1643 1644 1645 1646 1647 1648 1649 1650 1651 1652 1653 1654 1655 1656 1657 1658 1659 1660 1661 1662 1663 1664 1665 1666 1667 1668 1669 1670 1671 1672 1673 1674 1675 1676 1677 1678 1679 1680 1681 1682 1683 1684 1685 1686 1687 1688 1689 1690 1691 1692 1693 1694 1695 1696 1697 1698 1699 1700 1701 1702 1703 1704 1705 1706 1707 1708 1709 1710 1711 1712 1713 1714 1715 1716 1717 1718 1719 1720 1721 1722 1723 1724 1725 1726 1727 1728 1729 1730 1731 1732 1733 1734 1735 1736 1737 1738 1739 1740 1741 1742 1743 1744 1745 1746 1747 1748 1749 1750 1751 1752 1753 1754 1755 1756 1757 1758 1759 1760 1761 1762 1763 1764 1765 1766 1767 1768 1769 1770 1771 1772 1773 1774 1775 1776 1777 1778 1779 1780 1781 1782 1783 1784 1785 1786 1787 1788 1789 1790 1791 1792 1793 1794 1795 1796 1797 1798 1799 1800 1801 1802 1803 1804 1805 1806 1807 1808 1809 1810 1811 1812 1813 1814 1815 1816 1817 1818 1819 1820 1821 1822 1823 1824 1825 1826 1827 1828 1829 1830 1831 1832 1833 1834 1835 1836 1837 1838 1839 1840 1841 1842 1843 1844 1845 1846 1847 1848 1849 1850 1851 1852 1853 1854 1855 1856 1857 1858 1859 1860 1861 1862 1863 1864 1865 1866 1867 1868 1869 1870 1871 1872 1873 1874 1875 1876 1877 1878 1879 1880 1881 1882 1883 1884 1885 1886 1887 1888 1889 1890 1891 1892 1893 1894 1895 1896 1897 1898 1899 1900 1901 1902 1903 1904 1905 1906 1907 1908 1909 1910 1911 1912 1913 1914 1915 1916 1917 1918 1919 1920 1921 1922 1923 1924 1925 1926 1927 1928 1929 1930 1931 1932 1933 1934 1935 1936 1937 1938 1939 1940 1941 1942 1943 1944 1945 1946 1947 1948 1949 1950 1951 1952 1953 1954 1955 1956 1957 1958 1959 1960 1961 1962 1963 1964 1965 1966 1967 1968 1969 1970 1971 1972 1973 1974 1975 1976 1977 1978 1979 1980 1981 1982 1983 1984 1985 1986 1987 1988 1989 1990 1991 1992 1993 1994 1995 1996 1997 1998 1999 2000 2001 2002 2003 2004 2005 2006 2007 2008 2009 2010 2011 2012 2013 2014 2015 2016 2017 2018 2019 2020 2021 2022 2023 2024 2025 2026 2027 2028 2029 2030 2031 2032 2033 2034 2035 2036 2037 2038 2039 2040 2041 2042 2043 2044 2045 2046 2047 2048 2049 2050 2051 2052 2053 2054 2055 2056 2057 2058 2059 2060 2061 2062 2063 2064 2065 2066 2067 2068 2069 2070 2071 2072 2073 2074 2075 2076 2077 2078 2079 2080 2081 2082 2083 2084 2085 2086 2087 2088 2089 2090 2091 2092 2093 2094 2095 2096 2097 2098 2099 2100 2101 2102 2103 2104 2105 2106 2107 2108 2109 2110 2111 2112 2113 2114 2115 2116 2117 2118 2119 2120 2121 2122 2123 2124 2125 2126 2127 2128 2129 2130 2131 2132 2133 2134 2135 2136 2137 2138 2139 2140 2141 2142 2143 2144 2145 2146 2147 2148 2149 2150 2151 2152 2153 2154 2155 2156 2157 2158 2159 2160 2161 2162 2163 2164 2165 2166 2167 2168 2169 2170 2171 2172 2173 2174 2175 2176 2177 2178 2179 2180 2181 2182 2183 2184 2185 2186 2187 2188 2189 2190 2191 2192 2193 2194 2195 2196 2197 2198 2199 2200 2201 2202 2203 2204 2205 2206 2207 2208 2209 2210 2211 2212 2213 2214 2215 2216 2217 2218 2219 2220 2221 2222 2223 2224 2225 2226 2227 2228 2229 2230 2231 2232 2233 2234 2235 2236 2237 2238 2239 2240 2241 2242 2243 2244 2245 2246 2247 2248 2249 2250 2251 2252 2253 2254 2255 2256 2257 2258 2259 2260 2261 2262 2263 2264 2265 2266 2267 2268 2269 2270 2271 2272 2273 2274 2275 2276 2277 2278 2279 2280 2281 2282 2283 2284 2285 2286 2287 2288 2289 2290 2291 2292 2293 2294 2295 2296 2297 2298 2299 2300 2301 2302 2303 2304 2305 2306 2307 2308 2309 2310 2311 2312 2313 2314 2315 2316 2317 2318 2319 2320 2321 2322 2323 2324 2325 2326 2327 2328 2329 2330 2331 2332 2333 2334 2335 2336 2337 2338 2339 2340 2341 2342 2343 2344 2345 2346 2347 2348 2349 2350 2351 2352 2353 2354 2355 2356 2357 2358 2359 2360 2361 2362 2363 2364 2365 2366 2367 2368 2369 2370 2371 2372 2373 2374 2375 2376 2377 2378 2379 2380 2381 2382 2383 2384 2385 2386 2387 2388 2389 2390 2391 2392 2393 2394 2395 2396 2397 2398 2399 2400 2401 2402 2403 2404 2405 2406 2407 2408 2409 2410 2411 2412 2413 2414 2415 2416 2417 2418 2419 2420 2421 2422 2423 2424 2425 2426 2427 2428 2429 2430 2431 2432 2433 2434 2435 2436 2437 2438 2439 2440 2441 2442 2443 2444 2445 2446 2447 2448 2449 2450 2451 2452 2453 2454 2455 2456 2457 2458 2459 2460 2461 2462 2463 2464 2465 2466 2467 2468 2469 2470 2471 2472 2473 2474 2475 2476 2477 2478 2479 2480 2481 2482 2483 2484 2485 2486 2487 2488 2489 2490 2491 2492 2493 2494 2495 2496 2497 2498 2499 2500 2501 2502 2503 2504 2505 2506 2507 2508 2509 2510 2511 2512 2513 2514 2515 2516 2517 2518 2519 2520 2521 2522 2523 2524 2525 2526 2527 2528 2529 2530 2531 2532 2533 2534 2535 2536 2537 2538 2539 2540 2541 2542 2543 2544 2545 2546 2547 2548 2549 2550 2551 2552 2553 2554 2555 2556 2557 2558 2559 2560 2561 2562 2563 2564 2565 2566 2567 2568 2569 2570 2571 2572 2573 2574 2575 2576 2577 2578 2579 2580 2581 2582 2583 2584 2585 2586 2587 2588 2589 2590 2591 2592 2593 2594 2595 2596 2597 2598 2599 2600 2601 2602 2603 2604 2605 2606 2607 2608 2609 2610 2611 2612 2613 2614 2615 2616 2617 2618 2619 2620 2621 2622 2623 2624 2625 2626 2627 2628 2629 2630 2631 2632 2633 2634 2635 2636 2637 2638 2639 2640 2641 2642 2643 2644 2645 2646 2647 2648 2649 2650 2651 2652 2653 2654 2655 2656 2657 2658 2659 2660 2661 2662 2663 2664 2665 26



1414 Stanislaus Street  
 Fresno, California 93706  
 (559) 497-2888  
 Fax (559) 485-6935

**Certificate of Analysis**  
**NELAP Certificate #04227CA**  
**ELAP Certificate #1180**

Jason Moore  
 URS Corporation  
 30 River Park Place West, Suite 180  
 Fresno, CA 93720

**BSK Submission #: 2009071303**

**BSK Sample ID #: 1137689**

Report Issue Date: 07/29/2009

Project ID:

Project Desc: Panoche Energy Center

Submission Comments:

Sample Type: Liquid

Date Sampled: 07/16/2009

Sample Description: PEC-MW-4A

Time Sampled: 1229

Sample Comments:

Date Received: 07/16/2009

**Inorganics**

Analyte	Method	Result	Units	PQL	Dilution	DLR	Prep Date/Time	Analysis Date/Time
MBAS, Calculated as LAS, mol wt 340SM 5540 C		ND	mg/L	0.050	1	0.050	07/16/09 19:00	07/16/09 19:00
Mercury (Hg) - Dissolved	EPA 200.8	ND	µg/L	0.40	1	0.40	07/16/09	07/21/09
Molybdenum (Mo) - Dissolved	EPA 200.8	ND	µg/L	10	1	10	07/16/09	07/21/09
Nickel (Ni) - Dissolved	EPA 200.8	ND	µg/L	10	1	10	07/16/09	07/23/09
Nitrate (NO3)	EPA 300.0	360	mg/L	1.0	20	20	07/16/09 23:27	07/16/09 23:27
Nitrite (NO2-N)	EPA 300.0	ND	mg/L	0.050	20	1.0	07/16/09 23:27	07/16/09 23:27
o-Phosphate as PO4	EPA 300.0	ND	mg/L	0.60	20	12	07/16/09 23:27	07/16/09 23:27
pH at 22.96°C	SM 4500-H+ B	7.9	Std. Unit	-	1	N/A	07/17/09 01:17	07/17/09 01:17
Phosphorus - Total (P)	EPA 365.4	ND	mg/L	1.0	1	1.0	07/17/09	07/17/09
Potassium (K) - Dissolved	EPA 200.7	10	mg/L	2	1	2.0	07/16/09	07/20/09
Selenium (Se) - Total - Dissolved	EPA 200.8	370	µg/L	2	1	2.0	07/16/09	07/21/09
Silica - Total (SiO2) - Dissolved	EPA 200.7	45	mg/L	0.20	1	0.20	07/16/09	07/20/09
Silver (Ag) - Dissolved	EPA 200.7	ND	mg/L	0.010	1	0.010	07/16/09	07/20/09
Sodium (Na) - Dissolved	EPA 200.7	510	mg/L	1.0	2	2.0	07/16/09	07/21/09
Strontium (Sr) - Dissolved	EPA 200.8	4900	µg/L	1.0	5	5.0	07/16/09	07/22/09
Sulfate (SO4)	EPA 300.0	2000	mg/L	2	50	100	07/18/09	07/18/09
Thallium (Tl) - Dissolved	EPA 200.8	ND	µg/L	1.0	1	1.0	07/16/09	07/21/09
Tin (Sn)	EPA 200.8	ND	µg/L	5.0	1	5.0	07/16/09	07/22/09
Titanium (Ti) - Dissolved	EPA 200.7	ND	mg/L	0.050	1	0.050	07/16/09	07/20/09
Total Dissolved Solids (TDS)	SM 2540 C	4300	mg/L	5.0	1	5.0	07/17/09	07/20/09
Total Suspended (TSS)	SM 2540 D	23	mg/L	5.0	1	5.0	07/17/09	07/20/09
Vanadium (V) - Dissolved	EPA 200.8	ND	µg/L	10	1	10	07/16/09	07/21/09
Zinc (Zn) - Dissolved	EPA 200.7	ND	mg/L	0.050	1	0.050	07/16/09	07/20/09

mg/L: Milligrams/Liter (ppm)  
 mg/Kg: Milligrams/Kilogram (ppm)  
 µg/L: Micrograms/Liter (ppb)  
 µg/Kg: Micrograms/Kilogram (ppb)  
 %Rec: Percent Recovered (surrogates)

PQL: Practical Quantitation Limit  
 DLR: Detection Limit for Reporting  
 : PQL x Dilution  
 ND: None Detected at DLR  
 pCi/L: Picocurie per Liter

H: Analyzed outside of hold time  
 P: Preliminary result  
 S: Suspect result. See Case Narrative for comments.  
 E: Analysis performed by External laboratory.  
 See External Laboratory Report attachments.  
 MDC: Min Detectable Concentration

Report Authentication Code:





1414 Stanislaus Street  
 Fresno, California 93706  
 (559) 497-2888  
 Fax (559) 485-6935

**Certificate of Analysis**  
**NELAP Certificate #04227CA**  
**ELAP Certificate #1180**

Jason Moore  
 URS Corporation  
 30 River Park Place West, Suite 180  
 Fresno, CA 93720

**BSK Submission #: 2009071303**

**BSK Sample ID #: 1137690**

Report Issue Date: 07/29/2009

Project ID:

Project Desc: Panoche Energy Center

Submission Comments:

Sample Type: Liquid

Date Sampled: 07/16/2009

Sample Description: PEC-MW-4B

Time Sampled: 1326

Sample Comments:

Date Received: 07/16/2009

**Inorganics**

Analyte	Method	Result	Units	PQL	Dilution	DLR	Prep Date/Time	Analysis Date/Time
MBAS, Calculated as LAS, mol wt 340	SM 5540 C	ND	mg/L	0.050	1	0.050	07/16/09 19:00	07/16/09 19:00
Mercury (Hg) - Dissolved	EPA 200.8	ND	µg/L	0.40	1	0.40	07/16/09	07/21/09
Molybdenum (Mo) - Dissolved	EPA 200.8	ND	µg/L	10	1	10	07/16/09	07/21/09
Nickel (Ni) - Dissolved	EPA 200.8	ND	µg/L	10	1	10	07/16/09	07/23/09
Nitrate (NO3)	EPA 300.0	370	mg/L	1.0	20	20	07/16/09 23:35	07/16/09 23:35
Nitrite (NO2-N)	EPA 300.0	ND	mg/L	0.050	20	1.0	07/16/09 23:35	07/16/09 23:35
o-Phosphate as PO4	EPA 300.0	ND	mg/L	0.60	20	12	07/16/09 23:35	07/16/09 23:35
pH at 22.72°C	SM 4500-H+ B	7.9	Std. Unit	-	1	N/A	07/17/09 01:26	07/17/09 01:26
Phosphorus - Total (P)	EPA 365.4	ND	mg/L	1.0	1	1.0	07/17/09	07/17/09
Potassium (K) - Dissolved	EPA 200.7	10	mg/L	2	1	2.0	07/16/09	07/20/09
Selenium (Se) - Total - Dissolved	EPA 200.8	390	µg/L	2	1	2.0	07/16/09	07/21/09
Silica - Total (SiO2) - Dissolved	EPA 200.7	47	mg/L	0.20	1	0.20	07/16/09	07/20/09
Silver (Ag) - Dissolved	EPA 200.7	ND	mg/L	0.010	1	0.010	07/16/09	07/20/09
Sodium (Na) - Dissolved	EPA 200.7	500	mg/L	1.0	2	2.0	07/16/09	07/21/09
Strontium (Sr) - Dissolved	EPA 200.8	5200	µg/L	1.0	5	5.0	07/16/09	07/22/09
Sulfate (SO4)	EPA 300.0	2100	mg/L	2	50	100	07/18/09	07/18/09
Thallium (Tl) - Dissolved	EPA 200.8	ND	µg/L	1.0	1	1.0	07/16/09	07/21/09
Tin (Sn)	EPA 200.8	ND	µg/L	5.0	1	5.0	07/16/09	07/22/09
Titanium (Ti) - Dissolved	EPA 200.7	ND	mg/L	0.050	1	0.050	07/16/09	07/20/09
Total Dissolved Solids (TDS)	SM 2540 C	4000	mg/L	5.0	1	5.0	07/17/09	07/20/09
Total Suspended (TSS)	SM 2540 D	33	mg/L	5.0	1	5.0	07/17/09	07/20/09
Vanadium (V) - Dissolved	EPA 200.8	ND	µg/L	10	1	10	07/16/09	07/21/09
Zinc (Zn) - Dissolved	EPA 200.7	ND	mg/L	0.050	1	0.050	07/16/09	07/20/09

mg/L: Milligrams/Liter (ppm)

mg/Kg: Milligrams/Kilogram (ppm)

µg/L: Micrograms/Liter (ppb)

µg/Kg: Micrograms/Kilogram (ppb)

%Rec: Percent Recovered (surrogates)

Report Authentication Code:

PQL: Practical Quantitation Limit

DLR: Detection Limit for Reporting  
 : PQL x Dilution

ND: None Detected at DLR

pCi/L: Picocurie per Liter

H: Analyzed outside of hold time

P: Preliminary result

S: Suspect result. See Case Narrative for comments.

E: Analysis performed by External laboratory.

See External Laboratory Report attachments.

MDC: Min Detectable Concentration

Jason Moore  
URS Corporation  
30 River Park Place West, Suite 180  
Fresno, CA 93720

**BSK Submission #: 2009080177**

**BSK Sample ID #: 1144470**

Report Issue Date: 08/07/2009

Project ID:

Project Desc: Panoche Energy Center Production Well-West

Submission Comments:

Sample Type: Liquid

Date Sampled: 08/04/2009

Sample Description: PEC-MW4 A

Time Sampled: 1200

Sample Comments: Metals are on a dissolved basis due to field filtration

Date Received: 08/04/2009

**Inorganics**

Analyte	Method	Result	Units	PQL	Dilution	DLR	Prep Date/Time	Analysis Date/Time
Aggressive Index		13	-		1	N/A	08/07/09	08/07/09
Alkalinity (as CaCO3)	SM 2320 B	130	mg/L	3.0	1	3.0	08/05/09	08/05/09
Aluminum (Al)	EPA 200.7	ND	mg/L	0.050	1	0.050	08/05/09	08/05/09
Ammonia (NH3-N)	SM 4500-NH3 G	0.12	mg/L	0.1	1	0.10	08/06/09	08/06/09
Antimony (Sb)	EPA 200.8	ND	µg/L	2	1	2.0	08/05/09	08/05/09
Arsenic (As)	EPA 200.8	32	µg/L	2	1	2.0	08/05/09	08/05/09
Barium (Ba)	EPA 200.7	ND	mg/L	0.050	1	0.050	08/05/09	08/05/09
Beryllium (Be)	EPA 200.8	ND	µg/L	1.0	1	1.0	08/05/09	08/05/09
Bicarbonate (as CaCO3)	SM 2320 B	130	mg/L	3.0	1	3.0	08/05/09	08/05/09
Boron (B)	EPA 200.7	3.2	mg/L	0.10	1	0.10	08/05/09	08/05/09
Cadmium (Cd)	EPA 200.8	ND	µg/L	1.0	1	1.0	08/05/09	08/05/09
Calcium (Ca)	EPA 200.7	440	mg/L	0.10	1	0.10	08/05/09	08/05/09
Carbon Dioxide - Free	SM 4500-CO2 D	3.6	mg/L	1.0	1	1.0	08/06/09	08/06/09
Carbon Dioxide - Total	SM 4500-CO2 D	120	mg/L	1.0	1	1.0	08/06/09	08/06/09
Carbonate (as CaCO3)	SM 2320 B	ND	mg/L	1.0	1	1.0	08/05/09	08/05/09
Chloride (Cl)	EPA 300.0	450	mg/L	1.0	50	50	08/05/09	08/05/09
Chlorine - Residual (Cl2)	SM 4500-Cl-B	ND	mg/L	0.10	1	0.10	08/04/09 20:15	08/04/09 20:15
Chromium - Total (Cr)	EPA 200.8	19	µg/L	10	1	10	08/05/09	08/05/09
Cobalt (Co)	EPA 200.8	ND	µg/L	50	1	50	08/05/09	08/05/09
Conductivity - Specific (EC) @25°C	SM 2510 B	5700	µmho/cm	1.0	1	1.0	08/05/09	08/05/09
Copper (Cu)	EPA 200.7	ND	mg/L	0.050	1	0.050	08/05/09	08/05/09
Cyanide (CN)	SM 4500-CN E	ND	mg/L	0.01	1	0.010	08/06/09	08/06/09
Fluoride	SM 4500-F C	0.32	mg/L	0.10	1	0.10	08/05/09	08/05/09
Hardness (as CaCO3)	SM 2340 B	2400	mg/L	1.0	1	1.0	08/06/09	08/06/09
Hydroxide (as CaCO3)	SM 2320 B	ND	mg/L	1.0	1	1.0	08/05/09	08/05/09
Iron (Fe)	EPA 200.7	ND	mg/L	0.050	1	0.050	08/05/09	08/05/09
Langelier Index (Saturation Index)	SM 2330 B	7.0	-	-	1	N/A	08/07/09	08/07/09
Lead (Pb)	EPA 200.8	ND	µg/L	5.0	1	5.0	08/05/09	08/05/09
Magnesium (Mg)	EPA 200.7	330	mg/L	0.10	1	0.10	08/05/09	08/05/09
Manganese (Mn)	EPA 200.7	ND	mg/L	0.010	1	0.010	08/05/09	08/05/09

mg/L: Milligrams/Liter (ppm)  
mg/Kg: Milligrams/Kilogram (ppm)  
µg/L: Micrograms/Liter (ppb)  
µg/Kg: Micrograms/Kilogram (ppb)  
%Rec: Percent Recovered (surrogates)

PQL: Practical Quantitation Limit  
DLR: Detection Limit for Reporting  
: PQL x Dilution  
ND: None Detected at DLR  
pCi/L: Picocurie per Liter

H: Analyzed outside of hold time  
P: Preliminary result  
S: Suspect result. See Case Narrative for comments.  
E: Analysis performed by External laboratory.  
See External Laboratory Report attachments.  
MDC: Min Detectable Concentration

Report Authentication Code:



Jason Moore  
URS Corporation  
30 River Park Place West, Suite 180  
Fresno, CA 93720

**BSK Submission #: 2009080177**

**BSK Sample ID #: 1144470**

Report Issue Date: 08/07/2009

Project ID:

Project Desc: Panoche Energy Center Production Well-West

Submission Comments:

Sample Type: Liquid

Date Sampled: 08/04/2009

Sample Description: PEC-MW4 A

Time Sampled: 1200

Sample Comments: Metals are on a dissolved basis due to field filtration

Date Received: 08/04/2009

**Inorganics**

Analyte	Method	Result	Units	PQL	Dilution	DLR	Prep Date/Time	Analysis Date/Time
MBAS, Calculated as LAS, mol wt 340	SM 5540 C	0.058	mg/L	0.050	1	0.050	08/05/09 07:10	08/05/09 07:10
Mercury (Hg)	EPA 200.8	ND	µg/L	0.40	1	0.40	08/05/09	08/05/09
Molybdenum (Mo)	EPA 200.8	ND	µg/L	10	1	10	08/05/09	08/05/09
Nickel (Ni)	EPA 200.8	18	µg/L	10	1	10	08/05/09	08/05/09
Nitrate (NO3)	EPA 300.0	420	mg/L	1.0	50	50	08/05/09 00:49	08/05/09 00:49
Nitrite (NO2-N)	EPA 300.0	ND	mg/L	0.050	50	2.5	08/06/09 00:55	08/06/09 00:55
o-Phosphate as PO4	EPA 300.0	ND	mg/L	0.60	50	30	08/05/09 00:49	08/05/09 00:49
pH at 22.31°C	SM 4500-H+ B	7.9	Std. Unit	-	1	N/A	08/05/09 01:56	08/05/09 01:56
Phosphorus - Total (P)	EPA 365.4	ND	mg/L	0.1	1	0.10	08/05/09	08/06/09
Potassium (K)	EPA 200.7	12	mg/L	2	1	2.0	08/05/09	08/05/09
Selenium (Se) - Total	EPA 200.8	700	µg/L	2	1	2.0	08/05/09	08/05/09
Silica - Total (SiO2)	EPA 200.7	47	mg/L	0.20	1	0.20	08/05/09	08/05/09
Silver (Ag)	EPA 200.7	ND	mg/L	0.010	1	0.010	08/05/09	08/05/09
Sodium (Na)	EPA 200.7	560	mg/L	1.0	5	5.0	08/05/09	08/05/09
Strontium (Sr)	EPA 200.8	5600	µg/L	1.0	5	5.0	08/05/09	08/06/09
Sulfate (SO4)	EPA 300.0	2300	mg/L	2	50	100	08/05/09	08/05/09
Thallium (Tl)	EPA 200.8	ND	µg/L	1.0	1	1.0	08/05/09	08/05/09
Tin (Sn)	EPA 200.8	ND	µg/L	5.0	5	25	08/05/09	08/06/09
Titanium (Ti)	EPA 200.7	ND	mg/L	0.050	1	0.050	08/05/09	08/05/09
Total Dissolved Solids (TDS)	SM 2540 C	4800	mg/L	5.0	1	5.0	08/05/09	08/07/09
Total Suspended (TSS)	SM 2540 D	37	mg/L	5.0	1	5.0	08/05/09	08/07/09
Vanadium (V)	EPA 200.8	ND	µg/L	10	1	10	08/05/09	08/05/09
Zinc (Zn)	EPA 200.7	ND	mg/L	0.050	1	0.050	08/05/09	08/05/09

mg/L: Milligrams/Liter (ppm)  
mg/Kg: Milligrams/Kilogram (ppm)  
µg/L: Micrograms/Liter (ppb)  
µg/Kg: Micrograms/Kilogram (ppb)  
%Rec: Percent Recovered (surrogates)

PQL: Practical Quantitation Limit  
DLR: Detection Limit for Reporting  
: PQL x Dilution  
ND: None Detected at DLR  
pCi/L: Picocurie per Liter

H: Analyzed outside of hold time  
P: Preliminary result  
S: Suspect result. See Case Narrative for comments.  
E: Analysis performed by External laboratory.  
See External Laboratory Report attachments.  
MDC: Min Detectable Concentration

Report Authentication Code:

1144470 080409 080709 080709 080709 080709 080709 080709 080709 080709

Jason Moore  
URS Corporation  
30 River Park Place West, Suite 180  
Fresno, CA 93720

**BSK Submission #: 2009080177**

**BSK Sample ID #: 1144471**

Report Issue Date: 08/07/2009

Project ID:

Project Desc: Panoche Energy Center Production Well-West

Submission Comments:

Sample Type: Liquid  
Sample Description: PEC-MW4 B  
Sample Comments:

Date Sampled: 08/04/2009  
Time Sampled: 1205  
Date Received: 08/04/2009

**Inorganics**

Analyte	Method	Result	Units	PQL	Dilution	DLR	Prep Date/Time	Analysis Date/Time
Aggressive Index		13	-		1	N/A	08/07/09	08/07/09
Alkalinity (as CaCO3)	SM 2320 B	130	mg/L	3.0	1	3.0	08/05/09	08/05/09
Aluminum (Al) - Dissolved	EPA 200.7	ND	mg/L	0.050	1	0.050	08/04/09	08/06/09
Ammonia (NH3-N)	SM 4500-NH3 G	ND	mg/L	0.1	1	0.10	08/06/09	08/06/09
Antimony (Sb) - Dissolved	EPA 200.8	ND	µg/L	2	1	2.0	08/04/09	08/06/09
Arsenic (As) - Dissolved	EPA 200.8	26	µg/L	2	1	2.0	08/04/09	08/06/09
Barium (Ba) - Dissolved	EPA 200.7	ND	mg/L	0.050	1	0.050	08/04/09	08/06/09
Beryllium (Be) - Dissolved	EPA 200.8	ND	µg/L	1.0	1	1.0	08/04/09	08/06/09
Bicarbonate (as CaCO3)	SM 2320 B	130	mg/L	3.0	1	3.0	08/05/09	08/05/09
Boron (B) - Dissolved	EPA 200.7	3.2	mg/L	0.10	1	0.10	08/04/09	08/06/09
Cadmium (Cd) - Dissolved	EPA 200.8	ND	µg/L	1.0	1	1.0	08/04/09	08/06/09
Calcium (Ca) - Dissolved	EPA 200.7	440	mg/L	0.10	1	0.10	08/04/09	08/06/09
Carbon Dioxide - Free	SM 4500-CO2 D	3.6	mg/L	1.0	1	1.0	08/06/09	08/06/09
Carbon Dioxide - Total	SM 4500-CO2 D	120	mg/L	1.0	1	1.0	08/06/09	08/06/09
Carbonate (as CaCO3)	SM 2320 B	ND	mg/L	1.0	1	1.0	08/05/09	08/05/09
Chloride (Cl)	EPA 300.0	440	mg/L	1.0	50	50	08/05/09	08/05/09
Chlorine - Residual (Cl2)	SM 4500-Cl-B	ND	mg/L	0.10	1	0.10	08/04/09 20:16	08/04/09 20:16
Chromium - Total (Cr) - Dissolved	EPA 200.8	14	µg/L	10	1	10	08/04/09	08/06/09
Cobalt (Co) - Dissolved	EPA 200.8	ND	µg/L	50	1	50	08/04/09	08/06/09
Conductivity - Specific (EC) @25°C	SM 2510 B	5700	µmho/cm	1.0	1	1.0	08/05/09	08/05/09
Copper (Cu) - Dissolved	EPA 200.7	ND	mg/L	0.050	1	0.050	08/04/09	08/06/09
Cyanide (CN)	SM 4500-CN E	ND	mg/L	0.01	1	0.010	08/06/09	08/06/09
Fluoride	SM 4500-F C	0.30	mg/L	0.10	1	0.10	08/05/09	08/05/09
Hardness (as CaCO3)	SM 2340 B	2500	mg/L	1.0	1	1.0	08/07/09	08/07/09
Hydroxide (as CaCO3)	SM 2320 B	ND	mg/L	1.0	1	1.0	08/05/09	08/05/09
Iron (Fe) - Dissolved	EPA 200.7	ND	mg/L	0.050	1	0.050	08/04/09	08/06/09
Langelier Index (Saturation Index)	SM 2330 B	7.3	-	-	1	N/A	08/07/09	08/07/09
Lead (Pb) - Dissolved	EPA 200.8	ND	µg/L	5.0	1	5.0	08/04/09	08/06/09
Magnesium (Mg) - Dissolved	EPA 200.7	340	mg/L	0.10	1	0.10	08/04/09	08/06/09
Manganese (Mn) - Dissolved	EPA 200.7	ND	mg/L	0.010	1	0.010	08/04/09	08/06/09

mg/L: Milligrams/Liter (ppm)  
mg/Kg: Milligrams/Kilogram (ppm)  
µg/L: Micrograms/Liter (ppb)  
µg/Kg: Micrograms/Kilogram (ppb)  
%Rec: Percent Recovered (surrogates)

PQL: Practical Quantitation Limit  
DLR: Detection Limit for Reporting  
: PQL x Dilution  
ND: None Detected at DLR  
pCi/L: Picocurie per Liter

H: Analyzed outside of hold time  
P: Preliminary result  
S: Suspect result. See Case Narrative for comments.  
E: Analysis performed by External laboratory.  
See External Laboratory Report attachments.  
MDC: Min Detectable Concentration

Report Authentication Code: [Barcode]





1414 Stanislaus Street  
 Fresno, California 93706  
 (559) 497-2888  
 Fax (559) 485-6935

**Certificate of Analysis**  
**NELAP Certificate #04227CA**  
**ELAP Certificate #1180**

Jason Moore  
 URS Corporation  
 30 River Park Place West, Suite 180  
 Fresno, CA 93720

**BSK Submission #: 2009080177**

**BSK Sample ID #: 1144471**

Report Issue Date: 08/07/2009

Project ID:

Project Desc: Panoche Energy Center Production Well-West

Submission Comments:

Sample Type: Liquid

Date Sampled: 08/04/2009

Sample Description: PEC-MW4 B

Time Sampled: 1205

Sample Comments:

Date Received: 08/04/2009

**Inorganics**

Analyte	Method	Result	Units	PQL	Dilution	DLR	Prep Date/Time	Analysis Date/Time
Mercury (Hg) - Dissolved	EPA 200.8	ND	µg/L	0.40	1	0.40	08/04/09	08/06/09
Molybdenum (Mo) - Dissolved	EPA 200.8	ND	µg/L	10	1	10	08/04/09	08/06/09
Nickel (Ni) - Dissolved	EPA 200.8	12	µg/L	10	1	10	08/04/09	08/06/09
Nitrate (NO3)	EPA 300.0	420	mg/L	1.0	50	50	08/05/09 01:00	08/05/09 01:00
Nitrite (NO2-N)	EPA 300.0	ND	mg/L	0.050	50	2.5	08/06/09 01:05	08/06/09 01:05
o-Phosphate as PO4	EPA 300.0	ND	mg/L	0.60	50	30	08/05/09 01:00	08/05/09 01:00
pH at 22.54°C	SM 4500-H+ B	7.9	Std. Unit	-	1	N/A	08/05/09 02:05	08/05/09 02:05
Phosphorus - Total (P)	EPA 365.4	ND	mg/L	0.1	1	0.10	08/05/09	08/06/09
Potassium (K) - Dissolved	EPA 200.7	11	mg/L	2	1	2.0	08/04/09	08/06/09
Selenium (Se) - Total - Dissolved	EPA 200.8	520	µg/L	2	1	2.0	08/04/09	08/06/09
Silica - Total (SiO2) - Dissolved	EPA 200.7	45	mg/L	0.20	1	0.20	08/04/09	08/06/09
Silver (Ag) - Dissolved	EPA 200.7	ND	mg/L	0.010	1	0.010	08/04/09	08/06/09
Sodium (Na) - Dissolved	EPA 200.7	540	mg/L	1.0	10	10	08/04/09	08/06/09
Strontium (Sr) - Dissolved	EPA 200.8	5500	µg/L	1.0	5	5.0	08/04/09	08/06/09
Sulfate (SO4)	EPA 300.0	2400	mg/L	2	50	100	08/05/09	08/05/09
Sulfide (S) - Total	SM 4500-S E	ND	mg/L	0.10	1	0.10	08/05/09	08/05/09
Thallium (Tl) - Dissolved	EPA 200.8	ND	µg/L	1.0	1	1.0	08/04/09	08/06/09
Tin (Sn)	EPA 200.8	ND	µg/L	5.0	1	5.0	08/04/09	08/06/09
Titanium (Ti) - Dissolved	EPA 200.7	ND	mg/L	0.050	1	0.050	08/04/09	08/06/09
Total Dissolved Solids (TDS)	SM 2540 C	4900	mg/L	5.0	1	5.0	08/05/09	08/07/09
Total Organic Carbon (TOC)	SM 5310-C	1.5	mg/L	0.20	1	0.20	08/06/09	08/06/09
Total Suspended (TSS)	SM 2540 D	13	mg/L	5.0	1	5.0	08/05/09	08/07/09
Vanadium (V) - Dissolved	EPA 200.8	ND	µg/L	10	1	10	08/04/09	08/06/09
Zinc (Zn) - Dissolved	EPA 200.7	ND	mg/L	0.050	1	0.050	08/04/09	08/06/09

mg/L: Milligrams/Liter (ppm)  
 mg/Kg: Milligrams/Kilogram (ppm)  
 µg/L: Micrograms/Liter (ppb)  
 µg/Kg: Micrograms/Kilogram (ppb)  
 %Rec: Percent Recovered (surrogates)

PQL: Practical Quantitation Limit  
 DLR: Detection Limit for Reporting  
 : PQL x Dilution  
 ND: None Detected at DLR  
 pCi/L: Picocurie per Liter

H: Analyzed outside of hold time  
 P: Preliminary result  
 S: Suspect result. See Case Narrative for comments.  
 E: Analysis performed by External laboratory.  
 See External Laboratory Report attachments.  
 MDC: Min Detectable Concentration


Report Authentication Code: [Barcode]

---

**APPENDIX C**

**Water Balance**

---



3	Revised Water Disposal	DES			8/15/08
2	Revised Supply Water	DES			
1	Added UF Skid	BMC	DES	REB	6/30/09
0	Issued For Construction	REB	BMC	BMC	2/28/08
Rev	DESCRIPTION	Drawn	Chk	Appr	Date

PAMOCH ENERGY CENTER, LLC	
<b>Kiewit</b>	
8401 Renner Blvd Lawton, Kansas 67218	
WATER BALANCE FLOW DIAGRAM	
Drawn	REB 8/23/07
Checked	BMC 8/23/07
Approved	SAC 8/23/07
by	dtls
	DRAWING NUMBER
	2007-018 -W/B- 001

Modified for PTA

Page 1 of 3

Pamoche Energy Center  
KPE Project No. 2007-018

Notes:

- 1) All Flows are displayed in GPM
- 2) Based on GE APPS performance
- 3) RO 1st Pass Recovery Rate 75%
- 4) RO 2nd Pass Recovery Rate 85%
- 5) Overall RO Recovery Rate 72%
- 6) Cooling Tower Drift 0.0005%
- 7) Cooling Tower Drift 0.14 gpm
- 8) Cooling Twr Cycles of Conc. 3.00
- 9) Evap Cooler Cycles of Conc. 6.50
- 10) Evap Cooler demin split 69%
- 11) Service Water Use, gpm 5
- 12) Potable water demand 2.6
- 13) Annual Capacity Factor 57%
- 14) Weighted averages based on hours at the different operating conditions

PEAK DAY OPERATION

Case Number/ Case ID	NORMAL OPERATION				PEAK DAY OPERATION				
	1	2	3	4	5	6	7	8	9
Ambient Temperature	52	68	80	56	65	97	80	97	97
Wet Bulb Temperature	48	57	64	49	55	69	64	69	69
Relative Humidity	73.6	51.5	41.9	66.2	56.8	26.0	41.8	23.7	26.0
Ambient Pressure	14.500	14.500	14.500	14.500	14.500	14.500	14.500	14.500	14.500
Inlet Air Cooler Status	N/A	N/A	N/A	N/A	N/A	On	On	On	On
CTs in service	4	4	4	4	4	4	4	4	4
Description									
Flow from SW Tank	1157.0	1297.3	1375.5	1190.5	1265.8	1658.1	1379.1	1520.1	1519.4
SW Tank Net Flow	643.0	502.7	424.5	609.5	534.2	141.9	420.9	279.9	280.6
Supply Well Use	64%	72%	76%	66%	70%	92%	77%	84%	84%
Supply Wells to SW Tank	1800.0	1800.0	1800.0	1800.0	1800.0	1800.0	1800.0	1800.0	1800.0
Cooling Tower Makeup	790.1	923.4	994.5	823.5	892.9	1257.7	998.1	1129.2	1128.6
Service Water Flow	5.0	11.9	19.0	5.0	11.0	36.5	19.0	29.0	28.8
Service water to evap coolers	0.0	6.9	14.0	0.0	6.0	33.5	14.0	24.0	23.8
Washdown hose use	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0
UF System Feed	379.9	379.9	379.9	379.9	379.9	379.9	379.9	379.9	379.9
UF System Backwash	17.9	17.9	17.9	17.9	17.9	17.9	17.9	17.9	17.9
RO System Feed	362.0	362.0	362.0	362.0	362.0	362.0	362.0	362.0	362.0
RO Pass 1 Inlet Flow	407.8	407.8	407.8	407.8	407.8	407.8	407.8	407.8	407.8
RO Pass 2 Inlet Flow	305.9	305.9	305.9	305.9	305.9	305.9	305.9	305.9	305.9
RO Pass 2 Reject to Pass 1	45.9	45.9	45.9	45.9	45.9	45.9	45.9	45.9	45.9
RO Product Water	260.0	260.0	260.0	260.0	260.0	260.0	260.0	260.0	260.0
Potable water to admin bldg	2.6	2.6	2.6	2.6	2.6	2.6	2.6	2.6	2.6
Demin Tank Net Flow	17.1	8.7	4.7	17.1	11.3	-25.9	4.6	-11.2	-10.9
Water Treatment System Use	93%	97%	98%	93%	96%	100%	98%	100%	100%
Demineralized Water Flow	240.3	248.7	252.7	240.3	246.1	283.3	252.8	268.6	268.3
Demin water to evap coolers	0.0	15.4	31.2	0.0	13.4	74.5	31.1	53.3	53.1
NOx Injection	240.3	233.3	221.5	240.3	232.8	208.8	221.7	215.3	215.3
Evap cooler evaporation	0.0	18.9	38.3	0.0	16.4	91.4	38.2	65.4	65.1
Evaporative cooler blowdown	0.0	3.4	7.0	0.0	3.0	16.6	6.9	11.9	11.8
Inert cooler condensation	0.0	0.0	10.6	0.0	3.4	57.8	8.6	31.7	32.4
Cooling Tower Evaporation	526.7	617.9	674.7	549.0	599.5	887.9	675.8	781.9	781.9
RO rejects	102.0	102.0	102.0	102.0	102.0	102.0	102.0	102.0	102.0
Oil/Water Sep Effluent	22.9	22.9	22.9	22.9	22.9	22.9	22.9	22.9	22.9
Cooling Tower Blowdown	263.4	308.9	337.4	274.5	299.7	444.0	337.9	390.9	390.9
Wastewater Flow - WT Operating	386.2	433.8	462.2	399.4	424.6	568.8	462.8	515.8	515.8
Wastewater Flow - Average	381.5	430.4	460.4	392.6	420.2	568.8	461.0	515.8	515.8

Case Number/ Case ID	NORMAL OPERATION				PEAK DAY OPERATION				
	1	2	3	4	5	6	7	8	9
Daily Operation	18	18	24	18	20	6	6	12	24
Water Used	1,250	1,401	1,981	1,286	1,526	597	496	1,095	2,188
Wastewater Made	412	465	653	424	507	205	166	371	742

Case Number/ Case ID	NORMAL OPERATION				PEAK DAY OPERATION				
	1	2	3	4	5	6	7	8	9
Annual Operation	1,100	1,100	1,600	1,200	1,200	5,000	5,000	5,000	5,000
Water Use	76,364	85,621	132,050	85,716	379,751	263	1,166	2,188	2,188
Wastewater	234	263	405	263	1,166	100	87	186	387
Creation	25,177	28,406	44,197	28,269	126,049	87	87	186	387

3	Revised Supply Water	USE	
2	Revised Supply Water	USE	
1	Added UF Sids	BMC	DES
0	Issued For Construction	REB	BMC

PANOCHO ENERGY CENTER, LLC

**OKIEWIT**  
8401 Renner Blvd  
Lenexa, Kansas 66219

WATER BALANCE FLOW VALUES

Drawn	REB	8/23/07	DATE	DRAWING NUMBER
Checked	BMC	8/23/07		
Approved	SMG	8/23/07		2007-018 -WB- 002


**WATER QUALITIES**

Stream Diagram ID	Supply / Svc Wtr		Demin Water		Evap Cir Blwdown		RO Rejects		OWS Effluent		Circulating Water		Wastewater	
	as such	as CaCO3	as such	as CaCO3	as such	as CaCO3	as such	as CaCO3	as such	as CaCO3	as such	as CaCO3	as such	as CaCO3
<b>CATIONS</b>														
Ca	16.0	40	0.16	0.40	32	81	57	142	16.0	40	48	120	48	121
Mg	3.9	16	0.04	0.16	8	32	14	57	3.9	16	12	48	12	48
Na	439	953	0.80	1.74	885	1920	1558	3382	439	953	1317	2858	1325	2876
K	2.5	3	0.01	0.01	5	6	9	11	2.5	3	8	10	8	10
<b>Total</b>		1012		2.31		2039		3592		1012		3036		3054
<b>ANIONS</b>														
M/Alk	190	200		1.00		403		710		200		150		150
SO4	645	671	0.65	0.67	1300	1352	2290	2381	645	671	2368	2462	2383	2479
Cl	100	141	0.40	0.56	202	284	355	501	100	141	300	423	302	426
NO3	0.0	0	0.00	0.00	0	0	0	0	0.0	0	0	0	0	0
CO2	1.14	2			3	3								
SiO2	0.84	52.0	0.10	2.23	105	2039	185	3592	52.0	1012	156	3035	157	3054
<b>Total</b>		180		8.0		113		199		180		8.0		7.0
pH	8.4		6.0 - 8.0		8.0		8.5		8.4		8.0		8.0	
Total Hardness		56	<1.0	0.56	3962		6949		2100		6564		6606	
Spec Cond	2100				2547		4467		1258		4220		4247	
TDS	1350		2		50.0				0.0		50.0		35.7	
TSS	0.0								0.0		100.0		71.3	
Turbidity	0.0								0.0		0.5		0.3	
Ortho Phosphate	0.0		0.0		0.0		0.0		0.0		1.0		0.7	
Chlorine Residual	0.0		0.0		0.0		0.0		0.0					
Oil/Grease	0.0		0.0		0.0		0.0		0.0					
BOD5	0.0						18		0					
COD	0.41				0.83		1.46		0.41		1.23		1.24	
F	0.36				0.73		1.28		0.36		1.08		1.09	
<b>Trace Metals, ppb</b>														
Aluminum	0		0.00		0		0		0					
Antimony	0		0.00		0		0		0					
Arsenic	31		0.09		62		110		31		93		94	
Ba	0		0.00		0		0		0					
Beryllium	0		0.00		0		0		0					
Boron	3500		10.50		7053		12425		3500		10500		10565	
Cadmium	0		0.00		0		0		0					
Chromium	0		0.00		0		0		0					
Copper	0		0.00		0		0		0					
Cyanide	0		0.00		0		0		0					
Iron	79		0.24		159		280		79		237		238	
Lead	0		0.00		0		0		0					
Manganese	53		0.16		107		188		53		159		160	
Mercury	0.00		0.00		0		0		0					
Molybdenum	51		0.15		103		181		51		153		154	
Nickel	0		0.00		0		0		0					
Phosphorus	135		0.41		272		479		135		405		408	
Selenium	3.8		0.01		8		13		4		11		11	
Silver	0		0.00		0		0		0					
Strontium	150		0.45		302		533		150		450		453	
Thallium	0		0.00		0		0		0					
Tin	0		0.00		0		0		0					
Titanium	0		0.00		0		0		0					
Vanadium	0		0.00		0		0		0					
Zinc	0		0.00		0		0		0					

- Notes:
- 1) Values are expressed as mg/l (ppm) or standard units except as noted.
  - 2) Sodium was added to provide a balance of cations and anions.
  - 3) RO Reject Concentration
  - 4) Supply water based upon a combination of samples received on 8/11/08 and 10/6/08.
  - 5) Wastewater pH is controlled with acid injection
  - 6) Evap cooler blowdown and intercooler condensate (P&Q) are added to the circ water system. Their water quality impacts are negligible.

3	Revised Supply Water Quality	DES	
2	Revised Supply Water	DES	
1	Original Supply Water	BMC	DES
0	Issued For Construction	REB	BMC

PANOCHO ENERGY CENTER, LLC



9401 Renner Blvd  
Lawton, Kansas 66219

**WATER BALANCE WATER QUALITIES**

Drawn	by	date	
Checked	REB	8/23/07	
Approved	BMC	8/23/07	
	SMD	8/23/07	

DRAWING NUMBER  
2007-018 W/B-003


---

**APPENDIX D**


**Groundwater Modeling Figures**

---

**Groundwater Model  
Panoche Energy Center**



**Model grid plan view**




**Model grid (Cross-section, vertical exaggeration = 50)**


**Model Domain:**  
 Length=10.0 miles = 52,800 ft  
 Width = 10.0 Miles = 52,800 ft  
 Thickness = 490 ft  
**Model Grid:**  
 Pond area: 25X25 ft  
 Model edge: 1,000X1,000 ft  
 Rows = 95  
 Columns = 121  
 Layers = 30  
**Aquifer Parameters:**  
 K\_h = 10 feet/day  
 K\_v = 0.1 foot/day  
 natural gradient = 0.005

Layer Thickness (ft)	Final 20 layers
10	Layer 21
12	Layer 22
14	Layer 23
17	Layer 24
20	Layer 25
24	Layer 26
28	Layer 27
35	Layer 28
40	Layer 29
50	Layer 30






**Infiltration area: 1000 X 300 ft**  
**Infiltration rate: 0.154 ft/day**  
**Maximum Head:**  
**Pond Center: 32.0 ft**  
**Pond dg. Edge: 19.5 ft**




Plan view simulated head in 3D model

Pond




Cross-section view contour map of simulated hydraulic head distribution along the pond centerline





Cross-section view contour map of simulated TDS concentration (mg/L) along the pond centerline (T=20 years)



**Plan view contour map of simulated TDS concentration along the pond centerline (T=20 years)  
(Contour level = 4250, 4300, 4350, 4400, 4450, and 4470 mg/L)**

**TDS Concentration vs Pond Discharge Time**

