## POWER AUTHORITY P.O. Box 15830 · Sacramento, CA · 95852-1830 · SPA Cogeneration Project

DOCKET
93-AFC-3C
DATE FEB 2 4 2009
RECD. FEB 2 4 2009

February 24, 2009 SPA 09-005

Mary Dyas
Compliance Project Manager
California Energy Commission
Siting, Transmission & Environmental Protection Division
1516 Ninth Street
Sacramento, CA 95814

Re: Sacramento Power Authority (SPA) – Docket No. 93-AFC-3C Errata to Petition to Amend Conditions of Certification

Dear Ms. Dyas:

Please accept the following errata to the petition to amend the Conditions of Certification (COCs) for the Sacramento Power Authority (SPA) at Campbell Cogeneration Project, 93-AFC-3C, filed with the Commission on February 9, 2009. The correction occurs in Table 9 of the January 27, 2009 SPA application for Authority to Construct to the Sacramento Metropolitan Air Quality Management District, which is included as one of the petition attachments.

Table 9 Maximum Ambient Impacts, (μg/m3)						
Pollutant	Averaging Time	SPA Project Impact (µg/m³)	Background Conc. <sup>a</sup> (µg/m <sup>3</sup> )	Total Impact (µg/m³)	State Standard (µg/m³)	Federal Standard (µg/m³)
NO <sub>2</sub>	1-hour	182	. 147	329	339	-
CO	1-hour	3,637	5,470	9,107	23,000	40,000
CO	8-hour	1,775	4 <del>,620</del> 4.889	<del>7,876</del> <u>6,664</u>	10,000	10,000

This erratum corrects a transcription error in the Table 9 values for the 8-hour CO background concentration and total impact. As indicated in Table 9, this correction results in lower listed total impacts for the CO emissions from the project's commissioning activities.

If there are any questions, please contact me at (916) 732-6246.

Sincerely,

Stuart Husband

Regulatory Compliance Coordinator

Stuart Husband

Enclosure

Cc: Jeff Adkins, Sierra Research

Ross Gould, SMUD Kurt Hook, WGPO

Lourdes Jimenez-Price, SMUD

SPA Files 1600.01 Corporate Files