

**From:** Pierre Martinez  
**To:** Maria Santourdjian  
**Date:** 9/30/2010 9:32 AM  
**Subject:** Fwd: RE: Oakley Traffic Question

<b>DOCKET</b>	
<b>09-AFC-4</b>	
DATE	<u>09/29/10</u>
RECD.	<u>09/30/10</u>

Maria, below is the email string I just gave you a hard copy of.

Thanks,

Pierre

Pierre Martinez, AICP  
Project Manager

California Energy Commission  
Siting, Transmission and Environmental Protection Division  
1516 Ninth Street, MS 15  
Sacramento, CA 95814  
phone: 916-651-3765  
fax: 916-654-3882  
Email: [pmartine@energy.state.ca.us](mailto:pmartine@energy.state.ca.us)

>>> <[Doug.Davy@CH2M.com](mailto:Doug.Davy@CH2M.com)> 9/29/2010 3:13 PM >>>  
Scott and Pierre,

The project will involve replacing the existing line with a new 230 kV line. The existing line crosses the highway overhead and the new one will also. The new line involves replacing the existing steel lattice towers with new monopoles. PG&E has designated a pull-and-tensioning site in a vineyard just west of the highway crossing.

Doug Davy  
CH2M HILL  
(916) 286-0278  
[ddavy@ch2m.com](mailto:ddavy@ch2m.com)

-----Original Message-----

From: Pierre Martinez [<mailto:PMartine@energy.state.ca.us>]  
Sent: September 29, 2010 3:11 PM  
To: Scott Debauche  
Cc: Davy, Doug/SAC  
Subject: Re: Oakley Traffic Question

Hi Scott, I don't know off the top of my head. I believe you would find a quicker answer from the applicant if you don't mind making the call. My primary contact at CH2M Hill is Doug Davey, the project manager.

I am copying Doug on this email so that can get looking into it for you. You can contact Doug directly at 916-286-0278

Regards,

Pierre

Pierre Martinez, AICP  
Project Manager

California Energy Commission  
Siting, Transmission and Environmental Protection Division  
1516 Ninth Street, MS 15  
Sacramento, CA 95814  
phone: 916-651-3765  
fax: 916-654-3882  
Email: [pmartine@energy.state.ca.us](mailto:pmartine@energy.state.ca.us)

>>> Scott Debauche <[SDebauche@aspeneq.com](mailto:SDebauche@aspeneq.com)> 9/29/2010 3:02 PM >>>

Hello Pierre. I am finally underway on the Oakley project and have a question for you that I cannot find an answer for in either AFC Section 2.0 or 3.0 (I apologize if the answer is elsewhere for me). Figure 3.2-1 shows the proposed 230-kV transmission line crossing SR 160. Do we know if they plan on pipe jacking under that roadway or if they are proposing an overhead line? Please let me know if you have that answer or any ideas on how I can get it. I'm happy to contact the applicant directly if that is easiest. Much thanks, Scott

Scott Debauche  
Environmental Planner  
Aspen Environmental Group  
30423 Canwood Street, Suite 215  
Agoura Hills, CA 91301  
(323) 381-8999 Cell  
(818) 597-8001 Fax