



BAY AREA
AIR QUALITY
MANAGEMENT
DISTRICT
SINCE 1955

January 21, 2011

DOCKET
09-AFC-4

DATE 01/21/11

RECD. 01/24/11

ALAMEDA COUNTY
Tom Bates
(Vice Chairperson)
Scott Haggerty
Jennifer Hosterman
Nate Miley

Mr. Pierre Martinez, AICP
Project Manager
California Energy Commission
1516 Ninth Street, MS-15
Sacramento, CA 95814-5512

Re: Oakley Generating Station, Oakley, CA
BAAQMD Application 20737

CONTRA COSTA COUNTY
John Gioia
(Secretary)
David Hudson
Mark Ross
Gayle B. Uilkema

Dear Mr. Martinez:

The District has prepared a Final Determination of Compliance (FDOC) for the proposed Oakley Generating Station.

MARIN COUNTY
Harold C. Brown, Jr.

The proposed Oakley Generating Station consists of two gas turbines, two heat recovery steam generators, one steam turbine, with associated equipment including an air-cooled condenser, a natural gas-fired auxiliary boiler, a 3-cell evaporative fluid cooler, a diesel-engine driven fire pump, and an oil-water separator. The facility would be located at 6000 Bridgehead Road, Oakley, CA in Contra Costa County.

NAPA COUNTY
Brad Wagenknecht
(Chairperson)

SAN FRANCISCO COUNTY
Chris Daly
Eric Mar
Gavin Newsom

The FDOC summarizes how the facility will comply with applicable air quality regulations, including BACT and emission offset requirements. The FDOC has satisfied the public notice and 30-day public comment requirements of District Regulations 2-2-405 and 406.

SAN MATEO COUNTY
Carol Klatt
Carole Groom

Enclosed is a copy of the FDOC.

SANTA CLARA COUNTY
Susan Garner
Liz Kniss
Ken Yeager

If you have any questions regarding this matter, please contact Kathleen Truesdell, Air Quality Engineer II, at (415) 749-4628 (ktruesdell@baaqmd.gov).

SOLANO COUNTY
James Sperring

Sincerely,

SONOMA COUNTY
Shirlee Zane
Pamela Torliatt

Jack P. Broadbent
Executive Officer/APCO

Jack P. Broadbent
EXECUTIVE OFFICER/APCO

Enclosure
JPB:kht

Spare the Air

The Air District is a Certified Green Business

Printed using soy-based inks on 100% post-consumer recycled content paper





BAY AREA
AIR QUALITY
MANAGEMENT
DISTRICT

Final Determination of Compliance

Oakley Generating Station

6000 Bridgehead Road
Oakley, CA 94561

Bay Area Air Quality Management District
Application 20798

January 2011

Kathleen Truesdell
Air Quality Engineer II

Table of Contents

1.	Introduction.....	1
2.	The Power Plant Permitting Process and Opportunities for Public Participation	3
3.	Project Description	5
3.1	The Oakley Generating Station’s Combined-Cycle “Fast-Start” Design for Intermediate-to-Baseload Operation:	5
3.2	Project Location	6
3.3	How the Project Will Operate	11
3.4	Project Ownership	16
3.5	Equipment Specifications.....	16
4.	Facility Emissions	17
4.1	Criteria Pollutants	17
4.1.1	Hourly Emissions from Gas Turbines	17
4.1.2	Emissions During Gas Turbine Startup, Shutdown, and Tuning Operations	18
4.1.3	Hourly Emissions from Auxiliary Boiler	19
4.1.4	Hourly Emissions from Fire Pump Diesel Engine	19
4.1.5	Daily Facility Emissions	19
4.1.6	Annual Facility Emissions.....	21
4.2	Toxic Air Contaminants.....	24
5.	Best Available Control Technology (BACT).....	27
5.1	Introduction.....	27
5.2	Gas Turbines	28
5.2.1	Best Available Control Technology for Oxides of Nitrogen (NO_x).....	28
5.2.2	Best Available Control Technology for Carbon Monoxide (CO).....	37
5.2.3	Best Available Control Technology for Precursor Organic Compounds (POC) ..	42
5.2.4	Best Available Control Technology for Particulate Matter (PM)	45

5.2.5	Best Available Control Technology for Sulfur Dioxide (SO ₂)	48
5.2.6	Best Available Control Technology For Startups, Shutdowns, and Combustor Tuning ⁴⁹	
5.2.7	Best Available Control Technology During Gas Turbine Commissioning.....	57
5.3	Fire Pump Diesel Engine.....	62
6.	Requirement to Offset Emissions Increases.....	65
6.1	POC Offsets.....	65
6.2	NO _x Offsets	65
6.3	PM ₁₀ Offsets.....	65
6.4	SO ₂ Offsets.....	66
7.	Federal Permit Requirements	67
7.1	Federal “Prevention of Significant Deterioration” Program.....	67
7.2	Non-Attainment NSR for PM _{2.5}	68
8.	Health Risk Screening Analyses.....	70
9.	Other Applicable Requirements	71
9.1	Applicable District Rules and Regulations	71
9.2	State Requirements.....	76
9.3	Federal Requirements	77
9.4	Greenhouse Gases	82
9.5	Environmental Justice.....	85
10.	Proposed Permit Conditions.....	86
11.	Final Determination	104
12.	Glossary of Acronyms	105

Appendices

Appendix A: Emission Calculations

Appendix B: Health Risk Analysis Results

**Appendix C: District Response to Comments on the Preliminary
Determination of Compliance**

**Appendix D: Comments Received on the Preliminary Determination of
Compliance**

List of Tables

TABLE 1: GAS TURBINE STEADY-STATE EMISSIONS RATES (PER TURBINE) ...	17
TABLE 2: COMBINED-CYCLE TURBINE/HRSG EMISSIONS (PER TURBINE) DURING STARTUP AND TUNING OPERATIONS.....	18
TABLE 3: MAXIMUM EMISSIONS PER SHUTDOWN (PER TURBINE)	18
TABLE 4: AUXILIARY BOILER EMISSION RATES.....	19
TABLE 5: FIRE PUMP DIESEL ENGINE EMISSION RATES.....	19
TABLE 6: MAXIMUM DAILY REGULATED CRITERIA AIR POLLUTANT EMISSIONS FROM EACH SOURCE.....	21
TABLE 7: MAXIMUM ANNUAL CRITERIA AIR POLLUTANT EMISSIONS FOR THE FACILITY.....	22
TABLE 8: MAXIMUM FACILITY TOXIC AIR CONTAMINANT (TAC) EMISSIONS	24
TABLE 9: NO_x EMISSION LIMITS FOR LARGE GAS TURBINES IN COMBINED-CYCLE POWER PLANTS.....	33
TABLE 10: CO EMISSION LIMITS FOR LARGE GAS TURBINES IN COMBINED-CYCLE POWER PLANTS.....	39
TABLE 11: POC EMISSION LIMITS FOR LARGE GAS TURBINES IN COMBINED-CYCLE POWER PLANTS.....	42
TABLE 12: PROPOSED STARTUP AND SHUTDOWN EMISSION LIMITS FOR OAKLEY GENERATING STATION.....	51
TABLE 13: STARTUP AND SHUTDOWN PERMIT LIMITS FOR SIMILAR COMBINED-CYCLE POWER PLANT PROEJCTS USING FAST-START TECHNOLOGY	55
TABLE 14: COMMISSIONING PERIOD EMISSION LIMITS	58
TABLE 15: COMMISSIONING SCHEDULE FOR OAKLEY GENERATING STATION	60
TABLE 16: HEALTH RISK ASSESSMENT RESULTS FOR THE PROJECT	70
TABLE 17: HEALTH RISK ASSESSMENT RESULTS FROM EACH SOURCE.....	70
TABLE 18: NEW SOURCE PERFORMANCE STANDARDS FOR COMBINED-CYCLE GAS TURBINES.....	78
TABLE 19: OAKLEY GENERATING STATION GHG EMISSIONS	84

List of Figures

FIGURE 1: PROJECT LOCATION	7
FIGURE 2: ARCHITECTURAL RENDERING.....	8
FIGURE 3: PLOT PLAN.....	10
FIGURE 4: OAKLEY GENERATING STATION COMBINED-CYCLE DIAGRAM	15

1. Introduction

The Bay Area Air Quality Management District (District) is issuing a Final Determination of Compliance pursuant to BAAQMD Regulation 2, Rule 3, Section 405, for the Oakley Generating Station, a proposed 624-megawatt natural gas-fired electric power generation facility that would be built at 6000 Bridgehead Road in Oakley, CA. The Final Determination of Compliance sets forth the District's analysis as to how the facility will comply with applicable air quality regulatory requirements, as well as permit conditions to ensure compliance. The District has previously published a Preliminary Determination of Compliance for public review and comment, and has reviewed and considered all comments received from the public before issuing this Final Determination of Compliance (FDOC).

The proposed Oakley Generating Station project will be a combined-cycle intermediate-to-baseload power plant that uses a state-of-the-art "Rapid Response" design for fast startups. This design means that the proposed facility will be able to operate efficiently both to meet contractual load and spot-sale demand for shaping or load-following generation, and on a full-time, base-loaded basis. As a combined-cycle facility, the proposed project will use Heat Recovery Steam Generators (HRSGs) to recover waste heat in the exhaust gases to make steam to generate additional power, increasing the plant's overall efficiency. This highly efficient design will allow the facility to operate efficiently when needed full-time in a base-loaded mode. In addition, the proposed project's "Rapid Response" design will allow fast startups, so that it can provide power to the grid quickly. The proposed facility will thus provide energy-efficient electric generation capacity using new conventional generation technology, with operational flexibility to efficiently address grid fluctuations due to the intermittent nature of renewable generation such as wind and solar.

The proposed project consists of two GE Frame 7FA gas turbines, two heat recovery steam generators (HRSGs), and one GE D-11 steam turbine in a combined-cycle configuration, with associated equipment including an air-cooled condenser, a natural gas-fired auxiliary boiler, a 3-cell evaporative fluid cooler, a diesel engine-driven fire pump, and an oil-water separator. More detail about the proposed facility is provided in Section 3 below (Project Description).

This FDOC sets forth the District's reasons and analysis underlying the District's determination that the project will comply with all applicable regulatory requirements relating to air quality. These requirements include applying Best Available Control Technology and providing emission offsets as described in District Regulation 2, Rule 2. This document also includes permit conditions necessary to ensure compliance with applicable rules and regulations, air pollutant emission calculations, and a health risk assessment that estimates the impact of emissions from the project on public health.

This remainder of this document is organized as follows. Section 2 provides an overview of the legal framework for power plant permitting in California and describes how members of the public can learn more about the project and provide input to the California Energy Commission. Section 3 then proceeds to describe the proposed Oakley Generating Station project. Section 4 details the project's air emissions. Sections 5 and 6 then describe the "Best Available Control Technology" and emissions offset requirements for the project and how the proposed facility will

comply with them. Section 7 addresses two federal permitting requirements, the “Prevention of Significant Deterioration” requirement and the “Non-Attainment New Source Review” requirement for fine particulate matter, and explains how this facility is not subject to those requirements. Section 8 presents the results of the Health Risk Screening Analysis the District has conducted for the project, which found that the health risks from the project will be less than significant. Section 9 addresses other applicable legal requirements for the proposed project. Section 10 sets forth the permit conditions for the project. Section 11 concludes with the District’s Final Determination of Compliance for the project.

2. The Power Plant Permitting Process and Opportunities for Public Participation

The California Energy Commission (Energy Commission or CEC) is the primary permitting authority for new power plants in California. The California Legislature has granted the Energy Commission exclusive licensing authority for all thermal power plants in California of 50 megawatts or more. (See Warren-Alquist State Energy Resources Conservation and Development Act, Cal. Public Resources Code §§ 25000 *et seq.*) This licensing authority supersedes all other local and state permitting authority. The intent behind this system is to streamline the licensing process for new power plants while at the same time providing for a comprehensive review of potential environmental and other impacts.

As the lead permitting agency, the CEC conducts an in-depth review of environmental and other issues posed by the proposed power plant. This comprehensive environmental review is the equivalent of the review required for major projects under the California Environmental Quality Act (CEQA), and the Energy Commission's license satisfies the requirements of CEQA for these projects. This CEQA-equivalent review encompasses air quality issues within the purview of the District, and also includes all other types of environmental and other issues, including water quality issues, endangered species issues, and land use issues, among others.

The District collaborates with the Energy Commission regarding the air quality portion of its environmental analysis and prepares a "Determination of Compliance" that outlines whether and how the proposed project will comply with applicable air quality regulatory requirements. The Determination of Compliance is used by the Energy Commission to assess air quality issues of the proposed power plant. This document presents the District's Final Determination of Compliance for the proposed Oakley Generating Station. The District solicited and considered public input on the Preliminary Determination of Compliance, and is issuing a Final Determination of Compliance for use by the Energy Commission in its CEQA-equivalent environmental review. The CEC will conduct its environmental review, and at the end of that process, it will decide whether to issue a license for the project and under what conditions.

Both the Energy Commission licensing process and the District's Determination of Compliance process relating to air quality issues provide opportunities for public participation. For the District's Determination of Compliance, the District published its preliminary determination – the PDOC – and invited interested members of the public to review and comment on it. This public process allowed members of the public to review the District's analysis of whether and how the facility will comply with applicable regulatory requirements and to bring to the District's attention any area in which members of the public believe the District may have erred in its analysis. This process helps improve the District's final determination by bringing to the District's attention any areas where interested members of the public disagree with the District's proposal at an early enough stage that the District can correct any deficiencies before making the final determination. The Energy Commission provides similar opportunities for public participation, and publishes its proposed actions for public review and comment before taking any final actions.

The District published its Preliminary Determination of Compliance on October 29, 2010. The public comment period for the PDOC was noticed in the Contra Costa Times on November 6, 2010 and the comment period ended on December 7, 2010. Comments were received from two members of the public, the applicant, and the CEC.

At this time, the District is publishing its Final Determination of Compliance for the project. The District has considered the comments received on the PDOC in determining whether to issue a Final Determination of Compliance and on what basis. All comments received during the comment period were considered by the District and addressed as necessary in the Final Determination of Compliance. The District's response to comments is included in Appendix C.

The power plant approval process also provides opportunities for members of the public to participate in person in public hearings regarding this project. Members of the public will be afforded an opportunity to participate in public hearings regarding the project at the Energy Commission as part of the Commission's environmental review process. The public hearings before the Energy Commission will encompass all aspects of the project, including air quality issues and all other environmental issues.

Interested members of the public are invited to learn more about the project as part of the public review process. Detailed information about the project and how it will comply with applicable regulatory requirements are set forth in the subsequent sections of this document. All supporting documentation, including the permit application and data submitted by the applicant and all other information the District has relied on in its analysis, are available for public inspection at the District Headquarters, 939 Ellis Street, San Francisco, CA, 94109. This FDOC and the principal supporting documentation are also available on the District's website at www.baaqmd.gov. The public may also contact Ms. Truesdell for further information (see contact information above). **Para obtener información en español, comuníquese con Brenda Cabral en la sede del Distrito, (415) 749-4686, bcabral@baaqmd.gov.**

In addition to the District's permitting process involving air quality issues, interested members of the public are also invited to participate in the Energy Commission's licensing proceeding, which addresses other environmental concerns including those that are not related to air quality. For more information, go to the following CEC website: www.energy.ca.gov/sitingcases/oakley/. The public may also contact the Energy Commission's Public Adviser's office at:

Public Adviser
California Energy Commission
1516 Ninth Street, MS-12
Sacramento, CA 95814
Phone: 916-654-4489
Toll-Free in California: 1-800-822-6228
E-mail: PublicAdviser@energy.state.ca.us

3. Project Description

The Oakley Generating Station project is a proposed 624-megawatt combined-cycle intermediate-to-baseload power plant to be located at 6000 Bridgehead Road in Oakley, CA. This section describes the how the proposed project will function, describes where it will be located, and provides information about the specific equipment being proposed for the project.

3.1 The Oakley Generating Station's Combined-Cycle "Fast-Start" Design for Intermediate-to-Baseload Operation:

The proposed Oakley Generating Station project is a combined-cycle intermediate-to-baseload power plant, meaning that it will be able to operate efficiently to meet both contractual load and spot sale demand for electrical power, and on a full-time, base-loaded basis.¹

The facility will be a combined-cycle power plant. In a combined-cycle plant, gas turbines burn natural gas to generate electricity, and then the heat from the gas turbine exhaust is used to produce steam in a heat recovery steam generator (HRSG) to generate additional electricity via the steam turbine. The recovery of energy from the gas turbine exhaust, which otherwise would be wasted, increases the efficiency of electrical generation. Combined-cycle operation is the most efficient type of operation for a natural-gas-fired power plant, and it is typically used for base-loaded facilities that will operate full-time or near full-time. The drawback of conventional combined-cycle operation is that it takes longer for the facility to start up because the HRSG and steam turbine have to be brought up slowly to a high temperature before the plant can come on-line. Combined-cycle facilities have therefore been traditionally used for base-loaded facilities, whereas simple-cycle facilities – which use just a gas turbine and not a HRSG and steam turbine – have been used for “peaker” plants that operate only at times of peak electrical demand. Peaker plants need to come on-line quickly to be able to respond to fluctuations in demand, but they are not operated for long periods so their less-efficient design is not as great a concern.

The proposed project would overcome many of the drawbacks inherent in traditional combined-cycle operation by utilizing GE's 207FA Fast Start Rapid Response Engineered Equipment Package, which is designed to have improved operational flexibility over conventional combined-cycle power plants. The Rapid Response package allows the plant to start up significantly faster than conventional combined-cycle plants by uncoupling the steam turbine as the gas turbine ramps up and comes on-line. The steam turbine is brought on-line more slowly to allow the equipment to heat up. Using this Rapid Response package, the proposed plant will be able to complete hot startups in less than 30 minutes and cold startups in less than 90 minutes. By contrast, conventional combined-cycle power plants can take up to three hours for hot startups and six hours for cold startups. The shorter startup periods of the proposed plant mean that it can come on-line and provide electricity to the grid more quickly, and also translate to reduced startup emissions; while the combined-cycle configuration retains high thermal efficiency. This fast startup capability coupled with high efficiency will give the plant a high degree of operational flexibility, which will allow it to rapidly respond to grid fluctuations that

¹ See PG&E *All Source Long-Term Request for Offers*, April 1, 2008

will result as more intermittent renewable resources are integrated into the grid while providing highly efficient generating capacity.

3.2 Project Location

The proposed Oakley Generating Station would be located at 6000 Bridgehead Road in Oakley, CA, on a 21.95-acre industrial site currently part of a 210-acre parcel owned by E. I. Du Pont de Nemours and Company (DuPont). To the west of the project site is the PG&E Antioch Terminal natural gas transmission hub, to the north is DuPont industrial and vacant industrial property, to the east is a DuPont's landfill area, and to the south is the Atchison, Topeka and Santa Fe railroad. Currently, the proposed site is partly in viticultural use and partly undeveloped space. The proposed project location is identified on the Project Location Map below (Figure 1). (Note that the map also identifies the locations of two other existing natural gas-fired power plants in the area, the Contra Costa Power Plant and the Gateway Generating Station, as well as the location of the recently-permitted Marsh Landing Generating Station, which is intended as a replacement for the Contra Costa Power Plant. The Contra Costa Power Plant is scheduled to shut down before the Marsh Landing Generating Station becomes operational, and before the proposed Oakley Generating Station would start operating.) An architectural rendering of the proposed project (Figure 2) and a plot plan (Figure 3) are also provided.

FIGURE 1: PROJECT LOCATION





FIGURE 2: ARCHITECTURAL RENDERING




Source: Environmental Vision, May 2009

EY042009001284/C Figure_1.1-4.a1 05.24.09 10:52

ARCHITECTURAL RENDERING
CONTRA COSTA GENERATING STATION
OAKLEY, CALIFORNIA

CH2MHILL

FIGURE 3: PLOT PLAN



Source: Black & Veatch Holding Company, 03/26/09, Drawing 163994-SS-1002 R1

EY04209002SAC Figure_2.1-2.m 06.12.09 mda

FIGURE 3 LEGEND

FACILITIES LEGEND

[illegible]

NOTES

1. COORDINATES ARE BASED ON CALIFORNIA COORDINATE SYSTEM CCS83, ZONE 3. ELEVATION ARE BASED ON, NGVD 29 DATUM. BENCHMARK IS NATIONAL GEODETIC SURVEY BENCH MARK "W 563", LOCATED ADJACENT TO THE FLAGPOLE AT THE DUPONT PLANT ENTRANCE, ELEVATION = 11.168 FEET. TO OBTAIN DUPONT PLANT DATUM ELEVATION, ADD 0.70 FEET TO THE ELEVATIONS SHOWN. TOPOGRAPHIC DATA IS BASED ON AERIAL PHOTOGRAPH DATED JUNE 11, 2001. AERIAL SURVEY INFORMATION WAS OBTAINED BY RONALD GREENWELL & ASSOCIATES, INC.
2. SEE PLANT ARRANGEMENT DRAWING SM-2001, FOR LEGEND OF MAIN POWER BLOCK.
3. PROPERTY AND EASEMENT BOUNDARY INFORMATION IS BASED UPON DRAWING EXHIBIT D, BY RONALD GREENWELL & ASSOCIATES, INC. REVISION DATED 05/FEB/09.

GENERAL LEGEND

	NEW FENCE		EASEMENT BOUNDARY (SEE NOTE 3)
	EXISTING FENCE		LANDSCAPE BUFFER
	PROPERTY BOUNDARY (SEE NOTE 3)		

3.3 How the Project Will Operate

The proposed facility would generate electric power for the grid using gas turbines and a steam turbine in a combined-cycle configuration. As noted above, “combined-cycle” means that the facility generates power from burning fuel in the gas turbines directly, and then also generates additional power using the heat in the turbine exhaust by making steam to turn a steam turbine. Generating additional power from the heat in the turbine exhaust, which would otherwise be wasted, increases the facility’s overall energy efficiency. This type of operation is represented schematically in Figure 4.

- Power Generating Equipment

The gas turbines generate power by burning natural gas, which expands as it burns and turns the turbine blades, which in turn rotate an electrical generator to generate electricity. The main components of the system consist of a compressor, combustor, and turbine. Each gas turbine will be equipped with an inlet air filter and an evaporative cooler to lower the temperature of the inlet air to the compressor and increase the mass of the inlet air during hot days, which increases power output. The compressor compresses combustion air to the combustor where the fuel is mixed with the combustion air and burned. Hot exhaust gases then enter the power turbine where the gases expand across the turbine blades, rotating a shaft to power the electric generator. The proposed two GE Frame 7FA gas turbines will be equipped with dry low NO_x combustors to reduce NO_x emissions and larger compressors than previous 7FA models.²

After exiting the gas turbine, the hot exhaust gases are then sent to a heat recovery steam generator (HRSG), which makes steam from the hot exhaust gases. The proposed facility will use a triple-pressure, reheat, natural circulation HRSG³ without duct burners. Triple-pressure reheat HRSGs maximize the amount of heat extracted from exhaust gases that would otherwise be wasted and produce high pressure (HP), intermediate pressure (IP), and low pressure (LP) steam. Under normal operating conditions, this steam is sent to a steam turbine to generate additional electricity, thereby increasing overall thermal efficiency. The reheat cycle⁴ extracts more heat from the exhaust gases by reheating the cold reheat steam (steam exiting the HP section of the steam turbine) combined with superheated IP steam in the reheater sections of the HRSGs prior to being admitted to the IP section of the steam turbine. The reheat cycle makes the steam entering the IP section of the steam turbine hotter and drier, which reduces the potential for moisture erosion and increases steam turbine electrical output. Steam leaving the IP section of the steam turbine is combined with LP steam from the HRSG and enters the LP section of the steam turbine. Steam leaving the LP section of the steam turbine enters the air-

² For more information, see GE Energy 7FA Heavy Duty Gas Turbine Product Evolution, at p. 4.

³ For a detailed description of the HRSG, see Radback Energy, *Application for Certification Contra Costa Generating Station*, June 2009, Vol. 1, Section 2.1, at p. 2-14. (available at: <http://energy.ca.gov/sitingcases/oakley/documents/applicant/afc/index.php>)

⁴ For more information about the reheat cycle, see M. Boss, GE Power Systems, *Steam Turbines for STAGTM Combined-Cycle Power Systems* at p. 7-8. (available at: http://www.gepower.com/prod_serv/products/tech_docs/en/downloads/ger3582e.pdf)

cooled condenser, transfers heat to the ambient air, condenses and returns to the HRSG feedwater system.

After the exhaust gases exit the HRSGs, they will be routed to post-combustion emissions control devices to treat the exhaust gases prior to exit from the stack. The proposed post-combustion emissions controls consist of a Selective Catalytic Reduction (SCR) unit to reduce oxides of nitrogen (NO_x) in the exhaust and an oxidation catalyst to reduce organic compounds and carbon monoxide in the exhaust. In the SCR system, NO_x in the exhaust reacts with ammonia and oxygen in the presence of a catalyst to form nitrogen and water. A small amount of ammonia is not consumed in the reaction and is emitted in the exhaust stream as what is commonly called “ammonia slip”. The oxidation catalyst oxidizes the carbon monoxide and unburned hydrocarbons in the exhaust gases to form CO_2 and water. These emissions control devices are described in more detail in Section 5.

Finally, the facility will use an air-cooled condenser to condense the steam from the steam turbine and recycle it back to the HRSGs. The air-cooled condenser will take the place of the traditional wet cooling tower at other combined-cycle facilities. It will use ambient air blown by large fans across finned tubes through which the steam flows. The condensed steam (condensate) is recycled back to the HRSGs. The use of an air-cooled condenser significantly reduces the amount of water consumed by the facility.

- “Rapid Response” Startup Technology

In addition to having the higher thermal efficiency of a combined-cycle plant, the proposed facility is designed to be able to start up and dispatch quickly with GE’s Rapid Response package. The Rapid Response package allows the plant to start up from warm or hot conditions in less than 30 minutes. The Rapid Response package achieves this fast performance by initially bypassing the steam turbine when the gas turbines are started up. In a conventional combined-cycle system, the gas turbine needs to be held at low load for a period of time while the HRSG is warmed up and steam is gradually fed into the steam turbine and the steam turbine is brought up to operating temperature. The steam turbine needs to be brought up to operating temperature slowly in order to minimize thermal stresses on the equipment and to maintain the necessary clearances between the rotating and stationary components of the turbine. This delay necessitated by having to slowly warm up the HRSG and steam turbine means that the gas turbine cannot increase load as rapidly as a simple-cycle gas turbine to quickly provide power to the grid. It also causes increased startup NO_x and CO emissions, because the combustion turbine needs to be held at low load – where it is not as efficient – while the HRSG and steam turbine are warmed up. The “Rapid Response” system initially bypasses the steam turbine when the combustion turbines are started, allowing them to ramp up quickly and begin providing power to the grid. The steam turbine can then be warmed up slowly without requiring the combustion turbines to be held at low load (except for a short time for cold startups), through the controlled admission of steam from the HRSGs into the steam turbine. The Rapid Response package therefore allows the facility to start up and begin providing power more quickly than a conventional system, which will enhance operational flexibility and reduce emissions associated with startups.

As part of the “Rapid Response” package, the proposed facility would also use a 50.6 MMBtu/hr natural gas-fired auxiliary boiler that would provide auxiliary steam when the plant is offline and during startups. When the plant is offline for relatively short periods, the auxiliary boiler would provide steam to be used for condensate sparging (to keep the oxygen level in the condensate low in order to prevent corrosion in the HRSG) and steam turbine seals (to maintain the seals and prevent loss of vacuum in the steam turbine and condenser) to maintain the steam turbine in a warm and ready state and expedite startups. At conventional combined-cycle plants (and at the proposed Oakley Generating Station during extended periods of shutdown), the steam turbine and condenser vacuum is released and vacuum needs to be re-established prior to startup. By eliminating these delays, the auxiliary boiler will allow the steam turbine to come on-line sooner and begin providing power to the grid.

- Additional Equipment

In addition to the two gas turbines, two HRSGs, steam turbine, air-cooled condenser, and auxiliary boiler, the Oakley Generating Station is proposed to include an evaporative fluid cooler to provide cooling water used by various equipment at the site, an oil-water separator, and a fire pump diesel engine.

The evaporative fluid cooler would be a relatively small, 3-cell heat exchanger, which extracts heat from a closed loop cooling system.⁵ The closed loop cooling system provides cooling water to various plant equipment including gas turbine and steam turbine generator coolers, gas turbine and steam turbine lube oil coolers, and boiler feedwater pumps. During cool days, the evaporative fluid cooler would not be used. Instead, the closed-loop cooling water would be routed to an air-cooled heat exchanger that uses large fans to blow ambient air across the finned tubes carrying the closed-loop cooling water. During hot days when air-cooling would be insufficient to lower the temperature of the closed-loop cooling water, the evaporative fluid cooler would be used and circulating water would be sprayed over the tubes within the evaporative fluid cooler containing the closed-loop cooling water. The evaporation of the sprayed water would extract more heat from the closed-loop cooling water. Since this is a closed loop system, there is no contact between the closed-loop cooling water and the circulating water sprayed over the finned-tubes that evaporates. Water that is not evaporated would be captured in a sump at the bottom of the evaporative fluid cooler and circulated back to the top of the unit.

The proposed facility would have an oil-water separator to handle stormwater runoff from the powerblock area before discharge to the sanitary sewer system.⁶ In the event that stormwater runoff picks up any liquid hydrocarbons (*e.g.*, oil), the oil-water separator would remove them so that only water is discharged into the sanitary sewer system.

⁵ See Radback Energy, *Application for Certification Contra Costa Generating Station*, June 2009, Vol. 1, Section 2.1.8.5, at p.2-26. (available at: <http://www.energy.ca.gov/sitingcases/oakley/documents/applicant/afc/index.php>)


⁶ See Radback Energy, *Application for Certification Contra Costa Generating Station*, June 2009, Vol. 1, Section 5.15, at p.5.15-14. (available at: <http://www.energy.ca.gov/sitingcases/oakley/documents/applicant/afc/index.php>)

The proposed facility would also have a 400 hp diesel engine to power a fire pump onsite to be used in emergencies to provide water to fight fires in the event that electricity is not available for the electric-motor driven fire pumps.⁷ The diesel engine-driven fire pump would be used in case of emergency, and would also need to be operated periodically for short periods for testing and reliability purposes.

The schematic diagram in Figure 4 below illustrates how the proposed Oakley Generating Station works.

⁷ See e-mail from J. McLucas Radback Energy to K. Truesdell BAAQMD dated 10/6/10.

Figure 4: Oakley Generating Station Combined-Cycle Diagram



3.4 Project Ownership

The Oakley Generating Station is being developed by Contra Costa Generating Station, LLC (Applicant), wholly owned by Radback Energy, Inc. Contra Costa Generating Station, LLC and Radback Energy, Inc., intend to sell the project after it is built to PG&E, who would own and operate the facility thereafter.

3.5 Equipment Specifications

The proposed facility will use GE's 207FA Fast Start Rapid Response Engineered Equipment Package, including two GE Frame 7FA.05 natural gas-fired gas turbine-generators, each with a gross electrical output of 213 MW, and two unfired triple-steam-pressure heat recovery steam generators (HRSGs) that would feed one GE D-11 condensing steam turbine generator with a gross electrical output of 218 MW. Plant electrical auxiliary loads will be about 20 MW, so the net electrical output of the facility would be 624 MW. The proposed project also consists of an air-cooled condenser, a natural gas-fired auxiliary boiler, a 3-cell evaporative fluid cooler, a diesel engine-driven fire pump, and an oil-water separator.

The equipment that the Applicant has identified for use at the Oakley Generating Station will be identified by the following identification numbers:

- S-1 Gas Turbine Generator #1, GE Frame 7FA, Natural Gas-Fired, 213 MW, 2150 MMBtu/hr (HHV) maximum rated capacity with high-efficiency inlet air filter; abated by A-1 Selective Catalytic Reduction System (SCR) and A-2 Oxidation Catalyst
- S-2 Gas Turbine Generator #2, GE Frame 7FA, Natural Gas-Fired, 213 MW, 2150 MMBtu/hr (HHV) maximum rated capacity with high-efficiency inlet air filter; abated by A-3 Selective Catalytic Reduction System (SCR) and A-4 Oxidation Catalyst
- S-3 Auxiliary Boiler, Natural Gas-Fired, 50.6 MMBtu/hr maximum rated capacity (abated by A-5 Oxidation Catalyst if required)
- S-4 Fire Pump Diesel Engine, Clarke JW6H-UFAD80 (or equivalent), 400 hp, 2.78 MMBtu/hr maximum rated heat input
- S-5 Evaporative Fluid Cooler, 3-Cell, 5,880 gallons per minute (Exempt from District Permit requirements per Regulation 2, Rule 1, Section 128.4)
- S-6 Oil-Water Separator, 120 gallons per hour (Exempt from District Permit requirements per Regulation 2, Rule 1, Section 103 and Regulation 8, Rule 8, Section 113)

4. Facility Emissions

This section describes the air pollutant emissions that the Oakley Generating Station will have the potential to emit, as well as the principal regulatory requirements to which the emissions will be subject. Detailed emission calculations, including the derivations of emission factors, are presented in Appendix A.

4.1 Criteria Pollutants

A “criteria” air pollutant is an air pollutant for which health-based standards have been established for the amount of the pollutant in the ambient air. This section discusses the criteria air pollutants that the facility will emit, along with the facility’s maximum hourly, daily, and annual emissions rates.

4.1.1 Hourly Emissions from Gas Turbines

The Oakley Generating Station’s gas turbines will have the potential to emit up to the following amounts of criteria and precursor air pollutants per hour, as set forth in Table 1. These are the maximum emission rates for these air pollutants from each turbine during normal steady-state operations. Note that the emissions from the gas turbines will go to the HRSGs, where the heat in the exhaust will be used to make steam to generate additional power. The HRSGs will not fire any additional fuel, however, and so no additional emissions will be generated by them. The gas turbine emissions rates listed in this section therefore represent the emissions rates for the complete gas turbine/HRSG trains, although it is only the gas turbine equipment that actually generates the emissions. Emissions from this equipment will be measured at the stack at the end of the gas turbine/HRSG train, after abatement by the add-on control devices.

TABLE 1: GAS TURBINE STEADY-STATE EMISSIONS RATES (PER TURBINE)

Pollutant	Turbine Emissions Rate (lb/hr)
NO _x (as NO ₂)	15.52
CO	9.45
POC (as CH ₄)	2.71
PM ₁₀ /PM _{2.5}	7.74
SO _x (as SO ₂)	6.0

Note that particulate matter from natural gas combustion sources normally has a diameter less than one micron.⁸ The particulate matter will therefore be both PM₁₀ (particulate matter with a diameter of less than 10 microns) and PM_{2.5} (particulate matter with a diameter of less than 2.5 microns).⁹

⁸ See AP-42, Table 1.4-2, July 1998, at footnote c. (available at www.epa.gov/ttnchie1/ap42/ch01/final/c01s04.pdf).

4.1.2 Emissions During Gas Turbine Startup, Shutdown, and Tuning Operations

Maximum emissions during turbine startups and combustor tuning operations, when the turbines are at low load where they are not as efficient and when emissions control equipment may not be fully operational, are summarized in Table 2. (These operating scenarios are discussed in more detail in Section 5.2.6 below.) Table 2 shows the startup emissions and tuning emissions for each turbine. (Note that only NO_x, CO, and POC emissions are affected by reduced efficiency during startups. For PM and SO₂, emission rates will not be any greater than normal operation during startup, shutdown, or tuning.)

**TABLE 2: COMBINED-CYCLE TURBINE/HRSG EMISSIONS (PER TURBINE)
DURING STARTUP AND TUNING OPERATIONS**

Pollutant	Cold Startup (lb/event) ^a	Cold Startup (lb/hour) ^b	Hot/Warm Startup (lb/event) ^c	Hot/Warm Startup (lb/hour) ^d	Tuning (lb/event) ^e	Tuning (lb/hour)
NO _x (as NO ₂)	96.3	99.9	22.3	33.9	576.0	96
CO	360.2	362.4	85.2	92.2	2,160.0	360
POC (as CH ₄)	67.1	67.7	31.1	33.1	402.0	67

^a Cold Startups not to exceed 90 minutes; by definition, occurs after turbine has been inoperative for at least 48 hours

^b Hourly emissions with a cold startup assumes one cold startup in 45 minutes and 15 minutes of steady-state operation

^c Hot/Warm Startups not to exceed 30 minutes; by definition, occur between 0 and 48 hours after a shutdown

^d Hourly emissions with a hot or warm startup assumes one hot startup in 14 minutes and 46 minutes of steady-state operation

^e Combustor tuning not to exceed 8 hours per event and 2 tuning events per year per turbine. Note that emissions rates from combustor tuning may turn out to be lower than the rates listed here, and the District will evaluate turning emissions and potentially impose lower emissions limits once the facility commences operation. See Section 5.2.6.2. for further details. The rates listed here represent worst-case emissions.

Maximum emissions during gas turbine shutdowns (also discussed in detail in Section 5.2.6) are summarized in Table 3.

TABLE 3: MAXIMUM EMISSIONS PER SHUTDOWN (PER TURBINE)

Pollutant	Shutdown Emissions Rate (lb/shutdown) ^a	Shutdown Emissions Rate (lb/hour)
NO _x (as NO ₂)	39.3	46.8
CO	140.2	144.7
POC (as CH ₄)	17.1	18.4

^a Shutdowns not to exceed 30 minutes.

⁹ PM_{2.5} is a subset of particulate matter that has recently come under heightened regulatory scrutiny. EPA has established federal regulations for PM_{2.5}, but they do not apply to this facility as discussed in Section 7. The District is also in the process of developing regulations specifically directed to control PM_{2.5}, but those regulations are not in place yet. For this facility, however, the District's existing PM₁₀ regulations will be equally effective in controlling PM_{2.5} because all of the PM emissions from this facility will be both PM_{2.5} and PM₁₀.

4.1.3 Hourly Emissions from Auxiliary Boiler

The auxiliary boiler will have the potential to emit up to the following amounts of regulated air pollutants per hour, as set forth in Table 4.

TABLE 4: AUXILIARY BOILER EMISSION RATES

Pollutant	Steady-State Emissions Rate (lb/hr)	Startup/Shutdown^a Emissions Rate (lb/hr)	Commissioning/Tuning (lb/hr)
NO _x (as NO ₂)	0.42	1.27	2.55
CO	0.37	1.11	2.22
POC (as CH ₄)	0.11	0.32	0.63
PM ₁₀ /PM _{2.5}	0.35	0.35	0.35
SO _x (as SO ₂)	0.14	0.14	0.14

^a Startups make take up to one hour and shutdowns may take up to 15 minutes. Tuning required annually by District Regulation 9, Rule 7, section 313 in accordance with the procedures set forth in District Manual of Procedures, Volume I, Chapter 5.

4.1.4 Hourly Emissions from Fire Pump Diesel Engine

The fire pump diesel engine will have the potential to emit up to the following amounts of regulated air pollutants per hour, as set forth in Table 5. These are the emission rates for regulated air pollutants based on emission factors from CARB certification in Executive Order U-R-004-0369 for one hour of operation.

TABLE 5: FIRE PUMP DIESEL ENGINE EMISSION RATES

Pollutant	Fire Pump Diesel Engine Emissions Rate (lb/hr)
NO _x (as NO ₂)	2.311
CO	0.592
POC (as CH ₄)	0.122
PM ₁₀ /PM _{2.5}	0.105
SO _x (as SO ₂)	0.004

4.1.5 Daily Facility Emissions

Maximum daily emissions of regulated air pollutants emissions for the Oakley Generating Station are set forth in Table 6 below. The table shows emissions from the gas turbines, the auxiliary boiler, and the diesel engine-driven fire pump. The table also shows emissions from the evaporative fluid cooler and oil water separator, which are both exempt from District permit requirements.

Note that for NO_x, CO and POC, the daily maximum emission rates for the gas turbines are taken from the enforceable daily permit limits being proposed in condition Parts 18 and 19. The District is proposing these daily limits based on a reasonable assumption of the maximum

operation likely for this equipment. The District has assumed such a reasonable maximum operating scenario to consist of one cold startup lasting 45 minutes and with the maximum permitted cold startup emissions of 96.3 lb NO_x, 360.2 lb CO, and 67.1 lb POC; one shutdown lasting 30 minutes and with maximum permitted shutdown emissions of 39.3 lb NO_x, 140.2 lb CO, and 17.1 lb POC; and the remaining 22.75 hours of the day in normal steady-state operation. For days on which combustor tuning occurs (limited to twice per year per turbine), 8 hours of the 22.75 steady-state operating hours were assumed to involve combustor tuning with a limit of the equivalent of 6 hours of currently estimated maximum hourly emission rates for tuning. The District has based the proposed daily emissions limits on these assumptions as a reasonable scenario of maximum foreseeable daily emissions, but it is important to note that emissions from this equipment will be limited to these emissions rates regardless of actual operating profile. This is because the emissions limitations in condition Parts 18 and 19 are enforceable permit limits, and the facility will be required to keep emissions below these levels regardless of operating profile. Thus, if for example the facility has more than one startup per day, leading to more startup emissions than the District used in its calculation of the reasonably foreseeable maximum operating scenario, the facility will be required to curtail operations to ensure that the daily maximum is not exceeded.¹⁰

The daily maximum emission rates for the auxiliary boiler are taken from the enforceable daily permit limits being proposed in condition Part 35. As with the turbine limits, these daily limits are based on reasonable assumptions of how the auxiliary boiler is likely to operate, but they are enforceable permit limits that the facility will be required to meet regardless of how it is operated on any particular day.

Maximum daily emissions for the fire pump diesel engine assume 24-hour operation in a prolonged emergency using the maximum hourly rates listed above. Maximum daily emissions from the evaporative fluid cooler are calculated from the total dissolved solids in the water, flow rate, and drift rate of the evaporative fluid cooler. Maximum daily emissions from the oil-water separator were calculated using EPA's published emission factor for this equipment using the maximum hourly operating rate and assuming 24 hours per day operation. Full details are set forth in Appendix A.

¹⁰ As an intermediate-to-baseload facility, the Oakley Generating Station is not expected to have multiple startups per day under normal circumstances. It is possible that on a particular day the facility could be called on to start up and shut down more than once, however. The facility will still be subject to all permit conditions in such cases, including maximum limits on hourly emissions, startup and shutdown emissions, and daily emissions.

**TABLE 6: MAXIMUM DAILY REGULATED CRITERIA AIR POLLUTANT
EMISSIONS FROM EACH SOURCE**

Source	Pollutant (lb/day)				
	Nitrogen Oxides (as NO ₂)	Carbon Monoxide	Precursor Organic Compounds	Particulate Matter (PM ₁₀)	Sulfur Dioxide
Gas Turbine (no tuning)	488	715	146	186	144
Gas Turbine (tuning)	971	2818	531	186	144
S-3 Auxiliary Boiler	9.8	9.8	2.8	8.5	3.4
S-4 Fire Pump Diesel Engine	55.5	14.2	2.9	2.5	0.1
S-5 Evaporative Fluid Cooler ^a	0	0	0	3.2	0
S-6 Oil-water separator ^b	0	0	0.6	0	0

^a S-5 Evaporative Fluid Cooler is exempt from District Regulations per BAAQMD Regulation 2-1-128.4.

^b S-6 Oil-water separator is exempt from District Regulations per BAAQMD Regulations 2-1-103 and 8-8-113.

These daily emission rates are used to determine which sources at the facility are subject to the requirement to use “Best Available Control Technology” pursuant to District New Source Review regulation (NSR; Regulation 2, Rule 2). Pursuant to District Regulation 2-2-301.1, any new source that has the potential to emit 10 pounds or more per highest day of POC, NO_x, SO₂, PM₁₀, or CO is subject to the BACT requirement for that pollutant. As Table 6 shows, the gas turbines will emit over 10 pounds per highest day of NO_x, CO, POC, PM₁₀, and SO₂, and are required to use Best Available Control Technology per Regulation 2-2-301 to limit emissions of these pollutants. The Fire pump diesel engine will have the potential to emit over 10 pounds per day of NO_x and CO and is required to use Best Available Control Technology to limit emissions of these pollutants.¹¹ The District’s analysis of the Best Available Control Technology for this equipment is described in Section 5 below.

The remaining equipment at the facility is not subject to the BACT requirement in District Regulation 2, Rule 2, as none of it will emit more than 10 pounds per day of any criteria pollutant. In addition, the evaporative fluid cooler is exempt from District permitting per Regulation 2, Rule 1, Section 128.4, and the oil/water separator is exempt from District permitting per Regulation 2, Rule 1, Section 103 and Regulation 8, Rule 8, Section 113.

4.1.6 Annual Facility Emissions

The maximum annual emissions of regulated air pollutants for the proposed Oakley Generating Station project are set forth in Table 7 below. Table 7 shows the annual emissions from the

¹¹ Note that under normal circumstances, the fire pump diesel engine will only be operated for short periods for testing and reliability purposes. Under these circumstances, emissions of all criteria pollutants are likely to be well under 10 pounds per day. It is possible, however, that the engine would need to be operated for longer periods in the event of an emergency. The District is therefore providing worst-case emissions based on a full 24 hours per day of emergency operation.

facility, totaled for the permitted sources and for the permitted sources plus the exempt sources. Annual facility emissions for permitted sources are used to determine whether the facility will need to offset its emissions with Emissions Reduction Credits under District Regulations 2-2-202 and 2-2-203. Offsets are required for permitted sources with NO_x and POC emissions over 10 tons per year and for PM₁₀ and SO₂ emissions over 100 tons per year. (Note that annual emissions are also used to determine whether additional federal permitting requirements apply. This project is not subject to any additional federal requirements because it will not emit more than 100 tons per year of any pollutant as discussed in more detail in Section 7.)

Annual emissions will be subject to enforceable permit limits to ensure that they remain below the amounts listed in Table 7. These maximum annual rates are based on estimates derived from reasonable operating scenarios that the facility is likely to experience in operation as an intermediate-to-baseload facility. Information about the operating scenarios the District used to develop these annual emissions rates is provided in the explanatory notes to Table 7, with additional details provided in Appendix A. While the District believes that these operating scenarios are realistic, it should be noted that compliance with the emissions rates listed in Table 7 does not require the facility to conform to any specific operating scenario. Because the emission rates listed in Table 7 are enforceable, not-to-exceed emissions limits in the permit, the facility will be required to monitor its emissions and ensure that they do not exceed the limits during any 12-month period. If it appears that the facility is nearing its annual limit, it will be required by law to reduce or curtail operations to ensure that emissions do not exceed the permitted annual rates.

TABLE 7: MAXIMUM ANNUAL CRITERIA AIR POLLUTANT EMISSIONS FOR THE FACILITY

	NO₂^a (ton/yr)	CO^b (ton/yr)	POC^c (ton/yr)	PM₁₀^a (ton/yr)	SO₂^a (ton/yr)
Gas Turbines	98.626	98.000	29.274	63.715	12.524
Auxiliary Boiler	0.099	0.803	0.217	0.060	0.024
Fire Pump Diesel Engine	0.057	0.015	0.003	0.003	0.0001
Total subject to District Permits	98.78	98.82	29.49	63.78	12.55
Total including equipment exempt from District Permits	98.78	98.82	29.60	63.88	12.55

Notes: Exempt equipment includes Evaporative Fluid Cooler and Oil-water separator. See Appendices for Emission Calculations.

^a Annual NO_x, PM, and SO₂ emissions are based on 8,463 hours per year of operation from the turbines (including 1 cold start, 51 hot starts, 52 shutdowns), 401 hours for the auxiliary boiler (including 52 startups and 52 shutdowns), 1,500 hours per year for the evaporative fluid cooler, and 49 hours per year of maintenance and testing for the fire pump diesel engine. Gas turbine annual NO_x emissions are based on expected 1.5 ppmvd; annual SO₂ emissions are based on annual average grain loading (0.25 gr/100 scf) and 1.5 lb/hr emission rate.

^b Annual CO emissions are based on 5,390 hours per year of operation from the turbines (including 25 cold starts, 275 warm/hot starts, 300 shutdowns), 3,978 hours for the auxiliary boiler (including 300 startups and 300 shutdowns), 1,500 hours per year for the evaporative fluid cooler, and 49 hours per year of maintenance and testing for the fire pump diesel engine. Gas turbine annual CO emissions are based on expected 1.0 ppmvd.

^c Annual POC emissions are based on 5,662 hours per year of operation from the turbines (including 1 cold start, 311 hot/warm starts, 312 shutdowns) and 3,717 hours for the auxiliary boiler (including 312 startups and 312 shutdowns), 1,500 hours per year for the evaporative fluid cooler, and 49 hours per year of maintenance and testing for the fire pump diesel engine.

These annual emissions rates show that the facility will be required to offset its emissions of NO_x and POC under District Regulation 2-2-302, because emissions will be over 10 tons per year (and for NO_x, will have to provide credits at a ratio of 1.15 tons of credits per 1 ton of emissions, because emissions will be over 35 tons per year). The facility will not be required to offset its PM₁₀ and SO₂ emissions under District Regulation 2-2-303 because emissions of each of these pollutants will be less than 100 tons per year. Offset requirements are discussed in more detail in Section 6.

4.2 Toxic Air Contaminants

Toxic Air Contaminants (TACs) are a subset of air pollutants that can be harmful to health and the environment even in very small amounts. Table 8 provides a summary of the maximum annual facility toxic air contaminant (TAC) emissions from the project.¹²

TABLE 8: MAXIMUM FACILITY TOXIC AIR CONTAMINANT (TAC) EMISSIONS

Toxic Air Contaminant	Project Emissions (lb/hour)	Project Emissions (lb/year)	Acute Risk Screening Trigger Level (lb/hr)	Chronic Risk Screening Trigger Level (lb/yr)
1,3-Butadiene	0.001	4.40	None	0.63
Acetaldehyde	5.386 ^e	4952.12	1.0	38
Acrolein	0.290 ^e	663.67	0.0055	14
Ammonia	29.321	241336.38	7.1	7,700
Benzene	0.108 ^e	463.33	2.9	3.8
Benzo(a)anthracene ^a	0.00010	0.78	None	None
Benzo(a)pyrene ^a	0.00006	0.48	None	0.0069
Benzo(b)fluoranthene ^a	0.00005	0.39	None	None
Benzo(k)fluoranthene ^a	0.00005	0.38	None	None
Chrysene ^a	0.00011	0.87	None	None
Dibenz(a,h)anthracene ^a	0.00010	0.81	None	None
Ethylbenzene	0.137 ^e	622.64	None	43
Formaldehyde	19.487 ^e	16652.10	0.12	18
Hexane	1.090	8970.54	None	270,000
Indeno(1,2,3-cd)pyrene ^a	0.00010	0.81	None	None
Naphthalene	0.007	57.49	None	3.2
Propylene	3.244	26703.82	None	120,000
Propylene Oxide	0.201	1655.57	6.8	29
Toluene	0.391 ^e	2463.78	82	12,000
Xylene (Total)	0.110	903.98	49	27,000
Sulfuric Acid Mist (H ₂ SO ₄)	6.194	12795.41	0.26	39
Benzo(a)pyrene equivalents	0.00019	1.58	None	0.0069
Specified PAHs ^b	0.00055	4.54	None	None
Diesel Particulate Matter ^c	0.105	5.16	None	0.34
Arsenic ^d	0.000018	0.03	0.000440	0.0072
Copper ^d	0.000047	0.07	0.220000	None
Lead ^d	0.000013	0.02	None	3.2

Notes:

^a Polycyclic Aromatic Hydrocarbons (PAHs) impacts are evaluated as Benzo(a)pyrene equivalents.

¹² See “Project TACs Summary” spreadsheet in *OGS Emissions Calcs FDOC* workbook, prepared by K. Truesdell.

^b Specified PAHs are the sum of the following PAHs.

PAHs	Equivalency Factor
Benzo(a)anthracene	0.1
Benzo(a)pyrene	1.0
Benzo(b)fluoranthrene	0.1
Benzo(k)fluoranthrene	0.1
Chrysene	0.01
Dibenz(a,h)anthracene	1.05
Indeno(1,2,3-cd)pyrene	0.1

^c Diesel Particulate Matter is a surrogate for all air toxics emitted by the diesel engine.

^d Emitted by Evaporative Fluid Cooler

^e Maximum hourly rates of these TACs from the gas turbines are based on the source test at Palomar Energy Center during a cold startup, as listed in The Carlsbad Energy Center Final Determination of Compliance Appendix B at p. 8-9.¹³

Total of Hazardous Pollutants listed in Section 112(b) of the Federal Clean Air Act = 18.7 tons/year. Section 112(b) list does not include ammonia, propylene, or sulfuric acid mist, which are included as Toxic Air Contaminants in BAAQMD Regulation 2, Rule 5. The project is not a major source of hazardous air pollutants under the Clean Air Act because emissions are less than 10 tons/year of any single hazardous air pollutant listed under Section 112(b) and less than 25 tons/year of all such hazardous air pollutants combined. Emissions from the exempt evaporative fluid cooler are included.

Table 8 is also a summary of the emissions used as input data for air pollutant dispersion models used to assess the increased health risk to the public resulting from the project. The ammonia emissions shown are based upon a worst-case ammonia emission concentration of 5 ppmvd @ 15% O₂ from the gas turbine SCR systems. The chronic and acute screening trigger levels shown are per Table 2-5-1 of Regulation 2, Rule 5.

If emissions are above certain established screening levels prescribed in Table 2-5-1 of Regulation 2, Rule 5, a health risk assessment is required. Where no acute trigger level is listed for a TAC, none has been established for that TAC. Based on the information contained in Table 8, a health risk assessment is required by District Regulation 2, Rule 5. The health risk assessment is conducted to determine the potential impact on public health resulting from the worst-case TAC emissions from the project.

The results of the health risk assessment are discussed in full in Section 8 of this document. As explained in Section 8, the proposed facility will comply with all health risk requirements in District Regulation 2, Rule 5. Results from the health risk screening analysis indicate that the maximum cancer risk for the project as a whole is estimated at 1.56 in a million, and the maximum non-cancer risks for the project as a whole are estimated at a hazard index of 0.0832 for chronic health impacts and 0.2665 for acute health impacts. The risk from each source individually is below 1.0 in a million for the maximum individual cancer risk and below 0.02 for the maximum chronic hazard index. In accordance with the District's Regulation 2, Rule 5, the

¹³ See Final Determination of Compliance Carlsbad Energy Center Project, San Diego air Pollution Control District, August 4, 2009, Appendix B at p. 8-9. (available at: <http://energy.ca.gov/sitingcases/carlsbad/documents/index.html>)

proposed Oakley Generating Station will comply with all toxic risk requirements for each individual source and for the project as a whole.

5. Best Available Control Technology (BACT)

The District's New Source Review regulations require the proposed Oakley Generating Station to utilize the "Best Available Control Technology" (BACT) to minimize air emissions, as discussed in more detail below. This section describes how the BACT requirements will apply to the facility.

5.1 Introduction

District Regulation 2-2-301 requires that the Oakley Generating Station use the Best Available Control Technology to control NO_x, CO, POC, PM₁₀, and SO_x emissions from sources that will have the potential to emit over 10 pounds per highest day of each of those pollutants. Pursuant to Regulation 2-2-206, BACT is defined as the more stringent of:

- (a) The most effective control device or technique which has been successfully utilized for the type of equipment comprising such a source; or
- (b) The most stringent emission limitation achieved by an emission control device or technique for the type of equipment comprising such a source; or
- (c) Any emission control device or technique determined to be technologically feasible and cost-effective by the APCO; or
- (d) The most effective emission control limitation for the type of equipment comprising such a source which the EPA states, prior to or during the public comment period, is contained in an approved implementation plan of any state, unless the applicant demonstrates to the satisfaction of the APCO that such limitations are not achievable. Under no circumstances shall the emission control required be less stringent than the emission control required by any applicable provision of federal, state or District laws, rules or regulations.

The type of BACT described in definitions (a) and (b) must have been demonstrated in practice and is referred to as "BACT 2". This type of BACT is termed "achieved in practice". The BACT category described in definition (c) is referred to as "technologically feasible/cost-effective" and it must be commercially available, demonstrated to be effective and reliable on a full-scale unit, and shown to be cost-effective on the basis of dollars per ton of pollutant abated. This is referred to as "BACT 1". BACT specifications (for both the "achieved in practice" and "technologically feasible/cost-effective" categories) for various source categories have been compiled in the BAAQMD BACT Guideline.

The gas turbines are subject to BACT under the District's New Source Review regulations (Regulation 2, Rule 2, Section 301) for NO_x, CO, POC, PM₁₀, and SO_x because each unit will have the potential to emit more than 10 pounds per highest day of those pollutants. The fire pump diesel engine will have the potential to emit over 10 pounds per day of NO_x and CO in

emergency situations,¹⁴ and it is subject to BACT for these pollutants. The following sections provide the basis for the District BACT analyses for this equipment.

5.2 Gas Turbines

The following section provides the District's BACT analyses for the project's gas turbines.

5.2.1 Best Available Control Technology for Oxides of Nitrogen (NO_x)

Oxides of Nitrogen (NO_x) are a byproduct of the combustion of an air-and-fuel mixture in a high-temperature environment. NO_x is formed when the heat of combustion causes the nitrogen molecules in the combustion air to dissociate into individual nitrogen atoms, which then combine with oxygen atoms to form nitric oxide (NO) and nitrogen dioxide (NO₂). This reaction primarily forms NO (95% to 98%) and only a small amount of NO₂ (2% to 5%), but the NO eventually oxidizes and converts to NO₂ in the atmosphere. NO₂ is a reddish-brown gas with detectable odor at very low concentrations. NO and NO₂ are generally referred to collectively as "NO_x".¹⁵ NO_x is a precursor to the formation of ground-level ozone, the principal ingredient in smog.

Control Technology Review:

The District has examined technologies that may be effective to control NO_x emissions in two general areas: combustion controls that will minimize the amount of NO_x created during combustion; and post-combustion controls that can remove NO_x from the exhaust stream after combustion has occurred.

Combustion Controls

The formation of NO_x during combustion is highly dependent on the primary combustion zone temperature, as the formation of NO_x increases exponentially with temperature. There are therefore three basic strategies to reduce thermal NO_x in the combustion process:

- Reduce the peak combustion temperature
- Reduce the amount of time the air/fuel mixture spends exposed to the high combustion temperature
- Reduce the oxygen level in the primary combustion zone

¹⁴ Routine, non-emergency use is limited to short periods of operation for testing and reliability purposes, with emissions well under 10 pounds per day of all pollutants.

¹⁵ NO_x can also be formed when a nitrogen-bound hydrocarbon fuel is combusted, resulting in the release of nitrogen atoms from the fuel (fuel NO_x), and NO_x can be formed by organic free radicals and nitrogen in the earliest stages of combustion (prompt NO_x). Natural gas does not contain significant amounts of fuel-bound nitrogen. Therefore, thermal NO_x is the primary formation mechanism for natural gas fired gas turbines. References to NO_x formation during combustion in this analysis refer to "thermal NO_x", which is NO_x formed from nitrogen in the combustion air.

It should be noted, however, that techniques that control NO_x by reducing combustion temperatures involve a trade-off with the formation of other pollutants. Reducing combustion temperatures to limit NO_x formation can decrease combustion efficiency, resulting in increased byproducts of incomplete combustion such as carbon monoxide and unburned hydrocarbons. (Unburned hydrocarbons from natural gas combustion consist of methane, ethane and precursor organic compounds.) The District prioritizes NO_x reductions over carbon monoxide emissions, however, because the Bay Area is not in compliance with applicable ozone standards, but does comply with carbon monoxide standards. The District therefore requires applicants to minimize NO_x emissions to the greatest extent feasible, and then optimize CO and POC emissions for that level of NO_x control. This is a trade-off that must be kept in mind when selecting appropriate emissions control technologies for these pollutants.

The District has identified the following available combustion control technologies for reducing NO_x emissions from the gas turbines.

Steam/Water Injection: Steam or water injection was one of the first NO_x control techniques utilized on gas turbines. Water or steam is injected into the combustion zone to act as a heat sink, lowering the peak flame temperature and thus lowering the quantity of thermal NO_x formed. The injected water or steam exits the turbine as part of the exhaust. The lower peak flame temperature can also reduce combustion efficiency and prevent complete combustion, so carbon monoxide and POC emissions can increase as water/steam-to-fuel ratios increase. In addition, the injected steam or water may cause flame instability and can cause the flame to quench (go out). Water/steam injection in the gas turbines used in conjunction with Low-NO_x burners can achieve NO_x emissions as low as 25 ppm @ 15% O₂.¹⁶

Dry Low-NO_x Combustors: A technology that can control NO_x without water/steam injection is Dry Low-NO_x combustion technology. Dry Low-NO_x Combustors reduce the formation of thermal NO_x through (1) “lean combustion” that uses excess air to reduce the primary combustion temperature; (2) reduced combustor residence time to limit exposure in a high temperature environment; (3) “lean premixed combustion” that reduces the peak flame temperature by mixing fuel and air in an initial stage to produce a lean and uniform fuel/air mixture that is delivered to a secondary stage where combustion takes place; and/or (4) two-stage rich/lean combustion using a primary fuel-rich combustion stage to limit the amount of oxygen available to combine with nitrogen and then a secondary lean burn-stage to complete combustion in a cooler environment. Dry Low-NO_x combustors can achieve NO_x emissions as low as 9 ppm for frame-size turbines.¹⁷

¹⁶ M. Schorr, J. Chalfin, GE Power Systems, *Gas Turbine NO_x Emissions Approaching Zero – Is it Worth the Price?* GER4172, September 1999, at p. 2 (available at: http://www.gepower.com/prod_serv/products/tech_docs/en/downloads/ger4172.pdf)

¹⁷ J. Kovac, Siemens Energy Inc., *Advanced SGT6-5000F Development*, Power-Gen International 2008-Orlando, Florida, at p. 8 (available at: http://www.energy.siemens.com/hq/pool/hq/energy-topics/pdfs/en/gas-turbines-power-plants/PowerGen2008_SGT65000F.pdf)

Catalytic Combustors: Catalytic combustors, marketed under trade names such as XONON™, use a catalyst to allow the combustion reaction to take place with a lower peak flame temperature in order to reduce thermal NO_x formation. XONON™ uses a flameless catalytic combustion module followed by completion of combustion (at lower temperatures) downstream of the catalyst. Catalytic combustors such as XONON™ have not been demonstrated on large-scale utility gas turbines such as the Siemens F Class or GE Frame 7FA so the technology is not available for use at the proposed Oakley Generating Station.

Post-Combustion Controls

The District has identified the following post-combustion controls that can remove NO_x from the emissions stream after it has been formed.

Selective Catalytic Reduction (SCR): Selective catalytic reduction is a technology that reacts the NO_x in the turbine exhaust with ammonia and oxygen in the presence of a catalyst to form nitrogen and water. NO_x conversion is sensitive to exhaust gas temperature, and performance can be limited by contaminants in the exhaust gas that may mask or poison the catalyst. A small amount of ammonia is not consumed in the reaction and is emitted in the exhaust stream as what is commonly called “ammonia slip”. The SCR catalyst requires replacement periodically. SCR is a widely used post-combustion NO_x control technique on utility-scale gas turbines, usually in conjunction with combustion controls. SCR has been demonstrated to be able to achieve NO_x emission limits of 2.0 ppm.¹⁸

Selective non-catalytic reduction (SNCR): Selective non-catalytic reduction involves injection of ammonia or urea with proprietary conditioners into the exhaust gas stream without a catalyst. SNCR technology requires gas temperatures in the range of 1600°F to 2100°F¹⁹ and is most commonly used in boilers because gas turbines do not have exhaust temperatures in that range. Selective non-catalytic reduction (SNCR) requires a temperature window that is higher than the exhaust temperatures from utility gas turbine installations. The exhaust temperature from the proposed turbines ranges from approximately 1030°F to 1135°F²⁰, so SNCR is technically infeasible.

EMx™: EMx™ (formerly SCONOX™) is a catalytic oxidation and absorption technology that uses a two-stage catalyst/absorber system for the control of NO_x emissions for gas turbine applications (as well as CO, VOC and optionally SO_x emissions). A coated catalyst oxidizes NO to NO₂ (as well as oxidizing CO to CO₂ and VOCs to CO₂ and water), and the NO₂ is then absorbed onto the catalyst surface where it is chemically converted to and stored as potassium nitrates and nitrites. A proprietary regenerative gas is periodically passed through the catalyst to

¹⁸ See, e.g., facilities listed in Table 9 below using SCR to achieve 2.0 ppm permit limits.

¹⁹ See EPA Air Pollution Control Fact Sheet, EPA-452/F-03-031 (available at: <http://www.epa.gov/ttn/catc/dir1/fsncr.pdf>)

²⁰ See Radback Energy Supplemental Filing Air Quality and Public Health Revised April 7, 2010, Application for Certification for Oakley Generating Station Project, Appendix 5.1F, at p. 5.1F-16. (available at: http://energy.ca.gov/sitingcases/oakley/documents/applicant/2010-07-12_Supplemental_Filing_Air_Quality_Public_Health_TN-56162.pdf)

desorb the NO₂ from the catalyst and reduce it to elemental nitrogen (N₂). No ammonia is used by the EMx™ process. The EMx™ catalyst requires washing and replacement periodically. EMx™ has been successfully demonstrated on several small gas turbine projects, including one on a 45 megawatt turbine. The District is not aware of any EMx™ installations on a gas turbine of the size proposed for the Oakley Generating Station (Siemens F Class or GE Frame 7FA), although the manufacturer has claimed that it can be effectively scaled up and made available for utility-scale turbines.²¹

EMx could potentially be an improvement over SCR as an add-on control device for achieving NO_x reductions – assuming it can achieve the same level of NO_x control – because it does not use ammonia. Ammonia has the potential, under certain atmospheric conditions, to react with nitric acid in the atmosphere to form ammonium nitrate, which can be a form of fine particulate matter (PM_{2.5}). The atmospheric chemistry regarding the extent to which this process actually happens under real-world conditions has historically not been well understood, and the District's scientific understanding has been until recently that there was insufficient nitric acid in the atmosphere to make secondary PM_{2.5} formation a significant concern. As a result, the District has not historically regulated ammonia as a PM_{2.5} precursor, and has not found that EMx's lack of ammonia slip emissions would provide any significant benefit over SCR. The District has recently been reevaluating whether ammonia is in fact a significant contributor to secondary PM_{2.5}. The focus of the District's further evaluation has been a computer modeling exercise designed to predict what PM_{2.5} levels will be around the Bay Area, given certain assumptions about emissions of PM_{2.5} and its precursors, about regional atmospheric chemistry, and about prevailing meteorological conditions.²² The results of this study, while still preliminary, confirm that the predominant limiting factor in the formation of secondary particulate matter is the availability of nitric acid, not ammonia. However, the study suggests that the amount of available nitric acid is not uniform, and varies in different locations around the Bay Area, and that in some locations there is available nitric acid to react with ammonia. The District's model thus predicts that a reduction of 20% in total ammonia emissions throughout the Bay Area would result in changes in ambient PM_{2.5} levels of between 0% and 4%, depending on the availability of nitric acid. While this analysis is still preliminary, it suggests that ammonia restrictions might play a role in a regional strategy to reduce PM_{2.5}.²³ The District is therefore evaluating whether it should impose regulations on ammonia emissions as a PM_{2.5} precursor, as well as taking a harder look at whether it should require EMx as a BACT control technology for NO_x reductions instead of SCR.

EMx has never been used on a large utility-scale turbine, however, and so there is no data on which to make a direct evaluation of how well the technology would work at this facility. EMx

²¹ See EmeraChem, High Performance EMx™ Technology For Fine Particles, NO_x, CO, and VOCs From Gas Turbines and Stationary IC Engines (EMx White Paper), May 2008 at p. 15. (available at: <http://www.emerachempower.com/index.php?section=downloads&id=10>)

²² See BAAQMD, *Fine Particulate Matter Data Analysis and Modeling in the Bay Area* (Preliminary Report, Oct. 1, 2009), at p. 8 (Preliminary PM_{2.5} Modeling Report). (available at: <http://www.baaqmd.gov/~media/Files/Planning%20and%20Research/Research%20and%20Modeling/PM-data-analysis-and-modeling-report.ashx>)

²³ Preliminary PM_{2.5} Modeling Report at pp. E-3 – E-4.

has been used on a smaller aeroderivative turbine at the Redding Power Plant Unit No. 5, a 45-MW combined-cycle facility in Shasta County, CA. The data from that facility show that EMx cannot readily keep emissions as low as 2.0 ppm, which SCR can consistently achieve. The Shasta County Air Quality Management District evaluated EMx™ at the Redding facility under a demonstration NO_x limit of 2.0 ppm. After three years of operation, the Shasta County AQMD evaluated whether the facility was meeting this demonstration limit with EMx™, and concluded that “Redding Power is not able to reliably and continuously operate while maintaining the NO_x demonstration limit of 2.0 ppmvd @ 15% O₂.”²⁴ Although the manufacturer maintains that such problems have been overcome, concerns remain about how consistently the technology would be able to perform. Recent communications with the Shasta County Air District confirm that the earlier conclusions about the achievability of a lower limit remain valid.²⁵ In addition, monthly reports of Continuous Emissions Monitoring System (CEMS) data submitted by Redding Power Plant to Shasta County Air District during 2007 and 2008 indicate that emissions have often been substantially higher.²⁶ Furthermore, the data from Redding are from a smaller aeroderivative turbine, and there is no guarantee that if it were scaled up for use on utility-size turbines that it would even be able to achieve the performance of the Redding Power facility. For all of these reasons, it is clear that EMx is not as developed as SCR at this time and cannot achieve the same level of emissions performance that SCR is capable of.

Proposed BACT Control Technology for NO_x for Gas Turbines:

The applicant has proposed the use of Dry Low-NO_x combustors and SCR as BACT for the combined-cycle gas turbines. As explained above, these are the most effective combustion and post-combustion control technologies available for this type of facility. These emissions control technologies therefore satisfy the District’s BACT requirement.

Proposed BACT Emissions Limit for NO_x for Gas Turbines:

The District is also proposing to establish a BACT emissions limit in the permit of 2.0 ppmvd @ 15% O₂ (averaged over one hour), which is the most stringent limit that has been achieved in practice at any other similar facility and is the most stringent limit that would be technologically feasible.

To determine the most stringent emissions limit that has been achieved in practice, the District evaluated other similar combined-cycle gas turbines. The District reviewed the NO_x emissions limits of power plants using large turbines in a combined-cycle mode abated by SCR systems. The District reviewed BACT determinations at the EPA RACT/BACT/LAER Clearinghouse, ARB BACT Clearinghouse and recent projects listed by the CEC as approved or under

²⁴ Letter from R. Bell, Air Quality District Manager, Shasta County Air Quality Management District, to R. Bennett, Safety & Environmental Coordinator, Redding Electric Utility, June 23, 2005.

²⁵ See Memorandum of Record of Telephone call to Shasta County dated 10/25/2010, prepared by W. Lee BAAQMD.

²⁶ See Redding Unit 5 NO_x CEM summary (SCONO_x) 2007-2008.

construction. The combined-cycle facilities with the most stringent permit limits, as listed in these databases, are shown in the table below.

TABLE 9: NO_x EMISSION LIMITS FOR LARGE GAS TURBINES IN COMBINED-CYCLE POWER PLANTS

Facility Name	RBLC ID or CEC Docket #	NO _x ppmvd @ 15% O ₂ (averaging period)
Lawrence Energy	OH-0248	3.0
Longview Energy Development	WA-0288	3.0 (24-hr); 2.5 (12-month)
Middleton Facility	ID-0010	3.0 (24-hr) without duct firing; 3.5 (24-hr) with duct firing; 2.5 (12-month) all modes
Wansley Combined Cycle Energy Facility	GA-0102	3.0
Augusta Energy Center	GA-0093	3.0
Delta - Calpine	1998-AFC-03	2.5 (1-hr)
Moss Landing - L.S. Power	1999-AFC-04	2.5 (1-hr)
La Paloma - Complete Energy Holdings	1998-AFC-02	2.5 (1-hr)
Los Medanos - Calpine	1998-AFC-01	2.5 (1-hr)
Pastoria - Calpine	1999-AFC-07	2.5 (1-hr)
Gateway - PG&E	2000-AFC-01	2.5 (1-hr)
High Desert - Constellation	1997-AFC-01	2.5 (1-hr)
Sutter - Calpine	1997-AFC-02	2.5 (1-hr)
Blythe I - NextEra Energy (FPL)	1999-AFC-08	2.5 (1-hr)
Elk Hills - Sempra & Oxy	1999-AFC-01	2.5 (1-hr)
Metcalf - Calpine	1999-AFC-03	2.5 (1-hr)
COB Energy Facility, LLC	OR-0039	2.5 (4-hr)
Wallula Power Plant	WA-0291	2.5 (3-hr)
McIntosh Combined Cycle Facility	GA-0105	2.5
Cogen Technologies Linden Venture, L.P.	NJ-0059	2.5
Empire Power Plant	NY-0100	2.0 (3-hr) without duct firing; 3 (3-hr) with duct firing
FPL Turkey Point Power Plant	FL-0263	2.0 (24-hr)
Otay Mesa - Calpine	1999-AFC-05	2.0 (1-hr), allows 15 1-hr excursions for transient load etc.
Mountainview	2000-AFC-02	2.0 (1-hr), allows 15 one-hour excursions for transient load etc.
Cosumnes - SMUD	2001-AFC-19	2.0 (1-hr); 30 (1-hr) transient load
Palomar Escondido - SDG&E	2001-AFC-24	2.0 (1-hr); 2.0 (3-hr) with duct firing or transient hour of +25 MW
Sacramento Municipal Utility District	CA-0997	2.0
PSEG Fossil LLC Linden Generating Station	NJ-0058	2.0
Warren County Facility	VA-0308	2.0
Warren County Facility	VA-0308	2.0
Warren County Facility	VA-0308	2.0
Tracy Substation Expansion Project	NV-0035	2.0 (3-hr)
Copper Mountain Power	NV-0037	2.0 (3-hr)
Sumas Energy 2 Generation Facility	WA-0315	2.0 (3-hr)
Magnolia - So. Ca. Power Producers	2001-AFC-06	2.0 (3-hr)
Goldendale Energy, Inc.	WA-0302	2.0 (3-hr)
La Paz Generating Facility, Siemens option	AZ-0049	2.0 (3-hr) changes to (1-hr) after 18 months
La Paz Generating Facility, GE option	AZ-0049	2.0 (3-hr) changes to (1-hr) after 18 months
Wellton Mohawk Generating Station, Siemens-Westinghouse 501F option	AZ-0047	2.0 (3-hr) changes to (1-hr) after 18 months

Facility Name	RBLC ID or CEC Docket #	NOx ppmvd @ 15% O2 (averaging period)
Wellton Mohawk Generating Station, GE 7FA option	AZ-0047	2.0 (3-hr) changes to (1-hr) after 18 months
Ivanpah Energy Center, L.P.	NV-0038	2.0 (1-hr) without duct firing; 13.96 lb/hr with duct firing
Gila Bend Power Generating Station	AZ-0038	2.0 (1-hr)
El Segundo Repower - NRG	2000-AFC-14	2.0 (1-hr)
Victorville Hybrid Gas-Solar - City of Victorville	2007-AFC-1	2.0 (1-hr)
Duke Energy Arlington Valley	AZ-0043	2.0 (1-hr)
Colusa II Generation Station - PG&E Final Decision	2006-AFC-9	2.0 (1-hr)
Lodi Energy Center - NCPA	2008-AFC-10	2.0 (1-hr)
Avenal Energy - Avenal Power Center, LLC	2008-AFC-1	2.0 (1-hr)
Russell City - Calpine & GE	2001-AFC-07	2.0 (1-hr)
CPV Warren	VA-0291	2.0 (1-hr)
Kleen Energy Systems, Inc.	CT-0151	2.0 (1-hr)
IDC Bellingham ^a	CA-1050	2.0/1.5 (1-hr)

^a The IDC Bellingham facility in Massachusetts, was permitted with a two-tiered NO_x emissions limit that imposed an absolute not-to-exceed limit of 2.0 ppm but also required the facility to maintain emissions below 1.5 ppm during normal operations. (Note also that the facility was never built.) This two-tiered limit recognized that emissions can be highly variable depending on operating circumstances, and will have relatively lower emissions at some times and relatively higher emissions at other times. The proposed Oakley Generating Station is expected to exhibit the same type of variation in emissions under the various operating scenarios it will face, and it is expected to have emissions below 2.0 ppm at times but will have emissions as high as 2.0 ppm under some circumstances. The District is therefore proposing a 2.0 ppm limit to ensure that the limit will be achievable under all operating conditions.

As Table 9 shows, emissions of 2.0 ppm NO_x averaged over 1-hour is the most stringent emission limitation that has been determined to be achievable at any similar facility using SCR for NO_x control.

The District also considered whether it would be feasible to implement a NO_x permit limit below 2.0 ppm. Consistent compliance with a limit below 2.0 ppm has never been demonstrated in practice, and the equipment vendors that the District contacted regarding this issue stated that they would not be able to guarantee that a lower limit could be achieved.²⁷ The District nevertheless considered whether it would be technologically feasible to do so. The District has concluded that imposing a NO_x emissions limit below 2.0 ppm cannot be justified as BACT at this time.

Additional NO_x reductions could potentially be achieved by increasing the amount of catalyst or size of the catalyst bed in the SCR system. It would be difficult to achieve any substantial additional reductions, however, because at the very low NO_x levels that are currently being achieved by SCR, additional efforts produce diminishing returns. SCR performance for NO_x

²⁷ See, e.g., Letter from T. Pintcke, Vice President, Black & Veatch, to K. Truesdell, Air Quality Engineer, Bay Area Air Quality Management District, Oct. 11, 2010, stating that Black & Veatch “sees no basis for and will not guarantee an hourly limit for NO_x emissions below 2 ppm for any averaging period.”

control is highly dependent on the NO_x to ammonia reaction stoichiometry. At stoichiometric conditions, there would be just enough ammonia to react with the NO_x with no additional ammonia slip exhausted out the stack. It becomes highly challenging to ensure a uniform distribution of ammonia to NO_x over the entire gas turbine operating range when NO_x concentrations are very low. Alternatively, some vendors have considered staging two separate ammonia injection grids and catalyst beds in series in order to achieve an optimal distribution of ammonia to NO_x that might maintain emissions at less than 2.0 ppm NO_x over the entire gas turbine operating range. But this approach has its own drawbacks, such as increasing the backpressure on the turbine exhaust and decreasing the efficiency of the turbine resulting in higher emissions per megawatt of power generated. Moreover, no installation using a staged series of ammonia injection grids has been demonstrated in practice. Additionally, temperature variations across the catalyst bed also impact SCR performance. At progressively lower NO_x concentrations, these variations have an increasingly significant impact on reaction rates. For all of these reasons, it becomes increasingly difficult to gain additional NO_x reductions as concentrations are driven to extremely low levels simply by increasing the amount of catalyst or the size of the catalyst bed. Increasing the amount of catalyst or size of catalyst bed theoretically can provide for more NO_x reduction, but for a number of reasons simply adding more catalyst reaches a point of diminishing returns as NO_x levels approach zero.²⁸

In addition, achieving lower NO_x emissions levels would have other potential offsetting impacts. Ensuring emissions consistently remain below 2.0 ppm could potentially cause a significant increase in ammonia slip and require a higher ammonia slip permit limit. Implementing a NO_x limit below 2.0 ppm would also likely require an increase in the frequency of catalyst change-outs to maintain compliance. This would have both cost impacts and ancillary environmental impacts, because the old catalyst must be disposed of as hazardous waste, because the larger amount of catalyst needed would generate more spent catalyst to be disposed of, and because additional energy and natural resources would need to be used to produce the new catalyst. A NO_x permit limit below 2.0 ppm limit would also result in additional maintenance, which adds to operating costs and requires maintenance outages during which the plant is unavailable to meet demand. For example, achieving very low NO_x limits would require the seals in the SCR system to be maintained to very tight tolerances to minimize the amount of NO_x that may slip by them. With a NO_x permit limit below 2.0 ppm, it is likely that more frequent outages will be required to inspect and maintain these seals, which adds to the cost and could significantly impact the plant's availability to support the grid.

Finally, assuming that an SCR system could be designed to achieve emissions below 2.0 by increasing the amount of catalyst or the size of the catalyst bed, the system would have to be able to operate to maintain compliance at all times, including during periods of transient load. Compliance is much more difficult during such periods because the SCR system's ammonia injection control system is limited in how quickly it can respond to rapidly changing conditions. The amount of ammonia being injected is determined based on turbine operating conditions and the NO_x concentration in the exhaust. There is an optimal amount of ammonia based on the

²⁸ See generally M. Schorr & J. Chalfin, *Gas Turbine NO_x Emissions Approaching Zero – Is it Worth the Price?*, GE Power Generation, Publication No. GER 4172. (available at: http://www.gepower.com/prod_serv/products/tech_docs/en/downloads/ger4172.pdf)

incoming NO_x and the ammonia injection system provides a slight excess to ensure the NO_x emissions are minimized while ammonia slip levels are also minimized. When gas turbine load is ramped quickly, its NO_x emissions can change much more rapidly than the ammonia injection system can respond due to the lag time in the ammonia injection control system and the NO_x continuous emission monitor. This control system lag and continuous emission monitor (CEM) lag time make meeting a permit limit below 2.0 ppm NO_x averaged over one hour much more difficult during rapid load changes.

Designing an SCR system to consistently maintain compliance with a limit below 2.0 ppm would also be more difficult because transient load conditions and fast ramp rates are expected to become more common in the coming years as California moves to more renewable power generation. Renewable sources of electrical power such as wind and solar are much more intermittent and uncertain than traditional power plants. Fossil fuel fired plants will be needed to fill in the gaps when the sun is not shining or the wind is not blowing, and they will be required to ramp up quickly when needed and then ramp back down when renewable sources come back on-line.²⁹ For this reason, facilities such as the Oakley Generating Station are expected to experience a significantly increased amount of transient load conditions, although it is difficult to predict with certainty exactly how these facilities will need to operate. An SCR system would need to be designed to operate at a very high degree of efficiency in order to ensure that it would be able to maintain compliance with a short-term NO_x limit below 2.0 during all potential transient load conditions. Moreover, given the uncertainty as to how exactly the facility will need to operate in support of additional renewable generation, it would be difficult to predict the maximum design parameters that would be needed to ensure compliance.

Based on all of this analysis, the District has concluded that there is insufficient evidence on which to make a determination that a lower NO_x emissions limit can be justified as BACT for this facility. Although it may be possible in theory to design an enhanced SCR system that could potentially be more effective in reducing NO_x, there is substantial uncertainty as to how effective such an enhanced system would actually be in consistently achieving a lower permit limit. Moreover, even if a lower limit could theoretically be achieved, there is substantial uncertainty over how the SCR system would need to be designed to do so given the changes in power plant operating scenarios that are expected as California moves to more renewable power sources, and in particular the greater incidence of transient load conditions. The District is also concerned that if the facility is subjected to a lower limit and finds that it cannot achieve it during transient loads, the facility would not be able to be operated to support renewable resources as readily, which would hinder California's efforts to develop those resources. And finally, the District is also mindful of the additional costs and ancillary adverse environmental impacts that would be associated with an enhanced SCR system. Although additional costs and ancillary impacts can be acceptable where justified by the increased effectiveness of a better add-on control system under a BACT analysis, there is little clear indication that additional NO_x reductions beyond the very stringent 2.0 ppm levels that are currently being achieved would be worth it here (to the extent that any additional reductions could even be obtained in practice). Given the high degree

²⁹ Integration of Renewable Resources, Operational Requirements and Generation Fleet Capability at 20% RPS, August 31, 2010, California ISO, pg. iii. (available at: <http://www.caiso.com/2804/2804d036401f0.pdf>)

of uncertainty regarding what level of additional NO_x reductions could actually be achieved, what would be required from a technical standpoint to achieve any such additional reductions, and what the adverse ancillary impacts would be, the technical information available at this point does not provide a sufficiently certain basis to support a BACT determination that a NO_x emissions limit below 2.0 should be required. The District has considered all of this evidence and has concluded that it does not support imposing a NO_x emissions limit below 2.0 ppm as BACT for this project.

The District has therefore determined that 2.0 ppmvd at 15% O₂, averaged over 1-hour, is the BACT emission limit for NO_x for the combined-cycle gas turbines. The District is also proposing corresponding hourly mass emissions limits. Compliance with the NO_x permit limits will be demonstrated on a continuous basis using a continuous emissions monitor.

5.2.2 Best Available Control Technology for Carbon Monoxide (CO)

Carbon monoxide is a colorless odorless gas that is a product of incomplete combustion.

Control Technology Review:

As with NO_x, the District has examined both combustion controls to reduce the amount of carbon monoxide generated and post-combustion controls to remove carbon monoxide from the exhaust stream.

Combustion Controls

Carbon monoxide is formed by incomplete combustion. Incomplete combustion occurs when there is not enough air to fully combust the fuel, and when the air and fuel are not properly mixed due to poor combustor tuning. Maximizing complete combustion by ensuring an adequate air/fuel mixture with good mixing will reduce carbon monoxide emissions by preventing its formation in the first place.

Increasing combustion temperatures can also promote complete combustion, but doing so will increase NO_x emissions due to thermal NO_x formation as described in the previous section. The District prioritizes NO_x control over carbon monoxide control because the Bay Area is not in compliance with state and federal standards for ozone, which is formed by NO_x emissions reacting with other pollutants in the atmosphere. The District therefore does not favor increasing combustion temperatures to control carbon monoxide. Instead, the District favors approaches that reduce NO_x to the lowest achievable rate and then optimize carbon monoxide emissions for that level of NO_x emissions.

Good Combustion Practice: The District has identified good combustion practice as an available combustion control technology for minimizing carbon monoxide formation during combustion. Good combustion practice utilizes “lean combustion” – large amount of excess air – to produce a cooler flame temperature to minimize NO_x formation, while still ensuring good air/fuel mixing with excess air to achieve complete combustion, thus minimizing CO emissions. Good combustion

practice can be used with the low-NO_x combustion technology selected for minimizing NO_x emissions (Dry Low-NO_x Combustors).

Post-Combustion Controls

The District has also identified two post-combustion technologies to remove carbon monoxide from the exhaust stream.

Oxidation Catalysts: An oxidation catalyst oxidizes the carbon monoxide in the exhaust gases to form CO₂. Oxidation catalysts are a proven post-combustion control technology widely in use on large gas turbines to abate CO and POC emissions.

EMx™: EMx™, described above in the NO_x discussion, is a multimedia control technology that abates CO and POC emissions as well as NO_x. EMx™ technology uses a catalyst to oxidize carbon monoxide emissions to form CO₂, and is therefore also an oxidation catalyst. However, it is not a stand-alone oxidation catalyst since the EMx™ is also a NO_x reduction device. Hence, it is identified as a device separate from the oxidation catalyst. EMx™ is not as effective as SCR in achieving NO_x reductions, however, and so the District rejected it as a BACT control technology.

Proposed BACT Control Technology for CO for Gas Turbines:

Based on the foregoing discussion, the District has determined that the proposed combination of good combustion practice to reduce the formation of carbon monoxide during combustion and an oxidation catalyst to remove carbon monoxide from the gas turbines exhaust satisfies the BACT requirement.

Proposed BACT Emissions Limit for Carbon Monoxide (CO) for Gas Turbines:

The District is also proposing a CO BACT limit of 2.0 ppmvd @ 15% O₂ (1-hour average), which is the most stringent that has been achieved in practice at other similar combined-cycle facilities and is the most stringent limit that is technologically feasible and cost-effective.

To establish what level of emissions performance has been achieved in practice for this type of facility, the District reviewed the CO emissions limits of other large combined-cycle power plants using oxidation catalyst systems. As with the NO_x comparison set forth above, the District reviewed BACT determinations for CO at the EPA RACT/BACT/LAER Clearinghouse, ARB BACT Clearinghouse and recent projects listed by the CEC as approved or under construction. The combined-cycle facilities with the most stringent permit limits, as listed in these databases, are shown in the table below.

TABLE 10: CO EMISSION LIMITS FOR LARGE GAS TURBINES IN COMBINED-CYCLE POWER PLANTS

Facility Name	RBLC ID or CEC Docket #	CO ppmvd @ 15% O2 (averaging period)
FPL Turkey Point Power Plant	FL-0263	14.1 (24-hr) with duct firing and power aug; 6.0 (all modes) annual average
Delta – Calpine	1998-AFC-03	10 (3-hr)
La Paloma - Complete Energy Holdings	1998-AFC-02	10 (3-hr) if < 221 MW, or 6.0 (3-hr) if > 221 MW
Moss Landing - L.S. Power	1999-AFC-04	9.0 (3-hr)
Pastoria – Calpine	1999-AFC-07	6.0 (3-hr)
Gateway - PG&E	2000-AFC-01	6.0 (3-hr)
Los Medanos – Calpine	1998-AFC-01	6.0 (3-hr)
Otay Mesa – Calpine	1999-AFC-05	6.0 (3-hr)
Mountainview	2000-AFC-02	6.0 (1-hr)
Longview Energy Development	WA-0288	6.0 (1-hr); 2.0 (12-month)
Middleton Facility	ID-0010	5.0 (1-hr), 2.0 (12-month)
Sacramento Municipal Utility District	CA-0997	4.0
High Desert – Constellation	1997-AFC-01	4.0 (24-hr)
Blythe I - NextEra Energy (FPL)	1999-AFC-08	4.0 (3-hr)
Sutter – Calpine	1997-AFC-02	4.0 (3-hr)
Cosumnes – SMUD	2001-AFC-19	4.0 (3-hr)
Elk Hills - Sempra & Oxy	1999-AFC-01	4.0 (3-hr)
Metcalf – Calpine	1999-AFC-03	4.0 (3-hr)
Palomar Escondido - SDG&E	2001-AFC-24	4.0 (3-hr)
Gila Bend Power Generating Station	AZ-0038	4.0 (3-hr)
Ivanpah Energy Center, L.P.	NV-0038	4.0 (1-hr) without duct firing; 17 lb/hr with duct firing
El Segundo Repower – NRG	2000-AFC-14	4.0 (1-hr)
Tracy Substation Expansion Project	NV-0035	3.5 (3-hr)
La Paz Generating Facility, Siemens option	AZ-0049	3.0 (3-hr)
La Paz Generating Facility, GE option	AZ-0049	3.0 (3-hr)
Wellton Mohawk Generating Station, Siemens-Westinghouse 501F option	AZ-0047	3.0 (3-hr)
Wellton Mohawk Generating Station, GE 7FA option	AZ-0047	3.0 (3-hr)
Copper Mountain Power	NV-0037	3.0 (3-hr)
Duke Energy Arlington Valley	AZ-0043	3.0 (3-hr)
Colusa II Generation Station - PG&E Final Decision	2006-AFC-9	3.0 (3-hr)
Lawrence Energy	OH-0248	2.0 without duct firing; 10.0 with duct firing
Victorville Hybrid Gas-Solar - City of Victorville	2007-AFC-1	2.0 (1-hr) without duct firing; 3.0 (1-hr) with duct firing
Wansley Combined Cycle Energy Facility	GA-0102	2.0
Augusta Energy Center	GA-0093	2.0
McIntosh Combined Cycle Facility	GA-0105	2.0
Cogen Technologies Linden Venture, L.P.	NJ-0059	2.0
PSEG Fossil LLC Linden Generating Station	NJ-0058	2.0
COB Energy Facility, LLC	OR-0039	2.0 (4-hr)
Avenal Energy - Avenal Power Center, LLC	2008-AFC-1	2.0 (3-hr)
Wallula Power Plant	WA-0291	2.0 (3-hr)
Lodi Energy Center - NCPA	2008-AFC-10	2.0 (3-hr)
Magnolia - So. Ca. Power Producers	2001-AFC-06	2.0 (1-hr)

Facility Name	RBLC ID or CEC Docket #	CO ppmvd @ 15% O2 (averaging period)
Sumas Energy 2 Generation Facility	WA-0315	2.0 (1-hr)
Goldendale Energy, Inc.	WA-0302	2.0 (1-hr)
IDC Bellingham	CA-1050	2.0 (1-hr)
Russell City - Calpine & GE	2001-AFC-07	2.0 (1-hr)
Warren County Facility ^a	VA-0308	1.8 without duct firing; 2.5 with duct firing
CPV Warren ^a	VA-0291	1.3 without duct firing; 1.8 with duct firing and power aug
Warren County Facility ^a	VA-0308	1.3 without power aug.
Warren County Facility ^a	VA-0308	1.3 without duct firing; 1.2 with duct firing
Kleen Energy Systems, Inc. ^b	CT-0151	0.9 (1-hr) without duct firing

Notes:

^a Warren County Facility and CPV Warren are the same facility (Permit Number 81391) and have not been built; a new application amended April 27, 2010, by Virginia Electric Power and Power Company (Dominion) is under review and will replace the listed determinations.

^b Kleen Energy Systems has not yet been operated.

Based on the facilities that the District has reviewed, the most stringent permit limit that has been achieved in practice by any other similar facility is 2.0 ppmvd @ 15% oxygen averaged over one hour. Permits issued for two facilities – the Warren County facility and the Kleen Energy Systems facility – included some limits of less than 2.0, but neither of these facilities has actually come online yet and so there is no operating data available on which to assess whether they will actually be able to meet these lower limits. The fact that permits have been issued with limits below 2.0 ppm does not establish that such lower limits have actually been “achieved” as that term is used in the BACT definition where there is no evidence from actual operations demonstrating that the facilities have in fact been operating in compliance with these permit limits. As the District’s BACT guidelines explain, an “achieved in practice” emissions limit is “the most stringent emission limit achieved in the field for the type and capacity of equipment comprising the source under review and operating under similar conditions, e.g. process throughput and material usage, hours of operation, site-specific limitations and opportunities, etc. For example, the control device performance or emission limit has already been verified by source tests or other appropriate documentation approved by this District or another California air district.”³⁰ Where a limit has simply been included in a permit, but the facility had not been built and emissions have not been verified as being in compliance with the limits, the limits are not “achieved in practice” for purposes of the District BACT requirement. The lowest permit limit that has actually been achieved in practice is 2.0 ppm averaged over one hour.

The District also considered whether it would be technically feasible and cost-effective to require the proposed facility to meet an emission limit below the 2.0 ppm level that has been achieved for similar combined-cycle facilities. The District found that although it may be technically feasible to do so, it would not be cost-effective to do so given the magnitude of the costs involved. Additionally, a larger catalyst capable of meeting a CO permit limit below 2 ppm may have other implementation problems such as a high back pressure, which could adversely impact turbine operating performance and efficiency.

³⁰ BAAQMD BACT/TBACT Workbook, “Guidelines For Best Available Control Technology”, Section 3 (“Policy and Implementation Procedure”), subsection 1 (“Interpretation of BACT”), available at <http://hank.baaqmd.gov/pmt/bactworkbook/default.htm>.

The District evaluated the costs and emissions reduction benefits of installing a larger oxidation catalyst capable of consistently maintaining emissions below 1.0 ppm. Based on these analyses, the cost of achieving a 1.0 ppm permit limit would be an additional \$77,882 per year (above what it would cost to achieve a 2.0 ppm limit), and the additional reduction in CO emissions would be approximately 20.11 tons per year, making an incremental cost-effectiveness value of over \$3,874 per ton of additional CO reduction.³¹ Moreover, the total cost of achieving a 1.0 ppm CO limit (as opposed to the incremental costs of going from 2.0 ppm to 1.0 ppm) would be over \$524,959 per year, and the total emission reductions from 9.0 ppm from the turbine to a 1.0 ppm limit would be 121.01 tons per year, resulting in a total (or “average”) cost effectiveness value of \$4,338. Based on these costs (on a per-ton basis) and the relatively little additional CO emissions benefit to be achieved (on a per-dollar basis), requiring a 1.0 ppm CO permit limit cannot reasonably be justified as a BACT limit. Requiring controls to meet a 1.0 ppm limit would be more expensive, on a per-ton basis, than what other similar facilities are required to achieve. The District has not adopted its own cost-effectiveness guidelines for CO,³² but a review of guidelines adopted by other districts in California and of BACT determinations made by agencies around the country found that additional CO controls are not normally required where the cost per ton exceeds a few hundred to a few thousand dollars per ton.³³ Additional CO reductions here would not be justified as BACT given these costs.

The District has therefore determined that BACT for CO for this facility is the use of good combustion practice with abatement by an oxidation catalyst, and a permit limit of 2.0 ppmvd @ 15% O₂, averaged over 1-hour. The District is also proposing corresponding hourly mass

³¹ See *OGS Cost effectiveness spreadsheet*, prepared by K. Truesdell BAAQMD, and *Responses to BAAQMD 092310 E-mail Attachment 2*, prepared by Gregory Darvin Atmospheric Dynamics.

³² Bay Area Air Quality Management District Best Available Control Technology (BACT) Guideline, § 1, Policy and Implementation Procedure, available at: <http://hank.baaqmd.gov/pmt/bactworkbook/default.htm>.

³³ See South Coast Air Quality Management District, Best Available Control Technology Guidelines, August 17, 2000, revised July 14, 2006, at 29; available at: www.aqmd.gov/bact/BACTGuidelines2006-7-14.pdf; Memorandum, David Warner, Director of Permit Services, to Permit Services Staff, Subject: “Revised BACT Cost Effectiveness Thresholds”, May 14, 2008; available at: www.valleyair.org/busind/pto/bact/May%202008%20updates%20to%20BACT%20cost%20effectiveness%20thresholds.pdf; U.S. EPA RACT/BACT/LAER Clearinghouse Identification No. GA-0127, for permit issued to Southern Company/Georgia Power, Plant McDonough Combined Cycle, Permit No. 4911-067-0003-V-02-2, issued January 7, 2008; U.S. EPA RACT/BACT/LAER Clearinghouse Identification No. NV-0035, for permit issued to Sierra Pacific Power Company Tracey Substation Expansion Project, Permit No. AP4911-1504, issued August 16, 2005; U.S. EPA RACT/BACT/LAER Clearinghouse Identification No. OR-0041, Wanapa Energy Center, Permit No. R10PSD-OR-05-01, August 8, 2005; BAAQMD Application No. 15487, Russell City Energy Center, Responses to Public Comments (Feb. 3, 2010), pp. 69-74; EPA Region 4, “National Combustion Turbine List,” available at: www.epa.gov/region4/air/permits/national_ct_list.xls.

emissions limits of 9.45 pounds per turbine. Compliance with the CO permit limits will be demonstrated on a continuous basis using a continuous emissions monitor.

5.2.3 Best Available Control Technology for Precursor Organic Compounds (POC)

Emissions of POC from combustion sources are products of incomplete combustion, as is the case with CO emissions.

Control Technology Review:

Emissions control techniques for CO are also applicable to POC emissions from combustion sources and are discussed above. The appropriate BACT control device or technique for CO is therefore also the BACT control device or technique for POC.

Proposed BACT Control Technology for POC for Combined-Cycle Gas Turbines:

The District has reviewed the available control technologies in the BACT analysis for CO (equally applicable to POC) and determined that good combustion practice and abatement using an oxidation catalyst are the BACT technologies for controlling POC from the proposed combined-cycle gas turbines at Oakley Generating Station.

Proposed BACT Emissions Limit for POC for Combined-Cycle Gas Turbines:

To establish what level of emissions performance has been achieved in practice for this type of facility, the District reviewed the POC emissions limits of other large combined-cycle power plants using oxidation catalyst systems. The District reviewed BACT determinations for POC at the EPA RACT/BACT/LAER Clearinghouse, ARB BACT Clearinghouse and recent projects listed by the CEC as approved or under construction. The combined-cycle facilities with most stringent permit limits, as listed in these databases, are shown in the table below.

TABLE 11: POC EMISSION LIMITS FOR LARGE GAS TURBINES IN COMBINED-CYCLE POWER PLANTS

Facility Name	RBLC ID or CEC Docket #	VOC ppmvd @ 15% O₂ (averaging period)
Wallula Power Plant	WA-0291	5.0 (1-hr)
Kleen Energy Systems, Inc.	CT-0151	5.0 (1-hr)
La Paz Generating Facility, GE option	AZ-0049	4.5 (3-hr)
Tracy Substation Expansion Project	NV-0035	4.0 (3-hr)
Duke Energy Arlington Valley	AZ-0043	4.0 (3-hr)
Copper Mountain Power	NV-0037	4.0 (3-hr) without duct firing; 1.9 (3-hr) with duct firing;
Wellton Mohawk Generating Station	AZ-0047	3.0 (3-hr)
Wellton Mohawk Generating Station	AZ-0047	3.0 (3-hr)
Ivanpah Energy Center, L.P.	NV-0038	2.3 (1-hr) without duct firing; 5.6 lb/hr with duct firing
La Paloma	1998-AFC-02	2.80 lb/hr and 0.7 (3-hr) (as propane)
Wansley Combined Cycle Energy Facility	GA-0102	2.0

Facility Name	RBLC ID or CEC Docket #	VOC ppmvd @ 15% O ₂ (averaging period)
Augusta Energy Center	GA-0093	2.0
McIntosh Combined Cycle Facility	GA-0105	2.0
Otay Mesa - Calpine	1999-AFC-05	2.0
Pastoria - Calpine	1999-AFC-07	2.0 (3-hr)
Elk Hills - Sempra & Oxy	1999-AFC-01	2.0 (3-hr)
Palomar Escondido - SDG&E	2001-AFC-24	2.0 (3-hr)
Magnolia - So. Ca. Power Producers	2001-AFC-06	2.0 (1-hr)
Avenal Energy - Avenal Power Center, LLC	2008-AFC-1	1.4 without duct firing; 2.0 with duct firing (3-hr)
Victorville Hybrid Gas-Solar - City of Victorville	2007-AFC-1	1.4 without duct firing; 2.0 with duct firing
Gila Bend Power Generating Station	AZ-0038	1.4
Sacramento Municipal Utility District	CA-0997	1.4
Cosumnes - SMUD	2001-AFC-19	1.4 (3-hr)
Lodi Energy Center - NCPA	2008-AFC-10	1.4 (3-hr)
Colusa II Generation Station - PG&E	2006-AFC-9	1.38 without; 2.0 with duct firing (1-hr)
FPL Turkey Point Power Plant	FL-0263	1.3 without duct firing; 1.9 with duct firing
Cogen Technologies Linden Venture, L.P.	NJ-0059	1.2
Empire Power Plant	NY-0100	1.0 without duct firing; 7.0 with duct firing
Sutter - Calpine	1997-AFC-02	1.0 (3-hr)
IDC Bellingham	CA-1050	1.0 (1-hr)
Blythe I - NextEra Energy (FPL)	1999-AFC-08	2.9 lb/hr (based on 1.0 ppm)
Russell City - Calpine & GE	2001-AFC-07	2.86 lb/hr (based on 1.0 ppm)
High Desert - Constellation	1997-AFC-01	2.51 lb/hr (based on 1.0 ppm)
CPV Warren ^a	VA-0291	0.7 without duct firing; 1.0 with duct firing; 1.4 with duct firing and power aug.
Warren County Facility, Scenario 1 ^a	VA-0308	0.7 without duct firing; 1.0 with duct firing; 1.4 with duct firing and power aug.
Warren County Facility, Scenario 2 ^a	VA-0308	0.7 without duct firing; 1.0 with duct firing
Warren County Facility, Scenario 3 ^a	VA-0308	0.7 without duct firing; 1.0 with duct firing

Notes:

Only facilities with known concentration limits were included for comparison.

^a Warren County Facility and CPV Warren are the same facility (Permit Number 81391) and have not been built; a new application amended April 27, 2010, by Virginia Electric Power and Power Company (Dominion) will replace the listed determinations.

As this review of POC permit emissions limits for similar facilities shows, 1.0 ppmvd @ 15% O₂ is the most stringent emissions limit achieved by an emissions control device or technique on utility-sized gas turbines. As with CO, the CPV Warren plant has had a permit issued with certain limits lower than 1.0 ppm, but this plant has not been built (and will not be built, according to the permitting agency)³⁴ and so there is no operational data indicating this limit is achievable. Such a permit limit is not achieved-in-practice for purposes of the District's BACT requirement. The La Paloma facility has a 0.7 ppm limit, but it is measured as propane and it is based on a three-hour averaging period, both of which indicate that it is not a more stringent limit. The District's proposed limit here is 1.0 ppm measured as methane, which is approximately three times lighter than propane. As a result, the mass of POC emissions corresponding to a 0.7 ppm limit measured as propane will be about twice the mass of POC

³⁴ See e-mail from J. Pandey VADEQ to K. Truesdell BAAQMD dated July 7, 2010.

emissions corresponding to a 1.0 ppm limit measured as methane. This is reflected in the fact that the facility emits up to 2.8 pounds per hour of POC, whereas the proposed Oakley facility will only emit only 2.71 pounds per hour using larger turbines. (La Paloma uses ASEA Brown Boveri GT024 turbines with a capacity of 171.1 MW each, which are smaller than the Oakley facility's 213 MW GE Frame 7FA turbines.) In addition, the longer averaging time will allow for significant excursions above the 0.7 ppm permit limit compared with the District's proposed more stringent 1-hour averaging time. For all of these reasons, La Paloma does not establish that a limit has been achieved in practice that is more stringent than 1.0 ppm measured as methane and averaged over one hour.

To determine whether a lower limit could be justified as BACT 1 (technologically feasible and cost-effective), the District evaluated the costs and emissions reduction benefits of installing a larger oxidation catalyst that could be capable of consistently maintaining emissions below 0.7 ppm. Based on these analyses, the cost of achieving a 0.7 ppm permit limit would be an additional \$77,882 per year (above what it would cost to achieve a 1.0 ppm limit), and the additional reduction in POC emissions would be approximately 3.29 tons per year, making an incremental cost-effectiveness value of \$23,706 per ton of additional POC reduction. The total cost of achieving a 0.7 ppm POC limit (as opposed to the incremental costs of going from 1.0 ppm to 0.7 ppm) would be over \$524,959 per year, and the total emission reductions from 1.4 ppm from the turbine to a 0.7 ppm limit would be 6.16 tons per year, resulting in a total (or "average") cost effectiveness value of \$85,238. The District has adopted guidelines that limit the maximum cost per ton of POC controlled that would be considered cost-effective to \$17,500.³⁵ Based on the high costs (on a per-ton basis) and the relatively little additional POC emissions benefit to be achieved (on a per-dollar basis), requiring a 0.7 ppm POC permit limit cannot reasonably be justified as a BACT limit. Requiring controls to meet a 0.7 ppm limit would be significantly more expensive, on a per-ton basis, than what the District would require any other similar facilities to achieve under the District's cost-effectiveness guidelines for POC.

The District has therefore determined that BACT for POC for this facility is the use of good combustion practice with abatement by an oxidation catalyst for each gas turbine with permit limits of 2.71 lb per hour, which corresponds to 1.0 ppmvd @ 15% O₂. Compliance with the POC permit limits will be demonstrated by annual source tests.

³⁵ See Bay Area Air Quality Management District Best Available Control Technology (BACT) Guideline, § 1, Policy and Implementation Procedure, available at: <http://hank.baaqmd.gov/pmt/bactworkbook/default.htm>.

5.2.4 Best Available Control Technology for Particulate Matter (PM)³⁶

Particulate matter emissions from gas turbines result from several processes. Particulate matter may be entrained in the combustion air that passes through the combustor inlet filter, which will pass through the combustion chamber and out into the exhaust stream. Trace amounts of particulate matter may also be entrained in the natural gas and will also end up in the exhaust stream. Sulfur in the natural gas can form PM during combustion, and can also combine with other compounds in the atmosphere after it is emitted to form secondary PM such as sulfates. Unburned hydrocarbons from the natural gas that are not fully combusted may condense to form PM.

Control Technology Review:

The District evaluated control technologies for PM in three areas: (1) pre-combustion controls (2) combustion controls, and (3) post-combustion controls.

Pre-Combustion Controls

- **Inlet Air Filter:** An inlet air filter is commonly used to protect the turbine from contaminants in the air, which can damage the turbine. There are two main types of filters, static filters and self-cleaning filters. Self-cleaning filters are cleaned periodically by a pulse of backflow air that dislodges the layer of dust collected on the outside surface of the filter. Self-cleaning filters require less maintenance than static filters and can be used in harsher environments. Both filter types can utilize high-efficiency filters capable of filtering particles less than 10 µm in diameter.

Combustion Controls

- **Good Combustion Practice:** Good combustion will ensure proper air/fuel mixing to achieve complete combustion, thus minimizing emissions of unburned hydrocarbons that can lead to formation of PM at the stack.

³⁶ This facility is subject to BACT requirements for PM₁₀ only. PM_{2.5}, a subset of PM₁₀, is regulated under federal requirements in 40 C.F.R. Section 52.21 (PSD) and 40 C.F.R. Part 51, Appendix S (Non-Attainment NSR). The facility is not subject to PSD or PM_{2.5} Non-Attainment NSR permit requirements under Section 52.21 or Appendix S because the facility is not a “major facility” for the purposes of these regulations. The District is therefore not conducting a PSD permitting analysis or an Appendix S permitting analysis for PM_{2.5}. For a detailed discussion of the applicability of these federal requirements for PM_{2.5}, see Section 7 below. The District notes, however, that for combustion turbines essentially all of the PM emissions are less than one micron in diameter, so it is both PM₁₀ and PM_{2.5}. (See AP-42, Table 1.4-2, footnote c, 7/98 (available at www.epa.gov/ttnchie1/ap42/ch01/final/c01s04.pdf). Moreover, the same emissions control technologies that will be effective for PM₁₀ for this facility will also be similarly effective for PM_{2.5}. The District’s BACT analysis and emissions limit for PM₁₀ will also therefore effectively be a BACT limit on PM_{2.5} emissions as well, even though the facility is not subject to the federal PM_{2.5} BACT requirements as discussed in Section 7.

- **Clean-burning fuels:** The use of clean-burning fuels, such as natural gas that has only trace amounts of sulfur that can form particulates, will result in minimal formation of PM during combustion. The use of low-sulfur natural gas is commercially available and demonstrated for gas turbines.
- **Dry Low-NO_x Combustor:** The use of a Dry Low-NO_x Combustor provides efficient combustion to ensure complete combustion thereby minimizing the emissions of unburned fuel that can form condensable PM. Dry Low-NO_x Combustors are in wide use on utility scale gas turbines.

Post-Combustion Controls

- **Electrostatic precipitators:** Electrostatic precipitators are used on solid fuel boilers and incinerators to remove PM from the exhaust. Electrostatic precipitators use a high-voltage direct-current corona to electrically charge particles in the gas stream. The suspended particles are attracted to collecting electrodes and deposited on collection plates. Particles are collected and disposed of by mechanically rapping the electrodes and plates and dislodging the particles into collection hoppers.
- **Baghouses:** Bagoes are used to collect PM by drawing the exhaust gases through a fabric filter. Particulates collect on the outside of filter bags that are periodically shaken to release the particulates into hoppers.

Inlet air filters, good combustion practice, clean-burning fuels, and Dry Low-NO_x Combustors are common control devices/techniques that are technically feasible for combined-cycle gas turbines and are often used to control emissions from sources of this type. These technologies are “achieved in practice” for this type of facility, and the District is proposing to require them here as the BACT control technologies.

With respect to the add-on controls – electrostatic precipitators and baghouses – these control devices are not achieved-in-practice for natural gas-fired gas turbines. These devices are normally used on solid-fuel fired sources or others with high PM emissions, and are not used in natural gas-fired applications, which have inherently low PM emissions. The District is not aware of any gas turbine that has ever been required to use add-on controls such as these. The District also reviewed the EPA BACT/LAER Clearinghouse and confirmed that EPA has no record of any post-combustion particulate controls that have been required for natural gas-fired gas turbines. The District has therefore determined that these control devices are not achieved in practice for purposes of the BACT analysis.

Furthermore, these devices would not be technologically feasible to implement here. If add-on control equipment were installed, it would create significant backpressure that would significantly reduce the efficiency of the plant and would cause more emissions per unit power produced. Moreover, these devices are designed to be applied to emissions streams with far higher particulate emissions, and they would have very little effect on the low-PM emissions

streams from this facility in further reducing PM emissions.³⁷ It takes an emissions stream with a much higher grain loading for these types of abatement devices to operate efficiently. This low level of abatement efficiency (if any) also means that these types of control devices would not be cost-effective, even if they could feasibly be applied to this type of source. For all of these reasons, post-combustion particulate control equipment is not technologically feasible/cost effective for the proposed turbines.

Proposed BACT Control Technology for PM for Combined-Cycle Gas Turbines:

The District has determined that use of a high efficiency inlet air filter, low-sulfur natural gas and Dry Low-NO_x combustors with good combustion practice are the BACT control technologies for the proposed Oakley Generating Station. For low-sulfur fuel, the highest quality commercially available natural gas is natural gas that meets the PG&E Gas Rule 21, Section C standard of less than 1.0 grains of sulfur per 100 scf. This PG&E standard is the maximum sulfur content at any point in time.³⁸ The District is therefore proposing a BACT limit for fuel sulfur content of 1.0 grains of sulfur per 100 scf. Good combustion practice for the proposed gas turbines at Oakley Generating Station³⁹ would include the use of GE's DLN-2.6 combustion system, which controls turbine emissions of CO to 9 ppm (prior to abatement by the oxidation catalyst), Continuous Dynamics Monitoring (CDM) enhancements, including onsite visual tools for monitoring combustion dynamics and performing diagnostics, and other advanced controls software. The high level of control of CO indicates unburned hydrocarbons are also well controlled, thereby minimizing PM emissions. Compliance with the stringent CO emission limits will ensure that good combustion practice is being maintained.

The District is not proposing to impose a numerical emissions limit in addition to the BACT requirement to use low-sulfur natural gas and good combustion practices. The District's BACT regulations require the District to implement BACT either as a control device or technique (Regulation 2-2-206.1 and 2-2-206.3) or as an emission limitation (Regulation 2-2-206.2 and 2-2-206.4), and do not require both types of BACT limits. The District is therefore proposing the control techniques described above to fulfill the BACT requirement for PM in accordance with Regulations 2-2-206.1 and 2-2-206.3. The District considered whether to require a numerical

³⁷ For example, if a baghouse were installed on the turbines, the turbine exhaust at the *inlet* to the baghouse would contain less PM than is normally seen in baghouse *output*, after abatement. PM emissions from a baghouse are normally in the range 0.0013 to 0.01 grains per standard cubic foot (see *BAAQMD BACT/TBACT Workbook*, Section 11: Miscellaneous Sources), whereas PM emissions from the proposed Oakley Generating Station turbines would be 0.00081 gr/dscf (@ 15% O₂).

³⁸ PG&E's Gas Rule 21, Section C requires the quality of gas received into the pipeline system to have a maximum sulfur content of 1.0 grain per 100 scf. The actual average content is expected to be less than 0.25 grains per 100 scf. The District has based its calculations of annual emissions on this 0.25 grain per 100 scf average sulfur content. Note that a portion of the sulfur contained in natural gas is intentionally added as an odorant to allow for the detection of leaks which would be a safety concern. PG&E Gas Rule 21, Section C can be found at: http://www.pge.com/pipeline/operations/sulfur/sulfur_info.shtml.

³⁹ See e-mail from J. McLucas, Radback Energy, to K. Truesdell dated 8/31/2010.

emissions limit as well, but has concluded that doing so would not be warranted here, given that there are no add-on control devices that the facility can use to control PM emissions. Assuming the facility is using good combustion practices, PM emissions will be determined by the amount of sulfur in the fuel and the way that the combustion equipment functions, which are factors that are not within the control of the operator. PM therefore presents a different situation than other pollutants such as NO_x or CO where the project owner can design its add-on control systems to achieve the required level of emissions and ensure that it will comply with its emission limits by operating the add-on control systems properly.

This proposed BACT determination is consistent with guidance from the California Air Resources Board in setting BACT for natural gas-fired gas turbines.⁴⁰ This proposed BACT determination is also consistent with District BACT Guideline 89.1.6, which specifies BACT for PM₁₀ for combined-cycle gas turbines with rated output of ≥ 40 MW as the exclusive use of clean-burning natural gas with a maximum sulfur content of ≤ 1.0 grains per 100 scf.⁴¹ These guidance documents do not suggest that a numerical emissions limit should be required as a BACT permit condition.

5.2.5 Best Available Control Technology for Sulfur Dioxide (SO₂)

Emissions of SO₂ are formed from the oxidation of trace amounts of sulfur in the fuel.

Control Technology Review:

There are two primary mechanisms used to reduce SO₂ emissions from combustion sources: (i) reduce the amount of sulfur in the fuel, and (ii) remove the sulfur from the combustion exhaust gases.

Limiting the amount of sulfur in the fuel is a common practice for natural gas-fired power plants. Such plants in California are typically required to combust only natural gas with a sulfur content of less than 1 grain per 100 standard cubic feet (scf). In the Bay Area, PG&E supplies gas that complies with its Gas Rule 21, Section C, which requires a sulfur content of less than 1.0 grains of sulfur per 100 scf. This PG&E standard is the maximum sulfur content at any point in time. The requirement for low-sulfur natural gas is a control technique has been achieved in practice at other facilities, and it is technologically feasible and cost-effective. The District is therefore proposing to require the use of natural gas with a sulfur content of less than 1 grain/100 scf as a BACT control technique for SO₂.

⁴⁰ Guidance for Power Plant Siting and Best Available Control Technology, California Air Resources Board, Stationary Source Division, September 1999, pg. 34. (available at: <http://www.arb.ca.gov/energy/powerpl/power.htm>)

⁴¹ See Bay Area Air Quality Management District Best Available Control Technology (BACT) Guideline, § 1, Policy and Implementation Procedure, available at: <http://hank.baaqmd.gov/pmt/bactworkbook/default.htm>

Add-on controls that remove sulfur from the combustion exhaust, such as flue gas desulfurization, are not feasible for natural gas-fired power plants and have not been used at such facilities. These types of control devices are typically installed on coal fired power plants that burn fuels with much higher sulfur contents. There are two main types of SO₂ post-combustion control technologies: wet scrubbing and dry scrubbing. Wet scrubbers use an alkaline solution to remove the SO₂ from the exhaust gases and may remove up to 90% of the SO₂ from the exhaust stream. Dry scrubbers use an SO₂ sorbent injected as a powder or slurry to remove the SO₂, and the SO₂ and sorbent are removed by a particulate control device. The abatement efficiencies vary with different types of dry scrubbing technologies, but are generally lower than efficiencies for wet scrubbing technologies. These technologies are not feasible for combustion sources burning low sulfur content natural gas. The SO_x concentrations in the natural gas combustion exhaust gases are too low (less than 1 ppm) for the scrubbing technologies to work effectively or be technologically feasible and cost effective. These control technologies require much higher sulfur concentrations in the combustion exhaust gases to become feasible as a control technology. For this reason, they have not been used at natural gas-fired power plants such as the proposed Oakley Generating Station. As these control technologies have not been achieved in practice at other similar facilities and are not technologically feasible here, the District is not proposing to require them as BACT for this facility.

Proposed BACT Control Technology for SO₂ for Gas Turbines:

Fuel sulfur limits are the only feasible SO₂ control technology for natural gas combustion sources, and the District is proposing to require this technology as BACT. The District is proposing BACT permit limits requiring the use of natural gas containing a maximum of 1 grain of sulfur per 100 scf of natural gas. Compliance will be demonstrated with monthly sulfur content data. As with the PM BACT requirement, the District is proposing to implement BACT as a control technology only and not as a condition establishing a numerical limit on SO₂ emitted from the stack. The same reasons why the District has concluded that a numerical emissions limit would not be warranted for PM apply to as SO₂ well.

5.2.6 Best Available Control Technology For Startups, Shutdowns, and Combustor Tuning

Startup and shutdown periods are a normal part of the operation of natural gas-fired power plants. They involve emissions rates that are greater than emissions during steady-state operation and that are highly variable. Emissions are greater during startup and shutdown for several reasons. One reason is that during startup and shutdown, the turbines are not operating at full load where they are most efficient. Another reason is that the exhaust temperatures are lower than during steady-state operations. Post-combustion emissions control systems such as the SCR catalyst and oxidation catalyst do not function optimally outside a certain temperature range, and so there may be partial or no abatement for NO_x, carbon monoxide and precursor organic compounds for a portion of the startup period. Thus, emissions can be minimized by reducing the duration of the startup sequence and by controlling the startup sequence to reduce emissions.

In addition, the gas turbines will need to perform combustor tuning. This is a regular plant equipment maintenance procedure in which testing, adjustment, tuning, and calibration operations are performed, as recommended by the equipment manufacturer, to ensure safe and reliable steady-state operation, and to minimize NO_x and CO emissions. Emissions will be greater during tuning because the turbines need to be operated at low load where they are less efficient, and because the SCR and oxidation catalyst may not be fully operational. The applicant will need to be able to conduct up to two 8-hour tuning operations per year per turbine.

Because emissions are greater during startups, shutdowns, and combustor tuning periods, the BACT limits established in the previous sections for steady-state operations are not technically feasible during these periods. The District is therefore establishing separate BACT limits representing the most stringent emissions limits that are achieved-in-practice or technologically feasible/cost-effective for this type of facility. To do so, the District has conducted an additional BACT analysis specifically for startups, shutdowns, and combustor tuning periods.

5.2.6.1 Turbine Startups and Shutdowns

Control Technology Review:

Best Work Practice: Emissions from startups and shutdowns can be minimized using best work practice. By following the plant equipment manufacturers' recommendations, power plant operators can minimize emissions during these operating modes and can limit the duration of each startup and shutdown to the minimum duration achievable. Plant operators also use their own operational experience with their particular turbines and ancillary equipment to optimize startup and shutdown.

Fast-Start Technology: Turbine manufacturers have recently developed design improvements that allow combined-cycle facilities such as this one to start up more quickly and efficiently. These improvements allow combined-cycle facilities to bypass the steam turbine during the early stages of startup, eliminating some of the delay. With a conventional combined-cycle design, the combustion turbine must be held at low load while the steam turbine is being heated up, which needs to be done slowly to minimize thermal stresses and maintain the necessary clearances between the rotating and stationary components of the steam turbine. These new designs allow steam generated by the HRSGs to bypass the steam turbine during startups, allowing the turbines to come up to full load quickly. As the proper steam conditions are achieved, a portion of the steam will be sent to the steam turbine, which will ramp up slowly until the point is reached where steam is no longer bypassing the steam turbine. GE is marketing this new technology under the name "Rapid Response", and Siemens is marketing a similar technology under the name "Flex-Plant". The applicant is proposing to use the GE "Rapid Response" design for the Oakley Generating Station.

Proposed BACT Control Technology for Startups and Shutdowns

The District is proposing the use of best work practices with fast-start technology as BACT for startups and shutdowns of combined-cycle plants. Both control technologies are technically feasible and are the most effective technology available for decreasing startup and shutdown

emissions. The applicant has proposed the use of best work practices and GE's Rapid Response Technology, which satisfies the BACT requirement. The facility will be equipped with a specially-designed HRSG that can heat up quickly without generating excessive thermal stresses. The facility will also be equipped with an auxiliary boiler that would provide auxiliary steam when the plant is offline and during startups. This auxiliary steam will be used for condensate sparging and to maintain the seals and prevent loss of vacuum in the steam turbine and condenser, so that the steam turbine is maintained in a ready state and can start up as quickly as possible when called upon. (See Section 3.3 above for further detail regarding the use of the auxiliary boiler to improve startup performance.)

Proposed BACT Emissions Limits for Startups and Shutdowns

The District is also proposing numerical emissions limits for startups and shutdowns that represent the best emissions performance that can consistently be achieved by the BACT technology discussed above. The proposed emissions limits for Oakley Generating Station are shown in Table 12 below.

TABLE 12: PROPOSED STARTUP AND SHUTDOWN EMISSION LIMITS FOR OAKLEY GENERATING STATION

Pollutant	Cold Startup (lb/event)	Hot/Warm Startup (lb/event)	Shutdown Emission Limits (lb/event)
NO _x (as NO ₂)	96.3	22.3	39.3
CO	360.2	85.2	140.2
POC (as CH ₄)	67.1	31.1	17.1

The District is also proposing to add time limits for startups and shutdowns, in addition to numerical emissions limits. BACT limits are normally expressed as numerical emissions limits, as it is the actual emissions of air pollutants from a facility that have an impact on air quality. The numerical emissions limits are therefore the primary permit limits – and the permit conditions required by BACT – but the District is also proposing limits on startup and shutdown duration for this facility as an additional backstop to help ensure that startup and shutdown emissions are kept to a minimum. The District is proposing time limits of 30 minutes for hot/warm startups, 90 minutes for cold startups, and 30 minutes for shutdowns.

These proposed startup and shutdown limits are based on an analysis of what is involved in startup and shutdown operations using best work practices and GE's Rapid Response system.⁴² The facility will typically start from a "ready-to-start" condition, with the electrical systems energized, steam process vessels filled to prestart level, manual valves in run position, and controls in auto. The plant will also typically have "Purge Credit" established, meaning the gas turbine and HRSG were purged with air to clear any remaining combustible gases and the gas turbine fuel train was prepared to assure that no fuel entered the gas turbine and HRSG while the unit was offline. The steps of purging the gases from the gas turbine and HRSG are also referred

⁴² See Gordon R. Smith and Andrew Baxter, *GE Energy Rapid Response Combined Cycle*, PowerPoint presentation (Sept. 24, 2007).

to as a “purge cycle” and, at conventional combined-cycle plants, are performed in the startup sequence and can take approximately 15 minutes. A purge cycle is required prior to firing the gas turbine to prevent explosion of any residual gases. GE has worked with the National Fire Protection Agency to establish safe conditions (proposed in the 2010 Fall Revision Cycle to NFPA 85) without the delay in startup time that the purge cycle normally takes by moving the purge cycle to the end of the shutdown sequence. GE calls this feature Purge Credit.

The gas turbine starting process is initiated to roll the gas turbine, and the gas turbine is fired within a couple of minutes after roll. After fire, the gas turbine accelerates to full speed no load (FSNL) with the driving power provided by the load commutated inverter (LCI), a variable speed drive motoring the generator. At about 95% speed, the LCI disengages and the gas turbine settles at FSNL. Accelerating the gas turbines to 95% speed occurs as fuel is burned in certain burners within the combustors to ensure a stable flame and takes about 5 to 6 minutes to complete.⁴³ The combustors are not operating at their optimum efficiency at this point so emissions are higher than during steady-state operation.

On hot and warm starts,⁴⁴ the gas turbine synchronizes and loads directly to the desired load. This immediate loading is the benefit of the fast-start design compared to conventional combined-cycle designs, in which the combustion turbine cannot be brought up to minimum emissions compliance load until the steam turbine is brought up to operating temperature. Startup emissions in the Rapid Response plant are therefore lower than in a conventional combined-cycle plant, although they are still greater than steady-state emissions because the combustors must be loaded in a particular sequence to maintain a controlled and stable flame as load is increased. The combustors go through six modes of firing different burner combinations to reach steady-state emissions compliance, which takes another 5 or 6 minutes to complete. For cold starts, the gas turbine needs somewhat longer to come up to minimum emissions compliance load because the HRSG needs to be brought up to temperature gradually to reduce thermal stresses. Cold startups therefore require an additional hold at low load, which causes cold starts to be longer than hot and warm starts (although cold starts with the Rapid Response system are still shorter than cold starts with a conventional combined-cycle system).

⁴³ See *Dry Low NOx Combustion Systems for GE Heavy-Duty Gas Turbines* GER3568g L.B. Davis and S.H. Black, GE Power Systems, October 2000, at pp. 12-14. (available at: http://www.gepower.com/prod_serv/products/tech_docs/en/downloads/ger3568g.pdf) See also *GE Rapid Response 207FA Plant Operation* G.R. Smith, GE June 4, 2010. See also Email from J. McLucas Radback Energy to K. Truesdell BAAQMD subject: OGS-Additional Information on Startups, dated 10/21/2010.

⁴⁴ Note that there will be no difference in performance between hot and warm startups. The District has often differentiated between hot startups and warm startups for other combined-cycle facilities with conventional designs (with hot startups being defined as startups when the turbine has been down for less than 8 hours and warm startups being defined as startups when the turbine has been down for 8-48 hours). To avoid confusion, the District is maintaining the hot/warm terminology here, even though there is no difference in startup performance between hot and warm startups. A hot/warm startups for this facility are defined as any startup that occurs within 48 hours of a shutdown.

Based on discussions with and a letter from GE, the District estimates that with this Rapid Response system, a typical hot/warm startup will take approximately 15 minutes until emissions reach compliance with the proposed steady-state emission limits, and a typical cold startup will take approximately 46 minutes.⁴⁵ The District estimates that hot/warm startups will generate up to 22.3 pounds of NO_x, 85.2 pounds of CO, and 31.1 pounds of POC; and that cold startups will generate up to 96.3 pounds of NO_x, 360.2 pounds of CO, and 67.1 pounds of POC.⁴⁶ The District has found that the duration of turbine startups can vary significantly from startup to startup depending on a large number of variables, and that not-to-exceed startup limits need to reflect this variability so that the facility can comply with them consistently over the life of the facility under all reasonably foreseeable operating scenarios.⁴⁷ The District is therefore proposing limits on startup duration of 30 minutes for hot/warm startups and 90 minutes for cold startups, which is twice the duration of a typical startup as estimated by the equipment manufacturer, to ensure that the facility will be able to achieve these limits consistently.⁴⁸

For shutdowns, the process is as follows. Over approximately 10 minutes, the gas turbines unload to the point where gas turbine exhaust temperature is slightly above rated steam temperature. This is the lowest load at which the gas turbine can operate without causing the steam temperature to drop below the rated steam temperature. The purpose of this hold is to avoid unintentionally cooling the steam turbine to a point that could cause the next plant startup to be longer than necessary. The gas turbine hold is expected to be around 20 percent load. While the gas turbines are holding, the steam turbine is unloaded by closing all steam turbine control valves. As the steam turbine control valves close, the steam turbine bypass valves begin

⁴⁵ See Memorandum of Record of Telephone call dated 10/21/2010, prepared by K. Truesdell BAAQMD. See also letter from Peter Bukunt GE to K. Truesdell BAAQMD Re: Contra Costa Generating Station (Oakley) – Emissions Guarantees and Estimated Startup and Shutdown Durations and Emissions dated December 1, 2010. GE provided estimates of what would be required to reach steady-state emissions compliance, but did not include any emissions at the steady-state emissions rate. The District's startup definitions provide that a startup ends with two consecutive compliant emissions readings, however. The District has therefore added one minute to GE's estimated startup duration and one minute's worth of steady-state emissions. Including one minute of steady-state emissions in addition to the manufacturer's emissions limits is appropriate to ensure compliance based on the CEMs' reading.

⁴⁶ See id.

⁴⁷ The District has evaluated startup data in prior permit proceedings for power plants such as this one and has documented the high degree of variability in individual startups. See, e.g., Statement of Basis, Russell City Energy Center, Application No. 15487 (Dec. 8, 2008), available at

www.baaqmd.gov/~media/Files/Engineering/Public%20Notices/2009/15487/B3161_nsr_15487_sb-corrected_121208.ashx, at Section V.A.4.

⁴⁸ Since no fast-start facilities have yet been built, there is no startup data available from actual operating facilities on which to base a compliance margin specifically for the GE Rapid Response system. Variability in individual startups of twice the typical startup is not unusual for other combined-cycle facilities using conventional designs, however, and in the District's professional engineering judgment it is an appropriate basis for establishing a startup duration permit limit for a Rapid Response design.

to divert steam from the steam turbine to the condenser, essentially maintaining constant steam pressure. After approximately 5 minutes, the steam turbine will be completely unloaded, desynchronized, and the steam turbine will begin to decelerate. After the steam turbine has unloaded and the gas turbine resumes unloading, a second low load hold will occur when the gas turbine reaches approximately 10 percent load. This hold is designed to further reduce steam temperature and allow the cooler steam to reduce the temperature of the HRSG superheater lower header. Ten minutes are allotted for this hold per HRSG manufacturer direction. This hold is necessary to reduce the potential for HRSG damage during the purge operation shortly following shutdown, as described above, where relatively cool air will be blown through the gas turbine and HRSG as part of establishing Purge Credit. At the end of this hold, the gas turbines will resume ramping to zero load over a period of about 3 to 4 minutes whereupon they will desynchronize and begin fired shutdown. Flame is maintained in the gas turbines during deceleration to reduce the thermal shock on the hot gas path parts (gas turbine and HRSG). At about 20 percent gas turbine speed, fuel is cut off, the gas turbine flames out, and decelerates freely from this point to turning gear. Based on discussions with GE, the District estimates that shutdowns will take up to 30 minutes and involve 39.3 pounds of NO_x emissions, 140.2 pounds of CO emissions, and 17.1 pounds of POC emissions.⁴⁹ The District is proposing these limits as not-to-exceed permit limits on shutdowns. The District does not believe any additional time allowance is required for shutdown.

The District has also compared these proposed startup and shutdown limits with other proposed facilities using fast-start combined cycle designs. The District compared the startup and shutdown limits for the Lodi Energy Center, which was licensed by the CEC in April of 2010,⁵⁰ and the Blythe II project, which is currently in the CEC licensing process.⁵¹ Both of these projects incorporate the Siemens Flex-Plant 30 fast-start system. In addition, the District also evaluated the Victorville 2 Hybrid Power Project and the Palmdale Hybrid Power Project, which are designed with an earlier application of the fast-start concept. This application, which GE called “Rapid Start”, provides for the steam turbine to be bypassed during startups to achieve faster starts and is therefore somewhat comparable, although it does not include all of the additional elements of the more recent Rapid Response design. In comparing these facilities, the District looked at the permit limits applicable to startups and shutdowns combined, for several reasons. One reason is that every startup is necessarily coupled with a shutdown, as by definition a startup has to follow a shutdown. Another reason is that the proposed Oakley project will incorporate “Purge Credit” into its shutdown sequence, which removes a required step from the startup process as described above so that the facility can be started up more quickly. It would not make sense to penalize this project for moving this step from the startup sequence to the shutdown sequence, and so to avoid such an outcome the District evaluated overall facility

⁴⁹ See Memorandum of Record of Telephone call dated 10/21/2010, prepared by K. Truesdell BAAQMD. As with the startup emissions, the manufacturer’s shutdown emissions do not account for any time at steady-state. The District therefore add one minute’s worth of steady-state emissions to the manufacturer’s estimates to establish permit limits on turbine shutdowns.

⁵⁰ See Final Commission Decision, available at: www.energy.ca.gov/2010publications/CEC-800-2010-003/CEC-800-2010-003-CMF.PDF .

⁵¹ The Energy Commission’s web page for this proceeding can be found at www.energy.ca.gov/sitingcases/blythe2/compliance/ .

performance for startups and shutdowns combined. The comparison of the applicable permit conditions for these facilities and the proposed Oakley Generating Station permit conditions is summarized in Table 13 below.

**TABLE 13: STARTUP AND SHUTDOWN PERMIT LIMITS FOR SIMILAR
COMBINED-CYCLE POWER PLANT PROEJCTS USING FAST-START
TECHNOLOGY**

Facility Name	Victorville 2 Hybrid Power Project	Palmdale Hybrid Power Project	Lodi Energy Center	Blythe Energy Project II (proposed)	Oakley Generating Station (proposed)
Technology	GE Rapid Start Process	GE Rapid Start Process	Siemens Flex-Plant 30	Siemens Flex-Plant 30	GE Rapid Response
Maximum Heat Input (MMBtu/hr/gas turbine)	1736.4	1736.4	2142	2019.6	2150
Hot/Warm Startup + Shutdown					
Total Duration (min)	110	110	360	120	60
Total Emissions Limit (lb)					
NO_x	97	97	960	111.6	61
CO	666	666	5400	83.8	225
POC	no limit	no limit	96	no limit	48
Cold Startup + Shutdown					
Total Duration (min)	140	140	360	240	120
Total Emissions Limit (lb)					
NO_x	153	153	960	150.6	135
CO	747	747	5400	165.7	500
POC	no limit	no limit	96	no limit	84

As Table 13 shows, the proposed permit conditions for the Oakley Generating Station are very stringent compared with other similar facilities, and meet or exceed all of the other facilities' permit limits with one exception. The one exception is the CO emissions limits that are currently being proposed for the Blythe II project, which, if adopted in their current form, will limit combined CO emissions to 83.8 pounds of CO for a hot/warm startup and shutdown (compared with the proposed 225 pounds for Oakley) and 165.7 pounds of CO for a cold startup and shutdown (compared with the proposed 500 pounds for Oakley). The District has evaluated these proposed CO limits for Blythe II and has concluded that they do not suggest that the District's proposed limits for the Oakley Generating Station are inappropriate, for several reasons. First, the Blythe II project is still under review, and the limits that are currently being considered have not yet been finalized and could potentially change when the project is

approved. Second, even if the Blythe II project is ultimately permitted with these limits, the facility is not yet built and operational and so there is no actual operating data that demonstrate that these limits will in fact be achievable by the facility. And third, even assuming that the Blythe II facility will be able to be operated in compliance these proposed permit conditions, the limits being proposed for the facility reflect a balance between NO_x and CO reductions that has been made in a manner different from how the District would make it. There is an inherent tradeoff between achieving additional NO_x reductions and achieving additional CO reductions because NO_x is reduced by lowering the combustion temperature to reduce the formation of thermal NO_x whereas CO is reduced by increasing the combustion temperature to avoid incomplete combustion. (See discussion in Section 5.2.1 above for more details.) The District prioritizes NO_x reductions over CO reductions because the Bay Area is not in attainment of the state and federal ambient air quality standards for ozone (NO_x is a precursor to ozone formation), whereas it is in attainment of the CO standards. The District therefore prefers lower NO_x limits even if that means somewhat higher CO limits. In this case, the Oakley Generating Station will be able to achieve NO_x emissions for startups that are significantly below the proposed limits for Blythe II (61 pounds vs. 111.6 pounds for hot/warm startups/shutdowns, and 135 pounds vs. 150.6 pounds for cold startups/shutdowns). The District considers these additional NO_x reductions to be more important than the additional CO reductions reflected in the proposed Blythe II conditions. For all of these reasons, the District has concluded that the Blythe II project does not suggest that the proposed conditions for the Oakley Generating Station are inappropriate.

Based on all of this analysis, the District is proposing the startup and shutdown conditions described above as BACT for the Oakley Generating Station. The District finds that these are the most stringent emission limits that can be achieved by this facility based on all of the information available at this time regarding the performance of this newly developed technology.

5.2.6.2 Combustor Tuning

Combustor tuning is required to maintain the gas turbines in optimal operating condition. Tuning is done in response to turbine wear and variations in fuel, temperature, and humidity. The gas turbines will be subject to extremely stringent limits for startups and shutdowns in addition to stringent steady-state limits, so providing an allowance for tuning is necessary to assure compliance during the rest of the year.

The burners in the turbines that would be used at the Oakley Generating Station have 6 modes of operation, depending on where and how much fuel and air are routed to different parts of the burner (combustion fuel staging). Details on the modes of operation can be seen in the GE Publication #GER 3568G “Dry Low NO_x Combustion Systems for GE Heavy-Duty Gas Turbines.” Tuning involves testing and adjusting the 6 modes and the transition from one mode to another. These operations are time-intensive and are expected to take up to 8 hours to complete.⁵² The reason that up to 8 hours are required to complete the tuning is that during

⁵² See Letter from Peter Bukunt, GE, to Kathleen Truesdell, BAAQMD, dated December 1, 2010 regarding: Contra Costa Generating Station (Oakley) – Preliminary Determination of Compliance Combustion Turbine Tuning.

tuning, the turbine operating rate is brought up 5 MW at a time and tuning is performed at each MW level. The turbines are held at each load level while settings are varied to establish the optimal operating conditions. The complexity of the model-based control system requires tuning the turbine at each turbine operating point, which establishes tuning set points. The tuning set points are then saved in the plant control system algorithms and used during normal operation as the gas turbine continuously and automatically tunes itself. Tuning would need to be performed up to two times per year per turbine. Each turbine would be able to be tuned separately to keep tuning emissions to a minimum.

Tuning has traditionally been performed during cold startups. Cold startups involve bringing the turbine load up slowly, and so they provide an appropriate opportunity to conduct tuning. Recently, regulatory agencies have started imposing shorter time limits on cold startups, and so it has become increasingly difficult for operators to complete tuning within their cold startup time limits. Recent permits have therefore had to include specific provisions allowing for tuning operations outside of cold startups. Since tuning operations were originally conducted under cold startup limits, these provisions have typically provided for tuning operations to be subject to the same emissions limits applicable during cold startups. These limits are also generally appropriate for tuning because tuning involves low-load operation where emissions controls are not as effective, as is the case with cold startups. (Tuning takes longer than cold startups, however, because the turbines must be kept at each load level for a period of time while tuning takes place, and cannot be ramped up as soon as equipment conditions allow.)

The District is therefore proposing that tuning operations should be subject to emissions limits at least as stringent as the hourly emissions limits that apply during cold startups – 96 lb/hour of NO_x, 260 lb/hour of CO, and 67 lb/hour of POC. The District believes that it may be possible to maintain tuning emissions at even lower levels, although the facility has not yet been built and so there is not yet sufficient operating data on which to base lower permit limits. The District is therefore proposing that further emissions limits for tuning operations would be established after the facility is built based on test data obtained during actual tuning operations. These further emissions limits would be at least as stringent as the cold startup limits, and would be even lower if lower limits prove to be feasible.

The District is therefore proposing a provision that would allow the Oakley Generating Station to conduct up to two tuning events per year per turbine, with a duration not to exceed 8 hours per tuning event. In addition, the facility would be allowed to conduct tuning on only one turbine at a time. Emissions would be subject to the lowest limits that can be achieved by the facility, which the District would establish based on testing after the facility is built and which would in no event be greater than the hourly emissions rates applicable for cold startups.

5.2.7 Best Available Control Technology During Gas Turbine Commissioning

The combined-cycle gas turbines and associated equipment are highly complex and have to be carefully tested, adjusted, tuned and calibrated after the facility is constructed. These activities are generally referred to as “commissioning” of the facility. During the commissioning period, each of the gas turbine generators needs to be fine-tuned at zero load, partial load, and full load to optimize its performance. The dry-low NO_x combustors also need to be tuned to ensure that

the turbines run efficiently while meeting both the performance guarantees and emission guarantees. In addition, the selective catalytic reduction (SCR) systems and oxidation catalysts need to be installed and tuned.

The combined-cycle gas turbines will not be able to meet the stringent BACT limits for normal operations during the commissioning period for a number of reasons. First, the SCR systems and oxidation catalysts cannot be installed immediately when the turbines are initially started up. There may be oils or lubricants in the equipment from the manufacture and installation of the equipment, which would damage the catalysts if they were installed immediately. Instead, the turbines need to be operated without the SCR systems and oxidation catalysts for a period of time to burn off any impurities that may be left in the equipment. In addition, once all of the pollution control equipment is installed, it needs to be tuned in order to achieve optimum emissions performance. Until the equipment is tuned, it will not be able to achieve the very high levels of emissions reductions reflected in the stringent BACT limits for normal operations.

Because the BACT limits established for normal operations are not technically feasible during the commissioning period, these limits are not BACT for this phase of the facility's operation. Alternate BACT limits must therefore be specified for this mode of operation. To do so, the District has conducted an additional BACT analysis specifically for the required commissioning activities.

The only control technology available for limiting emissions during commissioning is to use best work practices to minimize emissions as much as possible during commissioning, and to expedite the commissioning process so that compliance with the stringent BACT limits for normal operations can be achieved as quickly as possible. There are no add-on control devices or other technologies that can be installed for commissioning activities.

To implement best work practices as an enforceable BACT requirement, the District is proposing conditions that will require the turbines to minimize emissions to the maximum extent possible during commissioning. The District is also proposing numerical emissions limits based upon the equipment manufacturer's best estimates of uncontrolled emissions at the operating loads that the turbines will experience during commissioning (see table below).⁵³ The proposed permit conditions will limit emissions to below the following levels:

TABLE 14: COMMISSIONING PERIOD EMISSION LIMITS

Air Pollutant	Proposed Commissioning Period Emission Limits (Uncontrolled or Partially controlled)	
	(lb/calendar day)	(lb/hr)
NO ₂	2,380.8	148.7
Carbon Monoxide	13,303	700

Note: Please see "OGS Supplemental Air Quality Filing April 7 2010" Table 5.1A-5b for GE's detailed commissioning schedule.

⁵³ See e-mail attachment from Greg Darvin, Atmospheric Dynamics, to K. Truesdell, BAAQMD, dated 7/19/2010

Commissioning emissions will also be subject to the annual emissions limits applicable to normal operations. All emissions from commissioning activities will be counted towards the facility's annual limits. Because commissioning is a relatively short-term period, the facility should be able to stay within those limits over the course of the entire year. Counting commissioning emissions towards the annual limits will also provide an additional incentive for the facility operator to minimize emissions as much as possible.

The District is also proposing permit conditions to minimize the duration of commissioning activities. The proposed conditions require the facility to tune the gas turbines to minimize emissions at the earliest feasible opportunity; and to install, adjust and operate the SCR systems and oxidation catalysts at the earliest feasible opportunity. The District is also proposing to cap the total amount of time that the turbines can operate partially abated and/or without the SCR systems and oxidation catalysts at 831 total hours. This limit represents the shortest amount of time in which the facility can reasonably complete the required commissioning activities without jeopardizing safety and equipment warranties. The proposed limit is based on the following estimates from GE of the time it will take for each specific commissioning activity in Table 15.

TABLE 15: COMMISSIONING SCHEDULE FOR OAKLEY GENERATING STATION

Test Description	Duration (hours)	Average GT Load (%)	Total Emissions (tons)			
			NO _x	CO	VOC	PM ₁₀
GT Initial Start-up GT first firing GT FSNL on primary fuel & generator filtration GT intertripping matrix checks GT generator short circuit, overspeed and open circuit tests	50	0	1.5	11.4	1.0	0.2
GT Sync & Load GT first synchro	10	7.5	0.7	3.5	0.2	0.0
HRSG Steam blows HRSG MS steam blows HRSG CRH & HRH steam blows HRSG LP steam blows Air cooled condenser flushing Steam to gland seal, condenser vacuum tests	240	7.5	5.7	13.8	4.3	1.1
HRSG Operation on Steam Bypass HRSG startup, steam bypass checks HRSG steam safety valve tests HRSG & BOP control loop tuning	323	25	16	9.7	0.6	1.5
GT Loading up to Base on PPM Part load tests Full load tests HRSG operation on bypass for steam purity	50	46	2.5	1.5	0.1	0.2
ST Initial Start-up ST generator filtration ST intertripping checks ST generator short circuit, overspeed and open circuit tests	23	19	1.1	0.7	0.0	0.1
ST Sync & Load ST first synchro ST tests on load with one GT	38	68	0.3	0.1	0.0	0.2
GT Tuning up to Base on PSS Mode with Primary Fuel Part load tests Full load tests	97	64	0.7	0.2	0.1	0.4
Total ^a	831	-	28.6	40.8	6.4	3.7

Duration and emissions are for both gas turbines. See “OGS Supplemental Air Quality Filing April 7 2010” Table 5.1A-5b for GE’s detailed commissioning schedule. Totals are slightly different than adding the emissions for each activity due to rounding. Emissions will be limited by annual permit limits.

The District also looked to other similar facilities to determine whether any other facility has achieved better commissioning performance. Commissioning limits for conventional combined-cycle plants would not be feasible for this facility due to the complex design of Rapid Response that allows faster startups, and there are currently no operating GE Rapid Response or Siemens Flex Plant 30 plants with which to compare the proposed commissioning period. The proposed Siemens Flex Plant 30 in Lodi, CA is for one gas turbine and one steam turbine and does not have a permit limit for commissioning hours.⁵⁴ The Victorville 2 Hybrid Power Project and City of Palmdale Hybrid Power Plant Project will both use GE's Rapid Start Process, which utilizes a modified HRSG and an auxiliary boiler to reduce startup times, and they are limited to 624 hours of commissioning per turbine.⁵⁵ The proposed Siemens Flex Plant 30 for Blythe Energy Project Phase II Amendment, which is proposed as two gas turbines and one steam turbine, is proposed for up to 734 hours of commissioning per gas turbine/HRSG train.⁵⁶ The BACT limit for the commissioning period of conventional combined-cycle plants is not technologically feasible for the combined-cycle plant proposed for Oakley Generating Station due to the complex design of Rapid Response that allows faster startups. The proposed limit for the commissioning period for Oakley Generating Station is less than the limits proposed at other fast start/rapid start plants proposed in California. The District is proposing 831 total hours for the BACT limit on commissioning at Oakley Generating Station.

Emissions during commissioning will accrue towards the facility's annual emission limits. Compliance with these proposed conditions for the commissioning period will be monitored by continuous emissions monitors that the applicant will be required to install before any commissioning work begins, and through a written commissioning plan laying out all commissioning activities in advance, which the applicant will be required to submit to the District for review and approval.

⁵⁴ See Lodi Energy Center Final Commission Decision (08-AFC-10), California Energy Commission, April 2010. (available at:

<http://www.energy.ca.gov/sitingcases/loidi/documents/index.html>)

⁵⁵ See Victorville 2 Hybrid Power Project Final Commission Decision, California Energy Commission, July 2008, AQT-23 at p. 131. (available at:

<http://www.energy.ca.gov/sitingcases/victorville2/documents/index.html>). See also VOLUME 2: Preliminary Staff Assessment for the Palmdale Hybrid Power Plant Project (Docket # 08-AFC-9), February 2010, AQT-23 at p. 4.1-65 (available at:

<http://www.energy.ca.gov/sitingcases/palmdale/documents/index.html>)

⁵⁶ See Final Determination of Compliance Blythe Energy Project II, Mojave Desert Air Quality Management District, August 10, 2010, at p. 25.

5.3 Fire Pump Diesel Engine

The proposed Oakley Generating Station will require an emergency fire pump diesel engine to be used in case of emergency to provide water to fight fires. The fire pump diesel engine would be used solely to pressurize a fire suppression system. It would be operated only in case of emergency, as well as for short periods for inspection, maintenance, and testing, as required by the standards of the National Fire Protection Agency (NFPA) to ensure reliability in case of fire.

The following section provides the District's BACT analysis for the project's fire pump diesel engine. The fire pump diesel engine will have the potential to emit over 10 pounds per day of NO_x and CO since emergency use is not limited, and it is subject to BACT for these pollutants.

Control Technology Review:

The District has identified three primary types of control technologies that could potentially be used to reduce air pollutant emissions from the fire pump diesel engine: the use of clean diesel fuel; combustion technologies to limit pollutant formation during combustion; and post-combustion technologies that remove pollutants that are formed before they can enter the atmosphere.

Clean Fuel Technologies

The use of diesel fuel that meets the CARB ultra-low sulfur diesel fuel standard (< 0.0015% by weight sulfur) can reduce the amount of NO_x formed during combustion. Using ultra-low sulfur fuel reduces NO_x emissions because the hydro-treating technique used to remove the sulfur from the diesel fuel also removes nitrogen, leaving only trace amounts. Reducing the amount of nitrogen in the fuel reduces the amount of nitrogen available to form NO_x during combustion. Ultra-low sulfur diesel fuel is available and demonstrated for stationary compression ignition engines. It is technically feasible for the fire pump engine.⁵⁷

Combustion Technologies

There are also a number of design features that can be used for diesel engines that can reduce the amount of air pollutants generated during combustion of the fuel, including NO_x and Carbon Monoxide. These features include turbocharging, which uses an exhaust gas-driven air compressor to increase the mass of air entering the engine to create more power and thereby increase efficiency; intercooling, or charge air cooling, which uses an air-to-air or air-to-liquid heat exchange device to increase the intake air charge density through cooling, another method to increase efficiency; retarded injection timing, which slightly delays the injection of fuel into the engine to reduce the peak flame temperature, thereby improving NO_x emissions (but typically resulting in higher PM emissions); exhaust gas recirculation, which allows a controlled portion of spent combustion gases to circulate back into the intake system where they mix with pre-

⁵⁷ Under Title 17, California Code of Regulations, section 93115 "Airborne Toxic Control Measure for Stationary Compression Ignition (CI) Engines," the emergency fire pump engine will use only California ultra-low sulfur diesel fuel when operating.

combustion air, similarly reducing peak combustion temperature; and the use of a pre-combustion chamber, which involves a prechamber in the engine that improves air/fuel mixing and lowers combustion temperature.

The design of a diesel engine – including the choice of combustion technologies to reduce the formation of air pollutants during combustion – is determined by the manufacturer of the engine, not by the end-user. Emissions from such engines are regulated by EPA under a system of “Tiers”, or progressively more stringent emissions standards that engine manufacturers must meet. Engine manufacturers design their equipment using appropriate control technology to meet these EPA-designated Tiers. Diesel engine users, such as the Oakley Generating Station here, are limited to the engines that are commercially available from manufacturers. The determination of what combustion control technologies are technically feasible must therefore focus on what types of engines are commercially available to be purchased for this project, and what “Tier” standards such equipment can meet. The technologies that are commercially available are those that manufacturers are using to achieve the EPA “Tier 3” requirements for engines of the class needed for emergency fire service at the Oakley Generating Station.

Post-Combustion Controls

Finally, there are several post-combustion technologies that could potentially be used to remove emissions from the fire pump diesel engine’s exhaust before they are emitted to the atmosphere. One such system discussed above in connection with the gas turbines and auxiliary boiler is selective catalytic reduction (SCR), which uses a reagent, typically ammonia or urea, to convert NO_x to nitrogen and oxygen over a catalyst. Another after-treatment based NO_x control technology is referred to as the lean-NO_x catalyst. Similar in principle to an SCR system, a Lean-NO_x Catalyst system relies on injection of a reagent upstream of the catalyst to reduce NO_x emissions. Finally, NO_x adsorbers, also called NO_x traps, are one of the newest emission control strategies under development. They employ catalysts that adsorb NO_x in the exhaust stream when the engine runs lean. After the adsorber has been fully saturated with NO_x, the system is regenerated with released NO_x being catalytically reduced when the engine runs rich.

Post-combustion controls are not feasible for direct-drive fire pump engines of the type needed to serve the emergency fire suppression needs of the Oakley Generating Station, however. Addition of a catalytic device to the exhaust system would be technically infeasible, due to the variable load of the engine and the nature of the control system. Injection of a reagent into the engine exhaust to control pollutants (mainly NO_x) is dependent on a constant steady state engine load. But the fire pump engine will need to operate effectively under highly variable loads, thus ruling out this type of control technology. Installation of other after-treatment devices will also compromise reliability, performance, and safe operation of the fire pump.⁵⁸

In addition, the use of post-combustion control technologies would be incompatible with the fire pump’s role as a safety device for use in emergencies. Direct-drive fire pump engines of the type proposed for the Oakley Generating Station are designed differently than other stationary or offroad diesel-fueled engines. Direct-drive fire pump engines must meet the stringent National Fire Protection Association (NFPA) standards that establish minimum requirements for reserve

⁵⁸ Clarke, letter dated December 11, 2006 to K. Kjellman Edison Mission Energy.

horsepower capacity, engine cranking systems, engine cooling systems, fuel types used, instrumentation and control, and exhaust systems, among others. The direct-drive fire pump engine, and anything connected to the engine that may affect its performance abilities, must be tested and certified by an independent agency (e.g. Underwriters' Laboratories) to be conforming to the requirements of NFPA Standards 20 (Installation of Stationary Pumps for Fire Protection) and/or 25 (Inspection, Testing and Maintenance of Water-Based Fire Protection Systems).⁵⁹ Adding exhaust system controls to these engines would void the existing certifications.⁶⁰

Proposed BACT Control Technology Emergency Fire Pump Diesel Engines

The District has determined the use of ultra-low sulfur diesel and Tier 3 engine technology are the only feasible control technologies and therefore meet BACT. Tier 3 engines incorporate control technologies that meet the emission standards for fire pump diesel engines required by EPA in 40 CFR Part 60, Subpart IIII, Standards of Performance for Stationary Compression Ignition Internal Combustion Engines.⁶¹ EPA does not require future stationary fire pump engines to meet Tier 4 emission standards, which would likely involve the use of after-treatment devices. The proposed Tier 3 engine also meets the emission standards set forth in the California Air Resources Board (CARB) Airborne Toxic Control Measure for Stationary Compression Ignition Engines (sections 93115 through 93115.15, title 17, California Code of Regulations).

⁵⁹ In addition, even if add-on post-combustion technologies were technologically feasible for an emergency fire pump engine, they would not be cost-effective for an engine that is operated only a small number of hours per year. With a small number of operating hours, the cost per hour of operation of adding a post-combustion control system would be prohibitive.

⁶⁰ March 30, 2005, letter from the California Air Resources Board (CARB) to Clarke Fire Protection Products (recognizing the limited number of options that direct-drive fire pump manufacturers have in replacing or modifying engines); Clarke December 11, 2006, letter to K. Kjellman Edison Mission Energy.

⁶¹ 40 CFR Part 60, Subpart IIII, Table 4 - Emission Standards for Stationary Fire Pump Engines

6. Requirement to Offset Emissions Increases

District regulations require that new facilities must provide Emission Reduction Credits (ERCs) to offset the increases in air emissions that they will cause. ERCs are generated when old facilities sources are shut down, or when sources are controlled below regulatory limits. The emissions reductions granted by the District are used to offset the increases from new facilities, so that there will be no overall increase in emissions from facilities subject to this offset program.

Pursuant to Regulation 2-2-302, federally enforceable emission offsets are required for POC and NO_x emission increases from permitted sources at facilities that will emit 10 tons per year or more of those pollutants. For facilities that will emit more than 35 tons per year of NO_x offsets must be provided by the applicant at a ratio of 1.15 to 1.0. Pursuant to Regulation 2-2-302.2, POC offsets may be used to offset emission increases of NO_x. For PM₁₀ and SO₂, offsets are required for facilities that will emit 100 tons per year or more of those pollutants under District Regulation 2-2-303.

Pursuant to District Regulation 2-2-302, the applicant will be required to surrender sufficient ERCs to offset the levels of POC and NO_x emissions specified below prior to issuance of the Authority to Construct, although many applicants identify the ERCs they hold during the permitting process in order to demonstrate that they will be able to satisfy the emission offset requirements.

The District's analysis of the applicable offset requirements for the four pollutants for which offsets requirements have been established is outlined below.

6.1 POC Offsets

Because the proposed Oakley Generating Station will emit less than 35 tons of POC per year from permitted sources, the POC emissions must be offset at a ratio of 1.0 to 1.0 pursuant to District Regulation 2-2-302. The facility will be required to provide offsets for 29.49 tons per year of POC emissions.

6.2 NO_x Offsets

Because the proposed Oakley Generating Station will emit greater than 35 tons per year of NO_x from permitted sources, the NO_x emissions must be offset at a ratio of 1.15 to 1.0 pursuant to District Regulation 2-2-302. The facility will emit up to 98.78 tons/yr of NO_x, and will therefore be required to provide offsets for 113.60 tons per year of NO_x emissions.

6.3 PM₁₀ Offsets

Because the total PM₁₀ emissions from permitted sources will not exceed 100 tons per year, the proposed Oakley Generating Station is not required to offset its PM₁₀ emissions under District Regulation 2-2-303.

6.4 SO₂ Offsets

Pursuant to Regulation 2-2-303, emission reduction credits are not required for the SO₂ emission increases associated with this project since the facility's SO₂ emissions will not exceed 100 tons per year.

7. Federal Permit Requirements

In addition to the Bay Area Air Quality Management District permit requirements in District Regulation 2, Rule 2 and Regulation 2, Rule 3, there are two federal permitting programs that apply to major facilities: (i) the federal “Prevention of Significant Deterioration” (PSD) requirements under 40 C.F.R. section 52.21; and (ii) the “Non-Attainment New Source Review” (Non-Attainment NSR) requirements for PM_{2.5} sources set forth in Appendix S of 40 C.F.R. Part 51. The District has analyzed these requirements for the proposed Oakley Generating Station and has determined that neither of these permit requirements applies to this facility because it will not be a major source under either of those programs. The District is therefore not proposing to issue a PSD permit for this facility or to include Appendix S PM_{2.5} Non-Attainment NSR requirements in the permit.

7.1 Federal “Prevention of Significant Deterioration” Program

The federal PSD program applies to “major” stationary sources. For 28 categories, including fossil fuel-fired steam electric plants of more than 250 MMBtu/hr heat input such as the proposed Oakley Generating Station, major stationary source means a new source that emits more than 100 tons per year of any PSD pollutant.⁶² PSD pollutants are regulated pollutants for which the Bay Area is not in violation of the National Ambient Air Quality Standard (NAAQS) for that pollutant. For the Bay Area, PSD pollutants include carbon monoxide, PM₁₀, PM_{2.5}, and SO₂, among others. Facilities that exceed the federal PSD “major source” threshold for any of these pollutants must apply for and obtain PSD permits before they can commence construction. Although PSD permits are federal permits issued under the authority of EPA Region 9, the District conducts the PSD analysis and issues PSD permits on behalf of EPA Region 9 pursuant to a Delegation Agreement between the District and EPA Region 9.⁶³

The Oakley Generating Station will not be subject to PSD permitting requirements because it is not a “major source” because annual emissions are less than 100 tons of all PSD pollutants. (See Annual Emissions, listed in Table 7 in Section 4.1.6 above.) Annual emissions will be subject to enforceable permit limits to ensure that they remain below the amounts listed in Table 7. As explained in Section 4.1.6, although these annual emissions rates are based on certain assumptions about how the facility will operate, they will subject to enforceable permit conditions that will ensure that emissions do not exceed the 100 ton PSD threshold. The facility will be required to monitor its emissions and ensure that they do not exceed the limits during any

⁶² Note that starting in 2011, EPA will regulate greenhouse gas emissions under the PSD program, with a “major source” applicability threshold of 100,000 tons per year and a PSD “significance” threshold 75,000 tons per year. See 40 C.F.R. § 52.21(b)(1)(i)(a) and § 52.21(b)(49)(iv)-(v). For new sources such as this one that are not otherwise subject to PSD permitting requirements, these requirements would not be effective until July 1, 2011.

⁶³ The District also has incorporated PSD requirements from the federal PSD regulations into its NSR Rule in Regulation 2, Rule 2. The substance of these requirements in Regulation 2, Rule 2 track the federal requirements.

12-month period. If it appears that the facility is nearing its annual limit, it will be required by law to reduce or curtail operations to ensure that emissions do not exceed the permitting annual rates. These permit limits will ensure that the facility does not operate in a manner that would require a PSD permit. EPA's PSD program specifically allows the use of enforceable emissions limitations in the permit as a basis for concluding that a facility's emissions will not trigger PSD requirements and that the facility is therefore not subject to PSD permitting.⁶⁴ The District is therefore not proposing to issue a federal PSD permit for this facility.

7.2 Non-Attainment NSR for PM_{2.5}

The Bay Area has recently been designated as “non-attainment” of the National Ambient Air Quality Standard for PM_{2.5} (24-hour average).⁶⁵ Areas classified as non-attainment are subject to the “Non-Attainment New Source Review” (Non-Attainment NSR) requirements of the federal Clean Air Act. The Clean Air Act requires states to develop Non-Attainment NSR regulations to implement this requirement within 3 years of a non-attainment designation, and the District will be doing so for PM_{2.5} in the months and years to come. In the interim, while the District is working on its own PM_{2.5} Non-Attainment NSR regulations, Non-Attainment NSR for PM_{2.5} is governed by the federal Non-Attainment NSR rule in EPA's Emissions Offset Interpretive Ruling, which is set forth in Appendix S of 40 C.F.R. Part 51 (“Appendix S”).

Non-Attainment NSR under Appendix S is a federal permit program and is implemented under the federal regulations set forth in Appendix S. It is not a state law permitting program and it is not implemented under the requirements of District regulations established pursuant to the California Health & Safety Code. The Environmental Protection Agency has determined that the District can impose conditions in its District permits (Authority to Construct and Permit to Operate) that will allow a facility to establish compliance with the federal Non-Attainment NSR requirements for PM_{2.5}.^{66,67} If the District includes requirements in its District permits pursuant to District Regulation 2-1-403 (Permit Conditions) that satisfy the applicable PM_{2.5} Non-

⁶⁴ See 40 C.F.R. § 52.21(b)(4); *see also National Mining Ass'n v. EPA*, 50 F.3d 1351, 1365 (D.C. Cir. 1995).

⁶⁵ EPA promulgated National Ambient Air Quality Standards (NAAQS) for PM_{2.5} in 1997 (with an update in 2006), and began designating certain regions of the country as non-attainment with those Standards starting in 2005. EPA made a determination as to the region's attainment status with respect to PM_{2.5}, which it published on November 13, 2009. EPA determined that the Bay Area is in attainment of the PM_{2.5} NAAQS for the annual standard, and is non-attainment for the 24-hour standard. The EPA's non-attainment determination for the PM_{2.5} 24-hour standard became effective on December 14, 2009 (See Federal Register Friday November 13, 2009, Air Quality Designations for the 2006 24-Hour Fine Particle (PM_{2.5}) National Ambient Air Quality Standards).

⁶⁶ Letter dated 10/28/09 from Jack Broadbent of BAAQMD to Deborah Jordan U.S. EPA Region IX, Re: Guidance on “Appendix S” Non-Attainment NSR Permitting for PM_{2.5} Source During PM_{2.5} Transition Period.

⁶⁷ Letter dated 12/9/09 from Deborah Jordan U.S. EPA Region IX to Jack Broadbent of BAAQMD, Re: Guidance on “Appendix S” Non-Attainment NSR Permitting for PM_{2.5} Source During PM_{2.5} Transition Period.

Attainment NSR requirements of Appendix S for a source, EPA has determined that it will treat those conditions as satisfying the federal Appendix S requirements for that source.

Under Appendix S, Non-Attainment NSR requirements for PM_{2.5} apply to facilities with PM_{2.5} emissions of more than 100 tons per year. (See 40 CFR 51, Appendix S, II.A.4(i)(a) establishing 100 tpy threshold for regulation of Major Stationary Sources.⁶⁸) The proposed Oakley Generating Station would emit only 63.78 tons per year of PM_{2.5}, so the Appendix S Non-Attainment NSR requirements do not apply for this facility. The District is therefore not proposing to include conditions in the permit for compliance with Appendix S for PM_{2.5}. Note, however, that the proposed permit includes permit limits on PM₁₀, which will be effective to control PM_{2.5} emissions as well.

⁶⁸ The facility will emit less than 100 tons per year of direct PM_{2.5} emissions and less than 100 tons per year of any PM_{2.5} precursors, as defined in Appendix S II.A.31(iii). (See Final Determination of Compliance, Table 7.)

8. Health Risk Screening Analyses

Pursuant to the District's Toxic Risk Management regulation (Regulation 2, Rule 5), a health risk screening must be conducted to determine the potential impact on public health resulting from the worst-case emissions of toxic air contaminants (TACs) from the proposed Oakley Generation Station. In accordance with the requirements of District Regulation 2, Rule 5 and California Office of Health Hazard Assessment (OEHHA) guidelines, the impact on public health due to the emission of these compounds was assessed utilizing EPA-approved air pollutant dispersion models.

Tables 16 and 17 present the Health Risk Assessment results for the Oakley Generating Station. Table 16 summarizes the maximum cancer and non-cancer health risks from the project as a whole, and Table 17 summarizes the maximum cancer risk from each source individually.

TABLE 16: HEALTH RISK ASSESSMENT RESULTS FOR THE PROJECT

Receptor	Cancer Risk	Chronic Non-Cancer Hazard Index	Acute Non-Cancer Hazard Index
Maximum Values	1.56 in a million	0.0832	0.2665

TABLE 17: HEALTH RISK ASSESSMENT RESULTS FROM EACH SOURCE

Source	Maximum Residential/Worker Cancer Risk from Source
North Gas Turbine	0.70 in a million
South Gas Turbine	0.65 in a million
Auxiliary Boiler	0.03 in a million
Evaporative Fluid Cooler	0.39 in a million
Fire Pump Diesel Engine	0.73 in a million

The District performed a health risk assessment in accordance with guidelines adopted by Cal/EPA's Office of Environmental Health Hazard Assessment (OEHHA), the California Air Resources Board (CARB), and the California Air Pollution Control Officers Association (CAPCOA). Based on this assessment, the proposed sources for Oakley Generating Station will comply with the project risk requirements in accordance with the District's Regulation 2, Rule 5. Regulation 2, Rule 5 requires that the maximum health risk from the project as a whole must be less than 10 in one million excess cancer risk and less than a hazard index of 1.0 chronic and acute non-cancer risk; and that the maximum health risk from each individual source at the project must be less than 1.0 in one million excess cancer risk and less than a hazard index of 0.2 chronic non-cancer risk. As shown in Table 16, the maximum increased carcinogenic risk attributed to this project is 1.56 in one million, and the chronic hazard index and the acute hazard index attributed to the emission of non-carcinogenic air contaminants are 0.0832 and 0.2665, respectively. As shown in Table 17, the risk from each source individually is below 1.0 in a million maximum individual cancer risk; and since the maximum chronic non-cancer hazard index for the project as a whole is less than 0.2, the chronic hazard index for each source is less than 0.20. Please see Appendix B (Memo dated August 12, 2010, prepared by Glen Long, Air Toxics Section) for further discussion.

9. Other Applicable Requirements

The following section summarizes the applicable District, state and federal rules and regulations and describes how the Oakley Generating Station will comply with those requirements.

9.1 Applicable District Rules and Regulations

Regulation 1, Section 301: Public Nuisance

None of the project's sources of air contaminants are expected to cause injury, detriment, nuisance, or annoyance to any considerable number of persons or the public with respect to any impacts resulting from the emission of air contaminants regulated by the District.

Regulation 2, Rule 1, Sections 301 and 302: Authority to Construct and Permit to Operate

Pursuant to Sections 2-1-301 and 2-1-302, the applicant has submitted an application to the District to obtain an Authority to Construct and Permit to Operate for all regulated sources at the proposed Oakley Generating Station. Those permits will be issued after the CEC completes its licensing process.

Regulation 2, Rule 2: New Source Review

The primary requirements of New Source Review that apply to the proposed Oakley Generating Station are Section 2-2-301; “Best Available Control Technology Requirement”, Section 2-2-302; “Offset Requirements, Precursor Organic Compounds and Nitrogen Oxides, NSR”, Section 2-2-303, “Offset Requirement, PM₁₀ and Sulfur Dioxide, NSR”.

Regulation 2, Rule 2, Section 301: BACT

The District has performed a BACT analysis for the gas turbines, auxiliary boiler, and fire pump diesel engine as shown in Section 5. The proposed Oakley Generating Station meets the BACT requirements under Section 2-2-301.

Regulation 2, Rule 2: Sections 302 and 303

The District has presented the offsets required for the project for NO_x and POC as shown in Section 6 of this document. The proposed Oakley Generating Station will meet the offset requirements under Sections 2-2-302 and 2-2-303.

Regulation 2, Rule 2: Sections 304, 305, 306 and 414

The Prevention of Significant Deterioration (PSD) requirements in District Regulation 2, Rule 2 (Sections 304, 305, 306, and 308) are intended to implement the federal PSD requirements in 40 C.F.R. Section 52.21 and track those federal requirements. The proposed Oakley Generating

Station will not be subject to PSD requirements. Those requirements are discussed in detail in Section 7 above.

Regulation 2, Rule 3: Power Plants

Pursuant to Section 2-3-304, the Preliminary Determination of Compliance was subject to the public notice, public comment, and public inspection requirements contained in Sections 2-2-406 and 2-2-407. The District published its Preliminary Determination of Compliance in October of 2010. The public comment period for the PDOC was noticed in the Contra Costa Times on November 6, 2010 and the comment period ended on December 7, 2010. Comment were received from two members of the public, the applicant, the manufacturer of the turbines, and the CEC.

At this time, the District is publishing its Final Determination of Compliance for the project. The District has considered the comments received on the PDOC in determining whether to issue a Final Determination of Compliance and on what basis. All comments received during the comment period were considered by the District and addressed as necessary in the Final Determination of Compliance. The Final Determination of Compliance will be relied upon by the CEC in their licensing amendment proceeding. If the CEC grants a license to the project, then the District will issue an Authority to Construct.

Regulation 2, Rule 5: New Source Review of Toxic Air Contaminants

A risk screening analysis was performed to estimate the health risk resulting from the toxic air contaminant (TAC) emissions from the proposed Oakley Generating Station. The proposed sources for Oakley Generating Station comply with the project risk requirements in accordance with the District's Regulation 2, Rule 5. The increased carcinogenic risk attributed to this project is less than 10.0 in one million, and the chronic hazard index and the acute hazard index attributed to the emission of non-carcinogenic air contaminants are less than 1.0. The risk from each source individually is below 1.0 in a million maximum individual cancer risk, and the chronic hazard index is less than 0.20.

Regulation 2, Rule 6: Major Facility Review

After construction, the facility will be subject to Regulation 2, Rule 6, which implements the Title V program of the Federal Clean Air Act and 40 CFR 70, State Operating Permit Programs.

Pursuant to Section 404.1, the owner/operator of the Oakley Generating Station shall submit an application to the District for a major facility review permit within 12 months after the facility becomes subject to Regulation 2, Rule 6. Pursuant to Section 2-6-217 (Phase II Acid Rain Facility), the Oakley Generating Station will become subject to Regulation 2, Rule 6, upon completion of construction as demonstrated by first firing of the gas turbines.

Regulation 2, Rule 7: Acid Rain

The Oakley Generating Station gas turbine units will be subject to the requirements of Title IV of the federal Clean Air Act. The requirements of the Acid Rain Program are outlined in 40 CFR Part 72. The specifications for the type and operation of continuous emission monitors (CEMs)

for pollutants that contribute to the formation of acid rain are given in 40 CFR Part 75. District Regulation 2, Rule 7 incorporates by reference the provisions of 40 CFR Part 72.

40 CFR Part 72, Subpart A - Acid Rain Program

Part 72, Subpart A, establishes general provisions and operating permit program requirements for sources and affected units under the Acid Rain program, pursuant to Title IV of the Clean Air Act. The gas turbines are affected units subject to the program in accordance with 40 CFR Part 72, Subpart A, Section 72.6(a)(3)(i).

40 CFR Part 72, Subpart C – Acid Rain Permit Applications

Subpart C, section 72.30(b)(2)(ii) requires that the applicant submit a complete Acid Rain Permit application 24 months before the gas turbines commence operation. Pursuant to 40 CFR Part 72.2, “commence operation” includes the start-up of the unit’s combustion chamber.

40 CFR Part 73 - Sulfur Dioxide Allowance System

Part 73 establishes the sulfur dioxide allowance system for tracking, holding, and transferring allowances. The applicant will be required to obtain sufficient SO₂ allowances for each operating year on March 1st (or February 29th in a leap year) of the following year.

40 CFR Part 75 – Continuous Emission Monitoring

Part 75 contains the continuous emission monitoring requirements for units subject to the Acid Rain program. The applicant will be required to meet the Part 75 requirements for monitoring, recordkeeping and reporting of SO₂, NO_x, and CO₂ emissions. The applicant will also need to meet Part 75 requirement for monitoring, recordkeeping, and reporting volumetric flowrate and opacity.

Regulation 6, Rule 1: Particulate Matter – General Requirements

Opacity Requirements

The gas turbines and auxiliary boiler are expected to comply with the visible emissions limitation in Section 6-1-301 (Ringelmann No. 1 Limitation) through the use of dry low-NO_x burner technology, good combustion practice, and natural gas. The evaporative fluid cooler is expected to comply with the visible emissions limitation in Section 6-1-301 (Ringelmann No. 1 Limitation) through the use of water with a maximum total dissolved solids content of 1,500 mg/l, which is not expected to result in visible emissions. The fire pump diesel engine is expected to comply with the visible emissions limitation in Section 6-1-303 (Ringelmann No. 2 Limitation) through the use of an EPA/CARB-certified Tier 3 engine and ultra-low sulfur diesel.

Visible Particles

The facility's sources are expected to comply with Section 6-1-305 (Visible Particles) with emissions of particles not causing annoyance to others or large enough to be visible as individual

particles at the emission point or of such size and nature as to be visible individually as incandescent particles.

Particulate Weight Limitation

The gas turbines and auxiliary boiler are subject to 6-1-310 (Particulate Weight Limitation) with particulate matter emissions of less than 0.15 grains per dry standard cubic foot of exhaust gas volume, in actual conditions and calculated in accordance with Section 6-1-310.3 since the HRSG and auxiliary boiler involve heat transfer operations. The grain loading resulting from the operation of each gas turbine is 0.0008 gr/dscf @ 15% O₂ and from the boiler is 0.0048 gr/dscf @ 3% O₂. The grain loading resulting from the operation of each gas turbine is 0.0021 gr/dscf @ 6% O₂ and from the boiler is 0.0040 gr/dscf @ 6% O₂.

The fire pump diesel engine is subject to Section 6-1-310 (Particulate Weight Limitation) with particulate matter emissions of less than 0.15 grains per dry standard cubic foot of exhaust gas volume. The grain loading resulting from the operation of the fire pump diesel engine is 0.029 gr/dscf @ 0% O₂. See Appendix A for calculations.

General Operations

The evaporative fluid cooler is subject to Regulation 6-1-311 (General Operations), which limits particulate matter emissions based on process weight. Based on 352,800 gallons of water per hour, the emission limit in Section 6-1-311 would be 40 lb PM/hour; emissions of PM based on a 0.003% drift rate and 1,500 total dissolved solids content would be 0.132 lb PM/hour, so the evaporative fluid cooler would comply with Section 6-1-311. See Appendix A for calculations.

Particulate matter emissions associated with the construction of the facility are exempt from District permit requirements, but are subject to Regulation 6, Rule 1. However, the California Energy Commission will impose requirements for construction activities such as the use of water and/or chemical dust suppressants to minimize PM₁₀ emissions and prevent visible particulate emissions.

Regulation 7: Odorous Substances

Section 7-302 prohibits the discharge of odorous substances, which remain odorous beyond the facility property line after dilution with four parts odor-free air. Section 7-303 limits ammonia emissions to 5000 ppm. Because the ammonia slip emissions from the combined-cycle units will be limited by permit condition to 5 ppmvd @ 15% O₂, the facility is expected to comply with the requirements of Regulation 7.

Regulation 8: Organic Compounds

The gas turbines and auxiliary boiler are exempt from Regulation 8, Rule 2, "Miscellaneous Operations" per Section 8-2-110 since natural gas will be fired exclusively at those sources. The fire pump diesel engine will comply with Section 8-2-301 since its emissions will contain a total carbon concentration of less than 300 ppmv, dry, and it will emit less than 15 lb VOC/day.

The evaporative fluid cooler is exempt from Regulation 8, Rule 2, “Miscellaneous Operations” per 8-2-114 since it is a closed loop cooling tower. The evaporated water, which is sprayed over the enclosed tubes containing the cooling fluid, does not contact the cooling fluid.

The use of solvents for cleaning and maintenance at the Oakley Generating Station is expected to be at a level that is exempt from permitting in accordance with Regulation 2, Rule 1, Section 118. The facility may utilize less than 20 gallons per year of solvent for wipe cleaning per Section 2-1-118.9 and remain exempt from permitting requirements. The facility may also utilize a cold cleaner for maintenance cleaning as long as the unit meets the exemption set forth in Section 2-1-118.4. The facility may also perform solvent cleaning and preparation using aerosol cans meeting the exemption set forth in Section 2-1-118.10. Any solvent usage exceeding the amounts in Section 2-1-118 would require a permit. In addition, any solvent usage in excess of a toxic air contaminant trigger level contained in Regulation 2, Rule 5 would require a permit.

The oil-water separator is exempt from Regulation 8, Rule 8, “Wastewater Collection and Separation Systems” per Section 8-8-113, since it is a stormwater sewer system for collection of stormwater that is segregated from a process wastewater collection system.

Regulation 9: Inorganic Gaseous Pollutants

Regulation 9, Rule 1, Sulfur Dioxide

This regulation establishes emission limits for sulfur dioxide from all sources and applies to the combustion sources at this facility. Section 9-1-301 (Limitations on Ground Level Concentrations) prohibits emissions, which would result in ground level SO₂ concentrations in excess of 0.5 ppm continuously for 3 consecutive minutes, 0.25 ppm averaged over 60 consecutive minutes, or 0.05 ppm averaged over 24 hours. Section 9-1-302 (General Emission Limitation) prohibits SO₂ emissions in excess of 300 ppmv (dry). With maximum projected SO₂ emissions of < 1 ppmv, the gas turbines and natural gas-fired auxiliary boiler are not expected to cause ground level SO₂ concentrations in excess of the limits specified in Section 301 and should easily comply with Section 302.

Section 9-1-304 (Fuel Burning (Liquid and Solid Fuels)) prohibits burning of liquid fuel having a sulfur content in excess of 0.5% by weight. The fire pump diesel engine will be required to burn CARB diesel as defined in title 13, CCR, sections 2281 and 2282, which has a maximum sulfur content of 0.0015%.

Regulation 9, Rule 3, Nitrogen Oxides from Heat Transfer Operations

The gas turbines shall comply with the Section 9-3-303 NO_x limit of 125 ppm by complying with a permit condition NO_x emission limit of 2.0 ppmvd @ 15% O₂. The auxiliary boiler shall comply with the Section 9-3-303 NO_x limit of 125 ppm by using a boiler with manufacturer guaranteed emission rate of 7 ppmvd @ 3% O₂. The proposed fire pump diesel engine is not subject to this regulation since it is not a heat transfer operation.

Regulation 9, Rule 7, Nitrogen Oxides and Carbon Monoxide from Industrial, Institutional, and Commercial Boilers, Steam Generators, and Process Heaters

The gas turbines are not subject to Regulation 9, Rule 7 requirements per Section 9-7-110.5 (waste heat recovery boilers that are used to recover sensible heat from the exhaust of gas turbines).

The natural gas-fired boiler is subject to Regulation 9, Rule 7 requirements. The boiler shall comply with the NO_x emission limit of 30 ppm contained in Section 9-7-301.1, the future NO_x emission limit of 9 ppm contained in Section 9-7-307.5, and the CO emission limit of 400 ppmvd @ 3% O₂ by using a boiler with manufacturer guaranteed emission rates of 7 ppmvd @ 3% O₂ for NO_x and 10 ppmvd @ 3% O₂ for CO or lower. The boiler is also subject to and expected to comply with 9-7-311 (Insulation Requirements), 312 (Stack Gas Temperature Limits), 313 (Tune-Up Requirements), 403 (Initial Demonstration of Compliance), and 503 (Records).

Regulation 9, Rule 9, Nitrogen Oxides from Stationary Gas Turbines

Because each of the gas turbines will be limited by permit condition to NO_x emissions of 2.0 ppmvd @ 15% O₂, respectively, they will comply with the Regulation 9-9-301.2 NO_x limitation of 5 ppmvd @ 15% O₂. The gas turbines exhaust emissions will be monitored by CEMs and will comply with 9-9-501, which requires each unit to have a CEM to monitor NO_x.

Regulation 10: Standards of Performance for New Stationary Sources

Regulation 10 incorporates Title 40 of the Code of Federal Regulations Part 60 into the Rules and Regulations of the Bay Area Air Quality Management District. The specific requirements applicable to the proposed Oakley Generating Station are discussed in Section 9.4, Federal Requirements, of this document.

9.2 State Requirements

California Health and Safety Code Sections 25531 to 25541

Title 19, Division 2, Chapter 4.5 California Accidental Release Prevention Program (CalARP)

The proposed facility will utilize aqueous ammonia in a 29.4% (by weight) solution for SCR ammonia injection, which will be transported to the facility and stored on-site in tanks. The transportation and storage of ammonia presents a risk of an ammonia release in the event of a major accident. These risks will be addressed in a number of ways under safety regulations and sound industry safety codes and standards. These safety measures include the Risk Management Plan requirements pursuant to the California Accidental Release Prevention Program.⁶⁹ The

⁶⁹ See *Contra Costa Generating Station Application for Certification*, Vol. 1, section 5.5.4.2.2 at p. 5.5-21. (available at:

<http://www.energy.ca.gov/sitingcases/oakley/documents/applicant/afc/index.php>)

Risk Management Plan must include an off-site consequences analysis and appropriate mitigation measures; a requirement to implement a Safety Management Plan (SMP) for delivery of ammonia and other liquid hazardous materials; a requirement to instruct vendors delivering hazardous chemicals, including aqueous ammonia, to travel certain routes; a requirement to install ammonia sensors to detect the occurrence of any potential migration of ammonia vapors offsite; a requirement to use an ammonia tank that meets specific standards to reduce the potential for a release event; and a requirement to conduct a “Vulnerability Assessment” to address the potential security risk associated with storage and use of aqueous ammonia onsite. The Energy Commission will also be evaluating these risks further through its CEQA-equivalent environmental review process and will impose mitigating conditions as necessary to ensure that the risks are less than significant.

California Health and Safety Code Section 44300 et seq

The proposed Oakley Generating Station will be subject to the Air Toxic “Hot Spots” Program contained in the California Health and Safety Code Section 44300 et seq. The facility will be required to prepare inventory plans and reports as required.

Title 17, California Code of Regulations Section 93115

Section 93115 Airborne Toxic Control Measure for Stationary Compression Ignition (CI) Engines applies to the fire pump diesel engine. Section 93115.5 requires the use of CARB diesel fuel, which the engine will use. Section 93115.6(a)(4) requires the engine to meet Tier 3 Off-Road Compression Ignition Engine Standards and allows the engine to be tested as required by the National Fire Protection Maintenance Association (NFPA) 25 standards. The proposed engine is certified to Tier 3 Off-Road Compression Ignition Engine Standards and will be limited to 49 hours per year for maintenance and testing. Section 93115.10 Recordkeeping, Reporting, and Monitoring requirements requires reporting and emissions submittal to the District, installation of a non-resettable hour meter, and recordkeeping requirements regarding hours of operation and fuel usage. The on-going applicable requirements will be included in the permit conditions.

Title 17, California Code of Regulations Sections 95100 to 95133, Article 2, Subchapter 10

The proposed Oakley Generating Station will be subject to the Mandatory Greenhouse Gas Emissions Reporting regulation. Potential GHG emissions were calculated in accordance with this regulation in Section 9.4 of this document. The proposed Oakley Generating Station would have to submit a greenhouse gas emissions data report and verification opinion to the California Air Resources Board each year.

9.3 Federal Requirements

40 CFR Part 60 Subpart Dc

Subpart Dc “Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units” applies to this facility. The boiler will comply with all applicable standards

and limits in this regulation. Since the boiler will exclusively use natural gas, there are no applicable NO_x, SO₂, or opacity standards in this regulation.

Section 60.48c(a) requires notification of date of construction and actual startup along with design heat capacity and anticipated annual capacity factor. Section 60.48c(g)(2) requires the facility to record and maintain records of the amount of fuel combusted during each calendar month, which will also be included as a permit condition. Section 60.48c(g)(2) requires submittal of reports every six months.

40 CFR Part 60 Subpart IIII

Subpart IIII “Standards of Performance for Stationary Compression Ignition Internal Combustion Engines” applies to this facility. The fire pump diesel engine will comply with all applicable standards and limits by meeting the emission standards in section 60.4205(c), operating and maintaining the engine according to manufacturer’s instructions per section 60.4206, using ultra low sulfur diesel fuel per section 60.4207, installing a non-resettable hour meter, and limiting maintenance and testing hours to 49 hours per year, which complies with the 100 hours per year limit in section 60.4211(e). The engine is exempt from notification requirements per 60.4214(b).

40 CFR Part 60 Subpart KKKK

Generally Regulation 10 incorporates by reference the provisions of Title 40 CFR Part 60. However, the District has not sought delegation of the New Source Performance Standard (NSPS) contained in Subpart KKKK. Subpart KKKK “Standards of Performance for Stationary Gas Turbines” applies to this facility. The gas turbines will comply with all applicable standards and limits required by these regulations. The applicable emission limitations are summarized below:

TABLE 18: NEW SOURCE PERFORMANCE STANDARDS FOR COMBINED-CYCLE GAS TURBINES

Source	Requirement	Emission Limitation	Compliance Demonstration
Gas Turbines	Subpart KKKK §60.4320 (NO _x) §60.4330(SO ₂)	0.43 lb NO _x /MW-hr, or 15 ppm NO _x as NO ₂ @ 15%O ₂ ; 0.9 lb SO ₂ /MW-hr, or 0.06 lb SO ₂ /MMBtu maximum No CO limit in Subpart KKKK No PM limit in Subpart KKKK	2.0 ppm NO _x as NO ₂ @ 15%O ₂ Permit Limit; 0.00281 lb SO ₂ /MMBtu Permit Limit

Section 60.4340(b)(1) requires continuous emissions monitors for NO_x, and NO_x initial and annual performance tests are to be satisfied by complying with Section 60.4405 RATA testing.

Section 60.4365(a) exempts the facility from SO₂ monitoring by requiring a contract for natural gas with 20 grains of sulfur or less per 100 standard cubic feet. The facility will use PUC-regulated natural gas and be conditioned to use natural gas with 1 grain of sulfur or less per 100 standard cubic feet.

Section 60.4375 requires submittal of reports of excess emissions and monitoring of downtime for all periods of unit operation, including startup, shutdown, and malfunction. The applicant is expected to maintain adequate records for Subpart KKKK reporting requirements. The gas turbines will be equipped with continuous emissions monitors for NO_x and CO and annual emission test will not be required for Subpart KKKK.

40 CFR 63 Subpart Q

Subpart Q “National Emission Standards for Hazardous Air Pollutants for Industrial Process Cooling Towers” does not apply to this facility per section 63.400(a) since this regulation applies specifically to Industrial Process Cooling Towers that use chromium-based water treatment chemicals and are located at major sources of HAP emissions. Oakley Generating Station will not use chromium-based water treatment chemicals and is not a major source of HAP emissions, so Subpart Q does not apply.

40 CFR Part 63 Subpart YYYY

Subpart YYYY contains the National Emission Standards for Hazardous Air Pollutants (NESHAPs) for Stationary Combustion Turbines. This regulation has been stayed (Federal Register; April 7, 2004, Volume 69, Number 67) for a combustion turbine that is a lean premix gas fired unit or a diffusion flame gas fired unit.

The emissions standards contained in Subpart YYYY have been stayed for natural gas-fired combustion turbines per Section 63.6095. If a gas fired combustion turbine were subject to Subpart YYYY, then it would still need to comply with the Initial Notification requirements in Section 63.6145.

Subpart YYYY does not apply to the Oakley Generating Station gas turbines since the facility is not a major source of Hazardous Air Pollutants (HAPs). The Oakley Generating Station emits less than the major HAP thresholds of 10 tons/year of any single HAP, or 25 tons/year of aggregate HAP. Please note that ammonia, propylene, and sulfuric acid are not HAPs pursuant to section 112(b) of the Clean Air Act.

40 CFR Part 63 Subpart ZZZZ

Subpart ZZZZ “National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines” applies to this facility. Per Section 63.6590(c), the fire pump diesel engine will meet the requirements of this subpart by meeting the requirements of 40 CFR Part 60 Subpart IIII.

40 CFR Part 63 Subpart JJJJJ

Subpart JJJJJ “National Emission Standards for Area Sources: Industrial/Commercial/Institutional Boilers” is proposed and the public comment period has been extended to August 3, 2010. If the regulation is adopted, the proposed auxiliary boiler at the Oakley Generating Station would not be subject to this subpart per section 63.11195(e) since it would be a gas-fired boiler.

40 CFR Part 64 – Compliance Assurance Monitoring (CAM)

Requirements for enhanced monitoring may apply to facilities that are required to obtain Part 70 (Title V or Major Facility Review) permits. If so, they would apply at the time of issuance of the Major Facility Review permit. Although, these requirements would not apply at the completion of construction, it is prudent to determine at this time if they will apply so that it can be determined whether the monitoring strategy would comply with CAM.

In general, the requirement applies if an emission unit, as defined in Section 64.1, is subject to a federally-enforceable emission limit for a pollutant, has emissions of the pollutant that are greater than the major source thresholds (100 tpy of any regulated air pollutant or 10 tpy of a HAP) and the emissions of that pollutant are abated by a control device. There are several exemptions.

In this case, NO_x and CO from the gas turbines are controlled by SCR and a CO catalyst and CO from the auxiliary boiler may be controlled by a CO catalyst.

Monitoring for the NO_x limits for the gas turbines is exempt in accordance with 40 CFR 64.2(b)(iii) because the monitoring is subject to the Acid Rain monitoring requirements in 40 CFR 75.

Monitoring for the CO limits for the gas turbines is required since the pre-abatement potential to emit of CO for each turbine is greater than 100 tons per year. Each gas turbine will have a continuous emission monitor for CO.

Monitoring for the CO limits for the auxiliary boiler is not required since the pre-abatement potential to emit of CO is less than 100 tons per year.

The estimated potential to emit from each gas turbine is calculated using the following parameters:

Fuel input: 2150 MMBtu/hr

CO Concentration: 9.0 ppmv (Normal Operation)

lb-mol CO = 28 lb CO

8743 scf flue gas/MMbtu @ 0% O₂

386.8 dscf/lbmol

At 9.0 ppm

$(9.0 \text{ ppmv})(20.95 - 0)/(20.95 - 15) = 31.69 \text{ ppmv, dry @ 0\% O}_2$

$(31.69/106)(\text{lbmol}/386.8 \text{ dscf})(28 \text{ lb CO/lbmol})(8743 \text{ dscf/MM Btu}) = 0.0201 \text{ lb CO/MMBtu}$

$(2150 \text{ MMBtu/hr})(0.0201 \text{ lb CO/MMBtu}) = 43.12 \text{ lb CO/hr}$

At 5390 hours/year of normal operation + 25 cold starts + 275 hot starts + 300 shutdowns

$$\begin{aligned}
&= (5390 \text{ hours})(43.12 \text{ lb CO/hr}) + (25 \text{ cold start})(360 \text{ lb/cold start}) + (275 \text{ hot start})(85 \text{ lb/hot start}) + (300 \text{ shutdowns})(140 \text{ lb/shutdown}) \\
&= 153 \text{ TPY CO/turbine}
\end{aligned}$$

The auxiliary boiler may be required to be abated by an oxidation catalyst if the CO limit cannot be met without abatement. If the oxidation catalyst is needed, pre-abatement CO potential to emit is estimated below.

Fuel input: 50.6 MMBtu/hr
CO Concentration: 50.0 ppmv
lb-mol CO = 28 lb CO
8743 scf flue gas/MMbtu @ 0% O₂
386.8 dscf/lbmol

At 50.0 ppm
 $(50.0 \text{ ppmv})(20.95 - 0)/(20.95 - 15) = 176.1 \text{ ppmv, dry @ 0\% O}_2$

$$(176.1/106)(\text{lbmol}/386.8 \text{ dscf})(28 \text{ lb CO/lbmol})(8743 \text{ dscf/MM Btu}) = 0.1114 \text{ lb CO/MMBtu}$$

$$(50.6 \text{ MMBtu/hr})(0.1114 \text{ lb CO/MMBtu}) = 5.64 \text{ lb CO/hr}$$

At 4324 hours/year
 $= (4324 \text{ hour/year})(5.64 \text{ lb CO/hr})$
 $= 12.2 \text{ TPY}$

Since pre-abatement potential to emit for CO is less than 100 tons per year, the auxiliary boiler is not subject to CAM.

40 CFR Part 70, State Operating Permit Programs

These requirements are discussed in Section 8.2 under Regulation 2, Rule 6, Major Facility Review, which implements Part 70.

40 CFR Part 72, Subpart A – Acid Rain Program

Part 72, Subpart A, establishes general provisions and operating permit program requirements for sources and affected units under the Acid Rain program, pursuant to Title IV of the Clean Air Act. The gas turbines are affected units subject to the program in accordance with 40 CFR Part 72, Subpart A, Section 72.6(a)(3)(i).

40 CFR Part 72, Subpart C – Acid Rain Permit Applications

Subpart C, section 72.30(b)(2)(ii) requires that the applicant submit a complete Acid Rain Permit application 24 months before the gas turbines commence operation. Pursuant to 40 CFR Part 72.2, “commence operation” includes the start-up of the unit’s combustion chamber.

40 CFR Part 73 – Sulfur Dioxide Allowance System

Part 73 establishes the sulfur dioxide allowance system for tracking, holding, and transferring allowances. The applicant will be required to obtain sufficient SO₂ allowances for each operating year on March 1st (or February 29th in a leap year) of the following year.

40 CFR Part 75 – Continuous Emission Monitoring

Part 75 contains the continuous emission monitoring requirements for units subject to the Acid Rain program. The applicant will be required to meet the Part 75 requirements for monitoring, recordkeeping and reporting of SO₂, NO_x, and CO₂ emissions. The applicant will also need to meet Part 75 requirement for monitoring, recordkeeping, and reporting volumetric flowrate and opacity.

40 CFR Part 98

Part 98 Mandatory Greenhouse Gas Reporting, requires certain facilities, including electrical generation facilities such as Oakley Generating Station, to monitor, keep records of, and report GHG emissions every March 31 for the previous calendar year.

9.4 Greenhouse Gases

Climate change poses a significant risk to the Bay Area with such impacts such as rising sea levels, reduced runoff from snow pack in the Sierra Nevada, increased air pollution, impacts to agriculture, increased energy consumption, and adverse changes to sensitive ecosystems. The generation of electricity from burning natural gas produces air emissions known as greenhouse gases (GHGs) in addition to the criteria air pollutants. GHGs are known to contribute to the warming of the earth's atmosphere. These include primarily carbon dioxide, nitrous oxide (N₂O, not NO or NO₂, which are commonly known as NO_x or oxides of nitrogen), and methane (unburned natural gas). Also included are sulfur hexafluoride (SF₆) from transformers, and hydrofluorocarbons (HFCs) and perfluorocarbons (PFCs) from refrigeration chillers. The proposed Oakley Generating Station would use evaporative inlet air cooling, which uses water, and not HFCs or PFCs.

The California Global Warming Solutions Act of 2006 (AB32) requires the California Air Resources Board (ARB) to adopt a statewide GHG emissions limit equivalent to the statewide GHG emissions levels in 1990 to be achieved by 2020. To achieve this, ARB has a mandate to adopt rules and regulations to achieve the maximum technologically feasible and cost-effective GHG emission reductions.

The ARB is expected to adopt early action GHG reduction measures in the near future to reduce greenhouse gas emissions by 2020. ARB has adopted regulations requiring mandatory GHG emissions reporting. The facility is expected to report all GHG emissions to meet ARB requirements. ARB is also in the process of adopting a Regulation for Energy Efficiency and

Co-Benefits Assessment of Large Industrial Facilities⁷⁰ to require an energy efficiency assessment of California's large industrial facilities to determine the potential for greenhouse gas emission reductions and other pollution reduction co-benefits. However, combined-cycle electricity generating facilities built after 1995 are exempt per section 95152, so this regulation will not apply to the Oakley Generating Station.

The facility will also be required to report GHG emissions to CARB, the District, and US EPA. In 2008, the District placed a fee on GHG emissions from large stationary sources of GHGs.

The GHG emissions estimates for Oakley Generating Station are shown below.

⁷⁰ See Article 2.1 in Subchapter 10, sections 95150 to 95162, title 17, California Code of Regulations (available at: <http://www.arb.ca.gov/regact/2010/energyeff10/energyeff10.htm>)

TABLE 19: OAKLEY GENERATING STATION GHG EMISSIONS

	Fuel Usage	Emission Factor	Emission Factor	Emission Factor	GHG Emissions	Global Warming	CO2 equivalents
	(MMBtu/year)	(kg CO2/MMBtu)	(g CH4/MMBtu)	(g N2O/MMBtu)	(metric tons/year)	Potential	(metric tons/year)
Gas Turbines	35397277						
CO2		52.87			1.871E+06	1	1871454.035
CH4			0.9		3.186E+01	21	669.009
N2O				0.1	3.540E+00	310	1097.316
Auxiliary Boiler	218606						
CO2		52.87			1.156E+04	1	11557.699
CH4			0.9		1.967E-01	21	4.132
N2O				0.1	2.186E-02	310	6.777
Fire Pump Engine	136						
CO2		73.10			9.942E+00	1	9.942
CH4			3.0		4.080E-04	21	0.009
N2O				0.6	8.160E-05	310	0.025
Circuit Breakers	Total Capacity of SF6	leak rate		GHG Emissions	GHG Emissions	Global Warming	CO2 equivalents
	(lbs)	(%)		(kg/year)	(metric tons/year)	Potential	(metric tons/year)
SF6	200	0.50%		0.454	4.536E-04	23900	10.841
TOTAL GHG Emissions (CO2 equivalent, metric tons/year)							1,884,809.8

Oakley Generating Station has the potential to emit 1,884,809.8 metric tons of CO₂ equivalents per year using the ARB Mandatory Reporting Rule calculation methodology.

The Oakley Generating Station combined-cycle gas turbines will have a gross electrical efficiency of 56% at 59°F and a relative humidity of 60%.⁷¹ The Oakley Generating Station will have a net facility heat rate of 6,752 (HHV) Btu/KW-hr at 59°F and a relative humidity of 60%.⁷²

On September 29, 2006, Governor Arnold Schwarzenegger signed into law Senate Bill 1368 (Perata, Chapter 598, Statutes of 2006). The law limits long-term investments in baseload generation by the state's utilities to power plants that meet an emissions performance standard (EPS) jointly established by the California Energy Commission and the California Public Utilities Commission.

The Energy Commission has evaluated the Oakley Generating Station for compliance with these requirements in the Staff Assessment and determined that the facility will comply.⁷³

As published in the Federal Register on June 3, 2010, beginning January 2, 2011, only stationary sources that are major for a regulated new source review pollutant that is not a GHG and will emit or have the potential to emit 75,000 TPY CO₂ equivalent or more are subject to Prevention of Significant Deterioration for GHGs.⁷⁴ Beginning July 1, 2011, new stationary sources that will emit or have the potential to emit 100,000 TPY CO₂ equivalent or more are subject to Prevention of Significant Deterioration for GHG. Therefore, Oakley Generating Station is not required to address GHG emissions under the Clean Air Act at this time.

As the lead agency under the CEQA-equivalent process, the CEC will be required to quantify and assess GHG emissions from the Oakley Generating Station to evaluate the facility's compliance with applicable laws, ordinances, regulations and standards, and the potential impacts and benefits associated with adding Oakley Generating Station to the electricity system.

9.5 Environmental Justice

The District is committed to implementing its permit programs in a manner that is fair and equitable to all Bay Area residents regardless of age, culture, ethnicity, gender, race,

⁷¹ See Radback Energy *Supplemental Filing Air Quality and Public Health Revised April 7, 2010, Application for Certification for Oakley Generating Station Project*, at p. Appendix 5.1F-33.

⁷² See Radback Energy *Supplemental Filing Air Quality and Public Health Revised April 7, 2010, Application for Certification for Oakley Generating Station Project*, Table 5.1-1 at p. 5.1-3.

⁷³ See CEC *Oakley Generating Station Preliminary Staff Assessment – Part B*, CEC-700-2011-001 PSA-PTB, January 2011 at p. 4.1-43. (PSA Part B) (available at: <http://www.energy.ca.gov/2011publications/CEC-700-2011-001/CEC-700-2011-001-PSA-PTB.PDF>)

⁷⁴ See 40 CFR Part 52.21(b)(49)(iv)-(v).

socioeconomic status, or geographic location in order to protect against the health effects of air pollution. The District has worked to fulfill this commitment in the current permitting action, although there is no legal requirement that the District undertake an environmental justice analysis for this permitting action.⁷⁵ Nevertheless, regardless of any applicable legal requirements, the District considers environmental justice concerns to be sufficiently important to warrant a discussion in this document.

The emissions from the proposed project will not cause or contribute to any significant public health impacts in the community. As described in detail above, the District has undertaken a detailed review of the potential public health impacts of the emissions authorized under the proposed permitting action, and has found that they will involve no significant public health risks. The District has found that the maximum lifetime cancer risk associated with the facility is 1.56 in one million, and that the maximum chronic Hazard Index would be 0.0832 and the maximum acute Hazard Index would be 0.2665. These risk levels are below what the District considers to be significant. In particular, these risk levels are less than the thresholds of significance that the District's Board of Directors recently adopted as indicating whether health risk impacts would be significant in the context of a CEQA review.⁷⁶ The District anticipates that there will be no significant impacts due to air emissions related to the Oakley Generating Station after all of the mitigations required by District Rules and the California Energy Commission are implemented. The District does not anticipate a significant adverse impact on any community due to air emissions from the Oakley Generating Station; therefore, there will be no significant disparate adverse impact on any Environmental Justice community located near the facility.

10. Proposed Permit Conditions

The District is proposing the following permit conditions to ensure that the project complies with all applicable District, state, and federal regulations. The proposed conditions would limit operational parameters such as fuel use, stack gas emission concentrations, and mass emission rates. The permit conditions also specify abatement device operation and performance levels. To aid enforcement efforts, conditions specifying emission monitoring, source testing, and record keeping requirements are included. Furthermore, pollutant mass emission limits (in units of lb/hr) will ensure that daily and annual emission rate limitations are not exceeded.

⁷⁵ The environmental justice analysis requirements of the federal Executive Order 12898 do not apply here because the District is not issuing a federal permit, and state requirements for evaluating environmental justice impacts as part of the overall CEQA environmental review are handled through the CEC's CEQA-equivalent. (Note that Title VI civil rights requirements applicable to agencies that receive federal funds impose anti-discriminatory requirements on the agency's programs as a whole, and do not impose any specific requirements for an environmental justice analysis for individual permitting actions.)

⁷⁶ See BAAQMD Air Quality CEQA Threshold of Significance (June 2, 2010), available at: www.baaqmd.gov/~media/Files/Planning%20and%20Research/CEQA/Adopted%20Thresholds%20Table_6_2_10.ashx.

For the gas turbines and auxiliary boiler, compliance with CO and NO_x limitations would be verified by continuous emission monitors (CEMs) that will be in operation during all turbine operating modes, including start-up, shutdown, and combustor tuning. Compliance with POC, SO₂, and PM₁₀ mass emission limits would be verified by source testing.

In addition to permit conditions that apply to steady-state operation of each gas turbine power train, the District is proposing conditions that govern equipment operation during the initial commissioning period when the gas turbine power trains will operate without their SCR systems and/or oxidation catalysts fully functional. Commissioning activities include, but are not limited to, the testing of the gas turbines and adjustment of control systems. Parts 1 through 9 of the proposed permit conditions for the combined-cycle gas turbines apply to this commissioning period and are intended to minimize emissions during the commissioning period.

Proposed Oakley Generating Station Permit Conditions

Definitions:

Hour:	Any continuous 60-minute period
Clock Hour:	Any continuous 60-minute period beginning on the hour
Calendar Day:	Any continuous 24-hour period beginning at 12:00 midnight or 0000 hours
Year:	Any consecutive twelve-month period of time
Rolling 3-hour period:	Any consecutive three-clock hour period, not including start-up or shutdown periods
Heat Input:	All heat inputs refer to the heat input at the higher heating value (HHV) of the fuel, in BTU/scf
Firing Hours:	Period of time during which fuel is flowing to a unit, measured in hours
MMBtu:	million British thermal units
Gas Turbine Cold Start-up	A gas turbine startup that occurs more than 48 hours after a gas turbine shutdown, and is limited in time to the lesser of (i) the first 90 minutes of continuous fuel flow to the Gas Turbine after fuel flow is initiated or (ii) the period of time from Gas Turbine fuel flow initiation until the Gas Turbine achieves the first of two consecutive CEM data points in compliance with the emission concentration limits of Parts 15(b) and 15(d)
Gas Turbine Hot/Warm Start-up	A gas turbine startup that occurs within 48 hours of a gas turbine shutdown, and is limited in time to the lesser of (i) the first 30 minutes of continuous fuel flow to the Gas Turbine after fuel flow is initiated or (ii) the period of time from Gas Turbine fuel flow initiation until the Gas Turbine achieves the first of two consecutive CEM data points in compliance with the emission concentration limits of Parts 15(b) and 15(d)
Gas Turbine Shutdown:	The lesser of the 30-minute period immediately prior to the termination of fuel flow to the Gas Turbine or the period of time from non-compliance with any requirement listed in Parts 15(b) and 15(d) until termination of fuel flow to the Gas Turbine
Gas Turbine Combustor Tuning:	The period of time, not to exceed 8 operating hours per tuning event, in which testing, adjustment, tuning, and calibration operations are performed, as recommended by the gas turbine manufacturer, to ensure safe and reliable steady-state operation, and to minimize NO _x and CO emissions.

Specified PAHs:	The polycyclic aromatic hydrocarbons listed below shall be considered to be Specified PAHs for these permit conditions. Any emission limits for Specified PAHs refer to the sum of the emissions for all six of the following compounds: Benzo[a]anthracene Benzo[b]fluoranthene Benzo[k]fluoranthene Benzo[a]pyrene Dibenzo[a,h]anthracene Indeno[1,2,3-cd]pyrene
Corrected Concentration:	The concentration of any pollutant (generally NO_x, CO, or NH₃) corrected to a standard stack gas oxygen concentration. For emission points P-1, the exhaust of Gas Turbine (S-1), and P-2, the exhaust of Gas Turbine (S-2), the standard stack gas oxygen concentration is 15% O₂ by volume on a dry basis. For emission point P-3, the exhaust of Auxiliary Boiler (S-3), the standard stack gas oxygen concentration is 3% O₂ by volume on a dry basis.
Commissioning Activities:	All testing, adjustment, tuning, and calibration activities recommended by the equipment manufacturers and the OGS construction contractor to ensure safe and reliable steady-state operation of the gas turbines, heat recovery steam generators, steam turbine, and associated electrical delivery systems during the commissioning period
Commissioning Period:	The Commissioning Period shall commence when all mechanical, electrical, and control systems are installed and individual system start-up has been completed, or when a gas turbine is first fired, whichever occurs first. The Commissioning Period for each gas turbine shall terminate when the activities identified in the Commissioning Plan (submitted under Part 4 below) are complete and the gas turbine has reached safe and reliable steady-state operation as demonstrated by compliance with NO_x and CO normal operating limits using the continuous emissions monitors.
Precursor Organic Compounds (POCs):	Any compound of carbon, excluding methane, ethane, carbon monoxide, carbon dioxide, carbonic acid, metallic carbides or carbonates, and ammonium carbonate
CEC CPM:	California Energy Commission Compliance Program Manager
OGS:	Oakley Generating Station
Owner/operator:	The owner/operator of Oakley Generating Station
Total Particulate Matter:	The sum of all filterable and all condensable particulate matter.

GE 7FA Combined-Cycle Gas Turbines

Applicability:

Parts 1 through 9 of this condition shall only apply during the commissioning period as defined above. Unless otherwise indicated, Parts 10 through 30 of this condition shall apply after the commissioning period has ended.

Conditions for the Commissioning Period for GE 7FA Gas Turbines (S-1 and S-2)

1. The owner/operator shall minimize emissions of carbon monoxide and nitrogen oxides from S-1 and S-2 Gas Turbines to the maximum extent possible during the commissioning period. (Basis: BACT, Regulation 2, Rule 2, Section 409)
2. At the earliest feasible opportunity in accordance with the recommendations of the equipment manufacturers and the construction contractor, the owner/operator shall tune the S-1 and S-2 Gas Turbines combustors to minimize the emissions of carbon monoxide and nitrogen oxides. (Basis: BACT, Regulation 2, Rule 2, Section 409)
3. At the earliest feasible opportunity in accordance with the recommendations of the equipment manufacturers and the construction contractor, the owner/operator shall install, adjust, and operate the A-2 and A-4 Oxidation Catalysts and A-1 and A-3 SCR Systems to minimize the emissions of carbon monoxide and nitrogen oxides from S-1 and S-2 Gas Turbines. (Basis: BACT, Regulation 2, Rule 2, Section 409)
4. The owner/operator shall submit a plan to the District Engineering Division and the CEC CPM at least four weeks prior to first firing of S-1 and S-2 Gas Turbines describing the procedures to be followed during the commissioning of the gas turbines. The plan shall include a description of each commissioning activity, the anticipated duration of each activity in hours, and the purpose of the activity. The activities described shall include, but not be limited to, the tuning of the Dry-Low-NO_x combustors, the installation and operation of the required emission control systems, the installation, calibration, and testing of the CO and NO_x continuous emission monitors, and any activities requiring the firing of the Gas Turbines (S-1 and S-2) without abatement or with partial abatement by their respective oxidation catalysts and/or SCR Systems. The owner/operator shall not fire any of the Gas Turbines (S-1 or S-2) sooner than 28 days after the District receives the commissioning plan. (Basis: Regulation 2, Rule 2, Section 419)
5. During the commissioning period, the owner/operator shall demonstrate compliance with Parts 7, 8, and 9 through the use of properly operated and maintained continuous emission monitors and data recorders for the following parameters and emission concentrations:

- firing hours
- fuel flow rates
- stack gas nitrogen oxide emission concentrations
- stack gas carbon monoxide emission concentrations
- stack gas oxygen concentrations

The monitored parameters shall be recorded at least once every 15 minutes (excluding normal calibration periods or when the monitored source is not in operation) for the Gas

Turbines (S-1 and S-2). The owner/operator shall use District-approved methods to calculate heat input rates, nitrogen dioxide mass emission rates, carbon monoxide mass emission rates, and NO_x and CO emission concentrations, summarized for each clock hour and each calendar day. The owner/operator shall retain records on site for at least 5 years from the date of entry and make such records available to District personnel upon request. (Basis: Regulation 2, Rule 2, Section 419)

6. The owner/operator shall install, calibrate, and operate the District-approved continuous monitors specified in Part 5 prior to first firing of the Gas Turbines (S-1 and S-2). After first firing of the turbines, the owner/operator shall adjust the detection range of these continuous emission monitors as necessary to accurately measure the resulting range of CO and NO_x emission concentrations. The instruments shall operate at all times of operation of S-1 and S-2 including start-up, shutdown, upset, and malfunction, except as allowed by BAAQMD Regulation 1-522, BAAQMD Manual of Procedures, Volume V. If necessary to comply with this requirement, the owner/operator shall install dual-span monitors. The type, specifications, and location of these monitors shall be subject to District review and approval. (Basis: Regulation 2, Rule 2, Section 419)
7. The owner/operator shall not fire S-1 and S-2 Gas Turbine without abatement of nitrogen oxide emissions by the corresponding SCR System A-1 and A-3 and/or abatement of carbon monoxide emissions by the corresponding Oxidation Catalyst A-2 and A-4 for more than a combined total of 831 hours during the commissioning period. Such operation of any Gas Turbine (S-1, S-2) without abatement shall be limited to discrete commissioning activities that can only be properly executed without the SCR system and/or oxidation catalyst in place. Upon completion of these activities, the owner/operator shall provide written notice to the District Engineering Division and Compliance and Enforcement Division and the unused balance of the 831 firing hours without abatement shall expire. (Basis: BACT, Regulation 2, Rule 2, Section 409)
8. The total mass emissions of nitrogen oxides, carbon monoxide, precursor organic compounds, PM₁₀, and sulfur dioxide that are emitted by the Gas Turbines (S-1, and S-2) during the commissioning period shall accrue towards the consecutive twelve-month emission limitations specified in Part 43. (Basis: Regulation 2, Rule 2, Section 409)
9. The owner/ operator shall not operate the Gas Turbines (S-1 and S-2) in a manner such that the pollutant emissions from each gas turbine will exceed the following limits during the commissioning period. These emission limits shall include emissions resulting from the start-up and shutdown of the Gas Turbines (S-1, S-2). (Basis: BACT, Regulation 2, Rule 2, Section 409)

NO _x (as NO ₂)	2,380.8 pounds per calendar day	148.7 pounds per hour
CO	13,303 pounds per calendar day	700 pounds per hour

Conditions for the GE 7FA Combined-Cycle Gas Turbines (S-1 and S-2)

10. The owner/operator shall fire the Gas Turbines (S-1 and S-2) exclusively on PUC regulated natural gas with a maximum sulfur content of 1 grain per 100 standard cubic feet. To demonstrate compliance with this limit, the operator of S-1 and S-2 shall sample and analyze

the gas from each supply source at least monthly to determine the sulfur content of the gas. PG&E monthly sulfur data may be used provided that such data can be demonstrated to be representative of the gas delivered to the OGS. (Basis: BACT for SO₂ and PM₁₀)

11. The owner/operator shall not operate the units such that the heat input rate to each Gas Turbine (S-1 and S-2) exceeds 2,150 MMBtu (HHV) per hour. (Basis: BACT for NO_x)
12. The owner/operator shall not operate the units such that the heat input rate to each Gas Turbine (S-1 and S-2) exceeds 51,600 MMBtu (HHV) per day. (Basis: Cumulative Increase for PM₁₀)
13. The owner/operator shall not operate the units such that the combined cumulative heat input rate for the Gas Turbines (S-1 and S-2) exceeds 35,397,277 MMBtu (HHV) per year. (Basis: Offsets)
14. The owner/operator shall ensure that each Gas Turbine (S-1, S-2) is abated by the properly operated and properly maintained Selective Catalytic Reduction (SCR) System A-1 or A-3 and Oxidation Catalyst System A-2 or A-4 whenever fuel is combusted at those sources and the corresponding SCR catalyst bed (A-1 or A-3) has reached minimum operating temperature. (Basis: BACT for NO_x, POC and CO)
15. The owner/operator shall ensure that the Gas Turbines (S-1, S-2) comply with the following limits. The limits in this part do not apply during a gas turbine start-up, combustor tuning operation or shutdown. (Basis: BACT and Regulation 2, Rule 5)
 - a) Nitrogen oxide mass emissions (calculated as NO₂) at each exhaust point P-1 and P-2 (exhaust point for S-1 and S-2 Gas Turbine after abatement by A-1 and A-3 SCR System) shall not exceed 15.52 pounds per hour, averaged over any 1-hour period. (Basis: Cumulative Increase for NO_x)
 - b) The nitrogen oxide emission concentration at each exhaust point P-1 and P-2 shall not exceed 2.0 ppmv, on a dry basis, corrected to 15% O₂, averaged over any 1-hour period. (Basis: BACT for NO_x)
 - c) Carbon monoxide mass emissions at each exhaust point P-1 and P-2 shall not exceed 9.45 pounds per hour, averaged over any 1-hour period. (Basis: Cumulative Increase for CO)
 - d) The carbon monoxide emission concentration at each exhaust point P-1 and P-2 shall not exceed 2.0 ppmv, on a dry basis, corrected to 15% O₂ averaged over any 1-hour period. (Basis: BACT for CO)
 - e) Ammonia (NH₃) emission concentrations at each exhaust point P-1 and P-2 shall not exceed 5 ppmv, on a dry basis, corrected to 15% O₂, averaged over any rolling 3-hour period. This ammonia emission concentration shall be verified by the continuous recording of the ammonia injection rate to each SCR System A-1 and A-3. The correlation between the gas turbine heat input rates, A-1 and A-3 SCR System ammonia injection rates, and corresponding ammonia emission concentration at emission points P-1 and P-2 shall be determined in accordance with Part 24 or a District approved alternative method. The APCO may require the installation on one exhaust point (P-1 or P-2 at the owner/operator's discretion) of a CEM designed to monitor

ammonia concentrations if the APCO determines that a commercially available CEM has been proven to be accurate and reliable and that an adequate Quality Assurance/Quality Control protocol for the CEM has been established. The District or another agency must establish a District-approved Quality Assurance/Quality Control protocol prior to the ammonia CEM being a requirement of this part. The APCO shall use the first year of ammonia CEM data to establish the appropriate ammonia emission concentration limit and averaging time for compliance demonstration by CEM. After the APCO has established the ammonia limit, the ammonia CEM shall be used to demonstrate compliance for the gas turbine being monitored by CEM. The gas turbine with the ammonia CEM shall still be subject to the emission testing requirements in Part 24. For the gas turbine with the ammonia CEM, calculations of corrected ammonia concentrations based upon the source test correlation and continuous records of ammonia injection rate shall be submitted to the District for informational purposes only. (Basis: Regulation 2, Rule 5)

- f) Precursor organic compound (POC) mass emissions (as CH₄) at each exhaust point P-1 and P-2 shall not exceed 2.71 pounds per hour. (Basis: Cumulative Increase for POC)

16. The owner/operator shall ensure that the regulated air pollutant mass emission rates from each of the Gas Turbines (S-1, and S-2) during a start-up or shutdown does not exceed the limits established below. (Basis: BACT Limit for Non-Steady-State Operation)

Pollutant	Hot/Warm Startup (lb/startup)	Maximum Emissions During an Hour Containing a Hot/Warm Startup (lb/hr)	Maximum Emissions Per Cold Startup (lb/startup)	Maximum Emissions During an Hour Containing a Cold Startup (lb/hr)	Maximum Emissions Per Shutdown (lb/shutdown)	Maximum Emissions During an Hour Containing a Shutdown (lb/hr)
NO _x (as NO ₂)	22.3	33.9	96.3	99.9	39.3	46.8
CO	85.2	92.2	360.2	362.4	140.2	144.7
POC (as CH ₄)	31.1	33.1	67.1	67.7	17.1	18.4

17. The owner/operator shall not perform combustor tuning on each Gas Turbine (S-1 or S-2) more than twice in any consecutive 12 month period. Each tuning event shall not exceed 8 hours. Combustor tuning shall only be performed on one gas turbine per day. The owner/operator shall notify the District Engineering Division and Compliance and Enforcement Division no later than 7 days prior to combustor tuning activity, except in exigent circumstances. If exigent circumstances arise, the owner/operator shall notify the District Engineering Division and Compliance and Enforcement Division in writing 24 hours

prior to combustor tuning activity detailing the circumstances. The emissions during combustor tuning from each gas turbine shall not exceed the hourly limits established below, and shall not exceed hourly limits established by the District based on emissions data obtained during the first tuning event for each turbine. The owner/operator shall measure and record mass emissions of NO_x and CO using the continuous emission monitors during tuning.

The owner/operator shall measure POC emissions during the first tuning after the first turbine has been commissioned using a District-approved source test method. The owner/operator shall seek District approval of the test method in accordance with Part 29 below. The owner/operator shall submit the record of the NO_x, CO, and POC emissions during the first tuning event after the first turbine has been commissioned to the District within 60 days after the first tuning event. The District shall establish mass emissions limits for the future tuning events based on this test data and shall notify the owner/operator of these limits. (Basis: BACT, Offsets, Cumulative Increase)

Pollutant	Emissions Limit (lb/hr)
NO _x (as NO ₂)	96
CO	360
POC (as CH ₄)	67

18. The owner/operator shall not allow total emissions from each Gas Turbine (S-1 or S-2), including emissions generated during gas turbine start-ups, and shutdowns to exceed the following limits during any calendar day (except for days during which combustor tuning events occur, which are subject to Part 19 below):
 - a) 488 pounds of NO_x (as NO₂) per day (Basis: Cumulative Increase)
 - b) 715 pounds of CO per day (Basis: Cumulative Increase)
 - c) 146 pounds of POC (as CH₄) per day (Basis: Cumulative Increase)
19. The owner/operator shall not allow total emissions from each Gas Turbine (S-1 or S-2), including emissions generated during gas turbine start-ups, shutdowns, and combustor tuning events to exceed the following limits during any calendar day on which a tuning event occurs:
 - a) 971 pounds of NO_x (as NO₂) per day (Basis: Cumulative Increase)
 - b) 2818 pounds of CO per day (Basis: Cumulative Increase)
 - c) 531 pounds of POC (as CH₄) per day (Basis: Cumulative Increase)
20. The owner/operator shall not allow the maximum projected annual toxic air contaminant emissions (per Part 23) from the Gas Turbines (S-1, S-2) combined to exceed the following limits:

Formaldehyde	16,636.1 pounds per year
Benzene	462.9 pounds per year
Specified polycyclic aromatic hydrocarbons (PAHs)	4.54 pounds per year

unless the following requirement is satisfied:

The owner/operator shall perform a health risk assessment to determine the total facility risk using the emission rates determined by source testing and the most current Bay Area Air Quality Management District approved procedures and unit risk factors in effect at the time of the analysis. The owner/operator shall submit the risk analysis to the District and the CEC CPM within 60 days of the source test date. The owner/operator may request that the District and the CEC CPM revise the carcinogenic compound emission limits specified above. If the owner/operator demonstrates to the satisfaction of the APCO that these revised emission limits will not result in a significant cancer risk, the District and the CEC CPM may, at their discretion, adjust the carcinogenic compound emission limits listed above. (Basis: Regulation 2, Rule 5)

21. The owner/operator shall demonstrate compliance with Parts 11 through 13, 15(a) through 15(d), 16 (NO_x and CO limits), 17 (NO_x and CO limits), 18(a), 18(b), 19(a), 19(b), 43(a) and 43(b) by using properly operated and maintained continuous monitors (during all hours of operation including gas turbine start-up, combustor tuning, and shutdown periods). If necessary to comply with this requirement, the owner/operator shall install dual-span monitors. The owner/operator shall monitor for all of the following parameters and record each parameter at least every 15 minutes (excluding normal calibration periods):

- a) Firing Hours and Fuel Flow Rates for each of the following sources: S-1 and S-2
- b) Oxygen (O₂) concentration, Nitrogen Oxides (NO_x) concentration, and carbon monoxide (CO) concentration at exhaust points P-1 and P-2
- c) Ammonia injection rate at A-1 and A-2 SCR Systems

The owner/operator shall use the parameters measured above and District approved calculation methods to calculate and record the following parameters for each gas turbine (S-1 and S-2):

- d) Corrected NO_x concentration and corrected CO concentration, averaged for each clock hour
- e) Corrected NO_x concentration and corrected CO concentration, averaged for each calendar day

The owner/operator shall use the parameters measured above and District-approved calculation methods to calculate and record the following parameters for each gas turbine (S-1 and S-2) and totaled for S-1 and S-2:

- f) For each rolling three hour period, the heat input rate in MMBtu (HHV) per hour
- g) For each calendar day, the average hourly heat input rate in MMBtu (HHV) per hour and total daily heat input rate in MMBtu (HHV) per day
- h) For each consecutive twelve month period, the total heat input rate in MMBtu (HHV) per year

- i) For each clock hour, the NO_x mass emission rate (as NO₂) and CO mass emissions rate in pounds per hour
- j) For each calendar day, the NO_x mass emission rate (as NO₂) and CO mass emissions rate in pounds per day
- k) For each consecutive 12-month period, the monthly NO_x (as NO₂) and CO mass emissions rates in pounds per month and annual NO_x and CO mass emissions rates in pounds per year and tons per year

(Basis: 1-520.1, 9-9-501, BACT, Offsets, NSPS, Cumulative Increase)

22. To demonstrate compliance with Parts 15(f), 18(c), 19(c), and 43(c) the owner/operator shall calculate and record on a daily basis, the precursor organic compound (POC) mass emissions from each power train. The owner/operator shall use the actual heat input rates measured pursuant to Part 21, actual Gas Turbine start-up times, actual Gas Turbine shutdown times, and CEC and District-approved emission factors developed pursuant to source testing under Part 25 to calculate these emissions. The owner/operator shall present the calculated emissions in the following format:
- a) For each calendar day, POC mass emissions, summarized for each gas turbine and S-1 and S-2 combined
 - b) For each consecutive 12-month period, the cumulative total POC mass emissions for each gas turbine and S-1 and S-2 combined.

(Basis: Offsets, Cumulative Increase)

23. To demonstrate compliance with Part 20, the owner/operator shall calculate and record on an annual basis the maximum projected annual emissions of: Formaldehyde, Benzene, and Specified PAHs. The owner/operator shall calculate the maximum projected annual emissions using the combined maximum annual heat input rate of 35,397,277 MMBtu/year for S-1 and S-2 combined and the highest emission factor (pounds of pollutant per MMBtu of heat input) determined by the most recent of any source test of the S-1 or S-2 Gas Turbines. If the highest emission factor for a given pollutant occurs during minimum-load turbine operation, a reduced annual heat input rate may be utilized to calculate the maximum projected annual emissions to reflect the reduced heat input rates during gas turbine start-up and minimum-load operation. The reduced annual heat input rate shall be subject to District review and approval. (Basis: Regulation 2, Rule 5)
24. Within 90 days of the beginning of the start-up period (as defined in Regulation 2-1-210) of each of the OGS GE 7FA units or as otherwise approved by the APCO, the owner/operator shall conduct a District-approved source test on each corresponding exhaust point P-1 or P-2 to determine the corrected ammonia (NH₃) emission concentration to determine compliance with Part 15(e). The source test shall determine the correlation between the heat input rates of the gas turbine, A-1 or A-3 SCR System ammonia injection rate, and the corresponding NH₃ emission concentration at emission point P-1 or P-2. The source test shall be conducted over the expected operating range of the turbine (including, but not limited to, minimum and full load modes) to establish the range of ammonia injection rates necessary to achieve NO_x emission reductions while maintaining ammonia slip levels. The owner/operator shall repeat the source testing on an annual basis thereafter. Ongoing compliance with Part 15(e) shall be demonstrated through calculations of corrected ammonia concentrations based upon the

source test correlation and continuous records of ammonia injection rate. The owner/operator shall submit the source test results to the District and the CEC CPM within 60 days of conducting the tests. (Basis: Regulation 2, Rule 5)

25. Within 90 days of the beginning of the start-up period (as defined in Regulation 2-1-210) of each of the OGS GE 7FA units or as otherwise approved by the APCO and, at a minimum, on an annual basis thereafter, the owner/operator shall conduct a District-approved source test on exhaust points P-1 and P-2 while each Gas Turbine is operating at maximum load to determine compliance with Parts 15(a), 15(b), 15(c), 15(d), 15(f), and to establish the emissions factors to be used to demonstrate compliance with Parts 43(d) and 43(e); and while each Gas Turbine is operating at minimum load to determine compliance with Parts 15(c) and 15(d); and to verify the accuracy of the continuous emission monitors required in Part 21. The owner/operator shall test for (as a minimum each year): water content, stack gas flow rate, oxygen concentration, precursor organic compound concentration and mass emissions, nitrogen oxide concentration and mass emissions (as NO₂), carbon monoxide concentration and mass emissions, sulfur dioxide concentration and mass emissions, methane, ethane, and PM₁₀ emissions including condensable particulate matter. The owner/operator may conduct source tests of individual compounds listed in this part separately. The owner/operator shall submit the source test results to the District and the CEC CPM within 60 days of conducting the tests. The owner/operator may perform up to four tests per year for PM₁₀ emissions including condensable particulate matter. (Basis: BACT, Offsets, Cumulative Increase)
26. Within 90 days of the beginning of the start-up period (as defined in Regulation 2-1-210) of each OGS GE 7FA units or as otherwise approved by the APCO, the owner/operator shall conduct District- and CEC-approved source tests for that Gas Turbine to determine compliance with the emission limitations specified in Part 16. The source tests shall determine NO_x, CO, and POC emissions during start-up and shutdown of the gas turbines. The POC emissions shall be analyzed for methane and ethane to account for the presence of unburned natural gas. The source test shall include a minimum of three start-up and three shutdown periods. Thirty working days before the execution of the source tests, the owner/operator shall submit to the District and the CEC Compliance Program Manager (CPM) a detailed source test plan designed to satisfy the requirements of this Part. The District and the CEC CPM will notify the owner/operator of any necessary modifications to the plan within 20 working days of receipt of the plan; otherwise, the plan shall be deemed approved. The owner/operator shall incorporate the District and CEC CPM comments into the test plan. The owner/operator shall notify the District and the CEC CPM within seven (7) working days prior to the planned source testing date. The owner/operator shall submit the source test results to the District and the CEC CPM within 60 days of the source testing date. (Basis: Regulation 2, Rule 2, Section 419)
27. Within 90 days of the beginning of the start-up period (as defined in Regulation 2-1-210) of the second of the OGS GE 7FA gas turbines or as otherwise approved by the APCO, and on a biennial basis (once every two years) thereafter, the owner/operator shall conduct a District-approved source test on one of the following exhaust points P-1 or P-2 while the Gas Turbine is operating at maximum allowable operating rates to demonstrate compliance with Part 20. The owner/operator shall also test the gas turbine while it is operating at minimum load. If three consecutive biennial source tests demonstrate that the annual emission rates calculated pursuant to Part 23 for any of the compounds are less than 50% of the levels listed

in Part 20, then the owner/operator may discontinue future testing for that pollutant. (Basis: Regulation 2, Rule 5)

28. Within 90 days of the beginning of the start-up period (as defined in Regulation 2-1-210) of each of the OGS GE 7FA gas turbines or as otherwise approved by the APCO and on an annual basis thereafter, the owner/operator shall conduct a District-approved source test on one of the two exhaust points P-1 or P-2 while the gas turbine is operating at maximum heat input rate to demonstrate compliance with the total sulfuric acid mist emission rate for S-1 and S-2 of 6.3 tons per year. The owner/operator shall test for (as a minimum) SO₂, SO₃, and H₂SO₄, and the sulfur content of the fuel. The owner/operator shall submit the source test results to the District and the CEC CPM within 60 days of conducting the tests. (Basis: Regulation 2, Rule 5)
29. The owner/operator shall obtain approval for all source test procedures from the District's Source Test Section and the CEC CPM prior to conducting any tests. The owner/operator shall comply with all applicable testing requirements for continuous emission monitors as specified in Volume V of the District's Manual of Procedures. The owner/operator shall notify the District's Source Test Section and the CEC CPM in writing of the source test protocols and projected test dates at least 7 days prior to the testing date(s). As indicated above, the owner/operator shall measure the contribution of condensable PM (back half) to any measurement of the total particulate matter or PM₁₀ emissions. However, the owner/operator may propose alternative measuring techniques to measure condensable PM such as the use of a dilution tunnel or other appropriate method used to capture semi-volatile organic compounds. The owner/operator shall submit the source test results to the District and the CEC CPM within 60 days of conducting the tests. (Basis: BACT, Regulation 2, Rule 2, Section 419)
30. The owner/operator shall ensure that the stack height of emission points P-1 and P-2 is each at least 155.5 feet above grade level at the stack base. (Basis: Regulation 2, Rule 5)

Auxiliary Boiler (S-3)

31. The owner/operator shall submit manufacturer's specifications and emissions guarantees for NO_x and CO for the Auxiliary Boiler (S-3) to the District Engineering Division and the CEC CPM at least four weeks prior to first firing of Auxiliary Boiler (S-3). (Basis: Regulation 2, Rule 2, Section 419)
32. If Oxidation Catalyst (A-5) is required, the owner/operator shall install, adjust, and operate the A-5 Oxidation Catalyst at the earliest feasible opportunity, in accordance with the recommendations of the equipment manufacturers and the construction contractor, to minimize the emissions of carbon monoxide from S-3 Auxiliary Boiler. (Basis: Regulation 2, Rule 2, Section 419)
33. The heat input rate to the Auxiliary Boiler (S-3) shall not exceed 50.6 MMBtu per hour, averaged over any rolling 3-hour period. (Basis: Cumulative Increase)
34. The heat input rate to the Auxiliary Boiler (S-3) shall not exceed 218,606 MMBtu per year. (Basis: Cumulative Increase)
35. The owner/operator of the Auxiliary Boiler (S-3) shall meet all of the requirements listed in below.
 - a) Nitrogen oxide emissions at P-3 (the exhaust point for the Auxiliary Boiler) shall not exceed 9.8 pounds per day, calculated as NO_2 . (Basis: Regulation 2-1-403)
 - b) Carbon monoxide emissions at P-3 shall not exceed 9.8 pounds per day. (Basis: Regulation 2-1-403)
 - c) POC emissions (as CH_4) at P-3 shall not exceed 2.8 pounds per day. (Basis: Regulation 2-1-403)
36. The owner/operator shall demonstrate compliance with Parts 35(a), 35(b) and 43(a) and 43(b) by using properly operated and maintained continuous monitors (during all hours of operation including auxiliary boiler start-up, tuning, and shutdown periods). The owner/operator shall monitor for all of the following parameters and record each parameter at least every 15 minutes (excluding normal calibration periods):
 - a) Firing Hours and Fuel Flow Rates
 - b) Oxygen (O_2) concentration, Nitrogen Oxides (NO_x) concentration, and carbon monoxide (CO) concentration at exhaust point P-3The owner/operator shall use the parameters measured above and District approved calculation methods to calculate and record the following parameters for the Auxiliary Boiler (S-3):
 - c) Corrected NO_x concentration and corrected CO concentration, averaged for each clock hour
 - d) Corrected NO_x concentration and corrected CO concentration, averaged for each calendar day

The owner/operator shall use the parameters measured above and District-approved calculation methods to calculate and record the following parameters for Auxiliary Boiler (S-3):

- e) For each rolling three hour period, the heat input rate in MMBtu (HHV) per hour
- f) For each calendar day, the average hourly heat input rate in MMBtu (HHV) per hour and total daily heat input rate in MMBtu (HHV) per day
- g) For each consecutive twelve month period, the total heat input rate in MMBtu (HHV) per year
- h) For each clock hour, the NO_x mass emission rate (as NO₂) and CO mass emissions rate in pounds per hour
- i) For each calendar day, the NO_x mass emission rate (as NO₂) and CO mass emissions rate in pounds per day
- j) For each consecutive 12-month period, the monthly NO_x (as NO₂) and CO mass emissions rates in pounds per month and annual NO_x (as NO₂) and CO mass emissions rates in pounds per year and tons per year

(Basis: 1-520.1, 9-7-307, BACT, Offsets, Cumulative Increase)

37. To demonstrate compliance with Part 35(c) the owner/operator shall calculate and record on a daily basis, the precursor organic compound (POC) mass emissions from the auxiliary boiler. The owner/operator shall use the actual heat input rates measured pursuant to Part 36, and CEC and District-approved emission factors developed pursuant to source testing under Part 38 to calculate these emissions. The owner/operator shall present the calculated emissions in the following format:

- a) For each calendar day, POC mass emissions, summarized for S-3
- b) For each consecutive 12-month period, the cumulative total POC mass emissions for S-3.

(Basis: Offsets, Cumulative Increase)

38. Within 90 days of start-up of Auxiliary Boiler (S-3), the owner/operator shall conduct a District-approved source test on exhaust point P-3 while the auxiliary boiler is operating at maximum load to determine emission factors for POC, PM₁₀ and SO_x. The owner/operator shall test for (as a minimum): water content, stack gas flow rate, oxygen concentration, precursor organic compound concentration and mass emissions, nitrogen oxide concentration and mass emissions (as NO₂), carbon monoxide concentration and mass emissions, sulfur dioxide concentration and mass emissions, methane, ethane, and PM₁₀ emissions including condensable particulate matter. Thirty working days before the execution of the source tests, the owner/operator shall submit to the District and the CEC Compliance Program Manager (CPM) a detailed source test plan designed to satisfy the requirements of this Part. The District and the CEC CPM will notify the owner/operator of any necessary modifications to the plan within 20 working days of receipt of the plan; otherwise, the plan shall be deemed approved. The owner/operator shall incorporate the District and CEC CPM comments into the test plan. The owner/operator shall notify the District and the CEC CPM within seven (7) working days prior to the planned source testing date. The owner/operator shall submit the

source test results to the District and the CEC CPM within 60 days of the source testing date. (Basis: Regulation 2, Rule 2, Section 419)

Conditions for the Fire Pump Diesel Engine (S-4)

39. The owner/operator shall fire the Fire Pump Diesel Engine (S-4) exclusively on diesel fuel having a sulfur content no greater than 0.0015% by weight. (Regulation 2, Rule 5, Cumulative Increase, "Stationary Diesel Engine ATCM", CA Code of Regulations, Title 17, Section 93115.5(a))
40. The owner/operator shall operate the Fire Pump Diesel Engine (S-4) for no more than 49 hours per year for the purpose of reliability testing and non-emergency operation. (Regulation 2, Rule 5, Cumulative Increase, "Stationary Diesel Engine ATCM", CA Code of Regulations, Title 17, Section 93115.6(a)(4)(A))
41. The owner/operator shall operate the Fire Pump Diesel Engine (S-4) only when a non-resettable totalizing hour meter (with a minimum display capability of 9,999 hours) is installed, operated and properly maintained. (Basis: BAAQMD Regulation 9-8-530, "Stationary Diesel Engine ATCM", CA Code of Regulations, Title 17, Section 93115.10(e)(1))
42. The owner/operator shall maintain the following monthly records for Fire Pump Engine (S-4) in a District-approved log for at least 5 years.
 - a. Hours of operation for reliability-related activities (maintenance and testing).
 - b. Hours of operation for emission testing to show compliance with emission limits.
 - c. Hours of operation for emergency use.
 - d. For each emergency, the nature of the emergency condition.
 - e. Fuel usage.

Log entries shall be retained on-site, either at a central location or at the engine's location, and made immediately available to the District staff upon request. (Basis: BAAQMD Regulation 9-8-530, "Stationary Diesel Engine ATCM", CA Code of Regulations, Title 17, Section 93115.10(g))

Conditions for the Combined-Cycle Gas Turbines (S-1 and S-2), Auxiliary Boiler (S-3), and Fire Pump Engine (S-4)

43. The owner/operator shall not allow total combined emissions from the Gas Turbines (S-1 and S-2), including emissions generated during gas turbine start-ups, combustor tuning, shutdowns, and malfunctions, the auxiliary boiler (S-3), including emissions generated during auxiliary boiler start-ups, tune-ups, shutdowns, and malfunctions, and the fire pump diesel engine (S-4), including non-emergency and emergency operation, to exceed the following limits during any consecutive twelve-month period:
 - a) 98.78 tons of NO_x (as NO₂) (Basis: Offsets)
 - b) 98.82 tons of CO (Basis: Cumulative Increase)
 - c) 29.49 tons of POC (as CH₄) (Basis: Offsets)

- d) 63.78 tons of PM₁₀ (Basis: Cumulative Increase)
- e) 12.55 tons of SO₂ (Basis: Cumulative Increase)

Compliance with the limits in this part shall be determined using the following procedures:

Emissions of PM₁₀ and SO₂ from each gas turbine shall be calculated by multiplying turbine fuel usage times an emission factor determined by source testing of the turbine conducted in accordance with Part 25. The emission factor for each turbine shall be based on the average of the emissions rates observed during the 4 most recent source tests on that turbine (or, prior to the completion of 4 source tests on a turbine, on the average of the emission rates observed during all source tests on the turbine).

Emissions of PM₁₀, SO₂, and POC from the auxiliary boiler shall be calculated by multiplying auxiliary boiler fuel usage times an emission factor determined by source testing of the auxiliary boiler conducted in accordance with Part 38.

The owner/operator shall calculate emissions from the fire pump diesel engine from the hours of operation recorded in Part 42 and the following emission factors:

NO_x: 2.62 g/hp-hr

CO: 0.67 g/hp-hr

POC: 0.14 g/hp-hr

PM: 0.119 g/hp-hr

SO_x: 0.004 g/hp-hr

- 44. To demonstrate compliance with Part 43, the owner/operator shall record the total emissions for each consecutive 12-month period. The owner/operator shall calculate emissions of each pollutant listed in Part 43(a) through (e) from the gas turbines, auxiliary boiler, and fire pump diesel engine for each calendar month using the calculation procedures established in Part 43, and shall calculate annual emissions to determine compliance with the limits listed in Part 43(a) through (e) by summing the monthly totals for the previous 12 months. (Basis: Regulation 2, Rule 2, Section 419)
- 45. The owner/operator shall submit all reports (including, but not limited to monthly CEM reports, monitor breakdown reports, emission excess reports, equipment breakdown reports, etc.) as required by District Rules or Regulations and in accordance with all procedures and time limits specified in the Rule, Regulation, Manual of Procedures, or Compliance and Enforcement Division Policies & Procedures Manual. (Basis: Regulation 2, Rule 1, Section 403)
- 46. The owner/operator shall maintain all records and reports on site for a minimum of 5 years. These records shall include but are not limited to: continuous monitoring records (firing hours, fuel flows, emission rates, monitor excesses, breakdowns, etc.), source test and analytical records, natural gas sulfur content analysis results, emission calculation records, records of plant upsets and related incidents. The owner/operator shall make all records and reports available to District and the CEC CPM staff upon request. (Basis: Regulation 2, Rule 1, Section 403, Regulation 2, Rule 6, Section 501)

47. The owner/operator shall notify the District and the CEC CPM of any violations of these permit conditions. Notification shall be submitted in a timely manner, in accordance with all applicable District Rules, Regulations, and the Manual of Procedures. Notwithstanding the notification and reporting requirements given in any District Rule, Regulation, or the Manual of Procedures, the owner/operator shall submit written notification (facsimile is acceptable) to the Compliance and Enforcement Division within 96 hours of the violation of any permit condition. (Basis: Regulation 2, Rule 1, Section 403)
48. The owner/operator shall provide adequate stack sampling ports and platforms to enable the performance of source testing. The location and configuration of the stack sampling ports shall comply with the District Manual of Procedures, Volume IV, Source Test Policy and Procedures, and shall be subject to BAAQMD review and approval, except that the facility shall provide four sampling ports that are at least 6 inches in diameter in the same plane of each gas turbine stack (P-1, P-2). (Basis: Regulation 1, Section 501)
49. Within 180 days of the issuance of the Authority to Construct for the OGS, the owner/operator shall contact the BAAQMD Technical Services Division regarding requirements for the continuous emission monitors, sampling ports, platforms, and source tests required by Parts 24 through 28, and 38. The owner/operator shall conduct all source testing and monitoring in accordance with the District approved procedures. (Basis: Regulation 1, Section 501)
50. The owner/operator shall ensure that the OGS complies with the continuous emission monitoring requirements of 40 CFR Part 75. (Basis: Regulation 2, Rule 7)

11. Final Determination

The APCO has made a final determination that the proposed Oakley Generating Station power plant, which is composed of the permitted sources listed below, complies with all applicable District, state and federal air quality rules and regulations. The following sources will be subject to the permit conditions and BACT and offset requirements discussed previously.

- S-1 Gas Turbine Generator #1, GE Frame 7FA, Natural Gas-Fired, 213 MW, 2150 MMBtu/hr (HHV) maximum rated capacity with high-efficiency inlet air filter; abated by A-1 Selective Catalytic Reduction System (SCR) and A-2 Oxidation Catalyst
- S-2 Gas Turbine Generator #2, GE Frame 7FA, Natural Gas-Fired, 213 MW, 2150 MMBtu/hr (HHV) maximum rated capacity with high-efficiency inlet air filter; abated by A-3 Selective Catalytic Reduction System (SCR) and A-4 Oxidation Catalyst
- S-3 Auxiliary Boiler, Natural Gas-Fired, 50.6 MMBtu/hr (HHV) maximum rated capacity (abated by A-5 Oxidation Catalyst if required)
- S-4 Fire Pump Diesel Engine, Clarke JW6H-UFAD80, 400 hp, 2.78 MMBtu/hr maximum rated heat input
- S-5 Evaporative Fluid Cooler, 3-Cell, 5,880 gallons per minute (Exempt from District Permit requirements per Regulation 2, Rule 1, Section 128.4)
- S-6 Oil-Water Separator, 120 gallons per hour (Exempt from District Permit requirements per Regulation 2, Rule 1, Section 103 and Regulation 8, Rule 8, Section 113)

12. Glossary of Acronyms

AAQS	Ambient Air Quality Standard
ARB	Air Resource Board
BTU	British Thermal Unit
BAAQMD	Bay Area Air Quality Management District
BACT	Best Available Control Technology
Cal ISO	California Independent System Operator
CAISO	California Independent System Operator
CARB	California Air Resources Board
CEC	California Energy Commission
CEM	Continuous Emission Monitor
CEQA	California Environmental Quality Act
CO	Carbon Monoxide
CO ₂	Carbon Dioxide
CPUC	California Public Utilities Commission
CTG	Combustion Turbine Generator
EO/APCO	Executive Officer/Air Pollution Control Officer
EPA	Environmental Protection Agency
ERC	Emission Reduction Credit
FDOC	Final Determination of Compliance
FSNL	Full Speed No Load
GE	General Electric Company
GHG	Greenhouse Gases
GT	Gas Turbine
MW	Megawatt
NH ₃	Ammonia
N ₂	Nitrogen
NO	Nitric Oxide
NO ₂	Nitrogen Dioxide
NO _x	Nitrogen Oxides
NSR	New Source Review
O ₂	Oxygen
OGS	Oakley Generating Station
LAER	Lowest Achievable Emissions Rate
LLC	Limited Liability Company
MMBtu	Million Btu
NAAQS	National Ambient Air Quality Standard
PAH	Polycyclic Aromatic Hydrocarbon
PDOC	Preliminary Determination of Compliance
PG&E	Pacific Gas & Electric Company
PM ₁₀	Particulate Matter less than 10 Microns in Diameter
PM _{2.5}	Particulate Matter less than 2.5 Microns in Diameter
POC	Precursor Organic Compounds
ppmvd	Parts Per Million by Volume, Dry

PSD	Prevention of Significant Deterioration
PUC	Public Utilities Commission
RACT	Reasonably Available Control Technology
RATA	Relative Accuracy Test Audit
SCAQMD	South Coast Air Quality Management District
SNCR	Selective Non-catalytic Reduction
SCR	Selective Catalytic Reduction
SJVAPCD	San Joaquin Valley Air Pollution Control District
SO ₂	Sulfur Dioxide
SO _x	Sulfur Oxides
TAC	Toxic Air Contaminant
TBACT	Toxics Best Available Control Technology
U.S. EPA	United States Environmental Protection Agency
VOC	Volatile Organic Compounds

Appendix A

Emission Calculations

Emission Calculations

The following physical constants and standard conditions were utilized to derive the criteria-pollutant emission factors used to estimate and verify criteria pollutant and toxic air contaminant emissions submitted in the permit application. The criteria emission calculations were prepared by the applicant's consultant and are based on a combustion model. The District has verified these values using the calculations shown below. For the toxic air contaminants the District revised the calculation submitted by the applicant.

standard temperature ^a :	70°F
standard pressure ^a :	14.7 psia
molar volume:	386.8 dscf/lbmol
ambient oxygen concentration:	20.95%
dry flue gas factor ^b :	8743 dscf/MM Btu
natural gas higher heating value:	1020 Btu/dscf

^a BAAQMD standard conditions per Regulation 1, Section 228.

^b F-factor is based upon the assumption of complete stoichiometric combustion of natural gas. In effect, it is assumed that all excess air present before combustion is emitted in the exhaust gas stream. Value shown reflects the typical composition and heat content of utility-grade natural gas in San Francisco bay area.

Table A-1 summarizes the regulated air pollutant emission factors that were used to calculate mass emission rates for the gas turbines. All units are pounds per million Btu of natural gas-fired based upon the high heating value (HHV). All emission factors are after abatement by applicable control equipment.

**TABLE A-1
CONTROLLED REGULATED AIR POLLUTANT EMISSION FACTORS FOR
GAS TURBINES AND HRSGS**

Pollutant	Source	
	Combined-Cycle Gas Turbine	
	lb/MM Btu ^c	lb/hr ^c
Nitrogen Oxides (as NO ₂) ^a	0.00722	15.52
Carbon Monoxide ^b	0.004395	9.45
Precursor Organic Compounds	0.00126	2.71
Particulate Matter (PM ₁₀)	0.0036	7.74
Sulfur Dioxide	0.00281	6.0
Sulfur Dioxide (Annual Average)	0.00070	1.5

^a based upon stack concentration of 2.0 ppmvd NO_x @ 15% O₂ that reflects the use of dry low-NO_x combustors at the CTG and abatement by the Selective Catalytic Reduction Systems with ammonia injection.

^b based upon the permit condition emission limit of 2.0 ppmvd CO @ 15% O₂ that reflects abatement by oxidation catalysts.

^c based upon firing rate of 2150 MMBtu/hour (100% Load, 34°F)

REGULATED AIR POLLUTANTS

NITROGEN OXIDE EMISSION FACTORS

The NO_x emissions from the combined-cycle gas turbines during normal operation will be 2.0 ppmv, dry @ 15% O₂. This concentration is converted to a mass emission factor as follows:

$$\begin{aligned} (2.0 \text{ ppmvd})(20.95 - 0)/(20.95 - 15) &= 7.04 \text{ ppmv NO}_x, \text{ dry @ 0\% O}_2 \\ (7.04/10^6)(1 \text{ lbmol}/386.8 \text{ dscf})(46 \text{ lb NO}_2/\text{lbmol})(8743 \text{ dscf/MM Btu}) \\ &= \mathbf{0.00732 \text{ lb NO}_2/\text{MM Btu}} \end{aligned}$$

Calculations shown below are based on emission factors submitted by the applicant.

The NO_x(as NO₂) mass emission rate based upon the maximum firing rate of the combined-cycle gas turbine is calculated as follows:

$$(0.00722 \text{ lb/MM Btu})(2150 \text{ MM Btu/hr}) = \mathbf{15.52 \text{ lb NO}_x(\text{as NO}_2)/\text{hr}}$$

CARBON MONOXIDE EMISSION FACTORS

The CO emissions from the combined-cycle gas turbines during normal operation will be 2.0 ppmv, dry @ 15% O₂. This concentration is converted to a mass emission factor as follows:

$$\begin{aligned} (2.0 \text{ ppmv})(20.95 - 0)/(20.95 - 15) &= 7.04 \text{ ppmv, dry @ 0\% O}_2 \\ (7.04/10^6)(1 \text{ lbmol}/386.8 \text{ dscf})(28 \text{ lb CO}/\text{lbmol})(8743 \text{ dscf/MM Btu}) \\ &= \mathbf{0.00446 \text{ lb CO/MM Btu}} \end{aligned}$$

Calculations shown below are based on emission factors submitted by the applicant.

The CO maximum mass emission rate based upon the maximum firing rate of the combined-cycle gas turbine is calculated as follows:

$$(0.004395 \text{ lb/MM Btu})(2150 \text{ MM Btu/hr}) = \mathbf{9.45 \text{ lb CO/hr}}$$

PRECURSOR ORGANIC COMPOUND (POC) EMISSION FACTORS

The POC emissions from the combined-cycle gas turbines during normal operation will be 1.0 ppmv, dry @ 15% O₂. This concentration is converted to a mass emission factor as follows:

$$(1.0 \text{ ppmv})(20.95 - 0)/(20.95 - 15) = 3.52 \text{ ppmv, dry @ 0\% O}_2$$
$$(3.52/10^6)(\text{lbmol}/386.8 \text{ dscf})(16 \text{ lb CH}_4/\text{lbmol})(8743 \text{ dscf/MM Btu})$$
$$= \mathbf{0.00127 \text{ lb POC/MMBtu}}$$

Calculations shown below are based on emission factors submitted by the applicant.

The POC mass emission rate based upon the maximum firing rate of the combined-cycle gas turbine is calculated as follows:

$$(0.00126 \text{ lb/MMBtu})(2150 \text{ MMBtu/hr}) = \mathbf{2.71 \text{ lb POC/hr}}$$

PARTICULATE MATTER (PM₁₀) EMISSION FACTORS

The District has determined the BACT technology for the combined-cycle gas turbines corresponds to a PM₁₀ emission rate of 0.0036 lb per MMBtu.

The PM mass emission rate based upon the maximum firing rate of the combined-cycle gas turbine is calculated as follows:

$$(0.0036 \text{ lb/MMBtu})(2150 \text{ MMBtu/hr}) = \mathbf{7.74 \text{ lb PM/hr}}$$
$$(0.0036 \text{ lb/MMBtu})(35,397,277 \text{ MMBtu/year})/(2,000 \text{ lb/ton}) = \mathbf{63.715 \text{ TPY PM/year}}$$

SULFUR DIOXIDE EMISSION FACTORS

The SO₂ emission factor is based upon annual average natural gas sulfur content of 0.25 grains per 100 scf and a higher heating value of 1020 Btu/scf.

The sulfur emission factor is calculated as follows:

SO₂ lb/hr

Natural Gas 1 grains of S/100 scf for Maximum Hourly

$$\text{SO}_2 = (1 \text{ gr S}/100 \text{ scf})(\text{lb S}/7000 \text{ gr})(1/1020 \text{ BTU}/\text{scf})(1 \times 10^6 \text{ Btu/MMBtu})(64 \text{ lb SO}_2/32 \text{ lb S})$$
$$= 0.00280 \text{ lb/MMBtu}$$

Natural Gas 0.25 grains of S/100 scf for Annual Average

$$\text{SO}_2 = (0.25 \text{ gr}/100 \text{ scf})(\text{lb}/7000 \text{ gr})(1/1020 \text{ BTU}/\text{scf})(1 \times 10^6 \text{ Btu/MMBtu})(64 \text{ lb SO}_2/32 \text{ lb S})$$
$$= 0.00070 \text{ lb/MMBtu}$$

Calculations shown below are based on emission factors submitted by the applicant.

Max Hourly SO₂

The corresponding SO₂ emission rate for the combined-cycle gas turbine firing:

$$(0.00281 \text{ lb SO}_2/\text{MM Btu})(2150 \text{ MM Btu/hr}) = 6.0 \text{ lb/hr}$$

Annual Average SO₂

The corresponding SO₂ emission rate for the combined-cycle gas turbine firing:

$$(0.00070 \text{ lb SO}_2/\text{MM Btu})(2150 \text{ MM Btu/hr}) = 1.5 \text{ lb/hr}$$

GE estimates for startups and shutdowns are summarized below by Radback Energy.

		
Oakley Generating Station 2x1		
Startup Emissions Summary		
Calculated Values		Proposed Limits
Hot Start		
Start Duration, minutes	14.0	30.0
Total per Start (per turbine)		
NO _x , lbs	22.0	22.0
CO, lbs	85.0	85.0
POC, lbs	31.0	31.0
PM ₁₀ , lbs	2.1	
SO ₂ , lbs (maximum)	0.9	
SO ₂ , lbs (annual average)	0.2	
Warm Start		
Start Duration, minutes	14.0	30.0
Total per Start (per turbine)		
NO _x , lbs	22.0	22.0
CO, lbs	85.0	85.0
POC, lbs	31.0	31.0
PM ₁₀ , lbs	2.1	
SO ₂ , lbs (maximum)	0.9	
SO ₂ , lbs (annual average)	0.2	
Cold Start		
Start Duration, minutes	45.0	90.0
Total per Start (per turbine)	5.0	
NO _x , lbs	96.0	96.0
CO, lbs	360.0	360.0
POC, lbs	67.0	67.0
PM ₁₀ , lbs	6.8	
SO ₂ , lbs (maximum)	2.9	
SO ₂ , lbs (annual average)	0.8	
Shutdown		
Shutdown Duration, minutes	30.0	60.0
Total per Shutdown (per turbine)		
NO _x , lbs	39.0	39.0
CO, lbs	140.0	140.0
POC, lbs	17.0	17.0
PM ₁₀ , lbs	4.5	
SO ₂ , lbs (maximum)	1.9	
SO ₂ , lbs (annual average)	0.5	

Maximum Hourly Emissions (per turbine)								
Pollutant	Cold Startup (lb/event) ^a	Cold Startup (lb/hour) ^b	Hot/Warm Startup (lb/event) ^c	Hot/Warm Startup (lb/hour) ^d	Tuning (lb/event) ^e	Tuning (lb/hour)	Shutdown (lb/event)	Shutdown (lb/hour)
NO _x (as NO ₂)	96.0	99.9	22.0	33.9	576	96.0	39	46.8
CO	360.0	362.4	85.0	92.2	2160	360.0	140	144.7
POC (as CH ₄)	67.0	67.7	31.0	33.1	402	67.0	17	18.4

Maximum Daily Emissions for 2 turbines (without a Tuning Event)

Pollutant	(lb/day/turbine)	(lb/day/ 2 turbines)
NO _x (as NO ₂)	488.1	976.2
CO	715.0	1430.0
POC (as CH ₄)	145.7	291.3
PM ₁₀ /PM _{2.5}	185.8	371.5
SO _x (as SO ₂)	144.0	288.0

NO_x, CO, and POC are calculated by 1 cold start (45 min), 1 shut down (30 min), normal operation (22.75 hours)

PM and SO_x are maximum pound per hour x 24 hours/day

Maximum Daily Emissions with a Tuning Event (2 turbines)

Pollutant	(lb/day/CT 1)	(lb/day/CT 2)	(lb/day/2 turbines)
NO _x (as NO ₂)	971.0	488.1	1459.0
CO	2818.3	715.0	3533.3
POC (as CH ₄)	531.4	145.7	677.0
PM ₁₀ /PM _{2.5}	185.8	185.8	371.5
SO _x (as SO ₂)	144.0	144.0	288.0

CT 1 turbine: 1 tuning event (6 hours) + 1 cold start (45 min) + 1 shutdown (30 min) + normal operation (16.75 hours).

CT 2 turbine: 1 cold start (45 min) + 1 shutdown (30 min) + normal operation (22.75 hours).

Combustor tuning shall only be performed on one gas turbine per day.

Maximum Annual Emissions were calculated using three operating scenarios. The maximum emissions for each pollutant was used to establish the annual facility-wide emissions limits.

	Scenario 1	Scenario 2	Scenario 3			
Combustion Turbines/HRSGs (per unit unless noted)						
Number of Turbines/HRSGs	2	2	2			
Minimum Load Hours - Natural Gas	0	0	0			
Base Load ISO Hours - Natural Gas	3657	3933	6924			
Base Load Peak July Hours - Natural Gas	1500	1500	1500			
Total Hot Starts - Natural Gas	275	260	51			
Total Warm Starts - Natural Gas	0	51	0			
Total Cold Starts - Natural Gas	25	1	1			
Total Shutdowns - Natural Gas	300	312	52			
Startup/Shutdown Hours	233	229	39			
Total Hours of Operation	5390	5662	8463			
Offline Hours	3370	3098	297			
Annual Fuel Use, MMBtu (HHV) (all units)	22480757	23625816	35397277			
Auxiliary Boiler						
Operating Hours	3603	3327	336			
Total Starts	300	312	52			
Total Shutdowns - Natural Gas	300	312	52			
Evaporative Fluid Cooler						
Operating Hours	1500	1500	1500			
Fire Pump						
Duration of Periodic Tests, mins	56	56	56			
Frequency of Tests, tests/year	53	53	53			
Load During Testing, %	1	1	1			
Operating Hours	49	49	49			
Annual Fuel Use, gals/yr	980	980	980			
Pollutant	Factors (Estimated Annual Average)	Calculated Normal Operation (ISO)	Calculated Normal Operation (Peak July)	Hot/Warm Start (typical)	Cold Start (typical)	Shutdown (typical)
	ppmvd at 15% O2	lb/hour/turbine	lb/hour/turbine	lb/event	lb/event	lb/event
NO2	1.5	11.38	11.06	22	96	39
CO	1.0	4.62	4.49	85	360	140
POC	1.0	2.65	2.57	31	67	17
PM10	-	7.57	7.35	1.8	5.8	3.9
SO2 (annual)	0.25 grain/100scf	1.50	1.50	0.23	0.37	0.5
Ammonia	5.0	14.36	14.36			
Time (minutes)				14	45	30
Notes:						
Emission rates and concentrations estimated by Radback Energy						
BAAQMD adjusted PM emissions based on 0.0036 lb/MMBtu						

Maximum Annual Regulated Air Pollutant emission calculations submitted by the Applicant were verified below. Proposed permit limits are calculated by the Applicant and differences can be attributed to rounding.

Scenario 1	2 turbines				Boiler	Boiler	Fire Pump Engine	Evaporative Fluid	Oil/Water	Scenario 1
	Normal Operation	Hot/Warm Starts	Cold Starts	Shutdown	Normal Operation	Startup & Shutdown		Cooler	Separator	Emissions
Pollutant	TPY	TPY	TPY	TPY	TPY	TPY	TPY	TPY	TPY	TPY
NO2	58.20	6.05	2.40	11.70	0.76	0.24	0.06			79.4
CO	23.62	23.38	9.00	42.00	0.66	0.21	0.01			98.9
POC	13.53	8.53	1.68	5.10	0.19	0.06	0.00		0.11	29.2
PM10	38.71	0.50	0.15	1.16	0.64	0.07	0.00	0.10		41.3
SO2	7.74	0.06	0.01	0.15	0.25	0.03	0.00			8.2
	2 turbines				Boiler	Boiler	Fire Pump Engine	Evaporative Fluid	Oil/Water	Scenario 2
Scenario 2	Normal Operation	Hot/Warm Starts	Cold Starts	Shutdown	Normal Operation	Startup & Shutdown		Cooler	Separator	Emissions
Pollutant	TPY	TPY	TPY	TPY	TPY	TPY	TPY	TPY	TPY	TPY
NO2	61.34	6.84	0.10	12.17	0.70	0.25	0.06			81.5
CO	24.90	26.44	0.36	43.68	0.61	0.22	0.01			96.2
POC	14.26	9.64	0.07	5.30	0.18	0.06	0.00		0.11	29.6
PM10	40.79	0.56	0.01	1.21	0.59	0.07	0.00	0.10		43.3
SO2	8.15	0.07	0.00	0.16	0.23	0.03	0.00			8.6
	2 turbines				Boiler	Boiler	Fire Pump Engine	Evaporative Fluid	Oil/Water	Scenario 3
Scenario 3	Normal Operation	Hot/Warm Starts	Cold Starts	Shutdown	Normal Operation	Startup & Shutdown		Cooler	Separator	Emissions
Pollutant	TPY	TPY	TPY	TPY	TPY	TPY	TPY	TPY	TPY	TPY
NO2	95.38	1.12	0.10	2.03	0.07	0.04	0.06			98.8
CO	38.71	4.34	0.36	7.28	0.06	0.04	0.01			50.8
POC	22.17	1.58	0.07	0.88	0.02	0.01	0.00		0.11	24.8
PM10	63.43	0.09	0.01	0.20	0.06	0.01	0.00	0.10		63.9
SO2	12.64	0.01	0.00	0.03	0.02	0.00	0.00			12.7

Maximum Toxic Air Contaminant Emissions from Normal Operation of the Gas Turbines									
	EF	Per Turbine EF	Per Turbine Firing Rate	Firing Rate	Per Turbine	Per Turbine	Total CT	Total CT	Total CT
Toxic Air Contaminant	lb/MMBtu	lb/mmscf	mmscf/hour	mmscf/year	lb/hour	lb/year	lb/hour	lb/year	TPY
1,3-Butadiene	1.24E-07	1.27E-04	2.104	17,317.65	2.67E-04	2.20E+00	5.34E-04	4.40E+00	2.20E-03
Acetaldehyde	1.34E-04	1.37E-01			2.88E-01	2.37E+03	5.76E-01	4.75E+03	2.37E+00
Acrolein	1.85E-05	1.89E-02			3.98E-02	3.27E+02	7.95E-02	6.55E+02	3.27E-01
Ammonia	6.82E-03	6.97E+00			1.47E+01	1.21E+05	2.93E+01	2.41E+05	1.21E+02
Benzene	1.30E-05	1.33E-02			2.80E-02	2.30E+02	5.60E-02	4.61E+02	2.30E-01
Benzo(a)anthracene	2.21E-08	2.26E-05			4.76E-05	3.91E-01	9.51E-05	7.83E-01	3.91E-04
Benzo(a)pyrene	1.36E-08	1.39E-05			2.92E-05	2.41E-01	5.85E-05	4.81E-01	2.41E-04
Benzo(b)fluoranthene	1.11E-08	1.13E-05			2.38E-05	1.96E-01	4.76E-05	3.91E-01	1.96E-04
Benzo(k)fluoranthene	1.08E-08	1.10E-05			2.31E-05	1.90E-01	4.63E-05	3.81E-01	1.90E-04
Chrysene	2.47E-08	2.52E-05			5.30E-05	4.36E-01	1.06E-04	8.73E-01	4.36E-04
Dibenz(a,h)anthracene	2.30E-08	2.35E-05			4.94E-05	4.07E-01	9.89E-05	8.14E-01	4.07E-04
Ethylbenzene	1.75E-05	1.79E-02			3.77E-02	3.10E+02	7.53E-02	6.20E+02	3.10E-01
Formaldehyde	4.49E-04	4.59E-01			9.65E-01	7.94E+03	1.93E+00	1.59E+04	7.94E+00
Hexane	2.53E-04	2.59E-01			5.45E-01	4.49E+03	1.09E+00	8.97E+03	4.49E+00
Indeno(1,2,3-cd)pyrene	2.30E-08	2.35E-05			4.94E-05	4.07E-01	9.89E-05	8.14E-01	4.07E-04
Naphthalene	1.62E-06	1.66E-03			3.49E-03	2.87E+01	6.99E-03	5.75E+01	2.87E-02
Propylene	7.54E-04	7.71E-01			1.62E+00	1.34E+04	3.24E+00	2.67E+04	1.34E+01
Propylene Oxide	4.68E-05	4.78E-02			1.01E-01	8.28E+02	2.01E-01	1.66E+03	8.28E-01
Toluene	6.95E-05	7.10E-02			1.49E-01	1.23E+03	2.99E-01	2.46E+03	1.23E+00
Xylene (Total)	2.55E-05	2.61E-02			5.49E-02	4.52E+02	1.10E-01	9.04E+02	4.52E-01
Sulfuric Acid Mist (H2SO4) - short term	1.42E-03	1.45E+00			3.06E+00		6.12E+00		
Sulfuric Acid Mist (H2SO4) - annual average	3.56E-04	3.64E-01				6.30E+03		1.26E+04	6.30E+00
Benzo(a)pyrene equivalents	4.47E-08	4.57E-05			9.61E-05	7.91E-01	1.92E-04	1.58E+00	7.91E-04
Specified PAHs					0.00	2.27	0.00	4.54	0.00
Formaldehyde emissions reflect 50% destruction due to oxidation catalyst.									
	Equivalency								
	Factor								
Benzo(a)anthracene	0.1								
Benzo(a)pyrene	1								
Benzo(b)fluoranthene	0.1								
Benzo(k)fluoranthene	0.1								
Chrysene	0.01								
Dibenz(a,h)anthracene	1.05								
Indeno(1,2,3-cd)pyrene	0.1								
Ammonia lb/MMBtu = $\text{ppmvd} \times 10^{-6} \times \text{1/molar volume} \times \text{MW} \times \text{Fd} \times 20.9/(20.9 - \%O_2)$									
ppm =	5	ppmvd @15%O2 limit							
molar volume =	386.8	dscf/lbmol @ 14.696 psia, 70 deg. F							
MW =	17.03	molecular weight, lb/lb-mol							
Fd =	8743	dscf/MMBtu for Natural Gas @ 70 deg. F							
O2 in exhaust air	15	%							
Ammonia lb/MMBtu = 5.0E-06 ft3 of NH3/lb stack gas x 1/386.8 dscf/lb-mol x 17.03 lb/lb-mol x 8743 dscf/MMBtu x 20.9/(20.9 - 15)									
Ammonia lb/MMBtu =		6.82E-03							
Ammonia lb/mmscf =		6.97E+00							

	Annual Toxic Air Contaminant Emissions						
	Scenario 1						
	2 turbines						Scenario 1
	Normal Operation	Hot Starts	Warm Starts	Cold Starts	Shutdowns	Tuning	Emissions
Toxic Air Contaminant	lb/year	lb/year	lb/year	lb/year	lb/year	lb/year	lb/year
1,3-Butadiene	2.70E+00	2.40E-02	0.00E+00	7.01E-03	1.60E-01	8.55E-03	2.90E+00
Acetaldehyde	2.91E+03	2.42E+02	0.00E+00	7.07E+01	1.73E+02	8.62E+01	3.48E+03
Acrolein	4.02E+02	1.30E+01	0.00E+00	3.81E+00	2.39E+01	4.64E+00	4.47E+02
Ammonia	1.48E+05	1.32E+03	0.00E+00	3.85E+02	8.80E+03	4.69E+02	1.59E+05
Benzene	2.83E+02	4.84E+00	0.00E+00	1.41E+00	1.68E+01	1.72E+00	3.07E+02
Benzo(a)anthracene	4.80E-01	4.27E-03	0.00E+00	1.25E-03	2.85E-02	1.52E-03	5.16E-01
Benzo(a)pyrene	2.95E-01	2.63E-03	0.00E+00	7.68E-04	1.75E-02	9.36E-04	3.17E-01
Benzo(b)fluoranthene	2.40E-01	2.14E-03	0.00E+00	6.24E-04	1.43E-02	7.61E-04	2.58E-01
Benzo(k)fluoranthene	2.34E-01	2.08E-03	0.00E+00	6.08E-04	1.39E-02	7.41E-04	2.51E-01
Chrysene	5.35E-01	4.76E-03	0.00E+00	1.39E-03	3.18E-02	1.70E-03	5.75E-01
Dibenz(a,h)anthracene	4.99E-01	4.44E-03	0.00E+00	1.30E-03	2.97E-02	1.58E-03	5.36E-01
Ethylbenzene	3.80E+02	6.16E+00	0.00E+00	1.80E+00	2.26E+01	2.19E+00	4.13E+02
Formaldehyde	9.74E+03	8.75E+02	0.00E+00	2.56E+02	5.79E+02	3.12E+02	1.18E+04
Hexane	5.50E+03	4.90E+01	0.00E+00	1.43E+01	3.27E+02	1.74E+01	5.91E+03
Indeno(1,2,3-cd)pyrene	4.99E-01	4.44E-03	0.00E+00	1.30E-03	2.97E-02	1.58E-03	5.36E-01
Naphthalene	3.53E+01	3.14E-01	0.00E+00	9.17E-02	2.10E+00	1.12E-01	3.79E+01
Propylene	1.64E+04	1.46E+02	0.00E+00	4.26E+01	9.73E+02	5.19E+01	1.76E+04
Propylene Oxide	1.02E+03	9.03E+00	0.00E+00	2.64E+00	6.03E+01	3.22E+00	1.09E+03
Toluene	1.51E+03	1.75E+01	0.00E+00	5.13E+00	8.96E+01	6.25E+00	1.63E+03
Xylene (Total)	5.54E+02	4.93E+00	0.00E+00	1.44E+00	3.29E+01	1.76E+00	5.96E+02
Sulfuric Acid Mist (H2SO4)	7.73E+03	2.75E+02	0.00E+00	8.04E+01	1.84E+03	9.80E+01	1.00E+04
Benzo(a)pyrene equivalents	9.70E-01	8.63E-03	0.00E+00	2.52E-03	5.77E-02	3.07E-03	1.04E+00

	Annual Toxic Air Contaminant Emissions						
	Scenario 2						
	2 turbines						Scenario 2
	Normal Operation	Hot Starts	Warm Starts	Cold Starts	Shutdowns	Tuning	Emissions
Toxic Air Contaminant	lb/year	lb/year	lb/year	lb/year	lb/year	lb/year	lb/year
1,3-Butadiene	2.39E+00	2.27E-02	4.45E-03	2.81E-04	5.84E-02	8.55E-03	2.49E+00
Acetaldehyde	2.58E+03	2.29E+02	4.49E+01	2.83E+00	5.88E+02	8.62E+01	3.53E+03
Acrolein	3.56E+02	1.23E+01	2.42E+00	1.52E-01	3.17E+01	4.64E+00	4.08E+02
Ammonia	1.31E+05	1.25E+03	2.44E+02	1.54E+01	3.20E+03	4.69E+02	1.37E+05
Benzene	2.51E+02	4.57E+00	8.97E-01	5.66E-02	1.18E+01	1.72E+00	2.70E+02
Benzo(a)anthracene	4.26E-01	4.04E-03	7.92E-04	4.99E-05	1.04E-02	1.52E-03	4.43E-01
Benzo(a)pyrene	2.62E-01	2.48E-03	4.87E-04	3.07E-05	6.39E-03	9.36E-04	2.72E-01
Benzo(b)fluoranthene	2.13E-01	2.02E-03	3.96E-04	2.50E-05	5.19E-03	7.61E-04	2.21E-01
Benzo(k)fluoranthene	2.07E-01	1.97E-03	3.86E-04	2.43E-05	5.05E-03	7.41E-04	2.16E-01
Chrysene	4.75E-01	4.50E-03	8.83E-04	5.57E-05	1.16E-02	1.70E-03	4.94E-01
Dibenz(a,h)anthracene	4.43E-01	4.20E-03	8.24E-04	5.19E-05	1.08E-02	1.58E-03	4.61E-01
Ethylbenzene	3.37E+02	5.83E+00	1.14E+00	7.20E-02	1.50E+01	2.19E+00	3.62E+02
Formaldehyde	8.64E+03	8.27E+02	1.62E+02	1.02E+01	2.13E+03	3.12E+02	1.21E+04
Hexane	4.88E+03	4.63E+01	9.08E+00	5.72E-01	1.19E+02	1.74E+01	5.08E+03
Indeno(1,2,3-cd)pyrene	4.43E-01	4.20E-03	8.24E-04	5.19E-05	1.08E-02	1.58E-03	4.61E-01
Naphthalene	3.13E+01	2.97E-01	5.82E-02	3.67E-03	7.63E-01	1.12E-01	3.25E+01
Propylene	1.45E+04	1.38E+02	2.70E+01	1.70E+00	3.54E+02	5.19E+01	1.51E+04
Propylene Oxide	9.01E+02	8.54E+00	1.68E+00	1.06E-01	2.20E+01	3.22E+00	9.37E+02
Toluene	1.34E+03	1.66E+01	3.25E+00	2.05E-01	4.26E+01	6.25E+00	1.41E+03
Xylene (Total)	4.92E+02	4.66E+00	9.15E-01	5.77E-02	1.20E+01	1.76E+00	5.11E+02
Sulfuric Acid Mist (H2SO4)	6.86E+03	2.60E+02	5.10E+01	3.21E+00	6.69E+02	9.80E+01	7.94E+03
Benzo(a)pyrene equivalents	8.61E-01	8.16E-03	1.60E-03	1.01E-04	2.10E-02	3.07E-03	8.95E-01

	Annual Toxic Air Contaminant Emissions								
	Scenario 3						Scenario 3	Full Load	Worst Case
	2 turbines						Emissions	Emissions	Max. Annual
	Normal Operation	Hot Starts	Warm Starts	Cold Starts	Shutdowns	Tuning	from 2 turbines	from 2 turbines	Emissions per turbine
Toxic Air Contaminant	lb/year	lb/year	lb/year	lb/year	lb/year	lb/year	lb/year	lb/year	lb/year
1,3-Butadiene	4.38E+00	4.45E-03	0.00E+00	2.81E-04	9.73E-03	8.55E-03	4.3987E+00	4.3987E+00	2.1993E+00
Acetaldehyde	4.72E+03	4.49E+01	0.00E+00	2.83E+00	9.80E+01	8.62E+01	4.9521E+03	4.7450E+03	2.4761E+03
Acrolein	6.51E+02	2.42E+00	0.00E+00	1.52E-01	5.28E+00	4.64E+00	6.6367E+02	6.5461E+02	3.3183E+02
Ammonia	2.40E+05	2.44E+02	0.00E+00	1.54E+01	5.34E+02	4.69E+02	2.4134E+05	2.4134E+05	1.2067E+05
Benzene	4.58E+02	8.97E-01	0.00E+00	5.66E-02	1.96E+00	1.72E+00	4.6288E+02	4.6065E+02	2.3144E+02
Benzo(a)anthracene	7.79E-01	7.92E-04	0.00E+00	4.99E-05	1.73E-03	1.52E-03	7.8276E-01	7.8276E-01	3.9138E-01
Benzo(a)pyrene	4.79E-01	4.87E-04	0.00E+00	3.07E-05	1.06E-03	9.36E-04	4.8143E-01	4.8143E-01	2.4072E-01
Benzo(b)fluoranthene	3.89E-01	3.96E-04	0.00E+00	2.50E-05	8.65E-04	7.61E-04	3.9138E-01	3.9138E-01	1.9569E-01
Benzo(k)fluoranthene	3.79E-01	3.86E-04	0.00E+00	2.43E-05	8.42E-04	7.41E-04	3.8099E-01	3.8099E-01	1.9049E-01
Chrysene	8.68E-01	8.83E-04	0.00E+00	5.57E-05	1.93E-03	1.70E-03	8.7281E-01	8.7281E-01	4.3640E-01
Dibenz(a,h)anthracene	8.10E-01	8.24E-04	0.00E+00	5.19E-05	1.80E-03	1.58E-03	8.1393E-01	8.1393E-01	4.0696E-01
Ethylbenzene	6.17E+02	1.14E+00	0.00E+00	7.20E-02	2.50E+00	2.19E+00	6.2264E+02	6.1997E+02	3.1132E+02
Formaldehyde	1.58E+04	1.62E+02	0.00E+00	1.02E+01	3.55E+02	3.12E+02	1.66361E+04	1.5880E+04	8.3180E+03
Hexane	8.92E+03	9.08E+00	0.00E+00	5.72E-01	1.98E+01	1.74E+01	8.9705E+03	8.9705E+03	4.4853E+03
Indeno(1,2,3-cd)pyrene	8.10E-01	8.24E-04	0.00E+00	5.19E-05	1.80E-03	1.58E-03	8.1393E-01	8.1393E-01	4.0696E-01
Naphthalene	5.72E+01	5.82E-02	0.00E+00	3.67E-03	1.27E-01	1.12E-01	5.7495E+01	5.7495E+01	2.8747E+01
Propylene	2.66E+04	2.70E+01	0.00E+00	1.70E+00	5.90E+01	5.19E+01	2.6704E+04	2.6704E+04	1.3352E+04
Propylene Oxide	1.65E+03	1.68E+00	0.00E+00	1.06E-01	3.66E+00	3.22E+00	1.6556E+03	1.6556E+03	8.2778E+02
Toluene	2.45E+03	3.25E+00	0.00E+00	2.05E-01	7.11E+00	6.25E+00	2.4631E+03	2.4591E+03	1.2315E+03
Xylene (Total)	8.99E+02	9.15E-01	0.00E+00	5.77E-02	2.00E+00	1.76E+00	9.0398E+02	9.0398E+02	4.5199E+02
Sulfuric Acid Mist (H2SO4)	1.25E+04	5.10E+01	0.00E+00	3.21E+00	1.11E+02	9.80E+01	1.2795E+04	1.2598E+04	6.3976E+03
Benzo(a)pyrene equivalents	1.57E+00	1.60E-03	0.00E+00	1.01E-04	3.50E-03	3.07E-03	1.5817E+00	1.5817E+00	7.9085E-01
Specified PAHs							4.5372E+00	4.5372E+00	2.2686E+00

Toxic Air Contaminant Emissions from Startup/Shutdown of Gas Turbines					
	CATEF		SDAPCD	Startup/Shutdown	Startup/Shutdown
	EF		EF	EF	EF Source
Toxic Air Contaminant	lb/mmscf		lb/mmscf	lb/mmscf	
1,3-Butadiene	1.27E-04			1.27E-04	CATEF
Acetaldehyde	1.37E-01		1.28E+00	1.28E+00	SDAPCD
Acrolein	1.89E-02		6.89E-02	6.89E-02	SDAPCD
Ammonia				6.97E+00	Permit limit
Benzene	1.33E-02		2.56E-02	2.56E-02	SDAPCD
Benzo(a)anthracene	2.26E-05	ND	2.25E-05	2.26E-05	CATEF
Benzo(a)pyrene	1.39E-05	ND	1.39E-05	1.39E-05	CATEF
Benzo(b)fluoranthene	1.13E-05			1.13E-05	CATEF
Benzo(k)fluoranthene	1.10E-05			1.10E-05	CATEF
Chrysene	2.52E-05	ND	2.25E-05	2.52E-05	CATEF
Dibenz(a,h)anthracene	2.35E-05	ND	2.25E-05	2.35E-05	CATEF
Ethylbenzene	1.79E-02		3.26E-02	3.26E-02	SDAPCD
Formaldehyde	9.17E-01		4.63E+00	4.63E+00	SDAPCD
Hexane	2.59E-01			2.59E-01	CATEF
Indeno(1,2,3-cd)pyrene	2.35E-05	ND	2.25E-05	2.35E-05	CATEF
Naphthalene	1.66E-03		1.04E-03	1.66E-03	CATEF
Propylene	7.71E-01			7.71E-01	CATEF
Propylene Oxide	4.78E-02			4.78E-02	CATEF
Toluene	7.10E-02		9.28E-02	9.28E-02	SDAPCD
Xylene (Total)	2.61E-02		3.48E-03	2.61E-02	CATEF
Sulfuric Acid Mist (H2SO4)				1.45E+00	Permit limit of SO2
Benzo(a)pyrene equivalents (calculated)	4.57E-05		4.23E-05	4.57E-05	CATEF
	Equivalency Factor				
Benzo(a)anthracene	0.1				
Benzo(a)pyrene	1				
Benzo(b)fluoranthrene	0.1				
Benzo(k)fluoranthene	0.1				
Chrysene	0.01				
Dibenz(a,h)anthracene	1.05				
Indeno(1,2,3-cd)pyrene	0.1				
Event	Fuel Usage nmscf	Minimum Time minutes	Fuel Usage MMBtu		
Cold Startup	1.1046	45	1128.9		
Warm/Hot Startup	0.3437	14	351.2		
Shutdown	0.7364	30	752.6		
Tuning	16.8320	480	17202.3		
CATEF = California Air Toxics Emission Factors Database maintained by the California Air Resources Board					
SDAPCD = San Diego Air Pollution Control District. Emission factors developed from source testing of					
Palomar GE Frame 7FA turbine during the 1st hour of a cold startup. Data from Carlsbad Energy Center Final					
Determination of Compliance, Appendix B, August 4, 2009, SDAPCD					
ND = Non Detect from SDAPCD, Emission Factor is one half of the detection limit.					
Natural Gas Higher Heating Value = 1022 Btu/scf					
Startup Emission Factors are the highest value of the CATEF of SDAPCD Emission Factors					
Fuel Usage during startup/shutdown assumed to be 70% of baseload rate					
Fuel Usage during commissioning assumed to be 100% of baseload rate					

Toxic Air Contaminant Emissions from Startup/Shutdown/Tuning of Gas Turbines					
	45 min Cold Startup	14 min Warm/Hot Startup	30 min Shutdown	14 min Warm/Hot Startup	Tuning
	balance Normal	balance Normal	balance Normal	30 min Shutdown	
	Emissions	Emissions	Emissions	balance Normal	
Toxic Air Contaminant	lb/hour	lb/hour	lb/hour	lb/hour	lb/hour
1,3-Butadiene	2.07E-04	2.49E-04	2.27E-04	2.08E-04	2.67E-04
Acetaldehyde	1.49E+00	6.61E-01	1.09E+00	1.46E+00	2.69E+00
Acrolein	8.60E-02	5.42E-02	7.06E-02	8.50E-02	1.45E-01
Ammonia	1.14E+01	1.36E+01	1.25E+01	1.14E+01	1.47E+01
Benzene	3.53E-02	3.03E-02	3.28E-02	3.51E-02	5.39E-02
Benzo(a)anthracene	3.69E-05	4.42E-05	4.04E-05	3.71E-05	4.76E-05
Benzo(a)pyrene	2.27E-05	2.72E-05	2.49E-05	2.28E-05	2.92E-05
Benzo(b)fluoranthene	1.84E-05	2.21E-05	2.02E-05	1.85E-05	2.38E-05
Benzo(k)fluoranthene	1.79E-05	2.15E-05	1.97E-05	1.81E-05	2.31E-05
Chrysene	4.11E-05	4.93E-05	4.51E-05	4.14E-05	5.30E-05
Dibenz(a,h)anthracene	3.83E-05	4.60E-05	4.20E-05	3.86E-05	4.94E-05
Ethylbenzene	4.54E-02	4.01E-02	4.28E-02	4.53E-02	6.86E-02
Formaldehyde	5.36E+00	2.33E+00	3.89E+00	5.26E+00	9.74E+00
Hexane	4.22E-01	5.07E-01	4.63E-01	4.25E-01	5.45E-01
Indeno(1,2,3-cd)pyrene	3.83E-05	4.60E-05	4.20E-05	3.86E-05	4.94E-05
Naphthalene	2.71E-03	3.25E-03	2.97E-03	2.72E-03	3.49E-03
Propylene	1.26E+00	1.51E+00	1.38E+00	1.27E+00	1.62E+00
Propylene Oxide	7.79E-02	9.35E-02	8.55E-02	7.84E-02	1.01E-01
Toluene	1.40E-01	1.46E-01	1.43E-01	1.40E-01	1.95E-01
Xylene (Total)	4.26E-02	5.11E-02	4.67E-02	4.28E-02	5.49E-02
Sulfuric Acid Mist (H2SO4)	2.37E+00	2.85E+00	2.60E+00	2.39E+00	3.06E+00
Benzo(a)pyrene equivalents (c	7.45E-05	8.94E-05	8.17E-05	7.49E-05	9.61E-05

Toxic Air Contaminant Emissions from Startup/Shutdown of Gas Turbines				
	Worst Case		Worst Case	
	Maximum Hourly	Worst Case	Maximum Hourly	Worst Case
	Emissions per Turbine	Maximum Hourly	Emissions per Turbine	Maximum Hourly
	No Tuning	Emissions per Turbine	Including Tuning	Emissions per Turbine
Toxic Air Contaminant	lb/hour		lb/hour	
1,3-Butadiene	2.67E-04	Normal Operation	2.67E-04	Normal Operation
Acetaldehyde	1.49E+00	45 min Cold Startup balance Normal	2.69E+00	Tuning
Acrolein	8.60E-02	45 min Cold Startup balance Normal	1.45E-01	Tuning
Ammonia	1.47E+01	Normal Operation	1.47E+01	Normal Operation
Benzene	3.53E-02	45 min Cold Startup balance Normal	5.39E-02	Tuning
<i>Benzo(a)anthracene</i>	4.76E-05	Normal Operation	4.76E-05	Normal Operation
<i>Benzo(a)pyrene</i>	2.92E-05	Normal Operation	2.92E-05	Normal Operation
<i>Benzo(b)fluoranthene</i>	2.38E-05	Normal Operation	2.38E-05	Normal Operation
<i>Benzo(k)fluoranthene</i>	2.31E-05	Normal Operation	2.31E-05	Normal Operation
<i>Chrysene</i>	5.30E-05	Normal Operation	5.30E-05	Normal Operation
<i>Dibenz(a,h)anthracene</i>	4.94E-05	Normal Operation	4.94E-05	Normal Operation
Ethylbenzene	4.54E-02	45 min Cold Startup balance Normal	6.86E-02	Tuning
Formaldehyde	5.36E+00	45 min Cold Startup balance Normal	9.74E+00	Tuning
Hexane	5.45E-01	Normal Operation	5.45E-01	Normal Operation
<i>Indeno(1,2,3-cd)pyrene</i>	4.94E-05	Normal Operation	4.94E-05	Normal Operation
Naphthalene	3.49E-03	Normal Operation	3.49E-03	Normal Operation
Propylene	1.62E+00	Normal Operation	1.62E+00	Normal Operation
Propylene Oxide	1.01E-01	Normal Operation	1.01E-01	Normal Operation
Toluene	1.49E-01	Normal Operation	1.95E-01	Tuning
Xylene (Total)	5.49E-02	Normal Operation	5.49E-02	Normal Operation
Sulfuric Acid Mist (H ₂ SO ₄)	3.06E+00	Normal Operation	3.06E+00	Normal Operation
Benzo(a)pyrene equivalents (calculated)	9.61E-05	Normal Operation	9.61E-05	Normal Operation

CATEF Gas Turbine TAC Emission Factors

ID	System Type	Material Type	SCC	APC Device	Other Description	CAS	Substance	Max Emission factor	Mean	Median	Unit
4544	Turbine	Natural gas	2E+07	None	None	106-99-0	1,3-Butadiene	1.33E-04	1.27E-04	1.24E-04	lbs/MMcf
4569	Turbine	Natural gas	2E+07	None	None	75-07-0	Acetaldehyde	5.11E-01	1.37E-01	5.38E-02	lbs/MMcf
4574	Turbine	Natural gas	2E+07	None	None	107-02-8	Acrolein	6.93E-02	1.89E-02	1.09E-02	lbs/MMcf
4587	Turbine	Natural gas	2E+07	None	None	71-43-2	Benzene	4.72E-02	1.33E-02	1.01E-02	lbs/MMcf
4594	Turbine	Natural gas	2E+07	None	None	56-55-6	Benzo(a)anthracene	1.34E-04	2.26E-05	3.61E-06	lbs/MMcf
4599	Turbine	Natural gas	2E+07	None	None	50-32-8	Benzo(a)pyrene	9.16E-05	1.39E-05	2.57E-06	lbs/MMcf
4604	Turbine	Natural gas	2E+07	None	None	205-99-2	Benzo(b)fluoranthene	6.72E-05	1.13E-05	2.87E-06	lbs/MMcf
4619	Turbine	Natural gas	2E+07	None	None	207-08-9	Benzo(k)fluoranthene	6.72E-05	1.10E-05	2.87E-06	lbs/MMcf
4624	Turbine	Natural gas	2E+07	None	None	218-01-9	Chrysene	1.50E-04	2.52E-05	4.99E-06	lbs/MMcf
4629	Turbine	Natural gas	2E+07	None	None	53-70-3	Dibenz(a,h)anthracene	1.34E-04	2.35E-05	3.03E-06	lbs/MMcf
4634	Turbine	Natural gas	2E+07	None	None	100-41-4	Ethylbenzene	5.70E-02	1.79E-02	9.74E-03	lbs/MMcf
4649	Turbine	Natural gas	2E+07	None	None	50-00-0	Formaldehyde	6.87E+00	9.17E-01	1.12E-01	lbs/MMcf
4654	Turbine	Natural gas	2E+07	None	None	110-54-3	Hexane	3.82E-01	2.59E-01	2.19E-01	lbs/MMcf
4659	Turbine	Natural gas	2E+07	None	None	193-39-5	Indeno(1,2,3-cd)pyrene	1.34E-04	2.35E-05	2.87E-06	lbs/MMcf
4664	Turbine	Natural gas	2E+07	None	None	91-20-3	Naphthalene	7.88E-03	1.66E-03	9.26E-04	lbs/MMcf
4679	Turbine	Natural gas	2E+07	None	None	115-07-1	Propylene	2.00E+00	7.71E-01	5.71E-01	lbs/MMcf
4684	Turbine	Natural gas	2E+07	None	None	75-56-9	Propylene Oxide	5.87E-02	4.78E-02	4.48E-02	lbs/MMcf
4694	Turbine	Natural gas	2E+07	None	None	108-88-3	Toluene	1.68E-01	7.10E-02	5.91E-02	lbs/MMcf
4709	Turbine	Natural gas	2E+07	None	None	1330-20-7	Xylene (Total)	6.26E-02	2.61E-02	1.93E-02	lbs/MMcf

Table A-2 summarizes the regulated air pollutant emission factors submitted by the applicant that were used to calculate mass emission rates for the auxiliary boiler. All units are pounds per million Btu of natural gas-fired based upon the high heating value (HHV). All emission factors are after abatement by applicable control equipment.

**TABLE A-2
CONTROLLED REGULATED AIR POLLUTANT EMISSION FACTORS FOR
AUXILIARY BOILER**

Pollutant	Source	
	Auxiliary Boiler	
	lb/MM Btu ^c	lb/hr ^c
Nitrogen Oxides (as NO ₂) ^a	0.0083	0.42
Carbon Monoxide ^b	0.0073	0.37
Precursor Organic Compounds	0.0022	0.11
Particulate Matter (PM ₁₀)	0.0069	0.35
Sulfur Dioxide	0.0028	0.14

^a Based upon stack concentration of 7.0 ppmvd NO_x @ 3% O₂ that reflects the use of ultra-low-NO_x burners and flue gas recirculation. NO_x concentration will be monitored by continuous emission monitors.

^b Based upon stack concentration of 10.0 ppmvd CO @ 3% O₂. Applicant may use vendor guarantee of 10.0 ppm CO or may use an oxidation catalyst. CO concentration will be monitored by continuous emission monitors.

^c Based upon firing rate of 50.6 MMBtu/hour

REGULATED AIR POLLUTANTS

NITROGEN OXIDE EMISSION FACTORS

The NO_x emissions from the auxiliary boiler during normal operation will be 7.0 ppmv, dry @ 3% O₂. This concentration is converted to a mass emission factor as follows:

$$(7.0 \text{ ppmvd})(20.95 - 0)/(20.95 - 3) = 8.17 \text{ ppmv NO}_x, \text{ dry @ 0\% O}_2$$

$$(8.17/10^6)(1 \text{ lbmol}/386.8 \text{ dscf})(46 \text{ lb NO}_2/\text{lbmol})(8743 \text{ dscf/MM Btu}) = \mathbf{0.0085 \text{ lb NO}_2/\text{MM Btu}}$$

Calculations shown below are based on emission factors submitted by the applicant.

The NO_x(as NO₂) mass emission rate based upon the maximum firing rate of the auxiliary boiler is calculated as follows:

$$(0.0083 \text{ lb/MM Btu})(50.6 \text{ MM Btu/hr}) = \mathbf{0.42 \text{ lb NO}_x(\text{as NO}_2)/\text{hr}}$$

CARBON MONOXIDE EMISSION FACTORS

The CO emissions from the auxiliary boiler during normal operation will be 10.0 ppmv, dry @ 3% O₂. This concentration is converted to a mass emission factor as follows:

$$(10.0 \text{ ppmv})(20.95 - 0)/(20.95 - 3) = 11.67 \text{ ppmv, dry @ } 0\% \text{ O}_2$$

$$(11.67/10^6)(\text{lbmol}/386.8 \text{ dscf})(28 \text{ lb CO}/\text{lbmol})(8743 \text{ dscf}/\text{MM Btu}) = \mathbf{0.00739 \text{ lb CO/MM Btu}}$$

Calculations shown below are based on emission factors submitted by the applicant.

The CO maximum mass emission rate based upon the maximum firing rate of the auxiliary boiler is calculated as follows:

$$(0.0073 \text{ lb/MM Btu})(50.6 \text{ MM Btu/hr}) = \mathbf{0.37 \text{ lb CO/hr}}$$

PRECURSOR ORGANIC COMPOUND (POC) EMISSION FACTORS

The POC emissions from the auxiliary boiler during normal operation will be 5.0 ppmv, dry @ 3% O₂. This concentration is converted to a mass emission factor as follows:

$$(5.0 \text{ ppmv})(20.95 - 0)/(20.95 - 3) = 5.36 \text{ ppmv, dry @ } 0\% \text{ O}_2$$

$$(5.36/10^6)(\text{lbmol}/386.8 \text{ dscf})(16 \text{ lb CH}_4/\text{lbmol})(8743 \text{ dscf}/\text{MM Btu}) = \mathbf{0.0019 \text{ lb POC/MMBtu}}$$

Calculations shown below are based on emission factors submitted by the applicant.

The POC mass emission rate based upon the maximum firing rate of the combined-cycle gas turbine is calculated as follows:

$$(0.0022 \text{ lb/MM Btu})(50.6 \text{ MM Btu/hr}) = \mathbf{0.11 \text{ lb POC/hr}}$$

PARTICULATE MATTER (PM₁₀) EMISSION FACTORS

The applicant has estimated PM emissions to be 0.007 lb/MMBtu.

$$(0.007 \text{ lb/MMBtu})(50.6 \text{ MMBtu/hr}) = \mathbf{0.35 \text{ lb PM}_{10}/\text{hr}}$$

SULFUR DIOXIDE EMISSION FACTORS

The sulfur emission factor is calculated as follows:

Natural Gas 1 grains of S/100 scf for Maximum Hourly

$$\text{SO}_2 = (1 \text{ gr S}/100 \text{ scf})(1 \text{ lb S}/7000 \text{ gr})(1/1020 \text{ BTU}/\text{scf})(1 \times 10^6 \text{ Btu}/\text{MMBtu})(64 \text{ lb SO}_2/32 \text{ lb S}) = 0.00280 \text{ lb}/\text{MMBtu}$$

Calculations shown below are based on emission factors submitted by the applicant.

Max Hourly SO₂

The corresponding SO₂ emission rate for the combined-cycle gas turbine firing:

$$(0.0028 \text{ lb SO}_2/\text{MM Btu})(50.6 \text{ MM Btu}/\text{hr}) = \mathbf{0.14 \text{ lb}/\text{hr}}$$

Toxic Air Contaminants from the auxiliary boiler were adjusted by the District in accordance with the memo from dated September 7, 2005 from Brian Bateman to the Engineering Division Staff regarding Emission Factors for Toxic Air Contaminants from Miscellaneous Natural Gas Combustion Sources (included at the end of this Appendix).

**TABLE A-3
TOXIC AIR CONTAMINANT EMISSIONS FROM
AUXILIARY BOILER**

Toxic Air Contaminant	Factor	Factor	Emissions		Trigger Levels	
	lb/MMBTU	lb/mmscf	lb/hr	lb/yr	lb/hr	lb/yr
Benzene	2.06E-06	2.10E-03	1.04E-04	0.45	2.9E+00	3.8E+00
Formaldehyde	7.35E-05	7.50E-02	3.71E-03	16.04	1.2E-01	1.8E+01
Sulfuric Acid	1.42E-03	1.45E+00	7.20E-02	0.16	2.6E-01	3.9E+01
Toluene	3.33E-06	3.40E-03	1.65E-07	0.73	8.2E+01	1.2E+04

Emergency Diesel-driven Fire Pump						
Manufacturer	Clarke					
Model	JW6H-UFAD80					
CARB-certified Tier 3	U-R-004-0369					
Operating Hours Per Year (hr/yr)	49					
From Manufacturer's Data						
Fuel Consumption Rate (gal/hr)	20		Calc MMBtu/hr = 2.78			
Brake Horsepower of Engine (HP)	400		MMBtu/year = 136			
From CARB/EPA Certified Data	Emission Factor	Emission Factor	Max. Hourly	Max. Daily	Annual	Annual
Pollutant	(g/kw-hr)	(g/hp-hr)	(lb/hour)	(lb/day)	Emissions (lb/yr)	Emissions (TPY)
NMHC+NOx	3.7	2.76				
NOx	3.52	2.62	2.311	55.47	113.26	0.0566
POC	0.19	0.14	0.122	2.92	5.96	0.0030
CO	0.9	0.67	0.592	14.20	29.00	0.0145
PM10 = PM2.5	0.16	0.119	0.105	2.53	5.16	0.0026
SO2*		0.004	0.004	0.09	0.18	0.00009
Note: * Assume complete conversion of sulfur in fuel to SO2						
15ppm ULSD						
Toxic Air Contaminant	Factor	Emissions		Trigger Levels		
	(g/hp-hr)	lb/hr	lb/yr	lb/hr	lb/yr	
Diesel PM	0.119	1.05E-01	5.16	-	0.34	

Hazardous Air Pollutants from Fire Pump Diesel Engine

HAPs were reviewed for Federal Major Source of Hazardous Air Pollutants applicability. Impacts to health were analyzed using diesel particulate matter as a surrogate. Emission factors are from California Air Toxics Emission Factors (CATEF) database.

SOURCEID	MATERIAL	SCC	TYPE	DESCRIPTION	CAS	SUBSTANCE	MEAN	UNIT	Annual HAP Emissions	
3246	Diesel	20200102	None	O2>13%	106-99-0	1,3-Butadiene	5.41E-03	lbs/Mgal	5.30E-03	lb/year
3251	Diesel	20200102	None	O2>13%	75-07-0	Acetaldehyde	1.07E-01	lbs/Mgal	1.05E-01	lb/year
3252	Diesel	20200102	None	O2>13%	107-02-8	Acrolein	1.30E-02	lbs/Mgal	1.27E-02	lb/year
3256	Diesel	20200102	None	O2>13%	71-43-2	Benzene	1.22E-01	lbs/Mgal	1.20E-01	lb/year
3220	Diesel	20100102	None	O2>13%	50-32-8	Benzo(a)pyrene	3.35E-03	lbs/Mgal	3.28E-03	lb/year
3222	Diesel	20100102	None	O2>13%	205-99-2	Benzo(b)fluoranthene	6.70E-03	lbs/Mgal	6.57E-03	lb/year
3226	Diesel	20100102	None	O2>13%	207-08-9	Benzo(k)fluoranthene	6.70E-03	lbs/Mgal	6.57E-03	lb/year
3227	Diesel	20100102	None	O2>13%	218-01-9	Chrysene	3.58E-03	lbs/Mgal	3.51E-03	lb/year
3229	Diesel	20100102	None	O2>13%	53-70-3	Dibenz(a,h)anthracene	3.49E-03	lbs/Mgal	3.42E-03	lb/year
3235	Diesel	20100102	None	O2>13%	50-00-0	Formaldehyde	1.11E+00	lbs/Mgal	1.09E+00	lb/year
3238	Diesel	20100102	None	O2>13%	193-39-5	Indeno(1,2,3-cd)pyrene	3.46E-03	lbs/Mgal	3.39E-03	lb/year
3240	Diesel	20100102	None	O2>13%	91-20-3	Naphthalene	5.64E-02	lbs/Mgal	5.53E-02	lb/year
3286	Diesel	20200102	None	O2>13%	108-88-3	Toluene	5.50E-02	lbs/Mgal	5.39E-02	lb/year
3289	Diesel	20200102	None	O2>13%	1330-20-7	Xylene (Total)	3.59E-02	lbs/Mgal	3.52E-02	lb/year
								Total	1.50E+00	lb/year

Sulfuric Acid Mist (H2SO4) Estimate								
7000	grain/lb							
1022	Btu/scf							
1000000	Btu/MMBtu							
32.07	Molecular weight of Sulfur							
64.06	Molecular weight of Sulfur dioxide							
98.08	Molecular weight of Sulfuric Acid							
Assumptions								
33.3	% SO2 converts to H2SO4	Conversion based on Guidance from the National Park Service						
2150	MMBtu/hour/turbine	http://www.nature.nps.gov/air/Permits/ect/ectGasFiredCT.cfm						
17698638.3	MMBtu/year/turbine							
50.6	MMBtu/hour/boiler							
218794.4	MMBtu/year/boiler							
grain Sulfur/100 scf	lb S/MMBtu	lb SO2/MMBtu	lb H2SO4/MMBtu	lb SO2/turbine/hour	lb SO2/turbine/year	tons SO2/turbine/year	lb H2SO4/turbine/hour	ton H2SO4/turbine/year
1	0.0014	0.0028	0.0014	6.00	49417.29	24.7086	3.0607	
0.25	0.0003	0.0007	0.0004	1.50	12354.32	6.3000	0.7652	3.15
grain Sulfur/100 scf	lb S/MMBtu	lb SO2/MMBtu	lb H2SO4/MMBtu	lb SO2/boiler/hour	lb SO2/boiler/year	tons SO2/boiler/year	lb H2SO4/boiler/hour	lb H2SO4/boiler/year
1	0.0014	0.0028	0.0014	0.14	610.91	0.3100	0.0720	0.16
							Project Total =	6.45
Example Calculations								
lb S/MMBtu = 1 grain S/100 scf x 1 lb/7000 grain x 1 scf/1022 Btu x 1E06 Btu/MMBtu = 0.0014 lb S/MMBtu								
lb SO2/MMBtu = 0.0014 lb S/MMBtu x 64.06/32.07 = 0.0028 lb SO2/MMBtu								
lb H2SO4/MMBtu = 0.0028 lb SO2/MMBtu x 98.08/64.06 x 0.10 = 0.0004 lb H2SO4/MMBtu								
lb H2SO4/turbine/hour = 0.0004 lb H2SO4/MMBtu x 2150 MMBtu/hr = 0.9191 lb H2SO4/turbine/hour								

Grain Loading Calculation									
CTG (each)									
PM-10 Maximum Emission Rate		7.74	lb/hr						
HHV Firing Rate		2150	MMBtu/hr						
F-factor*		8743	dscf/MMBtu						
lb =		7000	grain						
Corrected O2%		15	%						
Ambient Air O2 Concentration		20.9	%						
grains/dscf = (7.74 lb/hr x 7000 grains/lb)/(2150 MMBtu/hr x 8743 dscf/MMBtu x 20.9/(20.9 - corrected O2%))									
grains/dscf @ 15% O2=		0.0008137							
grains/dscf @ 6% O2=		0.0020548							
Boiler									
PM-10 Maximum Emission Rate		0.3542	lb/hr						
HHV Firing Rate		50.6	MMBtu/hr						
F-factor *		8743	dscf/MMBtu						
lb =		7000	grain						
Corrected O2%		3	%						
Ambient Air O2 Concentration		20.9	%						
grains/dscf = (0.3542 lb/hr x 7000 grains/lb)/(50.6 MMBtu/hr x 8743 dscf/MMBtu x 20.9/(20.9 - corrected O2%))									
grains/dscf @ 3% O2=		0.0048							
grains/dscf @ 6% O2=		0.0039955							
Fire Pump									
PM-10 Maximum Emission Rate		0.105	lb/hr						
HHV Firing Rate		2.78	MMBtu/hr						
F-factor*		9083	dscf/MMBtu						
lb =		7000	grain						
Corrected O2%		0	%						
Ambient Air O2 Concentration		20.9	%						
grains/dscf = (0.09 lb/hr x 7000 grains/lb)/(2.66 MMBtu/hr x 9048 dscf/MMBtu x 20.9/(20.9 - corrected O2%))									
grains/dscf =		0.0291687							
For compliance with Regulation 8-2-301 (15 lb VOC/day and 300 ppm C limit):									
POC (lb/day) =		2.92							
Actual exhaust flowrate (ft3/min)=		2214.00							
POC (lb/hr) =		0.12							
POC (ppm) = (0.122 lb/hr x 10 ⁶ x 386.8 ft3/lbmol)/(16 lb/lbmol x 2214 ft3/min*60 min/hr)									
POC (ppm) =		17632.05							
*Source: http://www.epa.gov/ttn/emc/promgate/m-19.pdf Equation 19-13									

Oakley Generating Station
Plant No. 19771
Application No. 20798
BAAQMD July 2010

Grain Loading Calculation

CTG (each)

PM-10 Maximum Emission Rate	7.74 lb/hr
HHV Firing Rate	2150 MMBtu/hr
F-factor*	8743 dscf/MMBtu
lb =	7000 grain
Corrected O2%	15 %
Ambient Air O2 Concentration	20.9 %

$\text{grains/dscf} = (9.0 \text{ lb/hr} \times 7000 \text{ grains/lb}) / (2150 \text{ MMBtu/hr} \times 8743 \text{ dscf/MMBtu} \times 20.9 / (20.9 - \text{corrected O2\%}))$

grains/dscf @ 15% O2= 0.000814

grains/dscf @ 6% O2= 0.002055

Boiler

PM-10 Maximum Emission Rate	0.3542 lb/hr
HHV Firing Rate	50.6 MMBtu/hr
F-factor *	8743 dscf/MMBtu
lb =	7000 grain
Corrected O2%	3 %
Ambient Air O2 Concentration	20.9 %

$\text{grains/dscf} = (0.3542 \text{ lb/hr} \times 7000 \text{ grains/lb}) / (50.6 \text{ MMBtu/hr} \times 8743 \text{ dscf/MMBtu} \times 20.9 / (20.9 - \text{corrected O2\%}))$

grains/dscf @ 3% O2= 0.0048

grains/dscf @ 6% O2= 0.003996

Fire Pump

PM-10 Maximum Emission Rate	0.105 lb/hr
HHV Firing Rate	2.78 MMBtu/hr
F-factor*	9083 dscf/MMBtu
lb =	7000 grain
Corrected O2%	0 %
Ambient Air O2 Concentration	20.9 %

$\text{grains/dscf} = (0.09 \text{ lb/hr} \times 7000 \text{ grains/lb}) / (2.66 \text{ MMBtu/hr} \times 9048 \text{ dscf/MMBtu} \times 20.9 / (20.9 - \text{corrected O2\%}))$

grains/dscf = 0.029169

For compliance with Regulation 8-2-301 (15 lb VOC/day and 300 ppm C limit):

POC (lb/day) = 2.92

Actual exhaust flowrate (ft3/min)= 2214.00

POC (lb/hr) = 0.12

POC (ppm) = $(0.122 \text{ lb/hr} \times 10^6 \times 386.8 \text{ ft}^3/\text{lbmol}) / (16 \text{ lb/lbmol} \times 2214 \text{ ft}^3/\text{min} \times 60 \text{ min/hr})$

POC (ppm) = 17632.05

*Source: <http://www.epa.gov/ttn/emc/promgate/m-19.pdf> Equation 19-13

Evaporative Fluid Cooler [Exempt from Air District Permits per Regulation 2-1-128.4]							
Max Operating Rate	5880	gal/min					
	352800	gal/hour					
Max drift rate	0.003%						
Max drift rate (lb of water/hour)	88.2	lb water/hr					
Max Total Dissolved Solids (TDS)	1500	mg/liter (ppm)					
Hours of Operation	24	hours/day					
	1500	hours/year					
Pollutant	Hourly lb/hour	Daily lb/day	Annual lb/yr	Annual tons/yr			
PM10/2.5	0.132	3.174	198.371	0.099			
Example Calculation							
$(352,800 \text{ gal/hr})(8.33 \text{ lb/gal})(0.003\%)(1500\text{ppm})/(10^6) = 0.132 \text{ lb PM/hr}$							
Toxic Air Contaminant	Initial Concentration in Water ppm*	Average Cycles of Concentration*	Concentration in Drift Water ppm	Emissions		Trigger Levels	
				lb/hr	lb/yr	lb/hr	lb/yr
Arsenic	0.069	3	0.207	1.83E-05	2.74E-02	4.40E-04	7.20E-03
Copper	0.177	3	0.531	4.68E-05	7.03E-02	2.20E-01	None
Lead	0.0497	3	0.1491	1.32E-05	1.97E-02	None	3.2
*provided by Applicant. Amended AFC Table 5.1A-7							
For compliance with Regulation 6-1-311:							
Emission limit (lb/hr) = 4.10 Process weight ^{0.67}							
Process weight = 352800 gal/hour x 8.33 lb/gal = 2938824 lb/hr = 1469.4 ton/hr							
Emission limit = (4.10)(1469.4 ^{0.67}) = 542.96 lb PM/hour							

Oil-Water Separator [Exempt from Air District Permits per Regulation 2-1-103.1 and 8-8-113]					
Max Operating Rate		120	gal/hr		
		0.12	1000 gal/hr		
Hours of Operation		24	hours/day		
		365	day/year		
Pollutant	Emission Factor lb/1000 gallons	Hourly lb/hour	Daily lb/day	Annual lb/yr	Annual tons/yr
VOC*	0.2	0.024	0.576	210.240	0.105
*Emission Factor from AP-42, Section 5.1 Petroleum Refining,					
Table 5.1-2 Fugitive Emission Factors For Petroleum Refineries - Oil/Water Separators controlled emissions, 1/95					

Memorandum
September 7, 2005

To: Engineering Division Staff

From: Brian Bateman
Director of Engineering

Subject: Emission Factors for Toxic Air Contaminants from Miscellaneous
Natural Gas Combustion Sources

This memorandum serves to provide guidelines on the emission factors to use to calculate toxic air contaminant (TAC) emissions from miscellaneous natural gas combustion sources. When site specific or source category specific emission factors are not available, the following emission factors shall be used to calculate TAC emissions from miscellaneous natural gas combustion sources:

TAC Emission Factors for Miscellaneous Natural Gas Combustion		
TAC	Emission Factor, lbs/Mscf	Emission Factor, lbs/therms *
Benzene	2.1 E-6	2.06 E-7
Formaldehyde	7.5 E-5	7.35 E-6
Toluene	3.4 E-6	3.33E-7

* based on 1020 Btu/scf

These emission factors are taken from AP42 Table 1.4-3, Emission Factors for Speciated Organic Compounds from Natural Gas Combustion, and are those for which a reasonable number of sources had been tested and the tests were performed using sound methodology. AP42 emission factors for PAHs are not used because they are based on single tests in which the speciated PAH emissions were found to be below detection levels. AP42 emission factors for metal emissions are not used because they are based on a small number of tests and have poor EPA data quality ratings. CATEF factors are not used because there was inadequate data, the data quality was poor, or the quality of AP42 data was better. Based on the data from their websites, neither Ventura nor San Diego APCD use metal emission factors and except for naphthalene, neither uses any other speciated or benzo(a)pyrene equivalent PAH emission factor.

BFB:SBL:jhl

Appendix B

Health Risk Assessment Results

INTEROFFICE MEMORANDUM
AUGUST 12, 2010

TO: Kathleen Truesdell

Via: Scott B. Lutz
Daphne Y. Chong

FROM: Glen Long

SUBJECT: Results of Health Risk Screening Analysis for Contra Costa Generating Station LLC [also known as Oakley Generating Station] (Oakley, CA), Combined Cycle Power Plant, Plant #19771, Application #20798

Per your request, we have completed a health risk screening analysis for the above referenced permit application. The analysis estimates the incremental health risk resulting from toxic air contaminant (TAC) emissions from the operation of two gas powered turbines, an auxiliary boiler, a three-cell evaporative condenser, and a fire pump. Results from the health risk screening analysis indicate that the project maximum cancer risk is estimated at 1.56 in a million, a chronic non-cancer hazard index of 0.0832, and an acute hazard index of 0.2665. The risk from each source individually is below 1.0 in a million maximum individual cancer risk and the chronic hazard index is less than 0.20. In accordance with the District's Regulation 2, Rule 5, this source is in compliance with all project risk requirements.

EMISSIONS: TAC emission were obtained from your August 10, 2010 emissions spreadsheet for the facility. Table I summarizes these emissions.

MODELING: The AERMOD air dispersion computer model was used to estimate maximum one-hour and annual average ambient air concentrations. AERMET was used to create two sets of five years of data with the Contra Costa Power meteorological data (2001-2002 and 2004-2006; 2003 did not meet the EPA required data recovery rates). The first set, Contra Costa Power (CCP), was processed using the land use characteristics around the meteorological tower. The second set was also created with the Contra Costa Power meteorological data, but the site characteristics around the proposed project site were used. All maximum impacts occurred using the CCGS data. Stack and building parameters for the analysis were based on information provided by the applicant.

HEALTH RISK: AERMOD results were imported into HARP using the HARP on-ramp module and the latest version of HARP (version 1.4a) was used to predict all health impacts. Estimates of residential risk assume potential exposure to annual average TAC concentrations occur 24 hours per day, 350 days per year, for a 70-year lifetime. The HARP option "Derived (Adjusted) Method" was used for calculating residential cancer risks. Risk estimates for offsite workers assume potential exposure occurs 8 hours per day, 245 day per year, for 40 years. The HARP default exposure assumptions were used for calculating worker cancer risks. Cancer risk adjustment factors (CRAFs) were used to calculate all cancer risk estimates. The CRAFs are age-specific weighting factors used in calculating cancer risks from exposures of infants, children and adolescents, to reflect their anticipated special sensitivity to carcinogens. There are no schools located within 1000 feet of the facility. Shown in Figures 1-4 are the cancer risk and the chronic hazard index for both residents and workers. Shown in Figure 5 is the acute hazard index. The estimated health risks for this permit application at the Point of Maximum Impact (PMI) are presented in Table II. Shown in Table III is the maximum cancer risk from each source. Because the cancer risk for each source is less than 1.0 in one million and the chronic hazard index for each source is less than 0.20, and because the total project risk is less than 10 in one million and the project chronic hazard index and acute hazard index are less than 1.0, the project complies with all of the toxic risk requirements of District Regulation 2, Rule 5.

Table I: Maximum Oakley Generating Station TAC emissions.

	Turbines		Boiler		Evaporative Cooler		Firepump	
	Max 1- hour Emissions per turbine including tuning (lb/hr)	Max Annual lb/yr	Max 1- hour Emissions lb/hr	Max Annual lb/yr	Max 1- hour Emissions per cell (lb/hour)	Max Annual per cell (lb/yr)	Max 1- hour Emissions lb/hour	Max Annual lb/yr
Toxic Air Contaminant								
1,3-Butadiene	2.672080E-04	2.199342E+00						
Acetaldehyde	2.693120E+00	2.476060E+03						
Ammonia	1.466053E+01	1.206682E+05	0.000000E+00	0.000000E+00				
Benzene	5.386240E-02	2.314390E+02	1.039500E-04	4.491900E-01				
Benzo(a)anthracene	4.755040E-05	3.913789E-01						
Benzo(a)pyrene	2.924560E-05	2.407153E-01						
Benzo(b)fluoranthene	2.377520E-05	1.956894E-01						
Benzo(k)fluoranthene	2.314400E-05	1.904942E-01						
Chrysene	5.302080E-05	4.364048E-01						
Dibenz(a,h)anthracene	4.944400E-05	4.069648E-01						
Ethylbenzene	6.859040E-02	3.113176E+02						
Formaldehyde	9.741520E+00	8.318029E+03	3.712500E-03	1.604250E+01				
Hexane	5.449360E-01	4.485271E+03						
Indeno(1,2,3-cd)pyrene	4.944400E-05	4.069648E-01						
Naphthalene	3.492640E-03	2.874730E+01						
Propylene	1.622184E+00	1.335191E+04						
Propylene Oxide	1.005712E-01	8.277837E+02						
Toluene	2.066128E-01	1.232017E+03	1.648350E-07	7.272600E-01				
Xylene (Total)	5.491440E-02	4.519907E+02						
Sulfuric Acid Mist (H2SO4)	3.061071E+00	6.397629E+03	7.203230E-02	1.557338E-01				
Arsenic					6.085800E-06	9.128700E-03		
Copper					1.561140E-05	2.341710E-02		
Lead					4.383540E-06	6.575310E-03		
Diesel PM							1.052157E-01	5.155457E+00


Table II. Maximum project health effects.

Receptor	Cancer Risk	Chronic Non-cancer Hazard Index	Acute Hazard Index
Resident	1.56 chances in a million	0.0832	0.2665
Worker	0.14 chances in a million	0.0790	

Table III. Maximum cancer risk from each source.

Source	Maximum Residential/Worker Cancer Risk from source
North Turbine	0.70 in a million
South Turbine	0.65 in a million
Auxiliary Boiler	0.03 in a million
Evaporative Cooler	0.39 in a million
Fire Pump	0.73 in a million

Figure 1: Oakley Generating Station Residential Cancer Risk




Met data:CCGS
August 12, 2010

Figure 2: Oakley Generating Station Worker Cancer Risk




Met data:CCGS
August 12, 2010

Figure 3: Oakley Generating Station Residential Chronic HI



Met data:CCGS
August 12, 2010

Figure 4: Oakley Generating Station Worker Chronic HI



Met data:CCGS
August 12, 2010

Figure 5: Oakley Generating Station Acute HI



Met data:CCGS
August 12, 2010

Appendix C

District Response to Comments on the Preliminary Determination of Compliance

Responses to Public Comments

Final Determination of Compliance

Oakley Generating Station

Bay Area Air Quality Management District
Application Number 20798

January 2011

The Bay Area Air Quality Management District (District) has received comments regarding the District's Preliminary Determination of Compliance (PDOC) for the proposed Oakley Generating Station. The District has considered all comments that were submitted, and has made a final determination that the proposed project meets all applicable District Regulations as well as applicable State and Federal regulatory requirements. The public comments received on the Preliminary Determination of Compliance are addressed below. The District appreciates the public's interest and values the public's input into this permitting process.

CONTENTS

I. BEST AVAILABLE CONTROL TECHNOLOGY	1
Comment I.1 – Startup Emissions Control Technology	1
Comment I.2 – Combustor Tuning	1
Comment I.3 – Facility Commissioning and Initial Source Testing	2
II. OFFSETS	3
Comment II.1	3
III. POTENTIAL ENVIRONMENTAL AND HEALTH IMPACTS	5
Comment III.1 – Health Risk Assessment.....	5
Comment III.2 – Ammonia Emissions	6
Comment III.3 – Nitrogen Deposition Impact on Antioch Dunes.....	7
Comment III.4 – Regulatory Consistency with the San Joaquin Valley Air District Offset Requirements	8
Comment III.5 –Air Quality Impacts From Water, Heat and Carbon Dioxide Emissions	10
Comment III.6 – Effects of Natural Gas Use.....	10
IV. FEDERAL AIR QUALITY PERMITTING REQUIREMENTS	11
Comment IV.1. – Federal PSD Requirements.....	11
Comment IV.2. – Analysis of Impacts on Federal National Ambient Air Quality Standards.....	15
Comment IV.3 – PM _{2.5} Non-Attainment NSR Issues.....	15
Comment IV.4 – PSD Requirements for Greenhouse Gases.....	16
Comment IV.5 – Federal Guidance on Greenhouse Gas Considerations in PSD BACT Determinations.....	17
V. COMMENTS REGARDING OTHER FEDERAL STATUTES	17
Comment V.1 – Coastal Zone Management Act, Clean Air Act, and Endangered Species Act	18
VI. ENVIRONMENTAL JUSTICE.....	18
Comment VI.1 – Environmental Justice Concerns.....	18
VII. MONITORING	20
Comment VII.1 – Ammonia CEM	20
VIII. COMMENTS REGARDING PERMITTING PROCESS AND PUBLIC PARTICIPATION	20
Comment VIII.1 – Energy Commission Licensing Authority.....	20

Comment VIII.2 – Public Notice and Outreach Regarding the Determination of Compliance Process	22
Comment VIII.3 – Public Comment Process.....	22
Comment VIII.4 – Time Periods for Determination of Compliance and Permit Issuance	23
Comment VIII.5 – Public Hearing Request.....	24
Comment VIII.6 – Information on Permit Appeals.....	24
Comment VIII.7 – Exceedances of Permit Limits and Enforcement Action	25
IX. MISCELLANEOUS COMMENTS, CLARIFICATIONS AND TYPOGRAPHICAL ERRORS	26
Comment IX.1 – Project Description	26
Comment IX.2 – Equipment Specifications	27
Comment IX.3 – Clarification of Maximum Hourly Formaldehyde Emission Rate....	27
Comment IX.4 – Formatting of Footnote 10	28
Comment IX.5 – Typographical Error.....	28
Comment IX.6 – Electric Reliability Requirements	28

I. BEST AVAILABLE CONTROL TECHNOLOGY

Comment I.1 – Startup Emissions Control Technology

The District received comments citing the District’s explanation in the PDOC regarding Fast-Start Technology, which the District explained is now a feasible technology for reducing start-up emissions. The comments generally agreed with the District’s explanation in the PDOC. The comments criticized statements the District made regarding a different facility in February of 2010, however, in which the District stated that, as of February of 2010, no other facility to date had been equipped with a “Rapid Response CC” facility (a similar application for combined-cycle turbines).

Response: The District agrees with the comments suggesting that the District was correct in its description of Fast-Start Technology, and does not find anything in the comments to suggest that this description needs to be changed. The District is not making any changes to the Determination of Compliance based on this comment.

With respect to comments regarding statements from February of 2010 regarding a different facility, those comments have no bearing on the District’s Determination of Compliance for the proposed Oakley Generating Station. Moreover, the comments criticized those earlier statements and implied that the District was incorrect in February of 2010 and was correct in the Oakley PDOC. Thus, to the extent that there is anything in these comments that could be relevant here, the District reads the comments as suggesting that the District should follow the position it took in the PDOC, and not any other allegedly inconsistent position from February of 2010. These comments therefore further support the District’s conclusion that nothing in the PDOC needs to be changed on this issue.

Furthermore, the District disagrees that there has been anything inconsistent or inaccurate in any statements it has made in connection with any other facility, including the statements from February of 2010 referenced in these comments. The District was correct in stating that, as of February of 2010, no other facility had been equipped with a fast-start system; this is a new technology that has only recently been developed. The position the District took in February of 2010 was challenged in permit appeals filed by both of the commenters who submitted comments here (among other appellants), and all such challenges were rejected. For all of these reasons, nothing in the comments about the District’s analysis of another facility in February of 2010 provides any reason for the District to alter its Preliminary Determination of Compliance in any way on this issue.

Comment I.2 – Combustor Tuning

The applicant commented that per manufacturer’s estimates, tuning of the gas turbines proposed for Oakley Generating Station is expected to take up to eight hours due to the included model-based control system requiring detailed tuning over the entire operating range after turbine components are replaced. The comment did not request an increase in the daily emissions limit in connection with being allowed to take up to 8 hours to

complete a tuning event; the applicant has committed to maintaining the same overall daily emissions limits with the 8-hour tuning allowance. The applicant also stated that requiring a 7-day advance notice to the District prior to combustion tuning could result in an unreasonable loss of availability for power generation, especially in instances of component failure or unscheduled maintenance. The applicant suggested a 24-hour advance notification requirement instead.

Response: The District agrees with the comment that the tuning provision should reasonably allow up to 8 hours to complete a tuning event. According to GE, the turbine manufacturer, the 7FA.05 turbines that the applicant intends to use are equipped with a sophisticated model-based control (MBC) system and will be able to continuously and automatically tune themselves during normal operations using its established model-based set points and controls. Manual tuning will be required under certain infrequent circumstances, however, such as where combustion turbine components have to be replaced. In these situations, it may be necessary to reset the model-based controls to reflect the new hardware conditions, and this may require a detailed retuning of the combustion turbine over the entire operating range. The tuning set points will then be saved in the plant's control system algorithms. This manual tuning is expected to take as long as 8 hours in total to complete, according to GE's estimates.¹ Based on this information, the District agrees with this comment and has modified proposed condition part 17 and the relevant parts of the FDOC to allow 8 hours for each tuning event in accordance with manufacturer estimates. The District has not made any changes to the total daily emissions limits for days with tuning operations.

With regard to the advance notice to the District about a tuning event, the District agrees there will potentially be situations where the owner/operator could not have anticipated 7 days in advance that they would need to conduct tuning activities (for example, after unplanned maintenance resulting from unforeseen equipment malfunction). The District is therefore requiring a 7-day advance notice except in exigent circumstances, whereupon the District is requiring notification as early as is reasonably possible under the circumstances, and at least 24 hours in advance of the tuning activity, with details of the circumstances why the full 7-day notice is not possible. The District has modified proposed condition part 17 to reflect this requirement.

Comment I.3 – Facility Commissioning and Initial Source Testing

The applicant requested that the timing of the initial source testing of the gas turbines be allowed to be within 90 days “or as otherwise approved by the APCO” since commissioning could take longer than 90 days. The applicant also suggested noting on Table 15: Commissioning Schedule for Oakley Generating Station that the durations and emissions in the table are totals for both units.

The Energy Commission also requested clarification about when the normal operating

¹ See Letter from P. Bukunt, GE Energy, to K. Truesdell, BAAQMD, Dec. 1, 2010, re “Contra Costa Generating Station (Oakley) – Preliminary Determination of Compliance Combustion Turbine Tuning”.

limits apply to the gas turbines.

Response: The District agrees that commissioning of a large project such as Oakley Generating Station may take longer than 90 days and agrees that it may not be feasible to conduct the initial source testing of the gas turbines within 90 days after they are first fired. The District is therefore inserting language in the proposed source testing conditions to allow the facility to conduct the initial source testing more than 90 days after startups under appropriate circumstances, subject to approval by the APCO, if the District determines source testing within 90 days is not feasible. The District has modified source testing conditions (parts 24 through 28 in the FDOC) to reflect this possibility.

Regarding the suggested clarification in Table 15, the District agrees that an explanation would clarify that the table refers to the totals for both units and has added this information below Table 15.

Regarding the CEC's comment on how the commissioning limits would apply, the District intends the normal operating limits to apply after the abatement devices are installed and fully functional and is allowing 831 total hours for commissioning activities without abatement or with partial abatement. Any commissioning activities conducted after the 831 hours are subject to the normal operating limits. The District has revised the definition of "Commissioning Period" to specify that the Commissioning Period for each gas turbine ends when that gas turbine has reached safe and reliable steady-state operation as demonstrated by compliance with NO_x and CO normal operating limits using the continuous emissions monitors (CEMs). The gas turbines will be required to be in compliance with normal operating limits by the end of the District's definition of Commissioning Period (*i.e.*, after 831 hours of commissioning activities), and compliance will be monitored with the CEMs; however, source testing may be conducted after since further commissioning activities, pointed out by the Energy Commission to last up to 1725 hours, will continue to occur. The District has also moved condition part 10 in the PDOC to condition part 26 in the FDOC with the other source test conditions to reduce confusion as to when the District's Commissioning Period limits end.

II. OFFSETS

Comment II.1

Energy Commission staff commented that the Determination of Compliance is required to identify the specific offsets that the applicant intends to use to satisfy the applicable offset requirements, and that it must "demostrat[e] that any ERCs are held or proposed to be surrendered by [the applicant]." Commission staff stated that in accordance with the Warren-Alquist Act, Public Resources Code Section 25523(d)(2), the Determination of Compliance should identify specific offsets and should provide "information . . . that indicates any ERCs are in the applicant's control."

Response: The District respectfully disagrees with Energy Commission staff’s characterization of what is required in the Determination of Compliance under Section 25523(d)(2). Section 25523(d)(2) provides that the commission must “require as a condition of certification that the applicant obtain any required emission offsets *within the time required by the applicable district rules*, consistent with any applicable federal and state laws and regulations, and prior to the commencement of the operation of the proposed facility.” (emphasis added). It also provides that the Commission must determine that the facility will satisfy applicable offset requirements based on one of two alternative bases: (i) a demonstration by the District that sufficient offsets “have been identified and will be obtained by the applicant within the time required by the district’s rules”; or (ii) a demonstration by the District that that “the applicant requires emissions offsets to be obtained prior to the commencement of operation” of the facility. The Commission can make its determination under either of these alternative provisions without a demonstration that the applicant already owns or controls the offsets it intends to use. Both of these alternatives contemplate the applicant “obtaining” the offsets (*i.e.*, bringing the offsets within the applicant’s ownership or control) after the time that the Determination of Compliance is issued. The first alternative speaks of obtaining the offsets by the time that they are required by District rules, which (with certain exceptions) is at the time of issuance of the Authority to Construct. See District Regulation 2-2-302 (requiring that ERCs must be surrendered by the time the District issues the Authority to Construct). The second alternative speaks of obtaining the offsets prior to commencement of operation. Neither of these requires that the Commission find that the offsets are “held” by the applicant or “in the applicant’s control” before it can issue its licensing decision, nor do they demonstrate an expectation that the District will make such a showing in the Determination of Compliance.

Nevertheless, in response to Commission staff’s interest in ensuring that the applicant will in fact be able to provide sufficient offsets at the time required by applicable regulatory requirements, the District explored further with the applicant which specific offsets it intends to use to comply with the District’s offset requirements. The applicant has obtained option contracts for the purchase of specific credits to offset the levels of POC and NO_x emissions specified in the Final Determination of Compliance. The credits have been transferred to an escrow agent, who is holding them in trust for delivery to the applicant, when and if the project is approved and goes forward, under the terms of the option contracts. This arrangement ensures that the credits are presently within the applicant’s control such that they will be able to be surrendered before the District issues the Authority to Construct in accordance with District regulations. The specific credits are described in the table below:

<u>Banking Certificate Number</u> ²	<u>Pollutant</u>	<u>Credits</u>	<u>Company that Banked the Credits</u>	<u>Location</u>	<u>Original Issue Date</u>
1241	POC	20.79	New United Motor Manufacturing, Inc	Fremont	10/03/1986
1242	POC	18.47	New United Motor Manufacturing, Inc	Fremont	08/12/1996
1245	POC	103.84	New United Motor Manufacturing, Inc	Fremont	10/06/1993

The District also notes that if the Energy Commission believes that it needs to impose additional requirements in its license beyond what is required by District rules, it certainly has the power to do so under the Warren-Alquist Act. Nothing in the District's regulations would prohibit the Commission or its staff from requiring the applicant to submit additional information or documentation about its offsets, or to impose additional requirements about when offsets need to be obtained as conditions of certification.

III. POTENTIAL ENVIRONMENTAL AND HEALTH IMPACTS

Comment III.1 – Health Risk Assessment

The District received comments criticizing the District's health risk assessment for this facility. The comments stated that the health risk assessment did not consider the potential health impacts from fine particulate matter from the project. The comments also stated that no other agency, including the CEC, has considered the potential health impacts of fine particulate matter. The comments also stated that the health risk assessment did not consider the cumulative impacts of the emissions from this facility along with emissions of other facilities in the area of public health, and failed to address characteristics of the specific populations in the vicinity of the project that make them more vulnerable to health impacts from air pollution.

Response: Health risks associated with fine particulate matter is a rapidly-evolving area of scientific understanding, and it is only recently that this pollutant has come under heightened regulatory scrutiny. The Office of Environmental Health Hazard Assessment (OEHHA), the agency that sets the health risk assessment that the state's air districts use in their permit evaluations, is planning to develop new procedures to address fine particulate matter and to incorporate them into its health risk assessment guidelines that are used by air districts. The District intends to participate in the public process to develop future updates to the risk assessment guidelines and procedures. These guidelines have not been developed at this stage, however, and so the District's currently applicable

² The District changes the Banking Certificate Number when it is transferred. The Banking Certificate Number of these same credits, when they are transferred to Oakley and then surrendered, will be different from the numbers listed in this table.

regulatory procedures do not require an analysis of fine particulate matter in Health Risk Assessments.

Regarding cumulative health risks from this project in conjunction with other nearby emissions sources, the District evaluated cumulative health impacts based on the District's updated CEQA guidelines, which have expanded the District's policy on when toxic emissions will be considered to have a cumulatively significant impact.³ This analysis demonstrated that the cumulative impacts for health and fine particulate matter are below the thresholds of significance under the District's policy.⁴ Note in particular that the District's CEQA guidelines specifically address fine particulate matter concerns, in addition to health risks in general. The District would be happy to provide further input into the CEC's CEQA-equivalent environmental review on these issues.

Regarding the comment that the populations in the areas near the project may have heightened sensitivities that could make them more vulnerable to health impacts from air pollution, the District's Health Risk Assessment is designed to take individuals with heightened sensitivities into account. The Reference Exposure Levels on which the Health Risk Assessment analysis is based are established at levels that take into account sensitive populations (with an appropriate margin of safety), and there is no reason to conclude that any populations would experience any significant risk of adverse health effects where TAC concentrations will be below these levels, as is the case here.

Comment III.2 – Ammonia Emissions

The District received comments stating that the facility will have the potential to emit up to 120 tpy of ammonia, and that the District should evaluate the potential environmental impacts from ammonia emissions. In particular, the comments were concerned about potential impacts on the formation of secondary PM_{2.5}. The comments suggested that the District should evaluate the secondary PM_{2.5} impacts of the proposed Oakley facility's ammonia emissions in conjunction with ammonia emissions from the Marsh Landing and Gateway facilities.

Response: The impacts of ammonia emissions on secondary PM_{2.5} formation is a rapidly evolving area both in terms of the technical understanding of the issue and in terms of adopting regulatory approaches to it. There is currently no regulatory requirement for the District to perform an analysis of the impacts of ammonia on the formation of secondary PM_{2.5}, although the District is continuing to study PM_{2.5} and its precursors, including ammonia, to develop a SIP-approved program for reducing PM_{2.5}. The District is imposing a stringent ammonia slip limit for Oakley Generating Station and has included an option to require an ammonia CEMS in the future. Actual emissions of ammonia may be lower than estimated and the APCO will re-evaluate the ammonia slip limit after more

³ See BAAQMD *California Environmental Quality Act Air Quality Guidelines*, December 2010 (available at: <http://www.baaqmd.gov/Divisions/Planning-and-Research/CEQA-GUIDELINES/Updated-CEQA-Guidelines.aspx>)

⁴ See BAAQMD *Summary of CEQA Cumulative Impact Analysis for Permit Application 20798, Oakley Generating Station*, January 20, 2011.

information is available from the CEMS. These measures will minimize ammonia emissions from the facility, and thereby minimize any impacts that the facility could have on secondary PM_{2.5} formation as a result of its ammonia emissions.

In addition, the CEC has evaluated secondary PM_{2.5} impacts in its environmental review, including recommending “limiting ammonia slip emissions to the extent feasible to avoid unnecessary ammonia emissions”.⁵ For Oakley Generating Station, this means limiting ammonia slip emissions to 5 ppmvd, which is consistent with what the District is proposing as a condition of approval.

Comment III.3 – Nitrogen Deposition Impact on Antioch Dunes

The District received comments stating that ammonia and NO_x emissions from the proposed Oakley facility, in conjunction with emissions from the Marsh Landing and Gateway projects, could have nitrogen deposition impacts on the Antioch Dunes National Wildlife Refuge (NWR). The comments cited comments from the United States Fish & Wildlife Service (FWS) that the Oakley facility must provide mitigation for nitrogen deposition impacts on the Antioch Dunes.

Response: The District shares the commenters’ concerns about endangered species impacts. Endangered species impacts are addressed under the Endangered Species Act through the incidental take permit process in conjunction with FWS oversight, as well as more generally under CEQA. Those concerns are being addressed by the FWS and the California Department of Fish and Game with respect to this facility, as evidenced by the FWS’s letter in the CEC proceeding and by the CEC’s consideration of the issue in its CEQA-equivalent licensing process. These concerns do not implicate anything in the air quality regulatory requirements that are the subject of the Determination of Compliance, however. The District is therefore not making any changes to the Preliminary Determination of Compliance based on these comments. But the District encourages commenters to engage in the CEC process, as well as with the FWS, on the issue of nitrogen deposition in the Antioch Dunes NWR. The CEC is addressing nitrogen deposition at the Antioch Dunes NWR in the Biological Resources section of the Staff Assessment. CEC staff has taken into consideration and responded to the comments from FWS regarding the Antioch Dunes NWR⁶ and reviewed the responses from the applicant regarding nitrogen deposition in Response to CEC Staff Data Requests #68-73.⁷ CEC staff has recommended mitigation measures in condition BIO-19, which requires annual payment to Friends of San Pablo Bay to assist in noxious weed (the greatest threat to the

⁵ See CEC Oakley Generating Station Preliminary Staff Assessment – Part B, CEC-700-2011-001 PSA-PTB, January 2011 at p. 4.1-30. (PSA Part B) (available at: <http://www.energy.ca.gov/2011publications/CEC-700-2011-001/CEC-700-2011-001-PSA-PTB.PDF>)

⁶ PSA Part B at pp. 4.2-49 to 4.2-51.

⁷ See Radback Energy Supplemental Filing Response to CEC Staff Data Requests 68 through 73, May 2010. (available at:

[http://energy.ca.gov/sitingcases/oakley/documents/applicant/2010-07-14 Applicants Response to Data Requests 68-73 TN-56640.pdf](http://energy.ca.gov/sitingcases/oakley/documents/applicant/2010-07-14%20Applicants%20Response%20to%20Data%20Requests%2068-73%20TN-56640.pdf))

endangered species at the NWR⁸) management of the Antioch Dunes National Wildlife Refuge in an amount proportional to the project's expected contribution to nitrogen deposition.⁹

Comment III.4 – Regulatory Consistency with the San Joaquin Valley Air District Offset Requirements

The District received comments stating that emissions from the proposed Oakley facility, along with emissions from three other existing or proposed power plants in the District's jurisdiction, could be transported in the atmosphere into the San Joaquin Valley. The comments listed the total annual criteria pollutant emissions potential for each project and calculated a percentage of the emissions that could "impact" the San Joaquin Valley, and then summed each of these percentages to estimate a "total impact" from these projects in the San Joaquin Valley. The comments then cited the transport mitigation requirements in 17 CCR sections 70600 and 70601 adopted to address ozone transport issues, which the comments characterize as requiring upwind districts (1) to consult with downwind neighbors and adopt "all feasible measures" to control emissions of ozone precursors; and (2) to amend their "no net increase" thresholds for permitting so that they are equivalent to those of their downwind neighbors. The comments went on to claim that the District's permitting regulations do not satisfy these requirements because the San Joaquin Valley Air Pollution Control District's (SJVAPCD's) offset thresholds are lower than the District's; and because the SJVAPCD's regulations increase the required offset ratios depending on the distance between the location at which the offsets were created and the location at which they will be used, which the District's regulations do not.

Response: The District disagrees with the commenter's interpretation of the 17 CCR sections 70600 and 70601. Section 70600 applies specifically to ozone precursors (NO_x and reactive organic gases). Per section 70600(b)(2), the San Francisco Bay Area Air Basin shall:

- “(A) require the adoption and implementation of all feasible measures as expeditiously as practicable.
- (B) require the adoption and implementation of best available retrofit control technology, as defined in Health and Safety Code section 40406, on all existing stationary sources of ozone precursor emissions as expeditiously as practicable.
- (C) require the implementation, by December 31, 2004, of a stationary source permitting program designed to achieve no net increase in the emissions of ozone precursors from new or modified stationary sources that emit or have the potential to emit 10 tons or greater per year of an ozone precursor.
- (D) include measures sufficient to attain the state ambient air quality standard for ozone by the earliest practicable date within the North Central Coast Air Basin, that portion of Solano County within the Broader Sacramento Area, that portion of Sonoma County within the North Coast Air Basin, and that portion of Stanislaus County west of Highway 33, except as provided in the Health and

⁸ PSA Part B at p. 4.2-39.

⁹ PSA Part B at p. 4.2-73.

Safety Code section 41503(d), during air pollution episodes which the state board has determined meet the following conditions:

- (i) are likely to produce a violation of the state ozone standard in the North Central Coast Air Basin, or that portion of Solano County within the Broader Sacramento Area, or that portion of Sonoma County within the North Coast Air Basin, or that portion of Stanislaus County west of Highway 33;
- (ii) are dominated by overwhelming pollutant transport from the San Francisco Bay Area Air Basin; and
- (iii) are not measurably affected by emissions of ozone precursors from sources located within the North Central Coast Air Basin, or that portion of Solano County within the Broader Sacramento Area, or that portion of Sonoma County within the North Coast Air Basin, or that portion of Stanislaus County west of Highway 33.”

As described in the District’s 2010 Clean Air Plan (CAP), the 2010 CAP control strategy, together with the District rule development and permitting processes, address the requirement to adopt all feasible measures, including measures sufficient to attain the State ozone standard in specified transport areas, and to implement best available retrofit control technology on all existing stationary sources.¹⁰

With respect to the no-net-increase requirement, the District adopted a 10 ton per year no-net-increase requirement for ozone precursors (NO_x and POC) in Regulation 2, Rule 2 on December 21, 2004.¹¹ This District permitting requirement satisfies Section 70600; that section does not require the District to adopt the same offset requirements as downwind districts as the comments claim. The Districts permitting programs comply with all aspects of Sections 70600 and 70601. The District consulted with downwind air districts, as required by §70600(c)(1), to ensure the CAP control strategy includes all feasible measures.¹²

The District also sought comment from neighboring districts regarding the PDOC for Oakley Generating Station and did not receive any comments. Other districts are also welcome to participate in the CEC licensing process for the project.

¹⁰ See BAAQMD *Bay Area 2010 Clean Air Plan Volume 1*, September 15, 2010, at p. C-2 to C-3. (available at: <http://www.baaqmd.gov/~media/Files/Planning%20and%20Research/Plans/2010%20Clean%20Air%20Plan/CAP%20Volume%20I%20%20Appendices.ashx>)

¹¹ See BAAQMD Regulation 2 Permits, Rule 2 New Source Review, section 302 at p. 2-2-11. (available at: <http://www.baaqmd.gov/~media/Files/Planning%20and%20Research/Rules%20and%20Regs/reg%2002/r0202.ashx>)

¹² See *Bay Area 2010 Clean Air Plan Volume 1*, September 15, 2010, at p. C-3.

Comment III.5 –Air Quality Impacts From Water, Heat and Carbon Dioxide Emissions

The District received comments concerning the global warming effects of water vapor emissions from the facility, and questioning whether water vapor, carbon dioxide or heat emitted from the facility could have adverse local impacts.

Response: Water vapor in the atmosphere is a contributor to the greenhouse effect. The entirety of all human activity has only a small effect on the amount of atmospheric water vapor, however;¹³ and the bulk of this small effect comes from changes in land use (such as extensive irrigation), not from power plants.¹⁴ The District notes that there are large amounts of naturally occurring water vapor in the atmosphere, and the water vapor emissions from this facility will be relatively small by comparison. In addition, the water vapor from the facility will be released with a high temperature and at a sufficient height that it will be dispersed widely and it is unlikely that ambient conditions near the plant would be impacted. In short, there is no indication whatsoever that water vapor emissions from this facility could have any significant adverse impacts, either locally or globally.

Similarly, there is no indication that carbon dioxide emissions from this single facility will have any significant adverse impacts, either locally or globally, and the comments have not pointed to any.

The impact of any one facility on local or regional ambient temperatures would be minimal. Ambient temperatures are governed by climatic factors that are far larger than any impact that could arise from the heat exhausted from any single facility (or even from multiple facilities combined), and there is nothing in this comment to suggest otherwise. The District does not believe there is any need to evaluate temperature impacts from this facility, and notes that there is no regulatory requirement to do so.

The District does not see any reason why water vapor, heat, or carbon dioxide would have adverse local impacts and there is nothing in the comment to suggest otherwise. Moreover, the comments have not pointed to any regulatory requirement that would be implicated by greenhouse gas, water, or heat emitted by the facility that could impact the conclusions the District is making in the Determination of Compliance in any way. The District therefore finds no reason to make any changes to its Preliminary Determination of Compliance based on these comments.

Comment III.6 – Effects of Natural Gas Use

The District received comments stating that the District should consider “life cycle air quality effects” of natural gas use. In what appears to be a related point, the comments

¹³ Contribution of Working Group I to the Fourth Assessment Report of the Intergovernmental Panel on Climate Change, 2007, Chapter 2 Changes in Atmospheric Constituents and Radiative Forcing at p. 135 (available at: http://www.ipcc.ch/publications_and_data/ar4/wg1/en/contents.html)

¹⁴ Contribution of Working Group I to the Fourth Assessment Report of the Intergovernmental Panel on Climate Change, 2007, Chapter 2 Changes in Atmospheric Constituents and Radiative Forcing at p. 185.

stated that the District should “consider the effects of LNG [presumably liquefied natural gas] use”, and in particular potential effects related to the use of imported LNG.

Response: The District is interested in the carbon intensity (as well as the intensity of emissions of other pollutants) of various sources of natural gas, but there is no District regulatory requirement to perform a ‘life-cycle analysis’ for the Oakley project. Concerns such as this are primarily issues related to how California is going to meet its energy needs as a state, not with how a specific facility such as this one will comply with applicable air pollution regulations, which is the subject of the Determination of Compliance. Other expert agencies concerned with electricity supply policy, such as the CEC, CPUC, and ARB, are performing studies on the life cycle analysis and carbon intensity of various sources of natural gas including LNG.

The proposed Oakley Generating Station will utilize natural gas supplied by PG&E. The proposed facility will utilize modern combustion controls that will be able to be adjusted to account for any changes in the source of the natural gas supplied by PG&E and post-combustion emission controls that will ensure compliance with applicable permit limits regardless of the source of natural gas supplied.

IV. FEDERAL AIR QUALITY PERMITTING REQUIREMENTS

Comment IV.1. – Federal PSD Requirements

The District received comments stating that the proposed Oakley Generating Station should be subject to the federal “Prevention of Significant Deterioration” (PSD) requirements of 40 C.F.R. section 52.21. The comments noted the District’s discussion of PSD applicability in the PDOC, which explained that the facility’s emissions are below the applicability thresholds for the PSD requirements, but objected to that conclusion. The comments stated that the District should treat the proposed Oakley facility as a modification to PG&E’s Gateway facility, as well as PG&E’s nearby natural gas terminal. The comments stated that the Oakley facility will be sold to PG&E after construction, and that two nearby plants ultimately owned by the same company (PG&E here) should be treated as a single facility. The comments stated that if the proposed Oakley facility is treated as a modification to the existing Gateway facility (and natural gas terminal), instead of a new stand-alone facility, then as a modification it would be subject to PSD requirements.

The comments also stated that the Marsh Landing Generating Station, which is not owned by PG&E, should also be considered part of the same facility as the proposed Oakley facility. The comments stated that as a modification to this existing facility the proposed Oakley facility would be subject to PSD requirements, for similar reasons to those stated for the Gateway facility as discussed above. The comments did not claim that the Marsh Landing facility is owned by PG&E (it is owned by Mirant Marsh Landing, LLC, an indirect wholly-owned subsidiary of Mirant Corporation), but they implied that it is “contractually linked to provide power under contract to PG&E.” The comments implied that all of these facilities may be “part of a larger strategy that would

support the conclusion that they operate as one source.” The comments stated that under such circumstances, treating the facilities as separate sources would contravene the intent of the PSD provisions of the Clean Air Act. The comments stated that the District should evaluate “long term plans for ownership and operation of individual projects, information on contractual agreements and voting interests, or contracts for service among owners and operators” to evaluate this claim.

Finally, the comments also expressed a concern generally that the construction of separate facilities that are not subject to federal PSD permitting requirements individually “is circumventing the level of protection that Congress intended in crafting the PSD program.” The comments claimed that “the District appears to be enabling this pattern” by approving these facilities without PSD permits, and also noted that the District has received an application for another power plant, the Willow Pass Generating Station, that it is currently considering. These comments implied that emissions from all of these facilities should be treated together for permitting purposes, which would mean that they would be subjected to the requirements of the federal PSD program.

Response: The District has reviewed the points raised in these comments and has found nothing that would alter its conclusion that the facilities mentioned above should be treated as separate facilities under applicable EPA guidance on implementing the federal PSD permitting requirements.

At the outset, the comments are correct that PG&E, the owner of the Gateway facility, will likely eventually own the Oakley facility. To the extent that the issue of whether the two plants should be treated as a single “facility” for purposes of the PSD requirement is forward-looking (*i.e.*, to the extent that the question of ownership is decided based on a future date instead of the date of permitting or facility construction), then PG&E would be considered the ultimate corporate parent of both plants. The District has not found any specific guidance from EPA on this particular issue. But ultimately the issue is moot because EPA guidance establishes that where the plants are operated as completely separate entities, they should not be treated as a single “facility” even if they did have the same ultimate corporate parent.

EPA has established on a number of occasions that “[i]f facilities can provide information showing that the new sources has no ties to the existing source, or vice versa, then the new source is most likely a separate entity under its own control,”¹⁵ even where they are contiguous or adjacent and are subject to the same ultimate ownership. For example, EPA has found that two gasoline bulk terminals that were operated independently, had separate fuel and utility pipelines, were not interconnected, and could continue to operate with no substantial change if the other were to shut down, were separate “facilities” even though they were adjacent and under common ownership.¹⁶ Similarly, EPA has found that two adjacent power plants under common ownership were separate “facilities” where

¹⁵ See Letter from W. Spratlin, EPA, to P. Hamlin, Iowa Dep’t of Nat. Resources (Sept. 18, 1995).

¹⁶ See Letter from EPA Region 4 to Mecklenburg County Dep’t of Env’tl Protection (May 19, 1999).

they would not share the same transmission lines, fuel supply contracts, power sales contracts, gas metering stations, or connections to water and wastewater systems.¹⁷ EPA has also found that a landfill and a collocated power plant were separate “facilities” where they did not share common equipment, compliance responsibilities, intermediates, products, byproducts, or payroll activities or other administrative functions.¹⁸

The Oakley Generating Station and the Gateway Generating Station will be operated as separate plants in exactly the same manner as in these earlier cases. The proposed Oakley plant will be built at a completely different location from the Gateway plant, approximately half a mile away on the other side of Highway 160. It will have separate natural gas supply connections, separate transmission line connections, separate gas metering, separate water and wastewater connections, a separate control room, and a separate fire protection system. It will be operated as a completely separate entity dispatched by the California Independent Systems Operator, and its operation will not depend in any way on operation of the Gateway facility. It is being developed separately from the Gateway facility, has independent contractual arrangements covering the sale of its power output, and will have independent economic viability. Thus, regardless of whom the ultimate owner of the Oakley plant is, it is clear that the two plants will be operating as separate, independent operations and should not be treated as a single common “facility” as EPA applies that term in the PSD context.¹⁹

Notably, the District was recently faced with a similar question of whether two separate power plants that were located next to each other on the same piece of land should be treated as a single, common “facility” for PSD purposes. The issue arose in connection with the Mirant Marsh Landing facility, which is being built as a replacement for – and right next to – another Mirant facility, the existing Contra Costa Power Plant. The issue was a considerably closer question in that case, as the two plants were essentially on the same exact site, and not half a mile apart on opposite sides of a major highway as in the situation the District is presented with currently. The District concluded that the Marsh Landing plant and Contra Costa Power Plant were separate “facilities” for PSD permitting because they would be operated as completely separate, independent entities under EPA’s guidance. Mirant and the District sought concurrence from EPA Region 9, and Region 9 expressed no disapproval and no indication that it would need to take any enforcement action if Mirant goes ahead with its plans and builds the Marsh Landing facility without a PSD permit. Since EPA condoned Mirant’s plans to build the plant without a PSD permit in that case, the District can see no reason why EPA Region 9 would object to the applicant’s plans to build the Oakley facility without a PSD permit in this case.

¹⁷ See Letter from D. Cole, EPA, to G. Cooper & R. McKay (Oct. 12, 2001).

¹⁸ See Letter from J. Katz, EPA, to G. Graham, Virginia Dep’t of Env’tl Quality (May 1, 2002).

¹⁹ See also generally Letter from D. Farabee, Pillsbury Winthrop Shaw Pittman LLP, to G. Rios, EPA Region 9, and B. Bateman, BAAQMD, January 5, 2011 (presenting the applicant’s input on the issue of whether the proposed Oakley project is a “modification” to any existing facility).

The District has also sought EPA Region 9's express concurrence in the District's determination that the proposed Oakley Generating Station is not a modification to an existing facility and is not subject to PSD requirements. The District does not expect that EPA Region 9 will disagree, as noted above, but EPA Region 9 has not had time to prepare a formal response. The District is therefore going ahead and issuing the Final Determination of Compliance with a determination that the facility will not need a PSD permit. Should EPA subsequently disagree and conclude that the facility will need a PSD permit, that will trigger a separate PSD permitting process. That is, the applicant will need to submit a PSD permit application to the District and the District will need to process that application in accordance with the federal PSD requirements in 40 C.F.R. section 52.21. Since the PSD permitting process can be undertaken separately from the Determination of Compliance and CEC licensing process if need be – and importantly, since the facility cannot be built without a PSD permit if EPA determines that one is required, regardless of how far along the CEC licensing proceeding is – the District finds no need to hold up issuance of the Final Determination of Compliance pending final confirmation from EPA Region 9. Moreover, the District notes that there is no requirement that the District obtain EPA Region 9's concurrence in a determination that the federal PSD requirements do not apply to a project before going ahead and issuing a Determination of Compliance.

For all of these reasons, the District has concluded that the Oakley Generating Station should not be treated as a modification to the existing Gateway Generating Station and is issuing its Final Determination of Compliance on that basis. The District has also concluded that the Oakley Generating Station should not be treated as a modification of PG&E's nearby Antioch natural gas terminal, for similar reasons. The Antioch natural gas terminal is a completely separate operation and should not be treated as a single common "facility" for PSD permitting purposes under the EPA guidance discussed above. Moreover, the natural gas terminal is not a "major" facility under the PSD program. The Oakley project therefore would not be a "major modification" to an existing major facility that would trigger PSD permitting even if it were treated as a modification to the natural gas terminal (which it is not, as explained above).

Furthermore, regarding other facilities owned by other entities that ultimately sell power to PG&E for distribution to its customers, such as Mirant's Marsh Landing facilities, such facilities are clearly separate facilities for purposes of PSD permitting. Not only are they sited at different locations and operated separately and independently from the proposed Oakley Generating Station, they are not even owned by a common ultimate corporate parent. The facilities are therefore lacking an additional element of the commonality required to find that sources are part of the same "facility" under 40 C.F.R. section 52.21(b)(6). Indeed, if completely separate facilities located at completely different locations and owned by completely different companies were the same "facility" simply by virtue of the fact that they fed into a common distribution system, then essentially all of the power plants in California would be part of a single enormous "facility". There is no indication that EPA intended for this regulatory term to apply in such a broad manner, and none of the comments has cited any.

Finally, with respect to the contention that the District is somehow circumventing the will of Congress in applying EPA's rules regarding major facilities that are subject to PSD permitting, the District notes that it was Congress itself that created the 100-ton "major source" threshold. In doing so, Congress clearly understood and intended that facilities with emissions below this level would not need to get "major source" permits even if they are located in the same geographical area and are engaged in similar operations. The District therefore disagrees with these comments, and believes that it is in fact implementing this permitting program exactly as Congress has directed.

Comment IV.2. – Analysis of Impacts on Federal National Ambient Air Quality Standards

The District received comments suggesting that it should conduct an analysis of the facility's impacts on ambient air quality in relation to the National Ambient Air Quality Standards. The comments suggested that the District should issue a revised PDOC, and publish a public notice, that includes such a demonstration.

Response: Analyzing impacts on National Ambient Air Quality Standards is a requirement of PSD permitting, which as explained above is not applicable for this facility. The District therefore disagrees that any such analysis is required here. The Energy Commission is addressing potential impacts on National Ambient Air Quality Standards as part of its CEQA-equivalent environmental review, however. For any emissions that will contribute to a violation of any such standard, the CEC is proposing to require mitigation at a ratio of at least one-to-one so that any new emissions will be mitigated by a corresponding reduction.²⁰ The public is encouraged to participate in the CEC proceeding on this issue.

Comment IV.3 – PM_{2.5} Non-Attainment NSR Issues

The District received comments regarding the applicability of the federal Non-Attainment New Source Review (Non-Attainment NSR) requirements in 40 C.F.R. Part 51, Appendix S (Appendix S). These comments were similar to the comments on the federal PSD requirements. The comments stated that the District should treat the proposed Oakley Generating Station as a modification of an existing source (or sources), and not as a separate new source, for reasons similar to those put forward in the PSD context. The comments stated that if the District were to treat the facility as a modification of an existing facility instead of as a new facility in its own right, then as a modification it would be subject to Appendix S permitting requirements for PM_{2.5}. The comments stated that treating the facility as a separate facility would contravene the intent of Appendix S. The comments also stated that no PM offsets are being provided for this facility.

Response: As discussed in the response to Comment IV.1, the District has concluded that Oakley Generating Station is a separate source and not a modification any existing source. Appendix S therefore does not apply since emissions of PM_{2.5} from Oakley

²⁰ PSA Part B at pp. 4.1-30 and 4.1-43.

Generating Station are less than 100 TPY, which is the threshold for Appendix S applicability.

With regard to the provision of PM offsets, the District disagrees that any PM offsets are required, because the facility is not subject to Appendix S and so any offset requirements in Appendix S cannot be applicable. Similarly, the facility does not trigger PM offsets under District regulations, which require PM₁₀ offsets for facilities with emissions over 100 tons per year. This facility's PM₁₀ emissions will be well below this level. The District notes, however, that the CEC will be requiring mitigation under CEQA for the particulate matter emissions from this facility, which may be in the form of offsets.²¹

Comment IV.4 – PSD Requirements for Greenhouse Gases

The District received comments stating that the District should include conditions in the FDOC requiring the facility to begin construction by July 1, 2011, in order that the facility will not be subject to PSD permitting requirements for greenhouse gases. July 1, 2011, is the date on which PSD regulation becomes applicable for facilities with greenhouse gas emissions over 100,000 tons per year that do not otherwise need a PSD permit. The comments stated that the FDOC should contain explicit permit conditions stating that the facility must commence actual construction by this date in order for PSD permitting for greenhouse gases to be inapplicable.

Response: Although the District is not aware of any definitive guidance from EPA interpreting the new greenhouse gas PSD regulations stating that facilities that have received non-attainment NSR permits issued before July 1, 2011, have to begin construction by that date in order not to be subject to PSD permitting requirements, that is how the District understands EPA's program to work. The District therefore agrees with this interpretation of the new greenhouse gas regulations, although obviously if EPA issues guidance to the contrary the District will follow that guidance. The District disagrees that the proposed Oakley Generating Station should have explicit permit conditions requiring it to commence construction before this date, however. The PSD requirements exist in 40 C.F.R. Section 52.21 independent of any permit conditions, and the proposed Oakley Generating Station will be subject to any applicable PSD requirements regardless of any such conditions. Adding specific permit conditions on this issue is therefore not necessary to ensure that the PSD requirements are complied with, and adds no benefit in terms of clarity or enforceability of the applicable regulatory requirements. Moreover, the new greenhouse gas PSD regulations do not impose an absolute requirement that this facility to commence construction by July 1, 2011. To the contrary, the regulations would allow the facility to delay construction until after that date; they would merely require (as the District currently understands them) that the facility obtain a PSD permit under Section 52.21 in order to do so. The District is therefore not making any changes to the PDOC as a result of these comments.

²¹ PSA Part B at pp. 4.1-35 and 4.1-48.

Comment IV.5 – Federal Guidance on Greenhouse Gas Considerations in PSD BACT Determinations

The District received comments citing a federal guidance document on how agencies issuing federal PSD permits should take potential greenhouse gas emissions into account when they select their BACT technologies. The comments cited the guidance's explanation that in selecting a BACT technology for a federal PSD Permit, federal regulations require the permitting agency to "take into account energy, environmental, and economic impacts," which can include greenhouse gas emissions associated with the technology. The comments cited the guidance's direction that energy efficiency should be taken into account when reviewing available pollution control methods because energy efficiency is normally related to greenhouse gas emissions efficiency as well as being related to emissions of criteria pollutants. The comments acknowledged that the federal PSD BACT requirement was (at the time of the comments) not applicable to greenhouse gases, but stated that BACT technology choices for other pollutants can indirectly result in lower greenhouse gas emissions through the use of more efficient production processes.

Response: This federal guidance applies to federal PSD permits. This facility is not subject to federal PSD permit requirements, as noted above, and the District is not proposing to issue a PSD permit and has not conducted a PSD BACT analysis as part of its Determination of Compliance. These comments are therefore not relevant here. Moreover, even if the guidance were applicable here, the comments have not suggested that there is any way that the District could have made any of its BACT technology determinations differently in any way that could have resulted in lower greenhouse gas emissions. The District evaluated a number of technologies in its Determination of Compliance, and the comments have not identified any areas in which there may be preferable technologies that could have lower emissions that the District should have considered instead. The District also notes that the CEC addresses power plant efficiency and greenhouse gases in its Staff Assessment. The CEC concludes that "[w]hile [Oakley Generating Station] will consume substantial amounts of energy, it will do so in the most efficient manner practicable"²² and that "[c]ompared to the other existing power plants that remain in place to provide local reliability and that OGS would be likely to displace, the proposed OGS would be more efficient, and emit fewer GHG emissions during any hour of operation."²³

V. COMMENTS REGARDING OTHER FEDERAL STATUTES

²² See CEC Oakley Generating Station Preliminary Staff Assessment – Part A, CEC-700-2010-019 PSA-PTA, December 2010 at p. 5.3-1 (PSA Part A). (available at: <http://www.energy.ca.gov/2010publications/CEC-700-2010-019/CEC-700-2010-019-PSA-PTA.PDF>)

²³ PSA Part B at p. 4.1-82.

Comment V.1 – Coastal Zone Management Act, Clean Air Act, and Endangered Species Act

The District received comments stating that the project appears to violate the Coastal Zone Management Act, the Clean Air Act, and the Endangered Species Act. The comments assert that the project appears to require a Prevention of Significant Deterioration (PSD) permit under the Clean Air Act. Beyond this assertion, the comments do not specify any way in which the commenters believe that the facility would violate any of these statutes, other than that it “appears” to do so.

Response: Concerns regarding the applicability of the Clean Air Act’s PSD permitting requirements are discussed above in response to Comment IV.1. Beyond this specific concern, the comment does not cite any additional requirement of the Clean Air Act that this facility may not comply with, and the District is not aware of any. As discussed in the District’s Determination of Compliance, the District has evaluated all applicable air quality requirements and has determined that, with appropriate conditions, the proposed facility will comply with them. With respect to other statutory requirements unrelated to air quality such as the Coastal Zone Management Act and the Endangered Species Act, those are concerns for the Energy Commission to evaluate in its general environmental review that it is undertaking for this project, as well as for other agencies such as the Coastal Commission or the Fish and Wildlife Service, as appropriate. The District notes in connection with these concerns that the comments have not cited any specific area in which the proposed facility could potentially violate any requirements of these statutes, and the District is not aware of any.

VI. ENVIRONMENTAL JUSTICE

Comment VI.1 – Environmental Justice Concerns

The District received comments citing guidance issued by the federal Council on Environmental Quality for evaluating environmental justice concerns under Executive Order 12898 in connection with federal administrative actions. The comments stated that the guidance discusses five steps involved in undertaking an environmental justice analysis and that the District should evaluate each of these five individual steps in detail as part of its environmental justice analysis. The comments noted that the District stated in the environmental justice discussion in the PDOC that Executive Order 12898 is not applicable to this facility because it is a federal executive order that applies only to federal agency actions, but they disagreed with this conclusion because they claim that the facility should in fact be subject to federal PSD permitting requirements (and federal non-attainment NSR requirements for PM_{2.5}) as discussed above.²⁴ The comments

²⁴ The comments also cited the definition of environmental justice in California Government Code section 65040.12, which defines environmental justice as the fair treatment of all races, cultures and incomes with respect to the development, adoption, implementation and enforcement of environmental laws, regulations and policies. The District absolutely supports this environmental justice policy. The District’s environmental justice evaluation in the Determination of Compliance supports this policy, and the comments have not provided any reason to suggest that it does not.

contended that the District should not conclude that the fact that there will be no significant adverse impacts to any community necessarily means that there will be no significant adverse impacts to an environmental justice community. The comments stated that drawing this conclusion in this way would “back load” the environmental justice analysis, and that the District needs to address each of the five specific steps the commenter outlines before concluding that there would be no adverse impact on any environmental justice community. Some comments also implied that the District would still go forward with permitting a facility even if there would be significant adverse impacts, implied that the District does not take environmental justice concerns seriously, and implied that the District uses a different threshold for considering health risks in considering impacts on environmental justice communities than it does for other communities.

Response: The comments are correct that federal Executive Order 12898 applies only to federal permitting actions, and that no federal permits are required for this facility. The District has responded to claims that federal PSD and PM_{2.5} Non-Attainment NSR permits should be required in response to comments IV.1. and IV.3.; as stated there, the District disagrees with these comments. The District therefore disagrees that it is required to strictly follow the cited guidance, and disagrees that there is anything erroneous in its conclusion that the facility will not have any significant adverse impact on any environmental justice community. Moreover, even if the District did follow the guidance, the results of such an exercise could not affect the District’s ultimate conclusion.

The District’s health risk assessment concluded that the facility would not have any significant adverse impact on any community. Thus, even if the District conducted an in-depth evaluation of the specific communities in the vicinity of the plant and found that there are environmental justice communities, it would conclude that there would not be any significant adverse impacts to such communities. The District believes that this is a sensible, conservative way to address potential environmental justice concerns, and disagrees with the characterization of it as somehow “back loading” the analysis. The District further notes that the CEC staff assessment uses the cited guidance documents to determine whether there are any affected environmental justice communities and by the demographic screening analysis criteria in the guidance documents, there are none.²⁵

As for the comments that the District does not take environmental justice issues seriously, the District strongly disagrees. The District is committed to equity in air quality decisions for everyone throughout the Bay Area. The District has and will exercise its discretion to promote environmental justice in all of its permitting decisions, and it applies the same stringent standards in protecting public health in environmental justice communities as it does in every other community.

²⁵ See CEC Oakley Generating Station Preliminary Staff Assessment – Part B, CEC-700-2011-001 PSA-PTB, January 2011 at pp. 1-5 to 1-6. (available at: <http://www.energy.ca.gov/2011publications/CEC-700-2011-001/CEC-700-2011-001-PSA-PTB.PDF>)

VII. MONITORING

Comment VII.1 – Ammonia CEM

The Energy Commission suggested the District consider including the option of requiring a continuous emissions monitor for compliance verification with the ammonia emission concentration limit. The Commission pointed out that the District recently included a similar requirement in its proposed conditions for another power plant project.

Response: The District agrees with this comment and has included the option for the District to require a continuous emissions monitor (CEM) for ammonia on one turbine if the APCO determines that a commercially available CEM has been proven to be accurate and reliable and that an adequate Quality Assurance/Quality Control protocol for the CEM has been established. The District or other agency must establish a District-approved Quality Assurance/Quality Control protocol prior to the ammonia CEM being required. Proposed condition part 15(e) includes this requirement.

VIII. COMMENTS REGARDING PERMITTING PROCESS AND PUBLIC PARTICIPATION

Comment VIII.1 – Energy Commission Licensing Authority

The District received comments stating that the discussion of the CEC approval process should clarify that the CEC cannot “modify” the District’s determination of whether and how a proposed power plant will comply with applicable air quality requirements, but can only “override” the District’s conclusions pursuant to its primacy over power plant permitting matters under the Warren-Alquist Act.

Other comments questioned whether the Energy Commission has authority over “the District SIP”, and over “the District’s responsibility under the Clean Air Act”. The comments questioned if the District is required to issue an ATC and whether the CEC license (or FDOC) could confer the legal authority to construct a CEC-licensed power plant. The comments questioned what would happen if the District declined to participate in this licensing proceeding. One commenter asked what permit fees the District will receive if the facility is permitted, compared to how much it will receive if it is not permitted.

Response: The District agrees that the Energy Commission cannot change the District’s determination of whether and how the facility will apply with applicable requirements, in the sense that the District’s determination is its own judgment on these issues, and the Energy Commission cannot change the District’s mind if it disagrees. But as the comments acknowledge, under the Warren-Alquist Act the CEC has exclusive jurisdiction over power plant licensing, and that authority supersedes any District authority on air-quality related issues. Under this exclusive authority, the Energy Commission has final say over air quality compliance and the appropriate air quality

related permit conditions to which the facility will be subject. The District does not find anything in the language it used in the PDOC that is inconsistent with this regulatory situation as described in these comments and the District's response.

The remainder of these comments asked questions about how the power-plant licensing process and the cooperation between the District and Energy Commission works; they did not raise any substantive concerns about the PDOC or suggest that the District should modify its preliminary determination or should not issue a Final Determination of Compliance. There is therefore nothing of substance in these comments to which to respond. Nevertheless, in order to provide the public with as much information as possible regarding the permitting process, the District provides the following responses. Regarding the comments about the CEC's authority over "the District SIP", and over "the District's responsibility under the Clean Air Act", the CEC has authority over power plant licensing, which supersedes any District authority under state law in this area. The Energy Commission does not have authority over the District to compel the District to do anything (or refrain from doing anything it is authorized to do); its authority simply supersedes any District authority over power plant permitting such that the District cannot regulate in that area (although it can take limited actions consistent with the CEC's license, such as issuing an Authority to Construct after the CEC issues its license). Regarding whether the District is required to issue an ATC or whether the CEC license (or FDOC) could confer legal authority to construct a CEC-licensed power plant, some California air districts have chosen to allow the energy commission license (or FDOC) to be deemed to provide legal authorization to construct a power plant for purposes of those districts' regulations. These districts' rules work differently than the Bay Area District's rules, in that the District goes ahead and issues its own ATC after the CEC issues its license. The Bay Area District could have taken a different course with its power plant regulations, but chose not to. Regarding what would happen if the District chose not to participate in the CEC's proceedings, this is a hypothetical question because the District supports the CEC's process and is committed to participating in that process and helping the CEC address air quality-related issues regarding power plant licensing. Moreover, the District has adopted regulations providing for its participation in the CEC process, and the District follows those regulations. If for some reason the District did not participate, however, the CEC would be left to address air-quality-related issues by itself. Finally, regarding permit fees, the District's fee schedule is set forth in District Regulation 3.²⁶ The District receives application fees at the time of permit application, which it uses to defray the costs of processing the application (among other costs). These fees are normally not refunded if the permit is not issued and are subject to the Regulation 3-305 Cancellation or Withdrawal provision. If the facility is constructed and operated, it will need to obtain a District Permit to Operate, and it will need to submit permit fees in connection with that permit as well. The permit to operate will need to be renewed periodically, and fees will need to be submitted for the renewals as well.

²⁶ Regulation 3 is available on the District's website at www.baaqmd.gov/~media/Files/Planning%20and%20Research/Rules%20and%20Regs/reg%2003/reg03_061610.ashx.

Comment VIII.2 – Public Notice and Outreach Regarding the Determination of Compliance Process

The District received comments inquiring into the extent of the public notice and outreach that the District has conducted for this Determination of Compliance. The comments inquired in particular as to whether the District has sent a notice to “the CEC list(s)” or caused a notice to be published in the CEC licensing proceeding for this facility.

Response: The District conducted a very robust public outreach effort, which went well above the minimum required by law and which was designed to ensure that as many interested members of the public as possible were informed about the District’s preliminary determination. The District published notices in English and Spanish in the *Contra Costa Times* and in Spanish in *El Mensajero*, issued a Media Advisory and Fact Sheet, sent written notices to the CEC, ARB, the regional office of the EPA and adjacent districts and the City of Oakley, and sent via e-mail and/or hard copy the notice to parties it had identified who may have had an interest in the PDOC. The CEC posted the Preliminary Determination of Compliance and Errata Sheet on the Documents and Reports page for the Oakley Generating Station as well as sent out a listserve notice to those subscribed to the CEC Oakley list. In addition, to make public review and comment easier, the District posted online the Public Notice, PDOC, Errata Sheet, administrative record documents cited in PDOC footnotes that were not readily available online, and other supporting documents. These efforts more than satisfied the applicable public notice requirements for a PDOC, which are set forth in District Regulations 2-3-404 and 2-2-405.

Comment VIII.3 – Public Comment Process

The District received comments expressing confusion as to why the CEC and the District are both providing comment periods regarding the proposed Oakley Generating Station. These comments claimed not to understand the nature of the public comment periods being provided by these two agencies. They also asked whether there is any authority that requires the District to respond to comments, and if so what is that authority?

Response: The District explained the power plant permitting process, including the roles of the District and Energy Commission, in Section 2 of the PDOC, and is including a similar discussion in the FDOC being issued in conjunction with this Response to Comments document. The District provides its public comment opportunities in order to solicit input from members of the public regarding the air quality issues that are the subject of the Determination of Compliance. The CEC provides its public comment opportunities in order to solicit input from the public on all issues related to power plant licensing, from air quality issues to other environmental issues such as water quality, hazardous materials, potential wildlife habitat issues, etc., to all other types of issues such as land use, traffic, or socioeconomic issues. The District’s public comment procedures require that the District consider all public comments it receives before taking final action. The procedures do not explicitly require that the District provide a written response to such comments, but the District is responding in writing to all comments received and explaining to the commenters whether the District agrees or disagrees with

the comments and why. The District values the input from members of the public on these issues and appreciates the time that they devote to providing it.

Comment VIII.4 – Time Periods for Determination of Compliance and Permit Issuance

The District received comments regarding deadlines applicable to District processing of determinations of compliance and permit issuance for facilities such as this one, and what these time limits are based on. The comments asked what the effect would be if the District was not able to meet these deadlines. The comments also asked how long a Determination of Compliance and ATC remain valid. The comments also asked what authority governs the renewal of an ATC after it has expired, and whether there is any regulatory requirement that requires a public comment period for a renewal of an ATC.

Response: The District is required to make a determination within 20 days after receiving an application for a power plant whether the application has sufficient information to make a Determination of Compliance. Once the District accepts an application as complete, it then has 180 days in which to issue the Preliminary Determination of Compliance. The District must publish a notice for the Preliminary Determination of Compliance and then provide the public with an opportunity to comment on it, which must be at least 30 days. The District must then issue the Final Determination of Compliance within 240 days of accepting the application as complete (or notify the CEC that it cannot issue a Final Determination of Compliance). These time periods are based on District Regulation 2, Rule 3, Sections 403 through 405 (which incorporate by reference some provisions of Regulation 2, Rule 2). The District strives to meet these timelines under all circumstances, but it is possible that given the District's workload and limited resources that in a particular instance the District may not do so. In that case, the permit applicant would have a right to request that the District expedite its permit review for that project and complete it as quickly as is reasonably possible.

Regarding how long Determinations of Compliance and ATCs remain valid, a Determination of Compliance remains valid as long as the Energy Commission wants to use it. The Energy Commission normally completes its licensing proceeding and makes a licensing decision shortly after the District issues a Determination of Compliance, so the ongoing validity of the Determination of Compliance is not normally a concern. If the Energy Commission were to delay its proceeding for some reason, and the continuing validity was a concern, it could always ask the District to review or update the Determination of Compliance to ensure that it is current. For ATCs, they remain valid for a period of two years from the date of issuance. An ATC may be renewed after it has expired pursuant to District Regulation 2-1-407, provided that the permitholder submits a written request and pays the applicable application fee before expiration and the renewal satisfies current BACT and offset requirements (unless the permitholder has begun substantial use of the ATC, in which case the requirements for current BACT and offsets do not apply). There is no regulatory requirement for a public comment period for the renewal of an ATC. (Note that the District is not undertaking any renewal actions at this stage, and this information is being provided here simply as a matter of public

information in response to requests for information in the public comments that the District received.)

Comment VIII.5 – Public Hearing Request

The District received requests from two individuals that the District hold a public hearing for this Determination of Compliance. One of the requests claimed that a hearing is warranted because several of the issues involved in this project are “complicated”, including issues regarding potential transport of pollutants to the San Joaquin Valley, issues regarding the applicability of PSD requirements, and concerns about two other facilities in the vicinity of this project. The other request did not assert any reason why a public hearing would be warranted for this project.

Response: The District has considered these requests and does not believe that a public hearing would be warranted for this project. The District received requests for a public hearing from only two members of the public. Neither of these commenters has identified any reason why they would need an additional opportunity to comment verbally, and the District has not found any (especially given that these two individuals are sophisticated commenters who have engaged permitting agencies on air quality issues at a high level and are experienced at submitting comments in writing). The fact that issues involved in the Determination of Compliance may be “complicated” does not necessarily mean that a public hearing is needed in order to adequately address them, in addition to a written comment opportunity. For all of these reasons, the District disagrees that there is a need for a public hearing for this Determination of Compliance. The District also notes that the Energy Commission provides for public hearings related to all aspects of the licensing of this facility, including air quality and all other issued, and that these commenters will have the opportunity for verbal input there.

Comment VIII.6 – Information on Permit Appeals

The District received comments stating that the Determination of Compliance should include a discussion about how members of the public may appeal the issuance of an Authority to Construct for this facility to the District’s Hearing Board, including procedures and deadlines for filing an appeal, the costs that would be associated with an appeal, and the regulations that govern appeals. The District also received comments along similar lines asking what recourse a commenter would have if it was dissatisfied with the District’s response to its comments.

Response: The District refers these commenters generally to the provisions of the Warren-Alquist Act, and in particular of Public Resources Code section 25531, establishing that the sole and exclusive avenue for appealing power plant permitting approval issues (for power plants over 50 MW and subject to the Warren-Alquist Act) is on direct review of the Energy Commission’s licensing decision to the California Supreme Court. A number of courts and other authorities have established based on this statute that an appeal based on any such issue can be brought only through a direct appeal to the Supreme Court of the CEC’s licensing decision on that issue. It is not the District’s place to provide legal advice to commenters or other members of the public as to what legal remedies may be available to them with respect to specific projects or issues. The

District therefore refers the commenters to these legal principles in general, and advises them to consult legal counsel of their own choosing with respect to evaluating their legal position in any particular circumstance. The District also notes that there is no regulatory requirement that information on appeal avenues be specified in detail in the Determination of Compliance.

Comment VIII.7 – Exceedances of Permit Limits and Enforcement Action

The District received comments seeking information on what agency (or agencies) has enforcement authority in the event that the facility violates any permit conditions. The comments asked whether any other facilities in Contra Costa County have violated permit conditions in the past 5 years. The comments asked what kind of enforcement action has occurred for such violations, in order to understand better how the enforcement process works. The comment asked whether California air districts have ever “caused curtailment” of an electrical generating facility in the past.

Another comment asked, “[i]f the project is required to operate in excess of its permitted levels for electrical reliability,” whether “the operational curtailment plan” would be enforceable. The comment also asked whether the permit could be amended in the future in the event that an increase in any emissions limits may become necessary.

Response: The regulatory enforcement mechanisms that governmental agencies use to ensure compliance with applicable legal requirements at power plant projects have no bearing on the permitting review issues at issue in the District’s Determination of Compliance. The Determination of Compliance is aimed at the establishment of the applicable operating conditions for the facility at the front end of the approval process; enforcement mechanisms come into play at the back end of the process, after the facility is built and operated, to ensure that the facility complies with the applicable requirements going forward. These comments therefore seek information on what enforcement actions can be taken in the future in the event of non-compliance, and do not go to any of the relevant issues addressed in the Determination of Compliance.

Nevertheless, the District is happy to provide information on the enforcement process in response to these comments. The District’s inspectors have uncovered a number of violations of air quality requirements at facilities in Contra Costa County over the past five years and have initiated enforcement action. There are a number of governmental entities that can take enforcement action regarding such violations, including the local air districts, the attorney general, local district attorneys, and the California Energy Commission. When the District takes enforcement action, its action typically commences with the issuance of a Notice of Violation to the facility. The District then discusses with facility representatives what they need to do to get into compliance (if compliance has not already been achieved), and follows up to ensure that the necessary steps are implemented. The District also assesses civil penalties for such violations, based on the statutory penalty ranges set forth in Health & Safety Code sections 42402 through 42402.4. The District also takes legal action if it cannot negotiate an appropriate settlement of any violation by filing a request for an abatement order with the District’s Hearing Board and/or filing a complaint in Superior Court seeking civil penalties and/or

injunctive relief, as appropriate. California air districts have “caused curtailment” at electrical generating facilities on a number of occasions, meaning that facilities have shut down or reduced operation of equipment because of enforcement action or a threat of enforcement action by the air districts.

Regarding a circumstance where “the project is required to operate in excess of its permitted levels for electrical reliability,” the facility would be prohibited from operating in violation of any permit limits or conditions except if it had explicit legal authorization to do so, for example if the Legislature suspended certain regulatory requirements in response to a state of emergency or if the facility was granted a variance by the District’s Hearing Board pursuant to Health & Safety Code sections 42350 *et seq.* Any violation of any permit condition remains enforceable, unless there is some such specific legal authorization beyond the permit conditions allowing the facility to operate in such a manner. It is not clear what the comments mean by “the operational curtailment plan” and whether it will be enforceable in the event of violation of permit conditions, but the facility will be required to comply with its permit limits and will be subject to enforcement action as outlined above in the event of any violation.

Regarding the potential for future permit amendments that could involve an increase in any emissions limits, air quality regulations allow for permits to be amended to increase permit limits in appropriate circumstances. Any such amendments must go through the appropriate regulatory review process to ensure that the amended permit will still comply with applicable requirements, however. All appropriate procedural and substantive requirements will be applied in the event that the project applicant here requests any increase in emissions limits.

IX. MISCELLANEOUS COMMENTS, CLARIFICATIONS AND TYPOGRAPHICAL ERRORS

Comment IX.1 – Project Description

The applicant requested that the District clarify the statement in the PDOC that the project would be built only if the California Public Utilities Commission (PUC) determines that there will be a need for it. The applicant stated that PUC approval of the contract between PG&E and Contra Costa Generating Station, LLC, is not a prerequisite for constructing the Oakley Generating Station. The applicant stated that in the absence of PUC approval of sale to PG&E, the facility could be constructed as a merchant plant. The District also received comments from the public stating that the facility will be developed only if the PUC approves the contract, and that the PUC initially denied approval but that PG&E – who the comments stated will be the owner of the project not the developer – has petitioned for a modification of the PUC’s decision.

Response: At the outset, it is important to note that PUC approval and whether the project will be operated as a utility plant or a merchant plant does not have any bearing on the facility’s air emissions or on its compliance with any applicable air quality

regulatory requirements. Nothing in these comments therefore has any impact on the District's Determination of Compliance.

Nevertheless, since the issue of PUC approval has been a subject of public comments, the District has reviewed recent developments at the PUC on this issue. On December 16, 2010, the PUC reversed its earlier decision and approved the project, on the condition that PG&E not purchase the facility before January 1, 2016 (or alternatively, if PG&E does purchase the facility before January 1, 2016, that its shareholders absorb the associated revenue requirements from the date of purchase until the January 1, 2016).²⁷ PUC approval renders any issues regarding what would happen without PUC approval moot, and so the District has revised the discussion in the FDOC to remove consideration of this issue.

Comment IX.2 – Equipment Specifications

The applicant requested the description of the proposed technology be updated from “Expedited Rapid Response” to “Fast Start Rapid Response” to reflect the current General Electric (GE) nomenclature for the system.

Response: The District agrees with this comment and has made the change.

Comment IX.3 – Clarification of Maximum Hourly Formaldehyde Emission Rate

The applicant suggested that the source of the maximum hourly formaldehyde emission rate be noted in Table 8. The applicant noted that this maximum emissions rate is taken from data from a source test conducted during startup operations (a cold startup at the Palomar facility), and expressed a concern that this rate could be misinterpreted as the expected emission rate during normal operation (*i.e.*, as opposed to during startups).

Response: The District agrees the basis of the hourly emission rates in Table 8 should be clarified and has noted the reference for the formaldehyde, acetaldehyde, acrolein, benzene, ethylbenzene, and toluene maximum hourly rates are based on data from a source test at Palomar Energy Center during a cold startup, as listed in the Final Determination of Compliance for Carlsbad Energy Center Appendix B.²⁸ As seen in Appendix A, page A-13, the maximum emission factor (either from the Palomar source test or the California Air Toxics Emission Factors Database, whichever was higher) was used for non-normal operation. The District corrected the emission factor for toluene from 9.82E-3 lb/mmcsf to 9.28E-2 lb/mmcsf in Appendix A and the associated hourly and annual emission rates in Table 8.

²⁷ See California Public Utilities Comm'n, Decision 10-12-050, Application of Pacific Gas & Electric Company for Approval of 2008 Long-Term Request for Offer Results and for Adoption of Cost Recovery and Ratemaking Mechanisms (U 39 E), Application 09-09-021, Dec. 16, 2010, Date of issuance 12/20/2010, available at http://docs.cpuc.ca.gov/WORD_PDF/FINAL_DECISION/128515.PDF.

²⁸ See Final Determination of Compliance Carlsbad Energy Center, San Diego Air Pollution Control District, August 4, 2009 at Appendix B p.8. Available at: http://energy.ca.gov/sitingcases/carlsbad/documents/others/2009-08-04_SDAPCD_FDOC.pdf

Comment IX.4 – Formatting of Footnote 10

A commenter pointed out that Page 19, last paragraph, has an extra phrase “as discussed in Section 7”.

Response: The phrase is a continuation of the discussion in Footnote 10. The District has reformatted the footnote.

Comment IX.5 – Typographical Error

A commenter suggested that on page 36, third paragraph, first sentence, the word “lower” be inserted prior to “NO_x emissions limit”.

Response: The District agrees the word “lower” was mistakenly left out and has made the correction.

Comment IX.6 – Electric Reliability Requirements

The District received a comment inquiring as to whether this project is required for electrical reliability.

Response: The demand and supply of electricity in California is overseen by other expert agencies such as the California Energy Commission, the California Independent System Operator, and the California Public Utilities Commission. The District defers to the judgment of expert agencies such as these in determining how demand will be met and what new generating capacity is needed and how it should be provided. The District notes that the Public Utilities Commission has determined that there is a risk of capacity shortfall in 2016 and beyond, and the Oakley facility is needed to mitigate the risk of any such capacity shortfall (as well as to do so in the most efficient possible manner).²⁹

²⁹ See CPUC Decision 10-12-050, findings 9 and 10.

Appendix D

**Comments Received on the
Preliminary Determination of Compliance**

CALIFORNIA ENERGY COMMISSION

1516 NINTH STREET
SACRAMENTO, CA 95814-5512



December 1, 2010

Ms. Brenda Cabral
Supervising Air Quality Engineer
Bay Area Air Quality Management District
939 Ellis Street
San Francisco, California 94109

Dear Ms. Cabral:

DOCKET

09-AFC-4

DATE DEC 01 2010

RECD. DEC 01 2010

**OAKLEY GENERATING STATION (09-AFC-4)
PRELIMINARY DETERMINATION OF COMPLIANCE, APPLICATION 20798**

Energy Commission staff appreciates the opportunity to provide written public comments on the Preliminary Determination of Compliance (PDOC) issued by the Bay Area Air Quality Management District on October 29, 2010 for the Oakley Generating Station (OGS) in eastern Contra Costa County.

Energy Commission staff, pursuant to both the Warren-Alquist Act and the California Environmental Quality Act (CEQA), must determine whether the facility is likely to conform with applicable laws, ordinances, regulations, and standards, and whether mitigation measures can be developed to lessen potential impacts to a level of insignificance. These determinations may be difficult or impossible without additional information from the Bay Area Air Quality Management District (BAAQMD or District) in support of the Final Determination of Compliance.

Requirement for Offsets and Emission Reduction Credits

The PDOC does not show which emission reduction credits (ERC) would be used to satisfy the requirements under Regulation 2-2-302 for offsets. The PDOC claims that: "The applicant has committed to identify a list of offsets holders who have indicated in writing their willingness to sell sufficient ERCs. . ." (PDOC, p. 65). However, a list of ERC holders, even if it had been provided, would fall short of demonstrating that any ERCs are held by or proposed to be surrendered by OGS.

With only this tentative information from the OGS and BAAQMD, Energy Commission staff cannot discern whether the applicant has the ability to offset the project. Energy Commission staff indicated the need for OGS to provide its offset package in our Data Request 16 (1/19/2010).¹ This is a persistent information deficiency that makes it difficult for us to determine whether project impacts can be mitigated.

¹ Staff Data Request 16 to OGS (1/19/2010, TN 54860) said: "Please provide a tabulated list showing expected emissions and emission offset accounting indicating the proposed quantity of offsets, including the locations of emission reductions, in a quantity sufficient to fully offset the project's emissions, including appropriate offset ratios. Please show the current updated ERC certificate number and former certificate numbers for certificates that have been recently split and/or re-issued in the name of the project."

The BAAQMD should identify the specific offsets that are in the control of the applicant and list which ERCs would be surrendered. Normally, this kind of information is provided as part of the Determination of Compliance for disclosure [for more information, see the Warren-Alquist Act rules at Public Resources Code, Section 25523(d)(2)]. At this point, there is no information from OGS or BAAQMD that indicates any ERCs are in the applicant's control.

Transition of Commissioning into Routine Operation

The PDOC (Table 15) illustrates the total emissions due to 831 hours of commissioning activities, for both turbines combined. The applicant provided information indicating that an additional 1,725 hours could be required for commissioning activities for both turbines combined, with the turbines operating at levels compliant with normal limits (in OGS 4/7/2010, Supplemental AFC, Appendix 5.1A, Table 5.1A-5b, p. 1 of 2). In PDOC Condition 7, commissioning *without abatement devices* would be limited to 831 hours combined. However, for the applicant's proposed additional 1,725 hours of commissioning *with abatement*, it is not clear whether all normal operating limits become applicable. The District should clarify whether Conditions 11 through 30 become applicable only after the abatement devices are installed or upon the close of the 90 day period in Condition 10.

Requirement for Ammonia Continuous Emission Monitor

In PDOC Condition 16(e), the District requires continuous recording of ammonia (NH₃) injection rates as a means of verifying compliance with the NH₃ emission concentration limit. Energy Commission staff notes it may be feasible to use a continuous emissions monitor (CEM) to also monitor NH₃ concentrations in the stack, and that the District has established this as an optional means of verification in the license for the Marsh Landing Generating Station (District Application 18404, Final Determination of Compliance, June 2010). The District should consider adding a similar requirement to OGS Condition 16(e).

We appreciate the District working with Energy Commission staff on this licensing case. If you have any questions regarding our comments, please contact Gerald Bemis at (916) 654-4960. We look forward to discussing our comments in further detail with you.

Sincerely,

MATTHEW S. LAYTON
Supervising Mechanical Engineer

cc: Docket (09-AFC-4)
Proof of Service List
Dave Mehl, California Air Resources Board
Gerardo Rios, U.S. Environmental Protection Agency, Region IX



December 3, 2010

Kathleen Truesdell
Air Quality Engineer
Bay Area Air Quality Management District
939 Ellis Street
San Francisco, CA 94109

Subject: Oakley Generating Station – Comments on Preliminary Determination of Compliance

Dear Kathleen,

On behalf of Contra Costa Generating Station, LLC (CCGS), Radback Energy (Radback) provides the following comments on the Preliminary Determination of Compliance for the Oakley Generating Station (OGS):

1. Page 7, second paragraph – Radback requests that the sentence which reads “It should also be noted that the project would only be built if the California Public Utilities Commission (PUC) determines that there will be a need for it” be deleted. PUC approval of the contract between Pacific Gas and Electric Company (PG&E) and CCGS should not be construed as a prerequisite for constructing the Oakley Generating Station. Although unlikely, the project could potentially be constructed as a merchant project.
2. Page 17, second paragraph, first sentence – Radback requests that “Expedited Rapid Response” be replaced with “Fast Start Rapid Response” so as to use the most current General Electric (GE) nomenclature for the proposed technology.
3. Page 19, last paragraph – “as discussed in Section 7” appears to be extra text that does not relate to the prior or following sentences.
4. Page 25, Table 8 – The listed formaldehyde emission rate in lb/hr should be referenced as an uncontrolled startup emission rate based on a single source test from Palomar. Without this reference, the listed formaldehyde emission rate could be misinterpreted as the expected emission rate for the OGS during normal operation .
5. Page 36, third paragraph, first sentence – Radback requests that “lower” be inserted prior to “NO_x emissions limit”.
6. Page 60, Table 15 – Radback suggests adding a footnote clarifying that the durations and emissions shown are totals for both units.
7. Page 91, Permit Condition 10, first sentence – Radback requests that “or as otherwise approved by the APCO,” be inserted following “Within 90 operating days after first fire of each Gas Turbine,”. Radback believes that commissioning of the OGS may well run beyond the 90 days allowed between first fire and source testing. As our construction schedule becomes more refined, we will determine if it will be necessary to request an extension as provided for in Regulation 2, Rule 2, Section 419.

8. Page 93, Permit Condition 18, second sentence – Radback requests that 8 hours, not 6 hours, be allowed for each combustion turbine tuning event. While 6 hours may be sufficient time for tuning the existing generation of 7FA combustion turbine, GE informs us that the 7FA.05 will take up to 8 hours to tune because of the complexity of the model-based controls. While we would like to see Permit Condition 18 revised to allow an 8-hour duration, we are not requesting a corresponding increase in the total daily emissions indicated in Permit Condition 19.
9. Page 93, Permit Condition 18, fourth sentence – Radback requests that the notification requirement be revised to allow a shorter prior notice (e.g. 24 hours) as some tuning events will be necessary because of an emergency (e.g. a part fails and needs to be replaced thus requiring re-tuning, or the unit is otherwise not able to comfortably meet the permitted emissions limits as a result an issue that could not be contemplated 7 days in advance).

If you have any questions or require additional information, please do not hesitate to call me at 925/820-5222 (office) or 925/570-0835 (cell).

Yours Truly,



Jim McLucas
Senior Vice President
Radback Energy, Inc.

cc: Jose Xavier, GE
Craig Matis, GE
Pete Bukunt, GE
Greg Darwin, Atmospheric Dynamics
Bryan Bertacchi, Radback Energy
Greg Lamberg, Radback Energy

Sarvey - Oakley PDOC comments

From: Sarveybob@aol.com
Sent: Tuesday, December 07, 2010 5:35 PM
To: Kathleen Truesdell; Alexander Crockett; rios.gerardo@epa.gov;
mtollstr@arb.ca.gov
Cc: sarveybob@aol.com
Subject: Oakley PDOC comments
Attachments: Oakley PDOC Comments.doc

Attached are the comments of Robert Sarvey on the Oakely PDOC

Kathleen Truesdell
Air Quality Engineer II
Bay Area Air Quality Management District
939 Ellis Street, San Francisco, CA 94109
(415) 749-4628,
ktruesdell@baaqmd.gov

Dear Ms. Truesdell

Thank you for the opportunity to comment on the Oakley Generating Station Preliminary Determination of Compliance Application number 20798. Pursuant to Regulation 2, Rule 2, Section 405 I request a public hearing so the district can take oral testimony and answer questions. The permit involves several complicated issues including transport to the San Joaquin Valley, PSD requirements, and the district's approval of two other major sources next to the Oakley project neither of which obtained a valid PSD permit.

2. The Power Plant Permitting Process and Opportunities for Public Participation

This section should be modified to describe the districts issuance of the Authority to Construct and the public's rights to appeal the Authority to Construct Decision to the Districts Hearing Board. The discussion should include procedures for the appeal, the cost of the appeal, and the deadline of the appeal, and the appropriate regulations governing an appeal to the hearing board. This is an important part of the public's opportunity to participate in the districts permitting decisions.

Page 3 of the PDOC states, "The District collaborates with the Energy Commission regarding the air quality portion of its environmental analysis and prepares a "Determination of Compliance" that outlines whether and how the proposed project will comply with applicable air quality regulatory requirements. The Determination of Compliance is used by the Energy Commission to assess air quality issues of the proposed power plant." The section should be modified to underscore that it is the district not the CEC that determines whether the project complies with relevant Federal and State air quality laws and regulations. The CEC may not modify the districts

determinations without override of the districts conclusions under section 1752.3 of the California Code of Regulations which prescribe:

§ 1752.3. Presiding Member's Proposed Decision; Air Quality Findings.

(a) The presiding member's proposed decision shall include findings and conclusions on conformity with all applicable air quality laws, including required conditions, based upon the determination of compliance submitted by the local air pollution control district.

(b) If the determination of compliance concludes that the facility will comply with all applicable air quality requirements, the commission shall include in its certification any and all feasible conditions necessary to ensure compliance. If the determination of compliance concludes that the proposed facility will not comply with all applicable air quality requirements, the commission shall direct its staff to meet and consult with the agency concerned to attempt to correct or eliminate the noncompliance.

(c) If the noncompliance cannot be corrected or eliminated, the commission shall determine whether the facility is required for the public convenience and necessity and whether there are not more prudent and feasible means of achieving such public convenience and necessity. In such cases, the commission shall require compliance with all provisions and schedules required by the Clean Air Act and compliance with all applicable air quality requirements which in the judgment of the commission, can be met.

3.2 Project Location

The district in its description of the project location makes brief reference to the three power plants and a PG&E natural gas terminal adjacent to the Oakley Project. The applicant discusses the proximity of the power plants in relation to the Oakley Project in its Supplemental filing for Air Quality and Public Health Revised April 7, 2010:¹

*In evaluating the potential cumulative localized impacts of CCGS in conjunction with the **impacts of existing power generation facilities immediately adjacent** to the project site and facilities not yet in operation but that are reasonably foreseeable, a potential impact area in which cumulative localized impacts could occur was identified as an area with a radius of 8 miles around the plant site.*

The Gateway project is owned by PG&E and so is the Antioch Natural Gas Terminal. Both are adjacent to the Oakley Project which will be owned by PG&E pursuant to a purchase and sale agreement. The ownership of these facilities has permitting implications which are important to the Federal PSD Requirements and the Federal PM 2.5 requirements which are discussed under Section 7 of the PDOC.

¹Supplemental filing Air Quality and Public Health Revised April 7, 2010 Page 298

3.4 Project Ownership

The Oakley Generating Station will be developed if and only if the Purchase and Sales Agreement for the Oakley Project is approved by the CPUC. The Commission has initially denied approval of the Oakley Project because it is not needed at this time.² PG&E currently has a petition for modification³ for D.10-07-045. PG&E will be the project owner and Radback is merely the developer

5.2.6 Best Available Control Technology For Startups, Shutdowns, and Combustor Tuning

Page 50 of the PDOC states, “Fast-Start Technology:

Turbine manufacturers have recently developed design improvements that allow combined-cycle facilities such as this one to start up more quickly and efficiently. These improvements allow combined-cycle facilities to bypass the steam turbine during the early stages of startup, eliminating some of the delay. With a conventional combined-cycle design, the combustion turbine must be held at low load while the steam turbine is being heated up, which needs to be done slowly to minimize thermal stresses and maintain the necessary clearances between the rotating and stationary components of the steam turbine. These new designs allow steam generated by the HRSGs to bypass the steam turbine during startups, allowing the turbines to come up to full load quickly. As the proper steam conditions are achieved, a portion of the steam will be sent to the steam turbine, which will ramp up slowly until the point is reached where steam is no longer bypassing the steam turbine. GE is marketing this new technology under the name “Rapid Response”, and Siemens is marketing a similar technology under the name “Flex-Plant”. The applicant is proposing to use the GE “Rapid Response” design for the Oakley Generating Station.

The District is proposing the use of best work practices with fast-start technology as BACT for startups and shutdowns of combined-cycle plants. Both control technologies are technically feasible and are the most effective technology available for decreasing startup and shutdown emissions. The applicant has proposed the use of best work practices and GE’s Rapid Response Technology, which satisfies the BACT requirement.

The public has spent a good part of the last two years trying to convince the district that fast start technology was BACT for startups in the Russell City Energy Center Proceeding. The district is now admitting that the public was right that the fast start technology is “technically feasible and the most effective technology available for

² CPUC Decision 10-07-045

³ <http://docs.cpuc.ca.gov/eFile/PM/122506.pdf>

decreasing startup and shutdown emissions.” Compare that to what the district said in February of this year about the Rapid Response System in the Russell City proceeding:

“As no facility has to date been equipped with the Rapid Response CC system, no facility has had an opportunity to demonstrate actual startup emissions performance. Moreover, the performance of existing combined-cycle facilities indicates significant variability in emissions between startup events, making it difficult to predict exactly what level of emissions this new technology will be able to achieve. And the experience of other projects representing “first-of-its-kind” combined cycle plants indicates that initial predictions of startup emissions are often inaccurate. For example, Inland Empire Energy Center (“IEEC”) recently requested an amendment of its California Energy Commission license to increase permitted emissions during startup events due to the facility’s failure to meet the existing limits.²²⁴ IEEC, which is a demonstration project for GE’s first 60-Hz H-class turbines, commenced commercial operation of one of its units on June 29, 2009. (The second unit was damaged during commissioning and is not expected to begin operating until early 2010.) The requested amendment in IEEC’s license would increase the permitted CO emissions during startups/shutdowns from 95 lbs/hr to 800 lbs/hr and from 300 lbs/event to 2,000 lbs/event – more than 8- and 6-fold increases, respectively. Increases in startup emissions of this magnitude, if applied to GE’s estimated emissions for the Rapid Response CC plant and 7FA.05 Advanced Gas Turbines, would in some cases exceed the BACT limits being established for Russell City.⁴

In less than 10 months the Rapid Response technology went from an untested unproven technology to “*technically feasible and the most effective technology available for decreasing startup and shutdown emissions.*”

Ammonia Emissions

The project has the potential to emit over 120 tpy of ammonia which is more than any other criteria pollutant. The ammonia emissions have significant impacts that the district fails to recognize or mitigate. The PDOC should provide an adequate discussion and an analysis of the effects of the ammonia emissions on the environment. The districts PM 2.5 study indicates that ammonia emission around large sources of NOx have a higher potential for secondary particulate formation than other areas in the district. In this case

⁴ Responses to Public Comments Federal “Prevention of Significant Deterioration” Permit Russell City Energy Center pages 111,112
http://www.baaqmd.gov/~media/Files/Engineering/Public%20Notices/2010/15487/PSD%20Permit/B3161_nsr_15487_res-com_020410.ashx

the Oakley Project, the Marsh Landing, and the Gateway project are all located within one mile of each other. This creates a potentially large NOx concentration⁵ in and around the project area and the district must make an attempt to quantify the environmental impacts from the formation of secondary PM 2.5.

Secondly the Oakley Project in conjunction with the Marsh Landing and Gateway Project will emit large amounts of ammonia and NOx which will have nitrogen deposition impacts on the Antioch Dunes. USFW has already opined that the Oakley project must provide mitigation for this impact.⁶ The district has permitted 3 large major sources within one mile of each other and none of these sources has obtained a valid PSD permit so no vegetation and soils analysis has been conducted. With the combined potential ammonia emissions of 472 tpy from the three major sources the district has permitted without PSD permits, impacts to the Antioch Dunes Preserve and the surrounding residents remains unanalyzed and unmitigated by the district.

7.1 Federal “Prevention of Significant Deterioration” Program

Since January 2009 the district has allowed PG&E to operate the Gateway project without a Federal PSD permit. The Gateway Project like the Oakley Project will be owned by PG&E. The operation of the Gateway Project without a PSD Permit has resulted in a civil action by the United States vs. PG&E.⁷ The district has known of PG&E’s plan to circumvent the PSD regulations at the Gateway Project since August 1, 2008.⁸ Now the district is proposing to approve the Oakley Project without a PSD permit. The Oakley and the Gateway Project and the PG&E natural gas terminal are in close proximity to each other.⁹ 40 CFR 52.21(b) defines the stationary sources as:

⁵ Combined potential NOx emissions from the three projects is 345 tpy.

⁶ http://www.energy.ca.gov/sitingcases/oakley/documents/others/2010-10-13_USFWS_Comments_on_AFC_TN-58786.pdf

⁷ United States Vs. PG&E Civil Action NO. 09-0453

⁸ See Exhibit 1 **Gateway Generating Station Teleconference Notes August 4, 2008**

⁹ Supplemental filing Air Quality and Public Health Revised April 7, 2010 Page 298

*In evaluating the potential cumulative localized impacts of CCGS in conjunction with the **impacts of existing power generation facilities immediately adjacent to the project***

(6) Building, structure, facility, or installation means all of the pollutant-emitting activities which belong to the same industrial grouping, are located on one or more contiguous or adjacent properties, and are under the control of the same person (or persons under common control) except the activities of any vessel. Pollutant-emitting activities shall be considered as part of the same industrial grouping if they belong to the same Major Group (i.e., which have the same first two digit code) as described in the Standard Industrial Classification Manual, 1972, as amended by the 1977 Supplement (U. S. Government Printing Office stock numbers 41010066 and 003005001760, respectively).

The Oakley Project is a major modification to the Gateway Project and the natural gas terminal since they are all owned by PG&E and belong to the same industrial classification and are on adjacent properties.

The district has recently approved the Marsh Landing Facility, the Gateway Facility, and now is considering approval of the Oakley Facility within a 1 mile radius of each other. Each project is a major source but the Marsh Landing and now the Oakley project have escaped PSD review. The combined emissions from these three sources the Gateway Project, Marsh Landing, and Oakley, none of which has a PSD permit will collectively exceed the PSD emission limits. The table below captures the combined emissions of the three major sources all within a 1 mile radius.

<i>Total Maximum Annual Emissions Gateway, Oakley and Marsh Landing tons per year</i>						
	NO2	VOC	PM 2.5	CO	SO2	Ammonia
Marsh Landing	72.0	14.2	31.6	138.9	4.9	108
Oakley	98.8	30.0	76.3	98.8	12.6	120
Gateway	174.3	46.6	101.7	554.3	37.0	244
Total	345.1	90.8	209.6	792.0	43.1	472

A pattern of development is emerging, either through design or circumstance that is circumventing the level of protection that Congress intended in crafting the PSD

site and facilities not yet in operation but that are reasonably foreseeable, a potential impact area in which cumulative localized impacts could occur was identified as an area with a radius of 8 miles around the plant site.

program. It is clear that the permitting of many “synthetic minor” sources in a limited geographic area are resulting in emissions increases that should be controlled and assessed through the PSD program. The combined emissions from these projects has already impacted the Antioch Bay Dunes Refuge. The district appears to be enabling this pattern and is also considering another major source the Willow Pass Generating Station which is near these other three major sources all permitted without PSD permits.

The district as the permitting agency for all of these projects should first examine the cumulative environmental impacts of these plants regardless of their major or minor status to ensure that individually and collectively they do not cause or contribute to a violation of the NAAQS and applicable PSD increments. The district should use all credible information available in making this assessment, including ambient monitoring data and modeling analyses. Second, the district must evaluate whether the development of individual power projects are part of a larger strategy that would support the conclusion that they operate as one source. The districts permitting staff should ask for documentation concerning long term plans for ownership and operation of individual projects, information on contractual agreements¹⁰ and voting interests, or contracts for service among owners and operators. The district should note that all of three of these facilities are either owned or contractually linked to provide power under contract to PG&E. The district should also note that USFWS has informed the CEC that emissions from the Oakley Project will negatively impact the Antioch Dunes Wildlife Refuge.¹¹ In the permitting of the Oakley Project these issues should be considered.

7.2 Non-Attainment NSR for PM2.5

As explained above the district has permitted several large sources of PM 2.5 all within close proximity of one another totaling a potential 209 tons of PM 2.5. Despite these approvals not one facility has been examined for its PM 2.5 impact nor have they been examined collectively. This pattern of development by the district contravenes the

¹⁰ Oakley and Gateway are both owned by PG&E and Marsh Landings output is contracted to PG&E.

¹¹ http://www.energy.ca.gov/sitingcases/oakley/documents/others/2010-10-13_USFWS_Comments_on_AFC_TN-58786.pdf

intent of 40 CFR 51 Appendix S¹² and the PSD provisions of the Clean Air Act. The district must examine these impacts since the health effects of PM 2.5 are not assessed by the district in its health risk assessment and are not evaluated by any other agency including the CEC. The district has not provided one ounce of PM offsets for any of these projects.¹³

PSD requirements for Greenhouse Gasses

The district needs to include in the FDOC that OGS must begin construction by July of 2011 in order to qualify for a current grandfathering exemption contained in the Prevention of Significant Deterioration (PSD) Tailoring Rule. EPA adopted the Tailoring Rule which applied PSD requirements to Greenhouse Gas Emissions, which were previously not regulated by the PSD process. The Tailoring Rule allows projects such as OGS, which prior to the Tailoring Rule were not required to obtain a PSD Permit, an exemption if the OGS has begun “actual construction” by July 1, 2011. “Actual construction” under the current EPA Guidance would require physical permanent construction of an emitting unit, such as pouring foundations.

EPA’s Interim Policy to Mitigate Concerns Regarding GHG Emissions from Construction or Modification of Large Stationary Sources¹⁴ provides that permitting authorities that issue permits before January 2, 2011 are already in a position to, and should, use the discretion currently available under the BACT provisions of the PSD program to promote technology choices for control of criteria pollutants that will also facilitate the reduction of GHG emissions. More specifically, the CAA BACT definition requires permitting authorities selecting BACT to consider the reductions available through application of not only control methods, systems, and techniques, but also

¹² A major new source or major modification which would locate in an area designated in 40 CFR 81.300 *et seq.*, as nonattainment for a pollutant for which the source to insure that **the new source’s emissions will be controlled to the greatest degree possible; that more than equivalent offsetting emission reductions (emission offsets) will be obtained from existing sources; and that there will be progress toward achievement of the NAAQS.**

¹³ The Gateway Facility provided offsets in the form of SO₂ but no PM offsets were required. The other two facilities fall under the districts 100 ton offset threshold which is a disgrace for an area classified as non attainment.

¹⁴ Reconsideration of Interpretation of Regulations that Determine Pollutants Covered by Clean Air Act Permitting Programs http://www.epa.gov/nsr/documents/psd_memo_recon_032910.pdf

through production processes, and requires them to take into account energy, environmental, and economic impacts. Thus, the statute expresses the need for a comprehensive review of available pollution control methods when evaluating BACT that clearly requires consideration of energy efficiency. The consideration of energy efficiency is important because it contributes to reduction of pollutants to which the PSD requirements currently apply and have historically been applied.

Further, although BACT does not now apply to GHG, BACT for other pollutants can, through application of more efficient production processes, indirectly result in lower GHG emissions.¹⁵

5. Transport of Pollutants to the San Joaquin Valley

The District has approved two applications for power projects near the Oakley Project, the Gateway Project and the Marsh Landing Project. The District is also reviewing the Mariposa Project which sits on the border of the San Joaquin Valley Pollution Control District and the BAAQMD. One Hundred percent of the emissions from the Mariposa Project will impact the San Joaquin Valley.

In the Tesla Proceeding the CEC determined that 70 % of the emissions from sources in the Antioch and Pittsburg area impact the San Joaquin Valley.¹⁶ The impact from the four projects in the Tracy area and San Joaquin Valley is represented below in the table below.

<i>Total Maximum Annual Emissions</i>					
	NO2	VOC	PM 2.5	CO	SO2
Marsh Landing	72.0	14.2	31.6	138.9	4.96
Oakley	98.8	30.0	76.3	98.8	12.6
Gateway	174.3	46.6	101.7	554.3	37.1
Total	422.2	119.3	249.0	792.0	54.66
70% Impact	295.5	83.5	174.3	554.4	38.2
Mariposa 100%	48.6	11.1	25.8	69.5	3.2
Total Impact SJV	344.1	94.6	200.1	613.9	41.4

¹⁵ Reconsideration of Interpretation of Regulations that Determine Pollutants Covered by Clean Air Act Permitting Programs

http://www.epa.gov/nsr/documents/psd_memo_recon_032910.pdf page 98

¹⁶ Commission Decision Tesla Project Page 158

http://www.energy.ca.gov/sitingcases/tesla/documents/2004-06-22_FINAL.PDF

The ARB originally established transport mitigation requirements in 1990 which are contained in Title 17, California Code of Regulations, Sections 70600 and 70601. These regulations were amended in 1993 and more recently in 2003. The Board adopted amendments on May 22, 2003, which were approved by the Office of Administrative Law on December 4, 2003, and became effective on January 3, 2004. These amendments added two new requirements for upwind districts. These amendments require upwind districts to (1) consult with their downwind neighbors and adopt "all feasible measures" for ozone precursors¹⁷ and (2) amend their "no net increase" thresholds for permitting so that they are equivalent to those of their downwind neighbors no later than December 31, 2004.¹⁸

At the present time the district does not comply with these requirements as the SJVAPCD offset requirements are higher than the districts. SJVAPCD Rule 4.5.3 requires offsets for NOx and VOC emissions for any emissions over 10 tpy. The BAAQMD offset thresholds are 35 tpy per district rule 2-2-302. In the SJVAPCD PM-10 emissions over 14.6 tpy must be offset per district rule 4.5.3. The BAAQMD requires no offsets for PM-10 emissions less than 100 tpy pursuant to district rule 2-2-303. SOx emissions over 22.7 tpy must be offset in the SJVAPCD but in the BAAQMD SOx emissions under 100 tpy do not require offsets.

In addition the SJVAPCD has more stringent offset distance ratios than the BAAQMD. SJVAPCD Rule 4.8.3 provides the offset ratios as below:

Table 4-2, Standard Distance Offset Ratio ORIGINAL LOCATION OF EMISSION OFFSETS	OFFSET RATIO
at the same Stationary Source as the new or modified emissions unit	1.0
within 15 miles of the new or modified emissions unit's Stationary Source	1.2 for Non-Major Sources 1.3 for Major Sources
15 miles or more from the new or modified emissions unit's Stationary Source	1.5

¹⁷ First, is a new requirement that upwind districts adopt all feasible measures for the ozone-forming pollutants, independent of the upwind district's attainment status.

¹⁸ A new requirement intended to equalize permitting programs in upwind and downwind areas. The ARB staff is proposed and the ARB passed into law that "no net increase" thresholds for new source review permitting programs in upwind areas must be as stringent as those in downwind districts.

9.5 Environmental Justice

The PDOC Fails to Comply With Environmental Justice Requirements

In 1994 President Clinton issued Executive Order 12898 calling on federal agencies to identify and address. “Disproportionately high and adverse human health and environmental effects on minority populations and low income population in the United States” The EPA led an interagency effort to carry out the executive order. In 1998 the EPA issued guidance for federal agencies conducting analyses under the National Environmental Policy Act (NEPA) entitled “Final Guidance for incorporating Environmental Justice Concerns in USEPA’s National Environmental Policy ACT Compliance Analysis,” This document followed and was explicitly designed to supplement the Council on Environmental Quality’s Environmental Justice Guidance under NEPA.

California Government Code Section 65040.12 defines environmental justice as the fair treatment of all races, cultures and incomes with respect to the development adoption, implementation and enforcement of environmental laws, regulations and polices. Under these laws the District is required to provide an assessment of disproportionate impacts to minority and low-income residents near the MLGS. Accordingly, a proper environmental justice analysis consists of a five step process:

- 1) Description of the existing setting.
- 2) Analysis of the unique circumstances of the affected population
- 3) Analysis of the project’s direct, indirect, and cumulative impacts.
- 4) Assess and recommend the appropriate mitigation
- 5) Determine whether the project creates an unavoidable significant impact on the affected population and, if so, consider whether the impact is disproportionate.

The District’s Environmental Justice Analysis Falls Short

The District’s “environmental justice analysis” consists only of a health risk screening conducted under its Risk Management Regulation 2 Rule 5, which is meant to determine the potential impact on public health resulting from the worst-case emissions of toxic air

contaminants (TACs) from the proposed OGS. The district analysis does not even include a health risk assessment of the particulate matter impacts from the project or the other three power projects operating adjacent to the proposed project. Based on that analysis the district concluded that, “The District does not anticipate a significant adverse impact on any community due to air emissions from the Oakley Generating Station; therefore, there will be no significant disparate adverse impact on any Environmental Justice community located near the facility. The environmental justice analysis requirements of the federal Executive Order 12898 do not apply here because the District is not issuing a federal permit, and state requirements for evaluating environmental justice impacts as part of the overall CEQA environmental review are handled through the CEC’s CEQA-equivalent. (Note that Title VI civil rights requirements applicable to agencies that receive federal funds impose anti-discriminatory requirements on the agency’s programs as a whole, and do not impose any specific requirements for an environmental justice analysis for individual permitting actions.”¹⁹

The district’s judgment is flawed in this respect. As mentioned above a pattern of development is emerging, either through design or circumstance that is circumventing the level of protection that Congress intended in crafting the PSD program. It is clear that the permitting of many “synthetic minor” sources in a limited geographic area are resulting in emissions increases that should be controlled and assessed through the PSD program. The district permitting program is the source of this disparate treatment since the district fails to examine the cumulative effects of its permitting decision on the minority and low income population near the projects. The district fails to own up to its obligations to the public. This project is in fact subject to PSD permitting and Federal Environmental Justice Requirements even though the PDOC refuses to require one. The District’s analysis fails to comply with the requirements of the 1998 EPA Guidance and the requirements of Government Code section 65040.12. The District’s analysis does not provide any of the five steps described above:

1) Description of the existing setting.

¹⁹ PDOC Page 86

First, the district performs no demographic assessment and fails to identify if a minority or low income community exists.

2) Analysis of the unique circumstances of the affected population

Second, the District fails to analyze the unique circumstances of the population. Poor health and premature death are by no means randomly distributed in Contra Costa County. Low income communities and communities of color suffer from substantially worse health outcomes and die earlier. Pittsburgh and Antioch are home to many minority communities, especially around the facility,²⁰ and a significant percentage of the residents live below the federal poverty line.²¹ The community is disproportionately impacted by illnesses known to be related to exposure to industrial pollution. For instance, in Contra Costa County, the hospitalization rate due to asthma for African American children is almost five times that of Caucasian children.²² Childhood asthma rates in Contra Costa County are nearly twice the national average.²³ There is also a significant disparity of disease rates between whites and people of color in Contra Costa County. For instance, African-Americans in Contra Costa County have a 59% higher death rate from all causes of death, including heart disease, cancer, and stroke, than the country average.²⁴

Death rates from cardiovascular and respiratory diseases in Contra Costa County are also currently higher than statewide rates and continue to rise.²⁵ Further, Richmond,

²⁰ Contra Costa Health Services, *available at* http://cchealth.org/health_data/hospital_council/pdf/poverty.pdf

²¹ Contra Costa Health Services, *available at* http://cchealth.org/health_data/hospital_council/pdf/poverty.pdf

²² Contra Costa Health Services, *Health Disparities in Contra Costa*, *available at* http://cchealth.org/groups/rhdi/pdf/health_disparities_in_cc.pdf

²³ See Contra Costa Asthma Coalition, *available at* http://www.calendow.org/uploadedFiles/CAFA3_CCscreen.pdf (Contra Costa County asthma rate in children is 23.7%, whereas national rate is 14.2%).

²⁴ Community Health Indicator for Contra Costa County, *Community Health Assessment, Planning and Evaluation Group Executive Report* (June 2007), *available at* http://cchealth.org/health_data/hospital_council_2007/.

²⁵ See *A Framework for Contra Costa County*, *available at*

Pittsburgh, and Antioch have significantly higher hospital discharge rates for chronic diseases than other cities and the county overall.²⁶ Contra Costa County's cancer death rate is also higher than the state average.²⁷ In addition, scientific links have been made between certain types of cancer – including lung, nasal cavity, and skin cancers – and pollutant emissions in Contra Costa County.²⁸ All of these health impacts are especially problematic and severe for those without health insurance, 43% of low-income residents in Contra Costa County are un-insured. They cannot afford expensive health plans, extended stays in the hospitals, or preventative medicines.

3) Analysis of the project's direct, indirect, and cumulative impacts.

Third, the District entirely ignores the cumulative impacts from the multiple emissions sources in the project area. Contra Costa is home to over half of the power plants in the District and a large number of chemical plants and refineries. Contra Costa is the second most industrialized county in California. The District does not even bother to perform a cumulative assessment of existing facilities and their impact on the minority and low income residents.

4) Assess and recommend the appropriate mitigation

Fourth, the mitigation that the District provides consists of a couple of emission reduction credits which were originated in the 80's and 90's. No other mitigation is offered by the District to offset the project's emissions.

http://cchealth.org/groups/chronic_disease/framework.php.

²⁶ See Contra Costa Health Services, Health Disparities in Contra Costa, *available at* http://cchealth.org/groups/rhdi/pdf/health_disparities_in_cc.pdf.

²⁷ See A Framework for Contra Costa County, *available at* http://cchealth.org/groups/chronic_disease/framework.php.

²⁸ See Cancer Incidence and Community Exposure to Air Emissions from Petroleum and Chemical Plants in Contra Costa County, California: A Critical Epidemiological Assessment, Otto Wong, and William J. Bailey; Journal of Environmental Health, Vol. 56 1993, *available at* <http://www.questia.com/googleScholar.qst;jsessionid=KngJLJhFRCYFhpTfY5K100wTX5dSl4BvRR1qZvvDw.L7bKfCG921F!568259201!-950397748?docId=5002198605>

5) Determine whether the project creates an unavoidable significant impact on the affected population and, if so, consider whether the impact is disproportionate.

Finally, the District cannot determine whether the project creates a unavoidable significant impact on the affected population or consider whether the impact is disproportionate since the district failed to complete the first four steps of the analysis. The district approach is akin to analyzing the health effects of one diesel truck idling in a parking lot full of idling diesel trucks.

Submitted by,

A rectangular box containing a handwritten signature in dark ink. The signature appears to be "Robert Sarvey" written in a cursive style.

Robert Sarvey
501 W. Grantline RD
Tracy, Ca. 95375
209 835-7162

Exhibit 1

RE: Follow up **CGS Air Permit** Page 1 of 1

Alexander Crockett

From: Brian Lusher

Sent: Thursday, August 07, 2008 11 :59 AM

To: Alexander Crockett

Cc: Brian Bateman; Bob Nishimura

Subject: FW: Follow up **GGs Air Permit**

Attachments: BAAQMD teleconference notes 080408.doc

-----Original Message-----

From: Allen, Thomas [mailto:HTAl@PGE.COM]

Sent: Wednesday, August 06, 2008 10:51 AM

To: Allen, Thomas; Royall, Steve; Nancy L. Matthews; Gary Rubenstein; sgalati@gb-LLP.rnrn; Andrea@agrenier.mm; Maring, Jon; Royall, Stwe; Espiritu, Angel 8;

Brian Lusher; Phung, Hoc

Cc: Farabee, David R.

Subject: RE: Follow up **GGs Air Permit**

<cBAAQMD teleconference notes 080408.doc>>

All

Here are **notes** from our **previous** meeting that **Nancy prepared**. Let Nancy and me know if **there are questions or comments**

Tom Allen

Project Manager

Gateway Generating Station

925-459-7201 cetl 41 5-31 7-4463

--

From: Allen, Thomas

Sent: Thursday, March 03, 2005 12: 17 Pt.?

To: Royal, Steve; 'Nancy L. Matthewa'; %av Ruben!Zeinl; ' Smt t Galati (sgalati@~b-CLP.cor)r'; 'Andrea@agrenier.m'; Manng, Ion, Royall, Steve; Esp~rhAngel 5; 'blusher@baaqmd.gm'; Phung, HOE

Cc: Farabee, David A.

Subject: Follow up GGS Air Permit

When: Wednesday, August 06,2008 11:00 AM- 11: 3 0 AM (GHT-08:00) Pa ~ fTa~ ne(U S & Cmada).

Where: GGS Conference Callir. 866-257-0480 '4159735105"

Gateway Generating Station Teleconference Notes

August 4,2008

Participants:

BAAQMD Alexander (Sandy) Crockett (staff attorney)

Brian Bateman (head of Permit Services)

Bob Nishimura (senior permitting engineer)

Brian Lusher (permit engineer)

Tom Allen

Steve Royal1

Hoc Phung

Angel Espiritu

Teresa DeBono

Latharn & Watkins David Farabee

Sierra Research Gary Rubenstein

Nancy Matthews

Meeting Notes:

1. Discussion of Environmental Appeals Board Decision in the Russell City Energy Center licensing proceeding.

Sandy Crockett provided a summary of the EAB decision on the Russell City Energy Center PSD permit amendment and the timing implications of a EAB appeal for GGS. District was taken to task by EAB for not complying with noticing requirements of 40 CFR 124 and is concerned that the notice provided for the GGS amendment might also be viewed by EAB as deficient. Sandy is concerned that the EAB plaintiff in the RCEC case would appeal the GGS permit to the EAB on the same grounds. He indicated that the RCEC plaintiff had been in contact with Bob Sarvey, who had submitted public comments on the GGS draft permit. He noted that power plant project opponents such as Sarvey appear to have discovered that the EAB appeal process is an effective means of delaying projects since an EAB appeal stays the PSD pennit for 6 months or more even if EAB ultimately rejects the appeal.

2. Renoticing under Section Title 40 Part 124 requirements.

Area lists of interested parties by Region.

District believes (that it may *be* preferable to renotice the amendment using a District wide rather than a countywide notice list, resulting in a 30-day delay for issuance of the amended PSD permit but eliminating the RCEC plaintiffs ability to appeal this issue to the EAB.

Gary Rubenstein indicated that we expect the permit to be appealed to the EAB by Sarvey anyway. He stated that since the time-critical element for PG&E was the commission-related permit conditions, and since an appeal would stay the permit whether it had any merit or not, it's not clear that any time would be saved by renouncing the draft permit. Sandy suggested that it may be easier for the EAB to dismiss the appeal without the notice issue.

3. Public Meeting; may be required under Title 40 Part 1 24.

District also noted that if amendment is renounced, comments could request a public hearing. Gary and David Farabee recommended that if the permit is renounced, PG&E should request a public hearing so the hearing notice period could run concurrently with the comment period, avoiding additional delays.

4. AC amendment considered a non-major modification of PSD permit.

There was a discussion of the need for amended CO emission limits during commissioning. Gary and Steve Royall explained that the limits in the current permit are not adequate; if amendment is delayed beyond project startup, GGS may need to request variance from Hearing Board. Gary and Tom Allen indicated that GGS is exploring ways of reducing CO emissions during commissioning to comply with current limits, such as installing oxidation catalyst before first fire. Gary noted that under EPA policy, once a facility starts up, a non-major amendment no longer requires PSD review and public notice, so if amendment issuance were to be delayed until after startup the PSD issues could be moot. However, District would appear to be circumventing the regulatory process if it were to delay. If GGS were to withdraw permit amendment until after commissioning it would be hard for District staff to support, and the Hearing Board to grant, a variance.

5. Basis of revised annual CO limit.

Brian Lusher said he had received information from Sierra on this topic; it appeared to address his questions and he will contact Sierra directly if he had additional questions.

6. Additional discussion on fast start/rapid start technology and the possible implementation of this technology for this project.

District staff believe they need to address startup BACT in response to comments. Brian Lusher noted that he had received some information from Sierra to address this. Gary noted that EPA **had addressed this issue in the Colusa** PSD permit; Brian will

look at the information PG&E has already submitted, and may request additional information, **to assist in preparing his response.** There was a general discussion of the physical changes necessary to implement fast **start** technology - software changes alone are not adequate-- and why this is not feasible for GGS at this point in project development.

Brian would like to include a warm startup time limit in the GGS permit as one way to address the BACT issue. There was a general discussion regarding the need to maintain the 900 lb hr CO limit-that the hourly limits could not be lowered. The District understands this issue. Brian Lusher indicated that the CEC staff was pressuring the BAAQMD staff on the proposal to raise the ammonia slip limit to 10 ppm. He had reviewed the District's studies on the contribution of ammonia to secondary particulate. Although previous District statements were that ammonia did not contribute to secondary particulate in the BAAQMD, some staff members were now reevaluating that position. He noted that many recent projects had accepted 5 ppm ammonia slip limits. Gary pointed out that the 5 ppm slip limits for recent projects were proposed or accepted for other reasons, including BACT determinations (San Luis Obispo County APCD and SCAQMD), and these reasons are not relevant to GGS. He said that the District staff had been consistent in its position regarding the contribution of ammonia slip to secondary PM in the Bay Area, and that if the District staff changed the technical conclusions regarding atmospheric chemistry, GGS would accept that determination. However, the BAAQMD staff, not *the* CEC staff, were the experts on this air quality issue.

8. Excursion **Language** Necessary? Justification for Excursion **Lanmage**?

Brian Lusher asked for some justification for the requested excursion language in the draft permit. Gary indicated that Sierra was working on an analysis of acid rain monitoring data to address the question, and that a summary of the analysis would be provided to the District when it was completed later this week. Brian Lusher said the District believes that CO2 emissions need to be addressed in permit evaluations. Gary warned against including CO2 emissions in a PSD permit evaluation because that could lead to making every project a major facility for CO2. Sandy Crockett agreed with this concern.

Brian also indicated that the District was considering whether the modeling results for other non-PSD pollutants needed to be included in the public notice and engineering evaluation. Gary expressed concern that this could make it appear as if the entire PSD permit was subject to public notice, and not just the requested amendment. The District staff indicated that this was their intent, as a fallback position. Gary indicated that while PG&E could figure out a way to deal with delays related to the pending permit amendment, if there was even a slight chance that the public notice for the amendment could be construed as a renote of the entire PSD permit, and hence an appeal could stay the effectiveness of the initial PSD permit, PG&E would withdraw the amendment request. The District staff agreed to continue to review these issues internally. A follow-up conference call was scheduled for 11 am Wednesday, August 6.

Oakley PDOC comments

From: rob@redwoodrob.com
Sent: Tuesday, December 07, 2010 4:59 PM
To: Kathleen Truesdell
Cc: Sarveybob@aol.com
Subject: Oakley PDOC comments
Attachments: Oakley PDOC comments ROB.pdf

Thank you for this opportunity to comment regarding the Preliminary Determination of Compliance (PDOC) for the Oakley Generating Station. Please find my comments attached or below.

Rob Simpson
27126 Grandview Avenue
Hayward CA.
94542
rob@redwoodrob.com
510-909-1800

Thank you for this opportunity to comment regarding the Preliminary Determination of Compliance (PDOC) for the Oakley Generating Station. I have commented on other PDOC's

It appears that on occasion the district does not comprehend in my comments that I "disagree with the District's proposal" as I do not necessarily denote in each statement or question that I "disagree" Please construe each of these comments/questions as "disagreement".

The District should re-notice the PDOC and publish a public notice which includes a demonstration of the ambient air quality and effects of project expressed consistent with the National Ambient Air Quality Standards

It is not clear why there is a public comment period for this PDOC and one at the CEC please explain the the authority for each comment period and differences. What is the potential recourse(s) if a member of the public is dissatisfied with the Districts response to comments? Is the district even required to respond to comments? If so under what Authority?

The PDOC states; "The California Legislature has granted the Energy Commission exclusive licensing authority for all thermal power plants in California of 50 megawatts or more. (See Warren-Alquist State Energy Resources Conservation and Development Act, Cal. Public Resources Code §§ 25000 et seq.) This licensing authority supersedes all other local and state permitting authority." Does the Clean Air Act recognize this authority?

Does the CEC have authority over the District SIP? Does the CEC have authority over the Districts responsibility under the Clean Air Act? Is the District required to issue an ATC or would the CEC license or FDOC act as an ATC and under what Authority? What would be the effect if the District chose not to participate in this action? How much money does the District receive if this facility is permitted? How much if it is not

Oakley PDOC comments

permitted?

Are there time periods for review of this application in which the District must respond?

What is the basis for time periods in permit considerations? What is the effect of going beyond the time periods? If the District issues an FDOC is that the District's Final Action? If the District issues an FDOC or ATC how long will it be valid? If the District chooses to extend the permit beyond the original issuance time period would the Clean Air Act or other rule require that they provide another public comment period? Under what Authority could the District extend the time period after expiration?

What is the global warming effect of water vapor emissions? Could water vapor, Carbon

Dioxide or heat from the facility create localized negative air quality effects or cause other pollutants to concentrate in the area.

Who has enforcement authority if the facility violates its permit(s). Have other facilities in the county violated their permits limits within the last 5 years? Please identify the specific violations and what enforcement has occurred as a basis to understand what can be expected at this facility.

The District would seem to wish to back load its environmental justice determination with the contention that "The District does not anticipate a significant adverse impact on any community due to air emissions from the Oakley Generating Station; therefore, there will be no significant disparate adverse impact on any Environmental Justice community located near the facility" The District appeared to skip the first step of EJ considerations which should be identifying EJ communities. Are there EJ communities which are in the area of the projects impacts? Would the District issue a permit for any facility where they did "anticipate a significant adverse impact" if not would this construction lead to the conclusion that EJ considerations are unimportant as the threshold for consideration would never be met and that the District should eliminate EJ considerations altogether or is it possible that EJ communities have a different threshold for consideration than the one the district uses for "any community"

What outreach has the District conducted in this proceeding beyond publishing a notice, which contains no details of Air Quality impacts? Has the District sent a Notice to the CEC list(s) for this proceeding? Has the District caused any notice to be published in the "Notices" section of this proceeding at the CEC or in the Intervenor's and Others' Documents section?

What is the effect of nitrogen Deposition from the project?

Oakley PDOC comments

This project does appear to require a PSD permit and one year of actual monitoring prior to issuance of a decision. The project appears to violate the Coastal Zone Management Act, Clean Air Act and Endangered Species Act.

If the project is required to operate in excess of its permitted levels for electrical reliability would the operation curtailment plan be enforceable? Has the District or any other air district ever caused curtailment of an operational electrical generation facility? Is the project required for electrical reliability?

The District should consider the life cycle air quality effects of natural gas use. The District should consider the effects of LNG use as a fuel since it is presently being imported into California for this type of use. Is it possible that the district would allow the permit to be amended to higher limits after the initial determination?

I request that the District conduct a hearing regarding this proceeding. I incorporate the comments of Robert Sarvey into these comments, by reference.

Rob Simpson
27126 Grandview Avenue
Hayward CA.
94542
rob@redwoodrob.com
510-909-1800

Thank you for this opportunity to comment regarding the Preliminary Determination of Compliance (PDOC) for the Oakley Generating Station. I have commented on other PDOC's. It appears that on occasion the district does not comprehend in my comments that I "disagree with the District's proposal" as I do not necessarily denote in each statement or question that I "disagree". Please construe each of these comments/questions as "disagreement".

The District should re-notice the PDOC and publish a public notice which includes a demonstration of the ambient air quality and effects of project expressed consistent with the National Ambient Air Quality Standards

It is not clear why there is a public comment period for this PDOC and one at the CEC please explain the authority for each comment period and differences. What is the potential recourse(s) if a member of the public is dissatisfied with the District's response to comments? Is the district even required to respond to comments? If so under what Authority?

The PDOC states; "The California Legislature has granted the Energy Commission exclusive licensing authority for all thermal power plants in California of 50 megawatts or more. (See Warren-Alquist State Energy Resources Conservation and Development Act, Cal. Public Resources Code §§ 25000 et seq.) This licensing authority supersedes all other local and state permitting authority." Does the Clean Air Act recognize this authority?

Does the CEC have authority over the District SIP? Does the CEC have authority over the District's responsibility under the Clean Air Act? Is the District required to issue an ATC or would the CEC license or FDOC act as an ATC and under what Authority?

What would be the effect if the District chose not to participate in this action?

How much money does the District receive if this facility is permitted? How much if it is not permitted?

Are there time periods for review of this application in which the District must respond? What is the basis for time periods in permit considerations? What is the effect of going beyond the time periods? If the District issues an FDOC is that the District's Final Action? If the District issues an FDOC or ATC how long will it be valid? If the District chooses to extend the permit beyond the original issuance time period would the Clean Air Act or other rule require that they provide another public comment period? Under what Authority could the District extend the time period after expiration?

What is the global warming effect of water vapor emissions? Could water vapor, Carbon Dioxide or heat from the facility create localized negative air quality effects or cause other pollutants to concentrate in the area.

Who has enforcement authority if the facility violates its permit(s). Have other facilities in the county violated their permits limits within the last 5 years? Please identify the specific violations and what enforcement has occurred as a basis to understand what can be expected at this facility.

The District would seem to wish to back load its environmental justice determination with the contention that "The District does not anticipate a significant adverse impact on any community due to air emissions from the Oakley Generating Station; therefore, there will be no significant disparate adverse impact on any Environmental Justice community located near the facility" The District appeared to skip the first step of EJ considerations which should be identifying EJ communities. Are there EJ communities which are in the area of the project's impacts? Would the District issue a permit

for any facility where they did "anticipate a significant adverse impact" if not would this construction lead to the conclusion that EJ considerations are unimportant as the threshold for consideration would never be met and that the District should eliminate EJ considerations altogether or is it possible that EJ communities have a different threshold for consideration than the one the district uses for "any community"

What outreach has the Districts conducted in this proceeding beyond publishing a notice, which contains no details of Air Quality impacts? Has the District sent a Notice to the CEC list(s) for this proceeding? Has the District caused any notice to be published in the "Notices" section of this proceeding at the CEC or in the Intervenor's and Others' Documents section?

What is the effect of nitrogen Deposition from the project?

This project does appear to require a PSD permit and one year of actual monitoring prior to issuance of a decision. The project appears to violate the Coastal Zone Management Act, Clean Air Act and Endangered Species Act.

If the project is required to operate in excess of its permitted levels for electrical reliability would the operation curtailment plan be enforceable? Has the District or any other air district ever caused curtailment of an operational electrical generation facility? Is the project required for electrical reliability?

The District should consider the life cycle air quality effects of natural gas use. The District should consider the effects of LNG use as a fuel since it is presently being imported into California for this type of use. Is it possible that the district would allow the permit to be amended to higher limits after the initial determination?

I request that the District conduct a hearing regarding this proceeding. I incorporate the comments of Robert Sarvey into these comments, by reference.

Rob Simpson
27126 Grandview Avenue
Hayward CA.
94542
rob@redwoodrob.com
510-909-1800