

**DOCKETED**

<b>Docket Number:</b>	18-IEPR-06
<b>Project Title:</b>	Integrating Renewable Energy
<b>TN #:</b>	223856
<b>Document Title:</b>	Renewable Integration Update
<b>Description:</b>	Presentation by Clyde Loutan at the June 20, 2018 IEPR Workshop on Renewable Integration and Electric System Flexibility
<b>Filer:</b>	Stephanie Bailey
<b>Organization:</b>	California ISO
<b>Submitter Role:</b>	Public
<b>Submission Date:</b>	6/19/2018 1:13:27 PM
<b>Docketed Date:</b>	6/19/2018



# Renewable Integration Update

Clyde Loutan

Principal, Renewable Energy Integration


2018 IEPR Commissioner Workshop on Renewable Integration  
and Electric System Flexibility, California Energy Commission

June 20, 2018

# STATUS

# Industry in the midst of unprecedented change

*- Driven by fast-growing mix of interrelated issues*



## Sample of operationally notable days with high renewable production


September 1, 2017: Peak demand of 50,116 MW

February 18, 2018: Minimum net load 7,149 MW

March 4, 2018: Maximum 3-hour upward ramp 14,777 MW  
Maximum 1-hour upward ramp 7,545 MW


May 25, 2018: Maximum demand served by wind/solar was 13,726 MW or 64%

# Actual net-load and 3-hour ramps are approximately four years ahead of the ISO's original estimate



# In 2017, the CAISO peak load was 50,116 MW and occurred at 15:58:24 on Friday, September 1

## Generation Breakdown --- 09/01/2017




Max net-load of 47,168 MW served by:  
 Imports: 24%  
 Hydro: 11%  
 Thermal: 56%  
 Other: 9%

- High temperatures along the coast
- Peak Load: 50,116 MW
- Peak net-load: 47,168 MW
- Peak load decreased by 2,948 MW
- Solar production decreased by 7,199 MW
- Net Load increased by 5,301 MW
- Essentially no wind

# On Sunday, February 18, 2018, the ISO experienced a minimum net-load of 7,149 MW @ 14:06

Generation Breakdown --- 02/18/2018




3-hr, 13,597 MW ramp met by:  
 - Import ~ 62%  
 - Hydro - 10%  
 - Thermal - 28%

- Max renewables curtailed 1,905 MW
- Total curtailment was 9,070 MWh
- Max EIM Export was 2,338 MW
- Diablo Unit 2 was off-line
- One of the biggest challenges during low minimum net-load is the capability to commit internal resources to meet the evening ramp and other AS requirements
- Rely on imports on low net-load days to meet ramps


# On Sunday, March 4, 2018 the maximum 3-hour upward ramp was 14,777 MW

**Generation Breakdown --- 03/04/2018**




- The CAISO markets economically optimized resources both internally and externally to meet demand
- Imports may or may not be available when needed to meet evening ramps
- Internal resources makes up about 64% of ramp
- Cannot rely on wind to meet ramps


The 3-Hour upward ramps are more than 50% of the daily peak demand, which indicates the need for faster ramping resources



# Maximum percentage of 1-minute load served by wind/solar, total RPS and non-Carbon resources




# Percentage of daily load served by wind/solar, total RPS and non-carbon resources



# Greenhouse gas reductions are occurring as renewables increase


YTD (January - March) million mTCO2	2015	2016	2017	2018
GHG Emission to serve ISO load	19.81	17.22	14.60	15.73



# Summary/Observations


- Load reliably served by renewable resources continue to grow
- GHG associated with serving the CAISO load has decreased 24% over the last four years
- Minimum net load continues to drop lower than expected
- Curtailment of renewable resources although low relative to total production is increasing
- Ramps are increasing and present a risk going forward if sufficient ramping capability does not exist
- During spring our reliance on imports and internal gas resources to meet the ramps is significant and creates opportunities for solutions
  - The CAISO relies heavily on imports to meet its ramps during days with low loads and high renewable production
  - During the spring months, at higher net-load levels, the CAISO relies on internal resources to meet its ramps

# CAISO proactively tracks real-time supply and demand balance as a measure of operational effectiveness







# Need to enhance operational performance during periods of increased supply variability

Wind/Solar vs. CPS1 --- 01/31/2016



CPS1 is NERC Control Performance Standard 1, which is evaluated on a rolling 12-month average. Over the past few years, the rolling average has been declining as a result of some poor daily performances. Thus, the CAISO need to take measures to enhance daily performance on days with higher variability.


# CAISO's average hourly CPS1 for the first four months of 2018 shows operational challenges during net-load ramps




# OPPORTUNITIES

# Opportunity 1: Manage oversupply and minimize curtailment

## Renewable Curtailment




# Opportunity 2: New price patterns incentivize innovation in responsive demand and storage



# Opportunity 3: Enhance operational performance during periods of increased supply variability


Wind/Solar vs. CPS1 --- 01/31/2016



CPS1 is NERC Control Performance Standard 1, which is evaluated on a rolling 12-month average. Over the past few years, the rolling average has been declining as a result of some poor daily performances. Thus, the CAISO need to take measures to enhance daily performance on days with higher variability.


# Opportunity 4: Enhance forecasting to manage supply uncertainty

## Current:



## Persistence Method:

- More recent actuals are used in forecast
- 6+ minutes are eliminated from lag



Forecast calculated in market, eliminating ALFS & processing time needed outside of CAISO

## Opportunity 5: Utilizing grid connected VERs to provide essential reliability services

- The CAISO is working with SCE and a solar developer to use an existing solar facility to participate in regulation up/down service
- The CAISO is tentatively scheduled to test a 131 MW wind plant in July 2018 for:
  - Regulation up/down capability
  - Voltage Control
  - Active Power Management Capability,
  - Frequency response
  - Inertia Capability

# SOLUTIONS

# A suite of solutions including VERs will be necessary



**Storage** – increase the effective participation by energy storage resources.



**Western EIM expansion** – expand the western Energy Imbalance Market.



**Demand response** – enhance DR initiatives to enable adjustments in consumer demand, both up and down, when warranted by grid conditions.



**Regional coordination** – offers more diversified set of clean energy resources through a cost effective and reliable regional market.



**Time-of-use rates** – implement time-of-use rates that match consumption with efficient use of clean energy supplies.



**Electric vehicles** – incorporate electric vehicle charging systems that are responsive to changing grid conditions.




**Minimum generation** – explore policies to reduce minimum operating levels for existing generators, thus making room for more renewable production.



**Flexible resources** – invest in modern, fast-responding resources that can follow sudden increases and decreases in demand.

# Western Energy Imbalance benefits: \$331 million

- Entities now in the implementation phase
  - ~ BANC/SMUD & Seattle City Light – Spring 2019
  - ~ Salt River Project, Seattle City Light, Los Angeles Department of Water & Power (LADWP) – Spring 2020
- Entities exploring future entry
  - ~ CENACE, Baja California, Mexico



# Energy imbalance market helps avoid curtailment

