

DOCKETED

Docket Number:	12-AFC-02C
Project Title:	Huntington Beach Energy Project - Compliance
TN #:	211428
Document Title:	South Coast Air Quality Management District Correspondance 05-06-16 Part 4
Description:	N/A
Filer:	Cindy Salazar
Organization:	CH2M HILL
Submitter Role:	Applicant Consultant
Submission Date:	5/10/2016 10:54:09 AM
Docketed Date:	5/10/2016

Calculated values for Specific Volume, BTU and F (factor)

Report Date: December 18, 2013
 Client: SCEC
 Project Location: OCSD
 Date Received: December 11, 2013
 Date Analyzed: December 11, 2013
 AtmAA Lab No.: 13453-9 P2E1

Specific volume, BTU, and F factor are calculated using laboratory analysis results for methane, carbon dioxide, nitrogen, oxygen, TGNMO, and sulfur compounds in equations that include assumed values for the specific volume of gases (CH₄, CO₂, N₂, O₂, Ar, and (CH₂)_n). The specific volume of gases were taken from the Scott Speciality Gases catalogue, 2001, and represents "as is" ideal gas at 60° F and 1 atm. The F factor is calculated according to the equation in ASTM D-3588.B89

Component	Mole %	Wt %	C,H,O,N,S, Wt. %	
Methane	62.07	38.13	Carbon	44.65
Carbon dioxide	34.79	58.76	Hydrogen	9.54
Nitrogen	2.24	2.41	Oxygen	43.37
Oxygen	0.51	0.63	Nitrogen	2.41
Argon	0.023	0.035	Argon	0.03
(CH ₂) _n	0.066	0.035	Sulfur	0.00
Specific Volume		14.361		
BTU/ft ³		627	HHV	565 LHV
BTU/ lb.		9010	HHV	8113 LHV
F (factor)		9259	HHV	10283 LHV

"as is" ideal gas at 60° F, 1 atm, where CH₄-1010H, 909.4L TGNMO-804H, 756L BTU/cu.ft.

Component	Specific volume reference values *
Methane	23.35 (ft ³ /lb)
Carbon dioxide	8.59
Nitrogen	13.54
Oxygen	11.87
Argon	9.52
(CH ₂) _n	10.428

* reference, Scott Specialty Gases Catalogue, 2001 adjusted to 60°F



Calculated values for SCAQMD RECLAIM HHV and F (factor)

Report Date: December 18, 2013
 Client: SCEC
 Project Location: OCSD
 Date Received: December 11, 2013
 Date Analyzed: December 11, 2013
 AtmAA Lab No.: 13453-9 P2E1

HHV, and F factor are calculated using laboratory analysis results for methane, carbon dioxide, nitrogen, oxygen, TGNMO, and sulfur compounds inserted into SCAQMD RECLAIM D3588 spreadsheet.
 Results represent a dry "real" gas at 60°F and 1 atm.

Component	Mole %	Wt %	C,H,O,N,S, Wt. %
Methane	62.29	38.13	Carbon 44.66
Carbon dioxide	34.91	58.77	Hydrogen 9.54
Nitrogen	2.25	2.41	Oxygen 43.40
Oxygen	0.54	0.66	Nitrogen 2.41
(CH ₂) _n	0.066	0.035	Sulfur 0.00
HHV (btu/scf)		620	
Average MW		26.14	
Gas Density (Ideal Gas)		0.06779	
Compressibility Factor		0.99702	
Gas Density (Real Gas)		0.06800	
HHV (btu/lb)		9116	
F Factor (dry)		9149	
F Factor - dry (60 F)		9011	
F Factor (wet)		11169	
F Factor - wet (60 F)		10999	
Fwet / Fdry		1.221	
Fc (dry)		1572	





LABORATORY ANALYSIS REPORT

Hydrogen Sulfide and Reduced Sulfur Compounds Analysis in Tedlar Bag Sample

Report Date: December 17, 2013
Client: SCEC
Project Location: OCSD Plant 2 / Fuel Sample
Project No.: 2061.1053
Date Received: December 6, 2013
Date Analyzed: December 6, 2013

ANALYSIS DESCRIPTION

Hydrogen sulfide was analyzed by gas chromatography with a Hall electrolytic conductivity detector operated in the oxidative sulfur mode. All other components were measured by GC/ Mass Spec.

AtmAA Lab No.: 13403-5
Sample I.D.: P2E2
(Concentration in ppmv)

Components	
Hydrogen sulfide	22.4
Carbonyl sulfide	<0.2
Methyl mercaptan	<0.2
Ethyl mercaptan	<0.2
Dimethyl sulfide	<0.2
Carbon disulfide	<0.2
isopropyl mercaptan	<0.2
n-propyl mercaptan	0.30
Dimethyl disulfide	<0.2
TRS	22.7

TRS - total reduced sulfur

Michael L. Porter
Laboratory Director

QUALITY ASSURANCE SUMMARY
(Repeat Analyses)

Project Location: OCSD Plant 2 / Fuel Sample

Date Received: December 6, 2013

Date Analyzed: December 6, 2013

Components	Sample ID	Repeat Analysis		Mean Conc.	% Diff. From Mean
		Run #1	Run #2		
		(Concentration in ppmv)			
Hydrogen sulfide	P2E2	22.0	22.9	22.4	2.0
Carbonyl sulfide	P2E2	<0.2	<0.2	---	---
Methyl mercaptan	P2E2	<0.2	<0.2	---	---
Ethyl mercaptan	P2E2	<0.2	<0.2	---	---
Dimethyl sulfide	P2E2	<0.2	<0.2	---	---
Carbon disulfide	P2E2	<0.2	<0.2	---	---
iso-propyl mercaptan	P2E2	<0.2	<0.2	---	---
n-propyl mercaptan	P2E2	0.30	0.31	0.30	1.6
Dimethyl disulfide	P2E2	<0.2	<0.2	---	---

One Tedlar bag sample, laboratory number 13403-5, was analyzed for total reduced sulfur compounds. Agreement between repeat analyses is a measure of precision and is shown above in the column "% Difference from Mean". The average % difference from mean for 2 repeat measurements from one Tedlar bag sample is 1.8%.





LABORATORY ANALYSIS REPORT

Speciated Hydrocarbons Analysis in Tedlar Bag Samples

Report Date: December 18, 2013
Client: SCEC
Site: OCSD
Project: Plant 2 / Fuel Samples
Project No.: 2061.1053

Date Received: December 6, 2013
Date Analyzed: December 6, 2013

ANALYSIS DESCRIPTION

Hydrocarbon Speciation analysis was performed by flame ionization detection/gas chromatography (FID/GC), modified EPA-18.

AtmAA Lab No.:	13403-5	(repeat)
Sample ID:	P2E2	P2E2
	(Concentration in ppmv, component)	
Methane	632000	636000
non-methane hydrocarbons		
analysis by carbon		
<u>number grouping</u>		
C2	2.71	2.93
C3	2.23	2.24
C4	0.56	0.56
C5	0.94	0.85
C6	0.76	0.74
C7	0.78	0.74
C8	1.94	1.35
C9	4.74	5.81
C10	22.82	23.58
C11	29.82	28.02
C12	3.40	3.62
C13	1.61	1.70
TNMHC	705	701

TNMHC - total non-methane hydrocarbons as ppmvC.

Michael L. Porter
Laboratory Director

Calculated values for Specific Volume, BTU and F (factor)

Report Date: December 18, 2013
 Client: SCEC
 Project Location: OCSD
 Date Received: December 6, 2013
 Date Analyzed: December 6, 2013
 AtmAA Lab No.: 13403-5 P2E2

Specific volume, BTU, and F factor are calculated using laboratory analysis results for methane, carbon dioxide, nitrogen, oxygen, TGNMO, and sulfur compounds in equations that include assumed values for the specific volume of gases (CH₄, CO₂, N₂, O₂, Ar, and (CH₂)_n). The specific volume of gases were taken from the Scott Speciality Gases catalogue, 2001, and represents "as is" ideal gas at 60° F and 1 atm. The F factor is calculated according to the equation in ASTM D-3588.B89

Component	Mole %	Wt %	C,H,O,N,S, Wt. %	
Methane	63.39	39.26	Carbon	45.60
Carbon dioxide	34.70	59.10	Hydrogen	9.82
Nitrogen	1.08	1.17	Oxygen	43.39
Oxygen	0.33	0.41	Nitrogen	1.17
Argon	0.015	0.023	Argon	0.02
(CH ₂) _n	0.070	0.038	Sulfur	0.00
Specific Volume		14.460		
BTU/ft ³		641	HHV	577 LHV
BTU/ lb.		9266	HHV	8343 LHV
F (factor)		9251	HHV	10274 LHV

"as is" ideal gas at 60° F, 1 atm, where CH₄-1010H, 909.4L TGNMO-804H, 756L BTU/cu.ft.

Component	Specific volume reference values *
Methane	23.35 (ft ³ /lb)
Carbon dioxide	8.59
Nitrogen	13.54
Oxygen	11.87
Argon	9.52
(CH ₂) _n	10.428

* reference, Scott Specialty Gases Catalogue, 2001 adjusted to 60°F



Calculated values for SCAQMD RECLAIM HHV and F (factor)

Report Date: December 18, 2013
 Client: SCEC
 Project Location: OCSD
 Date Received: December 6, 2013
 Date Analyzed: December 6, 2013
 AtmAA Lab No.: 13403-5 P2E2

HHV, and F factor are calculated using laboratory analysis results for methane, carbon dioxide, nitrogen, oxygen, TGNMO, and sulfur compounds inserted into SCAQMD RECLAIM D3588 spreadsheet.
 Results represent a dry "real" gas at 60°F and 1 atm.

Component	Mole %	Wt %	C,H,O,N,S, Wt. %
Methane	63.70	39.26	Carbon 45.60
Carbon dioxide	34.87	59.11	Hydrogen 9.82
Nitrogen	1.08	1.17	Oxygen 43.41
Oxygen	0.35	0.43	Nitrogen 1.17
(CH ₂) _n	0.070	0.038	Sulfur 0.00
HHV (btu/scf)		634	
Average MW		25.95	
Gas Density (Ideal Gas)		0.06732	
Compressibility Factor		0.99698	
Gas Density (Real Gas)		0.06752	
HHV (btu/lb)		9387	
F Factor (dry)		9130	
F Factor - dry (60 F)		8991	
F Factor (wet)		11149	
F Factor - wet (60 F)		10980	
Fwet / Fdry		1.221	
Fc (dry)		1559	





LABORATORY ANALYSIS REPORT

Hydrogen Sulfide and Reduced Sulfur Compounds Analysis in Tedlar Bag Sample

Report Date: December 23, 2013
Client: SCEC
Project Location: OCSD Plant 2 / Fuel Sample
Project No.: 2061.1053
Date Received: December 12, 2013
Date Analyzed: December 12, 2013

ANALYSIS DESCRIPTION

Hydrogen sulfide was analyzed by gas chromatography with a Hall electrolytic conductivity detector operated in the oxidative sulfur mode. All other components were measured by GC/ Mass Spec.

AtmAA Lab No.: 13463-40
Sample I.D.: P2E3
(Concentration in ppmv)

Components	
Hydrogen sulfide	<0.5
Carbonyl sulfide	<0.2
Methyl mercaptan	<0.2
Ethyl mercaptan	<0.2
Dimethyl sulfide	<0.2
Carbon disulfide	<0.2
isopropyl mercaptan	<0.2
n-propyl mercaptan	<0.2
Dimethyl disulfide	<0.2
TRS	<0.5

TRS - total reduced sulfur

Michael L. Porter
Laboratory Director

QUALITY ASSURANCE SUMMARY
(Repeat Analyses)

Project Location: OCSD Plant 2 / Fuel Sample

Date Received: December 12, 2013

Date Analyzed: December 12, 2013

Components	Sample ID	Repeat Analysis		Mean Conc.	% Diff. From Mean
		Run #1	Run #2		
		(Concentration in ppmv)			
Hydrogen sulfide	P2E3	<0.5	<0.5	---	---
Carbonyl sulfide	P2E3	<0.2	<0.2	---	---
Methyl mercaptan	P2E3	<0.2	<0.2	---	---
Ethyl mercaptan	P2E3	<0.2	<0.2	---	---
Dimethyl sulfide	P2E3	<0.2	<0.2	---	---
Carbon disulfide	P2E3	<0.2	<0.2	---	---
iso-propyl mercaptan	P2E3	<0.2	<0.2	---	---
n-propyl mercaptan	P2E3	<0.2	<0.2	---	---
Dimethyl disulfide	P2E3	<0.2	<0.2	---	---

One Tedlar bag sample, laboratory number 13403-40, was analyzed for total reduced sulfur compounds. Agreement between repeat analyses is a measure of precision and is shown above in the column "% Difference from Mean". No % difference from mean can be calculated from the one Tedlar bag sample.





LABORATORY ANALYSIS REPORT

Speciated Hydrocarbons Analysis in Tedlar Bag Samples

Report Date: December 23, 2013
Client: SCEC
Site: OCSD
Project: Plant 2 / Fuel Samples
Project No.: 2061.1053

Date Received: December 12, 2013
Date Analyzed: December 12, 2013

ANALYSIS DESCRIPTION

Hydrocarbon Speciation analysis was performed by flame ionization detection/gas chromatography (FID/GC), modified EPA-18.

AtmAA Lab No.:	13463-40	(repeat)
Sample ID:	P2E3	P2E3
	(Concentration in ppmv, component)	
Methane	628000	626000
non-methane hydrocarbons		
analysis by carbon		
<u>number grouping</u>		
C2	2.77	1.79
C3	2.45	2.44
C4	0.64	0.81
C5	0.97	1.02
C6	0.64	0.59
C7	0.86	0.87
C8	0.56	0.80
C9	4.13	5.45
C10	6.04	6.42
C11	3.80	3.59
C12	0.16	0.18
C13	1.90	0.17
TNMHC	201	192

TNMHC - total non-methane hydrocarbons as ppmvC.

Michael L. Porter
Laboratory Director

Calculated values for Specific Volume, BTU and F (factor)

Report Date: December 23, 2013
 Client: SCEC
 Project Location: OCSD
 Date Received: December 12, 2013
 Date Analyzed: December 12, 2013
 AtmAA Lab No.: 13463-40 P2E3

Specific volume, BTU, and F factor are calculated using laboratory analysis results for methane, carbon dioxide, nitrogen, oxygen, TGNMO, and sulfur compounds in equations that include assumed values for the specific volume of gases (CH₄, CO₂, N₂, O₂, Ar, and (CH₂)_n). The specific volume of gases were taken from the Scott Speciality Gases catalogue, 2001, and represents "as is" ideal gas at 60° F and 1 atm. The F factor is calculated according to the equation in ASTM D-3588.B89

Component	Mole %	Wt %	C,H,O,N,S, Wt.%	
Methane	62.70	38.63	Carbon	45.44
Carbon dioxide	35.62	60.35	Hydrogen	9.66
Nitrogen	0.72	0.78	Oxygen	44.11
Oxygen	0.18	0.22	Nitrogen	0.78
Argon	0.008	0.012	Argon	0.01
(CH ₂) _n	0.020	0.011	Sulfur	0.00
Specific Volume		14.340		
BTU/ft ³		633	HHV	570 LHV
BTU/ lb.		9083	HHV	8178 LHV
F (factor)		9303	HHV	10332 LHV

"as is" ideal gas at 60° F, 1 atm, where CH₄-1010H, 909.4L TGNMO-804H, 756L BTU/cu.ft.

Component	Specific volume reference values *
Methane	23.35 (ft ³ /lb)
Carbon dioxide	8.59
Nitrogen	13.54
Oxygen	11.87
Argon	9.52
(CH ₂) _n	10.428

* reference, Scott Specialty Gases Catalogue, 2001 adjusted to 60°F



Calculated values for SCAQMD RECLAIM HHV and F (factor)

Report Date: December 23, 2013
 Client: SCEC
 Project Location: OCSD
 Date Received: December 12, 2013
 Date Analyzed: December 12, 2013
 AtmAA Lab No.: 13463-40 P2E3

HHV, and F factor are calculated using laboratory analysis results for methane, carbon dioxide, nitrogen, oxygen, TGNMO, and sulfur compounds inserted into SCAQMD RECLAIM D3588 spreadsheet.
 Results represent a dry "real" gas at 60°F and 1 atm.

Component	Mole %	Wt %	C,H,O,N,S, Wt. %
Methane	63.19	38.63	Carbon 45.44
Carbon dioxide	35.90	60.36	Hydrogen 9.66
Nitrogen	0.73	0.78	Oxygen 44.12
Oxygen	0.19	0.23	Nitrogen 0.78
(CH ₂) _n	0.020	0.011	Sulfur 0.00
HHV (btu/scf)		629	
Average MW		26.17	
Gas Density (Ideal Gas)		0.06788	
Compressibility Factor		0.99693	
Gas Density (Real Gas)		0.06809	
HHV (btu/lb)		9231	
F Factor (dry)		9153	
F Factor - dry (60 F)		9015	
F Factor (wet)		11173	
F Factor - wet (60 F)		11004	
Fwet / Fdry		1.221	
Fc (dry)		1580	





LABORATORY ANALYSIS REPORT

Hydrogen Sulfide and Reduced Sulfur Compounds Analysis in Tedlar Bag Samples

Report Date: December 19, 2013
Client: SCEC
Project Location: OCSD Plant 2 / Fuel Samples
Project No.: 2061.1053
Date Received: December 10, 2013
Date Analyzed: December 10, 2013

ANALYSIS DESCRIPTION

Hydrogen sulfide was analyzed by gas chromatography with a Hall electrolytic conductivity detector operated in the oxidative sulfur mode. All other components were measured by GC/ Mass Spec.

AtmAA Lab No.:	13443-1	13443-2
Sample I.D.:	P2E4	P2E5
Components	(Concentration in ppmv)	
Hydrogen sulfide	18.0	16.9
Carbonyl sulfide	<0.2	<0.2
Methyl mercaptan	<0.2	<0.2
Ethyl mercaptan	<0.2	<0.2
Dimethyl sulfide	<0.2	<0.2
Carbon disulfide	<0.2	<0.2
isopropyl mercaptan	<0.2	<0.2
n-propyl mercaptan	0.26	0.28
Dimethyl disulfide	<0.2	<0.2
TRS	18.3	17.2

TRS - total reduced sulfur

Michael L. Porter
Laboratory Director

QUALITY ASSURANCE SUMMARY
(Repeat Analyses)

Project Location: OCSD Plant 2 / Fuel Samples

Date Received: December 10, 2013

Date Analyzed: December 10, 2013

Components	Sample ID	Repeat Analysis		Mean Conc.	% Diff. From Mean
		Run #1	Run #2		
		(Concentration in ppmv)			
Hydrogen sulfide	P2E4	17.0	18.9	18.0	5.3
	P2E5	17.2	16.6	16.9	1.8
Carbonyl sulfide	P2E4	<0.2	<0.2	---	---
	P2E5	<0.2	<0.2	---	---
Methyl mercaptan	P2E4	<0.2	<0.2	---	---
	P2E5	<0.2	<0.2	---	---
Ethyl mercaptan	P2E4	<0.2	<0.2	---	---
	P2E5	<0.2	<0.2	---	---
Dimethyl sulfide	P2E4	<0.2	<0.2	---	---
	P2E5	<0.2	<0.2	---	---
Carbon disulfide	P2E4	<0.2	<0.2	---	---
	P2E5	<0.2	<0.2	---	---
iso-propyl mercaptan	P2E4	<0.2	<0.2	---	---
	P2E5	<0.2	<0.2	---	---
n-propyl mercaptan	P2E4	0.25	0.27	0.26	3.8
	P2E5	0.28	0.28	0.28	0.0
Dimethyl disulfide	P2E4	<0.2	<0.2	---	---
	P2E5	<0.2	<0.2	---	---

Two Tedlar bag samples, laboratory numbers 13443-(1 & 2), were analyzed for total reduced sulfur compounds. Agreement between repeat analyses is a measure of precision and is shown above in the column "% Difference from Mean". The average % difference from mean for 4 repeat measurements from two Tedlar bag samples is 2.8%.





LABORATORY ANALYSIS REPORT

Speciated Hydrocarbons Analysis in Tedlar Bag Samples

Report Date: December 20, 2013
Client: SCEC
Site: OCSD
Project: Plant 2 / Fuel Samples
Project No.: 2061.1053

Date Received: December 10, 2013
Date Analyzed: December 10, 2013

ANALYSIS DESCRIPTION

Hydrocarbon Speciation analysis was performed by flame ionization detection/gas chromatography (FID/GC), modified EPA-18.

AtmAA Lab No.:	13443-1	(repeat)	13443-2
Sample ID:	P2E4	P2E4	P2E5
	(Concentration in ppmv, component)		
Methane	632000	634000	634000
non-methane hydrocarbons analysis by carbon number grouping			
C2	3.46	3.76	2.77
C3	2.21	2.25	2.16
C4	0.43	0.37	0.73
C5	1.07	0.98	1.12
C6	0.91	0.72	0.94
C7	1.09	0.92	1.02
C8	1.39	1.41	1.80
C9	5.75	6.34	5.50
C10	27.03	26.54	29.89
C11	27.69	26.95	30.40
C12	3.26	3.21	4.27
C13	1.45	1.44	1.63
TNMHC	729	719	803

TNMHC - total non-methane hydrocarbons as ppmvC.

Michael L. Porter
Laboratory Director

Calculated values for Specific Volume, BTU and F (factor)

Report Date: December 20, 2013
 Client: SCEC
 Project Location: OCSD
 Date Received: December 10, 2013
 Date Analyzed: December 10, 2013
 AtmAA Lab No.: 13443-1 P2E4

Specific volume, BTU, and F factor are calculated using laboratory analysis results for methane, carbon dioxide, nitrogen, oxygen, TGNMO, and sulfur compounds in equations that include assumed values for the specific volume of gases (CH₄, CO₂, N₂, O₂, Ar, and (CH₂)_n). The specific volume of gases were taken from the Scott Speciality Gases catalogue, 2001, and represents "as is" ideal gas at 60° F and 1 atm. The F factor is calculated according to the equation in ASTM D-3588.B89

Component	Mole %	Wt %	C,H,O,N,S, Wt. %
Methane	63.26	38.90	Carbon 45.58
Carbon dioxide	35.50	60.03	Hydrogen 9.73
Nitrogen	0.74	0.79	Oxygen 43.88
Oxygen	0.18	0.22	Nitrogen 0.79
Argon	0.008	0.012	Argon 0.01
(CH ₂) _n	0.072	0.039	Sulfur 0.00

Specific Volume	14.382			
BTU/ft ³	640	HHV	576	LHV
BTU/ lb.	9197	HHV	8282	LHV
F (factor)	9251	HHV	10274	LHV

"as is" ideal gas at 60° F, 1 atm, where CH₄-1010H, 909.4L TGNMO-804H, 756L BTU/cu.ft.

Component	Specific volume reference values *
Methane	23.35 (ft ³ /lb)
Carbon dioxide	8.59
Nitrogen	13.54
Oxygen	11.87
Argon	9.52
(CH ₂) _n	10.428

* reference, Scott Specialty Gases Catalogue, 2001 adjusted to 60°F



Calculated values for SCAQMD RECLAIM HHV and F (factor)

Report Date: December 20, 2013
 Client: SCEC
 Project Location: OCSD
 Date Received: December 10, 2013
 Date Analyzed: December 10, 2013
 AtmAA Lab No.: 13443-1 P2E4

HHV, and F factor are calculated using laboratory analysis results for methane, carbon dioxide, nitrogen, oxygen, TGNMO, and sulfur compounds inserted into SCAQMD RECLAIM D3588 spreadsheet.
 Results represent a dry "real" gas at 60°F and 1 atm.

Component	Mole %	Wt %	C,H,O,N,S, Wt. %
Methane	63.46	38.90	Carbon 45.58
Carbon dioxide	35.61	60.03	Hydrogen 9.73
Nitrogen	0.74	0.79	Oxygen 43.90
Oxygen	0.19	0.23	Nitrogen 0.79
(CH ₂) _n	0.072	0.039	Sulfur 0.00
HHV (btu/scf)		632	
Average MW		26.10	
Gas Density (Ideal Gas)		0.06769	
Compressibility Factor		0.99694	
Gas Density (Real Gas)		0.06789	
HHV (btu/lb)		9301	
F Factor (dry)		9147	
F Factor - dry (60 F)		9008	
F Factor (wet)		11166	
F Factor - wet (60 F)		10997	
Fwet / Fdry		1.221	
Fc (dry)		1573	



Calculated values for Specific Volume, BTU and F (factor)

Report Date: December 20, 2013
 Client: SCEC
 Project Location: OCSD
 Date Received: December 10, 2013
 Date Analyzed: December 10, 2013
 AtmAA Lab No.: 13443-2 P2E5


Specific volume, BTU, and F factor are calculated using laboratory analysis results for methane, carbon dioxide, nitrogen, oxygen, TGNMO, and sulfur compounds in equations that include assumed values for the specific volume of gases (CH₄, CO₂, N₂, O₂, Ar, and (CH₂)_n). The specific volume of gases were taken from the Scott Speciality Gases catalogue, 2001, and represents "as is" ideal gas at 60° F and 1 atm. The F factor is calculated according to the equation in ASTM D-3588.B89

Component	Mole %	Wt %	C,H,O,N,S, Wt. %	
Methane	63.45	38.97	Carbon	45.64
Carbon dioxide	35.55	60.03	Hydrogen	9.75
Nitrogen	0.72	0.77	Oxygen	43.83
Oxygen	0.14	0.17	Nitrogen	0.77
Argon	0.006	0.009	Argon	0.01
(CH ₂) _n	0.080	0.043	Sulfur	0.00
Specific Volume		14.389		
BTU/ft ³		641	HHV	578 LHV
BTU/ lb.		9231	HHV	8312 LHV
F (factor)		9236	HHV	10257 LHV

"as is" ideal gas at 60° F, 1 atm, where CH₄-1010H, 909.4L TGNMO-804H, 756L BTU/cu.ft.

Component	Specific volume reference values *
Methane	23.35 (ft ³ /lb)
Carbon dioxide	8.59
Nitrogen	13.54
Oxygen	11.87
Argon	9.52
(CH ₂) _n	10.428

* reference, Scott Specialty Gases Catalogue, 2001 adjusted to 60°F



Calculated values for SCAQMD RECLAIM HHV and F (factor)

Report Date: December 20, 2013
 Client: SCEC
 Project Location: OCSD
 Date Received: December 10, 2013
 Date Analyzed: December 10, 2013
 AtmAA Lab No.: 13443-2 P2E5

HHV, and F factor are calculated using laboratory analysis results for methane, carbon dioxide, nitrogen, oxygen, TGNMO, and sulfur compounds inserted into SCAQMD RECLAIM D3588 spreadsheet.
 Results represent a dry "real" gas at 60°F and 1 atm.

Component	Mole %	Wt %	C,H,O,N,S, Wt. %
Methane	63.53	38.97	Carbon 45.64
Carbon dioxide	35.59	60.04	Hydrogen 9.75
Nitrogen	0.72	0.77	Oxygen 43.84
Oxygen	0.15	0.18	Nitrogen 0.77
(CH ₂) _n	0.080	0.043	Sulfur 0.00
HHV (btu/scf)		632	
Average MW		26.08	
Gas Density (Ideal Gas)		0.06765	
Compressibility Factor		0.99694	
Gas Density (Real Gas)		0.06786	
HHV (btu/lb)		9318	
F Factor (dry)		9148	
F Factor - dry (60 F)		9010	
F Factor (wet)		11167	
F Factor - wet (60 F)		10998	
Fwet / Fdry		1.221	
Fc (dry)		1572	





LABORATORY ANALYSIS REPORT

environmental consultants
laboratory services

TO-15 Component Analysis in SUMMA Canister Samples, by GC/MS

Report Date: January 8, 2014
Client: SCEC
Project Location: OCSD / Plant 1 and 2
Client Project No.: 2061.1053
Date Received: December 12, 2013
Date Analyzed: December 17 & 18, 2013

AtmAA Lab No.:	13463-47	13463-48	13463-49	13463-50	13463-51	13463-52
Sample ID:	P2E1 Run 1	P2E1 Run 2	P2E1 Run 3	P2E2 Run 1	P2E2 Run 2	P2E2 Run 3
Components	(Concentrations in ppbv)					
Freon 12	<1	<1	<1	<1	<1	<1
Chloromethane	<1.4	<1.4	<1.4	<1.4	<1.4	<1.4
Freon 114	<1	<1	<1	<1	<1	<1
Vinyl Chloride	<1	<1	<1	<1	<1	<1
1,3-Butadiene	<1.4	<1.4	<1.4	<1.4	<1.4	<1.4
Bromomethane	<1.4	<1.4	<1.4	<1.4	<1.4	<1.4
Chloroethane	<1.4	<1.4	<1.4	<1.4	<1.4	<1.4
Bromoethene	<1.4	<1.4	<1.4	<1.4	<1.4	<1.4
Acetone	118	99.6	85.1	63.3	93.5	106
Freon 11	<1	<1	<1	<1	<1	<1
Isopropyl Alcohol	<2	<2	<2	<2	<2	<2
1,1-Dichloroethene	<1.4	<1.4	<1.4	<1.4	<1.4	<1.4
Methylene Chloride	<1.4	<1.4	<1.4	<1.4	<1.4	<1.4
3-Chloro-1-Propene	<1.4	<1.4	<1.4	<1.4	<1.4	<1.4
Carbon Disulfide	<1.4	<1.4	1.41	<1.4	1.59	3.26
Freon 113	<1.4	<1.4	<1.4	<1.4	<1.4	<1.4
trans-1,2-Dichloroethene	<1.4	<1.4	<1.4	<1.4	<1.4	<1.4
1,1-Dichloroethane	<1.4	<1.4	<1.4	<1.4	<1.4	<1.4
MTBE	<1.4	<1.4	<1.4	<1.4	<1.4	<1.4
Vinyl Acetate	<1.4	<1.4	<1.4	<1.4	<1.4	<1.4
2-Butanone	18.7	15.3	15.0	11.3	12.4	12.2
cis-1,2-Dichloroethene	<1.4	<1.4	<1.4	<1.4	<1.4	<1.4
n-Hexane	5.28	5.05	4.53	2.89	2.53	2.55
Chloroform	<1	<1	<1	<1	<1	<1
Ethyl Acetate	<1.4	<1.4	<1.4	<1.4	<1.4	<1.4
Tetrahydrofuran	2.19	1.62	1.46	<1.4	<1.4	<1.4
1,2-Dichloroethane	<1.4	<1.4	<1.4	<1.4	<1.4	<1.4
1,1,1-Trichloroethane	<1	<1	<1	<1	<1	<1
Benzene	23.6	23.2	21.8	5.48	5.31	5.08
Carbon Tetrachloride	<1	<1	<1	<1	<1	<1
Cyclohexane	<1.4	<1.4	<1.4	<1.4	<1.4	<1.4
1,2-Dichloropropane	<1.4	<1.4	<1.4	<1.4	<1.4	<1.4
Bromodichloromethane	<1.4	<1.4	<1.4	<1.4	<1.4	<1.4
Trichloroethene	<1	<1	<1	<1	<1	<1
1,4-Dioxane	<1.4	<1.4	<1.4	<1.4	<1.4	<1.4
2,2,4-Trimethylpentane	<1.4	<1.4	<1.4	<1.4	<1.4	<1.4
n-Heptane	2.74	2.60	2.43	<1.4	<1.4	<1.4
cis-1,3-Dichloropropene	<1.4	<1.4	<1.4	<1.4	<1.4	<1.4
4-Methyl-2-pentanone	<1.4	<1.4	<1.4	<1.4	<1.4	<1.4
trans-1,3-Dichloropropene	<1.4	<1.4	<1.4	<1.4	<1.4	<1.4
1,1,2-Trichloroethane	<1.4	<1.4	<1.4	<1.4	<1.4	<1.4
Toluene	12.6	12.3	12.0	2.55	2.39	2.23
2-Hexanone	2.56	1.98	1.96	<1.4	1.52	<1.4
Dibromochloromethane	<1.4	<1.4	<1.4	<1.4	<1.4	<1.4
1,2-Dibromomethane	<1.4	<1.4	<1.4	<1.4	<1.4	<1.4
Tetrachloroethene	<1	<1	<1	<1	<1	<1
Chlorobenzene	<1.4	<1.4	<1.4	<1.4	<1.4	<1.4
Ethylbenzene	<1.4	<1.4	<1.4	<1.4	<1.4	<1.4
m,p-Xylene	3.16	3.80	2.90	<1.4	<1.4	<1.4
Bromoform	<1	<1	<1	<1	<1	<1
Styrene	<1.4	<1.4	<1.4	<1.4	<1.4	<1.4
1,1,2,2-Tetrachloroethane	<1.4	<1.4	<1.4	<1.4	<1.4	<1.4
o-Xylene	<1.4	<1.4	<1.4	<1.4	<1.4	<1.4
Benzyl Chloride	<1.4	<1.4	<1.4	<1.4	<1.4	<1.4
4-Ethyltoluene	<1.4	<1.4	<1.4	<1.4	<1.4	<1.4
1,3,5-Trimethylbenzene	<1.4	<1.4	<1.4	<1.4	<1.4	<1.4
1,2,4-Trimethylbenzene	<1.4	<1.4	<1.4	<1.4	<1.4	<1.4
1,3-Dichlorobenzene	<1	<1	<1	<1	<1	<1
1,4-Dichlorobenzene	<1	<1	<1	<1	<1	<1
1,2-Dichlorobenzene	<1	<1	<1	<1	<1	<1
1,2,4-Trichlorobenzene	<1.4	<1.4	<1.4	<1.4	<1.4	<1.4
Hexachlorobutadiene	<1.4	<1.4	<1.4	<1.4	<1.4	<1.4

Michael L. Porter
Michael L. Porter
Laboratory Director

QUALITY ASSURANCE SUMMARY
(Repeat Analyses)


Project Location: OCSD / Plant 1 and 2
Date Received: December 12, 2013
Date Analyzed: December 17 & 18, 2013

Components	Sample ID	Repeat Analysis		Mean Conc.	% Diff. From Mean
		Run #1	Run #2		
		(Concentration in ppbv)			
Freon 12	P1E2 Run 1	<1	<1	---	---
	P2E1 Run 1	<1	<1	---	---
Chloromethane	P1E2 Run 1	<1.4	<1.4	---	---
	P2E1 Run 1	<1.4	<1.4	---	---
Freon 114	P1E2 Run 1	<1	<1	---	---
	P2E1 Run 1	<1	<1	---	---
Vinyl Chloride	P1E2 Run 1	<1	<1	---	---
	P2E1 Run 1	<1	<1	---	---
1,3-Butadiene	P1E2 Run 1	<1.4	<1.4	---	---
	P2E1 Run 1	<1.4	<1.4	---	---
Bromomethane	P1E2 Run 1	<1.4	<1.4	---	---
	P2E1 Run 1	<1.4	<1.4	---	---
Chloroethane	P1E2 Run 1	<1.4	<1.4	---	---
	P2E1 Run 1	<1.4	<1.4	---	---
Bromoethene	P1E2 Run 1	<1.4	<1.4	---	---
	P2E1 Run 1	<1.4	<1.4	---	---
Acetone	P1E2 Run 1	118	127	122	3.7
	P2E1 Run 1	117	119	118	0.85
Freon 11	P1E2 Run 1	<1	<1	---	---
	P2E1 Run 1	<1	<1	---	---
Isopropyl Alcohol	P1E2 Run 1	<2	<2	---	---
	P2E1 Run 1	<2	<2	---	---
1,1-Dichloroethene	P1E2 Run 1	<1.4	<1.4	---	---
	P2E1 Run 1	<1.4	<1.4	---	---
Methylene Chloride	P1E2 Run 1	<1.4	<1.4	---	---
	P2E1 Run 1	<1.4	<1.4	---	---
3-Chloro-1-Propene	P1E2 Run 1	<1.4	<1.4	---	---
	P2E1 Run 1	<1.4	<1.4	---	---
Carbon Disulfide	P1E2 Run 1	<1.4	<1.4	---	---
	P2E1 Run 1	<1.4	<1.4	---	---
Freon 113	P1E2 Run 1	<1.4	<1.4	---	---
	P2E1 Run 1	<1.4	<1.4	---	---




QUALITY ASSURANCE SUMMARY
(Repeat Analyses)
(continued)

Components	Sample ID	Repeat Analysis		Mean Conc.	% Diff. From Mean
		Run #1	Run #2		
		(Concentration in ppbv)			
trans-1,2-Dichloroethene	P1E2 Run 1	<1.4	<1.4	---	---
	P2E1 Run 1	<1.4	<1.4	---	---
1,1-Dichloroethane	P1E2 Run 1	<1.4	<1.4	---	---
	P2E1 Run 1	<1.4	<1.4	---	---
MTBE	P1E2 Run 1	<1.4	<1.4	---	---
	P2E1 Run 1	<1.4	<1.4	---	---
Vinyl Acetate	P1E2 Run 1	<1.4	<1.4	---	---
	P2E1 Run 1	<1.4	<1.4	---	---
2-Butanone	P1E2 Run 1	108	108	108	0.0
	P2E1 Run 1	19.3	18.1	18.7	3.2
cis-1,2-Dichloroethene	P1E2 Run 1	<1.4	<1.4	---	---
	P2E1 Run 1	<1.4	<1.4	---	---
n-Hexane	P1E2 Run 1	3.86	4.19	4.02	4.1
	P2E1 Run 1	5.46	5.11	5.28	3.3
Chloroform	P1E2 Run 1	<1	<1	---	---
	P2E1 Run 1	<1	<1	---	---
Ethyl Acetate	P1E2 Run 1	<1.4	<1.4	---	---
	P2E1 Run 1	<1.4	<1.4	---	---
Tetrahydrofuran	P1E2 Run 1	5.08	4.77	4.92	3.1
	P2E1 Run 1	2.01	2.37	2.19	8.2
1,2-Dichloroethane	P1E2 Run 1	<1.4	<1.4	---	---
	P2E1 Run 1	<1.4	<1.4	---	---
1,1,1-Trichloroethane	P1E2 Run 1	<1	<1	---	---
	P2E1 Run 1	<1	<1	---	---
Benzene	P1E2 Run 1	59.6	62.9	61.2	2.7
	P2E1 Run 1	23.6	23.5	23.6	0.21
Carbon Tetrachloride	P1E2 Run 1	<1	<1	---	---
	P2E1 Run 1	<1	<1	---	---
Cyclohexane	P1E2 Run 1	<1.4	<1.4	---	---
	P2E1 Run 1	<1.4	<1.4	---	---
1,2-Dichloropropane	P1E2 Run 1	<1.4	<1.4	---	---
	P2E1 Run 1	<1.4	<1.4	---	---
Bromodichloromethane	P1E2 Run 1	<1.4	<1.4	---	---
	P2E1 Run 1	<1.4	<1.4	---	---



QUALITY ASSURANCE SUMMARY
(Repeat Analyses)
(continued)


Components	Sample ID	Repeat Analysis		Mean Conc.	% Diff. From Mean
		Run #1	Run #2		
		(Concentration in ppbv)			
Trichloroethene	P1E2 Run 1	<1	<1	---	---
	P2E1 Run 1	<1	<1	---	---
1,4-Dioxane	P1E2 Run 1	<1.4	<1.4	---	---
	P2E1 Run 1	<1.4	<1.4	---	---
2,2,4-Trimethylpentane	P1E2 Run 1	<1.4	<1.4	---	---
	P2E1 Run 1	<1.4	<1.4	---	---
n-Heptane	P1E2 Run 1	3.08	3.55	3.32	7.1
	P2E1 Run 1	2.89	2.58	2.74	5.7
cis-1,3-Dichloropropene	P1E2 Run 1	<1.4	<1.4	---	---
	P2E1 Run 1	<1.4	<1.4	---	---
4-Methyl-2-pentanone	P1E2 Run 1	3.14	3.23	3.18	1.4
	P2E1 Run 1	<1.4	<1.4	---	---
trans-1,3-Dichloropropene	P1E2 Run 1	<1.4	<1.4	---	---
	P2E1 Run 1	<1.4	<1.4	---	---
1,1-2-Trichloroethane	P1E2 Run 1	<1.4	<1.4	---	---
	P2E1 Run 1	<1.4	<1.4	---	---
Toluene	P1E2 Run 1	18.2	19.4	18.8	3.2
	P2E1 Run 1	12.9	12.4	12.6	2.0
2-Hexanone	P1E2 Run 1	17.9	18.5	18.2	1.6
	P2E1 Run 1	2.71	2.42	2.56	5.6
Dibromochloromethane	P1E2 Run 1	<1.4	<1.4	---	---
	P2E1 Run 1	<1.4	<1.4	---	---
1,2-Dibromomethane	P1E2 Run 1	<1.4	<1.4	---	---
	P2E1 Run 1	<1.4	<1.4	---	---
Tetrachloroethene	P1E2 Run 1	<1	<1	---	---
	P2E1 Run 1	<1	<1	---	---
Chlorobenzene	P1E2 Run 1	<1.4	<1.4	---	---
	P2E1 Run 1	<1.4	<1.4	---	---
Ethylbenzene	P1E2 Run 1	2.01	2.12	2.06	2.7
	P2E1 Run 1	<1.4	<1.4	---	---
m,p-Xylene	P1E2 Run 1	3.06	3.31	3.18	3.9
	P2E1 Run 1	3.21	3.11	3.16	1.6
Bromoform	P1E2 Run 1	<1	<1	---	---
	P2E1 Run 1	<1	<1	---	---



QUALITY ASSURANCE SUMMARY
(Repeat Analyses)
(continued)

Components	Sample ID	Repeat Analysis		Mean Conc.	% Diff. From Mean
		Run #1	Run #2		
		(Concentration in ppbv)			
Styrene	P1E2 Run 1	2.30	2.76	2.53	9.1
	P2E1 Run 1	<1.4	<1.4	---	---
1,1,2,2-Tetrachloroethane	P1E2 Run 1	<1.4	<1.4	---	---
	P2E1 Run 1	<1.4	<1.4	---	---
o-Xylene	P1E2 Run 1	<1.4	1.44	---	---
	P2E1 Run 1	<1.4	<1.4	---	---
Benzyl Chloride	P1E2 Run 1	<1.4	<1.4	---	---
	P2E1 Run 1	<1.4	<1.4	---	---
4-Ethyltoluene	P1E2 Run 1	<1.4	<1.4	---	---
	P2E1 Run 1	<1.4	<1.4	---	---
1,3,5-Trimethylbenzene	P1E2 Run 1	<1.4	<1.4	---	---
	P2E1 Run 1	<1.4	<1.4	---	---
1,2,4-Trimethylbenzene	P1E2 Run 1	<1.4	<1.4	---	---
	P2E1 Run 1	<1.4	<1.4	---	---
1,3-Dichlorobenzene	P1E2 Run 1	<1	<1	---	---
	P2E1 Run 1	<1	<1	---	---
1,4-Dichlorobenzene	P1E2 Run 1	<1	<1	---	---
	P2E1 Run 1	<1	<1	---	---
1,2-Dichlorobenzene	P1E2 Run 1	<1	<1	---	---
	P2E1 Run 1	<1	<1	---	---
1,2,4-Trichlorobenzene	P1E2 Run 1	<1.4	<1.4	---	---
	P2E1 Run 1	<1.4	<1.4	---	---
Hexachlorobutadiene	P1E2 Run 1	<1.4	<1.4	---	---
	P2E1 Run 1	<1.4	<1.4	---	---

Twelve SUMMA canister samples, laboratory numbers 13463-(41-52), were analyzed for TO-15 components by GC/MS. Agreement between repeat analyses is a measure of precision and is shown above in the column "% Difference from Mean". The average % difference from mean for 21 repeat measurements from 12 SUMMA canister samples is 3.5%.



GRAVIMETRIC ANALYSIS

CLIENT: OCS D
 REPORT#: 2061-1053
 TEST DATE: 12/11/13

ANALYST: AC
 METHOD: SCA Q m 1 5-1

LOCATION/UNIT: <u>P2E1</u>			RUN #: <u>1</u>		
FRACTION	VOLUME	EVAP DISH	SAMPLE WEIGHTS		
			Weight (g)	Weight (g)	Weight (g)
Probe/Nozzle		Tare:	Date/Time:	Date/Time:	Date/Time:
Condensable (Inorg)	<u>470 ml</u>	<u>E-24</u> Tare: <u>99.6975</u>	<u>99.7077</u> Date/Time: <u>12/30 9:15</u>	<u>99.7075</u> Date/Time: <u>12/31 9:41</u>	
Condensable (Org)	<u>125 ml</u>	<u>E-82</u> Tare: <u>101.4818</u>	<u>101.4840</u> Date/Time: <u>12/30 10:00</u>	<u>101.4839</u> Date/Time: <u>12/31 9:50</u>	
Filter <u>55-839</u> Tare: <u>.13966</u>	----	----	<u>.14107</u> Date/Time: <u>12/27 8:31</u>	<u>.14105</u> Date/Time: <u>12/27/13 8:26</u>	

LOCATION/UNIT: <u>P2E</u>			RUN #: <u>2</u>		
FRACTION	VOLUME	EVAP DISH	SAMPLE WEIGHTS		
			Weight (g)	Weight (g)	Weight (g)
Probe/Nozzle		Tare:	Date/Time:	Date/Time:	Date/Time:
Condensable (Inorg)	<u>548 ml</u>	<u>E-113</u> Tare: <u>115.2026</u>	<u>115.2135</u> Date/Time: <u>12/30 8:43</u>	<u>115.2133</u> Date/Time: <u>12/31 8:17</u>	
Condensable (Org)	<u>125 ml</u>	<u>E-92</u> Tare: <u>113.1201</u>	<u>113.1234</u> Date/Time: <u>12/30 9:48</u>	<u>113.1232</u> Date/Time: <u>12/31 9:06</u>	
Filter <u>55-837</u> Tare: <u>.13802</u>	----	----	<u>.14075</u> Date/Time: <u>12/27 8:34</u>	<u>.14077</u> Date/Time: <u>12/27/13 8:28</u>	

LOCATION/UNIT: <u>P2E</u>			RUN #: <u>3</u>		
FRACTION	VOLUME	EVAP DISH	SAMPLE WEIGHTS		
			Weight (g)	Weight (g)	Weight (g)
Probe/Nozzle		Tare:	Date/Time:	Date/Time:	Date/Time:
Condensable (Inorg)	<u>506 ml</u>	<u>E-8</u> Tare: <u>118.8226</u>	<u>118.8262</u> Date/Time: <u>12/30 8:50</u>	<u>118.8250</u> Date/Time: <u>12/31 8:45</u>	<u>118.8254</u> Date/Time: <u>01/02 8:25</u>
Condensable (Org)	<u>125 ml</u>	<u>E-34</u> Tare: <u>97.0818</u>	<u>97.0850</u> Date/Time: <u>12/30 10:15</u>	<u>97.0842</u> Date/Time: <u>12/31 9:24</u>	<u>97.0839</u> Date/Time: <u>01/02 8:34</u>
Filter <u>55-834</u> Tare: <u>.15722</u>	----	----	<u>.15742</u> Date/Time: <u>12/27 8:37</u>	<u>.15743</u> Date/Time: <u>12/30/13 8:30</u>	

GRAVIMETRIC ANALYSIS

CLIENT: OCSD
 REPORT#: 2061-1053
 TEST DATE: _____

ANALYST: AE
 METHOD: SCAQMD 5-1

LOCATION/UNIT: <u>P2E4</u>			RUN #: <u>41</u>		
FRACTION	VOLUME	EVAP DISH	SAMPLE WEIGHTS		
			Weight (g)	Weight (g)	Weight (g)
Probe/Nozzle		Tare:	Date/Time:	Date/Time:	Date/Time:
Condensable (Inorg)	<u>538 ml</u>	<u>E 120</u> Tare: <u>114.3112</u>	<u>114.3150</u> Date/Time: <u>12/30 9:10</u>	<u>114.3146</u> Date/Time: <u>12/31 8:54</u>	Date/Time:
Condensable (Org)	<u>125 ml</u>	<u>E 96</u> Tare: <u>113.7054</u>	<u>113.7072</u> Date/Time: <u>12/30 10:02</u>	<u>113.7071</u> Date/Time: <u>12/31 9:53</u>	Date/Time:
Filter <u>55-822</u> Tare: <u>.15372</u>	----	----	<u>.15479</u> Date/Time: <u>12/27 8:40</u>	<u>.15479</u> Date/Time: <u>12/30/13 8:32</u>	Date/Time:

LOCATION/UNIT: <u>P2E5</u>			RUN #: <u>51</u>		
FRACTION	VOLUME	EVAP DISH	SAMPLE WEIGHTS		
			Weight (g)	Weight (g)	Weight (g)
Probe/Nozzle		Tare:	Date/Time:	Date/Time:	Date/Time:
Condensable (Inorg)	<u>4184 ml</u>	<u>E 70</u> Tare: <u>118.5642</u>	<u>118.5687</u> Date/Time: <u>12/30 8:53</u>	<u>118.5681</u> Date/Time: <u>12/31 8:50</u>	Date/Time: <u>01/02 8:29</u>
Condensable (Org)	<u>125 ml</u>	<u>E 18</u> Tare: <u>101.2149</u>	<u>101.2180</u> Date/Time: <u>12/30 9:56</u>	<u>101.2178</u> Date/Time: <u>12/31 9:14</u>	Date/Time:
Filter <u>55-835</u> Tare: <u>.15832</u>	----	----	<u>.15955</u> Date/Time: <u>12/27 8:43</u>	<u>.15955</u> Date/Time: <u>12/30/13 8:34</u>	Date/Time:

LOCATION/UNIT: <u>Blanks</u>			RUN #:		
FRACTION	VOLUME	EVAP DISH	SAMPLE WEIGHTS		
			Weight (g)	Weight (g)	Weight (g)
Probe/Nozzle		Tare:	Date/Time:	Date/Time:	Date/Time:
<u>DI water</u> Condensable (Inorg)	<u>250 ml</u>	<u>E 109</u> Tare: <u>110.2146</u>	<u>110.2147</u> Date/Time: <u>12/30 9:28</u>	<u>110.2146</u> Date/Time: <u>12/31 8:30</u>	Date/Time:
<u>Methylene Chloride</u> Condensable (Org)	<u>200 ml</u>	<u>E 80</u> Tare: <u>118.1548</u>	<u>118.1548</u> Date/Time: <u>12/30 9:59</u>	<u>118.1548</u> Date/Time: <u>12/31 9:20</u>	Date/Time:
Filter	----	----	Date/Time:	Date/Time:	Date/Time:

Appendix G
Calibration Data and Calibration Gas Certificates

CB-11

CERTIFICATE OF CALIBRATION

CUSTOMER: SOUTH COAST ENVIRONMENTAL ORANGE CA
PO NUMBER: 4531
INST. MANUFACTURER: APEX INSTRUMENTS
INST. DESCRIPTION: AIR SAMPLER
MODEL NUMBER: XC-60A
SERIAL NUMBER: 0608010
RATED UNCERTAINTY: +/-1% RD.
UNCERTAINTY GIVEN: FLOW measurement uncertainty: +/- .199% RD. K=2
NOTES: AS RECEIVED/ AS LEFT WITHIN SPECS. REFERENCE CONDITIONS ARE: 760 mm HGA 70 F

CALIBRATION DATE: 03/11/13
CALIBRATION DUE: 03/11/14
PROCEDURE: NAVAIR 17-20MG-02
CALIBRATION FLUID: AIR @ 14.7 PSIA 70 F
STANDARD(S) USED: A797, A24 DUE 07-2013
NIST TRACE #' S: 1361269184, 1360578741, 1360586185
AMBIENT CONDITIONS: 765 mm HGA 46 % RH 69 F
CERTIFICATE FILE #: 432503.13

TEST POINT NUMBER	UUT INDICATED	DM.STD. ACTUAL	CORRECTION FACTOR	UUT INDICATED	DM.STD. ACTUAL
	M3/HR	M3/HR		FLOWMETER	FLOWMETER
	PD.METER	PD.METER		SCCM	SCCM
1	0.050	0.050	1.000	100	101.2
2	0.100	0.100	1.000	400	404.1
3	0.249	0.250	1.004	600	605.6
4	0.498	0.500	1.004	800	808.0
5	0.997	1.000	1.003	1000	1008.9
6	1.494	1.500	1.004	GAUGE	GAUGE
7	1.991	2.000	1.005	"HG VAC.	"HG VAC.
8	2.488	2.500	1.005	0-30	0-30
		AVERAGE	1.00305	TEMPERATURE	TEMPERATURE
				F DEG.	F DEG.
				72	71.91

All instruments used in the performance of the shown calibration have traceability to the National Institute of Standards and Technology (NIST). The uncertainty ratio between the calibration standards (DM.STD.) used and the unit under test (UUT) is a minimum of 4:1, unless otherwise noted. Calibration has been performed per the shown procedure number, in accordance with ISO 10012:2003, ISO 17025:2005, ANSI/NCSL-Z-540.3, and/or MIL-STD-45662A. Test methods: API2530-92 & ASME MFC-3M-1989.

Dick Munns Company • 10572 Calle Lee #138 • Los Alamitos, CA 90720
 Phone (714) 827-1215 • Fax (714) 827-0823


This Calibration Certificate shall not be reproduced except, in full, without approval by DICK MUNNS COMPANY. The data shown applies only to the instrument being calibrated and under the stated conditions of calibration.


Date:

Approved By:

Calibration Technician:

3/11/2013





Page 1 of 1

CB-12

CERTIFICATE OF CALIBRATION

CUSTOMER: SOUTH COAST ENVIRONMENTAL ORANGE CA
PO NUMBER: 4531
INST. MANUFACTURER: APEX INSTRUMENTS
INST. DESCRIPTION: AIR SAMPLER
MODEL NUMBER: XC-60A
SERIAL NUMBER: 0602002
RATED UNCERTAINTY: +/-1% RD.
UNCERTAINTY GIVEN: FLOW measurement uncertainty: +/- .199% RD. K=2
NOTES: AS RECEIVED/ AS LEFT WITHIN SPECS. REFERENCE CONDITIONS ARE: 760 mm HGA 70 F

CALIBRATION DATE: 03/11/13
CALIBRATION DUE: 03/11/14
PROCEDURE: NAVAIR 17-20MG-02
CALIBRATION FLUID: AIR @ 14.7 PSIA 70 F
STANDARD(S) USED: A797, A24 DUE 07-2013
NIST TRACE #'S: 1361269184, 1360578741, 1360586185
AMBIENT CONDITIONS: 765 mm HGA 46 % RH 69 F
CERTIFICATE FILE #: 432502.13

TEST POINT	UUT	DM.STD.		UUT	DM.STD.	
NUMBER	INDICATED	ACTUAL	CORRECTION	INDICATED	ACTUAL	
	M3/HR	M3/HR	FACTOR	FLOWMETER	FLOWMETER	
	PD.METER	PD.METER		SCCM	SCCM	
1	0.050	0.050	1.000	100	100.8	
2	0.100	0.100	1.000	400	403.6	
3	0.251	0.250	0.996	600	604.9	
4	0.502	0.500	0.996	800	807.5	
5	1.002	1.000	0.998	1000	1008.2	
6	1.504	1.500	0.997	GAUGE	GAUGE	
7	2.007	2.000	0.997	"HG VAC.	"HG VAC.	
8	2.510	2.500	0.996	0-30	0-30	
		AVERAGE	0.99749	TEMPERATURE	TEMPERATURE	
				F DEG.	F DEG.	
				71	70.93	

All instruments used in the performance of the shown calibration have traceability to the National Institute of Standards and Technology (NIST). The uncertainty ratio between the calibration standards (DM.STD.) used and the unit under test (UUT) is a minimum of 4:1, unless otherwise noted. Calibration has been performed per the shown procedure number, in accordance with ISO 10012:2003, ISO 17025:2005, ANSI/NCSL-Z-540.3, and/or MIL-STD-45662A. Test methods: API2530-92 & ASME MFC-3M-1989.

Dick Munns Company • 10572 Calle Lee #138 • Los Alamitos, CA 90720
 Phone (714) 827-1215 • Fax (714) 827-0823

This Calibration Certificate shall not be reproduced except, in full, without approval by DICK MUNN'S COMPANY. The data shown applies only to the instrument being calibrated and under the stated conditions of calibration.

Date:

Approved By:

Calibration Technician:

3/11/2013





James Acosta

Page 1 of 1

Table 2G-1. Type S Probe Inspection Sheet

Note: Method 2 provides the criteria for an acceptably constructed Type S pitot tube. However, the procedure for making the necessary measurements is not specified. One approach is given below.

1. Use a vise with parallel and perpendicular faces. Use an angle-measuring device (analog or digital) for this check.
2. Place the pitot tube in the vise, and level the pitot tube horizontally using the angle-measuring device.
3. Place the angle-measuring device as shown below.
4. Measure distance A, which is P_A plus P_B . Method 2 specifies that $P_A = P_B$, but provides no tolerance for this measurement. Because this measurement is very difficult, it is suggested that $P_A = P_B = A/2$.
5. Measure the external tube diameter (D_t) with a micrometer, machinist's rule, or internal caliper.
6. Record all data as shown on the form below.
7. Calculate dimensions w and z as shown below.

 <p>Degree indicating level position for determining α_1 and α_2</p>	Level and perpendicular?	Y
 <p>Degree indicating level position for determining β_1 and β_2</p>	Obstruction?	N
 <p>Degree indicating level position for determining θ</p>	Damaged?	N
 <p>Degree indicating level position for determining γ, then calculating z.</p>	α_1 $(-2^\circ \leq \alpha_1 \leq +2^\circ)$	0
	α_2 $(-2^\circ \leq \alpha_2 \leq +2^\circ)$	0
	β_1 $(-2^\circ \leq \beta_1 \leq +2^\circ)$	1
	β_2 $(-2^\circ \leq \beta_2 \leq +2^\circ)$	0
	γ	0
	θ	0
	$z = A (\tan \gamma)$ [$\leq 0.5 \text{ mm (0.02 in.)}$]	0
	$w = A (\tan \theta)$ [$\leq 0.5 \text{ mm (0.02 in.)}$]	0
	D_t [$\geq 9.5 \text{ mm (3/8 in.)}$]	3/8
	A	0.904
	$A/2D_t$ ($1.05 \leq P_A/D_t \leq 1.5$) *	1.2
	* Recommended dimensions	

QA/QC Check

Completeness ☒
Specifications ☒

Legibility ☒
Reasonableness ☒

Accuracy ☒

Certification

I certify that the Type S probe ID 7 meets or exceeds all specifications, criteria, and applicable design features.








Certified by: [Signature]

Date: 11/15/13

Table 2G-1. Type S Probe Inspection Sheet

Note: Method 2 provides the criteria for an acceptably constructed Type S pitot tube. However, the procedure for making the necessary measurements is not specified. One approach is given below.

1. Use a vise with parallel and perpendicular faces. Use an angle-measuring device (analog or digital) for this check.
2. Place the pitot tube in the vise, and level the pitot tube horizontally using the angle-measuring device.
3. Place the angle-measuring device as shown below.
4. Measure distance A, which is P_A plus P_B . Method 2 specifies that $P_A = P_B$, but provides no tolerance for this measurement. Because this measurement is very difficult, it is suggested that $P_A = P_B = A/2$.
5. Measure the external tube diameter (D_t) with a micrometer, machinist's rule, or internal caliper.
6. Record all data as shown on the form below.
7. Calculate dimensions w and z as shown below.

	Degree indicating level position for determining α_1 and α_2		Level and perpendicular?	Y
	Degree indicating level position for determining β_1 and β_2		Obstruction?	N
	Degree indicating level position for determining θ		Damaged?	N
	Degree indicating level position for determining γ , then calculating z.		α_1 $(-2^\circ \leq \alpha_1 \leq +2^\circ)$	1
			α_2 $(-2^\circ \leq \alpha_2 \leq +2^\circ)$	0
			β_1 $(-2^\circ \leq \beta_1 \leq +2^\circ)$	1
			β_2 $(-2^\circ \leq \beta_2 \leq +2^\circ)$	1
			γ	0
			θ	0
			$z = A (\tan \gamma)$ [$\leq 0.5 \text{ mm (0.02 in.)}$]	0
			$w = A (\tan \theta)$ [$\leq 0.5 \text{ mm (0.02 in.)}$]	0
			D_t [$\geq 9.5 \text{ mm (3/8 in.)}$]	5/16
			A	864
			$A/2D_t$ $(1.05 \leq P_A/D_t \leq 1.5)^a$	1.38
* Recommended dimensions				

QA/QC Check

Completeness ☒

Specifications ☒

Legibility ☒

Reasonableness ☒

Accuracy ☒

Certification

I certify that the Type S probe ID 59 meets or exceeds all specifications, criteria, and applicable design features.

Certified by: [Signature]

Date: 7-3-13

SCEC
1582-1 North Batavia
Orange CA 92867
(714) 282 - 8240

BAROMETER CALIBRATION

BAROMETER ID #:	SNA-BAR-4
DATE:	10/31/2013
ANNUAL OR MONTHLY CALIBRATION:	ANNUAL
REFERENCE BAROMETER #:	LAB
CALIBRATION PERFORMED BY	MAA
ELEVATION DURING CALIBRATION:	250

BAROMETER		
ACTUAL	REFERENCE	DIFFERENCE
30.02	30.02	0

TOLERANCE MAXIMUM DIFFERENCE IS 0.1 IN. Hg
ELEVATION CORRECTION: (2.5MM OR 0.1 IN.) PER (30 METERS OR 100Ft.)

SCEC
1582-1 NORTH BATAVIA STREET
ORANGE, CALIFORNIA 92867
(714) 282-8240

TEMPERATURE SENSOR CALIBRATION

TEMPERATURE SENSOR I.D. #:	Stack KO 5
THERMOCOUPLE SOURCE:	PIE Model 520-K
SOURCE SERIAL NUMBER:	S/N 106970
CALIBRATION DATE:	January 12, 2012
CALIBRATED BY:	GM

ALL TEMPERATURES ARE IN DEGREES FAHRENHEIT

ICE BATH		
SIMULATED THERMOMETER TEMPERATURE	FIELD SENSOR TEMPERATURE	ABSOLUTE % DIFFERENCE
32	33	0.20
32	33	0.20
32	33	0.20

BOILING WATER		
SIMULATED THERMOMETER TEMPERATURE	FIELD SENSOR TEMPERATURE	ABSOLUTE % DIFFERENCE
212	215	0.45
212	215	0.45
212	215	0.45

BOILING OIL		
SIMULATED THERMOMETER TEMPERATURE	FIELD SENSOR TEMPERATURE	ABSOLUTE % DIFFERENCE
365	369	0.48
365	369	0.48
365	369	0.48

MAXIMUM TOLERANCE BETWEEN ANY TWO MEASUREMENTS IS 1.5%
NOTE: TAKE READINGS EVERY 1 MINUTE

SCEC
1582-1 NORTH BATAVIA STREET
ORANGE, CALIFORNIA 92867
(714) 282-8240

TEMPERATURE SENSOR CALIBRATION

TEMPERATURE SENSOR I.D. #:	Heated Line 6
THERMOCOUPLE SOURCE:	PIE Model 520-K
SOURCE SERIAL NUMBER:	S/N 106970
CALIBRATION DATE:	February 6, 2013
CALIBRATED BY:	GM

ALL TEMPERATURES ARE IN DEGREES FAHRENHEIT

ICE BATH		
SIMULATED THERMOMETER TEMPERATURE	FIELD SENSOR TEMPERATURE	ABSOLUTE % DIFFERENCE
32	35	0.61
32	35	0.61
32	35	0.61

BOILING WATER		
SIMULATED THERMOMETER TEMPERATURE	FIELD SENSOR TEMPERATURE	ABSOLUTE % DIFFERENCE
212	216	0.60
212	216	0.60
212	216	0.60

BOILING OIL		
SIMULATED THERMOMETER TEMPERATURE	FIELD SENSOR TEMPERATURE	ABSOLUTE % DIFFERENCE
365	368	0.36
365	368	0.36
365	368	0.36

MAXIMUM TOLERANCE BETWEEN ANY TWO MEASUREMENTS IS 1.5%
NOTE: TAKE READINGS EVERY 1 MINUTE

SCEC
1582-1 NORTH BATAVIA STREET
ORANGE, CALIFORNIA 92867
(714) 282-8240

TEMPERATURE SENSOR CALIBRATION

TEMPERATURE SENSOR I.D. #:	PT55 TC 55
THERMOCOUPLE SOURCE:	PIE Model 520-K
SOURCE SERIAL NUMBER:	S/N 106970
CALIBRATION DATE:	July 3, 2013
CALIBRATED BY:	GM

ALL TEMPERATURES ARE IN DEGREES FAHRENHEIT

ICE BATH		
SIMULATED THERMOMETER TEMPERATURE	FIELD SENSOR TEMPERATURE	ABSOLUTE % DIFFERENCE
32	31	0.20
32	31	0.20
32	31	0.20

BOILING WATER		
SIMULATED THERMOMETER TEMPERATURE	FIELD SENSOR TEMPERATURE	ABSOLUTE % DIFFERENCE
212	210	0.30
212	210	0.30
212	210	0.30

BOILING OIL		
SIMULATED THERMOMETER TEMPERATURE	FIELD SENSOR TEMPERATURE	ABSOLUTE % DIFFERENCE
365	363	0.24
365	361	0.48
365	363	0.24

MAXIMUM TOLERANCE BETWEEN ANY TWO MEASUREMENTS IS 1.5%
NOTE: TAKE READINGS EVERY 1 MINUTE

SCEC
1582-1 NORTH BATAVIA STREET
ORANGE, CALIFORNIA 92867
(714) 282-8240

TEMPERATURE SENSOR CALIBRATION

TEMPERATURE SENSOR I.D. #:	PT7 TC53 (stack)
THERMOCOUPLE SOURCE:	PIE Model 520-K
SOURCE SERIAL NUMBER:	S/N 106970
CALIBRATION DATE:	February 19, 2013
CALIBRATED BY:	GM

ALL TEMPERATURES ARE IN DEGREES FAHRENHEIT

ICE BATH		
SIMULATED THERMOMETER TEMPERATURE	FIELD SENSOR TEMPERATURE	ABSOLUTE % DIFFERENCE
32	33	0.20
32	32	0.00
32	33	0.20

BOILING WATER		
SIMULATED THERMOMETER TEMPERATURE	FIELD SENSOR TEMPERATURE	ABSOLUTE % DIFFERENCE
212	213	0.15
212	213	0.15
212	213	0.15

BOILING OIL		
SIMULATED THERMOMETER TEMPERATURE	FIELD SENSOR TEMPERATURE	ABSOLUTE % DIFFERENCE
365	366	0.12
365	366	0.12
365	366	0.12

MAXIMUM TOLERANCE BETWEEN ANY TWO MEASUREMENTS IS 1.5%
NOTE: TAKE READINGS EVERY 1 MINUTE

SEMI-ANNUAL METER BOX CALIBRATION DATA AT STANDARD TEMPERATURE OF 60 DEG F

Orifice Method - Triplicate Runs/Four Calibration Points
English Meter Box Units, English K' Factor
Filename:
File Modified From: APEX 522 Series Meter box Calibration
Revised: 4/7/2004

Model #: CAE
ID #: CB15
Date: July 9, 2013
Bar. Pressure: 29.00 (in. Hg)
Performed By: MAA

Theoretical Critical Vacuum = 14.11														
DRY GAS METER READINGS									CRITICAL ORIFICE READINGS			Ambient Temperature		
dH (in H ₂ O)	Time (min)	Volume Initial (cu ft)	Volume Final (cu ft)	Volume Total (cu ft)	Initial Temps Inlet (deg F)	Initial Temps Outlet (deg F)	Final Temps Inlet (deg F)	Final Temps Outlet (deg F)	Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	Initial (deg F)	Final (deg F)	Average (deg F)
0.30	18.00	252.53	258.15	5.62	78.00	79.00	80.00	79.00	40	0.231	24.00	77.00	77.00	77.00
0.30	18.00	258.15	263.77	5.62	80.00	79.00	80.00	80.00	40	0.231	24.00	77.00	78.00	77.50
0.30	18.00	263.77	269.40	5.62	80.00	80.00	81.00	81.00	40	0.231	24.00	78.00	79.00	78.50
0.62	13.00	269.40	275.42	6.03	81.00	81.00	81.00	81.00	48	0.343	22.00	79.00	80.00	79.50
0.62	13.00	275.42	281.46	6.04	81.00	81.00	82.00	81.00	48	0.343	22.00	80.00	80.00	80.00
0.62	13.00	281.46	287.51	6.04	82.00	81.00	82.00	82.00	48	0.343	22.00	80.00	81.00	80.50
1.60	8.00	293.69	299.78	6.09	82.00	81.00	84.00	82.00	63	0.562	19.00	81.00	81.00	81.00
1.60	8.00	299.78	305.87	6.09	84.00	82.00	84.00	83.00	63	0.562	19.00	81.00	82.00	81.50
1.60	8.00	305.87	311.96	6.09	84.00	83.00	84.00	83.00	63	0.562	19.00	82.00	82.00	82.00
3.30	6.00	311.96	318.30	6.34	83.00	83.00	84.00	83.00	73	0.779	15.00	82.00	82.00	82.00
3.30	6.00	318.30	324.65	6.35	84.00	83.00	85.00	84.00	73	0.779	15.00	82.00	82.00	82.00
3.30	6.00	324.65	331.00	6.35	85.00	84.00	86.00	84.00	73	0.779	15.00	82.00	82.00	82.00

DRY GAS METER		ORIFICE		DRY GAS METER		ORIFICE		Individual Run	Individual Orifice	Orifice Average	Orifice Average
VOLUME CORRECTED Vm(std) (cu ft)	VOLUME CORRECTED Vm(std) (liters)	VOLUME CORRECTED Vcr(std) (cu ft)	VOLUME CORRECTED Vcr(std) (liters)	VOLUME NOMINAL Vcr (cu ft)	Y Value (number)	dH@ Value (in H ₂ O)					
5.503	155.9	5.365	151.9	5.544	0.975	1.833	0.95 < Y < 1.05?	0.95 < Y < 1.05?	Ymax - Ymin < 0.010?	0.98 < Y/Yd < 1.02?	dH@ - dH@ av < 0.155?
5.497	155.7	5.362	151.9	5.547	0.976	1.833	Pass	Pass	Pass	Pass	Pass
5.489	155.5	5.358	151.7	5.552	0.976	1.833	Pass	Pass	Pass	Pass	Pass
Average					0.975	1.833			Pass	Pass	Pass
5.886	166.7	5.740	162.6	5.959	0.975	1.720	Pass	Pass	Pass	Pass	Pass
5.894	166.9	5.737	162.5	5.962	0.973	1.722	Pass	Pass	Pass	Pass	Pass
5.892	166.9	5.735	162.4	5.985	0.973	1.722	Pass	Pass	Pass	Pass	Pass
Average					0.974	1.721			Pass	Pass	Pass
5.949	168.5	5.780	163.7	6.017	0.972	1.657	Pass	Pass	Pass	Pass	Pass
5.939	168.2	5.777	163.6	6.020	0.973	1.655	Pass	Pass	Pass	Pass	Pass
5.933	168.0	5.774	163.5	6.022	0.973	1.655	Pass	Pass	Pass	Pass	Pass
Average					0.972	1.656			Pass	Pass	Pass
6.201	175.6	6.003	170.0	6.261	0.968	1.777	Pass	Pass	Pass	Pass	Pass
6.211	175.9	6.003	170.0	6.261	0.967	1.775	Pass	Pass	Pass	Pass	Pass
6.193	175.4	6.003	170.0	6.261	0.969	1.773	Pass	Pass	Pass	Pass	Pass
Average					0.968	1.775			Pass	Pass	Pass

Average Yd: 0.972 dH@: 1.746

Q @ dH = 1: 0.568

SIGNED:

Date:

IMPORTANT
IMPORTANT

For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.
The Critical Orifice Coefficient, K', must be entered in English units, (ft)³/(deg R)^{0.5}((in.Hg)^{0.5}/(min)).

DocNumber: 000059034

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information:

PRAXAIR WHSE SANTA ANA CA
1545 E EDINGER AVE
SANTA ANA CA 927050

Praxair Order Number: 25027246
Customer P. O. Number: 04593013
Customer Reference Number:

Fill Date: 9/25/2013
Part Number: NI CD8,508E-AS
Lot Number: 109326806
Cylinder Style & Outlet: AS CGA 590
Cylinder Pressure & Volume: 2000 psig 140 cu. ft.

Certified Concentration:

Expiration Date:	9/30/2021	NIST Traceable
Cylinder Number:	CC272639	Analytical Uncertainty:
8.31 %	CARBON DIOXIDE	± 1 %
12.5 %	OXYGEN	± 1.2 %
Balance	NITROGEN	

Certification Information: Certification Date: 9/30/2013 Term: 96 Months Expiration Date: 9/30/2021

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1. Do Not Use this Standard if Pressure is less than 100 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: CARBON DIOXIDE

Requested Concentration: 8.5 %
Certified Concentration: 8.31 %
Instrument Used: Horiba VIA-510 S/N 2807014
Analytical Method: NDIR
Last Multipoint Calibration: 9/24/2013

Reference Standard Type: GMIS
Ref. Std. Cylinder #: CC207040
Ref. Std. Conc: 9.96%
Ref. Std. Traceable to SRM #: vs. 1674b
SRM Sample #: 7-F-32
SRM Cylinder #: CAL014645

First Analysis Data: Date: 9/30/2013
Z: 0 R: 9.96 C: 8.31 Conc: 8.31
R: 9.96 Z: 0 C: 8.31 Conc: 8.31
Z: 0 C: 8.31 R: 9.96 Conc: 8.31
UOM: % Mean Test Assay: 8.31 %

Second Analysis Data: Date:
Z: 0 R: 0 C: 0 Conc: 0
R: 0 Z: 0 C: 0 Conc: 0
Z: 0 C: 0 R: 0 Conc: 0
UOM: % Mean Test Assay: 0 %

2. Component: OXYGEN


Requested Concentration: 12.5 %
Certified Concentration: 12.5 %
Instrument Used: OXYMAT 5E
Analytical Method: PARAMAGNETIC
Last Multipoint Calibration: 9/24/2013

Reference Standard Type: GMIS
Ref. Std. Cylinder #: SA15925
Ref. Std. Conc: 10.01%
Ref. Std. Traceable to SRM #: 2658a
SRM Sample #: 72-28-B
SRM Cylinder #: CLM-006896


First Analysis Data: Date: 9/30/2013
Z: 0 R: 10.02 C: 12.48 Conc: 12.468
R: 10.02 Z: 0 C: 12.48 Conc: 12.468
Z: 0 C: 12.48 R: 10.02 Conc: 12.468
UOM: % Mean Test Assay: 12.468 %

Second Analysis Data: Date:
Z: 0 R: 0 C: 0 Conc: 0
R: 0 Z: 0 C: 0 Conc: 0
Z: 0 C: 0 R: 0 Conc: 0
UOM: % Mean Test Assay: 0 %

Analyzed by:


Ying Yu

Certified by:


Jacquelyn Fiero

DocNumber: 000055291

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information:

PRAXAIR WHSE SANTA ANA CA
1545 E EDINGER AVE
SANTA ANA CA 927050

Praxair Order Number: 24009839
Customer P. O. Number: 04448150
Customer Reference Number:

Fill Date: 6/17/2013
Part Number: NI CD17O7ZE-AS
Lot Number: 109316809
Cylinder Style & Outlet: AS CGA 590
Cylinder Pressure & Volume: 2000 psig 140 cu. ft.

Certified Concentration:

Expiration Date:	6/24/2021	NIST Traceable
Cylinder Number:	CC107912	Analytical Uncertainty:
16.7 %	CARBON DIOXIDE	± 1 %
21.0 %	OXYGEN	± 1 %
Balance	NITROGEN	

Certification Information: Certification Date: 6/24/2013 Term: 96 Months Expiration Date: 6/24/2021

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-800/R-12/531, using Procedure G1. Do Not Use this Standard if Pressure is less than 100 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: CARBON DIOXIDE

Requested Concentration: 16.0 %
Certified Concentration: 16.7 %
Instrument Used: Horiba VIA-510 S/N 2807014
Analytical Method: NDIR
Last Multipoint Calibration: 5/24/2013

Reference Standard Type: GMIS
Ref. Std. Cylinder #: CC265304
Ref. Std. Conc: 17.97%
Ref. Std. Traceable to SRM #: 2745
SRM Sample #: 9-B-09
SRM Cylinder #: CAL-010765

First Analysis Data:		Date: 6/21/2013	
Z: 0	R: 17.97	C: 16.75	Conc: 16.75
R: 17.97	Z: 0	C: 16.71	Conc: 16.71
Z: 0	C: 16.71	R: 17.97	Conc: 16.71
UOM: %	Mean Test Assay:		16.723 %

Second Analysis Data:		Date:	
Z: 0	R: 0	C: 0	Conc: 0
R: 0	Z: 0	C: 0	Conc: 0
Z: 0	C: 0	R: 0	Conc: 0
UOM: %	Mean Test Assay:		0 %

2. Component: OXYGEN

Requested Concentration: 18 %
Certified Concentration: 21.0 %
Instrument Used: OXYMAT 5E
Analytical Method: PARAMAGNETIC
Last Multipoint Calibration: 5/30/2013

Reference Standard Type: GMIS
Ref. Std. Cylinder #: CC92589
Ref. Std. Conc: 19.99%
Ref. Std. Traceable to SRM #: 2659a
SRM Sample #: 71-37-B
SRM Cylinder #: CLM-006734

First Analysis Data:		Date: 6/24/2013	
Z: 0	R: 19.98	C: 21.02	Conc: 21.016
R: 20	Z: 0	C: 21.04	Conc: 21.036
Z: 0	C: 21.04	R: 20	Conc: 21.036
UOM: %	Mean Test Assay:		21.03 %

Second Analysis Data:		Date:	
Z: 0	R: 0	C: 0	Conc: 0
R: 0	Z: 0	C: 0	Conc: 0
Z: 0	C: 0	R: 0	Conc: 0
UOM: %	Mean Test Assay:		0 %

Analyzed by:



Ting Yu

Certified by:



Henry Koung

DocNumber: 000052222

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information:

PRAXAIR WHSE SANTA ANA CA
1545 E EDINGER AVE
SANTA ANA CA 927050

Praxair Order Number: 23176665
Customer P. O. Number: 04326925
Customer Reference Number:

Fill Date: 3/28/2013
Part Number: NI NO8.5ME-AS
Lot Number: 109308713
Cylinder Style & Outlet: AS CGA 660
Cylinder Pressure & Volume: 2000 psig 140 cu. ft.

Certified Concentration:

Expiration Date:	4/9/2016	NIST Traceable
Cylinder Number:	CC253049	Analytical Uncertainty:
8.54 ppm	NITRIC OXIDE	± 1 %
Balance	NITROGEN	

NOx = 8.58 ppm

NOx for Reference Only

Certification Information: Certification Date: 4/9/2013 Term: 36 Months Expiration Date: 4/9/2016

This cylinder was certified according to the 1997 EPA Traceability Protocol, Document #EPA-600/R-97/121, using Procedure G1. The certification expiration date was assigned using the May 2012 revision of the EPA Traceability Protocol document. Do Not Use this Standard if Pressure is less than 150 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, G=Gas Candidate)

1. Component: NITRIC OXIDE

Requested Concentration: 8.5 ppm
Certified Concentration: 8.54 ppm
Instrument Used: Thermo Electron 42C S/N 518112467
Analytical Method: Chemiluminescence
Last Multipoint Calibration: 3/11/2013

Reference Standard Type: GMIS
Ref. Std. Cylinder #: CC335674
Ref. Std. Conc: 9.83 ppm
Ref. Std. Traceable to SRM #: 2629a
SRM Sample #: 50-G-109
SRM Cylinder #: FF31631

First Analysis Data:		Date: 4/1/2013
Z: 0	R: 9.88	C: 8.52
R: 9.88	Z: 0	C: 8.52
Z: 0	C: 8.51	R: 9.88
UOM: ppm	Mean Test Assay: 8.52 ppm	

Analyzed by: Diego Mestanza

Second Analysis Data:		Date: 4/8/2013
Z: 0	R: 9.88	C: 8.56
R: 9.88	Z: 0	C: 8.55
Z: 0	C: 8.55	R: 9.88
UOM: ppm	Mean Test Assay: 8.55 ppm	

Certified by: Jack Fu



Praxair
5700 South Alameda Street
Los Angeles, CA 90058
Tel: (323) 585-2154 Fax: (714) 542-6689
PGVPID: F22012

DocNumber: 000042111

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information:

PRAXAIR WHSE SANTA ANA CA
1545 E EDINGER AVE
SANTA ANA CA 927050

Praxair Order Number: 21057267
Customer P. O. Number: 04004890
Customer Reference Number:

Fill Date: 7/30/2012
Part Number: NI NO18ME-AS
Lot Number: 109221201
Cylinder Style & Outlet: AS CGA 660
Cylinder Pressure & Volume: 2000 psig 140 cu. ft.

Certified Concentration:

Expiration Date:	8/23/2014	NIST Traceable
Cylinder Number:	CC362482	Analytical Uncertainty:
18.4 ppm	NITRIC OXIDE	± 1 %
Balance	NITROGEN	

NOx = 18.6 ppm

NOx for Reference Only

Certification Information: Certification Date: 8/23/2012 Term: 24 Months Expiration Date: 8/23/2014

This cylinder was certified according to the 1997 EPA Traceability Protocol, Document #EPA-600/R-97/121, using Procedure G1
Do Not Use this Standard if Pressure is less than 150 PSIG

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: NITRIC OXIDE

Requested Concentration: 18 ppm
Certified Concentration: 18.4 ppm
Instrument Used: Thermo Electron 42C S/N 518112467
Analytical Method: Chemiluminescence
Last Multipoint Calibration: 8/11/2012

Reference Standard Type: GMIS
Ref. Std. Cylinder #: SA17261
Ref. Std. Conc: 25.17 ppm
Ref. Std. Traceable to SRM #: 2529a
SRM Sample #: 50-G-109
SRM Cylinder #: FF31631

First Analysis Data:				Date:	8/7/2012
Z:	0	R:	25.2	C:	18.28
R:	25.2	Z:	0	C:	18.39
Z:	0	C:	18.33	R:	25.2
UOM:	ppm	Mean Test Assay:	18.3 ppm		

Second Analysis Data:				Date:	8/14/2012
Z:	0	R:	25.2	C:	18.4
R:	25.2	Z:	0	C:	18.41
Z:	0	C:	18.41	R:	25.2
UOM:	ppm	Mean Test Assay:	18.4 ppm		

Analyzed by:



Jack Fu

Certified by:



Diego Mestanza

Information contained herein has been prepared at your request by qualified experts within Praxair Distribution, Inc. While we believe that the information is accurate within the limits of the analytical methods employed and is complete to the extent of the specific analyses performed, we make no warranty or representation as to the suitability of the use of the information for any purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall the liability of Praxair Distribution, Inc., arising out of the use of the information contained herein exceed the fee established for providing such information.

DocNumber: 000035822

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information:

PRAXAIR WHSE SIGNAL HILL
2677 SIGNAL PARKWAY
SIGNAL HILL CA 907550

Praxair Order Number: 19501717
Customer P. O. Number: 03773283
Customer Reference Number:

Fill Date: 2/24/2012
Part Number: NI NO42ME-AS
Lot Number: 109205512
Cylinder Style & Outlet: AS CGA 680
Cylinder Pressure & Volume: 2000 psig 140 cu ft

Certified Concentration:

Expiration Date:	3/13/2014	NIST Traceable
Cylinder Number:	CC307301	Analytical Uncertainty:
43.6 ppm	NITRIC OXIDE	± 1 %
Balance	NITROGEN	

NOx = 43.9 ppm

NOx for Reference Only

Certification Information: Certification Date: 3/13/2012 Term: 24 Months Expiration Date: 3/13/2014

This cylinder was certified according to the 1997 EPA Traceability Protocol, Document #EPA-600/R-97/121, using Procedure G1

Do Not Use this Standard if Pressure is less than 150 PSIG

PGVP I.D.# F22012

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: NITRIC OXIDE

Requested Concentration: 42 ppm
Certified Concentration: 43.6 ppm
Instrument Used: Thermo Electron 42C S/N 518112467
Analytical Method: Chemiluminescence
Last Multipoint Calibration: 2/10/2012

Reference Standard Type: GMIS
Ref. Std. Cylinder #: CC3401
Ref. Std. Conc.: 51.11ppm
Ref. Std. Traceable to SRM #: vs. 1683b
SRM Sample #: 45-U-37
SRM Cylinder #: CAL015617

First Analysis Data:

Date: 3/1/2012


Z: 0 R: 51.1 C: 43.6 Conc: 43.6
R: 51.1 Z: 0 C: 43.8 Conc: 43.8
Z: 0 C: 43.7 R: 51.1 Conc: 43.7
UOM: ppm Mean Test Assay: 43.7 ppm

Second Analysis Data:

Date: 3/8/2012

Z: 0 R: 51.1 C: 43.5 Conc: 43.5
R: 51.1 Z: 0 C: 43.5 Conc: 43.5
Z: 0 C: 43.6 R: 51.1 Conc: 43.6
UOM: ppm Mean Test Assay: 43.5 ppm

Analyzed by:



Certified by:



DocNumber: 000059247

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS**Customer & Order Information:**

PRAXAIR WHSE SANTA ANA CA
1545 E EDINGER AVE
SANTA ANA CA 927050

Praxair Order Number: 25104385
Customer P. O. Number: 04603463
Customer Reference Number:

Fill Date: 10/3/2013
Part Number: NI NO42ME-AS
Lot Number: 109327602
Cylinder Style & Outlet: AS CGA 660
Cylinder Pressure & Volume: 2000 psig 140 cu. ft.

Certified Concentration:

Expiration Date:	10/14/2016	NIST Traceable
Cylinder Number:	SA13976	Analytical Uncertainty:
42.4 ppm	NITRIC OXIDE	± 0.7 %
Balance	NITROGEN	

NOx = 42.6 ppm

NOx for Reference Only

Certification Information: Certification Date: 10/14/2013 Term: 36 Months Expiration Date: 10/14/2016

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1. Do Not Use this Standard if Pressure is less than 100 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: NITRIC OXIDE

Requested Concentration: 42 ppm
Certified Concentration: 42.4 ppm
Instrument Used: Thermo Electron 42C S/N 518112467
Analytical Method: Chemiluminescence
Last Multipoint Calibration: 9/24/2013

Reference Standard Type: GMIS
Ref. Std. Cylinder #: CC382460
Ref. Std. Conc: 50.0 ppm
Ref. Std. Traceable to SRM #: 1683b
SRM Sample #: 45-U-37
SRM Cylinder #: CAL015817

First Analysis Data: Date: 10/7/2013

Z:	0	R:	50	C:	42.4	Conc:	42.4
R:	50	Z:	0	C:	42.4	Conc:	42.4
Z:	0	C:	42.4	R:	50	Conc:	42.4

UOM: ppm Mean Test Assay: 42.4 ppm

Analyzed by:

Jack Fu
Jack Fu

Second Analysis Data: Date: 10/14/2013

Z:	0	R:	50	C:	42.6	Conc:	42.6
R:	50	Z:	0	C:	42.3	Conc:	42.3
Z:	0	C:	42.4	R:	50	Conc:	42.4

UOM: ppm Mean Test Assay: 42.433 ppm

Certified by:

Diana Mastanza
Diana Mastanza



Praxair
5700 South Alameda Street
Los Angeles, CA 90058
Tel: (323) 585-2154 Fax: (714) 542-6689
PGVPID: F22013

DocNumber: 000052109

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information:

PRAXAIR WHSE SANTA ANA CA
1545 E EDINGER AVE
SANTA ANA CA 927050

Praxair Order Number: 23211280
Customer P. O. Number: 04331929
Customer Reference Number:

Fill Date: 3/20/2013
Part Number: NI N085ME-AS
Lot Number: 109307905
Cylinder Style & Outlet: AS CGA 660
Cylinder Pressure & Volume: 2000 psig 140 cu. ft.

Certified Concentration:

Expiration Date:	4/8/2021	NIST Traceable
Cylinder Number:	CC121068	Analytical Uncertainty:
87.4 ppm	NITRIC OXIDE	± 1 %
Balance	NITROGEN	

NOx = 87.4 ppm

NOx for Reference Only

Certification Information: Certification Date: 4/8/2013 Term: 96 Months Expiration Date: 4/8/2021

This cylinder was certified according to the 1997 EPA Traceability Protocol, Document #EPA-600/R-97/121, using Procedure G1. The certification expiration date was assigned using the May 2012 revision of the EPA Traceability Protocol document. Do Not Use this Standard if Pressure is less than 150 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: NITRIC OXIDE

Requested Concentration: 85 ppm
Certified Concentration: 87.4 ppm
Instrument Used: Thermo Electron 42i S/N 072602432C
Analytical Method: Chemiluminescence
Last Multipoint Calibration: 3/27/2013

Reference Standard Type: GMIS
Ref. Std. Cylinder #: CC146330
Ref. Std. Conc: 103.2 ppm
Ref. Std. Traceable to SRM #: vs. 1684b
SRM Sample #: 44-S-81
SRM Cylinder #: CALD15454

First Analysis Data:				Date:	3/25/2013
Z:	0	R:	103.2	C:	87.5
R:	103.2	Z:	0	C:	87.3
Z:	0	C:	87.1	R:	103.2
UOM:	ppm	Mean Test Assay:	87.3 ppm		

Second Analysis Data:				Date:	4/1/2013
Z:	0	R:	103.2	C:	87.6
R:	103.2	Z:	0	C:	87.5
Z:	0	C:	87.2	R:	103.2
UOM:	ppm	Mean Test Assay:	87.4 ppm		

Analyzed by:

Nelson Ma

Certified by:

Rolonda Kaywood

Information contained herein has been prepared at your request by qualified experts within Praxair Distribution, Inc. While we believe that the information is accurate within the limits of the analytical methods employed and is complete to the extent of the specific analyses performed, we make no warranty or representation as to the suitability of the use of the information for any purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall the liability of Praxair Distribution, Inc., arising out of the use of the information contained herein exceed the fee established for providing such information.



Praxair
5700 South Alameda Street
Los Angeles, CA 90058
Tel: (323) 585-2154 Fax: (714) 542-6689
PGVPID: F22013

DocNumber: 000051900

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information:

PRAXAIR WHSE SANTA ANA CA
1545 E EDINGER AVE
SANTA ANA CA 927050

Praxair Order Number: 23090548
Customer P. O. Number: 04313129
Customer Reference Number:

Fill Date: 3/12/2013
Part Number: NI CO8.5ME-AS
Lot Number: 109306106
Cylinder Style & Outlet: AS CGA 350
Cylinder Pressure & Volume: 2000 psig 140 cu. ft.

Certified Concentration:

Expiration Date:	4/4/2021	NIST Traceable
Cylinder Number:	CC351722	Analytical Uncertainty:
9.05 ppm	CARBON MONOXIDE	± 1 %
Balance	NITROGEN	

Certification Information: Certification Date: 4/4/2013 Term: 96 Months Expiration Date: 4/4/2021

This cylinder was certified according to the 1997 EPA Traceability Protocol, Document #EPA-600/R-97/121, using Procedure G1. The certification expiration date was assigned using the May 2012 revision of the EPA Traceability Protocol document. Do Not Use this Standard if Pressure is less than 150 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: CARBON MONOXIDE

Requested Concentration: 8.5 ppm
Certified Concentration: 9.05 ppm
Instrument Used: Horiba VIA-510 S/N 576876015
Analytical Method: NDIR
Last Multipoint Calibration: 3/11/2013

First Analysis Data: Date: 4/2/2013
Z: 0 R: 167.8 C: 149.7 Conc: 9.1
R: 169.2 Z: 0 C: 150.1 Conc: 9.05
Z: 0 C: 148.8 R: 168.5 Conc: 9.01
UOM: ppm Mean Test Assay: 9.05 ppm

Analyzed by:

Reference Standard Type: GMIS
Ref. Std. Cylinder #: SA6687
Ref. Std. Conc: 10.2 ppm
Ref. Std. Traceable to SRM #: 1677c
SRM Sample #: 5-1-42
SRM Cylinder #: XF 002143B

Second Analysis Data: Date:
Z: 0 R: 0 C: 0 Conc: 0
R: 0 Z: 0 C: 0 Conc: 0
Z: 0 C: 0 R: 0 Conc: 0
UOM: ppm Mean Test Assay: 0 ppm

Certified by:

Shameela Jiffrey

Information contained herein has been prepared at your request by qualified experts within Praxair Distribution, Inc. While we believe that the information is accurate within the limits of the analytical methods employed and is complete to the extent of the specific analyses performed, we make no warranty or representation as to the suitability of the use of the information for any purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall the liability of Praxair Distribution, Inc., arising out of the use of the information contained herein exceed the fee established for providing such information.



Praxair
5700 South Alameda Street
Los Angeles, CA 90058
Tel: (323) 585-2154 Fax: (714) 542-6689
PGVPID: F22013

DocNumber: 000052504

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information:

PRAXAIR WHSE SANTA ANA CA
1545 E EDINGER AVE
SANTA ANA CA 927050

Praxair Order Number: 23177434
Customer P. O. Number: 04326926
Customer Reference Number:

Fill Date: 3/20/2013
Part Number: NI CO18ME-AS
Lot Number: 109307808
Cylinder Style & Outlet: AS CGA 350
Cylinder Pressure & Volume: 2000 psig 140 cu. ft.

Certified Concentration:

Expiration Date:	4/13/2021	NIST Traceable
Cylinder Number:	SA7530	Analytical Uncertainty:
18.4 ppm	CARBON MONOXIDE	± 1 %
Balance	NITROGEN	

Certification Information: Certification Date: 4/13/2013 Term: 96 Months Expiration Date: 4/13/2021

This cylinder was certified according to the 1997 EPA Traceability Protocol, Document #EPA-600/R-97/121, using Procedure G1. The certification expiration date was assigned using the May 2012 revision of the EPA Traceability Protocol document. Do Not Use this Standard if Pressure is less than 150 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: CARBON MONOXIDE

Requested Concentration: 18 ppm
Certified Concentration: 18.4 ppm
Instrument Used: Horiba VIA-510, S/N 577172043
Analytical Method: NDIR
Last Multipoint Calibration: 3/20/2013

First Analysis Data:		Date:	4/2/2013
Z: 0	R: 24.7	C: 18.5	Conc: 18.5
R: 24.7	Z: 0	C: 18.4	Conc: 18.4
Z: 0	C: 18.4	R: 24.7	Conc: 18.4
UOM: ppm	Mean Test Assay: 18.4 ppm		

Analyzed by:

Shameela Jiffrey

Reference Standard Type: GMIS
Ref. Std. Cylinder #: CC147286
Ref. Std. Conc: 24.7 ppm
Ref. Std. Traceable to SRM #: 2635a
SRM Sample #: 58-C-32
SRM Cylinder #: CAL011907

Second Analysis Data:		Date:	
Z: 0	R: 0	C: 0	Conc: 0
R: 0	Z: 0	C: 0	Conc: 0
Z: 0	C: 0	R: 0	Conc: 0
UOM: ppm	Mean Test Assay: 0 ppm		

Certified by:

Yiq Yu

Information contained herein has been prepared at your request by qualified experts within Praxair Distribution, Inc. While we believe that the information is accurate within the limits of the analytical methods employed and is complete to the extent of the specific analyses performed, we make no warranty or representation as to the suitability of the use of the information for any purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall the liability of Praxair Distribution, Inc., arising out of the use of the information contained herein exceed the fee established for providing such information.



Praxair
5700 South Alameda Street
Los Angeles, CA 90058
Tel: (323) 585-2154 Fax: (714) 542-6689
PGVPID: F22013

DocNumber: 000051419

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information:

PRAXAIR WHSE SANTA ANA CA
1545 E EDINGER AVE
SANTA ANA CA 927050

Praxair Order Number: 23177434
Customer P. O. Number: 04326926
Customer Reference Number:

Fill Date: 3/20/2013
Part Number: NI CO850E-AS
Lot Number: 109307801
Cylinder Style & Outlet: AS CGA 350
Cylinder Pressure & Volume: 2000 psig 140 cu. ft.

Certified Concentration:

Expiration Date:	3/28/2021	NIST Traceable
Cylinder Number:	CC160848	Analytical Uncertainty:
857 ppm	CARBON MONOXIDE	± 1 %
Balance	NITROGEN	

Certification Information: Certification Date: 3/28/2013 Term: 96 Months Expiration Date: 3/28/2021

This cylinder was certified according to the 1997 EPA Traceability Protocol, Document #EPA-600/R-97/121, using Procedure G1. The certification expiration date was assigned using the May 2012 revision of the EPA Traceability Protocol document. Do Not Use this Standard if Pressure is less than 150 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: CARBON MONOXIDE

Requested Concentration: 850 ppm
Certified Concentration: 857 ppm
Instrument Used: Horiba VIA-510, S/N 577172043
Analytical Method: NDIR
Last Multipoint Calibration: 3/4/2013

Reference Standard Type: GMIS
Ref. Std. Cylinder #: CC126587
Ref. Std. Conc: 1001 ppm
Ref. Std. Traceable to SRM #: 1689b
SRM Sample #: 1-28-I
SRM Cylinder #: CLM-009404

First Analysis Data:		Date: 3/27/2013	
Z: 0	R: 1001	C: 856	Conc: 856
R: 1001	Z: 0	C: 857	Conc: 857
Z: 0	C: 857	R: 1001	Conc: 857
UOM: ppm	Mean Test Assay: 857 ppm		

Second Analysis Data:		Date:	
Z: 0	R: 0	C: 0	Conc: 0
R: 0	Z: 0	C: 0	Conc: 0
Z: 0	C: 0	R: 0	Conc: 0
UOM: ppm	Mean Test Assay: 0 ppm		

Analyzed by:

Ying Yu

Certified by:

Shameela Jiffrey

Information contained herein has been prepared at your request by qualified experts within Praxair Distribution, Inc. While we believe that the information is accurate within the limits of the analytical methods employed and is complete to the extent of the specific analyses performed, we make no warranty or representation as to the suitability of the use of the information for any purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall the liability of Praxair Distribution, Inc., arising out of the use of the information contained herein exceed the fee established for providing such information.

DocNumber: 000050355

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS**Customer & Order Information:**PRAXAIR WHSE SANTA ANA CA
1545 E EDINGER AVE
SANTA ANA CA 927050Praxair Order Number: 22864530
Customer P. O. Number: 04279623
Customer Reference Number:Fill Date: 2/23/2013
Part Number: NI CO1800E-AS
Lot Number: 109305203
Cylinder Style & Outlet: AS CGA 350
Cylinder Pressure & Volume: 2000 psig 140 cu. ft.**Certified Concentration:**

Expiration Date:	3/9/2021	NIST Traceable
Cylinder Number:	CC101717	Analytical Uncertainty:
1814 ppm	CARBON MONOXIDE	± 1 %
Balance	NITROGEN	

Certification Information: Certification Date: 3/9/2013 Term: 96 Months Expiration Date: 3/9/2021


This cylinder was certified according to the 1997 EPA Traceability Protocol, Document #EPA-600/R-97/121, using Procedure G1. The certification expiration date was assigned using the May 2012 revision of the EPA Traceability Protocol document. Do Not Use this Standard if Pressure is less than 150 PSIG.

Analytical Data:


(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: CARBON MONOXIDERequested Concentration: 1800 ppm
Certified Concentration: 1814 ppm
Instrument Used: Horiba VIA-510, S/N 577172043
Analytical Method: NDIR
Last Multipoint Calibration: 3/4/2013Reference Standard Type: GMIS
Ref. Std. Cylinder #: CC74842
Ref. Std. Conc.: 1736 ppm
Ref. Std. Traceable to SRM #: vs. 2637a
SRM Sample #: 56-E-40
SRM Cylinder #: FF23073**First Analysis Data:** Date: 3/7/2013
Z: 0 R: 1736 C: 1813 Conc: 1813
R: 1736 Z: 0 C: 1814 Conc: 1814
Z: 0 C: 1814 R: 1736 Conc: 1814
UOM: ppm Mean Test Assay: 1814 ppm**Second Analysis Data:** Date:
Z: 0 R: 0 C: 0 Conc: 0
R: 0 Z: 0 C: 0 Conc: 0
Z: 0 C: 0 R: 0 Conc: 0
UOM: ppm Mean Test Assay: 0 ppm

Analyzed by:


Ying Yu

Certified by:


Shameela Jiffrey



SCOTT-MARRIN, INC.

6531 BOX SPRINGS BLVD. • RIVERSIDE, CA 92507

(951) 653-6780 • FAX (951) 653-2430 • WWW.SCOTTMARRIN.COM

Report Of Analysis
NIST-Traceable Gas Mixtures

SCEC01

TO: SCEC - Air Quality Specialists
Attn: Chris Lovett
1582-1 North Batavia Street
Orange, CA 92867
(714) 282-8240

REPORT NO: 63964-02

REPORT DATE: November 5, 2013

CUSTOMER PO NO: 100413

CYLINDER NUMBER: CC311802

COMPONENT	CONCENTRATION (v/v)	NIST TRACEABLE REFERENCE STANDARD
Nitrogen dioxide	17.32 ± 0.35 ppmv	SRM 1683b
Nitrogen	Balance	

Cylinder Size: 150A (71 std cu ft)
Cylinder Pressure: 1000 psig
Shelf Life: 6 months

ppm = umole/mole

% = mole-%

The above analyses are traceable to the National Institute of Standards and Technology by intercomparison with the reference standard listed herein. Where indicated, volumetric and gravimetric reference standards are traceable thru use of our analytical balance. NIST Certificate Numbers 822/272801-6 and 822/274081-06.

ANALYST:

D.C. Marrin

D.C. Marrin

APPROVED:

J. T. Marrin

J. T. Marrin

The only liability of this company for gas which fails to comply with this analysis shall be replacement or reanalysis thereof by the company without extra cost.

STANDARD CALIBRATION GASES IN ALUMINUM CYLINDERS



SCOTT-MARRIN, INC.

6531 BOX SPRINGS BLVD. • RIVERSIDE, CA 92507

(951) 653-6780 • FAX (951) 653-2430 • WWW.SCOTTMARRIN.COM

Report Of Analysis NIST-Traceable Gas Mixtures

SCEC01

TO: SCEC - Air Quality Specialists
Attn: Chris Lovett
1582-1 North Batavia Street
Orange, CA 92867
(714) 282-8240

REPORT NO: 63964-03

REPORT DATE: November 5, 2013

CUSTOMER PO NO: 100413

CYLINDER NUMBER: **CC74096**

COMPONENT	CONCENTRATION (v/v)	NIST TRACEABLE REFERENCE STANDARD
Nitrogen dioxide	35.8 ± 0.7 ppmv	SRM 1683b
Nitrogen	Balance	

Cylinder Size: 150A (137 std cu ft)
Cylinder Pressure: 1950 psig
Shelf Life: 6 months

ppm = umole/mole

% = mole-%

The above analyses are traceable to the National Institute of Standards and Technology by intercomparison with the reference standard listed herein. Where indicated, volumetric and gravimetric reference standards are traceable thru use of our analytical balance. NIST Certificate Numbers 822/272801-6 and 822/274081-06.

ANALYST:

D.C. Marrin

D.C. Marrin

APPROVED:

J. T. Marrin

J. T. Marrin

The only liability of this company for gas which fails to comply with this analysis shall be replacement or reanalysis thereof by the company without extra cost.
STANDARD CALIBRATION GASES IN ALUMINUM CYLINDERS



Praxair
5700 South Alameda Street
Los Angeles, CA 90058
Tel: (323) 585-2154 Fax: (714) 542-6689
PGVPID: F22013

DocNumber: 000052508

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information:

PRAXAIR WHSE SANTA ANA CA
1545 E EDINGER AVE
SANTA ANA CA 927050

Praxair Order Number: 23177434
Customer P. O. Number: 04326926
Customer Reference Number:

Fill Date: 3/19/2013
Part Number: NI CO42.5ME-AS
Lot Number: 109307812
Cylinder Style & Outlet: AS CGA 350
Cylinder Pressure & Volume: 2000 psig 140 cu. ft.

Certified Concentration:

Expiration Date:	4/13/2021	NIST Traceable
Cylinder Number:	CC163770	Analytical Uncertainty:
42.3 ppm	CARBON MONOXIDE	± 1 %
Balance	NITROGEN	

Certification Information: Certification Date: 4/13/2013 Term: 96 Months Expiration Date: 4/13/2021

This cylinder was certified according to the 1997 EPA Traceability Protocol, Document #EPA-600/R-97/121, using Procedure G1. The certification expiration date was assigned using the May 2012 revision of the EPA Traceability Protocol document. Do Not Use this Standard if Pressure is less than 150 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: CARBON MONOXIDE

Requested Concentration: 42.5 ppm
Certified Concentration: 42.3 ppm
Instrument Used: Horiba VIA-510, S/N 577172043
Analytical Method: NDIR
Last Multipoint Calibration: 3/10/2013

Reference Standard Type: GMIS
Ref. Std. Cylinder #: CC272592
Ref. Std. Conc: 50.6 ppm
Ref. Std. Traceable to SRM #: 1679c
SRM Sample #: 4-J-21
SRM Cylinder #: XF001068B

First Analysis Data:				Date:	4/2/2013
Z:	0	R:	50.6	C:	42.2
R:	50.6	Z:	0	C:	42.4
Z:	0	C:	42.3	R:	50.6
UOM:	ppm	Mean Test Assay:	42.3 ppm		

Second Analysis Data:				Date:	
Z:	0	R:	0	C:	0
R:	0	Z:	0	C:	0
Z:	0	C:	0	R:	0
UOM:	ppm	Mean Test Assay:	0 ppm		

Analyzed by:

Ying Yu

Certified by:

Shameela Jiffrey

Information contained herein has been prepared at your request by qualified experts within Praxair Distribution, Inc. While we believe that the information is accurate within the limits of the analytical methods employed and is complete to the extent of the specific analyses performed, we make no warranty or representation as to the suitability of the use of the information for any purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall the liability of Praxair Distribution, Inc., arising out of the use of the information contained herein exceed the fee established for providing such information.

Appendix H

Chain of Custody Information








AAC# 131678

SCEC

1582-1 N. Batavia St. Orange, CA 92867
(714) 282-8240 phone, (714) 282-8247 fax

Chain of Custody Record Analytical Services Request

Client/Project Name: OCSD		Client Project No.: 2061.1053		ANALYSES REQUESTED				Laboratory Name: AAC		
Project Location: Plant 1 and 2 Engines Exhaust				SCAQMD 25.3					Lab Contact: Marcus Hueppe	
Contact: Rudy Nunez		Sampler (Signature): 							Lab Phone No.: (805) 650 - 1642	
Sample #	Description	Date	Time						Type	Turnaround Time N.T.A.T.
Remarks:										
108081	P1E1 RUN1A	12/4/2013		TANK 256	x				Please Include Data Package	
	P1E1 RUN1A	12/4/2013		TRAP A	x					
108082	P1E1 RUN1B	12/4/2013		TANK 255						
	P1E1 RUN1B	12/4/2013		TRAP B						
108083	P2E3 RUN1A	12/11/2013		TANK 131						
	P2E3 RUN1A	12/11/2013		TRAP A						
108084	P2E3 RUN1B	12/11/2013		TANK 208						
	P2E3 RUN1B	12/11/2013		TRAP B						
Relinquished by (Signature): 		Company: SCEC	Date: 12/12/13	Time: 9:41	Received by (Signature): 		Company: ACS	Date: 12/12/13	Time: 12:04	
Relinquished by (Signature): 		Company:	Date:	Time:	Received by (Signature): 		Company: AAC	Date: 12/12/13	Time: 1440	
Relinquished by (Signature):		Company:	Date:	Time:	Received by (Signature):		Company:	Date:	Time:	



SCEC

1582-1 N. Batavia St. Orange, CA 92867
(714) 282-8240 phone, (714) 282-8247 fax

Chain of Custody Record Analytical Services Request

Client/Project Name: OCSD				Client Project No.: 2061.1053		ANALYSES REQUESTED				Laboratory Name: AtmAA Inc	
Project Location: Plant 1 and 2 Engine Exhaust Samples						TGNMO/CH4 Per SCAQMD 25.1					Lab Contact: Mike Porter
Contact: Rudy Nunez		Sampler (Signature)		Lab Phone No.: (818) 223 - 3277							
Sample #	Description	Date	Time	Type	Turnaround Time: NORMAL						
					Remarks:						
	P1E3 RUN1A	12/2/2013		TANK 206	x						Please Include Data Package
	P1E3 RUN1A	12/2/2013		TRAP 303	x						
	P1E3 RUN1B	12/2/2013		TANK 207	x						
	P1E3 RUN1B	12/2/2013		Trap 304	x						
	P1E2 RUN1A	12/3/2013		TANK 91	x						
	P1E2 RUN1A	12/3/2013		TRAP 170	x						
	P1E2 RUN1B	12/3/2013		TANK 93	x						
	P1E2 RUN1B	12/3/2013		TRAP 181	x						
	P2E2 RUN1A	12/5/2013		TANK 58	x						
	P2E2 RUN1A	12/5/2013		TRAP 305	x						
	P2E2 RUN1B	12/5/2013		TANK 62	x						
	P2E2 RUN1B	12/5/2013		TRAP 306	x						
Relinquished by (Signature):		Company:		Date:	Time:	Received by (Signature):		Company:		Date:	Time:
Relinquished by (Signature):		Company:		Date:	Time:	Received by (Signature):		Company:		Date:	Time:
Relinquished by (Signature):		Company:		Date:	Time:	Received by (Signature):		Company:		Date:	Time:

13463
-53
-54
-58
-56
-57
-58






3 - H



SCEC

1582-1 N. Batavia St. Orange, CA 92867
(714) 282-8240 phone, (714) 282-8247 fax

Chain of Custody Record Analytical Services Request

Client/Project Name: OCSD				Client Project No.: 2061.1053		ANALYSES REQUESTED				Laboratory Name: AtmAA Inc	
Project Location: Plant 1 and 2 Engine Exhaust Samples						TGNMO/CH4 Per SCAQMD 25.1					Lab Contact: Mike Porter
Contact: Rudy Nunez				Sampler (Signature) 							Lab Phone No.: (818) 223 - 3277
Sample #	Description	Date	Time	Type	Turnaround Time: NORMAL						
					Remarks:						
	P2E4 RUN1A	12/6/2013		TANK 9	x						Please Include Data Package
	P2E4 RUN1A	12/6/2013		TRAP 110	x						
	P2E4 RUN1B	12/6/2013		TANK 14	x						
	P2E4 RUN1B	12/6/2013		TRAP 128	x						
	P2E5 RUN1A	12/9/2013		TANK 50	x						
	P2E5 RUN1A	12/9/2013		TRAP 319	x						
	P2E5 RUN1B	12/9/2013		TANK 92	x						
	P2E5 RUN1B	12/9/2013		TRAP 320	x						
	P2E1 RUN1A	12/10/2013		TANK 30	x						
	P2E1 RUN1A	12/10/2013		TRAP 308	x						
	P2E1 RUN1B	12/10/2013		TANK 31	x						
	P2E1 RUN1B	12/10/2013		TRAP 137	x						
Relinquished by (Signature): 		Company: SCEC		Date: 12/12/13	Time: 9:43	Received by (Signature): 		Company: ACS		Date: 12/12/13	Time: 11:02
Relinquished by (Signature): 		Company:		Date:	Time:	Received by (Signature): 		Company: AtmAA		Date: 12/12/13	Time:
Relinquished by (Signature):		Company:		Date:	Time:	Received by (Signature):		Company:		Date:	Time:

H
-
4

13463
-59
-60
-61
-62
-63
-64

AAC# 131678

SCEC

1582-1 N. Batavia St. Orange, CA 92867
(714) 282-8240 phone, (714) 282-8247 fax

Chain of Custody Record Analytical Services Request

Client/Project Name OCSD		Client Project No. 2061.1053		ANALYSES REQUESTED				Laboratory Name AAC		
Project Location Plant 2						Aldehydes (Formaldehyde and Acetaldehyde) per EPA Method 323			Lab Contact Sucha Parmer	
Contact Rudy Nunez (714)936 8050		Sampler (Signature) <i>R Nunez</i>								Lab Phone No. (805)650-1642
Sample No.	Description	SAMPLE Date Time Type		Turnaround Time Normal						
Remarks:										
<i>68085</i>	P2E1 Run- 1	12/10/2013	1046-1146	VOA Vial	X				Please supply complete analytical data package	
<i>68086</i>	P2E1 Run- 2	12/10/2013	1150-1250	VOA Vial	X					
<i>68087</i>	P2E1 Run- 3A	12/10/2013	1255-1355	VOA Vial	X					
<i>68088</i>	P2E1 Run- 3B	12/10/2013	1255-1355	VOA Vial	X					
<i>68089</i>	P2E1-FB	12/10/2013	1600	VOA Vial	X					
<i>68090</i>	P2E1-RB	12/10/2013	1615	VOA Vial	X					
<i>68091</i>	P2E3 Run- 1	12/11/2013	1016-1116	VOA Vial	X					
<i>68092</i>	P2E3 Run- 2A	12/11/2013	1207-1307	VOA Vial	X					
<i>68093</i>	P2E3 Run- 2B	12/11/2013	1207-1307	VOA Vial	X					
<i>68094</i>	P2E3 Run- 3	12/11/2013	1319-1419	VOA Vial	X					
<i>68095</i>	P2E3-FB	12/11/2013	1500	VOA Vial	X					
<i>68096</i>	P2E3-RB	12/11/2013	1525	VOA Vial	X					
Relinquished by (Signature): <i>R Nunez</i>		Company: <i>SCEC</i>		Date <i>12/12/13</i>	Time <i>940</i>	Received by (Signature): <i>[Signature]</i>		Company: <i>AAC</i>	Date: <i>12/12/13</i>	Time: <i>11:00</i>
Relinquished by (Signature):		Company:		Date	Time	Received by (Signature):		Company: <i>AAC</i>	Date: <i>12/12/13</i>	Time: <i>1440</i>
Relinquished by (Signature):		Company:		Date	Time	Received by (Signature):		Company:	Date:	Time:





-0.50C



SCEC

1582-1 N. Batavia St. Orange, CA 92867
(714) 282-8240 phone, (714) 282-8247 fax

Chain of Custody Record Analytical Services Request

Client/Project Name: OCSD				Client Project No.: 2061.1053		ANALYSES REQUESTED				Laboratory Name: AtmAA Inc			
Project Location: Plant 2/ Fuel Samples										SCAQMD Mod. 307.91 (Sulfur, H2S & TRS) SCAQMD Method 10.1 Fixed Gases (O2, CO2, N2) ASTM D3588 (C1-C6+, BTU, CHONS)		Lab Contact: Mike Porter	
Contact: Rudy Nunez				Sampler (Signature) 								Lab Phone No.: (818) 223 - 3277	
Sample #				Description								Turnaround Time: NORMAL	
				Date		Time		Type				Remarks:	
P2E1				12/10/13		1530		Tedlar Bag		x		13453-9	
Relinquished by (Signature): 				Company: SCEC		Date: 12/10		Time: 1533		Received by (Signature): FOD EX		Company: FODEY	
Relinquished by (Signature): 				Company:		Date:		Time:		Received by (Signature):		Date:	
Relinquished by (Signature):				Company:		Date:		Time:		Received by (Signature): 		Date: 12-11-13	
												Time: 10:00	

9 - H



1582-1 N. Batavia St. Orange, CA 92867
(714) 282-8240 phone, (714) 282-8247 fax

Chain of Custody Record Analytical Services Request






Client/Project Name: OCSD				Client Project No.: 2061.1053		ANALYSES REQUESTED							Laboratory Name: AtmAA Inc										
Project Location: Plant 2/ Fuel Samples									SCAQMD Mod. 307.91 (Sulfur, H ₂ S & TRS)		SCAQMD Method 10.1 Fixed Gases (O ₂ , CO ₂ , N ₂)		ASTM D3588 (C1-C6+, BTU, CHONS)						Lab Contact: Mike Porter				
Contact: Rudy Nunez				Sampler (Signature) 															Lab Phone No.: (818) 223 - 3277				
Sample #		Description		Date	Time	Type	Turnaround Time: NORMAL																
	P2E2	12/5/13	1315	Tedlar Bag	x	x	x																
Relinquished by (Signature):				Company: SCW		Date: 12/5/13	Time: 1320	Received by (Signature): FOD ey				Company: FOD ey		Date: 12/5/13	Time: 1400								
Relinquished by (Signature):				Company:		Date:	Time:	Received by (Signature):				Company:		Date:	Time:								
Relinquished by (Signature):				Company:		Date:	Time:	Received by (Signature):				Company: AtmAA		Date: 12/6/13	Time: 9:15								



SCEC

1582-1 N. Batavia St. Orange, CA 92867
(714) 282-8240 phone, (714) 282-8247 fax

Chain of Custody Record Analytical Services Request

Client/Project Name: OCSD				Client Project No.: 2061.1053		ANALYSES REQUESTED				Laboratory Name: AtmAA Inc				
Project Location: Plant 2/ Fuel Samples						SCAQMD Mod. 307.91 (Sulfur, H2S & TRS)	SCAQMD Method 10.1 Fixed Gases (O2, CO2, N2)	ASTM D3588 (C1-C6+, BTU, CHONS)				Lab Contact: Mike Porter		
Contact: Rudy Nunez				Sampler (Signature): 								Lab Phone No.: (818) 223 - 3277		
Sample #		Description		Date	Time							Type	Turnaround Time: NORMAL	
												Remarks:		
		P2E3		12/11/13	1600	Tedlar Bag	x	x	x			13463-40		
Relinquished by (Signature): 				Company: Sca.		Date: 12/11/13	Time: 1609		Received by (Signature): 		Company: ACS		Date: 12/12/13	Time: 11:04
Relinquished by (Signature): 				Company:		Date:	Time:		Received by (Signature):		Company:		Date:	Time:
Relinquished by (Signature):				Company:		Date:	Time:		Received by (Signature): 		Company: ATMOR		Date: 12-12-13	Time: 1:00

8 - H



SCEC

1582-1 N. Batavia St. Orange, CA 92867
(714) 282-8240 phone, (714) 282-8247 fax

Chain of Custody Record Analytical Services Request

Client/Project Name: OCSD				Client Project No.: 2061.1053		ANALYSES REQUESTED				Laboratory Name: AtmAA Inc							
Project Location: Plant 2/ Fuel Samples										SCAQMD Mod. 307.91 (Sulfur, H2S & TRS)		SCAQMD Method 10.1 Fixed Gases (O2, CO2, N2)		ASTM D3588 (C1-C6+, BTU, CHONS)		Lab Contact: Mike Porter	
Contact: Rudy Nunez				Sampler (Signature) <i>R Nunez</i>		Lab Phone No.: (818) 223 - 3277											
Turnaround Time: NORMAL																	
Sample #	Description	Date	Time	Type									Remarks:				
	P2E4	12/6/13	1200	Tedlar Bag	x	x	x						13443-1				
	P2E5	12/9/13	1100	↓	x	x	x						-2				
Relinquished by (Signature): <i>R Nunez</i>		Company: <i>SCEC</i>		Date: 12/9/13	Time: 11:10		Received by (Signature): <i>For ex</i>		Company: <i>For ex</i>		Date: 12/9	Time: 1400					
Relinquished by (Signature):		Company:		Date:	Time:		Received by (Signature):		Company:		Date:	Time:					
Relinquished by (Signature):		Company:		Date:	Time:		Received by (Signature): <i>[Signature]</i>		Company: <i>AtmAA</i>		Date: 12-10-13	Time: 10:30					




6 - H



SCEC

1582-1 N. Batavia St. Orange, CA 92867
(714) 282-8240 phone, (714) 282-8247 fax

Chain of Custody Record Analytical Services Request

Client/Project Name: Orange County Sanitation District (Plant 1 and 2)				Client Project No.: 2061.1053		ANALYSES REQUESTED				Laboratory Name: ATMAA			
Project Location: Engine Exhaust						TO-15					Lab Contact: Mike Porter		
Contact: Rudy Nunez (714) 936 - 8050											Lab Phone No.: (818) 223-3277		
Sampler (Signature) 											Turnaround Time N.T.A.T.		
SAMPLE											Remarks:		
Sample #	Description	Date	Time	Type									
1	P1E2 RUN1	12/3/2013		TANK 397	x								
2	P1E2 RUN2	12/3/2013		TANK 114	x								
3	P1E2 RUN3	12/3/2013		TANK 151	x								
4	P1E1 RUN1	12/4/2013		TANK 129	x								
5	P1E1 RUN2	12/4/2013		TANK 343	x								
6	P1E1 RUN3	12/4/2013		TANK 166	x								
7	P2E1 RUN1	12/10/2013		TANK 286	x								
8	P2E1 RUN2	12/10/2013		TANK 362	x								
9	P2E1 RUN3	12/10/2013		TANK 396	x								
10	P2E2 RUN 1 P2E3	12/11/2013		TANK 2011	x								
11	P2E2 RUN 2 P2E3	12/11/2013		TANK 170	x								
12	P2E2 RUN 3 P2E3	12/11/2013		TANK 366	x								
Relinquished by (Signature): 		Company: SCEC		Date: 12/12/13	Time: 9:42	Received by (Signature): 		Company: ACS		Date: 12/12/13	Time: 10:20 Z		
Relinquished by (Signature):		Company:		Date:	Time:	Received by (Signature):		Company:		Date:	Time:		
Relinquished by (Signature):		Company:		Date:	Time:	Received by (Signature):		Company:		Date:	Time:		

3463
-41
-42
-43
-44
-45
-46
-47
-48
-49
-50
-51
-52
-53

SCEC
IN-HOUSE CHAIN-OF-CUSTODY

CLIENT: OCSD P1 AND P2
PROJECT NO.: 2061. 1053

TEST DATE(S): 12/2-11/13
LAB HOURS:

PROJECT MANAGER: RN

(In Budget)

RESULTS DUE BY: 12/31/13 or 1/3/14

IN-HOUSE ANALYSIS

Compound(s) to be Analyzed	Method	Probe & Nozzles (Quantity)	Filters (Quantity)	Condensables (Quantity)	
				Inorganic	Organic
PM	SCARMD S-1	8	8	8	8
(UNITS = P1E1, E2, E3)					
(UNITS = P2E1, E2, E3 E4, E5)					
H2O BLANK 200ml					
MELT BLANK 200ml					

OUTSIDE LABORATORY ANALYSIS

Compound(s) to be Analyzed	Methodology	TAT	No. Of Samples	Receiving Laboratory	Method of Shipment	Shipping Instructions *

* Example: "Chilled in Cooler, On dry-ice, etc."

**PROJECT MANAGER IS RESPONSIBLE FOR ATTACHING COMPLETED
CHAIN-OF-CUSTODY TO BE SENT WITH SAMPLES TO OUTSIDE LABORATORY.**

Appendix I
Process Operating Data and Fuel Usage

Date/Time	Title1-ICE % Load	Title2-Natural Gas Flow (dscfm)	Title3-Digester Gas Flow (dscfm)
12/10/13 13:00	76.80566667	14.066	660.6973333
12/10/13 13:06	77.902	14.13583333	661.3401667
12/10/13 13:12	78.606	14.27533333	666.5843333
12/10/13 13:18	79.2275	14.20583333	661.5093333
12/10/13 13:24	78.727	14.27566667	662.2198333
12/10/13 13:30	77.374	14.229	661.4416667
12/10/13 13:36	77.715	14.41516667	671.321
12/10/13 13:42	79.02766667	14.392	670.103
12/10/13 13:48	80.3	14.39183333	672.0991667
12/10/13 13:54	79.53733333	14.43833333	670.3398333
12/10/13 14:00	78.782	14.299	668.3436667
12/10/13 14:06	81.367	14.50833333	675.2795
AVERAGE	78.78	14.30	666.77

Date/Time	Title1-ICE % Load	Title2-Natural Gas Flow (dscfm)	Title3-Digester Gas Flow (dscfm)
12/10/13 14:42	101.5355	18.6465	820.3906667
12/10/13 14:48	100.3053333	18.69316667	825.3641667
12/10/13 14:54	101.3393333	18.78616667	824.3491667
AVERAGE	101.06	18.71	823.37

[illegible]

P2E2 NORMAL

Date/Time	Title1-ICE % Load	Title2-Natural Gas Flow (dscfm)	Title3-Digester Gas Flow (dscfm)
12/5/13 11:24	83.13983333	13.41533333	676.4975
12/5/13 11:30	82.863	13.2525	675.8885
12/5/13 11:36	83.2865	13.0665	671.9638333
12/5/13 11:42	81.76666667	13.15966667	672.5728333
12/5/13 11:48	84.29483333	12.99666667	673.6555
12/5/13 11:54	85.272	13.50833333	684.3468333
12/5/13 12:00	85.47916667	13.4615	686.343
12/5/13 12:06	82.99133333	13.2525	683.0611667
12/5/13 12:12	83.88416667	13.41516667	683.8055
12/5/13 12:18	85.657	13.462	687.4933333
12/5/13 12:24	83.204	13.60133333	686.546
AVERAGE	83.80	13.33	680.20

P2E2 HIGH LOAD

Date/Time	Title1-ICE % Load	Title2-Natural Gas Flow (dscfm)	Title3-Digester Gas Flow (dscfm)
12/5/13 13:12	102.0268333	17.368	815.8231667
12/5/13 13:18	104.2103333	17.43733333	819.714
12/5/13 13:24	104.2121667	17.01883333	810.8835
AVERAGE	103.48	17.27	815.47

P2E2 LOW LOAD

[illegible]

P2E3 NORMAL LOAD

Date/Time	Title1-ICE % Load	Title2-Natural Gas Flow (dscfm)	Title3-Digester Gas Flow (dscfm)
12/11/13 10:36	81.114	15.48416667	687.0873333
12/11/13 10:42	79.695	15.1125	675.2795
12/11/13 10:48	78.1275	15.1125	675.1103333
12/11/13 10:54	80.93983333	15.32166667	682.6551667
12/11/13 11:00	82.58983333	15.46116667	690.4706667
12/11/13 11:06	82.74566667	15.55416667	691.8578333
12/11/13 11:12	82.2745	15.53083333	689.3541667
12/11/13 11:18	82.91983333	15.57733333	691.2488333
12/11/13 11:24	82.74016667	15.6005	691.7563333
12/11/13 11:30	79.92416667	15.554	686.4106667
12/11/13 11:36	80.7675	15.39133333	684.4821667
AVERAGE	81.26	15.43	685.97

P2E3 LOW LOAD

Date/Time	Title1-ICE % Load	Title2-Natural Gas Flow (dscfm)	Title3-Digester Gas Flow (dscfm)
12/11/13 14:48	75.82483333	14.415	650.4796667
12/11/13 14:54	73.3755	14.485	646.5211667
12/11/13 15:00	74.47733333	14.1125	632.4126667
12/11/13 15:06	77.05133333	14.76383333	661.8138333
AVERAGE	75.18	14.44	647.81

P2E3 HIGH LOAD

Date/Time	Title1-ICE % Load	Title2-Natural Gas Flow (dscfm)	Title3-Digester Gas Flow (dscfm)
12/11/13 15:24	106.0913333	19.8555	871.3098333
12/11/13 15:30	104.302	19.69316667	870.3963333
12/11/13 15:36	108.8065	19.809	870.058
AVERAGE	106.40	19.79	870.59

P2E4 NORMAL LOAD

Date/Time	Title1-ICE % Load	Title2-Natural Gas Flow (dscfm)	Title3-Digester Gas Flow (dscfm)
12/6/13 10:06	77.50783333	14.97316667	640.1605
12/6/13 10:12	77.90566667	14.92683333	638.6718333
12/6/13 10:18	77.8415	14.99666667	643.9836667
12/6/13 10:24	77.30616667	14.60133333	633.3938333
12/6/13 10:30	78.60233333	14.927	646.2505
12/6/13 10:36	78.232	15.01983333	648.2128333
12/6/13 10:42	78.12383333	15.11283333	643.0025
12/6/13 10:48	78.133	14.78733333	635.0516667
12/6/13 10:54	76.70116667	14.857	639.8221667
12/6/13 11:00	77.08066667	15.06633333	648.5511667
12/6/13 11:06	80.96183333	15.229	654.3366667
AVERAGE	78.04	14.95	642.86

P2E4 LOW LOAD

Date/Time	Title1-ICE % Load	Title2-Natural Gas Flow (dscfm)	Title3-Digester Gas Flow (dscfm)
12/6/13 11:24	72.81083333	13.57816667	596.82
12/6/13 11:30	68.72433333	13.36866667	589.2075
12/6/13 11:36	69.45583333	13.29883333	585.7565
AVERAGE	70.33	13.42	590.59

P2E4 HIGH LOAD

Date/Time	Title1-ICE % Load	Title2-Natural Gas Flow (dscfm)	Title3-Digester Gas Flow (dscfm)
12/6/13 11:54	100.5601667	18.83216667	790.6173333
12/6/13 12:00	99.85983333	19.1345	801.3086667
12/6/13 12:06	98.22633333	19.11166667	793.5946667
12/6/13 12:12	97.8725	18.949	786.6926667
AVERAGE	99.13	19.01	793.05

P2E5 HIGH LOAD

Date/Time	Title1-ICE % Load	Title2-Natural Gas Flow (dscfm)	Title3-Digester Gas Flow (dscfm)
12/9/13 13:12	99.3685	19.065	810.0038333
12/9/13 13:18	102.0561667	19.53	824.5183333
12/9/13 13:24	102.8335	19.57666667	821.2026667
12/9/13 13:30	100.1036667	19.29766667	810.8158333
AVERAGE	101.09	19.37	816.64

P2E5 LOW

Date/Time	Title1-ICE % Load	Title2-Natural Gas Flow (dscfm)	Title3-Digester Gas Flow (dscfm)
12/9/13 13:42	68.93883333	12.183	592.7261667
12/9/13 13:48	69.65933333	12.06683333	592.5231667
12/9/13 13:54	70.79783333	12.71816667	611.2668333
12/9/13 14:00	79.0735	14.11283333	661.6785
AVERAGE	72.12	12.77	614.55

P2E5 NORMAL

Date/Time	Title1-ICE % Load	Title2-Natural Gas Flow (dscfm)	Title3-Digester Gas Flow (dscfm)
12/9/13 14:42	89.42083333	17.15816667	749.7128333
12/9/13 14:48	90.68033333	17.158	750.8631667
12/9/13 14:54	91.61166667	17.06533333	743.792
12/9/13 15:00	88.18333333	17.135	746.7355
12/9/13 15:06	89.29433333	17.27466667	744.9423333
12/9/13 15:12	90.77016667	17.1815	744.6716667
12/9/13 15:18	88.27133333	17.25133333	746.1265
12/9/13 15:24	87.10533333	17.1585	744.5025
12/9/13 15:30	83.8365	15.99583333	707.6918333
12/9/13 15:36	83.127	15.624	699.4703333
12/9/13 15:42	83.68983333	24.99366667	684.11
AVERAGE	87.82	17.64	732.97

SUMMARY OF EPA METHOD 19 SOURCE TEST DATA AND CALCULATIONS
OCS D PLANT 2
ENGINE #1

PARAMETER	UNITS	NORM LOAD	HIGH LOAD	LOW LOAD
DATE		12/10/2013	12/10/2013	12/10/2013
FUEL FLOW - @ 60 DEG F	SCFM	666.77	823.37	587.50
CALORIFIC VALUE - @ 60 DEG F	BTU/CF	627.0	627.0	627.0
F FACTOR (Fd) - @ 60 DEG F	DSCF/MMBTU	9,259	9,259	9,259
EXHAUST O2 CONCENTRATION	%VD	11.94	12.26	11.32
HEAT INPUT - DIGESTER GAS	MMBTU/MIN	0.41806479	0.51625299	0.3683625
EXHAUST VOLUME FLOW RATE @ 60 DEG F	DSCFM	9,029	11,567	7,440

SUMMARY OF EPA METHOD 19 SOURCE TEST DATA AND CALCULATIONS
OCSO PLANT 2
ENGINE #2

PARAMETER	UNITS	NORM LOAD	HIGH LOAD	LOW LOAD
DATE		12/5/2013	12/5/2013	12/5/2013
FUEL FLOW - @ 60 DEG F	SCFM	680.20	815.47	622.88
CALORIFIC VALUE - @ 60 DEG F	BTU/CF	641.0	641.0	641.0
F FACTOR (Fd) - @ 60 DEG F	DSCF/MMBTU	9,251	9,251	9,251
EXHAUST O2 CONCENTRATION	%VD	11.54	11.70	11.16
HEAT INPUT - DIGESTER GAS	MMBTU/MIN	0.4360082	0.52271627	0.39926608
EXHAUST VOLUME FLOW RATE @ 60 DEG F	DSCFM	9,011	10,982	7,925

SUMMARY OF EPA METHOD 19 SOURCE TEST DATA AND CALCULATIONS
OCSD PLANT 2
ENGINE #3

PARAMETER	UNITS	NORM LOAD	HIGH LOAD	LOW LOAD
DATE		12/11/2013	12/11/2013	12/11/2013
FUEL FLOW - @ 60 DEG F	SCFM	685.97	870.59	647.81
CALORIFIC VALUE - @ 60 DEG F	BTU/CF	633.0	633.0	633.0
F FACTOR (Fd) - @ 60 DEG F	DSCF/MMBTU	9,303	9,303	9,303
EXHAUST O2 CONCENTRATION	%VD	12.07	11.91	12.36
HEAT INPUT - DIGESTER GAS	MMBTU/MIN	0.43421901	0.55108347	0.41006373
EXHAUST VOLUME FLOW RATE @ 60 DEG F	DSCFM	9,565	11,918	9,334

SUMMARY OF EPA METHOD 19 SOURCE TEST DATA AND CALCULATIONS
OCS D PLANT 2
ENGINE #4

PARAMETER	UNITS	NORM LOAD	HIGH LOAD	LOW LOAD
DATE		12/6/2013	12/6/2013	12/6/2013
FUEL FLOW - @ 60 DEG F	SCFM	642.86	793.05	590.59
CALORIFIC VALUE - @ 60 DEG F	BTU/CF	640.0	640.0	640.0
F FACTOR (Fd) - @ 60 DEG F	DSCF/MMBTU	9,251	9,251	9,251
EXHAUST O2 CONCENTRATION	%VD	11.77	12.20	11.44
HEAT INPUT - DIGESTER GAS	MMBTU/MIN	0.4114304	0.507552	0.3779776
EXHAUST VOLUME FLOW RATE @ 60 DEG F	DSCFM	8,710	11,278	7,729

SUMMARY OF EPA METHOD 19 SOURCE TEST DATA AND CALCULATIONS
OCS D PLANT 2
ENGINE #5

PARAMETER	UNITS	NORM LOAD	HIGH LOAD	LOW LOAD
DATE		12/9/2013	12/9/2013	12/9/2013
FUEL FLOW - @ 60 DEG F	SCFM	732.970	816.640	614.550
CALORIFIC VALUE - @ 60 DEG F	BTU/CF	641.0	641.0	641.0
F FACTOR (Fd) - @ 60 DEG F	DSCF/MMBTU	9,236	9,236	9,236
EXHAUST O2 CONCENTRATION	%VD	12.46	12.72	12.21
HEAT INPUT - DIGESTER GAS	MMBTU/MIN	0.46983377	0.52346624	0.39392655
EXHAUST VOLUME FLOW RATE @ 60 DEG F	DSCFM	10,747	12,351	8,750

Appendix J

Certifications

CERTIFICATE OF NO CONFLICT OF INTEREST

SCEC

1582-1 N. Batavia Street
Orange, California 92867

I certify that I am responsible for the testing operations of SCEC and am authorized to sign this certificate on the company's behalf.

SCEC may conduct tests as an independent tester as certified by South Coast Air Quality Management District (SCAQMD) and California Air Resource Board (CARB). SCEC is fully compliant with SCAQMD Rule 304. I further certify that SCEC has no conflict of interests and is not related or owned in any way to the company being tested.

Facility To Be Tested: OCSD P2 CGS ICE 1, 2, 3, 4, 5

Facility ID No.: A/N 540708, 540709, 540710, 540711, 540712

Signature: 

Name (printed/typed): Rudy Nunez

Title: Program Manager

Date: February 10, 2014



South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

October 8, 2013

Mr. Jason R. Wirth
SCEC
1582-1 North Batavia Street
Orange, CA 92867

Subject: LAP Approval Notice
Reference # 94LA0215

Dear Mr. Wirth:

We completed our review of the renewal application you submitted for approval under the South Coast Air Quality Management District's Laboratory Approval Program (SCAQMD LAP). We are pleased to inform you that your firm is approved for the period beginning October 31, 2013, and ending October 31, 2014 for the following methods, subject to the requirements in the LAP Conditions For Approval Agreement and conditions listed in the attachment to this letter:

SCAQMD Methods 1-4	SCAQMD Rule 1420 – (Lead) Source Sampling
SCAQMD Method 100.1	SCAQMD Rule 1121/ 1146.2 Protocol
SCAQMD Methods 25.1 and 25.3 (Sampling)	USEPA CTM-030 and ASTM D6522-00
SCAQMD Methods 5.1, 5.2, 5.3, 6.1 (Sampling)	

Your LAP approval to perform nitrogen oxide emissions compliance testing for SCAQMD Rule 1121/ 1146.2 Protocols includes satellite facilities located at:

McKenna Boiler
1510 North Spring Street
Los Angeles, CA 90012

Noritz America Corp.
11160 Grace Avenue
Fountain Valley, CA 92708

Ajax Boiler, Inc.
2701 S. Harbor Blvd.
Santa Ana, CA 92704

Thank you for participating in the SCAQMD LAP. Your cooperation helps us to achieve the goal of the LAP: to maintain high standards of quality in the sampling and analysis of source emissions. You may direct any questions or information to LAP Coordinator, Glenn Kasai. He may be reached by telephone at (909) 396-2271, by facsimile at (909) 396-2099, or via e-mail at gkasai@aqmd.gov.

Sincerely,

Rudy Eden, Senior Manager
Laboratory Services &
Source Test Engineering

RE:GK/gk

cc: Mike Garibay

131008 LapRenewal.doc

ATTACHMENT
Conditions For SCEC's LAP Approval
For Rules 1121/ 1146.2 Testing

- 1) Both Mr. Keith Shannon and Mr. Travis Fago shall conduct Rules 1121/ 1146.2 testing until other SCEC personnel have been trained to conduct these tests. A record book listing the names of SCEC personnel who are trained by Mr. Shannon and Mr. Fago for these tests shall be maintained. The entries to the record book must be legible; note that word processing entries are acceptable. This record book shall also include the location of the tests, the sampling procedures conducted, and the training provided to the SCEC testers. A copy of the record book shall be provided to the District upon request.
- 2) At least seven days prior to conducting Rules 1121/ 1146.2 tests, a notification must be made to Glenn Kasai by e-mail at gkasai@aqmd.gov. The notification shall provide the facility name, address, phone number, and contact name of the test site. Additionally, the notification shall list safety items required to observe testing, and whether any special training or equipment are mandatory.
- 3) Calibration data of the humidity instruments shall be provided for District review prior to commencement of testing.
- 4) The fuel meter flow measurements during testing shall be limited to the range calibrated in the most recent calibration report. Calibration of the fuel meter must be performed by an independent laboratory.



Air Resources Board



Matthew Rodriguez
Secretary for
Environmental Protection

Mary D. Nichols, Chairman
1001 I Street • P.O. Box 2815
Sacramento, California 95812 • www.arb.ca.gov

Edmund G. Brown Jr.
Governor

July 12, 2013

Mr. Jason Wirth
SCEC
1582-1 North Batavia Street
Orange, California 92867

Dear Mr. Wirth:

I am pleased to inform you that the Air Resources Board has renewed SCEC's approval to perform the test methods identified in enclosed Executive Order I-13-030. This approval is valid through June 30, 2014, during which time a field audit of SCEC's testing ability may be performed. I have also enclosed two certificates of approval.

If you have questions or need further assistance, please contact Kathryn Gugeler at (916) 322-0221 or via email at kgugeler@arb.ca.gov or Angus MacPherson at (916) 445-4686 or via email at amacpher@arb.ca.gov.

Sincerely,

Dr. Michael T. Benjamin, Chief
Monitoring and Laboratory Division

Enclosures (3)

cc: Angus MacPherson, Manager
Testing and Certification Section

Kathryn Gugeler
Testing and Certification Section

10. SCEC uses caps on all probes, nozzles, lines, and/or impingers used in accordance with section 4.2 of ARB Test Method 5 or 17, as appropriate;
11. SCEC calibrates and repairs its nozzles used in isokinetic testing in accordance with section 5.1 of ARB Test Method 5 or 17, as appropriate, and establishes and maintains a log of the calibrations which shall include notes on the repairs on each nozzle;
12. SCEC participates in the United States Environmental Protection Agency Stationary Source Compliance Audit Program for approved methods;
13. SCEC back flushes the filter in the probe in accordance with section 2.1.2 of ARB Test Method 100 as necessary;
14. SCEC includes the following information on all strip charts and/or emissions data sheets: pollutant of interest, source, analyzer range, date and time, zero offsets, and the name of the person operating the instruments;
15. The person performing VEE passed ARB's Compliance Training Course #100: Fundamentals of Enforcement (FOE)/Visible Emissions Evaluation (Smoke School) and is currently certified to conduct VEE. Any recertification for VEE, following the initial passage of ARB's FOE, must be from a certifying body recognized by ARB at the time VEE is performed; and

WHEREAS, ARB Executive Officer, pursuant to California Health and Safety Code section 39516, issued Executive Order G-02-008, delegating to the Chief of ARB Monitoring and Laboratory Division (MLD) the authority to approve independent testers in accordance with Cal. Code Regs., title 17, section 91200 and following.

NOW, THEREFORE, I, Michael T. Benjamin, Chief of MLD, order that SCEC is granted approval from the date of execution of this order until June 30, 2014, to perform the test methods identified above, subject to compliance with Cal. Code Regs., title 17, section 91200 and following.

BE IT FURTHER ORDERED that during the approved period the Executive Officer or his authorized representative may field audit one or more tests performed pursuant to this order for each test method identified above.

Executed at Sacramento, California, this 12 day of July 2013.



Dr. Michael T. Benjamin, Chief
Monitoring and Laboratory Division

10. SCEC uses caps on all probes, nozzles, lines, and/or impingers used in accordance with section 4.2 of ARB Test Method 5 or 17, as appropriate;
11. SCEC calibrates and repairs its nozzles used in isokinetic testing in accordance with section 5.1 of ARB Test Method 5 or 17, as appropriate, and establishes and maintains a log of the calibrations which shall include notes on the repairs on each nozzle;
12. SCEC participates in the United States Environmental Protection Agency Stationary Source Compliance Audit Program for approved methods;
13. SCEC back flushes the filter in the probe in accordance with section 2.1.2 of ARB Test Method 100 as necessary;
14. SCEC includes the following information on all strip charts and/or emissions data sheets: pollutant of interest, source, analyzer range, date and time, zero offsets, and the name of the person operating the instruments;
15. The person performing VEE passed ARB's Compliance Training Course #100: Fundamentals of Enforcement (FOE)/Visible Emissions Evaluation (Smoke School) and is currently certified to conduct VEE. Any recertification for VEE, following the initial passage of ARB's FOE, must be from a certifying body recognized by ARB at the time VEE is performed; and

WHEREAS, ARB Executive Officer, pursuant to California Health and Safety Code section 39516, issued Executive Order G-02-008, delegating to the Chief of ARB Monitoring and Laboratory Division (MLD) the authority to approve independent testers in accordance with Cal. Code Regs., title 17, section 91200 and following.

NOW, THEREFORE, I, Michael T. Benjamin, Chief of MLD, order that SCEC is granted approval from the date of execution of this order until June 30, 2014, to perform the test methods identified above, subject to compliance with Cal. Code Regs., title 17, section 91200 and following.

BE IT FURTHER ORDERED that during the approved period the Executive Officer or his authorized representative may field audit one or more tests performed pursuant to this order for each test method identified above.

Executed at Sacramento, California, this 12 day of July 2013.



Dr. Michael T. Benjamin, Chief
Monitoring and Laboratory Division

State of California
Air Resources Board
Approved Independent Contractor

This is to certify that the company listed above has been approved
by the Air Resources Board to conduct compliance testing
pursuant to California Code of Regulations, title 17, section 91207,
until June 30, 2014, for those test methods listed below:

Air Resources Board Test Methods:
1, 2, 3, 4, 5, 6, 8, 17, 10
100 (CO, CO₂, NO, O₃, SO₂, THC)

Dr. Michael T. Benjamin, Chief
Monitoring and Laboratory Division

State of California
Air Resources Board
Approved ~~Independent~~ Contractor

This is to certify that the company listed above has been approved
by the Air Resources Board to conduct compliance testing
pursuant to California Code of Regulations, title 17, section 91207,
until June 30, 2014, for those test methods listed below:



Dr. Michael T. Benjamin, Chief
Monitoring and Laboratory Division

Appendix K
SCAQMD Permits



FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO OPERATE

Permit No. G27394
A/N 540708

Equipment Description:

RESOURCE RECOVERY SYSTEM NO. 1 CONSISTING OF:

INTERNAL COMBUSTION ENGINE (CG1-HB), COOPER BESSMER, SPARK IGNITION, FOUR STROKE, WITH A MODIFIED TURBOCHARGED-INTERCOOLED V-16 TYPE, MODEL NO. LSVB-16-SGC, 4166 HP, NATURAL GAS AND/OR DIGESTER GAS FIRED, DRIVING A 3000 KW ELECTRIC GENERATOR, WITH AN EXHAUST HEAT RECOVERY STEAM GENERATOR, 6,010,200 BTU/HR CAPACITY, UNFIRED.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS EQUIPMENT SHALL BE OPERATED BY PERSONNEL PROPERLY TRAINED IN ITS OPERATION.
[RULE 204]
4. THIS ENGINE SHALL HAVE AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER TO DETERMINE THE ENGINE ELAPSED OPERATING TIME FOR EACH FUEL BLEND BURNED.
[RULE 1110.2]
5. A FLOW INDICATING AND RECORDING DEVICE SHALL BE INSTALLED IN THE FUEL GAS, OR FUEL BLEND, SUPPLY LINE TO THE ENGINE TO MEASURE AND RECORD THE QUANTITY OF EACH FUEL GAS (IN SCFM) BURNED.
[RULE 204]
6. SAMPLING PORT SHALL BE INSTALLED FOR THE INLET GAS LINE TO THE ENGINE TO ALLOW THE COLLECTION OF A FUEL GAS OR FUEL BLEND SAMPLES.
[RULE 204]
7. MONTHLY READINGS OF THE BTU CONTENT OF FUEL GAS (BTU/SCF) AT THE COMBINED INLET TO THE CGS ENGINES SHALL BE TAKEN USING AN INSTRUMENT APPROVED BY THE SCAQMD. ALL RESULTS SHALL BE RECORDED.
[RULE 204]
8. ALL RECORDING DEVICES SHALL BE SYNCHRONIZED WITH RESPECT TO THE TIME OF THE DAY.
[RULE 204]



FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

9. THE TOTAL HEAT INPUT OF GASEOUS FUEL, OR FUEL BLEND, BURNED IN THIS ENGINE SHALL NOT EXCEED 33 MM BTU PER HOUR. A LOG SHALL BE KEPT INDICATING THE TOTAL HEATING VALUE OF FUEL GAS, OR FUEL BLEND, BURNED IN THIS ENGINE BASED ON THE RECORDED FLOW RATE (SCFM) AND THE LATEST MONTHLY BTU CONTENT READING.
[RULE 1303 (b) (1) AND 1303 (b) (2)-MODELING AND EMISSIONS OFFSET]

10. THIS EQUIPMENT SHALL BE OPERATED IN COMPLIANCE WITH RULES 218, 431.1 AND 1110.2.
[RULE 218, 431.1 AND 1110.2]

11. THIS EQUIPMENT SHALL BE OPERATED IN SUCH A MANNER THAT THE FOLLOWING EMISSION RATES ARE NOT EXCEEDED.

AIR CONTAMINANT	
CARBON MONOXIDE	600 PPMV AT 15% O ₂
PARTICULATES (PM ₁₀)	0.0058 GRAINS/ DSCF
ROG OR TNMHC (AS CARBON)	115 PPMV AT 15% O ₂
[RULE 1303 (a) (1), 1303(b) (1) AND 1303 (b) (2)-BACT, MODELING AND EMISSIONS OFFSET]	

12. THE COMBINED EMISSIONS FROM THE FOUR (4) CGS ENGINES, USING CALENDAR MONTHLY EMISSIONS DIVIDED BY 30, SHALL NOT EXCEED THE FOLLOWING:

AIR CONTAMINANT	LBS/DAY
CARBON MONOXIDE	2,644
NITROGEN OXIDES (AS NO ₂)	828
PARTICULATES (PM ₁₀)	72
ROG OR TNMHC (AS CH ₄)	372
SULFUR DIOXIDE	84
[RULE 1303 (b) (2)-EMISSIONS OFFSET]	

13. THE OPERATOR SHALL INSTALL AND MAINTAIN A CONTINUOUS EMISSION MONITORING SYSTEM (CEMS), OR AN ALTERNATIVE SYSTEM, AS APPROVED BY THE EXECUTIVE OFFICER, TO MEASURE THE ENGINE EXHAUST FOR NO_x AND O₂ CONCENTRATIONS ON A DRY BASIS, EXCEPT DURING SHUTDOWN FOR MAINTENANCE OF THE SYSTEM. IN ADDITION, THE CEMS SHALL CONVERT THE ACTUAL NO_x TO MASS EMISSION RATES; AND RECORD THE ACTUAL AND CORRECTED ENGINE NO_x CONCENTRATION AT 15% O₂ AND MASS EMISSION RATES ON AN HOURLY AND DAILY BASIS.
[RULE 218, RULE 1110.2]

14. THE OPERATOR SHALL CONDUCT PERFORMANCE TESTS ANNUALLY. WRITTEN NOTICE OF THE PERFORMANCE TEST SHALL BE PROVIDED TO THE AQMD AT LEAST 7 DAYS PRIOR TO THE TEST SO THAT AN OBSERVER MAY BE PRESENT. A COMPLETE FINAL REPORT OF THE TEST (LBS/HR, PPMVD AT 15% O₂, LBS/MMBTU, ETC.) SHALL BE PROVIDED TO THE AQMD WITHIN 45 DAYS AFTER TESTING. ALL TEST RUNS REQUIRED BY AQMD SHALL BE REPORTED. THE TESTS SHALL INCLUDE BUT NOT BE LIMITED TO, A TEST OF THE FUELS BURNED AND ENGINE EXHAUST FOR:

- TOTAL NON-METHANE HYDROCARBONS (EXHAUST ONLY)
- CARBON MONOXIDE (EXHAUST ONLY)
- TOTAL PARTICULATE MATTER (EXHAUST ONLY).
- OXIDES OF NITROGEN (EXHAUST ONLY).



**FACILITY PERMIT TO OPERATE
ORANGE COUNTY SANITATION DISTRICT**

- E. OXYGEN
 - F. FLOW RATE
 - G. MOISTURE
 - H. TOXIC AIR CONTAMINANTS (EXHAUST ONLY), FOR ONE ENGINE PER YEAR
 - I. ALDEHYDES (EXHAUST ONLY), FOR ONE ENGINE PER YEAR
 - J. TOTAL REDUCED SULFUR COMPOUNDS (FUEL ONLY)
 - K. NITROGEN AND CARBON DIOXIDE
 - L. BTU CONTENTS (FUEL ONLY)
 - M. POWER OUTPUT
- [RULE 1303(b) (1) AND 1303(b) (2) - MODELING AND EMISSION OFFSET], [RULE 1110.2], [RULE 404]

15. RECORDS SHALL BE KEPT AND MAINTAINED TO PROVE COMPLIANCE WITH ALL CONDITIONS FOR THIS PERMIT. THE RECORDS SHALL BE KEPT ON FILE FOR AT LEAST FIVE YEARS AND SHALL BE MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.
[RULE 204]

Emissions And Requirements:

16. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPMV, RULE 1110.2
NOx: 45.4 PPMV, RULE 1110.2 (WITH ECF ADJUSTMENT FACTOR = 1.26)
ROG: 315 PPMV, RULE 1110.2 (WITH ECF ADJUSTMENT FACTOR = 1.26)
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS.



FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

PERMIT TO OPERATE

Permit No. G27395
A/N 540709

Equipment Description:

RESOURCE RECOVERY SYSTEM NO. 2 CONSISTING OF:

INTERNAL COMBUSTION ENGINE (CG2-HB), COOPER BESSMER, SPARK IGNITION, FOUR STROKE, WITH A MODIFIED TURBOCHARGED-INTERCOOLED V-16 TYPE, MODEL NO. LSVB-16-SGC, 4166 HP, NATURAL GAS AND/OR DIGESTER GAS FIRED, DRIVING A 3000 KW ELECTRIC GENERATOR, WITH AN EXHAUST HEAT RECOVERY STEAM GENERATOR, 6,010,200 BTU/HR CAPACITY, UNFIRED.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS EQUIPMENT SHALL BE OPERATED BY PERSONNEL PROPERLY TRAINED IN ITS OPERATION.
[RULE 204]
4. THIS ENGINE SHALL HAVE AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER TO DETERMINE THE ENGINE ELAPSED OPERATING TIME FOR EACH FUEL BLEND BURNED.
[RULE 1110.2]
5. A FLOW INDICATING AND RECORDING DEVICE SHALL BE INSTALLED IN THE FUEL GAS, OR FUEL BLEND, SUPPLY LINE TO THE ENGINE TO MEASURE AND RECORD THE QUANTITY OF EACH FUEL GAS (IN SCFM) BURNED.
[RULE 204]
6. SAMPLING PORT SHALL BE INSTALLED FOR THE INLET GAS LINE TO THE ENGINE TO ALLOW THE COLLECTION OF A FUEL GAS OR FUEL BLEND SAMPLES.
[RULE 204]
7. MONTHLY READINGS OF THE BTU CONTENT OF FUEL GAS (BTU/SCF) AT THE COMBINED INLET TO THE CGS ENGINES SHALL BE TAKEN USING AN INSTRUMENT APPROVED BY THE SCAQMD. ALL RESULTS SHALL BE RECORDED.
[RULE 204]
8. ALL RECORDING DEVICES SHALL BE SYNCHRONIZED WITH RESPECT TO THE TIME OF THE DAY.
[RULE 204]



FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

9. THE TOTAL HEAT INPUT OF GASEOUS FUEL, OR FUEL BLEND, BURNED IN THIS ENGINE SHALL NOT EXCEED 33 MM BTU PER HOUR. A LOG SHALL BE KEPT INDICATING THE TOTAL HEATING VALUE OF FUEL GAS, OR FUEL BLEND, BURNED IN THIS ENGINE BASED ON THE RECORDED FLOW RATE (SCFM) AND THE LATEST MONTHLY BTU CONTENT READING.
[RULE 1303 (b) (1) AND 1303 (b) (2)-MODELING AND EMISSIONS OFFSET]

10. THIS EQUIPMENT SHALL BE OPERATED IN COMPLIANCE WITH RULES 218, 431.1 AND 1110.2.
[RULE 218, 431.1 AND 1110.2]

11. THIS EQUIPMENT SHALL BE OPERATED IN SUCH A MANNER THAT THE FOLLOWING EMISSION RATES ARE NOT EXCEEDED.

AIR CONTAMINANT	
CARBON MONOXIDE	600 PPMV AT 15% O ₂
PARTICULATES (PM ₁₀)	0.0058 GRAINS/DSCF
ROG OR TNMHC (AS CARBON)	115 PPMV AT 15% O ₂
[RULE 1303 (a) (1), 1303(b) (1) AND 1303 (b) (2)-BACT, MODELING AND EMISSIONS OFFSET]	

12. THE COMBINED EMISSIONS FROM THE FOUR (4) CGS ENGINES, USING CALENDAR MONTHLY EMISSIONS DIVIDED BY 30, SHALL NOT EXCEED THE FOLLOWING:

AIR CONTAMINANT	LBS/DAY
CARBON MONOXIDE	2,644
NITROGEN OXIDES (AS NO ₂)	828
PARTICULATES (PM ₁₀)	72
ROG OR TNMHC (AS CH ₄)	372
SULFUR DIOXIDE	84
[RULE 1303 (b) (2)-EMISSIONS OFFSET]	

13. THE OPERATOR SHALL INSTALL AND MAINTAIN A CONTINUOUS EMISSION MONITORING SYSTEM (CEMS), OR AN ALTERNATIVE SYSTEM, AS APPROVED BY THE EXECUTIVE OFFICER, TO MEASURE THE ENGINE EXHAUST FOR NO_x AND O₂ CONCENTRATIONS ON A DRY BASIS, EXCEPT DURING SHUTDOWN FOR MAINTENANCE OF THE SYSTEM. IN ADDITION, THE CEMS SHALL CONVERT THE ACTUAL NO_x TO MASS EMISSION RATES; AND RECORD THE ACTUAL AND CORRECTED ENGINE NO_x CONCENTRATION AT 15% O₂ AND MASS EMISSION RATES ON AN HOURLY AND DAILY BASIS.
[RULE 218, RULE 1110.2]

14. THE OPERATOR SHALL CONDUCT PERFORMANCE TESTS ANNUALLY. WRITTEN NOTICE OF THE PERFORMANCE TEST SHALL BE PROVIDED TO THE AQMD AT LEAST 7 DAYS PRIOR TO THE TEST SO THAT AN OBSERVER MAY BE PRESENT. A COMPLETE FINAL REPORT OF THE TEST (LBS/HR, PPMVD AT 15% O₂, LBS/MMBTU, ETC.) SHALL BE PROVIDED TO THE AQMD WITHIN 45 DAYS AFTER TESTING. ALL TEST RUNS REQUIRED BY AQMD SHALL BE REPORTED. THE TESTS SHALL INCLUDE BUT NOT BE LIMITED TO, A TEST OF THE FUELS BURNED AND ENGINE EXHAUST FOR:

- A. TOTAL NON-METHANE HYDROCARBONS (EXHAUST ONLY)
- B. CARBON MONOXIDE (EXHAUST ONLY)
- C. TOTAL PARTICULATE MATTER (EXHAUST ONLY).
- D. OXIDES OF NITROGEN (EXHAUST ONLY).



FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- E. OXYGEN
- F. FLOW RATE
- G. MOISTURE
- H. TOXIC AIR CONTAMINANTS (EXHAUST ONLY), FOR ONE ENGINE PER YEAR
- I. ALDEHYDES (EXHAUST ONLY), FOR ONE ENGINE PER YEAR
- J. TOTAL REDUCED SULFUR COMPOUNDS (FUEL ONLY)
- K. NITROGEN AND CARBON DIOXIDE
- L. BTU CONTENTS (FUEL ONLY)
- M. POWER OUTPUT

[RULE 1303(b) (1) AND 1303(b) (2) - MODELING AND EMISSION OFFSET], [RULE 1110.2], [RULE 404]

15. RECORDS SHALL BE KEPT AND MAINTAINED TO PROVE COMPLIANCE WITH ALL CONDITIONS FOR THIS PERMIT. THE RECORDS SHALL BE KEPT ON FILE FOR AT LEAST FIVE YEARS AND SHALL BE MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.
[RULE 204]

Emissions And Requirements:

16. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPMV, RULE 1110.2
NOx: 45.4 PPMV, RULE 1110.2 (WITH ECF ADJUSTMENT FACTOR = 1.26)
ROG: 315 PPMV, RULE 1110.2 (WITH ECF ADJUSTMENT FACTOR = 1.26).
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
ORANGE COUNTY SANITATION DISTRICT**

PERMIT TO OPERATE

**Permit No. G27396
A/N 540710**

Equipment Description:

RESOURCE RECOVERY SYSTEM NO. 3 CONSISTING OF:

INTERNAL COMBUSTION ENGINE (CG3-HB), COOPER BESSMER, SPARK IGNITION, FOUR STROKE, WITH A MODIFIED TURBOCHARGED-INTERCOOLED V-16 TYPE, MODEL NO. LSVB-16-SGC, 4166 HP, NATURAL GAS AND/OR DIGESTER GAS FIRED, DRIVING A 3000 KW ELECTRIC GENERATOR, WITH AN EXHAUST HEAT RECOVERY STEAM GENERATOR, 6,010,200 BTU/HR CAPACITY, UNFIRED.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS EQUIPMENT SHALL BE OPERATED BY PERSONNEL PROPERLY TRAINED IN ITS OPERATION.
[RULE 204]
4. THIS ENGINE SHALL HAVE AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER TO DETERMINE THE ENGINE ELAPSED OPERATING TIME FOR EACH FUEL BLEND BURNED.
[RULE 1110.2]
5. A FLOW INDICATING AND RECORDING DEVICE SHALL BE INSTALLED IN THE FUEL GAS, OR FUEL BLEND, SUPPLY LINE TO THE ENGINE TO MEASURE AND RECORD THE QUANTITY OF EACH FUEL GAS (IN SCFM) BURNED.
[RULE 204]
6. SAMPLING PORT SHALL BE INSTALLED FOR THE INLET GAS LINE TO THE ENGINE TO ALLOW THE COLLECTION OF A FUEL GAS OR FUEL BLEND SAMPLES.
[RULE 204]
7. MONTHLY READINGS OF THE BTU CONTENT OF FUEL GAS (BTU/SCF) AT THE COMBINED INLET TO THE CGS ENGINES SHALL BE TAKEN USING AN INSTRUMENT APPROVED BY THE SCAQMD. ALL RESULTS SHALL BE RECORDED.
[RULE 204]
8. ALL RECORDING DEVICES SHALL BE SYNCHRONIZED WITH RESPECT TO THE TIME OF THE DAY.
[RULE 204]



FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

9. THE TOTAL HEAT INPUT OF GASEOUS FUEL, OR FUEL BLEND, BURNED IN THIS ENGINE SHALL NOT EXCEED 33 MM BTU PER HOUR. A LOG SHALL BE KEPT INDICATING THE TOTAL HEATING VALUE OF FUEL GAS, OR FUEL BLEND, BURNED IN THIS ENGINE BASED ON THE RECORDED FLOW RATE (SCFM) AND THE LATEST MONTHLY BTU CONTENT READING.
[RULE 1303 (b) (1) AND 1303 (b) (2)-MODELING AND EMISSIONS OFFSET]

10. THIS EQUIPMENT SHALL BE OPERATED IN COMPLIANCE WITH RULES 218, 431.1 AND 1110.2.
[RULE 218, 431.1 AND 1110.2]

11. THIS EQUIPMENT SHALL BE OPERATED IN SUCH A MANNER THAT THE FOLLOWING EMISSION RATES ARE NOT EXCEEDED.

AIR CONTAMINANT

CARBON MONOXIDE	600 PPMV AT 15% O ₂
PARTICULATES (PM ₁₀)	0.0058 GRAINS/ DSCF
ROG OR TNMHC (AS CARBON)	115 PPMV AT 15% O ₂

[RULE 1303 (a) (1), 1303(b) (1) AND 1303 (b) (2)-BACT, MODELING AND EMISSIONS OFFSET]

12. THE COMBINED EMISSIONS FROM THE FOUR (4) CGS ENGINES, USING CALENDAR MONTHLY EMISSIONS DIVIDED BY 30, SHALL NOT EXCEED THE FOLLOWING:

AIR CONTAMINANT	LBS/DAY
-----------------	---------

CARBON MONOXIDE	2,644
NITROGEN OXIDES (AS NO ₂)	828
PARTICULATES (PM ₁₀)	72
ROG OR TNMHC (AS CH ₄)	372
SULFUR DIOXIDE	84

[RULE 1303 (b) (2)-EMISSIONS OFFSET]

13. THE OPERATOR SHALL INSTALL AND MAINTAIN A CONTINUOUS EMISSION MONITORING SYSTEM (CEMS), OR AN ALTERNATIVE SYSTEM, AS APPROVED BY THE EXECUTIVE OFFICER, TO MEASURE THE ENGINE EXHAUST FOR NO_x AND O₂ CONCENTRATIONS ON A DRY BASIS, EXCEPT DURING SHUTDOWN FOR MAINTENANCE OF THE SYSTEM. IN ADDITION, THE CEMS SHALL CONVERT THE ACTUAL NO_x TO MASS EMISSION RATES; AND RECORD THE ACTUAL AND CORRECTED ENGINE NO_x CONCENTRATION AT 15% O₂ AND MASS EMISSION RATES ON AN HOURLY AND DAILY BASIS.

[RULE 218, RULE 1110.2]

14. THE OPERATOR SHALL CONDUCT PERFORMANCE TESTS ANNUALLY. WRITTEN NOTICE OF THE PERFORMANCE TEST SHALL BE PROVIDED TO THE AQMD AT LEAST 7 DAYS PRIOR TO THE TEST SO THAT AN OBSERVER MAY BE PRESENT. A COMPLETE FINAL REPORT OF THE TEST (LBS/HR, PPMVD AT 15% O₂, LBS/MMBTU, ETC.) SHALL BE PROVIDED TO THE AQMD WITHIN 45 DAYS AFTER TESTING. ALL TEST RUNS REQUIRED BY AQMD SHALL BE REPORTED. THE TESTS SHALL INCLUDE BUT NOT BE LIMITED TO, A TEST OF THE FUELS BURNED AND ENGINE EXHAUST FOR:

- A. TOTAL NON-METHANE HYDROCARBONS (EXHAUST ONLY)
- B. CARBON MONOXIDE (EXHAUST ONLY)
- C. TOTAL PARTICULATE MATTER (EXHAUST ONLY).
- D. OXIDES OF NITROGEN (EXHAUST ONLY).



FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- E. OXYGEN
 - F. FLOW RATE
 - G. MOISTURE
 - H. TOXIC AIR CONTAMINANTS (EXHAUST ONLY), FOR ONE ENGINE PER YEAR
 - I. ALDEHYDES (EXHAUST ONLY), FOR ONE ENGINE PER YEAR
 - J. TOTAL REDUCED SULFUR COMPOUNDS (FUEL ONLY)
 - K. NITROGEN AND CARBON DIOXIDE
 - L. BTU CONTENTS (FUEL ONLY)
 - M. POWER OUTPUT
- [RULE 1303(b) (1) AND 1303(b) (2) - MODELING AND EMISSION OFFSET], [RULE 1110.2], [RULE 404]

- 15 RECORDS SHALL BE KEPT AND MAINTAINED TO PROVE COMPLIANCE WITH ALL CONDITIONS FOR THIS PERMIT. THE RECORDS SHALL BE KEPT ON FILE FOR AT LEAST FIVE YEARS AND SHALL BE MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.
[RULE 204]

Emissions And Requirements:

16. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:
- CO: 2000 PPMV, RULE 1110.2
 - NOx: 45.4 PPMV, RULE 1110.2 (WITH ECF ADJUSTMENT FACTOR = 1.26)
 - ROG: 315 PPMV, RULE 1110.2 (WITH ECF ADJUSTMENT FACTOR = 1.26)
 - PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
ORANGE COUNTY SANITATION DISTRICT**

PERMIT TO OPERATE

**Permit No. G27397
A/N 540711**

Equipment Description:

RESOURCE RECOVERY SYSTEM NO. 4 CONSISTING OF:

INTERNAL COMBUSTION ENGINE (CG4-HB), COOPER BESSMER, SPARK IGNITION, FOUR STROKE, WITH A MODIFIED TURBOCHARGED-INTERCOOLED V-16 TYPE, MODEL NO. LSVB-16-SGC, 4166 HP, NATURAL GAS AND/OR DIGESTER GAS FIRED, DRIVING A 3000 KW ELECTRIC GENERATOR, WITH AN EXHAUST HEAT RECOVERY STEAM GENERATOR, 6,010,200 BTU/HR CAPACITY, UNFIRED.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS EQUIPMENT SHALL BE OPERATED BY PERSONNEL PROPERLY TRAINED IN ITS OPERATION.
[RULE 204]
4. THIS ENGINE SHALL HAVE AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER TO DETERMINE THE ENGINE ELAPSED OPERATING TIME FOR EACH FUEL BLEND BURNED.
[RULE 1110.2]
5. A FLOW INDICATING AND RECORDING DEVICE SHALL BE INSTALLED IN THE FUEL GAS, OR FUEL BLEND, SUPPLY LINE TO THE ENGINE TO MEASURE AND RECORD THE QUANTITY OF EACH FUEL GAS (IN SCFM) BURNED.
[RULE 204]
6. SAMPLING PORT SHALL BE INSTALLED FOR THE INLET GAS LINE TO THE ENGINE TO ALLOW THE COLLECTION OF A FUEL GAS OR FUEL BLEND SAMPLES.
[RULE 204]
7. MONTHLY READINGS OF THE BTU CONTENT OF FUEL GAS (BTU/SCF) AT THE COMBINED INLET TO THE CGS ENGINES SHALL BE TAKEN USING AN INSTRUMENT APPROVED BY THE SCAQMD. ALL RESULTS SHALL BE RECORDED.
[RULE 204]
8. ALL RECORDING DEVICES SHALL BE SYNCHRONIZED WITH RESPECT TO THE TIME OF THE DAY.
[RULE 204]



FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

9. THE TOTAL HEAT INPUT OF GASEOUS FUEL, OR FUEL BLEND, BURNED IN THIS ENGINE SHALL NOT EXCEED 33 MM BTU PER HOUR. A LOG SHALL BE KEPT INDICATING THE TOTAL HEATING VALUE OF FUEL GAS, OR FUEL BLEND, BURNED IN THIS ENGINE BASED ON THE RECORDED FLOW RATE (SCFM) AND THE LATEST MONTHLY BTU CONTENT READING.
[RULE 1303 (b) (1) AND 1303 (b) (2)-MODELING AND EMISSIONS OFFSET]

10. THIS EQUIPMENT SHALL BE OPERATED IN COMPLIANCE WITH RULES 218, 431.1 AND 1110.2.
[RULE 218, 431.1 AND 1110.2]

11. THIS EQUIPMENT SHALL BE OPERATED IN SUCH A MANNER THAT THE FOLLOWING EMISSION RATES ARE NOT EXCEEDED.

AIR CONTAMINANT

CARBON MONOXIDE	600 PPMV AT 15% O ₂
PARTICULATES (PM ₁₀)	0.0058 GRAINS/ DSCF
ROG OR TNMHC (AS CARBON)	115 PPMV AT 15% O ₂

[RULE 1303 (a) (1), 1303(b) (1) AND 1303 (b) (2)-BACT, MODELING AND EMISSIONS OFFSET]

12. THE COMBINED EMISSIONS FROM THE FOUR (4) CGS ENGINES, USING CALENDAR MONTHLY EMISSIONS DIVIDED BY 30, SHALL NOT EXCEED THE FOLLOWING:

AIR CONTAMINANT	LBS/DAY
-----------------	---------

CARBON MONOXIDE	2,644
NITROGEN OXIDES (AS NO ₂)	828
PARTICULATES (PM ₁₀)	72
ROG OR TNMHC (AS CH ₄)	372
SULFUR DIOXIDE	84

[RULE 1303 (b) (2)-EMISSIONS OFFSET]

13. THE OPERATOR SHALL INSTALL AND MAINTAIN A CONTINUOUS EMISSION MONITORING SYSTEM (CEMS), OR AN ALTERNATIVE SYSTEM, AS APPROVED BY THE EXECUTIVE OFFICER, TO MEASURE THE ENGINE EXHAUST FOR NO_x AND O₂ CONCENTRATIONS ON A DRY BASIS, EXCEPT DURING SHUTDOWN FOR MAINTENANCE OF THE SYSTEM. IN ADDITION, THE CEMS SHALL CONVERT THE ACTUAL NO_x TO MASS EMISSION RATES; AND RECORD THE ACTUAL AND CORRECTED ENGINE NO_x CONCENTRATION AT 15% O₂ AND MASS EMISSION RATES ON AN HOURLY AND DAILY BASIS.

[RULE 218, RULE 1110.2]

14. THE OPERATOR SHALL CONDUCT PERFORMANCE TESTS ANNUALLY. WRITTEN NOTICE OF THE PERFORMANCE TEST SHALL BE PROVIDED TO THE AQMD AT LEAST 7 DAYS PRIOR TO THE TEST SO THAT AN OBSERVER MAY BE PRESENT. A COMPLETE FINAL REPORT OF THE TEST (LBS/HR, PPMVD AT 15% O₂, LBS/MMBTU, ETC.) SHALL BE PROVIDED TO THE AQMD WITHIN 45 DAYS AFTER TESTING. ALL TEST RUNS REQUIRED BY AQMD SHALL BE REPORTED. THE TESTS SHALL INCLUDE BUT NOT BE LIMITED TO, A TEST OF THE FUELS BURNED AND ENGINE EXHAUST FOR:

- A. TOTAL NON-METHANE HYDROCARBONS (EXHAUST ONLY)
- B. CARBON MONOXIDE (EXHAUST ONLY)
- C. TOTAL PARTICULATE MATTER (EXHAUST ONLY).
- D. OXIDES OF NITROGEN (EXHAUST ONLY).



FACILITY PERMIT TO OPERATE ORANGE COUNTY SANITATION DISTRICT

- E. OXYGEN
- F. FLOW RATE
- G. MOISTURE
- H. TOXIC AIR CONTAMINANTS (EXHAUST ONLY), FOR ONE ENGINE PER YEAR
- I. ALDEHYDES (EXHAUST ONLY), FOR ONE ENGINE PER YEAR
- J. TOTAL REDUCED SULFUR COMPOUNDS (FUEL ONLY)
- K. NITROGEN AND CARBON DIOXIDE
- L. BTU CONTENTS (FUEL ONLY)
- M. POWER OUTPUT

[RULE 1303(b) (1) AND 1303(b) (2) - MODELING AND EMISSION OFFSET], [RULE 1110.2], [RULE 404]

- 15 RECORDS SHALL BE KEPT AND MAINTAINED TO PROVE COMPLIANCE WITH ALL CONDITIONS FOR THIS PERMIT. THE RECORDS SHALL BE KEPT ON FILE FOR AT LEAST FIVE YEARS AND SHALL BE MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.
[RULE 204]

Emissions And Requirements:

16. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPMV, RULE 1110.2
NOx: 45.4 PPMV, RULE 1110.2 (WITH ECF ADJUSTMENT FACTOR = 1.26)
ROG: 315 PPMV, RULE 1110.2 (WITH ECF ADJUSTMENT FACTOR = 1.26)
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS



**FACILITY PERMIT TO OPERATE
ORANGE COUNTY SANITATION DISTRICT**

PERMIT TO OPERATE

**Permit No. G27398
A/N 540712**

Equipment Description:

RESOURCE RECOVERY SYSTEM NO. 5 CONSISTING OF:

INTERNAL COMBUSTION ENGINE (CG5-HB), COOPER BESSMER, SPARK IGNITION, FOUR STROKE, WITH A MODIFIED TURBOCHARGED-INTERCOOLED V-16 TYPE, MODEL NO. LSVB-16-SGC, 4166 HP, NATURAL GAS AND/OR DIGESTER GAS FIRED, DRIVING A 3000 KW ELECTRIC GENERATOR, WITH AN EXHAUST HEAT RECOVERY STEAM GENERATOR, 6,010,200 BTU/HR CAPACITY, UNFIRED.

Conditions:

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
[RULE 204]
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
[RULE 204]
3. THIS EQUIPMENT SHALL BE OPERATED BY PERSONNEL PROPERLY TRAINED IN ITS OPERATION.
[RULE 204]
4. THIS ENGINE SHALL HAVE AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER TO DETERMINE THE ENGINE ELAPSED OPERATING TIME FOR EACH FUEL BLEND BURNED.
[RULE 1110.2]
5. A FLOW INDICATING AND RECORDING DEVICE SHALL BE INSTALLED IN THE FUEL GAS, OR FUEL BLEND, SUPPLY LINE TO THE ENGINE TO MEASURE AND RECORD THE QUANTITY OF EACH FUEL GAS (IN SCFM) BURNED.
[RULE 204]
6. SAMPLING PORT SHALL BE INSTALLED FOR THE INLET GAS LINE TO THE ENGINE TO ALLOW THE COLLECTION OF A FUEL GAS OR FUEL BLEND SAMPLES.
[RULE 204]
7. MONTHLY READINGS OF THE BTU CONTENT OF FUEL GAS (BTU/SCF) AT THE COMBINED INLET TO THE CGS ENGINES SHALL BE TAKEN USING AN INSTRUMENT APPROVED BY THE SCAQMD. ALL RESULTS SHALL BE RECORDED.
[RULE 204]
8. ALL RECORDING DEVICES SHALL BE SYNCHRONIZED WITH RESPECT TO THE TIME OF THE DAY.
[RULE 204]



**FACILITY PERMIT TO OPERATE
ORANGE COUNTY SANITATION DISTRICT**

9. THE TOTAL HEAT INPUT OF GASEOUS FUEL, OR FUEL BLEND, BURNED IN THIS ENGINE SHALL NOT EXCEED 33 MM BTU PER HOUR. A LOG SHALL BE KEPT INDICATING THE TOTAL HEATING VALUE OF FUEL GAS, OR FUEL BLEND, BURNED IN THIS ENGINE BASED ON THE RECORDED FLOW RATE (SCFM) AND THE LATEST MONTHLY BTU CONTENT READING.
[RULE 1303 (b) (1) AND 1303 (b) (2)-MODELING AND EMISSIONS OFFSET]

10. THIS EQUIPMENT SHALL BE OPERATED IN COMPLIANCE WITH RULES 218, 431.1 AND 1110.2.
[RULE 218, 431.1 AND 1110.2]

11. THIS EQUIPMENT SHALL BE OPERATED IN SUCH A MANNER THAT THE FOLLOWING EMISSION RATES ARE NOT EXCEED.

AIR CONTAMINANT	
CARBON MONOXIDE	600 PPMV AT 15% O ₂
PARTICULATES (PM ₁₀)	0.0058 GRAINS/ DSCF
ROG OR TNMHC (AS CARBON)	115 PPMV AT 15% O ₂
[RULE 1303 (a) (1), 1303(b) (1) AND 1303 (b) (2)-BACT, MODELING AND EMISSIONS OFFSET]	

12. THE COMBINED EMISSIONS FROM THE FOUR (4) CGS ENGINES, USING CALENDAR MONTHLY EMISSIONS DIVIDED BY 30, SHALL NOT EXCEED THE FOLLOWING:

AIR CONTAMINANT	LBS/DAY
CARBON MONOXIDE	2,644
NITROGEN OXIDES (AS NO ₂)	828
PARTICULATES (PM ₁₀)	72
ROG OR TNMHC (AS CH ₄)	372
SULFUR DIOXIDE	84
[RULE 1303 (b) (2)-EMISSIONS OFFSET]	

13. THE OPERATOR SHALL INSTALL AND MAINTAIN A CONTINUOUS EMISSION MONITORING SYSTEM (CEMS), OR AN ALTERNATIVE SYSTEM, AS APPROVED BY THE EXECUTIVE OFFICER, TO MEASURE THE ENGINE EXHAUST FOR NO_x AND O₂ CONCENTRATIONS ON A DRY BASIS, EXCEPT DURING SHUTDOWN FOR MAINTENANCE OF THE SYSTEM. IN ADDITION, THE CEMS SHALL CONVERT THE ACTUAL NO_x TO MASS EMISSION RATES; AND RECORD THE ACTUAL AND CORRECTED ENGINE NO_x CONCENTRATION AT 15% O₂ AND MASS EMISSION RATES ON AN HOURLY AND DAILY BASIS.
[RULE 218, RULE 1110.2]

14. THE OPERATOR SHALL CONDUCT PERFORMANCE TESTS ANNUALLY. WRITTEN NOTICE OF THE PERFORMANCE TEST SHALL BE PROVIDED TO THE AQMD AT LEAST 7 DAYS PRIOR TO THE TEST SO THAT AN OBSERVER MAY BE PRESENT. A COMPLETE FINAL REPORT OF THE TEST (LBS/HR, PPMVD AT 15% O₂, LBS/MMBTU, ETC.) SHALL BE PROVIDED TO THE AQMD WITHIN 45 DAYS AFTER TESTING. ALL TEST RUNS REQUIRED BY AQMD SHALL BE REPORTED. THE TESTS SHALL INCLUDE BUT NOT BE LIMITED TO, A TEST OF THE FUELS BURNED AND ENGINE EXHAUST FOR:

- A. TOTAL NON-METHANE HYDROCARBONS (EXHAUST ONLY)
- B. CARBON MONOXIDE (EXHAUST ONLY)
- C. TOTAL PARTICULATE MATTER (EXHAUST ONLY).
- D. OXIDES OF NITROGEN (EXHAUST ONLY).



**FACILITY PERMIT TO OPERATE
ORANGE COUNTY SANITATION DISTRICT**

- E. OXYGEN
- F. FLOW RATE
- G. MOISTURE
- H. TOXIC AIR CONTAMINANTS (EXHAUST ONLY), FOR ONE ENGINE PER YEAR
- I. ALDEHYDES (EXHAUST ONLY), FOR ONE ENGINE PER YEAR
- J. TOTAL REDUCED SULFUR COMPOUNDS (FUEL ONLY)
- K. NITROGEN AND CARBON DIOXIDE
- L. BTU CONTENTS (FUEL ONLY)
- M. POWER OUTPUT

[RULE 1303(b) (1) AND 1303(b) (2) - MODELING AND EMISSION OFFSET], [RULE 1110.2], [RULE 404]

15. RECORDS SHALL BE KEPT AND MAINTAINED TO PROVE COMPLIANCE WITH ALL CONDITIONS FOR THIS PERMIT. THE RECORDS SHALL BE KEPT ON FILE FOR AT LEAST FIVE YEARS AND SHALL BE MADE AVAILABLE TO AQMD PERSONNEL UPON REQUEST.
[RULE 204]

Emissions And Requirements:

16. THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS:

CO: 2000 PPMV, RULE 1110.2
NOx: 45.4 PPMV, RULE 1110.2 (WITH ECF ADJUSTMENT FACTOR = 1.26)
ROG: 315 PPMV, RULE 1110.2 (WITH ECF ADJUSTMENT FACTOR = 1.26)
PM: RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

**ORANGE COUNTY SANITATION DISTRICT
PLANT NO. 2 – UNITS 2 and 4
RULE 1110.2 8760 HOUR & PERMIT COMPLIANCE
TEST REPORT YEAR 2014**

PREPARED FOR:

Orange County Sanitation District
10844 Ellis Avenue
Fountain Valley, California 92708-7018

EQUIPMENT LOCATION:

Treatment Plant No. 2
Huntington Beach, California

EQUIPMENT DESCRIPTION:

Engine 2 A/N: # 540709 & PTO: # G27395
Engine 4 A/N: # 540711 & PTO: # G27397

TEST DATES:

December 18, 2014
January 28, 2015

ISSUE DATE:

April 15, 2015

PREPARED BY:

Ellice Lin
SCEC
1631 East Saint Andrew Place
Santa Ana, California 92705

Report No: 2061.1060.rpt3

Tested By:


Rudy Nunez, QSTI

Reviewed By:


Kevin Cahill, Project Manager

Table of Contents

	<u>Page No.</u>
1.0 Executive Summary and Results	1
2.0 Introduction and Test Description	6
2.1 Test Conditions	6
2.2 Sample Locations	6
3.0 Source Information and Equipment Description	7
4.0 Test Critique	9
5.0 Sampling and Analytical Methods	10

Tables

1.1 Engine No. 2 Test Result Summary	2
1.2 Engine No. 4 Test Result Summary	3
1.3 Engine No. 2 VOC Test Results	4
1.4 Engine No. 4 VOC Test Results	5
3.1 Engine Operating Parameters	8
5.1 Test Procedures Engines 2 and 4	10

Appendices

Appendix A – SCAQMD Methods 100.1, 25.1/25.3, 1.1-4.1 and 5.1 Results	A-1
Appendix B – Stack Sampling Location Schematic	B-1
Appendix C – Field Data Sheets SCAQMD Methods 100.1, 25.1/25.3, 1.1-4.1, 5.1	C-1
Appendix D – QA/QC SCAQMD Method 100.1	D-1
Appendix E – Laboratory Analytical Data	E-1
Appendix F – Calibration Data and Calibration Gas Certificates	F-1

Table of Contents (Continued)

	<u>Page No.</u>
<u>Appendices (Continued)</u>	
Appendix G – Chain of Custody Information	G-1
Appendix H – Process Operating Data and Fuel Usage	H-1
Appendix I – Certifications	I-1
Appendix J – SCAQMD Permits	J-1

1.0 Executive Summary and Results

On December 18, 2014, SCEC performed a compliance source test program on two (2) internal combustion (IC) engines at the Orange County Sanitation District's Treatment Plant No. 2. The test program included nitrogen oxides (NO_x), carbon monoxide (CO), carbon dioxide (CO₂) and oxygen (O₂) concentration emission measurements. The tests were performed on each IC engine at high, normal and low loads. The normal load test was 60 minutes in duration. The low and high loads were each 15 minutes in duration. In addition, 60-minute total gaseous non-methane/ethane organics (TNMHC) samples and 72-minute particulate matter (PM) samples were collected at normal load. The TNMHC samples were conducted on December 18, 2014 and were resampled again on January 28, 2015. Digester gas fuel samples were collected at the inlet of each IC engine and analyzed for total reduced sulfurs (TRS), BTU content and fixed gases. All tests were conducted while each IC engine was fired on 5% natural gas and 95% digester gas fuel. All testing was performed under steady-state operating conditions at the outlets of (IC) Engines No. 2 and 4.

The purpose of this testing was to document emissions for comparison with South Coast Air Quality Management District (SCAQMD) Rule 1110.2 limits and to verify compliance with permit requirements. The test program was performed as part of the annual source test required by SCAQMD Rule 1110.2 and permit conditions.

NO_x, CO, CO₂ and O₂ concentrations were determined according to SCAQMD Method 100.1. The SCAQMD Method 100.1 results were recorded using a Data Acquisition System (DAS) in parts per million (ppm) for NO_x and CO and percent volume (%) for O₂ and CO₂ every 2 seconds and presented in one minute averages. All mass emissions were calculated based on pitot-measured volumetric flow rates (SCAQMD Methods 1.1-4.1) determined at high, normal and low loads. The results of the test program are summarized in Tables 1.1 through 1.4.

On-site source testing personnel for SCEC included Mr. Rudy Nunez – District Manager and Mr. Anthony L. Weiss and Mr. Jason Deberg– Project Technicians. Mr. Vladimir Kogan and Ms. Randa AbuShaban of OCSD coordinated all IC engine requirements. This compliance report presents the sampling methodology, data, calculations and results.

TABLE 1.1
SUMMARY OF RESULTS SCAQMD RULE 1110.2 8760 HOUR TEST & PERMIT COMPLIANCE
OCS D PLANT 2
ENGINE #2
December 18, 2014

Parameter	Units	Normal Load	High Load	Low Load	Average
NO _x	ppmvd	46.1	47.7	45.6	46.5
	ppmvd @ 15% O ₂	30.0	31.9	29.0	30.3
	lb/MMBtu	0.12	0.13	0.12	0.12
	lb/hr	3.04	3.53	2.46	3.01
	lb/MMcf	75.6	80.5	73.2	76.4
CO	ppmvd	509	535	494	513
	ppmvd @ 15% O ₂	331	358	314	334
	lb/MMBtu	0.80	0.87	0.76	0.81
	lb/hr	20.4	24.1	16.2	20.2
	lb/MMcf	508	549	483	513
PM	gr/DSCF	0.0061	-	-	0.0061
	lb/hr	0.47	-	-	0.47
O ₂	%	11.8	12.1	11.6	11.8
CO ₂	%	7.44	7.22	7.61	7.42
N ₂	%	80.74	80.70	80.78	80.74
Inlet TRS	ppmv	10.6	-	-	10.6
	lb/hr as SO ₂	0.97	-	-	0.97
Fuel Heating Value	BTU/SCF	622	-	-	622
Fuel Flow	SCFM	700	836	636	724
Load	kW	2,583	3,000	2,269	2,617
Volume Flow ⁽¹⁾	DSCFM	9,056	10,156	7,400	8,871

⁽¹⁾ Calculated based on SCAQMD Methods 1-4.

TABLE 1.2
SUMMARY OF RESULTS SCAQMD RULE 1110.2 8760 HOUR TEST & PERMIT COMPLIANCE
OCS D PLANT 2
ENGINE #4
December 18, 2014

Parameter	Units	Normal Load	High Load	Low Load	Average
NO _x	ppmvd	43.4	44.6	42.8	43.6
	ppmvd @ 15% O ₂	29.9	31.0	28.5	29.8
	lb/MMBtu	0.12	0.12	0.11	0.12
	lb/hr	2.98	3.36	2.41	2.92
	lb/MMcf	75.6	78.4	71.9	75.3
CO	ppmvd	571	581	552	568
	ppmvd @ 15% O ₂	393	404	367	388
	lb/MMBtu	0.95	0.97	0.88	0.94
	lb/hr	23.9	26.6	18.9	23.1
	lb/MMcf	605	621	564	597
PM	gr/DSCF	0.0033	-	-	0.0033
	lb/hr	0.27	-	-	0.27
O ₂	%	12.3	12.4	12.0	12.3
CO ₂	%	7.11	6.98	7.29	7.12
N ₂	%	80.56	80.60	80.68	80.61
Inlet TRS	ppmv	12.2	-	-	12.2
	lb/hr as SO ₂	1.17	-	-	1.17
Fuel Heating Value	BTU/SCF	627	-	-	627
Fuel Flow	SCFM	709	779	631	706
Load	kW	2,539	3,000	2,225	2,588
Volume Flow ⁽¹⁾	DSCFM	9,425	10,331	7,733	9,163

⁽¹⁾ Calculated based on SCAQMD Methods 1-4.

TABLE 1.3
SUMMARY OF VOC RESULTS
OCSD PLANT 2
ENGINE #2
January 28, 2015

Parameter	Units	Normal Load
TNMHC	ppmv	111.8
	ppmvd @ 15% O ₂	76.6
	lb/MMBtu	0.103
	lb/hr as CH ₄	2.66
	lbs/MMcf	64.4
O ₂	%	12.3
CO ₂	%	6.82
N ₂	%	80.88
Fuel Heating Value	BTU/SCF	614
Fuel Flow	SCFM	683
Load	kW	2,461
Volume Flow ⁽¹⁾	DSCFM	9,383

⁽¹⁾ Calculated based on SCAQMD Methods 1-4.

TABLE 1.4
SUMMARY OF VOC RESULTS
OCSD PLANT 2
ENGINE #4
January 28, 2015

Parameter	Units	Normal Load
TNMHC	ppmv	63.6
	ppmvd @ 15% O ₂	42.7
	lb/MMBtu	0.057
	lb/hr as CH ₄	1.50
	lbs/MMcf	35.9
O ₂	%	12.1
CO ₂	%	6.72
N ₂	%	81.16
Fuel Heating Value	BTU/SCF	614
Fuel Flow	SCFM	660
Load	kW	2,278
Volume Flow ⁽¹⁾	DSCFM	9,294

⁽¹⁾ Calculated based on SCAQMD Methods 1-4.

2.0 Introduction and Test Description

OCSD retained SCEC to source test two (2) Cooper-Bessemer engines subject to the requirements of SCAQMD Rule 1110.2 and site specific permit conditions. Gaseous, PM, TRS and fuel analysis test results for Engines 2 and 4 are presented in Table 1.1 – Table 1.2, respectively.

2.1 Test Conditions

Each IC engine was operated at three conditions (low, normal, and high load) while firing on 95% digester gas fuel. Engine data were monitored and recorded throughout each test period. These data are provided in Table 3.1 and Appendix H.

2.2 Sample Locations

All engine exhaust emissions samples were collected from each IC engine at its main exhaust stack. Emissions testing on each engine was conducted on the thirty-inch diameter discharge stack located approximately 59 feet above ground level on the engine building rooftop. Two sample ports 90° apart were utilized for sampling on the exhaust stack. The sample ports are located approximately 4.5 duct diameters downstream and 1.8 duct diameters upstream from the nearest flow disturbances.

Engine inlet fuel samples were analyzed for heat content, TRS and fixed gases. These samples were collected at the digester gas fuel line input to each IC engine.

3.0 Source Information and Equipment Description

Legal Owner: Orange County Sanitation District
10844 Ellis Avenue
Fountain Valley, CA 92708

Facility Contact: Mr. Vladimir Kogan
Environmental Compliance Division
Site No.: (714) 593-7085

Equipment Location: Treatment Plant No. 2
22212 Brookhurst Avenue
Huntington Beach, CA 92646

Equipment Description:

Engines 2 and 4 are Cooper LSVB-16-SGC reciprocating internal combustion engines and are located at the Orange County Sanitation District's facility in Huntington Beach, California. Each engine is a four-stroke turbocharged lean-burn spark-ignited unit, utilizing pre-combustion chambers to minimize NO_x emissions. Each engine is directly coupled to a synchronous generator and is rated at 3000 kW. Each engine was operated at high, normal and low loads while firing a 5%/95% natural-gas/digester-gas mixture.

TABLE 3.1
ENGINE OPERATING PARAMETERS

Engine 2 – Operating Parameters on December 18, 2014

Parameter	Units	High Load	Normal Load	Low Load
Load	KW	3,000	2,583	2,269
Fuel Usage (Di-gas)	SCFM	836	700	636
Speed	RPM	360	360	360

Engine 4 – Operating Parameters on December 18, 2014

Parameter	Units	High Load	Normal Load	Low Load
Load	KW	3,000	2,338	2,290
Fuel Usage (Di-gas)	SCFM	798	660	650
Speed	RPM	360	360	360

Engine 2 – Operating Parameters on January 28, 2015

Parameter	Units	Normal Load
Load	KW	2,461
Fuel Usage (Di-gas)	SCFM	683
Speed	RPM	360

Engine 4 – Operating Parameters on January 28, 2015

Parameter	Units	Normal Load
Load	KW	2,278
Fuel Usage (Di-gas)	SCFM	660
Speed	RPM	360

4.0 Test Critique

The Orange County Sanitation District retained the services of SCEC to perform the annual 8760 hour SCAQMD Rule 1110.2 and permit compliance source emissions test program on their Central Generation System natural gas/digester gas fired IC Engines 2 and 4 at Plant No. 2 in Huntington Beach, California. The test program was performed in accordance with SCAQMD Rule 1110.2 and each individual testing method. The results of the test program are considered to be representative of the engine emissions at the time of the test.

The TNMHCs were tested on January 28, 2015. The lab associate who conducted the testing commented that “the trap associated with the sample P2E4 Run – 1A released excess water upon burning, indicating it contained frozen water and biased the results high.” Therefore the test results for Run – 1A was found to be inconclusive and were omitted from the final reporting results. The test results from Run – 1B was used to calculate the TNMHC lb/hr and report final test results.

Calibration error checks were performed at the start and end of each test day. System bias checks were performed before and after each Method 100.1 sampling run. All system bias and calibration error checks were within the allowable tolerance. A NO_x converter efficiency check was performed daily. The NO_x converter efficiency checks conducted on December 18, 2014 for both Engines #2 and #4 was 95.5%.

Complete laboratory QA/QC data packages are provided in electronic PDF format on a CD-ROM included with this report.

All mass emissions were calculated based on pitot-tube measured volumetric flow rates. Moisture content from the particulate sample train was utilized during all volumetric flow rate calculations.

5.0 Sampling and Analytical Methods

The test procedures used for the inlet and exhaust measurements are summarized below in Table 5.1.

**TABLE 5.1
TEST PROCEDURES
OCS D Plant 2: Engines 2 and 4**

Parameter	Method	Number of Repetitions	Duration	Permit Required	Rule 1110.2 Required
<i>Inlet Sample Location</i>					
BTU	ASTM D3588	1	Grab	X	---
N ₂ , O ₂ , CO ₂	SCAQMD 10.1	1	Grab	X	---
TRS	SCAQMD 307	1	Grab	X	---
Flow Rate	CEMS Fuel Meter	1	60 min	X	X
<i>Exhaust Sample Location(Normal Load)</i>					
Moisture	SCAQMD 4.1	1	60 min	X	---
Flow Rate	SCAQMD 1.1, 2.1, 3.1	1	60 min	X	X
N ₂ , O ₂ , CO ₂	SCAQMD 100.1	1	60 min	X	X
NO _x	SCAQMD 100.1	1	60 min	X	X
CO	SCAQMD 100.1	1	60 min	X	X
TNMHC/CH ₄	SCAQMD 25.1	1 Tray	60 min	X	X
PM	SCAQMD 5.1	1	60 min	X	---
<i>Exhaust Sample Location(High and Low Load)</i>					
Flow Rate	SCAQMD 1.1, 2.1, 3.1	1	15 min	X	---
N ₂ , O ₂ , CO ₂	SCAQMD 100.1	1	15 min	X	---
NO _x	SCAQMD 100.1	1	15 min	X	---
CO	SCAQMD 100.1	1	15 min	X	---

There were no method deviations from the submitted source test protocol during the performance of the source test. PM sample time was increased from 60 to 72 minutes as sampling was done for three minutes at each traverse point.

List of Appendices

Appendix A – SCAQMD Methods 100.1, 25.1/25.3, 1.1-4.1 and 5.1 Results

Appendix B – Stack Sampling Location Schematic

**Appendix C – Field Data Sheets SCAQMD Methods 100.1, 25.1/25.3,
1.1-4.1, 5.1**

Appendix D – QA/QC SCAQMD Method 100.1

Appendix E – Laboratory Analytical Data

Appendix F – Calibration Data and Calibration Gas Certificates

Appendix G – Chain of Custody Information

Appendix H– Process Operating Data and Fuel Usage

Appendix I – Certifications

Appendix J – SCAQMD Permits

Appendix A

SCAQMD Methods 100.1, 25.1/25.3, 1.1-4.1 and 5.1 Results

SUMMARY OF CONTINUOUS MONITORING DATA

FACILITY:	OCSD PLANT 2	DATA FOR SAMPLING RUN:		NORMAL LOAD	
SOURCE ID:	ENGINE #2	DATE: 12/18/14		TIME:	1630-1730
OPERATOR:	RN	PROJECT No.:	2061.1060		
PARAMETER UNITS	O ₂ % VOL DRY	CO ₂ % VOL DRY	NO _x PPMV,D	CO PPMV,D	SO ₂ PPMV,D
INITIAL ZERO BIAS	0.00	0.21	0.80	1.20	---
INITIAL SPAN BIAS	12.45	8.33	42.40	854.10	---
FINAL ZERO BIAS	0.00	0.18	0.60	0.90	---
FINAL SPAN BIAS	12.51	8.25	43.00	855.30	---
AVERAGE ZERO BIAS	0.00	0.20	0.70	1.05	---
AVERAGE SPAN BIAS	12.48	8.29	42.70	854.70	---
BIAS GAS CONCENTRATION	12.50	8.23	42.60	858.00	---
FULL SCALE RANGE	25.00	20.00	100.00	2000.00	---
UNCORRECTED CONC.	11.80	7.51	46.13	507.28	---
CORRECTED CONC.	11.82	7.44	46.08	508.81	---
PPMV @ 15 % O2			29.95	330.74	---
LB/HR BASED ON PITOT FLOW (DSCFM)	9,056		3.04	20.42	---

SUMMARY OF CONTINUOUS MONITORING DATA

FACILITY:	OCSD PLANT 2	DATA FOR SAMPLING RUN:		HIGH LOAD	
SOURCE ID:	ENGINE #2	DATE: 12/18/14		TIME:	1825-1840
OPERATOR:	RN	PROJECT No.:	2061.1060		
PARAMETER UNITS	O ₂ % VOL DRY	CO ₂ % VOL DRY	NO _x PPMV,D	CO PPMV,D	SO ₂ PPMV,D
INITIAL ZERO BIAS	0.00	0.18	0.60	0.90	---
INITIAL SPAN BIAS	12.51	8.25	43.00	855.30	---
FINAL ZERO BIAS	0.01	0.15	0.90	1.60	---
FINAL SPAN BIAS	12.36	8.36	43.00	854.90	---
AVERAGE ZERO BIAS	0.01	0.17	0.75	1.25	---
AVERAGE SPAN BIAS	12.44	8.31	43.00	855.10	---
BIAS GAS CONCENTRATION	12.50	8.23	42.60	858.00	---
FULL SCALE RANGE	25.00	20.00	100.00	2000.00	---
UNCORRECTED CONC.	12.02	7.30	48.03	533.18	---
CORRECTED CONC.	12.08	7.22	47.67	534.51	---
PPMV @ 15 % O2			31.90	357.71	---
LB/HR BASED ON PITOT FLOW (DSCFM)	10,156		3.53	24.06	---

SUMMARY OF CONTINUOUS MONITORING DATA

FACILITY:	OCSD PLANT 2	DATA FOR SAMPLING RUN:		LOW LOAD	
SOURCE ID:	ENGINE #2	DATE: 12/18/14		TIME: 1753-1808	
OPERATOR:	RN	PROJECT No.:	2061.1060		
PARAMETER UNITS	O ₂ % VOL DRY	CO ₂ % VOL DRY	NO _x PPMV,D	CO PPMV,D	SO ₂ PPMV,D
INITIAL ZERO BIAS	0.01	0.18	0.60	0.80	---
INITIAL SPAN BIAS	12.51	8.25	43.00	855.30	---
FINAL ZERO BIAS	0.00	0.16	1.40	1.60	---
FINAL SPAN BIAS	12.36	8.36	43.00	854.90	---
AVERAGE ZERO BIAS	0.01	0.17	1.00	1.20	---
AVERAGE SPAN BIAS	12.44	8.31	43.00	855.10	---
BIAS GAS CONCENTRATION	12.50	8.23	42.60	858.00	---
FULL SCALE RANGE	25.00	20.00	100.00	2000.00	---
UNCORRECTED CONC.	11.56	7.69	46.00	493.15	---
CORRECTED CONC.	11.62	7.61	45.64	494.31	---
PPMV @ 15 % O2			29.01	314.21	---
LB/HR BASED ON PITOT FLOW (DSCFM)	7,400		2.46	16.21	---

OCSD PLANT 2 ENGINE 2 COMPLIANCE (NORM LOAD)

December 18, 2014

RAW DAS DATA - RM RUN 1

DATA PT	DATE	TIME	O2 % VD	CO2 % VD	NOx PPMVD	CO PPMVD
1	12/18	16:30:19	11.86	7.46	46.5	498.9
2	12/18	16:31:19	11.82	7.50	46.0	494.9
3	12/18	16:32:19	11.84	7.48	46.2	498.9
4	12/18	16:33:19	11.83	7.49	46.8	490.9
5	12/18	16:34:19	11.91	7.42	46.0	496.5
6	12/18	16:35:19	11.92	7.42	44.1	511.3
7	12/18	16:36:19	11.89	7.44	44.4	505.7
8	12/18	16:37:19	11.89	7.43	45.8	496.1
9	12/18	16:38:19	11.91	7.42	45.8	499.3
10	12/18	16:39:19	11.83	7.50	47.1	498.9
11	12/18	16:40:19	11.79	7.53	47.1	496.5
12	12/18	16:41:19	11.80	7.52	46.3	505.7
13	12/18	16:42:19	11.81	7.51	46.1	510.1
14	12/18	16:43:19	11.82	7.50	46.5	502.9
15	12/18	16:44:19	11.78	7.52	45.8	510.1
16	12/18	16:45:19	11.78	7.53	46.2	506.5
17	12/18	16:46:19	11.83	7.49	46.8	505.7
18	12/18	16:47:19	11.81	7.51	46.3	508.5
19	12/18	16:48:19	11.80	7.51	46.8	505.7
20	12/18	16:49:19	11.76	7.54	46.3	510.5
21	12/18	16:50:19	11.80	7.52	46.9	508.5
22	12/18	16:51:19	11.83	7.48	47.2	507.3
23	12/18	16:52:19	11.78	7.52	46.4	506.5
24	12/18	16:53:19	11.80	7.50	46.1	509.3
25	12/18	16:54:19	11.78	7.52	46.1	505.3
26	12/18	16:55:19	11.77	7.53	48.4	497.7
27	12/18	16:56:19	11.82	7.49	46.8	508.9
28	12/18	16:57:19	11.87	7.45	45.3	518.6
29	12/18	16:58:19	11.87	7.45	45.2	522.2
30	12/18	16:59:19	11.80	7.50	44.6	521.4

31	12/18	17:00:19	11.78	7.52	45.9	512.1
32	12/18	17:01:19	11.76	7.54	45.8	515.4
33	12/18	17:02:19	11.81	7.51	45.9	511.3
34	12/18	17:03:19	11.78	7.53	45.9	512.1
35	12/18	17:04:19	11.80	7.51	45.4	514.1
36	12/18	17:05:19	11.79	7.53	45.9	506.5
37	12/18	17:06:19	11.77	7.54	46.5	502.5
38	12/18	17:07:19	11.80	7.51	47.1	501.7
39	12/18	17:08:19	11.80	7.53	45.4	510.1
40	12/18	17:09:19	11.82	7.52	45.7	511.3
41	12/18	17:10:19	11.78	7.54	44.8	515.0
42	12/18	17:11:19	11.77	7.55	46.0	509.7
43	12/18	17:12:19	11.83	7.52	46.9	509.7
44	12/18	17:13:19	11.81	7.53	45.5	512.9
45	12/18	17:14:19	11.76	7.55	45.4	512.1
46	12/18	17:15:19	11.76	7.57	46.0	511.3
47	12/18	17:16:19	11.77	7.55	46.8	505.7
48	12/18	17:17:19	11.78	7.55	46.8	503.3
49	12/18	17:18:19	11.77	7.55	46.9	504.5
50	12/18	17:19:19	11.78	7.54	45.8	513.3
51	12/18	17:20:19	11.83	7.50	45.3	512.1
52	12/18	17:21:19	11.76	7.56	46.2	504.9
53	12/18	17:22:19	11.75	7.57	47.2	500.1
54	12/18	17:23:19	11.78	7.54	47.2	508.1
55	12/18	17:24:19	11.81	7.54	46.5	508.1
56	12/18	17:25:19	11.75	7.55	45.5	512.5
57	12/18	17:26:19	11.75	7.57	46.0	505.3
58	12/18	17:27:19	11.78	7.54	47.0	505.3
59	12/18	17:28:19	11.77	7.54	45.8	508.5
60	12/18	17:29:19	11.80	7.52	45.4	513.3
61	12/18	17:30:19	11.78	7.54	45.3	512.1
AVERAGES			11.80	7.51	46.13	507.28

OCSD PLANT 2 ENGINE 2 COMPLIANCE (HIGH LOAD)

December 18, 2014

RAW DAS DATA - RM RUN 2

DATA PT	DATE	TIME	O2 % VD	CO2 % VD	NOx PPMVD	CO PPMVD
1	12/18	18:25:19	11.99	7.34	47.5	537.8
2	12/18	18:26:19	12.00	7.33	47.9	535.4
3	12/18	18:27:19	12.02	7.31	48.1	534.2
4	12/18	18:28:19	12.01	7.31	48.3	530.2
5	12/18	18:29:19	12.01	7.33	48.1	531.4
6	12/18	18:30:19	12.04	7.29	48.0	530.6
7	12/18	18:31:19	12.03	7.30	48.1	530.2
8	12/18	18:32:19	12.03	7.30	48.2	534.2
9	12/18	18:33:19	12.06	7.28	47.4	541.0
10	12/18	18:34:19	12.04	7.28	47.9	535.4
11	12/18	18:35:19	11.99	7.32	48.0	529.4
12	12/18	18:36:19	12.02	7.29	49.1	527.8
13	12/18	18:37:19	12.01	7.29	48.4	528.2
14	12/18	18:38:19	12.03	7.28	48.5	533.8
15	12/18	18:39:19	12.04	7.29	47.4	534.2
16	12/18	18:40:19	12.02	7.30	47.5	537.0
AVERAGES			12.02	7.30	48.03	533.18

December 18, 2014
RAW DAS DATA - RM RUN 3

A-8

SUMMARY OF CONTINUOUS MONITORING DATA

FACILITY:	OCS D PLANT 2	DATA FOR SAMPLING RUN:		NORMAL LOAD	
SOURCE ID:	ENGINE #4	DATE: 12/18/14		TIME: 1304-1404	
OPERATOR:	RN	PROJECT No.:	2061.1060		
PARAMETER	O ₂	CO ₂	NO _x	CO	SO ₂
UNITS	% VOL DRY	% VOL DRY	PPMV,D	PPMV,D	PPMV,D
INITIAL ZERO BIAS	0.02	0.25	0.00	1.20	---
INITIAL SPAN BIAS	12.37	8.29	41.90	856.50	---
FINAL ZERO BIAS	0.00	0.14	0.30	0.80	---
FINAL SPAN BIAS	12.61	8.10	41.80	862.90	---
AVERAGE ZERO BIAS	0.01	0.20	0.15	1.00	---
AVERAGE SPAN BIAS	12.49	8.20	41.85	859.70	---
BIAS GAS CONCENTRATION	12.50	8.23	42.60	858.00	---
FULL SCALE RANGE	25.00	20.00	100.00	2000.00	---
UNCORRECTED CONC.	12.32	7.10	42.68	572.73	---
CORRECTED CONC.	12.33	7.11	43.45	571.27	---
PPMV @ 15 % O2			29.93	393.48	---
LB/HR BASED ON PITOT FLOW (DSCFM)	9,425		2.98	23.86	---

SUMMARY OF CONTINUOUS MONITORING DATA

FACILITY:	OCS D PLANT 2	DATA FOR SAMPLING RUN:		HIGH LOAD	
SOURCE ID:	ENGINE #4	DATE:	12/18/14	TIME:	1528-1543
OPERATOR:	RN	PROJECT No.:	2061.1060		
PARAMETER UNITS	O ₂ % VOL DRY	CO ₂ % VOL DRY	NO _x PPMV,D	CO PPMV,D	SO ₂ PPMV,D
INITIAL ZERO BIAS	0.00	0.14	0.30	0.80	---
INITIAL SPAN BIAS	12.61	8.10	41.80	862.90	---
FINAL ZERO BIAS	0.01	0.21	0.80	1.20	---
FINAL SPAN BIAS	12.45	8.33	42.40	854.10	---
AVERAGE ZERO BIAS	0.01	0.18	0.55	1.00	---
AVERAGE SPAN BIAS	12.53	8.22	42.10	858.50	---
BIAS GAS CONCENTRATION	12.50	8.23	42.60	858.00	---
FULL SCALE RANGE	25.00	20.00	100.00	2000.00	---
UNCORRECTED CONC.	12.45	6.99	44.06	581.71	---
CORRECTED CONC.	12.42	6.98	44.61	581.05	---
PPMV @ 15 % O2			31.04	404.34	---
LB/HR BASED ON PITOT FLOW (DSCFM)	10,331		3.36	26.61	---

SUMMARY OF CONTINUOUS MONITORING DATA

FACILITY:	OCSD PLANT 2	DATA FOR SAMPLING RUN:		LOW LOAD	
SOURCE ID:	ENGINE #4	DATE: 12/18/14		TIME:	1457-1512
OPERATOR:	RN	PROJECT No.:	2061.1060		
PARAMETER UNITS	O ₂ % VOL DRY	CO ₂ % VOL DRY	NO _x PPMV,D	CO PPMV,D	SO ₂ PPMV,D
INITIAL ZERO BIAS	0.00	0.14	0.30	0.80	---
INITIAL SPAN BIAS	12.61	8.10	41.80	862.90	---
FINAL ZERO BIAS	0.01	0.21	0.80	1.20	---
FINAL SPAN BIAS	12.45	8.33	42.40	854.10	---
AVERAGE ZERO BIAS	0.01	0.18	0.55	1.00	---
AVERAGE SPAN BIAS	12.53	8.22	42.10	858.50	---
BIAS GAS CONCENTRATION	12.50	8.23	42.60	858.00	---
FULL SCALE RANGE	25.00	20.00	100.00	2000.00	---
UNCORRECTED CONC.	12.06	7.29	42.28	552.63	---
CORRECTED CONC.	12.03	7.29	42.79	551.95	---
PPMV @ 15 % O2			28.47	367.25	---
LB/HR BASED ON PITOT FLOW (DSCFM)	7,733		2.41	18.92	---

OCSD PLANT 2 ENGINE 4 COMPLIANCE (NORM LOAD)**December 18, 2014****RAW DAS DATA - RM RUN 1**

DATA PT	DATE	TIME	O2 % VD	CO2 % VD	NOx PPMVD	CO PPMVD
1	12/18	13:04:19	12.28	7.08	39.3	563.5
2	12/18	13:05:19	12.31	7.06	40.2	567.1
3	12/18	13:06:19	12.30	7.08	40.1	571.9
4	12/18	13:07:19	12.28	7.10	41.5	562.7
5	12/18	13:08:19	12.28	7.10	41.8	560.7
6	12/18	13:09:19	12.35	7.07	41.5	567.5
7	12/18	13:10:19	12.33	7.08	40.3	576.8
8	12/18	13:11:19	12.33	7.09	39.9	574.8
9	12/18	13:12:19	12.32	7.10	41.0	572.7
10	12/18	13:13:19	12.28	7.14	44.3	563.5
11	12/18	13:14:19	12.28	7.14	47.0	558.7
12	12/18	13:15:19	12.29	7.12	45.6	565.5
13	12/18	13:16:19	12.26	7.15	44.4	567.5
14	12/18	13:17:19	12.27	7.14	44.9	569.5
15	12/18	13:18:19	12.22	7.18	43.9	568.7
16	12/18	13:19:19	12.25	7.16	44.8	560.7
17	12/18	13:20:19	12.27	7.14	44.2	565.5
18	12/18	13:21:19	12.28	7.14	44.0	565.9
19	12/18	13:22:19	12.28	7.14	42.9	571.1
20	12/18	13:23:19	12.27	7.14	43.2	568.7
21	12/18	13:24:19	12.29	7.13	43.7	570.7
22	12/18	13:25:19	12.29	7.14	44.6	571.5
23	12/18	13:26:19	12.39	7.10	42.6	584.0
24	12/18	13:27:19	12.38	7.08	41.9	584.0
25	12/18	13:28:19	12.42	7.05	41.8	583.2
26	12/18	13:29:19	12.41	7.04	40.6	595.2
27	12/18	13:30:19	12.38	7.08	41.7	582.8
28	12/18	13:31:19	12.39	7.08	40.9	585.2
29	12/18	13:32:19	12.42	7.06	40.2	593.2
30	12/18	13:33:19	12.42	7.04	40.4	596.4

31	12/18	13:34:19	12.41	7.03	39.9	600.8
32	12/18	13:35:19	12.34	7.09	40.7	586.8
33	12/18	13:36:19	12.31	7.10	42.6	572.3
34	12/18	13:37:19	12.33	7.09	42.6	572.3
35	12/18	13:38:19	12.32	7.10	43.0	569.9
36	12/18	13:39:19	12.31	7.10	42.0	576.8
37	12/18	13:40:19	12.32	7.10	42.6	571.9
38	12/18	13:41:19	12.34	7.09	41.9	576.0
39	12/18	13:42:19	12.31	7.12	43.1	573.6
40	12/18	13:43:19	12.32	7.10	42.7	574.8
41	12/18	13:44:19	12.34	7.09	42.2	577.2
42	12/18	13:45:19	12.37	7.08	43.2	569.9
43	12/18	13:46:19	12.35	7.08	43.3	570.7
44	12/18	13:47:19	12.37	7.08	42.3	578.8
45	12/18	13:48:19	12.41	7.05	42.8	577.6
46	12/18	13:49:19	12.34	7.09	44.0	572.3
47	12/18	13:50:19	12.30	7.12	45.3	554.3
48	12/18	13:51:19	12.28	7.14	45.6	553.9
49	12/18	13:52:19	12.30	7.12	45.0	554.7
50	12/18	13:53:19	12.31	7.12	43.2	572.7
51	12/18	13:54:19	12.27	7.16	43.2	569.5
52	12/18	13:55:19	12.32	7.12	44.4	561.9
53	12/18	13:56:19	12.35	7.10	43.9	568.7
54	12/18	13:57:19	12.35	7.08	43.0	572.3
55	12/18	13:58:19	12.35	7.09	42.8	574.8
56	12/18	13:59:19	12.34	7.10	42.0	573.6
57	12/18	14:00:19	12.31	7.12	42.3	574.0
58	12/18	14:01:19	12.33	7.10	42.7	571.5
59	12/18	14:02:19	12.32	7.11	43.4	572.3
60	12/18	14:03:19	12.31	7.12	42.6	576.8
61	12/18	14:04:19	12.34	7.10	42.0	574.8
AVERAGES			12.32	7.10	42.68	572.73

OCSD PLANT 2 ENGINE 4 COMPLIANCE (HIGH LOAD)**December 18, 2014****RAW DAS DATA - RM RUN 2**

DATA PT	DATE	TIME	O2 % VD	CO2 % VD	NOx PPMVD	CO PPMVD
1	12/18	15:28:19	12.25	7.16	45.9	551.1
2	12/18	15:29:19	12.33	7.09	45.1	564.3
3	12/18	15:30:19	12.38	7.05	44.0	573.6
4	12/18	15:31:19	12.41	7.03	42.8	581.6
5	12/18	15:32:19	12.42	7.02	42.2	580.8
6	12/18	15:33:19	12.39	7.03	42.4	583.2
7	12/18	15:34:19	12.42	7.02	43.4	578.4
8	12/18	15:35:19	12.42	7.01	42.6	582.0
9	12/18	15:36:19	12.44	7.00	42.6	590.0
10	12/18	15:37:19	12.46	6.98	43.9	583.2
11	12/18	15:38:19	12.39	7.04	42.5	591.2
12	12/18	15:39:19	12.41	7.02	48.1	555.9
13	12/18	15:40:19	12.63	6.84	49.6	570.3
14	12/18	15:41:19	12.62	6.86	44.0	602.8
15	12/18	15:42:19	12.63	6.84	43.2	608.9
16	12/18	15:43:19	12.62	6.86	42.7	610.1
AVERAGES			12.45	6.99	44.06	581.71

OCS D PLANT 2 ENGINE 4 COMPLIANCE (LOW LOAD)
December 18, 2014
RAW DAS DATA - RM RUN 3

DATA PT	DATE	TIME	O2 % VD	CO2 % VD	NOx PPMVD	CO PPMVD
1	12/18	14:57:19	12.12	7.19	41.0	558.3
2	12/18	14:58:19	12.13	7.21	41.1	557.1
3	12/18	14:59:19	12.09	7.25	40.2	559.9
4	12/18	15:00:19	12.08	7.26	40.9	559.9
5	12/18	15:01:19	12.00	7.35	41.9	553.1
6	12/18	15:02:19	12.03	7.32	42.7	547.5
7	12/18	15:03:19	12.02	7.33	43.0	546.7
8	12/18	15:04:19	12.09	7.28	42.8	549.9
9	12/18	15:05:19	12.07	7.29	42.5	555.9
10	12/18	15:06:19	12.08	7.29	43.0	551.1
11	12/18	15:07:19	12.10	7.28	41.9	558.7
12	12/18	15:08:19	12.08	7.30	42.2	552.7
13	12/18	15:09:19	12.03	7.33	42.9	550.3
14	12/18	15:10:19	12.01	7.34	42.9	551.1
15	12/18	15:11:19	12.01	7.36	44.1	544.3
16	12/18	15:12:19	12.05	7.32	43.4	545.5
AVERAGES			12.06	7.29	42.28	552.63

DAQ32 Historical Viewer R10.02.01

Software ID

Start Time 2014/12/18

11:31:37.5

End Time 2014/12/18

12:10:37.5

Sample Rate 60.0 Sec

Data Count 40

Group

01

-

01

Date	Time	Ch. msec	CH001 % O2	CH002 % CO2	CH003 ppmNOx	CH004 ppm CO
------	------	-------------	---------------	----------------	-----------------	-----------------

12/18	11:31:37	0.5	0.01	0.29	0.01	7.6
12/18	11:32:37	0.5	0.00	0.25	0.01	7.6 ZERO
12/18	11:33:37	0.5	0.00	0.24	-0.01	7.6
12/18	11:34:37	0.5	0.00	0.23	-0.01	7.6
12/18	11:35:37	0.5	0.00	0.22	-0.01	7.6
12/18	11:36:37	0.5	0.00	0.21	-0.01	7.6
12/18	11:37:37	0.5	0.00	0.21	-0.01	7.6
12/18	11:38:37	0.5	17.34	16.60	16.64	1670.8
12/18	11:39:37	0.5	17.27	16.59	18.36	1776.4
12/18	11:40:37	0.5	17.27	16.57	18.34	1776.4 SPAN
12/18	11:41:37	0.5	17.28	16.54	18.26	997.6
12/18	11:42:37	0.5	17.28	16.52	8.52	864.4
12/18	11:43:37	0.5	17.29	16.49	8.46	861.6
12/18	11:44:37	0.5	17.29	16.46	8.44	861.6 MID
12/18	11:45:37	0.5	17.31	16.42	8.46	863.6
12/18	11:46:37	0.5	17.32	16.38	15.86	22.4
12/18	11:47:37	0.5	17.34	16.35	16.22	7.6
12/18	11:48:37	0.5	17.36	16.30	16.28	7.6
12/18	11:49:37	0.5	17.37	16.27	16.34	7.6 NOX RESPONSE TO NO2 GAS
12/18	11:50:37	0.5	20.65	0.46	9.34	23.6
12/18	11:51:37	0.5	20.64	0.45	0.21	7.6
12/18	11:52:37	0.5	20.65	0.45	0.07	7.6
12/18	11:53:37	0.5	20.64	0.45	0.05	7.6
12/18	11:54:37	0.5	20.65	0.45	0.03	7.6
12/18	11:55:37	0.5	20.65	0.45	0.03	7.6
12/18	11:56:37	0.5	20.64	0.45	0.01	7.6
12/18	11:57:37	0.5	20.64	0.45	0.01	7.6 NO RESPONSE TO NO2 GAS
12/18	11:58:37	0.5	20.64	0.44	0.01	7.6
12/18	11:59:37	0.5	20.65	0.44	0.01	7.6
12/18	12:00:37	0.5	20.65	0.44	0.01	7.6
12/18	12:01:37	0.5	20.64	0.44	0.01	7.6
12/18	12:02:37	0.5	20.64	0.44	0.01	7.6
12/18	12:03:37	0.5	20.64	0.44	0.01	7.6
12/18	12:04:37	0.5	20.64	0.44	-0.01	7.6
12/18	12:05:37	0.5	20.64	0.44	-0.01	7.6
12/18	12:06:37	0.5	20.63	0.44	-0.01	7.6
12/18	12:07:37	0.5	20.64	0.44	-0.01	7.6
12/18	12:08:37	0.5	20.65	0.42	-0.01	7.6
12/18	12:09:37	0.5	20.66	0.42	-0.01	7.6
12/18	12:10:37	0.5	20.66	0.41	-0.01	7.6

DAQ32 Historical Viewer R10.02.01

Software ID

Start Time 2014/12/18

12:28:19.5

End Time 2014/12/18 19:12:19.5
Sample Rate 60.0 Sec
Data Count 405
Group 01 - 01

Date	Time	Ch. msec	CH001 % O2	CH002 % CO2	CH003 ppmNOx	CH004 ppm CO	
12/18	12:28:19	0.5	0.00	0.00	0.0	0.8	
12/18	12:29:19	0.5	0.00	0.00	0.0	0.8	ZERO
12/18	12:30:19	0.5	20.92	17.01	16.6	1025.1	
12/18	12:31:19	0.5	20.93	16.56	86.4	1766.8	
12/18	12:32:19	0.5	20.93	16.55	86.6	1756.0	
12/18	12:33:19	0.5	12.52	8.34	86.7	1794.9	SPAN
12/18	12:34:19	0.5	12.45	8.33	64.1	879.0	
12/18	12:35:19	0.5	12.44	8.32	42.9	863.7	MID
12/18	12:36:19	0.5	12.45	8.32	42.8	864.1	
12/18	12:37:19	0.5	3.79	0.52	27.3	407.8	
12/18	12:38:19	0.5	12.42	8.10	1.5	2.0	
12/18	12:39:19	0.5	12.65	8.03	0.1	0.8	
12/18	12:40:19	0.5	12.51	8.18	0.1	0.4	
12/18	12:41:19	0.5	12.37	8.29	0.0	0.8	O2/CO2 BIAS
12/18	12:42:19	0.5	12.37	8.32	0.0	0.8	
12/18	12:43:19	0.5	3.25	2.43	0.0	2.0	
12/18	12:44:19	0.5	0.04	0.30	0.0	842.1	
12/18	12:45:19	0.5	0.02	0.25	0.0	856.5	CO BIAS
12/18	12:46:19	0.5	0.03	0.24	0.0	855.3	
12/18	12:47:19	0.5	0.01	0.20	0.0	804.7	
12/18	12:48:19	0.5	0.01	0.19	41.2	2.8	
12/18	12:49:19	0.5	0.01	0.18	41.9	1.2	NOX BIAS
12/18	12:50:19	0.5	0.01	0.17	41.9	0.8	
12/18	12:51:19	0.5	20.60	0.23	40.1	0.8	
12/18	12:52:19	0.5	20.67	0.23	0.3	0.8	
12/18	12:53:19	0.5	12.80	6.03	1.3	121.2	
12/18	12:54:19	0.5	13.07	6.26	30.0	508.1	
12/18	12:55:19	0.5	12.93	6.23	32.7	514.1	
12/18	12:56:19	0.5	13.18	6.33	33.4	499.3	
12/18	12:57:19	0.5	20.58	0.22	32.1	267.3	
12/18	12:58:19	0.5	20.59	0.20	0.1	0.8	
12/18	12:59:19	0.5	20.61	0.19	0.0	0.4	
12/18	13:00:19	0.5	20.63	0.19	0.0	0.8	
12/18	13:01:19	0.5	20.62	0.18	0.0	0.8	
12/18	13:02:19	0.5	20.52	0.22	0.0	0.8	
12/18	13:03:19	0.5	12.32	7.02	18.3	447.9	
12/18	13:04:19	0.5	12.28	7.08	39.3	563.5	START NORMAL LOAD P2E4
12/18	13:05:19	0.5	12.31	7.06	40.2	567.1	
12/18	13:06:19	0.5	12.30	7.08	40.1	571.9	
12/18	13:07:19	0.5	12.28	7.10	41.5	562.7	
12/18	13:08:19	0.5	12.28	7.10	41.8	560.7	
12/18	13:09:19	0.5	12.35	7.07	41.5	567.5	
12/18	13:10:19	0.5	12.33	7.08	40.3	576.8	
12/18	13:11:19	0.5	12.33	7.09	39.9	574.8	
12/18	13:12:19	0.5	12.32	7.10	41.0	572.7	
12/18	13:13:19	0.5	12.28	7.14	44.3	563.5	
12/18	13:14:19	0.5	12.28	7.14	47.0	558.7	
12/18	13:15:19	0.5	12.29	7.12	45.6	565.5	
12/18	13:16:19	0.5	12.26	7.15	44.4	567.5	

12/18	13:17:19	0.5	12.27	7.14	44.9	569.5
12/18	13:18:19	0.5	12.22	7.18	43.9	568.7
12/18	13:19:19	0.5	12.25	7.16	44.8	560.7
12/18	13:20:19	0.5	12.27	7.14	44.2	565.5
12/18	13:21:19	0.5	12.28	7.14	44.0	565.9
12/18	13:22:19	0.5	12.28	7.14	42.9	571.1
12/18	13:23:19	0.5	12.27	7.14	43.2	568.7
12/18	13:24:19	0.5	12.29	7.13	43.7	570.7
12/18	13:25:19	0.5	12.29	7.14	44.6	571.5
12/18	13:26:19	0.5	12.39	7.10	42.6	584.0
12/18	13:27:19	0.5	12.38	7.08	41.9	584.0
12/18	13:28:19	0.5	12.42	7.05	41.8	583.2
12/18	13:29:19	0.5	12.41	7.04	40.6	595.2
12/18	13:30:19	0.5	12.38	7.08	41.7	582.8
12/18	13:31:19	0.5	12.39	7.08	40.9	585.2
12/18	13:32:19	0.5	12.42	7.06	40.2	593.2
12/18	13:33:19	0.5	12.42	7.04	40.4	596.4
12/18	13:34:19	0.5	12.41	7.03	39.9	600.8
12/18	13:35:19	0.5	12.34	7.09	40.7	586.8
12/18	13:36:19	0.5	12.31	7.10	42.6	572.3
12/18	13:37:19	0.5	12.33	7.09	42.6	572.3
12/18	13:38:19	0.5	12.32	7.10	43.0	569.9
12/18	13:39:19	0.5	12.31	7.10	42.0	576.8
12/18	13:40:19	0.5	12.32	7.10	42.6	571.9
12/18	13:41:19	0.5	12.34	7.09	41.9	576.0
12/18	13:42:19	0.5	12.31	7.12	43.1	573.6
12/18	13:43:19	0.5	12.32	7.10	42.7	574.8
12/18	13:44:19	0.5	12.34	7.09	42.2	577.2
12/18	13:45:19	0.5	12.37	7.08	43.2	569.9
12/18	13:46:19	0.5	12.35	7.08	43.3	570.7
12/18	13:47:19	0.5	12.37	7.08	42.3	578.8
12/18	13:48:19	0.5	12.41	7.05	42.8	577.6
12/18	13:49:19	0.5	12.34	7.09	44.0	572.3
12/18	13:50:19	0.5	12.30	7.12	45.3	554.3
12/18	13:51:19	0.5	12.28	7.14	45.6	553.9
12/18	13:52:19	0.5	12.30	7.12	45.0	554.7
12/18	13:53:19	0.5	12.31	7.12	43.2	572.7
12/18	13:54:19	0.5	12.27	7.16	43.2	569.5
12/18	13:55:19	0.5	12.32	7.12	44.4	561.9
12/18	13:56:19	0.5	12.35	7.10	43.9	568.7
12/18	13:57:19	0.5	12.35	7.08	43.0	572.3
12/18	13:58:19	0.5	12.35	7.09	42.8	574.8
12/18	13:59:19	0.5	12.34	7.10	42.0	573.6
12/18	14:00:19	0.5	12.31	7.12	42.3	574.0
12/18	14:01:19	0.5	12.33	7.10	42.7	571.5
12/18	14:02:19	0.5	12.32	7.11	43.4	572.3
12/18	14:03:19	0.5	12.31	7.12	42.6	576.8
12/18	14:04:19	0.5	12.34	7.10	42.0	574.8
12/18	14:05:19	0.5	12.34	7.10	42.0	575.6
12/18	14:06:19	0.5	12.56	7.99	40.7	296.6
12/18	14:07:19	0.5	12.61	8.10	2.7	1.2 O2/CO2 BIAS
12/18	14:08:19	0.5	12.63	8.13	2.0	0.8
12/18	14:09:19	0.5	10.08	6.55	1.7	2.8
12/18	14:10:19	0.5	0.73	0.35	1.4	799.9
12/18	14:11:19	0.5	0.70	0.28	1.1	828.4