

DOCKETED

Docket Number:	05-AFC-02C
Project Title:	The Walnut Creek Energy Park
TN #:	225983
Document Title:	Energy Commission Staff's Suggested Erratum for Staff Analysis for Proposed Revisions to Conditions of Certification
Description:	Energy Commission Staff's Suggested Erratum for Staff Analysis for Proposed Revisions to Conditions of Certification, Including Air Quality and Worker Safety
Filer:	Raquel Rodriguez
Organization:	California Energy Commission
Submitter Role:	Commission Staff
Submission Date:	11/29/2018 3:18:37 PM
Docketed Date:	11/29/2018



**Before the Energy Resources Conservation and Development
Commission of the State of California**

1516 Ninth Street, Sacramento, CA 95814
1-800-822-6228 – www.energy.ca.gov

*PETITION TO AMEND FOR:
WALNUT CREEK ENERGY PARK*

Docket No. 05-AFC-2C

**ENERGY COMMISSION STAFF’S SUGGESTED ERRATUM FOR STAFF ANALYSIS
FOR PROPOSED REVISIONS TO CONDITIONS OF CERTIFICATION, INCLUDING
AIR QUALITY AND WORKER SAFETY**

Staff recommends a minor correction to Condition of Certification **AQ-8** in the Air Quality section of the Staff Analysis of Proposed Revisions to Conditions of Certification, including Air Quality and Worker Safety for the Walnut Creek Energy Park. Staff recommends changing the timing for submittal of the source test results to “no later than 45 days after the source test was conducted,” instead of the 60 days originally provided. This change aligns the timing in the condition of certification with the timing provided in the verification section. This change does not affect any of staff’s conclusions regarding the air quality impacts and LORS compliance.

The change also makes the timing consistent with other conditions in the decision. While the South Coast Air Quality Management District (SCAQMD) Title V permit dated July 27, 2018, still has “60 days after the source test” for this condition, the district intends to incorporate this change in their next Title V permit update.

The recommended change is:

AQ-8 The project owner shall provide to the District a source test report in accordance with the following specifications:

Source test results shall be submitted to the District and the CPM no later than ~~60~~45 days after the source test was conducted.

Emission data shall be expressed in terms of concentration (PPMV) corrected to 15 percent oxygen (dry basis), mass rate (lbs/hr), and lbs/MM Cubic Feet. In addition, solid PM emissions, if required to be tested, shall also be reported in terms of grains per DSCF.

All exhaust flow rate shall be expressed in terms of dry standard cubic feet per minute (DSCFM) and dry actual cubic feet per minute (DACFM).

All moisture concentrations shall be expressed in terms of percent corrected to 15 percent oxygen.

Source test results shall also include the oxygen levels in the exhaust, fuel flow rate (CFH), the flue gas temperature, and the generator power output (MW) under which the test was conducted.

Verification: The project owner shall submit source test results no later than 45 days following the source test date to both the District and CPM.