| DOCKETED         |                                       |
|------------------|---------------------------------------|
| Docket Number:   | 01-AFC-25C                            |
| Project Title:   | Malburg Generating Station-Compliance |
| TN #:            | 226448                                |
| Document Title:  | Annual Compliance Report 2018         |
| Description:     | N/A                                   |
| Filer:           | Anwar Ali                             |
| Organization:    | Bicent (California) Malburg LLC       |
| Submitter Role:  | Applicant                             |
| Submission Date: | 2/4/2019 12:44:57 PM                  |
| Docketed Date:   | 2/4/2019                              |





4963 Soto Street Vernon, CA 90058 Telephone: (323) 476-3610

Fax: (323) 476-3640

30 January 2019

Mr. Anwar Ali Compliance Project Manager California Energy Commission Energy Facilities Siting Division 1516 9th Street, MS 2000 Sacramento, CA 95814-5512

Subject: Malburg Generating Station

2018 Q4 and Annual Compliance Report

Dear Mr. Anwar:

On behalf of the owner of the Malburg Generating Station, Bicent (California) Malburg LLC, Colorado Energy has compiled the attached Quarterly and Annual Compliance Report per the California Energy Commission Decision 01-AFC-25. A copy of the 2018 Hazardous Material Business Plan from CERS is also attached.

Please contact me at (303) 607-5590 or <a href="mailto:kmccormack@heorotpower.com">kmccormack@heorotpower.com</a> if you have any questions or need additional information.

Sincerely,

Kyle McCormack

Environmental Manager





4963 Soto Street Vernon, CA 90058 Telephone: (323) 476-3610

Fax: (323) 476-3640

# QUARTER 4 AND ANNUAL COMPLIANCE REPORT (October - December 2018)

### MALBURG GENERATING STATION 4963 SOTO STREET, VERNON, CA 90058

**SUBMITTED TO:** 

CALIFORNIA ENERGY COMMISSION 1516 9<sup>TH</sup> STREET, SACRAMENTO, CA 95814

January 2019

#### **TABLE OF CONTENTS**

|             | P   | age |
|-------------|---|-----|
| LIST OF FIG | SURES   | i   |
| LIST OF TAI | 3LES  | i   |
| ACRONYMS    | S AND ABBREVIATIONS                             | ii  |
| SECTION 1   | INTRODUCTION                                    | A   |
| 1.1         | Project Location and Description                | A   |
| 1.2         | Organization of the Quarterly Compliance Report |     |
| 1.3         | Satisfied Conditions of Certification           |     |
| SECTION 2   | QUARTERLY COMPLIANCE DETAILS                    | 1   |
| 2.1         | Condition of Certification AQ-C6                | 1   |
| 2.2         | Condition of Certification AQ-C7                | 1   |
| 2.3         | Condition of Certification AQ-C8                | 1   |
| 2.4         | Condition of Certification AQ-C9                | 2   |
| 2.5         | Condition of Certification AQ-C10               | 2   |
| 2.6         | Condition of Certification AQ-C11               | 2   |
| 2.7         | Condition of Certification AQ-2                 | 3   |
| 2.8         | Condition of Certification AQ-3                 | 3   |
| 2.9         | Condition of Certification AQ-5                 | 3   |
| 2.10        | Conditions of Certification AQ-6 and AQ-7       | 4   |
| 2.11        | Condition of Certification AQ-8                 | 4   |
| 2.12        | Condition of Certification AQ-9                 | 4   |
| 2.13        | Condition of Certification AQ-10                | 5   |
| 2.14        | Condition of Certification AQ-11                | 5   |
| 2.15        | Condition of Certification AQ-12                | 5   |
| 2.16        | Condition of Certification AQ-13                | 6   |
| 2.17        | Condition of Certification AQ-14                | 6   |
| 2.18        | Condition of Certification AQ-15                | 6   |
| 2.19        | Condition of Certification AQ-27                | 7   |

| SECTIO | )N 3 | ANNUAL COMPLIANCE D          | ETAILS  | . 8 |
|--------|------|------------------------------|---------|-----|
| 3      | 3.1  |                              | COM-2   |     |
| 3      | 3.2  | Condition of Certification ( | COM-3   | . 8 |
| 3      | 3.3  | Condition of Certification ( | COM-4   | . 8 |
| 3      | 3.4  | Condition of Certification ( | COM-6   | . 8 |
| 3      | 3.5  | Condition of Certification ( | COM-8   | . 9 |
| 3      | 3.6  |                              | COM-12  |     |
| 3      | 3.7  | Condition of Certification ( | COM-13  | 11  |
| 3      | 8.8  | Condition of Certification ( | COM-14  | 11  |
| 3      | 3.9  | Condition of Certification ( | COM-15  | 11  |
| 3      | 3.10 |                              | COM-16  |     |
| 3      | 3.11 | Condition of Certification A | AQ-C5   | 12  |
| 3      | 3.12 | Condition of Certification A | AQ-C13  | 12  |
| 3      | 3.13 | Condition of Certification A | AQ-1    | 13  |
| 3      | 3.14 | Condition of Certification A | AQ-4    | 13  |
| 3      | 3.15 | Condition of Certification A | AQ-16   | 13  |
| 3      | 3.16 | Condition of Certification A | AQ-17   | 14  |
| 3      | 3.17 | Condition of Certification A | AQ-18   | 14  |
| 3      | 3.18 | Condition of Certification A | AQ-19   | 14  |
| 3      | 3.19 | Condition of Certification A | AQ-20   | 14  |
| 3      | 3.20 | Condition of Certification A | AQ-21   | 15  |
| 3      | 3.21 | Condition of Certification A | AQ-22   | 15  |
| 3      | 3.22 | Condition of Certification A | AQ-23   | 16  |
| 3      | 3.23 | Condition of Certification A | AQ-24   | 16  |
| 3      | 3.24 | Condition of Certification A | AQ-25   | 17  |
| 3      | 3.25 | Condition of Certification A | 4Q-26   | 17  |
| 3      | 3.26 | Condition of Certification A | 4Q-28   | 17  |
| 3      | 3.27 | Condition of Certification A | 4Q-29   | 17  |
| 3      | 3.28 | Condition of Certification A | AQ-30   | 18  |
| 3      | 3.29 | Condition of Certification A | AQ-31   | 18  |
| 3      | 3.30 | Condition of Certification A | AQ-32   | 18  |
| 3      | 3.31 | Condition of Certification A | AQ-33   | 19  |
| 3      | 3.32 | Condition of Certification A | AQ-34   | 19  |
| 3      | 3.33 | Condition of Certification A | AQ-35   | 19  |
| 3      | 3.34 | Condition of Certification H | HAZ-6   | 20  |
| 3      | 3.35 | Condition of Certification H | HAZ-7   | 20  |
| 3      | 3.36 | Condition of Certification V | WASTE-3 | 20  |
| 3      | 3.37 | Condition of Certification V | WASTE-4 | 21  |

| 3.38 | Condition of Certification SOIL & WATER | 21 |
|------|---|----|
| 3.39 | Condition of Certification SOIL & WATER | 22 |
| 3.40 | Condition of Certification CUL-8        | 22 |
| 3.41 | Condition of Certification TRANS-8      | 22 |
| 3.42 | Condition of Certification VIS-1        | 23 |
| 3.43 | Condition of Certification VIS-2        | 23 |
| 3.44 | Condition of Certification VIS-3        | 24 |
| 3.55 | Condition of Certification NOISE-2      | 24 |

#### **LIST OF FIGURES**

- 2-1 Chevron GST Oil Specifications
- 2-2 Cooling Tower PM10 Guidance

2-19 POTABLE WATER USAGE2-20 RECLAIMED WATER USAGE

#### **LIST OF TABLES**

| 2-1  | COOLING TOWER TDS SAMPLING RESULTS                         |
|------|--|
| 2-2  | COOLING TOWER DAILY PM10 EMISSIONS DURING OCTOBER          |
| 2-3  | COOLING TOWER DAILY PM10 EMISSIONS DURING NOVEMBER         |
| 2-4  | COOLING TOWER DAILY PM10 EMISSIONS DURING DECEMBER         |
| 2-5  | DIESEL FIRED EMERGENCY FIREWATER PUMP TESTING TIMES        |
| 2-6  | AQ-C10 EMISSION LIMITS, LBS/HR                             |
| 2-7  | AQ-C10 EMISSION LIMITS, LBS/DAY                            |
| 2-8  | MAXIMUM HOURLY EMISSIONS DURING THE QUARTER                |
| 2-9  | MAXIMUM DAILY EMISSIONS DURING THE QUARTER                 |
| 2-10 | TOTAL ANNUAL EMISSIONS                                     |
| 2-11 | TOTAL MONTHLY EMISSIONS DURING OCTOBER                     |
| 2-12 | TOTAL MONTHLY EMISSIONS DURING NOVEMBER                    |
| 2-13 | TOTAL MONTHLY EMISSIONS DURING DECEMBER                    |
| 2-14 | [LEFT BLANK INTENTIONALLY]                                 |
| 2-15 | COMBUSTION TURBINES STARTUP AND SHUTDOWN EVENTS DURING THE |
|      | QUARTER  |
| 2-16 | COMBUSTION TURBINES AND DUCT BURNERS GAS USAGE DURING THE  |
|      | QUARTER  |
| 2-17 | DIESEL FIREWATER PUMP OPERATIONS SUMMARY                   |
| 2-18 | YEARLY WATER USAGE TOTALS                                  |

#### LIST OF APPENDICES

APPENDIX A: COOLING TOWER BLOW DOWN REPORTS

APPENDIX B: EXCESS EMISSIONS REPORTS
APPENDIX C: POTABLE WATER USAGE LOGS
APPENDIX D: [LEFT BLANK INTENTIONALLY]
APPENDIX E: [LEFT BLANK INTENTIONALLY]
APPENDIX F: [LEFT BLANK INTENTIONALLY]

APPENDIX G: MGS RECLAIM ANNUAL EMISSION ALLOCATION INFORMATION

APPENDIX H: [LEFT BLANK INTENTIONALLY]

APPENDIX I: MGS CEC - COMMISSION DECISION COMPLIANCE MATRIX

APPENDIX J: NH3 FLOW METER CALIBRATION REPORT

APPENDIX K: SCR TEMPERATURE GAUGE CALIBRATION REPORT APPENDIX L: SCR PRESSURE GAUGE CALIBRATION REPORT

APPENDIX M: STATION "A" MAINTENANCE REPORT

APPENDIX N: NOISE COMPLAINT LOG AND RESOLUTION RECORDS

# SECTION 1 INTRODUCTION

This Annual and Fourth Quarterly Compliance Report has been prepared to meet the California Energy Commission (CEC) requirements for the Malburg Generating Station (MGS). This report fulfills various Conditions of Certifications as described in the California Energy Commission's Decision #01-AFC-25, May 2003.

#### 1.1 PROJECT LOCATION AND DESCRIPTION

The Malburg Generating Station is located at 4963 Soto Street on approximately 3.4 acres, in an industrial land use area. MGS is located near the geographic center of metropolitan Los Angeles County. MGS consists of two Alstom GTX-100 frame type natural gas combustion turbine generators (CTGs); two heat recovery steam generators (HRSG); a steam turbine-generator (STG); a cooling tower, a diesel fuel fired emergency firewater pump and support equipment.

The commissioning of MGS was completed in October 2005 and the power plant began Commercial Operation on October 17, 2005.

#### 1.2 ORGANIZATION OF THE QUARTERLY COMPLIANCE REPORT

A summary of each quarterly condition of certification and required means of verification which has not been completely satisfied is provided in Section 2. A summary of each annual condition of certification and required means of verification which has not been completely satisfied is provided in Section 3. Each sub-section also contains a description of the method used by MGS to demonstrate compliance with the verification requirements and references to Appendices, Figures and Tables as appropriate.

#### 1.3 SATISFIED CONDITIONS OF CERTIFICATION

Several Conditions of Certification have been completely satisfied during the construction and startup phases of the project. These conditions were the subject of a communication between MGS and CEC on 30 March 2011 and also a subsequent meeting on 15 April 2011. At this meeting, MGS and CEC staff reached agreement that the following Conditions of Certification have been completely satisfied and, therefore, are not addressed in any report to the CPM:

COM-1, COM-5, COM-7, COM-9, COM-10, COM-11, GEN-1, GEN-2, GEN-3, GEN-4, GEN-5, GEN-6, GEN-7, GEN-8, CIVIL-1, CIVIL-2, CIVIL-3, CIVIL-4, STRUC-1, STRUC-2, STRUC-3, STRUC-4, MECH-1, MECH-2, MECH-3, ELEC-1, TSE-1, TSE-2, TSE-3, TSE-4, TSE-5, TSE-6, TSE-7, TSE-8, TLSN-1, AQ-C1, AQ-C2, AQ-C3, AQ-C4, AQC12, AQ-C14, AQ-36, PUBLIC HEALTH-1, WORKER SAFETY-1, WORKER SAFETY-2, HAZ-2, HAZ-3, HAZ-4, HAZ-5, HAZ-8, WASTE-1, WASTE-2, SOILS & WATER-1, SOILS & WATER-7, CUL-1, CUL-2, CUL-3, CUL-4, CUL-5, CUL-6, CUL-7, PAL-1, PAL-2, PAL-3, PAL-4, PAL-5, PAL-6, PAL-7, LAND-1, LAND-2, TRANS-1, TRANS-2, TRANS-3, TRANS-4, TRANS-5, TRANS-6, TRANS-7, TRANS-9, VIS-4, NOISE-1, NOISE-3, NOISE-4, NOISE-5, NOISE-6, NOISE-7, and NOISE-8.

# SECTION 2 COMPLIANCE DETAILS

The compliance details for various conditions of certification are provided below.

#### 2.1 CONDITION OF CERTIFICATION AQ-C6

As per the Condition of Certification Number AQ-C6, MGS shall determine the Total Dissolved Solids (TDS) levels in the blowdown water by independent laboratory testing prior to initial operation and periodically thereafter.

For verification of the above condition of certification, the CEC requires MGS to submit weekly TDS reports for the blowdown water as part of the quarterly emission report to the Compliance Project Manager (CPM) for approval.

As demonstration of compliance, the weekly TDS results are provided in Table 2-1, and the weekly sample reports during operation are provided in Appendix A.

#### 2.2 CONDITION OF CERTIFICATION AQ-C7

As per the Condition of Certification Number AQ-C7, particulate matter of diameter less than 10 microns (PM<sub>10</sub>) emissions from the cooling tower shall not exceed 6.2 lb/day.

Compliance with the PM<sub>10</sub> daily emission limit shall be demonstrated as follows:

 $PM_{10} Ib/day = A*B*C*D$ 

Where:

A = circulating water recirculation rate

B = total dissolved solids concentration in the blowdown water to be updated on a weekly basis

C = design drift rate

D = correction factor

For verification of the above condition of certification, the CEC requires MGS to calculate the daily PM<sub>10</sub> emissions from the cooling tower and submit all calculations and results on a quarterly basis in the quarterly emissions reports to the CPM for approval.

As demonstration of compliance, the daily PM<sub>10</sub> emissions from the cooling tower are provided in Tables 2-2 through 2-4.

#### 2.3 CONDITION OF CERTIFICATION AQ-C8

As per the Condition of certification Number AQ-C8, MGS shall refrain from testing the firewater pump on the same day as either gas fire combustion turbines have been started up or shutdown.

For verification of the above condition of certification, the CEC requires MGS to submit to the CPM for approval all testing times and results of the diesel fired emergency firewater pump in the quarterly emissions report.

As demonstration of compliance, the testing times for the diesel fired emergency firewater pump are provided in Table 2-5. MGS refrained from testing the diesel fired

emergency firewater pump on the same day the combustion turbines were either started or shutdown.

#### 2.4 CONDITION OF CERTIFICATION AQ-C9

As per the Condition of certification Number AQ-C9, MGS shall use the provided definitions to determine compliance with startup, shutdown and any related emission or operational limitations.

For verification of the above condition of certification, the CEC requires MGS to submit to the CPM for approval, a record of all startups and shutdowns including duration and date of occurrence on a quarterly basis as part of the quarterly emission report.

As demonstration of compliance, the startup and shutdown details as defined by the decision modifications issued in March, 2014 are provided in Table 2-14.

#### 2.5 CONDITION OF CERTIFICATION AQ-C10

As per the condition of certification number AQ-C10, MGS shall operate within the emission limits provided in Tables 2-6 and 2-7.

For verification of the above condition of certification, the CEC requires MGS to submit to the CPM for approval on a quarterly basis all emission records and calculations to demonstrate compliance with the emission limits stated herein as part of the quarterly emissions report.

As demonstration of compliance, the maximum hourly and daily emissions of CO,  $NO_X$ ,  $PM_{10}$ , VOC, and  $SO_X$  are provided in Tables 2-8 and 2-9. CO and NOx emissions data, provided in Tables 2-8 and 2-9, do not include substituted data. The substitution procedure is followed for reporting emissions to the South Coast Air Quality Management District (SCAQMD) or Environmental Protection Agency when there may be a problem with the Continuous Emission Monitoring System (CEMS). Also, the turbine emissions estimates for  $PM_{10}$ ,  $SO_X$ , and  $VOC_S$  are calculated using the original manufacturer's emission factors and do not represent actual emissions.

#### 2.6 CONDITION OF CERTIFICATION AQ-C11

As per the Condition of Certification Number AQ-C11, MGS shall submit a quarterly emissions report on a quarterly basis to the CPM for approval. The quarterly emissions report shall generally report all ammonia,  $NO_X$ ,  $SO_X$ , CO,  $PM_{10}$  and VOC emissions from the MGS as necessary to demonstrate compliance with all emission limits. The fourth quarter emission report shall include an annual summary of all emissions of ammonia,  $NO_X$ ,  $SO_X$ , CO,  $PM_{10}$  and VOC as necessary to demonstrate compliance with all annual emission limits.

For verification of the above condition of certification, the CEC requires MGS to submit the quarterly emissions report no less than 30 days after the end of each calendar quarter.

As demonstration of compliance, the maximum hourly and daily emissions of ammonia,  $NO_X$ ,  $SO_X$ , CO,  $PM_{10}$  and VOC are provided in Tables 2-8 and 2-9. Total Annual Emissions for these pollutants are provided in Table 2-10.

#### 2.7 CONDITION OF CERTIFICATION AQ-2

As per the Condition of Certification Number AQ-2, MGS shall not use diesel oil containing sulfur compounds in excess of 15 ppm by weight as supplied by the supplier.

For verification of the above condition of certification, the CEC requires MGS to submit fuel purchase records for approval to the CPM on a quarterly basis in the quarterly emissions report.

Diesel Fuel was purchased in October of this reporting period.

#### 2.8 CONDITION OF CERTIFICATION AQ-3

As per the Condition of Certification Number AQ-3, MGS shall keep records, in a manner approved by the District, for the following parameter(s) or item(s): Purchase records of fuel oil and sulfur content of the fuel.

For verification of the above condition of certification, the CEC requires MGS to submit fuel purchase records for approval to the CPM on a quarterly basis in the quarterly emissions report.

Diesel Fuel was purchased in October of this reporting period.

#### 2.9 CONDITION OF CERTIFICATION AQ-5

As per the condition of certification number AQ-5, MGS shall limit the emissions from both gas fired combustion turbine-heat recovery steam generator train exhaust stacks as follows:

#### Contaminant Emissions Limit

- CO 7,633 lbs in any one month
- PM<sub>10</sub> 4,876 lbs in any one month
- VOC 3,236 lbs in any one month
- SO<sub>x</sub> 214 lbs in any one month

For verification of the above condition of certification, the CEC requires the MGS to submit all emission calculations, fuel use and a summary demonstrating compliance of all emission limits stated in this condition for approval to the CPM on a quarterly basis in the guarterly emissions report.

As demonstration of compliance, the monthly emissions of CO, PM<sub>10</sub>, VOC, and SOx are presented in Tables 2-11 through 2-13. In addition, the fuel usage for the two turbineduct burner pairs is provided in Table 2-15. MGS calculates the emission limit(s) for CO based on readings from the certified CEMS. In the event the CO CEMS is not operating or the emissions exceed the valid upper range of the analyzer, the emissions are calculated in accordance with the approved CEMS Plan. MGS calculates the emission limit(s) by using the monthly fuel use data and the following emission factors:- PM<sub>10</sub>: 7.397 lb/mmscf, VOC: 1.63 lb/mmscf & SOx: 0.28lb/mmscf.

#### 2.10 CONDITION OF CERTIFICATION AQ-6 AND AQ-7

As per the condition of certification numbers AQ-6; following commissioning, start-ups shall not exceed 120 minutes during a cold start-up without a trip, and 150 minutes

during a cold start-up with a trip. Cold start-ups with or without a trip shall not exceed the following limits: NOx 122.8 lbs, CO 204.8 lbs and VOC 1.75 lbs.

Start-ups shall not exceed 90 minutes during a non-cold start-up without a trip or 120 minutes during a non-cold start-up with a trip. Non-cold start-ups shall not exceed the following limits: NOx 51.3 lbs, CO 59.9 lbs, and VOC 1.55 lbs.

Shut-downs shall not exceed 30 minutes. Shut-downs shall not exceed the following limits: NOx 4.5 lbs, CO 10.8 lbs, and VOC 0.71 lbs.

The number of startups shall not exceed two per day per turbine.

For verification of the above condition of certification, the CEC requires the MGS to submit a record of all startups and shutdowns including duration and date of occurrence on a quarterly basis as part of the quarterly emission report.

As demonstration of compliance, the startup and shutdown details are provided in Table 2-14. Additionally, quarterly excess emission reports from the DAHS are provided in Appendix B.

#### 2.11 CONDITION OF CERTIFICATION AQ-8

As per the Condition of Certification Number AQ-8, the 80.13 lb/mmscf NOx emission limit(s) shall only apply during interim period to report RECLAIM emissions. The interim period shall not exceed 12 months from the initial start-up date.

For verification of the above condition of certification, the CEC requires MGS to submit to the CPM for approval all emissions and emission calculations on a quarterly basis as part of the quarterly emissions report.

As demonstration of compliance, MGS advises that the lb/mmscf NOx emission limit(s) referenced in the above condition of certification applied only during the interim period which ended 12 months from the initial start-up date. There is no NOx lb/mmscf limit currently in place and therefore no supporting emission calculation is in place.

#### 2.12 CONDITION OF CERTIFICATION AQ-9

As per the Condition of Certification Number AQ-9, the 2 PPM oxides of nitrogen ( $NO_X$ ) emissions limit(s) are averaged over 1 hour at 15 percent oxygen, dry basis, during the normal operation of the MGS combustion turbine generators.

For verification of the above condition of certification, the CEC requires MGS to submit to the CPM for approval all emissions and emission calculations on a quarterly basis as part of the quarterly emissions report.

NO<sub>X</sub> emission for MGS Units 1 and 2 are measured using the CEMS. A review of CEMS NO<sub>X</sub> emission data indicated that the maximum corrected NO<sub>X</sub> emissions concentration for both MGS combustion turbines during normal operations was compliant with the emission concentration limit of 2 ppm. All CEMS data for MGS combustion turbines are stored electronically at MGS. As demonstration of compliance, excess emission reports from the DAHS are provided in Appendix B.

#### 2.13 CONDITION OF CERTIFICATION AQ-10

As per the Condition of Certification Number AQ-10 the 2 PPM carbon monoxide (CO) emissions limit(s) are averaged over 3 hour at 15 percent oxygen, dry basis, during the normal operation of the MGS combustion turbine generators.

For verification of the above condition of certification, the CEC requires MGS to submit to the CPM for approval all emissions and emission calculations on a quarterly basis as part of the quarterly emissions report.

CO emission for MGS Units 1 and 2 are measured using the CEMS. A review of CEMS CO emission data indicated that maximum CO emission concentration for both MGS combustion turbines was lower than the emission concentration limit of 2 ppm. All CEMS data for MGS combustion turbines are stored electronically at MGS. As demonstration of compliance, excess emission reports from the DAHS are provided in Appendix B.

#### 2.14 CONDITION OF CERTIFICATION AQ-11

As per the Condition of Certification Number AQ-11, the 2 ppm reactive organic gases (ROG) emission limit(s) are averaged over 1 hour at 15 percent oxygen, dry basis.

For verification of the above condition of certification, the CEC requires MGS to submit to the CPM for approval all emissions and emission calculations on a quarterly basis as part of the quarterly emissions report.

ROG emissions are not monitored on an hourly basis and compliance with 2 ppm limit is demonstrated by source testing. The last compliance source test, performed in March 2017, indicated compliance with the emission limits for CT1 and CT2.

#### 2.15 CONDITION OF CERTIFICATION AQ-12

As per the Condition of Certification Number AQ-12, the 5 ppm ammonia (NH<sub>3</sub>) emission limit(s) are averaged over 1 hour at 15 percent oxygen, dry basis. MGS shall calculate and continuously record the ammonia slip concentration using the following:

 $NH_3$  (ppmv) = [a-(b\*c/1,000,000)]\*(1,000,000\*d/b) where

a = ammonia injection rate (lbs/hr)/17 (lbs/lb-mole)

b = dry exhaust gas flow rate (lbs/hr)/29 (lbs/lb-mole)

c = change in measured NO<sub>X</sub> across the SCR (ppmv dry basis)

d = correction derived by comparing the measured and calculated NH3 slip concentrations during annual compliance testing.

For verification of the above condition of certification, the CEC requires MGS to submit to the CPM for approval all emissions and emission calculations on a quarterly basis as part of the quarterly emissions report.

NH<sub>3</sub> emissions are calculated via the CEMS on an hourly basis but compliance with 5 ppm limit is demonstrated from source tests. The last compliance source test, performed in February 2018, indicated compliance with the emission limits.

#### 2.16 CONDITION OF CERTIFICATION AQ-13

As per the Condition of Certification Number AQ-13, for the purpose of determining compliance with District Rule 475, combustion contaminant emissions may exceed the

concentration limit or the mass emission limit listed, but not both emission limits at the same time.

For verification of the above condition of certification, the CEC requires MGS to submit to the CPM for approval all emissions and emission calculations on a quarterly basis as part of the quarterly emissions report.

As demonstration of compliance, MGS advises that Rule 475 limits emission of combustion contaminants from electric generating equipment to no more than 5 kilograms (11 pounds) per hour or 23 milligrams per cubic meter (0.01 gr/SCF) calculated at three percent oxygen on a dry basis averaged over 15 consecutive minutes or any other averaging time specified by the Executive Officer. The results of the last compliance source tests performed in March 2017 showed that the total particulate matter emission from CT1 and CT2 were 0.88 lbs/hr (0.00105 gr/dscf) and 0.57 lbs/hr (0.00079 gr/dscf) with Duct Burners and 0.50 lbs/hr (0.00069 gr/dscf) and 0.62 lbs/hr (0.00087 gr/dscf) without.

#### 2.17 CONDITION OF CERTIFICATION AQ-14

As per the Condition of Certification Number AQ-14, MGS shall not use engine cylinder lubricating oil containing the following specified compounds:

Ash greater than 0.038 weight percent

For verification of the above condition of certification, the CEC requires MGS to submit fuel purchase records to the CPM on a quarterly basis as part of the quarterly emissions report.

MGS uses Chevron GST Oil for the MGS turbines. This is an ash less oil. As demonstration of compliance, detailed specifications of Chevron GST Oils are provided in Figure 2-1.

#### 2.18 Condition of certification AQ-15

As per the condition of certification number AQ-15, MGS will limit the operating time of the diesel fueled emergency backup generator and the firewater pump to no more than 199 hours each in any one year.

For verification of the above condition of certification, the CEC requires MGS to submit to the CPM for approval all testing times and results of the diesel fired emergency firewater pump in the quarterly emissions report.

As demonstration of compliance, the testing times for the diesel fired emergency firewater pump are provided in Table 2-5.

#### 2.19 CONDITION OF CERTIFICATION AQ-27

As per the Condition of Certification Number AQ-27, MGS shall limit the fuel usage of each turbine-duct burner pair to no more than 330 MM cubic feet per month.

For verification of the above condition of certification, the CEC requires MGS to submit to the CPM for approval all emissions and emission calculations on a quarterly basis as part of the quarterly emissions report.

As demonstration of compliance, the fuel usage for the two turbine-duct burner pairs is provided in Table 2-15.

#### **SECTION 3**

#### ANNUAL COMPLIANCE DETAILS

The compliance details for various conditions of certification are provided below.

#### 3.1 CONDITION OF CERTIFICATION COM-2

As per the Condition of Certification Number COM-2, the project owner shall grant Energy Commission staff and delegate agencies or consultants unrestricted access to the power plant site.

No specific means of verification of the above condition of certification are listed in the Decision.

As demonstration of compliance, the Malburg Generating Station site remains accessible for Energy Commission staff and delegate agencies or consultants.

#### 3.2 CONDITION OF CERTIFICATION COM-3

As per the Condition of Certification Number COM-3, the project owner shall maintain project files onsite. Energy Commission staff and delegate agencies shall be given unrestricted access to the files.

No specific means of verification of the above condition of certification are listed in the Decision.

As demonstration of compliance, the Malburg Generating Station files remain accessible for Energy Commission staff and delegate agencies or consultants.

#### 3.3 CONDITION OF CERTIFICATION COM-4

As per the Condition of Certification Number COM-4, the project owner is responsible for the delivery and content of all verification submittals to the CPM, whether such condition was satisfied by work performed or the project owner or his agent.

No specific means of verification of the above condition of certification are listed in the Decision.

As demonstration of compliance, MGS acknowledges that it is responsible for the delivery and content of verification submittals to the CPM.

#### 3.4 CONDITION OF CERTIFICATION COM-6

As per the Condition of Certification Number COM-6, the project owner shall submit a compliance matrix (in a spreadsheet format) with each monthly and annual compliance report which includes the status of all compliance conditions of certification.

No specific means of verification of the above condition of certification are listed in the Decision.

As demonstration of compliance, the MGS – CEC Commission Decision Compliance Matrix is provided in Appendix I.

#### 3.5 CONDITION OF CERTIFICATION COM-8

As per the Condition of Certification Number COM-8, after construction ends and throughout the life of the project, the project owner shall submit Annual Compliance Reports (ACRs) which include specific information.

No specific means of verification of the above condition of certification are listed in the Decision.

As demonstration of compliance, MGS submits the following information to comply with the individual requirements:

- 1. An updated compliance matrix which shows the status of all conditions of certification (fully satisfied and/or closed conditions do not need to be included in the matrix after they have been reported as closed); An updated Compliance Matrix is provided in Appendix I.
- 2. A summary of the current project operating status and an explanation of any significant changes to facility operations during the year; The facility remains in operation and no significant changes have occurred during the year.
- 3. Documents required by specific conditions to be submitted along with the Annual Compliance Report. Each of these items must be identified in the transmittal letter, and should be submitted as attachments to the Annual Compliance Report; These documents are submitted as Appendices to the Report and are listed as such in the 'Attachments' section of this transmittal letter.
- 4. A cumulative listing of all post-certification changes approved by the Energy Commission or cleared by the CPM; No post-certification changes have been approved during the year.
- 5. An explanation for any submittal deadlines that were missed, accompanied by an estimate of when the information will be provided; No submittal deadlines were missed.
- 6. A listing of filings made to, or permits issued by, other governmental agencies during the year; Filings to governmental agencies were submitted as required during the year, including Annual Compliance Certification to SCAQMD and EPA, Semi-Annual Monitoring Report to SCAQMD, daily, monthly and electronic NOx reports to AQMD, Quarterly Certification of Emission Reports (QCER) to AQMD, quarterly EDR's to EPA, Annual Emissions Inventory to SCAQMD, Annual Greenhouse Gas Report to CARB and EPA, source testing notification and test report to SCAQMD, Annual Permit Emissions Program (APEP) report to SCAQMD, Annual Storm Water Discharge Report to Los Angeles County Sanitation Districts, and Semi-Annual Industrial WW Monitoring Report to Los Angeles County Sanitation Districts. In November 2017, a filing was made to both the AQMD and CEC, permit revisions are pending.
- 7. A projection of project compliance activities scheduled during the next year; Aside from sampling, testing, monitoring and reporting according to various permits and the CEC Decision, no additional project compliance activities are scheduled. In November 2017, a filing was made to both the AQMD and CEC, permit revisions are pending. Upon permit issuance, compliance testing will be required within 180 days.

9

- 8. A listing of the year's additions to the on-site compliance file; All test and monitoring results, reports, filings, and other evidence of compliance with various permits and the CEC Decision were added to the plant files. Please refer to Condition #6 for specific items.
- 9. An evaluation of the on-site contingency plan for unplanned facility closure, including any suggestions necessary for bringing the plan up to date; As there have been no changes to the configuration or operation of the plant during the year, no changes or suggestions resulted from an evaluation of this plan.
- 10. A listing of complaints, notices of violation, official warnings, and citations received during the year, a description of the resolution of any resolved complaints, and the status of any unresolved complaints;
  - There were no complaints, official warnings or citations received during 2018.
- 11. A listing of all outages planned for the coming year and a listing of all outages that occurred during the previous year, including the anticipated duration and the reason for each outage occurrence.
  - March 5 thru April 29, 2018 CT1, CT2, Major Overhaul.
  - December 3 thru December 10, 2018 CT1, CT2, General Semi-Annual Maintenance.
  - May 5, 2019 thru May 11, 2019, General Semi-Annual Maintenance.
  - November 3, 2019 thru November 8, 2019, General Semi-Annual Maintenance.

#### 3.6 CONDITION OF CERTIFICATION COM-12

As per the Condition of Certification Number COM-12, within 10 days of receipt, the project owner shall report to the CPM, all notices, complaints, and citations.

No specific means of verification of the above condition of certification are listed in the Decision.

As demonstration of compliance, MGS shall report to the CPM all notices, complaints and citations.

#### 3.7 CONDITION OF CERTIFICATION COM-13

As per the Condition of Certification Number COM-13, the project owner shall submit a closure plan to the CPM at least twelve months prior to commencement of a planned closure.

No specific means of verification of the above condition of certification are listed in the Decision.

As demonstration of compliance, MGS shall submit a closure plan to the CPM at least twelve months prior to commencement of a planned closure, but at this time MGS remains in operation.

#### 3.8 CONDITION OF CERTIFICATION COM-14

As per the Condition of Certification Number COM-14, to ensure that public health and safety and the environment are protected in the event of an unplanned temporary closure, the project owner shall submit an on-site contingency plan no less than 60 days prior to commencement of commercial operation. The approved plan must be in place prior to commercial operation of the facility and shall be kept at the site at all times.

For verification of the above condition of certification, the project owner, in consultation with the CPM, will update the on-site contingency plan as necessary. The CPM may require revisions to the on-site contingency plan over the life of the project. In the annual compliance reports submitted to the Energy Commission, the project owner will review the on-site contingency plan, and recommend changes to bring the plan up to date. Any changes to the plan must be approved by the CPM. In the event of an unplanned temporary closure, the project owner shall notify the CPM, as well as other responsible agencies, by telephone, fax, or e-mail, within 24 hours and shall take all necessary steps to implement the on-site contingency plan.

As demonstration of compliance, MGS has submitted the on-site contingency plan as scheduled. MGS will review the on-site contingency plan as part of preparation for the annual compliance reports, and recommend changes to bring the plan up to date.

During this year, MGS recommends no changes to the plan. In the event of an unplanned temporary closure, MGS shall notify the CPM, as well as other responsible agencies, by telephone, fax, or e-mail, within 24 hours and shall take all necessary steps to implement the on-site contingency plan.

#### 3.9 CONDITION OF CERTIFICATION COM-15

As per the Condition of Certification Number COM-15, to ensure that public health and safety and the environment are protected in the event of an unplanned permanent closure, the project owner shall submit an on-site contingency plan no less than 60 days prior to commencement of commercial operation.

For verification of the above condition of certification, all of the requirements specified for unplanned temporary closure shall also apply to unplanned permanent closure.

As demonstration of compliance, MGS remains in operation. In the event of an unplanned permanent closure, MGS shall notify the CPM, as well as other responsible agencies, by telephone, fax, or e-mail, within 24 hours and shall take all necessary steps to implement the on-site contingency plan.

#### 3.10 CONDITION OF CERTIFICATION COM-16

As per the Condition of Certification Number COM-16, the project owner must petition the Energy Commission to delete or change a condition of certification, modify the project design or operational requirements and/or transfer ownership of operational control of the facility.

No specific means of verification of the above condition of certification are listed in the Decision.

A Petition to Amend the Final Decision for the Malburg Generating Station (01-AFC-25C) was submitted on November 17, 2017, and is currently pending.

#### 3.11 CONDITION OF CERTIFICATION AQ-C5

As per the Condition of Certification Number AQ-C5, no chromium containing compounds shall be added to cooling tower circulating water.

For verification of the above condition of certification, MGS shall make the site available for inspection by representatives of the District, CARB and the Commission.

As demonstration of compliance, the Malburg Generating Station site remains accessible for inspection by representatives of the District, CARB and the Commission.

#### 3.12 CONDITION OF CERTIFICATION AQ-C13

As per the Condition of Certification Number AQ-C13, MGS shall submit to the CPM for review and approval any modification proposed by either MGS or issuing agency to any project air permit.

For verification of the above condition of certification, MGS shall submit any proposed air permit modification to the CPM within five working days of its submittal either by MGS to an agency or receipt of proposed modifications from an agency. MGS shall submit all modified air permits to the CPM within 15 days of receipt.

A facility permit to operate was issued to MGS by the SCAQMD dated November 03, 2015. A copy of the permit modifications issued by the district has been sent to the CPM for review.

#### 3.13 CONDITION OF CERTIFICATION AQ-1

As per the Condition of Certification Number AQ-1, except for open abrasive blasting operations, MGS shall not discharge into the atmosphere from any single source of emissions whatsoever any contaminant for a period or periods aggregating more than three minutes in any one hour which is: a) As dark or darker in shade as that designated No. 1 on the Ringlemann Chart, as published by the United States Bureau of Mines; or b) Of such opacity as to obscure an observer's view to a degree equal to or greater than does smoke described in subparagraph (a) of this condition.

For verification of the above condition of certification, MGS shall make the Malburg Generating Facility site accessible for inspection to the District, CARB and Commission.

As demonstration of compliance, the Malburg Generating Station site remains accessible for Energy Commission staff and delegate agencies or consultants.

#### 3.14 CONDITION OF CERTIFICATION AQ-4

As per the Condition of Certification Number AQ-4, accident release prevention requirements of Section 112 (r)(7): a). MGS shall comply with the accidental release prevention requirements pursuant to 40CFR Part 68 and shall submit to the Executive Officer and the CPM, as a part of an annual compliance certification, a statement that certifies compliance with all of the requirements of 40 CFR Part 68, including the

registration and admission of a risk management plan (RMP). b). The City of Vernon shall submit any additional relevant information requested by the Executive Officer, designated agency or CPM.

For verification of the above condition of certification, MGS shall submit for approval to the CPM the above required statement of compliance and any further information requested on an annual basis as part of the annual compliance report.

As demonstration of compliance, MGS is compliant with all applicable requirements of 40 CFR Part 68, including the registration and admission of a risk management plan (RMP). MGS most recently updated its Risk Management Plan in July 2014.

#### 3.15 CONDITION OF CERTIFICATION AQ-16

As per the Condition of Certification Number AQ-16, MGS shall install and maintain a pressure relief valve set at 25 psig in the ammonia storage tank.

For verification of the above condition of certification, MGS shall make the ammonia storage tank available for inspection by the District, Commission or CARB.

As demonstration of compliance, the Malburg Generating Station ammonia storage tank remains available for inspection by the District, Commission or CARB.

#### 3.16 CONDITION OF CERTIFICATION AQ-17

As per the Condition of Certification Number AQ-17, MGS shall install and maintain a non-resettable elapsed time meter into the firewater pump to accurately indicate the elapsed operating time of the engine.

For verification of the above condition of certification, MGS shall make the firewater pump available for inspection by the District, Commission or CARB.

As demonstration of compliance, the Malburg Generating Station firewater pump remains available for inspection by the District, Commission or CARB.

#### 3.17 CONDITION OF CERTIFICATION AQ-18

As per the Condition of Certification Number AQ-18, MGS shall install and maintain a non-resettable totalizing fuel meter to accurately indicate the fuel usage of the turbines.

For verification of the above condition of certification, MGS shall make the firewater pump available for inspection by the District, Commission or CARB.

As demonstration of compliance, the Malburg Generating Station firewater pump remains available for inspection by the District, Commission or CARB.

#### 3.18 CONDITION OF CERTIFICATION AQ-19

As per the Condition of Certification Number AQ-19, MGS shall install and maintain a flow meter to accurately indicate the flow rate of the total hourly throughput of injected ammonia (NH3). MGS shall also install and maintain a device to continuously record the

parameter being measured. The measuring device or gauge shall be accurate to within plus or minus 5 percent. It shall be calibrated once every 12 months.

For verification of the above condition of certification, MGS shall submit to CPM for approval the design drawing that clearly show the flow meter and recording device for the ammonia injection grid no less than 90 days prior to installation of the ammonia injection grid. MGS shall submit to the CPM for approval the annual calibration report for the flow meter and recording device as part of the annual compliance report.

As demonstration of compliance, MGS has submitted to CPM for approval the design drawing that clearly show the flow meter and recording device for the ammonia injection grid as scheduled. MGS will include with each annual compliance report the annual calibration records for the NH3 flow meter. The calibration report for the NH3 Flow Meter for the compliance year is provided in Appendix J. The information demonstrates that the NH3 Flow Meter has been certified.

#### 3.19 CONDITION OF CERTIFICATION AQ-20

As per the Condition of Certification Number AQ-20, MGS shall install and maintain a temperature gauge to accurately indicate the temperature in the exhaust at the inlet to the SCR reactor. MGS shall also install and maintain a device to continuously record the parameter being measured. The measuring device or gauge shall be accurate to within plus or minus 5 percent. It shall be calibrated once every 12 months. For verification of the above condition of certification, MGS shall submit to CPM for approval the design drawing that clearly show the temperature gauge and recording device for the inlet to the SCR reactor no less than 90 days prior to installation of the SCR. MGS shall submit to the CPM for approval the annual calibration report for the temperature gauge and recording device as part of the annual compliance report.

As demonstration of compliance, MGS has submitted to CPM for approval the design drawing that clearly show the temperature gauge and recording device for the inlet to the SCR reactor as scheduled. MGS will include with each annual compliance report the annual calibration records for the SCR temperature gauge. The calibration report for the SCR Temperature Gauge for the compliance year is provided in Appendix K. The information demonstrates that the SCR Temperature Gauge has been certified.

#### 3.20 CONDITION OF CERTIFICATION AQ-21

As per the Condition of Certification Number AQ-21, MGS shall install and maintain a pressure gauge to accurately indicate the differential pressure across the SCR catalyst bed in inches of water column. MGS shall also install and maintain a device to continuously record the parameter being measured. The measuring device or gauge shall be accurate to within plus or minus 5 percent. It shall be calibrated once every 12 months.

For verification of the above condition of certification, MGS shall submit to CPM for approval the design drawing that clearly show the pressure gauge and recording device across the SCR reactor no less than 90 days prior to installation of the SCR. The City of Vernon shall submit to the CPM for approval the annual calibration report for the pressure gauge and recording device as part of the annual compliance report.

As demonstration of compliance, MGS has submitted to CPM for approval the design drawing that clearly show the pressure gauge and recording device across the SCR reactor as scheduled. MGS will include with each annual compliance report the annual calibration records for the SCR pressure gauge. The calibration report for the SCR Pressure Gauge for the compliance year is provided in Appendix L. The information demonstrates that the SCR Pressure Gauge has been certified.

#### 3.21 CONDITION OF CERTIFICATION AQ-22

As per the Condition of Certification Number AQ-22, MGS shall conduct source tests for the pollutants identified below:

- CO Emissions
- NOx Emissions
- VOC Emissions
- PM Emissions
- SOx Emissions
- NH3 Emissions

For verification of the above condition of certification, MGS shall submit for approval to the District and the CPM the required initial source testing protocol no less than 45 days prior to the date of the source test. MGS shall notify the District and CPM of the date and time of the source test no less than 10 days prior to the test. MGS shall submit to the District and CPM for approval the results of the initial source test no later than 60 days following the date of the source test.

As demonstration of compliance, MGS submits notification of test dates to the District and CPM no less than 10 days prior to the date of the source test as required in the RECLAIM/Title V. MGS submits the results of the source test to the District and CPM no later than 60 days following the date of the source test.

#### 3.22 CONDITION OF CERTIFICATION AQ-23

As per the Condition of Certification Number AQ-23, MGS shall conduct source tests for the pollutants identified below:

- VOC Emissions
- SOx Emissions
- PM Emissions

For verification of the above condition of certification, MGS shall submit for approval to the District and the CPM the required source testing protocol no less than 45 days prior to the date of the source test when required. MGS shall notify the District and CPM of the date and time of the source test no less than 10 days prior to the test. MGS shall submit to the District and CPM for approval the results of the source test no later than 60 days following the date of the source test.

As demonstration of compliance, MGS submits notification of test dates to the District and CPM no less than 10 days prior to the date of the source test as required in the

RECLAIM/Title V. MGS submits the results of the source test to the District and CPM no later than 60 days following the date of the source test.

#### 3.23 CONDITION OF CERTIFICATION AQ-24

As per the Condition of Certification Number AQ-24, MGS shall conduct source testing for the pollutant identified below:

#### -NH3 Emissions

For verification of the above condition of certification, MGS shall submit for approval to the District and the CPM the required source testing protocol no less than 45 days prior to the date of the source test. MGS shall notify the District and CPM of the date and time of the source test no less than 10 days prior to the test. MGS shall submit to the District and CPM for approval the results of the source test no later than 60 days following the date of the source test.

As demonstration of compliance, MGS submits notification of test dates to the District and CPM no less than 10 days prior to the date of the source test as required in the RECLAIM/Title V. MGS submits the results of the source test to the District and CPM no later than 60 days following the date of the source test.

#### 3.24 CONDITION OF CERTIFICATION AQ-25

As per the Condition of Certification Number AQ-25, MGS shall install and maintain a CEMS in each exhaust stack of the combustion turbine-HRSG trains to measure listed parameters.

For verification of the above condition of certification, MGS shall make the Malburg Generation Station available for inspection by the District, Commission or CARB.

As demonstration of compliance, the Malburg Generating Station site remains available for inspection by the District, Commission or CARB.

#### 3.25 CONDITION OF CERTIFICATION AQ-26

As per the Condition of Certification Number AQ-26, MGS shall install and maintain a CEMS to measure listed parameters.

For verification of the above condition of certification, MGS shall make the Malburg Generation Station available for inspection by the District, Commission or CARB.

As demonstration of compliance, the Malburg Generating Station site remains available for inspection by the District, Commission or CARB.

#### 3.26 CONDITION OF CERTIFICATION AQ-28

As per the Condition of Certification Number AQ-28, MGS shall vent combustion turbines and HRSGs to the CO oxidation/SCR control system whenever the turbines are in operation.

For verification of the above condition of certification, MGS shall make the Malburg Generation Station available for inspection by the District, Commission or CARB.

As demonstration of compliance, the Malburg Generating Station site remains available for inspection by the District, Commission or CARB.

#### 3.27 CONDITION OF CERTIFICATION AQ-29

As per the Condition of Certification Number AQ-29, MGS shall vent ammonia storage tank, during filling, only to the vessel from which it is being filled.

For verification of the above condition of certification, MGS shall make the Malburg Generation Station available for inspection by the District, Commission or CARB.

As demonstration of compliance, the Malburg Generating Station site remains available for inspection by the District, Commission or CARB.

#### 3.28 CONDITION OF CERTIFICATION AQ-30

As per the Condition of Certification Number AQ-30, for the purpose of the following condition number(s), "continuously record" shall be defined as recording at least once every hour and shall be calculated upon the average of the continuous monitoring for that hour. Condition of Certification AQ-17 Condition of Certification AQ-18

For verification of the above condition of certification, MGS shall make the Malburg Generation Station available for inspection by the District, Commission or CARB.

As demonstration of compliance, the Malburg Generating Station site remains available for inspection by the District, Commission or CARB.

#### 3.29 CONDITION OF CERTIFICATION AQ-31

As per the Condition of Certification Number AQ-31, for the purpose of the following condition number(s), "continuously record" shall be defined as recording at least once every hour and shall be calculated based upon the average of the continuous monitoring for that month. Condition of Certification AQ-19

For verification of the above condition of certification, MGS shall make the Malburg Generation Station available for inspection by the District, Commission or CARB.

As demonstration of compliance, the Malburg Generating Station site remains available for inspection by the District, Commission or CARB.

#### 3.30 CONDITION OF CERTIFICATION AQ-32

As per Condition of Certification AQ-32, the MGS electric generating equipment shall not be operated unless the City of Vernon demonstrates to the Executive Officer that the facility holds sufficient RTCs to offset the prorated annual emissions increase for the first compliance year of operation. In addition, this equipment shall not be operated unless the City of Vernon demonstrates to the Executive Officer that, at the commencement of each compliance year after the first compliance year of operation, the facility hold

sufficient RTCs in an amount equal to the annual emission increase. The City of Vernon shall submit all such information to the CPM for approval.

For verification of the above condition of certification, MGS shall submit all identified evidence demonstrating compliance to the CPM on an annual basis as part of the annual compliance report.

As demonstration of compliance, the NOx RECLAIM annual emission allocation information received from the SCAQMD for the compliance year for the Bicent (California) Malburg LLC facility are provided in Appendix G. The information demonstrates that the MGS facility held sufficient NOx RTCs to offset the annual emission increase.

#### 3.31 CONDITION OF CERTIFICATION AQ-33

As per the Condition of Certification Number AQ-33, MGS shall provide to the District a source test report in accordance with listed specifications.

For verification of the above condition of certification, MGS shall submit to the CPM the required source test of Conditions of Certification AQ-21, -22 and -23 in compliance with this condition.

As demonstration of compliance, MGS submitted to the CPM a copy of the 2018 Source Test Reports on March 27, 2018.

#### 3.32 CONDITION OF CERTIFICATION AQ-34

As per the Condition of Certification Number AQ-34, MGS shall keep records, in a manner approved by the District, for listed parameters or items.

For verification of the above condition of certification, MGS shall make these records available to the CPM upon request.

As demonstration of compliance, MGS will make the listed records available to the CPM upon request.

#### 3.33 CONDITION OF CERTIFICATION AQ-35

As per the Condition of Certification Number AQ-35, MGS shall keep records, in a manner approved by the District, for the date of operation, the elapsed time, in hour and the reason for operation of the emergency diesel powered generators and/or the firewater pump.

For verification of the above condition of certification, the CEC requires MGS to submit all identified evidence demonstrating compliance to the CPM on an annual basis as part of the compliance report.

As demonstration of compliance, the date of operation, the elapsed time, in hour and the reason for operation of are provided in Table 2-5. MGS refrained from testing the diesel fired emergency firewater pump on the same day the combustion turbines were either started or shutdown.

#### 3.34 CONDITION OF CERTIFICATION HAZ-1

As per Condition of Certification HAZ-1, the project owner shall not use any hazardous materials not listed in Appendix C of the Commission Decision Document, or in greater quantities than those identified by chemical name in Appendix C, unless approved in advance by the City of Vernon and the CPM.

For verification of the above condition of certification, the project owner shall provide to the CPM, in the annual compliance report, a list of hazardous materials contained at the facility in reportable quantities.

As demonstration of compliance, CEM provides the following list of hazardous materials stored at the facility during the compliance year in reportable quantities.

Aqueous Ammonia 19% Concentration

#### 3.35 CONDITION OF CERTIFICATION HAZ-6

As per Condition of Certification HAZ-6, the project owner shall require that the gas pipeline undergo a complete design review and detailed inspection every five years.

For verification of the above condition of certification, at least 30 days prior to the initial flow of gas in the pipeline, the project owner shall provide outline of the plan to accomplish a full and comprehensive pipeline design review to the CPM for review and approval. The full and complete plan shall be amended, as appropriate, and submitted to the CPM for review and approval, not later than one year before the plan is implemented by the project owner.

As demonstration of compliance, the original documents prior to initial gas flow were submitted as scheduled. The requirement for a follow up review and inspection was satisfied on January 29, 2013. Verification of the five year inspection due by the City of Vernon is pending.

#### 3.36 CONDITION OF CERTIFICATION HAZ-7

As per Condition of Certification HAZ-7, the project owner shall require that the gas pipeline undergo a detailed inspection after any significant seismic event in the area where surface rupturing occurs within one mile of the pipeline, or every 5 years.

For verification of the above condition of certification, at least 30 days prior to the initial flow of gas in the pipeline, the project owner shall provide a detailed plan to accomplish a full and comprehensive pipeline inspection in the event of an earthquake to the CPM for review and approval. This plan shall be reviewed and amended, as appropriate, and submitted to the CPM for review and approval, at least every five years.

As demonstration of compliance, the original documents prior to initial gas flow were submitted as scheduled. MGS certifies that there was no significant seismic activity in the compliance year. The requirement for a follow up review and inspection was satisfied on January 29, 2013. Verification of the five year inspection due by the City of Vernon is pending.

#### 3.37 CONDITION OF CERTIFICATION WASTE-3

As per the Condition of Certification Number WASTE-3, MGS shall upon becoming aware of any impending waste management enforcement action by any local, state or federal authority, notify the CPM of any such action taken or proposed to be taken against the project itself, or against any waste haulers or disposal facility or treatment operator with which the MGS contracts.

For verification of the above condition of certification, the project owner shall notify the CPM in writing within 10 days of becoming aware of an impending enforcement action. The CPM shall notify the project owner of any changes that will be required in the manner in which project-related wastes are managed.

As demonstration of compliance, MGS hereby certifies it became aware of no impending action taken or proposed for any waste management activity related to MGS in the compliance year.

#### 3.38 CONDITION OF CERTIFICATION WASTE-4

As per the Condition of Certification Number WASTE-4, the project owner shall prepare a Construction Waste Management Plan and an Operation Waste Management Plan for all wastes generated during construction and operation of the facility, respectively, and shall submit both plans to the City of Vernon, Environmental Health Department and the City of Vernon Fire Department for comment and to the CPM for review and approval. The plans shall contain, at a minimum, the following: A description of all waste streams, including projections of frequency, amounts generated and hazard classifications; and methods of managing each waste, including treatment methods and companies contracted with for treatment services, waste testing methods to assure correct classification, methods of transportation, disposal requirements and sites, and recycling and waste minimization/reduction plans.

For verification of the above condition of certification, no less than 30 days prior to the start of site mobilization, the project owner shall submit the Construction Waste Management Plan to the City of Vernon Environmental Health Department, City of Vernon Fire Department, and CPM. The operation waste management plan shall be submitted no less than thirty (30) days prior to the start of project operation. The project owner shall submit any required revisions within 20 days of notification by the CPM. In the Annual Compliance Reports, the project owner shall document the actual waste management methods used during the year compared to the planned management methods.

As demonstration of compliance, submittals of the Construction Waste Management Plan and the Operation Waste Management Plan were submitted as scheduled prior to the start of project operation. No notification has been received by MGS from the CPM that revisions to the Operation Waste Management Plan are required. Actual waste management methods used during the year were consistent with planned management methods.

#### 3.39 CONDITION OF CERTIFICATION SOIL & WATER-4

As per Condition of Certification SOIL & WATER-4, the project owner shall install metering devices and record on a monthly basis the amount of water, listed by source (potable and reclaimed) used by the project. The annual summary shall include the monthly range and monthly average of daily usage in gallons per day, and total water used by the project on a monthly and annual basis in acre-feet. The annual summary shall also include the yearly range and yearly average water use by the project.

For verification of the above condition of certification, the project owner shall submit an annual water use summary to the CPM as part of its annual compliance report for the life of the project.

As demonstration of compliance, the compliance year water use summary is provided in Tables 2-19 and 2-20.

#### 3.40 CONDITION OF CERTIFICATION SOIL & WATER-5

As per Condition of Certification Number SOIL & WATER-5, the project owner shall not use potable water for process cooling water for more than 9 days (216 hours) per calendar year.

For verification of the above condition of certification, the project owner shall include a detailed summary of all potable water and reclaimed water used for process water in the Annual Compliance Report.

As demonstration of compliance, a summary of potable and reclaimed water used during the compliance year is provided in Tables 2-19 and 2-20.

#### 3.41 CONDITION OF CERTIFICATION CUL-8

As per Condition of Certification CUL-8, the project owner shall ensure that Station A is maintained in accordance with the Secretary of the Interior's Standards for the Treatment of Historic Properties (1995) (36 CFR Part 68). The project owner shall provide a summary of maintenance activities completed within each calendar year.

For verification of the above condition of certification, in each annual compliance report, the project owner shall include the summary of Station A maintenance activities completed within the last calendar year.

As demonstration of compliance, a Station A Maintenance Summary Report for the compliance year is provided in Appendix M.

#### 3.42 CONDITION OF CERTIFICATION TRANS-8

As per Condition of Certification TRANS-8, the project owner shall only use the preferred and alternate truck travel routes for deliveries of aqueous ammonia to the MGS site. The preferred route shall be from Interstate 710, exiting at the Bandini Boulevard. Trucks will then travel west along Bandini Boulevard, south on Soto Avenue, and finally west on 50th Street to the MGS. The City shall use this route unless it notifies the CPM otherwise and the CPM approves.

For verification of the above condition of certification, the project owner may alter the final truck travel route only upon prior approval of the CPM.

As demonstration of compliance, the originally mandated route and alternate route have been communicated to the aqueous ammonia supplier and use of these routes is mandated by MGS. MGS may alter the final truck travel route only upon prior approval of the CPM.

#### 3.43 CONDITION OF CERTIFICATION VIS-1

As per Condition of Certification VIS-1, the project owner shall design and install all permanent lighting such that light bulbs and reflectors are not visible from public viewing areas; lighting does not cause reflected glare, and illumination of the project, the vicinity and the nighttime sky is minimized.

For verification of the above condition of certification, at least 60 days prior to ordering any permanent exterior lighting, the project owner shall submit to the CPM for review and comment written documentation describing the lighting control measures and fixtures, hoods, shields proposed for use, and incorporate the CPM's comments in lighting equipment orders. Prior to first turbine roll, the project owner shall notify the CPM that the lighting has been completed and is ready for inspection. If the CPM notifies the project owner that modifications to the lighting are needed to minimize impacts, within 30 days of receiving that notification the project owner shall implement the modifications and notify the CPM that the modifications have been completed. The project owner shall report any complaints about permanent lighting and provide documentation of resolution in the Annual Compliance Report, accompanied by any lighting complaint resolution forms for that year.

As demonstration of compliance, written documentation describing the lighting control measures was submitted as scheduled prior to first turbine roll. The CPM was notified that the lighting had been completed and was ready for inspection. No subsequent notification has been received from the CPM that modifications to the lighting are needed to minimize impacts. MGS certifies that there were no lighting related complaints in the compliance year.

#### 3.44 CONDITION OF CERTIFICATION VIS-2

As per Condition of Certification VIS-2, the project owner shall paint or treat the surfaces of all project structures and buildings visible to the public in a gray color to blend with the existing Station "A" building. Surfaces shall be treated with finishes that minimize glare. The project owner shall ensure proper treatment maintenance for the life of the project. For verification of the above condition of certification, at least 30 days prior to the start of commercial operation, the project owner shall notify the CPM that all buildings and structures are ready for inspection. The project owner shall provide a status report regarding treatment maintenance in the Annual Compliance Report.

As demonstration of compliance, the CPM was notified as scheduled that all buildings and structures were ready for inspection. All project structures on the MGS site are matching in color to the pre-existing structure of Station 'A'. Following maintenance activities, a gray color coating was applied where required.

Table 2-1

# Malburg Generating Station Cooling Tower TDS Sampling Results Quarter 4, 2018

| Starting   | Ending     | TDS (ppm) |
|------------|------------|-----------|
| 9/30/2018  | 10/7/2018  | 4540      |
| 10/7/2018  | 10/14/2018 | 4340      |
| 10/14/2018 | 10/21/2018 | 4980      |
| 10/21/2018 | 10/28/2018 | 4500      |
| 10/28/2018 | 11/4/2018  | 4340      |
| 11/4/2018  | 11/11/2018 | 4620      |
| 11/11/2018 | 11/18/2018 | 4480      |
| 11/18/2018 | 11/25/2018 | 4700      |
| 11/25/2018 | 12/2/2018  | 4750      |
| 12/2/2018  | 12/9/2018  | OFFLINE   |
| 12/9/2018  | 12/16/2018 | OFFLINE   |
| 12/16/2018 | 12/23/2018 | OFFLINE   |
| 12/23/2018 | 12/30/2018 | OFFLINE   |
|            |            |           |

Table 2-2

## Malburg Generating Station Cooling Tower Daily PM10 Emissions During Oct. 2018

PM<sub>10</sub> = A x B x C x D PM<sub>10</sub> Limit is 6.2 lbs/day A = Circulation Rate
C = Drift Factor

B = TDS

D = Correction Factor

| Date | Circulation<br>Rate<br>(gal/day) | TDS<br>(ppm) | PM <sub>10</sub><br>(lbs/day) |
|------|----------------------------------|--------------|-------------------------------|
| 1    | 36,339,840                       | 4540         | 1.37                          |
| 2    | 36,339,840                       | 4540         | 1.37                          |
| 3    | 36,339,840                       | 4540         | 1.37                          |
| 4    | 36,339,840                       | 4540         | 1.37                          |
| 5    | 36,339,840                       | 4540         | 1.37                          |
| 6    | 36,339,840                       | 4540         | 1.37                          |
| 7    | 36,339,840                       | 4340         | 1.31                          |
| 8    | 36,339,840                       | 4340         | 1.31                          |
| 9    | 36,339,840                       | 4340         | 1.31                          |
| 10   | 36,339,840                       | 4340         | 1.31                          |
| 11   | 36,339,840                       | 4340         | 1.31                          |
| 12   | 36,339,840                       | 4340         | 1.31                          |
| 13   | 36,339,840                       | 4340         | 1.31                          |
| 14   | 36,339,840                       | 4980         | 1.51                          |
| 15   | 36,339,840                       | 4980         | 1.51                          |
| 16   | 36,339,840                       | 4980         | 1.51                          |

| Date | Circulation<br>Rate<br>(gal/day) | TDS<br>(ppm) | PM <sub>10</sub><br>(lbs/day) |
|------|----------------------------------|--------------|-------------------------------|
| 17   | 36,339,840                       | 4980         | 1.51                          |
| 18   | 36,339,840                       | 4980         | 1.51                          |
| 19   | 36,339,840                       | 4980         | 1.51                          |
| 20   | 36,339,840                       | 4980         | 1.51                          |
| 21   | 36,339,840                       | 4500         | 1.36                          |
| 22   | 36,339,840                       | 4500         | 1.36                          |
| 23   | 36,339,840                       | 4500         | 1.36                          |
| 24   | 36,339,840                       | 4500         | 1.36                          |
| 25   | 36,339,840                       | 4500         | 1.36                          |
| 26   | 36,339,840                       | 4500         | 1.36                          |
| 27   | 36,339,840                       | 4500         | 1.36                          |
| 28   | 36,339,840                       | 4340         | 1.31                          |
| 29   | 36,339,840                       | 4340         | 1.31                          |
| 30   | 36,339,840                       | 4340         | 1.31                          |
| 31   | 36,339,840                       | 4340         | 1.31                          |
|      |                                  |              |                               |

Table 2-3

# Malburg Generating Station Cooling Tower Daily PM10 Emissions During Nov. 2018

 $PM_{10} = A \times B \times C \times D$  A = Circulation Rate B = TDS

| Date | Circulation<br>Rate<br>(gal/day) | TDS<br>(ppm) | PM <sub>10</sub><br>(lbs/day) |
|------|----------------------------------|--------------|-------------------------------|
| 1    | 36,339,840                       | 4340         | 1.31                          |
| 2    | 36,339,840                       | 4340         | 1.31                          |
| 3    | 36,339,840                       | 4340         | 1.31                          |
| 4    | 36,339,840                       | 4620         | 1.40                          |
| 5    | 36,339,840                       | 4620         | 1.40                          |
| 6    | 36,339,840                       | 4620         | 1.40                          |
| 7    | 36,339,840                       | 4620         | 1.40                          |
| 8    | 36,339,840                       | 4620         | 1.40                          |
| 9    | 36,339,840                       | 4620         | 1.40                          |
| 10   | 36,339,840                       | 4620         | 1.40                          |
| 11   | 36,339,840                       | 4480         | 1.36                          |
| 12   | 36,339,840                       | 4480         | 1.36                          |
| 13   | 36,339,840                       | 4480         | 1.36                          |
| 14   | 36,339,840                       | 4480         | 1.36                          |
| 15   | 36,339,840                       | 4480         | 1.36                          |
| 16   | 36,339,840                       | 4480         | 1.36                          |

| Date | Circulation<br>Rate<br>(gal/day) | TDS<br>(ppm) | PM <sub>10</sub><br>(lbs/day) |
|------|----------------------------------|--------------|-------------------------------|
| 17   | 36,339,840                       | 4480         | 1.36                          |
| 18   | 36,339,840                       | 4700         | 1.42                          |
| 19   | 36,339,840                       | 4700         | 1.42                          |
| 20   | 36,339,840                       | 4700         | 1.42                          |
| 21   | 36,339,840                       | 4700         | 1.42                          |
| 22   | 36,339,840                       | 4700         | 1.42                          |
| 23   | 36,339,840                       | 4700         | 1.42                          |
| 24   | 36,339,840                       | 4700         | 1.42                          |
| 25   | 36,339,840                       | 4750         | 1.44                          |
| 26   | 36,339,840                       | 4750         | 1.44                          |
| 27   | 36,339,840                       | 4750         | 1.44                          |
| 28   | 36,339,840                       | 4750         | 1.44                          |
| 29   | 36,339,840                       | 4750         | 1.44                          |
| 30   | 36,339,840                       | 4750         | 1.44                          |
|      |                                  | ·            |                               |
|      |                                  |              |                               |

Need to find the actual start date for Circ Pumps

Table 2-4

# Malburg Generating Station Cooling Tower Daily PM10 Emissions During Dec. 2018

 $PM_{10} = A \times B \times C \times D$  A = Circulation Rate B = TDS

| Date | Circulation<br>Rate<br>(gal/day) | TDS<br>(ppm) | PM <sub>10</sub><br>(lbs/day) |
|------|----------------------------------|--------------|-------------------------------|
| 1    | 36,339,840                       | 4750         | 1.44                          |
| 2    | 36,339,840                       | OFFLINE      | 0.00                          |
| 3    | 36,339,840                       | OFFLINE      | 0.00                          |
| 4    | 36,339,840                       | OFFLINE      | 0.00                          |
| 5    | 36,339,840                       | OFFLINE      | 0.00                          |
| 6    | 36,339,840                       | OFFLINE      | 0.00                          |
| 7    | 36,339,840                       | OFFLINE      | 0.00                          |
| 8    | 36,339,840                       | OFFLINE      | 0.00                          |
| 9    | 36,339,840                       | OFFLINE      | 0.00                          |
| 10   | 36,339,840                       | OFFLINE      | 0.00                          |
| 11   | 36,339,840                       | OFFLINE      | 0.00                          |
| 12   | 36,339,840                       | OFFLINE      | 0.00                          |
| 13   | 36,339,840                       | OFFLINE      | 0.00                          |
| 14   | 36,339,840                       | OFFLINE      | 0.00                          |
| 15   | 36,339,840                       | OFFLINE      | 0.00                          |
| 16   | 36,339,840                       | OFFLINE      | 0.00                          |

| Date | Circulation<br>Rate<br>(gal/day) | TDS<br>(ppm) | PM <sub>10</sub><br>(lbs/day) |
|------|----------------------------------|--------------|-------------------------------|
| 17   | 36,339,840                       | OFFLINE      | 0.00                          |
| 18   | 36,339,840                       | OFFLINE      | 0.00                          |
| 19   | 36,339,840                       | OFFLINE      | 0.00                          |
| 20   | 36,339,840                       | OFFLINE      | 0.00                          |
| 21   | 36,339,840                       | OFFLINE      | 0.00                          |
| 22   | 36,339,840                       | OFFLINE      | 0.00                          |
| 23   | 36,339,840                       | OFFLINE      | 0.00                          |
| 24   | 36,339,840                       | OFFLINE      | 0.00                          |
| 25   | 36,339,840                       | OFFLINE      | 0.00                          |
| 26   | 36,339,840                       | OFFLINE      | 0.00                          |
| 27   | 36,339,840                       | OFFLINE      | 0.00                          |
| 28   | 36,339,840                       | OFFLINE      | 0.00                          |
| 29   | 36,339,840                       | OFFLINE      | 0.00                          |
| 30   | 36,339,840                       | OFFLINE      | 0.00                          |
| 31   | 36,339,840                       | OFFLINE      | 0.00                          |
|      |                                  |              |                               |

Table 2-5

# Heorot Power Management Malburg Generating Station Diesel Fuel Fired Emergency Firewater Pump Testing Times During Quarter 4, 2018

| Date          | Time  | Main / Test<br>Emerg. | Hours of<br>Operation | Fuel Used<br>(gals) | Initials |  |
|---------------|-------|-----------------------|-----------------------|---------------------|----------|--|
| Oct. 08, 2018 | 23:29 | Testing               | 0.4                   | 3.6                 | JPFO     |  |
| Oct. 14, 2018 | 23:28 | Testing               | 0.5                   | 4.5                 | JAFO     |  |
| Oct. 21, 2018 | 23:28 | Testing               | 0.5                   | 4.5                 | VFFO     |  |
| Oct. 28, 2018 | 23:24 | Testing               | 0.6                   | 5.4                 | STFO     |  |
| Nov. 04, 2018 | 23:10 | Testing               | 0.4                   | 3.6                 | JPFO     |  |
| Nov. 11, 2018 | 23:17 | Testing               | 0.5                   | 4.5                 | STFO     |  |
| Nov. 18, 2018 | 23:23 | Testing               | 0.5                   | 4.5                 | STFO     |  |
| Nov. 25, 2018 | 23:15 | Testing               | 0.5                   | 4.5                 | MFFO     |  |
| Dec. 02, 2018 | 00:00 | DNR                   | 0.0                   | 0.0                 | 0        |  |
| Dec. 09, 2018 | 00:00 | DNR                   | 0.0                   | 0.0                 | 0        |  |
| Dec. 16, 2018 | 23:24 | Testing               | 0.6                   | 5.4                 | STFO     |  |
| Dec. 23, 2018 | 23:25 | Testing               | 0.5                   | 4.5                 | SCTFO    |  |
| Dec. 30, 2018 | 23:30 | Testing               | 0.4                   | 3.6                 | JPO      |  |

Note: Event 'DNR' - Did Not Run

Table 2-6

### AQ-C10 Emission Limits, lbs/hr

| Pollutant        | Gas Turbines<br>(2) | Cooling<br>Tower | Firewater Pump | Facility Total |
|------------------|---------------------|------------------|----------------|----------------|
| CO               | 140                 |                  | 0.59           | 140            |
| NOx              | 55                  | -                | 1.73           | 55             |
| PM <sub>10</sub> | 7.78                | 0.26             | 0.08           | 8.12           |
| VOC              | 3.3                 |                  | 0.05           | 3.35           |
| SOx              | 0.3                 |                  | 0.002          | 0.3            |
| Ammonia          | 7.6                 |                  |                | 7.6            |

Table 2-7

### AQ-C10 Emission Limits, Ibs/day

| Pollutant        | Gas Turbines<br>(2) | Cooling<br>Tower | Firewater Pump | Facility Total |
|------------------|---------------------|------------------|----------------|----------------|
| CO               | 245                 |                  | 0.59           | 245            |
| NOx              | 230                 |                  | 1.73           | 230            |
| PM <sub>10</sub> | 158                 | 6.2              | 0.08           | 164.28         |
| VOC              | 36                  |                  | 0.05           | 36.05          |
| SOx              | 6                   |                  | 0.002          | 6              |
| Ammonia          | 182.4               |                  |                | 182.4          |

#### Table 2-8

### Malburg Generating Station Maximum Hourly Emissions During Quarter 4, 2018

| Contaminant | Gas Turbines (2) |          | Cooling Tower |          | Firewate       | Firewater Pump |       |  |
|-------------|------------------|----------|---------------|----------|----------------|----------------|-------|--|
| Contaminant | Date & Hour      | Emission | Date & Hour   | Emission | Date & Hour    | Emission       | Total |  |
| CO lbs      | 11/10/18 17:00   | 31.96    | N/A           | N/A      | 10/28/18 23:24 | 0.092          | 32.05 |  |
| NOx lbs     | 11/17/18 16:00   | 31.70    | N/A           | N/A      | 10/28/18 23:24 | 0.918          | 32.62 |  |
| PM lbs      | 11/27/18 12:00   | 6.47     | 10/14/2018    | 0.06     | 10/28/18 23:24 | 0.022          | 6.55  |  |
| VOC lbs     | 11/27/18 12:00   | 1.43     | N/A           | N/A      | 10/28/18 23:24 | 0.022          | 1.45  |  |
| SO2 lbs     | 10/20/18 17:00   | 0.24     | N/A           | N/A      | 10/28/18 23:24 | 0.002          | 0.24  |  |
| NH3 lbs     | 11/13/18 20:00   | 7.49     | N/A           | N/A      | 10/28/18 23:24 |                | 7.49  |  |

a: Although the maximum gas turbines, cooling tower, and firewater pump emissions did not occur during the same hour, the facility total equals the sum of each device's maximum hourly emissions.

#### Table 2-9

### Malburg Generating Station Maximum Daily Emissions During Quarter 4, 2018

| Contaminant | Gas Turb    | Gas Turbines (2) Cooling Tower |             | Firewate | Firewater Pump |          |        |
|-------------|-------------|--------------------------------|-------------|----------|----------------|----------|--------|
| Contaminant | Date & Hour | Emission                       | Date & Hour | Emission | Date & Hour    | Emission | Total  |
| CO lbs      | 11/17/2018  | 72.76                          | N/A         | N/A      | 10/28/18 23:24 | 0.092    | 72.85  |
| NOx lbs     | 11/17/2018  | 118.92                         | N/A         | N/A      | 10/28/18 23:24 | 0.918    | 119.84 |
| PM lbs      | 11/27/2018  | 126.46                         | 10/14/2018  | 1.51     | 10/28/18 23:24 | 0.022    | 127.99 |
| VOC lbs     | 11/27/2018  | 27.83                          | N/A         | N/A      | 10/28/18 23:24 | 0.022    | 27.85  |
| SO2 lbs     | 11/27/2018  | 4.77                           | N/A         | N/A      | 10/28/18 23:24 | 0.002    | 4.77   |
| NH3 lbs     | 11/13/2018  | 145.20                         | N/A         | N/A      | 10/28/18 23:24 |          | 145.20 |

a: Although the maximum gas turbines, cooling tower, and firewater pump emissions did not occur during the same hour, the facility total equals the sum of each device's maximum hourly emissions.

### **Table 2-10**

### Malburg Generating Station 2018 Annual Emissions for MGS

| Contaminant | Gas Turbines (2) | Cooling Tower | Firewater Pump | Facility |
|-------------|------------------|---------------|----------------|----------|
| CO lbs      | 9975             | N/A           | 13.37          | 9988     |
| NOx lbs     | 28810            | N/A           | 95.41          | 28905    |
| PM10 lbs    | 29679            | 492           | 6.09           | 30177    |
| VOC lbs     | 6322             | N/A           | 7.49           | 6330     |
| SOx lbs     | 1091             | N/A           | 2.20           | 1093     |
| NH3 lbs     | 20678            | N/A           | N/A            | 20678    |

**Table 2-11** 

### Malburg Generating Station Total Monthly Emissions Oct-2018

| Contaminant | Gas Turbines (2) |
|-------------|------------------|
| CO lbs      | 972              |
| PM lbs      | 3,239            |
| VOC lbs     | 712              |
| SOx lbs     | 123              |

**Table 2-12** 

### Malburg Generating Station Total Monthly Emissions Nov-2018

| Gas Turbines (2) |
|------------------|
| 1,015            |
| 3,245            |
| 714              |
| 123              |
|                  |

**Table 2-13** 

### Malburg Generating Station Total Monthly Emissions Dec-2018

| Contaminant | Gas Turbines (2) |
|-------------|------------------|
| CO lbs      | 66               |
| PM lbs      | 209              |
| VOC lbs     | 46               |
| SOx lbs     | 8                |

**Table 2-14** 

### Malburg Generating Station Combustion Turbines Startup and Shutdown Events During Quarter 4, 2018

| Date                                   | Device            | Startup Duration (hrs:min) | Shutdown Duration (hrs:min) | Code |
|--|-------------------|----------------------------|-----------------------------|------|
| 11/16/2018                             | CT1               |                            | :30                         |      |
| 11/17/2018                             | CT1               | 1:30                       |                             |      |
| 12/02/2018                             | CT1               |                            | :30                         |      |
|  |                   |                            |                             |      |
|  |                   |                            |                             |      |
| 10/01/2018<br>10/02/2018               | CT2<br>CT2        | 1:30                       | :30                         |      |
|  | CT2               | 1:30                       | :30                         |      |
| 10/02/2018                             |                   | 1:30                       |                             |      |
| 10/02/2018<br>10/15/2018               | CT2<br>CT2        |                            |                             |      |
| 10/02/2018<br>10/15/2018<br>10/16/2018 | CT2<br>CT2<br>CT2 |                            | :30                         |      |

<sup>\*</sup>Trip

\*\*Testing under Variance Conditions
U=Unsuccessful Start

W=Warm Start 1 trip

C=Cold Start

**Table 2-15** 

## Malburg Generating Station Combustion Turbines and Duct Burner Gas Usage During Quarter 4,2018

| Month  | CT-1 / DB-1 Gas Usage (mmscf) | CT-2 / DB-2 Gas Usage (mmscf) |
|--------|-------------------------------|-------------------------------|
| Oct-18 | 226.51                        | 211.36                        |
| Nov-18 | 219.65                        | 219.10                        |
| Dec-18 | 14.15                         | 14.14                         |

### **Table 2-17**

### Malburg Generating Station Diesel Fuel Usages

### Year 2018

|           | Ho          | ours of Operati | on        | Fuel Used | Emi   | ssions | Factor ( | lbs/Mga | al)  |
|-----------|-------------|-----------------|-----------|-----------|-------|--------|----------|---------|------|
|           |             |                 |           | 9 gal/hr  | NOX   | SOX    | CO       | PM10    | VOC  |
| Month     | Maintenance | Testing         | Emergency | (gals)    | 469   | 11     | 66.9     | 30.5    | 37.5 |
| January   | 0.0         | 2.0             | 0.0       | 18.0      | 8.44  | 0.20   | 1.20     | 0.55    | 0.68 |
| February  | 0.0         | 1.7             | 0.0       | 15.3      | 7.18  | 0.17   | 1.02     | 0.47    | 0.57 |
| March     | 0.0         | 1.0             | 0.0       | 9.0       | 4.22  | 0.10   | 0.60     | 0.27    | 0.34 |
| April     | 0.0         | 1.5             | 0.0       | 13.5      | 6.33  | 0.15   | 0.90     | 0.41    | 0.51 |
| May       | 0.0         | 2.0             | 0.0       | 18.0      | 8.44  | 0.20   | 1.20     | 0.55    | 0.68 |
| June      | 0.0         | 2.1             | 0.0       | 18.9      | 8.86  | 0.21   | 1.26     | 0.58    | 0.71 |
| July      | 0.0         | 2.5             | 0.0       | 22.5      | 10.55 | 0.25   | 1.51     | 0.69    | 0.84 |
| August    | 0.0         | 1.5             | 0.0       | 13.5      | 6.33  | 0.15   | 0.90     | 0.41    | 0.51 |
| September | 0.0         | 2.5             | 0.0       | 22.5      | 10.55 | 0.25   | 1.51     | 0.69    | 0.84 |
| October   | 0.0         | 2.0             | 0.0       | 18.0      | 8.44  | 0.20   | 1.20     | 0.55    | 0.67 |
| November  | 0.0         | 1.9             | 0.0       | 17.1      | 8.02  | 0.19   | 1.14     | 0.52    | 0.64 |
| December  | 0.0         | 1.5             | 0.0       | 13.5      | 6.33  | 0.15   | 0.90     | 0.41    | 0.51 |
| TOTAL     | 0.0         | 22.2            | 0.0       | 199.8     | 93.71 | 2.20   | 13.37    | 6.09    | 7.49 |

Note: Operations for maintenance and testing shall not exceed 50 hours in any one calendar year per air permit condition C1.5 (Sec. H, pg. 16)

Table 2-18
Yearly Water Use Totals

|      | Reclaim Water Used |            |             |  |  |  |  |  |  |  |  |
|------|--------------------|------------|-------------|--|--|--|--|--|--|--|--|
| Year | (gal)              | (cu. ft.)  | (acre-feet) |  |  |  |  |  |  |  |  |
| 2018 | 183,802,933        | 24,569,300 | 564.034     |  |  |  |  |  |  |  |  |
| 2017 | 233,471,537        | 31,208,600 | 716.451     |  |  |  |  |  |  |  |  |
| 2016 | 260,574,452        | 34,831,500 | 799.621     |  |  |  |  |  |  |  |  |
| 2015 | 249,217,545        | 33,313,400 | 764.770     |  |  |  |  |  |  |  |  |
| 2014 | 286,933,755        | 38,355,000 | 880.510     |  |  |  |  |  |  |  |  |
| 2013 | 257,708,480        | 34,448,400 | 790.826     |  |  |  |  |  |  |  |  |
| 2012 | 231,756,143        | 30,979,300 | 711.187     |  |  |  |  |  |  |  |  |

Average

257,238,075

|      | Potable Water Used |           |             |  |  |  |  |  |  |  |  |
|------|--------------------|-----------|-------------|--|--|--|--|--|--|--|--|
| Year | (gal)              | (cu. ft.) | (acre-feet) |  |  |  |  |  |  |  |  |
| 2018 | 70,321             | 9,400     | 0.216       |  |  |  |  |  |  |  |  |
| 2017 | 1,220,899          | 163,200   | 3.747       |  |  |  |  |  |  |  |  |
| 2016 | 195,254            | 26,100    | 0.599       |  |  |  |  |  |  |  |  |
| 2015 | 412,203            | 55,100    | 1.265       |  |  |  |  |  |  |  |  |
| 2014 | 58,352             | 7,800     | 0.179       |  |  |  |  |  |  |  |  |
| 2013 | 0                  | 0         | 0.000       |  |  |  |  |  |  |  |  |
| 2012 | 3,288,648          | 439,600   | 10.092      |  |  |  |  |  |  |  |  |

Average

790,891

**Table 2-19** 

### Malburg Generating Station Potable Water Usage

Year: 2018

| Mandh           |        | Water Use | ed          | Average Water  | Days used              |
|-----------------|--------|-----------|-------------|----------------|------------------------|
| Month           | (gal)  | (cu. ft.) | (acre-feet) | Usage<br>(gpd) | For<br>Process Cooling |
| JANUARY         | 0      | 0         | 0.000       | 0              | 0.0                    |
| FEBRUARY        | 748    | 100       | 0.002       | 30             | 0.0                    |
| MARCH           | 15,710 | 2,100     | 0.048       | 510            | 0.0                    |
| APRIL           | 8,977  | 1,200     | 0.028       | 300            | 0.0                    |
| MAY             | 2,244  | 300       | 0.007       | 70             | 0.0                    |
| JUNE            | 748    | 100       | 0.002       | 20             | 0.0                    |
| JULY            | 32,916 | 4,400     | 0.101       | 1,060          | 0.0                    |
| AUGUST          | 2,992  | 400       | 0.009       | 100            | 0.0                    |
| SEPTEMBER       | 1,496  | 200       | 0.005       | 50             | 0.0                    |
| OCTOBER         | 1,496  | 200       | 0.005       | 50             | 0.0                    |
| NOVEMBER        | 1,496  | 200       | 0.005       | 50             | 0.0                    |
| DECEMBER        | 1,496  | 200       | 0.005       | 50             | 0.0                    |
| Yearly TOTAL    | 70,319 | 9,400     | 0.22        |                | 0.0                    |
| MONTHLY AVERAGE | 6,000  | 783       | 0.018       |                |                        |

**Table 2-20** 

### Malburg Generating Station Reclaimed Water Usage During 2018

| Month           |             |            | Average Water<br>Usage |         |
|-----------------|-------------|------------|------------------------|---------|
|                 | (gal)       | (cu. ft.)  | (acre-feet)            | (gpd)   |
| JANUARY         | 18,839,402  | 2,518,300  | 57.81                  | 607,720 |
| FEBRUARY        | 19,688,496  | 2,631,800  | 60.42                  | 703,160 |
| MARCH           | 6,047,640   | 808,400    | 18.56                  | 195,090 |
| APRIL           | 2,947,514   | 394,000    | 9.04                   | 98,250  |
| MAY             | 9,894,371   | 1,322,600  | 30.36                  | 319,170 |
| JUNE            | 15,030,825  | 2,009,200  | 46.12                  | 501,030 |
| JULY            | 21,694,152  | 2,899,900  | 66.57                  | 699,810 |
| AUGUST          | 20,070,775  | 2,682,900  | 61.59                  | 647,440 |
| SEPTEMBER       | 19,636,129  | 2,624,800  | 60.26                  | 654,540 |
| OCTOBER         | 22,187,150  | 2,965,800  | 68.09                  | 715,710 |
| NOVEMBER        | 19,748,344  | 2,639,800  | 60.60                  | 658,280 |
| DECEMBER        | 8,018,136   | 1,071,800  | 24.61                  | 258,650 |
| Yearly TOTAL    | 183,802,934 | 24,569,300 | 564.03                 |         |
| MONTHLY AVERAGE | 15,317,000  | 2,047,442  | 47.003                 | 504,900 |

## FIGURE 2-1 Chevron GST Oil Specifications

V. A)

SC Fuels P.O. Box 14237 Orange, CA 92863-1237 Tel: 800-659-5823 Fax: 714-992-7377

Fax: 714-992-7377
Credit Inquiries: 888-364-0121

DELIVERY TICKET



Order#: 1291140 Order Date: 10/25/2018 Delv Req Date: 10/29/2018 Sales Person: 0177 - Todd Cripps

SOLD TO: 01-0001084 COLORADO ENERGY MANAGEMENT LLC ATTN: ACCOUNTS PAYABLE 4963 S. SOTO STREET VERNON, CA 90058 (323) 476-3622 SHIP TO: 1L COLORADO ENERGY MANAGEMENT LLC 4963 SOTO STREET VERNON, CA 90058 (323) 476-3632

Confirm To: ASHLEY HURD

Customer PO: MGS14841

Ship Via:

Whse: 101

Terms: N30

| НМ | Product Code / Desc / Svc Type                              | Qty Ordered / Package De | esc Ext Qty Ordered | Qty Delivered | Unit Price | Extended Amount |
|----|---|--------------------------|---------------------|---------------|------------|-----------------|
| x  | UN1202, DIESEL FUEL, NONTAXABLE<br>PENALITY FOR TAXABLE USE | USE ONLY,                |                     | 2/66          |            |                 |
|    | 422D055 30<br>CARB ULTRA L.S. DYED DIESEL                   | 2.00 55 GAL DRM          | 110.00 GALS         | dear 50       | 3.79000    | 416.90          |
|    | Federal Lust  |                          |                     |               | 0.00100    | 0.11            |
|    | Federal Oil Spill   |                          |                     |               | 0.00214    | 0.24            |
| -  | CA - AB 32 - DSL  |                          |                     |               | 0.00271    | 0.30            |
|    |   |                          |                     | 1/55          | 3.79585    | 417.55          |
|    | CH235120981D055 30  | 1.00 55 GAL DRM          | 55.00 GALS          | 1123          | 13.93000   | 766.15          |
|    | DELO 400 SAE 40 55G   |                          |                     |               |            |                 |
|    | CA Oil Recycling Fee  |                          |                     |               | 0.24000    | 13.20           |
|    | CA Lube Fee   |                          |                     |               | 0.05000    | 2.75            |
|    |   |                          |                     |               | 14.22000   | 782.10          |
|    | DRUMDEPOSITC001 30 DRUM DEPOSIT FEE                         | 3.00 MISC CHRG           | 3.00 EACH           | 3.0           | 25.00000   | 75.00           |
|    | /FUELCH 30<br>FUEL SURCHARGE                                |                          | 0.00                |               |            | 9.92            |
|    | /RCF 30  REGULATORY COMPLIANCE FEE                          |                          | 0.00                |               |            | 12.95           |
|    |   |                          |                     |               |            |                 |



## CHEVRON GST® OILS ISO 32, 46, 68, 100

### **CUSTOMER BENEFITS**

Chevron GST Oils deliver value through:

- Superior oxidation stability for long service life at elevated temperatures.
- · Rust and corrosion protection
- High viscosity index assures minimum viscosity change when variations in temperature occur.
- Minimum foam prevents sump overflow or erratic governor operation.
- Fast air release minimizes possibility of pump cavitation in systems with high circulation rates and small reservoirs.
- Superior thermal stability minimizes deposit formation.
- Rapid water separation keeps water in oil to a minimum
- Hydraulic fluid service Chevron GST Oils ISO 32, 46, and 68 are excellent hydraulic fluids in low pressure systems up to 1000 psi.
- Air compressor lubricant when OEM recommends R&O type oil.
- Environmental benefits All grades are ashless.
   This facilitates reclaiming and recycling of the used oils. Chevron GST Oils are not expected to be harmful to aquatic organisms.

### **FEATURES**

Chevron GST Oils are designed to meet the critical demands of:



- gas, steam, and hydroelectric turbine bearing lubrication
- · reduction gear lubrication in marine operations

They are an excellent recommendation for many other industrial applications including air compression.

Chevron GST Oils are formulated with ISOSYN® base stocks.

Higher temperatures in advanced gas and steam turbines require a circulating system oil with exceptional high temperature stability. Chevron GST Oils have outstanding **thermal and oxidation stability**.

Nonvolatile **oxidation inhibition** minimizes the evaporative loss of the inhibitors, a common problem with turbine oils where bearing temperatures are high and system capacities are limited. With retained oxidation resistance for long periods under high temperature conditions, Chevron GST Oils have proven they will provide longer oil service life and reduced turbine down time.

**Corrosion inhibition** protects costly turbine shafts and gears from corrosion and rusting.

Chevron GST Oils have excellent demulsibility characteristics which allow these oils to maintain a high film strength coating on critical wear points of bearings and gear reducers and assure fast removal of water contamination.

**Foam inhibition** prevents sump overflow and erratic governor operation.

### **APPLICATIONS**

Chevron GST Oils are recommended for use in turbines of all types including gas, steam, and hydroelectric turbines, and marine gear turbine sets.

The following viscosity grades are formulated to meet the specified OEM requirements:

### **Chevron GST Oil ISO 32**

- · meets and exceeds
  - General Electric GEK-32568f, GEK 28143A, GEK-46506D, GEK-27070
  - Ingersoll Rand specification for Centac Centrifugal Compressors
  - Solar ES 9 224 requirements for gas turbine oils
  - ASTM D4304, British Standard 489, and DIN 51515 standard organization requirements for new lubricants used in gas and steam turbines and auxiliary equipment
- · is approved by
  - Cincinnati Machine P-38
  - Alstom Power HTGD 90117
  - Siemens Westinghouse M spec 55125Z3
  - Siemens TLV 901304

### **Chevron GST Oil ISO 46**

- meets
  - General Electric and Westinghouse requirements for marine gas turbine system oils. Recommended by Siemens Westinghouse for reactor coolant pump motor bearings.
  - Siemens TLV 901304
  - Solar ES 9 224 requirements for gas turbine oils
  - ASTM D4304, British Standard 489, and DIN 51515 standard organization requirements for new lubricants used in gas and steam turbines and auxiliary equipment
- · is approved by
  - Cincinnati Machine P 55
  - Alstom Power HTGD 90117

#### **Chevron GST Oil ISO 68**

- · meets
  - meets General Electric, Alstom, Westinghouse, and other OEM requirements for hydroelectric turbines, land and marine steam turbines, and associated reduction gears
  - ASTM D4304, British Standard 489, and DIN 51515 standard organization requirements for new lubricants used in gas and steam turbines and auxiliary equipment
- · is approved by
  - Cincinnati Machine P-54

### **Chevron GST Oil ISO 100**

- meets
  - meets General Electric, Alstom, Westinghouse, and other OEM requirements for hydroelectric turbines, land and marine steam turbines, and associated reduction gears
  - ASTM D4304, British Standard 489, and DIN 51515 standard organization requirements for new lubricants used in gas and steam turbines and auxiliary equipment

Chevron GST Oils ISO 32, 46, 68, and 100 are registered with NSF and are acceptable as lubricants where there is no possibility of food contact (H2) in and around food processing areas. The NSF Nonfood Compounds Registration Program is a continuation of the USDA product approval and listing program, which is based on meeting regulatory requirements of appropriate use, ingredient review and labeling verification.

Do not use in high pressure systems in the vicinity of flames, sparks and hot surfaces. Use only in well ventilated areas. Keep container closed.

Do not use in breathing air apparatus or medical equipment

### TYPICAL TEST DATA

| ISO Grade  | 32             | 46             | 68             | 100            |
|--|----------------|----------------|----------------|----------------|
| CPS Number   | 253026         | 253027         | 253028         | 253029         |
| MSDS Number  | 6710           | 6710           | 6710           | 6710           |
| AGMA Grade   | _              | 1              | 2              | 3              |
| API Gravity  | 32.7           | 32.0           | 31.7           | 31.4           |
| Viscosity, Kinematic<br>cSt at 40°C<br>cSt at 100°C                  | 30.4<br>5.2    | 43.7<br>6.6    | 64.6<br>8.5    | 95.0<br>11.0   |
| Viscosity, Saybolt<br>SUS at 100°F<br>SUS at 210°F                   | 157<br>43.8    | 225<br>48.2    | 334<br>54.8    | 495<br>63.9    |
| Viscosity Index  | 102            | 101            | 102            | 100            |
| Flash Point,°C(°F)   | 222(432)       | 224(435)       | 245(473)       | 262(504)       |
| Pour Point, °C(°F)   | -36(-33)       | -36(-33)       | -33(-27)       | -30(-22)       |
| Oxidation Stability ASTM D 943 <sup>1</sup> ASTM D 2272 <sup>2</sup> | 17,000<br>1700 | 12,000<br>1400 | 11,000<br>1400 | 11,000<br>1400 |
| FZG, Pass stage, DIN 51354   | _              | _              | _              | _              |

Typical test data are average values only. Minor variations which do not affect product performance are to be expected in normal manufacturing.

<sup>1</sup> Hours to 2.0 mg KOH/g acid number modified D943

<sup>2</sup> Minutes to 25 psi pressure drop

## Figure 2-2 Cooling Tower PM10 Guidance

### Calculating Realistic PM<sub>10</sub> Emissions from Cooling Towers

Abstract No. 216 Session No. AM-1b

### Joel Reisman and Gordon Frisbie

Greystone Environmental Consultants, Inc., 650 University Avenue, Suite 100, Sacramento, California 95825

### **ABSTRACT**

Particulate matter less than 10 micrometers in diameter ( $PM_{10}$ ) emissions from wet cooling towers may be calculated using the methodology presented in EPA's AP-42<sup>1</sup>, which assumes that all total dissolved solids (TDS) emitted in "drift" particles (liquid water entrained in the air stream and carried out of the tower through the induced draft fan stack.) are  $PM_{10}$ . However, for wet cooling towers with medium to high TDS levels, this method is overly conservative, and predicts significantly higher  $PM_{10}$  emissions than would actually occur, even for towers equipped with very high efficiency drift eliminators (e.g., 0.0006% drift rate). Such overprediction may result in unrealistically high  $PM_{10}$  modeled concentrations and/or the need to purchase expensive Emission Reduction Credits (ERCs) in  $PM_{10}$  non-attainment areas. Since these towers have fairly low emission points (10 to 15 m above ground), over-predicting  $PM_{10}$  emission rates can easily result in exceeding federal Prevention of Significant Deterioration (PSD) significance levels at a project's fenceline. This paper presents a method for computing realistic  $PM_{10}$  emissions from cooling towers with medium to high TDS levels.

### INTRODUCTION

Cooling towers are heat exchangers that are used to dissipate large heat loads to the atmosphere. Wet, or evaporative, cooling towers rely on the latent heat of water evaporation to exchange heat between the process and the air passing through the cooling tower. The cooling water may be an integral part of the process or may provide cooling via heat exchangers, for example, steam condensers. Wet cooling towers provide direct contact between the cooling water and air passing through the tower, and as part of normal operation, a very small amount of the circulating water may be entrained in the air stream and be carried out of the tower as "drift" droplets. Because the drift droplets contain the same chemical impurities as the water circulating through the tower, the particulate matter constituent of the drift droplets may be classified as an emission. The magnitude of the drift loss is influenced by the number and size of droplets produced within the tower, which are determined by the tower fill design, tower design, the air and water patterns, and design of the drift eliminators.

### AP-42 METHOD OF CALCULATING DRIFT PARTICULATE

EPA's AP-42<sup>1</sup> provides available particulate emission factors for wet cooling towers, however, these values only have an emission factor rating of "E" (the lowest level of confidence acceptable). They are also rather high, compared to typical present-day manufacturers' guaranteed drift rates, which are on the order of 0.0006%. (Drift emissions are typically

expressed as a percentage of the cooling tower water circulation rate). AP-42 states that "a *conservatively high* PM<sub>10</sub> emission factor can be obtained by (a) multiplying the total liquid drift factor by the TDS fraction in the circulating water, and (b) assuming that once the water evaporates, all remaining solid particles are within the PM<sub>10</sub> range." (Italics per EPA).

If TDS data for the cooling tower are not available, a source-specific TDS content can be estimated by obtaining the TDS for the make-up water and multiplying it by the cooling tower cycles of concentration. [The cycles of concentration is the ratio of a measured parameter for the cooling tower water (such as conductivity, calcium, chlorides, or phosphate) to that parameter for the make-up water.]

Using AP-42 guidance, the total particulate emissions (PM) (after the pure water has evaporated) can be expressed as:

$$PM = Water Circulation Rate x Drift Rate x TDS$$
 [1]

For example, for a typical power plant wet cooling tower with a water circulation rate of 146,000 gallons per minute (gpm), drift rate of 0.0006%, and TDS of 7,700 parts per million by weight (ppmw):

 $PM = 146,000 \text{ gpm x } 8.34 \text{ lb water/gal x } 0.0006/100 \text{ x } 7,700 \text{ lb solids/} 10^6 \text{ lb water x } 60 \text{ min/hr} = 3.38 \text{ lb/hr}$ 

On an annual basis, this is equivalent to almost 15 tons per year (tpy). Even for a state-of-the-art drift eliminator system, this is not a small number, especially if assumed to all be equal to  $PM_{10}$ , a regulated criteria pollutant. However, as the following analysis demonstrates, only a very small fraction is actually  $PM_{10}$ .

### COMPUTING THE PM<sub>10</sub> FRACTION

Based on a representative drift droplet size distribution and TDS in the water, the amount of solid mass in each drop size can be calculated. That is, for a given initial droplet size, assuming that the mass of dissolved solids condenses to a spherical particle after all the water evaporates, and assuming the density of the TDS is equivalent to a representative salt (e.g., sodium chloride), the diameter of the final solid particle can be calculated. Thus, using the drift droplet size distribution, the percentage of drift mass containing particles small enough to produce  $PM_{10}$  can be calculated. This method is conservative as the final particle is assumed to be perfectly spherical; hence as small a particle as can exist.

The droplet size distribution of the drift emitted from the tower is critical to performing the analysis. Brentwood Industries, a drift eliminator manufacturer, was contacted and agreed to provide drift eliminator test data from a test conducted by Environmental Systems Corporation (ESC) at the Electric Power Research Institute (EPRI) test facility in Houston, Texas in 1988 (Aull<sup>2</sup>, 1999). The data consist of water droplet size distributions for a drift eliminator that achieved a tested drift rate of 0.0003 percent. As we are using a 0.0006 percent drift rate, it is reasonable to expect that the 0.0003 percent drift rate would produce smaller droplets, therefore,

this size distribution data can be assumed to be <u>conservative</u> for predicting the fraction of  $PM_{10}$  in the total cooling tower PM emissions.

In calculating  $PM_{10}$  emissions the following assumptions were made:

- Each water droplet was assumed to evaporate shortly after being emitted into ambient air, into a single, solid, spherical particle.
- Drift water droplets have a density  $(\rho_w)$  of water; 1.0 g/cm<sup>3</sup> or 1.0 \* 10<sup>-6</sup>  $\mu$ g /  $\mu$ m<sup>3</sup>.
- The solid particles were assumed to have the same density  $(\rho_{TDS})$  as sodium chloride, (i.e., 2.2 g/cm<sup>3</sup>).

Using the formula for the volume of a sphere,  $V = 4\pi r^3/3$ , and the density of pure water,  $\rho_w = 1.0 \text{ g/cm}^3$ , the following equations can be used to derive the solid particulate diameter,  $D_p$ , as a function of the TDS, the density of the solids, and the initial drift droplet diameter,  $D_d$ :

Volume of drift droplet = 
$$(4/3)\pi(D_d/2)^3$$
 [2]

Mass of solids in drift droplet = (TDS)( $\rho_w$ )(Volume of drift droplet) [3]

substituting,

Mass of solids in drift = 
$$(TDS)(\rho_w)(4/3)\pi(D_d/2)^3$$
 [4]

Assuming the solids remain and coalesce after the water evaporates, the mass of solids can also be expressed as:

Mass of solids = 
$$(\rho_{TDS})$$
 (solid particle volume) =  $(\rho_{TDS})(4/3)\pi(D_p/2)^3$  [5]

Equations [4] and [5] are equivalent:

$$(\rho_{\text{TDS}})(4/3)\pi(D_{p}/2)^{3} = (\text{TDS})(\rho_{w})(4/3)\pi(D_{d}/2)^{3}$$
 [6]

Solving for D<sub>p</sub>:

$$D_{p} = D_{d} [(TDS)(\rho_{w}/\rho_{TDS})]^{1/3}$$
 [7]

Where,

TDS is in units of ppmw

 $D_p$  = diameter of solid particle, micrometers ( $\mu m$ )

 $D_d$  = diameter of drift droplet,  $\mu$ m

Using formulas [2] – [7] and the particle size distribution test data, Table 1 can be constructed for drift from a wet cooling tower having the same characteristics as our example; 7,700 ppmw TDS and a 0.0006% drift rate. The first and last columns of this table are the particle size distribution derived from test results provided by Brentwood Industries. Using straight-line interpolation for a solid particle size 10  $\mu$ m in diameter, we conclude that approximately 14.9 percent of the mass emissions are equal to or smaller than PM<sub>10</sub>. The balance of the solid

particulate are particulate greater than 10  $\mu$ m. Hence, PM<sub>10</sub> emissions from this tower would be equal to PM emissions x 0.149, or 3.38 lb/hr x 0.149 = 0.50 lb/hr. The process is repeated in Table 2, with all parameters equal except that the TDS is 11,000 ppmw. The result is that approximately 5.11 percent are smaller at 11,000 ppm. Thus, while total PM emissions are larger by virtue of a higher TDS, overall PM<sub>10</sub> emissions are actually lower, because more of the solid particles are larger than 10  $\mu$ m.

Table 1. Resultant Solid Particulate Size Distribution (TDS = 7700 ppmw)

| <b>EPRI Droplet</b> | Droplet                       | Droplet Mass | Particle Mass    | Solid Particle                    | Solid Particle | EPRI % Mass |
|---------------------|-------------------------------|--------------|------------------|-----------------------------------|----------------|-------------|
| Diameter            | Volume                        | ()           | (Solids)         | Volume                            | Diameter       | Smaller     |
| $(\mu_{ m Im})$     | $\left(\mu \text{m}^3\right)$ | (μg)<br>[3]  | $(\mu_{\! m g})$ | $\left(\mu \mathrm{m}^{3}\right)$ | $(\mu m)$      |             |
|                     | [2]¹                          |              | [4]              |                                   | [7]            |             |
| 10                  | 524                           | 5.24E-04     | 4.03E-06         | 1.83                              | 1.518          | 0.000       |
| 20                  | 4189                          | 4.19E-03     | 3.23E-05         | 14.66                             | 3.037          | 0.196       |
| 30                  | 14137                         | 1.41E-02     | 1.09E-04         | 49.48                             | 4.555          | 0.226       |
| 40                  | 33510                         | 3.35E-02     | 2.58E-04         | 117.29                            | 6.073          | 0.514       |
| 50                  | 65450                         | 6.54E-02     | 5.04E-04         | 229.07                            | 7.591          | 1.816       |
| 60                  | 113097                        | 1.13E-01     | 8.71E-04         | 395.84                            | 9.110          | 5.702       |
| 70                  | 179594                        | 1.80E-01     | 1.38E-03         | 628.58                            | 10.628         | 21.348      |
| 90                  | 381704                        | 3.82E-01     | 2.94E-03         | 1335.96                           | 13.665         | 49.812      |
| 110                 | 696910                        | 6.97E-01     | 5.37E-03         | 2439.18                           | 16.701         | 70.509      |
| 130                 | 1150347                       | 1.15E+00     | 8.86E-03         | 4026.21                           | 19.738         | 82.023      |
| 150                 | 1767146                       | 1.77E+00     | 1.36E-02         | 6185.01                           | 22.774         | 88.012      |
| 180                 | 3053628                       | 3.05E+00     | 2.35E-02         | 10687.70                          | 27.329         | 91.032      |
| 210                 | 4849048                       | 4.85E+00     | 3.73E-02         | 16971.67                          | 31.884         | 92.468      |
| 240                 | 7238229                       | 7.24E+00     | 5.57E-02         | 25333.80                          | 36.439         | 94.091      |
| 270                 | 10305995                      | 1.03E+01     | 7.94E-02         | 36070.98                          | 40.994         | 94.689      |
| 300                 | 14137167                      | 1.41E+01     | 1.09E-01         | 49480.08                          | 45.549         | 96.288      |
| 350                 | 22449298                      | 2.24E+01     | 1.73E-01         | 78572.54                          | 53.140         | 97.011      |
| 400                 | 33510322                      | 3.35E+01     | 2.58E-01         | 117286.13                         | 60.732         | 98.340      |
| 450                 | 47712938                      | 4.77E+01     | 3.67E-01         | 166995.28                         | 68.323         | 99.071      |
| 500                 | 65449847                      | 6.54E+01     | 5.04E-01         | 229074.46                         | 75.915         | 99.071      |
| 600                 | 113097336                     | 1.13E+02     | 8.71E-01         | 395840.67                         | 91.098         | 100.000     |

<sup>&</sup>lt;sup>1</sup> Bracketed numbers refer to equation number in text.

The percentage of  $PM_{10}/PM$  was calculated for cooling tower TDS values from 1000 to 12000 ppmw and the results are plotted in Figure 1. Using these data, Figure 2 presents predicted  $PM_{10}$  emission rates for the 146,000 gpm example tower. As shown in this figure, the PM emission rate increases in a straight line as TDS increases, however, the  $PM_{10}$  emission rate increases to a maximum at around a TDS of 4000 ppmw, and then <u>begins to decline</u>. The reason is that at higher TDS, the drift droplets contain more solids and therefore, upon evaporation, result in larger solid particles for any given initial droplet size.


### **CONCLUSION**

The emission factors and methodology given in EPA's AP- $42^1$  Chapter 13.4 *Wet Cooling Towers*, do not account for the droplet size distribution of the drift exiting the tower. This is a critical factor, as more than 85% of the mass of particulate in the drift from most cooling towers will result in solid particles larger than PM<sub>10</sub> once the water has evaporated. Particles larger than PM<sub>10</sub> are no longer a regulated air pollutant, because their impact on human health has been shown to be insignificant. Using reasonable, conservative assumptions and a realistic drift

droplet size distribution, a method is now available for calculating realistic  $PM_{10}$  emission rates from wet mechanical draft cooling towers equipped with modern, high-efficiency drift eliminators and operating at medium to high levels of TDS in the circulating water.

**Table 2. Resultant Solid Particulate Size Distribution (TDS = 11000 ppmw)** 

| <b>EPRI Droplet</b> | Droplet                           | Droplet Mass                 | Particle Mass | Solid Particle         | Solid Particle | EPRI % Mass |
|---------------------|-----------------------------------|------------------------------|---------------|------------------------|----------------|-------------|
| Diameter            | Volume                            | ()                           | (Solids)      | Volume                 | Diameter       | Smaller     |
| $(\mu m)$           | $\left(\mu \mathrm{m}^{3}\right)$ | ( <i>µ</i> g <i>)</i><br>[3] | $(\mu g)$     | $\left(\mu m^3\right)$ | $(\mu m)$      |             |
|                     | [2] <sup>1</sup>                  |                              | [4]           |                        | [7]            |             |
| 10                  | 524                               | 5.24E-04                     | 5.76E-06      | 2.62                   | 1.710          | 0.000       |
| 20                  | 4189                              | 4.19E-03                     | 4.61E-05      | 20.94                  | 3.420          | 0.196       |
| 30                  | 14137                             | 1.41E-02                     | 1.56E-04      | 70.69                  | 5.130          | 0.226       |
| 40                  | 33510                             | 3.35E-02                     | 3.69E-04      | 167.55                 | 6.840          | 0.514       |
| 50                  | 65450                             | 6.54E-02                     | 7.20E-04      | 327.25                 | 8.550          | 1.816       |
| 60                  | 113097                            | 1.13E-01                     | 1.24E-03      | 565.49                 | 10.260         | 5.702       |
| 70                  | 179594                            | 1.80E-01                     | 1.98E-03      | 897.97                 | 11.970         | 21.348      |
| 90                  | 381704                            | 3.82E-01                     | 4.20E-03      | 1908.52                | 15.390         | 49.812      |
| 110                 | 696910                            | 6.97E-01                     | 7.67E-03      | 3484.55                | 18.810         | 70.509      |
| 130                 | 1150347                           | 1.15E+00                     | 1.27E-02      | 5751.73                | 22.230         | 82.023      |
| 150                 | 1767146                           | 1.77E+00                     | 1.94E-02      | 8835.73                | 25.650         | 88.012      |
| 180                 | 3053628                           | 3.05E+00                     | 3.36E-02      | 15268.14               | 30.780         | 91.032      |
| 210                 | 4849048                           | 4.85E+00                     | 5.33E-02      | 24245.24               | 35.909         | 92.468      |
| 240                 | 7238229                           | 7.24E+00                     | 7.96E-02      | 36191.15               | 41.039         | 94.091      |
| 270                 | 10305995                          | 1.03E+01                     | 1.13E-01      | 51529.97               | 46.169         | 94.689      |
| 300                 | 14137167                          | 1.41E+01                     | 1.56E-01      | 70685.83               | 51.299         | 96.288      |
| 350                 | 22449298                          | 2.24E+01                     | 2.47E-01      | 112246.49              | 59.849         | 97.011      |
| 400                 | 33510322                          | 3.35E+01                     | 3.69E-01      | 167551.61              | 68.399         | 98.340      |
| 450                 | 47712938                          | 4.77E+01                     | 5.25E-01      | 238564.69              | 76.949         | 99.071      |
| 500                 | 65449847                          | 6.54E+01                     | 7.20E-01      | 327249.23              | 85.499         | 99.071      |
| 600                 | 113097336                         | 1.13E+02                     | 1.24E+00      | 565486.68              | 102.599        | 100.000     |






Figure 2: PM<sub>10</sub> Emission Rate vs. TDS

### **REFERENCES**

- 1. EPA, 1995. Compilation of Air pollutant Emission Factors, AP-42 Fifth edition, Volume I: *Stationary Point and Area Sources*, Chapter 13.4 Wet Cooling Towers, <a href="http://www.epa.gov/ttn/chief/ap42/">http://www.epa.gov/ttn/chief/ap42/</a>, United States Environmental Protection Agency, Office of Air Quality Planning and Standards, January.
- 2. Aull, 1999. Memorandum from R. Aull, Brentwood Industries to J. Reisman, Greystone, December 7, 1999.

### **KEY WORDS**

Drift
Drift eliminators
Cooling tower
PM<sub>10</sub> emissions
TDS

### APPENDIX A COOLING TOWER BLOW DOWN REPORTS



October 09, 2018

Tom Barnhart Colorado Energy Management 4963 Soto St. Vernon, CA 90058

Report No.: 1810018

Project Name: Malburg Generating Station Weekly

Dear Tom Barnhart,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on October 03, 2018.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

Project Manager



### 781 East Washington Blvd., Los Angeles, CA 90021 (213) 745-5312 FAX (213) 745-6372

### **Certificate of Analysis**

Page 2 of 2

Colorado Energy Management

4963 Soto St. Vernon, CA 90058 File #:74548

Report Date: 10/09/18 Submitted: 10/03/18

PLS Report No.: 1810018

Attn: Tom Barnhart

Phone: (323) 476-3626

FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

| Analido             | Dor                | sults | Elac     | D.E.            | Units     | POL     | Dea     | Prep/Test Method |       |          | Analyzed |       | B <sub>V</sub> | Batch    |
|---------------------|--------------------|-------|----------|-----------------|-----------|---------|---------|------------------|-------|----------|----------|-------|----------------|----------|
| Analyte             | Res                | ouits | Flag     | D.F.            | OHIG      | PQL     | Pre     | J I est Met      | IUU   | Prepared | Alldi    | yzeu  | Ву             | Datti    |
| Total Dissolved     | Solids 45          | 540   |          | 1               | mg/L      | 5.0     | -       | SM               | 2540C | 10/03/18 | 10/04/18 |       | am             | BJ80408  |
|                     |                    |       |          | Qι              | uality (  | Contro  | ol Data |                  |       |          |          |       |                |          |
|                     |                    |       |          |                 |           |         | Spike   | Source           |       | %REC     |          | RPD   |                |          |
| Analyte             |                    | Resu  | lt       | PQL             | ι         | Units   | Level   | Result           | %REC  | Limits   | RPD      | Limit | Q              | ualifier |
| Batch BJ80408       |                    |       |          |                 |           |         |         |                  |       |          |          |       |                |          |
| Blank               |                    | Prepa | red: 10, | /03/18 /        | Analyzed  | 10/04/: | L8      |                  |       |          |          |       |                |          |
| Total Dissolved So  | ids                | ND    |          | 5.0             | n         | ng/L    |         | _                |       |          |          |       |                |          |
| LCS                 |                    | Prepa | red: 10  | /03/18 /        | Analyzed  | 10/04/  | L8      |                  |       |          |          |       |                |          |
| Total Dissolved So  | ids                | 350   |          | 5.0             | п         | ng/L    | 356.0   |                  | 98.3  | 80-120   |          |       |                | •        |
| Duplicate           | Source: 1810018-01 | Prepa | red: 10  | /03/18 <i>A</i> | Analyzed: | 10/04/  | L8      |                  |       |          |          |       |                |          |
| Total Dissolved Sol | • 4_               | 4620  |          | 5.0             | _         | ng/L    |         | 4540             |       |          | 1.86     | 5     |                |          |

### **Notes and Definitions**

NA

Not Applicable

ND

Analyte NOT DETECTED at or above the detection limit

NR

Not Reported

MDL

Method Detection Limit

PQL

Practical Quantitation Limit

TQL Fractical Quartication Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Authorized Signature(s)

|    | 41            | PC                 | SIT<br>S SER  | CHAIN OF  781 East Washington Blvd (213) 745-5312 FAX (213) |          |         |        |          | NAI    | _YSI    |            | •                     |                       | DA      | re: <u>/S</u> | )-}-/-<br>E NO. | E        |          | PA       | age(_of)                                  |
|----|---------------|--------------------|---------------|---|----------|---------|--------|----------|--------|---------|------------|-----------------------|-----------------------|---------|---------------|-----------------|----------|----------|----------|---|
|    | CLIENT NA     | AME: Cim           | \             | Project Na  | me/No.   | mali    | Kuja P | Serel    | منكة   | 6 to    |            |                       |                       |         |               | . NO.           |          |          |          | AIRBILL NO:                               |
|    | ADDRESS:      |                    |               |   |          |         | 7.76   | 20.0     | 9(1.9) |         | <i>ROL</i> |                       |                       | REQU    | ESTE          | D:              |          |          |          | COOLER TEMP: 1.3.C                        |
|    | PROJECT       | MANAGER: -         | Ton Ban       | o hart PHONE NO:  |          |         | FAX    | NO:      |        |         |            |                       |                       |         |               |                 |          |          |          | PRESERVATIVE:                             |
|    |               |                    |               | (Printed)   | (Signati | ure)    |        |          |        |         |            |                       |                       |         |               |                 |          |          |          | REMARKS:                                  |
|    | TAT (Analy    | rtical Turn Ar     | ound Time): ( | 0 = Same Day; 1 = 1 Day; 2 = 2 Days;                        | 3 = 3 Da | ays; N  | = Norn | nal (5-7 | 7 Work | king Da | ays)       |                       |                       |         |               |                 | -        |          |          |   |
|    | CONTAINE      | R TYPES: E         | B = Brass, E  | = Encore, G = Glass, P = Plastic, V =                       | VOA Via  | al, 0 = | Other: |          |        |         |            |                       |                       |         |               |                 |          |          |          |   |
|    | UST Proje     | ect: Y I           | V - Globa     | al ID#  |          |         |        | 195      |        |         |            |                       |                       |         |               |                 |          |          |          | ~   |
|    | SAMPLE<br>NO. |                    | TIME          | SAMPLE DESCRIPTION  | WATER    |         | SLUDGE | OTHER    | TAT    | CONT    | TYPE       | Ě                     |                       |         |               |                 |          |          |          | SAMPLE CONDITION/<br>CONTAINER /COMMENTS: |
| 1  |               |                    | 0905          | Coving John Blunday   | صر       |         |        |          | 1      |         | A          | مر                    |                       |         |               |                 |          |          |          | ,   |
| 2  |               | (0)                | 701           | word jove violedim  | _        |         |        |          | - 0    |         | ,          |                       |                       |         |               |                 |          |          |          |   |
| 3  |               |                    |               | ,   |          |         |        |          |        |         |            |                       |                       |         |               |                 |          |          |          |   |
| 4  |               |                    |               |   |          |         |        |          |        |         |            |                       |                       |         |               |                 |          |          |          |   |
| 5  |               |                    |               |   |          |         |        |          |        |         |            |                       |                       |         |               |                 |          |          |          |   |
| 6  |               |                    |               |   |          |         |        |          |        |         |            |                       |                       |         |               |                 |          |          |          |   |
| 7  |               |                    |               |   |          |         |        |          |        |         |            |                       |                       |         |               |                 |          |          |          |   |
| 8  |               |                    |               |   |          |         |        |          |        |         |            |                       |                       |         |               |                 |          |          |          |   |
| 9  |               |                    |               | -   |          |         |        |          |        |         |            |                       |                       |         |               |                 |          |          |          |   |
| 10 |               |                    |               |   | +        |         |        |          |        |         |            |                       |                       |         | X             |                 |          |          |          |   |
|    | 4             | Sy: (Signature and |               | Pleceived By: (Signature Received By: (Signature            | Nex      | mal     | Ta) 4  | Mull     | lune   | /       | Date:      | 1<br>13 <del>/8</del> | ا<br>ات<br>ک<br>Time: | )<br>Vo | 1.            | Samp            |          | urned to | o client |   |
|    |               | By: (Signature and |               | Received By: (Signature                                     | //       |         |        |          |        |         | Date:      |                       | Time:                 |         | $\dashv$      | additio         | onal sto | orage ti | ime is r | l over 30 days, unless<br>requested.      |
|    | SPECIAL I     | INSTRUCTIO         | NS.           |   |          |         |        |          |        |         |            |                       |                       |         | 3.            | Storaç          | ge time  | reques   | sted: _  | days                                      |



October 12, 2018

Tom Barnhart Colorado Energy Management 4963 Soto St. Vernon, CA 90058

Report No.: 1810051

Project Name: Malburg Generating Station Weekly

Dear Tom Barnhart,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on October 08, 2018.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

Project Manager



### 781 East Washington Blvd., Los Angeles, CA 90021 [213] 745-5312 FAX [213] 745-6372

### **Certificate of Analysis**

Page 2 of 2

Colorado Energy Management 4963 Soto St.

Vernon, CA 90058

File #:74548

Report Date: 10/12/18 Submitted: 10/08/18

PLS Report No.: 1810051

Attn: Tom Barnhart

Phone: (323) 476-3626

FAX:(323) 476-3640

**Project:** Malburg Generating Station Weekly

| Sample ID: Cooling Tower I | Blowdown Wal | ter (181 | 0051-0   | 1) Samp  | led: 10 | /08/18 09 | :20 Received: | 10/08/18 0 | 9:20     |    |         |
|----------------------------|--------------|----------|----------|----------|---------|-----------|---------------|------------|----------|----|---------|
| Analyte                    | Results      | Flag     | D.F.     | Units    | PQL     | Prep/     | Test Method   | Prepared   | Analyzed | Ву | Batch   |
| Total Dissolved Solids     | 4340         |          | 1        | mg/L     | 5.0     | -         | SM 2540C      | 10/10/18   | 10/11/18 | am | BJ81207 |
|                            |              |          | $\Omega$ | iality ( | ontro   | nl Data   |               |            |          |    |         |

|                |                    |             |             |               | Spike | Source |      | %REC   |       | RPD   |           |
|----------------|--------------------|-------------|-------------|---------------|-------|--------|------|--------|-------|-------|-----------|
| Analyte        |                    | Result      | PQL         | Units         | Level | Result | %REC | Limits | RPD   | Limit | Qualifier |
| Batch BJ81207  | 7                  |             |             |               |       |        |      |        |       |       |           |
| Blank          |                    | Prepared: 1 | 0/10/18 Ana | lyzed: 10/11  |       |        |      |        |       |       |           |
| Total Dissolve | d Solids           | ND          | 5.0         | mg/L          |       |        |      |        |       |       |           |
| LCS            |                    | Prepared: 1 | 0/10/18 Ana | ilyzed: 10/11 | /18   |        |      |        |       |       |           |
| Total Dissolve | d Solids           | 359         | 5.0         | mg/L          | 356.0 |        | 101  | 80-120 |       |       |           |
| Duplicate      | Source: 1810051-01 | Prepared: 1 | 0/10/18 Ana | lyzed: 10/11  | /18   |        |      |        |       |       |           |
| Total Dissolve | d Solids           | 4320        | 5.0         | mg/L          |       | 4340   |      |        | 0.462 | 5     |           |

### **Notes and Definitions**

NA Not Applicable

ND Analyte NOT DETECTED at or above the detection limit

NR Not Reported

MDL Method Detection Limit PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Authorized Signature(s)

Salda

|    |               | PC                 | SIT             | IVE CHAIN OF  | CUS                   | ΓOD            | Y AN    | ID A     | NAL    | YSI    | S RE  | EQU  | EST   | D.47 | /s  | D -              | ų.                  |                   | D4                | 05 105 1                                  |
|----|---------------|--------------------|-----------------|---|-----------------------|----------------|---------|----------|--------|--------|-------|------|-------|------|-----|------------------|---------------------|-------------------|-------------------|---|
|    | 111           | LAF                | 3 SER           | 781 East Washington Blvd<br>VICE (213) 745-5312 FAX (213)                   | d., Los A<br>3) 745-6 | Angeles<br>372 | s, CA 9 | 0021     |        |        | LOG   | воок | NO    | DA   | FIL | E NO.            |                     | 1                 | LAB NO            | o. 181009                                 |
|    | CLIENT NA     | ME: CEV            |                 | Project Na  |                       |                |         |          |        |        |       |      |       |      |     |                  |                     |                   |                   | AIRBILL NO:                               |
|    | ADDRESS:      |                    |                 |   |                       |                | )       |          |        | · ·    |       |      | LYSES |      |     |                  |                     |                   |                   | COOLER TEMP: 28°C                         |
|    | PROJECT       | MANAGER: "         | Ton Bell        | nhary PHONE NO:   |                       |                | FAX     | NO:      |        |        |       |      |       |      |     |                  |                     |                   |                   | PRESERVATIVE:                             |
|    | SAMPLER       |                    | onBasie         | (Printed)   | (Signati              | ıre)           |         |          |        |        |       |      |       |      |     |                  |                     |                   |                   | REMARKS:                                  |
|    | TAT (Analy    | tical Turn Ar      | ound Time): (   | 0 = Same Day; 1 = 1 Day; 2 = 2 Days;  | 3 = 3 Da              | ays; N         | = Norm  | nal (5-7 | 7 Work | ing Da | ays)  |      |       |      |     |                  |                     |                   |                   |   |
|    | CONTAINE      | R TYPES: E         | B = Brass, E    | = Encore, G = Glass, P = Plastic, V =                                       | VOA Via               | ıl, 0 =        | Other:  |          |        |        |       |      |       |      |     |                  |                     |                   |                   |   |
|    | UST Proje     | ct: Y I            | N - Globa       | al ID#  |                       |                | -       | -        |        |        |       | ١٥   |       |      |     |                  |                     |                   |                   |   |
|    | SAMPLE<br>NO. | DATE<br>SAMPLED    | TIME<br>SAMPLED | SAMPLE DESCRIPTION  | WATER                 | _              | SLUDGE  | OTHER    | TAT    | CONT   | TYPE  | 12/2 | 10    |      |     |                  |                     |                   |                   | SAMPLE CONDITION/<br>CONTAINER /COMMENTS: |
| 1  |               | 10814              | 092             | Cooling tone Blondan  | صد                    |                |         |          | N      | -      | P     | حر   |       |      |     |                  |                     |                   |                   |   |
| 2  |               |                    |                 |   |                       |                |         |          |        |        |       |      |       |      |     |                  |                     |                   |                   |   |
| 3  |               |                    |                 |   |                       |                |         |          |        |        |       |      |       |      |     |                  |                     |                   |                   |   |
| 4  |               |                    |                 |   |                       |                |         |          |        |        |       |      |       |      |     |                  |                     |                   |                   |   |
| 5  |               |                    |                 |   |                       |                |         |          |        |        |       |      |       |      |     | _                |                     |                   |                   |   |
| 6  |               |                    |                 |   |                       |                |         |          |        |        |       |      |       |      |     |                  |                     |                   |                   |   |
| 7  |               |                    |                 |   |                       |                |         |          |        |        |       |      | Ш     |      |     |                  |                     |                   |                   |   |
| 8  |               |                    |                 |   | $\perp$               |                |         |          |        |        |       |      | Ш     |      |     |                  |                     |                   |                   |   |
| 9  |               |                    |                 |   |                       |                |         |          |        |        |       |      |       |      |     |                  |                     |                   |                   |   |
| 10 |               |                    | <u></u>         |   |                       |                | 00000   | (        |        |        | D-1   |      |       |      | los | MADIE            | DIODE               | 101710            |                   |   |
|    | J             | By: (Signature and |                 | Received By: (Signature  Received By: (Signature)  Received By: (Signature) | and Printe            | ed Name)       | CHILLIN | UU<br>Pa |        | 1      | Date: | E (  | Time: | ~    | 1.  | Sampl            | es retu             |                   | client            |   |
|    |               | By: (Signature and |                 | Received By: (Signature   |                       |                |         |          |        |        | Date: |      | Time: |      | 2.  | Sampl<br>additio | es will<br>onal sto | not be<br>rage ti | stored<br>me is r | over 30 days, unless equested.            |
|    | SPECIAL I     | NSTRUCTIO          | NS:             |   |                       |                |         |          |        |        |       |      |       |      |     | Storag           | je time             | reques            | sted: _           | days                                      |



October 23, 2018

Tom Barnhart Colorado Energy Management 4963 Soto St. Vernon, CA 90058

Report No.: 1810134

Project Name: Malburg Generating Station Weekly

Dear Tom Barnhart,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on October 17, 2018.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

Project Manager



### 781 East Washington Blvd., Los Angeles, CA 90021 [213] 745-5312 FAX [213] 745-6372

### **Certificate of Analysis**

Page 2 of 2

Colorado Energy Management

Vernon, CA 90058

File #:74548

Report Date: 10/23/18 Submitted: 10/17/18

PLS Report No.: 1810134

4963 Soto St.

Attn: Tom Barnhart

Phone: (323) 476-3626

FAX:(323) 476-3640

**Project:** Malburg Generating Station Weekly

| Sample ID: Co   | ooling Tower Blow | down Wat | er (1810   | 134-0 | 1) Samı  | pled: 10  | /17/18  | 08:50 Re   | ceived: | 10/17/18 | 08:50 |       |    |          |
|-----------------|-------------------|----------|------------|-------|----------|-----------|---------|------------|---------|----------|-------|-------|----|----------|
| Analyte         |                   | Results  | Flag       | D.F.  | Units    | PQL       | Pre     | p/Test Met | hod     | Prepared | Anal  | yzed  | Ву | Batch    |
| Total Dissolve  | ed Solids         | 4980     |            | 1     | mg/L     | 5.0       | -       | SM         | 2540C   | 10/22/18 | 10/2  | 23/18 | am | BJ82330  |
|                 |                   |          |            | Q     | uality   | Contro    | ol Data | 1          |         |          |       |       |    |          |
|                 |                   |          |            |       |          |           | Spike   | Source     |         | %REC     |       | RPD   |    |          |
| Analyte         |                   | Resu     | ılt        | PQL   |          | Units     | Level   | Result     | %REC    | Limits   | RPD   | Limit | Q  | ualifier |
| Batch BJ82330 - |                   |          |            |       |          |           |         |            |         |          |       |       |    |          |
| Blank           |                   | Prep     | ared: 10/2 | 22/18 | Analyzed | l: 10/23/ | 18      |            |         |          |       |       |    |          |
| Total Dissolved | Solids            | ND       |            | 5.0   |          | mg/L      |         |            |         |          |       |       |    |          |
| LCS             |                   | Prep     | ared: 10/2 | 22/18 | Analyzed | l: 10/23/ | 18      |            |         |          |       |       |    |          |
| Total Dissolved | Solids            | 365      |            | 5.0   |          | mg/L      | 356.0   |            | 103     | 80-120   |       |       |    |          |
| Duplicate       | Source: 1810134   | -01 Prep | ared: 10/2 | 22/18 | Analyzed | : 10/23/  | 18      |            |         |          |       |       |    |          |
| Total Dissolved | Solids            | 5010     | )          | 5.0   |          | mg/L      |         | 4980       |         |          | 0.566 | 5     |    |          |

### **Notes and Definitions**

NA

Not Applicable

ND

Analyte NOT DETECTED at or above the detection limit

NR

Not Reported

MDL

Method Detection Limit

POL

Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Authorized Signature(s)

|    |               |                                       | SIT             | CHAIN OF  781 East Washington Blv. (213) 745-5312 FAX (21 |          | TOD     | <b>Y AN</b> | <b>ND A</b> | NAL      | YSI       | S RI  | EQU  | EST   | DAT    | ге: <u>/о</u>          | -17-1   | ~e       |          | PA             | GEOF                                      |
|----|---------------|---------------------------------------|-----------------|---|----------|---------|-------------|-------------|----------|-----------|-------|------|-------|--------|------------------------|---------|----------|----------|----------------|---|
|    | CLIENT NA     | ME: CE                                |                 |   |          | 372     | L           | / .         | V = C2   | 4.        | LOG   | BOOK | NO    | nosc l | FIL                    | E NO.   |          |          | LAB NO         | AIRBILL NO:                               |
|    | ADDRESS:      |                                       |                 | Project Na  |          | 11811   | nury        | Ce          | <u> </u> | my        | 5 R   | ANA  | LYSES | REQU   | ESTE                   | D:      |          |          |                | COOLER TEMP: 26°C                         |
|    | PROJECT       | MANAGER:                              | Ton Br          | PHONE NO:   |          |         | FAX         | NO:         |          |           |       |      |       |        |                        |         |          |          |                | PRESERVATIVE:                             |
|    | SAMPLER       | NAME:                                 | OhBarie         | (Printed)   | (Signati | ure)    |             |             |          |           |       |      |       |        |                        |         |          |          |                | REMARKS:                                  |
|    |               |                                       |                 | 0 = Same Day; 1 = 1 Day; 2 = 2 Days;                      | 3 = 3 Da | ays; N  | = Norm      | nal (5-7    | 7 Work   | king Da   | ays)  |      |       |        |                        |         |          |          |                | 4   |
|    | CONTAINE      | R TYPES:                              | B = Brass, E    | = Encore, G = Glass, P = Plastic, V =                     | VOA Via  | al, 0 = | Other:      | la<br>K     |          |           |       |      |       |        | ,                      |         |          |          |                |   |
|    | UST Proje     | ct: Y I                               | N - Globa       | ıl ID#  |          |         |             |             |          |           |       | 5    |       |        |                        |         |          |          |                |   |
|    | SAMPLE<br>NO. | DATE<br>SAMPLED                       | TIME<br>SAMPLED | SAMPLE DESCRIPTION  | WATER    | _       | SLUDGE      | OTHER       | TAT      | CONT<br># | TYPE  | K    |       |        |                        |         |          |          |                | SAMPLE CONDITION/<br>CONTAINER /COMMENTS: |
| 1  |               | 191712                                | 0850            | Looking Tone Blowdown                                     | صا       |         |             |             | 1        | 1         | ρ     | ص    |       |        |                        |         |          |          |                |   |
| 2  |               |                                       |                 | 1   |          |         |             |             |          |           |       |      |       |        |                        |         |          |          |                |   |
| 3  |               |                                       |                 |   |          |         |             |             |          |           |       |      |       |        |                        |         |          |          |                |   |
| 4  |               |                                       |                 |   |          |         |             |             |          |           |       |      |       |        |                        |         |          |          |                |   |
| 5  |               |                                       |                 |   | -        |         |             |             |          |           |       |      |       |        |                        |         |          |          |                |   |
| 6  |               |                                       |                 | ,   |          |         |             |             |          |           |       |      |       |        |                        |         |          |          | _              |   |
| 7  |               |                                       |                 |   | -        |         | _           |             |          |           |       |      |       |        |                        |         |          |          |                |   |
| 8  |               |                                       |                 |   | -        |         |             |             |          |           |       |      |       |        |                        |         |          |          |                |   |
| 9  |               |                                       |                 |   | -        |         |             |             |          |           |       |      |       |        |                        |         |          | _        | _              |   |
| 10 |               | y: (Signature and                     | ***             | Received By: (Signatur                                    | MINA     | ///     |             |             |          |           | Date: | 30   | Time: |        |                        |         | DISP(    |          | N:<br>o client | ? YES NO                                  |
|    |               | By: (Signature and By: (Signature and |                 | Received By: (Signatur                                    |          |         |             |             |          | *         | Date: |      | Time: |        | $\dashv$               | additio | onal sto | orage ti | ime is r       | over 30 days, unless requested.           |
|    | SPECIAL I     | NSTRUCTIO                             | NS:             |   |          |         |             |             |          |           |       |      |       |        | —  <sup>3.</sup><br>Ву |         | je time  | reques   | sted: _        | days                                      |



October 29, 2018

Tom Barnhart Colorado Energy Management 4963 Soto St. Vernon, CA 90058

Report No.: 1810182

Project Name: Malburg Generating Station Weekly

Dear Tom Barnhart,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on October 24, 2018.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

Project Manager



### 781 East Washington Blvd., Los Angeles, CA 90021 (213) 745-5312 FAX (213) 745-6372

### **Certificate of Analysis**

Page 2 of 2

Colorado Energy Management

4963 Soto St. Vernon, CA 90058 File #:74548

Report Date: 10/29/18 Submitted: 10/24/18

PLS Report No.: 1810182

Attn: Tom Barnhart

Phone: (323) 476-3626

FAX:(323) 476-3640

**Project:** Malburg Generating Station Weekly

| Analyte                | Results | Flag | D.F. | Units | PQL | Prep/ | Test Method | Prepared | Analyzed | Ву | Batch   |
|------------------------|---------|------|------|-------|-----|-------|-------------|----------|----------|----|---------|
| Total Dissolved Solids | 4500    |      | 1    | mg/L  | 5.0 | -     | SM 2540C    | 10/25/18 | 10/26/18 | am | BJ82617 |

|                |                    |             |             |               | Spike | Source |      | %REC   |       | RPD   |           |
|----------------|--------------------|-------------|-------------|---------------|-------|--------|------|--------|-------|-------|-----------|
| Analyte        |                    | Result      | PQL         | Units         | Level | Result | %REC | Limits | RPD   | Limit | Qualifier |
| Batch BJ82617  | 7                  |             |             |               |       |        |      |        |       |       |           |
| Blank          |                    | Prepared: 1 | 0/25/18 Ana | lyzed: 10/26  | /18   |        |      |        |       |       |           |
| Total Dissolve | d Solids           | ND          | 5.0         | mg/L          |       |        |      |        |       |       |           |
| LCS            |                    | Prepared: 1 | 0/25/18 Ana | alyzed: 10/26 | /18   |        |      |        |       |       |           |
| Total Dissolve | d Solids           | 345         | 5.0         | mg/L          | 356.0 |        | 96.9 | 80-120 |       |       |           |
| Duplicate      | Source: 1810182-01 | Prepared: 1 | 0/25/18 Ana | alyzed: 10/26 | /18   |        |      |        |       |       |           |
| Total Dissolve | d Solids           | 4530        | 5.0         | mg/L          |       | 4500   |      |        | 0.626 | 5     |           |

### **Notes and Definitions**

NA Not Applicable

ND Analyte NOT DETECTED at or above the detection limit

NR Not Reported

MDL Method Detection Limit
PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Authorized Signature(s)

relda Min

|    |                |                               | )SIT            |  |            |          | s CA 9  | 0021      |          |         |       | •       |       |         |     |       | 18                   |        |                   | AGEOF/                                    |
|----|----------------|-------------------------------|-----------------|--|------------|----------|---------|-----------|----------|---------|-------|---------|-------|---------|-----|-------|----------------------|--------|-------------------|---|
|    | 111            |                               |                 | 781 East Washington Blvd (213) 745-5312 FAX (213 | 745-6      | 372      | 2, 0/10 | 5021      | 2        |         | LOG   | воок    | NO    |         | FIL | E NO. |                      |        | LAB N             |   |
|    | CLIENT NA      | ME: CEr                       | 7               | Project Nar                                      | ne/No.     | Ma       | huse    | 6         | enez     | Tho     | 52    | tun     | We    | eky     | P.0 | . NO. |                      |        |                   | AIRBILL NO:                               |
|    | ADDRESS:       |                               |                 |  |            |          |         | ,         |          | ,       |       |         | LYSES | 1       |     |       |                      |        |                   | COOLER TEMP: 1.3 00                       |
|    | PROJECT        | MANAGER: `                    | Tom B           | anhait PHONE NO:                                 |            |          | FAX     | NO:       |          |         |       |         |       |         |     |       |                      |        |                   | PRESERVATIVE:                             |
|    |                |                               | 5mB21           |  | (Signati   | ure)     |         |           |          |         |       |         |       |         |     |       |                      |        |                   | REMARKS:                                  |
|    |                | 3                             |                 | 0 = Same Day; 1 = 1 Day; 2 = 2 Days; 3           | = 3 Da     | ays; N   | = Norn  | nal (5-7  | 7 Work   | king Da | ays)  |         | i e   |         |     |       |                      |        |                   |   |
| 1  | CONTAINE       | R TYPES:                      | B = Brass, E    | = Encore, G = Glass, P = Plastic, V = V          | /OA Via    | al, 0 =  | Other:  |           |          |         |       |         |       |         |     |       |                      |        |                   |   |
|    | UST Proje      | JST Project: Y N - Global ID# |                 |  |            |          |         |           |          |         |       |         |       |         |     |       | )<br>                |        |                   |   |
|    | SAMPLE<br>NO.  | DATE<br>SAMPLED               | TIME<br>SAMPLED | SAMPLE DESCRIPTION                               | WATER      | SOIL     | RIX     | OTHER     | TAT      | CONT    | TYPE  | JOY NO. |       |         |     |       | -                    |        |                   | SAMPLE CONDITION/<br>CONTAINER /COMMENTS: |
| 1  |                | 10.241                        | 2850            | Coving tomer Blundown                            | مر         | . 2      |         |           | 1        | 1       | P     | حر      |       |         |     |       |                      |        |                   |   |
| 2  |                |                               |                 |  |            |          |         |           |          |         |       |         |       |         |     |       |                      |        |                   |   |
| 3  |                |                               |                 | 19   |            |          |         |           | ¥<br>:#: |         |       |         |       |         |     |       |                      |        |                   |   |
| 4  | **             |                               |                 |  |            |          |         | i.e       |          | 4       |       |         |       |         |     |       |                      |        |                   |   |
| 5  |                |                               |                 |  |            |          |         |           |          |         |       |         |       |         |     |       |                      |        |                   | ,   |
| 6  |                |                               |                 | *  |            |          |         |           |          |         |       |         |       |         |     |       |                      |        |                   |   |
| 7  |                |                               |                 |  |            |          |         |           |          |         |       |         |       |         |     |       |                      |        |                   | /   |
| 8  |                |                               |                 |  |            |          |         |           | . '      |         |       |         |       |         |     |       |                      |        |                   |   |
| 9  |                |                               |                 |  |            |          |         |           |          |         |       |         |       |         |     |       |                      |        |                   |   |
| 10 |                |                               |                 |  |            | 1        |         |           |          |         |       |         |       |         |     |       |                      |        |                   |   |
|    | Relinquished B | y: (Signature and             | Printed Name)   | Received Bur (Signature                          | and Print  | ed Name) | : Qu    | adalu     | W. U     | Mala    | Date: | 18      | Time: | B       |     |       | DISP(                |        | N:<br>client      | ? YES NO                                  |
|    | ·              | ly: (Signature and            |                 |  |            |          |         | - d d ala | 1        | 4       | Date: |         | Ťime: |         | 2.  | Sampl | les will<br>onal sto | not be | stored<br>me is r | over 30 days, unless requested.           |
|    | Relinquished B | ly: (Signature and            | Printed Name)   | Received By: (Signature                          | and Printe | ed Name) |         |           |          |         | Date: |         | Time: |         |     |       |                      |        |                   | days                                      |
|    | SPECIAL I      | NSTRUCTIO                     | NS:             |  |            |          |         |           |          |         |       |         |       | By Date |     |       |                      |        |                   |   |



November 02, 2018

Tom Barnhart Colorado Energy Management 4963 Soto St. Vernon, CA 90058

Report No.: 1810213

Project Name: Malburg Generating Station Weekly

Dear Tom Barnhart,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on October 29, 2018.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

Project Manager



### 781 East Washington Blvd., Los Angeles, CA 90021 [213] 745-5312 FAX [213] 745-6372

### **Certificate of Analysis**

Page 2 of 2

File #:74548

Report Date: 11/02/18 Submitted: 10/29/18

PLS Report No.: 1810213

Colorado Energy Management 4963 Soto St.

Vernon, CA 90058 Attn: Tom Barnhart

Phone: (323) 476-3626

FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

| Analyte                | Res             | ults  | Flag     | D.F.  | Units    | PQL      | Prep    | o/Test Met | hod   | Prepared | Anal  | yzed  | Ву | Batch    |
|------------------------|-----------------|-------|----------|-------|----------|----------|---------|------------|-------|----------|-------|-------|----|----------|
| Total Dissolved Solid  | s 43            | 40    |          | 1     | mg/L     | 5.0      | -       | SM         | 2540C | 11/01/18 | 11/0  | 2/18  | cg | BK80219  |
|                        |                 |       |          | Qı    | uality   | Contro   | ol Data | l          |       |          |       |       |    |          |
|                        |                 |       |          |       |          |          | Spike   | Source     |       | %REC     |       | RPD   |    |          |
| Analyte                |                 | Resul | t        | PQL   |          | Units    | Level   | Result     | %REC  | Limits   | RPD   | Limit | Q  | ualifier |
| Batch BK80219          |                 |       |          |       |          |          |         |            |       |          |       |       |    |          |
| Blank                  |                 | Prepa | red: 11  | 01/18 | Analyzed | : 11/02/ | 18      |            |       |          |       |       |    |          |
| Total Dissolved Solids |                 | ND    |          | 5.0   |          | mg/L     |         |            |       |          |       |       |    |          |
| LCS                    | 7               | Prepa | red: 11, | 01/18 | Analyzed | : 11/02/ | 18      |            |       |          |       |       |    |          |
| Total Dissolved Solids |                 | 370   |          | 5.0   |          | mg/L     | 356.0   |            | 104   | 80-120   |       |       |    |          |
| Duplicate Sou          | rce: 1810213-01 | Prepa | red: 11  | 01/18 | Analyzed | : 11/02/ | 18      |            |       |          |       |       |    |          |
| Total Dissolved Solids |                 | 4330  |          | 5.0   |          | mg/L     |         | 4340       |       |          | 0.185 | 5     |    |          |

#### **Notes and Definitions**

NA

Not Applicable

ND

Analyte NOT DETECTED at or above the detection limit

NR

Not Reported

MDL

Method Detection Limit

**PQL** 

Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Authorized Signature(s)

|     |                |                    |                 |                        |                                      |                              |                |              |          |        |        |       |      |             |       |     |                   |                      |                    |                    | 104421                                    |
|-----|----------------|--------------------|-----------------|------------------------|--------------------------------------|------------------------------|----------------|--------------|----------|--------|--------|-------|------|-------------|-------|-----|-------------------|----------------------|--------------------|--------------------|---|
|     | 1              | J PC               | SIT             | IVE                    | CHAIN OF                             | CUS                          | ΓOD            | Y AN         | ID A     | NAL    | YSI    | S RE  | EQUI | EST         | DATE  | - 1 | 29                | 2                    |                    | D4                 | 05 ) 05 /                                 |
|     | 111            |                    |                 | 781 Ea<br>VICE (213) 7 | st Washington Blv<br>45-5312 FAX (21 | d., Los <i>A</i><br>3) 745-6 | Angeles<br>372 | s, CA 9      | 0021     |        |        | LOG   | воок | NO          |       |     |                   |                      |                    |                    | o. 8 02 3                                 |
|     | CLIENT NA      | AME: CÈ,           | M               |                        | Project Na                           | me/No.                       | Ma             | Mul          | n 4      | enci   | 2/2    |       |      |             |       |     |                   |                      |                    |                    | AIRBILL NO:                               |
| - 1 | ADDRESS        |                    |                 | 941                    |                                      |                              |                | _            | ,        |        | ,      | )     |      |             | REQUE |     |                   |                      |                    |                    | COOLER TEMP: 1/0 0                        |
|     | PROJECT        | MANAGER:           | IUM Ban         | hart                   | PHONE NO:                            |                              |                | FAX          | NO:      |        |        |       |      |             |       |     |                   |                      |                    |                    | PRESERVATIVE:                             |
|     |                |                    | The Bane        |                        |                                      | (Signati                     | ure)           |              |          |        |        |       |      |             |       |     |                   |                      |                    |                    | REMARKS:                                  |
| - 1 |                |                    |                 | 0 = Same Day; 1 = 1    | Day; 2 = 2 Days;                     | 3 = 3 Da                     | ays; N         | = Norm       | nal (5-7 | 7 Work | ing Da | ays)  |      |             |       |     |                   |                      |                    |                    |   |
| Ī   | CONTAINE       | ER TYPES: I        | B = Brass, E    | = Encore, G = Glass    | s, P = Plastic, V =                  | VOA Via                      | al, 0 =        | Other:       |          |        |        |       |      |             |       |     |                   |                      |                    |                    |   |
|     | UST Proje      | ect: Y             | N - Globa       | ıl ID#                 |                                      |                              |                |              |          |        |        | _     |      |             | ×     |     |                   |                      |                    |                    | ٠   |
|     | SAMPLE<br>NO.  | DATE<br>SAMPLED    | TIME<br>SAMPLED | SAMPLE DE              | SCRIPTION                            | WATER                        | SOIL           | RIX          | OTHER    | TAT    | CONT.  | TYPE  | B    |             | , *   |     |                   |                      |                    |                    | SAMPLE CONDITION/<br>CONTAINER /COMMENTS: |
| 1   |                | 1029-M             | (100)           | Codnatore              | Brandon                              | 5                            |                |              |          | L      | (      | P     | صر   |             |       |     |                   |                      |                    |                    |   |
| 2   |                |                    |                 | 7,                     | ,                                    |                              |                |              |          |        |        |       |      |             |       |     |                   |                      |                    |                    |   |
| 3   |                |                    |                 |                        |                                      |                              |                |              |          |        |        |       |      |             |       |     |                   |                      |                    |                    |   |
| 4   |                |                    |                 |                        | ٠                                    |                              |                |              |          |        |        |       |      |             |       |     |                   |                      |                    |                    |   |
| 5   |                |                    |                 | 1                      | D.                                   |                              |                |              |          |        |        |       |      |             |       |     |                   |                      |                    |                    |   |
| 6   |                |                    |                 |                        |                                      |                              |                |              |          |        |        |       |      |             |       |     |                   |                      |                    |                    |   |
| 7   |                |                    |                 |                        |                                      |                              |                |              |          |        |        |       |      |             |       |     |                   |                      |                    |                    |   |
| 8   |                |                    |                 |                        |                                      |                              |                |              |          |        |        |       |      |             |       |     |                   |                      |                    |                    |   |
| 9   | 8              |                    |                 |                        |                                      |                              |                |              |          |        |        |       |      |             |       |     |                   |                      |                    |                    |   |
| 10  |                |                    |                 | /                      |                                      |                              | 1              |              | ,        |        |        |       |      |             |       |     |                   |                      |                    |                    |   |
| L   | A.             | (Signature and     |                 |                        | Regelver By: (Signatur               | GULL                         | ed Mame)       | Allul<br>Tuz | ulue     |        | /      | Date: | 142  | Time: /0 // | 7     |     |                   | DISPO<br>es retur    |                    |                    | ? YES NO                                  |
|     |                | By: (Signature and |                 |                        | Heceived By: (Signatur               | e and Printe                 | ed Name)       |              |          |        |        | Date: |      | Time:       |       | 2.  | Sample<br>additio | es will r<br>nal sto | not be<br>rage tir | stored<br>me is re | over 30 days, unless equested.            |
|     | Relinquished E | By: (Signature and | Printed Name)   |                        | Received By: (Signatur               | re and Printe                | ed Name)       |              |          |        |        | Date: |      | Time:       |       | 3.  | Storage           | e time i             | reques             | sted: _            | day                                       |

SPECIAL INSTRUCTIONS:

\_ Date



November 12, 2018

Tom Barnhart Colorado Energy Management 4963 Soto St. Vernon, CA 90058

Report No.: 1811035

Project Name: Malburg Generating Station Weekly

Dear Tom Barnhart,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on November 06, 2018.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

Project Manager



### 781 East Washington Blvd., Los Angeles, CA 90021 (213) 745-5312 FAX (213) 745-6372

### **Certificate of Analysis**

Page 2 of 2

Colorado Energy Management 4963 Soto St.

Sample ID: Cooling Tower Blowdown

File #:74548

Vernon, CA 90058

Report Date: 11/12/18 Submitted: 11/06/18

PLS Report No.: 1811035

Phone: (323) 476-3626 FAX:(323) 476-3640

Attn: Tom Barnhart

Project: Malburg Generating Station Weekly

Water (1811035-01) Sampled: 11/06/18 08:20 Received: 11/06/18 08:20

| Analyte                     | Results Flag    | D.F.   | Units     | PQL Pr      | ep/Test Me | thod    | Prepared | Anal  | yzed  | Ву | Batch    |
|-----------------------------|-----------------|--------|-----------|-------------|------------|---------|----------|-------|-------|----|----------|
| Total Dissolved Solids      | 4620            | 1      | mg/L      | 5.0 -       | SM         | 2540C   | 11/08/18 | 11/0  | 9/18  | am | BK80905  |
|                             |                 | Q      | uality (  | Control Dat | a          | Test or |          |       |       |    |          |
|                             |                 |        |           | Spike       | Source     |         | %REC     |       | RPD   |    |          |
| Analyte                     | Result          | PQL    | U         | Inits Level | Result     | %REC    | Limits   | RPD   | Limit | Qı | ualifier |
| Batch BK80905               |                 |        |           |             |            |         |          |       |       |    |          |
| Blank                       | Prepared: 11    | /08/18 | Analyzed: | 11/09/18    |            |         | * 13.    | le le |       |    |          |
| Total Dissolved Solids      | ND              | 5.0    | m         | ng/L        |            |         |          |       |       |    |          |
| LCS                         | Prepared: 11    | /08/18 | Analyzed: | 11/09/18    |            |         |          |       |       |    |          |
| Total Dissolved Solids      | 370             | 5.0    | m         | ng/L 356.0  |            | 104     | 80-120   |       |       |    |          |
| Duplicate Source: 1811035-0 | 01 Prepared: 11 | /08/18 | Analyzed: | 11/09/18    |            |         |          |       |       |    |          |
| Total Dissolved Solids      | 4610            | 5.0    | m         | ng/L        | 4620       |         |          | 0.253 | 5     |    |          |
| Duplicate Source: 1811054-0 | D5 Prepared: 11 | /08/18 | Analyzed: | 11/09/18    |            |         |          |       | liki. |    |          |
| Total Dissolved Solids      | 940             | 5.0    | m         | ng/L        | 940        | · .     | A 1      | 0.00  | 5     |    |          |

#### **Notes and Definitions**

NA

Not Applicable

ND

Analyte NOT DETECTED at or above the detection limit

NR

Not Reported

MDL

Method Detection Limit

**PQL** 

**Practical Quantitation Limit** 

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Authorized Signature(s)

|    |               | PC                                    | SIT             | IVE               | CHAIN OF                               | CUST                    | LOD.           |               |          |        |                  |       |          |       | ראַת     | re: //- | 678                | ,<br>                |                   | ΡΔι                | ge ) of)                                  |
|----|---------------|---------------------------------------|-----------------|-------------------|--|-------------------------|----------------|---------------|----------|--------|------------------|-------|----------|-------|----------|---------|--------------------|----------------------|-------------------|--------------------|---|
|    |               | LAE                                   | B SER           | VICE (213)        | East Washington Blv<br>745-5312 FAX (2 | /d., Los A<br>13) 745-6 | Angeles<br>372 | s, CA 90      | 0021     |        |                  | LOG   | воок     | NO    | DAI      | FIL     | E NO.              |                      | L                 | AB NO              | GE 1 OF 1                                 |
|    | CLIENT NA     | الله: الله                            | $\sim$          |                   | Project Na                             | ame/No.                 | ∕~a /          |               |          |        |                  |       |          |       |          |         | . NO.              |                      |                   |                    | AIRBILL NO:                               |
|    | ADDRESS:      |                                       |                 |                   |  |                         |                | J             |          | •      | , , , , ,        | •     |          |       |          | IESTEI  | ):                 |                      |                   |                    | COOLER TEMP: /16°C                        |
|    | PROJECT       | MANAGER:                              | Ton Bal         | nhaT              | PHONE NO:                              |                         |                | FAX           | NO:      |        |                  |       |          |       |          |         |                    |                      |                   |                    | PRESERVATIVE:                             |
|    |               | NAME: JE                              |                 | (Printed)         | d                                      | (Signatu                | ire)           |               |          |        |                  |       |          |       |          |         |                    |                      |                   |                    | REMARKS:                                  |
|    | TAT (Analy    | tical Turn Ar                         | ound Time):     | 0 = Same Day; 1 = | 1 Day; 2 = 2 Days;                     | 3 = 3 Da                | ays; N :       | = Norm        | nal (5-7 | 7 Work | king Da          | ays)  |          |       |          |         |                    |                      |                   |                    |   |
|    | CONTAINE      | R TYPES: E                            | B = Brass, E    | = Encore, G = Gla | ss, P = Plastic, V =                   | = VOA Via               | ıl, 0 =        | Other:        |          |        | ·                |       |          |       |          |         |                    |                      |                   |                    |   |
|    | UST Proje     | ct: Y                                 | V - Globa       | IID#              | -                                      |                         |                |               |          |        |                  |       |          |       |          |         |                    |                      |                   |                    |   |
|    | SAMPLE<br>NO. | DATE<br>SAMPLED                       | TIME<br>SAMPLED | SAMPLE            | DESCRIPTION                            | WATER                   | MAT<br>SOIL    | RIX<br>SLUDGE | OTHER    | TAT    | CON <sup>-</sup> | TYPE  | 12/2     |       |          |         |                    |                      | 1                 |                    | SAMPLE CONDITION/<br>CONTAINER /COMMENTS: |
| 1  | :             | 14613 DOW Congressiondon D NIPY       |                 |                   |  |                         |                |               |          |        |                  |       |          |       |          |         |                    |                      |                   |                    |   |
| 2  |               | 11613 De Coargere Dondon              |                 |                   |  |                         |                |               |          |        |                  |       |          |       |          |         |                    |                      |                   |                    |   |
| 3  |               |                                       |                 |                   |  |                         |                |               |          |        |                  |       |          |       |          |         |                    |                      |                   |                    |   |
| 4  |               |                                       |                 |                   |  |                         |                |               |          |        |                  |       |          |       |          |         |                    |                      |                   |                    |   |
| 5  |               |                                       |                 |                   |  |                         |                |               |          |        |                  | -     |          |       |          |         |                    |                      |                   |                    |   |
| 6  |               |                                       |                 |                   |  |                         |                |               |          |        |                  |       |          |       |          |         |                    |                      |                   |                    |   |
| 7  |               |                                       |                 |                   |  |                         |                |               |          |        |                  |       |          |       |          |         |                    |                      |                   |                    |   |
| 8  |               |                                       |                 |                   |  |                         |                |               |          |        |                  |       |          |       |          |         |                    |                      |                   |                    |   |
| 9  |               |                                       |                 |                   |  |                         |                |               |          |        |                  |       |          |       |          |         |                    |                      |                   |                    |   |
| 10 |               |                                       |                 |                   |  |                         |                |               |          |        |                  |       |          |       |          |         |                    |                      |                   |                    |   |
|    | 4             | By: (Signature and                    |                 | (                 | Piecewed By: (Signatu                  | re and Printe           | d Name)        | uda           | lune     | tanal  | a 1              | Date: | <u>e</u> | Time: | <u> </u> |         |                    | DISPO<br>es retu     |                   |                    | ? YES NO                                  |
|    |               | By: (Signature and By: (Signature and |                 |                   | Received By: (Signatu                  |                         |                |               |          |        |                  | Date: |          | Time: |          | 2.      | Sample<br>addition | es will ı<br>nal sto | not be<br>rage ti | stored<br>me is re | over 30 days, unless equested.            |
|    |               | NSTRUCTIO                             |                 |                   | , , , ,                                |                         |                |               |          |        |                  |       |          |       |          |         | _                  |                      |                   |                    | days                                      |
|    |               |                                       | <b></b>         |                   |  |                         |                |               |          |        |                  |       |          |       |          | lgà     |                    |                      |                   |                    | Date                                      |



November 16, 2018

Tom Barnhart Colorado Energy Management 4963 Soto St. Vernon, CA 90058

Report No.: 1811112

Project Name: Malburg Generating Station Weekly

Dear Tom Barnhart,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on November 12, 2018.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

Project Manager



#### 781 East Washington Blvd., Los Angeles, CA 90021 (213) 745-5312 FAX (213) 745-6372

### **Certificate of Analysis**

Page 2 of 2

Colorado Energy Management

4963 Soto St.

Vernon, CA 90058

File #:74548

Report Date: 11/16/18 Submitted: 11/12/18

PLS Report No.: 1811112

Attn: Tom Barnhart

Phone: (323) 476-3626

FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

| Sample ID: Cooling Tower I | Blowdown Wat | er (181   | 1112-0   | L) Samp  | oled: 11 | /12/18 ( | 9:05 Re    | ceived: | 11/12/18   | 09:05 |       | i k |          |
|----------------------------|--------------|-----------|----------|----------|----------|----------|------------|---------|------------|-------|-------|-----|----------|
| Analyte                    | Results      | Flag      | D.F.     | Units    | PQL      | Pre      | o/Test Met | hod     | Prepared   | Anal  | yzed  | Ву  | Batch    |
| Total Dissolved Solids     | 4480         |           | 1        | mg/L     | 5.0      | -        | SM         | 2540C   | 11/14/18   | 11/1  | .5/18 | am  | BK81506  |
|                            |              |           | Qı       | uality   | Contro   | ol Data  | Ì          |         |            |       |       |     |          |
|                            |              |           |          |          |          | Spike    | Source     |         | %REC       |       | RPD   |     |          |
| Analyte                    | Resu         | ılt       | PQL      |          | Units    | Level    | Result     | %REC    | Limits     | RPD   | Limit | Q   | ualifier |
| Batch BK81506              |              |           |          |          |          |          |            |         | g id a ret |       |       |     |          |
| Blank                      | Prep         | ared: 11  | /14/18 / | Analyzed | : 11/15/ | 18       |            |         |            |       |       |     |          |
| Total Dissolved Solids     | ND           |           | 5.0      |          | mg/L     |          |            |         |            |       |       |     |          |
| LCS                        | Prep         | ared: 11  | /14/18 / | Analyzed | : 11/15/ | 18       |            |         |            |       |       |     |          |
| Total Dissolved Solids     | 367          | •         | 5.0      | . 1      | mg/L     | 356.0    |            | 103     | 80-120     |       |       |     |          |
| Duplicate Source: 181      | 1112-01 Prep | ared: 11, | /14/18 / | Analyzed | : 11/15/ | 18       |            |         |            |       |       |     |          |
| Total Dissolved Solids     | 4550         | 0         | 5.0      |          | mg/L     |          | 4480       |         |            | 1.59  | 5     |     |          |

#### **Notes and Definitions**

NA

Not Applicable

ND

Analyte NOT DETECTED at or above the detection limit

NR

Not Reported

MDL

Method Detection Limit

**PQL** 

Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Authorized Signature(s)

| -  |   |                    |                |  |               |          |        |          |        |          |       |       |       |      |   |         |         |         |          | 100330                               |
|----|---|--------------------|----------------|--|---------------|----------|--------|----------|--------|----------|-------|-------|-------|------|---|---------|---------|---------|----------|--------------------------------------|
|    |   | PC                 | )SIT           | CHAIN OF 781 East Washington Blv               |               |          |        |          | NAL    | YSI      | S RI  | EQU   | EST   | DAT  | re: <u>                                    </u> | 1-12    | 8       | E       |          | AGE (OF (                            |
|    |   |                    |                | 781 East Washington Blv (213) 745-5312 FAX (2- |               |          |        |          |        |          |       |       |       |      | FIL   | E NO.   |         |         | LAB N    |                                      |
|    | CLIENT NA   | AME: COV           | Λ              | Project Na                                     | ame/No.       | alle     | UX C   | Dere     | vatur. | n 4      | 老太    | n U   | )ee   | Kly  | P.0   | . NO.   |         |         |          | AIRBILL NO:                          |
|    | ADDRESS:  |                    |                |  |               |          | 7      |          |        | ,        |       |       |       | REQU | ESTE  | D:      |         |         |          | COOLER TEMP: 1.) 2                   |
|    | PROJECT   | MANAGER: `         | Ton Bain       | hart PHONE NO:                                 |               |          | FAX    | NO:      |        |          |       |       |       |      |   |         |         |         |          | PRESERVATIVE:                        |
|    |   | NAME: J            |                | (Printed)                                      | (Signatu      | ıre)     |        |          |        |          |       |       |       | 4    |   |         |         |         |          | REMARKS:                             |
|    |   |                    |                | D = Same Day; 1 = 1 Day; 2 = 2 Days;           |               |          | = Norn | nal (5-7 | 7 Work | king Da  | ays)  |       |       |      |   |         |         |         |          |                                      |
|    | CONTAINE  | R TYPES: E         | B = Brass, E : | = Encore, G = Glass, P = Plastic, V =          | · VOA Via     | l. 0 =   | Other: |          |        |          |       |       |       |      |   |         |         |         |          |                                      |
|    | UST Proje   |                    | N - Globa      |  |               |          |        |          |        |          |       | 2     |       |      |   |         |         |         |          |                                      |
|    | SAMPLE  | DATE               | TIME           |  | $\equiv$      |          | RIX    |          |        | CONT     | AINER | 75    |       |      |   |         |         |         |          | SAMPLE CONDITION/                    |
|    | NO.   | SAMPLED            | SAMPLED        | SAMPLE DESCRIPTION                             | WATER         | SOIL     | SLUDGE | OTHER    | TAT    | #        | TYPE  | Ř     |       |      |   |         |         |         |          | CONTAINER /COMMENTS:                 |
| 1  | 1 11-12,13 0905 (DDINTON DOWN DOWN DOWN DOWN DOWN DOWN) |                    |                |  |               |          |        |          |        |          |       |       |       |      |   |         |         |         |          |                                      |
| 2  |   |                    |                |  |               |          |        |          |        | 1        |       |       |       |      |   |         |         |         |          | ,                                    |
| 3  |   |                    |                |  |               |          |        |          |        |          |       |       |       |      |   |         |         |         |          |                                      |
| 4  |   |                    |                |  |               |          |        |          |        |          |       |       |       |      |   |         |         |         |          |                                      |
| 5  |   |                    |                | 1  |               |          |        |          |        |          |       |       |       |      |   |         |         |         |          |                                      |
| 6  |   |                    |                |  |               |          |        |          |        |          |       |       |       |      |   |         |         |         |          |                                      |
| 7  |   |                    |                |  |               |          |        | ~        | -      |          |       |       |       |      |   |         |         |         |          |                                      |
| 8  |   |                    |                |  |               |          |        |          |        |          |       |       |       |      |   |         |         |         | $\vdash$ |                                      |
| 9  |   |                    |                |  | +             | -        |        |          | -      |          |       |       |       |      |   |         |         |         | $\vdash$ |                                      |
| 10 |   |                    |                |  | +             |          |        |          |        |          |       |       |       |      |   | _       |         | -       | $\vdash$ | -                                    |
| 10 | Relinquished B  | By: (Synature and  | Printed Name)  | Received By: (Signatu                          | re and Printe | ed Name) |        |          | L      | <u> </u> | Date: |       | Time: |      | ISA   | MPLE    | DISPO   | SITIO   | N:       | <u></u>                              |
|    | Relinquished B  | By: (Signature and | Printed Name)  | //////////////////////////////////////         | XIIII         | TVI)     | Chu    | idulue   | Juny   | 14       | Date: | 2-18/ | Time: |      | 1.  | Sampl   | es retu | rned to | o client |                                      |
|    | Relinquished E  | By: (Signature and | Printed Name)  | Received By: (Signatu                          | re and Printe | ed Name) |        |          |        |          | Date: |       | Time: |      | _ 2.  | additio | nal sto | rage ti | ime is r | l over 30 days, unless<br>requested. |
|    | SPECIAL I   | NSTRUCTIO          | NS:            |  |               |          |        |          |        |          |       |       |       | -    | 3.  |         | ge time | reque   | sted: _  | days                                 |



November 28, 2018

Tom Barnhart Colorado Energy Management 4963 Soto St. Vernon, CA 90058

Report No.: 1811191

Project Name: Malburg Generating Station Weekly

Dear Tom Barnhart,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on November 20, 2018.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.



#### 781 East Washington Blvd., Los Angeles, CA 90021 (213) 745-5312 FAX (213) 745-6372

### **Certificate of Analysis**

Page 2 of 2

Colorado Energy Management

File #:74548

Report Date: 11/28/18 Submitted: 11/20/18

PLS Report No.: 1811191

4963 Soto St. Vernon, CA 90058

Attn: Tom Barnhart

Phone: (323) 476-3626

FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

| Sample ID:     | Cooling Tower Blowdow | n Wat  | er (181   | 1191-0   | 1) Samı  | pled: 11  | /20/18  | 09:35 Re   | ceived: | 11/20/18   | 09:35 |       |    |          |
|----------------|-----------------------|--------|-----------|----------|----------|-----------|---------|------------|---------|--|-------|-------|----|----------|
| Analyte        | Re                    | esults | Flag      | D.F.     | Units    | PQL       | Pre     | p/Test Met | hod     | Prepared   | Anal  | yzed  | Ву | Batch    |
| Total Disso    | lved Solids 4         | 700    |           | 1        | mg/L     | 5.0       | -       | SM         | 2540C   | 11/20/18   | 11/2  | 21/18 | am | BK82706  |
|                |                       |        |           | Qı       | uality   | Contr     | ol Data | 1          |         |  |       |       |    |          |
|                |                       |        |           | 1        |          |           | Spike   | Source     |         | %REC   |       | RPD   |    |          |
| Analyte        |                       | Resi   | ılt       | PQL      |          | Units     | Level   | Result     | %REC    | Limits   | RPD   | Limit | Q  | ualifier |
| Batch BK8270   | 16                    |        |           |          |          |           |         |            |         |  |       |       |    |          |
| Blank          |                       | Prep   | ared: 11  | /20/18   | Analyzed | l: 11/21/ | 18      |            |         | A STATE OF THE STA |       |       |    |          |
| Total Dissolve | ed Solids             | ND     |           | 5.0      |          | mg/L      |         |            |         |  |       |       |    |          |
| LCS            |                       | Prep   | ared: 11, | /20/18 / | Analyzed | i: 11/21/ | 18      |            |         |  |       |       |    |          |
| Total Dissolve | ed Solids             | 365    | 5         | 5.0      |          | mg/L      | 356.0   |            | 103     | 80-120   |       |       |    |          |
| Duplicate      | Source: 1811174-01    | Prep   | ared: 11, | /20/18 / | Analyzed | l: 11/21/ | 18      |            |         |  |       |       |    |          |
| Total Dissolve | ed Solids             | 673    | 0         | 5.0      |          | mg/L      |         | 6650       |         |  | 1.21  | 5     |    |          |

#### **Notes and Definitions**

NA

Not Applicable

ND

Analyte NOT DETECTED at or above the detection limit

NR

Not Reported

MDL

Method Detection Limit

PQL

Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Authorized Signature(s)

|    |                | PC   | SIT           | IVE        | CHAIN OF  781 East Washington Blvc (213) 745-5312 FAX (213) |            |          |        |          | NAL    | YSI    |       |     |       | DAT  | E: /l' | 2/16    | 3        |          | PA        | GE (OF/                       |
|----|----------------|--|---------------|------------|---|------------|----------|--------|----------|--------|--------|-------|-----|-------|------|--------|---------|----------|----------|-----------|-------------------------------|
|    | CLIENT NA      | ME: CE   |               | A II CIL   | Project Na  |            |          |        |          | wn X   | ~ S    | - (   |     |       |      |        |         |          |          | LAD NO    | AIRBILL NO:                   |
|    | ADDRESS:       |  | 1             |            |   | ,          | 101      | פוטמ   | Co       | 1 60   | 7      |       | ANA | LYSES | REQU | ESTEI  | ):      |          |          |           | COOLER TEMP:                  |
|    | PROJECT I      | MANAGER:   | Ton B         | ein heit   | PHONE NO:   |            |          | FAX    | NO:      |        |        |       |     |       |      |        |         | ar i     |          |           | PRESERVATIVE:                 |
|    |                |  | mBarie        |            | 4.  | (Signatu   | ıre)     |        |          |        |        |       |     |       |      |        |         |          |          |           | REMARKS:                      |
|    | TAT (Analy     | tical Turn Ar  | ound Time):   | 0 = Same I | Day; 1 = 1 Day; 2 = 2 Days;                                 | 3 = 3 Da   | ays; N   | = Norn | nal (5-7 | 7 Work | ing Da | ays)  |     |       |      |        |         |          |          |           |                               |
|    | CONTAINE       | R TYPES: E   | B = Brass, E  | = Encore,  | G = Glass, P = Plastic, V =                                 | VOA Via    | ıl, 0 =  | Other: |          |        |        |       |     |       |      |        |         |          |          |           |                               |
|    | UST Proje      | ct: Y i  | N - Globa     | al ID#     |   |            |          |        |          |        | - N    | _     | ~   |       |      |        |         |          |          |           |                               |
|    | SAMPLE<br>NO.  | NO. SAMPLED SAMPLED SAMPLED SAMPLED DESCRIPTION WATER SOIL SLUDGE OTHER TAT # TYPE   CONTAINER/COMMENTS: |               |            |   |            |          |        |          |        |        |       |     |       |      |        |         |          |          |           |                               |
| 1  |                | 117072 0935 Goding Toner Blondon & NIPS  |               |            |   |            |          |        |          |        |        |       |     |       |      |        |         |          |          |           |                               |
| 2  |                | 11-1074 CH38 Cooling Jone Blordon C 1 1 Y  |               |            |   |            |          |        |          |        |        |       |     |       |      |        |         |          |          |           |                               |
| 3  |                |  |               |            |   |            |          |        |          |        | ,      |       |     |       |      |        |         |          |          |           |                               |
| 4  |                |  |               |            |   |            |          |        |          |        |        |       |     |       |      |        |         |          |          |           |                               |
| 5  |                |  |               |            |   |            |          |        |          |        |        |       |     |       |      |        |         |          |          |           |                               |
| 6  |                |  |               |            |   | _          |          |        |          |        |        | _     |     |       |      |        |         |          |          |           |                               |
| 7  |                |  |               |            |   | _          |          |        |          |        |        | _     |     |       |      |        |         |          |          |           |                               |
| 8  |                |  |               |            |   | -          |          |        |          |        |        | _     |     |       |      |        | -       |          |          |           |                               |
| 9  |                |  |               |            |   | ╄          | _        |        |          |        |        |       |     |       |      |        |         |          |          |           |                               |
| 10 | Relinquismed B | y: (Signature and  | Printed Name) |            | Received By Signatur  | alia Hala  | d Name)  | ,      |          |        |        | Date: |     | Time: |      | ISA    | MPLE    | DISPO    | SITIO    | N:        |                               |
|    | 1              | y: (Signature and  |               |            | Received By Signature                                       | and Printe | d Name)  | who    | rez      |        | //     | Date: | 3/9 | Time: |      | 1.     | Sampl   | les retu | irned to | o client? | ? YES NO over 30 days, unless |
|    | Relinquished B | y: (Signature and  | Printed Name) |            | Received By: (Signature                                     | and Printe | ed Name) |        |          |        |        | Date: |     | Time: |      | ٦.     | additio | onal sto | orage ti | ime is re | equested.                     |
|    | SPECIAL I      | SPECIAL INSTRUCTIONS:  3. Storage time requested: days  By Date  |               |            |   |            |          |        |          |        |        |       |     |       |      |        |         |          |          |           |                               |



November 30, 2018

Tom Barnhart Colorado Energy Management 4963 Soto St. Vernon, CA 90058

Report No.: 1811235

Project Name: Malburg Generating Station Weekly

Dear Tom Barnhart,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on November 26, 2018.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

Project Manager



#### 781 East Washington Blvd., Los Angeles, CA 90021 (213) 745-5312 FAX (213) 745-6372

### **Certificate of Analysis**

Page 2 of 2

Colorado Energy Management 4963 Soto St. Vernon, CA 90058 File #:74548

Report Date: 11/30/18 Submitted: 11/26/18

PLS Report No.: 1811235

Attn: Tom Barnhart

Phone: (323) 476-3626

Sample TD: Cooling Tower Blowdown Water (1911)25-01) Sampled: 11/26/19 11:50 Besolved: 11/26/19 11:50

FAX:(323) 476-3640

**Project:** Malburg Generating Station Weekly

| Sample 1D: C    | cooling Tower Blowdo | wn Wat  | er (181   | 1235-0 | 1) Samp  | oled: 11, | /26/18  | 11:50 Re   | eceived: | 11/26/18 | 11:50 |           |            |          |
|-----------------|----------------------|---------|-----------|--------|----------|-----------|---------|------------|----------|----------|-------|-----------|------------|----------|
| Analyte         |                      | Results | Flag      | D.F.   | Units    | PQL       | Pre     | p/Test Met | hod      | Prepared | Anal  | lyzed     | Ву         | Batch    |
| Total Dissolv   | ved Solids           | 4750    |           | 1      | mg/L     | 5.0       | -       | SM         | 2540C    | 11/29/18 | 11/3  | 30/18     | ai         | BK83018  |
|                 |                      |         |           | Qı     | uality   | Contro    | ol Data | ì          |          |          |       |           |            |          |
|                 |                      |         |           |        |          |           | Spike   | Source     |          | %REC     |       | RPD       |            |          |
| Analyte         |                      | Resu    | ılt       | PQL    | ı        | Jnits     | Level   | Result     | %REC     | Limits   | RPD   | Limit     | Q          | ualifier |
| Batch BK83018   | 8                    |         |           |        |          |           |         |            |          |          |       |           |            |          |
| Blank           |                      | Prep    | ared: 11  | /29/18 | Analyzed | : 11/30/  | 18      |            |          |          |       | 2.10-2-17 | A.Tonyotta |          |
| Total Dissolved | d Solids             | ND      |           | 5.0    | r        | mg/L      |         |            |          |          |       |           |            |          |
| LCS             |                      | Prep    | ared: 11, | /29/18 | Analyzed | : 11/30/  | 18      |            |          |          |       |           |            |          |
| Total Dissolved | d Solids             | 353     | 1         | 5.0    | ı        | mg/L      | 356.0   |            | 99.2     | 80-120   |       |           |            |          |
| Duplicate       | Source: 1811235-0    | 1 Prep  | ared: 11, | 29/18  | Analyzed | : 11/30/  | 18      |            |          |          |       |           |            |          |
| Total Dissolved | d Solids             | 4770    | 0         | 5.0    | г        | ng/L      |         | 4750       |          |          | 0.489 | 5         |            |          |
| Duplicate       | Source: 1811268-04   | 4 Prep  | ared: 11, | 29/18  | Analyzed | : 11/30/  | 18      |            |          |          |       |           |            |          |
| Total Dissolved | d Solids             | 4390    | 0         | 5.0    | r        | ng/L      |         | 4380       |          |          | 0.267 | 5         |            |          |

#### **Notes and Definitions**

NA

Not Applicable

ND

Analyte NOT DETECTED at or above the detection limit

NR

Not Reported

MDL

Method Detection Limit

**PQL** 

Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Authorized Signature(s)

|    | 1   | <b>JPC</b>         | SIT  | IVE CHAIN OF                                     | CUST                  | (DD            | Y AN     | ID A    | NAL    |        |       |      |       | DA- | re.   1: | 1610              | ζ.                   |                   | DΛ                 | GE / OE1                          |
|----|---|--------------------|--|--|-----------------------|----------------|----------|---------|--------|--------|-------|------|-------|-----|----------|-------------------|----------------------|-------------------|--------------------|-----------------------------------|
|    | <u>dd</u>   | LAE                | SER  | 781 East Washington Blvd (213) 745-5312 FAX (213 | I., Los A<br>3) 745-6 | ingeles<br>372 | s, CA 9  | 0021    |        |        | LOG   | воок | NO    | DA  | FIL      | E NO.             |                      | ו                 | LAB N              | OFOFOF                            |
|    | CLIENT NA   | ME: Color          | odo Energy                                       | Project Nar                                      | ne/No.                | Mell           | hua      | Gene    | Vide V | 150    | 100   | we   | ek'   | .y  | P.0      | . NO.             |                      |                   |                    | AIRBILL NO:                       |
|    | ADDRESS:  |                    | 3/   |  |                       |                | 7        |         |        |        |       |      | LYSES | ,   | IESTE    | D:                |                      |                   |                    | COOLER TEMP: 1./°                 |
|    | PROJECT I   | MANAGER:           | TOM BUILD  | hart PHONE NO:                                   |                       |                | FAX      | NO:     |        |        |       |      |       |     |          |                   |                      |                   |                    | PRESERVATIVE:                     |
|    | SAMPLER   | NAME:              | onn Base   | (Printed)  | (Signatu              | ıre)           |          |         |        |        |       |      |       |     |          |                   |                      |                   |                    | REMARKS:                          |
|    | TAT (Analy  | tical Turn Ar      | ound Time):                                      | 0 = Same Day; 1 = 1 Day; 2 = 2 Days; 3           | 3 = 3 Da              | ays; N         | = Norm   | nal (5- | 7 Work | ing Da | ays)  |      |       |     |          |                   |                      |                   |                    | ,                                 |
|    | CONTAINE  | R TYPES: E         | B = Brass, E                                     | = Encore, G = Glass, P = Plastic, V = V          | VOA Via               | ıl, 0 =        | Other:   |         |        |        |       |      |       |     |          |                   |                      |                   |                    |                                   |
|    | UST Proje   | ct: Y I            | l - Globa  | al ID#   |                       |                |          | -       | _      |        |       | ~    |       |     |          |                   |                      |                   |                    |                                   |
|    | SAMPLE DATE TIME SAMPLED SAMPLE DESCRIPTION MATRIX WATER SOIL SLUDGE OTHER TAT # TYPE SAMPLED |                    |  |  |                       |                |          |         |        |        |       |      |       |     |          |                   |                      |                   |                    |                                   |
| 1  |   |                    |  |  |                       |                |          |         |        |        |       |      |       |     |          |                   |                      |                   |                    |                                   |
| 2  |   |                    |  | 3  |                       |                |          |         |        |        |       | ,    |       |     |          |                   |                      |                   |                    |                                   |
| 3  |   |                    |  |  |                       |                |          |         |        |        |       |      |       |     |          |                   |                      |                   |                    | Ž.                                |
| 4  |   |                    |  |  |                       |                |          |         |        |        |       |      |       |     |          |                   |                      |                   |                    |                                   |
| 5  |   |                    |  | 7  |                       |                |          |         | v      |        |       |      |       |     |          | · · ·             |                      |                   |                    |                                   |
| 6  |   |                    |  |  |                       |                |          |         |        |        |       |      |       |     |          |                   |                      |                   |                    |                                   |
| 7  |   |                    |  |  |                       |                |          |         |        |        |       |      |       |     |          |                   |                      |                   |                    |                                   |
| 8  |   |                    |  |  |                       |                |          |         |        |        |       |      |       |     |          |                   |                      |                   |                    |                                   |
| 9  |   | V-                 |  |  |                       |                |          |         |        |        |       |      |       |     |          |                   |                      |                   |                    |                                   |
| 10 |   |                    |  |  |                       |                |          |         |        |        |       |      |       |     |          |                   |                      |                   |                    | .÷                                |
|    | - 0   | Signature and      |  | Received By: (Signature                          | ula                   | hum            | 11/11/17 | uula    |        |        |       | 3 M  |       |     |          |                   | DISP(<br>les retu    |                   | N:<br>o client     | ? YES NO                          |
|    |   | By: (Signature and | ** PETATA AND AND AND AND AND AND AND AND AND AN | Beceived By: (Signature  Received By: (Signature |                       |                |          |         | *      |        | Date: |      | Time: |     | 2.       | Sampl<br>addition | les will<br>onal sto | not be<br>rage ti | stored<br>ime is r | l over 30 days, unless requested. |
|    |   | By: (Signature and |  | neceived by, (orginalure                         | and i iiii            | o Hairie)      |          |         |        |        | Date. |      | Time. |     |          |                   |                      |                   |                    | days                              |
|    | SPECIALI  | NSTRUCTIO          | :си  |  |                       |                |          |         |        |        |       |      |       |     | Ву       |                   |                      | _                 |                    | Date                              |

# APPENDIX B EXCESS EMISSIONS REPORTS

### U1 CO Startup/Shutdown

From: 10/01/2018 00:00 To: 12/31/2018 23:59 Facility Name: Malburg Generating Station

Generated: 01/02/2019 09:58 Location: Vernon, California

Tag Name: U1\_CO\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

Total Operating Time: 1,496.53 Hours



|           |                             |          |       | Unit Operation     |                    |
|-----------|-----------------------------|----------|-------|--------------------|--------------------|
| E         | vent Period                 |          |       | Reason             | Action             |
| Begin/End | Duration<br>in<br>Minute(s) | Lb/Event | Limit | Code - Description | Code - Description |

### U1 NOx Startup/Shutdown

From: 10/01/2018 00:00 To: 12/31/2018 23:59 Facility Name: Malburg Generating Station

Generated: 01/02/2019 09:59 Location: Vernon, California

Tag Name: U1\_NOx\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

Total Operating Time: 1,496.53 Hours



|           |                             |          |       | Unit Operation     |                    |
|-----------|-----------------------------|----------|-------|--------------------|--------------------|
| E         | vent Period                 |          |       | Reason             | Action             |
| Begin/End | Duration<br>in<br>Minute(s) | Lb/Event | Limit | Code - Description | Code - Description |

### U1 VOC Startup/Shutdown

From: 10/01/2018 00:00 To: 12/31/2018 23:59 Facility Name: Malburg Generating Station

Generated: 01/02/2019 10:00 Location: Vernon, California

Tag Name: U1\_VOC\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

Total Operating Time: 1,496.53 Hours



| Unit Operation                                 |  |                    |                    |               |  |
|--|--|--------------------|--------------------|---------------|--|
| Event Period                                   |  |                    |                    | Reason Action |  |
| Duration in Begin/End Minute(s) Lb/Event Limit |  | Code - Description | Code - Description |               |  |

From:

### Unit 1 - CO ppmvdc 3-hour Rolling during Normal Operation

10/01/2018 00:00 To: 12/31/2018 23:59 Facility Name: Malburg Generating Station

Generated: 01/02/2019 09:49 Location: Vernon, California

HEOROT

Tag Name: U1\_CO\_3HrRoll\_Ppmvdc\_1H

Total Operating Time: 1,499.00 Hour(s) No Exclusions Allowed

Non-Operating Time: 709.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:

Total Duration (Online only):

Time in exceedance as a percentage of operating time:

Time in compliance as a percentage of operating time:

1,499.00 Hour(s)

0.00 %

100.00 %

### Unit 1 - NOx ppmvdc 1-hour during Normal Operation

HEI

From: 10/01/2018 00:00 To: 12/31/2018 23:59 Facility Name: Malburg Generating Station

Generated: 01/02/2019 09:47 Location: Vernon, California

Tag Name: U1\_NOxNormal\_Ppmvdc\_1H

Total Operating Time: 1,499.00 Hour(s) No Exclusions Allowed

Non-Operating Time: 709.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time: 1,499.00 Hour(s)

Total Duration (Online only): 0.00 Hour(s)

Time in exceedance as a percentage of operating time: 0.00 %

Time in compliance as a percentage of operating time: 100.00 %

### Unit 1 - VOC ppmvdc 1-hour during Normal Operation



From: 10/01/2018 00:00 To: 12/31/2018 23:59 Facility Name: Malburg Generating Station

Generated: 01/02/2019 09:51 Location: Vernon, California

Tag Name: U1\_VOCNormal\_Ppmvdc\_1H

Total Operating Time: 1,499.00 Hour(s) No Exclusions Allowed

Non-Operating Time: 709.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time: 1,499.00 Hour(s)

Total Duration (Online only): 0.00 Hour(s)

Time in exceedance as a percentage of operating time: 0.00%

Time in compliance as a percentage of operating time: 100.00 %

### Startup/Shutdown Event Report

### U2 CO Startup/Shutdown Events

From:

10/01/2018 00:00 **To:** 12/31/2018 23:59 **Facility Name:** Malburg Generating Station

Generated: 01/02/2019 10:05 Location: Vernon, California

Tag Name: U2\_CO\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

Total Operating Time: 1,459.60 Hours



| Unit Operation                                 |  |                    |                    |               |  |
|--|--|--------------------|--------------------|---------------|--|
| Event Period                                   |  |                    |                    | Reason Action |  |
| Duration in Begin/End Minute(s) Lb/Event Limit |  | Code - Description | Code - Description |               |  |

### Startup/Shutdown Event Report

### U2 VOC Startup/Shutdown Events

From: 10/01/2018 00:00 To: 12/31/2018 23:59 Facility Name: Malburg Generating Station

Generated: 01/02/2019 10:12 Location: Vernon, California

Tag Name: U2\_VOC\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

Total Operating Time: 1,459.60 Hours



| Unit Operation                                 |  |                    |                    |               |  |
|--|--|--------------------|--------------------|---------------|--|
| Event Period                                   |  |                    |                    | Reason Action |  |
| Duration in Begin/End Minute(s) Lb/Event Limit |  | Code - Description | Code - Description |               |  |

### U2 NOx Startup/Shutdown

From: 10/01/2018 00:00 To: 12/31/2018 23:59 Facility Name: Malburg Generating Station

Generated: 01/02/2019 10:11 Location: Vernon, California

Tag Name: U2\_NOx\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

Total Operating Time: 1,459.60 Hours



| Unit Operation                                 |  |                    |                    |               |  |
|--|--|--------------------|--------------------|---------------|--|
| Event Period                                   |  |                    |                    | Reason Action |  |
| Duration in Begin/End Minute(s) Lb/Event Limit |  | Code - Description | Code - Description |               |  |

### Unit 2 - CO ppmvdc 3-hour Rolling during Normal Operation



From: 10/01/2018 00:00 To: 12/31/2018 23:59 Facility Name: Malburg Generating Station

Generated: 01/02/2019 10:03 Location: Vernon, California

Tag Name: U2\_C0\_3HrRoll\_Ppmvdc\_1H

Total Operating Time: 1,465.00 Hour(s) No Exclusions Allowed

Non-Operating Time: 743.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:

Total Duration (Online only):

Time in exceedance as a percentage of operating time:

Time in compliance as a percentage of operating time:

1,465.00 Hour(s)

0.00 Hour(s)

100.00 %

From:

### Unit 2 - NOx ppmvdc 1-hour during Normal Operation

10/01/2018 00:00 To: 12/31/2018 23:59 Facility Name: Malburg Generating Station

Generated: 01/02/2019 10:04 Location: Vernon, California

HEOROT

Tag Name: U2\_NOxNormal\_Ppmvdc\_1H

Total Operating Time: 1,465.00 Hour(s) No Exclusions Allowed

Non-Operating Time: 743.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:

Total Duration (Online only):

Time in exceedance as a percentage of operating time:

Time in compliance as a percentage of operating time:

1,465.00 Hour(s)

0.00 Hour(s)

100.00 %

### Unit 2 - VOC ppmvdc 1-hour during Normal Operation

HEOROT

From: 10/01/2018 00:00 To: 12/31/2018 23:59 Facility Name: Malburg Generating Station

Generated: 01/02/2019 10:04 Location: Vernon, California

Tag Name: U2\_VOCNormal\_Ppmvdc\_1H

Total Operating Time: 1,465.00 Hour(s) No Exclusions Allowed

Non-Operating Time: 743.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time: 1,465.00 Hour(s)

Total Duration (Online only): 0.00 Hour(s)

Time in exceedance as a percentage of operating time: 0.00 %

Time in compliance as a percentage of operating time: 100.00 %

### **APPENDIX C**

### **Potable Water Usage Logs**

No Potable water was used for cooling for the year 2018

# APPENDIX G MGS RECLAIM ANNUAL EMISSION ALLOCATION

Section B Page: 1 Facility ID: 155474 Revision #: 13 Date: July 01, 2018

### FACILITY PERMIT TO OPERATE BICENT (CALIFORNIA) MALBURG LLC

#### SECTION B: RECLAIM ANNUAL EMISSION ALLOCATION

The annual allocation of NOx RECLAIM Trading Credits (RTCs) for this facility is calculated pursuant to Rule 2002. Total NOx emission shall not exceed such annual allocations unless the operator obtains RTCs corresponding to the facility's increased emissions in compliance with Rules 2005 and 2007.

The level of Starting Allocation plus Non-Tradable Credits used to determine compliance with Rule 2005(c)(4) and applicability of Rule 2005(e) - Trading Zone Restrictions is listed on the last page of this Section.

The following table lists the annual allocations that were issued to this facility and the amounts of RTCs held by this facility on the day of printing this Section.

### RECLAIM POLLUTANT ANNUAL ALLOCATION (POUNDS)

| Year<br>Begin End<br>(month/year) | Zone      | NOx RTC<br>Initially<br>Allocated | NOx RTC <sup>1</sup><br>Holding as of<br>07/01/2018<br>(pounds) | Non-Tradable<br>Non-Usable<br>RTCs<br>(pounds) |
|-----------------------------------|-----------|-----------------------------------|---|--|
| 7/2015 6/2016                     | Coastal   | 28480                             | 7517  | 0  |
| 1/2016 12/201                     | 6 Coastal | 0                                 | 7645  | 1854   |
| 7/2016 6/2017                     | Coastal   | 28480                             | 5699  | 1854   |
| 1/2017 12/201                     | 7 Coastal | 0                                 | 29794   | 0  |
| 7/2017 6/2018                     | Coastal   | 28480                             | 25012   | 0  |
| 1/2018 12/201                     | 8 Coastal | 0                                 | 30734   | 940  |
| 7/2018 6/2019                     | Coastal   | 28480                             | 24072   | 940  |
| 1/2019 12/201                     | 9 Coastal | 0                                 | 23132   | 940  |
| 7/2019 6/2020                     | Coastal   | 28480                             | 23132   | 940  |
| 1/2020 12/202                     | 0 Coastal | 0                                 | 21279   | 1854   |
| 7/2020 6/2021                     | Coastal   | 28480                             | 21278   | 1854   |
| 1/2021 12/202                     | 1 Coastal | 0                                 | 19398   | 1881   |
| 7/2021 6/2022                     | Coastal   | 28480                             | 19397   | 1881   |
| 1/2022 12/202                     | 2 Coastal | 0                                 | 15663   | 3735   |
| 7/2022 6/2023                     | Coastal   | 28480                             | 15663   | 3734   |
| 1/2023 12/202                     | Coastal   | 0                                 | 15663   | 0  |
| 7/2023 6/2024                     | Coastal   | 28480                             | 15663   | 0  |

#### Footnotes:

- This number may change due to pending trades, emissions reported under Quarterly Certification of Emissions Report (QCER) and Annual Permit Emission Program (APEP) Report required pursuant to Rule 2004, or deductions made pursuant to Rule 2010(b). The most recent total RTC information can be obtained from the District's RTC Listing.
- 2. The use of such credits is subject to restrictions set forth in paragraph (f)(1) of Rule 2002.

## South Coast Air Quality Management District 21865 Copley Drive, Diamond Bar, CA 91765-4178

Section B Page: Facility ID: 155 Revision #:

Date: July 01, 2018

13

### FACILITY PERMIT TO OPERATE BICENT (CALIFORNIA) MALBURG LLC

#### SECTION B: RECLAIM ANNUAL EMISSION ALLOCATION

The annual allocation of NOx RECLAIM Trading Credits (RTCs) for this facility is calculated pursuant to Rule 2002. Total NOx emission shall not exceed such annual allocations unless the operator obtains RTCs corresponding to the facility's increased emissions in compliance with Rules 2005 and 2007.

The level of Starting Allocation plus Non-Tradable Credits used to determine compliance with Rule 2005(c)(4) and applicability of Rule 2005(e) - Trading Zone Restrictions is listed on the last page of this Section.

The following table lists the annual allocations that were issued to this facility and the amounts of RTCs held by this facility on the day of printing this Section.

### RECLAIM POLLUTANT ANNUAL ALLOCATION (POUNDS)

| Year<br>Begin End<br>(month/year) | Zone    | NOx RTC<br>Initially<br>Allocated | NOx RTC <sup>1</sup><br>Holding as of<br>07/01/2018<br>(pounds) | Non-Tradable<br>Non-Usable<br>RTCs<br>(pounds) |
|-----------------------------------|---------|-----------------------------------|---|--|
| 1/2024 12/2024                    | Coastal | 0                                 | 15663   | 0  |
| 7/2024 6/2025                     | Coastal | 28480                             | 15663   | 0  |
| 1/2025 12/2025                    | Coastal | 0                                 | 15663   | 0  |
| 7/2025 6/2026                     | Coastal | 28480                             | 15663   | 0  |
| 1/2026 12/2026                    | Coastal | 0                                 | 15663   | 0  |
| 7/2026 6/2027                     | Coastal | 28480                             | 15663   | 0  |
| 1/2027 12/2027                    | Coastal | 0                                 | 15663   | 0  |
| 7/2027 6/2028                     | Coastal | 28480                             | 15663   | 0  |
| 1/2028 12/2028                    | Coastal | 0                                 | 15663   | 0  |
| 7/2028 6/2029                     | Coastal | 28480                             | 15663   | 0  |
| 1/2029 12/2029                    | Coastal | 0                                 | 15663   | 0  |
| 7/2029 6/2030                     | Coastal | 28480                             | 15663   | 0  |
| 1/2030 12/2030                    | Coastal | 0                                 | 15663   | 0  |
| 7/2030 6/2031                     | Coastal | 28480                             | 15663   | 0  |
| 1/2031 12/2031                    | Coastal | 0                                 | 15663   | 0  |
| 7/2031 6/2032                     | Coastal | 28480                             | 15663   | 0  |
| 1/2032 12/2032                    | Coastal | 0                                 | 15663   | 0  |
| T                                 |         |                                   |   |  |

#### Footnotes:

- This number may change due to pending trades, emissions reported under Quarterly Certification of Emissions Report (QCER) and Annual Permit Emission Program (APEP) Report required pursuant to Rule 2004, or deductions made pursuant to Rule 2010(b). The most recent total RTC information can be obtained from the District's RTC Listing.
- 2. The use of such credits is subject to restrictions set forth in paragraph (f)(1) of Rule 2002.

## South Coast Air Quality Management District 21865 Copley Drive, Diamond Bar, CA 91765-4178

Section B Page: 3 Facility ID: 155474 Revision #: 13 Date: July 01, 2018

### FACILITY PERMIT TO OPERATE BICENT (CALIFORNIA) MALBURG LLC

#### SECTION B: RECLAIM ANNUAL EMISSION ALLOCATION

The annual allocation of NOx RECLAIM Trading Credits (RTCs) for this facility is calculated pursuant to Rule 2002. Total NOx emission shall not exceed such annual allocations unless the operator obtains RTCs corresponding to the facility's increased emissions in compliance with Rules 2005 and 2007.

The level of Starting Allocation plus Non-Tradable Credits used to determine compliance with Rule 2005(c)(4) and applicability of Rule 2005(e) - Trading Zone Restrictions is listed on the last page of this Section.

The following table lists the annual allocations that were issued to this facility and the amounts of RTCs held by this facility on the day of printing this Section.

### RECLAIM POLLUTANT ANNUAL ALLOCATION (POUNDS)

| Yea<br>Begin<br>(month/ | ar<br>End<br>year) | Zone    | NOx RTC<br>Initially<br>Allocated | NOx RTC <sup>1</sup><br>Holding as of<br>07/01/2018<br>(pounds) | Non-Tradable<br>Non-Usable<br>RTCs<br>(pounds) |
|-------------------------|--------------------|---------|-----------------------------------|---|--|
| 7/2032                  | 6/2033             | Coastal | 28480                             | 15663   | 0  |
| 1/2033                  | 12/2033            | Coastal | 0                                 | 15663   | 0  |

#### Footnotes:

- This number may change due to pending trades, emissions reported under Quarterly Certification of Emissions Report (QCER) and Annual Permit Emission Program (APEP) Report required pursuant to Rule 2004, or deductions made pursuant to Rule 2010(b). The most recent total RTC information can be obtained from the District's RTC Listing.
- 2. The use of such credits is subject to restrictions set forth in paragraph (f)(1) of Rule 2002.



## South Coast Air Quality Management District 21865 Copley Drive, Diamond Bar, CA 91765-4178

Section B Page: 4
Facility ID: 155474
Revision #: 13

Date: July 01, 2018

### FACILITY PERMIT TO OPERATE BICENT (CALIFORNIA) MALBURG LLC

### SECTION B: RECLAIM ANNUAL EMISSION ALLOCATION

The annual allocation of RECLAIM Trading Credits (RTCs) for this facility is calculated pursuant to Rule 2002. If the facility submits a permit application to increase in an annual allocation to a level greater than the facility's starting Allocation plus Non-Tradable credits as listed below, the application will be evaluated for compliance with Rule 2005 (c)(4). Rule 2005 (e) - Trading Zone Restrictions applies if an annual allocation is increased to a level greater than the facility's Starting Allocation plus Non-Tradable Credits:

| Year                   |         | NOX RTC                      | Non-Tradable<br>Credits(NTC)<br>(pounds) |  |
|------------------------|---------|------------------------------|--|--|
| Begin End (month/year) | Zone    | Starting Allocation (pounds) |  |  |
| (monuly car)           |         | <b>u</b> ,                   | (P = 33222)                              |  |
| 7/1994 6/1995          | Coastal | 296280                       | 7720                                     |  |

# APPENDIX H MGS RISK MANAGEMENT PLAN ACCEPTANCE LETTER



#### Health and Environmental Control Department

Lewis J. Pozzebon, Director / Health Officer 4305 Santa Fe Avenue, Vernon, California 90058 Telephone (323) 583-8811

July 23, 2009

Colorado Energy Management, LLC 4963 Soto Street Vernon, California 90058 Attn: Erik Knutson, Plant Manager

SUBJECT:

California Accidental Release Prevention (CalARP) Risk Management Plan

(RMP) for Malburg Generation Station located at 4963 Soto Street, Vernon,

California 90058

Dear Mr. Knutson:

We have conducted a review of the subject CalARP documentation for the aqueous ammonia system at the subject facility. Based upon the information submitted, our Department accepts the document as complete. In accordance to California Health and Safety Code, Division 20, Chapter 6.95, Section 25535.2, we have notified the public that the RMP documents will be available for review for a period of 45 calendar days starting from the above date. During this time period, the public will have the opportunity to submit written comments to our Department. Thank you for your cooperation. Please call me at (323) 583-8811 extension 204 if you have any questions or comments.

Sincerely,

Jerrick Torres, R.E.H.S. Environmental Specialist

Cc: Fire Department

Community Services & Water Department

## APPENDIX I

#### MGS CEC COMMISSION DECISION COMPLIANCE MATRIX

## Malburg Generating Station CEC Conditions of Cerfitication Compliance Matrix

| Condition # | Subject   | Condition Description   | Means of Verification   | Methods & Comments   |
|-------------|---|---|---|--|
| COM-1       |   |   |   | Condition completely satisfied.  |
| COM-2       | Access  | The project owner shall grant Energy<br>Commission staff and delegate agencies<br>or consultants unrestricted access to the<br>power plant site.  | None Specified  | The Malburg Generating Facility site remains accessible for Energy Commission staff and delegate agencies or consultants.  |
| COM-3       | Compliance<br>Record                                    | The project owner shall maintain project files onsite. Energy Commission staff and delegate agencies shall be given unrestricted access to the files.   | None Specified  | Project files are on site. Energy Commission staff and delegate agencies are given unrestricted access to the files.   |
| COM-4       | Compliance<br>Verification<br>Submittals                | The project owner is responsible for the delivery and content of all verification submittals to the CPM, whether such condition was satisfied by work performed or the project owner or his agent.  | None Specified  | MGS is responsible for the delivery and content of all verification submittals to the CPM.   |
| COM-5       |   |   |   | Condition completely satisfied.  |
| COM-6       | Compliance<br>Matrix                                    | The project owner shall submit a compliance matrix (in a spreadsheet format) with each monthly and annual compliance report which includes the status of all compliance conditions of certification.  | None Specified  | This matrix satisfies the requirement and will be submitted with each annual compliance report.  |
| COM-7       |   |   |   | Condition completely satisfied.  |
| COM-8       | Annual<br>Compliance<br>Reports                         | After construction ends and throughout the life of the project, the project owner shall submit Annual Compliance Reports (ACRs) which include specific information. The first ACR is due after the air district has issued a Permit to Operate.   | Eleven specific requirements are listed in the Decision   | Reports are submitted annually as required. Responses to the eleven specific requirements are included in the Annual Fourth Quarter Compliance Report.   |
| COM-9       |   |   |   | Condition completely satisfied.  |
| COM-10      |   |   |   | Condition completely satisfied.  |
| COM-11      |   |   |   | Condition completely satisfied.  |
| COM-12      | Reporting of<br>Complaints,<br>Notices and<br>Citations | Within 10 days of receipt, the project owner shall report to the CPM, all notices, complaints, and citations.   | None Specified  | MGS shall report all notices, complaints, and citations to the CPM within 10 days of receipt. If no such item is received, this is verified in each annual report.   |
| COM-13      | Planned Facility<br>Closure                             | The project owner shall submit a closure plan to the CPM at least twelve months prior to commencement of a planned closure.   | None Specified  | MGS will submit plan as required at closure of facility. No action required until that time, but facility non-closure is affirmed in each annual report.   |
| COM-14      | Unplanned<br>Temporary<br>Facility Closure              | To ensure that public health and safety and the environment are protected in the event of an unplanned temporary closure, the project owner shall submit an on-site contingency plan no less than 60 days prior to commencement of commercial operation. The approved plan must be in place prior to commercial | The project owner, in consultation with the CPM, will update the on-site contingency plan as necessary. The CPM may require revisions to the onsite contingency plan over the life of the project. In the annual compliance reports submitted to the Energy | MGS will review the on-site contingency plan in the annual compliance reports, and recommend changes to bring the plan up to date. In the event of an unplanned temporary closure, MGS shall notify the CPM, as well as other responsible agencies, by telephone, fax, or e-mail, within 24 hours and shall take |

| Condition # | Subject  | Condition Description  | Means of Verification  | Methods & Comments  |
|-------------|--|--|--|---|
|             |  | operation of the facility and shall be kept at the site at all times.  | Commission, the project owner will review the on-site contingency plan, and recommend changes to bring the plan up to date. Any changes to the plan must be approved by the CPM. In the event of an unplanned temporary closure, the project owner shall notify the CPM, as well as other responsible agencies, by telephone, fax, or email, within 24 hours and shall take all necessary steps to implement the on-site contingency plan. | all necessary steps to implement the onsite contingency plan.   |
| COM-15      | Unplanned<br>Permanent<br>Facility Closure       | To ensure that public health and safety and the environment are protected in the event of an unplanned permanent closure, the project owner shall submit an on-site contingency plan no less than 60 days prior to commencement of commercial operation. | All of the requirements specified for unplanned temporary closure shall also apply to unplanned permanent closure.   | In the event of an unplanned permanent closure, MGS shall notify the CPM, as well as other responsible agencies, by telephone, fax, or e-mail, within 24 hours and shall take all necessary steps to implement the on-site contingency plan. No action required until that time, but facility non-closure should be affirmed in each annual report. |
| COM-16      | Post certification<br>changes to the<br>Decision | The project owner must petition the Energy Commission to delete or change a condition of certification, modify the project design or operational requirements and/or transfer ownership of operational control of the facility.                          | None Specified   | Whether or not such a submission has taken place during the prior year is addressed in each annual report.  |
| GEN-1       |  |  |  | Condition completely satisfied.   |
| GEN-2       |  |  |  | Condition completely satisfied.   |
| GEN-3       |  |  |  | Condition completely satisfied.   |
| GEN-4       |  |  |  | Condition completely satisfied.   |
| GEN-5       |  |  |  | Condition completely satisfied.   |
| GEN-6       |  |  |  | Condition completely satisfied.   |
| GEN-7       |  |  |  | Condition completely satisfied.   |
| GEN-8       |  |  |  | Condition completely satisfied.   |
| CIVIL-1     |  |  |  | Condition completely satisfied.   |
| CIVIL-2     |  |  |  | Condition completely satisfied.   |
| CIVIL-3     |  |  |  | Condition completely satisfied.   |
| CIVIL-4     |  |  |  | Condition completely satisfied.   |
| STRUC-1     |  |  |  | Condition completely satisfied.   |
| STRUC-2     |  |  |  | Condition completely satisfied.   |
| STRUC-3     |  |  |  | Condition completely satisfied.   |
| STRUC-4     |  |  |  | Condition completely satisfied.   |
| MECH-1      |  |  |  | Condition completely satisfied.   |
| MECH-2      |  |  |  | Condition completely satisfied.   |
| MECH-3      |  |  |  | Condition completely satisfied.   |
| ELEC-1      |  |  |  | Condition completely satisfied.   |
| TSE-1       |  |  |  | Condition completely satisfied.   |

| Condition # | Subject                          | Condition Description   | Means of Verification  | Methods & Comments  |
|-------------|----------------------------------|---|--|---|
| TSE-2       |                                  |   |  | Condition completely satisfied.   |
| TSE-3       |                                  |   |  | Condition completely satisfied.   |
| TSE-4       |                                  |   |  | Condition completely satisfied.   |
| TSE-5       |                                  |   |  | Condition completely satisfied.   |
| TSE-6       |                                  |   |  | Condition completely satisfied.   |
| TSE-7       |                                  |   |  | Condition completely satisfied.   |
| TSE-8       |                                  |   |  | Condition completely satisfied.   |
| TLSN-1      |                                  |   |  | Condition completely satisfied.   |
| AQ-C1       |                                  |   |  | Condition completely satisfied.   |
| AQ-C2       |                                  |   |  | Condition completely satisfied.   |
| AQ-C3       |                                  |   |  | Condition completely satisfied.   |
| AQ-C4       |                                  |   |  | Condition completely satisfied.   |
| AQ-C5       | Chromium compounds               | No chromium containing compounds shall be added to cooling tower circulating water.   | The City of Vernon shall make the site available for inspection by representatives of the District, CARB and the Commission.   | The site remains available for inspection by representatives of the District, CARB and the Commission.  |
| AQ-C6       | Blowdown water                   | The City of Vernon shall determine the TDS levels in the blowdown water by independent laboratory testing prior to initial operation and periodically thereafter.   | The City of Vernon shall submit for approval to the CPM, a protocol for initial and weekly testing and the identification of the independent laboratory to be used 90 days prior to cooling tower operation. The City of Vernon shall submit weekly TDS reports for the blowdown water as part of the quarterly emission report to the CPM for approval. | MGS shall submit weekly TDS reports for the blowdown water as part of the quarterly emission report to the CPM for approval.  |
| AQ-C7       | PM emissions                     | PM10 emissions from the cooling tower (in total) shall not exceed 6.2 lb/day.   | The City of Vernon shall calculate the daily PM10 emissions from the cooling tower and submit all calculations and results on a quarterly basis in the quarterly emission reports to the CPM for approval.   | MGS shall calculate the daily PM10 emissions from the cooling tower and submit all calculations and results on a quarterly basis in the quarterly emission reports to the CPM for approval. |
| AQ-C8       | Firewater pump<br>testing        | The City of Vernon shall refrain from testing the firewater pump on the same day as either gas fire combustion turbines have been started up or shut down as defined by Condition of Certification AQ-C9.                                     | The City of Vernon shall submit to the CPM for approval all testing times and results of the diesel fired emergency firewater pump in the quarterly emissions report.  | MGS shall submit to the CPM for approval all testing times and results of the diesel fired emergency firewater pump in the quarterly emissions report.                                      |
| AQ-C9       | Startup/Shut-<br>down compliance | The City of Vernon shall use the following definitions to determine compliance with startup, shutdown and any related emission or operational limitations.  Startup is defined as beginning when fuel is first delivered to the combustors of | See Verification for Condition of Certification AQ-6.  | MGS shall submit to the CPM for approval, a record of all startups and shutdowns including duration and date of occurrence on a quarterly basis as part of the quarterly emission report.   |
|             |                                  | the combustion turbine and ending when the combustion turbine reaches all NOx and CO emission limits for normal operation.  Shutdown is defined as beginning during normal operation with the intent to                                       |  |   |
|             |                                  | shutdown and ends with the secession of fuel being delivered to the combustors of   |  |   |

| Condition # | Subject                                      | Condition Description  the combustion turbine.   | Means of Verification  | Methods & Comments  |
|-------------|--|--|--|---|
| AQ-C10      | Emission limits                              | The City of Vernon shall commission and operate the Malburg Generation Station within the emission limits.   | The City of Vernon shall submit to the CPM for approval on a quarterly basis all emission records and calculations to demonstrate compliance with the emission limits stated herein as part of the quarterly emissions report.   | MGS shall submit to the CPM for approval on a quarterly basis all emission records and calculations to demonstrate compliance with the emission limits stated herein as part of the quarterly emissions report.   |
| AQ-C11      | Quarterly emissions report                   | The City of Vernon shall submit a quarterly emissions report on a quarterly basis to the CPM for approval. The quarterly emissions report shall generally report all ammonia, NOx, SOx, CO, PM10 and VOC emissions from the Malburg Generation Station as necessary to demonstrate compliance with all emission limits. The fourth quarter emission report shall include an annual summary of all emissions of ammonia, NOx, SOx, CO, PM10 and VOC as necessary to demonstrate compliance with all annual emission limits. | The City of Vernon shall submit to the CPM the quarterly emissions report no less than 30 days after the end of each calendar quarter.   | MGS shall submit to the CPM the quarterly emissions report no less than 30 days after the end of each calendar quarter.   |
| AQ-C12      |  |  |  | Condition completely satisfied.   |
| AQ-C13      | Modification to air permit                   | The City of Vernon shall submit to the CPM for review and approval any modification proposed by either the City or issuing agency to any project air permit.   | The City of Vernon shall submit any proposed air permit modification to the CPM within five working days of its submittal either by the City to an agency, or receipt of proposed modifications from an agency. The City of Vernon shall submit all modified air permits to the CPM within 15 days of receipt. | MGS shall submit any proposed air permit modification to the CPM within five working days of its submittal either by MGS to an agency, or receipt of proposed modifications from an agency. MGS shall submit all modified air permits to the CPM within 15 days of receipt.   |
| AQ-C14      |  |  |  | Condition completely satisfied.   |
| AQ-1        | Emissions<br>discharge                       | Except for open abrasive blasting operations, the City of Vernon shall not discharge into the atmosphere from any single source of emissions whatsoever any contaminant for a period or periods aggregating more than three minutes in any one hour as listed.   | The City of Vernon shall make the Malburg Generating Facility site accessible for inspection to the District, CARB and Commission.   | The Malburg Generating Facility site remains accessible for inspection to the District, CARB and Commission.  |
| AQ-2        | Diesel oil<br>containing sulfur<br>compounds | The City of Vernon shall not use diesel oil containing sulfur compounds in excess of 15 ppm by weight as supplied by the supplier.   | The City of Vernon shall submit fuel purchase records for approval to the CPM on a quarterly basis in the quarterly emissions report.  | MGS shall submit fuel purchase records for approval to the CPM on a quarterly basis in the quarterly emissions report.  |
| AQ-3        | Fuel purchase<br>records & sulfur<br>content | The city of Vernon shall keep records, in a manner approved by the District, for the following parameter(s) or item(s): Purchase records of fuel oil and sulfur content of the fuel  | The City of Vernon shall submit fuel purchase records for approval to the CPM on a quarterly basis in the quarterly emissions report.  | MGS shall submit fuel purchase records for approval to the CPM on a quarterly basis in the quarterly emissions report.  |
| AQ-4        | Accident release prevention                  | Accident release prevention requirements of Section 112 (r)(7):  a). The City of Vernon shall comply with the accidental release prevention requirements pursuant to 40CFR Part 68 and shall submit to the Executive Officer and the CPM, as a part of an annual compliance certification, a   | The City of Vernon shall submit for approval to the CPM the above required statement of compliance and any further information requested on an annual basis as part of the annual compliance report.   | MGS shall submit to the Executive Officer and the CPM, as a part of an annual compliance certification, a statement that certifies compliance with all of the requirements of 40 CFR Part 68, including the registration and admission of a risk management plan (RMP). In addition, MGS shall submit any additional relevant information requested by the Executive Officer, |

| Condition # | Subject                     | <b>Condition Description</b>  | Means of Verification   | Methods & Comments   |
|-------------|-----------------------------|---|---|--|
|             |                             | statement that certifies compliance with all of the requirements of 40 CFR Part 68, including the registration and admission of a risk management plan (RMP).   |   | designated agency or CPM.  |
|             |                             | b). The City of Vernon shall submit any additional relevant information requested by the Executive Officer, designated agency or CPM.   |   |  |
| AQ-5        | Steam generator emissions   | The City of Vernon shall limit the emissions from both gas fired combustion turbine-heat recovery steam generator train exhaust stacks.   | The City of Vernon shall submit all emission calculations, fuel use, CEM records and a summary demonstrating compliance of all emission limits stated in this Condition for approval to the CPM on a quarterly basis in the quarterly emissions report.   | MGS shall submit all emission calculations, fuel use, CEM records and a summary demonstrating compliance of all emission limits stated in this Condition for approval to the CPM on a quarterly basis in the quarterly emissions report. |
| AQ-6        | 2 ppm NOx<br>emission limit | The 2 ppm NOx emission limit shall not apply during turbine commissioning, start-up and shutdown. The commissioning period shall not exceed 573 operating hours per turbine from the initial start-up.  Following commissioning, start-ups shall not exceed 2 hours and the number of startups shall not exceed one per day per turbine.  Following commissioning, shutdowns shall not exceed 30 minutes and the number of shutdowns shall not exceed one per day per turbine. The City of Vernon shall provide the District and the CPM with the written notification of the initial start-up date. Written records of commissioning, start-ups and shutdowns shall be kept and made available to District and submitted to the CPM for                | The City of Vernon shall provide the District and the CPM with the written notification of the initial start-up date no later than 60 days prior to the startup date. The City of Vernon shall report to the CPM for approval all emissions, fuel use and emission calculations during the commissioning period on a monthly basis as part of the monthly compliance report. The City of Vernon shall submit to the CPM for approval, a record of all startups and shutdowns including duration and date of occurrence on a quarterly basis as part of the quarterly emission report. | MGS shall submit to the CPM for approval, a record of all startups and shutdowns including duration and date of occurrence on a quarterly basis as part of the quarterly emission report.  |
| AQ-7        | 2 ppm CO emission limit     | approval.  The 2 ppm CO emission limit shall not apply during turbine commissioning, start-up and shutdown. The commissioning period shall not exceed 573 operating hours per turbine from the initial start-up.  Following commissioning, start-ups shall not exceed 2 hours and the number of startups shall not exceed one per day per turbine.  Following commissioning, shutdowns shall not exceed 30 minutes and the number of shutdowns shall not exceed one per day per turbine. The City of Vernon shall provide the District and CPM with the written notification of the initial start-up date. Written records of commissioning, start-ups and shutdowns shall be kept and made available to District and reported for approval to the CPM. | See Verification for Condition of Certification AQ-6.   | MGS shall submit to the CPM for approval, a record of all startups and shutdowns including duration and date of occurrence on a quarterly basis as part of the quarterly emission report.  |

| Condition # | Subject   | Condition Description   | Means of Verification   | Methods & Comments   |
|-------------|---|---|---|--|
| AQ-8        | 80.13 lb/mscf<br>NOx emission<br>limits   | The 80.13 lb/mmscf NOx emission limit(s) shall only apply during interim period to report RECLAIM emissions. The interim period shall not exceed 12 months from the initial start-up date.                              | The City of Vernon shall submit to the CPM for approval all emissions and emission calculations on a quarterly basis as part of the quarterly emissions report. | MGS shall submit to the CPM for approval all emissions and emission calculations on a quarterly basis as part of the quarterly emissions report.       |
| AQ-9        | 2 ppm NOx<br>emissions limits<br>average  | The 2 PPM NOx emissions limit(s) are averaged over 1 hour at 15 percent oxygen, dry basis.  | The City of Vernon shall submit to the CPM for approval all emissions and emission calculations on a quarterly basis as part of the quarterly emissions report. | MGS shall submit to the CPM for approval all emissions and emission calculations on a quarterly basis as part of the quarterly emissions report.       |
| AQ-10       | 2 ppm CO<br>emission limits<br>average  | The 2 ppm CO emission limit(s) are averaged over 3 hours at 15 percent oxygen, dry basis.   | The City of Vernon shall submit to the CPM for approval all emissions and emission calculations on a quarterly basis as part of the quarterly emissions report. | MGS shall submit to the CPM for approval all emissions and emission calculations on a quarterly basis as part of the quarterly emissions report.       |
| AQ-11       | 2 ppm ROG<br>emission limits<br>average   | The 2 ppm ROG emission limit(s) are averaged over 1 hour at 15 percent oxygen, dry basis.   | The City of Vernon shall submit to the CPM for approval all emissions and emission calculations on a quarterly basis as part of the quarterly emissions report. | MGS shall submit to the CPM for approval all emissions and emission calculations on a quarterly basis as part of the quarterly emissions report.       |
| AQ-12       | 5 ppm NH3<br>emission limits<br>average   | The 5 ppm NH3 emission limit(s) are averaged over 1 hour at 15 percent oxygen, dry basis. The City of Vernon shall calculate and continuously record the ammonia slip concentration using the provided formula.         | The City of Vernon shall submit to the CPM for approval all emissions and emission calculations on a quarterly basis as part of the quarterly emissions report. | MGS shall submit to the CPM for approval all emissions and emission calculations on a quarterly basis as part of the quarterly emissions report.       |
| AQ-13       | Compliance with<br>District Rule 475  | For the purpose of determining compliance with District Rule 475, combustion contaminant emissions may exceed the concentration limit or the mass emission limit listed, but not both emission limits at the same time. | The City of Vernon shall submit to the CPM for approval all emissions and emission calculations on a quarterly basis as part of the quarterly emissions report. | MGS shall submit to the CPM for approval all emissions and emission calculations on a quarterly basis as part of the quarterly emissions report.       |
| AQ-14       | Engine cylinder lubricating oil   | The City of Vernon shall not use engine cylinder lubricating oil containing the following specified compounds:  Ash Content Greater than 0.038  | The City of Vernon shall submit fuel purchase records for approval to the CPM on a quarterly basis in the quarterly emissions report.                           | MGS shall submit to the CPM for approval all emissions and emission calculations on a quarterly basis as part of the quarterly emissions report.       |
| AQ-15       | Operating time for<br>Diesel fueled<br>backup<br>generators &<br>firewater pump | The City of Vernon shall limit the operating time of the diesel fueled emergency backup generators and the firewater pump to no more than 199 hours each in any one year.   | See Verification for Condition of Certification AQ-C8.  | MGS shall submit to the CPM for approval all testing times and results of the diesel fired emergency firewater pump in the quarterly emissions report. |
| AQ-16       | Pressure relief valves  | The City of Vernon shall install and maintain a pressure relief valve set at 25 psig in the ammonia storage tank.   | The City of Vernon shall make the ammonia storage tank available for inspection by the District, Commission or CARB.  | The ammonia storage tank remains accessible for inspection to the District, CARB and Commission.   |
| AQ-17       | Elapsed time<br>meter in firewater<br>pump                                      | The City of Vernon shall install and maintain a(n) non-resettable elapsed time meter into the firewater pump to accurately indicate the elapsed operating time of the engine.   | The City of Vernon shall make the firewater pump available for inspection by the District, Commission or CARB.  | The firewater pump remains accessible for inspection to the District, CARB and Commission.   |
| AQ-18       | Totalizing fuel<br>meter  | The City of Vernon shall install and maintain a(n) non-resettable totalizing fuel meter to accurately indicate the fuel usage of the turbines.  | The City of Vernon shall make the firewater pump available for inspection by the District, Commission or CARB.  | The firewater pump remains accessible for inspection to the District, CARB and Commission.   |
| AQ-19       | Injected ammonia (NH <sub>3</sub> )   | The City of Vernon shall install and maintain a(n) flow meter to accurately indicate the flow rate of the total hourly  | The City of Vernon shall submit to CPM for approval the design drawing that clearly show the flow meter and   | MGS shall submit to the CPM for approval the annual calibration report for the flow meter and recording device as                                      |

| Condition # | Subject                                       | Condition Description   | Means of Verification  | Methods & Comments  |
|-------------|---|---|--|---|
|             |   | throughput of injected ammonia (NH3).  The City of Vernon shall also install and maintain a device to continuously record the parameter being measured.  The measuring device or gauge shall be accurate to within plus or minus 5 percent. It shall be calibrated once every 12 months.  | recording device for the ammonia injection grid no less than 90 days prior to installation of the ammonia injection grid. The City of Vernon shall submit to the CPM for approval the annual calibration report for the flow meter and recording device as part of the annual compliance report.   | part of the annual compliance report.   |
| AQ-20       | SCR exhaust temperature                       | The City of Vernon shall install and maintain a(n) temperature gauge to accurately indicate the temperature in the exhaust at the inlet to the SCR reactor.  The City of Vernon shall also install and maintain a device to continuously record the parameter being measured. The measuring device or gauge shall be accurate to within plus or minus 5 percent. It shall be calibrated once every 12 months.               | The City of Vernon shall submit to CPM for approval the design drawing that clearly show the temperature gauge and recording device for the inlet to the SCR reactor no less than 90 days prior to installation of the SCR. The City of Vernon shall submit to the CPM for approval the annual calibration report for the temperature gauge and recording device as part of the annual compliance report.  | MGS shall submit to the CPM for approval the annual calibration report for the temperature gauge and recording device as part of the annual compliance report.  |
| AQ-21       | Differential pressure across SCR catalyst bed | The City of Vernon shall install and maintain a(n) pressure gauge to accurately indicate the differential pressure across the SCR catalyst bed in inches of water column.  The City of Vernon shall also install and maintain a device to continuously record the parameter being measured. The measuring device or gauge shall be accurate to within plus or minus 5 percent. It shall be calibrated once every 12 months. | The City of Vernon shall submit to CPM for approval the design drawing that clearly show the pressure gauge and recording device across the SCR reactor no less than 90 days prior to installation of the SCR. The City of Vernon shall submit to the CPM for approval the annual calibration report for the pressure gauge and recording device as part of the annual compliance report.  | MGS shall submit to the CPM for approval the annual calibration report for the pressure gauge and recording device as part of the annual compliance report.   |
| AQ-22       | Source test(s) for pollutants                 | The City of Vernon shall conduct source test (s) for the pollutant(s) identified below:  - CO Emissions - NOx EmissionsPM Emissions VOC Emissions - SOx Emissions - NH3 Emissions   | The City of Vernon shall submit for approval to the District and the CPM the required initial source testing protocol no less than 45 days prior to the date of the source test. The City of Vernon shall notify the District and CPM of the date and time of the source test no less than 10 days prior to the test. The City of Vernon shall submit to the District and CPM for approval the results of the initial source test no later than 60 days following the date of the source test. | MGS shall submit for approval to the District and the CPM the required source testing protocol no less than 45 days prior to the date of the source test. MGS shall notify the District and CPM of the date and time of the source test no less than 10 days prior to the test. MGS shall submit to the District and CPM for approval the results of the initial source test no later than 60 days following the date of the source test. |
| AQ-23       | Source test(s) for pollutants                 | The City of Vernon shall conduct source test(s) for the pollutant(s) identified below:  - VOC Emissions  - SOx Emissions  - PM Emissions  | The City of Vernon shall submit for approval to the District and the CPM the required source testing protocol no less than 45 days prior to the date of the source test. The City of Vernon shall notify the District and CPM of the date and time of the source test no less than 10 days prior to the test. The City of Vernon shall submit to the District and CPM for approval the results of the source test no later than 60 days following the date of the source test.                 | MGS shall submit for approval to the District and the CPM the required source testing protocol no less than 45 days prior to the date of the source test. MGS shall notify the District and CPM of the date and time of the source test no less than 10 days prior to the test. MGS shall submit to the District and CPM for approval the results of the initial source test no later than 60 days following the date of the source test. |
| AQ-24       | Source test(s) for                            | The City of Vernon shall conduct source   | The City of Vernon shall submit for  | MGS shall submit for approval to the  |

| Condition # | Subject                                 | Condition Description   | Means of Verification  | Methods & Comments   |
|-------------|---|---|--|--|
|             | pollutants                              | test(s) for the pollutant(s) identified below:  NH3 Emissions   | approval to the District and the CPM the required source testing protocol no less than 45 days prior to the date of the source test. The City of Vernon shall notify the District and CPM of the date and time of the source test no less than 10 days prior to the test. The City of Vernon shall submit to the District and CPM for approval the results of the source test no later than 60 days following the date of the source test. | District and the CPM the required source testing protocol no less than 45 days prior to the date of the source test. MGS shall notify the District and CPM of the date and time of the source test no less than 10 days prior to the test. MGS shall submit to the District and CPM for approval the results of the initial source test no later than 60 days following the date of the source test. |
| AQ-25       | Exhaust stack<br>CEMS                   | The City of Vernon shall install and maintain a CEMS in each exhaust stack of the combustion turbine-HRSG trains to measure tlisted parameters:   | The City of Vernon shall make the Malburg Generation Station available for inspection by the District, Commission or CARB.   | The Malburg Generating Station remains accessible for inspection to the District, CARB and Commission.   |
| AQ-26       | CEMs                                    | The City of Vernon shall install and maintain a CEMS to measure listed parameters.  | The City of Vernon shall make the Malburg Generation Station available for inspection by the District, Commission or CARB.   | The Malburg Generating Station remains accessible for inspection to the District, CARB and Commission.   |
| AQ-27       | Fuel usage                              | The City of Vernon shall limit the fuel usage of each turbine-duct burner pair to no more than 330 million cubic feet per month. The City of Vernon shall keep records, in a manner approved by the District, for the operational status of the duct burners and their fuel use.  | The City of Vernon shall submit to the CPM for approval all emissions and emission calculations on a quarterly basis as part of the quarterly emissions report.  | MGS shall submit to the CPM for approval all emissions and emission calculations on a quarterly basis as part of the quarterly emissions report.   |
| AQ-28       | Venting                                 | The City of Vernon shall vent combustion turbines and HRSGs to the CO oxidation/SCR control system whenever the turbines are in operation.  | The City of Vernon shall make the Malburg Generation Station available for inspection by the District, Commission or CARB.   | The Malburg Generating Station remains accessible for inspection to the District, CARB and Commission.   |
| AQ-29       | Venting                                 | The City of Vernon shall vent ammonia storage tank, during filling, only to the vessel from which it is being filled.   | The City of Vernon shall make the Malburg Generation Station available for inspection by the District, Commission or CARB.   | The Malburg Generating Station remains accessible for inspection to the District, CARB and Commission.   |
| AQ-30       | Continuously record                     | For the purpose of the following condition number(s), "continuously record" shall be defined as recording at least once every hour and shall be calculated upon the average of the continuous monitoring for that hour.  Condition of Certification AQ-17  Condition of Certification AQ-18   | The City of Vernon shall make the Malburg Generation Station available for inspection by the District, Commission or CARB.   | The Malburg Generating Station remains accessible for inspection to the District, CARB and Commission.   |
| AQ-31       | Continuously record                     | For the purpose of the following condition number(s), "continuously record" shall be defined as recording at least once every hour and shall be calculated based upon the average of the continuous monitoring for that month.  | The City of Vernon shall make the Malburg Generation Station available for inspection by the District, Commission or CARB.   | The Malburg Generating Station remains accessible for inspection to the District, CARB and Commission.   |
| AQ-32       | MGS electric<br>generating<br>equipment | Condition of Certification AQ-19  The MGS electric generating equipment shall not be operated unless the City of Vernon demonstrates to the Executive Officer that the facility holds sufficient RTCs to offset the prorated annual emissions increase for the first compliance year of operation. In addition, this equipment shall not be | The City of Vernon shall submit all identified evidence demonstrating compliance to the CPM on an annual basis as part of the annual compliance report.  | MGS shall submit all identified evidence demonstrating that, at the commencement of each compliance year, the facility holds sufficient RTCs in an amount equal to the annual emission increase to the CPM on an annual basis as part of the annual compliance report.   |

| Condition #     | Subject                    | <b>Condition Description</b>   | Means of Verification   | Methods & Comments  |
|-----------------|----------------------------|--|---|---|
|                 |                            | operated unless the City of Vernon demonstrates to the Executive Officer that, at the commencement of each compliance year after the first compliance year of operation, the facility hold sufficient RTCs in an amount equal to the annual emission increase. The City of Vernon shall submit all such information to the CPM for approval. |   |   |
| AQ-33           | Source test report         | The City of Vernon shall provide to the District a source test report in accordance with listed specifications:  | The City of Vernon shall submit to the CPM the required source test of Conditions of Certification AQ-21, -22 and -23 in compliance with this condition.  | MGS shall submit for approval to the District and the CPM the required source testing protocol no less than 45 days prior to the date of the source test. MGS shall notify the District and CPM of the date and time of the source test no less than 10 days prior to the test. MGS shall submit to the District and CPM for approval the results of the initial source test no later than 60 days following the date of the source test. |
| AQ-34           | Recordkeeping              | The City of Vernon shall keep records, in a manner approved by the District, for listed parameters or items.   | The City of Vernon shall make these records available to the CPM upon request.  | MGS shall make these records available to the CPM upon request.   |
| AQ-35           | Recordkeeping              | The City of Vernon shall keep records, in a manner approved by the District, for listed parameters or items.   | The City of Vernon shall submit these records to the CPM on an annual basis in the annual compliance report.  | MGS shall keep records of dates of operation, the elapsed time, in hour and the reason for operation of the emergency diesel powered generators and/or the firewater pump and shall submit these records to the CPM on an annual basis in the annual compliance report.   |
| AQ-36           |                            |  |   | Condition completely satisfied.   |
| Public Health-1 |                            |  |   | Condition completely satisfied.   |
| Worker Safety-1 |                            |  |   | Condition completely satisfied.   |
| Worker Safety-2 |                            |  |   | Condition completely satisfied.   |
| HAZ-1           | Use of hazardous materials | The project owner shall not use any hazardous materials not listed in Appendix C, below, or in greater quantities than those identified by chemical name in Appendix C, below, unless approved in advance by City of Vernon and the CPM.   | The project owner shall provide to the Compliance Project Manager (CPM), in the Annual Compliance Report, a list of hazardous materials contained at the facility in reportable quantities.   | MGS shall provide to the Compliance<br>Project Manager (CPM), in the Annual<br>Compliance Report, a list of hazardous<br>materials contained at the facility in<br>reportable quantities.   |
| HAZ-2           |                            |  |   | Condition completely satisfied.   |
| HAZ-3           |                            |  |   | Condition completely satisfied.   |
| HAZ-4           |                            |  |   | Condition completely satisfied.   |
| HAZ-5           |                            |  |   | Condition completely satisfied.   |
| HAZ-6           | Gas pipeline<br>review     | The project owner shall require that the gas pipeline undergo a complete design review and detailed inspection 30 days after initial startup and every 5 years thereafter.   | At least 30 days prior to the initial flow of gas in the pipeline, the project owner shall provide outline of the plan to accomplish a full and comprehensive pipeline design review to the CPM for review and approval. The full and complete plan shall be amended, as appropriate, and submitted to the CPM for review and approval, not later than one year | The initial requirement of the Condition has been completed during construction. Requirement for 5-year review satisfied 30 November 2010.  |

| Condition #       | Subject   | Condition Description  | Means of Verification   | Methods & Comments  |
|-------------------|---|--|---|---|
|                   |   |  | before the plan is implemented by the project owner.  |   |
| HAZ-7             | Seismic event inspections   | After any significant seismic event in the area where surface rupture occurs within one mile of the pipeline, the gas pipeline shall be inspected by the project owner.  | At least 30 days prior to the initial flow of gas in the pipeline, the project owner shall provide a detailed plan to accomplish a full and comprehensive pipeline inspection in the event of an earthquake to the CPM for review and approval. This plan shall be reviewed and amended, as appropriate, and submitted to the CPM for review and approval, at least every five years. | The initial requirement of the Condition has been completed during construction. Requirement for 5-year review satisfied 30 November 2010.  |
| HAZ-8             |   |  |   | Condition completely satisfied.   |
| WASTE-1           |   |  |   | Condition completely satisfied.   |
| WASTE-2           |   |  |   | Condition completely satisfied.   |
| WASTE-3           | Impending waste<br>management<br>related<br>enforcement<br>action | Upon becoming aware of any impending waste management related enforcement action by any local, state, or federal authority, the project owner shall notify the CPM of any such action taken or proposed to be taken against the project itself, or against any waste hauler or disposal facility or treatment operator with which the owner contracts.   | The project owner shall notify the CPM in writing within 10 days of becoming aware of an impending enforcement action. The CPM shall notify the project owner of any changes that will be required in the manner in which project-related wastes are managed.   | MGS shall notify the CPM in writing within 10 days of becoming aware of an impending enforcement action. The CPM shall notify the project owner of any changes that will be required in the manner in which project-related wastes are managed. If no such enforcement action occurs, this fact should be verified in each annual report. |
| WASTE-4           | Construction & operation waste management plan                    | The project owner shall prepare a Construction Waste Management Plan and an Operation Waste Management Plan for all wastes generated during construction and operation of the facility, respectively, and shall submit both plans to the City of Vernon. Environmental Health Department and the City of Vernon Fire Department for comment and to the CPM for review and approval.  | In the Annual Compliance Reports, the project owner shall document the actual waste management methods used during the year compared to the planned management methods.   | In the Annual Compliance Reports, MGS shall document the actual waste management methods used during the year compared to the planned management methods.   |
| SOIL &<br>WATER-1 |   |  |   | Condition completely satisfied.   |
| SOIL &<br>WATER-2 |   |  |   | Condition completely satisfied.   |
| SOIL &<br>WATER-3 |   |  |   | Condition completely satisfied.   |
| SOIL &<br>WATER-4 | Water usage<br>metering &<br>recording                            | The project owner shall install metering devices and record on a monthly basis the amount of water, listed by source (potable and reclaimed) used by the project. The annual summary shall include the monthly range and monthly average of daily usage in gallons per day, and total water used by the project on a monthly and annual basis in acrefeet.  The annual summary shall also include the yearly range and yearly average water use by the project. This information shall be supplied to the CPM. | The project owner shall submit an annual water use summary to the CPM as part of its annual compliance report for the life of the project.  | MGS shall submit an annual water use summary to the CPM as part of its annual compliance report for the life of the project.  |

| Condition #   | Subject                                 | Condition Description   | Means of Verification  | Methods & Comments  |
|---------------|---|---|--|---|
| WATER-5       | usage                                   | water for process cooling water for more than 9 days (216 hours) per calendar year.   | detailed summary of all potable water and reclaimed water used for process water in the Annual Compliance Report. If use of potable water exceeds 9 days per year, the project owner shall be subject to noncompliance procedures and enforcement action described in the General Compliance Conditions. | of all potable water and reclaimed water used for process water in the Annual Compliance Report.  |
| SOIL/ WATER-6 |   |   |  | Condition completely satisfied.   |
| SOIL/ WATER-7 |   |   |  | Condition completely satisfied.   |
| CUL-1         |   |   |  | Condition completely satisfied.   |
| CUL-2         |   |   |  | Condition completely satisfied.   |
| CUL-3         |   |   |  | Condition completely satisfied.   |
| CUL-4         |   |   |  | Condition completely satisfied.   |
| CUL-5         |   |   |  | Condition completely satisfied.   |
| CUL-6         |   |   |  | Condition completely satisfied.   |
| CUL-7         |   |   |  | Condition completely satisfied.   |
| CUL-8         | Station A                               | The project owner shall ensure that Station A is maintained in accordance with the Secretary of the Interior's Standards for the Treatment of Historic Properties (1995) (36 CFR Part 68). The project owner shall provide a summary of maintenance activities completed within each calendar year. | In each annual compliance report, the project owner shall include the summary of Station A maintenance activities completed within the last calendar year.   | MGS shall submit a summary of observed Station A maintenance activities completed within the last calendar year by City of Vernon personnel or contractors.   |
| PAL-1         |   |   |  | Condition completely satisfied.   |
| PAL-2         |   |   |  | Condition completely satisfied.   |
| PAL-3         |   |   |  | Condition completely satisfied.   |
| PAL-4         |   |   |  | Condition completely satisfied.   |
| PAL-5         |   |   |  | Condition completely satisfied.   |
| PAL-6         |   |   |  | Condition completely satisfied.   |
| PAL-7         |   |   |  | Condition completely satisfied.   |
| LAND-1        |   |   |  | Condition completely satisfied.   |
| LAND-2        |   |   |  | Condition completely satisfied.   |
| TRANS-1       |   |   |  | Condition completely satisfied.   |
| TRANS-2       |   |   |  | Condition completely satisfied.   |
| TRANS-3       |   |   |  | Condition completely satisfied.   |
| TRANS-4       |   |   |  | Condition completely satisfied.   |
| TRANS-5       |   |   |  | Condition completely satisfied.   |
| TRANS-6       |   |   |  | Condition completely satisfied.   |
| TRANS-7       |   |   |  | Condition completely satisfied.   |
| TRANS-8       | Truck travel routes for aqueous ammonia | The City of Vernon shall only use the preferred and alternate truck travel routes for deliveries of aqueous ammonia to the MGS site. The preferred route shall be from Interstate 710, exiting at the Bandini Boulevard. Trucks will  | The final preferred and alternative truck travel routes for aqueous ammonia delivery will be submitted to the Compliance Project Manager for approval 30 days prior to the first delivery of aqueous ammonia to the  | The originally mandated route and alternate route have been communicated to the aqueous ammonia supplier and use of these routes is mandated by MGS. MGS may alter the final truck travel route only upon prior |

| Condition # | Subject                  | Condition Description  | Means of Verification  | Methods & Comments   |
|-------------|--------------------------|--|--|--|
|             |                          | then travel west along Bandini Boulevard, south on Soto Avenue, and finally west on 50th Street to the MGS. The City shall use this route unless it notifies the CPM otherwise and the CPM approves.   | MGS. During operations, the City may alter the final truck travel route only upon prior approval of the CPM.   | approval of the CPM.   |
| TRANS-9     |                          |  |  | Condition completely satisfied.  |
| VIS-1       | Lighting<br>installation | The project owner shall design and install all permanent lighting such that light bulbs and reflectors are not visible from public viewing areas; lighting does not cause reflected glare; and illumination of the project, the vicinity, and the nighttime sky is minimized.  | The project owner shall report any complaints about permanent lighting and provide documentation of resolution in the Annual Compliance Report, accompanied by any lighting complaint resolution forms for that year.  | MGS shall report any complaints about permanent lighting and provide documentation of resolution in the Annual Compliance Report, accompanied by any lighting complaint resolution forms for that year.  |
| VIS-2       | Structure paint          | The project owner shall paint or treat the surfaces of all project structures and buildings visible to the public in a gray color to blend with the existing Station A building. Surfaces shall be treated with finishes that minimize glare. The project owner shall ensure proper treatment maintenance for the life of the project. | At least 30 days prior to the start of commercial operation, the project owner shall notify the CPM that all buildings and structures are ready for inspection. The project owner shall provide a status report regarding treatment maintenance in the Annual Compliance Report.   | MGS shall provide a status report regarding treatment maintenance in the Annual Compliance Report.   |
| VIS-3       | Tree planting            | The project owner shall plant trees along the east side of the MGS site to enhance views of the new power plant from Soto Street, consistent with the City of Vernon General Plan policy 1.3. The project owner shall ensure proper maintenance of the trees for the life of the project.  | At least 30 days prior to the start of commercial operation, the project owner shall notify the CPM that the trees are ready for inspection. The project owner shall provide a status report regarding tree maintenance in the Annual Compliance Report.   | MGS shall provide a status report regarding tree maintenance in the Annual Compliance Report.  |
| VIS-4       |                          |  |  | Condition completely satisfied.  |
| NOISE-1     |                          |  |  | Condition completely satisfied.  |
| NOISE-2     | Noise complaints         | Throughout the construction and operation of the project, the project owner shall document, investigate, evaluate, and attempt to resolve all project related noise complaints.  | Within 30 days of receiving a noise complaint, the project owner shall file a copy of the Noise Complaint Resolution Form, or similar instrument approved by the CPM, with the City of Vernon Director of Community Services & Water and the City of Huntington Park Senior Planner and with the CPM, documenting the resolution of the complaint. If mitigation is required to resolve a complaint, and the complaint is not resolved within a 30-day period, the project owner shall submit an updated Noise Complaint Resolution Form when the mitigation is finally implemented. | Within 30 days of receiving a noise complaint, MGS shall file a copy of the Noise Complaint Resolution Form, or similar instrument approved by the CPM, with the City of Vernon Director of Community Services & Water and the City of Huntington Park Senior Planner and with the CPM, documenting the resolution of the complaint. If no such complaint is received, this fact should be verified in each annual report. |
| NOISE-3     |                          |  |  | Condition completely satisfied.  |
| NOISE-4     |                          |  |  | Condition completely satisfied.  |
| NOISE-5     |                          |  |  | Condition completely satisfied.  |
| NOISE-6     |                          |  |  | Condition completely satisfied.  |
| NOISE-7     |                          |  |  | Condition completely satisfied.  |
| NOISE-8     |                          |  |  | Condition completely satisfied.  |

# APPENDIX J NH3 FLOW METER CALIBRATION RESULTS



**Process Management** 

Rosemount Service 8200 Market Blvd. Chanhassen, MN 55317 T: 800-654-7768

F: 952-906-8844

March 20, 2018

#### CALIBRATION DATA SHEET

Consistent with ISO 10474 2.1 or EN 10204 2.1

#### **Contact Information**

Purchase Order: MGS13324 1692384 Service Request: AEIA-14CVD0L **Customer Name:** Colorado Energy Management LLC Quote#: Location/Project: Sales Representative: RICHARD TSE Address 1: 4963 S Soto StVernon, CA 90058 Phone: Address 2: Email: **Customer Contact:** Service Representative: Ian Everts 323-350-3481 657-291-4328 Phone: Phone: Email: ieverts@heorotpower.com Email: Stevie.Day@emerson.com

#### **Device Information**

| Device Type: Pressure Transmitter      | Serial Number: 1287778 |
|--|------------------------|
| Device Tag: 11 HSJJ50 CF0100 FT FIT 18 | Range: 0 To 10 IN H2O  |
| Model: 3051CD1A02A1AS5M5Q4E5           |                        |

**Test Equipment Used** 

| Asset #  | Description   | Calibration Due |
|----------|---------------|-----------------|
| ES-01410 | FLUKE 754     | 24-Dec-18       |
| PS-01477 | FLUKE 750PDS2 | 25-Dec-18       |
| PS-01266 | FLUKE 700PD3  | 26-Dec-18       |
| PS-01349 | FLUKE 700PD7  | 27-Dec-18       |

#### **As Found Calibration Data**

| Specified<br>Range<br>IN H2O | Applied %<br>Of Span | Applied<br>IN H2O | Specified<br>Analog Output<br>In mA | Output<br>Tolerance<br>+/- | Indicated<br>Digital Output In<br>IN H2O | Measured<br>Analog Output<br>In mA | Pass/Fail |
|------------------------------|----------------------|-------------------|-------------------------------------|----------------------------|--|------------------------------------|-----------|
| 0.000                        | 0.00                 | 0.000             | 4.0000                              | 0.016                      | 0.000                                    | 3.9760                             | Fail      |
| 2.500                        | 25.00                | 2.500             | 12.0000                             | 0.016                      | 2.502                                    | 12.3300                            | Fail      |
| 5.000                        | 50.00                | 5.000             | 15.3137                             | 0.016                      | 5.030                                    | 15.3120                            | Fail      |
| 7.500                        | 75.00                | 7.500             | 17.8564                             | 0.016                      | 7.030                                    | 17.8570                            | Fail      |
| 10.000                       | 100.00               | 10.000            | 20.0000                             | 0.016                      | 10.030                                   | 20.0030                            | Fail      |

#### As Left Calibration Data

| 0.000  | 0.00   | 0.000  | 4.0000  | 0.016 | 0.000  | 4.0000  | Pass |
|--------|--------|--------|---------|-------|--------|---------|------|
| 2.500  | 25.00  | 2.500  | 12.0000 | 0.016 | 2.501  | 12.0010 | Pass |
| 5.000  | 50.00  | 5.000  | 15.3137 | 0.016 | 5.000  | 15.3130 | Pass |
| 7.500  | 75.00  | 7.500  | 17.8564 | 0.016 | 7.500  | 17.8570 | Pass |
| 10.000 | 100.00 | 10.000 | 20.0000 | 0.016 | 10.000 | 20.0000 | Pass |

#### Certification

This is to validate that the listed product performs within the acceptable performance variation of the test equipment. Measuring and test equipment used in the inspection and validation of the listed product are traceable to the National Institute of Standards and Technology.

| Stevie Day | March 20, 2018 |
|------------|----------------|
|            | Date           |



Rosemount Service 8200 Market Blvd. Chanhassen, MN 55317 T: 800-654-7768

F: 952-906-8844

**Process Management** 

March 20, 2018

#### **CALIBRATION DATA SHEET**

Consistent with ISO 10474 2.1 or EN 10204 2.1

#### **Contact Information**

| Purchase Order:   | MGS13324                       | Service Request:        | 1692384                |
|-------------------|--------------------------------|-------------------------|------------------------|
| Customer Name:    | Colorado Energy Management LLC | Quote#:                 | AEIA-14CVD0L           |
| Location/Project: |                                | Sales Representative:   | RICHARD TSE            |
| Address 1:        | 4963 S Soto StVernon, CA 90058 | Phone:                  |                        |
| Address 2:        |                                | Email:                  |                        |
| Customer Contact: | Ian Everts                     | Service Representative: |                        |
| Phone:            | 323-350-3481                   | Phone:                  | 657-291-4328           |
| Email:            | ieverts@heorotpower.com        | Email:                  | Stevie.Day@emerson.com |

#### **Device Information**

| Device Type: Pressure Transmitter | Serial Number: 1292706 |
|-----------------------------------|------------------------|
| Device Tag: 21 HSJ50 CF010 FT     | Range: 0 To 10 IN H2O  |
| Model: 3051CD1A02A1AS5M5Q4E5      |                        |

**Test Equipment Used** 

| Asset #  | Description   | Calibration Due |
|----------|---------------|-----------------|
| ES-01410 | FLUKE 754     | 24-Dec-18       |
| PS-01477 | FLUKE 750PDS2 | 25-Dec-18       |
| PS-01266 | FLUKE 700PD3  | 26-Dec-18       |
| PS-01349 | FLUKE 700PD7  | 27-Dec-18       |

#### **As Found Calibration Data**

| Specified<br>Range<br>IN H2O | Applied %<br>Of Span | Applied<br>IN H2O | Specified<br>Analog Output<br>In mA | Output<br>Tolerance<br>+/- | Indicated<br>Digital Output In<br>IN H2O | Measured<br>Analog Output<br>In mA | Pass/Fail |
|------------------------------|----------------------|-------------------|-------------------------------------|----------------------------|--|------------------------------------|-----------|
| 0.000                        | 0.00                 | 0.000             | 4.0000                              | 0.016                      | 0.190                                    | 3.9950                             | Fail      |
| 2.500                        | 25.00                | 2.500             | 12.0000                             | 0.016                      | 2.520                                    | 12.0320                            | Fail      |
| 5.000                        | 50.00                | 5.000             | 15.3137                             | 0.016                      | 5.010                                    | 15.0320                            | Fail      |
| 7.500                        | 75.00                | 7.500             | 17.8564                             | 0.016                      | 7.501                                    | 17.8570                            | Pass      |
| 10.000                       | 100.00               | 10.000            | 20.0000                             | 0.016                      | 10.000                                   | 20.0000                            | Pass      |

#### As Left Calibration Data

| 0.000  | 0.00   | 0.000  | 4.0000  | 0.016 | 0.000  | 4.0000  | Pass |
|--------|--------|--------|---------|-------|--------|---------|------|
| 2.500  | 25.00  | 2.500  | 12.0000 | 0.016 | 2.501  | 12.0010 | Pass |
| 5.000  | 50.00  | 5.000  | 15.3137 | 0.016 | 5.010  | 15.3250 | Pass |
| 7.500  | 75.00  | 7.500  | 17.8564 | 0.016 | 7.501  | 17.8570 | Pass |
| 10.000 | 100.00 | 10.000 | 20.0000 | 0.016 | 10.000 | 20.0000 | Pass |

#### Certification

This is to validate that the listed product performs within the acceptable performance variation of the test equipment. Measuring and test equipment used in the inspection and validation of the listed product are traceable to the National Institute of Standards and Technology.

| Stevie Day | March 20, 2018 |
|------------|----------------|
|            | Date           |

Rosemount Service Representative

PH: 657-291-4328

# APPENDIX K SCR TEMPERATURE GAUGE CALIBRATION REPORT



#### **Rosemount Service**

8200 Market Blvd. Chanhassen, MN 55317 T: 800-654-7768

F: 952-906-8844

March 20, 2018

#### **CALIBRATION DATA SHEET**

Consistent with ISO 10474 2.1 or EN 10204 2.1

#### **Contact Information**

Purchase Order: MGS13324 Service Request: 1692384 AEIA-14CVD0L **Customer Name:** Colorado Energy Management LLC Quote#: Location/Project: Sales Representative: RICHARD TSE Address 1: 4963 S Soto StVernon, CA 90058 Phone: Address 2: Email: Customer Contact: Service Representative: Ian Everts 657-291-4328

Phone: 323-350-3481

Phone: Email: ieverts@heorotpower.com

Email: Stevie.Day@emerson.com

#### **Device Information**

| Device Type: Temperature Transmitter | Serial #: 9029664 Range: 0 to 800 Deg. F |  |
|--------------------------------------|--|--|
| Device Tag: 21HBK70CT031             | Sensor Type: PT-100 (x = 0.00385)        |  |
| Model: YTA110                        |  |  |

#### **Test Equipment Used**

| Asset #  | Description   | Calibration Due |
|----------|---------------|-----------------|
| ES-01410 | FLUKE 754     | 24-Dec-18       |
| PS-01477 | FLUKE 750PDS2 | 25-Dec-18       |
| PS-01266 | FLUKE 700PD3  | 26-Dec-18       |
| PS-01349 | FLUKE 700PD7  | 27-Dec-18       |

#### As Found Calibration Data

| Specified<br>Range Deg F | Applied %<br>Of Span | Applied<br>Deg F | Specified<br>Analog Output In mA | Output<br>Tolerance<br>+/- | Indicated<br>Digital Output In F | Measured<br>Analog Output In<br>mA | Pass/Fail |
|--------------------------|----------------------|------------------|----------------------------------|----------------------------|----------------------------------|------------------------------------|-----------|
| 0.00                     | 0.00                 | 0.00             | 4.0000                           | 0.007                      | 0.10                             | 4.0000                             | Pass      |
| 200.00                   | 25.00                | 200.00           | 8.0000                           | 0.007                      | 199.96                           | 7.9990                             | Pass      |
| 400.00                   | 50.00                | 400.00           | 12.0000                          | 0.007                      | 400.10                           | 12.0000                            | Pass      |
| 600.00                   | 75.00                | 600.00           | 16.0000                          | 0.007                      | 600.00                           | 15.9990                            | Pass      |
| 800.00                   | 100.00               | 800.00           | 20.0000                          | 0.007                      | 800.00                           | 19.9990                            | Pass      |

#### As Left Calibration Data

| 0.00   | 0.00   | 0.00   | 4.0000  | 0.007 | 0.10   | 4.0000  | Pass |
|--------|--------|--------|---------|-------|--------|---------|------|
| 200.00 | 25.00  | 200.00 | 8.0000  | 0.007 | 200.11 | 8.0020  | Pass |
| 400.00 | 50.00  | 400.00 | 12.0000 | 0.007 | 400.10 | 12.0000 | Pass |
| 600.00 | 75.00  | 600.00 | 16.0000 | 0.007 | 599.98 | 15.9990 | Pass |
| 800.00 | 100.00 | 800.00 | 20.0000 | 0.007 | 800.10 | 19.9990 | Pass |

#### Certification

This is to validate that the listed product performs within the acceptable performance variation of the test equipment. Measuring and test equipment used in the inspection and validation of the listed product are traceable to the National Institute of Standards and Technology.

Stevie Day

March 20, 2018

Date



Email:

ieverts@heorotpower.com

#### **Rosemount Service**

8200 Market Blvd. Chanhassen, MN 55317 T: 800-654-7768

Email:

F: 952-906-8844

March 20, 2018

Stevie.Day@emerson.com

#### **CALIBRATION DATA SHEET**

Consistent with ISO 10474 2.1 or EN 10204 2.1

#### **Contact Information**

Purchase Order: MGS13324 Service Request: 1692384 AEIA-14CVD0L **Customer Name:** Colorado Energy Management LLC Quote#: Location/Project: Sales Representative: RICHARD TSE Address 1: 4963 S Soto StVernon, CA 90058 Phone: Address 2: Email: Customer Contact: Service Representative: Ian Everts Phone: 323-350-3481 Phone: 657-291-4328

#### **Device Information**

| 201100 1111011110111                 |                                   |                        |
|--------------------------------------|-----------------------------------|------------------------|
| Device Type: Temperature Transmitter | Serial #: 9029687                 | Range: 0 to 800 Deg. F |
| Device Tag: 11HBK70CT031             | Sensor Type: PT-100 (x = 0.00385) |                        |
| Model: YTA110                        |                                   |                        |

**Test Equipment Used** 

| Asset #  | Description   | Calibration Due |
|----------|---------------|-----------------|
| ES-01410 | FLUKE 754     | 24-Dec-18       |
| PS-01477 | FLUKE 750PDS2 | 25-Dec-18       |
| PS-01266 | FLUKE 700PD3  | 26-Dec-18       |
| PS-01349 | FLUKE 700PD7  | 27-Dec-18       |

#### As Found Calibration Data

| Specified<br>Range Deg F | Applied %<br>Of Span | Applied<br>Deg F | Specified<br>Analog Output In mA | Output<br>Tolerance<br>+/- | Indicated<br>Digital Output In F | Measured<br>Analog Output In<br>mA | Pass/Fail |
|--------------------------|----------------------|------------------|----------------------------------|----------------------------|----------------------------------|------------------------------------|-----------|
| 0.00                     | 0.00                 | 0.00             | 4.0000                           | 0.007                      | -0.12                            | 3.9950                             | Pass      |
| 200.00                   | 25.00                | 200.00           | 8.0000                           | 0.007                      | 199.90                           | 7.9970                             | Pass      |
| 400.00                   | 50.00                | 400.00           | 12.0000                          | 0.007                      | 399.88                           | 11.9970                            | Pass      |
| 600.00                   | 75.00                | 600.00           | 16.0000                          | 0.007                      | 599.87                           | 15.9970                            | Pass      |
| 800.00                   | 100.00               | 800.00           | 20.0000                          | 0.007                      | 799.84                           | 19.9980                            | Pass      |

#### As Left Calibration Data

| 0.00   | 0.00   | 0.00   | 4.0000  | 0.007 | -0.12  | 3.9950  | Pass |
|--------|--------|--------|---------|-------|--------|---------|------|
| 200.00 | 25.00  | 200.00 | 8.0000  | 0.007 | 199.90 | 7.9970  | Pass |
| 400.00 | 50.00  | 400.00 | 12.0000 | 0.007 | 399.88 | 11.9970 | Pass |
| 600.00 | 75.00  | 600.00 | 16.0000 | 0.007 | 599.87 | 15.9970 | Pass |
| 800.00 | 100.00 | 800.00 | 20.0000 | 0.007 | 799.84 | 19.9980 | Pass |

#### Certification

This is to validate that the listed product performs within the acceptable performance variation of the test equipment. Measuring and test equipment used in the inspection and validation of the listed product are traceable to the National Institute of Standards and Technology.

Stevie Day

March 20, 2018

Date

# APPENDIX L SCR PRESSURE GAUGE CALIBRATION REPORT



**Process Management** 

Rosemount Service 8200 Market Blvd. Chanhassen, MN 55317 T: 800-654-7768

F: 952-906-8844

March 19, 2018

#### **CALIBRATION DATA SHEET**

Consistent with ISO 10474 2.1 or EN 10204 2.1

#### **Contact Information**

Purchase Order: MGS13324 1692384 Service Request: AEIA-14CVD0L **Customer Name:** Colorado Energy Management LLC Quote#: Location/Project: Sales Representative: RICHARD TSE Address 1: 4963 S Soto StVernon, CA 90058 Phone: Address 2: Email: **Customer Contact:** Service Representative: Ian Everts 323-350-3481 657-291-4328 Phone: Phone: Email: ieverts@heorotpower.com Email: Stevie.Day@emerson.com

#### **Device Information**

| Device Type: Pressure Transmitter | Serial Number: 2161036 |
|-----------------------------------|------------------------|
| Device Tag: 170CP010              | Range: 0 To 2.5 IN H2O |
| Model: EJA110A                    |                        |

**Test Equipment Used** 

| Asset #  | Description   | Calibration Due |
|----------|---------------|-----------------|
| ES-01410 | FLUKE 754     | 24-Dec-18       |
| PS-01477 | FLUKE 750PDS2 | 25-Dec-18       |
| PS-01266 | FLUKE 700PD3  | 26-Dec-18       |
| PS-01349 | FLUKE 700PD7  | 27-Dec-18       |

#### **As Found Calibration Data**

| Specified<br>Range<br>IN H2O | Applied %<br>Of Span | Applied<br>IN H2O | Specified<br>Analog Output<br>In mA | Output<br>Tolerance<br>+/- | Indicated<br>Digital Output In<br>IN H2O | Measured<br>Analog Output<br>In mA | Pass/Fail |
|------------------------------|----------------------|-------------------|-------------------------------------|----------------------------|--|------------------------------------|-----------|
| 0.000                        | 0.00                 | 0.000             | 4.0000                              | 0.082                      | -0.008                                   | 3.9950                             | Pass      |
| 0.625                        | 25.00                | 0.625             | 12.0000                             | 0.082                      | 0.622                                    | 11.9980                            | Pass      |
| 1.250                        | 50.00                | 1.250             | 15.3137                             | 0.082                      | 1.249                                    | 15.3090                            | Pass      |
| 1.875                        | 75.00                | 1.875             | 17.8564                             | 0.082                      | 1.875                                    | 17.8570                            | Pass      |
| 2.500                        | 100.00               | 2.500             | 20.0000                             | 0.082                      | 2.500                                    | 20.0010                            | Pass      |

#### As Left Calibration Data

| 0.000 | 0.00   | 0.000 | 4.0000  | 0.082 | -0.008 | 3.9950  | Pass |
|-------|--------|-------|---------|-------|--------|---------|------|
| 0.625 | 25.00  | 0.625 | 12.0000 | 0.082 | 0.622  | 11.9980 | Pass |
| 1.250 | 50.00  | 1.250 | 15.3137 | 0.082 | 1.249  | 15.3090 | Pass |
| 1.875 | 75.00  | 1.875 | 17.8564 | 0.082 | 1.875  | 17.8570 | Pass |
| 2.500 | 100.00 | 2.500 | 20.0000 | 0.082 | 2.500  | 20.0010 | Pass |

#### Certification

This is to validate that the listed product performs within the acceptable performance variation of the test equipment. Measuring and test equipment used in the inspection and validation of the listed product are traceable to the National Institute of Standards and Technology.

| Stevie Day | March 19, 2018 |
|------------|----------------|
|            | Date           |



Rosemount Service 8200 Market Blvd. Chanhassen, MN 55317 T: 800-654-7768

March 19, 2018

F: 952-906-8844

#### **CALIBRATION DATA SHEET**

Consistent with ISO 10474 2.1 or EN 10204 2.1

#### **Contact Information**

**Process Management** 

Purchase Order: MGS13324 1692384 Service Request: AEIA-14CVD0L **Customer Name:** Colorado Energy Management LLC Quote#: Location/Project: Sales Representative: RICHARD TSE Address 1: 4963 S Soto StVernon, CA 90058 Phone: Address 2: Email: **Customer Contact:** Service Representative: Ian Everts 323-350-3481 657-291-4328 Phone: Phone: Email: ieverts@heorotpower.com Email: Stevie.Day@emerson.com

#### **Device Information**

| Device Type: Pressure Transmitter | Serial Number: | 2161035         |
|-----------------------------------|----------------|-----------------|
| Device Tag: 270CP010              | Range:         | 0 To 2.5 IN H2O |
| Model: EJA110A                    |                |                 |

**Test Equipment Used** 

| Asset #  | Description   | Calibration Due |
|----------|---------------|-----------------|
| ES-01410 | FLUKE 754     | 24-Dec-18       |
| PS-01477 | FLUKE 750PDS2 | 25-Dec-18       |
| PS-01266 | FLUKE 700PD3  | 26-Dec-18       |
| PS-01349 | FLUKE 700PD7  | 27-Dec-18       |

#### **As Found Calibration Data**

| Specified<br>Range<br>IN H2O | Applied %<br>Of Span | Applied<br>IN H2O | Specified<br>Analog Output<br>In mA | Output<br>Tolerance<br>+/- | Indicated<br>Digital Output In<br>IN H2O | Measured<br>Analog Output<br>In mA | Pass/Fail |
|------------------------------|----------------------|-------------------|-------------------------------------|----------------------------|--|------------------------------------|-----------|
| 0.000                        | 0.00                 | 0.000             | 4.0000                              | 0.082                      | 0.005                                    | 4.0320                             | Pass      |
| 0.625                        | 25.00                | 0.625             | 12.0000                             | 0.082                      | 0.626                                    | 12.0010                            | Pass      |
| 1.250                        | 50.00                | 1.250             | 15.3137                             | 0.082                      | 1.260                                    | 15.3450                            | Pass      |
| 1.875                        | 75.00                | 1.875             | 17.8564                             | 0.082                      | 1.875                                    | 17.8690                            | Pass      |
| 2.500                        | 100.00               | 2.500             | 20.0000                             | 0.082                      | 2.500                                    | 20.0010                            | Pass      |

#### As Left Calibration Data

| 0.000 | 0.00   | 0.000 | 4.0000  | 0.082 | 0.001 | 4.0000  | Pass |
|-------|--------|-------|---------|-------|-------|---------|------|
| 0.625 | 25.00  | 0.625 | 12.0000 | 0.082 | 0.625 | 12.0000 | Pass |
| 1.250 | 50.00  | 1.250 | 15.3137 | 0.082 | 1.250 | 15.3140 | Pass |
| 1.875 | 75.00  | 1.875 | 17.8564 | 0.082 | 1.875 | 17.8570 | Pass |
| 2.500 | 100.00 | 2.500 | 20.0000 | 0.082 | 2.500 | 20.0010 | Pass |

#### Certification

This is to validate that the listed product performs within the acceptable performance variation of the test equipment. Measuring and test equipment used in the inspection and validation of the listed product are traceable to the National Institute of Standards and Technology.

| Stevie Day | March 19, 2018 |
|------------|----------------|
|            | Date           |

# APPENDIX M STATION "A" MAINTENANCE REPORT

## ANNUAL COMPLIANCE REPORT CONDITION OF CERTIFICATION NUMBER CUL-8, YEAR 2018

For the:

# MALBURG GENERATING STATION (Docket 01-AFC-25C)

Submitted To:

## CALIFORNIA ENERGY COMMISSION 1516 Ninth Street Sacramento, CA 95814

Prepared by:

CITY OF VERNON 4305 Santa Fe Avenue Vernon, CA 90058

# MALBURG GENERATING STATION ANNUAL COMPLIANCE REPORT CONDITION OF CERTIFICATION NUMBER CUL-8 YEAR 2018

#### INTRODUCTION

The City of Vernon (City) has been operating an electric power generating facility (Station "A") since 1933 in the City of Vernon. The facility consists of the Johnson & Heinze Diesel Plant and H. Gonzales Generating Station. The City constructed Malburg Generating Station (MGS) at the Station "A" facility in 2005 (Docket 01-AFC-25C). The commissioning of MGS was completed in October 2005 and the power plant was put under commercial operation on October 17, 2005. The City sold MGS to Bicent (California) Malburg LLC (Bicent) in 2008. After the sale of MGS, the City continued to retain ownership of the Johnson & Heinze Diesel Plant, H. Gonzales Generating Station, and Station "A" building.

Condition of Certification Number CUL-8 requires the City to maintain the Station "A" building as an Historic Property in accordance with the Secretary of the Interior's Standards for the Treatment of Historic Properties, which include standards for preservation, rehabilitation, restoration, and reconstruction, as codified in Title 36 of the Code of Federal Regulations (CFR), Part 68 (1995). Each of the standards can be applied to a historic property to assist the long-term preservation of a property's significance through the retention of historic materials and features.

The Station "A" building is still in use and no major changes or alterations occurred to the building in 2017 and 2018. Routine maintenance has occurred and 16¹ security cameras were installed along the exterior of the building, in accordance with the Secretary of the Interior's Standards for the Treatment of Historic Properties.

To verify that the Station "A" building is maintained in accordance with the Standards for the Treatment of Historic Properties (36 CFR Part 68), the California Energy Commission (CEC) requires the City to submit an annual report that summarizes the maintenance activities completed to preserve the property within each calendar year. The City is, therefore, submitting this annual compliance report, which provides a summary of the maintenance and camera installation activities completed for the Station "A" building during the years 2017 and 2018.

# COMPLIANCE DETAILS FOR CONDITION OF CERTIFICATION NUMBER CUL-8

As per Condition of Certification Number CUL-8, the project owner shall ensure that Station "A" is maintained in accordance with the Secretary of the Interior's Standards for the Treatment of Historic Properties (36 CFR Part 68). The project owner shall provide a summary of maintenance activities completed within each calendar year. These maintenance activities were completed in accordance with the Secretary of the Interior's Standards for Preservation, as detailed in 36 CFR

 $<sup>^{</sup>f 1}$  This camera system includes 7 additional cameras not physically located on the Station "A" building.

Part 68, and sustained the historic use and appearance of the building; did not alter or diminish its historic character, materials, features, or spaces; avoided use of abrasive chemical or physical treatments; and preserved its craftsmanship.

For verification of the above condition of certification, the project owner shall include the summary of Station "A" maintenance activities completed to preserve the Station "A" building within the calendar year. A summary of the maintenance activities completed by the City during the year 2018 is presented at the end of this report.

Additionally, in October 2018, the CEC inquired whether the 2017 installation of a Station "A" building security system conforms with the Secretary of the Interior's Standards for the Treatment of Historic Properties. Based on a review of applicable standards, the addition of cameras is a treatment type that falls under the Secretary of the Interior's Standards for Rehabilitation. The Standards for Rehabilitation acknowledge the need to alter a historic property to meet new uses or needs through compatible changes to the property, while also retaining the building's historic character. Based on this analysis, the City has determined that the camera installation activities do conform with the following applicable Standards for Rehabilitation, as detailed in 36 CFR Part 68:

- Standard 1: A property shall be used for its historic purpose or be placed in a new use that
  requires minimal change to the defining characteristics of the building and its site and
  environment.
- Standard 2: The historic character of a property shall be retained and preserved. The removal of historic materials or alteration of features and spaces that characterize a property shall be avoided.
- Standard 3: Each property shall be recognized as a physical record of its time, place, and use. Changes that create a false sense of historical development, such as adding conjectural features or architectural elements from other buildings, shall not be undertaken.
- Standard 5: Distinctive features, finishes, and construction techniques or examples of craftsmanship that characterize a property shall be preserved.
- Standard 7: Chemical or physical treatments, such as sandblasting, that cause damage to historic materials shall not be used. The surface cleaning of structures, if appropriate, shall be undertaken using the gentlest means possible.
- Standard 9: New additions, exterior alterations, or related new construction shall not destroy historic materials that characterize the property. The new work shall be differentiated from the old and shall be compatible with the massing, size, scale, and architectural features to protect the historic integrity of the property and its environment.
- Standard 10: New additions and adjacent or related new construction shall be undertaken in such a manner that, if removed in the future, the essential form and integrity of the historic property and its environment would be unimpaired.

Each of these applicable Secretary of the Interior's Standards for Rehabilitation, as they relate to the camera installation activities, are discussed in more detail at the end of this report.

#### Maintenance Activities Completed to Preserve the Exterior of the Station "A" Building:

#### 1. Weekly Maintenance of the Exterior of Station "A"

- a. Cleaning of 50th Street, Seville Avenue and parking lot, and outside areas to the north and east of the building.
- b. Maintenance of lawns, flower beds, and trees provided outside the Station "A" building, including the mowing of lawns.

#### 2. Monthly Maintenance of the Exterior of Station "A"

Sweeping of the following roads: (a) northeast access road from Seville Avenue to the northeast corner of the building, (b) south access road from 50th Street to the northeast corner of the building, (c) 50th Street access gate to Seville Avenue, and (d) Seville Avenue access gate to 50th Street.

#### 3. Quarterly Maintenance of the Exterior of Station "A"

Inspection of the following items: (a) lighting, (b) waste water separator, (c) safety systems, and (d) compressor backflow catch basin.

#### 4. Annual Maintenance of the Exterior of Station "A"

- a. A visual inspection of the Station "A" building (exterior inspection) was conducted to determine if maintenance repairs were required.
- b. Roof drains were inspected and cleaned.
- c. First floor exterior windows were cleaned.

#### Maintenance Activities Completed to Preserve the Interior of the Station "A" Building:

#### 1. Daily Maintenance of the Interior of Station "A"

Sweeping and mopping of floors (control room, west offices and hallway, east offices and hallway, and dressing room and lavatory).

#### 2. Weekly Maintenance of the Interior of Station "A"

Sweeping and mopping of floors (battery charger room, basement, west 7-kilovolt [kV] room, east 7-kV room, main floor, 480-volt room, operations manager office, control room, machine shop, and piping gallery). Waxing of floors (control room and main floor hallways).

#### 3. Monthly Maintenance of the Interior of Station "A"

Elevator inspection, fire extinguisher inspections, automated external defibrillator (AED) inspection, and eye wash inspections.

#### 4. Quarterly Maintenance of the Interior of Station "A"

Inspection of the following items: (a) crane, (b) lighting, (c) spill cabinet, (d) exit sign emergency lighting, (e) safety systems, (f) smoke detectors, (g) maintenance of air conditioner units, (h) hot sticks and high voltage gloves used for switching and hot work, and (g) first aid kits.

#### 5. Semi-Annual Maintenance of the Interior of Station "A"

- a. Waxing of floors (480-volt room, operations manager office, piping gallery, main floor, west 7-kV room, east 7-kV room, basement, battery charger room, machine shop, muffler deck, engine room, and air washer deck).
- b. Inspection of the east and west 7-kV room fire suppression system.

#### 6. Annual Maintenance of the Interior of Station "A"

- a. Testing of potable water backflow device.
- b. Verification of safety data sheet (SDS) book.

#### Security of the Station "A" Building:

The security system includes 23 high definition (HD) infrared cameras with digital video recording (DVR), 16 of which are physically located on the Station "A" building. Managers and control room staff can access the camera system to monitor any suspicious activity at Station "A". The camera system also helps identify the vehicles, drivers, passengers, and license plates entering the Soto Street and Seville Avenue gates.

The Station "A" building also includes a 24/7 security guard and a locked gate at the Soto Street entrance. The security guard screens visitors seeking access to Station "A", and the control room staff have the ability to screen visitors through the camera system at both the Soto Street and Seville Avenue entrance gates, as well as through an audible intercom system at the Soto Street entrance gate. The facility security restricts access to Station "A" to authorized personnel, consistent with Condition of Certification Number COM-9's Operational Security Plan and industry standards. Exterior and interior doors to Station "A" are accessed via use of a card key issued by the City of Vernon Police Department. All visitors to the facility are recorded in the Visitors and Systems Logs. Monthly checks are performed on all entrance and exit security doors.

The 16 cameras physically located on the Station "A" building replaced existing security system components. The cameras were installed along the exterior building walls or immediately behind the roof parapet, which limits the visibility of the roof cameras from a public vantage point. When feasible, the replacement cameras were installed on existing camera mounts, which avoided impacts to historic fabric and materials. When new camera mounts were required, they were installed through the addition of four screws inserted into the building exterior. Cabling for the new system was completed along the exterior walls, either in existing conduits or along the building exterior, and did not require destructive opening of any walls or spaces. Within the existing control room, no changes were required to the space configuration and layout of the room to accommodate the new security system; instead, new flat-screen surveillance monitors were mounted to the existing walls.

The following provides additional information on how the camera installation activities conform to the Secretary of the Interior's Standards for the Treatment of Historic Properties through the following applicable Standards for Rehabilitation, as detailed in 36 CFR Part 68:

• Standard 1: A property shall be used for its historic purpose or be placed in a new use that requires minimal change to the defining characteristics of the building and its site and environment. The historic property has retained its historic use and character as a power-related property, originally constructed in 1933, and the security camera installation activities required minimal changes to its exterior character-defining features, specifically its

- exterior stucco coating and stepped roof parapet. These character-defining features remain as highly visible elements that convey the property's historic integrity of design, materials, workmanship, and feeling.
- Standard 2: The historic character of a property shall be retained and preserved. The removal of historic materials or alteration of features and spaces that characterize a property shall be avoided. The new / replacement security cameras and the installation of new monitors in an existing control room did not affect historic materials or alter a space that characterizes the historic property. The cameras were installed in areas where cameras either previously existed (and re-used the existing mounts, when feasible) or were located away from key features that characterize the property or contribute to its significance. For example, major exterior character-defining features, such as the stepped parapet, metal-sash industrial windows, ornamental window molding, and coarse stucco and fluted wall composition, remain intact and were not diminished by the new camera installation activities. Further, the new monitors in the control room were added to an interior space that lacks distinctive features and did not alter the configuration or character of the space.
- Standard 3: Each property shall be recognized as a physical record of its time, place, and use. Changes that create a false sense of historical development, such as adding conjectural features or architectural elements from other buildings, shall not be undertaken. The cameras do not create a false sense of historic development. They are clearly distinguishable as modern features and do not impinge upon the property's historic sense of time, place, and use. Aside from the cameras, cabling, and monitors, no other features were installed and the property retains its core architectural elements from its period of significance.
- Standard 5: Distinctive features, finishes, and construction techniques or examples of
  craftsmanship that characterize a property shall be preserved. The camera installation
  activities did not affect the craftsmanship, workmanship, feeling, or materials of the historic
  property. As noted earlier, major character-defining features of the property remain intact.
  As a result, the property retains sufficient physical evidence from its period of development
  and significance, reflecting construction techniques and design elements and patterns from
  its construction.
- Standard 7: Chemical or physical treatments, such as sandblasting, that cause damage to historic materials shall not be used. The surface cleaning of structures, if appropriate, shall be undertaken using the gentlest means possible. No type of abrasive physical or chemical treatment was needed for the improvements.
- Standard 9: New additions, exterior alterations, or related new construction shall not destroy historic materials that characterize the property. The new work shall be differentiated from the old and shall be compatible with the massing, size, scale, and architectural features to protect the historic integrity of the property and its environment. The camera installation activities include very small-scale elements added to the exterior of the building and did not require destruction or major changes to any of the building's historic materials or character-defining features. When feasible, the cameras were installed within the existing camera mounts which avoided new drilling into the walls. In other areas, the new mounts were installed through the addition of four small screws. The cameras are approximately 8.3" long, 2.83" high, and 3.14" wide; the new mounts have an approximately 3.5" diameter. These are minor changes to a large building and are

- compatible with its massing, size, scale, and appearance. Additionally, due to other nearby changes in the surrounding area, the cameras do not cause further changes to the setting and feeling of the property and other nearby power facilities.
- Standard 10: New additions and adjacent or related new construction shall be undertaken in such a manner that, if removed in the future, the essential form and integrity of the historic property and its environment would be unimpaired. The new cameras, cabling, and monitors are all reversible features that could be removed in the future without impacts to the property's form, design, context, appearance, and feeling. The cameras were installed through the addition of small drill holes and the cabling was added to the exterior of the building within existing conduits or placed along the walls. The monitors were installed within interior walls in the existing control room and did not affect the configuration or use of any spaces.

In conclusion, based on the above analysis, the City has determined that the installation of new or replacement security cameras and their associated systems conform with the Secretary of the Interior's Standards for the Treatment of Historic Properties, and specifically the Standards for Rehabilitation. A representative sample of photographs depicting the new cameras, as well as specifications for the cameras, are included in Attachment A.

# ATTACHMENT A




Photo 1: Camera at top of parapet




Photo 2: Camera at top of parapet with exterior cabling




Photo 3: New camera at top of parapet; old camera located towards bottom of photograph





Photo 4: New camera at top of parapet with exterior cabling

## CCVWB2D1Z



## 2.4Megapixel 1080P Water-proof HDCVI IR-Bullet Camera



#### **Features**

- 1/2.8" 2.4Megapixel CMOS
- 25/30@1080P, 25/30/50/60fps@720P
- High speed, long distance real-time transmission
- HD and standard definition switchable
- OSD Menu, control over coaxial cable
- Day/Night(ICR), AWB, AGC, BLC, 3D-DNR
- 2.7~12mm motorized lens
- Max. IR LEDs length 30m (60m optional), Smart IR
- IP66, DC12V


# CCVWB2D1Z


## **Technical Specifications**

| Camera                |  |
|-----------------------|--|
| Image Sensor          | 1/2.8" 2.4Megapixel CMOS                               |
| Effective Pixels      | 1984(H)×1225(V)  |
| Electronic Shutter    | 1/3s~1/100,000s  |
| Video Frame Rate      | 25/30/50/60fps@720P; 25/30fps@1080P                    |
| Synchronization       | Internal   |
| Mini. Illumination    | 0.05Lux@F1.2(AGC ON), 0Lux IR on                       |
| Video Output          | 1-channel BNC HDCVI high definition video output/ CVBS |
|                       | standard definition video output (Can switch)          |
| Camera Features       |  |
| Max. IR LEDs Length   | 30m (60m optional), Smart IR                           |
| Day/Night             | Auto(ICR) / Color / B/W                                |
| Noise Reduction       | 2D/3D  |
| OSD Menu              | Support  |
| Lens                  |  |
| Focal Length          | 2.7~12mm   |
| Angle of View         | H: 105.5° ~32.9°                                       |
| Lens Type             | Motorized / Fixed Iris                                 |
| Mount Type            | Ф14  |
| General               |  |
| Power Supply          | DC12V±10%  |
| Power Consumption     | Max 7.44W(30m IR) / 11W(60m IR)                        |
| Working Environment   | -30°C~+60°C / Less than 95%RH (no condensation)        |
| Transmission Distance | Over 300m via 75-3 coaxial cable                       |
| Ingress Protection    | IP66   |
| Dimensions(W×D×H)     | 213mm×80mm×72mm  |
| Weight                | 0.55kg   |


## CCVWB2D1Z

## Dimensions (mm)





## **Accessories (optional)**



# APPENDIX N NOISE COMPLAINT LOG AND RESOLUTION FORM

## **CEC Complaint Log**

| Consulation Law November | Data Bassinad | Camalainant Nama | Complete and Complete traff           | Natura of Consolidat                   | Developed Cook and the data CEC |
|--------------------------|---------------|------------------|---------------------------------------|--|---------------------------------|
| Complaint Log Number     | Date Received | Complainant Name | Complainant Contact Info.             | Nature of Complaint                    | Report Submitted to CEC         |
| C1001                    |               |                  |                                       |  | 7/2/2010 (Closed)               |
| C1002                    |               |                  |                                       |  | 7/27/11 (Closed)                |
| C1003                    | 7/26/2012     | Ken Wilson       | 323-236-7600 KenWilson@microalarm.com | Startup noise from steam relief vents. | 8/10/2012 (Closed)              |
|                          |               |                  |                                       |  |                                 |
|                          |               |                  |                                       |  |                                 |
|                          |               |                  |                                       |  |                                 |
|                          |               |                  |                                       |  |                                 |
|                          |               |                  |                                       |  |                                 |
|                          |               |                  |                                       |  |                                 |
|                          |               |                  |                                       |  |                                 |
|                          |               |                  |                                       |  |                                 |
|                          |               |                  |                                       |  |                                 |
|                          |               |                  |                                       |  |                                 |
|                          |               |                  |                                       |  |                                 |
|                          |               |                  |                                       |  |                                 |
|                          |               |                  |                                       |  |                                 |
|                          |               |                  |                                       |  |                                 |
|                          |               |                  |                                       |  |                                 |
|                          |               |                  |                                       |  |                                 |
|                          |               |                  |                                       |  |                                 |
|                          |               |                  |                                       |  |                                 |
|                          |               |                  |                                       |  |                                 |
|                          |               |                  |                                       |  |                                 |

### Malburg Generating Station (CERSID: 10451263)

#### Facility Information Submitted Jul 30, 2018

Submitted on 7/30/2018 1:33:22 PM by Kyle McCormack of Malburg Generating Station (Vernon, CA)

- · Business Activities
- · Business Owner/Operator Identification

#### Hazardous Materials Inventory Submitted Jul 30, 2018

Submitted on 7/30/2018 1:33:22 PM by Kyle McCormack of Malburg Generating Station (Vernon, CA)

- Hazardous Material Inventory (47)
- · Site Map (Official Use Only)
  - · Annotated Site Map (Official Use Only) (Adobe PDF, 434KB)
  - Annotated Site Map (Official Use Only) (Adobe PDF, 395KB)
  - Annotated Site Map (Official Use Only) (Adobe PDF, 1419KB)

#### Emergency Response and Training Plans Submitted Jul 30, 2018

Submitted on 7/30/2018 1:33:22 PM by Kyle McCormack of Malburg Generating Station (Vernon, CA)

- Emergency Response/Contingency Plan
  - Emergency Response/Contingency Plan (Adobe PDF, 258KB)
  - Emergency Response/Contingency Plan (Adobe PDF, 891KB)
- Employee Training Plan
  - Provided In Submital Element: Emergency Response and Training Plans

#### Aboveground Petroleum Storage Act Submitted Jul 30, 2018

Submitted on 7/30/2018 1:33:22 PM by Kyle McCormack of Malburg Generating Station (Vernon, CA)

- Aboveground Petroleum Storage Act Documentation
  - Provided In Submital Element: Hazardous Materials Inventory

#### California Environmental Reporting System (CERS)

**Business Activities** 

#### Site Identification

#### Malburg Generating Station

4963 S Soto St Vernon, CA 90058 County

Los Angeles

CERS ID 10451263

EPA ID Number CAL000333289

#### **Submittal Status**

Submitted on 7/30/2018 by Kyle McCormack of Malburg Generating Station (Vernon, CA)

#### Hazardous Materials

Does your facility have on site (for any purpose) at any one time, hazardous materials at or above 55 gallons for liquids, 500 pounds for solids, or 200 cubic feet for compressed gases (include liquids in ASTs and USTs); or is regulated under more restrictive inventory local reporting requirements (shown below if present); or the applicable Federal threshold quantity for an extremely hazardous substance specified in 40 CFR Part 355, Appendix A or B; or handle radiological materials in quantities for which an emergency plan is required pursuant to 10 CFR Parts 30, 40 or 70?

Yes

#### Underground Storage Tank(s) (UST)

Does your facility own or operate underground storage tanks?

No

|  |  |  | last |  |
|--|--|--|------|--|
|  |  |  |      |  |
|  |  |  |      |  |

Is your facility a Hazardous Waste Generator?

Does your facility treat hazardous waste on-site?

No

No

Is your facility's treatment subject to financial assurance requirements (for Permit by Rule and Conditional Authorization)?

Does your facility consolidate hazardous waste generated at a remote site?

No

Does your facility need to report the closure/removal of a tank that was classified as hazardous waste and cleaned on-site?

No

Does your facility generate in any single calendar month 1,000 kilograms (kg) (2,200 pounds) or more of federal RCRA hazardous waste, or generate in any single calendar month, or accumulate at any time, 1 kg (2.2 pounds) of RCRA acute hazardous waste; or generate or accumulate at any time more than 100 kg (220 pounds) of spill cleanup materials contaminated with RCRA acute hazardous waste.

No

Is your facility a Household Hazardous Waste (HHW) Collection site?

No

#### **Excluded and/or Exempted Materials**

Does your facility recycle more than 100 kg/month of excluded or exempted recyclable materials (per HSC 25143.2)?

No

Does your facility own or operate ASTs above these thresholds? Store greater than 1,320 gallons of petroleum products (new or used) in aboveground tanks or containers.

Yes

Does your facility have Regulated Substances stored onsite in quantities greater than the threshold quantities established by the California Accidental Release prevention Program (CalARP)?

Yes

#### Additional Information

No additional comments provided.

#### California Environmental Reporting System (CERS)

**Business Owner Operator** 

Facility/Site

#### Malburg Generating Station

4963 S Soto St Vernon, CA 90058 **CERS ID** 10451263

#### Submittal Status

Submitted on 7/30/2018 by Kyle McCormack of Malburg Generating Station (Vernon, CA)

**Business Fax** 

(323) 476-3640

Identification

Colorado Energy Management, LLC

Operator Phone **Business Phone** (303) 442-5112

(323) 476-3610

**Beginning Date** 

031850840

**Ending Date** 

**Dun & Bradstreet** 

SIC Code 4911

**Primary NAICS** 221112

Facility/Site Mailing Address

4963 S Soto St Vernon, CA 90058 **Primary Emergency Contact** 

Matt Richards

Plant Manager

Business Phone (323) 476-3623 24-Hour Phone (626) 393-3748 Pager Number

Owner

Bicent (California) Malburg, LLC

(410) 770-9500 100 N. West Street Easton, MD 20601

Secondary Emergency Contact

Kyle McCormack

Title

**Environmental Manager** 

**Business Phone** 24-Hour Phone (323) 775-3873 (303) 607-5590

Pager Number

**Billing Contact** 

Charlotte McLemore

(323) 476-3622 4963 S Soto St Vernon, CA 90058 cmclemore@coloradoenergy.com

**Environmental Contact** 

Thomas Barnhart (720) 545-7231

4963 Soto Street

tbarnhart@coloradoenergy.com

Vernon, CA 90058

Name of Signer Matt Richards Signer Title Plant Manager **Document Preparer Thomas Barnhart** 

Additional Information

Locally-collected Fields

Some or all of the following fields may be required by your local regulator(s).

**Property Owner** 

Phone

Mailing Address

Assessor Parcel Number (APN)

**Number of Employees** 

Facility ID **VERN** 

| Facility Name Malbu                            | rg Generating Station rg Generating Station oto St, Vernon 90058  |                |  | Chemical Loca  Ammonia   |  | n - HRSG                  | 1 Vaporizing Sk  |                        | D VERN   | 0/2010 1.22 084 |
|--|---|----------------|--|--------------------------|--|---------------------------|--|------------------------|--|-----------------|
| OT Code/Fire Haz. Class                        | Common Name   | Unit           | Max. Daily                                 | Quantities Largest Cont. | Avg. Daily                               | Annual<br>Waste<br>Amount | Federal Hazard<br>Categories   | Status  Component Name | Submitted on 7/3 Hazardous Component (For mixture only) % Wt | •               |
| oxic, Corrosive, Flammable<br>iquid, Class I-C | Aqueous Ammonia  CAS No 1336-21-6  Map: SA-3A Grid: 4/5 B Item 18 | Liquid<br>Type | Storage Container Other  Days on Site: 365 | <b>50</b>                | 50 Pressue > Ambient Temperature Ambient | Waste Code                | - Physical - Physical Gas Under Pressure - Health Acute Toxicity - Health Skin Corrosion Irritation - Health Respiratory Skin Sensitization - Health Serious Eye Damage Eye Irritation |                        |  |                 |

Printed on 11/7/2018 10:00 AM Page 1 of 31

|  |   | Hazardo        | us Materials  | And Waste                | s Inventory                              | Matrix I                  | Report  |                           |   |                |
|--|---|----------------|---|--------------------------|--|---------------------------|---|---------------------------|---|----------------|
| Facility Name Malburg                            | g Generating Station<br>g Generating Station<br>to St, Vernon 90058 |                |   | Chemical Loca Ammonia    |  | n - HRSG 2                | 2 Vaporizing Ski  | CERS ID  Facility  Status | 10451263 ID VERN Submitted on 7/3                 | 0/2018 1:33 PM |
| OOT Code/Fire Haz. Class                         | Common Name   | Unit           | Max. Daily  | Quantities Largest Cont. | Avg. Daily                               | Annual<br>Waste<br>Amount | Federal Hazard<br>Categories  | Component Name            | Hazardous Component<br>(For mixture only)<br>% Wt | EHS CAS No.    |
| Toxic, Corrosive, Flammable<br>Liquid, Class I-C | Aqueous Ammonia  CAS No 1336-21-6  Map: SA-3A Grid: 4/5 B Item 19   | Liquid<br>Type | 50<br>Storage Container<br>Other<br>Days on Site: 365 | 50                       | 50 Pressue > Ambient Temperature Ambient | Waste Code                | - Health Acute Toxicity - Health Skin Corrosion Irritation - Health Respiratory Skin Sensitization - Health Serious Eye Damage Eye Irritation |                           |   |                |

Printed on 11/7/2018 10:00 AM Page 2 of 31

| CERS Resigned (One Malbur                   | a Conorating Station  |                | us Materials /                                       |               |                        |                 |  | OFFICE ID      | 10451262                                  |                |
|---|---|----------------|--|---------------|------------------------|-----------------|--|----------------|---|----------------|
|   | g Generating Station<br>g Generating Station                      |                |  | Chemical Loc  |                        | n Undor         | ground Piping  | CERS ID        | 10451263  D VERN                          |                |
|   | to St, Vernon 90058   |                |  | Ammonia       | Distributio            | ni - Olidei     | ground Piping  | Status         | Submitted on 7/3                          | 0/2018 1:33 PM |
|   |   |                |  | Quantities    |                        | Annual<br>Waste | Federal Hazard   |                | Hazardous Component<br>(For mixture only) | ts             |
| OOT Code/Fire Haz. Class                    | Common Name   | Unit           | Max. Daily   | Largest Cont. | Avg. Daily             | Amount          | Categories   | Component Name | % Wt                                      | EHS CAS No.    |
| oxic, Corrosive, Flammable iquid, Class I-C | Aqueous Ammonia  CAS No 1336-21-6  Map: SA-3A Grid: 2 C/D Item 16 | Liquid<br>Type | Storage Container Aboveground Tank Days on Site: 365 | 50            | 50 Pressue Temperature | Waste Code      | - Physical - Physical Gas Under Pressure - Health Acute Toxicity - Health Skin Corrosion Irritation - Health Respiratory Skin Sensitization - Health Serious Eye Damage Eye Irritation |                |   |                |

Printed on 11/7/2018 10:00 AM Page 3 of 31

| acility Name Malburg                          | Generating Station Generating Station                             |                                |   | Chemical Local           | storage Ar                  | ea - Pum                  | p Skid   | CERS ID<br>Facility I  | D VERN   |   |
|---|---|--------------------------------|---|--------------------------|-----------------------------|---------------------------|--|------------------------|--|---|
| 4963 S SOT  OT Code/Fire Haz. Class           | o St, Vernon 90058  Common Name                                   | Unit                           | Max. Daily  | Quantities Largest Cont. | Avg. Daily                  | Annual<br>Waste<br>Amount | Federal Hazard<br>Categories   | Status  Component Name | Submitted on 7/36 Hazardous Component (For mixture only)  % Wt | • |
| oxic, Corrosive, Flammable<br>quid, Class I-C | Aqueous Ammonia  CAS No 1336-21-6  Map: SA-3A Grid: 2 C/D Item 16 | Gallons State Liquid Type Pure | S 5<br>Storage Container<br>Aboveground Tank<br>Days on Site: 365 | 5                        | 5<br>Pressue<br>Temperature | Waste Cod                 | - Physical Flammable - Health Acute Toxicity - Health Skin Corrosion Irritation - Health Respiratory Skin Sensitization - Health Serious Eye Damage Eye Irritation |                        |  |   |

Printed on 11/7/2018 10:00 AM Page 4 of 31

| acility Name Malburg                           | Generating Station Generating Station o St, Vernon 90058          |                |  | Chemical Loca  Ammonia      | Storage Ar               | ea - Stora                | ge Tank  | Status         | VERN Submitted on 7/3                             | •           |
|--|---|----------------|--|-----------------------------|--------------------------|---------------------------|--|----------------|---|-------------|
| OT Code/Fire Haz. Class                        | Common Name   | Unit           | Max. Daily   | Quantities<br>Largest Cont. | Avg. Daily               | Annual<br>Waste<br>Amount | Federal Hazard<br>Categories   | Component Name | Hazardous Component<br>(For mixture only)<br>% Wt | EHS CAS No. |
| oxic, Corrosive, Flammable<br>iquid, Class I-C | Aqueous Ammonia  CAS No 1336-21-6  Map: SA-3A Grid: 2 C/D Item 15 | Liquid<br>Type | 8000<br>Storage Container<br>Aboveground Tank<br>Days on Site: 365 | 10809                       | 4000 Pressue Temperature | Waste Code                | - Physical - Physical Gas Under Pressure - Health Acute Toxicity - Health Skin Corrosion Irritation - Health Respiratory Skin Sensitization - Health Serious Eye Damage Eye Irritation |                |   |             |

Printed on 11/7/2018 10:00 AM Page 5 of 31

|                       |               |  | Hazardo          | ous Materials /             | And Waste     | s Inventory                           | Matrix          | Report                             |  |  |                |
|-----------------------|---------------|--|------------------|-----------------------------|---------------|---------------------------------------|-----------------|------------------------------------|--|--|----------------|
| CERS Business/Org.    | Malburg 6     | Generating Station                                   |                  |                             | Chemical Loca | ition                                 |                 |                                    | CERS ID  | 10451263                                 |                |
| Facility Name         | Malburg 6     | Generating Station                                   |                  |                             | Auxiliary     | Power Distri                          | ibution 1       | Transformer Are                    | a Facility ID                                  | VERN                                     |                |
|                       | 4963 S Soto S | St, Vernon 90058                                     |                  |                             | Transforn     | ner A                                 |                 |                                    | Status   | Submitted on 7/30                        | 0/2018 1:33 PM |
|                       |               |  |                  |                             | Quantities    |                                       | Annual<br>Waste | Federal Hazard                     |  | zardous Component:<br>(For mixture only) | 5              |
| DOT Code/Fire Haz. Cl | lass          | Common Name  | Unit             | Max. Daily                  | Largest Cont. | Avg. Daily                            | Amount          | Categories                         | Component Name                                 | % Wt                                     | EHS CAS No.    |
|                       |               | Transformer Oil                                      | Gallons<br>State | \$ 280<br>Storage Container | 280           | 280<br>Pressue                        |                 | - Physical<br>Flammable            | Severely Hydrotreated I<br>Napthalic Hydro Oil | _ight 100 %                              | 64742-53-6     |
| Combustible Liquid    | , Class III-B | CAS No<br>64742-53-6<br>Map: SA-3A Grid: 1 B Item 44 | Liquid<br>Type   | Other  Days on Site: 365    |               | > Ambient<br>Temperature<br>> Ambient | Waste Cod       | e - Physical Gas<br>Under Pressure | 2,6 di-tert-butyl                              | 0 %                                      | 128-37-0       |

Printed on 11/7/2018 10:00 AM Page 6 of 31

|                      |                |  | Hazardo          | ous Materials A             | And Waste     | s Inventory                           | Matrix          | Report                              |  |  |                |
|----------------------|----------------|--|------------------|-----------------------------|---------------|---------------------------------------|-----------------|-------------------------------------|--|--|----------------|
| CERS Business/Org.   | Malburg 0      | Generating Station                                   |                  |                             | Chemical Loca | ition                                 |                 |                                     | CERS ID  | 10451263                                 |                |
| Facility Name        | Malburg 6      | Generating Station                                   |                  |                             | Auxiliary     | Power Distri                          | ibution T       | Transformer Are                     | ea Facility ID                                 | VERN                                     |                |
|                      | 4963 S Soto    | St, Vernon 90058                                     |                  |                             | Transforn     | ner B                                 |                 |                                     | Status   | Submitted on 7/3                         | )/2018 1:33 PM |
|                      |                |  |                  |                             | Quantities    |                                       | Annual<br>Waste | Federal Hazard                      |  | azardous Component<br>(For mixture only) | 5              |
| DOT Code/Fire Haz. C | Class          | Common Name  | Unit             | Max. Daily                  | Largest Cont. | Avg. Daily                            | Amount          | Categories                          | Component Name                                 | % Wt                                     | EHS CAS No.    |
|                      |                | Transformer Oil                                      | Gallons<br>State | \$ 280<br>Storage Container | 280           | 280<br>Pressue                        |                 | - Physical<br>Flammable             | Severely Hydrotreated I<br>Napthalic Hydro Oil | Light 100 %                              | 64742-53-6     |
| Combustible Liquid   | l, Class III-B | CAS No<br>64742-53-6<br>Map: SA-3A Grid: 1 B Item 45 | Liquid<br>Type   | Other  Days on Site: 365    |               | > Ambient<br>Temperature<br>> Ambient | Waste Cod       | le - Physical Gas<br>Under Pressure | 2,6 di-tert-butyl                              | 0 %                                      | 128-37-0       |

Printed on 11/7/2018 10:00 AM Page 7 of 31

|                                     |         |   | Hazardous Materials And Wastes Inventory Matrix Report |   |                   |  |                 |                                    |                               |   |                |
|-------------------------------------|---------|---|--|---|-------------------|--|-----------------|------------------------------------|-------------------------------|---|----------------|
| CERS Business/Org.<br>Facility Name | Malburg | g Generating Station<br>g Generating Station<br>to St. Vernon 90058                   |  |   | Chemical Loca     | ition  |                 |                                    | CERS ID<br>Facility<br>Status | 10451263  VERN Submitted on 7/3                   | 0/2018 1:33 PM |
| DOT Code/Fire Haz. C                | lace    | Common Name   | Unit   | May Daily   | Quantities        | Aug Dailu  | Annual<br>Waste | Federal Hazard                     | Component Name                | Hazardous Component<br>(For mixture only)<br>% Wt | •              |
| JOT Code/Fire Haz. C                | idss    | Nitrogen  CAS No 7717-37-9  Map: SA-3A Grid: 3 B Item 36                              | Cu. Feet   | Max. Daily  568 Storage Container Cylinder                              | Largest Cont. 568 | 284 Pressue > Ambient Temperature                      |                 | - Physical Gas<br>- Under Pressure | Component Name                | 76 WL   | ERS CAS NO.    |
| oxic                                |         | Nitrogen / Nitrogen Oxide / Carbon Monoxide Blend CAS No Map: SA-3A Grid: 3 B item 37 | Cu. Feet<br>State<br>Gas<br>Type                       | Days on Site: 365  1704  Storage Container  Cylinder  Days on Site: 365 | 284               | Ambient  852  Pressue  > Ambient  Temperature  Ambient |                 | - Physical Gas<br>Under Pressure   |                               |   |                |

Printed on 11/7/2018 10:00 AM Page 8 of 31

|                                     |                |  | Hazardou | us Materials   | And Waste                   | s Inventor                                   | y Matrix     | Report                                |                |                         |             |
|-------------------------------------|----------------|--|----------|--|-----------------------------|--|--------------|---------------------------------------|----------------|-------------------------|-------------|
| CERS Business/Org.<br>Facility Name | _              | Generating Station Generating Station                  |          |  | Chemical Loca               |  | Generato     | or Building CTG1                      | CERS ID        | 10451263<br>VERN        |             |
|                                     | _              | St, Vernon 90058                                       |          |  |                             |  | Annual       |                                       | Status         | Submitted on 7/3        | •           |
| DOT Code/Fire Haz. (                | class          | Common Name  | Unit     | Max. Daily   | Quantities<br>Largest Cont. | Avg. Daily                                   | Waste Amount | Federal Hazard<br>Categories          | Component Name | (For mixture only) % Wt | EHS CAS No. |
| Combustible Liquic                  | l, Class III-B | CAS No<br>64742-54-7<br>Map: SA-3A Grid: 6/7 B Item 33 | Liquid A | 3700 Storage Container Aboveground Tan Days on Site: 365 | ,                           | 3700 Pressue > Ambient Temperature > Ambient |              | - Physical<br><sub>le</sub> Flammable |                |                         |             |

Printed on 11/7/2018 10:00 AM Page 9 of 31

|                                     |                |  | Hazardo        | us Materials /  | And Waste                   | s Inventor                                   | y Matrix     | Report                                |                |                            |             |
|-------------------------------------|----------------|--|----------------|---|-----------------------------|--|--------------|---------------------------------------|----------------|----------------------------|-------------|
| CERS Business/Org.<br>Facility Name |                | Generating Station Generating Station                              |                |   | Chemical Loca               |  | Generato     | or Building CTG2                      | CERS ID        | 10451263<br>VERN           |             |
|                                     | _              | St, Vernon 90058   |                |   |                             |  | Annual       |                                       | Status         | Submitted on 7/3           | •           |
| DOT Code/Fire Haz. (                | Class          | Common Name  | Unit           | Max. Daily  | Quantities<br>Largest Cont. | Avg. Daily                                   | Waste Amount | Federal Hazard<br>Categories          | Component Name | (For mixture only)<br>% Wt | EHS CAS No. |
| Combustible Liquid                  | I, Class III-B | Lubricating Oil  CAS No 64742-54-7  Map: SA-3A Grid: 6/7 C Item 34 | Liquid<br>Type | 3700 Storage Container Aboveground Tank Days on Site: 365 | 3700                        | 3700 Pressue > Ambient Temperature > Ambient |              | - Physical<br><sub>le</sub> Flammable |                |                            |             |

Printed on 11/7/2018 10:00 AM Page 10 of 31

|  |  | Hazardous Ma   | terials And Waste       | es Inventor                                    | y Matrix I               | Report  |                                     |   |                         |
|--|--|--|-------------------------|--|--------------------------|---|-------------------------------------|---|-------------------------|
| Facility Name Malburg  | Generating Station<br>Generating Station                               |  | Chemical Loc<br>Covered |  | a Next to                | Ammonia Tanl  | CERS ID<br>K Facility ID            |   |                         |
| 4963 S Soto  | St, Vernon 90058   |  | Quantities              |  | Annual<br>Waste          | Federal Hazard  | Status<br>H                         | Submitted on 7/3<br>lazardous Component<br>(For mixture only) | •                       |
| OOT Code/Fire Haz. Class OOT: 3 - Flammable and Combustible Liquids Combustible Liquid, Class II | Common Name  Diesel Fuel No. 2  CAS No 68476-34-6  Map: SA-3a Grid: D3 | Gallons 1 State Storage Co Liquid Steel Dru Type     | ım                      | Avg. Daily  100  Pressue  Ambient  Temperature |                          | - Physical<br>Flammable<br>- Health Acute<br>Toxicity | Component Name                      | % Wt  | EHS CAS No.             |
| Combustible Liquid, Class III-B  | Used lubricating oils  CAS No. 70514-12-4                              | Gallons State Storage Co Liquid Steel Dru Type Waste | 5 55<br>ontainer        | Ambient  1 Pressue Ambient Temperature Ambient | 350<br>Waste Code<br>221 |   | Waste Oil<br>Water                  | 95 %<br>5 %   | 70514-12-4<br>7732-18-5 |
|  | Rags<br>CAS No.<br>65996-61-4  |  | ım                      | 1 Pressue Temperature                          | 500<br>Waste Code        |   | Oil<br>Rags<br>Wipes, Polypropylene | 30 %<br>70 %<br>20 %  | 8012-95-1               |

Printed on 11/7/2018 10:00 AM Page 11 of 31

|  |   | Hazardous | Materials /  | And Waste                  | s Inventor                              | y Matrix        | Report                        |                       |   |             |
|--|---|-----------|--|----------------------------|---|-----------------|-------------------------------|-----------------------|---|-------------|
| CERS Business/Org.<br>Facility Name                            | Malburg Generating Station Malburg Generating Station |           |  | Chemical Loca  Diesel Fire | tion<br>Pump Hou                        | use             |                               | CERS ID<br>Facility I | 10451263<br>D VERN                                      |             |
|  | 4963 S Soto St, Vernon 90058                          |           |  | Quantities                 |   | Annual<br>Waste | Federal Hazard                | Status                | Submitted on 7/3 Hazardous Component (For mixture only) | •           |
| OOT Code/Fire Haz. C   | class Common Name                                     | Unit      | Max. Daily   | Largest Cont.              | Avg. Daily                              | Amount          | Categories                    | Component Name        | % Wt  | EHS CAS No. |
| DOT: 3 - Flammable<br>Combustible Liquid<br>Combustible Liquid | CAS No. 68476-34-6                                    | Liquid Ta | 240<br>orage Container<br>ink Inside Buildin<br>ays on Site: 365 | <b>240</b>                 | 240 Pressue Ambient Temperature Ambient | Waste Cod       | - Physical<br>Flammable<br>le |                       |   |             |

Printed on 11/7/2018 10:00 AM Page 12 of 31

|                         |            |  | Hazardo                   | us Materials <i>i</i>                                       | And Waste                | s Inventor                                   | y Matrix I                | Report  |   |                                     |                        |
|-------------------------|------------|--|---------------------------|---|--------------------------|--|---------------------------|---|---|-------------------------------------|------------------------|
| Facility Name           | Malburg G  | enerating Station enerating Station st, Vernon 90058             |                           |   | Chemical Loca            |  | SU) Area                  | - GSU CTG1  | CERS ID 1045 Facility ID VERN Status Submi                              | ı                                   | 0/2018 1:33 PM         |
| DOT Code/Fire Haz. Clas | 55         | Common Name  | Unit                      | Max. Daily  | Quantities Largest Cont. | Avg. Daily                                   | Annual<br>Waste<br>Amount | Federal Hazard<br>Categories                                | Hazardou  | s Component<br>ixture only)<br>% Wt | •                      |
| Combustible Liquid, C   |            | Transformer Oil  CAS No 64742-53-6  Map: SA-3A Grid: 7 D Item 30 | Gallons State Liquid Type |   | 4370                     | 4370 Pressue > Ambient Temperature > Ambient | Waste Code                | - Physical<br>Flammable<br>- Physical Gas<br>Under Pressure | Severely Hydrotreated Light<br>Napthalic Hydro Oil<br>2,6 di-tert-butyl | 100 %                               | 64742-53-6<br>128-37-0 |
| DOT: 2.2 - Nonflamm     | able Gases | Nitrogen  CAS No   | Gas<br>Type               | t 140<br>Storage Container<br>Cylinder<br>Days on Site: 365 |                          | Pressue > Ambient Temperature Ambient        |                           | - Physical Gas<br>Under Pressure                            |   |                                     | ,<br>,<br>,            |

Printed on 11/7/2018 10:00 AM Page 13 of 31

|  |  | Hazardou                | s Materials   | And Waste              | s Inventory   | y Matrix I      | Report  |  |                          |                        |
|--|--|-------------------------|---|------------------------|---|-----------------|---|--|--------------------------|------------------------|
| Facility Name Ma                                   | alburg Generating Station<br>alburg Generating Station<br>i3 S Soto St, Vernon 90058 |                         |   | Chemical Loca Generato |   | SU) Area        | - GSU CTG2  | CERS ID 10451 Facility ID VERN Status Submit                                     |                          | 0/2018 1:33 PM         |
| 207.0 1 /5: 11 .01                                 |  |                         |   | Quantities             |   | Annual<br>Waste | Federal Hazard  | (For mix   | Component<br>cture only) |                        |
| DOT Code/Fire Haz. Class  Combustible Liquid, Clas | Common Name   Transformer Oil  | Liquid O<br>Type        | Max. Daily 4370 torage Container other  asys on Site: 365 | Largest Cont. 4370     | Avg. Daily 4370 Pressue > Ambient Temperature > Ambient |                 | - Physical<br>Flammable<br>- Physical Gas<br>Under Pressure | Component Name Severely Hydrotreated Light Napthalic Hydro Oil 2,6 di-tert-butyl | % Wt<br>100 %<br>0 %     | 64742-53-6<br>128-37-0 |
| DOT: 2.2 - Nonflammab                              | CAS No   | Cu. Feet State Si Gas C | 140<br>torage Container<br>ylinder                        |                        | Pressue > Ambient Temperature Ambient                   |                 | - Physical Gas<br>Under Pressure                            |  |                          |                        |

Printed on 11/7/2018 10:00 AM Page 14 of 31

|                         |             |   | Hazardou         | ıs Materials .  | And Waste               | s Inventory                             | y Matrix I      | Report                           |  |               |                           |
|-------------------------|-------------|---|------------------|---|-------------------------|---|-----------------|----------------------------------|--|---------------|---------------------------|
| Facility Name           | Malburg G   | enerating Station<br>ienerating Station<br>st, Vernon 90058 |                  |   | Chemical Loca Generator | tion<br>r Step up (G                    | SSU) Area       | - GSU STG                        | CERS ID 10451 Facility ID VERN Status Submit                   |               | 0/2018 1:33 PM            |
|                         |             |   |                  |   | Quantities              |   | Annual<br>Waste | Federal Hazard                   | (For mix   | Component     |                           |
| DOT Code/Fire Haz. Clas | SS          | Transformer Oil   | Gallons          | Max. Daily 4370   | Largest Cont.           | Avg. Daily<br>4370                      | Amount          | - Physical<br>Flammable          | Component Name Severely Hydrotreated Light Napthalic Hydro Oil | % Wt<br>100 % | EHS CAS No.<br>64742-53-6 |
| Combustible Liquid, (   | Class III-B | CAS No  | Liquid C<br>Type | Other  Days on Site: 365                                  |                         | > Ambient Temperature > Ambient         |                 | Physical Gas<br>Under Pressure   | 2,6 di-tert-butyl  | 0 %           | 128-37-0                  |
| DOT: 2.2 - Nonflamm     | able Gases  | Nitrogen  CAS No 7727-37-9  Map: SA-3A Grid: 6 D Item 32    | Gas C            | 140<br>Storage Container<br>Cylinder<br>Days on Site: 365 |                         | 0 Pressue > Ambient Temperature Ambient |                 | - Physical Gas<br>Under Pressure |  |               |                           |

Printed on 11/7/2018 10:00 AM Page 15 of 31

|  |                    |  | Hazardo                                 | ous Materials <i>A</i>   | And Waste                     | s Inventory   | / Matrix                                | Report  |                                 |   |
|--|--------------------|--|---|--|-------------------------------|---|---|---|---------------------------------|---|
| Facility Name Ma   | alburg G           | enerating Station<br>enerating Station<br>t, Vernon 90058                                  |   |  | Chemical Loca                 | oling Tower   | Bulk Cher                               | nical Area  | CERS ID<br>Facility I<br>Status | 10451263  VERN Submitted on 7/30/2018 1:33 PM             |
| DOT Code/Fire Haz. Class<br>Toxic, Combustible Liqui<br>III-B                | iid, Class         | Common Name  Acrylate Polymer, Phosphate, Phosphonate  CAS No  Map: SA-3B Grid: 2 A Item 6 | Unit  Gallons State Liquid Type Mixture | Max. Daily  1300 Storage Container Aboveground Tank  Days on Site: 365 | Quantities Largest Cont. 1300 | Avg. Daily<br>650<br>Pressue<br>Ambient<br>Temperature<br>Ambient | Annual<br>Waste<br>Amount<br>Waste Code | Federal Hazard<br>Categories<br>- Health Skin<br>Corrosion<br>Irritation                                    |                                 | Hazardous Components (For mixture only)  % Wt EHS CAS No. |
| DOT: 8 - Corrosives (Liqu<br>Solids)<br>Toxic, Corrosive, Water I<br>Class 2 | uids and Reactive, | Sulfuric Acid 66 Be  | Gallons State Liquid Type Pure          | Storage Container Aboveground Tank Days on Site: 365                   | 2500                          | 1500<br>Pressue<br>Ambient<br>Temperature<br>Ambient              | Waste Code                              | - Physical Corrosive To Metal - Health Skin Corrosion Irritation - Health Serious Eye Damage Eye Irritation |                                 |   |
| DOT: 8 - Corrosives (Liqu<br>Solids)<br>Corrosive, Toxic, Oxidizii<br>2      | ing, Class         | Sodium Hypochlorite  CAS No 7681-52-9  Map: SA-3B Grid: 2 A Item 8                         | Gallons State Liquid Type Pure          | Storage Container Plastic/Non-metali Days on Site: 365                 | <b>2400</b><br><br>c Drum     | 1500<br>Pressue<br>Ambient<br>Temperature<br>Ambient              | Waste Code                              | - Physical Oxidize  - Health Skin Corrosion Irritation - Health Serious Eye Damage Eye Irritation           | r                               |   |

Printed on 11/7/2018 10:00 AM Page 16 of 31

|   |  | Hazardo                 | us Materials A   | And Waste     | s Inventory   | y Matrix        | Report  |  |   |                      |
|---|--|-------------------------|--|---------------|---|-----------------|---|--|---|----------------------|
| acility Name Malburg  | Generating Station Generating Station St, Vernon 90058                 |                         |  | Chemical Loca |   | Specialty       | Chemical Area   | Facility ID  | 10451263<br>VERN<br>Submitted on 7/3      | 0/2018 1:33 PM       |
|   |  |                         |  | Quantities    |   | Annual<br>Waste | Federal Hazard  |  | lazardous Component<br>(For mixture only) |                      |
| DOT Code/Fire Haz. Class DOT: 8 - Corrosives (Liquids and Solids) Corrosive, Toxic, Flammable Liquid, Class I-C | Common Name  Biocide  CAS No  Map: SA-3B Grid: 4 B/C Item 4            | Liquid<br>Type          | Max. Daily  150  Storage Container Aboveground Tank  Days on Site: 365 | 75            | Avg. Daily  100  Pressue  Ambient  Temperature  Ambient | Waste Code      | - Health Acute Toxicity - Health Skin Corrosion Irritation - Health Serious Eye Damage Eye Irritation | Component Name  Dimethyl-Dioctyl-Amm Chloride Glycerol | % Wt<br>nonium 50 %<br>10 %               | 5538-94-3<br>56-81-5 |
| lammable Liquid, Class I-C  | Biodispersant - Deposit Penetra  CAS No  Map: SA-3B Grid: 4 B/C Item 5 | State<br>Liquid<br>Type | 475 Storage Container Aboveground Tank Days on Site: 365               | 400           | 250 Pressue Ambient Temperature Ambient                 | Waste Code      | <u>!</u>  |  |   |                      |

Printed on 11/7/2018 10:00 AM Page 17 of 31

|  |                               | Hazardou          | s Materials                          | And Waste     | s inventory            | viviatrix       | Keport              |                       |  |                |
|--|-------------------------------|-------------------|--------------------------------------|---------------|------------------------|-----------------|---------------------|-----------------------|--|----------------|
| _  | Generating Station            |                   |                                      | Chemical Loca |                        |                 |                     | CERS ID               | 10451263                                 |                |
| Facility Name Malburg                                    | Generating Station            |                   |                                      | HRSG Wa       | ter Chemica            | l Area          |                     | Facility ID           | VERN                                     |                |
| 4963 S Soto  | St, Vernon 90058              |                   |                                      |               |                        |                 |                     | Status                | Submitted on 7/3                         | 0/2018 1:33 PM |
|  |                               |                   |                                      | Quantities    |                        | Annual<br>Waste | Federal Hazard      | Ha                    | azardous Component<br>(For mixture only) | S              |
| OOT Code/Fire Haz. Class                                 | Common Name                   | Unit              | Max. Daily                           | Largest Cont. | Avg. Daily             | Amount          | Categories          | Component Name        | % Wt                                     | EHS CAS No.    |
|  | Oxygen Scavenger              | Gallons           | 300                                  | 200           | 200                    |                 | - Physical          |                       |  |                |
| Explosive  | CAS No<br>497-18-7            |                   | torage Container<br>Aboveground Tanl | <br>k         | Pressue<br>Ambient     | Waste Cod       | - Health Acute      |                       |  |                |
|  | Map: SA-3A Grid: 3 B/C Item 1 | Type<br>Mixture D | Days on Site: 365                    |               | Temperature<br>Ambient |                 | Toxicity            |                       |  | 1              |
|  | Corrosion Inhibitor           | Gallons           | 600                                  | 200           | 400                    |                 | - Physical          | Cyclohexylamine       | 30 %                                     | 108-91-8       |
| oxic, Corrosive, Flammable iquid, Class I-C, Combustible | CAS No                        |                   | torage Container<br>Aboveground Tan  | <br>k         | Pressue<br>Ambient     | Waste Cod       | - Health Acute      | Morpholine            | 10 %                                     | 110-91-8       |
| iquid, Class II  | Map: SA-3A Grid: S B/C Item 2 | Type<br>Mixture D | Days on Site: 365                    |               | Temperature<br>Ambient |                 | Toxicity            |                       |  |                |
|  | Boiler Phosphate              | Gallons           | 200                                  | 200           | 100                    |                 | - Health Skin       | Sodium Hydroxide      | 5 %                                      | 1310-73-2      |
| orrosive   | CAS No                        |                   | torage Container<br>Aboveground Tan  | <br>k         | Pressue<br>Ambient     | Waste Cod       | Entroion Irritation | Sodium Tripolyphospha | ite 5 %                                  | 7758-29-4      |
|  | Map: SA-3A Grid: 3 B/C Item 3 | Type<br>Mixture D | Days on Site: 365                    |               | Temperature<br>Ambient |                 |                     |                       |  |                |

Printed on 11/7/2018 10:00 AM Page 18 of 31

|                                     |               |  | Hazardo                           | ous Materials /                            | And Waste                  | s Inventory                                 | / Matrix                  | Report                        |   |  |                        |
|-------------------------------------|---------------|--|-----------------------------------|--|----------------------------|---|---------------------------|-------------------------------|---|--|------------------------|
| CERS Business/Org.<br>Facility Name | Malburg 0     | Generating Station Generating Station St, Vernon 90058 |                                   |  | Chemical Loca  Main Pow  A |   | ion Tran                  | sformer Area T                | ransformer Facility ID  | 10451263<br>VERN<br>Submitted on 7/30            | 0/2010 1·22 DM         |
| DOT Code/Fire Haz. (                |               | Common Name  | Unit                              | Max. Daily                                 | Quantities Largest Cont.   | Avg. Daily                                  | Annual<br>Waste<br>Amount | Federal Hazard<br>Categories  | На  | azardous Component<br>(For mixture only)<br>% Wt | •                      |
| Combustible Liquic                  | , Class III-B | CAS No<br>64742-53-6<br>Map: SA-3A Grid: 5/6 C Item 42 | Gallons State Liquid Type Mixture | Storage Container Other  Days on Site: 365 | 280                        | 280 Pressue > Ambient Temperature > Ambient | Waste Coo                 | - Physical<br>Flammable<br>de | Severely Hydrotreated<br>Napthalic Hydro Oil<br>2,6 di-tert-butyl | Light 100 % 0 %                                  | 64742-53-6<br>128-37-0 |

Printed on 11/7/2018 10:00 AM Page 19 of 31

| CERS Business/Org.     | Malhurg (   | Generating Station   | Hazardo                                      | ous Materials A                            | And Waste     |   | y Matrix        | Report                  | cers id <b>10451</b>  | 263                      |                        |
|------------------------|-------------|--|--|--|---------------|---|-----------------|-------------------------|---|--------------------------|------------------------|
|                        | _           | Generating Station   |  |  |               |   | tion Trans      | former Area             | Transformer Facility ID VERN  |                          |                        |
|                        | _           | St, Vernon 90058   |  |  | В             |   |                 |                         | ,                                 |                          | )/2018 1:33 PM         |
|                        |             |  |  |  | Quantities    |   | Annual<br>Waste | Federal Hazard          |   | Components<br>ture only) | 5                      |
| DOT Code/Fire Haz. Cla | SS          | Common Name  | Unit   | Max. Daily                                 | Largest Cont. | Avg. Daily                                  | Amount          | Categories              | Component Name  | % Wt                     | EHS CAS No.            |
| Combustible Liquid, (  | Class III-B | Transformer Oil  CAS No 64742-53-6  Map: SA-3A Grid: 5/6 C Item 43 | Gallon<br>State<br>Liquid<br>Type<br>Mixture | Storage Container Other  Days on Site: 365 | 280           | 280 Pressue > Ambient Temperature > Ambient | Waste Code      | - Physical<br>Flammable | Severely Hydrotreated Light<br>Napthalic Hydro Oil<br>2,6 di-tert-butyl | 100 %<br>0 %             | 64742-53-6<br>128-37-0 |
| Combustible Liquid, (  | Class III-B | CAS No<br>64742-53-6<br>Map: SA-3A Grid: 5/6 C Item 43             | Gallon<br>State<br>Liquid<br>Type<br>Mixture | Storage Container Other  Days on Site: 365 | 280           | 280 Pressue > Ambient Temperature > Ambient | Waste Code      | - Physical<br>Flammable | Severely Hydrotreated Light<br>Napthalic Hydro Oil<br>2,6 di-tert-butyl | 100 %<br>0 %             | 64742-53-6<br>128-37-0 |

Printed on 11/7/2018 10:00 AM Page 20 of 31

|                              |   | Hazardou | s Materials A   | And Waste                | s Inventor   | y Matrix                  | Report   |                                  |   |                |
|------------------------------|---|----------|---|--------------------------|--|---------------------------|--|----------------------------------|---|----------------|
| Facility Name Malbur         | g Generating Station<br>g Generating Station<br>to St, Vernon 90058 |          |   | Chemical Local Natural G | ation<br>as Accumu                                     | lator                     |  | CERS ID<br>Facility II<br>Status | 10451263 VERN Submitted on 7/3                    | 0/2018 1:33 PM |
| OOT Code/Fire Haz. Class     | Common Name   | Unit     | Max. Daily  | Quantities Largest Cont. | Avg. Daily   | Annual<br>Waste<br>Amount | Federal Hazard<br>Categories   | Component Name                   | Hazardous Component<br>(For mixture only)<br>% Wt | EHS CAS No.    |
| Flammable Gas, Explosive, To | Natural Gas  xic  | Gas Al   | 1600<br>torage Container<br>boveground Tank<br>ays on Site: 365 | 1600                     | 1600<br>Pressue<br>> Ambient<br>Temperature<br>Ambient | Waste Cod                 | - Physical Flammable - Physical Gas Under Pressure - Physical Explosive - Health Simple Asphyxiant |                                  |   |                |

Printed on 11/7/2018 10:00 AM Page 21 of 31

|   |   | Hazardou | s Materials <i>I</i>   | And Waste                | s Inventor   | y Matrix                  | Report  |                |  |             |  |
|---|---|----------|--|--------------------------|--|---------------------------|---|----------------|--|-------------|--|
| CERS Business/Org. Malburg Generating Station Facility Name Malburg Generating Station 4963 S Soto St, Vernon 90058 |   |          |  |                          | Chemical Location  Natural Gas Compressor Skid         |                           |   |                | CERS ID 10451263  Facility ID VERN  Status Submitted on 7/30/2018 1: |             |  |
| DOT Code/Fire Haz. Class  | Common Name   | Unit     | Max. Daily   | Quantities Largest Cont. | Avg. Daily   | Annual<br>Waste<br>Amount | Federal Hazard<br>Categories  | Component Name | Hazardous Component<br>(For mixture only)<br>% Wt                    | EHS CAS No. |  |
| Flammable Gas, Explosive  | Natural Gas  CAS No 8006-1-2 Map: SA-3A Grid: 4 C Item 20 | Gas Al   | 4000<br>orage Container<br>boveground Tank<br>ays on Site: 365 | 4000                     | 4000<br>Pressue<br>> Ambient<br>Temperature<br>Ambient | Waste Cod                 | - Physical - Physical - Physical Gas - Under Pressure - Physical Explosive - Health Simple Asphyxiant |                |  |             |  |

Printed on 11/7/2018 10:00 AM Page 22 of 31

|   |  | Hazardou                              | s Materials /   | And Waste                | s Inventor                                 | y Matrix                  | Report   |  |   |             |
|---|--|---------------------------------------|---|--------------------------|--|---------------------------|--|--|---|-------------|
| CERS Business/Org. Malb<br>Facility Name Malb<br>4963 S |  | Chemical Location  Natural Gas Cooler |   |                          |  |                           |  | CERS ID 10451263  Facility ID VERN  Status Submitted on 7/30/2018 1:3: |   |             |
| DOT Code/Fire Haz. Class                                | Common Name  | Unit                                  | Max. Daily  | Quantities Largest Cont. | Avg. Daily                                 | Annual<br>Waste<br>Amount | Federal Hazard<br>Categories   | Component Name   | Hazardous Component<br>(For mixture only)<br>% Wt | EHS CAS No. |
| Flammable Gas   | Natural Gas  CAS No 8006-14-2 Map: SA-3A Grid: 4 C Item 22 | Gas Al                                | 1600<br>corage Container<br>boveground Tank<br>ays on Site: 365 | 1600                     | 1600 Pressue > Ambient Temperature Ambient | Waste Cod                 | - Physical Flammable - Physical Gas Under Pressure - Physical Explosive - Health Simple Asphyxiant |  |   |             |

Printed on 11/7/2018 10:00 AM Page 23 of 31

|   |   | Hazardou | ıs Materials <i>I</i>   | And Waste  | s Inventor   | y Matrix                  | Report   |   |   |             |
|---|---|----------|---|--|--|---------------------------|--|---|---|-------------|
| CERS Business/Org. Malburg Generating Station Facility Name Malburg Generating Station 4963 S Soto St, Vernon 90058 |   |          |   | Chemical Location Natural Gas CTG1 Metering / Control Skid |  |                           |  | CERS ID 10451263  Facility ID VERN  Status Submitted on 7/30/2018 1 |   |             |
| OOT Code/Fire Haz. Class  | Common Name   | Unit     | Max. Daily  | Quantities Largest Cont.                                   | Avg. Daily   | Annual<br>Waste<br>Amount | Federal Hazard<br>Categories   | Component Name  | Hazardous Component<br>(For mixture only)<br>% Wt | EHS CAS No. |
| Flammable Gas, Explosive, To  | Natural Gas  Oxic CAS No 8006-14-2 Map: SA-3A Grid: 6 B Item 26 | Gas A    | 9000<br>torage Container<br>Aboveground Tank<br>Days on Site: 365 | 9000   | 9000<br>Pressue<br>> Ambient<br>Temperature<br>Ambient | Waste Cod                 | - Physical Flammable - Physical Gas Under Pressure - Physical Explosive - Health Simple Asphyxiant |   |   |             |

Printed on 11/7/2018 10:00 AM Page 24 of 31

|   |  | Hazardou | s Materials /  | And Waste                | s Inventor                                     | y Matrix                  | Report                       |                |   |             |  |
|---|--|----------|--|--------------------------|--|---------------------------|------------------------------|----------------|---|-------------|--|
| CERS Business/Org. Malburg Generating Station Facility Name Malburg Generating Station 4963 S Soto St, Vernon 90058 |  |          |  |                          | Chemical Location  Natural Gas Electric Heater |                           |                              |                | CERS ID 10451263 Facility ID VERN Status Submitted on 7/30/2018 |             |  |
| DOT Code/Fire Haz. Class  | Common Name  | Unit     | Max. Daily   | Quantities Largest Cont. | Avg. Daily                                     | Annual<br>Waste<br>Amount | Federal Hazard<br>Categories | Component Name | Hazardous Component<br>(For mixture only)<br>% Wt               | EHS CAS No. |  |
| Flammable Gas, Explosive  | Natural Gas  CAS No 8006-14-2 Map: SA-3B Grid: 4 C Item 24 | Gas Al   | 1600<br>orage Container<br>boveground Tank<br>ays on Site: 365 | 1600                     | 1600 Pressue > Ambient Temperature Ambient     | Waste Cod                 | - Physical                   |                |   |             |  |

Printed on 11/7/2018 10:00 AM Page 25 of 31

|   |   |  | Hazardo                      | us Materials A                        | And Waste        | s Inventor                    | y Matrix        | Report                 |  |  |   |  |  |
|---|---|--|------------------------------|---------------------------------------|------------------|-------------------------------|-----------------|------------------------|--|--|---|--|--|
| CERS Business/Org.                                |   | Generating Station<br>Generating Station |                              |                                       | Chemical Loca    | CERS ID 10451263              |                 |                        |  |  |   |  |  |
| racility Name                                     | _ | St, Vernon 90058                         |                              | Natural Gas Liquid Drain Tank         |                  |                               |                 |                        |  | Facility ID VERN Status Submitted on 7/30/2018 1:33 PM |   |  |  |
|   |   |  |                              | Quantities                            |                  |                               | Annual<br>Waste | e Federal Hazard       | Hazardous Components<br>(For mixture only) |  |   |  |  |
| DOT Code/Fire Haz. Class                          |   | Common Name  Lubricating Oil             | Unit Max. Daily  Gallons 100 | Largest Cont.                         | Avg. Daily<br>50 | Amount<br>200                 | - Physical      | Component Name         | % Wt                                       | EHS CAS No.  |   |  |  |
| Flammable Gas, Combustible<br>Liquid, Class III-A |   | 64742-54-7                               | Liquid                       | Storage Container<br>Aboveground Tank |                  | Pressue > Ambient Temperature |                 | <sub>a</sub> Flammable |  |  |   |  |  |
|   |   | Map: SA-3A Grid: 4 C Item 25             | Type<br>Pure                 | Days on Site: 365                     |                  | Ambient                       |                 |                        |  |  | 1 |  |  |

Printed on 11/7/2018 10:00 AM Page 26 of 31

|   | Hazardous Materials And Wastes Inventory Matrix Report     |        |  |                          |  |                           |  |                |   |             |  |  |  |
|---|--|--------|--|--------------------------|--|---------------------------|--|----------------|---|-------------|--|--|--|
| CERS Business/Org. Malburg Generating Station Facility Name Malburg Generating Station 4963 S Soto St, Vernon 90058 |  |        |  |                          | Chemical Location  Natural Gas Regulation / Metering Pad |                           |  |                | CERS ID 10451263 Facility ID VERN Status Submitted on 7/30/2018 1:3 |             |  |  |  |
| DOT Code/Fire Haz. Class  | Common Name  | Unit   | Max. Daily   | Quantities Largest Cont. | Avg. Daily   | Annual<br>Waste<br>Amount | Federal Hazard<br>Categories   | Component Name | Hazardous Component<br>(For mixture only)<br>% Wt                   | EHS CAS No. |  |  |  |
| Flammable Gas, Explosive  | Natural Gas  CAS No 8006-14-2 Map: SA-3A Grid: 4 C Item 21 | Gas Al | 3000<br>torage Container<br>boveground Tank<br>rays on Site: 365 | 3000                     | 3000 Pressue > Ambient Temperature Ambient               | Waste Cod                 | - Physical - Flammable - Physical Gas Under Pressure - Physical Explosive - Health Simple Asphyxiant |                |   |             |  |  |  |

Printed on 11/7/2018 10:00 AM Page 27 of 31

|  | Hazardous Materials And Wastes Inventory Matrix Report |  |                    |                                 |  |                                 |           |                                    |  |                  |                |  |  |
|--|--|--|--------------------|---------------------------------|--|---------------------------------|-----------|------------------------------------|--|------------------|----------------|--|--|
| CERS Business/Org.                       | Malburg (  | Generating Station                                   |                    |                                 | Chemical Location                      |                                 |           |                                    | CERS ID                                      | 10451263         |                |  |  |
| Facility Name Malburg Generating Station |  |  |                    | Starting Motor Transformer CTG1 |  |                                 |           | Facility ID                        | VERN   |                  |                |  |  |
|  | 4963 S Soto  | St, Vernon 90058                                     |                    |                                 |  |                                 |           |                                    | Status                                       | Submitted on 7/3 | 0/2018 1:33 PM |  |  |
|  |  |  |                    |                                 | Annual Quantities Waste Federal Hazard |                                 |           | Federal Hazard                     | Hazardous Components<br>(For mixture only)   |                  |                |  |  |
| DOT Code/Fire Haz. Cl                    | lass   | Common Name  | Unit               | Max. Daily                      | Largest Cont.                          | Avg. Daily                      | Amount    | Categories                         | Component Name                               | % Wt             | EHS CAS No.    |  |  |
|  |  | Transformer Oil                                      | Gallons<br>State S | 490<br>Storage Container        | 490                                    | 490<br>Pressue                  |           | - Physical<br>Flammable            | Severely Hydrotreated<br>Napthalic Hydro Oil | d Light 100 %    | 64742-53-6     |  |  |
| Combustible Liquid                       | , Class III-B  | CAS No<br>64742-53-6<br>Map: SA-3A Grid: 7 B Item 40 | Liquid C           | Other  Days on Site: 365        |  | > Ambient Temperature > Ambient | Waste Cod | e - Physical Gas<br>Under Pressure | 2,6 di-tert-butyl                            | 0 %              | 128-37-0       |  |  |

Printed on 11/7/2018 10:00 AM Page 28 of 31

|  |             |  | Hazardou            | s Materials <i>l</i>    | And Waste   | s Inventory                     | y Matrix        | Report                                      |  |             |             |  |
|--|-------------|--|---------------------|-------------------------|---|---------------------------------|-----------------|---|--|-------------|-------------|--|
| ERS Business/Org. Malburg Generating Station acility Name Malburg Generating Station |             |  |                     |                         | Chemical Location Starting Motor Transformer CTG2 |                                 |                 |   | CERS ID 10451263 Facility ID VERN              |             |             |  |
|  | _           | St, Vernon 90058                                     |                     | Starting it             | notor mans  | ioriner c                       | 102             | Status <b>Submitted</b> on 7/30/2018 1:33 P |  |             |             |  |
|  |             |  | Quantiti            |                         |   |                                 | Annual<br>Waste | Federal Hazard                              | Hazardous Components (For mixture only)        |             |             |  |
| DOT Code/Fire Haz. Cla   | ass         | Common Name  | Unit                | Max. Daily              | Largest Cont.                                     | Avg. Daily                      | Amount          | Categories                                  | Component Name                                 | % Wt        | EHS CAS No. |  |
|  |             | Transformer Oil                                      | Gallons<br>State St | 490<br>torage Container | 490   | 490<br>Pressue                  |                 | - Physical<br>Flammable                     | Severely Hydrotreated L<br>Napthalic Hydro Oil | _ight 100 % | 64742-53-6  |  |
| Combustible Liquid,  | Class III-B | CAS No<br>64742-53-6<br>Map: SA-3A Grid: 7 C Item 41 | Liquid O<br>Type    | Other Oays on Site: 365 |   | > Ambient Temperature > Ambient | Waste Cod       | le - Physical Gas<br>Under Pressure         | 2,6 di-tert-butyl                              | 0 %         | 128-37-0    |  |


Printed on 11/7/2018 10:00 AM Page 29 of 31


|                      |       |  | Hazardoı        | us Materials <i>i</i>                 | And Waste     | s Inventor                    | y Matrix        | Report         |                       |   |                |
|----------------------|-------|--|-----------------|---------------------------------------|---------------|-------------------------------|-----------------|----------------|-----------------------|---|----------------|
| CERS Business/Org.   | _     | Generating Station                     |                 |                                       | Chemical Loca |                               | D               | Lilia - CTC    | CERS ID               |   |                |
| Facility Name        | _     | Generating Station<br>St, Vernon 90058 |                 |                                       | Steam Iu      | rbine Gene                    | rator Bui       | iding - STG    | Facility II<br>Status | VERN<br>Submitted on 7/3                  | 0/2018 1:33 PM |
|                      |       |  |                 |                                       | Quantities    |                               | Annual<br>Waste | Federal Hazard |                       | Hazardous Component<br>(For mixture only) | rs .           |
| DOT Code/Fire Haz. ( | Class | Common Name  Lubricating Oil           | Unit<br>Gallons | Max. Daily 4480                       | Largest Cont. | Avg. Daily<br>4480            | Amount          | Categories     | Component Name        | % Wt                                      | EHS CAS No.    |
|                      |       | CAS No 64742-54-7                      |                 | Storage Container<br>Aboveground Tank | <br><b>C</b>  | Pressue > Ambient Temperature | Waste Coo       | le             |                       |   |                |
|                      |       | Map: SA-3A Grid: 2 B/C Item 35         |                 | Days on Site: 365                     |               | > Ambient                     |                 |                |                       |   | 1              |


Printed on 11/7/2018 10:00 AM Page 30 of 31


| acility Name Malburg   | Generating Station Generating Station                              |                                | s Materials   | Chemical Loca                |   |              |  | Facility ID <b>V</b>   |  |   |
|--|--|--------------------------------|---|------------------------------|---|--------------|--|--|--|---|
| 4963 S Soto DOT Code/Fire Haz. Class DOT: 8 - Corrosives (Liquids and solids) Corrosive, Toxic, Oxidizing, Clase | CAS No.  | Liquid P<br>Type               | Max. Daily 100 torage Container lastic/Non-metal                | Quantities Largest Cont. 100 | Avg. Daily 1 Pressue Ambient Temperature Ambient    |              | Federal Hazard Categories - Physical Oxidizer - Health Skin Corrosion Irritation - Health Serious            | Haza<br>(I<br>Component Name   | ubmitted on 7/3<br>ardous Component<br>For mixture only)<br>% Wt | •   |
| DOT: 8 - Corrosives (Liquids and<br>Solids)<br>Corrosive, Toxic  | Ferric Chloride  CAS No  Map: SA-3B Grid: 5 C Item 11              | Liquid P<br>Type               | 60<br>torage Container<br>lastic/Non-metal<br>rays on Site: 365 | <b>30</b><br>Lic Drum        | 50<br>Pressue<br>Ambient<br>Temperature<br>Ambient  | " Waste Codo | - Health Acute<br>Toxicity<br>- Health Skin<br>Corrosion<br>Irritation<br>- Health Serious<br>Eye Damage Eye | Ferric Chloride<br>Hydrochloric Acid   | 45 %<br>1 %  | 7705-08-0<br>7647-01-0  |
| oxic, Corrosive  | Anti-Scalant CAS No Map: SA-3B Grid: 5 C Item 56                   | Liquid O<br>Type               | 75<br>torage Container<br>Other                                 | <b>75</b>                    | 50<br>Pressue<br>Temperature                        | Waste Code   | Irritation   | Phosphonic Acid Salt<br>Alkali Hydroxide<br>Aminotrialkylphosphonic<br>Phosphonic Acid<br>Inorganic Acid | 12 %<br>9 %<br>Acid 16 %<br>1 %<br>0 %                           | Proprietary<br>Proprietary<br>Proprietary<br>Proprietary<br>Proprietary |
| oxic, Corrosive, Water Reactiv<br>Class 1  | Caustic Soda  e, CAS No  | Gallons State St Liquid O Type | 400<br>torage Container<br>other<br>ways on Site: 365           | 400                          | 300<br>Pressue<br>Ambient<br>Temperature<br>Ambient | Waste Code   | - Physical Corrosive To Metal - Health Skin Corrosion Irritation - Health Serious Eye Damage Eye Irritation  |  |  |   |
| orrosive, Toxic  | Chlorine Scavenger  CAS No 7631-90-5  Map: SA-3B Grid: 5 C Item 12 | Liquid O<br>Type               | torage Container other  | 100                          | 75 Pressue Ambient Temperature Ambient              | Waste Code   | - Health Skin  |  |  |   |


Printed on 11/7/2018 10:00 AM Page 31 of 31














## CALIFORNIA ENVIRONMENTAL REPORTING SYSTEM (CERS)

## CONSOLIDATED EMERGENCY RESPONSE / CONTINGENCY PLAN Prior to completing this Plan, please refer to the INSTRUCTIONS FOR COMPLETING A CONSOLIDATED CONTINGENCY PLAN

| A.   | FAC                                     | ILIT                   | Y              | IDE           | ENT                          | IFIC                    | AT                | ION                   | ANI                        | OP              | ERAT                                     | OI             | NS OV      | ERVI                                    | EW                     |                         |                       |                   |
|--|---|------------------------|----------------|---------------|------------------------------|-------------------------|-------------------|-----------------------|----------------------------|-----------------|--|----------------|------------|---|------------------------|-------------------------|-----------------------|-------------------|
| FACILITY ID#   | and control                             | N.S                    |                |               |                              |                         | 1.                | CERS                  |                            |                 | A1.                                      |                |            | LAN PRI                                 | PARAT                  | ION/REV                 | ISION                 | A2                |
| BUSINESS NAME (Same as I   | Facility A                              | lama or                | DP 4           | Do            | ing Du                       | nimann.                 | 40)               | 104                   | 5126                       | 3               |  | 1              | /17/20     | 13                                      |                        |                         |                       | 3.                |
| Malburg Generatin  |   |                        | DDA            | - D0          | ıng Du                       | siness.                 | as)               |                       |                            |                 |  |                |            |   |                        |                         |                       | ***               |
| BUSINESS SITE ADDRESS  | .5                                      |                        |                |               |                              |                         |                   |                       |                            |                 |  |                |            |   |                        |                         |                       | 103.              |
| 4963 S Soto St   |   |                        |                |               |                              |                         |                   |                       |                            |                 |  |                |            |   |                        |                         |                       |                   |
| BUSINESS SITE CITY   |   |                        |                |               |                              |                         |                   |                       |                            |                 | 104.                                     |                |            | ZIP COI                                 | DE                     |                         |                       | 105               |
| Vernon   |   |                        |                |               |                              |                         |                   |                       |                            |                 |  | С              | A          | 90058                                   | 3                      |                         |                       |                   |
| TYPE OF BUSINESS (e.g., Pa   | -                                       | ntractor               | r)             |               |                              |                         |                   | A3.                   | INCI                       | DENTA           | AL OPER                                  | ATIO           | NS (e.g.,  | Fleet Maii                              | ntenance)              | ı                       |                       | A4.               |
| Electric Power Gener   |   |                        |                |               |                              |                         |                   |                       |                            |                 |  |                |            |   |                        |                         |                       |                   |
| THIS PLAN COVERS CHEM  |   |                        |                |               |                              | _                       |                   | ES INV                | OLVIN                      | G: (Ch          | eck all tha                              | at appl        | y)         |   |                        |                         |                       | A5.               |
| ☑ I. HAZARDOUS MATER   | UALS; L                                 | ₫ 2. H <i>A</i>        | AZAI           | RDO           | US WA                        | ASTES                   | A Sallie          | - All Control         |                            | en-o Fot        | 01802                                    |                | tioner see |   | 200,000,000,000        | V = 25140               | : 10 20 IV            |                   |
|  |   |                        |                |               |                              |                         |                   | RNAI                  |                            |                 | NSE                                      |                |            |   |                        |                         |                       |                   |
| INTERNAL FACILITY EMER  I. CALLING PUBLIC EMI  2. CALLING HAZARDOU  3. ACTIVATING IN-HOUS  | ERGENC<br>IS WAST                       | Y RESI<br>E CON        | PONI<br>TRA    | DER!          | S (i.e.,<br>R                | 9-1-1)                  | /IA: (            | Check a               | ll that a                  | pply)           |  |                |            |   |                        |                         |                       | B1                |
| C. EMERC   | SENC                                    | Y CC                   | M              | MU            | INIC                         | CAT                     | ION               | IS, P                 | HON                        | EN              | UMBE                                     | ERS            | AND        | NOTI                                    | FICA                   | TION                    | S                     |                   |
| Whenever there is an immine<br>Emergency Coordinator is on conficulties. I. Activate internal facility alar<br>2. Notify appropriate local auth<br>3. Notify the California Emerge                   | all) shall:<br>ms or co<br>iorities (i. | mmunic<br>e., call 9   | ation<br>9-1-1 | ıs sysi<br>). | tems, v                      | where a                 | pplica            | able, to              |                            |                 | ,  |                | ergency (  | Coordinato                              | r (or his              | /her desig              | gnee wh               | en the            |
| Before facility operations are substances Control (DTSC), the with requirements to:  I. Provide for proper storage at the facility; and  2. Ensure that no material that cleanup procedures are comp | ne local Und dispose is inconstituted.  | Inified F<br>al of rec | over<br>with   | am A          | gency<br>aste, co<br>release | (UPA)<br>ontamined mate | ), and<br>nated s | the loca<br>soil or s | al fire durface verred, so | epartmovater, o | ent's haza<br>or any othe<br>or disposed | er mate        | material   | s program<br>results fro<br>f the facil | that the :<br>m an exp | facility is losion, fir | in comp<br>e, or rele | liance<br>ease at |
| INTERNAL FACILITY EMER   | RGENCY                                  | COMM                   | IUNI           | CAT           | IONS                         | OR AI                   | ARM               | 1 NOTII               | FICATI                     | ON WI           | LL OCCU                                  | J <b>R V</b> I | A: (Chec   | k all that a                            | pply)                  |                         |                       | Cl                |
| ☐ I. VERBAL WARNINGS,  |   | 100                    |                |               |                              |                         | OR I              | NTERC                 | OM SY                      | STEM            | ;  |                | 3. TELEI   | -                                       |                        |                         |                       |                   |
| 4. PAGERS;   |   |                        |                |               | A SYS                        |                         |                   |                       |                            |                 |  |                |            | ABLE RA                                 |                        |                         |                       | C2                |
| NOTIFICATIONS TO NEIGH   | BORING                                  |                        |                |               |                              |                         |                   | ECTED<br>NTERC        |                            |                 |  |                |            | OCCUR B<br>PHONE;                       | Y: (Chec               | k all that a            | apply)                | C2;               |
| <ul><li>I. VERBAL WARNINGS;</li><li>☐ 4. PAGERS;</li></ul>   |   |                        |                |               | A SYS                        |                         | UK I              | NIEKC                 | .OIVI 3 I                  | SIEW            | ,  |                |            | ABLE RA                                 | סומ                    |                         |                       |                   |
| EMERGENCY RESPONSE   | AMBII                                   |                        |                |               |                              | <u></u>                 | CHP               | 5555 1000 0000        | without tempor             | meda esper      |  |                |            |   | 9-1-                   | 1                       |                       |                   |
| PHONE NUMBERS:   |   |                        | •              | -             |                              |                         |                   |                       |                            |                 |  |                |            |   | •                      | •                       | 550                   |                   |
|  |   |                        |                |               |                              |                         |                   |                       |                            |                 |  |                |            |   |                        | 424-88                  |                       |                   |
|  |   |                        |                |               |                              |                         |                   |                       |                            |                 | 1 1/2/1/2/2/2/2                          |                |            |   |                        | 222-12                  |                       |                   |
|  |   |                        |                |               |                              |                         |                   |                       |                            |                 | . 255                                    |                |            |   | 1                      | 583-88                  |                       | C3,               |
|  |   | R (Speci               | 1              |               |                              |                         |                   |                       |                            |                 |  |                |            | C4                                      |                        |                         |                       | C5.               |
| NEAREST MEDICAL FACILI   |   |                        |                | ME:           | Stac                         | ey M                    | edic              | al Ce                 | nter                       |                 |  |                |            | C6.                                     | (323)                  | 584-07                  | 779                   | C7,               |
| AGENCY NOTIFICATION PH   |   |                        |                |               |                              |                         |                   |                       |                            | UBSTA           | ANCES C                                  | ONTE           | ROL (DT    | SC)                                     | (916)                  | 255-35                  | 545                   |                   |
|  |   |                        | -              |               |                              |                         |                   |                       |                            |                 | OL BOAR                                  |                |            |   |                        |                         |                       | C8.               |
|  |   |                        |                |               |                              |                         |                   | -                     |                            |                 |  |                |            |   | (800)                  | 300-21                  | 193                   |                   |
|  |   |                        |                |               |                              |                         |                   |                       |                            |                 | IE (DFG)                                 | •              | •          |   | , ,                    | 358-29                  |                       |                   |
|  |   |                        |                |               |                              |                         |                   |                       |                            |                 | , ,                                      |                |            | enera i interior.                       | • •                    | 267-21                  |                       |                   |
|  |   |                        |                |               |                              |                         |                   |                       |                            |                 |  |                |            |   | , ,                    | 263-28                  |                       |                   |
|  |   |                        |                |               |                              |                         |                   |                       |                            |                 |  |                |            |   | 100                    | 445-82                  |                       |                   |
|  |   |                        |                |               |                              |                         |                   | IIAL .                | 44 . 4                     |                 |  |                |            | C9.                                     | (310)                  | TT-0-02                 | .00                   | C10.              |
|  |   |                        |                |               |                              | (Special                |                   |                       |                            |                 |  |                |            | CII                                     |                        |                         |                       | C12.              |
|  |   |                        |                | U.            | пЕК                          | (Speci                  | (y).              |                       | _                          |                 |  |                |            |   | L                      |                         |                       |                   |

| D. EMERGENCY CONTAINMENT AND CLEANUP PROCEDURES   |
|---|
| SPILL PREVENTION, CONTAINMENT, AND CLEANUP PROCEDURES: (Check all boxes that apply to indicate your procedures for containing spills, releases, fires or explosions; and preventing and mitigating associated harm to persons, property, and the environment.)  |
| DI.  I. MONITOR FOR LEAKS, RUPTURES, PRESSURE BUILD-UP, ETC.;  2. PROVIDE STRUCTURAL PHYSICAL BARRIERS (e.g., Portable spill containment walls);  3. PROVIDE ABSORBENT PHYSICAL BARRIERS (e.g., Pads, pigs, pillows);  4. COVER OR BLOCK FLOOR AND/ OR STORM DRAINS;  5. BUILT-IN BERM IN WORK / STORAGE AREA;  6. AUTOMATIC FIRE SUPPRESSION SYSTEM;  7. ELIMINATE SOURCES OF IGNITION FOR FLAMMABLE HAZARDS (e.g. Flammable liquids, Propane);  8. STOP PROCESSES AND/OR OPERATIONS;  9. AUTOMATIC / ELECTRONIC EQUIPMENT SHUT-OFF SYSTEM;  10. SHUT-OFF WATER, GAS, ELECTRICAL UTILITIES AS APPROPRIATE;  11. CALL 9-1-1 FOR PUBLIC EMERGENCY RESPONDER ASSISTANCE / MEDICAL AID;  12. NOTIFY AND EVACUATE PERSONS IN ALL THREATENED AREAS;  13. ACCOUNT FOR EVACUATED PERSONS IMMEDIATELY AFTER EVACUATION CALL;  14. PROVIDE PROTECTIVE EQUIPMENT FOR ON-SITE RESPONSE TEAM;  15. REMOVE OR ISOLATE CONTAINERS / AREA AS APPROPRIATE;  16. HIRE LICENSED HAZARDOUS WASTE CONTRACTOR;  17. USE ABSORBENT MATERIAL FOR SPILLS WITH SUBSEQUENT PROPER LABELING, STORAGE, AND HAZARDOUS WASTE DISPOSAL AS APPROPRIATE;  18. SUCTION USING SHOP VACUUM WITH SUBSEQUENT PROPER LABELING, STORAGE, AND HAZARDOUS WASTE DISPOSAL AS APPROPRIATE; |
| ☐ 19. WASH / DECONTAMINATE EQUIPMENT W/ CONTAINMENT and DISPOSAL OF EFFLUENT / RINSATE AS HAZARDOUS WASTE;  ☑ 20. PROVIDE SAFE TEMPORARY STORAGE OF EMERGENCY-GENERATED WASTES;  ☐ 21. OTHER (Specify):  D2.  |
| E. FACILITY EVACUATION  |
| THE FOLLOWING ALARM SIGNAL(S) WILL BE USED TO BEGIN EVACUATION OF THE FACILITY (CHECK ALL THAT APPLY):  |
| ☐ I. BELLS;  ☐ 2. HORNS/SIRENS;  ☐ 3. VERBAL (I.E., SHOUTING);  ☐ 4. OTHER (Specify): Strobes   |
| THE FOLLOWING LOCATION(S) IS/ARE EVACUEE EMERGENCY ASSEMBLY AREA(S) (i.e., Front parking lot, specific street corner, etc.)   |
| Southwest corner of 50th and Seville. In the case of an ammonia tank rupture and wind blowing to the southwest, the assembly location moves to the Northwest corner of Seville and Leonis.  |
| Note: The Emergency Coordinator must account for all on site employees and/or site visitors after evacuation.  EVACUATION ROUTE MAP(S) POSTED AS REQUIRED  E4.  |
| Note: The map(s) must show primary and alternate evacuation routes, emergency exits, and primary and alternate staging areas, and must be prominently posted throughout the facility in locations where it will be visible to employees and visitors.   |
| F. ARRANGEMENTS FOR EMERGENCY SERVICES  |
| Explanation of Requirement: Advance arrangements with local fire and police departments, hospitals, and/or emergency services contractors should be made as appropriate for your facility. You may determine that such arrangements are not necessary.  |
| ADVANCE ARRANGEMENTS FOR LOCAL EMERGENCY SERVICES (Check one of the following)  |
| <ul> <li>I. HAVE BEEN DETERMINED NOT NECESSARY; or</li> <li>□ 2. THE FOLLOWING ARRANGEMENTS HAVE BEEN MADE (Specify):</li> </ul>  |
|   |

## G. EMERGENCY EQUIPMENT

| Check all boxes that apply to list emergency response equipment available at     | the facility and identify the location(s) where the equipment is kept and the |
|--|---|
| equipment's capability, if applicable, [e.g., \infty] CHEMICAL PROTECTIVE GLOVES | Spill response kit   One time use. Oil & solvent resistant only.)             |

| equipment'         | s capability, if applicable. [e.g., 🛛 CHEMICAL PROTECTIVE | GLOVES   Spill response kit   One time use,                                | Oil & solvent resistant only.] |
|--------------------|---|--|--------------------------------|
| TYPE               | EQUIPMENT AVAILABLE G1.                                   | LOCATION   | CAPABILITY (If applicable)     |
| Safety             | CHEMICAL PROTECTIVE SUITS, APRONS,     OR VESTS           | Warehouse, Bulk Chemical   | G3                             |
| and<br>First Aid   | 2. CHEMICAL PROTECTIVE GLOVES                             | G4.<br>Warehouse Safety Lcoker   | G5.                            |
|                    | 3. CHEMICAL PROTECTIVE BOOTS                              | G6.  | G7                             |
|                    | 4. X SAFETY GLASSES / GOGGLES / SHIELDS                   | G8,<br>Warehouse Safety Locker, Lead Operators Office                      | G9.                            |
|                    | 5. 🗷 HARD HATS  | G10.<br>Warehouse  | G11                            |
|                    | 6. CARTRIDGE RESPIRATORS                                  | G12  | G13.                           |
|                    | 7. SELF-CONTAINED BREATHING APPARATUS (SCBA)              | G14.   | G15.                           |
|                    | 8. FIRST AID KITS / STATIONS                              | G16 Control Room, Wall behind Control Room, Machine Shop and Center Office | G17.                           |
|                    | 9. PLUMBED EYEWASH FOUNTAIN / SHOWER                      | G18 Bulk Chemical, NH3 Skid, CEMS and Water Treatment Areas                | G19.                           |
|                    | 10. ■ PORTABLE EYEWASH KITS                               | Aux PDCM, Lab  | G21.                           |
|                    | II. ☐ OTHER   | G22.   | G23                            |
|                    | 12. OTHER   | G24  | G25                            |
| Fire               | 13.  PORTABLE FIRE EXTINGUISHERS                          | G26  | G27.                           |
| Fighting           | 14.   ■ FIXED FIRE SYSTEMS / SPRINKLERS / FIRE HOSES      | G28  | G29                            |
|                    | 15. X FIRE ALARM BOXES OR STATIONS                        | G30.   | G31                            |
|                    | 16. ☐ OTHER   | G32,   | G33,                           |
| Spill              | 17. ☑ ALL-IN-ONE SPILL KIT                                | G34 Outside Both CTG's and STG, Main Accumulation Area                     | G35,                           |
| Control<br>and     | 18. 🗵 ABSORBENT MATERIAL                                  | G36,<br>Spill Kits, Tool Crib, Warehouse Safety Cabinet                    | G37.                           |
| Clean-Up           | 19. CONTAINER FOR USED ABSORBENT                          | G38. Main Accumulation Area, Satellite Accumulation Area                   | G39                            |
|                    | 20. ☐ BERMING / DIKING EQUIPMENT                          | G40,   | G41                            |
|                    | 21. ☐ BROOM   | G42.   | G43                            |
|                    | 22. SHOVEL  | G44.   | G45.                           |
|                    | 23. SHOP VAC  | G46.   | G47.                           |
|                    | 24. ☐ EXHAUST HOOD  | G48.   | G49.                           |
|                    | 25. EMERGENCY SUMP / HOLDING TANK                         | G50  | G51.                           |
|                    | 26. ☐ CHEMICAL NEUTRALIZERS                               | G52.   | G53                            |
|                    | 27. GAS CYLINDER LEAK REPAIR KIT                          | G54,   | G55.                           |
|                    | 28. SPILL OVERPACK DRUMS                                  | G56.   | G57                            |
|                    | 29. OTHER   | G58.   | G59.                           |
| Communi-<br>ations | 30. X TELEPHONES (Includes cellular)                      | G60,   | G61                            |
| nd<br>Marm         | 31. ☑ INTERCOM / PA SYSTEM                                | G62.   | G63                            |
| ystems             | 32. PORTABLE RADIOS                                       | G64.   | G65.                           |
|                    | 33. AUTOMATIC ALARM CHEMICAL MONITORING EQUIPMENT         | G66.   | G67                            |
| Other              | 34. OTHER   | G68,   | G69                            |
|                    | 35. ☐ OTHER   | G70  | G71.                           |

| H. EARTHQUAKE   | VULNERABILITY  |
|---|--|
| Identify areas of the facility that are vulnerable to hazardous materials releases / spii inspection.   | lls due to earthquake-related motion. These areas require immediate isolation and  |
| VULNERABLE AREAS: (Check all that apply)   ■ 1. HAZARDOUS MATERIALS / WASTE STORAGE AREA  | HI LOCATIONS (e.g., shop, outdoor shed, forensic lab)  Main Accumulation Area near ammonia tank.  H2   |
| 2. PROCESS LINES / PIPING   | Н3.  |
| 3. LABORATORY   | H4   |
| 4. WASTE TREATMENT AREA   | Н5   |
| Identify mechanical systems vulnerable to releases / spills due to earthquake-related m  VULNERABLE SYSTEMS: (Check all that apply)   | notion. These systems require immediate isolation and inspection.  H6 LOCATIONS  |
| ■ 1. SHELVES, CABINETS AND RACKS  | Warehouse H7.  |
| 2. TANKS (EMERGENCY SHUTOFF)  | H8   |
| ■ 3. PORTABLE GAS CYLINDERS   | CEMS Building H9.  |
| ■ 4. EMERGENCY SHUTOFF AND/OR UTILITY VALVES  5. SPRINKLER SYSTEMS  | HIO.   |
| 6. STATIONARY PRESSURIZED CONTAINERS (e.g., Propane dispensing tan  |  |
| I. EMPLOYER   |  |
| Explanation of Requirement: Employee training is required for all employees handli  |  |
| <ul> <li>Hazard communication related to health and safety;</li> <li>Methods for safe handling of hazardous substances;</li> <li>Fire hazards of materials / processes;</li> <li>Conditions likely to worsen emergencies;</li> <li>Coordination of emergency response;</li> <li>Notification procedures;</li> </ul>   | <ul> <li>Communication and alarm systems;</li> <li>Personal protective equipment;</li> <li>Use of emergency response equipment (e.g. Fire extinguishers, respirators, etc.);</li> <li>Decontamination procedures;</li> <li>Evacuation procedures;</li> <li>Control and containment procedures;</li> <li>UST monitoring system equipment and procedures (if applicable).</li> </ul> |
| ☑ 1. FORMAL CLASSROOM; ☑ 2. VIDEOS; ☑ 3. SAFETY / TAI   |  |
| 4. STUDY GUIDES / MANUALS (Specify): Procedures, Powerpoint Presentations   | 12.  |
| ☐ 5. OTHER (Specify): ☐ 6. NOT APPLICABLE BECAUSE FACILITY HAS NO EMPLOYEES   | 13.  |
| Large Quantity Generator (LQG) Training Records: Large quantity hazardous variations waste per month) must retain written documentation of employee hazardous.  A written outline/agenda of the type and amount of both introductory and con responsibility for the management of hazardous waste (e.g., labeling, manifesting, c).  The name, job title, and date of training for each hazardous waste management train.  A written job description for each of the above job positions that describes job duti to the position.  Current employee training records must be retained until closure of the facility.  Former employee training records must be retained at least three years after termina. | waste management training sessions which includes: tinuing training that will be given to persons filling each job position having ompliance with accumulation time limits, etc.). ing session given to an employee filling such a job position; and es and the skills, education, or other qualifications required of personnel assigned  |
| J. LIST OF ATT  | CACHMENTS  |
| (Check one of the following)  | JI.  |
| ■ 1. NO ATTACHMENTS ARE REQUIRED; or  | 12.  |
| 2. THE FOLLOWING DOCUMENTS ARE ATTACHED:  | J.E.   |
|   |  |
| K. SIGNATURE / C  | ERTIFICATION   |
| Certification: Based on my inquiry of those individuals responsible for obtaining the am familiar with the information submitted and believe the information is true, accurate  |  |
| SIGNATURE OF OWNER/OPERATOR   | DATE SIGNED K1.  |
| Want Junes  | 30 July 2013   |
| NAME OF SIGNER (print) K2   | TITLE OF SIGNER K3   |
| DANIEL DUNLAP   | SEMIOR DIRECTUR REGULATORY AFFAIRS   |

# CALIFORNIA ENVIRONMENTAL REPORTING SYSTEM (CERS) CONSOLIDATED EMERGENCY RESPONSE / CONTINGENCY PLAN Prior to completing this Plan, please refer to the INSTRUCTIONS FOR COMPLETING A CONSOLIDATED CONTINGENCY PLAN

| C12.  | CIL  | OTHER (Specify):   |
|---|--|--|
| C10.  | 79   | OTHER (Specify):   |
| (916) 445-8200  |  | STATE FIRE MARSHAL   |
| (916) 263-2800  |  | CAL/OSHA   |
| (202) 267-2180  |  | U.S. COAST GUARD   |
| (916) 358-2900  | CALIFORNIA DEPT OF FISH AND GAME (DFG)                                   | CALIFORNIA DEPT OF   |
| (800) 300-2193  | U.S. ENVIRONMENTAL PROTECTION AGENCY (US EPA)                            | U.S. ENVIRONMENTAI   |
| C8.   | REGIONAL WATER QUALITY CONTROL BOARD                                     | REGIONAL WATER QU  |
| (916) 255-3545  | CALIFORNIA DEPT. OF TOXIC SUBSTANCES CONTROL (DTSC)                      | AGENCY NOTIFICATION PHONE NUMBERS: CALIFORNIA DEPT. OF   |
| (323) 584-0779 <sup>C7.</sup>                                     | Center C6.   | NEAREST MEDICAL FACILITY / HOSPITAL NAME: Stacey Medical Center  |
| C5.   | $c_4$  | OTHER (Specify):   |
| (323) 583-8811 <sup>C3</sup>                                      |  | LOCAL UNIFIED PROGRAM AGENCY (UPA/CUPA)  |
| (800) 222-1222  |  | POISON CONTROL CENTER  |
| (800) 424-8802  |  | NATIONAL RESPONSE CENTER (NRC)   |
| (800) 852-7550  | T AGENCY (CAL/EMA)   | CALIFORNIA EMERGENCY MANAGEMENT AGENCY (CAL/EMA)   |
| 9-1-1   |  | EMERGENCY RESPONSE AMBULANCE, FIRE, POLICE AND CHP   |
| DIO   | _  |  |
| Y: (Check all that apply)   | ED BY AN OFF-SITE RELEASE WILL OCCUR BY RECORD SYSTEM;   © 3. TELEPHONE; | ■ 2. PUBLIC ADDRESS OR INTERCOM SYSTEM; ■ 3. TELEPHONE;  |
|   | Ø 6. PORTABLE RADIO  | U4. PAGERS;    X 5. ALARM SYSTEM;  NOTIFICATIONS TO NEIGHBORING EACH THES THAT MAY BE AFFECT.  |
|   | RCOM SYSTEM;   3. TELEPHONE;   | ☐ 1. VERBAL WARNINGS; ■ 2. PUBLIC ADDRESS OR INTERCOM SYSTEM:  |
| mals)   | TIEIO ATION WILL OCCUP VIA: (Check all that a                            | cleanup procedures are completed.  INTERNAL FACILITY EMERGENCY COMMINICATIONS OR ALARM NOTIFICATION WILL OCCUP VIA CONSOLAR SHARE STATES.  |
| tv affected by the incident until                                 | nsferred stored or disposed of in areas of the facili                    | the facility; and  2. Ensure that no material that is incompatible with the released material is transferred, stored, or disposed of in areas of the facility affected by the incident until   |
| n an explosion. fire, or release at                               | or surface water, or any other material that results fron                | 1. Provide for proper storage and disposal of recovered waste, contaminated soil or surface water, or any other material that results from an explosion, fire, or release at   |
| California Department of Toxic that the facility is in compliance | local fire department's hazardous materials program to                   | before admity operations are resulted in areas of the facility affected by the incident, the emergency coordinator shall notify the California Department of Toxic Substances Control (DTSC), the local Unified Program Agency (UPA), and the local fire department's hazardous materials program that the facility is in compliance with requirements to:   |
|   |  | Defen failte management in the fail of the |
|   |  | <ol> <li>Notify appropriate local authorities (i.e., call 9-1-1).</li> <li>Notify the California Emergency Management Agency at (800) 852-7550.</li> </ol>   |
|   | to notify all facility personnel.  |  |
| r (or his/her designee when the                                   | olosion, fire, or release, the Emergency Coordinator                     | Whenever there is an imminent or actual emergency situation such as an explosion, fire, or release, the Emergency Coordinator (or his/her designee Emergency Coordinator is on call) shall:  |
| FICATIONS   | PHONE NUMBERS AND NOTH   | C. EMERGENCY COMMUNICATIONS, PHONE NUMBERS AND NOTIFICATIONS   |
|   |  | ■ 2. CALLING HAZARDOUS WASTE CONTRACTOR  3. ACTIVATING IN-HOUSE EMERGENCY RESPONSE TEAM  |
| B1  | k all that apply)  | INTERNAL FACILITY EMERGENCY RESPONSE WILL OCCUR VIA: (Check all that apply)  3. CALLING PUBLIC EMERGENCY RESPONDERS (i.e., 9-1-1)  |
|   | INTERNAL RESPONSE  | B. INTERNA   |
|   |  | ☑ 1. HAZARDOUS MATERIALS; ☑ 2. HAZARDOUS WASTES  |
| A5.   | NVOLVING: (Check all that apply)   | THIS PLAN COVERS CHEMICAL SPILLS, FIRES, AND EARTHOUAKES INVOLVING: (Check all that apply)   |
| ntenance) A4.   | INCIDENTAL OPERATIONS (e.g., Fleet Maintenance)                          | Electric Power Generation  |
|   | -  |  |
| DE 105.   | 104. ZIP CODE  | BUSINESS SITE CITY   |
| 103   |  | 4963 S Soto St   |
| м   |  | Malburg Generating Station   |
|   | 10451263 7/29/2015   | $\vdash$   |
| DATE OF PLAN PREPARATION/REVISION A2.                             | CERS ID     Al. DATE OF PLAN PR  |  |
| EW  | FACILITY IDENTIFICATION AND OPERATIONS OVERVIEW                          | A. FACILITY IDENTIFICATION   |

|   | 7  |          |   |
|---|--|----------|---|
|   | ı  |          |   |
|   | -  |          |   |
| ı | Ì  | _        |   |
|   | 1  | 1        |   |
|   | 6  |          |   |
|   | į  | 2        | Ę |
|   | 1  | 4        | 2 |
|   | (  |          |   |
|   | F  |          |   |
|   | (  |          |   |
| ŀ | (  |          |   |
| ı | 4  | 4        |   |
| ı | 1.4  | _        |   |
|   |  |          |   |
|   | i  | 4        |   |
| ŀ | Ě  | 5        |   |
|   | ļ  | 3        | 5 |
|   | A I  | _        |   |
| ı | -  | <b>D</b> |   |
|   | F  | 7        | 7 |
|   | į  |          |   |
|   | 1  |          |   |
|   | ì  |          | - |
|   | Ē  |          | 5 |
| ١ | 1  |          | _ |
|   | 4  | 4        |   |
|   | ر<br>ا   | 7        |   |
|   | þ  | •        |   |
|   | į  | ì        |   |
|   | 6  |          | 5 |
|   | (  | ã        | 5 |
|   |  | 7        | 7 |
|   |  |          |   |
|   | THE PERSON OF TH | _        |   |
|   |  | 1        |   |
|   | È  | 1        | ń |

- MONITOR FOR LEAKS, RUPTURES, PRESSURE BUILD-UP, ETC
- PROVIDE STRUCTURAL PHYSICAL BARRIERS (e.g., Portable spill containment walls); PROVIDE ABSORBENT PHYSICAL BARRIERS (e.g., Pads, pigs, pillows); COVER OR BLOCK FLOOR AND/ OR STORM DRAINS:
  - BUILT-IN BERM IN WORK / STORAGE AREA
  - AUTOMATIC FIRE SUPPRESSION SYSTEM;
  - ELIMINATE SOURCES OF IGNITION FOR FLAMMABLE HAZARDS (e.g. Flammable liquids, Propane);
  - STOP PROCESSES AND/OR OPERATIONS
  - AUTOMATIC / ELECTRONIC EQUIPMENT SHUT-OFF SYSTEM

  - 10. SHUT-OFF WATER, GAS, ELECTRICAL UTILITIES AS APPROPRIATE;
    11. CALL 9-1-1 FOR PUBLIC EMERGENCY RESPONDER ASSISTANCE / M
    12. NOTIFY AND EVACUATE PERSONS IN ALL THREATENED AREAS;
    13. ACCOUNT FOR EVACUATED PERSONS IMMEDIATELY AFTER EVAC CALL 9-1-1 FOR PUBLIC EMERGENCY RESPONDER ASSISTANCE / MEDICAL AID
  - ACCOUNT FOR EVACUATED PERSONS IMMEDIATELY AFTER EVACUATION CALL;
  - 14. PROVIDE PROTECTIVE EQUIPMENT FOR ON-SITE RESPONSE TEAM
  - 15 REMOVE OR ISOLATE CONTAINERS / AREA AS APPROPRIATE
  - 16. HIRE LICENSED HAZARDOUS WASTE CONTRACTOR;
- 17 USE ABSORBENT MATERIAL FOR SPILLS WITH SUBSEQUENT PROPER LABELING, STORAGE, AND HAZARDOUS WASTE DISPOSAL AS APPROPRIATE;
- 18. SUCTION USING SHOP VACUUM WITH SUBSEQUENT PROPER LABELING, STORAGE, APPROPRIATE; AND HAZARDOUS WASTE DISPOSAL AS
- 21. OTHER (Specify): 20. PROVIDE SAFE TEMPORARY STORAGE OF EMERGENCY-GENERATED WASTES 19. WASH / DECONTAMINATE EQUIPMENT W/ CONTAINMENT and DISPOSAL OF EFFLUENT / RINSATE AS HAZARDOUS WASTE

D2

Ε

## F **FACILITY EVACUATION**

# THE FOLLOWING ALARM SIGNAL(S) WILL BE USED TO BEGIN EVACUATION OF THE FACILITY (CHECK ALL THAT APPLY)

## **XXX**□ 4 3 2 1

- HORNS/SIRENS; VERBAL (I.E., SHOUTING);

☑ 4. OTHER (Specify): Strobes

THE FOLLOWING LOCATION(S) IS/ARE EVACUEE EMERGENCY ASSEMBLY AREA(S) (i.e., Front parking lot, specific street corner, etc.)

THE FOLLOWING LOCATION(S) IS/ARE EVACUEE EMERGENCY ASSEMBLY AREA(S) (i.e., Front parking lot, specific street corner, etc.)

THE FOLLOWING LOCATION(S) IS/ARE EVACUEE EMERGENCY ASSEMBLY AREA(S) (i.e., Front parking lot, specific street corner, etc.)

THE FOLLOWING LOCATION(S) IS/ARE EVACUEE EMERGENCY ASSEMBLY AREA(S) (i.e., Front parking lot, specific street corner, etc.)

THE FOLLOWING LOCATION(S) IS/ARE EVACUEE EMERGENCY ASSEMBLY AREA(S) (i.e., Front parking lot, specific street corner, etc.)

THE FOLLOWING LOCATION(S) IS/ARE EVACUEE EMERGENCY ASSEMBLY AREA(S) (i.e., Front parking lot, specific street corner, etc.)

THE FOLLOWING LOCATION (S) IS/ARE EVACUEE EMERGENCY ASSEMBLY AREA(S) (i.e., Front parking lot, specific street corner, etc.)

THE FOLLOWING LOCATION (S) IS/ARE EVACUEE EMERGENCY ASSEMBLY AREA(S) (i.e., Front parking lot, specific street corner, etc.)

THE FOLLOWING LOCATION (S) IS/ARE EVACUEE EMERGENCY ASSEMBLY AREA(S) (i.e., Front parking lot, specific street corner, etc.)

THE FOLLOWING LOCATION (S) IS/ARE EVACUEE EMERGENCY ASSEMBLY AREA(S) (i.e., Front parking lot, specific street corner, etc.)

THE FOLLOWING LOCATION (S) IS/AREA (S) (I.e., Front parking lot, specific street corner, etc.)

THE FOLLOWING LOCATION (S) IS/AREA (S) (I.e., Front parking lot, specific street corner, etc.)

THE FOLLOWING LOCATION (S) IS/AREA (S) (I.e., Front parking lot, specific street corner, etc.)

THE FOLLOWING LOCATION (S) IS/AREA (S) (I.e., Front parking lot, specific street corner, etc.)

THE FOLLOWING LOCATION (S) IS/AREA (S) (I.e., Front parking lot, specific street corner, etc.)

THE FOLLOWING LOCATION (S) (I.e., Front parking lot, specific street corner, etc.)

THE FOLLOWING LOCATION (S) (I.e., Front parking lot, specific street corner, etc.)

THE FOLLOWING LOCATION (S) (I.e., Front parking lot, specific street corner, etc.)

THE FOLLOWING LOCATION (

E3

Southwest corner of 50th and Seville. In the case of ammonia tank rupture and wind blowing to the southwest, the assembly location moves to the northwest corner of Seville and Leonis.

Note: The Emergency Coordinator must account for all on site employees and/or site visitors after evacuation X EVACUATION ROUTE MAP(S) POSTED AS REQUIRED

Note: The map(s) must show primary and alternate evacuation routes, emergency exits, and primary and alternate staging areas, throughout the facility in locations where it will be visible to employees and visitors. and must be prominently posted

## ARRANGEMENTS FOR EMERGENCY SERVICES

**Explanation of Requirement:** Advance arrangements with local fire and police departments, hospitals, and/or emergency appropriate for your facility. You may determine that such arrangements are not necessary. services contractors should be made as

ADVANCE ARRANGEMENTS FOR LOCAL EMERGENCY SERVICES (Check one of the following)

- □ X 2 1 HAVE BEEN DETERMINED NOT NECESSARY;
- THE FOLLOWING ARRANGEMENTS HAVE BEEN MADE (Specify)

F2

Ξ

| G71.  | G70.  | 35. OTHER   |                     |
|---|---|---|---------------------|
| G69.  | G68.  | 34. OTHER   | Other               |
| G67   | G66   | 33. AUTOMATIC ALARM CHEMICAL MONITORING EQUIPMENT   |                     |
| G65   | G64.  | 32. X PORTABLE RADIOS   | Systems             |
| G63   | G62.  | 31. 🗵 INTERCOM / PA SYSTEM  | and                 |
| G61.  | G60   | 30.   | Communi-<br>cations |
| G59.  | G58.  | 29. OTHER   |                     |
| G57   | G56,  | 28. SPILL OVERPACK DRUMS  |                     |
| G55.  | G54,  | 27. GAS CYLINDER LEAK REPAIR KIT  |                     |
| G53.  | G52.  | 26. CHEMICAL NEUTRALIZERS   |                     |
| 031.  | G50   | 25.   EMERGENCY SUMP / HOLDING TANK   |                     |
| G49,  | G48   | 24.  EXHAUST HOOD   |                     |
| G47.  | G46   | 23. SHOP VAC  |                     |
| G45   | G44,  | 22. SHOVEL  |                     |
| G43.  | G42   | 21.  BROOM  |                     |
| G41   | G40.  | 20. BERMING / DIKING EQUIPMENT  |                     |
| G39.  | G38. Main Accumulation Area, Satellite Accumulation Area                    | 19. X CONTAINER FOR USED ABSORBENT  | Cican-Op            |
| G37.  | G36.<br>Spill Kits, Tool Crib, Warehouse Safety Cabinet                     | ×   | and                 |
| G35.  | G34. Outside both CTG's and STG, Main Accumulation Area                     | ×   | Spill<br>Control    |
| G33.  | G32.  |   |                     |
| G31.  | G30.  | 15. 🗷 FIRE ALARM BOXES OR STATIONS  |                     |
| G29   | G28.  | ×   | a                   |
| G27   | G26   | ×   | Fire<br>Fighting    |
| G25   | G24.  | 12. OTHER   |                     |
| G23   | G22.  | 11. OTHER   |                     |
| G21.  | G20   | 10. PORTABLE EYEWASH KITS   |                     |
| GID   | G18. Bulk Chemical, NH3 Skid, CEMS, Water Treatment Area                    | 9. 🗵 PLUMBED EYEWASH FOUNTAIN / SHOWER  |                     |
| G17.  | G16. Control Room, West behind Control Room, Machine Shop, Center Office Tr | 8. X FIRST AID KITS / STATIONS  |                     |
| GIS   | G14   | 7. SELF-CONTAINED BREATHING APPARATUS (SCBA)  |                     |
| G13   | G12.  | 6. CARTRIDGE RESPIRATORS  |                     |
| 611   | GI0.  | 5. X HARD HATS  |                     |
| G9  | G8. Warehouse Safety Locker   | 4. X SAFETY GLASSES / GOGGLES / SHIELDS   |                     |
| G7  | 06  | 3. CHEMICAL PROTECTIVE BOOTS  |                     |
| G5.   | G4. Warehouse Safety Locker   | 2. X CHEMICAL PROTECTIVE GLOVES   | First Aid           |
| G   | G2. Warehouse, Bulk Chemical  | 1. X CHEMICAL PROTECTIVE SUITS, APRONS, OR VESTS  | Safety              |
| CAPABILITY (If applicable)  | LOCATION  | EQUIPMENT AVAILABLE GI.   | TYPE                |
| ation(s) where the equipment is kept and the ill & solvent resistant only.] | /ailable at the facility and identify the loca                              | Check all boxes that apply to list emergency response equipment available at the facility and identify the location(s) where the equipment is kept and the equipment's capability, if applicable, [e.g., 🗵 CHEMICAL PROTECTIVE GLOVES   Spill response kit   One time use, Oil & solvent resistant only.] | Check all be        |
|   | EMERGENCY EQUIPMENT   | G. EMER   |                     |
|   |   |   |                     |

| Identify areas of the facility that are vulnerable to hazardous materials releases / spills due to earthquake-related motion. These areas require immediate isolation and Inspection.  VULNERABLE AREAS (Check all that apply)  31. LABORATIONS  12. LABORATIONS  13. LECATIONS (Cinck all that apply)  44. LABORATIONS  14. LABORATIONS  14. LABORATIONS  15. SERLIVES, CABNETS AND RACKS  26. LABIEVES, CABNETS AND RACKS  27. TANKS (EMERGENCY SHITOFF)  28. LEMERGENCY SHITOFF AND CONTAINERS  31. SERLIVES, CABNETS AND TRACKS  29. SPRINKLER SYSTEMS  21. STATIONARY PRESSURZED CONTAINERS (e.g., Propane dispensing tank)  32. SPRINKLER SYSTEMS  33. PORTABLE GAS CYLINDERS  44. LEMPLOYEE TRAINING  35. SPRINKLER SYSTEMS  36. STATIONARY PRESSURZED CONTAINERS (e.g., Propane dispensing tank)  45. SPRINKLER SYSTEMS  45. Propagation of Requirement: Employee training its required for all employees handing hazardous materials and hazardous wastes in day-to-day or clean-up operations reluding volunteers and/or contractors. Training must be provided within 6 months for new hires, expuring the property response.  4. Provided a vinit of months for new hires, expuring the processors.  4. Provided vinitin 6 months for new hires, expuring the processors.  4. Provided to within 6 months for new hires, expuring the processors.  4. Provided to within 6 months for new hires, expuring the processors.  4. Provided to within 6 months for new hires, expuring the processors.  5. Fire hazardo of materials / processors.  6. Continuation of contractors. Training must be expured to an unably for all employees.  8. Required communication related to health and safety.  8. Hazardous procedures;  9. Communication procedures;  10. Communication procedures;  11. EMPLOYEE TRAINING PROGRAM IS ADMINISTERED (Check all that apply)  11. EXECUTIONAL ALE MEETINGS.  12. STORMAL CLASSROOM.  13. SERVINGAL CLASSROOM.  14. SERVINGAL CLASSROOM.  15. SERVINGAL CONTRAINERS (S. S. ADETY / TALLOCATE MEETINGS.  16. STORMAL CLASSROOM.  17. SERVINGAL CLASSROOM.  18. SERVINGAL CONTRAINER | A written outline/agenda of the type and amount of both introductory and continuing training that will be given to persons filling each job position having responsibility for the management of hazardous waste (e.g., labeling, manifesting, compliance with accumulation time limits, etc.)  The name, job title, and date of training for each of the above job positions that describes job duties and the skills, education, or other qualifications required of personnel assigned to the position.  Current employee training records must be retained until closure of the facility.  Former employee training records must be retained at least three years after termination of employment.  J. LIST OF ATTACHMENTS  Theck one of the following)  1. THE FOLLOWING DOCUMENTS ARE ATTACHED:  K. SIGNATURE / CERTIFICATION  K. SIGNATURE / CERTIFICATION  Entitleation: Based on my inquiry of those individuals responsible for obtaining the information, I certify under penalty of law that I have personally examined and n familiar with the information submitted and believe the information is true, accurate, and complete, and that a copy is available on site.  KI DATE SIGNER (print)  K. SIGNATURE / CERTIFICATION  KI DATE SIGNER  KI DATE SIGNER  KI DATE SIGNER  KI DATE SIGNER  KI DATE SIGNER | nazardous waste per month) must retain written documentation of employee hazardous waste namagement at retain written durine/agenda of the type and amount of both introductory and continuing training that will be given to persons fillin responsibility for the management of hazardous waste (e.g., labeling, manifesting, compliance with accumulation time limits, etc.).  • The name, job title, and date of training for each hazardous waste management training sessions which includes:  • A written job description for each of the above job positions that describes job duties and the skills, education, or other qualifications reto to the position.  • Current employee training records must be retained until closure of the facility.  • Former employee training records must be retained at least three years after termination of employment.  ■ J. LIST OF ATTACHMENTS  Check one of the following.)  ■ 1. NO ATTACHMENTS ARE REQUIRED, or  □ 2. THE FOLLOWING DOCUMENTS ARE ATTACHED:  ■ ATTACHMENTS ARE ATTACHED:  ■ Certification: Based on my inquiry of those individuals responsible for obtaining the information, I certify under penalty of law that I ha am familiar with the information submitted and believe the information is true, accurate, and complete, and that a copy is available on site.  ■ SIGNATURE OF OWNER/OPERATOR  MAME OF SIGNER (print)  MAME OF SIGNER (print) |
|--|--|--|
| ILNERABLE AREAS: (Check all that apply)  1. HAZARDOUS MATERIALS / WASTE STORAGE AREA  2. PROCESS LINES / PIPING  3. LABORATORY  4. WASTE TREATMENT AREA  2. TANKS (EMERGENCY SHUTOFF)  3. PORTABLE GAS CYLINDERS  4. EMERGENCY SHUTOFF AND/OR UTILITY VALVES  5. SPRINKLER SYSTEMS  6. STATIONARY PRESSURIZED CONTAINERS (e.g., Propane dispensing tank)  ILNERABLE TREATMING  H. LOCATIONS (e.g., shop, outdoor shed, forensic lab)  H. LOCATIONS (e.g., shop, outdoor shed, forensic lab)  Main Accumulation Area near Ammonia Tank  LOCATIONS  LOCATIONS  LOCATIONS  LOCATIONS  Warehouse  CEMS Building  CEMS Building  CEMS Building  A EMERGENCY SHUTOFF AND/OR UTILITY VALVES  5. SPRINKLER SYSTEMS  6. STATIONARY PRESSURIZED CONTAINERS (e.g., Propane dispensing tank)  LOCATIONS  CEMS Building   | r all employees handling hazardous materials and hazardous wastes in day-to-day or clean-up opera ignment;  genery Plan, and updated/refreshed annually for all employees.  Communication and alarm systems;  Personal protective equipment;  Use of emergency response equipment (e.g. Fire extinguishers, respirators, etc.);  Pocontamination procedures;  Evacuation procedures;  Control and containment procedures;  VIST monitoring system equipment and procedures (if applicable).  MINISTERED (Check all that apply)  3. SAFETY / TAILGATE MEETINGS;  Powerpoint Presentations   | Explanation of Requirement: Employee training is required for all employee including volunteers and/or contractors. Training must be:  Provided within 6 months for new hires; Amended as necessary prior to change in process or work assignment; Given upon modification to the Emergency Response / Contingency Plan, a Required content includes all of the following: Material Safety Data Sheets; Material Safety Data Sheets; Hazard communication related to health and safety; Methods for safe handling of hazardous substances; Fire hazards of materials / processes; Conditions likely to worsen emergencies; Coordination of emergency response; Notification procedures; Applicable laws and regulations;  INDICATE HOW EMPLOYEE TRAINING PROGRAM IS ADMINISTERE X 1. FORMAL CLASSROOM; APPLICABLE HOW EMPLOYEE TRAINING PROGRAM IS ADMINISTERE X 2. STUDY GUIDES / MANUALS (Specify): Frocedures, Powerpoint Presse S. OTHER (Specify):  S. OTHER (Specify):  Required for all employee training must be:  Not APPLICABLE BECAUSE FACILITY HAS NO EMPLOYEES  |
| rials releases / spills due to earthquake-related motion. These areas require immediate  HI. LOCATIONS (e.g., shop, outdoor shed, forensic lab)  Main Accumulation Area near Ammonia Tank  | s earthquake-related motion. These systems require immediate isolation and inspection.  Ho LOCATIONS  Warehouse  CEMS Building  CEMS Building  EMPLOYEE TRAINING   | Identify mechanical systems vulnerable to releases / spills due to earthquake-revulnerable Systems: (Check all that apply)  I. SHELVES, CABINETS AND RACKS  2. TANKS (EMERGENCY SHUTOFF)  3. PORTABLE GAS CYLINDERS  4. EMERGENCY SHUTOFF AND/OR UTILITY VALVES  5. SPRINKLER SYSTEMS  6. STATIONARY PRESSURIZED CONTAINERS (e.g., Propane dispense)   |
|  | aterials releases / spills due to earthquake-related motion. These areas require immediate isolation and  HI. LOCATIONS (e.g., shop, outdoor shed, forensic lab)  H2. Main Accumulation Area near Ammonia Tank  H3. H4. H4.  | Identify areas of the facility that are vulnerable to hazardous materials releas inspection.  VULNERABLE AREAS: (Check all that apply)  I. HAZARDOUS MATERIALS / WASTE STORAGE AREA  2. PROCESS LINES / PIPING  3. LABORATORY  4. WASTE TREATMENT AREA   |