

<b>DOCKETED</b>	
<b>Docket Number:</b>	81-AFC-01C
<b>Project Title:</b>	Compliance - Application for Certification of the Occidental Plant # 1
<b>TN #:</b>	228707
<b>Document Title:</b>	Record of Conversation Calistoga Geothermal
<b>Description:</b>	N/A
<b>Filer:</b>	Joe Douglas
<b>Organization:</b>	California Energy Commission
<b>Submitter Role:</b>	Energy Commission
<b>Submission Date:</b>	6/7/2019 8:38:51 AM
<b>Docketed Date:</b>	6/7/2019

**CALIFORNIA ENERGY COMMISSION**  
**REPORT OF CONVERSATION Page 1 of 1**



**Siting, Transmission  
 and Environmental  
 Protection Division**

**FILE:**

**PROJECT TITLE: Calistoga Geothermal** **Docket: 81-AFC-01C**

**TECHNICAL AREA(S): geology**

**email** Barbara.McBride@calpine.com  **Meeting Location:**

**NAME:** Garry Maurath **DATE:** 3 June 2019 **TIME:** 1113

**WITH:** Barbara McBride, Calpine

**SUBJECT:** Request for information on Calistoga Transmission Line upgrade

**COMMENTS:**

(copy of email string attached)

<b>cc:</b> Paul Marshall Joe Douglas	<b>Signed:</b> 
	<b>Name:</b> Garry Maurath

**From:** [Barbara McBride](#)  
**To:** [Maurath, Garry@Energy](mailto:Maurath.Garry@Energy)  
**Subject:** RE: Calistoga - follow-up site visit  
**Date:** Monday, June 03, 2019 11:13:23 AM

---

**CAUTION:** This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Gary,

In response to your question from last week concerning the power line replacement at Calistoga, Power Poles #1, #2 and #6 are outside of the active landslide area. The remaining poles are within the active landslide area but are above the current depth of movement. The power pole depth will be about 6.5 feet and the depth of movement is much deeper at 65-100 feet. Let me know if you need additional information.

**COMPANY CONFIDENTIALITY NOTICE:** The information in this e-mail may be confidential and/or privileged and protected by work product immunity or other legal rules. No confidentiality or privilege is waived or lost by mis-transmission. If you are not the intended recipient or an authorized representative of the intended recipient, you are hereby notified that any review, dissemination, or copying of this e-mail and its attachments, if any, or the information contained herein is prohibited. If you have received this e-mail in error, please immediately notify the sender by return e-mail and delete this e-mail from your computer system.