

237 102 OCT 04 99
DOCKET
99-AFC-5
DATE OCT 0 1 1999
RECD. OCT 0 4 1999



Dedicated to Community Service

2664 SWEETWATER SPRINGS BOULEVARD SPRING VALLEY CALIFORNIA 91978 2088
TELEPHONE 670-2222, AREA CODE 619

October 1, 1999

W O 2980

Ms Eileen Allen
Energy Commission Project Manager
California Energy Commission
1516 Ninth Street
Sacramento, California 95814-5512

Subject Comments to Otay Mesa Generating Project
Application for Certification (99-AFC-5) -
Supplemental Material

Dear Ms Allen

The Otay Water District (District) has reviewed the above-referenced document and is submitting the following comments

- **Page 5 5-2, Section 5 5 1 1 1, Paragraph 2** The District will not provide "potable water to fulfill all water needs associated with the operation of the plant" where recycled water may be used. Recycled water will be used for irrigation at the facility. An example of where recycled water might also be used at the facility is for process water needs.

Please incorporate these changes into the Application for Certification

We apologize for the delay in submitting these comments to you. If you have any questions or require further information, please contact me at (619) 670-2293

Sincerely,

Michael F. Coleman, AICP
Principal Environmental Specialist
Engineering and Planning

Ms Eileen Allen
October 1, 1999
Page 2 of 2

MC MN 1w

cc Jim Peasley
Terry Kreuter
Dan Mahanke
Jim Gunstinson