DOCKETED	
Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	230337
Document Title:	Air Quality Quarterly Operation Report For Third Quarter 2019
Description:	N/A
Filer:	Anwar Ali
Organization:	City of Roseville
Submitter Role:	Public Agency
Submission Date:	10/24/2019 12:46:43 PM
Docketed Date:	10/24/2019

CITY OF ROSEVILLE CALIFORNIA

Roseville Electric – Roseville Energy Park
5120 Phillip Road
Roseville, California 95747

October 22, 2019

Mr Anwar Ali
California Energy Commission
1516 Ninth Street, MS-2000
Sacramento, Ca. 95814

Subject: Roseville Energy Park (03-AFC-1)
Quarterly Air Quality Report – Third Quarter 2019

Mr. Ali,

As required by various air quality Conditions of Certification, Roseville Energy Park hereby submits the Quarterly Air Quality Report for the Third Quarter 2019. The report is submitted electronically via flash drive. If at any time you have any questions regarding this submittal, please do not hesitate to contact me.

Sincerely,

Julie Manfredi

Julie Manfredi
Electric Compliance Analyst
(916) 774-5674
JManfredi@roseville.ca.us

Cc: District Compliance Manager, PCAPCD
File

City of Roseville

Roseville Energy Park

(07-AFC-06C)

California Energy Commission

Quarterly Operational Report

Second Quarter 2019

List of Attachments

Attachment 1: AQ15 – SCR Installed before commissioning in 2007

Attachment 2: AQ20 - The gas turbine engine shall be fired exclusively on pipeline quality natural gas with sulfur content no greater than 0.50 grains of sulfur compounds per 100 dry scf of natural gas

Attachment 3: AQ21 – Startups and Shutdowns

Attachment 4: AQ32 – All hourly, quarter NOx and CO emissions AQ-SC6

Attachment 5: AQ33 – All hourly, daily, and quarterly Sox AQ-SC6

Attachment 6: AQ34 – Start Up and Shut downs

Attachment 7: AQ36 – Breakdown condition

Attachment 8: AQ37 – Violations of Emissions

Attachment 9: AQ40 – CEMS quality assurance test failures

Attachment 10: AQ41 – Excess Emissions

Attachment 11: AQ42 – Running 12 month summary

Attachment 12: AQ47 – All nuisance violations

N/A for this report period

Attachment 13: AQ48 – Nuisance complaints and stack emission opacity as dark as Ringlemann No. 1 (20% opacity) for periods aggregating more than 3 min.

N/A for this report period

Attachment 14: AQ51 – Ammonia slip exceedances

Attachment 15: AQ55 – Emission rates from each gas turbine and heat recovery steam generator exhaust during startup and shutdown – NOx and CO

Attachment 16: AQ57 – Emission exceedance rates during startup and shutdown – CO, NOX, PM-10, SOX, and VOC

Attachment 17: AQ59 – Emission limit exceedances – NOX, CO, VOC, PM-10, SO2

Attachment 18: AQ60 – Quarterly emission exceedances for Alstom GTX100 turbine – NOx, CO, VOCs, PMO, Sox

Attachment 19: AQ63 – Total facility emission exceedances – NOX, CO, VOC, PM-10, SO2

Attachment 20: AQ68 – Annual water sample analysis of cooling tower water

Attachment 21: AQ69 – Nuisance complaints

None

Attachment 22: AQ70 – PM-10 quarterly emission rate exceedances from cooling tower

Attachment 23: AQ71 – Exceedance of cooling tower PM-10 emission limit – PM-10 = cooling water recirculation rate*total dissolved solids concentration in the blow own water* design drift rate

Attachment 24: AQ86 – Limits for operation for maintenance and testing of emergency diesel engine and generator limited to 50 hours per year

Attachment 25: AQ87 – Operation for maintenance and testing purposes shall be limited to involuntary interruptions of electrical power. Operation shall not exceed 24 hours

Attachment 26: AQ88 – Sulfur content of diesel fuel used shall not exceed 15 ppm by weight

N/A for this report period

Attachment 27: AQ89 – Records of hours of operation engine run for maintenance and testing, during interruption of electrical power, records of sulfur content of diesel used for five years

Attachment 28: AQ90 – No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance

N/A for this report period

Attachment 29: AQ91 – Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited and is in violation of PCAPCD Rule 202, Visible Emissions

N/A for this report period

Attachment 30: AQ99 – Operation for maintenance and testing of the emergency diesel engine and generator shall be limited to 50 hours per year.

Attachment 31: AQ100 – Emergency diesel Generator; Operation for other than maintenance and testing purposes shall be limited to involuntary interruptions of electrical power

Attachment 32: AQ101 - The sulfur content of the diesel used shall not exceed 15ppm by weight

N/A for this report period

Attachment 33: AQ102 – Records of operation and maintenance shall be kept by the owner or operator for a period of five years

Attachment 34: AQ103 – No emissions are permitted, from any source, which are a nuisance

N/A for this report period

Attachment 35: AQ104 – Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited

N/A for this report period

ATTACHMENT 1

AQ-15

AQ-15 The Project owner shall install a selective catalytic reduction (SCR) system and an oxidation catalyst on the gas turbine. The SCR and oxidation catalyst equipment shall be operated whenever the gas turbine is operated.

Verification: The Project owner shall submit to the CPM a written statement by a California registered Professional Engineer stating that said engineer has reviewed the as built deigns or inspected the identified equipment and certifies that it is operational and air tight. The Project owner shall include the operational status of the SCR and oxidation catalyst during all hours of operation as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

This document is on file from the 2007 4Q QAQR.

ATTACHMENT 2

AQ-20

AQ-20 The gas turbine engine shall be fired exclusively on pipeline quality natural gas with sulfur content no greater than 0.50 grains of sulfur compounds per 100 dry scf of natural gas.

Verification: The Project owner shall submit to the CPM the most recent fuel testing analysis performed as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

Gas System Sulfur Surve

pge.com/pipeline/operations/sulfur/sulfur_info_values/index.page

California Gas Transmission

Pipe Ranger

Search Go Log in

About CGT | Products | Tools & Services | Operating Data | Reference/Library

- Current Pipeline Status
- Forecasts
- Historical Archives
- Gas Quality/Heating Values

Gas System Sulfur Survey Results

Date	Total Sulfur Maximum		Total Sulfur Average all sites	
	PPMv	gr/100 scf	PPMv	gr/100 scf
2019				
Second Quarter	5.8	0.36	3.75	0.23
First Quarter	5.1	0.32	3.75	0.23

AQ20 ROSEVILLE ENERGY PARK

3Q19

Fuel Quality Analysis BTU values

http://www.pge.com/pipeline/operations/gas_quality/p01_2_weeks.shtml

	JUL	AUG	SEP
1	1038.91	1044.33	1050.92
2	1036.07	1042.89	1043.99
3	1045.86	1042.92	1045.59
4	1045.85	1043.25	1044.61
5	1039.62	1045.70	1042.78
6	1035.19	1048.60	1044.64
7	1043.08	1047.78	1046.50
8	1044.59	1047.04	1047.19
9	1038.04	1047.61	1051.18
10	1039.97	1048.03	1049.42
11	1039.55	1050.13	1045.19
12	1040.29	1051.23	1044.52
13	1042.30	1,047.22	1043.12
14	1044.38	1045.84	1044.13
15	1045.98	1045.94	1044.80
16	1045.45	1044.84	1045.62
17	1045.32	1047.00	1045.20
18	1046.05	1046.27	1044.78
19	1047.31	1047.99	1045.13
20	1048.35	1046.55	1046.78
21	1048.23	1048.66	1048.13
22	1048.63	1046.68	1048.64
23	1048.31	1045.16	1046.43
24	1049.30	1048.56	1045.85
25	1046.83	1049.20	1044.35
26	1048.44	1048.24	1043.92
27	1048.61	1045.23	1042.91
28	1047.98	1044.53	1045.08
29	1044.43	1047.04	1046.35
30	1110.69	1048.69	1045.51
31	1044.36	1048.86	X

ATTACHMENT 3

AQ-21

AQ-21 Startup is defined as the period beginning with the turbine light-off until the unit meets the lb/hr and ppmv emission limits in Conditions of Certification AQ-52, -54 and -55. Shutdown is defined as the period beginning with initiation of turbine shutdown sequence and ending with cessation of firing of the gas turbine engine. Startup and shutdown durations shall not exceed 3.0 hours and one hour, respectively, per occurrence.

Verification: The Project owner shall identify and submit to the CPM as part of the Quarterly Air Quality Report all startups and shutdowns for all units including the maximum hourly emission rate, total emissions and duration.

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:01 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
07/01/2019	0.00	0.00	0.00	0.00	0.00
07/02/2019	0.00	0.00	0.00	0.00	0.00
07/03/2019	0.00	0.00	0.00	0.00	0.00
07/04/2019	0.00	0.00	0.00	0.00	0.00
07/05/2019	0.00	0.00	0.00	0.00	0.00
07/06/2019	0.00	0.00	0.00	0.00	0.00
07/07/2019	0.00	0.00	0.00	0.00	0.00
07/08/2019	0.00	0.00	0.00	0.00	0.00
07/09/2019	0.00	0.00	0.00	0.00	0.00
07/10/2019	0.00	0.00	0.00	0.00	0.00
07/11/2019	0.00	0.00	0.00	0.00	0.00
07/12/2019	0.00	0.00	0.00	0.00	0.00
07/13/2019	0.00	0.00	0.00	0.00	0.00
07/14/2019	0.00	0.00	0.00	0.00	0.00
07/15/2019	0.00	0.00	0.00	0.00	0.00
07/16/2019	0.00	0.00	0.00	0.00	0.00
07/17/2019	0.00	0.00	0.00	0.00	0.00
07/18/2019	0.00	0.00	0.00	0.00	0.00
07/19/2019	0.00	0.00	0.00	0.00	0.00
07/20/2019	0.00	0.00	0.00	0.00	0.00
07/21/2019	0.00	0.00	0.00	0.00	0.00
07/22/2019	27.81	37.22	2.49	4.96	8.30
07/23/2019	29.53	91.83	8.98	17.99	30.01
07/24/2019	7.40	93.50	8.98	17.98	29.95
07/25/2019	15.45	79.03	7.60	15.23	25.36
07/26/2019	14.85	80.58	7.75	15.52	25.86
07/27/2019	42.08	83.84	6.91	13.83	23.07
07/28/2019	31.86	144.37	13.84	27.61	46.05
07/29/2019	32.64	154.66	14.79	29.56	49.26
07/30/2019	34.96	111.05	10.60	21.19	35.32
07/31/2019	29.32	119.89	11.42	22.89	38.15
Monthly Avg/Sum*:	265.90 *	995.97 *	93.36 *	186.76 *	311.33 *
Daily Min:	7.40	37.22	2.49	4.96	8.30
Daily Max:	42.08	154.66	14.79	29.56	49.26
Jul 2019 - Jul 2019	265.90	995.97	93.36	186.76	311.33
QTD:	265.90 *	995.97 *	93.36 *	186.76 *	311.33 *
YTD 2019:	3,190.65 *	9,282.43 *	870.52 *	1,742.01 *	2,903.47 *

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:01 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
08/01/2019	32.28	112.72	10.75	21.54	35.87
08/02/2019	30.10	116.24	11.12	22.22	37.00
08/03/2019	29.83	124.10	11.85	23.77	39.57
08/04/2019	27.26	131.11	12.51	24.97	41.60
08/05/2019	25.16	111.76	11.62	23.28	38.76
08/06/2019	30.10	127.41	12.19	24.43	40.66
08/07/2019	30.47	121.93	11.59	23.24	38.66
08/08/2019	31.45	21.55	1.87	3.76	6.23
08/09/2019	0.00	0.00	0.00	0.00	0.00
08/10/2019	0.00	0.00	0.00	0.00	0.00
08/11/2019	0.00	0.00	0.00	0.00	0.00
08/12/2019	0.00	0.00	0.00	0.00	0.00
08/13/2019	31.38	63.44	5.12	10.24	17.09
08/14/2019	56.92	129.68	11.42	22.84	38.09
08/15/2019	31.31	129.75	12.57	25.18	41.94
08/16/2019	38.17	132.93	12.67	25.38	42.27
08/17/2019	21.76	63.82	5.98	12.01	20.00
08/18/2019	0.00	0.00	0.00	0.00	0.00
08/19/2019	0.00	0.00	0.00	0.00	0.00
08/20/2019	0.00	0.00	0.00	0.00	0.00
08/21/2019	0.00	0.00	0.00	0.00	0.00
08/22/2019	0.00	0.00	0.00	0.00	0.00
08/23/2019	0.00	0.00	0.00	0.00	0.00
08/24/2019	0.00	0.00	0.00	0.00	0.00
08/25/2019	38.98	65.25	5.20	10.44	17.38
08/26/2019	20.39	68.80	6.54	13.08	21.82
08/27/2019	57.36	131.96	11.59	23.16	38.61
08/28/2019	25.76	153.44	14.70	29.37	49.01
08/29/2019	60.99	128.03	12.03	24.04	40.10
08/30/2019	0.00	0.00	0.00	0.00	0.00
08/31/2019	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	619.67 *	1,933.92 *	181.32 *	362.95 *	604.66 *
Daily Min:	20.39	21.55	1.87	3.76	6.23
Daily Max:	60.99	153.44	14.70	29.37	49.01
Jul 2019 - Aug 2019	885.57	2,929.89	274.68	549.71	915.99
QTD:	885.57 *	2,929.89 *	274.68 *	549.71 *	915.99 *
YTD 2019:	3,810.32 *	11,216.35 *	1,051.84 *	2,104.96 *	3,508.13 *

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:01 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
09/01/2019	0.00	0.00	0.00	0.00	0.00
09/02/2019	0.00	0.00	0.00	0.00	0.00
09/03/2019	0.00	0.00	0.00	0.00	0.00
09/04/2019	84.83	128.20	10.09	20.18	33.62
09/05/2019	54.31	133.96	12.64	25.30	42.16
09/06/2019	0.00	0.00	0.00	0.00	0.00
09/07/2019	0.00	0.00	0.00	0.00	0.00
09/08/2019	0.00	0.00	0.00	0.00	0.00
09/09/2019	26.06	15.30	0.24	0.48	0.80
09/10/2019	21.23	68.35	6.57	13.13	21.90
09/11/2019	63.84	79.38	6.42	12.87	21.44
09/12/2019	68.03	88.44	7.04	14.09	23.47
09/13/2019	0.00	0.00	0.00	0.00	0.00
09/14/2019	0.00	0.00	0.00	0.00	0.00
09/15/2019	0.00	0.00	0.00	0.00	0.00
09/16/2019	0.00	0.00	0.00	0.00	0.00
09/17/2019	0.00	0.00	0.00	0.00	0.00
09/18/2019	0.00	0.00	0.00	0.00	0.00
09/19/2019	0.00	0.00	0.00	0.00	0.00
09/20/2019	0.00	0.00	0.00	0.00	0.00
09/21/2019	0.00	0.00	0.00	0.00	0.00
09/22/2019	0.00	0.00	0.00	0.00	0.00
09/23/2019	56.71	68.38	5.19	10.37	17.28
09/24/2019	82.79	131.06	11.51	22.99	38.34
09/25/2019	33.98	128.33	12.36	24.69	41.13
09/26/2019	44.70	124.85	11.84	23.67	39.36
09/27/2019	29.32	76.81	7.20	14.44	24.12
09/28/2019	0.00	0.00	0.00	0.00	0.00
09/29/2019	0.00	0.00	0.00	0.00	0.00
09/30/2019	104.05	60.53	3.27	6.56	10.91
Monthly Avg/Sum*:	669.85 *	1,103.59 *	94.37 *	188.77 *	314.53 *
Daily Min:	21.23	15.30	0.24	0.48	0.80
Daily Max:	104.05	133.96	12.64	25.30	42.16
Jul 2019 - Sep 2019	1,555.42	4,033.48	369.05	738.48	1,230.52
QTD:	1,555.42 *	4,033.48 *	369.05 *	738.48 *	1,230.52 *
YTD 2019:	4,480.17 *	12,319.94 *	1,146.21 *	2,293.73 *	3,822.66 *

Monthly Summary By Day Report

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:04 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)
07/01/2019	0.0	0.0	0.0	0.0
07/02/2019	0.0	0.0	0.0	0.0
07/03/2019	0.0	0.0	0.0	0.0
07/04/2019	0.0	0.0	0.0	0.0
07/05/2019	0.0	0.0	0.0	0.0
07/06/2019	0.0	0.0	0.0	0.0
07/07/2019	0.0	0.0	0.0	0.0
07/08/2019	0.0	0.0	0.0	0.0
07/09/2019	0.0	0.0	0.0	0.0
07/10/2019	0.0	0.0	0.0	0.0
07/11/2019	0.0	0.0	0.0	0.0
07/12/2019	0.0	0.0	0.1	0.0
07/13/2019	0.0	0.0	0.0	0.0
07/14/2019	0.0	0.0	0.0	0.0
07/15/2019	0.0	0.0	0.0	0.0
07/16/2019	0.0	0.0	0.0	0.0
07/17/2019	0.0	0.0	0.0	0.0
07/18/2019	0.0	0.0	0.0	0.0
07/19/2019	0.0	0.0	0.0	0.0
07/20/2019	0.0	0.0	0.0	0.0
07/21/2019	0.0	0.0	0.0	0.0
07/22/2019	0.0	0.0	20.2	12.4
07/23/2019	0.0	0.0	7.4	1.1
07/24/2019	0.0	0.0	0.0	0.0
07/25/2019	0.0	0.0	0.0	0.0
07/26/2019	0.0	0.0	0.0	0.0
07/27/2019	0.0	0.0	22.3	13.1
07/28/2019	0.0	0.0	0.0	0.0
07/29/2019	0.0	0.0	0.0	0.0
07/30/2019	0.0	0.0	0.0	0.0
07/31/2019	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	0.0 *	0.0 *	49.9 *	26.6 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	0.0	0.0	22.3	13.1
Jul 2019 - Jul 2019	0.0	0.0	49.9	26.6
QTD:	0.0 *	0.0 *	50.0 *	26.6 *
YTD 2019:	250.5 *	82.7 *	367.0 *	158.2 *

Monthly Summary By Day Report

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:04 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)
08/01/2019	0.0	0.0	0.0	0.0
08/02/2019	0.0	0.0	0.0	0.0
08/03/2019	0.0	0.0	0.0	0.0
08/04/2019	0.0	0.0	0.0	0.0
08/05/2019	0.0	0.0	0.0	0.0
08/06/2019	0.0	0.0	0.0	0.0
08/07/2019	0.0	0.0	0.0	0.0
08/08/2019	5.6	1.1	7.8	1.1
08/09/2019	0.0	0.0	0.0	0.0
08/10/2019	0.0	0.0	0.0	0.0
08/11/2019	0.0	0.0	0.0	0.0
08/12/2019	0.0	0.0	0.0	0.0
08/13/2019	23.3	11.9	0.0	0.0
08/14/2019	0.0	0.0	29.8	12.8
08/15/2019	0.0	0.0	0.0	0.0
08/16/2019	0.0	0.0	9.0	1.3
08/17/2019	7.3	1.1	0.0	0.0
08/18/2019	0.0	0.0	0.0	0.0
08/19/2019	0.0	0.0	0.0	0.0
08/20/2019	0.0	0.0	0.0	0.0
08/21/2019	0.0	0.0	0.0	0.0
08/22/2019	0.0	0.0	0.0	0.0
08/23/2019	0.0	0.0	0.0	0.0
08/24/2019	0.0	0.0	0.0	0.0
08/25/2019	0.0	0.0	26.2	14.0
08/26/2019	0.0	0.0	0.0	0.0
08/27/2019	29.1	13.0	0.0	0.0
08/28/2019	0.0	0.0	0.0	0.0
08/29/2019	7.9	1.1	9.3	1.5
08/30/2019	0.0	0.0	0.0	0.0
08/31/2019	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	73.2 *	28.2 *	82.1 *	30.7 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	29.1	13.0	29.8	14.0
Jul 2019 - Aug 2019	73.2	28.2	132.0	57.3
QTD:	73.2 *	28.2 *	132.1 *	57.3 *
YTD 2019:	323.7 *	110.9 *	449.1 *	188.9 *

Monthly Summary By Day Report

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:04 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)
09/01/2019	0.0	0.0	0.0	0.0
09/02/2019	0.0	0.0	0.0	0.0
09/03/2019	0.0	0.0	0.0	0.0
09/04/2019	30.3	12.0	28.7	13.6
09/05/2019	5.6	0.9	9.2	1.4
09/06/2019	0.0	0.0	0.0	0.0
09/07/2019	0.0	0.0	0.0	0.0
09/08/2019	0.0	0.0	0.0	0.0
09/09/2019	0.0	0.0	26.1	14.8
09/10/2019	0.0	0.0	0.0	0.0
09/11/2019	28.3	11.9	8.9	2.1
09/12/2019	12.5	1.3	32.0	15.1
09/13/2019	0.0	0.0	0.0	0.0
09/14/2019	0.0	0.0	0.0	0.0
09/15/2019	0.0	0.0	0.0	0.0
09/16/2019	0.0	0.0	0.0	0.0
09/17/2019	0.0	0.0	0.0	0.0
09/18/2019	0.0	0.0	0.0	0.0
09/19/2019	0.0	0.0	0.0	0.0
09/20/2019	0.0	0.0	0.0	0.0
09/21/2019	0.0	0.0	0.0	0.0
09/22/2019	0.0	0.0	0.0	0.0
09/23/2019	0.0	0.0	40.1	15.9
09/24/2019	39.0	12.0	0.0	0.0
09/25/2019	0.0	0.0	0.0	0.0
09/26/2019	6.7	1.0	0.0	0.0
09/27/2019	0.0	0.0	10.3	1.4
09/28/2019	0.0	0.0	0.0	0.0
09/29/2019	0.0	0.0	0.0	0.0
09/30/2019	39.4	13.7	43.6	16.7
Monthly Avg/Sum*:	161.8 *	52.8 *	198.9 *	81.0 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	39.4	13.7	43.6	16.7
Jul 2019 - Sep 2019	235.0	81.0	330.9	138.3
QTD:	235.0 *	81.0 *	331.0 *	138.3 *
YTD 2019:	485.5 *	163.7 *	648.0 *	269.9 *

Startup / Shutdown Events

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:05 **Location:** Roseville, CA

Unit Offline

Tag Name: CT1_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
07/01/2019 00:00	07/23/2019 04:00	533
08/08/2019 05:00	08/13/2019 05:00	121
08/18/2019 00:00	08/27/2019 04:00	221
08/30/2019 00:00	09/04/2019 04:00	125
09/06/2019 00:00	09/11/2019 07:00	128
09/12/2019 13:00	09/24/2019 06:00	282
09/27/2019 00:00	09/30/2019 05:00	78
09/30/2019 13:00	09/30/2019 23:00	11

Startup / Shutdown Events

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:05 **Location:** Roseville, CA

Operating Time Summary	
Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	1,499.00 Hour(s)
Offline Percentage:	67.89 %
Total Online:	709.00 Hour(s)
Online Percentage:	32.11 %

Startup / Shutdown Events

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:05 **Location:** Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	07/23/2019 05:45	07/23/2019 06:59	Cold Startup	75
2	08/08/2019 04:50	08/08/2019 04:58	Shutdown	9
3	08/13/2019 06:45	08/13/2019 07:38	Cold Startup	54
4	08/17/2019 22:57	08/17/2019 23:05	Shutdown	9
5	08/27/2019 05:44	08/27/2019 06:44	Cold Startup	61
6	08/29/2019 22:55	08/29/2019 23:05	Shutdown	11
7	09/04/2019 05:44	09/04/2019 06:36	Cold Startup	53
8	09/05/2019 22:56	09/05/2019 23:03	Shutdown	8
9	09/11/2019 08:45	09/11/2019 09:43	Cold Startup	59
10	09/12/2019 11:51	09/12/2019 12:02	Shutdown	12
11	09/24/2019 07:43	09/24/2019 07:43	Cold Startup	1
12	09/24/2019 07:43	09/24/2019 07:43	Shutdown	1
13	09/24/2019 07:56	09/24/2019 08:54	Cold Startup	59
14	09/26/2019 22:53	09/26/2019 23:00	Shutdown	8
15	09/30/2019 06:44	09/30/2019 07:36	Cold Startup	53
16	09/30/2019 11:53	09/30/2019 12:03	Shutdown	11

Startup / Shutdown Events

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:05 **Location:** Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	8	415	0.99
Warm Startup	0		0.00
Shutdown	8	69	0.16
Total Process Events:	16	484	1.16

Total Report Time:	2,207.98 Hour(s)
Total Operating Time:	698.02 Hour(s)
Total Startup Time:	415 Minute(s)
Total Shutdown Time:	69 Minute(s)
Total Startup/Shutdown Time:	484 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	1.16 %

CT1 SUSD EVENT 1

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/23/19 5:40	0			0	X		0	X		0	X		0	X		0		
07/23/19 5:41	0			0	X		0	X		0	X		0	X		0		
07/23/19 5:42	0			0	X		0	X		0	X		0	X		0		
07/23/19 5:43	0			0	X		0	X		0	X		0	X		0		
07/23/19 5:44	0			0	X		0	X		0	X		0	X		0		
07/23/19 5:45	0			0.2	X		0	X		0	X		0	X		1		
07/23/19 5:46	4543.9			0.3	X		0	X		0	X		0	X		1		
07/23/19 5:47	30652.4			56.6	X		28.32	X		4.04	X		3.33	X		1		
07/23/19 5:48	47672.9			516.4	X		17.08	X		57.45	X		3.13	X		1		
07/23/19 5:49	69545.4			354.3	X		23.31	X		57.5	X		6.22	X		1		
07/23/19 5:50	114368.7			201.9	X		25.75	X		53.88	X		11.31	X		1		
07/23/19 5:51	135625.1			86.7	X		44.25	X		27.42	X		23.03	X		1		
07/23/19 5:52	146715.4			229.9	X		53.64	X		78.69	X		30.21	X		1		
07/23/19 5:53	166123.5			1841	X		38.98	X		713.34	X		24.85	X		1		
07/23/19 5:54	189151.2			1133.9	X		48	X		500.28	X		34.85	X		1		
07/23/19 5:55	214643.5			163.1	X		57.22	X		81.69	X		47.15	X		1		
07/23/19 5:56	234436.6			9.3	X		51.78	X		5.07	X		46.6	X		1		
07/23/19 5:57	261007.1			2	X		46.13	X		1.24	X		46.22	X		1		
07/23/19 5:58	284728.1			1.9	X		42.28	X		1.24	X		46.22	X		1		
07/23/19 5:59	305599.4			1.8	X		30.73	X		1.26	X		36.05	X		1		
07/23/19 6:00	326008.6			1.9	X		16.14	X		1.45	X		20.2	X		1		
07/23/19 6:01	337561			2	X		15.27	X		1.57	X		19.79	X		1		
07/23/19 6:02	339178.3			1.8	X		12.23	X		1.44	X		15.93	X		1		
07/23/19 6:03	339332.4			1.7	X		11.45	X		1.37	X		14.92	X		1		
07/23/19 6:04	343491.3			1.6	X		9.8	X		1.25	X		12.93	X		1		
07/23/19 6:05	354581.5			1.5	X		8.42	X		1.22	X		11.46	X		1		
07/23/19 6:06	358278.3			1.4	X		6.97	X		1.2	X		9.59	X		1		
07/23/19 6:07	359279.5			1.3	X		6.88	X		1.05	X		9.49	X		1		
07/23/19 6:08	363130.3			1.2	X		6.26	X		0.98	X		8.72	X		1		
07/23/19 6:09	365363.8			1.1	X		5.72	X		0.91	X		8.02	X		1		
07/23/19 6:10	367982.3			1	X		5.72	X		0.84	X		8.08	X		1		
07/23/19 6:11	370677.9			1	X		5.63	X		0.86	X		8.01	X		1		
07/23/19 6:12	371525.1			0.9	X		5.54	X		0.79	X		7.9	X		1		
07/23/19 6:13	372064.2			0.9	X		5.45	X		0.79	X		7.78	X		1		
07/23/19 6:14	372295.2			0.9	X		5.45	X		0.79	X		7.78	X		1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/23/19 6:15	371987.2			0.9	X		5.54	X		0.79	X		7.91	X		1		
07/23/19 6:16	371679.1			0.9	X		5.54	X		0.79	X		7.9	X		1		
07/23/19 6:17	370831.9			0.8	X		5.54	X		0.71	X		7.88	X		1		
07/23/19 6:18	370523.8			0.8	X		5.63	X		0.71	X		8	X		1		
07/23/19 6:19	370677.9			0.8	X		5.72	X		0.71	X		8.14	X		1		
07/23/19 6:20	370215.8			0.8	X		5.81	X		0.71	X		8.26	X		1		
07/23/19 6:21	369599.7			0.8	X		5.9	X		0.7	X		8.37	X		1		
07/23/19 6:22	367674.3			0.8	X		5.99	X		0.7	X		8.45	X		1		
07/23/19 6:23	352964.2			0.8	X		6.35	X		0.67	X		8.61	X		1		
07/23/19 6:24	342798.1			0.8	X		6.97	X		0.64	X		9.18	X		1		
07/23/19 6:25	340641.7			0.8	X		6.78	X		0.63	X		8.87	X		1		
07/23/19 6:26	339717.5			0.8	X		5.99	X		0.64	X		7.81	X		1		
07/23/19 6:27	337407			0.8	X		5.01	X		0.63	X		6.48	X		1		
07/23/19 6:28	327471.9			0.8	X		4.29	X		0.61	X		5.39	X		1		
07/23/19 6:29	320925.6			0.8	X		4.23	X		0.59	X		5.21	X		1		
07/23/19 6:30	319924.3			0.9	X		4.14	X		0.66	X		5.08	X		1		
07/23/19 6:31	319924.3			0.9	X		3.87	X		0.66	X		4.76	X		1		
07/23/19 6:32	319924.3			0.9	X		3.61	X		0.66	X		4.43	X		1		
07/23/19 6:33	319616.3			0.8	X		3.43	X		0.59	X		4.21	X		1		
07/23/19 6:34	319616.3			0.8	X		3.4	X		0.6	X		4.17	X		1		
07/23/19 6:35	319770.3			0.8	X		3.31	X		0.6	X		4.06	X		1		
07/23/19 6:36	319924.3			0.8	X		3.31	X		0.6	X		4.06	X		1		
07/23/19 6:37	319616.3			0.8	X		3.22	X		0.6	X		3.95	X		1		
07/23/19 6:38	319847.3			0.8	X		3.13	X		0.6	X		3.84	X		1		
07/23/19 6:39	320309.4			0.8	X		3.04	X		0.6	X		3.74	X		1		
07/23/19 6:40	320463.5			0.8	X		2.95	X		0.6	X		3.63	X		1		
07/23/19 6:41	320232.4			0.8	X		2.95	X		0.6	X		3.63	X		1		
07/23/19 6:42	320309.4			0.8	X		2.86	X		0.6	X		3.52	X		1		
07/23/19 6:43	320463.5			0.8	X		2.86	X		0.6	X		3.52	X		1		
07/23/19 6:44	320771.5			0.8	X		2.95	X		0.6	X		3.63	X		1		
07/23/19 6:45	320848.5			0.8	X		2.95	X		0.6	X		3.63	X		1		
07/23/19 6:46	320617.5			0.8	X		2.86	X		0.6	X		3.52	X		1		
07/23/19 6:47	320463.5			0.8	X		2.77	X		0.6	X		3.41	X		1		
07/23/19 6:48	320386.4			0.8	X		2.77	X		0.6	X		3.41	X		1		
07/23/19 6:49	320232.4			0.8	X		2.68	X		0.6	X		3.3	X		1		
07/23/19 6:50	320155.4			0.8	X		2.68	X		0.6	X		3.3	X		1		
07/23/19 6:51	319924.3			0.8	X		2.68	X		0.6	X		3.29	X		1		
07/23/19 6:52	319693.3			0.8	X		2.59	X		0.6	X		3.18	X		1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/23/19 6:53	320001.4			0.8	X		2.59	X		0.6	X		3.18	X		1		
07/23/19 6:54	319924.3			0.8	X		2.59	X		0.6	X		3.18	X		1		
07/23/19 6:55	327240.9			0.8	X		2.59	X		0.61	X		3.26	X		1		
07/23/19 6:56	332709			0.8	X		2.41	X		0.62	X		3.08	X		1		
07/23/19 6:57	333094.1			0.8	X		1.79	X		0.63	X		2.29	X		1		
07/23/19 6:58	333633.2			0.8	X		1.7	X		0.63	X		2.17	X		1		
07/23/19 6:59	333787.2			0.8	X		1.52	X		0.63	X		1.95	X		1		
07/23/19 7:00	337715			0.8	X		1.34	X		0.63	X		1.74	X		0		
07/23/19 7:01	344569.5			0.8	X		1.25	X		0.65	X		1.66	X		0		
07/23/19 7:02	347342			0.8	X		1.18	X		0.66	X		1.57	X		0		
07/23/19 7:03	349498.5			0.7	X		1.18	X		0.59	X		1.58	X		0		
07/23/19 7:04	352964.2			0.7	X		1.09	X		0.6	X		1.48	X		0		

CT1 SUSD EVENT 2

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/08/19 4:45	284266			0.6			1.75			0.43			1.91			0		
08/08/19 4:46	284343			0.6			1.66			0.43			1.81			0		
08/08/19 4:47	284343			0.6			1.75			0.43			1.91			0		
08/08/19 4:48	284497			0.6			1.75			0.43			1.91			0		
08/08/19 4:49	284574			0.6			1.75			0.43			1.91			0		
08/08/19 4:50	283726.8			0.6			1.75			0.43			1.91			1		
08/08/19 4:51	266013.2			0.6			1.75			0.4			1.79			1		
08/08/19 4:52	241830.2			0.7			3.65			0.37			3.39			1		
08/08/19 4:53	222114.1			0.6			8.22			0.3			7.01			1		
08/08/19 4:54	196852.8			0.5			15.22			0.24			11.5			1		
08/08/19 4:55	172900.9			2.3			18.38			0.92			12.2			1		
08/08/19 4:56	151336.4			80.2			20.78			28.3			12.07			1		
08/08/19 4:57	133468.7			598.9			21.39			186.46			10.96			1		
08/08/19 4:58	30652.4			1626			22.08			116.11			2.6			1		
08/08/19 4:59	0			0			22.24			0			0			0		
08/08/19 5:00	0			0			0.2			0			0			0		
08/08/19 5:01	0			0			0.1			0			0			0		
08/08/19 5:02	0			0			0.1			0			0			0		
08/08/19 5:03	0			0			0.1			0			0			0		

CT1 SUSD EVENT 3

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/13/19 6:40	0			0			0			0			0			0		
08/13/19 6:41	0			0			0			0			0			0		
08/13/19 6:42	0			0			0			0			0			0		
08/13/19 6:43	0			0			0			0			0			0		
08/13/19 6:44	0			0			0			0			0			0		
08/13/19 6:45	0			0.2			0			0			0			1		
08/13/19 6:46	6084.3			0.2			0			0			0			1		
08/13/19 6:47	31576.5			60			26.55			4.42			3.22			1		
08/13/19 6:48	48135			521.1			17.08			58.55			3.16			1		
08/13/19 6:49	71008.7			355.2			22.72			58.83			6.19			1		
08/13/19 6:50	118142.5			198.5			25.75			54.69			11.68			1		
08/13/19 6:51	138012.6			83.5			43.34			26.88			22.96			1		
08/13/19 6:52	154263			367.6			50.7			132.25			30.02			1		
08/13/19 6:53	175750.5			1737			44.08			711.94			29.73			1		
08/13/19 6:54	199779.4			593.9			56.73			276.8			43.51			1		
08/13/19 6:55	223654.4			56.4			63.98			29.4			54.92			1		
08/13/19 6:56	244217.6			3.8			66.64			2.17			62.48			1		
08/13/19 6:57	272097.4			1.8			59.93			1.12			62.59			1		
08/13/19 6:58	293815.9			1.7			41.77			1.16			47.12			1		
08/13/19 6:59	312992.9			1.7			22.56			1.27			27.1			1		
08/13/19 7:00	333402.2			1.9			14.84			1.48			18.99			1		
08/13/19 7:01	349806.5			1.9			13.8			1.56			18.52			1		
08/13/19 7:02	368213.4			1.8			10.48			1.51			14.81			1		
08/13/19 7:03	391549.2			1.5			8.99			1.41			13.51			1		
08/13/19 7:04	414654			1.4			8.2			1.34			13.06			1		
08/13/19 7:05	425513.3			1.2			7.02			1.21			11.47			1		
08/13/19 7:06	424820.1			1.1			6.91			1.1			11.28			1		
08/13/19 7:07	423895.9			1			6.36			1			10.35			1		
08/13/19 7:08	424281			1			6.18			1			10.06			1		
08/13/19 7:09	423510.8			1			5.99			1			9.74			1		
08/13/19 7:10	423356.8			0.9			5.81			0.91			9.44			1		
08/13/19 7:11	423125.8			0.9			5.81			0.91			9.43			1		
08/13/19 7:12	422509.6			0.9			5.72			0.91			9.27			1		
08/13/19 7:13	422740.7			0.9			5.72			0.91			9.28			1		
08/13/19 7:14	422509.6			0.8			5.62			0.82			9.12			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/13/19 7:15	422663.7			0.8			5.62			0.82			9.12			1		
08/13/19 7:16	422432.6			0.8			5.62			0.82			9.12			1		
08/13/19 7:17	422817.7			0.8			5.62			0.82			9.13			1		
08/13/19 7:18	422509.6			0.8			5.62			0.82			9.12			1		
08/13/19 7:19	422124.5			0.8			5.72			0.82			9.26			1		
08/13/19 7:20	421431.4			0.8			5.72			0.82			9.25			1		
08/13/19 7:21	421739.5			0.8			5.81			0.82			9.4			1		
08/13/19 7:22	421046.3			0.8			5.81			0.81			9.39			1		
08/13/19 7:23	422355.6			0.8			5.81			0.82			9.42			1		
08/13/19 7:24	421739.5			0.8			3.6			0.82			5.82			1		
08/13/19 7:25	422047.5			0.8			2.67			0.82			4.33			1		
08/13/19 7:26	421662.4			0.8			2.12			0.82			3.43			1		
08/13/19 7:27	421123.3			0.8			2.12			0.81			3.43			1		
08/13/19 7:28	420815.3			0.8			2.21			0.81			3.57			1		
08/13/19 7:29	420969.3			0.8			2.21			0.81			3.58			1		
08/13/19 7:30	421123.3			0.8			2.3			0.81			3.73			1		
08/13/19 7:31	421354.4			0.7			2.3			0.72			3.73			1		
08/13/19 7:32	421893.5			0.7			2.3			0.73			3.73			1		
08/13/19 7:33	421354.4			0.8			2.21			0.82			3.58			1		

CT1 SUSD EVENT 4

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/17/19 22:52	402793.5			1.2			1.66			1.13			2.57			0		
08/17/19 22:53	381768.2			0.9			1.66			0.82			2.43			0		
08/17/19 22:54	360126.7			0.8			1.72			0.69			2.38			0		
08/17/19 22:55	335943.7			0.8			2.06			0.63			2.65			0		
08/17/19 22:56	312453.8			0.8			2.11			0.58			2.54			0		
08/17/19 22:57	290581.3			0.9			2.03			0.6			2.26			1		
08/17/19 22:58	273252.7			0.9			1.88			0.57			1.97			1		
08/17/19 22:59	252535.4			0.8			2.18			0.48			2.11			1		
08/17/19 23:00	229892.7			0.7			6.37			0.35			5.62			1		
08/17/19 23:01	207404			0.6			12.6			0.29			10.03			1		
08/17/19 23:02	183144			0.5			17.26			0.23			12.13			1		
08/17/19 23:03	160501.3			5.5			19.79			2.07			12.19			1		
08/17/19 23:04	141863.4			337.6			21.35			111.68			11.63			1		
08/17/19 23:05	103355.4			1333.6			22.16			321.5			8.79			1		
08/17/19 23:06	0			0			23.05			0			0			0		
08/17/19 23:07	0			0			35.4			0			0			0		
08/17/19 23:08	0			0			0.1			0			0			0		
08/17/19 23:09	0			0			0.1			0			0			0		
08/17/19 23:10	0			0			0.1			0			0			0		

CT1 SUSD EVENT 5

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/27/19 5:39	0			0			0			0			0			0		
08/27/19 5:40	0			0			0			0			0			0		
08/27/19 5:41	0			0			0			0			0			0		
08/27/19 5:42	0			0			0			0			0			0		
08/27/19 5:43	0			0			0			0			0			0		
08/27/19 5:44	0			0.2			0			0			0			1		
08/27/19 5:45	7932.6			0.2			0			0			0			1		
08/27/19 5:46	32346.7			85.6			30.98			6.45			3.85			1		
08/27/19 5:47	48443			510			17.7			57.65			3.29			1		
08/27/19 5:48	68621.2			333.9			23.01			53.45			6.06			1		
08/27/19 5:49	114907.8			185.9			26.01			49.8			11.47			1		
08/27/19 5:50	135394.1			77.8			43.57			24.58			22.65			1		
08/27/19 5:51	142941.6			241.5			53.65			80.5			29.43			1		
08/27/19 5:52	160347.3			1849.9			42.02			691.96			25.86			1		
08/27/19 5:53	182527.9			1384.4			51.46			589.4			36.06			1		
08/27/19 5:54	206633.9			289.8			66.2			139.68			52.5			1		
08/27/19 5:55	228737.4			20.7			72.06			11.05			63.26			1		
08/27/19 5:56	252612.4			2.4			67.68			1.44			65.63			1		
08/27/19 5:57	277411.5			2			55.54			1.32			59.15			1		
08/27/19 5:58	292891.8			1.9			35.85			1.3			40.31			1		
08/27/19 5:59	293970			1.9			16.73			1.33			18.88			1		
08/27/19 6:00	296588.5			2			13.65			1.4			15.54			1		
08/27/19 6:01	314379.2			1.9			12.69			1.38			15.32			1		
08/27/19 6:02	319231.2			1.8			12.24			1.31			15			1		
08/27/19 6:03	319154.2			1.7			10.66			1.25			13.06			1		
08/27/19 6:04	318615.1			1.6			9.77			1.18			11.96			1		
08/27/19 6:05	318384			1.5			8.98			1.11			10.98			1		
08/27/19 6:06	317382.8			1.4			8.58			1.06			10.46			1		
08/27/19 6:07	315842.5			1.3			7.78			0.99			9.43			1		
08/27/19 6:08	316227.6			1.3			7.6			0.92			9.22			1		
08/27/19 6:09	315919.5			1.2			7.51			0.86			9.11			1		
08/27/19 6:10	315996.5			1.2			7.33			0.86			8.89			1		
08/27/19 6:11	315688.5			1.1			7.24			0.79			8.77			1		
08/27/19 6:12	315380.4			1.1			7.06			0.79			8.55			1		
08/27/19 6:13	316150.6			1.1			7.08			0.8			8.59			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/27/19 6:14	331091.7			1.1			6.99			0.84			8.88			1		
08/27/19 6:15	339255.3			1			6.44			0.79			8.39			1		
08/27/19 6:16	340795.7			0.9			6.18			0.73			8.08			1		
08/27/19 6:17	341411.8			0.9			6.27			0.73			8.21			1		
08/27/19 6:18	341565.8			0.9			6.36			0.73			8.34			1		
08/27/19 6:19	341950.9			0.9			6.45			0.74			8.47			1		
08/27/19 6:20	341950.9			0.9			6.64			0.74			8.71			1		
08/27/19 6:21	341488.8			0.8			6.73			0.66			8.82			1		
08/27/19 6:22	337792.1			0.8			6.91			0.65			8.97			1		
08/27/19 6:23	320694.5			0.8			7.1			0.62			8.74			1		
08/27/19 6:24	308294.9			0.9			7.9			0.65			9.34			1		
08/27/19 6:25	307370.8			0.9			7.87			0.64			9.28			1		
08/27/19 6:26	307370.8			0.9			8.08			0.65			9.53			1		
08/27/19 6:27	307062.7			0.9			8.26			0.65			9.74			1		
08/27/19 6:28	307139.7			0.9			8.35			0.65			9.84			1		
08/27/19 6:29	307062.7			0.9			6.72			0.65			7.92			1		
08/27/19 6:30	307216.7			0.9			3.54			0.65			4.17			1		
08/27/19 6:31	307139.7			0.9			3			0.65			3.53			1		
08/27/19 6:32	306831.6			0.9			3			0.65			3.53			1		
08/27/19 6:33	306831.6			0.9			3			0.65			3.53			1		
08/27/19 6:34	306831.6			0.9			3.27			0.65			3.85			1		
08/27/19 6:35	305830.4			0.9			3.54			0.65			4.16			1		
08/27/19 6:36	303211.9			0.9			3.63			0.64			4.23			1		
08/27/19 6:37	302595.8			0.9			3.18			0.64			3.69			1		
08/27/19 6:38	299669.2			0.9			2.81			0.63			3.24			1		
08/27/19 6:39	298899			0.8			2.63			0.57			3.02			1		

CT1 SUSD EVENT 6

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/29/19 22:50	312607.8			0.8			1.7			0.59			2.04			0		
08/29/19 22:51	312992.9			0.8			1.7			0.59			2.04			0		
08/29/19 22:52	313378			0.8			1.7			0.59			2.04			0		
08/29/19 22:53	313069.9			0.8			1.7			0.59			2.04			0		
08/29/19 22:54	313069.9			0.8			1.7			0.59			2.04			0		
08/29/19 22:55	313069.9			0.8			1.7			0.59			2.04			1		
08/29/19 22:56	301517.5			0.8			1.7			0.57			1.97			1		
08/29/19 22:57	279953.1			0.8			1.7			0.53			1.83			1		
08/29/19 22:58	259235.8			0.8			2			0.49			1.99			1		
08/29/19 22:59	236439			0.7			5.53			0.41			5.02			1		
08/29/19 23:00	215490.7			0.6			9.05			0.3			7.48			1		

CT1 SUSD EVENT 7

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/04/19 5:39	0			0			0			0			0			0		
09/04/19 5:40	0			0			0			0			0			0		
09/04/19 5:41	0			0			0			0			0			0		
09/04/19 5:42	0			0			0			0			0			0		
09/04/19 5:43	0			0			0			0			0			0		
09/04/19 5:44	0			0.3			0			0			0			1		
09/04/19 5:45	0			0.3			0			0			0			1		
09/04/19 5:46	4004.8			1.1			0.2			0			0			1		
09/04/19 5:47	30190.3			645.8			20.38			45.54			2.37			1		
09/04/19 5:48	46748.7			488.8			18.63			53.28			3.34			1		
09/04/19 5:49	80250.6			314.8			24.49			58.9			7.54			1		
09/04/19 5:50	128308.6			178.3			26.28			53.37			12.95			1		
09/04/19 5:51	136087.2			73.1			45.09			23.21			23.56			1		
09/04/19 5:52	153569.8			970.6			46.28			347.61			27.28			1		
09/04/19 5:53	174441.2			1817.2			44.42			739.51			29.75			1		
09/04/19 5:54	197160.9			723.3			57.49			332.55			43.5			1		
09/04/19 5:55	221652			79.9			67.58			41.32			57.51			1		
09/04/19 5:56	242215.2			5.7			66.55			3.2			61.88			1		
09/04/19 5:57	269632.9			2.8			58.89			1.79			60.97			1		
09/04/19 5:58	292275.6			2.7			42.54			1.82			47.73			1		
09/04/19 5:59	311991.7			2.7			24.3			1.99			29.11			1		
09/04/19 6:00	330937.6			3			14.75			2.28			18.74			1		
09/04/19 6:01	348266.2			3.1			13.54			2.54			18.1			1		
09/04/19 6:02	366056.9			3.3			10.66			2.78			14.97			1		
09/04/19 6:03	388853.7			3.4			9.08			3.13			13.55			1		
09/04/19 6:04	412343.5			3.5			8.2			3.37			12.99			1		
09/04/19 6:05	428131.8			3.6			7.01			3.59			11.51			1		
09/04/19 6:06	423433.8			3.7			7.38			3.64			11.99			1		
09/04/19 6:07	421970.5			4			6.36			3.9			10.3			1		
09/04/19 6:08	421277.4			4.1			6.18			4.08			9.99			1		
09/04/19 6:09	420969.3			4.1			6.08			4.07			9.83			1		
09/04/19 6:10	420276.2			4.1			5.9			3.98			9.52			1		
09/04/19 6:11	420507.2			4.1			5.9			3.98			9.52			1		
09/04/19 6:12	420430.2			4.1			5.9			3.98			9.52			1		
09/04/19 6:13	420661.3			3.8			5.9			3.71			9.53			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/04/19 6:14	422278.6			3.6			5.9			3.51			9.56			1		
09/04/19 6:15	424281			3.3			5.81			3.24			9.46			1		
09/04/19 6:16	424897.1			3.1			5.72			3.11			9.32			1		
09/04/19 6:17	425205.2			3.2			5.81			3.2			9.48			1		
09/04/19 6:18	425282.2			3.3			5.9			3.29			9.63			1		
09/04/19 6:19	425821.3			3.2			5.9			3.2			9.64			1		
09/04/19 6:20	425898.3			3			5.99			2.93			9.8			1		
09/04/19 6:21	425821.3			3			6.08			2.93			9.95			1		
09/04/19 6:22	426283.4			3			6.18			2.93			10.11			1		
09/04/19 6:23	425898.3			2.8			5.53			2.75			9.04			1		
09/04/19 6:24	425744.3			2.4			2.95			2.38			4.82			1		
09/04/19 6:25	425205.2			2.2			2.12			2.19			3.46			1		
09/04/19 6:26	426052.3			2.3			2.12			2.29			3.47			1		
09/04/19 6:27	425898.3			2.5			2.12			2.47			3.47			1		
09/04/19 6:28	425513.3			2.6			2.4			2.56			3.92			1		
09/04/19 6:29	424974.1			2.8			2.86			2.74			4.66			1		
09/04/19 6:30	425205.2			2.9			2.86			2.83			4.67			1		
09/04/19 6:31	424589.1			3.1			2.77			3.1			4.51			1		

CT1 SUSD EVENT 8

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/05/19 22:51	355582.8			0.8			1.66			0.69			2.26			0		
09/05/19 22:52	342027.9			0.8			1.75			0.66			2.3			0		
09/05/19 22:53	330013.4			0.8			1.82			0.63			2.3			0		
09/05/19 22:54	313840.1			0.9			1.82			0.66			2.19			0		
09/05/19 22:55	298976			0.9			1.79			0.62			2.05			0		
09/05/19 22:56	278566.8			0.9			1.82			0.59			1.94			1		
09/05/19 22:57	256694.2			0.8			1.75			0.5			1.73			1		
09/05/19 22:58	233666.5			0.8			4.19			0.41			3.76			1		
09/05/19 22:59	214797.5			0.7			8.46			0.34			6.97			1		
09/05/19 23:00	187996			0.5			15.07			0.23			10.87			1		
09/05/19 23:01	164891.2			2.8			18.41			1.09			11.65			1		
09/05/19 23:02	145560.2			146.7			20.52			49.81			11.47			1		
09/05/19 23:03	107206.2			1146.2			20.96			286.58			8.63			1		
09/05/19 23:04	0			0			22.71			0			0			0		
09/05/19 23:05	0			0			26.55			0			0			0		
09/05/19 23:06	0			0			0.2			0			0			0		
09/05/19 23:07	0			0			0.2			0			0			0		
09/05/19 23:08	0			0			0.1			0			0			0		

CT1 SUSD EVENT 9

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/11/19 8:40	0			0			0			0			0			0		
09/11/19 8:41	0			0			0			0			0			0		
09/11/19 8:42	0			0			0			0			0			0		
09/11/19 8:43	0			0			0			0			0			0		
09/11/19 8:44	0			0			0			0			0			0		
09/11/19 8:45	0			0.2			0			0			0			1		
09/11/19 8:46	0			0.2			0			0			0			1		
09/11/19 8:47	19485			129.8			64.9			5.93			4.88			1		
09/11/19 8:48	40664.4			588.9			17.7			56.16			2.78			1		
09/11/19 8:49	59225.3			427			21.43			59.26			4.89			1		
09/11/19 8:50	101045			240.8			25.57			57.02			9.96			1		
09/11/19 8:51	136472.3			121.4			36.88			38.85			19.41			1		
09/11/19 8:52	140862.2			57.8			53.49			19.09			29.07			1		
09/11/19 8:53	160347.3			1535.1			41.48			576.95			25.66			1		
09/11/19 8:54	181988.8			1551.4			46.36			661.54			32.53			1		
09/11/19 8:55	206787.9			356.2			61.21			172.63			48.82			1		
09/11/19 8:56	229507.6			29.4			67.85			15.8			60.06			1		
09/11/19 8:57	252304.3			2.6			65.92			1.54			64.16			1		
09/11/19 8:58	277796.6			1.8			55.54			1.19			59.52			1		
09/11/19 8:59	300362.3			1.8			37.06			1.23			42.94			1		
09/11/19 9:00	312453.8			1.8			18.13			1.33			21.85			1		
09/11/19 9:01	313609			2			14.23			1.47			17.21			1		
09/11/19 9:02	318692.1			1.9			13.19			1.43			16.21			1		
09/11/19 9:03	320309.4			1.7			11.54			1.3			14.26			1		
09/11/19 9:04	316227.6			1.6			10.06			1.22			12.28			1		
09/11/19 9:05	314379.2			1.6			9.16			1.17			11.11			1		
09/11/19 9:06	315149.3			1.5			8.37			1.11			10.17			1		
09/11/19 9:07	314610.3			1.4			7.66			1.04			9.3			1		
09/11/19 9:08	314456.2			1.3			7.31			0.97			8.86			1		
09/11/19 9:09	314148.2			1.3			6.88			0.92			8.34			1		
09/11/19 9:10	312684.8			1.2			6.79			0.85			8.19			1		
09/11/19 9:11	312145.8			1.2			6.62			0.85			7.96			1		
09/11/19 9:12	312376.8			1.1			6.44			0.79			7.76			1		
09/11/19 9:13	312453.8			1.1			6.35			0.79			7.65			1		
09/11/19 9:14	311221.5			1.1			6.26			0.78			7.51			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/11/19 9:15	310836.5			1			6.26			0.72			7.5			1		
09/11/19 9:16	310990.5			1			6.26			0.72			7.51			1		
09/11/19 9:17	311067.5			1			6.26			0.73			7.51			1		
09/11/19 9:18	310836.5			0.9			6.17			0.65			7.39			1		
09/11/19 9:19	310759.4			0.9			6.17			0.65			7.39			1		
09/11/19 9:20	310374.4			0.9			6.35			0.66			7.61			1		
09/11/19 9:21	310836.5			0.9			6.35			0.66			7.62			1		
09/11/19 9:22	310836.5			0.9			6.35			0.66			7.62			1		
09/11/19 9:23	303519.9			0.9			6.44			0.65			7.55			1		
09/11/19 9:24	288039.8			0.9			6.72			0.61			7.46			1		
09/11/19 9:25	285960.3			0.8			6.36			0.56			7.02			1		
09/11/19 9:26	285421.2			0.8			6.27			0.55			6.9			1		
09/11/19 9:27	286114.3			0.7			6.18			0.49			6.82			1		
09/11/19 9:28	286191.3			0.7			6.37			0.5			7.03			1		
09/11/19 9:29	285498.2			0.7			4.78			0.5			5.26			1		
09/11/19 9:30	285652.3			0.7			3.18			0.5			3.51			1		
09/11/19 9:31	285883.3			0.7			2.81			0.5			3.1			1		
09/11/19 9:32	285498.2			0.7			2.62			0.5			2.89			1		
09/11/19 9:33	285575.2			0.7			2.43			0.5			2.68			1		
09/11/19 9:34	285575.2			0.7			2.43			0.5			2.68			1		
09/11/19 9:35	285344.2			0.7			2.43			0.5			2.68			1		
09/11/19 9:36	285575.2			0.7			2.43			0.5			2.68			1		
09/11/19 9:37	285575.2			0.7			2.43			0.5			2.68			1		
09/11/19 9:38	285421.2			0.7			2.34			0.5			2.58			1		
09/11/19 9:39	285806.3			0.7			2.25			0.5			2.48			1		
09/11/19 9:40	285267.2			0.7			2.15			0.5			2.37			1		
09/11/19 9:41	285344.2			0.7			2.06			0.5			2.27			1		
09/11/19 9:42	284497			0.7			1.87			0.5			2.06			1		
09/11/19 9:43	284882.1			0.7			1.78			0.5			1.96			1		
09/11/19 9:44	284574			0.7			1.69			0.5			1.85			0		
09/11/19 9:45	285036.1			0.7			1.69			0.5			1.85			0		
09/11/19 9:46	284959.1			0.7			1.69			0.5			1.85			0		
09/11/19 9:47	285113.1			0.7			1.59			0.5			1.75			0		
09/11/19 9:48	285036.1			0.7			1.59			0.5			1.75			0		

CT1 SUSD EVENT 10

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/12/19 11:46	355582.8			0.8			1.72			0.68			2.37			0		
09/12/19 11:47	355428.7			0.8			1.72			0.68			2.36			0		
09/12/19 11:48	354966.6			0.8			1.72			0.68			2.36			0		
09/12/19 11:49	355120.7			0.8			1.72			0.68			2.36			0		
09/12/19 11:50	354735.6			0.8			1.72			0.68			2.36			0		
09/12/19 11:51	346186.8			0.8			1.72			0.66			2.3			1		
09/12/19 11:52	327086.8			0.8			1.72			0.63			2.18			1		
09/12/19 11:53	304444.1			0.8			1.88			0.57			2.2			1		
09/12/19 11:54	282879.7			0.9			2.41			0.59			2.63			1		
09/12/19 11:55	262162.4			0.8			2.45			0.5			2.48			1		
09/12/19 11:56	238210.4			0.7			5.15			0.42			4.73			1		
09/12/19 11:57	218032.2			0.7			9.44			0.35			7.94			1		
09/12/19 11:58	193079			0.5			16.75			0.24			12.48			1		
09/12/19 11:59	170975.5			3			19.59			1.18			12.92			1		
09/12/19 12:00	151028.3			187.6			21.32			66.39			12.42			1		
09/12/19 12:01	133930.8			1251.4			21.74			392.74			11.23			1		
09/12/19 12:02	30729.4			1886.2			22.53			135.96			2.67			1		
09/12/19 12:03	20563.3			0			22.42			146.4			1.78			0		
09/12/19 12:04	19562.1			0			0.2			0			0			0		
09/12/19 12:05	18329.8			0			0.1			0			0			0		
09/12/19 12:06	17482.6			0			0.1			0			0			0		
09/12/19 12:07	16866.5			0			0.1			0			0			0		

CT1 SUSD EVENT 11

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/24/19 7:38	0			0			0			0			0			0		
09/24/19 7:39	0			0			0			0			0			0		
09/24/19 7:40	0			0			0			0			0			0		
09/24/19 7:41	0			0			0			0			0			0		
09/24/19 7:42	0			0			0			0			0			0		
09/24/19 7:43	0			0.2			0			0			0			1		
09/24/19 7:44	0			0			0			0			0			0		
09/24/19 7:45	0			0			0			0			0			0		
09/24/19 7:46	0			0			0			0			0			0		
09/24/19 7:47	0			0			0			0			0			0		
09/24/19 7:48	0			0			0			0			0			0		

CT1 SUSD EVENT 11

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/24/19 7:38	0			0			0			0			0			0		
09/24/19 7:39	0			0			0			0			0			0		
09/24/19 7:40	0			0			0			0			0			0		
09/24/19 7:41	0			0			0			0			0			0		
09/24/19 7:42	0			0			0			0			0			0		
09/24/19 7:43	0			0.2			0			0			0			1		
09/24/19 7:44	0			0			0			0			0			0		
09/24/19 7:45	0			0			0			0			0			0		
09/24/19 7:46	0			0			0			0			0			0		
09/24/19 7:47	0			0			0			0			0			0		
09/24/19 7:48	0			0			0			0			0			0		

CT1 SUSD EVENT 13

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/24/19 7:51	0			0			0			0			0			0		
09/24/19 7:52	0			0			0			0			0			0		
09/24/19 7:53	0			0			0			0			0			0		
09/24/19 7:54	0			0			0			0			0			0		
09/24/19 7:55	0			0			0			0			0			0		
09/24/19 7:56	0			0.2			0			0			0			1		
09/24/19 7:57	0			0.2			0			0			0			1		
09/24/19 7:58	5853.2			1.6			0.1			0			0			1		
09/24/19 7:59	31807.6			690.9			23.01			51.5			2.82			1		
09/24/19 8:00	49675.3			491.6			19.56			57.22			3.75			1		
09/24/19 8:01	82869.2			306.8			25.96			59.61			8.3			1		
09/24/19 8:02	128924.7			162.1			31.81			48.99			15.82			1		
09/24/19 8:03	136626.3			62			52.05			19.84			27.44			1		
09/24/19 8:04	142864.6			846.2			45.23			283.37			24.93			1		
09/24/19 8:05	153723.9			1891.8			38.44			681.35			22.79			1		
09/24/19 8:06	174056.1			1783.3			40.79			727.32			27.38			1		
09/24/19 8:07	198085.1			709.2			52.95			329.26			40.46			1		
09/24/19 8:08	221343.9			70.5			63.56			36.58			54.25			1		
09/24/19 8:09	242677.3			5.3			65.37			3.02			61.19			1		
09/24/19 8:10	270326.1			2.3			59.32			1.47			61.84			1		
09/24/19 8:11	292121.6			2.2			43.2			1.5			48.67			1		
09/24/19 8:12	308834.1			2.1			23.07			1.53			27.48			1		
09/24/19 8:13	305830.4			2.2			14.06			1.55			16.58			1		
09/24/19 8:14	292583.7			2.1			13.28			1.43			14.98			1		
09/24/19 8:15	290427.2			1.9			10.74			1.32			12.04			1		
09/24/19 8:16	290273.2			1.8			9.3			1.22			10.41			1		
09/24/19 8:17	289888.1			1.6			8.85			1.09			9.9			1		
09/24/19 8:18	292583.7			1.5			8.08			1			9.12			1		
09/24/19 8:19	311991.7			1.4			7.35			1			8.85			1		
09/24/19 8:20	327086.8			1.3			7.26			0.97			9.16			1		
09/24/19 8:21	329705.4			1.2			6.62			0.9			8.41			1		
09/24/19 8:22	330013.4			1.2			6.44			0.91			8.2			1		
09/24/19 8:23	329936.4			1.2			6.44			0.9			8.19			1		
09/24/19 8:24	333402.2			1.1			6.44			0.84			8.28			1		
09/24/19 8:25	342413			1.1			6.26			0.87			8.27			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/24/19 8:26	344107.4			1			5.81			0.81			7.71			1		
09/24/19 8:27	344184.4			1			5.9			0.82			7.83			1		
09/24/19 8:28	343876.3			1			5.99			0.82			7.95			1		
09/24/19 8:29	345031.6			0.9			5.9			0.73			7.85			1		
09/24/19 8:30	345185.6			0.9			5.99			0.75			7.98			1		
09/24/19 8:31	345416.6			0.9			5.99			0.75			7.98			1		
09/24/19 8:32	345878.7			0.9			6.08			0.75			8.12			1		
09/24/19 8:33	347188			0.9			6.18			0.75			8.27			1		
09/24/19 8:34	347573.1			0.8			6.27			0.68			8.4			1		
09/24/19 8:35	338947.3			0.8			6.64			0.66			8.68			1		
09/24/19 8:36	334480.4			0.9			6.81			0.71			8.78			1		
09/24/19 8:37	332015.8			0.9			6.81			0.71			8.72			1		
09/24/19 8:38	331168.7			0.9			6.9			0.7			8.81			1		
09/24/19 8:39	331245.7			0.9			6.9			0.7			8.81			1		
09/24/19 8:40	330552.6			0.9			4.54			0.7			5.79			1		
09/24/19 8:41	331245.7			0.9			2.81			0.7			3.59			1		
09/24/19 8:42	326855.8			0.9			2.72			0.7			3.43			1		
09/24/19 8:43	322851			0.8			2.72			0.62			3.39			1		
09/24/19 8:44	322465.9			0.9			2.81			0.69			3.5			1		
09/24/19 8:45	322773.9			0.9			3			0.69			3.73			1		
09/24/19 8:46	322851			0.9			3.09			0.69			3.84			1		
09/24/19 8:47	322928			0.9			2.9			0.69			3.62			1		
09/24/19 8:48	321079.6			0.9			2.72			0.68			3.37			1		
09/24/19 8:49	320771.5			0.9			2.54			0.68			3.14			1		
09/24/19 8:50	320309.4			0.9			2.27			0.68			2.8			1		
09/24/19 8:51	320078.4			0.9			2.09			0.68			2.58			1		
09/24/19 8:52	319462.3			0.9			1.91			0.68			2.35			1		
09/24/19 8:53	319000.2			0.9			1.82			0.68			2.23			1		
09/24/19 8:54	319154.2			0.8			1.72			0.61			2.12			1		
09/24/19 8:55	319231.2			0.8			1.63			0.61			2.01			0		
09/24/19 8:56	319616.3			0.8			1.54			0.61			1.9			0		
09/24/19 8:57	319154.2			0.8			1.54			0.61			1.9			0		
09/24/19 8:58	319539.3			0.9			1.54			0.68			1.9			0		
09/24/19 8:59	319308.2			0.8			1.54			0.61			1.9			0		

CT1 SUSD EVENT 14

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/26/19 22:58	163967			3.2			19			1.22			12.02			1		
09/26/19 22:59	144019.9			228			20.92			76.95			11.62			1		
09/26/19 23:00	106128			1291			21.43			321.07			8.77			1		
09/26/19 23:01	0			0			23.42			0			0			0		
09/26/19 23:02	0			0			25.08			0			0			0		
09/26/19 23:03	0			0			0.1			0			0			0		
09/26/19 23:04	0			0			0.1			0			0			0		
09/26/19 23:05	0			0			0.1			0			0			0		

CT1 SUSD EVENT 15

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/30/19 6:39	0			0			0			0			0			0		
09/30/19 6:40	0			0			0			0			0			0		
09/30/19 6:41	0			0			0			0			0			0		
09/30/19 6:42	0			0			0			0			0			0		
09/30/19 6:43	0			0			0			0			0			0		
09/30/19 6:44	0			0.3			0			0			0			1		
09/30/19 6:45	0			0.3			0			0			0			1		
09/30/19 6:46	0			1.4			0.4			0			0			1		
09/30/19 6:47	24722.1			702.6			19.67			40.73			1.88			1		
09/30/19 6:48	48135			540.8			19.34			61.02			3.59			1		
09/30/19 6:49	85333.7			333.6			24.19			66.69			7.96			1		
09/30/19 6:50	130850.1			191.8			25.48			58.8			12.86			1		
09/30/19 6:51	139630			72			48.01			23.57			25.86			1		
09/30/19 6:52	155341.2			1143.3			45.73			416.13			27.39			1		
09/30/19 6:53	176289.6			1889.4			47.38			780.75			32.22			1		
09/30/19 6:54	200087.5			919.9			59.16			431.41			45.66			1		
09/30/19 6:55	223269.3			115.9			65.84			60.63			56.71			1		
09/30/19 6:56	242754.3			7.8			66.83			4.45			62.58			1		
09/30/19 6:57	271250.3			2.3			59.97			1.43			62.74			1		
09/30/19 6:58	295048.2			2			45.33			1.36			51.59			1		
09/30/19 6:59	313609			1.9			26.95			1.42			32.59			1		
09/30/19 7:00	333017.1			2.1			14.11			1.6			18.12			1		
09/30/19 7:01	351038.8			2.1			12.83			1.69			17.36			1		
09/30/19 7:02	367674.3			1.9			10.67			1.65			15.14			1		
09/30/19 7:03	390625			1.8			8.85			1.64			13.33			1		
09/30/19 7:04	411419.3			1.5			8.17			1.49			12.97			1		
09/30/19 7:05	419429			1.4			7.56			1.36			12.23			1		
09/30/19 7:06	420584.2			1.3			7.38			1.27			11.96			1		
09/30/19 7:07	420738.3			1.1			7.1			1.09			11.52			1		
09/30/19 7:08	420199.2			1.1			6.82			1.09			11.06			1		
09/30/19 7:09	420430.2			1.1			6.64			1.09			10.76			1		
09/30/19 7:10	420045.1			1.1			6.55			1.09			10.6			1		
09/30/19 7:11	418427.8			1			6.45			0.99			10.42			1		
09/30/19 7:12	417734.6			1			6.45			0.99			10.4			1		
09/30/19 7:13	417195.5			1			6.45			0.99			10.38			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/30/19 7:14	416887.5			1			6.45			0.99			10.38			1		
09/30/19 7:15	416425.4			1			6.36			0.99			10.22			1		
09/30/19 7:16	415886.3			1			6.36			0.99			10.2			1		
09/30/19 7:17	415732.2			0.9			6.27			0.9			10.05			1		
09/30/19 7:18	415347.1			0.9			6.27			0.9			10.04			1		
09/30/19 7:19	415347.1			0.9			6.36			0.9			10.19			1		
09/30/19 7:20	414654			0.9			6.45			0.9			10.32			1		
09/30/19 7:21	414345.9			0.9			6.55			0.9			10.46			1		
09/30/19 7:22	414345.9			0.9			6.64			0.9			10.61			1		
09/30/19 7:23	414422.9			0.8			5.44			0.81			8.69			1		
09/30/19 7:24	414500			0.8			2.86			0.81			4.57			1		
09/30/19 7:25	413960.8			0.8			2.4			0.8			3.83			1		
09/30/19 7:26	413806.8			0.8			2.3			0.8			3.68			1		
09/30/19 7:27	414191.9			0.8			2.77			0.81			4.42			1		
09/30/19 7:28	413575.8			0.8			3.13			0.8			5			1		
09/30/19 7:29	413806.8			0.8			3.13			0.8			5			1		
09/30/19 7:30	413267.7			0.8			3.04			0.8			4.85			1		
09/30/19 7:31	413344.7			0.8			2.49			0.8			3.97			1		
09/30/19 7:32	413267.7			0.8			2.21			0.8			3.53			1		
09/30/19 7:33	413190.7			0.8			2.12			0.8			3.38			1		
09/30/19 7:34	412882.6			0.8			2.03			0.8			3.23			1		
09/30/19 7:35	413036.7			0.8			1.84			0.8			2.94			1		
09/30/19 7:36	413267.7			0.8			1.84			0.8			2.94			1		
09/30/19 7:37	413036.7			0.8			1.75			0.8			2.79			0		
09/30/19 7:38	412574.6			0.8			1.75			0.8			2.79			0		
09/30/19 7:39	412728.6			0.8			1.66			0.8			2.64			0		
09/30/19 7:40	412343.5			0.8			1.66			0.8			2.64			0		
09/30/19 7:41	412574.6			0.8			1.66			0.8			2.64			0		

CT1 SUSD EVENT 16

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/30/19 11:58	215798.8			0.7			9.54			0.35			7.94			1		
09/30/19 11:59	190845.6			0.5			16.84			0.24			12.4			1		
09/30/19 12:00	167586.8			2.2			19.47			0.88			12.59			1		
09/30/19 12:01	147254.5			164.5			21.95			56.79			12.47			1		
09/30/19 12:02	120453			1107.2			21.89			312.52			10.17			1		
09/30/19 12:03	0			1892.6			22.53			0			0			1		
09/30/19 12:04	0			0			24.78			0			0			0		
09/30/19 12:05	0			0			0.2			0			0			0		
09/30/19 12:06	0			0			0.2			0			0			0		
09/30/19 12:07	0			0			0.1			0			0			0		
09/30/19 12:08	0			0			0.1			0			0			0		

Startup / Shutdown Events

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:07 **Location:** Roseville, CA

Unit Offline

Tag Name: CT2_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
07/01/2019 00:00	07/22/2019 11:00	516
07/23/2019 13:00	07/27/2019 21:00	105
08/08/2019 06:00	08/14/2019 05:00	144
08/17/2019 00:00	08/25/2019 06:00	199
08/30/2019 00:00	09/04/2019 05:00	126
09/06/2019 00:00	09/09/2019 21:00	94
09/11/2019 13:00	09/12/2019 07:00	19
09/13/2019 00:00	09/23/2019 06:00	247
09/28/2019 00:00	09/30/2019 09:00	58
09/30/2019 18:00	09/30/2019 23:00	6

Startup / Shutdown Events

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:07 **Location:** Roseville, CA

Operating Time Summary	
Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	1,514.00 Hour(s)
Offline Percentage:	68.57 %
Total Online:	694.00 Hour(s)
Online Percentage:	31.43 %

Startup / Shutdown Events

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:07 **Location:** Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	07/22/2019 12:55	07/22/2019 13:49	Cold Startup	55
2	07/23/2019 11:56	07/23/2019 12:04	Shutdown	9
3	07/27/2019 22:45	07/27/2019 23:33	Cold Startup	49
4	08/08/2019 04:55	08/08/2019 05:03	Shutdown	9
5	08/14/2019 06:44	08/14/2019 07:30	Cold Startup	47
6	08/16/2019 22:56	08/16/2019 23:04	Shutdown	9
7	08/25/2019 07:43	08/25/2019 08:29	Cold Startup	47
8	08/29/2019 22:57	08/29/2019 23:07	Shutdown	11
9	09/04/2019 06:46	09/04/2019 07:31	Cold Startup	46
10	09/05/2019 23:00	09/05/2019 23:08	Shutdown	9
11	09/09/2019 22:43	09/09/2019 23:36	Cold Startup	54
12	09/11/2019 11:52	09/11/2019 12:07	Shutdown	16
13	09/12/2019 08:45	09/12/2019 09:33	Cold Startup	49
14	09/12/2019 22:57	09/12/2019 23:05	Shutdown	9
15	09/23/2019 07:44	09/23/2019 08:34	Cold Startup	51
16	09/27/2019 22:55	09/27/2019 23:04	Shutdown	10
17	09/30/2019 10:45	09/30/2019 11:35	Cold Startup	51
18	09/30/2019 17:04	09/30/2019 17:13	Shutdown	10

Startup / Shutdown Events

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:07 **Location:** Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	9	449	1.10
Warm Startup	0		0.00
Shutdown	9	92	0.23
Total Process Events:	18	541	1.33

Total Report Time:	2,207.98 Hour(s)
Total Operating Time:	679.23 Hour(s)
Total Startup Time:	449 Minute(s)
Total Shutdown Time:	92 Minute(s)
Total Startup/Shutdown Time:	541 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	1.33 %

CT2 SUSD EVENT 1

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/22/19 12:50	0			0			0			0			0			0		
07/22/19 12:51	0			0			0			0			0			0		
07/22/19 12:52	0			0			0			0			0			0		
07/22/19 12:53	0			0			0			0			0			0		
07/22/19 12:54	4698			0			0			0			0			0		
07/22/19 12:55	0			0.2			0			0			0			1		
07/22/19 12:56	24645.1			0.2			0			0			0			1		
07/22/19 12:57	38122.9			1.3			0.3			0			0			1		
07/22/19 12:58	50676.5			454.3			18.54			53.69			3.61			1		
07/22/19 12:59	63153.1			365.2			19.67			53.8			4.77			1		
07/22/19 13:00	86951			212.9			23.87			43.18			7.97			1		
07/22/19 13:01	133930.8			110.6			30.98			34.57			15.93			1		
07/22/19 13:02	145175.1			35.8			46.81			12.12			26.09			1		
07/22/19 13:03	156188.4			17			44.25			6.19			26.52			1		
07/22/19 13:04	177752.9			1531.4			34.36			634.86			23.44			1		
07/22/19 13:05	203476.2			658.6			46.42			312.55			36.26			1		
07/22/19 13:06	228352.4			57.7			51.76			30.71			45.36			1		
07/22/19 13:07	253459.6			4.4			56.05			2.58			54.53			1		
07/22/19 13:08	279413.9			1.7			63.64			1.1			68.24			1		
07/22/19 13:09	304521.2			1.6			51.39			1.15			60.07			1		
07/22/19 13:10	315611.5			1.8			25.51			1.34			30.9			1		
07/22/19 13:11	314764.3			1.9			17.52			1.38			21.17			1		
07/22/19 13:12	313994.1			1.8			14.75			1.31			17.78			1		
07/22/19 13:13	313224			1.6			13.77			1.18			16.55			1		
07/22/19 13:14	312684.8			1.4			12.6			1.04			15.13			1		
07/22/19 13:15	312761.9			1.4			11.26			1.04			13.52			1		
07/22/19 13:16	312761.9			1.3			10.46			0.98			12.56			1		
07/22/19 13:17	311298.6			1.3			9.62			0.92			11.5			1		
07/22/19 13:18	312376.8			1.2			9.08			0.86			10.88			1		
07/22/19 13:19	311683.6			1.1			8.71			0.79			10.43			1		
07/22/19 13:20	309681.2			1			8.35			0.72			9.93			1		
07/22/19 13:21	311144.5			1			8.08			0.72			9.65			1		
07/22/19 13:22	311298.6			0.9			7.9			0.66			9.44			1		
07/22/19 13:23	308603			0.9			7.72			0.65			9.14			1		
07/22/19 13:24	309373.2			0.8			7.62			0.59			9.06			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/22/19 13:25	309296.2			0.9			7.53			0.65			8.95			1		
07/22/19 13:26	307293.7			0.9			7.65			0.66			9.03			1		
07/22/19 13:27	307986.9			0.9			7.74			0.66			9.15			1		
07/22/19 13:28	309681.2			0.8			7.74			0.6			9.21			1		
07/22/19 13:29	309065.1			0.8			7.84			0.6			9.3			1		
07/22/19 13:30	308063.9			0.8			7.93			0.6			9.38			1		
07/22/19 13:31	308371.9			0.8			7.93			0.6			9.38			1		
07/22/19 13:32	307293.7			0.8			7.93			0.59			9.35			1		
07/22/19 13:33	307293.7			0.7			7.93			0.53			9.35			1		
07/22/19 13:34	308757			0.7			8.02			0.53			9.51			1		
07/22/19 13:35	306985.7			0.7			8.11			0.53			9.56			1		
07/22/19 13:36	307447.8			0.7			8.2			0.53			9.68			1		
07/22/19 13:37	306600.6			0.7			8.3			0.53			9.77			1		
07/22/19 13:38	306677.6			0.7			8.39			0.53			9.88			1		
07/22/19 13:39	306831.6			0.7			6.45			0.53			7.6			1		
07/22/19 13:40	306523.6			0.7			3.69			0.53			4.34			1		
07/22/19 13:41	307909.8			0.7			3.32			0.53			3.92			1		
07/22/19 13:42	307524.8			0.7			2.95			0.53			3.48			1		
07/22/19 13:43	305522.4			0.7			2.67			0.53			3.14			1		
07/22/19 13:44	305676.4			0.7			2.4			0.53			2.81			1		

CT2 SUSD EVENT 2

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/23/19 11:51	426437.4			0.8			1.66			0.83			2.72			0		
07/23/19 11:52	404487.9			0.8			1.59			0.8			2.47			0		
07/23/19 11:53	381152			0.7			1.57			0.66			2.29			0		
07/23/19 11:54	354350.5			0.8			1.43			0.66			1.95			0		
07/23/19 11:55	327548.9			0.9			1.34			0.68			1.69			0		
07/23/19 11:56	306446.6			0.9			1.32			0.63			1.55			1		
07/23/19 11:57	284034.9			0.9			1.27			0.6			1.39			1		
07/23/19 11:58	261623.3			0.8			1.97			0.51			1.98			1		
07/23/19 11:59	239981.8			0.7			5.61			0.38			5.17			1		
07/23/19 12:00	213488.3			0.6			9.83			0.31			8.06			1		
07/23/19 12:01	188073			0.6			17.59			0.25			12.7			1		
07/23/19 12:02	163350.9			8.6			20.01			3.27			12.55			1		
07/23/19 12:03	145098.1			621.4			22.57			210.32			12.57			1		
07/23/19 12:04	61381.7			1598.9			25.12			229.06			5.92			1		
07/23/19 12:05	0			0			25.96			0			0			0		
07/23/19 12:06	0			0			11.8			0			0			0		
07/23/19 12:07	0			0			0.1			0			0			0		
07/23/19 12:08	0			0			0.1			0			0			0		
07/23/19 12:09	0			0			0.1			0			0			0		

CT2 SUSD EVENT 3

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/27/19 22:40	0			0			0			0			0			0		
07/27/19 22:41	0			0			0			0			0			0		
07/27/19 22:42	0			0			0			0			0			0		
07/27/19 22:43	0			0			0			0			0			0		
07/27/19 22:44	21025.4			0			0			0			0			0		
07/27/19 22:45	17020.5			0.4			0			0			0			1		
07/27/19 22:46	35042.3			0.4			0			0			0			1		
07/27/19 22:47	47595.9			45.5			22.76			5.05			4.16			1		
07/27/19 22:48	58532.1			440.4			17.11			60.14			3.85			1		
07/27/19 22:49	74859.5			287.7			23.04			50.23			6.62			1		
07/27/19 22:50	120684			160.1			25.14			45.04			11.64			1		
07/27/19 22:51	148332.8			64.7			40.86			22.38			23.27			1		
07/27/19 22:52	157420.6			108.3			51.67			39.77			31.22			1		
07/27/19 22:53	177906.9			1416.7			37.83			587.94			25.84			1		
07/27/19 22:54	201627.8			881.5			48.95			414.57			37.89			1		
07/27/19 22:55	227274.1			135.3			58.04			71.71			50.63			1		
07/27/19 22:56	251072.1			7			61.65			4.09			59.41			1		
07/27/19 22:57	276641.4			2			66.51			1.32			70.64			1		
07/27/19 22:58	304829.2			1.8			55.03			1.31			64.39			1		
07/27/19 22:59	326855.8			1.8			31.91			1.36			40.04			1		
07/27/19 23:00	346032.8			1.9			18.05			1.56			23.98			1		
07/27/19 23:01	352579.1			1.9			16.38			1.59			22.17			1		
07/27/19 23:02	353349.3			1.8			13.8			1.5			18.71			1		
07/27/19 23:03	351809			1.8			13.36			1.5			18.05			1		
07/27/19 23:04	355890.8			1.7			11.63			1.44			15.88			1		
07/27/19 23:05	357585.2			1.6			9.89			1.37			13.58			1		
07/27/19 23:06	358047.3			1.6			9.33			1.32			12.83			1		
07/27/19 23:07	357739.2			1.5			8.98			1.25			12.34			1		
07/27/19 23:08	358047.3			1.4			8.28			1.18			11.38			1		
07/27/19 23:09	356121.8			1.3			8.1			1.1			11.08			1		
07/27/19 23:10	355967.8			1.3			7.96			1.11			10.87			1		
07/27/19 23:11	355890.8			1.3			7.66			1.1			10.47			1		
07/27/19 23:12	355197.7			1.2			7.57			1.02			10.33			1		
07/27/19 23:13	353965.4			1.3			7.6			1.03			10.32			1		
07/27/19 23:14	360819.8			1.3			7.6			1.05			10.53			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/27/19 23:15	376531.1			1.2			7.15			1.02			10.34			1		
07/27/19 23:16	382461.3			1.2			6.72			1.05			9.86			1		
07/27/19 23:17	384386.7			1.1			6.81			0.98			10.04			1		
07/27/19 23:18	385233.9			1			7.08			0.9			10.47			1		
07/27/19 23:19	380767			1			7.26			0.89			10.61			1		
07/27/19 23:20	370831.9			1.1			7.53			0.94			10.72			1		
07/27/19 23:21	367289.2			1			7.96			0.84			11.22			1		
07/27/19 23:22	366133.9			1			7.87			0.84			11.06			1		
07/27/19 23:23	366210.9			1			7.87			0.84			11.06			1		
07/27/19 23:24	366750.1			1			7.78			0.84			10.95			1		
07/27/19 23:25	366056.9			1			7.33			0.84			10.3			1		
07/27/19 23:26	365440.8			1			4.29			0.84			6.02			1		
07/27/19 23:27	366365			1.1			3.22			0.92			4.53			1		
07/27/19 23:28	366596			1.1			2.59			0.92			3.65			1		
07/27/19 23:29	366210.9			1.1			2.23			0.92			3.14			1		
07/27/19 23:30	366210.9			1.1			2.15			0.92			3.02			1		
07/27/19 23:31	366210.9			1.1			1.88			0.92			2.64			1		
07/27/19 23:32	365671.8			1.1			1.7			0.91			2.38			1		
07/27/19 23:33	365748.8			1.1			1.61			0.92			2.26			1		
07/27/19 23:34	365363.8			1.1			1.43			0.91			2.01			0		
07/27/19 23:35	364747.7			1			1.34			0.84			1.88			0		
07/27/19 23:36	364362.6			1			1.25			0.84			1.75			0		
07/27/19 23:37	365671.8			1			1.16			0.84			1.63			0		
07/27/19 23:38	365132.7			1			1.16			0.84			1.63			0		

CT2 SUSD EVENT 4

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/08/19 4:50	308217.9			0.8			1.66			0.6			1.96			0		
08/08/19 4:51	307909.8			0.8			1.75			0.6			2.07			0		
08/08/19 4:52	305676.4			0.8			1.75			0.59			2.06			0		
08/08/19 4:53	308834.1			0.8			1.75			0.6			2.08			0		
08/08/19 4:54	306138.5			0.8			1.75			0.59			2.06			0		
08/08/19 4:55	305214.3			0.8			1.66			0.59			1.94			1		
08/08/19 4:56	287269.6			0.8			1.57			0.56			1.73			1		
08/08/19 4:57	264472.8			0.8			3			0.52			3.04			1		
08/08/19 4:58	243909.6			0.8			7.54			0.44			7.06			1		
08/08/19 4:59	216877			0.7			13.83			0.36			11.52			1		
08/08/19 5:00	190229.5			1			17.13			0.45			12.51			1		
08/08/19 5:01	168202.9			9			19.5			3.52			12.59			1		
08/08/19 5:02	148717.8			636.9			22.27			220.98			12.72			1		
08/08/19 5:03	63076.1			1670			23.77			245.61			5.75			1		
08/08/19 5:04	0			0			25.46			0			0			0		
08/08/19 5:05	0			0			11.8			0			0			0		
08/08/19 5:06	0			0			0.1			0			0			0		
08/08/19 5:07	0			0			0.1			0			0			0		
08/08/19 5:08	0			0			0.1			0			0			0		

CT2 SUSD EVENT 5

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/14/19 6:39	0			0			0			0			0			0		
08/14/19 6:40	0			0			0			0			0			0		
08/14/19 6:41	0			0			0			0			0			0		
08/14/19 6:42	0			0			0			0			0			0		
08/14/19 6:43	0			0			0			0			0			0		
08/14/19 6:44	26647.5			0.3			0			0			0			1		
08/14/19 6:45	39740.2			1.2			0.1			0			0			1		
08/14/19 6:46	52062.8			506			18.61			61.39			3.72			1		
08/14/19 6:47	63538.2			471.1			17.7			69.81			4.32			1		
08/14/19 6:48	86951			309			23.04			62.68			7.69			1		
08/14/19 6:49	134855			177.5			24.88			55.83			12.88			1		
08/14/19 6:50	154571.1			72.1			42.78			25.99			25.39			1		
08/14/19 6:51	163273.9			381.8			45.29			145.36			28.38			1		
08/14/19 6:52	181911.7			1688.1			37.48			716.45			26.18			1		
08/14/19 6:53	204554.4			1049.1			45.76			500.43			35.93			1		
08/14/19 6:54	229430.6			186.7			55.02			99.95			48.46			1		
08/14/19 6:55	254460.8			10.8			58.52			6.43			57.15			1		
08/14/19 6:56	277026.4			2.7			62.39			1.77			66.35			1		
08/14/19 6:57	305830.4			2.3			54.08			1.61			63.5			1		
08/14/19 6:58	328011			2.2			34.77			1.71			43.79			1		
08/14/19 6:59	341103.8			2.4			18.76			1.89			24.56			1		
08/14/19 7:00	341334.8			2.4			16.4			1.93			21.49			1		
08/14/19 7:01	339332.4			2.3			14.49			1.79			18.88			1		
08/14/19 7:02	344492.4			2.2			12.86			1.77			17			1		
08/14/19 7:03	349421.5			2.1			11.54			1.72			15.47			1		
08/14/19 7:04	365440.8			2			10.04			1.73			14.08			1		
08/14/19 7:05	375915			2			8.22			1.72			11.87			1		
08/14/19 7:06	387390.3			1.8			7.62			1.64			11.34			1		
08/14/19 7:07	388622.6			1.6			7.35			1.48			10.97			1		
08/14/19 7:08	388391.6			1.5			7.35			1.4			10.96			1		
08/14/19 7:09	396786.3			1.5			7.17			1.34			10.92			1		
08/14/19 7:10	400560.1			1.4			7.1			1.29			10.92			1		
08/14/19 7:11	402716.5			1.4			6.91			1.3			10.69			1		
08/14/19 7:12	404025.8			1.3			7.19			1.22			11.15			1		
08/14/19 7:13	403024.6			1.2			7.28			1.13			11.27			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/14/19 7:14	403486.7			1.2			7.38			1.13			11.42			1		
08/14/19 7:15	401330.2			1.2			7.47			1.12			11.5			1		
08/14/19 7:16	402331.4			1.1			7.47			1.04			11.53			1		
08/14/19 7:17	400791.1			1.1			7.56			1.03			11.63			1		
08/14/19 7:18	399712.9			1.1			7.65			1.03			11.74			1		
08/14/19 7:19	400098			1.1			7.74			1.03			11.89			1		
08/14/19 7:20	400945.2			1.1			7.74			1.03			11.92			1		
08/14/19 7:21	401099.2			1.1			7.84			1.03			12.06			1		
08/14/19 7:22	399173.8			1.1			7.93			1.03			12.15			1		
08/14/19 7:23	399404.8			1.1			4.87			1.05			7.47			1		
08/14/19 7:24	398403.6			1.1			2.86			1.03			4.37			1		
08/14/19 7:25	398942.8			1.1			2.49			1.03			3.81			1		
08/14/19 7:26	399250.8			1.1			2.21			1.03			3.39			1		
08/14/19 7:27	398557.7			1			1.94			0.94			2.96			1		
08/14/19 7:28	399558.9			1			1.78			0.96			2.73			1		
08/14/19 7:29	397325.4			1.1			1.59			1.04			2.43			1		
08/14/19 7:30	390856.1			1			1.4			0.94			2.11			1		
08/14/19 7:31	377532.3			1			1.29			0.89			1.87			0		
08/14/19 7:32	374297.6			1			1.18			0.87			1.7			0		
08/14/19 7:33	368906.5			1			1.09			0.86			1.54			0		
08/14/19 7:34	365517.8			1.1			1.09			0.93			1.53			0		
08/14/19 7:35	365748.8			1.1			1			0.93			1.4			0		

CT2 SUSD EVENT 6

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/16/19 22:51	424435			1.5			1.57			1.46			2.55			0		
08/16/19 22:52	401176.2			1.3			1.57			1.21			2.41			0		
08/16/19 22:53	376531.1			1.1			1.63			0.96			2.36			0		
08/16/19 22:54	350730.8			1.1			1.7			0.88			2.29			0		
08/16/19 22:55	324853.4			1.1			1.76			0.8			2.2			0		
08/16/19 22:56	306600.6			1.1			1.76			0.76			2.07			1		
08/16/19 22:57	290581.3			1			1.72			0.68			1.92			1		
08/16/19 22:58	266321.2			0.9			2.95			0.57			3.02			1		
08/16/19 22:59	248145.5			0.9			7.04			0.5			6.71			1		
08/16/19 23:00	220188.7			0.8			15.9			0.41			13.44			1		
08/16/19 23:01	193618.2			0.8			20.54			0.35			15.27			1		
08/16/19 23:02	171360.5			5.4			22.62			2.16			14.88			1		
08/16/19 23:03	151952.5			485.1			25			171.88			14.58			1		
08/16/19 23:04	99196.6			1577.3			27.53			365.07			10.49			1		
08/16/19 23:05	0			0			29.5			0			0			0		
08/16/19 23:06	0			0			29.5			0			0			0		
08/16/19 23:07	0			0			0.2			0			0			0		
08/16/19 23:08	0			0			0.2			0			0			0		
08/16/19 23:09	0			0			0.1			0			0			0		

CT2 SUSD EVENT 7

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/25/19 7:38	0			0			0			0			0			0		
08/25/19 7:39	0			0			0			0			0			0		
08/25/19 7:40	0			0			0			0			0			0		
08/25/19 7:41	0			0			0			0			0			0		
08/25/19 7:42	45131.4			0			0			0			0			0		
08/25/19 7:43	11706.4			0.3			0			0			0			1		
08/25/19 7:44	30883.4			0.3			0			0			0			1		
08/25/19 7:45	45285.4			51.6			25.08			5.45			4.36			1		
08/25/19 7:46	57068.8			494.9			17.04			65.92			3.74			1		
08/25/19 7:47	71316.8			370.8			21.24			61.67			5.81			1		
08/25/19 7:48	108900.6			212.7			24.67			54.03			10.32			1		
08/25/19 7:49	149565			106.2			34.69			37.06			19.92			1		
08/25/19 7:50	150874.3			38.6			50.82			13.6			29.43			1		
08/25/19 7:51	169512.2			1054.3			40.94			416.78			26.64			1		
08/25/19 7:52	192771			1440.8			41.97			647.93			31.07			1		
08/25/19 7:53	217647.1			416.7			53.1			211.55			44.37			1		
08/25/19 7:54	243293.5			36.7			59.38			20.82			55.46			1		
08/25/19 7:55	265243			3			64.11			1.83			65.28			1		
08/25/19 7:56	293353.8			2.1			63.04			1.42			70.99			1		
08/25/19 7:57	315842.5			1.9			46.45			1.38			56.32			1		
08/25/19 7:58	318461			1.8			24.83			1.37			30.35			1		
08/25/19 7:59	316843.7			1.9			16.82			1.43			20.45			1		
08/25/19 8:00	322080.8			2			16.54			1.48			20.45			1		
08/25/19 8:01	342567			1.8			14.93			1.43			19.63			1		
08/25/19 8:02	361667			1.7			14.93			1.43			20.73			1		
08/25/19 8:03	371217			1.6			11.98			1.39			17.07			1		
08/25/19 8:04	386081.1			1.5			10.8			1.39			16.01			1		
08/25/19 8:05	402716.5			1.5			9.8			1.36			15.15			1		
08/25/19 8:06	419197.9			1.3			9.96			1.26			16.02			1		
08/25/19 8:07	441994.7			1.2			9.18			1.26			15.57			1		
08/25/19 8:08	445691.4			1.1			8.71			1.17			14.9			1		
08/25/19 8:09	447154.8			1.1			9.5			1.15			16.3			1		
08/25/19 8:10	447693.8			1.1			9.46	X		1.17			16.26	X		1		
08/25/19 8:11	449080.1			1			9.22	X		1.06			15.89	X		1		
08/25/19 8:12	449927.3			1			9.27			1.08			16.01			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/25/19 8:13	449773.3			1			9.22			1.06			15.92			1		
08/25/19 8:14	450466.4			1			9.22			1.07			15.94			1		
08/25/19 8:15	449157.2			0.9			9.4			0.97			16.21			1		
08/25/19 8:16	452083.8			0.9			9.5			0.97			16.48			1		
08/25/19 8:17	448464			0.9			9.59			0.96			16.51			1		
08/25/19 8:18	450774.5			0.9			9.77			0.97			16.91			1		
08/25/19 8:19	449773.3			0.9			9.86			0.97			17.03			1		
08/25/19 8:20	450389.4			0.9			10.05			0.97			17.37			1		
08/25/19 8:21	450851.5			0.9			9.03			0.97			15.64			1		
08/25/19 8:22	451698.7			0.9			4.33			0.97			7.51			1		
08/25/19 8:23	450389.4			0.9			3.04			0.97			5.26			1		
08/25/19 8:24	450774.5			0.9			2.77			0.97			4.79			1		
08/25/19 8:25	450389.4			0.9			2.4			0.97			4.14			1		
08/25/19 8:26	450543.4			0.9			2.12			0.97			3.67			1		
08/25/19 8:27	450620.5			0.9			1.84			0.97			3.19			1		
08/25/19 8:28	451082.6			0.9			1.57			0.97			2.71			1		
08/25/19 8:29	450312.4			0.9			1.38			0.97			2.39			1		
08/25/19 8:30	449388.2			0.9			1.29			0.97			2.23			0		
08/25/19 8:31	451082.6			0.9			1.2			0.97			2.08			0		
08/25/19 8:32	449619.3			0.9			1.11			0.97			1.91			0		
08/25/19 8:33	450389.4			0.9			1.01			0.97			1.75			0		
08/25/19 8:34	451159.6			0.9			1.01			0.97			1.76			0		

CT2 SUSD EVENT 8

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/29/19 22:52	337407			1			1.79			0.77			2.32			0		
08/29/19 22:53	338716.3			1			1.79			0.78			2.32			0		
08/29/19 22:54	338023.1			1			1.7			0.78			2.2			0		
08/29/19 22:55	338639.2			1			1.61			0.78			2.09			0		
08/29/19 22:56	337946.1			1			1.61			0.78			2.09			0		
08/29/19 22:57	338100.1			1			1.61			0.78			2.09			1		
08/29/19 22:58	327240.9			0.9			1.7			0.68			2.13			1		
08/29/19 22:59	303365.9			1			1.7			0.7			1.98			1		
08/29/19 23:00	281031.3			1			2.12			0.66			2.29			1		
08/29/19 23:01	259697.9			0.9			5.62			0.57			5.6			1		
08/29/19 23:02	235437.8			0.8			9.64			0.43			8.71			1		
08/29/19 23:03	208790.3			0.7			19.91			0.36			15.96			1		
08/29/19 23:04	184222.2			3			22.21			1.29			15.71			1		
08/29/19 23:05	162426.7			197.4			25.21			74.8			15.72			1		
08/29/19 23:06	143018.7			1110.6			27.79			370.42			15.26			1		
08/29/19 23:07	24414.1			1914.8			29.5			108.87			2.76			1		
08/29/19 23:08	0			0			30.09			0			0			0		
08/29/19 23:09	0			0			0.2			0			0			0		
08/29/19 23:10	0			0			0.2			0			0			0		
08/29/19 23:11	0			0			0.1			0			0			0		
08/29/19 23:12	0			0			0.1			0			0			0		

CT2 SUSD EVENT 9

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/04/19 6:41	0			0			0			0			0			0		
09/04/19 6:42	0			0			0			0			0			0		
09/04/19 6:43	0			0			0			0			0			0		
09/04/19 6:44	0			0			0			0			0			0		
09/04/19 6:45	0			0			0			0			0			0		
09/04/19 6:46	19562.1			0.4			0			0			0			1		
09/04/19 6:47	36659.6			0.8			0.1			0			0			1		
09/04/19 6:48	49367.2			5.2			22.29			0.6			4.22			1		
09/04/19 6:49	61535.8			475.8			16.82			68.28			3.97			1		
09/04/19 6:50	79942.6			334.1			21.91			62.29			6.72			1		
09/04/19 6:51	125998.1			220.2			25.48			64.71			12.32			1		
09/04/19 6:52	151952.5			97.7			38.9			34.61			22.68			1		
09/04/19 6:53	160963.4			190.8			48.45			71.61			29.93			1		
09/04/19 6:54	180063.3			1669.9			39.33			701.24			27.18			1		
09/04/19 6:55	205016.5			1109.5			47.2			530.5			37.14			1		
09/04/19 6:56	229738.6			227.3			58.02			121.8			51.17			1		
09/04/19 6:57	254229.7			18.2			59.86			10.79			58.42			1		
09/04/19 6:58	279953.1			4.7			61.08			3.07			65.63			1		
09/04/19 6:59	307216.7			4.1			55.2			2.94			65.09			1		
09/04/19 7:00	328319.1			3.9			36.85			2.99			46.44			1		
09/04/19 7:01	350499.7			3.8			19.18			3.12			25.8			1		
09/04/19 7:02	368521.4			3.8			17.61			3.28			24.92			1		
09/04/19 7:03	373450.4			3.5			13.8			3.02			19.78			1		
09/04/19 7:04	376300			2.9			12.86			2.55			18.57			1		
09/04/19 7:05	375144.8			2.4			11.71			2.08			16.87			1		
09/04/19 7:06	389700.8			2			10.83			1.84			16.2			1		
09/04/19 7:07	408107.6			1.8			9.74			1.7			15.27			1		
09/04/19 7:08	419120.9			1.7			8.94			1.62			14.39			1		
09/04/19 7:09	423587.8			1.5			8.94			1.46			14.54			1		
09/04/19 7:10	425744.3			1.4			9.13			1.37			14.91			1		
09/04/19 7:11	425282.2			1.3			9.03			1.28			14.75			1		
09/04/19 7:12	425821.3			1.2			9.13			1.19			14.92			1		
09/04/19 7:13	424743.1			1.2			9.31	X		1.19			15.18	X		1		
09/04/19 7:14	424666.1			1.2			9.31	X		1.19			15.18	X		1		
09/04/19 7:15	423202.8			1.2			9.22			1.18			14.98			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/04/19 7:16	421123.3			1.2			9.31			1.18			15.05			1		
09/04/19 7:17	422201.6			1.2			9.31			1.18			15.09			1		
09/04/19 7:18	421585.4			1.2			9.4			1.18			15.22			1		
09/04/19 7:19	420199.2			1.2			9.5			1.17			15.31			1		
09/04/19 7:20	421277.4			1.1			9.59			1.09			15.51			1		
09/04/19 7:21	420430.2			1.1			9.93			1.1			16.02			1		
09/04/19 7:22	420353.2			1			10.02			1.01			16.17			1		
09/04/19 7:23	421508.4			1			10.11			1.01			16.36			1		
09/04/19 7:24	419506			1.1			7.3			1.1			11.76			1		
09/04/19 7:25	418889.9			1			3.6			0.99			5.78			1		
09/04/19 7:26	417657.6			1			2.81			1			4.5			1		
09/04/19 7:27	419197.9			1			2.34			1.01			3.77			1		
09/04/19 7:28	417426.6			1			2.15			1			3.45			1		
09/04/19 7:29	418735.8			1			1.97			1.01			3.16			1		
09/04/19 7:30	418735.8			1			1.78			1.01			2.86			1		
09/04/19 7:31	417503.6			1			1.59			1			2.55			1		
09/04/19 7:32	419583			1			1.5			1.01			2.41			0		
09/04/19 7:33	419737.1			1			1.4			1.01			2.26			0		
09/04/19 7:34	416810.4			1			1.31			1			2.1			0		
09/04/19 7:35	417503.6			1			1.22			1			1.95			0		
09/04/19 7:36	418581.8			1			1.12			1.01			1.81			0		

CT2 SUSD EVENT 10

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/05/19 22:55	324314.3			1.1			1.7			0.81			2.11			0		
09/05/19 22:56	307524.8			1.1			1.82			0.78			2.14			0		
09/05/19 22:57	306369.5			1.1			1.75			0.79			2.06			0		
09/05/19 22:58	305676.4			0.9			1.69			0.67			1.98			0		
09/05/19 22:59	306061.5			0.9			1.69			0.67			1.98			0		
09/05/19 23:00	306061.5			0.9			1.59			0.67			1.87			1		
09/05/19 23:01	289503			0.9			1.59			0.63			1.77			1		
09/05/19 23:02	266937.4			0.9			2.62			0.58			2.69			1		
09/05/19 23:03	246220.1			0.9			6.58			0.5			6.22			1		
09/05/19 23:04	219649.5			0.8			16.28			0.42			13.72			1		
09/05/19 23:05	194850.4			0.8			20.82			0.35			15.57			1		
09/05/19 23:06	169204.1			6			23.1			2.38			15			1		
09/05/19 23:07	148640.8			533.4			25.61			184.97			14.62			1		
09/05/19 23:08	98965.5			1557.9			27.86			359.55			10.58			1		
09/05/19 23:09	0			0			34.09			0			0			0		
09/05/19 23:10	0			0			29.5			0			0			0		
09/05/19 23:11	0			0			0.2			0			0			0		
09/05/19 23:12	0			0			0.2			0			0			0		
09/05/19 23:13	0			0			0.1			0			0			0		

CT2 SUSD EVENT 11

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/09/19 22:38	0			0			0			0			0			0		
09/09/19 22:39	0			0			0			0			0			0		
09/09/19 22:40	0			0			0			0			0			0		
09/09/19 22:41	0			0			0			0			0			0		
09/09/19 22:42	0			0			0			0			0			0		
09/09/19 22:43	8394.7			0.4			0			0			0			1		
09/09/19 22:44	28187.8			0.4			0			0			0			1		
09/09/19 22:45	42281.8			59			26.55			5.85			4.33			1		
09/09/19 22:46	54758.4			506			16.31			64.9			3.44			1		
09/09/19 22:47	67080.9			428.9			19.18			67.4			4.96			1		
09/09/19 22:48	98272.4			275.6			24.16			63.48			9.16			1		
09/09/19 22:49	145252.1			165.7			25.4			56.42			14.23			1		
09/09/19 22:50	154263			61.6			46.39			22.29			27.6			1		
09/09/19 22:51	172361.8			786			43.62			317.56			29.01			1		
09/09/19 22:52	195928.6			1461.7			44.33			671.07			33.5			1		
09/09/19 22:53	222268.1			438.4			56.64			228.34			48.56			1		
09/09/19 22:54	245295.9			42.8			59.13			24.63			55.94			1		
09/09/19 22:55	266937.4			3.5			61.89			2.17			63.73			1		
09/09/19 22:56	295972.4			1.9			61.48			1.29			70.19			1		
09/09/19 22:57	323621.1			1.8			44.86			1.35			55.99			1		
09/09/19 22:58	333556.2			1.8			24.92			1.45			32.06			1		
09/09/19 22:59	333171.1			2			17.61			1.56			22.63			1		
09/09/19 23:00	331630.8			2			17.08			1.57			21.85			1		
09/09/19 23:01	331399.7			1.9			15.59			1.5			19.92			1		
09/09/19 23:02	330552.6			1.8			14			1.36			17.85			1		
09/09/19 23:03	330167.5			1.7			12.77			1.29			16.26			1		
09/09/19 23:04	330321.5			1.6			12.34			1.25			15.72			1		
09/09/19 23:05	330090.5			1.5			11.71			1.18			14.91			1		
09/09/19 23:06	328935.2			1.4			10.82			1.1			13.72			1		
09/09/19 23:07	330167.5			1.3			10.64			1.04			13.55			1		
09/09/19 23:08	336174.7			1.3			10.37			1.06			13.45			1		
09/09/19 23:09	335481.6			1.3			10.19			0.98			13.19			1		
09/09/19 23:10	335943.7			1.3			10.19			0.99			13.2			1		
09/09/19 23:11	335404.6			1.3			10.01			0.98			12.95			1		
09/09/19 23:12	334249.3			1.3			10.01			0.98			12.91			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/09/19 23:13	333633.2			1.3			9.92			0.98			12.77			1		
09/09/19 23:14	333710.2			1.2			9.92			0.91			12.77			1		
09/09/19 23:15	332709			1.2			9.92			0.91			12.73			1		
09/09/19 23:16	332632			1.1			9.92			0.84			12.73			1		
09/09/19 23:17	332015.8			1.1			10.01			0.83			12.82			1		
09/09/19 23:18	332400.9			1.1			9.92			0.84			12.72			1		
09/09/19 23:19	332323.9			1.2			9.92			0.91			12.72			1		
09/09/19 23:20	331091.7			1.1			10.1			0.83			12.9			1		
09/09/19 23:21	330783.6			1.1			10.1			0.83			12.89			1		
09/09/19 23:22	331707.8			1.1			10.35			0.85			13.24			1		
09/09/19 23:23	329859.4			1.1			10.53			0.84			13.4			1		
09/09/19 23:24	332015.8			1.1			10.71			0.85			13.72			1		
09/09/19 23:25	331245.7			1.1			10.8			0.85			13.8			1		
09/09/19 23:26	330244.5			1			8.99			0.77			11.45			1		
09/09/19 23:27	331476.8			1			4.63			0.78			5.92			1		
09/09/19 23:28	330321.5			1			3.72			0.77			4.74			1		
09/09/19 23:29	329782.4			1			3.09			0.77			3.93			1		
09/09/19 23:30	330013.4			1			2.81			0.77			3.58			1		
09/09/19 23:31	331399.7			1			2.54			0.78			3.25			1		
09/09/19 23:32	330629.6			1			2.18			0.77			2.78			1		
09/09/19 23:33	330552.6			1			2			0.77			2.55			1		
09/09/19 23:34	330090.5			1			1.82			0.77			2.31			1		
09/09/19 23:35	330090.5			1			1.63			0.77			2.08			1		
09/09/19 23:36	331091.7			1			1.54			0.77			1.97			1		
09/09/19 23:37	330244.5			1			1.36			0.77			1.73			0		
09/09/19 23:38	330167.5			1			1.27			0.77			1.62			0		
09/09/19 23:39	328473.1			1			1.27			0.77			1.61			0		
09/09/19 23:40	329705.4			1			1.18			0.77			1.5			0		
09/09/19 23:41	330552.6			1			1.09			0.77			1.39			0		

CT2 SUSD EVENT 12

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/11/19 11:47	453085			2.1			1.67			2.31			3			0		
09/11/19 11:48	451775.7			2.1			1.67			2.3			3			0		
09/11/19 11:49	451698.7			2.1			1.7			2.34			3.05			0		
09/11/19 11:50	452545.8			2.1			1.7			2.32			3.03			0		
09/11/19 11:51	453316			2.1			1.7			2.3			3			0		
09/11/19 11:52	452006.8			2.2			1.7			2.37			2.96			1		
09/11/19 11:53	451929.7			2.3			1.75			2.44			3.05			1		
09/11/19 11:54	432675.7			2			1.75			2.06			2.92			1		
09/11/19 11:55	408800.8			1.5			1.94			1.41			3.05			1		
09/11/19 11:56	385850			1.2			2.45			1.07			3.65			1		
09/11/19 11:57	361050.9			1.1			2.86			0.91			3.98			1		
09/11/19 11:58	334942.5			1.1			3.08			0.83			3.98			1		
09/11/19 11:59	311452.6			1.1			3.35			0.84			4.02			1		
09/11/19 12:00	288193.8			1.1			3.63			0.74			4.04			1		
09/11/19 12:01	265474.1			1			5.99			0.64			6.14			1		
09/11/19 12:02	245603.9			1			6.19			0.56			5.86			1		
09/11/19 12:03	219033.4			0.8			22.38			0.42			18.9			1		
09/11/19 12:04	192308.9			1.6			26.55			0.72			19.69			1		
09/11/19 12:05	168511			13.9			27.58			5.47			17.92			1		
09/11/19 12:06	151028.3			668.1			29.21			236.46			17.01			1		
09/11/19 12:07	69391.4			1703.6			31.02			277.23			8.31			1		
09/11/19 12:08	0			0			32.99			0			0			0		
09/11/19 12:09	0			0			23.6			0			0			0		
09/11/19 12:10	0			0			0.2			0			0			0		
09/11/19 12:11	0			0			0.2			0			0			0		
09/11/19 12:12	0			0			0.1			0			0			0		

CT2 SUSD EVENT 13

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/12/19 8:40	0			0			0			0			0			0		
09/12/19 8:41	0			0			0			0			0			0		
09/12/19 8:42	0			0			0			0			0			0		
09/12/19 8:43	0			0			0			0			0			0		
09/12/19 8:44	0			0			0			0			0			0		
09/12/19 8:45	13554.8			0.3			0			0			0			1		
09/12/19 8:46	32500.7			0.6			0			0			0			1		
09/12/19 8:47	45901.5			55.3			26.55			5.96			4.7			1		
09/12/19 8:48	57607.9			482.6			20.95			65.14			4.65			1		
09/12/19 8:49	73165.2			327.3			25.29			56.12			7.14			1		
09/12/19 8:50	112674.4			201.4			33.79			53.2			14.69			1		
09/12/19 8:51	151952.5			97.7			45.55			34.8			26.7			1		
09/12/19 8:52	158729.9			48.1			61.77			17.9			37.82			1		
09/12/19 8:53	180063.3			1266.8			53.62			534.51			37.24			1		
09/12/19 8:54	203630.2			1004.4			55.97			479.36			43.96			1		
09/12/19 8:55	229584.6			185.7			57.31			99.94			50.76			1		
09/12/19 8:56	253459.6			10.2			58.26			6.06			56.96			1		
09/12/19 8:57	276564.3			2			60.31			1.27			64.34			1		
09/12/19 8:58	304213.1			1.7			53.59			1.19			62.88			1		
09/12/19 8:59	329166.3			1.7			33.68			1.33			42.75			1		
09/12/19 9:00	339409.4			1.8			17.44			1.47			22.83			1		
09/12/19 9:01	340795.7			1.9			15.06			1.55			19.79			1		
09/12/19 9:02	340333.6			1.8			13.39			1.47			17.57			1		
09/12/19 9:03	339871.5			1.7			12.58			1.38			16.49			1		
09/12/19 9:04	337407			1.7			12.06			1.32			15.7			1		
09/12/19 9:05	338408.2			1.6			11.54			1.26			15.06			1		
09/12/19 9:06	337098.9			1.5			11.1			1.18			14.43			1		
09/12/19 9:07	337869.1			1.5			10.74			1.19			14			1		
09/12/19 9:08	337407			1.4			10.48			1.11			13.64			1		
09/12/19 9:09	338408.2			1.2			10.39			0.98			13.56			1		
09/12/19 9:10	336328.8			1.3			10.55			0.99			13.68			1		
09/12/19 9:11	335943.7			1.3			10.46			0.99			13.55			1		
09/12/19 9:12	336251.8			1.2			10.37			0.92			13.45			1		
09/12/19 9:13	334942.5			1.2			10.37			0.91			13.4			1		
09/12/19 9:14	335712.6			1.2			10.28			0.91			13.31			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/12/19 9:15	335019.5			1.2			10.19			0.91			13.17			1		
09/12/19 9:16	336944.9			1.1			10.28			0.85			13.36			1		
09/12/19 9:17	335019.5			1.1			10.28			0.84			13.29			1		
09/12/19 9:18	334634.4			1.1			10.37			0.84			13.39			1		
09/12/19 9:19	335019.5			1.1			10.37			0.84			13.4			1		
09/12/19 9:20	334403.3			1.1			10.37			0.84			13.37			1		
09/12/19 9:21	332169.9			1.1			10.46			0.84			13.4			1		
09/12/19 9:22	334403.3			1.1			10.64			0.84			13.72			1		
09/12/19 9:23	334249.3			1.1			10.55			0.84			13.6			1		
09/12/19 9:24	333633.2			1			6.35			0.77			8.17			1		
09/12/19 9:25	332709			1			3.93			0.77			5.05			1		
09/12/19 9:26	333633.2			1			3.4			0.77			4.37			1		
09/12/19 9:27	328473.1			1			2.95			0.76			3.74			1		
09/12/19 9:28	322388.9			1			2.77			0.74			3.45			1		
09/12/19 9:29	322080.8			1			2.36			0.75			2.93			1		
09/12/19 9:30	321464.7			0.9			2.18			0.68			2.7			1		
09/12/19 9:31	320232.4			0.9			1.82			0.68			2.24			1		
09/12/19 9:32	319770.3			1			1.63			0.75			2.02			1		
09/12/19 9:33	319000.2			1			1.54			0.75			1.9			1		
09/12/19 9:34	318615.1			1			1.45			0.75			1.78			0		
09/12/19 9:35	319000.2			0.9			1.27			0.68			1.56			0		
09/12/19 9:36	318384			0.9			1.18			0.68			1.45			0		
09/12/19 9:37	318538.1			0.9			1.18			0.68			1.45			0		
09/12/19 9:38	318692.1			0.9			1.18			0.68			1.45			0		

CT2 SUSD EVENT 14

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/12/19 22:52	415193.1			1.4			2.3			1.35			3.69			0		
09/12/19 22:53	394167.8			1.4			2.03			1.28			3.08			0		
09/12/19 22:54	368367.4			1.3			1.88			1.16			2.67			0		
09/12/19 22:55	342644.1			1.3			1.76			1.06			2.33			0		
09/12/19 22:56	317382.8			1.4			1.59			1.05			1.94			0		
09/12/19 22:57	307139.7			1.4			1.43			1.03			1.69			1		
09/12/19 22:58	291890.5			1.4			1.18			0.93			1.33			1		
09/12/19 22:59	268785.8			1.2			2.12			0.75			2.2			1		
09/12/19 23:00	249608.8			1.1			6			0.67			5.77			1		
09/12/19 23:01	222730.2			1			6.3			0.52			5.41			1		
09/12/19 23:02	194465.3			1.1			18.59			0.51			13.94			1		
09/12/19 23:03	172592.8			7.5			21.47			3.05			14.29			1		
09/12/19 23:04	152645.7			570.4			24.46			204.05			14.4			1		
09/12/19 23:05	88029.3			1565.8			26.88			323.16			9.13			1		
09/12/19 23:06	0			0			33.04			0			0			0		
09/12/19 23:07	0			0			17.7			0			0			0		
09/12/19 23:08	0			0			0.1			0			0			0		
09/12/19 23:09	0			0			0.1			0			0			0		
09/12/19 23:10	0			0			0.1			0			0			0		
09/12/19 23:11	0			0			0.1			0			0			0		
09/12/19 23:12	0			0			0.1			0			0			0		
09/12/19 23:13	0			0			0.1			0			0			0		

CT2 SUSD EVENT 15

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/23/19 7:39	0			0			0			0			0			0		
09/23/19 7:40	0			0			0			0			0			0		
09/23/19 7:41	0			0			0			0			0			0		
09/23/19 7:42	0			0			0			0			0			0		
09/23/19 7:43	4081.8			0			0			0			0			0		
09/23/19 7:44	8317.7			0.3			0			0			0			1		
09/23/19 7:45	29266.1			0.3			0			0			0			1		
09/23/19 7:46	44438.2			41.3			23.6			4.3			4.04			1		
09/23/19 7:47	56683.8			534.6			16.06			70.96			3.51			1		
09/23/19 7:48	68775.3			443.7			19.77			71.51			5.24			1		
09/23/19 7:49	105049.8			282.6			24.72			69.59			10.02			1		
09/23/19 7:50	149257			150.2			33.19			52.55			19.11			1		
09/23/19 7:51	154031.9			58.4			48.77			21.09			28.98			1		
09/23/19 7:52	161348.5			1035.9			37.72			391.65			23.47			1		
09/23/19 7:53	177059.7			1857.8			34.36			771.01			23.47			1		
09/23/19 7:54	199548.4			1390.3			39.66			650.11			30.52			1		
09/23/19 7:55	222807.2			430.8			50.74			225			43.61			1		
09/23/19 7:56	248607.6			42.1			57.08			24.51			54.73			1		
09/23/19 7:57	272790.6			3.7			62.18			2.39			65.42			1		
09/23/19 7:58	299592.1			2.5			60.93			1.79			70.42			1		
09/23/19 7:59	326162.7			2.3			41.85			1.76			52.65			1		
09/23/19 8:00	346725.9			2.2			23.6			1.79			31.56			1		
09/23/19 8:01	365209.8			2.3			18.39			1.93			25.91			1		
09/23/19 8:02	373758.5			2.3			15.96			1.98			23.01			1		
09/23/19 8:03	384617.8			2.1			13.65			1.91			20.25			1		
09/23/19 8:04	400637.1			1.9			12.59			1.82			19.46			1		
09/23/19 8:05	411188.3			1.9			10.91			1.81			17.3			1		
09/23/19 8:06	421123.3			1.7			10.53			1.7			17.1			1		
09/23/19 8:07	437835.8			1.5			10.26			1.58			17.32			1		
09/23/19 8:08	457937			1.5			9.5			1.58			16.77			1		
09/23/19 8:09	457628.9			1.4			10.51			1.48			18.55			1		
09/23/19 8:10	454702.3			1.3			10.51			1.38			18.43			1		
09/23/19 8:11	456550.7			1.3			10.42			1.38			18.34			1		
09/23/19 8:12	454625.3			1.3			10.42			1.38			18.27			1		
09/23/19 8:13	453932.1			1.3			10.6			1.37			18.56			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/23/19 8:14	452930.9			1.3			10.69			1.37			18.68			1		
09/23/19 8:15	454163.2			1.2			10.69			1.28			18.73			1		
09/23/19 8:16	452853.9			1.2			10.79			1.27			18.84			1		
09/23/19 8:17	453162			1.1			10.88			1.18			19.02			1		
09/23/19 8:18	451082.6			1.2			11.24			1.29			19.55			1		
09/23/19 8:19	452776.9			1.2			11.25			1.27			19.64			1		
09/23/19 8:20	451621.7			1.1			11.61			1.19			20.23			1		
09/23/19 8:21	453085			1.1			11.71			1.19			20.46			1		
09/23/19 8:22	452006.8			1.1			11.99			1.19			20.9			1		
09/23/19 8:23	451775.7			1.1			7.12			1.19			12.4			1		
09/23/19 8:24	451929.7			1.1			3.56			1.19			6.2			1		
09/23/19 8:25	451082.6			1			3.09			1.09			5.38			1		
09/23/19 8:26	451467.6			1			2.81			1.09			4.89			1		
09/23/19 8:27	451544.7			1.1			2.72			1.19			4.73			1		
09/23/19 8:28	450774.5			1.1			2.62			1.19			4.56			1		
09/23/19 8:29	451390.6			1.1			2.53			1.19			4.4			1		
09/23/19 8:30	450158.3			1.1			2.34			1.19			4.07			1		
09/23/19 8:31	451929.7			1.1			2.15			1.19			3.75			1		
09/23/19 8:32	451929.7			1			1.87			1.09			3.27			1		
09/23/19 8:33	451929.7			1.1			1.78			1.19			3.1			1		
09/23/19 8:34	450312.4			1.1			1.59			1.19			2.77			1		
09/23/19 8:35	451390.6			1			1.5			1.09			2.61			0		
09/23/19 8:36	450466.4			1			1.4			1.09			2.44			0		
09/23/19 8:37	448464			1			1.4			1.08			2.43			0		
09/23/19 8:38	450081.3			1			1.31			1.09			2.28			0		
09/23/19 8:39	449850.3			1			1.22			1.09			2.11			0		

CT2 SUSD EVENT 16

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/27/19 22:50	324391.3			1.1			1.63			0.83			2.04			0		
09/27/19 22:51	322851			1.1			1.63			0.82			2.03			0		
09/27/19 22:52	324237.3			1.1			1.63			0.83			2.04			0		
09/27/19 22:53	323929.2			1.1			1.63			0.83			2.04			0		
09/27/19 22:54	322851			1.1			1.54			0.82			1.92			0		
09/27/19 22:55	324314.3			1.1			1.72			0.83			2.16			1		
09/27/19 22:56	312607.8			1.1			1.72			0.8			2.08			1		
09/27/19 22:57	289272			1.1			1.82			0.74			2.03			1		
09/27/19 22:58	266629.3			1.1			4.12			0.7			4.24			1		
09/27/19 22:59	245681			1.1			8.03			0.61			7.61			1		
09/27/19 23:00	217262.1			0.9			16.56			0.47			13.88			1		
09/27/19 23:01	192077.8			1.8			19.29			0.82			14.29			1		
09/27/19 23:02	169358.1			11.9			21.29			4.73			13.91			1		
09/27/19 23:03	149334			826.1			23.6			289.05			13.59			1		
09/27/19 23:04	76168.8			1777.8			25.62			317.16			7.52			1		
09/27/19 23:05	0			0			28.1			0			0			0		
09/27/19 23:06	0			0			17.7			0			0			0		
09/27/19 23:07	0			0			0.1			0			0			0		
09/27/19 23:08	0			0			0.1			0			0			0		
09/27/19 23:09	0			0			0.1			0			0			0		

CT2 SUSD EVENT 17

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/30/19 10:40	0			0			0			0			0			0		
09/30/19 10:41	0			0			0			0			0			0		
09/30/19 10:42	0			0			0			0			0			0		
09/30/19 10:43	0			0			0			0			0			0		
09/30/19 10:44	0			0			0			0			0			0		
09/30/19 10:45	7855.6			0.3			0			0			0			1		
09/30/19 10:46	30575.3			0.4			0			0			0			1		
09/30/19 10:47	44669.3			50.2			26.55			5.25			4.58			1		
09/30/19 10:48	56298.7			549.4			16.06			72.43			3.49			1		
09/30/19 10:49	69699.5			419.5			19.47			68.55			5.24			1		
09/30/19 10:50	106128			271.1			24.72			67.43			10.12			1		
09/30/19 10:51	149334			151.7			31.96			53.07			18.4			1		
09/30/19 10:52	156573.5			56.6			50.74			20.78			30.64			1		
09/30/19 10:53	166200.5			1086.1			45.41			423.04			29.11			1		
09/30/19 10:54	185993.6			1793.9			49.46			781.85			35.47			1		
09/30/19 10:55	209329.4			958			60.59			470.08			48.93			1		
09/30/19 10:56	234975.7			174			62.84			95.8			56.95			1		
09/30/19 10:57	258080.5			12.9			60.97			7.81			60.69			1		
09/30/19 10:58	281724.4			2.6			62.61			1.73			68.04			1		
09/30/19 10:59	310220.3			2.2			57.5			1.6			68.8			1		
09/30/19 11:00	334018.3			2			38.21			1.56			49.23			1		
09/30/19 11:01	355120.7			2.1			20.04			1.73			27.45			1		
09/30/19 11:02	371140			2.2			17.87			1.89			25.59			1		
09/30/19 11:03	387467.3			2.2			13.91			2			20.79			1		
09/30/19 11:04	396401.2			2.1			12.25			1.91			18.72			1		
09/30/19 11:05	402023.4			1.9			11.08			1.77			17.19			1		
09/30/19 11:06	404256.8			1.7			10.53			1.63			16.42			1		
09/30/19 11:07	406721.3			1.5			9.98			1.47			15.66			1		
09/30/19 11:08	406182.3			1.5			9.44			1.38			14.79			1		
09/30/19 11:09	406413.3			1.4			9.44			1.3			14.8			1		
09/30/19 11:10	405181			1.4			9.35			1.29			14.61			1		
09/30/19 11:11	404179.8			1.3			9.26			1.2			14.43			1		
09/30/19 11:12	403409.7			1.3			9.17			1.2			14.27			1		
09/30/19 11:13	403563.7			1.2			9.26			1.12			14.41			1		
09/30/19 11:14	402639.5			1.2			9.35			1.11			14.52			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/30/19 11:15	402639.5			1.2			9.44			1.11			14.66			1		
09/30/19 11:16	402639.5			1.2			9.59			1.13			14.89			1		
09/30/19 11:17	402639.5			1.2			9.59			1.13			14.89			1		
09/30/19 11:18	400021			1.1			9.77			1.04			15.08			1		
09/30/19 11:19	400714.1			1.1			9.86			1.04			15.24			1		
09/30/19 11:20	400329			1.1			9.96			1.04			15.37			1		
09/30/19 11:21	400868.1			1.1			10.14			1.04			15.68			1		
09/30/19 11:22	400021			1.1			10.23			1.04			15.79			1		
09/30/19 11:23	400252			1.1			10.33			1.04			15.94			1		
09/30/19 11:24	400329			1.1			8.2			1.04			12.67			1		
09/30/19 11:25	399866.9			1.1			3.78			1.04			5.83			1		
09/30/19 11:26	394552.8			1			3.13			0.94			4.77			1		
09/30/19 11:27	374528.7			1.1			2.9			0.96			4.2			1		
09/30/19 11:28	369753.7			1.1			2.86			0.93			4.08			1		
09/30/19 11:29	367828.3			1.2			2.77			1			3.93			1		
09/30/19 11:30	367289.2			1.2			2.5			1			3.55			1		
09/30/19 11:31	366519			1.2			2.27			1.01			3.21			1		
09/30/19 11:32	366442			1.2			2			1.01			2.82			1		
09/30/19 11:33	364978.7			1.1			1.82			0.93			2.56			1		
09/30/19 11:34	365286.8			1.1			1.72			0.93			2.43			1		
09/30/19 11:35	361281.9			1.1			1.63			0.92			2.28			1		
09/30/19 11:36	359202.5			1.2			1.54			0.99			2.14			0		
09/30/19 11:37	356429.9			1.2			1.54			0.99			2.12			0		
09/30/19 11:38	353580.3			1.2			1.45			0.98			1.98			0		
09/30/19 11:39	351886			1.2			1.43			0.96			1.94			0		
09/30/19 11:40	351963			1.2			1.34			0.96			1.82			0		

CT2 SUSD EVENT 18

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/30/19 16:59	434986.2			1.1			1.97			1.15			3.3			0		
09/30/19 17:00	411727.4			1			2.06			0.99			3.27			0		
09/30/19 17:01	388006.5			1			2.03			0.92			3.03			0		
09/30/19 17:02	362052.1			1.1			2			0.92			2.79			0		
09/30/19 17:03	336636.8			1.1			1.79			0.85			2.32			0		
09/30/19 17:04	325546.5			1.2			1.7			0.89			2.13			1		
09/30/19 17:05	312299.8			1.2			1.82			0.86			2.19			1		
09/30/19 17:06	288347.8			1.1			2.03			0.75			2.26			1		
09/30/19 17:07	266629.3			1			3.84			0.64			3.95			1		
09/30/19 17:08	246143			1			7.54			0.56			7.16			1		
09/30/19 17:09	219495.5			0.8			17.09			0.42			14.47			1		
09/30/19 17:10	192308.9			0.8			21.1			0.36			15.65			1		
09/30/19 17:11	170744.4			6.4			23.22			2.57			15.29			1		
09/30/19 17:12	150797.3			489.4			25.18			172.98			14.65			1		
09/30/19 17:13	86566			1612			26.3			326.93			8.78			1		
09/30/19 17:14	0			0			27.7			0			0			0		
09/30/19 17:15	0			0			17.7			0			0			0		
09/30/19 17:16	0			0			0.2			0			0			0		
09/30/19 17:17	0			0			0.1			0			0			0		
09/30/19 17:18	0			0			0.1			0			0			0		

ATTACHMENT 4

AQ-32

AQ-32 The Project owner shall maintain hourly records of NOx and CO emission concentrations (ppmv @ 15% O2), and hourly, daily, and quarterly records of NOx and CO emissions. Ongoing compliance with the CO emission limits during normal operation shall be deemed compliance with the VOC emission limits during normal operation.

Verification: The project owner shall submit to the CPM all concentration, hourly, daily, and quarter NOx and CO emissions as part of the Quarterly Air Quality Report required by Condition of Certification AQ-SC6

Tons 12 Month Rolling Summary

CT1 and CT2 Combined

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:02 **Location:** Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2 CO, Ton 1 Day(s) Sum	Rolling Sum	Units CT1 & CT2 NOx, Ton 1 Day(s) Sum	Rolling Sum	Units CT1 & CT2 PM10, Ton 1 Day(s) Sum	Rolling Sum	Units CT1 & CT2 SO2, Ton 1 Day(s) Sum	Rolling Sum	Units CT1 & CT2 VOC, Ton 1 Day(s) Sum	Rolling Sum
Jul 2019	0.1329	3.6349	0.4979	9.8697	0.0934	1.8340	0.0467	0.9169	0.1557	3.0568
Aug 2019	0.3100	3.5358	0.9671	9.0841	0.1814	1.6947	0.0908	0.8474	0.3022	2.8241
Sep 2019	0.3350	3.8708	0.5519	9.6360	0.0943	1.7890	0.0471	0.8945	0.1574	2.9815
Sum/Avg	3.8708		9.6360		1.7890		0.8945		2.9815	
Limit Value										

AQ32 DAILY NOX CO

	CT1_CO_Lb_1D			CT1_NOx_Lb_1D			CT2_CO_Lb_1D			CT2_NOx_Lb_1D								
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/01/19 0:00	0			0			0			0								
07/02/19 0:00	0			0			0			0								
07/03/19 0:00	0			0			0			0								
07/04/19 0:00	0			0			0			0								
07/05/19 0:00	0			0			0			0								
07/06/19 0:00	0			0			0			0								
07/07/19 0:00	0			0			0			0								
07/08/19 0:00	0			0			0			0								
07/09/19 0:00	0			0			0			0								
07/10/19 0:00	0			0			0			0								
07/11/19 0:00	0			0			0			0								
07/12/19 0:00	0			0			0			0								
07/13/19 0:00	0			0			0			0								
07/14/19 0:00	0			0			0			0								
07/15/19 0:00	0			0			0			0								
07/16/19 0:00	0			0			0			0								
07/17/19 0:00	0			0			0			0								
07/18/19 0:00	0			0			0			0								
07/19/19 0:00	0			0			0			0								
07/20/19 0:00	0			0			0			0								
07/21/19 0:00	0			0			0			0								
07/22/19 0:00	0			0			27.81			37.22								
07/23/19 0:00	6.04			60.94			19.35			30.89								
07/24/19 0:00	7.4			93.5			0			0								
07/25/19 0:00	15.45			79.03			0			0								
07/26/19 0:00	14.85			80.58			0			0								
07/27/19 0:00	19.18			69.81			22.9			14.03								
07/28/19 0:00	14.15			69.98			17.71			74.39								
07/29/19 0:00	14.21			75			18.43			79.66								
07/30/19 0:00	15.16			52.19			19.8			58.86								
07/31/19 0:00	13.28			57.69			16.04			62.2								
08/01/19 0:00	14.27			53.57			18.01			59.15								
08/02/19 0:00	13.54			55.7			16.56			60.54								
08/03/19 0:00	13.37			59.61			16.46			64.49								
08/04/19 0:00	11.76			62.65			15.5			68.46								

	CT1_CO_Lb_1D			CT1_NOx_Lb_1D			CT2_CO_Lb_1D			CT2_NOx_Lb_1D								
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/05/19 0:00	10.77			54.5			14.39			57.26								
08/06/19 0:00	12.63			61.39			17.47			66.02								
08/07/19 0:00	12.38			58.63			18.09			63.3								
08/08/19 0:00	16.84			10.41			14.61			11.14								
08/09/19 0:00	0			0			0			0								
08/10/19 0:00	0			0			0			0								
08/11/19 0:00	0			0			0			0								
08/12/19 0:00	0			0			0			0								
08/13/19 0:00	31.38			63.44			0			0								
08/14/19 0:00	14.07			69.26			42.85			60.42								
08/15/19 0:00	13.24			62.56			18.07			67.19								
08/16/19 0:00	11.56			65.54			26.61			67.39								
08/17/19 0:00	21.76			63.82			0			0								
08/18/19 0:00	0			0			0			0								
08/19/19 0:00	0			0			0			0								
08/20/19 0:00	0			0			0			0								
08/21/19 0:00	0			0			0			0								
08/22/19 0:00	0			0			0			0								
08/23/19 0:00	0			0			0			0								
08/24/19 0:00	0			0			0			0								
08/25/19 0:00	0			0			38.98			65.25								
08/26/19 0:00	0			0			20.39			68.8								
08/27/19 0:00	38.21			62.38			19.15			69.58								
08/28/19 0:00	10.26			73.78			15.5			79.66								
08/29/19 0:00	27.47			61.2			33.52			66.83								
08/30/19 0:00	0			0			0			0								
08/31/19 0:00	0			0			0			0								
09/01/19 0:00	0			0			0			0								
09/02/19 0:00	0			0			0			0								
09/03/19 0:00	0			0			0			0								
09/04/19 0:00	42.25			62.31			42.58			65.89								
09/05/19 0:00	20.86			63.5			33.45			70.46								
09/06/19 0:00	0			0			0			0								
09/07/19 0:00	0			0			0			0								
09/08/19 0:00	0			0			0			0								
09/09/19 0:00	0			0			26.06			15.3								
09/10/19 0:00	0			0			21.23			68.35								
09/11/19 0:00	39.47			49.95			24.37			29.43								

	CT1_CO_Lb_1D			CT1_NOx_Lb_1D			CT2_CO_Lb_1D			CT2_NOx_Lb_1D								
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/12/19 0:00	20.9			28.26			47.13			60.18								
09/13/19 0:00	0			0			0			0								
09/14/19 0:00	0			0			0			0								
09/15/19 0:00	0			0			0			0								
09/16/19 0:00	0			0			0			0								
09/17/19 0:00	0			0			0			0								
09/18/19 0:00	0			0			0			0								
09/19/19 0:00	0			0			0			0								
09/20/19 0:00	0			0			0			0								
09/21/19 0:00	0			0			0			0								
09/22/19 0:00	0			0			0			0								
09/23/19 0:00	0			0			56.71			68.38								
09/24/19 0:00	54.53			55.46			28.26			75.6								
09/25/19 0:00	13.43			61.12			20.55			67.21								
09/26/19 0:00	22.82			59.3			21.88			65.55								
09/27/19 0:00	0			0			29.32			76.81								
09/28/19 0:00	0			0			0			0								
09/29/19 0:00	0			0			0			0								
09/30/19 0:00	48.79			25.3			55.26			35.23								

AQ32 HOURLY NOX CO

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/01/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/02/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/04/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/05/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/07/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/08/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/10/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/11/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/13/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/13/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/13/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/13/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/13/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/13/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/13/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/13/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/13/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/13/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/13/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/13/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/13/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/13/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/13/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/13/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/13/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/13/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/13/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/13/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/13/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/13/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/13/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/13/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/14/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/14/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/14/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/14/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/14/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/14/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/14/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/14/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/14/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/14/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/14/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/14/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/14/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/14/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/14/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/14/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/14/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/14/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/14/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/14/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/14/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/14/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/14/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/14/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/15/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/15/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/15/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/15/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/15/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/15/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/15/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/15/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/15/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/15/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/15/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/15/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/15/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/15/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/15/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/15/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/15/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/15/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/15/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/15/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/15/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/15/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/15/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/15/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/16/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/16/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/16/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/16/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/16/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/16/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/16/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/16/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/16/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/16/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/16/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/16/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/16/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/16/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/16/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/16/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/16/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/16/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/16/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/16/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/16/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/16/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/16/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/16/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/17/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/17/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/17/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/17/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/17/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/17/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/17/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/17/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/17/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/17/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/17/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/17/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/17/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/17/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/17/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/17/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/17/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/17/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/17/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/17/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/17/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/17/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/17/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/17/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/18/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/18/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/18/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/18/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/18/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/18/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/18/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/18/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/18/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/18/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/18/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/18/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/18/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/18/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/18/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/18/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/18/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/18/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/18/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/18/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/18/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/18/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/18/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/18/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/19/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/19/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/19/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/19/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/19/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/19/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/19/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/19/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/19/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/19/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/19/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/19/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/19/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/19/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/19/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/19/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/19/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/19/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/19/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/19/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/19/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/19/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/19/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/19/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/20/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/20/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/20/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/20/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/20/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/20/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/20/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/20/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/20/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/20/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/20/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/20/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/20/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/20/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/20/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/20/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/20/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/20/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/20/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/20/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/20/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/20/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/20/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/20/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/21/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/21/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/21/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/21/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/21/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/21/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/21/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/21/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/21/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/21/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/21/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/21/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/21/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/21/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/21/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/21/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/21/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/21/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/21/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/21/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/21/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/21/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/21/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/21/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/22/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/22/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/22/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/22/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/22/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/22/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/22/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/22/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/22/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/22/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/22/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/22/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/22/19 12:00	0	X		0	X		0	X	1	0			0			20.2		1
07/22/19 13:00	0	X		0	X		0	X	1	0.7			1.3			14.9		1
07/22/19 14:00	0	X		0	X		0	X	1	0.8			1.6			14.5		1
07/22/19 15:00	0	X		0	X		0	X	1	0.8			1.7			14.4		1
07/22/19 16:00	0	X		0	X		0	X	1	0.8			1.7			14.4		1
07/22/19 17:00	0	X		0	X		0	X	1	0.8			1.7			14.4		1
07/22/19 18:00	0	X		0	X		0	X	1	0.8			1.7			14.4		1
07/22/19 19:00	0	X		0	X		0	X	1	0.8			1.7			14.4		1
07/22/19 20:00	0	X		0	X		0	X	1	0.9			1.7			14.3		1
07/22/19 21:00	0	X		0	X		0	X	1	0.9			1.7			14.3		1
07/22/19 22:00	0	X		0	X		0	X	1	0.9			1.7			14.3		1
07/22/19 23:00	0	X		0	X		0	X	1	0.9			1.7			14.3		1
07/23/19 0:00	0	X		0	X		0	X	1	0.9			1.7			14.3		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/23/19 1:00	0	X		0	X		0	X	1	0.9			1.7			14.3		1
07/23/19 2:00	0	X		0	X		0	X	1	0.9			1.7			14.3		1
07/23/19 3:00	0	X		0	X		0	X	1	0.9			1.7			14.3		1
07/23/19 4:00	0	X		0	X		0	X	1	0.9			1.7			14.3		1
07/23/19 5:00	0	X		0	X		0	X	0	0.9			1.7			14.3		1
07/23/19 6:00	0	X		0	X		0	X	0	0.9			1.7			14.3		1
07/23/19 7:00	0.8			1.8			14.4		1	0.8			1.7			14.4		1
07/23/19 8:00	0.7			1.7			14.4		1	0.8			1.7			14.5		1
07/23/19 9:00	0.7			1.7			14.5		1	0.8			1.6			14.5		1
07/23/19 10:00	0.8			1.7			14.5		1	0.7			1.7			14.6		1
07/23/19 11:00	0.4			1.7			12.8		1	0.8			1.7			14.5		1
07/23/19 12:00	0.2			1.7			11.8		1	0			0			16.3		1
07/23/19 13:00	0.1			1.7			11.8		1	0	X		0	X		0	X	1
07/23/19 14:00	0.1			1.7			11.8		1	0	X		0	X		0	X	1
07/23/19 15:00	0.1			1.7			11.8		1	0	X		0	X		0	X	1
07/23/19 16:00	0.1			1.7			11.8		1	0	X		0	X		0	X	1
07/23/19 17:00	0.1			1.7			11.8		1	0	X		0	X		0	X	1
07/23/19 18:00	0.1			1.7			11.8		1	0	X		0	X		0	X	1
07/23/19 19:00	0.2			1.7			11.8		1	0	X		0	X		0	X	1
07/23/19 20:00	0.2			1.7			11.7		1	0	X		0	X		0	X	1
07/23/19 21:00	0.2			1.7			11.7		1	0	X		0	X		0	X	1
07/23/19 22:00	0.2			1.7			11.7		1	0	X		0	X		0	X	1
07/23/19 23:00	0.2			1.7			11.8		1	0	X		0	X		0	X	1
07/24/19 0:00	0.2			1.7			11.8		1	0	X		0	X		0	X	1
07/24/19 1:00	0.2			1.7			11.8		1	0	X		0	X		0	X	1
07/24/19 2:00	0.2			1.7			11.9		1	0	X		0	X		0	X	1
07/24/19 3:00	0.2			1.7			11.9		1	0	X		0	X		0	X	1
07/24/19 4:00	0.2			1.7			11.9		1	0	X		0	X		0	X	1
07/24/19 5:00	0.2			1.7			11.9		1	0	X		0	X		0	X	1
07/24/19 6:00	0.2			1.7			11.9		1	0	X		0	X		0	X	1
07/24/19 7:00	0.2			1.7			11.9		1	0	X		0	X		0	X	1
07/24/19 8:00	0.2			1.7			11.9		1	0	X		0	X		0	X	1
07/24/19 9:00	0.2			1.7			11.8		1	0	X		0	X		0	X	1
07/24/19 10:00	0.2			1.7			11.8		1	0	X		0	X		0	X	1
07/24/19 11:00	0.2			1.7			11.8		1	0	X		0	X		0	X	1
07/24/19 12:00	0.2			1.7			11.8		1	0	X		0	X		0	X	1
07/24/19 13:00	0.2			1.7			11.8		1	0	X		0	X		0	X	1
07/24/19 14:00	0.2			1.7			11.8		1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/24/19 15:00	0.2			1.7			11.8		1	0	X		0	X		0	X	1
07/24/19 16:00	0.2			1.7			11.8		1	0	X		0	X		0	X	1
07/24/19 17:00	0.2			1.7			11.8		1	0	X		0	X		0	X	1
07/24/19 18:00	0.2			1.7			11.8		1	0	X		0	X		0	X	1
07/24/19 19:00	0.2			1.7			11.8		1	0	X		0	X		0	X	1
07/24/19 20:00	0.2			1.7			11.8		1	0	X		0	X		0	X	1
07/24/19 21:00	0.2			1.7			11.8		1	0	X		0	X		0	X	1
07/24/19 22:00	0.2			1.7			11.9		1	0	X		0	X		0	X	1
07/24/19 23:00	1.1			1.8			14.3		1	0	X		0	X		0	X	1
07/25/19 0:00	1.3			1.7			14.2		1	0	X		0	X		0	X	1
07/25/19 1:00	1.3			1.7			14.2		1	0	X		0	X		0	X	1
07/25/19 2:00	0.8			1.7			14.5		1	0	X		0	X		0	X	1
07/25/19 3:00	0.8			1.7			14.5		1	0	X		0	X		0	X	1
07/25/19 4:00	0.8			1.7			14.5		1	0	X		0	X		0	X	1
07/25/19 5:00	0.9			1.7			14.5		1	0	X		0	X		0	X	1
07/25/19 6:00	0.8			1.7			14.5		1	0	X		0	X		0	X	1
07/25/19 7:00	1			1.7			14.3		1	0	X		0	X		0	X	1
07/25/19 8:00	0.2			1.6			11.9		1	0	X		0	X		0	X	1
07/25/19 9:00	0.2			1.7			11.8		1	0	X		0	X		0	X	1
07/25/19 10:00	0.2			1.7			11.8		1	0	X		0	X		0	X	1
07/25/19 11:00	0.2			1.7			11.8		1	0	X		0	X		0	X	1
07/25/19 12:00	0.2			1.7			11.8		1	0	X		0	X		0	X	1
07/25/19 13:00	0.2			1.7			11.8		1	0	X		0	X		0	X	1
07/25/19 14:00	0.2			1.7			11.8		1	0	X		0	X		0	X	1
07/25/19 15:00	0.2			1.7			11.8		1	0	X		0	X		0	X	1
07/25/19 16:00	0.3			1.7			12.8		1	0	X		0	X		0	X	1
07/25/19 17:00	0.4			1.7			13		1	0	X		0	X		0	X	1
07/25/19 18:00	0.9			1.7			13.7		1	0	X		0	X		0	X	1
07/25/19 19:00	0.6			1.7			13.2		1	0	X		0	X		0	X	1
07/25/19 20:00	0.3			1.7			12.4		1	0	X		0	X		0	X	1
07/25/19 21:00	0.4			1.7			12.8		1	0	X		0	X		0	X	1
07/25/19 22:00	1.1			1.8			14.4		1	0	X		0	X		0	X	1
07/25/19 23:00	0.9			1.7			14.2		1	0	X		0	X		0	X	1
07/26/19 0:00	0.8			1.7			13.6		1	0	X		0	X		0	X	1
07/26/19 1:00	0.9			1.8			14.5		1	0	X		0	X		0	X	1
07/26/19 2:00	0.7			1.7			14.5		1	0	X		0	X		0	X	1
07/26/19 3:00	0.7			1.7			14.5		1	0	X		0	X		0	X	1
07/26/19 4:00	0.8			1.7			14.5		1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/26/19 5:00	0.8			1.7			14.4		1	0	X		0	X		0	X	1
07/26/19 6:00	1.2			1.7			14		1	0	X		0	X		0	X	1
07/26/19 7:00	1.2			1.7			13.9		1	0	X		0	X		0	X	1
07/26/19 8:00	1.1			1.7			13.9		1	0	X		0	X		0	X	1
07/26/19 9:00	1			1.7			13.8		1	0	X		0	X		0	X	1
07/26/19 10:00	0.5			1.7			13		1	0	X		0	X		0	X	1
07/26/19 11:00	0.2			1.7			11.8		1	0	X		0	X		0	X	1
07/26/19 12:00	0.2			1.7			11.8		1	0	X		0	X		0	X	1
07/26/19 13:00	0.2			1.7			12.5		1	0	X		0	X		0	X	1
07/26/19 14:00	0.2			1.7			12.5		1	0	X		0	X		0	X	1
07/26/19 15:00	0.2			1.7			11.8		1	0	X		0	X		0	X	1
07/26/19 16:00	0.2			1.7			11.8		1	0	X		0	X		0	X	1
07/26/19 17:00	0.2			1.7			11.8		1	0	X		0	X		0	X	1
07/26/19 18:00	0.2			1.7			12.1		1	0	X		0	X		0	X	1
07/26/19 19:00	0.3			1.7			12.6		1	0	X		0	X		0	X	1
07/26/19 20:00	0.2			1.7			12.2		1	0	X		0	X		0	X	1
07/26/19 21:00	0.2			1.7			12		1	0	X		0	X		0	X	1
07/26/19 22:00	0.5			1.7			13.1		1	0	X		0	X		0	X	1
07/26/19 23:00	0.7			1.7			13.4		1	0	X		0	X		0	X	1
07/27/19 0:00	1.1			1.7			13.8		1	0	X		0	X		0	X	1
07/27/19 1:00	1.2			1.7			14		1	0	X		0	X		0	X	1
07/27/19 2:00	0.9			1.7			14.3		1	0	X		0	X		0	X	1
07/27/19 3:00	0.9			1.7			14.3		1	0	X		0	X		0	X	1
07/27/19 4:00	0.9			1.7			14.3		1	0	X		0	X		0	X	1
07/27/19 5:00	1			1.7			14.3		1	0	X		0	X		0	X	1
07/27/19 6:00	1			1.7			14.3		1	0	X		0	X		0	X	1
07/27/19 7:00	0.9			1.7			14.4		1	0	X		0	X		0	X	1
07/27/19 8:00	0.9			1.7			14.4		1	0	X		0	X		0	X	1
07/27/19 9:00	0.9			1.7			14.4		1	0	X		0	X		0	X	1
07/27/19 10:00	0.8			1.7			14.5		1	0	X		0	X		0	X	1
07/27/19 11:00	1.5			1.7			14.4		1	0	X		0	X		0	X	1
07/27/19 12:00	1.4			1.7			14.5		1	0	X		0	X		0	X	1
07/27/19 13:00	1.4			1.7			14.5		1	0	X		0	X		0	X	1
07/27/19 14:00	1.5			1.7			14.5		1	0	X		0	X		0	X	1
07/27/19 15:00	1.5			1.7			14.3		1	0	X		0	X		0	X	1
07/27/19 16:00	0.3			1.7			11.9		1	0	X		0	X		0	X	1
07/27/19 17:00	0.2			1.7			11.9		1	0	X		0	X		0	X	1
07/27/19 18:00	0.2			1.7			11.9		1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/27/19 19:00	0.2			1.7			11.9		1	0	X		0	X		0	X	1
07/27/19 20:00	0.3			1.7			11.9		1	0	X		0	X		0	X	1
07/27/19 21:00	0.2			1.7			11.9		1	0	X		0	X		0	X	1
07/27/19 22:00	0.4			1.6			12.3		1	0			0			17.7		1
07/27/19 23:00	0.9			1.8			14.4		1	1			1.3			14.3		1
07/28/19 0:00	0.9			1.7			14.4		1	1			1.7			14.4		1
07/28/19 1:00	1			1.7			14.3		1	1			1.6			14.3		1
07/28/19 2:00	0.9			1.7			14.3		1	0.9			1.6			14.4		1
07/28/19 3:00	0.9			1.7			14.3		1	1			1.7			14.3		1
07/28/19 4:00	1			1.7			14.3		1	1			1.7			14.3		1
07/28/19 5:00	1			1.7			14.3		1	1.1			1.7			14.3		1
07/28/19 6:00	1			1.7			14.3		1	1.1			1.7			14.3		1
07/28/19 7:00	1			1.7			14.3		1	1.1			1.7			14.3		1
07/28/19 8:00	0.9			1.7			14.3		1	1			1.7			14.3		1
07/28/19 9:00	0.8			1.7			14.4		1	0.9			1.7			14.4		1
07/28/19 10:00	1.3			1.7			14.5		1	1.7			1.7			14.5		1
07/28/19 11:00	1.4			1.7			14.4		1	1.8			1.7			14.4		1
07/28/19 12:00	0.4			1.7			12.7		1	0.5			1.7			12.8		1
07/28/19 13:00	0.2			1.7			12		1	0.3			1.7			12		1
07/28/19 14:00	0.2			1.7			11.8		1	0.3			1.7			11.8		1
07/28/19 15:00	0.2			1.7			11.8		1	0.3			1.7			11.9		1
07/28/19 16:00	0.1			1.7			11.8		1	0.3			1.7			11.9		1
07/28/19 17:00	0.2			1.7			11.8		1	0.3			1.7			11.9		1
07/28/19 18:00	0.2			1.7			11.9		1	0.3			1.7			12		1
07/28/19 19:00	0.5			1.7			13.2		1	0.6			1.7			13.2		1
07/28/19 20:00	0.2			1.7			11.9		1	0.3			1.7			12		1
07/28/19 21:00	0.2			1.7			12.1		1	0.3			1.7			12.2		1
07/28/19 22:00	0.5			1.7			13.2		1	0.6			1.7			13.2		1
07/28/19 23:00	0.9			1.8			14.4		1	1			1.7			14.4		1
07/29/19 0:00	0.8			1.7			14.5		1	0.9			1.7			14.5		1
07/29/19 1:00	0.8			1.7			14.5		1	0.9			1.7			14.5		1
07/29/19 2:00	0.8			1.7			14.4		1	0.9			1.7			14.4		1
07/29/19 3:00	0.8			1.7			14.4		1	0.9			1.7			14.4		1
07/29/19 4:00	0.8			1.7			14.4		1	0.9			1.7			14.4		1
07/29/19 5:00	0.9			1.7			14.4		1	0.9			1.7			14.5		1
07/29/19 6:00	0.8			1.7			13.5		1	0.9			1.7			13.6		1
07/29/19 7:00	0.5			1.7			13		1	0.6			1.7			13.1		1
07/29/19 8:00	0.8			1.8			14.5		1	0.9			1.7			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/29/19 9:00	0.7			1.7			14.5		1	0.9			1.7			14.5		1
07/29/19 10:00	0.6			1.7			13.2		1	0.7			1.7			13.3		1
07/29/19 11:00	0.3			1.7			12.6		1	0.4			1.7			12.7		1
07/29/19 12:00	1.3			1.8			14.4		1	1.6			1.8			14.5		1
07/29/19 13:00	0.4			1.7			12.2		1	0.5			1.7			12.3		1
07/29/19 14:00	0.2			1.7			11.7		1	0.3			1.7			11.8		1
07/29/19 15:00	0.2			1.7			11.7		1	0.3			1.7			11.8		1
07/29/19 16:00	0.1			1.7			12		1	0.3			1.7			12.1		1
07/29/19 17:00	0.1			1.7			12		1	0.3			1.7			12.1		1
07/29/19 18:00	0.2			1.7			12.1		1	0.3			1.7			12.2		1
07/29/19 19:00	0.5			1.7			13.1		1	0.6			1.7			13.2		1
07/29/19 20:00	0.2			1.7			12.3		1	0.3			1.7			12.5		1
07/29/19 21:00	0.4			1.7			12.9		1	0.4			1.7			13		1
07/29/19 22:00	0.9			1.8			14.3		1	1			1.7			14.3		1
07/29/19 23:00	0.7			1.7			14.4		1	0.9			1.7			14.4		1
07/30/19 0:00	0.7			1.7			14.5		1	0.8			1.7			14.5		1
07/30/19 1:00	0.7			1.7			14.5		1	0.9			1.7			14.5		1
07/30/19 2:00	0.7			1.7			14.5		1	0.8			1.7			14.5		1
07/30/19 3:00	0.7			1.7			14.5		1	0.9			1.7			14.5		1
07/30/19 4:00	0.7			1.7			14.5		1	0.9			1.7			14.4		1
07/30/19 5:00	0.9			1.7			14.3		1	1			1.7			14.4		1
07/30/19 6:00	0.9			1.7			14.3		1	0.9			1.7			14.4		1
07/30/19 7:00	0.8			1.7			14.4		1	0.9			1.7			14.5		1
07/30/19 8:00	0.8			1.7			14.5		1	0.9			1.7			14.5		1
07/30/19 9:00	0.8			1.7			14.4		1	0.9			1.7			14.5		1
07/30/19 10:00	0.8			1.7			14.5		1	0.9			1.7			14.6		1
07/30/19 11:00	0.8			1.7			14.4		1	0.9			1.7			14.6		1
07/30/19 12:00	0.8			1.7			14.5		1	0.9			1.7			14.6		1
07/30/19 13:00	0.8			1.7			14.5		1	0.9			1.7			14.5		1
07/30/19 14:00	0.8			1.7			14.5		1	0.9			1.7			14.5		1
07/30/19 15:00	0.8			1.7			14.5		1	1			1.7			14.5		1
07/30/19 16:00	0.8			1.7			14.6		1	1			1.7			14.6		1
07/30/19 17:00	0.9			1.7			14.4		1	1.2			1.7			14.4		1
07/30/19 18:00	0.7			1.7			14.4		1	0.9			1.7			14.4		1
07/30/19 19:00	0.8			1.7			14.3		1	0.9			1.7			14.4		1
07/30/19 20:00	0.8			1.7			14.4		1	0.9			1.7			14.4		1
07/30/19 21:00	0.8			1.7			14.3		1	0.9			1.7			14.4		1
07/30/19 22:00	0.8			1.7			14.4		1	0.9			1.7			14.4		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/30/19 23:00	0.9			1.7			14.3		1	1			1.7			14.3		1
07/31/19 0:00	0.8			1.7			14.4		1	0.9			1.7			14.4		1
07/31/19 1:00	0.8			1.7			14.5		1	0.8			1.7			14.5		1
07/31/19 2:00	0.8			1.7			14.4		1	0.8			1.7			14.5		1
07/31/19 3:00	0.8			1.7			14.4		1	0.9			1.7			14.5		1
07/31/19 4:00	0.8			1.7			14.4		1	0.8			1.7			14.5		1
07/31/19 5:00	0.8			1.7			14.5		1	0.8			1.7			14.5		1
07/31/19 6:00	0.8			1.7			14.5		1	0.8			1.7			14.5		1
07/31/19 7:00	0.8			1.7			14.4		1	0.9			1.7			14.4		1
07/31/19 8:00	0.9			1.7			14.4		1	1			1.7			14.4		1
07/31/19 9:00	0.7			1.7			14.5		1	0.9			1.7			14.5		1
07/31/19 10:00	0.7			1.7			14.6		1	0.8			1.7			14.6		1
07/31/19 11:00	0.7			1.7			14.6		1	0.8			1.7			14.6		1
07/31/19 12:00	0.8			1.7			14.6		1	0.9			1.7			14.6		1
07/31/19 13:00	0.8			1.7			14.6		1	0.9			1.7			14.6		1
07/31/19 14:00	0.4			1.7			12.6		1	0.6			1.6			12.6		1
07/31/19 15:00	0.3			1.7			12.7		1	0.4			1.7			12.7		1
07/31/19 16:00	0.4			1.7			12.8		1	0.4			1.7			12.9		1
07/31/19 17:00	0.4			1.7			13		1	0.4			1.7			13		1
07/31/19 18:00	0.4			1.7			13		1	0.4			1.7			13		1
07/31/19 19:00	0.4			1.7			12.9		1	0.4			1.7			12.9		1
07/31/19 20:00	0.8			1.8			14.4		1	0.9			1.7			14.4		1
07/31/19 21:00	0.8			1.7			14.4		1	0.9			1.7			14.4		1
07/31/19 22:00	0.8			1.7			14.4		1	0.8			1.7			14.4		1
07/31/19 23:00	0.8			1.7			14.5		1	0.8			1.7			14.5		1
08/01/19 0:00	0.7			1.7			14.5		1	0.8			1.7			14.5		1
08/01/19 1:00	0.7			1.7			14.5		1	0.8			1.7			14.5		1
08/01/19 2:00	0.7			1.7			14.5		1	0.8			1.7			14.5		1
08/01/19 3:00	0.7			1.7			14.5		1	0.8			1.7			14.5		1
08/01/19 4:00	0.7			1.7			14.5		1	0.8			1.7			14.4		1
08/01/19 5:00	0.7			1.7			14.5		1	0.9			1.7			14.4		1
08/01/19 6:00	0.7			1.7			14.5		1	0.9			1.7			14.4		1
08/01/19 7:00	0.7			1.7			14.4		1	0.9			1.7			14.3		1
08/01/19 8:00	0.7			1.7			14.5		1	0.9			1.7			14.4		1
08/01/19 9:00	0.8			1.7			14.4		1	0.9			1.7			14.4		1
08/01/19 10:00	0.7			1.7			14.5		1	0.9			1.6			14.4		1
08/01/19 11:00	0.7			1.7			14.6		1	0.9			1.7			14.4		1
08/01/19 12:00	0.7			1.7			14.6		1	0.8			1.7			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/01/19 13:00	0.7			1.7			14.5		1	0.8			1.7			14.5		1
08/01/19 14:00	0.7			1.7			14.5		1	0.8			1.7			14.5		1
08/01/19 15:00	0.8			1.7			14.5		1	1			1.7			14.5		1
08/01/19 16:00	0.9			1.7			13.8		1	1.1			1.7			13.9		1
08/01/19 17:00	0.9			1.7			13.7		1	0.9			1.7			13.7		1
08/01/19 18:00	0.3			1.7			12.8		1	0.5			1.7			12.8		1
08/01/19 19:00	0.8			1.8			14.4		1	0.9			1.7			14.5		1
08/01/19 20:00	0.7			1.7			14.4		1	0.8			1.7			14.5		1
08/01/19 21:00	0.8			1.7			14.4		1	0.8			1.7			14.5		1
08/01/19 22:00	0.7			1.7			14.4		1	0.8			1.7			14.5		1
08/01/19 23:00	0.7			1.7			14.5		1	0.8			1.7			14.5		1
08/02/19 0:00	0.7			1.7			14.5		1	0.7			1.7			14.5		1
08/02/19 1:00	0.7			1.7			14.5		1	0.8			1.7			14.5		1
08/02/19 2:00	0.7			1.7			14.5		1	0.8			1.7			14.5		1
08/02/19 3:00	0.7			1.7			14.5		1	0.8			1.7			14.5		1
08/02/19 4:00	0.7			1.7			14.5		1	0.8			1.7			14.5		1
08/02/19 5:00	0.7			1.7			14.5		1	0.8			1.7			14.5		1
08/02/19 6:00	0.7			1.7			14.5		1	0.8			1.7			14.5		1
08/02/19 7:00	0.7			1.7			14.5		1	0.8			1.7			14.5		1
08/02/19 8:00	0.7			1.7			14.5		1	0.8			1.7			14.5		1
08/02/19 9:00	0.7			1.7			14.5		1	0.8			1.7			14.5		1
08/02/19 10:00	0.7			1.7			14.6		1	0.8			1.7			14.5		1
08/02/19 11:00	0.7			1.7			14.6		1	0.8			1.7			14.6		1
08/02/19 12:00	0.8			1.7			14.5		1	0.9			1.7			14.5		1
08/02/19 13:00	1			1.7			14.2		1	1.2			1.7			14.2		1
08/02/19 14:00	1			1.7			14.1		1	1.2			1.7			14.1		1
08/02/19 15:00	0.3			1.7			12.4		1	0.4			1.7			12.4		1
08/02/19 16:00	0.2			1.7			12.2		1	0.3			1.7			12.3		1
08/02/19 17:00	0.2			1.7			12.1		1	0.3			1.7			12.2		1
08/02/19 18:00	0.5			1.7			13.1		1	0.5			1.7			13.2		1
08/02/19 19:00	1			1.8			14.1		1	1.1			1.7			14.1		1
08/02/19 20:00	0.9			1.7			14.3		1	0.9			1.7			14.3		1
08/02/19 21:00	0.8			1.7			14.4		1	0.9			1.7			14.4		1
08/02/19 22:00	0.8			1.7			14.5		1	0.9			1.7			14.5		1
08/02/19 23:00	0.8			1.7			14.4		1	0.9			1.7			14.4		1
08/03/19 0:00	0.8			1.7			14.4		1	0.9			1.7			14.4		1
08/03/19 1:00	0.8			1.7			14.5		1	0.8			1.7			14.5		1
08/03/19 2:00	0.7			1.7			14.5		1	0.8			1.7			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/03/19 3:00	0.7			1.7			14.5		1	0.8			1.7			14.5		1
08/03/19 4:00	0.7			1.7			14.5		1	0.8			1.7			14.5		1
08/03/19 5:00	0.8			1.7			14.5		1	0.8			1.7			14.5		1
08/03/19 6:00	0.7			1.7			14.5		1	0.8			1.7			14.5		1
08/03/19 7:00	0.8			1.7			14.4		1	0.9			1.7			14.5		1
08/03/19 8:00	0.8			1.7			14.5		1	0.9			1.7			14.5		1
08/03/19 9:00	0.7			1.7			14.5		1	0.9			1.7			14.5		1
08/03/19 10:00	0.8			1.7			14.5		1	0.9			1.7			14.5		1
08/03/19 11:00	0.8			1.7			14.5		1	0.9			1.7			14.5		1
08/03/19 12:00	0.8			1.7			14.5		1	0.9			1.7			14.6		1
08/03/19 13:00	1.1			1.7			14		1	1.3			1.7			14		1
08/03/19 14:00	0.7			1.7			13.5		1	0.8			1.7			13.5		1
08/03/19 15:00	0.2			1.7			11.7		1	0.3			1.7			11.8		1
08/03/19 16:00	0.2			1.7			11.8		1	0.3			1.7			11.9		1
08/03/19 17:00	0.2			1.7			12.1		1	0.3			1.7			12.2		1
08/03/19 18:00	0.2			1.7			11.9		1	0.3			1.7			12		1
08/03/19 19:00	0.2			1.7			12.6		1	0.4			1.7			12.6		1
08/03/19 20:00	1			1.7			13.9		1	1			1.7			13.9		1
08/03/19 21:00	0.8			1.7			14.4		1	0.9			1.7			14.4		1
08/03/19 22:00	0.8			1.7			14.3		1	0.9			1.7			14.3		1
08/03/19 23:00	0.8			1.7			14.4		1	0.9			1.7			14.4		1
08/04/19 0:00	0.8			1.7			14.4		1	0.9			1.7			14.5		1
08/04/19 1:00	0.8			1.7			14.4		1	0.8			1.7			14.4		1
08/04/19 2:00	0.8			1.7			14.4		1	0.9			1.7			14.4		1
08/04/19 3:00	0.7			1.7			14.4		1	0.9			1.7			14.4		1
08/04/19 4:00	0.7			1.7			14.5		1	0.8			1.7			14.4		1
08/04/19 5:00	0.8			1.7			14.4		1	0.9			1.7			14.4		1
08/04/19 6:00	0.7			1.7			14.5		1	0.8			1.7			14.5		1
08/04/19 7:00	0.7			1.7			14.5		1	0.8			1.7			14.5		1
08/04/19 8:00	0.8			1.7			14.5		1	0.9			1.7			14.5		1
08/04/19 9:00	0.7			1.7			14.5		1	0.9			1.7			14.5		1
08/04/19 10:00	0.7			1.7			14.5		1	0.8			1.7			14.5		1
08/04/19 11:00	0.8			1.7			14.5		1	0.9			1.7			14.5		1
08/04/19 12:00	0.7			1.7			13.9		1	0.8			1.7			13.9		1
08/04/19 13:00	0.2			1.7			12.5		1	0.4			1.7			12.6		1
08/04/19 14:00	0.3			1.7			12.6		1	0.4			1.7			12.7		1
08/04/19 15:00	0.2			1.7			12.4		1	0.3			1.7			12.5		1
08/04/19 16:00	0.3			1.7			12.8		1	0.4			1.7			12.9		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/04/19 17:00	0.2			1.7			12.5		1	0.4			1.7			12.6		1
08/04/19 18:00	0.1			1.7			11.9		1	0.3			1.7			12		1
08/04/19 19:00	0.1			1.7			11.9		1	0.3			1.7			12		1
08/04/19 20:00	0.2			1.7			12.5		1	0.4			1.7			12.6		1
08/04/19 21:00	1			1.7			13.8		1	1			1.7			13.8		1
08/04/19 22:00	0.9			1.7			14.4		1	0.9			1.7			14.5		1
08/04/19 23:00	0.8			1.7			14.4		1	0.9			1.7			14.4		1
08/05/19 0:00	0.7			1.7			14.5		1	0.8			1.7			14.6		1
08/05/19 1:00	0.7			1.7			14.5		1	0.7			1.7			14.5		1
08/05/19 2:00	0.7			1.7			14.5		1	0.8			1.7			14.5		1
08/05/19 3:00	0.7			1.7			14.5		1	0.8			1.7			14.5		1
08/05/19 4:00	0.7			1.7			14.5		1	0.8			1.7			14.5		1
08/05/19 5:00	0.8			1.7			14.5		1	0.8			1.7			14.5		1
08/05/19 6:00	0.8			1.7			14.4		1	0.9			1.7			14.4		1
08/05/19 7:00	0.8			1.7			14.4		1	0.9			1.7			14.4		1
08/05/19 8:00	0.8			1.7			14.5		1	0.9			1.7			14.4		1
08/05/19 9:00	0	X		0	X		0	X	0	0.9			1.7			14.4		1
08/05/19 10:00	0	X		0	X		0	X	0	0.9			1.7			14.4		1
08/05/19 11:00	0.7			1.7			14.5		1	1			1.7			14.5		1
08/05/19 12:00	0.7			1.6			14.6		1	0.9			1.7			14.7		1
08/05/19 13:00	0.7			1.7			14.6		1	0	X		0	X		0	X	0
08/05/19 14:00	0.7			1.7			14.6		1	0	X		0	X		0	X	0
08/05/19 15:00	0.2			1.7			12.5		1	0.4			1.5			12.5		1
08/05/19 16:00	0.1			1.7			12.3		1	0.3			1.7			12.4		1
08/05/19 17:00	0.1			1.7			11.8		1	0.3			1.7			11.9		1
08/05/19 18:00	0.1			1.7			11.8		1	0.3			1.7			11.8		1
08/05/19 19:00	0.2			1.7			12.6		1	0.4			1.7			12.6		1
08/05/19 20:00	0.8			1.8			14.4		1	1			1.7			14.3		1
08/05/19 21:00	0.8			1.7			14.7		1	0.9			1.7			14.6		1
08/05/19 22:00	0.8			1.7			14.5		1	1			1.7			14.4		1
08/05/19 23:00	0.7			1.7			14.6		1	0.9			1.7			14.6		1
08/06/19 0:00	0.7			1.7			14.6		1	0.8			1.7			14.6		1
08/06/19 1:00	0.7			1.7			14.6		1	0.8			1.7			14.6		1
08/06/19 2:00	0.7			1.7			14.6		1	0.8			1.7			14.6		1
08/06/19 3:00	0.7			1.7			14.5		1	0.9			1.7			14.5		1
08/06/19 4:00	0.7			1.7			14.5		1	0.8			1.7			14.5		1
08/06/19 5:00	0.9			1.7			14.4		1	1			1.7			14.4		1
08/06/19 6:00	0.8			1.7			14.4		1	1			1.7			14.4		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/06/19 7:00	0.8			1.7			14.4		1	1			1.7			14.4		1
08/06/19 8:00	0.8			1.7			14.4		1	1			1.7			14.4		1
08/06/19 9:00	0.7			1.7			14.6		1	0.9			1.7			14.6		1
08/06/19 10:00	0.8			1.7			14.5		1	0.9			1.7			14.5		1
08/06/19 11:00	0.7			1.7			14.6		1	0.9			1.7			14.6		1
08/06/19 12:00	0.7			1.7			14.6		1	0.8			1.7			14.6		1
08/06/19 13:00	1.1			1.7			14.1		1	1.6			1.7			14.1		1
08/06/19 14:00	0.1			1.7			11.8		1	0.3			1.7			11.9		1
08/06/19 15:00	0.1			1.7			12		1	0.3			1.7			12.1		1
08/06/19 16:00	0.1			1.7			12		1	0.3			1.7			12		1
08/06/19 17:00	0.1			1.7			11.8		1	0.3			1.7			11.9		1
08/06/19 18:00	0.1			1.7			12.3		1	0.3			1.7			12.3		1
08/06/19 19:00	0.7			1.7			13.7		1	0.9			1.7			13.7		1
08/06/19 20:00	0.6			1.7			13.5		1	0.8			1.7			13.5		1
08/06/19 21:00	0.7			1.7			14.5		1	0.9			1.7			14.5		1
08/06/19 22:00	0.7			1.7			14.4		1	1			1.7			14.4		1
08/06/19 23:00	0.7			1.7			14.6		1	0.8			1.7			14.6		1
08/07/19 0:00	0.7			1.7			14.6		1	0.8			1.7			14.6		1
08/07/19 1:00	0.7			1.7			14.6		1	0.8			1.7			14.6		1
08/07/19 2:00	0.6			1.7			14.5		1	0.8			1.7			14.6		1
08/07/19 3:00	0.6			1.7			14.5		1	0.8			1.7			14.5		1
08/07/19 4:00	0.7			1.7			14.5		1	0.8			1.7			14.5		1
08/07/19 5:00	0.7			1.7			14.5		1	0.8			1.7			14.5		1
08/07/19 6:00	0.7			1.7			14.4		1	0.9			1.7			14.4		1
08/07/19 7:00	0.7			1.7			14.5		1	1			1.7			14.4		1
08/07/19 8:00	0.8			1.7			14.4		1	1			1.7			14.4		1
08/07/19 9:00	0.8			1.7			14.4		1	1			1.7			14.4		1
08/07/19 10:00	0.8			1.7			14.4		1	1			1.7			14.4		1
08/07/19 11:00	0.8			1.7			14.4		1	1			1.7			14.4		1
08/07/19 12:00	0.7			1.7			14.5		1	0.9			1.7			14.5		1
08/07/19 13:00	1.2			1.7			14.2		1	1.8			1.7			14.2		1
08/07/19 14:00	0.3			1.7			12.9		1	0.5			1.7			12.9		1
08/07/19 15:00	0.1			1.7			12.5		1	0.4			1.7			12.5		1
08/07/19 16:00	0.1			1.7			12.2		1	0.3			1.7			12.3		1
08/07/19 17:00	0.1			1.7			11.8		1	0.3			1.7			11.9		1
08/07/19 18:00	0.2			1.7			12.3		1	0.3			1.7			12.4		1
08/07/19 19:00	1			1.8			14.1		1	1.1			1.7			14.1		1
08/07/19 20:00	0.7			1.7			14.5		1	0.9			1.7			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/07/19 21:00	0.7			1.7			14.5		1	1			1.7			14.4		1
08/07/19 22:00	0.7			1.7			14.5		1	0.8			1.7			14.6		1
08/07/19 23:00	0.8			1.7			14.4		1	1			1.7			14.4		1
08/08/19 0:00	0.7			1.7			14.5		1	1			1.7			14.4		1
08/08/19 1:00	0.6			1.7			14.5		1	0.8			1.7			14.5		1
08/08/19 2:00	0.6			1.7			14.5		1	0.8			1.7			14.5		1
08/08/19 3:00	0.6			1.7			14.5		1	0.8			1.7			14.5		1
08/08/19 4:00	0.6			1.7			14.7		1	0.8			1.7			14.5		1
08/08/19 5:00	0	X		0	X		0	X	1	0			0			16.6		1
08/08/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/08/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/08/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/08/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/08/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/08/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/08/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/08/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/08/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/08/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/08/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/08/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/08/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/08/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/08/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/08/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/08/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/08/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/09/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/09/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/09/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/09/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/09/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/09/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/09/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/09/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/09/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/09/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/09/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/09/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/09/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/09/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/09/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/09/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/09/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/09/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/09/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/09/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/09/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/09/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/09/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/09/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/10/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/10/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/10/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/10/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/10/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/10/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/10/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/10/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/10/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/10/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/10/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/10/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/10/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/10/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/10/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/10/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/10/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/10/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/10/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/10/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/10/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/10/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/10/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/10/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/11/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/11/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/11/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/11/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/11/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/11/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/11/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/11/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/11/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/11/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/11/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/11/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/11/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/11/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/11/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/11/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/11/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/11/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/11/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/11/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/11/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/11/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/11/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/11/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/12/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/12/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/12/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/12/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/12/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/12/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/12/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/12/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/12/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/12/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/12/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/12/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/12/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/12/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/12/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/12/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/12/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/12/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/12/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/12/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/12/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/12/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/12/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/12/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/13/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/13/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/13/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/13/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/13/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/13/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/13/19 6:00	0			0			17.7		1	0	X		0	X		0	X	1
08/13/19 7:00	0.7			1.7			14.5		1	0	X		0	X		0	X	1
08/13/19 8:00	0.7			1.7			14.5		1	0	X		0	X		0	X	1
08/13/19 9:00	0.7			1.7			14.4		1	0	X		0	X		0	X	1
08/13/19 10:00	0.6			1.7			14.5		1	0	X		0	X		0	X	1
08/13/19 11:00	0.7			1.7			14.5		1	0	X		0	X		0	X	1
08/13/19 12:00	0.7			1.7			14.5		1	0	X		0	X		0	X	1
08/13/19 13:00	0.7			1.7			14.5		1	0	X		0	X		0	X	1
08/13/19 14:00	0.7			1.7			14.5		1	0	X		0	X		0	X	1
08/13/19 15:00	0.2			1.7			12		1	0	X		0	X		0	X	1
08/13/19 16:00	0.1			1.7			11.7		1	0	X		0	X		0	X	1
08/13/19 17:00	0.1			1.7			11.7		1	0	X		0	X		0	X	1
08/13/19 18:00	0.3			1.7			12.6		1	0	X		0	X		0	X	1
08/13/19 19:00	0.1			1.7			11.9		1	0	X		0	X		0	X	1
08/13/19 20:00	0.1			1.7			12.1		1	0	X		0	X		0	X	1
08/13/19 21:00	0.3			1.7			12.8		1	0	X		0	X		0	X	1
08/13/19 22:00	1.1			1.7			13.8		1	0	X		0	X		0	X	1
08/13/19 23:00	0.4			1.7			12.7		1	0	X		0	X		0	X	1
08/14/19 0:00	0.6			1.7			13.3		1	0	X		0	X		0	X	1
08/14/19 1:00	0.7			1.7			13.5		1	0	X		0	X		0	X	1
08/14/19 2:00	1.1			1.7			13.9		1	0	X		0	X		0	X	1
08/14/19 3:00	1.1			1.7			13.9		1	0	X		0	X		0	X	1
08/14/19 4:00	0.2			1.7			12.3		1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/14/19 5:00	0.3			1.7			12.2		1	0	X		0	X		0	X	1
08/14/19 6:00	0.4			1.7			12.1		1	0			0			17.5		1
08/14/19 7:00	1			1.8			14.4		1	1.1			1.5			14.4		1
08/14/19 8:00	0.7			1.7			14.6		1	0.8			1.8			14.6		1
08/14/19 9:00	0.7			1.7			14.6		1	0.8			1.6			14.6		1
08/14/19 10:00	0.7			1.7			14.6		1	0.8			1.7			14.6		1
08/14/19 11:00	0.7			1.7			14.6		1	0.9			1.7			14.7		1
08/14/19 12:00	0.8			1.7			14.7		1	0.9			1.7			14.7		1
08/14/19 13:00	0.9			1.7			14.5		1	1.2			1.7			14.5		1
08/14/19 14:00	1.4			1.7			14.2		1	1.7			1.7			14.2		1
08/14/19 15:00	0.1			1.7			12		1	0.3			1.7			12		1
08/14/19 16:00	0.1			1.7			11.9		1	0.3			1.7			11.9		1
08/14/19 17:00	0.1			1.7			11.9		1	0.3			1.7			12		1
08/14/19 18:00	0.3			1.7			13		1	0.5			1.7			13		1
08/14/19 19:00	0.1			1.7			12.3		1	0.3			1.7			12.3		1
08/14/19 20:00	0.4			1.8			13.2		1	0.6			1.7			13.2		1
08/14/19 21:00	0.8			1.6			14.6		1	0.9			1.6			14.6		1
08/14/19 22:00	0.8			1.6			14.6		1	0.9			1.6			14.5		1
08/14/19 23:00	0.7			1.6			14.6		1	0.9			1.6			14.6		1
08/15/19 0:00	0.7			1.6			14.6		1	0.8			1.6			14.6		1
08/15/19 1:00	0.7			1.6			14.6		1	0.8			1.6			14.6		1
08/15/19 2:00	0.7			1.6			14.6		1	0.8			1.6			14.6		1
08/15/19 3:00	0.7			1.6			14.6		1	0.8			1.6			14.6		1
08/15/19 4:00	0.7			1.6			14.6		1	0.9			1.6			14.6		1
08/15/19 5:00	0.8			1.7			14.5		1	1			1.7			14.6		1
08/15/19 6:00	1.1			1.7			14.5		1	1.2			1.7			14.5		1
08/15/19 7:00	0.8			1.7			14.5		1	1			1.7			14.5		1
08/15/19 8:00	0.7			1.7			14.6		1	1			1.7			14.7		1
08/15/19 9:00	0.8			1.7			14.7		1	1			1.7			14.6		1
08/15/19 10:00	0.7			1.7			14.6		1	1			1.5			14.7		1
08/15/19 11:00	0.7			1.7			14.6		1	0.9			1.7			14.6		1
08/15/19 12:00	0.7			1.7			14.6		1	0.8			1.7			14.5		1
08/15/19 13:00	0.8			1.7			14.5		1	1			1.7			14.4		1
08/15/19 14:00	0.1			1.7			12		1	0.3			1.7			12		1
08/15/19 15:00	0.1			1.7			11.8		1	0.3			1.7			11.9		1
08/15/19 16:00	0.1			1.7			11.8		1	0.3			1.7			11.9		1
08/15/19 17:00	0.1			1.7			11.8		1	0.3			1.7			11.9		1
08/15/19 18:00	0.1			1.7			12		1	0.3			1.7			12.1		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/15/19 19:00	0.3			1.7			12.9		1	0.4			1.7			12.9		1
08/15/19 20:00	0.7			1.7			13.5		1	0.8			1.7			13.5		1
08/15/19 21:00	1			1.7			14.1		1	1.2			1.7			14.1		1
08/15/19 22:00	1.3			1.7			14.3		1	1.4			1.7			14.3		1
08/15/19 23:00	0.8			1.7			14.5		1	0.9			1.7			14.6		1
08/16/19 0:00	0.7			1.7			14.6		1	0.9			1.7			14.6		1
08/16/19 1:00	0.7			1.7			14.6		1	0.9			1.7			14.6		1
08/16/19 2:00	0.7			1.7			14.6		1	0.8			1.7			14.6		1
08/16/19 3:00	0.7			1.7			14.6		1	0.9			1.7			14.6		1
08/16/19 4:00	0.7			1.7			14.6		1	0.9			1.7			14.6		1
08/16/19 5:00	1.4			1.7			14.5		1	1.4			1.7			14.6		1
08/16/19 6:00	0.8			1.7			14.5		1	1			1.7			14.6		1
08/16/19 7:00	0.8			1.7			14.5		1	1.1			1.7			14.4		1
08/16/19 8:00	0.9			1.7			14.5		1	1.1			1.7			14.5		1
08/16/19 9:00	0.8			1.7			14.5		1	1			1.7			14.6		1
08/16/19 10:00	0.8			1.7			14.6		1	0.9			1.7			14.6		1
08/16/19 11:00	0.7			1.7			14.5		1	0.9			1.7			14.5		1
08/16/19 12:00	0.5			1.7			13.6		1	0.7			1.7			13.5		1
08/16/19 13:00	0.4			1.7			13		1	0.5			1.7			13		1
08/16/19 14:00	0.1			1.7			12.3		1	0.3			1.7			12.3		1
08/16/19 15:00	0.1			1.7			11.7		1	0.3			1.7			11.8		1
08/16/19 16:00	0.3			1.7			12.8		1	0.4			1.7			12.8		1
08/16/19 17:00	0.1			1.7			12.4		1	0.3			1.7			12.4		1
08/16/19 18:00	0.3			1.7			13		1	0.5			1.7			12.9		1
08/16/19 19:00	0.3			1.7			12.8		1	0.4			1.7			12.9		1
08/16/19 20:00	0.1			1.7			12.4		1	0.3			1.7			12.4		1
08/16/19 21:00	0.5			1.7			13.2		1	0.7			1.7			13.3		1
08/16/19 22:00	0.5			1.7			13.3		1	0.8			1.7			13.5		1
08/16/19 23:00	0.2			1.7			12		1	0			0			16.1		1
08/17/19 0:00	0.2			1.7			12.3		1	0	X		0	X		0	X	1
08/17/19 1:00	0.5			1.7			13.2		1	0	X		0	X		0	X	1
08/17/19 2:00	0.7			1.8			14.4		1	0	X		0	X		0	X	1
08/17/19 3:00	0.7			1.7			14.4		1	0	X		0	X		0	X	1
08/17/19 4:00	0.7			1.7			14.4		1	0	X		0	X		0	X	1
08/17/19 5:00	0.8			1.7			14.4		1	0	X		0	X		0	X	1
08/17/19 6:00	0.8			1.7			14.3		1	0	X		0	X		0	X	1
08/17/19 7:00	0.7			1.7			14.4		1	0	X		0	X		0	X	1
08/17/19 8:00	0.7			1.7			14.4		1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/17/19 9:00	0.7			1.7			14.4		1	0	X		0	X		0	X	1
08/17/19 10:00	0.7			1.7			14.4		1	0	X		0	X		0	X	1
08/17/19 11:00	0.7			1.7			14.5		1	0	X		0	X		0	X	1
08/17/19 12:00	0.7			1.7			14.5		1	0	X		0	X		0	X	1
08/17/19 13:00	0.7			1.7			14.5		1	0	X		0	X		0	X	1
08/17/19 14:00	0.7			1.7			14.4		1	0	X		0	X		0	X	1
08/17/19 15:00	0.7			1.7			14.4		1	0	X		0	X		0	X	1
08/17/19 16:00	0.9			1.7			14		1	0	X		0	X		0	X	1
08/17/19 17:00	0.1			1.7			11.8		1	0	X		0	X		0	X	1
08/17/19 18:00	0.1			1.7			11.8		1	0	X		0	X		0	X	1
08/17/19 19:00	0.4			1.7			12.9		1	0	X		0	X		0	X	1
08/17/19 20:00	0.6			1.7			13.3		1	0	X		0	X		0	X	1
08/17/19 21:00	0.5			1.7			13.3		1	0	X		0	X		0	X	1
08/17/19 22:00	0.8			1.7			13.7		1	0	X		0	X		0	X	1
08/17/19 23:00	0			0			15.9		1	0	X		0	X		0	X	1
08/18/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/18/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/18/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/18/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/18/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/18/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/18/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/18/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/18/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/18/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/18/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/18/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/18/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/18/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/18/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/18/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/18/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/18/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/18/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/18/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/18/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/18/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/18/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/18/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/19/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/19/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/19/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/19/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/19/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/19/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/19/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/19/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/19/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/19/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/19/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/19/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/19/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/19/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/19/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/19/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/19/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/19/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/19/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/19/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/19/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/19/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/19/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/19/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/20/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/20/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/20/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/20/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/20/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/20/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/20/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/20/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/20/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/20/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/20/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/20/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/20/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/20/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/20/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/20/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/20/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/20/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/20/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/20/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/20/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/20/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/20/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/20/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/21/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/21/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/21/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/21/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/21/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/21/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/21/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/21/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/21/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/21/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/21/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/21/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/21/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/21/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/21/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/21/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/21/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/21/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/21/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/21/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/21/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/21/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/21/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/21/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/22/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/22/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/22/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/22/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/22/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/22/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/22/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/22/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/22/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/22/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/22/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/22/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/22/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/22/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/22/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/22/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/22/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/22/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/22/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/22/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/22/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/22/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/22/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/22/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/23/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/23/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/23/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/23/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/23/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/23/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/23/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/23/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/23/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/23/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/23/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/23/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/23/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/23/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/23/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/23/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/23/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/23/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/23/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/23/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/23/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/23/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/23/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/23/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/24/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/24/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/24/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/24/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/24/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/24/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/24/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/24/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/24/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/24/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/24/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/24/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/24/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/24/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/24/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/24/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/24/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/24/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/24/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/24/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/24/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/24/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/24/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/24/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/25/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/25/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/25/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/25/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/25/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/25/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/25/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/25/19 7:00	0	X		0	X		0	X	1	0			0			17.5		1
08/25/19 8:00	0	X		0	X		0	X	1	0.9			1.6			14.5		1
08/25/19 9:00	0	X		0	X		0	X	1	0.9			1.6			14.5		1
08/25/19 10:00	0	X		0	X		0	X	1	0.9			1.7			14.5		1
08/25/19 11:00	0	X		0	X		0	X	1	0.4			1.4			12.2		1
08/25/19 12:00	0	X		0	X		0	X	1	0.3			1.4			11.9		1
08/25/19 13:00	0	X		0	X		0	X	1	0.3			1.5			11.9		1
08/25/19 14:00	0	X		0	X		0	X	1	0.3			1.6			11.9		1
08/25/19 15:00	0	X		0	X		0	X	1	0.3			1.7			11.9		1
08/25/19 16:00	0	X		0	X		0	X	1	0.8			1.7			13.4		1
08/25/19 17:00	0	X		0	X		0	X	1	1			1.7			13.6		1
08/25/19 18:00	0	X		0	X		0	X	1	1			1.7			13.6		1
08/25/19 19:00	0	X		0	X		0	X	1	1			1.7			13.6		1
08/25/19 20:00	0	X		0	X		0	X	1	0.5			1.7			12.7		1
08/25/19 21:00	0	X		0	X		0	X	1	1			1.7			14.5		1
08/25/19 22:00	0	X		0	X		0	X	1	1			1.7			14.5		1
08/25/19 23:00	0	X		0	X		0	X	1	1			1.7			14.4		1
08/26/19 0:00	0	X		0	X		0	X	1	1			1.7			14.4		1
08/26/19 1:00	0	X		0	X		0	X	1	1			1.7			14.4		1
08/26/19 2:00	0	X		0	X		0	X	1	1			1.7			14.5		1
08/26/19 3:00	0	X		0	X		0	X	1	1			1.7			14.5		1
08/26/19 4:00	0	X		0	X		0	X	1	1			1.7			14.5		1
08/26/19 5:00	0	X		0	X		0	X	1	1.1			1.7			14.5		1
08/26/19 6:00	0	X		0	X		0	X	1	1.1			1.7			14.4		1
08/26/19 7:00	0	X		0	X		0	X	1	1.1			1.7			14.4		1
08/26/19 8:00	0	X		0	X		0	X	1	1			1.7			14.5		1
08/26/19 9:00	0	X		0	X		0	X	1	1.2			1.7			14.3		1
08/26/19 10:00	0	X		0	X		0	X	1	0.4			1.7			12.3		1
08/26/19 11:00	0	X		0	X		0	X	1	0.3			1.7			12.3		1
08/26/19 12:00	0	X		0	X		0	X	1	0.3			1.7			12.3		1
08/26/19 13:00	0	X		0	X		0	X	1	0.4			1.7			12.8		1
08/26/19 14:00	0	X		0	X		0	X	1	0.7			1.7			13.4		1
08/26/19 15:00	0	X		0	X		0	X	1	1			1.8			14.5		1
08/26/19 16:00	0	X		0	X		0	X	1	0.9			1.7			13.5		1
08/26/19 17:00	0	X		0	X		0	X	1	0.8			1.7			13.5		1
08/26/19 18:00	0	X		0	X		0	X	1	0.9			1.7			13.6		1
08/26/19 19:00	0	X		0	X		0	X	1	1.1			1.7			14		1
08/26/19 20:00	0	X		0	X		0	X	1	0.7			1.6			13		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/26/19 21:00	0	X		0	X		0	X	1	1			1.7			14.4		1
08/26/19 22:00	0	X		0	X		0	X	1	1			1.7			14.4		1
08/26/19 23:00	0	X		0	X		0	X	1	1			1.7			14.4		1
08/27/19 0:00	0	X		0	X		0	X	1	1			1.7			14.6		1
08/27/19 1:00	0	X		0	X		0	X	1	1			1.7			14.5		1
08/27/19 2:00	0	X		0	X		0	X	1	1			1.7			14.5		1
08/27/19 3:00	0	X		0	X		0	X	1	1			1.7			14.5		1
08/27/19 4:00	0	X		0	X		0	X	1	1			1.6			14.6		1
08/27/19 5:00	0			0			17.7		1	1			1.7			14.5		1
08/27/19 6:00	0.8			1.5			14.4		1	1			1.7			14.5		1
08/27/19 7:00	0.8			1.7			14.4		1	1.1			1.7			14.4		1
08/27/19 8:00	0.8			1.7			14.5		1	1.1			1.7			14.4		1
08/27/19 9:00	0.9			1.7			14.5		1	1.1			1.7			14.5		1
08/27/19 10:00	0.8			1.7			14.5		1	1			1.7			14.5		1
08/27/19 11:00	0.8			1.7			14.6		1	1			1.7			14.5		1
08/27/19 12:00	0.8			1.7			14.7		1	1.1			1.7			14.6		1
08/27/19 13:00	0.6			1.7			13.4		1	0.8			1.5			13.4		1
08/27/19 14:00	0.5			1.7			13.2		1	0.7			1.6			13.2		1
08/27/19 15:00	0.1			1.7			11.8		1	0.3			1.7			11.8		1
08/27/19 16:00	0.1			1.7			11.8		1	0.3			1.7			11.9		1
08/27/19 17:00	0.1			1.7			12		1	0.3			1.7			12		1
08/27/19 18:00	0.1			1.7			12.1		1	0.3			1.7			12.2		1
08/27/19 19:00	0.1			1.7			12.1		1	0.3			1.7			12.2		1
08/27/19 20:00	0.2			1.7			12.3		1	0.3			1.7			12.4		1
08/27/19 21:00	0.9			1.8			14.4		1	1.1			1.7			14.4		1
08/27/19 22:00	0.8			1.7			14.4		1	1			1.7			14.4		1
08/27/19 23:00	0.8			1.7			14.3		1	1			1.7			14.4		1
08/28/19 0:00	0.8			1.7			14.4		1	1			1.7			14.4		1
08/28/19 1:00	0.7			1.7			14.4		1	1			1.7			14.4		1
08/28/19 2:00	0.7			1.7			14.5		1	1			1.7			14.5		1
08/28/19 3:00	0.7			1.7			14.5		1	1			1.7			14.4		1
08/28/19 4:00	0.9			1.7			14.4		1	1.1			1.6			14.4		1
08/28/19 5:00	0.9			1.7			14.4		1	1.1			1.7			14.4		1
08/28/19 6:00	0.9			1.7			14.4		1	1			1.7			14.5		1
08/28/19 7:00	0.4			1.7			12.2		1	0.5			1.7			12.2		1
08/28/19 8:00	0.2			1.7			11.9		1	0.3			1.7			12		1
08/28/19 9:00	0.2			1.7			11.9		1	0.3			1.7			12		1
08/28/19 10:00	0.2			1.7			11.8		1	0.3			1.7			11.9		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/28/19 11:00	0.2			1.7			11.7		1	0.3			1.7			11.8		1
08/28/19 12:00	0.2			1.7			11.7		1	0.3			1.7			11.8		1
08/28/19 13:00	0.1			1.7			11.8		1	0.3			1.7			11.9		1
08/28/19 14:00	0.1			1.7			11.8		1	0.3			1.7			11.8		1
08/28/19 15:00	0.1			1.7			11.8		1	0.3			1.7			11.9		1
08/28/19 16:00	0.1			1.7			11.8		1	0.3			1.7			11.9		1
08/28/19 17:00	0.2			1.7			11.8		1	0.3			1.7			11.9		1
08/28/19 18:00	0.1			1.7			11.9		1	0.3			1.7			12		1
08/28/19 19:00	0.3			1.7			12.6		1	0.4			1.7			12.7		1
08/28/19 20:00	0.9			1.7			13.7		1	1			1.7			13.8		1
08/28/19 21:00	0.8			1.7			14.4		1	0.9			1.7			14.4		1
08/28/19 22:00	0.8			1.7			14.3		1	1			1.7			14.3		1
08/28/19 23:00	0.7			1.7			14.5		1	0.9			1.7			14.4		1
08/29/19 0:00	0.8			1.7			14.4		1	1			1.7			14.3		1
08/29/19 1:00	0.7			1.7			14.5		1	0.9			1.7			14.4		1
08/29/19 2:00	0.7			1.7			14.5		1	0.9			1.7			14.4		1
08/29/19 3:00	0.7			1.7			14.5		1	0.9			1.7			14.4		1
08/29/19 4:00	0.8			1.6			14.4		1	1			1.7			14.3		1
08/29/19 5:00	0.8			1.7			14.5		1	0.9			1.7			14.4		1
08/29/19 6:00	0.8			1.7			14.4		1	1			1.7			14.4		1
08/29/19 7:00	0.8			1.7			14.4		1	1			1.7			14.3		1
08/29/19 8:00	0.8			1.7			14.4		1	0.9			1.7			14.4		1
08/29/19 9:00	0.8			1.7			14.5		1	0.9			1.7			14.5		1
08/29/19 10:00	0.7			1.7			14.5		1	0.8			1.7			14.5		1
08/29/19 11:00	1			1.7			13.7		1	1.1			1.7			13.8		1
08/29/19 12:00	0.5			1.7			13.2		1	0.6			1.7			13.2		1
08/29/19 13:00	0.6			1.7			13.3		1	0.7			1.7			13.3		1
08/29/19 14:00	0.4			1.7			12.9		1	0.4			1.7			12.9		1
08/29/19 15:00	0.3			1.7			12.8		1	0.4			1.7			12.8		1
08/29/19 16:00	0.3			1.7			12.8		1	0.4			1.7			12.8		1
08/29/19 17:00	0.3			1.7			12.8		1	0.4			1.7			12.9		1
08/29/19 18:00	0.3			1.7			12.7		1	0.4			1.7			12.8		1
08/29/19 19:00	0.4			1.7			13.1		1	0.6			1.7			13.1		1
08/29/19 20:00	0.8			1.7			14.5		1	0.9			1.7			14.5		1
08/29/19 21:00	0.8			1.7			14.5		1	0.9			1.7			14.4		1
08/29/19 22:00	0.8			1.7			14.3		1	1			1.7			14.3		1
08/29/19 23:00	0			0			16.2		1	0			0			15.8		1
08/30/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/30/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/30/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/30/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/30/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/30/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/30/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/30/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/30/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/30/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/30/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/30/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/30/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/30/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/30/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/30/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/30/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/30/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/30/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/30/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/30/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/30/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/30/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/30/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/31/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/31/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/31/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/31/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/31/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/31/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/31/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/31/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/31/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/31/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/31/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/31/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/31/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/31/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/31/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/31/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/31/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/31/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/31/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/31/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/31/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/31/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/31/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/31/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/01/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/01/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/01/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/01/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/01/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/01/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/01/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/01/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/01/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/01/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/01/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/01/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/01/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/01/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/01/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/01/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/01/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/01/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/01/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/01/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/01/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/01/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/01/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/01/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/02/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/02/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/02/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/02/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/02/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/02/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/02/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/02/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/02/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/02/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/02/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/02/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/02/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/02/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/02/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/02/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/02/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/02/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/02/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/02/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/02/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/02/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/02/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/02/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/03/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/03/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/03/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/03/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/03/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/03/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/03/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/03/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/03/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/03/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/03/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/03/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/03/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/03/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/03/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/03/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/03/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/03/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/03/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/03/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/03/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/03/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/03/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/03/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/04/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/04/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/04/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/04/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/04/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/04/19 5:00	0			0			17.9		1	0	X		0	X		0	X	1
09/04/19 6:00	3.2			1.7			14.5		1	0			0			18		1
09/04/19 7:00	0.9			1.7			14.5		1	1			1.5			14.5		1
09/04/19 8:00	0.9			1.7			14.5		1	1.1			1.7			14.5		1
09/04/19 9:00	0.8			1.7			14.6		1	1			1.7			14.6		1
09/04/19 10:00	0.8			1.7			14.5		1	1.2			1.7			14.5		1
09/04/19 11:00	0.5			1.7			13.1		1	0.7			1.7			13.2		1
09/04/19 12:00	0.4			1.7			13		1	0.6			1.7			13		1
09/04/19 13:00	0.3			1.7			12.7		1	0.5			1.7			12.7		1
09/04/19 14:00	0.2			1.7			11.8		1	0.4			1.7			11.8		1
09/04/19 15:00	0.2			1.7			11.8		1	0.3			1.7			11.9		1
09/04/19 16:00	0.2			1.7			11.8		1	0.3			1.7			11.9		1
09/04/19 17:00	0.7			1.7			14.4		1	0.9			1.7			14.4		1
09/04/19 18:00	0.7			1.7			14.5		1	0.9			1.7			14.5		1
09/04/19 19:00	0.7			1.7			14.5		1	0.9			1.7			14.5		1
09/04/19 20:00	0.6			1.7			13.3		1	0.8			1.7			13.2		1
09/04/19 21:00	0.9			1.8			14.5		1	1.1			1.7			14.4		1
09/04/19 22:00	0.8			1.7			14.5		1	1			1.7			14.5		1
09/04/19 23:00	0.8			1.7			14.6		1	1			1.7			14.6		1
09/05/19 0:00	0.8			1.7			14.5		1	1			1.7			14.5		1
09/05/19 1:00	0.9			1.7			14.4		1	1.1			1.7			14.5		1
09/05/19 2:00	0.7			1.7			14.6		1	1.1			1.7			14.5		1
09/05/19 3:00	0.7			1.7			14.6		1	1			1.7			14.5		1
09/05/19 4:00	0.8			1.6			14.4		1	1.1			1.7			14.4		1
09/05/19 5:00	0.8			1.7			14.5		1	1.1			1.7			14.4		1
09/05/19 6:00	0.8			1.7			14.4		1	1.1			1.7			14.4		1
09/05/19 7:00	0.9			1.7			14.4		1	1			1.7			14.5		1
09/05/19 8:00	0.8			1.7			14.5		1	1			1.7			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/05/19 9:00	1.4			1.7			14.3		1	1.8			1.7			14.3		1
09/05/19 10:00	1			1.7			13.8		1	1.2			1.7			13.8		1
09/05/19 11:00	0.6			1.7			13.4		1	0.9			1.7			13.4		1
09/05/19 12:00	0.5			1.7			13.1		1	0.7			1.7			13.1		1
09/05/19 13:00	0.2			1.7			11.8		1	0.4			1.7			11.9		1
09/05/19 14:00	0.1			1.7			11.8		1	0.3			1.7			11.9		1
09/05/19 15:00	0.1			1.7			11.8		1	0.3			1.7			11.9		1
09/05/19 16:00	0.3			1.7			12.8		1	0.5			1.7			12.8		1
09/05/19 17:00	0.3			1.7			12.8		1	0.5			1.7			12.8		1
09/05/19 18:00	0.7			1.7			13.6		1	0.9			1.7			13.6		1
09/05/19 19:00	0.8			1.8			14.6		1	1			1.7			14.5		1
09/05/19 20:00	0.8			1.7			14.6		1	1			1.7			14.6		1
09/05/19 21:00	0.7			1.7			14.6		1	0.9			1.7			14.6		1
09/05/19 22:00	0.8			1.7			14.6		1	1			1.7			14.5		1
09/05/19 23:00	0			0			16.2		1	0			0			15.5		1
09/06/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/06/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/06/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/06/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/06/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/06/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/06/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/06/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/06/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/06/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/06/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/06/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/06/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/06/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/06/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/06/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/06/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/06/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/06/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/06/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/06/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/06/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/06/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/06/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/07/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/07/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/07/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/07/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/07/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/07/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/07/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/07/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/07/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/07/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/07/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/07/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/07/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/07/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/07/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/07/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/07/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/07/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/07/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/07/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/07/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/07/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/07/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/07/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/08/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/08/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/08/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/08/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/08/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/08/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/08/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/08/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/08/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/08/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/08/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/08/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/08/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/08/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/08/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/08/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/08/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/08/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/08/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/08/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/08/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/08/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/08/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/08/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/09/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/09/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/09/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/09/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/09/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/09/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/09/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/09/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/09/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/09/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/09/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/09/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/09/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/09/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/09/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/09/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/09/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/09/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/09/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/09/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/09/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/09/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/09/19 22:00	0	X		0	X		0	X	1	0			0			17.5		1
09/09/19 23:00	0	X		0	X		0	X	1	1			1.3			14.4		1
09/10/19 0:00	0	X		0	X		0	X	1	1			1.7			14.4		1
09/10/19 1:00	0	X		0	X		0	X	1	1.1			1.6			14.3		1
09/10/19 2:00	0	X		0	X		0	X	1	1			1.6			14.4		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/10/19 3:00	0	X		0	X		0	X	1	1.1			1.7			14.3		1
09/10/19 4:00	0	X		0	X		0	X	1	1			1.8			14.4		1
09/10/19 5:00	0	X		0	X		0	X	1	1			1.7			14.4		1
09/10/19 6:00	0	X		0	X		0	X	1	1			1.7			14.4		1
09/10/19 7:00	0	X		0	X		0	X	1	1			1.7			14.5		1
09/10/19 8:00	0	X		0	X		0	X	1	1			1.7			14.4		1
09/10/19 9:00	0	X		0	X		0	X	1	1			1.7			14.3		1
09/10/19 10:00	0	X		0	X		0	X	1	1			1.7			14.5		1
09/10/19 11:00	0	X		0	X		0	X	1	1			1.7			14.5		1
09/10/19 12:00	0	X		0	X		0	X	1	0.7			1.7			13		1
09/10/19 13:00	0	X		0	X		0	X	1	1			1.8			14.5		1
09/10/19 14:00	0	X		0	X		0	X	1	0.6			1.6			12.6		1
09/10/19 15:00	0	X		0	X		0	X	1	1			1.8			14.4		1
09/10/19 16:00	0	X		0	X		0	X	1	0.6			1.6			12.4		1
09/10/19 17:00	0	X		0	X		0	X	1	0.4			1.7			12.1		1
09/10/19 18:00	0	X		0	X		0	X	1	0.4			1.7			12.2		1
09/10/19 19:00	0	X		0	X		0	X	1	0.7			1.7			13.1		1
09/10/19 20:00	0	X		0	X		0	X	1	1.2			1.7			14.3		1
09/10/19 21:00	0	X		0	X		0	X	1	1			1.7			14.5		1
09/10/19 22:00	0	X		0	X		0	X	1	1.1			1.7			14.5		1
09/10/19 23:00	0	X		0	X		0	X	1	1.2			1.7			14.4		1
09/11/19 0:00	0	X		0	X		0	X	1	1.1			1.7			14.5		1
09/11/19 1:00	0	X		0	X		0	X	1	1.1			1.7			14.5		1
09/11/19 2:00	0	X		0	X		0	X	1	1.1			1.7			14.5		1
09/11/19 3:00	0	X		0	X		0	X	1	1.1			1.7			14.4		1
09/11/19 4:00	0	X		0	X		0	X	1	1.1			1.7			14.4		1
09/11/19 5:00	0	X		0	X		0	X	1	1.3			1.7			14.4		1
09/11/19 6:00	0	X		0	X		0	X	1	1.3			1.7			14.4		1
09/11/19 7:00	0	X		0	X		0	X	1	1.1			1.7			14.4		1
09/11/19 8:00	0			0			18		1	1.1			1.7			14.4		1
09/11/19 9:00	0.7			1.6			14.4		1	0.9			1.7			14.6		1
09/11/19 10:00	0.8			1.7			14.5		1	0.9			1.7			14.4		1
09/11/19 11:00	1.4			1.7			14.3		1	2.2			1.7			14.3		1
09/11/19 12:00	0.5			1.7			12.8		1	0			0			15.6		1
09/11/19 13:00	0.8			1.7			14.3		1	0	X		0	X		0	X	1
09/11/19 14:00	0.4			1.7			12.6		1	0	X		0	X		0	X	1
09/11/19 15:00	0.8			1.7			14.4		1	0	X		0	X		0	X	1
09/11/19 16:00	1			1.7			14		1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/11/19 17:00	1.1			1.7			14		1	0	X		0	X		0	X	1
09/11/19 18:00	0.9			1.7			14.4		1	0	X		0	X		0	X	1
09/11/19 19:00	0.8			1.7			14.4		1	0	X		0	X		0	X	1
09/11/19 20:00	0.7			1.7			13.4		1	0	X		0	X		0	X	1
09/11/19 21:00	0.8			1.8			14.4		1	0	X		0	X		0	X	1
09/11/19 22:00	0.8			1.7			14.4		1	0	X		0	X		0	X	1
09/11/19 23:00	0.9			1.7			14.4		1	0	X		0	X		0	X	1
09/12/19 0:00	0.9			1.7			14.4		1	0	X		0	X		0	X	1
09/12/19 1:00	0.9			1.7			14.4		1	0	X		0	X		0	X	1
09/12/19 2:00	0.8			1.7			14.4		1	0	X		0	X		0	X	1
09/12/19 3:00	0.8			1.7			14.4		1	0	X		0	X		0	X	1
09/12/19 4:00	0.8			1.7			14.4		1	0	X		0	X		0	X	1
09/12/19 5:00	0.9			1.7			14.4		1	0	X		0	X		0	X	1
09/12/19 6:00	0.9			1.7			14.4		1	0	X		0	X		0	X	1
09/12/19 7:00	0.8			1.7			14.4		1	0	X		0	X		0	X	1
09/12/19 8:00	0.5			1.6			12.8		1	0			0			17.8		1
09/12/19 9:00	0.8			1.8			14.4		1	0.9			1.4			14.3		1
09/12/19 10:00	1.3			1.7			14.3		1	1.5			1.7			14.3		1
09/12/19 11:00	0.8			1.7			14.4		1	1			1.7			14.5		1
09/12/19 12:00	0			0			17.1		1	0.8			1.6			13.2		1
09/12/19 13:00	0	X		0	X		0	X	1	1			1.8			14.5		1
09/12/19 14:00	0	X		0	X		0	X	1	0.5			1.6			12.6		1
09/12/19 15:00	0	X		0	X		0	X	1	1			1.8			14.4		1
09/12/19 16:00	0	X		0	X		0	X	1	0.6			1.7			12.5		1
09/12/19 17:00	0	X		0	X		0	X	1	0.4			1.7			11.9		1
09/12/19 18:00	0	X		0	X		0	X	1	0.4			1.7			11.9		1
09/12/19 19:00	0	X		0	X		0	X	1	0.4			1.7			11.9		1
09/12/19 20:00	0	X		0	X		0	X	1	0.5			1.7			12.1		1
09/12/19 21:00	0	X		0	X		0	X	1	1.1			1.7			14.4		1
09/12/19 22:00	0	X		0	X		0	X	1	1.3			1.7			14.4		1
09/12/19 23:00	0	X		0	X		0	X	1	0			0			15.9		1
09/13/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/13/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/13/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/13/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/13/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/13/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/13/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/13/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/13/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/13/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/13/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/13/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/13/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/13/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/13/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/13/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/13/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/13/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/13/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/13/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/13/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/13/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/13/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/13/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/14/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/14/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/14/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/14/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/14/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/14/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/14/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/14/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/14/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/14/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/14/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/14/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/14/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/14/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/14/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/14/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/14/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/14/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/14/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/14/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/14/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/14/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/14/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/14/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/15/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/15/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/15/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/15/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/15/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/15/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/15/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/15/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/15/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/15/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/15/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/15/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/15/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/15/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/15/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/15/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/15/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/15/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/15/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/15/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/15/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/15/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/15/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/15/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/16/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/16/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/16/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/16/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/16/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/16/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/16/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/16/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/16/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/16/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/16/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/16/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/16/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/16/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/16/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/16/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/16/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/16/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/16/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/16/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/16/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/16/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/16/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/16/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/17/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/17/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/17/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/17/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/17/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/17/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/17/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/17/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/17/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/17/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/17/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/17/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/17/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/17/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/17/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/17/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/17/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/17/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/17/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/17/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/17/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/17/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/17/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/17/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/18/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/18/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/18/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/18/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/18/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/18/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/18/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/18/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/18/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/18/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/18/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/18/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/18/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/18/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/18/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/18/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/18/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/18/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/18/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/18/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/18/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/18/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/18/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/18/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/19/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/19/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/19/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/19/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/19/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/19/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/19/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/19/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/19/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/19/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/19/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/19/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/19/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/19/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/19/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/19/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/19/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/19/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/19/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/19/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/19/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/19/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/19/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/19/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/20/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/20/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/20/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/20/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/20/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/20/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/20/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/20/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/20/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/20/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/20/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/20/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/20/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/20/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/20/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/20/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/20/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/20/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/20/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/20/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/20/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/20/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/20/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/20/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/21/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/21/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/21/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/21/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/21/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/21/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/21/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/21/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/21/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/21/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/21/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/21/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/21/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/21/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/21/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/21/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/21/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/21/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/21/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/21/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/21/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/21/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/21/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/21/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/22/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/22/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/22/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/22/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/22/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/22/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/22/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/22/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/22/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/22/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/22/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/22/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/22/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/22/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/22/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/22/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/22/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/22/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/22/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/22/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/22/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/22/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/22/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/22/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/23/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/23/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/23/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/23/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/23/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/23/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/23/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/23/19 7:00	0	X		0	X		0	X	1	0			0			17.9		1
09/23/19 8:00	0	X		0	X		0	X	1	1			1.5			14.5		1
09/23/19 9:00	0	X		0	X		0	X	1	1			1.7			14.6		1
09/23/19 10:00	0	X		0	X		0	X	1	1.1			1.7			14.5		1
09/23/19 11:00	0	X		0	X		0	X	1	0.7			1.7			12.9		1
09/23/19 12:00	0	X		0	X		0	X	1	0.6			1.7			12.8		1
09/23/19 13:00	0	X		0	X		0	X	1	0.6			1.7			12.8		1
09/23/19 14:00	0	X		0	X		0	X	1	0.6			1.7			12.9		1
09/23/19 15:00	0	X		0	X		0	X	1	0.8			1.7			13.2		1
09/23/19 16:00	0	X		0	X		0	X	1	0.6			1.7			12.9		1
09/23/19 17:00	0	X		0	X		0	X	1	0.6			1.7			12.9		1
09/23/19 18:00	0	X		0	X		0	X	1	1.2			1.7			13.8		1
09/23/19 19:00	0	X		0	X		0	X	1	0.7			1.7			12.9		1
09/23/19 20:00	0	X		0	X		0	X	1	0.7			1.7			13		1
09/23/19 21:00	0	X		0	X		0	X	1	1.1			1.8			14.5		1
09/23/19 22:00	0	X		0	X		0	X	1	1.1			1.7			14.3		1
09/23/19 23:00	0	X		0	X		0	X	1	1.1			1.7			13.8		1
09/24/19 0:00	0	X		0	X		0	X	1	1.1			1.7			13.7		1
09/24/19 1:00	0	X		0	X		0	X	1	0.9			1.7			13.4		1
09/24/19 2:00	0	X		0	X		0	X	1	1.1			1.7			13.7		1
09/24/19 3:00	0	X		0	X		0	X	1	1			1.7			13.5		1
09/24/19 4:00	0	X		0	X		0	X	1	0.6			1.7			12.8		1
09/24/19 5:00	0	X		0	X		0	X	1	1.1			1.8			14.2		1
09/24/19 6:00	0	X		0	X		0	X	1	1.1			1.7			14.4		1
09/24/19 7:00	0			0			20.8		1	1.4			1.7			13.9		1
09/24/19 8:00	0.8			1.6			15		1	1			1.7			14		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/24/19 9:00	0.8			1.7			14.6		1	1.1			1.7			14.4		1
09/24/19 10:00	0.8			1.7			14.7		1	1			1.7			14.5		1
09/24/19 11:00	0.9			1.7			14.7		1	1			1.7			14.5		1
09/24/19 12:00	1.3			1.7			14.3		1	1.9			1.7			14.3		1
09/24/19 13:00	1			1.7			13.8		1	1.4			1.7			14.1		1
09/24/19 14:00	1.1			1.7			14.2		1	1.5			1.7			14.1		1
09/24/19 15:00	1			1.7			13.9		1	1.2			1.7			13.9		1
09/24/19 16:00	0.2			1.7			11.7		1	0.4			1.7			11.8		1
09/24/19 17:00	0.2			1.7			11.7		1	0.4			1.7			11.8		1
09/24/19 18:00	0.2			1.7			12.4		1	0.5			1.7			12.5		1
09/24/19 19:00	1			1.7			13.8		1	1.2			1.7			13.9		1
09/24/19 20:00	0.8			1.7			14.5		1	1			1.7			14.5		1
09/24/19 21:00	1.3			1.7			14.3		1	1.7			1.7			14.2		1
09/24/19 22:00	0.8			1.7			14.5		1	1.1			1.7			14.5		1
09/24/19 23:00	0.9			1.7			14.5		1	1.2			1.7			14.5		1
09/25/19 0:00	0.9			1.7			14.5		1	1.2			1.7			14.5		1
09/25/19 1:00	0.8			1.7			14.5		1	1.2			1.7			14.5		1
09/25/19 2:00	1.1			1.7			14.5		1	1.4			1.7			14.5		1
09/25/19 3:00	1.1			1.7			14.5		1	1.5			1.7			14.5		1
09/25/19 4:00	1.3			1.7			14.5		1	1.6			1.7			14.5		1
09/25/19 5:00	1.3			1.7			14.5		1	1.5			1.7			14.5		1
09/25/19 6:00	1			1.7			14.5		1	1.2			1.7			14.5		1
09/25/19 7:00	1			1.7			14.5		1	1.2			1.7			14.5		1
09/25/19 8:00	0.8			1.7			14.6		1	1			1.7			14.6		1
09/25/19 9:00	0.7			1.7			14.6		1	1			1.7			14.6		1
09/25/19 10:00	0.8			1.7			14.5		1	1.1			1.7			14.6		1
09/25/19 11:00	0.8			1.7			14.5		1	1.1			1.7			14.5		1
09/25/19 12:00	0.3			1.7			12.3		1	0.5			1.7			12.4		1
09/25/19 13:00	0.2			1.7			11.8		1	0.4			1.7			11.9		1
09/25/19 14:00	0.2			1.7			12.2		1	0.4			1.7			12.3		1
09/25/19 15:00	0.2			1.7			12.3		1	0.4			1.7			12.3		1
09/25/19 16:00	0.2			1.7			11.9		1	0.4			1.7			12		1
09/25/19 17:00	0.2			1.7			11.9		1	0.4			1.7			12		1
09/25/19 18:00	0.7			1.8			14.3		1	1.1			1.8			13.9		1
09/25/19 19:00	0.4			1.7			12.8		1	0.5			1.7			12.8		1
09/25/19 20:00	0.4			1.7			12.8		1	0.6			1.7			12.8		1
09/25/19 21:00	0.9			1.8			14.4		1	1.1			1.7			14.4		1
09/25/19 22:00	0.8			1.7			14.4		1	1.2			1.7			14.4		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/25/19 23:00	0.8			1.7			14.6		1	1.1			1.7			14.5		1
09/26/19 0:00	0.8			1.7			14.6		1	1			1.7			14.5		1
09/26/19 1:00	0.9			1.7			14.5		1	1.1			1.7			14.5		1
09/26/19 2:00	0.8			1.7			14.5		1	1.1			1.7			14.5		1
09/26/19 3:00	0.8			1.7			14.5		1	1.1			1.7			14.5		1
09/26/19 4:00	0.8			1.6			14.5		1	1.1			1.7			14.5		1
09/26/19 5:00	0.9			1.7			14.5		1	1.1			1.7			14.5		1
09/26/19 6:00	0.8			1.7			14.5		1	1			1.7			14.5		1
09/26/19 7:00	0.8			1.7			14.5		1	1.1			1.7			14.5		1
09/26/19 8:00	0.9			1.7			14.5		1	1.2			1.7			14.5		1
09/26/19 9:00	0.9			1.7			14.6		1	1.2			1.7			14.6		1
09/26/19 10:00	1.3			1.7			14.1		1	1.8			1.7			14.1		1
09/26/19 11:00	0.9			1.7			13.6		1	1.1			1.7			13.6		1
09/26/19 12:00	0.6			1.7			13.3		1	0.8			1.7			13.4		1
09/26/19 13:00	0.5			1.7			13.3		1	0.8			1.7			13.3		1
09/26/19 14:00	0.3			1.7			12.2		1	0.5			1.7			12.2		1
09/26/19 15:00	0.3			1.7			12.4		1	0.5			1.7			12.5		1
09/26/19 16:00	0.2			1.7			11.9		1	0.4			1.7			12		1
09/26/19 17:00	0.4			1.7			12.9		1	0.6			1.7			13		1
09/26/19 18:00	0.7			1.7			13.5		1	1			1.7			13.5		1
09/26/19 19:00	0.8			1.7			14.5		1	1			1.7			14.5		1
09/26/19 20:00	0.9			1.7			14.4		1	1.1			1.7			14.4		1
09/26/19 21:00	0.9			1.7			14.4		1	1.1			1.7			14.3		1
09/26/19 22:00	0.7			1.7			14.6		1	1			1.7			14.5		1
09/26/19 23:00	0			0			17.1		1	1			1.7			14.4		1
09/27/19 0:00	0	X		0	X		0	X	1	1			1.7			14.4		1
09/27/19 1:00	0	X		0	X		0	X	1	1			1.7			14.4		1
09/27/19 2:00	0	X		0	X		0	X	1	1			1.7			14.4		1
09/27/19 3:00	0	X		0	X		0	X	1	1			1.7			14.4		1
09/27/19 4:00	0	X		0	X		0	X	1	1			1.7			14.4		1
09/27/19 5:00	0	X		0	X		0	X	1	1.1			1.7			14.3		1
09/27/19 6:00	0	X		0	X		0	X	1	1.1			1.7			14.3		1
09/27/19 7:00	0	X		0	X		0	X	1	1			1.7			14.4		1
09/27/19 8:00	0	X		0	X		0	X	1	1			1.7			14.5		1
09/27/19 9:00	0	X		0	X		0	X	1	0.6			1.7			12.1		1
09/27/19 10:00	0	X		0	X		0	X	1	0.4			1.7			11.9		1
09/27/19 11:00	0	X		0	X		0	X	1	0.4			1.7			11.9		1
09/27/19 12:00	0	X		0	X		0	X	1	0.4			1.7			12		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/27/19 13:00	0	X		0	X		0	X	1	0.4			1.7			12		1
09/27/19 14:00	0	X		0	X		0	X	1	0.4			1.7			11.9		1
09/27/19 15:00	0	X		0	X		0	X	1	0.4			1.7			11.9		1
09/27/19 16:00	0	X		0	X		0	X	1	0.4			1.7			11.9		1
09/27/19 17:00	0	X		0	X		0	X	1	0.4			1.7			11.9		1
09/27/19 18:00	0	X		0	X		0	X	1	0.4			1.7			11.9		1
09/27/19 19:00	0	X		0	X		0	X	1	0.4			1.7			12		1
09/27/19 20:00	0	X		0	X		0	X	1	0.4			1.7			12.2		1
09/27/19 21:00	0	X		0	X		0	X	1	1.2			1.8			14.3		1
09/27/19 22:00	0	X		0	X		0	X	1	1.1			1.7			14.3		1
09/27/19 23:00	0	X		0	X		0	X	1	0			0			16.3		1
09/28/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/28/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/28/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/28/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/28/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/28/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/28/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/28/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/28/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/28/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/28/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/28/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/28/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/28/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/28/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/28/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/28/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/28/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/28/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/28/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/28/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/28/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/28/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/28/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/29/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/29/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/29/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/29/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/29/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/29/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/29/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/29/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/29/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/29/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/29/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/29/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/29/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/29/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/29/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/29/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/29/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/29/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/29/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/29/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/29/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/29/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/29/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/29/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/30/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/30/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/30/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/30/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/30/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/30/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/30/19 6:00	0			0			17.9		1	0	X		0	X		0	X	1
09/30/19 7:00	0.8			1.7			14.5		1	0	X		0	X		0	X	1
09/30/19 8:00	0.8			1.7			14.6		1	0	X		0	X		0	X	1
09/30/19 9:00	0.8			1.7			14.6		1	0	X		0	X		0	X	1
09/30/19 10:00	0.8			1.7			14.6		1	0			0			18.1		1
09/30/19 11:00	0.8			1.7			14.5		1	1.2			1.5			14.4		1
09/30/19 12:00	0			0			16.8		1	1			1.7			14.6		1
09/30/19 13:00	0	X		0	X		0	X	1	1.1			1.7			14.5		1
09/30/19 14:00	0	X		0	X		0	X	1	0.6			1.7			12.7		1
09/30/19 15:00	0	X		0	X		0	X	1	0.4			1.7			12.4		1
09/30/19 16:00	0	X		0	X		0	X	1	0.6			1.7			12.8		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/30/19 17:00	0	X		0	X		0	X	1	1.1			2			15.1		1
09/30/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/30/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/30/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/30/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/30/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
09/30/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

ATTACHMENT 5

AQ-33

AQ-33 The Project owner shall maintain records of Sox lb/hr, lb/day, and lb, quarter emissions. Sox emissions shall be based on fuel use records, natural gas sulfur content, and mass balance calculations.

Verification: The Project owner shall submit to the CPM all hourly, daily, and quarterly Sox emissions as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

Tons 12 Month Rolling Summary

CT1 and CT2 Combined

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:02 **Location:** Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2 CO, Ton 1 Day(s) Sum	Rolling Sum	Units CT1 & CT2 NOx, Ton 1 Day(s) Sum	Rolling Sum	Units CT1 & CT2 PM10, Ton 1 Day(s) Sum	Rolling Sum	Units CT1 & CT2 SO2, Ton 1 Day(s) Sum	Rolling Sum	Units CT1 & CT2 VOC, Ton 1 Day(s) Sum	Rolling Sum
Jul 2019	0.1329	3.6349	0.4979	9.8697	0.0934	1.8340	0.0467	0.9169	0.1557	3.0568
Aug 2019	0.3100	3.5358	0.9671	9.0841	0.1814	1.6947	0.0908	0.8474	0.3022	2.8241
Sep 2019	0.3350	3.8708	0.5519	9.6360	0.0943	1.7890	0.0471	0.8945	0.1574	2.9815
Sum/Avg	3.8708		9.6360		1.7890		0.8945		2.9815	
Limit Value										

AQ33 DAILY SOX

	CT1_SO2_Lb_1D			CT2_SO2_Lb_1D														
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/01/19 0:00	0			0														
07/02/19 0:00	0			0														
07/03/19 0:00	0			0														
07/04/19 0:00	0			0														
07/05/19 0:00	0			0														
07/06/19 0:00	0			0														
07/07/19 0:00	0			0														
07/08/19 0:00	0			0														
07/09/19 0:00	0			0														
07/10/19 0:00	0			0														
07/11/19 0:00	0			0														
07/12/19 0:00	0			0														
07/13/19 0:00	0			0														
07/14/19 0:00	0			0														
07/15/19 0:00	0			0														
07/16/19 0:00	0			0														
07/17/19 0:00	0			0														
07/18/19 0:00	0			0														
07/19/19 0:00	0			0														
07/20/19 0:00	0			0														
07/21/19 0:00	0			0														
07/22/19 0:00	0			2.3														
07/23/19 0:00	6.3			2.8														
07/24/19 0:00	9.5			0														
07/25/19 0:00	8			0														
07/26/19 0:00	8.1			0														
07/27/19 0:00	6.7			0.2														
07/28/19 0:00	7			7.1														
07/29/19 0:00	7.1			8														
07/30/19 0:00	5			5.5														
07/31/19 0:00	5.4			6														
08/01/19 0:00	5.6			5.7														
08/02/19 0:00	5.8			5.8														
08/03/19 0:00	6			6.1														
08/04/19 0:00	6.1			6.6														

	CT1_SO2_Lb_1D			CT2_SO2_Lb_1D														
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/05/19 0:00	5.9			6.3														
08/06/19 0:00	6.3			6.4														
08/07/19 0:00	5.8			6														
08/08/19 0:00	1			1														
08/09/19 0:00	0			0														
08/10/19 0:00	0			0														
08/11/19 0:00	0			0														
08/12/19 0:00	0			0														
08/13/19 0:00	5.1			0														
08/14/19 0:00	7			4.8														
08/15/19 0:00	6.3			6.6														
08/16/19 0:00	6.3			6.4														
08/17/19 0:00	5.8			0														
08/18/19 0:00	0			0														
08/19/19 0:00	0			0														
08/20/19 0:00	0			0														
08/21/19 0:00	0			0														
08/22/19 0:00	0			0														
08/23/19 0:00	0			0														
08/24/19 0:00	0			0														
08/25/19 0:00	0			5.3														
08/26/19 0:00	0			6.4														
08/27/19 0:00	5.1			6.5														
08/28/19 0:00	7.4			7.5														
08/29/19 0:00	5.7			6.3														
08/30/19 0:00	0			0														
08/31/19 0:00	0			0														
09/01/19 0:00	0			0														
09/02/19 0:00	0			0														
09/03/19 0:00	0			0														
09/04/19 0:00	4.7			5.2														
09/05/19 0:00	5.9			6.5														
09/06/19 0:00	0			0														
09/07/19 0:00	0			0														
09/08/19 0:00	0			0														
09/09/19 0:00	0			0.2														
09/10/19 0:00	0			6.5														
09/11/19 0:00	3.6			2.6														

	CT1_SO2_Lb_1D			CT2_SO2_Lb_1D														
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/12/19 0:00	2.6			4.5														
09/13/19 0:00	0			0														
09/14/19 0:00	0			0														
09/15/19 0:00	0			0														
09/16/19 0:00	0			0														
09/17/19 0:00	0			0														
09/18/19 0:00	0			0														
09/19/19 0:00	0			0														
09/20/19 0:00	0			0														
09/21/19 0:00	0			0														
09/22/19 0:00	0			0														
09/23/19 0:00	0			5.5														
09/24/19 0:00	4.3			7.4														
09/25/19 0:00	6.3			6.7														
09/26/19 0:00	5.8			6.1														
09/27/19 0:00	0			7.1														
09/28/19 0:00	0			0														
09/29/19 0:00	0			0														
09/30/19 0:00	1.4			2														

AQ33 HOURLY SOX

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
07/01/19 0:00	0	X		0	X		0											
07/01/19 1:00	0	X		0	X		0											
07/01/19 2:00	0	X		0	X		0											
07/01/19 3:00	0	X		0	X		0											
07/01/19 4:00	0	X		0	X		0											
07/01/19 5:00	0	X		0	X		0											
07/01/19 6:00	0	X		0	X		0											
07/01/19 7:00	0	X		0	X		0											
07/01/19 8:00	0	X		0	X		0											
07/01/19 9:00	0	X		0	X		0											
07/01/19 10:00	0	X		0	X		0											
07/01/19 11:00	0	X		0	X		0											
07/01/19 12:00	0	X		0	X		0											
07/01/19 13:00	0	X		0	X		0											
07/01/19 14:00	0	X		0	X		0											
07/01/19 15:00	0	X		0	X		0											
07/01/19 16:00	0	X		0	X		0											
07/01/19 17:00	0	X		0	X		0											
07/01/19 18:00	0	X		0	X		0											
07/01/19 19:00	0	X		0	X		0											
07/01/19 20:00	0	X		0	X		0											
07/01/19 21:00	0	X		0	X		0											
07/01/19 22:00	0	X		0	X		0											
07/01/19 23:00	0	X		0	X		0											
07/02/19 0:00	0	X		0	X		0											
07/02/19 1:00	0	X		0	X		0											
07/02/19 2:00	0	X		0	X		0											
07/02/19 3:00	0	X		0	X		0											
07/02/19 4:00	0	X		0	X		0											
07/02/19 5:00	0	X		0	X		0											
07/02/19 6:00	0	X		0	X		0											
07/02/19 7:00	0	X		0	X		0											
07/02/19 8:00	0	X		0	X		0											
07/02/19 9:00	0	X		0	X		0											
07/02/19 10:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/02/19 11:00	0	X		0	X		0											
07/02/19 12:00	0	X		0	X		0											
07/02/19 13:00	0	X		0	X		0											
07/02/19 14:00	0	X		0	X		0											
07/02/19 15:00	0	X		0	X		0											
07/02/19 16:00	0	X		0	X		0											
07/02/19 17:00	0	X		0	X		0											
07/02/19 18:00	0	X		0	X		0											
07/02/19 19:00	0	X		0	X		0											
07/02/19 20:00	0	X		0	X		0											
07/02/19 21:00	0	X		0	X		0											
07/02/19 22:00	0	X		0	X		0											
07/02/19 23:00	0	X		0	X		0											
07/03/19 0:00	0	X		0	X		0											
07/03/19 1:00	0	X		0	X		0											
07/03/19 2:00	0	X		0	X		0											
07/03/19 3:00	0	X		0	X		0											
07/03/19 4:00	0	X		0	X		0											
07/03/19 5:00	0	X		0	X		0											
07/03/19 6:00	0	X		0	X		0											
07/03/19 7:00	0	X		0	X		0											
07/03/19 8:00	0	X		0	X		0											
07/03/19 9:00	0	X		0	X		0											
07/03/19 10:00	0	X		0	X		0											
07/03/19 11:00	0	X		0	X		0											
07/03/19 12:00	0	X		0	X		0											
07/03/19 13:00	0	X		0	X		0											
07/03/19 14:00	0	X		0	X		0											
07/03/19 15:00	0	X		0	X		0											
07/03/19 16:00	0	X		0	X		0											
07/03/19 17:00	0	X		0	X		0											
07/03/19 18:00	0	X		0	X		0											
07/03/19 19:00	0	X		0	X		0											
07/03/19 20:00	0	X		0	X		0											
07/03/19 21:00	0	X		0	X		0											
07/03/19 22:00	0	X		0	X		0											
07/03/19 23:00	0	X		0	X		0											
07/04/19 0:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/04/19 1:00	0	X		0	X		0											
07/04/19 2:00	0	X		0	X		0											
07/04/19 3:00	0	X		0	X		0											
07/04/19 4:00	0	X		0	X		0											
07/04/19 5:00	0	X		0	X		0											
07/04/19 6:00	0	X		0	X		0											
07/04/19 7:00	0	X		0	X		0											
07/04/19 8:00	0	X		0	X		0											
07/04/19 9:00	0	X		0	X		0											
07/04/19 10:00	0	X		0	X		0											
07/04/19 11:00	0	X		0	X		0											
07/04/19 12:00	0	X		0	X		0											
07/04/19 13:00	0	X		0	X		0											
07/04/19 14:00	0	X		0	X		0											
07/04/19 15:00	0	X		0	X		0											
07/04/19 16:00	0	X		0	X		0											
07/04/19 17:00	0	X		0	X		0											
07/04/19 18:00	0	X		0	X		0											
07/04/19 19:00	0	X		0	X		0											
07/04/19 20:00	0	X		0	X		0											
07/04/19 21:00	0	X		0	X		0											
07/04/19 22:00	0	X		0	X		0											
07/04/19 23:00	0	X		0	X		0											
07/05/19 0:00	0	X		0	X		0											
07/05/19 1:00	0	X		0	X		0											
07/05/19 2:00	0	X		0	X		0											
07/05/19 3:00	0	X		0	X		0											
07/05/19 4:00	0	X		0	X		0											
07/05/19 5:00	0	X		0	X		0											
07/05/19 6:00	0	X		0	X		0											
07/05/19 7:00	0	X		0	X		0											
07/05/19 8:00	0	X		0	X		0											
07/05/19 9:00	0	X		0	X		0											
07/05/19 10:00	0	X		0	X		0											
07/05/19 11:00	0	X		0	X		0											
07/05/19 12:00	0	X		0	X		0											
07/05/19 13:00	0	X		0	X		0											
07/05/19 14:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H										
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/05/19 15:00	0	X		0	X		0											
07/05/19 16:00	0	X		0	X		0											
07/05/19 17:00	0	X		0	X		0											
07/05/19 18:00	0	X		0	X		0											
07/05/19 19:00	0	X		0	X		0											
07/05/19 20:00	0	X		0	X		0											
07/05/19 21:00	0	X		0	X		0											
07/05/19 22:00	0	X		0	X		0											
07/05/19 23:00	0	X		0	X		0											
07/06/19 0:00	0	X		0	X		0											
07/06/19 1:00	0	X		0	X		0											
07/06/19 2:00	0	X		0	X		0											
07/06/19 3:00	0	X		0	X		0											
07/06/19 4:00	0	X		0	X		0											
07/06/19 5:00	0	X		0	X		0											
07/06/19 6:00	0	X		0	X		0											
07/06/19 7:00	0	X		0	X		0											
07/06/19 8:00	0	X		0	X		0											
07/06/19 9:00	0	X		0	X		0											
07/06/19 10:00	0	X		0	X		0											
07/06/19 11:00	0	X		0	X		0											
07/06/19 12:00	0	X		0	X		0											
07/06/19 13:00	0	X		0	X		0											
07/06/19 14:00	0	X		0	X		0											
07/06/19 15:00	0	X		0	X		0											
07/06/19 16:00	0	X		0	X		0											
07/06/19 17:00	0	X		0	X		0											
07/06/19 18:00	0	X		0	X		0											
07/06/19 19:00	0	X		0	X		0											
07/06/19 20:00	0	X		0	X		0											
07/06/19 21:00	0	X		0	X		0											
07/06/19 22:00	0	X		0	X		0											
07/06/19 23:00	0	X		0	X		0											
07/07/19 0:00	0	X		0	X		0											
07/07/19 1:00	0	X		0	X		0											
07/07/19 2:00	0	X		0	X		0											
07/07/19 3:00	0	X		0	X		0											
07/07/19 4:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/07/19 5:00	0	X		0	X		0											
07/07/19 6:00	0	X		0	X		0											
07/07/19 7:00	0	X		0	X		0											
07/07/19 8:00	0	X		0	X		0											
07/07/19 9:00	0	X		0	X		0											
07/07/19 10:00	0	X		0	X		0											
07/07/19 11:00	0	X		0	X		0											
07/07/19 12:00	0	X		0	X		0											
07/07/19 13:00	0	X		0	X		0											
07/07/19 14:00	0	X		0	X		0											
07/07/19 15:00	0	X		0	X		0											
07/07/19 16:00	0	X		0	X		0											
07/07/19 17:00	0	X		0	X		0											
07/07/19 18:00	0	X		0	X		0											
07/07/19 19:00	0	X		0	X		0											
07/07/19 20:00	0	X		0	X		0											
07/07/19 21:00	0	X		0	X		0											
07/07/19 22:00	0	X		0	X		0											
07/07/19 23:00	0	X		0	X		0											
07/08/19 0:00	0	X		0	X		0											
07/08/19 1:00	0	X		0	X		0											
07/08/19 2:00	0	X		0	X		0											
07/08/19 3:00	0	X		0	X		0											
07/08/19 4:00	0	X		0	X		0											
07/08/19 5:00	0	X		0	X		0											
07/08/19 6:00	0	X		0	X		0											
07/08/19 7:00	0	X		0	X		0											
07/08/19 8:00	0	X		0	X		0											
07/08/19 9:00	0	X		0	X		0											
07/08/19 10:00	0	X		0	X		0											
07/08/19 11:00	0	X		0	X		0											
07/08/19 12:00	0	X		0	X		0											
07/08/19 13:00	0	X		0	X		0											
07/08/19 14:00	0	X		0	X		0											
07/08/19 15:00	0	X		0	X		0											
07/08/19 16:00	0	X		0	X		0											
07/08/19 17:00	0	X		0	X		0											
07/08/19 18:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
07/08/19 19:00	0	X		0	X		0											
07/08/19 20:00	0	X		0	X		0											
07/08/19 21:00	0	X		0	X		0											
07/08/19 22:00	0	X		0	X		0											
07/08/19 23:00	0	X		0	X		0											
07/09/19 0:00	0	X		0	X		0											
07/09/19 1:00	0	X		0	X		0											
07/09/19 2:00	0	X		0	X		0											
07/09/19 3:00	0	X		0	X		0											
07/09/19 4:00	0	X		0	X		0											
07/09/19 5:00	0	X		0	X		0											
07/09/19 6:00	0	X		0	X		0											
07/09/19 7:00	0	X		0	X		0											
07/09/19 8:00	0	X		0	X		0											
07/09/19 9:00	0	X		0	X		0											
07/09/19 10:00	0	X		0	X		0											
07/09/19 11:00	0	X		0	X		0											
07/09/19 12:00	0	X		0	X		0											
07/09/19 13:00	0	X		0	X		0											
07/09/19 14:00	0	X		0	X		0											
07/09/19 15:00	0	X		0	X		0											
07/09/19 16:00	0	X		0	X		0											
07/09/19 17:00	0	X		0	X		0											
07/09/19 18:00	0	X		0	X		0											
07/09/19 19:00	0	X		0	X		0											
07/09/19 20:00	0	X		0	X		0											
07/09/19 21:00	0	X		0	X		0											
07/09/19 22:00	0	X		0	X		0											
07/09/19 23:00	0	X		0	X		0											
07/10/19 0:00	0	X		0	X		0											
07/10/19 1:00	0	X		0	X		0											
07/10/19 2:00	0	X		0	X		0											
07/10/19 3:00	0	X		0	X		0											
07/10/19 4:00	0	X		0	X		0											
07/10/19 5:00	0	X		0	X		0											
07/10/19 6:00	0	X		0	X		0											
07/10/19 7:00	0	X		0	X		0											
07/10/19 8:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/10/19 9:00	0	X		0	X		0											
07/10/19 10:00	0	X		0	X		0											
07/10/19 11:00	0	X		0	X		0											
07/10/19 12:00	0	X		0	X		0											
07/10/19 13:00	0	X		0	X		0											
07/10/19 14:00	0	X		0	X		0											
07/10/19 15:00	0	X		0	X		0											
07/10/19 16:00	0	X		0	X		0											
07/10/19 17:00	0	X		0	X		0											
07/10/19 18:00	0	X		0	X		0											
07/10/19 19:00	0	X		0	X		0											
07/10/19 20:00	0	X		0	X		0											
07/10/19 21:00	0	X		0	X		0											
07/10/19 22:00	0	X		0	X		0											
07/10/19 23:00	0	X		0	X		0											
07/11/19 0:00	0	X		0	X		0											
07/11/19 1:00	0	X		0	X		0											
07/11/19 2:00	0	X		0	X		0											
07/11/19 3:00	0	X		0	X		0											
07/11/19 4:00	0	X		0	X		0											
07/11/19 5:00	0	X		0	X		0											
07/11/19 6:00	0	X		0	X		0											
07/11/19 7:00	0	X		0	X		0											
07/11/19 8:00	0	X		0	X		0											
07/11/19 9:00	0	X		0	X		0											
07/11/19 10:00	0	X		0	X		0											
07/11/19 11:00	0	X		0	X		0											
07/11/19 12:00	0	X		0	X		0											
07/11/19 13:00	0	X		0	X		0											
07/11/19 14:00	0	X		0	X		0											
07/11/19 15:00	0	X		0	X		0											
07/11/19 16:00	0	X		0	X		0											
07/11/19 17:00	0	X		0	X		0											
07/11/19 18:00	0	X		0	X		0											
07/11/19 19:00	0	X		0	X		0											
07/11/19 20:00	0	X		0	X		0											
07/11/19 21:00	0	X		0	X		0											
07/11/19 22:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/11/19 23:00	0	X		0	X		0											
07/12/19 0:00	0	X		0	X		0											
07/12/19 1:00	0	X		0	X		0											
07/12/19 2:00	0	X		0	X		0											
07/12/19 3:00	0	X		0	X		0											
07/12/19 4:00	0	X		0	X		0											
07/12/19 5:00	0	X		0	X		0											
07/12/19 6:00	0	X		0	X		0											
07/12/19 7:00	0	X		0	X		0											
07/12/19 8:00	0	X		0	X		0											
07/12/19 9:00	0	X		0	X		0											
07/12/19 10:00	0	X		0	X		0											
07/12/19 11:00	0	X		0	X		0											
07/12/19 12:00	0	X		0	X		0											
07/12/19 13:00	0	X		0	X		0											
07/12/19 14:00	0	X		0	X		0											
07/12/19 15:00	0	X		0	X		0											
07/12/19 16:00	0	X		0	X		0											
07/12/19 17:00	0	X		0	X		0											
07/12/19 18:00	0	X		0	X		0											
07/12/19 19:00	0	X		0	X		0											
07/12/19 20:00	0	X		0	X		0											
07/12/19 21:00	0	X		0	X		0											
07/12/19 22:00	0	X		0	X		0											
07/12/19 23:00	0	X		0	X		0											
07/13/19 0:00	0	X		0	X		0											
07/13/19 1:00	0	X		0	X		0											
07/13/19 2:00	0	X		0	X		0											
07/13/19 3:00	0	X		0	X		0											
07/13/19 4:00	0	X		0	X		0											
07/13/19 5:00	0	X		0	X		0											
07/13/19 6:00	0	X		0	X		0											
07/13/19 7:00	0	X		0	X		0											
07/13/19 8:00	0	X		0	X		0											
07/13/19 9:00	0	X		0	X		0											
07/13/19 10:00	0	X		0	X		0											
07/13/19 11:00	0	X		0	X		0											
07/13/19 12:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
07/13/19 13:00	0	X		0	X		0											
07/13/19 14:00	0	X		0	X		0											
07/13/19 15:00	0	X		0	X		0											
07/13/19 16:00	0	X		0	X		0											
07/13/19 17:00	0	X		0	X		0											
07/13/19 18:00	0	X		0	X		0											
07/13/19 19:00	0	X		0	X		0											
07/13/19 20:00	0	X		0	X		0											
07/13/19 21:00	0	X		0	X		0											
07/13/19 22:00	0	X		0	X		0											
07/13/19 23:00	0	X		0	X		0											
07/14/19 0:00	0	X		0	X		0											
07/14/19 1:00	0	X		0	X		0											
07/14/19 2:00	0	X		0	X		0											
07/14/19 3:00	0	X		0	X		0											
07/14/19 4:00	0	X		0	X		0											
07/14/19 5:00	0	X		0	X		0											
07/14/19 6:00	0	X		0	X		0											
07/14/19 7:00	0	X		0	X		0											
07/14/19 8:00	0	X		0	X		0											
07/14/19 9:00	0	X		0	X		0											
07/14/19 10:00	0	X		0	X		0											
07/14/19 11:00	0	X		0	X		0											
07/14/19 12:00	0	X		0	X		0											
07/14/19 13:00	0	X		0	X		0											
07/14/19 14:00	0	X		0	X		0											
07/14/19 15:00	0	X		0	X		0											
07/14/19 16:00	0	X		0	X		0											
07/14/19 17:00	0	X		0	X		0											
07/14/19 18:00	0	X		0	X		0											
07/14/19 19:00	0	X		0	X		0											
07/14/19 20:00	0	X		0	X		0											
07/14/19 21:00	0	X		0	X		0											
07/14/19 22:00	0	X		0	X		0											
07/14/19 23:00	0	X		0	X		0											
07/15/19 0:00	0	X		0	X		0											
07/15/19 1:00	0	X		0	X		0											
07/15/19 2:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/15/19 3:00	0	X		0	X		0											
07/15/19 4:00	0	X		0	X		0											
07/15/19 5:00	0	X		0	X		0											
07/15/19 6:00	0	X		0	X		0											
07/15/19 7:00	0	X		0	X		0											
07/15/19 8:00	0	X		0	X		0											
07/15/19 9:00	0	X		0	X		0											
07/15/19 10:00	0	X		0	X		0											
07/15/19 11:00	0	X		0	X		0											
07/15/19 12:00	0	X		0	X		0											
07/15/19 13:00	0	X		0	X		0											
07/15/19 14:00	0	X		0	X		0											
07/15/19 15:00	0	X		0	X		0											
07/15/19 16:00	0	X		0	X		0											
07/15/19 17:00	0	X		0	X		0											
07/15/19 18:00	0	X		0	X		0											
07/15/19 19:00	0	X		0	X		0											
07/15/19 20:00	0	X		0	X		0											
07/15/19 21:00	0	X		0	X		0											
07/15/19 22:00	0	X		0	X		0											
07/15/19 23:00	0	X		0	X		0											
07/16/19 0:00	0	X		0	X		0											
07/16/19 1:00	0	X		0	X		0											
07/16/19 2:00	0	X		0	X		0											
07/16/19 3:00	0	X		0	X		0											
07/16/19 4:00	0	X		0	X		0											
07/16/19 5:00	0	X		0	X		0											
07/16/19 6:00	0	X		0	X		0											
07/16/19 7:00	0	X		0	X		0											
07/16/19 8:00	0	X		0	X		0											
07/16/19 9:00	0	X		0	X		0											
07/16/19 10:00	0	X		0	X		0											
07/16/19 11:00	0	X		0	X		0											
07/16/19 12:00	0	X		0	X		0											
07/16/19 13:00	0	X		0	X		0											
07/16/19 14:00	0	X		0	X		0											
07/16/19 15:00	0	X		0	X		0											
07/16/19 16:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/16/19 17:00	0	X		0	X		0											
07/16/19 18:00	0	X		0	X		0											
07/16/19 19:00	0	X		0	X		0											
07/16/19 20:00	0	X		0	X		0											
07/16/19 21:00	0	X		0	X		0											
07/16/19 22:00	0	X		0	X		0											
07/16/19 23:00	0	X		0	X		0											
07/17/19 0:00	0	X		0	X		0											
07/17/19 1:00	0	X		0	X		0											
07/17/19 2:00	0	X		0	X		0											
07/17/19 3:00	0	X		0	X		0											
07/17/19 4:00	0	X		0	X		0											
07/17/19 5:00	0	X		0	X		0											
07/17/19 6:00	0	X		0	X		0											
07/17/19 7:00	0	X		0	X		0											
07/17/19 8:00	0	X		0	X		0											
07/17/19 9:00	0	X		0	X		0											
07/17/19 10:00	0	X		0	X		0											
07/17/19 11:00	0	X		0	X		0											
07/17/19 12:00	0	X		0	X		0											
07/17/19 13:00	0	X		0	X		0											
07/17/19 14:00	0	X		0	X		0											
07/17/19 15:00	0	X		0	X		0											
07/17/19 16:00	0	X		0	X		0											
07/17/19 17:00	0	X		0	X		0											
07/17/19 18:00	0	X		0	X		0											
07/17/19 19:00	0	X		0	X		0											
07/17/19 20:00	0	X		0	X		0											
07/17/19 21:00	0	X		0	X		0											
07/17/19 22:00	0	X		0	X		0											
07/17/19 23:00	0	X		0	X		0											
07/18/19 0:00	0	X		0	X		0											
07/18/19 1:00	0	X		0	X		0											
07/18/19 2:00	0	X		0	X		0											
07/18/19 3:00	0	X		0	X		0											
07/18/19 4:00	0	X		0	X		0											
07/18/19 5:00	0	X		0	X		0											
07/18/19 6:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
07/18/19 7:00	0	X		0	X		0											
07/18/19 8:00	0	X		0	X		0											
07/18/19 9:00	0	X		0	X		0											
07/18/19 10:00	0	X		0	X		0											
07/18/19 11:00	0	X		0	X		0											
07/18/19 12:00	0	X		0	X		0											
07/18/19 13:00	0	X		0	X		0											
07/18/19 14:00	0	X		0	X		0											
07/18/19 15:00	0	X		0	X		0											
07/18/19 16:00	0	X		0	X		0											
07/18/19 17:00	0	X		0	X		0											
07/18/19 18:00	0	X		0	X		0											
07/18/19 19:00	0	X		0	X		0											
07/18/19 20:00	0	X		0	X		0											
07/18/19 21:00	0	X		0	X		0											
07/18/19 22:00	0	X		0	X		0											
07/18/19 23:00	0	X		0	X		0											
07/19/19 0:00	0	X		0	X		0											
07/19/19 1:00	0	X		0	X		0											
07/19/19 2:00	0	X		0	X		0											
07/19/19 3:00	0	X		0	X		0											
07/19/19 4:00	0	X		0	X		0											
07/19/19 5:00	0	X		0	X		0											
07/19/19 6:00	0	X		0	X		0											
07/19/19 7:00	0	X		0	X		0											
07/19/19 8:00	0	X		0	X		0											
07/19/19 9:00	0	X		0	X		0											
07/19/19 10:00	0	X		0	X		0											
07/19/19 11:00	0	X		0	X		0											
07/19/19 12:00	0	X		0	X		0											
07/19/19 13:00	0	X		0	X		0											
07/19/19 14:00	0	X		0	X		0											
07/19/19 15:00	0	X		0	X		0											
07/19/19 16:00	0	X		0	X		0											
07/19/19 17:00	0	X		0	X		0											
07/19/19 18:00	0	X		0	X		0											
07/19/19 19:00	0	X		0	X		0											
07/19/19 20:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
07/19/19 21:00	0	X		0	X		0											
07/19/19 22:00	0	X		0	X		0											
07/19/19 23:00	0	X		0	X		0											
07/20/19 0:00	0	X		0	X		0											
07/20/19 1:00	0	X		0	X		0											
07/20/19 2:00	0	X		0	X		0											
07/20/19 3:00	0	X		0	X		0											
07/20/19 4:00	0	X		0	X		0											
07/20/19 5:00	0	X		0	X		0											
07/20/19 6:00	0	X		0	X		0											
07/20/19 7:00	0	X		0	X		0											
07/20/19 8:00	0	X		0	X		0											
07/20/19 9:00	0	X		0	X		0											
07/20/19 10:00	0	X		0	X		0											
07/20/19 11:00	0	X		0	X		0											
07/20/19 12:00	0	X		0	X		0											
07/20/19 13:00	0	X		0	X		0											
07/20/19 14:00	0	X		0	X		0											
07/20/19 15:00	0	X		0	X		0											
07/20/19 16:00	0	X		0	X		0											
07/20/19 17:00	0	X		0	X		0											
07/20/19 18:00	0	X		0	X		0											
07/20/19 19:00	0	X		0	X		0											
07/20/19 20:00	0	X		0	X		0											
07/20/19 21:00	0	X		0	X		0											
07/20/19 22:00	0	X		0	X		0											
07/20/19 23:00	0	X		0	X		0											
07/21/19 0:00	0	X		0	X		0											
07/21/19 1:00	0	X		0	X		0											
07/21/19 2:00	0	X		0	X		0											
07/21/19 3:00	0	X		0	X		0											
07/21/19 4:00	0	X		0	X		0											
07/21/19 5:00	0	X		0	X		0											
07/21/19 6:00	0	X		0	X		0											
07/21/19 7:00	0	X		0	X		0											
07/21/19 8:00	0	X		0	X		0											
07/21/19 9:00	0	X		0	X		0											
07/21/19 10:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
07/21/19 11:00	0	X		0	X		0											
07/21/19 12:00	0	X		0	X		0											
07/21/19 13:00	0	X		0	X		0											
07/21/19 14:00	0	X		0	X		0											
07/21/19 15:00	0	X		0	X		0											
07/21/19 16:00	0	X		0	X		0											
07/21/19 17:00	0	X		0	X		0											
07/21/19 18:00	0	X		0	X		0											
07/21/19 19:00	0	X		0	X		0											
07/21/19 20:00	0	X		0	X		0											
07/21/19 21:00	0	X		0	X		0											
07/21/19 22:00	0	X		0	X		0											
07/21/19 23:00	0	X		0	X		0											
07/22/19 0:00	0	X		0	X		0											
07/22/19 1:00	0	X		0	X		0											
07/22/19 2:00	0	X		0	X		0											
07/22/19 3:00	0	X		0	X		0											
07/22/19 4:00	0	X		0	X		0											
07/22/19 5:00	0	X		0	X		0											
07/22/19 6:00	0	X		0	X		0											
07/22/19 7:00	0	X		0	X		0											
07/22/19 8:00	0	X		0	X		0											
07/22/19 9:00	0	X		0	X		0											
07/22/19 10:00	0	X		0	X		0											
07/22/19 11:00	0	X		0	X		0											
07/22/19 12:00	0	X		0.02208			0											
07/22/19 13:00	0	X		0.1872			0.19											
07/22/19 14:00	0	X		0.27366			0.27											
07/22/19 15:00	0	X		0.24276			0.24											
07/22/19 16:00	0	X		0.2265			0.23											
07/22/19 17:00	0	X		0.22632			0.23											
07/22/19 18:00	0	X		0.23064			0.23											
07/22/19 19:00	0	X		0.22224			0.22											
07/22/19 20:00	0	X		0.22134			0.22											
07/22/19 21:00	0	X		0.21744			0.22											
07/22/19 22:00	0	X		0.22038			0.22											
07/22/19 23:00	0	X		0.2208			0.22											
07/23/19 0:00	0	X		0.22086			0.22											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/23/19 1:00	0	X		0.22098			0.22											
07/23/19 2:00	0	X		0.2211			0.22											
07/23/19 3:00	0	X		0.22128			0.22											
07/23/19 4:00	0	X		0.2214			0.22											
07/23/19 5:00	0.09192			0.2214			0.24											
07/23/19 6:00	0.21186			0.22662			0.44											
07/23/19 7:00	0.22266			0.23856			0.46											
07/23/19 8:00	0.2352			0.25254			0.49											
07/23/19 9:00	0.2601			0.27936			0.54											
07/23/19 10:00	0.25806			0.276			0.53											
07/23/19 11:00	0.33654			0.26724			0.6											
07/23/19 12:00	0.37866			0.09648			0.39											
07/23/19 13:00	0.37992			0	X		0.38											
07/23/19 14:00	0.37968			0	X		0.38											
07/23/19 15:00	0.37908			0	X		0.38											
07/23/19 16:00	0.3789			0	X		0.38											
07/23/19 17:00	0.3804			0	X		0.38											
07/23/19 18:00	0.3807			0	X		0.38											
07/23/19 19:00	0.38118			0	X		0.38											
07/23/19 20:00	0.38244			0	X		0.38											
07/23/19 21:00	0.3834			0	X		0.38											
07/23/19 22:00	0.3846			0	X		0.38											
07/23/19 23:00	0.38532			0	X		0.39											
07/24/19 0:00	0.38388			0	X		0.38											
07/24/19 1:00	0.38418			0	X		0.38											
07/24/19 2:00	0.3807			0	X		0.38											
07/24/19 3:00	0.38076			0	X		0.38											
07/24/19 4:00	0.38154			0	X		0.38											
07/24/19 5:00	0.38226			0	X		0.38											
07/24/19 6:00	0.38196			0	X		0.38											
07/24/19 7:00	0.38058			0	X		0.38											
07/24/19 8:00	0.37836			0	X		0.38											
07/24/19 9:00	0.37878			0	X		0.38											
07/24/19 10:00	0.3795			0	X		0.38											
07/24/19 11:00	0.37926			0	X		0.38											
07/24/19 12:00	0.37986			0	X		0.38											
07/24/19 13:00	0.37998			0	X		0.38											
07/24/19 14:00	0.37938			0	X		0.38											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/24/19 15:00	0.37998			0	X		0.38											
07/24/19 16:00	0.37812			0	X		0.38											
07/24/19 17:00	0.37866			0	X		0.38											
07/24/19 18:00	0.37878			0	X		0.38											
07/24/19 19:00	0.37488			0	X		0.37											
07/24/19 20:00	0.37692			0	X		0.38											
07/24/19 21:00	0.3798			0	X		0.38											
07/24/19 22:00	0.37008			0	X		0.37											
07/24/19 23:00	0.25794			0	X		0.26											
07/25/19 0:00	0.27264			0	X		0.27											
07/25/19 1:00	0.27018			0	X		0.27											
07/25/19 2:00	0.26082			0	X		0.26											
07/25/19 3:00	0.24972			0	X		0.25											
07/25/19 4:00	0.25434			0	X		0.25											
07/25/19 5:00	0.2565			0	X		0.26											
07/25/19 6:00	0.2553			0	X		0.26											
07/25/19 7:00	0.26604			0	X		0.27											
07/25/19 8:00	0.37884			0	X		0.38											
07/25/19 9:00	0.38112			0	X		0.38											
07/25/19 10:00	0.37884			0	X		0.38											
07/25/19 11:00	0.3786			0	X		0.38											
07/25/19 12:00	0.3795			0	X		0.38											
07/25/19 13:00	0.37998			0	X		0.38											
07/25/19 14:00	0.3792			0	X		0.38											
07/25/19 15:00	0.37692			0	X		0.38											
07/25/19 16:00	0.33342			0	X		0.33											
07/25/19 17:00	0.3243			0	X		0.32											
07/25/19 18:00	0.29436			0	X		0.29											
07/25/19 19:00	0.3177			0	X		0.32											
07/25/19 20:00	0.35526			0	X		0.36											
07/25/19 21:00	0.33456			0	X		0.33											
07/25/19 22:00	0.2625			0	X		0.26											
07/25/19 23:00	0.26376			0	X		0.26											
07/26/19 0:00	0.3003			0	X		0.3											
07/26/19 1:00	0.25362			0	X		0.25											
07/26/19 2:00	0.26034			0	X		0.26											
07/26/19 3:00	0.26202			0	X		0.26											
07/26/19 4:00	0.26136			0	X		0.26											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/26/19 5:00	0.24342			0	X		0.24											
07/26/19 6:00	0.28584			0	X		0.29											
07/26/19 7:00	0.29046			0	X		0.29											
07/26/19 8:00	0.28908			0	X		0.29											
07/26/19 9:00	0.2943			0	X		0.29											
07/26/19 10:00	0.3273			0	X		0.33											
07/26/19 11:00	0.37974			0	X		0.38											
07/26/19 12:00	0.38022			0	X		0.38											
07/26/19 13:00	0.35286			0	X		0.35											
07/26/19 14:00	0.35238			0	X		0.35											
07/26/19 15:00	0.37836			0	X		0.38											
07/26/19 16:00	0.37962			0	X		0.38											
07/26/19 17:00	0.38064			0	X		0.38											
07/26/19 18:00	0.3675			0	X		0.37											
07/26/19 19:00	0.34824			0	X		0.35											
07/26/19 20:00	0.36564			0	X		0.37											
07/26/19 21:00	0.37278			0	X		0.37											
07/26/19 22:00	0.31998			0	X		0.32											
07/26/19 23:00	0.3096			0	X		0.31											
07/27/19 0:00	0.28956			0	X		0.29											
07/27/19 1:00	0.28488			0	X		0.28											
07/27/19 2:00	0.23994			0	X		0.24											
07/27/19 3:00	0.21618			0	X		0.22											
07/27/19 4:00	0.213			0	X		0.21											
07/27/19 5:00	0.20454			0	X		0.2											
07/27/19 6:00	0.20718			0	X		0.21											
07/27/19 7:00	0.2415			0	X		0.24											
07/27/19 8:00	0.24156			0	X		0.24											
07/27/19 9:00	0.22668			0	X		0.23											
07/27/19 10:00	0.24492			0	X		0.24											
07/27/19 11:00	0.2592			0	X		0.26											
07/27/19 12:00	0.25776			0	X		0.26											
07/27/19 13:00	0.2565			0	X		0.26											
07/27/19 14:00	0.25392			0	X		0.25											
07/27/19 15:00	0.24378			0	X		0.24											
07/27/19 16:00	0.36714			0	X		0.37											
07/27/19 17:00	0.36924			0	X		0.37											
07/27/19 18:00	0.36762			0	X		0.37											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/27/19 19:00	0.36516			0	X		0.37											
07/27/19 20:00	0.36834			0	X		0.37											
07/27/19 21:00	0.37092			0	X		0.37											
07/27/19 22:00	0.33876			0.1011			0.36											
07/27/19 23:00	0.22848			0.228			0.46											
07/28/19 0:00	0.2163			0.23256			0.45											
07/28/19 1:00	0.20022			0.21546			0.42											
07/28/19 2:00	0.18822			0.20208			0.39											
07/28/19 3:00	0.19188			0.2061			0.4											
07/28/19 4:00	0.19344			0.2085			0.4											
07/28/19 5:00	0.19566			0.21048			0.41											
07/28/19 6:00	0.19722			0.21198			0.41											
07/28/19 7:00	0.21018			0.22566			0.44											
07/28/19 8:00	0.21024			0.22626			0.44											
07/28/19 9:00	0.21618			0.23202			0.45											
07/28/19 10:00	0.25452			0.27438			0.53											
07/28/19 11:00	0.25512			0.27396			0.53											
07/28/19 12:00	0.33492			0.35304			0.69											
07/28/19 13:00	0.36402			0.3846			0.75											
07/28/19 14:00	0.3729			0.39204			0.76											
07/28/19 15:00	0.37206			0.39126			0.76											
07/28/19 16:00	0.37194			0.39096			0.76											
07/28/19 17:00	0.37134			0.38904			0.76											
07/28/19 18:00	0.36864			0.38682			0.76											
07/28/19 19:00	0.31182			0.33246			0.64											
07/28/19 20:00	0.36774			0.38772			0.76											
07/28/19 21:00	0.35868			0.37968			0.74											
07/28/19 22:00	0.312			0.33444			0.65											
07/28/19 23:00	0.25926			0.28038			0.54											
07/29/19 0:00	0.2469			0.26622			0.51											
07/29/19 1:00	0.24408			0.26322			0.51											
07/29/19 2:00	0.23946			0.25824			0.5											
07/29/19 3:00	0.23718			0.25608			0.49											
07/29/19 4:00	0.23442			0.25308			0.49											
07/29/19 5:00	0.25626			0.27654			0.53											
07/29/19 6:00	0.30714			0.32748			0.63											
07/29/19 7:00	0.32634			0.345			0.67											
07/29/19 8:00	0.2496			0.26916			0.52											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/29/19 9:00	0.2463			0.26532			0.51											
07/29/19 10:00	0.31674			0.336			0.65											
07/29/19 11:00	0.3432			0.36186			0.71											
07/29/19 12:00	0.25932			0.2787			0.54											
07/29/19 13:00	0.36006			0.3786			0.74											
07/29/19 14:00	0.37932			0.3969			0.78											
07/29/19 15:00	0.3771			0.39594			0.77											
07/29/19 16:00	0.36444			0.38418			0.75											
07/29/19 17:00	0.36522			0.38358			0.75											
07/29/19 18:00	0.36114			0.37974			0.74											
07/29/19 19:00	0.31872			0.3363			0.66											
07/29/19 20:00	0.3561			0.3732			0.73											
07/29/19 21:00	0.32952			0.3519			0.68											
07/29/19 22:00	0.25956			0.27912			0.54											
07/29/19 23:00	0.18816			0.20298			0.39											
07/30/19 0:00	0.17946			0.19758			0.38											
07/30/19 1:00	0.17826			0.1998			0.38											
07/30/19 2:00	0.17802			0.1995			0.38											
07/30/19 3:00	0.17808			0.1995			0.38											
07/30/19 4:00	0.1782			0.1998			0.38											
07/30/19 5:00	0.20544			0.23112			0.44											
07/30/19 6:00	0.21168			0.24102			0.45											
07/30/19 7:00	0.22752			0.26202			0.49											
07/30/19 8:00	0.2271			0.26544			0.49											
07/30/19 9:00	0.21924			0.25884			0.48											
07/30/19 10:00	0.21726			0.26076			0.48											
07/30/19 11:00	0.20646			0.25284			0.46											
07/30/19 12:00	0.19956			0.24888			0.45											
07/30/19 13:00	0.18918			0.20232			0.39											
07/30/19 14:00	0.1911			0.2094			0.4											
07/30/19 15:00	0.19068			0.2145			0.41											
07/30/19 16:00	0.25392			0.27552			0.53											
07/30/19 17:00	0.25914			0.27984			0.54											
07/30/19 18:00	0.2277			0.24618			0.47											
07/30/19 19:00	0.21222			0.23292			0.45											
07/30/19 20:00	0.21834			0.24468			0.46											
07/30/19 21:00	0.20796			0.23628			0.44											
07/30/19 22:00	0.22092			0.24156			0.46											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/30/19 23:00	0.19746			0.21312			0.41											
07/31/19 0:00	0.18876			0.204			0.39											
07/31/19 1:00	0.18264			0.19716			0.38											
07/31/19 2:00	0.18246			0.19698			0.38											
07/31/19 3:00	0.18282			0.19758			0.38											
07/31/19 4:00	0.18186			0.1968			0.38											
07/31/19 5:00	0.17988			0.19446			0.37											
07/31/19 6:00	0.183			0.19734			0.38											
07/31/19 7:00	0.19044			0.20826			0.4											
07/31/19 8:00	0.19524			0.2172			0.41											
07/31/19 9:00	0.18402			0.20556			0.39											
07/31/19 10:00	0.17898			0.19458			0.37											
07/31/19 11:00	0.17982			0.1944			0.37											
07/31/19 12:00	0.21606			0.23508			0.45											
07/31/19 13:00	0.2376			0.25788			0.5											
07/31/19 14:00	0.34578			0.36522			0.71											
07/31/19 15:00	0.33678			0.35724			0.69											
07/31/19 16:00	0.33048			0.35064			0.68											
07/31/19 17:00	0.32688			0.34716			0.67											
07/31/19 18:00	0.32718			0.34758			0.67											
07/31/19 19:00	0.33156			0.35274			0.68											
07/31/19 20:00	0.24396			0.26322			0.51											
07/31/19 21:00	0.22878			0.24882			0.48											
07/31/19 22:00	0.19002			0.20526			0.4											
07/31/19 23:00	0.183			0.19914			0.38											
08/01/19 0:00	0.18144			0.19878			0.38											
08/01/19 1:00	0.18072			0.19926			0.38											
08/01/19 2:00	0.18			0.20052			0.38											
08/01/19 3:00	0.17928			0.20118			0.38											
08/01/19 4:00	0.17946			0.2025			0.38											
08/01/19 5:00	0.1803			0.20442			0.38											
08/01/19 6:00	0.18138			0.2058			0.39											
08/01/19 7:00	0.18528			0.21096			0.4											
08/01/19 8:00	0.18336			0.21054			0.39											
08/01/19 9:00	0.18756			0.21756			0.41											
08/01/19 10:00	0.18084			0.21324			0.39											
08/01/19 11:00	0.1842			0.21636			0.4											
08/01/19 12:00	0.25146			0.27384			0.53											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/01/19 13:00	0.25836			0.27858			0.54											
08/01/19 14:00	0.25758			0.27762			0.54											
08/01/19 15:00	0.2571			0.27744			0.53											
08/01/19 16:00	0.28824			0.30426			0.59											
08/01/19 17:00	0.2928			0.31212			0.6											
08/01/19 18:00	0.33492			0.35376			0.69											
08/01/19 19:00	0.25854			0.27906			0.54											
08/01/19 20:00	0.19152			0.20322			0.39											
08/01/19 21:00	0.1848			0.19692			0.38											
08/01/19 22:00	0.18408			0.19764			0.38											
08/01/19 23:00	0.18228			0.19662			0.38											
08/02/19 0:00	0.18168			0.19638			0.38											
08/02/19 1:00	0.18156			0.1968			0.38											
08/02/19 2:00	0.18096			0.19752			0.38											
08/02/19 3:00	0.18048			0.19764			0.38											
08/02/19 4:00	0.17934			0.19836			0.38											
08/02/19 5:00	0.17898			0.19878			0.38											
08/02/19 6:00	0.1797			0.1983			0.38											
08/02/19 7:00	0.17994			0.19824			0.38											
08/02/19 8:00	0.17946			0.1986			0.38											
08/02/19 9:00	0.17922			0.19878			0.38											
08/02/19 10:00	0.17916			0.19806			0.38											
08/02/19 11:00	0.18114			0.19872			0.38											
08/02/19 12:00	0.19968			0.2199			0.42											
08/02/19 13:00	0.26592			0.2826			0.55											
08/02/19 14:00	0.27354			0.29316			0.57											
08/02/19 15:00	0.35292			0.37308			0.73											
08/02/19 16:00	0.35664			0.37644			0.73											
08/02/19 17:00	0.3606			0.38052			0.74											
08/02/19 18:00	0.31386			0.33432			0.65											
08/02/19 19:00	0.2718			0.2895			0.56											
08/02/19 20:00	0.21474			0.2298			0.44											
08/02/19 21:00	0.18828			0.20202			0.39											
08/02/19 22:00	0.186			0.2016			0.39											
08/02/19 23:00	0.1866			0.20466			0.39											
08/03/19 0:00	0.18522			0.2052			0.39											
08/03/19 1:00	0.17874			0.19578			0.37											
08/03/19 2:00	0.17862			0.19536			0.37											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/03/19 3:00	0.1788			0.19542			0.37											
08/03/19 4:00	0.17892			0.19524			0.37											
08/03/19 5:00	0.17868			0.19512			0.37											
08/03/19 6:00	0.1791			0.19518			0.37											
08/03/19 7:00	0.18528			0.2025			0.39											
08/03/19 8:00	0.18396			0.20274			0.39											
08/03/19 9:00	0.18378			0.20424			0.39											
08/03/19 10:00	0.1881			0.21024			0.4											
08/03/19 11:00	0.19392			0.21642			0.41											
08/03/19 12:00	0.2052			0.22902			0.43											
08/03/19 13:00	0.27786			0.29724			0.58											
08/03/19 14:00	0.30324			0.32196			0.63											
08/03/19 15:00	0.37446			0.39378			0.77											
08/03/19 16:00	0.37182			0.39186			0.76											
08/03/19 17:00	0.36			0.37944			0.74											
08/03/19 18:00	0.3693			0.38868			0.76											
08/03/19 19:00	0.3405			0.36072			0.7											
08/03/19 20:00	0.2829			0.30336			0.59											
08/03/19 21:00	0.2304			0.24804			0.48											
08/03/19 22:00	0.20976			0.22494			0.43											
08/03/19 23:00	0.19032			0.20406			0.39											
08/04/19 0:00	0.1863			0.2016			0.39											
08/04/19 1:00	0.1854			0.20238			0.39											
08/04/19 2:00	0.18456			0.20316			0.39											
08/04/19 3:00	0.18324			0.20418			0.39											
08/04/19 4:00	0.17964			0.20274			0.38											
08/04/19 5:00	0.18228			0.2067			0.39											
08/04/19 6:00	0.17946			0.19848			0.38											
08/04/19 7:00	0.18054			0.1998			0.38											
08/04/19 8:00	0.18198			0.20316			0.39											
08/04/19 9:00	0.18156			0.20376			0.39											
08/04/19 10:00	0.18384			0.20466			0.39											
08/04/19 11:00	0.1986			0.21936			0.42											
08/04/19 12:00	0.26352			0.28482			0.55											
08/04/19 13:00	0.34434			0.36366			0.71											
08/04/19 14:00	0.33852			0.35826			0.7											
08/04/19 15:00	0.34758			0.36732			0.71											
08/04/19 16:00	0.32886			0.34938			0.68											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/04/19 17:00	0.34278			0.3627			0.71											
08/04/19 18:00	0.36882			0.3885			0.76											
08/04/19 19:00	0.37086			0.39102			0.76											
08/04/19 20:00	0.34362			0.36468			0.71											
08/04/19 21:00	0.28806			0.31104			0.6											
08/04/19 22:00	0.25704			0.27984			0.54											
08/04/19 23:00	0.19188			0.20718			0.4											
08/05/19 0:00	0.17826			0.19212			0.37											
08/05/19 1:00	0.17844			0.19236			0.37											
08/05/19 2:00	0.17844			0.19248			0.37											
08/05/19 3:00	0.17826			0.19254			0.37											
08/05/19 4:00	0.17814			0.19254			0.37											
08/05/19 5:00	0.17814			0.1926			0.37											
08/05/19 6:00	0.18534			0.2016			0.39											
08/05/19 7:00	0.18504			0.20268			0.39											
08/05/19 8:00	0.1839			0.20376			0.39											
08/05/19 9:00	0.18612			0.20724			0.39											
08/05/19 10:00	0.18624			0.2088			0.4											
08/05/19 11:00	0.19218			0.21642			0.41											
08/05/19 12:00	0.23094			0.25878			0.49											
08/05/19 13:00	0.25254			0.27354			0.53											
08/05/19 14:00	0.2505			0.27294			0.52											
08/05/19 15:00	0.34752			0.36672			0.71											
08/05/19 16:00	0.35196			0.37128			0.72											
08/05/19 17:00	0.3759			0.39552			0.77											
08/05/19 18:00	0.37584			0.39582			0.77											
08/05/19 19:00	0.34098			0.36228			0.7											
08/05/19 20:00	0.26148			0.28254			0.54											
08/05/19 21:00	0.24			0.2601			0.5											
08/05/19 22:00	0.19674			0.21264			0.41											
08/05/19 23:00	0.17952			0.19368			0.37											
08/06/19 0:00	0.1776			0.19104			0.37											
08/06/19 1:00	0.17766			0.19104			0.37											
08/06/19 2:00	0.17784			0.19134			0.37											
08/06/19 3:00	0.1803			0.1944			0.37											
08/06/19 4:00	0.18276			0.1971			0.38											
08/06/19 5:00	0.19392			0.20994			0.4											
08/06/19 6:00	0.1935			0.21042			0.4											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/06/19 7:00	0.19338			0.21072			0.4											
08/06/19 8:00	0.19266			0.21138			0.4											
08/06/19 9:00	0.18096			0.19914			0.38											
08/06/19 10:00	0.20088			0.22272			0.42											
08/06/19 11:00	0.23982			0.25716			0.5											
08/06/19 12:00	0.25206			0.2709			0.52											
08/06/19 13:00	0.27144			0.29304			0.56											
08/06/19 14:00	0.37332			0.39252			0.77											
08/06/19 15:00	0.3639			0.38328			0.75											
08/06/19 16:00	0.36546			0.38484			0.75											
08/06/19 17:00	0.37464			0.39426			0.77											
08/06/19 18:00	0.35322			0.3756			0.73											
08/06/19 19:00	0.29682			0.31758			0.61											
08/06/19 20:00	0.30198			0.32382			0.63											
08/06/19 21:00	0.25602			0.27768			0.53											
08/06/19 22:00	0.20544			0.22068			0.43											
08/06/19 23:00	0.18138			0.1947			0.38											
08/07/19 0:00	0.17784			0.19134			0.37											
08/07/19 1:00	0.1776			0.1914			0.37											
08/07/19 2:00	0.17838			0.1923			0.37											
08/07/19 3:00	0.17868			0.1929			0.37											
08/07/19 4:00	0.17982			0.19476			0.37											
08/07/19 5:00	0.18018			0.19476			0.37											
08/07/19 6:00	0.18618			0.20208			0.39											
08/07/19 7:00	0.18552			0.20298			0.39											
08/07/19 8:00	0.19134			0.213			0.4											
08/07/19 9:00	0.1926			0.21708			0.41											
08/07/19 10:00	0.1929			0.21822			0.41											
08/07/19 11:00	0.20274			0.21738			0.42											
08/07/19 12:00	0.234			0.25482			0.49											
08/07/19 13:00	0.273			0.29118			0.56											
08/07/19 14:00	0.33012			0.34884			0.68											
08/07/19 15:00	0.34824			0.36708			0.72											
08/07/19 16:00	0.3582			0.37758			0.74											
08/07/19 17:00	0.37794			0.39666			0.77											
08/07/19 18:00	0.35304			0.37374			0.73											
08/07/19 19:00	0.27138			0.29262			0.56											
08/07/19 20:00	0.22386			0.24144			0.47											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/07/19 21:00	0.2109			0.22884			0.44											
08/07/19 22:00	0.17922			0.1935			0.37											
08/07/19 23:00	0.20172			0.22122			0.42											
08/08/19 0:00	0.1842			0.20454			0.39											
08/08/19 1:00	0.17856			0.19302			0.37											
08/08/19 2:00	0.17874			0.19314			0.37											
08/08/19 3:00	0.17868			0.1932			0.37											
08/08/19 4:00	0.16944			0.19068			0.36											
08/08/19 5:00	0	X		0.08946			0.01											
08/08/19 6:00	0	X		0	X		0											
08/08/19 7:00	0	X		0	X		0											
08/08/19 8:00	0	X		0	X		0											
08/08/19 9:00	0	X		0	X		0											
08/08/19 10:00	0	X		0	X		0											
08/08/19 11:00	0	X		0	X		0											
08/08/19 12:00	0	X		0	X		0											
08/08/19 13:00	0	X		0	X		0											
08/08/19 14:00	0	X		0	X		0											
08/08/19 15:00	0	X		0	X		0											
08/08/19 16:00	0	X		0	X		0											
08/08/19 17:00	0	X		0	X		0											
08/08/19 18:00	0	X		0	X		0											
08/08/19 19:00	0	X		0	X		0											
08/08/19 20:00	0	X		0	X		0											
08/08/19 21:00	0	X		0	X		0											
08/08/19 22:00	0	X		0	X		0											
08/08/19 23:00	0	X		0	X		0											
08/09/19 0:00	0	X		0	X		0											
08/09/19 1:00	0	X		0	X		0											
08/09/19 2:00	0	X		0	X		0											
08/09/19 3:00	0	X		0	X		0											
08/09/19 4:00	0	X		0	X		0											
08/09/19 5:00	0	X		0	X		0											
08/09/19 6:00	0	X		0	X		0											
08/09/19 7:00	0	X		0	X		0											
08/09/19 8:00	0	X		0	X		0											
08/09/19 9:00	0	X		0	X		0											
08/09/19 10:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/09/19 11:00	0	X		0	X		0											
08/09/19 12:00	0	X		0	X		0											
08/09/19 13:00	0	X		0	X		0											
08/09/19 14:00	0	X		0	X		0											
08/09/19 15:00	0	X		0	X		0											
08/09/19 16:00	0	X		0	X		0											
08/09/19 17:00	0	X		0	X		0											
08/09/19 18:00	0	X		0	X		0											
08/09/19 19:00	0	X		0	X		0											
08/09/19 20:00	0	X		0	X		0											
08/09/19 21:00	0	X		0	X		0											
08/09/19 22:00	0	X		0	X		0											
08/09/19 23:00	0	X		0	X		0											
08/10/19 0:00	0	X		0	X		0											
08/10/19 1:00	0	X		0	X		0											
08/10/19 2:00	0	X		0	X		0											
08/10/19 3:00	0	X		0	X		0											
08/10/19 4:00	0	X		0	X		0											
08/10/19 5:00	0	X		0	X		0											
08/10/19 6:00	0	X		0	X		0											
08/10/19 7:00	0	X		0	X		0											
08/10/19 8:00	0	X		0	X		0											
08/10/19 9:00	0	X		0	X		0											
08/10/19 10:00	0	X		0	X		0											
08/10/19 11:00	0	X		0	X		0											
08/10/19 12:00	0	X		0	X		0											
08/10/19 13:00	0	X		0	X		0											
08/10/19 14:00	0	X		0	X		0											
08/10/19 15:00	0	X		0	X		0											
08/10/19 16:00	0	X		0	X		0											
08/10/19 17:00	0	X		0	X		0											
08/10/19 18:00	0	X		0	X		0											
08/10/19 19:00	0	X		0	X		0											
08/10/19 20:00	0	X		0	X		0											
08/10/19 21:00	0	X		0	X		0											
08/10/19 22:00	0	X		0	X		0											
08/10/19 23:00	0	X		0	X		0											
08/11/19 0:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H										
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
08/11/19 1:00	0	X		0	X		0											
08/11/19 2:00	0	X		0	X		0											
08/11/19 3:00	0	X		0	X		0											
08/11/19 4:00	0	X		0	X		0											
08/11/19 5:00	0	X		0	X		0											
08/11/19 6:00	0	X		0	X		0											
08/11/19 7:00	0	X		0	X		0											
08/11/19 8:00	0	X		0	X		0											
08/11/19 9:00	0	X		0	X		0											
08/11/19 10:00	0	X		0	X		0											
08/11/19 11:00	0	X		0	X		0											
08/11/19 12:00	0	X		0	X		0											
08/11/19 13:00	0	X		0	X		0											
08/11/19 14:00	0	X		0	X		0											
08/11/19 15:00	0	X		0	X		0											
08/11/19 16:00	0	X		0	X		0											
08/11/19 17:00	0	X		0	X		0											
08/11/19 18:00	0	X		0	X		0											
08/11/19 19:00	0	X		0	X		0											
08/11/19 20:00	0	X		0	X		0											
08/11/19 21:00	0	X		0	X		0											
08/11/19 22:00	0	X		0	X		0											
08/11/19 23:00	0	X		0	X		0											
08/12/19 0:00	0	X		0	X		0											
08/12/19 1:00	0	X		0	X		0											
08/12/19 2:00	0	X		0	X		0											
08/12/19 3:00	0	X		0	X		0											
08/12/19 4:00	0	X		0	X		0											
08/12/19 5:00	0	X		0	X		0											
08/12/19 6:00	0	X		0	X		0											
08/12/19 7:00	0	X		0	X		0											
08/12/19 8:00	0	X		0	X		0											
08/12/19 9:00	0	X		0	X		0											
08/12/19 10:00	0	X		0	X		0											
08/12/19 11:00	0	X		0	X		0											
08/12/19 12:00	0	X		0	X		0											
08/12/19 13:00	0	X		0	X		0											
08/12/19 14:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/12/19 15:00	0	X		0	X		0											
08/12/19 16:00	0	X		0	X		0											
08/12/19 17:00	0	X		0	X		0											
08/12/19 18:00	0	X		0	X		0											
08/12/19 19:00	0	X		0	X		0											
08/12/19 20:00	0	X		0	X		0											
08/12/19 21:00	0	X		0	X		0											
08/12/19 22:00	0	X		0	X		0											
08/12/19 23:00	0	X		0	X		0											
08/13/19 0:00	0	X		0	X		0											
08/13/19 1:00	0	X		0	X		0											
08/13/19 2:00	0	X		0	X		0											
08/13/19 3:00	0	X		0	X		0											
08/13/19 4:00	0	X		0	X		0											
08/13/19 5:00	0	X		0	X		0											
08/13/19 6:00	0.09582			0	X		0.02											
08/13/19 7:00	0.26226			0	X		0.26											
08/13/19 8:00	0.26334			0	X		0.26											
08/13/19 9:00	0.2346			0	X		0.23											
08/13/19 10:00	0.22698			0	X		0.23											
08/13/19 11:00	0.25554			0	X		0.26											
08/13/19 12:00	0.22716			0	X		0.23											
08/13/19 13:00	0.22392			0	X		0.22											
08/13/19 14:00	0.2286			0	X		0.23											
08/13/19 15:00	0.37176			0	X		0.37											
08/13/19 16:00	0.37902			0	X		0.38											
08/13/19 17:00	0.381			0	X		0.38											
08/13/19 18:00	0.34068			0	X		0.34											
08/13/19 19:00	0.37398			0	X		0.37											
08/13/19 20:00	0.36594			0	X		0.37											
08/13/19 21:00	0.3354			0	X		0.34											
08/13/19 22:00	0.29142			0	X		0.29											
08/13/19 23:00	0.33924			0	X		0.34											
08/14/19 0:00	0.31344			0	X		0.31											
08/14/19 1:00	0.30576			0	X		0.31											
08/14/19 2:00	0.28758			0	X		0.29											
08/14/19 3:00	0.29082			0	X		0.29											
08/14/19 4:00	0.36078			0	X		0.36											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/14/19 5:00	0.36492			0	X		0.36											
08/14/19 6:00	0.36228			0.11154			0.39											
08/14/19 7:00	0.21942			0.23082			0.45											
08/14/19 8:00	0.18168			0.19548			0.38											
08/14/19 9:00	0.17898			0.19386			0.37											
08/14/19 10:00	0.17934			0.19308			0.37											
08/14/19 11:00	0.1803			0.19248			0.37											
08/14/19 12:00	0.18294			0.19548			0.38											
08/14/19 13:00	0.25428			0.2742			0.53											
08/14/19 14:00	0.26928			0.2895			0.56											
08/14/19 15:00	0.36894			0.3894			0.76											
08/14/19 16:00	0.37248			0.39324			0.77											
08/14/19 17:00	0.37224			0.39282			0.77											
08/14/19 18:00	0.324			0.34668			0.67											
08/14/19 19:00	0.35682			0.3792			0.74											
08/14/19 20:00	0.29802			0.32388			0.62											
08/14/19 21:00	0.23598			0.25692			0.49											
08/14/19 22:00	0.23652			0.27156			0.51											
08/14/19 23:00	0.17904			0.19446			0.37											
08/15/19 0:00	0.17928			0.19242			0.37											
08/15/19 1:00	0.17892			0.1929			0.37											
08/15/19 2:00	0.1788			0.19272			0.37											
08/15/19 3:00	0.17856			0.1929			0.37											
08/15/19 4:00	0.17904			0.1929			0.37											
08/15/19 5:00	0.17874			0.19302			0.37											
08/15/19 6:00	0.21468			0.23364			0.45											
08/15/19 7:00	0.21558			0.23568			0.45											
08/15/19 8:00	0.22638			0.25116			0.48											
08/15/19 9:00	0.2304			0.25614			0.49											
08/15/19 10:00	0.22014			0.24264			0.46											
08/15/19 11:00	0.21498			0.2361			0.45											
08/15/19 12:00	0.24498			0.26022			0.51											
08/15/19 13:00	0.25032			0.26832			0.52											
08/15/19 14:00	0.36792			0.38844			0.76											
08/15/19 15:00	0.3726			0.39384			0.77											
08/15/19 16:00	0.37128			0.39342			0.76											
08/15/19 17:00	0.37098			0.39246			0.76											
08/15/19 18:00	0.35964			0.38112			0.74											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/15/19 19:00	0.32184			0.34356			0.67											
08/15/19 20:00	0.2955			0.31788			0.61											
08/15/19 21:00	0.2703			0.29322			0.56											
08/15/19 22:00	0.25656			0.27672			0.53											
08/15/19 23:00	0.18114			0.19464			0.38											
08/16/19 0:00	0.1791			0.19476			0.37											
08/16/19 1:00	0.1785			0.1932			0.37											
08/16/19 2:00	0.17814			0.19158			0.37											
08/16/19 3:00	0.17796			0.19158			0.37											
08/16/19 4:00	0.17802			0.1917			0.37											
08/16/19 5:00	0.17778			0.19194			0.37											
08/16/19 6:00	0.1809			0.195			0.38											
08/16/19 7:00	0.1986			0.21486			0.41											
08/16/19 8:00	0.19926			0.21762			0.42											
08/16/19 9:00	0.2097			0.23082			0.44											
08/16/19 10:00	0.25002			0.26946			0.52											
08/16/19 11:00	0.23532			0.25302			0.49											
08/16/19 12:00	0.28542			0.30612			0.59											
08/16/19 13:00	0.32202			0.34104			0.66											
08/16/19 14:00	0.34974			0.36876			0.72											
08/16/19 15:00	0.3702			0.38946			0.76											
08/16/19 16:00	0.3261			0.34686			0.67											
08/16/19 17:00	0.34458			0.36432			0.71											
08/16/19 18:00	0.31944			0.3408			0.66											
08/16/19 19:00	0.32994			0.35088			0.68											
08/16/19 20:00	0.34494			0.3675			0.71											
08/16/19 21:00	0.30978			0.33198			0.64											
08/16/19 22:00	0.31116			0.30294			0.61											
08/16/19 23:00	0.37044			0.105			0.38											
08/17/19 0:00	0.35598			0	X		0.36											
08/17/19 1:00	0.31884			0	X		0.32											
08/17/19 2:00	0.24372			0	X		0.24											
08/17/19 3:00	0.22572			0	X		0.23											
08/17/19 4:00	0.22116			0	X		0.22											
08/17/19 5:00	0.21834			0	X		0.22											
08/17/19 6:00	0.20682			0	X		0.21											
08/17/19 7:00	0.22254			0	X		0.22											
08/17/19 8:00	0.2238			0	X		0.22											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/17/19 9:00	0.22386			0	X		0.22											
08/17/19 10:00	0.22536			0	X		0.23											
08/17/19 11:00	0.22344			0	X		0.22											
08/17/19 12:00	0.1944			0	X		0.19											
08/17/19 13:00	0.1926			0	X		0.19											
08/17/19 14:00	0.20892			0	X		0.21											
08/17/19 15:00	0.21156			0	X		0.21											
08/17/19 16:00	0.27174			0	X		0.27											
08/17/19 17:00	0.37632			0	X		0.38											
08/17/19 18:00	0.3741			0	X		0.37											
08/17/19 19:00	0.33336			0	X		0.33											
08/17/19 20:00	0.31458			0	X		0.31											
08/17/19 21:00	0.3156			0	X		0.32											
08/17/19 22:00	0.28302			0	X		0.28											
08/17/19 23:00	0.10734			0	X		0.01											
08/18/19 0:00	0	X		0	X		0											
08/18/19 1:00	0	X		0	X		0											
08/18/19 2:00	0	X		0	X		0											
08/18/19 3:00	0	X		0	X		0											
08/18/19 4:00	0	X		0	X		0											
08/18/19 5:00	0	X		0	X		0											
08/18/19 6:00	0	X		0	X		0											
08/18/19 7:00	0	X		0	X		0											
08/18/19 8:00	0	X		0	X		0											
08/18/19 9:00	0	X		0	X		0											
08/18/19 10:00	0	X		0	X		0											
08/18/19 11:00	0	X		0	X		0											
08/18/19 12:00	0	X		0	X		0											
08/18/19 13:00	0	X		0	X		0											
08/18/19 14:00	0	X		0	X		0											
08/18/19 15:00	0	X		0	X		0											
08/18/19 16:00	0	X		0	X		0											
08/18/19 17:00	0	X		0	X		0											
08/18/19 18:00	0	X		0	X		0											
08/18/19 19:00	0	X		0	X		0											
08/18/19 20:00	0	X		0	X		0											
08/18/19 21:00	0	X		0	X		0											
08/18/19 22:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/18/19 23:00	0	X		0	X		0											
08/19/19 0:00	0	X		0	X		0											
08/19/19 1:00	0	X		0	X		0											
08/19/19 2:00	0	X		0	X		0											
08/19/19 3:00	0	X		0	X		0											
08/19/19 4:00	0	X		0	X		0											
08/19/19 5:00	0	X		0	X		0											
08/19/19 6:00	0	X		0	X		0											
08/19/19 7:00	0	X		0	X		0											
08/19/19 8:00	0	X		0	X		0											
08/19/19 9:00	0	X		0	X		0											
08/19/19 10:00	0	X		0	X		0											
08/19/19 11:00	0	X		0	X		0											
08/19/19 12:00	0	X		0	X		0											
08/19/19 13:00	0	X		0	X		0											
08/19/19 14:00	0	X		0	X		0											
08/19/19 15:00	0	X		0	X		0											
08/19/19 16:00	0	X		0	X		0											
08/19/19 17:00	0	X		0	X		0											
08/19/19 18:00	0	X		0	X		0											
08/19/19 19:00	0	X		0	X		0											
08/19/19 20:00	0	X		0	X		0											
08/19/19 21:00	0	X		0	X		0											
08/19/19 22:00	0	X		0	X		0											
08/19/19 23:00	0	X		0	X		0											
08/20/19 0:00	0	X		0	X		0											
08/20/19 1:00	0	X		0	X		0											
08/20/19 2:00	0	X		0	X		0											
08/20/19 3:00	0	X		0	X		0											
08/20/19 4:00	0	X		0	X		0											
08/20/19 5:00	0	X		0	X		0											
08/20/19 6:00	0	X		0	X		0											
08/20/19 7:00	0	X		0	X		0											
08/20/19 8:00	0	X		0	X		0											
08/20/19 9:00	0	X		0	X		0											
08/20/19 10:00	0	X		0	X		0											
08/20/19 11:00	0	X		0	X		0											
08/20/19 12:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/20/19 13:00	0	X		0	X		0											
08/20/19 14:00	0	X		0	X		0											
08/20/19 15:00	0	X		0	X		0											
08/20/19 16:00	0	X		0	X		0											
08/20/19 17:00	0	X		0	X		0											
08/20/19 18:00	0	X		0	X		0											
08/20/19 19:00	0	X		0	X		0											
08/20/19 20:00	0	X		0	X		0											
08/20/19 21:00	0	X		0	X		0											
08/20/19 22:00	0	X		0	X		0											
08/20/19 23:00	0	X		0	X		0											
08/21/19 0:00	0	X		0	X		0											
08/21/19 1:00	0	X		0	X		0											
08/21/19 2:00	0	X		0	X		0											
08/21/19 3:00	0	X		0	X		0											
08/21/19 4:00	0	X		0	X		0											
08/21/19 5:00	0	X		0	X		0											
08/21/19 6:00	0	X		0	X		0											
08/21/19 7:00	0	X		0	X		0											
08/21/19 8:00	0	X		0	X		0											
08/21/19 9:00	0	X		0	X		0											
08/21/19 10:00	0	X		0	X		0											
08/21/19 11:00	0	X		0	X		0											
08/21/19 12:00	0	X		0	X		0											
08/21/19 13:00	0	X		0	X		0											
08/21/19 14:00	0	X		0	X		0											
08/21/19 15:00	0	X		0	X		0											
08/21/19 16:00	0	X		0	X		0											
08/21/19 17:00	0	X		0	X		0											
08/21/19 18:00	0	X		0	X		0											
08/21/19 19:00	0	X		0	X		0											
08/21/19 20:00	0	X		0	X		0											
08/21/19 21:00	0	X		0	X		0											
08/21/19 22:00	0	X		0	X		0											
08/21/19 23:00	0	X		0	X		0											
08/22/19 0:00	0	X		0	X		0											
08/22/19 1:00	0	X		0	X		0											
08/22/19 2:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
08/22/19 3:00	0	X		0	X		0											
08/22/19 4:00	0	X		0	X		0											
08/22/19 5:00	0	X		0	X		0											
08/22/19 6:00	0	X		0	X		0											
08/22/19 7:00	0	X		0	X		0											
08/22/19 8:00	0	X		0	X		0											
08/22/19 9:00	0	X		0	X		0											
08/22/19 10:00	0	X		0	X		0											
08/22/19 11:00	0	X		0	X		0											
08/22/19 12:00	0	X		0	X		0											
08/22/19 13:00	0	X		0	X		0											
08/22/19 14:00	0	X		0	X		0											
08/22/19 15:00	0	X		0	X		0											
08/22/19 16:00	0	X		0	X		0											
08/22/19 17:00	0	X		0	X		0											
08/22/19 18:00	0	X		0	X		0											
08/22/19 19:00	0	X		0	X		0											
08/22/19 20:00	0	X		0	X		0											
08/22/19 21:00	0	X		0	X		0											
08/22/19 22:00	0	X		0	X		0											
08/22/19 23:00	0	X		0	X		0											
08/23/19 0:00	0	X		0	X		0											
08/23/19 1:00	0	X		0	X		0											
08/23/19 2:00	0	X		0	X		0											
08/23/19 3:00	0	X		0	X		0											
08/23/19 4:00	0	X		0	X		0											
08/23/19 5:00	0	X		0	X		0											
08/23/19 6:00	0	X		0	X		0											
08/23/19 7:00	0	X		0	X		0											
08/23/19 8:00	0	X		0	X		0											
08/23/19 9:00	0	X		0	X		0											
08/23/19 10:00	0	X		0	X		0											
08/23/19 11:00	0	X		0	X		0											
08/23/19 12:00	0	X		0	X		0											
08/23/19 13:00	0	X		0	X		0											
08/23/19 14:00	0	X		0	X		0											
08/23/19 15:00	0	X		0	X		0											
08/23/19 16:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
08/23/19 17:00	0	X		0	X		0											
08/23/19 18:00	0	X		0	X		0											
08/23/19 19:00	0	X		0	X		0											
08/23/19 20:00	0	X		0	X		0											
08/23/19 21:00	0	X		0	X		0											
08/23/19 22:00	0	X		0	X		0											
08/23/19 23:00	0	X		0	X		0											
08/24/19 0:00	0	X		0	X		0											
08/24/19 1:00	0	X		0	X		0											
08/24/19 2:00	0	X		0	X		0											
08/24/19 3:00	0	X		0	X		0											
08/24/19 4:00	0	X		0	X		0											
08/24/19 5:00	0	X		0	X		0											
08/24/19 6:00	0	X		0	X		0											
08/24/19 7:00	0	X		0	X		0											
08/24/19 8:00	0	X		0	X		0											
08/24/19 9:00	0	X		0	X		0											
08/24/19 10:00	0	X		0	X		0											
08/24/19 11:00	0	X		0	X		0											
08/24/19 12:00	0	X		0	X		0											
08/24/19 13:00	0	X		0	X		0											
08/24/19 14:00	0	X		0	X		0											
08/24/19 15:00	0	X		0	X		0											
08/24/19 16:00	0	X		0	X		0											
08/24/19 17:00	0	X		0	X		0											
08/24/19 18:00	0	X		0	X		0											
08/24/19 19:00	0	X		0	X		0											
08/24/19 20:00	0	X		0	X		0											
08/24/19 21:00	0	X		0	X		0											
08/24/19 22:00	0	X		0	X		0											
08/24/19 23:00	0	X		0	X		0											
08/25/19 0:00	0	X		0	X		0											
08/25/19 1:00	0	X		0	X		0											
08/25/19 2:00	0	X		0	X		0											
08/25/19 3:00	0	X		0	X		0											
08/25/19 4:00	0	X		0	X		0											
08/25/19 5:00	0	X		0	X		0											
08/25/19 6:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/25/19 7:00	0	X		0.1092			0.03											
08/25/19 8:00	0	X		0.2766			0.28											
08/25/19 9:00	0	X		0.27864			0.28											
08/25/19 10:00	0	X		0.27918			0.28											
08/25/19 11:00	0	X		0.36918			0.37											
08/25/19 12:00	0	X		0.39396			0.39											
08/25/19 13:00	0	X		0.39318			0.39											
08/25/19 14:00	0	X		0.39168			0.39											
08/25/19 15:00	0	X		0.39042			0.39											
08/25/19 16:00	0	X		0.32118			0.32											
08/25/19 17:00	0	X		0.31278			0.31											
08/25/19 18:00	0	X		0.31452			0.31											
08/25/19 19:00	0	X		0.31728			0.32											
08/25/19 20:00	0	X		0.35292			0.35											
08/25/19 21:00	0	X		0.27984			0.28											
08/25/19 22:00	0	X		0.27288			0.27											
08/25/19 23:00	0	X		0.24072			0.24											
08/26/19 0:00	0	X		0.20436			0.2											
08/26/19 1:00	0	X		0.20226			0.2											
08/26/19 2:00	0	X		0.20172			0.2											
08/26/19 3:00	0	X		0.20166			0.2											
08/26/19 4:00	0	X		0.20244			0.2											
08/26/19 5:00	0	X		0.20562			0.21											
08/26/19 6:00	0	X		0.2154			0.22											
08/26/19 7:00	0	X		0.21966			0.22											
08/26/19 8:00	0	X		0.24066			0.24											
08/26/19 9:00	0	X		0.28218			0.28											
08/26/19 10:00	0	X		0.3783			0.38											
08/26/19 11:00	0	X		0.37734			0.38											
08/26/19 12:00	0	X		0.37554			0.38											
08/26/19 13:00	0	X		0.35124			0.35											
08/26/19 14:00	0	X		0.32568			0.33											
08/26/19 15:00	0	X		0.2691			0.27											
08/26/19 16:00	0	X		0.3246			0.32											
08/26/19 17:00	0	X		0.32382			0.32											
08/26/19 18:00	0	X		0.31638			0.32											
08/26/19 19:00	0	X		0.28344			0.28											
08/26/19 20:00	0	X		0.33378			0.33											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/26/19 21:00	0	X		0.24174			0.24											
08/26/19 22:00	0	X		0.2304			0.23											
08/26/19 23:00	0	X		0.24258			0.24											
08/27/19 0:00	0	X		0.2589			0.26											
08/27/19 1:00	0	X		0.24144			0.24											
08/27/19 2:00	0	X		0.2403			0.24											
08/27/19 3:00	0	X		0.23556			0.24											
08/27/19 4:00	0	X		0.25956			0.26											
08/27/19 5:00	0.09594			0.2439			0.27											
08/27/19 6:00	0.19656			0.21996			0.42											
08/27/19 7:00	0.19572			0.21078			0.41											
08/27/19 8:00	0.19488			0.2097			0.4											
08/27/19 9:00	0.1953			0.21006			0.41											
08/27/19 10:00	0.19938			0.21558			0.41											
08/27/19 11:00	0.19776			0.2139			0.41											
08/27/19 12:00	0.21702			0.23952			0.46											
08/27/19 13:00	0.30606			0.3261			0.63											
08/27/19 14:00	0.31302			0.33246			0.65											
08/27/19 15:00	0.37392			0.39294			0.77											
08/27/19 16:00	0.37188			0.38976			0.76											
08/27/19 17:00	0.3648			0.3837			0.75											
08/27/19 18:00	0.36246			0.3816			0.74											
08/27/19 19:00	0.3615			0.38112			0.74											
08/27/19 20:00	0.35454			0.37626			0.73											
08/27/19 21:00	0.25908			0.28038			0.54											
08/27/19 22:00	0.21786			0.2331			0.45											
08/27/19 23:00	0.19308			0.20706			0.4											
08/28/19 0:00	0.1905			0.20676			0.4											
08/28/19 1:00	0.18366			0.2028			0.39											
08/28/19 2:00	0.18192			0.20418			0.39											
08/28/19 3:00	0.18066			0.20586			0.39											
08/28/19 4:00	0.19158			0.22014			0.41											
08/28/19 5:00	0.19362			0.2244			0.42											
08/28/19 6:00	0.21276			0.24624			0.46											
08/28/19 7:00	0.37152			0.39204			0.76											
08/28/19 8:00	0.37704			0.39876			0.78											
08/28/19 9:00	0.37716			0.39834			0.78											
08/28/19 10:00	0.3792			0.399			0.78											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/28/19 11:00	0.38238			0.40128			0.78											
08/28/19 12:00	0.3822			0.40014			0.78											
08/28/19 13:00	0.3783			0.39786			0.78											
08/28/19 14:00	0.3762			0.39666			0.77											
08/28/19 15:00	0.37488			0.39612			0.77											
08/28/19 16:00	0.37506			0.39552			0.77											
08/28/19 17:00	0.3738			0.39582			0.77											
08/28/19 18:00	0.36966			0.39132			0.76											
08/28/19 19:00	0.34014			0.36132			0.7											
08/28/19 20:00	0.29166			0.31248			0.6											
08/28/19 21:00	0.22248			0.24102			0.46											
08/28/19 22:00	0.20298			0.22104			0.42											
08/28/19 23:00	0.18282			0.20022			0.38											
08/29/19 0:00	0.19056			0.21108			0.4											
08/29/19 1:00	0.17958			0.20118			0.38											
08/29/19 2:00	0.17928			0.20136			0.38											
08/29/19 3:00	0.1797			0.20208			0.38											
08/29/19 4:00	0.1851			0.20898			0.39											
08/29/19 5:00	0.1797			0.20166			0.38											
08/29/19 6:00	0.18744			0.20898			0.4											
08/29/19 7:00	0.18864			0.2115			0.4											
08/29/19 8:00	0.20124			0.22608			0.43											
08/29/19 9:00	0.22398			0.25176			0.48											
08/29/19 10:00	0.25158			0.2769			0.53											
08/29/19 11:00	0.29508			0.3141			0.61											
08/29/19 12:00	0.31962			0.33918			0.66											
08/29/19 13:00	0.312			0.33186			0.64											
08/29/19 14:00	0.32874			0.34884			0.68											
08/29/19 15:00	0.33186			0.35148			0.68											
08/29/19 16:00	0.333			0.35298			0.69											
08/29/19 17:00	0.3339			0.3537			0.69											
08/29/19 18:00	0.33984			0.36042			0.7											
08/29/19 19:00	0.32352			0.34392			0.67											
08/29/19 20:00	0.26118			0.28296			0.54											
08/29/19 21:00	0.23364			0.25236			0.49											
08/29/19 22:00	0.19638			0.21348			0.41											
08/29/19 23:00	0.08886			0.1176			0.02											
08/30/19 0:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/30/19 1:00	0	X		0	X		0											
08/30/19 2:00	0	X		0	X		0											
08/30/19 3:00	0	X		0	X		0											
08/30/19 4:00	0	X		0	X		0											
08/30/19 5:00	0	X		0	X		0											
08/30/19 6:00	0	X		0	X		0											
08/30/19 7:00	0	X		0	X		0											
08/30/19 8:00	0	X		0	X		0											
08/30/19 9:00	0	X		0	X		0											
08/30/19 10:00	0	X		0	X		0											
08/30/19 11:00	0	X		0	X		0											
08/30/19 12:00	0	X		0	X		0											
08/30/19 13:00	0	X		0	X		0											
08/30/19 14:00	0	X		0	X		0											
08/30/19 15:00	0	X		0	X		0											
08/30/19 16:00	0	X		0	X		0											
08/30/19 17:00	0	X		0	X		0											
08/30/19 18:00	0	X		0	X		0											
08/30/19 19:00	0	X		0	X		0											
08/30/19 20:00	0	X		0	X		0											
08/30/19 21:00	0	X		0	X		0											
08/30/19 22:00	0	X		0	X		0											
08/30/19 23:00	0	X		0	X		0											
08/31/19 0:00	0	X		0	X		0											
08/31/19 1:00	0	X		0	X		0											
08/31/19 2:00	0	X		0	X		0											
08/31/19 3:00	0	X		0	X		0											
08/31/19 4:00	0	X		0	X		0											
08/31/19 5:00	0	X		0	X		0											
08/31/19 6:00	0	X		0	X		0											
08/31/19 7:00	0	X		0	X		0											
08/31/19 8:00	0	X		0	X		0											
08/31/19 9:00	0	X		0	X		0											
08/31/19 10:00	0	X		0	X		0											
08/31/19 11:00	0	X		0	X		0											
08/31/19 12:00	0	X		0	X		0											
08/31/19 13:00	0	X		0	X		0											
08/31/19 14:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H										
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/31/19 15:00	0	X		0	X		0											
08/31/19 16:00	0	X		0	X		0											
08/31/19 17:00	0	X		0	X		0											
08/31/19 18:00	0	X		0	X		0											
08/31/19 19:00	0	X		0	X		0											
08/31/19 20:00	0	X		0	X		0											
08/31/19 21:00	0	X		0	X		0											
08/31/19 22:00	0	X		0	X		0											
08/31/19 23:00	0	X		0	X		0											
09/01/19 0:00	0	X		0	X		0											
09/01/19 1:00	0	X		0	X		0											
09/01/19 2:00	0	X		0	X		0											
09/01/19 3:00	0	X		0	X		0											
09/01/19 4:00	0	X		0	X		0											
09/01/19 5:00	0	X		0	X		0											
09/01/19 6:00	0	X		0	X		0											
09/01/19 7:00	0	X		0	X		0											
09/01/19 8:00	0	X		0	X		0											
09/01/19 9:00	0	X		0	X		0											
09/01/19 10:00	0	X		0	X		0											
09/01/19 11:00	0	X		0	X		0											
09/01/19 12:00	0	X		0	X		0											
09/01/19 13:00	0	X		0	X		0											
09/01/19 14:00	0	X		0	X		0											
09/01/19 15:00	0	X		0	X		0											
09/01/19 16:00	0	X		0	X		0											
09/01/19 17:00	0	X		0	X		0											
09/01/19 18:00	0	X		0	X		0											
09/01/19 19:00	0	X		0	X		0											
09/01/19 20:00	0	X		0	X		0											
09/01/19 21:00	0	X		0	X		0											
09/01/19 22:00	0	X		0	X		0											
09/01/19 23:00	0	X		0	X		0											
09/02/19 0:00	0	X		0	X		0											
09/02/19 1:00	0	X		0	X		0											
09/02/19 2:00	0	X		0	X		0											
09/02/19 3:00	0	X		0	X		0											
09/02/19 4:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/02/19 5:00	0	X		0	X		0											
09/02/19 6:00	0	X		0	X		0											
09/02/19 7:00	0	X		0	X		0											
09/02/19 8:00	0	X		0	X		0											
09/02/19 9:00	0	X		0	X		0											
09/02/19 10:00	0	X		0	X		0											
09/02/19 11:00	0	X		0	X		0											
09/02/19 12:00	0	X		0	X		0											
09/02/19 13:00	0	X		0	X		0											
09/02/19 14:00	0	X		0	X		0											
09/02/19 15:00	0	X		0	X		0											
09/02/19 16:00	0	X		0	X		0											
09/02/19 17:00	0	X		0	X		0											
09/02/19 18:00	0	X		0	X		0											
09/02/19 19:00	0	X		0	X		0											
09/02/19 20:00	0	X		0	X		0											
09/02/19 21:00	0	X		0	X		0											
09/02/19 22:00	0	X		0	X		0											
09/02/19 23:00	0	X		0	X		0											
09/03/19 0:00	0	X		0	X		0											
09/03/19 1:00	0	X		0	X		0											
09/03/19 2:00	0	X		0	X		0											
09/03/19 3:00	0	X		0	X		0											
09/03/19 4:00	0	X		0	X		0											
09/03/19 5:00	0	X		0	X		0											
09/03/19 6:00	0	X		0	X		0											
09/03/19 7:00	0	X		0	X		0											
09/03/19 8:00	0	X		0	X		0											
09/03/19 9:00	0	X		0	X		0											
09/03/19 10:00	0	X		0	X		0											
09/03/19 11:00	0	X		0	X		0											
09/03/19 12:00	0	X		0	X		0											
09/03/19 13:00	0	X		0	X		0											
09/03/19 14:00	0	X		0	X		0											
09/03/19 15:00	0	X		0	X		0											
09/03/19 16:00	0	X		0	X		0											
09/03/19 17:00	0	X		0	X		0											
09/03/19 18:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/03/19 19:00	0	X		0	X		0											
09/03/19 20:00	0	X		0	X		0											
09/03/19 21:00	0	X		0	X		0											
09/03/19 22:00	0	X		0	X		0											
09/03/19 23:00	0	X		0	X		0											
09/04/19 0:00	0	X		0	X		0											
09/04/19 1:00	0	X		0	X		0											
09/04/19 2:00	0	X		0	X		0											
09/04/19 3:00	0	X		0	X		0											
09/04/19 4:00	0	X		0	X		0											
09/04/19 5:00	0.08976			0	X		0.02											
09/04/19 6:00	0.26328			0.096			0.29											
09/04/19 7:00	0.2439			0.25944			0.5											
09/04/19 8:00	0.21714			0.23424			0.45											
09/04/19 9:00	0.23214			0.25128			0.48											
09/04/19 10:00	0.24756			0.2709			0.52											
09/04/19 11:00	0.32238			0.3417			0.66											
09/04/19 12:00	0.3279			0.34758			0.68											
09/04/19 13:00	0.3399			0.36054			0.7											
09/04/19 14:00	0.37776			0.39864			0.78											
09/04/19 15:00	0.37824			0.399			0.78											
09/04/19 16:00	0.37434			0.3966			0.77											
09/04/19 17:00	0.2397			0.26052			0.5											
09/04/19 18:00	0.23268			0.25626			0.49											
09/04/19 19:00	0.23898			0.26748			0.51											
09/04/19 20:00	0.31692			0.34122			0.66											
09/04/19 21:00	0.2013			0.21696			0.42											
09/04/19 22:00	0.18756			0.20406			0.39											
09/04/19 23:00	0.23364			0.25974			0.49											
09/05/19 0:00	0.21366			0.24144			0.46											
09/05/19 1:00	0.19698			0.22806			0.43											
09/05/19 2:00	0.1794			0.20736			0.39											
09/05/19 3:00	0.1803			0.204			0.38											
09/05/19 4:00	0.19254			0.21888			0.41											
09/05/19 5:00	0.18234			0.20994			0.39											
09/05/19 6:00	0.18978			0.219			0.41											
09/05/19 7:00	0.20496			0.2361			0.44											
09/05/19 8:00	0.22512			0.25908			0.48											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/05/19 9:00	0.27012			0.29076			0.56											
09/05/19 10:00	0.29394			0.31416			0.61											
09/05/19 11:00	0.31002			0.33006			0.64											
09/05/19 12:00	0.32484			0.34464			0.67											
09/05/19 13:00	0.38262			0.4026			0.79											
09/05/19 14:00	0.38178			0.40212			0.78											
09/05/19 15:00	0.38112			0.40164			0.78											
09/05/19 16:00	0.33828			0.35934			0.7											
09/05/19 17:00	0.33564			0.35736			0.69											
09/05/19 18:00	0.30108			0.32328			0.62											
09/05/19 19:00	0.24834			0.27162			0.52											
09/05/19 20:00	0.22908			0.25326			0.48											
09/05/19 21:00	0.24276			0.27192			0.51											
09/05/19 22:00	0.22362			0.24564			0.47											
09/05/19 23:00	0.09504			0.1353			0.03											
09/06/19 0:00	0	X		0	X		0											
09/06/19 1:00	0	X		0	X		0											
09/06/19 2:00	0	X		0	X		0											
09/06/19 3:00	0	X		0	X		0											
09/06/19 4:00	0	X		0	X		0											
09/06/19 5:00	0	X		0	X		0											
09/06/19 6:00	0	X		0	X		0											
09/06/19 7:00	0	X		0	X		0											
09/06/19 8:00	0	X		0	X		0											
09/06/19 9:00	0	X		0	X		0											
09/06/19 10:00	0	X		0	X		0											
09/06/19 11:00	0	X		0	X		0											
09/06/19 12:00	0	X		0	X		0											
09/06/19 13:00	0	X		0	X		0											
09/06/19 14:00	0	X		0	X		0											
09/06/19 15:00	0	X		0	X		0											
09/06/19 16:00	0	X		0	X		0											
09/06/19 17:00	0	X		0	X		0											
09/06/19 18:00	0	X		0	X		0											
09/06/19 19:00	0	X		0	X		0											
09/06/19 20:00	0	X		0	X		0											
09/06/19 21:00	0	X		0	X		0											
09/06/19 22:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/06/19 23:00	0	X		0	X		0											
09/07/19 0:00	0	X		0	X		0											
09/07/19 1:00	0	X		0	X		0											
09/07/19 2:00	0	X		0	X		0											
09/07/19 3:00	0	X		0	X		0											
09/07/19 4:00	0	X		0	X		0											
09/07/19 5:00	0	X		0	X		0											
09/07/19 6:00	0	X		0	X		0											
09/07/19 7:00	0	X		0	X		0											
09/07/19 8:00	0	X		0	X		0											
09/07/19 9:00	0	X		0	X		0											
09/07/19 10:00	0	X		0	X		0											
09/07/19 11:00	0	X		0	X		0											
09/07/19 12:00	0	X		0	X		0											
09/07/19 13:00	0	X		0	X		0											
09/07/19 14:00	0	X		0	X		0											
09/07/19 15:00	0	X		0	X		0											
09/07/19 16:00	0	X		0	X		0											
09/07/19 17:00	0	X		0	X		0											
09/07/19 18:00	0	X		0	X		0											
09/07/19 19:00	0	X		0	X		0											
09/07/19 20:00	0	X		0	X		0											
09/07/19 21:00	0	X		0	X		0											
09/07/19 22:00	0	X		0	X		0											
09/07/19 23:00	0	X		0	X		0											
09/08/19 0:00	0	X		0	X		0											
09/08/19 1:00	0	X		0	X		0											
09/08/19 2:00	0	X		0	X		0											
09/08/19 3:00	0	X		0	X		0											
09/08/19 4:00	0	X		0	X		0											
09/08/19 5:00	0	X		0	X		0											
09/08/19 6:00	0	X		0	X		0											
09/08/19 7:00	0	X		0	X		0											
09/08/19 8:00	0	X		0	X		0											
09/08/19 9:00	0	X		0	X		0											
09/08/19 10:00	0	X		0	X		0											
09/08/19 11:00	0	X		0	X		0											
09/08/19 12:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/08/19 13:00	0	X		0	X		0											
09/08/19 14:00	0	X		0	X		0											
09/08/19 15:00	0	X		0	X		0											
09/08/19 16:00	0	X		0	X		0											
09/08/19 17:00	0	X		0	X		0											
09/08/19 18:00	0	X		0	X		0											
09/08/19 19:00	0	X		0	X		0											
09/08/19 20:00	0	X		0	X		0											
09/08/19 21:00	0	X		0	X		0											
09/08/19 22:00	0	X		0	X		0											
09/08/19 23:00	0	X		0	X		0											
09/09/19 0:00	0	X		0	X		0											
09/09/19 1:00	0	X		0	X		0											
09/09/19 2:00	0	X		0	X		0											
09/09/19 3:00	0	X		0	X		0											
09/09/19 4:00	0	X		0	X		0											
09/09/19 5:00	0	X		0	X		0											
09/09/19 6:00	0	X		0	X		0											
09/09/19 7:00	0	X		0	X		0											
09/09/19 8:00	0	X		0	X		0											
09/09/19 9:00	0	X		0	X		0											
09/09/19 10:00	0	X		0	X		0											
09/09/19 11:00	0	X		0	X		0											
09/09/19 12:00	0	X		0	X		0											
09/09/19 13:00	0	X		0	X		0											
09/09/19 14:00	0	X		0	X		0											
09/09/19 15:00	0	X		0	X		0											
09/09/19 16:00	0	X		0	X		0											
09/09/19 17:00	0	X		0	X		0											
09/09/19 18:00	0	X		0	X		0											
09/09/19 19:00	0	X		0	X		0											
09/09/19 20:00	0	X		0	X		0											
09/09/19 21:00	0	X		0	X		0											
09/09/19 22:00	0	X		0.1104			0.03											
09/09/19 23:00	0	X		0.20964			0.21											
09/10/19 0:00	0	X		0.23322			0.23											
09/10/19 1:00	0	X		0.21048			0.21											
09/10/19 2:00	0	X		0.20796			0.21											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/10/19 3:00	0	X		0.21828			0.22											
09/10/19 4:00	0	X		0.23856			0.24											
09/10/19 5:00	0	X		0.23448			0.23											
09/10/19 6:00	0	X		0.2442			0.24											
09/10/19 7:00	0	X		0.27102			0.27											
09/10/19 8:00	0	X		0.24474			0.24											
09/10/19 9:00	0	X		0.21516			0.22											
09/10/19 10:00	0	X		0.26712			0.27											
09/10/19 11:00	0	X		0.2664			0.27											
09/10/19 12:00	0	X		0.35214			0.35											
09/10/19 13:00	0	X		0.26928			0.27											
09/10/19 14:00	0	X		0.37176			0.37											
09/10/19 15:00	0	X		0.2703			0.27											
09/10/19 16:00	0	X		0.38382			0.38											
09/10/19 17:00	0	X		0.39558			0.4											
09/10/19 18:00	0	X		0.39318			0.39											
09/10/19 19:00	0	X		0.3504			0.35											
09/10/19 20:00	0	X		0.23694			0.24											
09/10/19 21:00	0	X		0.2394			0.24											
09/10/19 22:00	0	X		0.23676			0.24											
09/10/19 23:00	0	X		0.21714			0.22											
09/11/19 0:00	0	X		0.20232			0.2											
09/11/19 1:00	0	X		0.2031			0.2											
09/11/19 2:00	0	X		0.20358			0.2											
09/11/19 3:00	0	X		0.2037			0.2											
09/11/19 4:00	0	X		0.20868			0.21											
09/11/19 5:00	0	X		0.20934			0.21											
09/11/19 6:00	0	X		0.20916			0.21											
09/11/19 7:00	0	X		0.2094			0.21											
09/11/19 8:00	0.08826			0.20856			0.23											
09/11/19 9:00	0.19014			0.2013			0.39											
09/11/19 10:00	0.23616			0.2574			0.49											
09/11/19 11:00	0.27228			0.28524			0.56											
09/11/19 12:00	0.34122			0.12558			0.36											
09/11/19 13:00	0.20934			0	X		0.21											
09/11/19 14:00	0.34986			0	X		0.35											
09/11/19 15:00	0.20334			0	X		0.2											
09/11/19 16:00	0.28638			0	X		0.29											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/11/19 17:00	0.285			0	X		0.29											
09/11/19 18:00	0.24018			0	X		0.24											
09/11/19 19:00	0.19866			0	X		0.2											
09/11/19 20:00	0.30696			0	X		0.31											
09/11/19 21:00	0.22398			0	X		0.22											
09/11/19 22:00	0.22326			0	X		0.22											
09/11/19 23:00	0.22314			0	X		0.22											
09/12/19 0:00	0.21102			0	X		0.21											
09/12/19 1:00	0.18774			0	X		0.19											
09/12/19 2:00	0.18768			0	X		0.19											
09/12/19 3:00	0.18744			0	X		0.19											
09/12/19 4:00	0.18714			0	X		0.19											
09/12/19 5:00	0.1887			0	X		0.19											
09/12/19 6:00	0.1896			0	X		0.19											
09/12/19 7:00	0.19752			0	X		0.2											
09/12/19 8:00	0.34302			0.10146			0.37											
09/12/19 9:00	0.20634			0.2109			0.42											
09/12/19 10:00	0.27042			0.29154			0.56											
09/12/19 11:00	0.21462			0.2586			0.47											
09/12/19 12:00	0.06612			0.35016			0.35											
09/12/19 13:00	0	X		0.2694			0.27											
09/12/19 14:00	0	X		0.35868			0.36											
09/12/19 15:00	0	X		0.23844			0.24											
09/12/19 16:00	0	X		0.36456			0.36											
09/12/19 17:00	0	X		0.3999			0.4											
09/12/19 18:00	0	X		0.40182			0.4											
09/12/19 19:00	0	X		0.40152			0.4											
09/12/19 20:00	0	X		0.39072			0.39											
09/12/19 21:00	0	X		0.24762			0.25											
09/12/19 22:00	0	X		0.243			0.24											
09/12/19 23:00	0	X		0.1131			0.01											
09/13/19 0:00	0	X		0	X		0											
09/13/19 1:00	0	X		0	X		0											
09/13/19 2:00	0	X		0	X		0											
09/13/19 3:00	0	X		0	X		0											
09/13/19 4:00	0	X		0	X		0											
09/13/19 5:00	0	X		0	X		0											
09/13/19 6:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/13/19 7:00	0	X		0	X		0											
09/13/19 8:00	0	X		0	X		0											
09/13/19 9:00	0	X		0	X		0											
09/13/19 10:00	0	X		0	X		0											
09/13/19 11:00	0	X		0	X		0											
09/13/19 12:00	0	X		0	X		0											
09/13/19 13:00	0	X		0	X		0											
09/13/19 14:00	0	X		0	X		0											
09/13/19 15:00	0	X		0	X		0											
09/13/19 16:00	0	X		0	X		0											
09/13/19 17:00	0	X		0	X		0											
09/13/19 18:00	0	X		0	X		0											
09/13/19 19:00	0	X		0	X		0											
09/13/19 20:00	0	X		0	X		0											
09/13/19 21:00	0	X		0	X		0											
09/13/19 22:00	0	X		0	X		0											
09/13/19 23:00	0	X		0	X		0											
09/14/19 0:00	0	X		0	X		0											
09/14/19 1:00	0	X		0	X		0											
09/14/19 2:00	0	X		0	X		0											
09/14/19 3:00	0	X		0	X		0											
09/14/19 4:00	0	X		0	X		0											
09/14/19 5:00	0	X		0	X		0											
09/14/19 6:00	0	X		0	X		0											
09/14/19 7:00	0	X		0	X		0											
09/14/19 8:00	0	X		0	X		0											
09/14/19 9:00	0	X		0	X		0											
09/14/19 10:00	0	X		0	X		0											
09/14/19 11:00	0	X		0	X		0											
09/14/19 12:00	0	X		0	X		0											
09/14/19 13:00	0	X		0	X		0											
09/14/19 14:00	0	X		0	X		0											
09/14/19 15:00	0	X		0	X		0											
09/14/19 16:00	0	X		0	X		0											
09/14/19 17:00	0	X		0	X		0											
09/14/19 18:00	0	X		0	X		0											
09/14/19 19:00	0	X		0	X		0											
09/14/19 20:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/14/19 21:00	0	X		0	X		0											
09/14/19 22:00	0	X		0	X		0											
09/14/19 23:00	0	X		0	X		0											
09/15/19 0:00	0	X		0	X		0											
09/15/19 1:00	0	X		0	X		0											
09/15/19 2:00	0	X		0	X		0											
09/15/19 3:00	0	X		0	X		0											
09/15/19 4:00	0	X		0	X		0											
09/15/19 5:00	0	X		0	X		0											
09/15/19 6:00	0	X		0	X		0											
09/15/19 7:00	0	X		0	X		0											
09/15/19 8:00	0	X		0	X		0											
09/15/19 9:00	0	X		0	X		0											
09/15/19 10:00	0	X		0	X		0											
09/15/19 11:00	0	X		0	X		0											
09/15/19 12:00	0	X		0	X		0											
09/15/19 13:00	0	X		0	X		0											
09/15/19 14:00	0	X		0	X		0											
09/15/19 15:00	0	X		0	X		0											
09/15/19 16:00	0	X		0	X		0											
09/15/19 17:00	0	X		0	X		0											
09/15/19 18:00	0	X		0	X		0											
09/15/19 19:00	0	X		0	X		0											
09/15/19 20:00	0	X		0	X		0											
09/15/19 21:00	0	X		0	X		0											
09/15/19 22:00	0	X		0	X		0											
09/15/19 23:00	0	X		0	X		0											
09/16/19 0:00	0	X		0	X		0											
09/16/19 1:00	0	X		0	X		0											
09/16/19 2:00	0	X		0	X		0											
09/16/19 3:00	0	X		0	X		0											
09/16/19 4:00	0	X		0	X		0											
09/16/19 5:00	0	X		0	X		0											
09/16/19 6:00	0	X		0	X		0											
09/16/19 7:00	0	X		0	X		0											
09/16/19 8:00	0	X		0	X		0											
09/16/19 9:00	0	X		0	X		0											
09/16/19 10:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H										
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/16/19 11:00	0	X		0	X		0											
09/16/19 12:00	0	X		0	X		0											
09/16/19 13:00	0	X		0	X		0											
09/16/19 14:00	0	X		0	X		0											
09/16/19 15:00	0	X		0	X		0											
09/16/19 16:00	0	X		0	X		0											
09/16/19 17:00	0	X		0	X		0											
09/16/19 18:00	0	X		0	X		0											
09/16/19 19:00	0	X		0	X		0											
09/16/19 20:00	0	X		0	X		0											
09/16/19 21:00	0	X		0	X		0											
09/16/19 22:00	0	X		0	X		0											
09/16/19 23:00	0	X		0	X		0											
09/17/19 0:00	0	X		0	X		0											
09/17/19 1:00	0	X		0	X		0											
09/17/19 2:00	0	X		0	X		0											
09/17/19 3:00	0	X		0	X		0											
09/17/19 4:00	0	X		0	X		0											
09/17/19 5:00	0	X		0	X		0											
09/17/19 6:00	0	X		0	X		0											
09/17/19 7:00	0	X		0	X		0											
09/17/19 8:00	0	X		0	X		0											
09/17/19 9:00	0	X		0	X		0											
09/17/19 10:00	0	X		0	X		0											
09/17/19 11:00	0	X		0	X		0											
09/17/19 12:00	0	X		0	X		0											
09/17/19 13:00	0	X		0	X		0											
09/17/19 14:00	0	X		0	X		0											
09/17/19 15:00	0	X		0	X		0											
09/17/19 16:00	0	X		0	X		0											
09/17/19 17:00	0	X		0	X		0											
09/17/19 18:00	0	X		0	X		0											
09/17/19 19:00	0	X		0	X		0											
09/17/19 20:00	0	X		0	X		0											
09/17/19 21:00	0	X		0	X		0											
09/17/19 22:00	0	X		0	X		0											
09/17/19 23:00	0	X		0	X		0											
09/18/19 0:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/18/19 1:00	0	X		0	X		0											
09/18/19 2:00	0	X		0	X		0											
09/18/19 3:00	0	X		0	X		0											
09/18/19 4:00	0	X		0	X		0											
09/18/19 5:00	0	X		0	X		0											
09/18/19 6:00	0	X		0	X		0											
09/18/19 7:00	0	X		0	X		0											
09/18/19 8:00	0	X		0	X		0											
09/18/19 9:00	0	X		0	X		0											
09/18/19 10:00	0	X		0	X		0											
09/18/19 11:00	0	X		0	X		0											
09/18/19 12:00	0	X		0	X		0											
09/18/19 13:00	0	X		0	X		0											
09/18/19 14:00	0	X		0	X		0											
09/18/19 15:00	0	X		0	X		0											
09/18/19 16:00	0	X		0	X		0											
09/18/19 17:00	0	X		0	X		0											
09/18/19 18:00	0	X		0	X		0											
09/18/19 19:00	0	X		0	X		0											
09/18/19 20:00	0	X		0	X		0											
09/18/19 21:00	0	X		0	X		0											
09/18/19 22:00	0	X		0	X		0											
09/18/19 23:00	0	X		0	X		0											
09/19/19 0:00	0	X		0	X		0											
09/19/19 1:00	0	X		0	X		0											
09/19/19 2:00	0	X		0	X		0											
09/19/19 3:00	0	X		0	X		0											
09/19/19 4:00	0	X		0	X		0											
09/19/19 5:00	0	X		0	X		0											
09/19/19 6:00	0	X		0	X		0											
09/19/19 7:00	0	X		0	X		0											
09/19/19 8:00	0	X		0	X		0											
09/19/19 9:00	0	X		0	X		0											
09/19/19 10:00	0	X		0	X		0											
09/19/19 11:00	0	X		0	X		0											
09/19/19 12:00	0	X		0	X		0											
09/19/19 13:00	0	X		0	X		0											
09/19/19 14:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H										
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/19/19 15:00	0	X		0	X		0											
09/19/19 16:00	0	X		0	X		0											
09/19/19 17:00	0	X		0	X		0											
09/19/19 18:00	0	X		0	X		0											
09/19/19 19:00	0	X		0	X		0											
09/19/19 20:00	0	X		0	X		0											
09/19/19 21:00	0	X		0	X		0											
09/19/19 22:00	0	X		0	X		0											
09/19/19 23:00	0	X		0	X		0											
09/20/19 0:00	0	X		0	X		0											
09/20/19 1:00	0	X		0	X		0											
09/20/19 2:00	0	X		0	X		0											
09/20/19 3:00	0	X		0	X		0											
09/20/19 4:00	0	X		0	X		0											
09/20/19 5:00	0	X		0	X		0											
09/20/19 6:00	0	X		0	X		0											
09/20/19 7:00	0	X		0	X		0											
09/20/19 8:00	0	X		0	X		0											
09/20/19 9:00	0	X		0	X		0											
09/20/19 10:00	0	X		0	X		0											
09/20/19 11:00	0	X		0	X		0											
09/20/19 12:00	0	X		0	X		0											
09/20/19 13:00	0	X		0	X		0											
09/20/19 14:00	0	X		0	X		0											
09/20/19 15:00	0	X		0	X		0											
09/20/19 16:00	0	X		0	X		0											
09/20/19 17:00	0	X		0	X		0											
09/20/19 18:00	0	X		0	X		0											
09/20/19 19:00	0	X		0	X		0											
09/20/19 20:00	0	X		0	X		0											
09/20/19 21:00	0	X		0	X		0											
09/20/19 22:00	0	X		0	X		0											
09/20/19 23:00	0	X		0	X		0											
09/21/19 0:00	0	X		0	X		0											
09/21/19 1:00	0	X		0	X		0											
09/21/19 2:00	0	X		0	X		0											
09/21/19 3:00	0	X		0	X		0											
09/21/19 4:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/21/19 5:00	0	X		0	X		0											
09/21/19 6:00	0	X		0	X		0											
09/21/19 7:00	0	X		0	X		0											
09/21/19 8:00	0	X		0	X		0											
09/21/19 9:00	0	X		0	X		0											
09/21/19 10:00	0	X		0	X		0											
09/21/19 11:00	0	X		0	X		0											
09/21/19 12:00	0	X		0	X		0											
09/21/19 13:00	0	X		0	X		0											
09/21/19 14:00	0	X		0	X		0											
09/21/19 15:00	0	X		0	X		0											
09/21/19 16:00	0	X		0	X		0											
09/21/19 17:00	0	X		0	X		0											
09/21/19 18:00	0	X		0	X		0											
09/21/19 19:00	0	X		0	X		0											
09/21/19 20:00	0	X		0	X		0											
09/21/19 21:00	0	X		0	X		0											
09/21/19 22:00	0	X		0	X		0											
09/21/19 23:00	0	X		0	X		0											
09/22/19 0:00	0	X		0	X		0											
09/22/19 1:00	0	X		0	X		0											
09/22/19 2:00	0	X		0	X		0											
09/22/19 3:00	0	X		0	X		0											
09/22/19 4:00	0	X		0	X		0											
09/22/19 5:00	0	X		0	X		0											
09/22/19 6:00	0	X		0	X		0											
09/22/19 7:00	0	X		0	X		0											
09/22/19 8:00	0	X		0	X		0											
09/22/19 9:00	0	X		0	X		0											
09/22/19 10:00	0	X		0	X		0											
09/22/19 11:00	0	X		0	X		0											
09/22/19 12:00	0	X		0	X		0											
09/22/19 13:00	0	X		0	X		0											
09/22/19 14:00	0	X		0	X		0											
09/22/19 15:00	0	X		0	X		0											
09/22/19 16:00	0	X		0	X		0											
09/22/19 17:00	0	X		0	X		0											
09/22/19 18:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/22/19 19:00	0	X		0	X		0											
09/22/19 20:00	0	X		0	X		0											
09/22/19 21:00	0	X		0	X		0											
09/22/19 22:00	0	X		0	X		0											
09/22/19 23:00	0	X		0	X		0											
09/23/19 0:00	0	X		0	X		0											
09/23/19 1:00	0	X		0	X		0											
09/23/19 2:00	0	X		0	X		0											
09/23/19 3:00	0	X		0	X		0											
09/23/19 4:00	0	X		0	X		0											
09/23/19 5:00	0	X		0	X		0											
09/23/19 6:00	0	X		0	X		0											
09/23/19 7:00	0	X		0.09906			0.03											
09/23/19 8:00	0	X		0.27834			0.28											
09/23/19 9:00	0	X		0.28254			0.28											
09/23/19 10:00	0	X		0.28506			0.29											
09/23/19 11:00	0	X		0.35706			0.36											
09/23/19 12:00	0	X		0.35976			0.36											
09/23/19 13:00	0	X		0.3597			0.36											
09/23/19 14:00	0	X		0.35736			0.36											
09/23/19 15:00	0	X		0.34068			0.34											
09/23/19 16:00	0	X		0.35784			0.36											
09/23/19 17:00	0	X		0.35712			0.36											
09/23/19 18:00	0	X		0.31476			0.31											
09/23/19 19:00	0	X		0.35982			0.36											
09/23/19 20:00	0	X		0.35376			0.35											
09/23/19 21:00	0	X		0.27378			0.27											
09/23/19 22:00	0	X		0.21			0.21											
09/23/19 23:00	0	X		0.30906			0.31											
09/24/19 0:00	0	X		0.32706			0.33											
09/24/19 1:00	0	X		0.33882			0.34											
09/24/19 2:00	0	X		0.3288			0.33											
09/24/19 3:00	0	X		0.33822			0.34											
09/24/19 4:00	0	X		0.3672			0.37											
09/24/19 5:00	0	X		0.26364			0.26											
09/24/19 6:00	0	X		0.2619			0.26											
09/24/19 7:00	0.00474			0.31926			0.32											
09/24/19 8:00	0.18516			0.25122			0.44											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/24/19 9:00	0.22062			0.23862			0.46											
09/24/19 10:00	0.23736			0.26256			0.5											
09/24/19 11:00	0.23244			0.26328			0.5											
09/24/19 12:00	0.2625			0.27426			0.54											
09/24/19 13:00	0.2898			0.29742			0.59											
09/24/19 14:00	0.27366			0.2952			0.57											
09/24/19 15:00	0.28698			0.30804			0.6											
09/24/19 16:00	0.37974			0.40062			0.78											
09/24/19 17:00	0.3792			0.39972			0.78											
09/24/19 18:00	0.34638			0.36702			0.71											
09/24/19 19:00	0.28398			0.30576			0.59											
09/24/19 20:00	0.23424			0.2556			0.49											
09/24/19 21:00	0.26664			0.28818			0.55											
09/24/19 22:00	0.23052			0.2523			0.48											
09/24/19 23:00	0.183			0.20184			0.38											
09/25/19 0:00	0.17844			0.19686			0.38											
09/25/19 1:00	0.17826			0.19794			0.38											
09/25/19 2:00	0.1779			0.19824			0.38											
09/25/19 3:00	0.17808			0.19806			0.38											
09/25/19 4:00	0.17838			0.198			0.38											
09/25/19 5:00	0.17814			0.19698			0.38											
09/25/19 6:00	0.17886			0.19404			0.37											
09/25/19 7:00	0.18084			0.19686			0.38											
09/25/19 8:00	0.1788			0.19398			0.37											
09/25/19 9:00	0.1824			0.19764			0.38											
09/25/19 10:00	0.20754			0.22656			0.43											
09/25/19 11:00	0.24522			0.26616			0.51											
09/25/19 12:00	0.35478			0.37488			0.73											
09/25/19 13:00	0.3735			0.3939			0.77											
09/25/19 14:00	0.354			0.37434			0.73											
09/25/19 15:00	0.35238			0.37248			0.72											
09/25/19 16:00	0.36528			0.38526			0.75											
09/25/19 17:00	0.3639			0.38484			0.75											
09/25/19 18:00	0.2544			0.30234			0.56											
09/25/19 19:00	0.33168			0.35448			0.69											
09/25/19 20:00	0.32682			0.3504			0.68											
09/25/19 21:00	0.22134			0.2523			0.47											
09/25/19 22:00	0.19068			0.22272			0.41											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/25/19 23:00	0.17772			0.1974			0.38											
09/26/19 0:00	0.1779			0.19734			0.38											
09/26/19 1:00	0.17838			0.19722			0.38											
09/26/19 2:00	0.17808			0.19806			0.38											
09/26/19 3:00	0.17844			0.19812			0.38											
09/26/19 4:00	0.17874			0.19794			0.38											
09/26/19 5:00	0.17922			0.1983			0.38											
09/26/19 6:00	0.17904			0.19422			0.37											
09/26/19 7:00	0.18114			0.19626			0.38											
09/26/19 8:00	0.18684			0.20424			0.39											
09/26/19 9:00	0.22044			0.2439			0.46											
09/26/19 10:00	0.27696			0.2982			0.58											
09/26/19 11:00	0.29838			0.31926			0.62											
09/26/19 12:00	0.30948			0.33114			0.64											
09/26/19 13:00	0.30996			0.3315			0.64											
09/26/19 14:00	0.36132			0.38178			0.74											
09/26/19 15:00	0.34878			0.36984			0.72											
09/26/19 16:00	0.3681			0.38886			0.76											
09/26/19 17:00	0.3267			0.34824			0.67											
09/26/19 18:00	0.29838			0.32082			0.62											
09/26/19 19:00	0.25734			0.28014			0.54											
09/26/19 20:00	0.2127			0.23124			0.44											
09/26/19 21:00	0.1917			0.2112			0.4											
09/26/19 22:00	0.17388			0.2016			0.38											
09/26/19 23:00	0.06666			0.2127			0.21											
09/27/19 0:00	0	X		0.20424			0.2											
09/27/19 1:00	0	X		0.20472			0.2											
09/27/19 2:00	0	X		0.20334			0.2											
09/27/19 3:00	0	X		0.20328			0.2											
09/27/19 4:00	0	X		0.20568			0.21											
09/27/19 5:00	0	X		0.22128			0.22											
09/27/19 6:00	0	X		0.22272			0.22											
09/27/19 7:00	0	X		0.24366			0.24											
09/27/19 8:00	0	X		0.26676			0.27											
09/27/19 9:00	0	X		0.39666			0.4											
09/27/19 10:00	0	X		0.40242			0.4											
09/27/19 11:00	0	X		0.40146			0.4											
09/27/19 12:00	0	X		0.40074			0.4											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/27/19 13:00	0	X		0.40086			0.4											
09/27/19 14:00	0	X		0.4011			0.4											
09/27/19 15:00	0	X		0.4011			0.4											
09/27/19 16:00	0	X		0.40116			0.4											
09/27/19 17:00	0	X		0.40122			0.4											
09/27/19 18:00	0	X		0.4023			0.4											
09/27/19 19:00	0	X		0.40146			0.4											
09/27/19 20:00	0	X		0.39336			0.39											
09/27/19 21:00	0	X		0.23688			0.24											
09/27/19 22:00	0	X		0.20382			0.2											
09/27/19 23:00	0	X		0.10104			0.01											
09/28/19 0:00	0	X		0	X		0											
09/28/19 1:00	0	X		0	X		0											
09/28/19 2:00	0	X		0	X		0											
09/28/19 3:00	0	X		0	X		0											
09/28/19 4:00	0	X		0	X		0											
09/28/19 5:00	0	X		0	X		0											
09/28/19 6:00	0	X		0	X		0											
09/28/19 7:00	0	X		0	X		0											
09/28/19 8:00	0	X		0	X		0											
09/28/19 9:00	0	X		0	X		0											
09/28/19 10:00	0	X		0	X		0											
09/28/19 11:00	0	X		0	X		0											
09/28/19 12:00	0	X		0	X		0											
09/28/19 13:00	0	X		0	X		0											
09/28/19 14:00	0	X		0	X		0											
09/28/19 15:00	0	X		0	X		0											
09/28/19 16:00	0	X		0	X		0											
09/28/19 17:00	0	X		0	X		0											
09/28/19 18:00	0	X		0	X		0											
09/28/19 19:00	0	X		0	X		0											
09/28/19 20:00	0	X		0	X		0											
09/28/19 21:00	0	X		0	X		0											
09/28/19 22:00	0	X		0	X		0											
09/28/19 23:00	0	X		0	X		0											
09/29/19 0:00	0	X		0	X		0											
09/29/19 1:00	0	X		0	X		0											
09/29/19 2:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/29/19 3:00	0	X		0	X		0											
09/29/19 4:00	0	X		0	X		0											
09/29/19 5:00	0	X		0	X		0											
09/29/19 6:00	0	X		0	X		0											
09/29/19 7:00	0	X		0	X		0											
09/29/19 8:00	0	X		0	X		0											
09/29/19 9:00	0	X		0	X		0											
09/29/19 10:00	0	X		0	X		0											
09/29/19 11:00	0	X		0	X		0											
09/29/19 12:00	0	X		0	X		0											
09/29/19 13:00	0	X		0	X		0											
09/29/19 14:00	0	X		0	X		0											
09/29/19 15:00	0	X		0	X		0											
09/29/19 16:00	0	X		0	X		0											
09/29/19 17:00	0	X		0	X		0											
09/29/19 18:00	0	X		0	X		0											
09/29/19 19:00	0	X		0	X		0											
09/29/19 20:00	0	X		0	X		0											
09/29/19 21:00	0	X		0	X		0											
09/29/19 22:00	0	X		0	X		0											
09/29/19 23:00	0	X		0	X		0											
09/30/19 0:00	0	X		0	X		0											
09/30/19 1:00	0	X		0	X		0											
09/30/19 2:00	0	X		0	X		0											
09/30/19 3:00	0	X		0	X		0											
09/30/19 4:00	0	X		0	X		0											
09/30/19 5:00	0	X		0	X		0											
09/30/19 6:00	0.09054			0	X		0.02											
09/30/19 7:00	0.258			0	X		0.26											
09/30/19 8:00	0.26004			0	X		0.26											
09/30/19 9:00	0.26826			0	X		0.27											
09/30/19 10:00	0.26646			0.09498			0.29											
09/30/19 11:00	0.21108			0.23364			0.44											
09/30/19 12:00	0.06834			0.28242			0.29											
09/30/19 13:00	0	X		0.28542			0.29											
09/30/19 14:00	0	X		0.37464			0.37											
09/30/19 15:00	0	X		0.38328			0.38											
09/30/19 16:00	0	X		0.35814			0.36											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/30/19 17:00	0	X		0.1686			0.04											
09/30/19 18:00	0	X		0	X		0											
09/30/19 19:00	0	X		0	X		0											
09/30/19 20:00	0	X		0	X		0											
09/30/19 21:00	0	X		0	X		0											
09/30/19 22:00	0	X		0	X		0											
09/30/19 23:00	0	X		0	X		0											

ATTACHMENT 6

AQ-34

AQ-34 the Project owner shall maintain the following records: occurrence, duration, and type of any startup, shutdown, or malfunction: performance testing, evaluations, calibrations, check, adjustments, any period during which a continuous monitoring system or monitoring device was inoperative, maintenance of any continuous emission monitor; emission measurements, total daily and rolling twelve month averages hours of operation, hourly quantity of fuel used and gross three hour average operating load.

Verification; The Project owner shall submit to the CPM all data identified in this condition as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

Daily Calibration Results

CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:13 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/22/19 16:29	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/22/19 16:39	200.0	177.8	178.1		|R-A|/Span * 100	0.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/22/19 16:29	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/22/19 16:35	10.0	8.9	8.9		|R-A|/Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/22/19 16:29	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/22/19 16:39	200.0	178.7	179.3		|R-A|/Span * 100	0.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/22/19 16:29	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/22/19 16:35	10.0	9.2	9.2		|R-A|/Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	07/22/19 16:29	21.0	18.0	18.0		|R-A|	0.0
	Zero	07/22/19 16:35	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/23/19 04:14	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	07/23/19 04:25	200.0	178.7	171.5	>1x Alert	|R-A|/Span * 100	3.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/23/19 04:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	07/23/19 04:19	10.0	9.2	8.7	>1x Alert	|R-A|/Span * 100	5.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/23/19 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/23/19 05:25	200.0	177.8	178.1		|R-A|/Span * 100	0.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/23/19 05:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	07/23/19 05:19	10.0	8.9	8.9		|R-A|/Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/23/19 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/23/19 05:25	200.0	178.7	178.9		|R-A|/Span * 100	0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/23/19 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/23/19 05:19	10.0	9.2	9.2		|R-A|/Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	07/23/19 05:14	21.0	18.0	18.0		|R-A|	0.0
	Zero	07/23/19 05:19	21.0	0.0	0.0		|R-A|	0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:13 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/23/19 07:10	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	07/23/19 07:20	200.0	176.9	176.9		|R-A|/Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/23/19 07:10	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	07/23/19 07:15	10.0	9.1	9.2		|R-A|/Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/23/19 07:10	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/23/19 07:20	200.0	178.0	177.8		|R-A|/Span * 100	0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/23/19 07:10	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/23/19 07:15	10.0	8.8	8.7		|R-A|/Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	07/23/19 07:10	21.0	18.0	18.0		|R-A|	0.0
	Zero	07/23/19 07:15	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/23/19 08:43	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	07/23/19 08:54	200.0	178.0	179.0		|R-A|/Span * 100	0.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/23/19 08:43	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/23/19 08:48	10.0	8.8	9.0		|R-A|/Span * 100	2.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/23/19 09:42	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/23/19 09:52	200.0	178.7	179.3		|R-A|/Span * 100	0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/23/19 09:42	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/23/19 09:47	10.0	9.2	9.2		|R-A|/Span * 100	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/24/19 04:14	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	07/24/19 04:25	200.0	178.0	178.3		|R-A|/Span * 100	0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/24/19 04:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	07/24/19 04:19	10.0	8.8	8.7		|R-A|/Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/24/19 05:15	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	07/24/19 05:25	200.0	176.9	176.8		|R-A|/Span * 100	0.1

Daily Calibration Results

CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:13 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/24/19 05:15	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	07/24/19 05:20	10.0	9.1	9.2		|R-A|/Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/24/19 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/24/19 05:25	200.0	178.0	178.5		|R-A|/Span * 100	0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/24/19 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/24/19 05:20	10.0	8.8	8.8		|R-A|/Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	07/24/19 05:15	21.0	18.0	18.0		|R-A|	0.0
	Zero	07/24/19 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/25/19 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/25/19 04:25	200.0	178.0	177.0		|R-A|/Span * 100	0.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/25/19 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/25/19 04:19	10.0	8.8	8.4	>1x Alert	|R-A|/Span * 100	4.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/25/19 05:14	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	07/25/19 05:24	200.0	176.9	176.8		|R-A|/Span * 100	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/25/19 05:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	07/25/19 05:19	10.0	9.1	9.2		|R-A|/Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/25/19 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/25/19 05:24	200.0	178.0	177.3		|R-A|/Span * 100	0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/25/19 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/25/19 05:19	10.0	8.8	8.7		|R-A|/Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	07/25/19 05:14	21.0	18.0	18.0		|R-A|	0.0
	Zero	07/25/19 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/26/19 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/26/19 04:25	200.0	178.0	176.0		|R-A|/Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:13 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/26/19 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/26/19 04:20	10.0	8.8	8.4	>1x Alert	|R-A|/Span * 100	4.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/26/19 05:15	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	07/26/19 05:25	200.0	176.9	176.8		|R-A|/Span * 100	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/26/19 05:15	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	07/26/19 05:20	10.0	9.1	9.2		|R-A|/Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/26/19 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/26/19 05:25	200.0	178.0	177.1		|R-A|/Span * 100	0.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/26/19 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/26/19 05:20	10.0	8.8	8.7		|R-A|/Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	07/26/19 05:15	21.0	18.0	18.0		|R-A|	0.0
	Zero	07/26/19 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/26/19 08:53	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	07/26/19 09:03	200.0	178.0	178.7		|R-A|/Span * 100	0.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/26/19 08:53	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/26/19 08:59	10.0	8.8	9.1	>1x Alert	|R-A|/Span * 100	3.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/27/19 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/27/19 04:25	200.0	180.7	178.7		|R-A|/Span * 100	1.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/27/19 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/27/19 04:20	10.0	8.8	8.7		|R-A|/Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/27/19 05:15	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	07/27/19 05:24	200.0	180.3	179.2		|R-A|/Span * 100	0.6
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/27/19 05:15	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	07/27/19 05:20	10.0	9.1	9.1		|R-A|/Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:13 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/27/19 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/27/19 05:24	200.0	180.7	178.7		|R-A|/Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/27/19 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/27/19 05:20	10.0	8.8	8.7		|R-A|/Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	07/27/19 05:15	21.0	18.0	18.0		|R-A|	0.0
	Zero	07/27/19 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/28/19 02:19	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	07/28/19 02:30	200.0	177.4	178.8		|R-A|/Span * 100	0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/28/19 02:19	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	07/28/19 02:25	10.0	8.9	9.0		|R-A|/Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/28/19 02:19	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/28/19 02:30	200.0	177.2	177.4		|R-A|/Span * 100	0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/28/19 02:19	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/28/19 02:25	10.0	9.2	9.2		|R-A|/Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	07/28/19 02:19	21.0	18.0	18.0		|R-A|	0.0
	Zero	07/28/19 02:25	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/28/19 04:14	200.0	0.0	-0.1		|R-A|/Span * 100	0.1
	High	07/28/19 04:25	200.0	180.7	179.6		|R-A|/Span * 100	0.6
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/28/19 04:14	10.0	0.0	-0.1		|R-A|/Span * 100	1.0
	High	07/28/19 04:20	10.0	8.8	8.7		|R-A|/Span * 100	1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/28/19 04:14	200.0	0.0	-0.1		|R-A|/Span * 100	0.1
	High	07/28/19 04:25	200.0	177.2	176.8		|R-A|/Span * 100	0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/28/19 04:14	10.0	0.0	-0.1		|R-A|/Span * 100	1.0
	High	07/28/19 04:20	10.0	9.2	9.0		|R-A|/Span * 100	2.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:13 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/28/19 05:14	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	07/28/19 05:24	200.0	180.3	179.6		|R-A|/Span * 100	0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/28/19 05:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	07/28/19 05:19	10.0	9.1	9.2		|R-A|/Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/28/19 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/28/19 05:24	200.0	180.7	178.5		|R-A|/Span * 100	1.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/28/19 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/28/19 05:19	10.0	8.8	8.7		|R-A|/Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	07/28/19 05:14	21.0	18.0	18.0		|R-A|	0.0
	Zero	07/28/19 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/29/19 02:33	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	07/29/19 02:44	200.0	177.4	179.0		|R-A|/Span * 100	0.8
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/29/19 02:33	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	07/29/19 02:38	10.0	8.9	9.0		|R-A|/Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/29/19 02:33	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/29/19 02:44	200.0	177.2	176.7		|R-A|/Span * 100	0.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/29/19 02:33	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/29/19 02:38	10.0	9.2	9.2		|R-A|/Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	07/29/19 02:33	21.0	18.0	18.0		|R-A|	0.0
	Zero	07/29/19 02:38	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/29/19 04:15	200.0	0.0	-0.1		|R-A|/Span * 100	0.1
	High	07/29/19 04:25	200.0	180.7	181.5		|R-A|/Span * 100	0.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/29/19 04:15	10.0	0.0	-0.1		|R-A|/Span * 100	1.0
	High	07/29/19 04:20	10.0	8.8	8.7		|R-A|/Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:13 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/29/19 04:14	200.0	0.0	-0.1		|R-A|/Span * 100	0.1
	High	07/29/19 04:25	200.0	177.2	174.2		|R-A|/Span * 100	1.5
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/29/19 04:14	10.0	0.0	-0.1		|R-A|/Span * 100	1.0
	High	07/29/19 04:20	10.0	9.2	8.8	>1x Alert	|R-A|/Span * 100	4.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/29/19 05:14	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	07/29/19 05:25	200.0	180.3	179.9		|R-A|/Span * 100	0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/29/19 05:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	07/29/19 05:20	10.0	9.1	9.2		|R-A|/Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/29/19 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/29/19 05:25	200.0	180.7	178.8		|R-A|/Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/29/19 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/29/19 05:20	10.0	8.8	8.7		|R-A|/Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	07/29/19 05:14	21.0	18.0	18.0		|R-A|	0.0
	Zero	07/29/19 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/30/19 02:47	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	07/30/19 02:57	200.0	177.4	178.8		|R-A|/Span * 100	0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/30/19 02:47	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	07/30/19 02:53	10.0	8.9	8.9		|R-A|/Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/30/19 02:47	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/30/19 02:57	200.0	177.2	176.6		|R-A|/Span * 100	0.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/30/19 02:47	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/30/19 02:53	10.0	9.2	9.1		|R-A|/Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	07/30/19 02:47	21.0	18.0	18.0		|R-A|	0.0
	Zero	07/30/19 02:53	21.0	0.0	0.0		|R-A|	0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:13 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/30/19 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/30/19 04:24	200.0	180.7	182.6		|R-A|/Span * 100	1.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/30/19 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/30/19 04:19	10.0	8.8	8.8		|R-A|/Span * 100	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/30/19 04:14	200.0	0.0	-0.1		|R-A|/Span * 100	0.1
	High	07/30/19 04:25	200.0	177.2	174.1		|R-A|/Span * 100	1.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/30/19 04:14	10.0	0.0	-0.1		|R-A|/Span * 100	1.0
	High	07/30/19 04:19	10.0	9.2	8.8	>1x Alert	|R-A|/Span * 100	4.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/30/19 05:14	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	07/30/19 05:24	200.0	180.3	179.7		|R-A|/Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/30/19 05:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	07/30/19 05:19	10.0	9.1	9.2		|R-A|/Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/30/19 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/30/19 05:24	200.0	180.7	179.1		|R-A|/Span * 100	0.8
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/30/19 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/30/19 05:19	10.0	8.8	8.7		|R-A|/Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	07/30/19 05:14	21.0	18.0	18.0		|R-A|	0.0
	Zero	07/30/19 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/31/19 03:01	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	07/31/19 03:12	200.0	177.4	178.2		|R-A|/Span * 100	0.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/31/19 03:01	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	07/31/19 03:06	10.0	8.9	9.0		|R-A|/Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/31/19 03:01	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/31/19 03:12	200.0	177.2	176.3		|R-A|/Span * 100	0.5

Daily Calibration Results

CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:13 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/31/19 03:01	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/31/19 03:06	10.0	9.2	9.1		|R-A|/Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	07/31/19 03:01	21.0	18.0	18.0		|R-A|	0.0
	Zero	07/31/19 03:06	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/31/19 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/31/19 04:24	200.0	180.7	182.9		|R-A|/Span * 100	1.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/31/19 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/31/19 04:19	10.0	8.8	8.9		|R-A|/Span * 100	1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/31/19 04:14	200.0	0.0	-0.1		|R-A|/Span * 100	0.1
	High	07/31/19 04:24	200.0	177.2	174.1		|R-A|/Span * 100	1.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/31/19 04:14	10.0	0.0	-0.1		|R-A|/Span * 100	1.0
	High	07/31/19 04:19	10.0	9.2	8.8	>1x Alert	|R-A|/Span * 100	4.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/31/19 05:14	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	07/31/19 05:25	200.0	180.3	179.4		|R-A|/Span * 100	0.5
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/31/19 05:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	07/31/19 05:20	10.0	9.1	9.2		|R-A|/Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/31/19 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/31/19 05:25	200.0	180.7	178.9		|R-A|/Span * 100	0.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/31/19 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/31/19 05:20	10.0	8.8	8.7		|R-A|/Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	07/31/19 05:14	21.0	18.0	18.0		|R-A|	0.0
	Zero	07/31/19 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/31/19 11:44	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	07/31/19 11:54	200.0	177.4	178.8		|R-A|/Span * 100	0.7

Daily Calibration Results

CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:13 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/31/19 11:44	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	07/31/19 11:49	10.0	8.9	8.9		|R-A|/Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/31/19 11:44	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/31/19 11:54	200.0	177.2	176.9		|R-A|/Span * 100	0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/31/19 11:44	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/31/19 11:49	10.0	9.2	9.2		|R-A|/Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	07/31/19 11:44	21.0	18.0	18.0		|R-A|	0.0
	Zero	07/31/19 11:49	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/01/19 04:14	200.0	0.0	-0.1		|R-A|/Span * 100	0.1
	High	08/01/19 04:24	200.0	180.7	183.9		|R-A|/Span * 100	1.6
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/01/19 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/01/19 04:19	10.0	8.9	8.9		|R-A|/Span * 100	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/01/19 04:14	200.0	0.0	-0.1		|R-A|/Span * 100	0.1
	High	08/01/19 04:25	200.0	177.2	174.3		|R-A|/Span * 100	1.5
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/01/19 04:14	10.0	0.0	-0.1		|R-A|/Span * 100	1.0
	High	08/01/19 04:19	10.0	9.2	8.8	>1x Alert	|R-A|/Span * 100	4.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/01/19 05:15	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	08/01/19 05:25	200.0	180.3	179.4		|R-A|/Span * 100	0.5
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/01/19 05:15	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	08/01/19 05:20	10.0	8.9	8.9		|R-A|/Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/01/19 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/01/19 05:25	200.0	180.7	178.8		|R-A|/Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/01/19 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/01/19 05:20	10.0	8.9	8.6	>1x Alert	|R-A|/Span * 100	3.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:13 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	08/01/19 05:15	21.0	18.0	18.0		|R-A|	0.0
	Zero	08/01/19 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/01/19 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/01/19 05:25	200.0	177.4	178.2		|R-A|/Span * 100	0.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/01/19 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/01/19 05:19	10.0	8.9	8.9		|R-A|/Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/01/19 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/01/19 05:25	200.0	177.2	176.3		|R-A|/Span * 100	0.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/01/19 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/01/19 05:19	10.0	9.2	9.1		|R-A|/Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	08/01/19 05:15	21.0	18.0	18.0		|R-A|	0.0
	Zero	08/01/19 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/01/19 09:25	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	08/01/19 09:35	200.0	180.3	179.2		|R-A|/Span * 100	0.6
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/01/19 09:25	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	08/01/19 09:30	10.0	8.9	8.9		|R-A|/Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/01/19 09:25	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	08/01/19 09:35	200.0	180.7	180.8		|R-A|/Span * 100	0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/01/19 09:25	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	08/01/19 09:30	10.0	8.9	9.0		|R-A|/Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	08/01/19 09:25	21.0	18.0	18.0		|R-A|	0.0
	Zero	08/01/19 09:30	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/01/19 10:32	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	08/01/19 10:43	200.0	177.2	179.2		|R-A|/Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:13 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/01/19 10:32	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	08/01/19 10:38	10.0	9.2	9.5	>1x Alert	|R-A|/Span * 100	3.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/02/19 04:14	200.0	0.0	-0.1		|R-A|/Span * 100	0.1
	High	08/02/19 04:25	200.0	180.7	183.2		|R-A|/Span * 100	1.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/02/19 04:14	10.0	0.0	-0.1		|R-A|/Span * 100	1.0
	High	08/02/19 04:19	10.0	8.9	8.9		|R-A|/Span * 100	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/02/19 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/02/19 04:24	200.0	177.2	177.6		|R-A|/Span * 100	0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/02/19 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/02/19 04:19	10.0	9.2	9.2		|R-A|/Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/02/19 05:14	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	08/02/19 05:25	200.0	180.3	179.6		|R-A|/Span * 100	0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/02/19 05:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	08/02/19 05:19	10.0	8.9	8.9		|R-A|/Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/02/19 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/02/19 05:25	200.0	180.7	180.3		|R-A|/Span * 100	0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/02/19 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/02/19 05:19	10.0	8.9	8.9		|R-A|/Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	08/02/19 05:14	21.0	18.0	18.0		|R-A|	0.0
	Zero	08/02/19 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/02/19 05:15	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	08/02/19 05:25	200.0	177.4	177.6		|R-A|/Span * 100	0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/02/19 05:15	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	08/02/19 05:20	10.0	8.9	8.9		|R-A|/Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:13 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/02/19 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/02/19 05:25	200.0	177.2	175.9		|R-A|/Span * 100	0.7
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/02/19 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/02/19 05:20	10.0	9.2	9.1		|R-A|/Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	08/02/19 05:15	21.0	18.0	18.0		|R-A|	0.0
	Zero	08/02/19 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/03/19 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/03/19 04:24	200.0	177.2	177.9		|R-A|/Span * 100	0.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/03/19 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/03/19 04:19	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/03/19 04:15	200.0	0.0	-0.1		|R-A|/Span * 100	0.1
	High	08/03/19 04:25	200.0	180.7	184.6		|R-A|/Span * 100	2.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/03/19 04:15	10.0	0.0	-0.1		|R-A|/Span * 100	1.0
	High	08/03/19 04:20	10.0	8.9	9.0		|R-A|/Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/03/19 05:14	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	08/03/19 05:24	200.0	180.3	180.0		|R-A|/Span * 100	0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/03/19 05:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	08/03/19 05:19	10.0	8.9	8.9		|R-A|/Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/03/19 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/03/19 05:24	200.0	180.7	180.3		|R-A|/Span * 100	0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/03/19 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/03/19 05:19	10.0	8.9	8.9		|R-A|/Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	08/03/19 05:14	21.0	18.0	18.0		|R-A|	0.0
	Zero	08/03/19 05:19	21.0	0.0	0.0		|R-A|	0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:13 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/03/19 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/03/19 05:25	200.0	177.4	178.6		|R-A|/Span * 100	0.6
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/03/19 05:15	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	08/03/19 05:20	10.0	8.9	9.0		|R-A|/Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/03/19 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/03/19 05:25	200.0	177.2	176.1		|R-A|/Span * 100	0.6
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/03/19 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/03/19 05:20	10.0	9.2	9.1		|R-A|/Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	08/03/19 05:15	21.0	18.0	18.0		|R-A|	0.0
	Zero	08/03/19 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/04/19 04:14	200.0	0.0	-0.1		|R-A|/Span * 100	0.1
	High	08/04/19 04:25	200.0	180.7	185.8	>1x Alert	|R-A|/Span * 100	2.6
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/04/19 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/04/19 04:20	10.0	8.9	9.1		|R-A|/Span * 100	2.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/04/19 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/04/19 04:25	200.0	177.2	177.6		|R-A|/Span * 100	0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/04/19 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/04/19 04:20	10.0	9.2	9.2		|R-A|/Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/04/19 05:14	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	08/04/19 05:25	200.0	180.3	179.9		|R-A|/Span * 100	0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/04/19 05:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	08/04/19 05:20	10.0	8.9	8.9		|R-A|/Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/04/19 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/04/19 05:25	200.0	180.7	180.2		|R-A|/Span * 100	0.3

Daily Calibration Results

CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:13 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/04/19 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/04/19 05:20	10.0	8.9	8.9		|R-A|/Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	08/04/19 05:14	21.0	18.0	18.0		|R-A|	0.0
	Zero	08/04/19 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/04/19 05:14	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	08/04/19 05:24	200.0	177.4	178.8		|R-A|/Span * 100	0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/04/19 05:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	08/04/19 05:19	10.0	8.9	9.0		|R-A|/Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/04/19 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/04/19 05:24	200.0	177.2	175.8		|R-A|/Span * 100	0.7
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/04/19 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/04/19 05:19	10.0	9.2	9.1		|R-A|/Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	08/04/19 05:14	21.0	18.0	18.0		|R-A|	0.0
	Zero	08/04/19 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/05/19 04:14	200.0	0.0	-0.1		|R-A|/Span * 100	0.1
	High	08/05/19 04:25	200.0	180.7	187.1	>1x Alert	|R-A|/Span * 100	3.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/05/19 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/05/19 04:19	10.0	8.9	9.2	>1x Alert	|R-A|/Span * 100	3.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/05/19 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/05/19 04:24	200.0	177.2	177.3		|R-A|/Span * 100	0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/05/19 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/05/19 04:19	10.0	8.8	8.9		|R-A|/Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/05/19 05:15	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	08/05/19 05:24	200.0	180.3	179.9		|R-A|/Span * 100	0.2

Daily Calibration Results

CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:13 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/05/19 05:15	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	08/05/19 05:19	10.0	8.9	9.0		|R-A|/Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/05/19 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/05/19 05:24	200.0	180.7	180.2		|R-A|/Span * 100	0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/05/19 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/05/19 05:19	10.0	8.9	8.9		|R-A|/Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	08/05/19 05:15	21.0	18.0	18.0		|R-A|	0.0
	Zero	08/05/19 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/05/19 05:14	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	08/05/19 05:25	200.0	177.4	178.9		|R-A|/Span * 100	0.8
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/05/19 05:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	08/05/19 05:19	10.0	8.8	8.8		|R-A|/Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/05/19 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/05/19 05:25	200.0	177.2	175.7		|R-A|/Span * 100	0.8
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/05/19 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/05/19 05:19	10.0	8.8	8.7		|R-A|/Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	08/05/19 05:14	21.0	18.0	18.0		|R-A|	0.0
	Zero	08/05/19 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/05/19 08:59	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/05/19 09:10	200.0	180.3	180.1		|R-A|/Span * 100	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/05/19 08:59	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/05/19 09:05	10.0	8.9	8.8		|R-A|/Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/05/19 08:59	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	08/05/19 09:10	200.0	180.7	180.8		|R-A|/Span * 100	0.1

Daily Calibration Results

CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:13 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/05/19 08:59	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/05/19 09:05	10.0	8.9	9.0		|R-A|/Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	08/05/19 08:59	21.0	18.0	18.0		|R-A|	0.0
	Zero	08/05/19 09:05	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/06/19 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/06/19 04:25	200.0	180.7	189.3	>1x Alert	|R-A|/Span * 100	4.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/06/19 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/06/19 04:20	10.0	8.9	9.3	>1x Alert	|R-A|/Span * 100	4.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/06/19 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/06/19 04:25	200.0	177.2	178.0		|R-A|/Span * 100	0.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/06/19 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/06/19 04:19	10.0	8.8	9.0		|R-A|/Span * 100	2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/06/19 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/06/19 05:25	200.0	180.3	180.6		|R-A|/Span * 100	0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/06/19 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/06/19 05:19	10.0	8.9	8.9		|R-A|/Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/06/19 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/06/19 05:25	200.0	180.7	180.6		|R-A|/Span * 100	0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/06/19 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/06/19 05:19	10.0	8.9	8.8		|R-A|/Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	08/06/19 05:15	21.0	18.0	18.0		|R-A|	0.0
	Zero	08/06/19 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/06/19 05:14	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	08/06/19 05:24	200.0	177.4	178.9		|R-A|/Span * 100	0.8

Daily Calibration Results

CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:13 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/06/19 05:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	08/06/19 05:19	10.0	8.8	8.9		|R-A|/Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/06/19 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/06/19 05:24	200.0	177.2	175.8		|R-A|/Span * 100	0.7
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/06/19 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/06/19 05:19	10.0	8.8	8.7		|R-A|/Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	08/06/19 05:14	21.0	18.0	18.0		|R-A|	0.0
	Zero	08/06/19 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Warn
	Zero	08/07/19 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/07/19 04:25	200.0	180.7	190.8	>2x	|R-A|/Span * 100	5.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/07/19 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/07/19 04:19	10.0	8.9	9.4	>1x Alert	|R-A|/Span * 100	5.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/07/19 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/07/19 04:25	200.0	177.2	177.8		|R-A|/Span * 100	0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/07/19 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/07/19 04:20	10.0	8.8	9.0		|R-A|/Span * 100	2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/07/19 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/07/19 05:25	200.0	180.3	180.6		|R-A|/Span * 100	0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/07/19 05:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	08/07/19 05:19	10.0	8.9	8.8		|R-A|/Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/07/19 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/07/19 05:25	200.0	180.7	180.5		|R-A|/Span * 100	0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/07/19 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/07/19 05:19	10.0	8.9	8.8		|R-A|/Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:13 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	08/07/19 05:14	21.0	18.0	18.0		|R-A|	0.0
	Zero	08/07/19 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/07/19 05:14	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	08/07/19 05:25	200.0	177.4	178.6		|R-A|/Span * 100	0.6
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/07/19 05:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	08/07/19 05:20	10.0	8.8	8.9		|R-A|/Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/07/19 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/07/19 05:25	200.0	177.2	175.6		|R-A|/Span * 100	0.8
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/07/19 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/07/19 05:20	10.0	8.8	8.7		|R-A|/Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	08/07/19 05:14	21.0	18.0	18.0		|R-A|	0.0
	Zero	08/07/19 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/07/19 11:36	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/07/19 11:45	200.0	180.7	180.1		|R-A|/Span * 100	0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/07/19 11:36	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/07/19 11:40	10.0	8.9	8.4	>1x Alert	|R-A|/Span * 100	5.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/08/19 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/08/19 04:25	200.0	180.7	181.9		|R-A|/Span * 100	0.6
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/08/19 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/08/19 04:20	10.0	8.9	8.5	>1x Alert	|R-A|/Span * 100	4.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/08/19 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/08/19 04:25	200.0	177.2	177.1		|R-A|/Span * 100	0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/08/19 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/08/19 04:20	10.0	8.8	8.9		|R-A|/Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:13 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/13/19 08:50	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/13/19 09:01	200.0	180.3	180.0		|R-A|/Span * 100	0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/13/19 08:50	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	08/13/19 08:56	10.0	8.9	8.8		|R-A|/Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/13/19 08:50	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/13/19 09:01	200.0	180.7	180.0		|R-A|/Span * 100	0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/13/19 08:50	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/13/19 08:56	10.0	8.9	8.8		|R-A|/Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	08/13/19 08:50	21.0	18.0	18.0		|R-A|	0.0
	Zero	08/13/19 08:56	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/14/19 04:15	200.0	0.0	0.2		|R-A|/Span * 100	0.1
	High	08/14/19 04:25	200.0	180.7	179.4		|R-A|/Span * 100	0.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/14/19 04:15	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	08/14/19 04:20	10.0	8.9	8.4	>1x Alert	|R-A|/Span * 100	5.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/14/19 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/14/19 05:24	200.0	180.3	180.1		|R-A|/Span * 100	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/14/19 05:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	08/14/19 05:20	10.0	8.9	8.8		|R-A|/Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/14/19 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/14/19 05:24	200.0	180.7	180.6		|R-A|/Span * 100	0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/14/19 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/14/19 05:20	10.0	8.9	8.9		|R-A|/Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	08/14/19 05:14	21.0	18.0	18.0		|R-A|	0.0
	Zero	08/14/19 05:20	21.0	0.0	0.0		|R-A|	0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:13 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/14/19 08:58	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	08/14/19 09:09	200.0	180.7	182.0		|R-A|/Span * 100	0.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/14/19 08:58	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/14/19 09:04	10.0	8.9	8.9		|R-A|/Span * 100	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/14/19 10:17	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	08/14/19 10:27	200.0	177.4	178.5		|R-A|/Span * 100	0.6
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/14/19 10:17	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	08/14/19 10:22	10.0	8.8	8.9		|R-A|/Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/14/19 10:17	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/14/19 10:27	200.0	177.2	177.2		|R-A|/Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/14/19 10:17	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/14/19 10:22	10.0	8.8	8.8		|R-A|/Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	08/14/19 10:17	21.0	18.0	18.0		|R-A|	0.0
	Zero	08/14/19 10:22	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/15/19 04:14	200.0	0.0	-0.1		|R-A|/Span * 100	0.1
	High	08/15/19 04:25	200.0	180.7	181.2		|R-A|/Span * 100	0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/15/19 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/15/19 04:19	10.0	8.9	8.5	>1x Alert	|R-A|/Span * 100	4.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/15/19 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/15/19 04:25	200.0	177.2	179.8		|R-A|/Span * 100	1.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/15/19 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/15/19 04:20	10.0	8.8	9.1	>1x Alert	|R-A|/Span * 100	3.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/15/19 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/15/19 05:25	200.0	180.3	180.3		|R-A|/Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:13 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/15/19 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/15/19 05:19	10.0	8.9	8.8		|R-A|/Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/15/19 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/15/19 05:25	200.0	180.7	180.8		|R-A|/Span * 100	0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/15/19 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/15/19 05:19	10.0	8.9	8.8		|R-A|/Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	08/15/19 05:15	21.0	18.0	18.0		|R-A|	0.0
	Zero	08/15/19 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/15/19 05:15	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	08/15/19 05:25	200.0	177.4	178.1		|R-A|/Span * 100	0.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/15/19 05:15	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	08/15/19 05:20	10.0	8.8	8.9		|R-A|/Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/15/19 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/15/19 05:25	200.0	177.2	176.3		|R-A|/Span * 100	0.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/15/19 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/15/19 05:20	10.0	8.8	8.7		|R-A|/Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	08/15/19 05:15	21.0	18.0	18.0		|R-A|	0.0
	Zero	08/15/19 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/15/19 09:32	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/15/19 09:42	200.0	177.2	180.3		|R-A|/Span * 100	1.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/15/19 09:32	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/15/19 09:37	10.0	8.8	8.8		|R-A|/Span * 100	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/15/19 10:17	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/15/19 10:28	200.0	180.7	181.6		|R-A|/Span * 100	0.5

Daily Calibration Results

CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:13 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/15/19 10:17	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/15/19 10:22	10.0	8.9	8.9		|R-A|/Span * 100	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/16/19 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/16/19 04:25	200.0	180.7	182.3		|R-A|/Span * 100	0.8
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/16/19 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/16/19 04:19	10.0	8.9	8.9		|R-A|/Span * 100	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/16/19 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/16/19 04:25	200.0	177.2	179.6		|R-A|/Span * 100	1.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/16/19 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/16/19 04:20	10.0	8.8	8.8		|R-A|/Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/16/19 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/16/19 05:25	200.0	180.3	180.7		|R-A|/Span * 100	0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/16/19 05:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	08/16/19 05:19	10.0	8.9	8.9		|R-A|/Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/16/19 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/16/19 05:25	200.0	180.7	180.7		|R-A|/Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/16/19 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/16/19 05:19	10.0	8.9	8.8		|R-A|/Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	08/16/19 05:14	21.0	18.0	18.0		|R-A|	0.0
	Zero	08/16/19 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/16/19 05:14	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	08/16/19 05:24	200.0	177.4	178.8		|R-A|/Span * 100	0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/16/19 05:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	08/16/19 05:19	10.0	8.8	8.9		|R-A|/Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:13 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/16/19 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/16/19 05:24	200.0	177.2	176.3		|R-A|/Span * 100	0.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/16/19 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/16/19 05:19	10.0	8.8	8.7		|R-A|/Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	08/16/19 05:14	21.0	18.0	18.0		|R-A|	0.0
	Zero	08/16/19 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/17/19 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/17/19 04:25	200.0	180.7	183.4		|R-A|/Span * 100	1.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/17/19 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/17/19 04:20	10.0	8.9	8.9		|R-A|/Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/17/19 05:14	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	08/17/19 05:24	200.0	180.3	181.0		|R-A|/Span * 100	0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/17/19 05:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	08/17/19 05:19	10.0	8.9	8.9		|R-A|/Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/17/19 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/17/19 05:24	200.0	180.7	180.4		|R-A|/Span * 100	0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/17/19 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/17/19 05:19	10.0	8.9	8.8		|R-A|/Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	08/17/19 05:14	21.0	18.0	18.0		|R-A|	0.0
	Zero	08/17/19 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/25/19 10:58	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	08/25/19 11:08	200.0	177.4	178.9		|R-A|/Span * 100	0.8
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/25/19 10:58	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	08/25/19 11:03	10.0	8.8	9.0		|R-A|/Span * 100	2.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:13 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/25/19 10:58	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/25/19 11:08	200.0	177.2	177.2		|R-A|/Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/25/19 10:58	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/25/19 11:03	10.0	8.8	8.8		|R-A|/Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	08/25/19 10:58	21.0	18.0	18.0		|R-A|	0.0
	Zero	08/25/19 11:03	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/26/19 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/26/19 04:25	200.0	177.2	178.4		|R-A|/Span * 100	0.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/26/19 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/26/19 04:19	10.0	8.8	8.8		|R-A|/Span * 100	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/26/19 05:14	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	08/26/19 05:25	200.0	177.4	179.3		|R-A|/Span * 100	1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/26/19 05:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	08/26/19 05:20	10.0	8.8	9.0		|R-A|/Span * 100	2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/26/19 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/26/19 05:25	200.0	177.2	176.8		|R-A|/Span * 100	0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/26/19 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/26/19 05:20	10.0	8.8	8.8		|R-A|/Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	08/26/19 05:14	21.0	18.0	18.0		|R-A|	0.0
	Zero	08/26/19 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/27/19 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/27/19 04:25	200.0	177.2	178.1		|R-A|/Span * 100	0.5
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/27/19 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/27/19 04:20	10.0	8.8	8.7		|R-A|/Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:13 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/27/19 05:14	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	08/27/19 05:25	200.0	177.4	179.9		|R-A|/Span * 100	1.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/27/19 05:14	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	08/27/19 05:19	10.0	8.8	9.1		|R-A|/Span * 100	3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/27/19 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/27/19 05:25	200.0	177.2	176.8		|R-A|/Span * 100	0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/27/19 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/27/19 05:19	10.0	8.8	8.8		|R-A|/Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	08/27/19 05:14	21.0	18.0	18.0		|R-A|	0.0
	Zero	08/27/19 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/27/19 09:19	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	08/27/19 09:29	200.0	180.3	179.9		|R-A|/Span * 100	0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/27/19 09:19	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	08/27/19 09:24	10.0	8.9	8.9		|R-A|/Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/27/19 09:19	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/27/19 09:29	200.0	180.7	181.3		|R-A|/Span * 100	0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/27/19 09:19	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/27/19 09:24	10.0	8.9	8.9		|R-A|/Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	08/27/19 09:19	21.0	18.0	18.0		|R-A|	0.0
	Zero	08/27/19 09:24	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/28/19 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/28/19 04:25	200.0	180.7	188.0	>1x Alert	|R-A|/Span * 100	3.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/28/19 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/28/19 04:19	10.0	8.9	9.2	>1x Alert	|R-A|/Span * 100	3.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:13 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/28/19 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/28/19 04:25	200.0	177.2	177.5		|R-A|/Span * 100	0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/28/19 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/28/19 04:19	10.0	8.8	8.7		|R-A|/Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/28/19 05:15	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	08/28/19 05:25	200.0	180.3	180.0		|R-A|/Span * 100	0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/28/19 05:15	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	08/28/19 05:20	10.0	8.9	8.9		|R-A|/Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/28/19 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/28/19 05:25	200.0	180.7	181.2		|R-A|/Span * 100	0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/28/19 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/28/19 05:20	10.0	8.9	8.9		|R-A|/Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	08/28/19 05:15	21.0	18.0	18.0		|R-A|	0.0
	Zero	08/28/19 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/28/19 05:14	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	08/28/19 05:25	200.0	177.4	179.3		|R-A|/Span * 100	1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/28/19 05:14	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	08/28/19 05:20	10.0	8.8	9.0		|R-A|/Span * 100	2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/28/19 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/28/19 05:25	200.0	177.2	176.5		|R-A|/Span * 100	0.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/28/19 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/28/19 05:20	10.0	8.8	8.7		|R-A|/Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	08/28/19 05:14	21.0	18.0	18.0		|R-A|	0.0
	Zero	08/28/19 05:20	21.0	0.0	0.0		|R-A|	0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:13 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/29/19 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/29/19 04:24	200.0	177.2	177.6		|R-A|/Span * 100	0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/29/19 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/29/19 04:19	10.0	8.8	8.7		|R-A|/Span * 100	1.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/29/19 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/29/19 04:25	200.0	180.7	186.9	>1x Alert	|R-A|/Span * 100	3.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/29/19 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/29/19 04:19	10.0	8.9	9.2	>1x Alert	|R-A|/Span * 100	3.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/29/19 05:14	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	08/29/19 05:24	200.0	177.4	178.1		|R-A|/Span * 100	0.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/29/19 05:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	08/29/19 05:19	10.0	8.8	8.8		|R-A|/Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/29/19 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/29/19 05:24	200.0	177.2	176.3		|R-A|/Span * 100	0.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/29/19 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/29/19 05:19	10.0	8.8	8.7		|R-A|/Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	08/29/19 05:14	21.0	18.0	18.0		|R-A|	0.0
	Zero	08/29/19 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/29/19 05:14	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	08/29/19 05:25	200.0	180.3	179.7		|R-A|/Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/29/19 05:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	08/29/19 05:19	10.0	8.9	9.0		|R-A|/Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/29/19 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/29/19 05:25	200.0	180.7	180.5		|R-A|/Span * 100	0.1

Daily Calibration Results

CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:13 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/29/19 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/29/19 05:19	10.0	8.9	8.8		|R-A|/Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	08/29/19 05:14	21.0	18.0	18.0		|R-A|	0.0
	Zero	08/29/19 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/04/19 09:19	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	09/04/19 09:29	200.0	180.3	179.6		|R-A|/Span * 100	0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/04/19 09:19	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	09/04/19 09:23	10.0	8.9	8.9		|R-A|/Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/04/19 09:19	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/04/19 09:29	200.0	180.7	180.1		|R-A|/Span * 100	0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/04/19 09:19	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/04/19 09:23	10.0	8.9	8.8		|R-A|/Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	09/04/19 09:19	21.0	18.0	18.0		|R-A|	0.0
	Zero	09/04/19 09:23	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/04/19 10:21	200.0	0.0	0.3		|R-A|/Span * 100	0.2
	High	09/04/19 10:31	200.0	177.4	179.9		|R-A|/Span * 100	1.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/04/19 10:21	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	09/04/19 10:26	10.0	8.8	9.0		|R-A|/Span * 100	2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/04/19 10:21	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/04/19 10:31	200.0	177.2	177.1		|R-A|/Span * 100	0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/04/19 10:21	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/04/19 10:26	10.0	8.8	8.8		|R-A|/Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	09/04/19 10:21	21.0	18.0	18.0		|R-A|	0.0
	Zero	09/04/19 10:26	21.0	0.0	0.0		|R-A|	0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:13 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Warn
	Zero	09/05/19 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/05/19 04:25	200.0	180.7	191.3	>2x	|R-A|/Span * 100	5.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Warn
	Zero	09/05/19 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/05/19 04:19	10.0	8.9	9.5	>2x	|R-A|/Span * 100	6.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/05/19 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/05/19 04:25	200.0	177.2	177.5		|R-A|/Span * 100	0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/05/19 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/05/19 04:19	10.0	8.8	8.7		|R-A|/Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/05/19 05:14	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	09/05/19 05:25	200.0	180.3	179.7		|R-A|/Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/05/19 05:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	09/05/19 05:20	10.0	8.9	9.0		|R-A|/Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/05/19 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/05/19 05:25	200.0	180.7	180.8		|R-A|/Span * 100	0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/05/19 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/05/19 05:20	10.0	8.9	8.8		|R-A|/Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	09/05/19 05:14	21.0	18.0	18.0		|R-A|	0.0
	Zero	09/05/19 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/05/19 05:14	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	09/05/19 05:25	200.0	177.4	178.5		|R-A|/Span * 100	0.6
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/05/19 05:14	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	09/05/19 05:20	10.0	8.8	9.1		|R-A|/Span * 100	3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/05/19 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/05/19 05:25	200.0	177.2	176.6		|R-A|/Span * 100	0.3

Daily Calibration Results

CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:13 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/05/19 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/05/19 05:20	10.0	8.8	8.8		|R-A|/Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	09/05/19 05:14	21.0	18.0	18.0		|R-A|	0.0
	Zero	09/05/19 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/05/19 08:27	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	09/05/19 08:37	200.0	180.7	181.9		|R-A|/Span * 100	0.6
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/05/19 08:27	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	09/05/19 08:32	10.0	8.9	8.9		|R-A|/Span * 100	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/10/19 01:15	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	09/10/19 01:26	200.0	177.4	180.0		|R-A|/Span * 100	1.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/10/19 01:15	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	09/10/19 01:21	10.0	8.8	9.1		|R-A|/Span * 100	3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/10/19 01:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/10/19 01:26	200.0	177.2	176.7		|R-A|/Span * 100	0.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/10/19 01:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/10/19 01:21	10.0	8.8	8.8		|R-A|/Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	09/10/19 01:15	21.0	18.0	18.0		|R-A|	0.0
	Zero	09/10/19 01:21	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/10/19 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/10/19 04:25	200.0	177.2	178.6		|R-A|/Span * 100	0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/10/19 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/10/19 04:20	10.0	8.8	8.8		|R-A|/Span * 100	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/11/19 01:30	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	09/11/19 01:40	200.0	177.4	179.4		|R-A|/Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:13 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/11/19 01:30	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	09/11/19 01:35	10.0	8.8	9.0		|R-A|/Span * 100	2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/11/19 01:30	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/11/19 01:40	200.0	177.2	176.7		|R-A|/Span * 100	0.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/11/19 01:30	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/11/19 01:35	10.0	8.8	8.7		|R-A|/Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	09/11/19 01:30	21.0	18.0	18.0		|R-A|	0.0
	Zero	09/11/19 01:35	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/11/19 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/11/19 04:25	200.0	177.2	176.5		|R-A|/Span * 100	0.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/11/19 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/11/19 04:19	10.0	8.8	8.6		|R-A|/Span * 100	2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/11/19 10:19	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	09/11/19 10:30	200.0	180.3	179.4		|R-A|/Span * 100	0.5
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/11/19 10:19	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	09/11/19 10:24	10.0	8.9	8.9		|R-A|/Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/11/19 10:19	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/11/19 10:30	200.0	180.7	180.3		|R-A|/Span * 100	0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/11/19 10:19	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/11/19 10:24	10.0	8.9	8.9		|R-A|/Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	09/11/19 10:19	21.0	18.0	18.0		|R-A|	0.0
	Zero	09/11/19 10:24	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/12/19 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/12/19 04:25	200.0	180.7	181.6		|R-A|/Span * 100	0.5

Daily Calibration Results

CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:13 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/12/19 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/12/19 04:20	10.0	8.9	8.4	>1x Alert	|R-A|/Span * 100	5.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/12/19 05:15	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	09/12/19 05:25	200.0	180.3	179.7		|R-A|/Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/12/19 05:15	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	09/12/19 05:20	10.0	8.9	9.0		|R-A|/Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/12/19 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/12/19 05:25	200.0	180.7	181.1		|R-A|/Span * 100	0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/12/19 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/12/19 05:20	10.0	8.9	8.8		|R-A|/Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	09/12/19 05:15	21.0	18.0	18.0		|R-A|	0.0
	Zero	09/12/19 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/12/19 12:19	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	09/12/19 12:30	200.0	177.4	178.9		|R-A|/Span * 100	0.8
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/12/19 12:19	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	09/12/19 12:25	10.0	8.8	9.1		|R-A|/Span * 100	3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/12/19 12:19	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/12/19 12:30	200.0	177.2	177.2		|R-A|/Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/12/19 12:19	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/12/19 12:25	10.0	8.8	8.8		|R-A|/Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	09/12/19 12:19	21.0	18.0	18.0		|R-A|	0.0
	Zero	09/12/19 12:25	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/23/19 09:27	200.0	0.0	0.3		|R-A|/Span * 100	0.2
	High	09/23/19 09:38	200.0	177.4	179.6		|R-A|/Span * 100	1.1

Daily Calibration Results

CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:13 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/23/19 09:27	10.0	0.0	0.3		|R-A|/Span * 100	3.0
	High	09/23/19 09:32	10.0	8.8	9.2		|R-A|/Span * 100	4.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/23/19 09:27	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/23/19 09:38	200.0	177.2	177.2		|R-A|/Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/23/19 09:27	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/23/19 09:32	10.0	8.8	8.7		|R-A|/Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	09/23/19 09:27	21.0	18.0	18.0		|R-A|	0.0
	Zero	09/23/19 09:32	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/24/19 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/24/19 04:24	200.0	177.2	176.6		|R-A|/Span * 100	0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/24/19 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/24/19 04:20	10.0	8.8	8.7		|R-A|/Span * 100	1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/24/19 05:14	200.0	0.0	0.3		|R-A|/Span * 100	0.2
	High	09/24/19 05:25	200.0	177.4	179.6		|R-A|/Span * 100	1.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/24/19 05:14	10.0	0.0	0.3		|R-A|/Span * 100	3.0
	High	09/24/19 05:20	10.0	8.8	9.2		|R-A|/Span * 100	4.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/24/19 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/24/19 05:25	200.0	177.2	176.8		|R-A|/Span * 100	0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/24/19 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/24/19 05:20	10.0	8.8	8.8		|R-A|/Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	09/24/19 05:14	21.0	18.0	18.0		|R-A|	0.0
	Zero	09/24/19 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/24/19 11:30	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	09/24/19 11:41	200.0	180.3	179.4		|R-A|/Span * 100	0.5

Daily Calibration Results

CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:13 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/24/19 11:30	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	09/24/19 11:36	10.0	8.9	9.0		|R-A|/Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/24/19 11:30	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/24/19 11:41	200.0	180.7	181.0		|R-A|/Span * 100	0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/24/19 11:30	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/24/19 11:36	10.0	8.9	8.8		|R-A|/Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	09/24/19 11:30	21.0	18.0	18.0		|R-A|	0.0
	Zero	09/24/19 11:36	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/25/19 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/25/19 04:24	200.0	180.7	184.3		|R-A|/Span * 100	1.8
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/25/19 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/25/19 04:19	10.0	8.9	8.5	>1x Alert	|R-A|/Span * 100	4.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/25/19 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/25/19 04:25	200.0	177.2	175.9		|R-A|/Span * 100	0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/25/19 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/25/19 04:20	10.0	8.8	8.6		|R-A|/Span * 100	2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/25/19 05:14	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	09/25/19 05:25	200.0	180.3	180.3		|R-A|/Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/25/19 05:14	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	09/25/19 05:19	10.0	8.9	9.0		|R-A|/Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/25/19 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/25/19 05:25	200.0	180.7	181.0		|R-A|/Span * 100	0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/25/19 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/25/19 05:19	10.0	8.9	8.8		|R-A|/Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:13 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	09/25/19 05:14	21.0	18.0	18.0		|R-A|	0.0
	Zero	09/25/19 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/25/19 05:15	200.0	0.0	0.3		|R-A|/Span * 100	0.2
	High	09/25/19 05:25	200.0	177.4	181.0		|R-A|/Span * 100	1.8
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/25/19 05:15	10.0	0.0	0.3		|R-A|/Span * 100	3.0
	High	09/25/19 05:20	10.0	8.8	9.2		|R-A|/Span * 100	4.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/25/19 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/25/19 05:25	200.0	177.2	176.3		|R-A|/Span * 100	0.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/25/19 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/25/19 05:20	10.0	8.8	8.7		|R-A|/Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	09/25/19 05:15	21.0	18.0	18.0		|R-A|	0.0
	Zero	09/25/19 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/26/19 04:14	200.0	0.0	-0.1		|R-A|/Span * 100	0.1
	High	09/26/19 04:25	200.0	180.7	184.6		|R-A|/Span * 100	2.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/26/19 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/26/19 04:19	10.0	8.9	8.6	>1x Alert	|R-A|/Span * 100	3.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/26/19 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/26/19 04:25	200.0	177.2	176.1		|R-A|/Span * 100	0.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/26/19 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/26/19 04:20	10.0	8.8	8.6		|R-A|/Span * 100	2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/26/19 05:15	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	09/26/19 05:24	200.0	180.3	180.4		|R-A|/Span * 100	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/26/19 05:15	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	09/26/19 05:19	10.0	8.9	9.0		|R-A|/Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:13 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/26/19 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/26/19 05:24	200.0	180.7	180.6		|R-A|/Span * 100	0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/26/19 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/26/19 05:19	10.0	8.9	8.7		|R-A|/Span * 100	2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	09/26/19 05:15	21.0	18.0	18.0		|R-A|	0.0
	Zero	09/26/19 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/26/19 05:15	200.0	0.0	0.3		|R-A|/Span * 100	0.2
	High	09/26/19 05:25	200.0	177.4	180.3		|R-A|/Span * 100	1.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/26/19 05:15	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	09/26/19 05:20	10.0	8.8	9.1		|R-A|/Span * 100	3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/26/19 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/26/19 05:25	200.0	177.2	176.2		|R-A|/Span * 100	0.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/26/19 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/26/19 05:20	10.0	8.8	8.7		|R-A|/Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	09/26/19 05:15	21.0	18.0	18.0		|R-A|	0.0
	Zero	09/26/19 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/27/19 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/27/19 04:25	200.0	177.2	176.7		|R-A|/Span * 100	0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/27/19 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/27/19 04:20	10.0	8.8	8.7		|R-A|/Span * 100	1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/27/19 05:15	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	09/27/19 05:24	200.0	177.4	179.3		|R-A|/Span * 100	1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/27/19 05:15	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	09/27/19 05:20	10.0	8.8	9.1		|R-A|/Span * 100	3.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:13 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/27/19 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/27/19 05:24	200.0	177.2	175.9		|R-A|/Span * 100	0.7
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/27/19 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/27/19 05:20	10.0	8.8	8.7		|R-A|/Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	09/27/19 05:15	21.0	18.0	18.0		|R-A|	0.0
	Zero	09/27/19 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/30/19 10:19	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	09/30/19 10:29	200.0	180.3	179.7		|R-A|/Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/30/19 10:19	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	09/30/19 10:23	10.0	8.9	9.0		|R-A|/Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/30/19 10:19	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/30/19 10:29	200.0	180.7	180.8		|R-A|/Span * 100	0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/30/19 10:19	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/30/19 10:23	10.0	8.9	8.7		|R-A|/Span * 100	2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	09/30/19 10:19	21.0	18.0	18.0		|R-A|	0.0
	Zero	09/30/19 10:23	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/30/19 14:20	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	09/30/19 14:30	200.0	177.4	179.7		|R-A|/Span * 100	1.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/30/19 14:20	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	09/30/19 14:24	10.0	8.8	9.1		|R-A|/Span * 100	3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/30/19 14:20	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/30/19 14:30	200.0	177.2	177.0		|R-A|/Span * 100	0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/30/19 14:20	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/30/19 14:24	10.0	8.8	8.8		|R-A|/Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:13 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	09/30/19 14:20	21.0	18.0	18.0		|R-A|	0.0
	Zero	09/30/19 14:24	21.0	0.0	0.0		|R-A|	0.0

Monthly Summary Report

Units CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:12 **Location:** Roseville, CA

Date	Unit CT1 OperatingTime, Hr 1 Hour(s) Sum	Unit CT1 OperatingTime, Hr 1 Hour(s) Running Sum	Unit CT1 DBOn, Hr 1 Hour(s) Sum	Unit CT1 DBOn, Hr 1 Hour(s) Running Sum	Unit CT2 OperatingTime, Hr 1 Hour(s) Sum	Unit CT2 OperatingTime, Hr 1 Hour(s) Running Sum	Unit CT2 DBOn, Hr 1 Hour(s) Sum	Unit CT2 DBOn, Hr 1 Hour(s) Running Sum
Jul 19	210.25	210.25	113.25	113.25	120.41	120.41	31.17	31.17
Aug 19	350.72	560.97	131.44	244.69	348.83	469.24	125.42	156.59
Sep 19	137.08	698.05	51.10	295.79	209.97	679.21	91.17	247.76
Sum/Avg	698.05		295.79		679.21		247.76	

Tons 12 Month Rolling Summary

CT1 and CT2 Combined

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:02 **Location:** Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2 CO, Ton 1 Day(s) Sum	Rolling Sum	Units CT1 & CT2 NOx, Ton 1 Day(s) Sum	Rolling Sum	Units CT1 & CT2 PM10, Ton 1 Day(s) Sum	Rolling Sum	Units CT1 & CT2 SO2, Ton 1 Day(s) Sum	Rolling Sum	Units CT1 & CT2 VOC, Ton 1 Day(s) Sum	Rolling Sum
Jul 2019	0.1329	3.6349	0.4979	9.8697	0.0934	1.8340	0.0467	0.9169	0.1557	3.0568
Aug 2019	0.3100	3.5358	0.9671	9.0841	0.1814	1.6947	0.0908	0.8474	0.3022	2.8241
Sep 2019	0.3350	3.8708	0.5519	9.6360	0.0943	1.7890	0.0471	0.8945	0.1574	2.9815
Sum/Avg	3.8708		9.6360		1.7890		0.8945		2.9815	
Limit Value										

AQ34 3HR AVG LOAD

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/01/19 0:00	0			0			0											
07/01/19 1:00	0			0			0											
07/01/19 2:00	0			0			0											
07/01/19 3:00	0			0			0											
07/01/19 4:00	0			0			0											
07/01/19 5:00	0			0			0											
07/01/19 6:00	0			0			0											
07/01/19 7:00	0			0			0											
07/01/19 8:00	0			0			0											
07/01/19 9:00	0			0			0											
07/01/19 10:00	0			0			0											
07/01/19 11:00	0			0			0											
07/01/19 12:00	0			0			0											
07/01/19 13:00	0			0			0											
07/01/19 14:00	0			0			0											
07/01/19 15:00	0			0			0											
07/01/19 16:00	0			0			0											
07/01/19 17:00	0			0			0											
07/01/19 18:00	0			0			0											
07/01/19 19:00	0			0			0											
07/01/19 20:00	0			0			0											
07/01/19 21:00	0			0			0											
07/01/19 22:00	0			0			0											
07/01/19 23:00	0			0			0											
07/02/19 0:00	0			0			0											
07/02/19 1:00	0			0			0											
07/02/19 2:00	0			0			0											
07/02/19 3:00	0			0			0											
07/02/19 4:00	0			0			0											
07/02/19 5:00	0			0			0											
07/02/19 6:00	0			0			0											
07/02/19 7:00	0			0			0											
07/02/19 8:00	0			0			0											
07/02/19 9:00	0			0			0											
07/02/19 10:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/02/19 11:00	0			0			0											
07/02/19 12:00	0			0			0											
07/02/19 13:00	0			0			0											
07/02/19 14:00	0			0			0											
07/02/19 15:00	0			0			0											
07/02/19 16:00	0			0			0											
07/02/19 17:00	0			0			0											
07/02/19 18:00	0			0			0											
07/02/19 19:00	0			0			0											
07/02/19 20:00	0			0			0											
07/02/19 21:00	0			0			0											
07/02/19 22:00	0			0			0											
07/02/19 23:00	0			0			0											
07/03/19 0:00	0			0			0											
07/03/19 1:00	0			0			0											
07/03/19 2:00	0			0			0											
07/03/19 3:00	0			0			0											
07/03/19 4:00	0			0			0											
07/03/19 5:00	0			0			0											
07/03/19 6:00	0			0			0											
07/03/19 7:00	0			0			0											
07/03/19 8:00	0			0			0											
07/03/19 9:00	0			0			0											
07/03/19 10:00	0			0			0											
07/03/19 11:00	0			0			0											
07/03/19 12:00	0			0			0											
07/03/19 13:00	0			0			0											
07/03/19 14:00	0			0			0											
07/03/19 15:00	0			0			0											
07/03/19 16:00	0			0			0											
07/03/19 17:00	0			0			0											
07/03/19 18:00	0			0			0											
07/03/19 19:00	0			0			0											
07/03/19 20:00	0			0			0											
07/03/19 21:00	0			0			0											
07/03/19 22:00	0			0			0											
07/03/19 23:00	0			0			0											
07/04/19 0:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/04/19 1:00	0			0			0											
07/04/19 2:00	0			0			0											
07/04/19 3:00	0			0			0											
07/04/19 4:00	0			0			0											
07/04/19 5:00	0			0			0											
07/04/19 6:00	0			0			0											
07/04/19 7:00	0			0			0											
07/04/19 8:00	0			0			0											
07/04/19 9:00	0			0			0											
07/04/19 10:00	0			0			0											
07/04/19 11:00	0			0			0											
07/04/19 12:00	0			0			0											
07/04/19 13:00	0			0			0											
07/04/19 14:00	0			0			0											
07/04/19 15:00	0			0			0											
07/04/19 16:00	0			0			0											
07/04/19 17:00	0			0			0											
07/04/19 18:00	0			0			0											
07/04/19 19:00	0			0			0											
07/04/19 20:00	0			0			0											
07/04/19 21:00	0			0			0											
07/04/19 22:00	0			0			0											
07/04/19 23:00	0			0			0											
07/05/19 0:00	0			0			0											
07/05/19 1:00	0			0			0											
07/05/19 2:00	0			0			0											
07/05/19 3:00	0			0			0											
07/05/19 4:00	0			0			0											
07/05/19 5:00	0			0			0											
07/05/19 6:00	0			0			0											
07/05/19 7:00	0			0			0											
07/05/19 8:00	0			0			0											
07/05/19 9:00	0			0			0											
07/05/19 10:00	0			0			0											
07/05/19 11:00	0			0			0											
07/05/19 12:00	0			0			0											
07/05/19 13:00	0			0			0											
07/05/19 14:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/05/19 15:00	0			0			0											
07/05/19 16:00	0			0			0											
07/05/19 17:00	0			0			0											
07/05/19 18:00	0			0			0											
07/05/19 19:00	0			0			0											
07/05/19 20:00	0			0			0											
07/05/19 21:00	0			0			0											
07/05/19 22:00	0			0			0											
07/05/19 23:00	0			0			0											
07/06/19 0:00	0			0			0											
07/06/19 1:00	0			0			0											
07/06/19 2:00	0			0			0											
07/06/19 3:00	0			0			0											
07/06/19 4:00	0			0			0											
07/06/19 5:00	0			0			0											
07/06/19 6:00	0			0			0											
07/06/19 7:00	0			0			0											
07/06/19 8:00	0			0			0											
07/06/19 9:00	0			0			0											
07/06/19 10:00	0			0			0											
07/06/19 11:00	0			0			0											
07/06/19 12:00	0			0			0											
07/06/19 13:00	0			0			0											
07/06/19 14:00	0			0			0											
07/06/19 15:00	0			0			0											
07/06/19 16:00	0			0			0											
07/06/19 17:00	0			0			0											
07/06/19 18:00	0			0			0											
07/06/19 19:00	0			0			0											
07/06/19 20:00	0			0			0											
07/06/19 21:00	0			0			0											
07/06/19 22:00	0			0			0											
07/06/19 23:00	0			0			0											
07/07/19 0:00	0			0			0											
07/07/19 1:00	0			0			0											
07/07/19 2:00	0			0			0											
07/07/19 3:00	0			0			0											
07/07/19 4:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/07/19 5:00	0			0			0											
07/07/19 6:00	0			0			0											
07/07/19 7:00	0			0			0											
07/07/19 8:00	0			0			0											
07/07/19 9:00	0			0			0											
07/07/19 10:00	0			0			0											
07/07/19 11:00	0			0			0											
07/07/19 12:00	0			0			0											
07/07/19 13:00	0			0			0											
07/07/19 14:00	0			0			0											
07/07/19 15:00	0			0			0											
07/07/19 16:00	0			0			0											
07/07/19 17:00	0			0			0											
07/07/19 18:00	0			0			0											
07/07/19 19:00	0			0			0											
07/07/19 20:00	0			0			0											
07/07/19 21:00	0			0			0											
07/07/19 22:00	0			0			0											
07/07/19 23:00	0			0			0											
07/08/19 0:00	0			0			0											
07/08/19 1:00	0			0			0											
07/08/19 2:00	0			0			0											
07/08/19 3:00	0			0			0											
07/08/19 4:00	0			0			0											
07/08/19 5:00	0			0			0											
07/08/19 6:00	0			0			0											
07/08/19 7:00	0			0			0											
07/08/19 8:00	0			0			0											
07/08/19 9:00	0			0			0											
07/08/19 10:00	0			0			0											
07/08/19 11:00	0			0			0											
07/08/19 12:00	0			0			0											
07/08/19 13:00	0			0			0											
07/08/19 14:00	0			0			0											
07/08/19 15:00	0			0			0											
07/08/19 16:00	0			0			0											
07/08/19 17:00	0			0			0											
07/08/19 18:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/08/19 19:00	0			0			0											
07/08/19 20:00	0			0			0											
07/08/19 21:00	0			0			0											
07/08/19 22:00	0			0			0											
07/08/19 23:00	0			0			0											
07/09/19 0:00	0			0			0											
07/09/19 1:00	0			0			0											
07/09/19 2:00	0			0			0											
07/09/19 3:00	0			0			0											
07/09/19 4:00	0			0			0											
07/09/19 5:00	0			0			0											
07/09/19 6:00	0			0			0											
07/09/19 7:00	0			0			0											
07/09/19 8:00	0			0			0											
07/09/19 9:00	0			0			0											
07/09/19 10:00	0			0			0											
07/09/19 11:00	0			0			0											
07/09/19 12:00	0			0			0											
07/09/19 13:00	0			0			0											
07/09/19 14:00	0			0			0											
07/09/19 15:00	0			0			0											
07/09/19 16:00	0			0			0											
07/09/19 17:00	0			0			0											
07/09/19 18:00	0			0			0											
07/09/19 19:00	0			0			0											
07/09/19 20:00	0			0			0											
07/09/19 21:00	0			0			0											
07/09/19 22:00	0			0			0											
07/09/19 23:00	0			0			0											
07/10/19 0:00	0			0			0											
07/10/19 1:00	0			0			0											
07/10/19 2:00	0			0			0											
07/10/19 3:00	0			0			0											
07/10/19 4:00	0			0			0											
07/10/19 5:00	0			0			0											
07/10/19 6:00	0			0			0											
07/10/19 7:00	0			0			0											
07/10/19 8:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/10/19 9:00	0			0			0											
07/10/19 10:00	0			0			0											
07/10/19 11:00	0			0			0											
07/10/19 12:00	0			0			0											
07/10/19 13:00	0			0			0											
07/10/19 14:00	0			0			0											
07/10/19 15:00	0			0			0											
07/10/19 16:00	0			0			0											
07/10/19 17:00	0			0			0											
07/10/19 18:00	0			0			0											
07/10/19 19:00	0			0			0											
07/10/19 20:00	0			0			0											
07/10/19 21:00	0			0			0											
07/10/19 22:00	0			0			0											
07/10/19 23:00	0			0			0											
07/11/19 0:00	0			0			0											
07/11/19 1:00	0			0			0											
07/11/19 2:00	0			0			0											
07/11/19 3:00	0			0			0											
07/11/19 4:00	0			0			0											
07/11/19 5:00	0			0			0											
07/11/19 6:00	0			0			0											
07/11/19 7:00	0			0			0											
07/11/19 8:00	0			0			0											
07/11/19 9:00	0			0			0											
07/11/19 10:00	0			0			0											
07/11/19 11:00	0			0			0											
07/11/19 12:00	0			0			0											
07/11/19 13:00	0			0			0											
07/11/19 14:00	0			0			0											
07/11/19 15:00	0			0			0											
07/11/19 16:00	0			0			0											
07/11/19 17:00	0			0			0											
07/11/19 18:00	0			0			0											
07/11/19 19:00	0			0			0											
07/11/19 20:00	0			0			0											
07/11/19 21:00	0			0			0											
07/11/19 22:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/11/19 23:00	0			0			0											
07/12/19 0:00	0			0			0											
07/12/19 1:00	0			0			0											
07/12/19 2:00	0			0			0											
07/12/19 3:00	0			0			0											
07/12/19 4:00	0			0			0											
07/12/19 5:00	0			0			0											
07/12/19 6:00	0			0			0											
07/12/19 7:00	0			0			0											
07/12/19 8:00	0			0			0											
07/12/19 9:00	0			0			0											
07/12/19 10:00	0			0			0											
07/12/19 11:00	0			0			0											
07/12/19 12:00	0			0			0											
07/12/19 13:00	0			0			0											
07/12/19 14:00	0			0			0											
07/12/19 15:00	0			0			0											
07/12/19 16:00	0			0			0											
07/12/19 17:00	0			0			0											
07/12/19 18:00	0			0			0											
07/12/19 19:00	0			0			0											
07/12/19 20:00	0			0			0											
07/12/19 21:00	0			0			0											
07/12/19 22:00	0			0			0											
07/12/19 23:00	0			0			0											
07/13/19 0:00	0			0			0											
07/13/19 1:00	0			0			0											
07/13/19 2:00	0			0			0											
07/13/19 3:00	0			0			0											
07/13/19 4:00	0			0			0											
07/13/19 5:00	0			0			0											
07/13/19 6:00	0			0			0											
07/13/19 7:00	0			0			0											
07/13/19 8:00	0			0			0											
07/13/19 9:00	0			0			0											
07/13/19 10:00	0			0			0											
07/13/19 11:00	0			0			0											
07/13/19 12:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/13/19 13:00	0			0			0											
07/13/19 14:00	0			0			0											
07/13/19 15:00	0			0			0											
07/13/19 16:00	0			0			0											
07/13/19 17:00	0			0			0											
07/13/19 18:00	0			0			0											
07/13/19 19:00	0			0			0											
07/13/19 20:00	0			0			0											
07/13/19 21:00	0			0			0											
07/13/19 22:00	0			0			0											
07/13/19 23:00	0			0			0											
07/14/19 0:00	0			0			0											
07/14/19 1:00	0			0			0											
07/14/19 2:00	0			0			0											
07/14/19 3:00	0			0			0											
07/14/19 4:00	0			0			0											
07/14/19 5:00	0			0			0											
07/14/19 6:00	0			0			0											
07/14/19 7:00	0			0			0											
07/14/19 8:00	0			0			0											
07/14/19 9:00	0			0			0											
07/14/19 10:00	0			0			0											
07/14/19 11:00	0			0			0											
07/14/19 12:00	0			0			0											
07/14/19 13:00	0			0			0											
07/14/19 14:00	0			0			0											
07/14/19 15:00	0			0			0											
07/14/19 16:00	0			0			0											
07/14/19 17:00	0			0			0											
07/14/19 18:00	0			0			0											
07/14/19 19:00	0			0			0											
07/14/19 20:00	0			0			0											
07/14/19 21:00	0			0			0											
07/14/19 22:00	0			0			0											
07/14/19 23:00	0			0			0											
07/15/19 0:00	0			0			0											
07/15/19 1:00	0			0			0											
07/15/19 2:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/15/19 3:00	0			0			0											
07/15/19 4:00	0			0			0											
07/15/19 5:00	0			0			0											
07/15/19 6:00	0			0			0											
07/15/19 7:00	0			0			0											
07/15/19 8:00	0			0			0											
07/15/19 9:00	0			0			0											
07/15/19 10:00	0			0			0											
07/15/19 11:00	0			0			0											
07/15/19 12:00	0			0			0											
07/15/19 13:00	0			0			0											
07/15/19 14:00	0			0			0											
07/15/19 15:00	0			0			0											
07/15/19 16:00	0			0			0											
07/15/19 17:00	0			0			0											
07/15/19 18:00	0			0			0											
07/15/19 19:00	0			0			0											
07/15/19 20:00	0			0			0											
07/15/19 21:00	0			0			0											
07/15/19 22:00	0			0			0											
07/15/19 23:00	0			0			0											
07/16/19 0:00	0			0			0											
07/16/19 1:00	0			0			0											
07/16/19 2:00	0			0			0											
07/16/19 3:00	0			0			0											
07/16/19 4:00	0			0			0											
07/16/19 5:00	0			0			0											
07/16/19 6:00	0			0			0											
07/16/19 7:00	0			0			0											
07/16/19 8:00	0			0			0											
07/16/19 9:00	0			0			0											
07/16/19 10:00	0			0			0											
07/16/19 11:00	0			0			0											
07/16/19 12:00	0			0			0											
07/16/19 13:00	0			0			0											
07/16/19 14:00	0			0			0											
07/16/19 15:00	0			0			0											
07/16/19 16:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/16/19 17:00	0			0			0											
07/16/19 18:00	0			0			0											
07/16/19 19:00	0			0			0											
07/16/19 20:00	0			0			0											
07/16/19 21:00	0			0			0											
07/16/19 22:00	0			0			0											
07/16/19 23:00	0			0			0											
07/17/19 0:00	0			0			0											
07/17/19 1:00	0			0			0											
07/17/19 2:00	0			0			0											
07/17/19 3:00	0			0			0											
07/17/19 4:00	0			0			0											
07/17/19 5:00	0			0			0											
07/17/19 6:00	0			0			0											
07/17/19 7:00	0			0			0											
07/17/19 8:00	0			0			0											
07/17/19 9:00	0			0			0											
07/17/19 10:00	0			0			0											
07/17/19 11:00	0			0			0											
07/17/19 12:00	0			0			0											
07/17/19 13:00	0			0			0											
07/17/19 14:00	0			0			0											
07/17/19 15:00	0			0			0											
07/17/19 16:00	0			0			0											
07/17/19 17:00	0			0			0											
07/17/19 18:00	0			0			0											
07/17/19 19:00	0			0			0											
07/17/19 20:00	0			0			0											
07/17/19 21:00	0			0			0											
07/17/19 22:00	0			0			0											
07/17/19 23:00	0			0			0											
07/18/19 0:00	0			0			0											
07/18/19 1:00	0			0			0											
07/18/19 2:00	0			0			0											
07/18/19 3:00	0			0			0											
07/18/19 4:00	0			0			0											
07/18/19 5:00	0			0			0											
07/18/19 6:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/18/19 7:00	0			0			0											
07/18/19 8:00	0			0			0											
07/18/19 9:00	0			0			0											
07/18/19 10:00	0			0			0											
07/18/19 11:00	0			0			0											
07/18/19 12:00	0			0			0											
07/18/19 13:00	0			0			0											
07/18/19 14:00	0			0			0											
07/18/19 15:00	0			0			0											
07/18/19 16:00	0			0			0											
07/18/19 17:00	0			0			0											
07/18/19 18:00	0			0			0											
07/18/19 19:00	0			0			0											
07/18/19 20:00	0			0			0											
07/18/19 21:00	0			0			0											
07/18/19 22:00	0			0			0											
07/18/19 23:00	0			0			0											
07/19/19 0:00	0			0			0											
07/19/19 1:00	0			0			0											
07/19/19 2:00	0			0			0											
07/19/19 3:00	0			0			0											
07/19/19 4:00	0			0			0											
07/19/19 5:00	0			0			0											
07/19/19 6:00	0			0			0											
07/19/19 7:00	0			0			0											
07/19/19 8:00	0			0			0											
07/19/19 9:00	0			0			0											
07/19/19 10:00	0			0			0											
07/19/19 11:00	0			0			0											
07/19/19 12:00	0			0			0											
07/19/19 13:00	0			0			0											
07/19/19 14:00	0			0			0											
07/19/19 15:00	0			0			0											
07/19/19 16:00	0			0			0											
07/19/19 17:00	0			0			0											
07/19/19 18:00	0			0			0											
07/19/19 19:00	0			0			0											
07/19/19 20:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/19/19 21:00	0			0			0											
07/19/19 22:00	0			0			0											
07/19/19 23:00	0			0			0											
07/20/19 0:00	0			0			0											
07/20/19 1:00	0			0			0											
07/20/19 2:00	0			0			0											
07/20/19 3:00	0			0			0											
07/20/19 4:00	0			0			0											
07/20/19 5:00	0			0			0											
07/20/19 6:00	0			0			0											
07/20/19 7:00	0			0			0											
07/20/19 8:00	0			0			0											
07/20/19 9:00	0			0			0											
07/20/19 10:00	0			0			0											
07/20/19 11:00	0			0			0											
07/20/19 12:00	0			0			0											
07/20/19 13:00	0			0			0											
07/20/19 14:00	0			0			0											
07/20/19 15:00	0			0			0											
07/20/19 16:00	0			0			0											
07/20/19 17:00	0			0			0											
07/20/19 18:00	0			0			0											
07/20/19 19:00	0			0			0											
07/20/19 20:00	0			0			0											
07/20/19 21:00	0			0			0											
07/20/19 22:00	0			0			0											
07/20/19 23:00	0			0			0											
07/21/19 0:00	0			0			0											
07/21/19 1:00	0			0			0											
07/21/19 2:00	0			0			0											
07/21/19 3:00	0			0			0											
07/21/19 4:00	0			0			0											
07/21/19 5:00	0			0			0											
07/21/19 6:00	0			0			0											
07/21/19 7:00	0			0			0											
07/21/19 8:00	0			0			0											
07/21/19 9:00	0			0			0											
07/21/19 10:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/21/19 11:00	0			0			0											
07/21/19 12:00	0			0			0											
07/21/19 13:00	0			0			0											
07/21/19 14:00	0			0			0											
07/21/19 15:00	0			0			0											
07/21/19 16:00	0			0			0											
07/21/19 17:00	0			0			0											
07/21/19 18:00	0			0			0											
07/21/19 19:00	0			0			0											
07/21/19 20:00	0			0			0											
07/21/19 21:00	0			0			0											
07/21/19 22:00	0			0			0											
07/21/19 23:00	0			0			0											
07/22/19 0:00	0			0			0											
07/22/19 1:00	0			0			0											
07/22/19 2:00	0			0			0											
07/22/19 3:00	0			0			0											
07/22/19 4:00	0			0			0											
07/22/19 5:00	0			0			0											
07/22/19 6:00	0			0			0											
07/22/19 7:00	0			0			0											
07/22/19 8:00	0			0			0											
07/22/19 9:00	0			0			0											
07/22/19 10:00	0			0			0											
07/22/19 11:00	0			0			0											
07/22/19 12:00	1			0			0											
07/22/19 13:00	1			0			7											
07/22/19 14:00	1			0			20											
07/22/19 15:00	1			0			34											
07/22/19 16:00	1			0			41											
07/22/19 17:00	1			0			41											
07/22/19 18:00	1			0			42											
07/22/19 19:00	1			0			42											
07/22/19 20:00	1			0			43											
07/22/19 21:00	1			0			42											
07/22/19 22:00	1			0			42											
07/22/19 23:00	1			0			42											
07/23/19 0:00	1			0			42											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/23/19 1:00	1			0			42											
07/23/19 2:00	1			0			42											
07/23/19 3:00	1			0			42											
07/23/19 4:00	1			0			42											
07/23/19 5:00	1			3			42											
07/23/19 6:00	1			16			42											
07/23/19 7:00	1			32			44											
07/23/19 8:00	1			47			48											
07/23/19 9:00	1			52			53											
07/23/19 10:00	1			56			57											
07/23/19 11:00	1			61			59											
07/23/19 12:00	1			67			42											
07/23/19 13:00	1			73			22											
07/23/19 14:00	1			76			2											
07/23/19 15:00	1			76			0											
07/23/19 16:00	1			76			0											
07/23/19 17:00	1			76			0											
07/23/19 18:00	1			76			0											
07/23/19 19:00	1			77			0											
07/23/19 20:00	1			77			0											
07/23/19 21:00	1			77			0											
07/23/19 22:00	1			78			0											
07/23/19 23:00	1			78			0											
07/24/19 0:00	1			78			0											
07/24/19 1:00	1			78			0											
07/24/19 2:00	1			78			0											
07/24/19 3:00	1			78			0											
07/24/19 4:00	1			78			0											
07/24/19 5:00	1			78			0											
07/24/19 6:00	1			78			0											
07/24/19 7:00	1			77			0											
07/24/19 8:00	1			77			0											
07/24/19 9:00	1			77			0											
07/24/19 10:00	1			77			0											
07/24/19 11:00	1			76			0											
07/24/19 12:00	1			76			0											
07/24/19 13:00	1			76			0											
07/24/19 14:00	1			76			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/24/19 15:00	1			76			0											
07/24/19 16:00	1			76			0											
07/24/19 17:00	1			76			0											
07/24/19 18:00	1			76			0											
07/24/19 19:00	1			76			0											
07/24/19 20:00	1			76			0											
07/24/19 21:00	1			76			0											
07/24/19 22:00	1			76			0											
07/24/19 23:00	1			69			0											
07/25/19 0:00	1			63			0											
07/25/19 1:00	1			58			0											
07/25/19 2:00	1			58			0											
07/25/19 3:00	1			56			0											
07/25/19 4:00	1			55			0											
07/25/19 5:00	1			54			0											
07/25/19 6:00	1			55			0											
07/25/19 7:00	1			56			0											
07/25/19 8:00	1			63			0											
07/25/19 9:00	1			70			0											
07/25/19 10:00	1			76			0											
07/25/19 11:00	1			76			0											
07/25/19 12:00	1			76			0											
07/25/19 13:00	1			76			0											
07/25/19 14:00	1			76			0											
07/25/19 15:00	1			76			0											
07/25/19 16:00	1			74			0											
07/25/19 17:00	1			71			0											
07/25/19 18:00	1			66			0											
07/25/19 19:00	1			65			0											
07/25/19 20:00	1			67			0											
07/25/19 21:00	1			69			0											
07/25/19 22:00	1			66			0											
07/25/19 23:00	1			61			0											
07/26/19 0:00	1			59			0											
07/26/19 1:00	1			59			0											
07/26/19 2:00	1			58			0											
07/26/19 3:00	1			56			0											
07/26/19 4:00	1			56			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/26/19 5:00	1			55			0											
07/26/19 6:00	1			56			0											
07/26/19 7:00	1			58			0											
07/26/19 8:00	1			62			0											
07/26/19 9:00	1			62			0											
07/26/19 10:00	1			64			0											
07/26/19 11:00	1			68			0											
07/26/19 12:00	1			73			0											
07/26/19 13:00	1			75			0											
07/26/19 14:00	1			73			0											
07/26/19 15:00	1			73			0											
07/26/19 16:00	1			75			0											
07/26/19 17:00	1			76			0											
07/26/19 18:00	1			76			0											
07/26/19 19:00	1			74			0											
07/26/19 20:00	1			73			0											
07/26/19 21:00	1			73			0											
07/26/19 22:00	1			72			0											
07/26/19 23:00	1			69			0											
07/27/19 0:00	1			64			0											
07/27/19 1:00	1			62			0											
07/27/19 2:00	1			58			0											
07/27/19 3:00	1			53			0											
07/27/19 4:00	1			47			0											
07/27/19 5:00	1			43			0											
07/27/19 6:00	1			42			0											
07/27/19 7:00	1			45			0											
07/27/19 8:00	1			48			0											
07/27/19 9:00	1			50			0											
07/27/19 10:00	1			50			0											
07/27/19 11:00	1			52			0											
07/27/19 12:00	1			55			0											
07/27/19 13:00	1			56			0											
07/27/19 14:00	1			55			0											
07/27/19 15:00	1			54			0											
07/27/19 16:00	1			60			0											
07/27/19 17:00	1			67			0											
07/27/19 18:00	1			74			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/27/19 19:00	1			74			0											
07/27/19 20:00	1			74			0											
07/27/19 21:00	1			74			0											
07/27/19 22:00	1			73			3											
07/27/19 23:00	1			64			17											
07/28/19 0:00	1			54			32											
07/28/19 1:00	1			45			44											
07/28/19 2:00	1			42			43											
07/28/19 3:00	1			40			41											
07/28/19 4:00	1			39			40											
07/28/19 5:00	1			40			41											
07/28/19 6:00	1			41			42											
07/28/19 7:00	1			42			43											
07/28/19 8:00	1			44			45											
07/28/19 9:00	1			46			47											
07/28/19 10:00	1			50			51											
07/28/19 11:00	1			54			55											
07/28/19 12:00	1			61			63											
07/28/19 13:00	1			67			69											
07/28/19 14:00	1			73			75											
07/28/19 15:00	1			75			77											
07/28/19 16:00	1			75			78											
07/28/19 17:00	1			75			78											
07/28/19 18:00	1			75			77											
07/28/19 19:00	1			72			74											
07/28/19 20:00	1			72			74											
07/28/19 21:00	1			71			74											
07/28/19 22:00	1			71			74											
07/28/19 23:00	1			66			68											
07/29/19 0:00	1			60			62											
07/29/19 1:00	1			56			57											
07/29/19 2:00	1			54			55											
07/29/19 3:00	1			53			55											
07/29/19 4:00	1			52			54											
07/29/19 5:00	1			53			55											
07/29/19 6:00	1			58			60											
07/29/19 7:00	1			64			66											
07/29/19 8:00	1			64			65											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/29/19 9:00	1			60			61											
07/29/19 10:00	1			59			61											
07/29/19 11:00	1			65			66											
07/29/19 12:00	1			66			67											
07/29/19 13:00	1			68			69											
07/29/19 14:00	1			69			71											
07/29/19 15:00	1			75			77											
07/29/19 16:00	1			75			77											
07/29/19 17:00	1			75			77											
07/29/19 18:00	1			74			76											
07/29/19 19:00	1			72			74											
07/29/19 20:00	1			72			74											
07/29/19 21:00	1			70			72											
07/29/19 22:00	1			68			69											
07/29/19 23:00	1			56			57											
07/30/19 0:00	1			44			46											
07/30/19 1:00	1			37			39											
07/30/19 2:00	1			36			39											
07/30/19 3:00	1			36			39											
07/30/19 4:00	1			36			39											
07/30/19 5:00	1			39			42											
07/30/19 6:00	1			42			45											
07/30/19 7:00	1			46			51											
07/30/19 8:00	1			48			54											
07/30/19 9:00	1			48			55											
07/30/19 10:00	1			48			55											
07/30/19 11:00	1			46			54											
07/30/19 12:00	1			44			53											
07/30/19 13:00	1			41			48											
07/30/19 14:00	1			40			45											
07/30/19 15:00	1			39			42											
07/30/19 16:00	1			45			48											
07/30/19 17:00	1			51			54											
07/30/19 18:00	1			55			57											
07/30/19 19:00	1			51			53											
07/30/19 20:00	1			47			50											
07/30/19 21:00	1			45			49											
07/30/19 22:00	1			46			50											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/30/19 23:00	1			44			47											
07/31/19 0:00	1			43			44											
07/31/19 1:00	1			39			40											
07/31/19 2:00	1			38			39											
07/31/19 3:00	1			37			38											
07/31/19 4:00	1			37			38											
07/31/19 5:00	1			37			38											
07/31/19 6:00	1			37			38											
07/31/19 7:00	1			37			39											
07/31/19 8:00	1			39			41											
07/31/19 9:00	1			39			42											
07/31/19 10:00	1			38			41											
07/31/19 11:00	1			36			39											
07/31/19 12:00	1			39			41											
07/31/19 13:00	1			45			47											
07/31/19 14:00	1			56			58											
07/31/19 15:00	1			64			66											
07/31/19 16:00	1			70			72											
07/31/19 17:00	1			69			71											
07/31/19 18:00	1			69			71											
07/31/19 19:00	1			69			71											
07/31/19 20:00	1			65			66											
07/31/19 21:00	1			58			60											
07/31/19 22:00	1			48			49											
07/31/19 23:00	1			42			44											
08/01/19 0:00	1			38			39											
08/01/19 1:00	1			37			39											
08/01/19 2:00	1			37			39											
08/01/19 3:00	1			36			39											
08/01/19 4:00	1			36			39											
08/01/19 5:00	1			36			39											
08/01/19 6:00	1			36			40											
08/01/19 7:00	1			37			41											
08/01/19 8:00	1			37			41											
08/01/19 9:00	1			38			43											
08/01/19 10:00	1			37			43											
08/01/19 11:00	1			37			44											
08/01/19 12:00	1			43			48											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/01/19 13:00	1			50			54											
08/01/19 14:00	1			57			59											
08/01/19 15:00	1			58			59											
08/01/19 16:00	1			59			61											
08/01/19 17:00	1			61			63											
08/01/19 18:00	1			65			67											
08/01/19 19:00	1			64			66											
08/01/19 20:00	1			56			57											
08/01/19 21:00	1			45			46											
08/01/19 22:00	1			38			39											
08/01/19 23:00	1			37			38											
08/02/19 0:00	1			37			38											
08/02/19 1:00	1			37			38											
08/02/19 2:00	1			37			38											
08/02/19 3:00	1			37			38											
08/02/19 4:00	1			36			38											
08/02/19 5:00	1			36			38											
08/02/19 6:00	1			36			38											
08/02/19 7:00	1			36			39											
08/02/19 8:00	1			36			39											
08/02/19 9:00	1			36			39											
08/02/19 10:00	1			36			39											
08/02/19 11:00	1			36			39											
08/02/19 12:00	1			38			41											
08/02/19 13:00	1			46			48											
08/02/19 14:00	1			54			56											
08/02/19 15:00	1			64			66											
08/02/19 16:00	1			68			70											
08/02/19 17:00	1			73			75											
08/02/19 18:00	1			71			73											
08/02/19 19:00	1			67			69											
08/02/19 20:00	1			58			59											
08/02/19 21:00	1			48			50											
08/02/19 22:00	1			41			42											
08/02/19 23:00	1			38			40											
08/03/19 0:00	1			38			40											
08/03/19 1:00	1			37			39											
08/03/19 2:00	1			37			39											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/03/19 3:00	1			36			38											
08/03/19 4:00	1			36			38											
08/03/19 5:00	1			36			38											
08/03/19 6:00	1			36			38											
08/03/19 7:00	1			37			39											
08/03/19 8:00	1			37			39											
08/03/19 9:00	1			38			40											
08/03/19 10:00	1			38			41											
08/03/19 11:00	1			39			42											
08/03/19 12:00	1			41			44											
08/03/19 13:00	1			48			51											
08/03/19 14:00	1			56			58											
08/03/19 15:00	1			66			68											
08/03/19 16:00	1			71			73											
08/03/19 17:00	1			74			76											
08/03/19 18:00	1			74			76											
08/03/19 19:00	1			73			75											
08/03/19 20:00	1			70			71											
08/03/19 21:00	1			62			63											
08/03/19 22:00	1			53			54											
08/03/19 23:00	1			45			46											
08/04/19 0:00	1			41			42											
08/04/19 1:00	1			38			40											
08/04/19 2:00	1			38			40											
08/04/19 3:00	1			38			40											
08/04/19 4:00	1			37			40											
08/04/19 5:00	1			37			40											
08/04/19 6:00	1			36			40											
08/04/19 7:00	1			36			39											
08/04/19 8:00	1			36			39											
08/04/19 9:00	1			37			40											
08/04/19 10:00	1			37			40											
08/04/19 11:00	1			39			42											
08/04/19 12:00	1			46			49											
08/04/19 13:00	1			57			60											
08/04/19 14:00	1			67			69											
08/04/19 15:00	1			71			73											
08/04/19 16:00	1			70			72											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/04/19 17:00	1			71			73											
08/04/19 18:00	1			72			74											
08/04/19 19:00	1			74			76											
08/04/19 20:00	1			74			76											
08/04/19 21:00	1			70			73											
08/04/19 22:00	1			64			67											
08/04/19 23:00	1			54			56											
08/05/19 0:00	1			45			46											
08/05/19 1:00	1			37			38											
08/05/19 2:00	1			36			37											
08/05/19 3:00	1			36			37											
08/05/19 4:00	1			36			37											
08/05/19 5:00	1			36			37											
08/05/19 6:00	1			37			38											
08/05/19 7:00	1			37			39											
08/05/19 8:00	1			38			40											
08/05/19 9:00	1			38			40											
08/05/19 10:00	1			38			41											
08/05/19 11:00	1			39			42											
08/05/19 12:00	1			43			47											
08/05/19 13:00	1			49			52											
08/05/19 14:00	1			54			57											
08/05/19 15:00	1			61			63											
08/05/19 16:00	1			66			68											
08/05/19 17:00	1			73			75											
08/05/19 18:00	1			75			77											
08/05/19 19:00	1			74			77											
08/05/19 20:00	1			69			71											
08/05/19 21:00	1			61			63											
08/05/19 22:00	1			52			53											
08/05/19 23:00	1			44			45											
08/06/19 0:00	1			38			39											
08/06/19 1:00	1			36			37											
08/06/19 2:00	1			36			37											
08/06/19 3:00	1			36			37											
08/06/19 4:00	1			37			38											
08/06/19 5:00	1			38			39											
08/06/19 6:00	1			39			41											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/06/19 7:00	1			40			42											
08/06/19 8:00	1			40			42											
08/06/19 9:00	1			39			41											
08/06/19 10:00	1			40			42											
08/06/19 11:00	1			44			46											
08/06/19 12:00	1			50			52											
08/06/19 13:00	1			56			58											
08/06/19 14:00	1			64			65											
08/06/19 15:00	1			69			71											
08/06/19 16:00	1			74			76											
08/06/19 17:00	1			74			76											
08/06/19 18:00	1			74			76											
08/06/19 19:00	1			70			72											
08/06/19 20:00	1			67			69											
08/06/19 21:00	1			62			64											
08/06/19 22:00	1			55			57											
08/06/19 23:00	1			46			47											
08/07/19 0:00	1			39			40											
08/07/19 1:00	1			36			37											
08/07/19 2:00	1			36			37											
08/07/19 3:00	1			36			37											
08/07/19 4:00	1			36			37											
08/07/19 5:00	1			36			37											
08/07/19 6:00	1			37			38											
08/07/19 7:00	1			37			39											
08/07/19 8:00	1			38			41											
08/07/19 9:00	1			39			42											
08/07/19 10:00	1			40			44											
08/07/19 11:00	1			41			44											
08/07/19 12:00	1			45			47											
08/07/19 13:00	1			51			53											
08/07/19 14:00	1			60			62											
08/07/19 15:00	1			67			69											
08/07/19 16:00	1			71			73											
08/07/19 17:00	1			74			76											
08/07/19 18:00	1			74			76											
08/07/19 19:00	1			70			72											
08/07/19 20:00	1			61			63											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/07/19 21:00	1			52			53											
08/07/19 22:00	1			43			45											
08/07/19 23:00	1			41			43											
08/08/19 0:00	1			38			40											
08/08/19 1:00	1			38			40											
08/08/19 2:00	1			36			38											
08/08/19 3:00	1			36			37											
08/08/19 4:00	1			35			36											
08/08/19 5:00	1			23			25											
08/08/19 6:00	0			11			13											
08/08/19 7:00	0			0			1											
08/08/19 8:00	0			0			0											
08/08/19 9:00	0			0			0											
08/08/19 10:00	0			0			0											
08/08/19 11:00	0			0			0											
08/08/19 12:00	0			0			0											
08/08/19 13:00	0			0			0											
08/08/19 14:00	0			0			0											
08/08/19 15:00	0			0			0											
08/08/19 16:00	0			0			0											
08/08/19 17:00	0			0			0											
08/08/19 18:00	0			0			0											
08/08/19 19:00	0			0			0											
08/08/19 20:00	0			0			0											
08/08/19 21:00	0			0			0											
08/08/19 22:00	0			0			0											
08/08/19 23:00	0			0			0											
08/09/19 0:00	0			0			0											
08/09/19 1:00	0			0			0											
08/09/19 2:00	0			0			0											
08/09/19 3:00	0			0			0											
08/09/19 4:00	0			0			0											
08/09/19 5:00	0			0			0											
08/09/19 6:00	0			0			0											
08/09/19 7:00	0			0			0											
08/09/19 8:00	0			0			0											
08/09/19 9:00	0			0			0											
08/09/19 10:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/09/19 11:00	0			0			0											
08/09/19 12:00	0			0			0											
08/09/19 13:00	0			0			0											
08/09/19 14:00	0			0			0											
08/09/19 15:00	0			0			0											
08/09/19 16:00	0			0			0											
08/09/19 17:00	0			0			0											
08/09/19 18:00	0			0			0											
08/09/19 19:00	0			0			0											
08/09/19 20:00	0			0			0											
08/09/19 21:00	0			0			0											
08/09/19 22:00	0			0			0											
08/09/19 23:00	0			0			0											
08/10/19 0:00	0			0			0											
08/10/19 1:00	0			0			0											
08/10/19 2:00	0			0			0											
08/10/19 3:00	0			0			0											
08/10/19 4:00	0			0			0											
08/10/19 5:00	0			0			0											
08/10/19 6:00	0			0			0											
08/10/19 7:00	0			0			0											
08/10/19 8:00	0			0			0											
08/10/19 9:00	0			0			0											
08/10/19 10:00	0			0			0											
08/10/19 11:00	0			0			0											
08/10/19 12:00	0			0			0											
08/10/19 13:00	0			0			0											
08/10/19 14:00	0			0			0											
08/10/19 15:00	0			0			0											
08/10/19 16:00	0			0			0											
08/10/19 17:00	0			0			0											
08/10/19 18:00	0			0			0											
08/10/19 19:00	0			0			0											
08/10/19 20:00	0			0			0											
08/10/19 21:00	0			0			0											
08/10/19 22:00	0			0			0											
08/10/19 23:00	0			0			0											
08/11/19 0:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/11/19 1:00	0			0			0											
08/11/19 2:00	0			0			0											
08/11/19 3:00	0			0			0											
08/11/19 4:00	0			0			0											
08/11/19 5:00	0			0			0											
08/11/19 6:00	0			0			0											
08/11/19 7:00	0			0			0											
08/11/19 8:00	0			0			0											
08/11/19 9:00	0			0			0											
08/11/19 10:00	0			0			0											
08/11/19 11:00	0			0			0											
08/11/19 12:00	0			0			0											
08/11/19 13:00	0			0			0											
08/11/19 14:00	0			0			0											
08/11/19 15:00	0			0			0											
08/11/19 16:00	0			0			0											
08/11/19 17:00	0			0			0											
08/11/19 18:00	0			0			0											
08/11/19 19:00	0			0			0											
08/11/19 20:00	0			0			0											
08/11/19 21:00	0			0			0											
08/11/19 22:00	0			0			0											
08/11/19 23:00	0			0			0											
08/12/19 0:00	0			0			0											
08/12/19 1:00	0			0			0											
08/12/19 2:00	0			0			0											
08/12/19 3:00	0			0			0											
08/12/19 4:00	0			0			0											
08/12/19 5:00	0			0			0											
08/12/19 6:00	0			0			0											
08/12/19 7:00	0			0			0											
08/12/19 8:00	0			0			0											
08/12/19 9:00	0			0			0											
08/12/19 10:00	0			0			0											
08/12/19 11:00	0			0			0											
08/12/19 12:00	0			0			0											
08/12/19 13:00	0			0			0											
08/12/19 14:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/12/19 15:00	0			0			0											
08/12/19 16:00	0			0			0											
08/12/19 17:00	0			0			0											
08/12/19 18:00	0			0			0											
08/12/19 19:00	0			0			0											
08/12/19 20:00	0			0			0											
08/12/19 21:00	0			0			0											
08/12/19 22:00	0			0			0											
08/12/19 23:00	0			0			0											
08/13/19 0:00	0			0			0											
08/13/19 1:00	0			0			0											
08/13/19 2:00	0			0			0											
08/13/19 3:00	0			0			0											
08/13/19 4:00	0			0			0											
08/13/19 5:00	0			0			0											
08/13/19 6:00	1			2			0											
08/13/19 7:00	1			16			0											
08/13/19 8:00	1			29			0											
08/13/19 9:00	1			42			0											
08/13/19 10:00	1			44			0											
08/13/19 11:00	1			49			0											
08/13/19 12:00	1			49			0											
08/13/19 13:00	1			49			0											
08/13/19 14:00	1			47			0											
08/13/19 15:00	1			55			0											
08/13/19 16:00	1			65			0											
08/13/19 17:00	1			74			0											
08/13/19 18:00	1			73			0											
08/13/19 19:00	1			73			0											
08/13/19 20:00	1			73			0											
08/13/19 21:00	1			73			0											
08/13/19 22:00	1			68			0											
08/13/19 23:00	1			67			0											
08/14/19 0:00	1			66			0											
08/14/19 1:00	1			67			0											
08/14/19 2:00	1			64			0											
08/14/19 3:00	1			62			0											
08/14/19 4:00	1			65			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/14/19 5:00	1			70			0											
08/14/19 6:00	1			73			3											
08/14/19 7:00	1			63			17											
08/14/19 8:00	1			50			30											
08/14/19 9:00	1			38			39											
08/14/19 10:00	1			36			37											
08/14/19 11:00	1			36			37											
08/14/19 12:00	1			36			37											
08/14/19 13:00	1			43			44											
08/14/19 14:00	1			51			52											
08/14/19 15:00	1			63			65											
08/14/19 16:00	1			69			71											
08/14/19 17:00	1			74			77											
08/14/19 18:00	1			72			75											
08/14/19 19:00	1			71			74											
08/14/19 20:00	1			69			72											
08/14/19 21:00	1			64			66											
08/14/19 22:00	1			57			60											
08/14/19 23:00	1			47			50											
08/15/19 0:00	1			41			44											
08/15/19 1:00	1			36			37											
08/15/19 2:00	1			36			37											
08/15/19 3:00	1			36			37											
08/15/19 4:00	1			36			37											
08/15/19 5:00	1			36			37											
08/15/19 6:00	1			39			41											
08/15/19 7:00	1			43			44											
08/15/19 8:00	1			47			49											
08/15/19 9:00	1			48			51											
08/15/19 10:00	1			49			52											
08/15/19 11:00	1			48			51											
08/15/19 12:00	1			49			51											
08/15/19 13:00	1			51			53											
08/15/19 14:00	1			60			62											
08/15/19 15:00	1			67			69											
08/15/19 16:00	1			74			76											
08/15/19 17:00	1			74			76											
08/15/19 18:00	1			73			76											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/15/19 19:00	1			71			73											
08/15/19 20:00	1			67			70											
08/15/19 21:00	1			63			66											
08/15/19 22:00	1			60			63											
08/15/19 23:00	1			51			53											
08/16/19 0:00	1			44			45											
08/16/19 1:00	1			36			38											
08/16/19 2:00	1			36			37											
08/16/19 3:00	1			36			37											
08/16/19 4:00	1			36			37											
08/16/19 5:00	1			36			37											
08/16/19 6:00	1			36			37											
08/16/19 7:00	1			38			39											
08/16/19 8:00	1			40			42											
08/16/19 9:00	1			43			45											
08/16/19 10:00	1			47			49											
08/16/19 11:00	1			50			52											
08/16/19 12:00	1			56			58											
08/16/19 13:00	1			60			62											
08/16/19 14:00	1			66			69											
08/16/19 15:00	1			70			73											
08/16/19 16:00	1			71			73											
08/16/19 17:00	1			70			73											
08/16/19 18:00	1			68			71											
08/16/19 19:00	1			68			71											
08/16/19 20:00	1			69			71											
08/16/19 21:00	1			68			71											
08/16/19 22:00	1			67			69											
08/16/19 23:00	1			69			46											
08/17/19 0:00	1			71			24											
08/17/19 1:00	1			71			2											
08/17/19 2:00	1			64			0											
08/17/19 3:00	1			55			0											
08/17/19 4:00	1			49			0											
08/17/19 5:00	1			46			0											
08/17/19 6:00	1			44			0											
08/17/19 7:00	1			44			0											
08/17/19 8:00	1			45			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/17/19 9:00	1			46			0											
08/17/19 10:00	1			47			0											
08/17/19 11:00	1			46			0											
08/17/19 12:00	1			44			0											
08/17/19 13:00	1			40			0											
08/17/19 14:00	1			39			0											
08/17/19 15:00	1			41			0											
08/17/19 16:00	1			48			0											
08/17/19 17:00	1			58			0											
08/17/19 18:00	1			69			0											
08/17/19 19:00	1			72			0											
08/17/19 20:00	1			69			0											
08/17/19 21:00	1			67			0											
08/17/19 22:00	1			64			0											
08/17/19 23:00	1			44			0											
08/18/19 0:00	0			22			0											
08/18/19 1:00	0			3			0											
08/18/19 2:00	0			0			0											
08/18/19 3:00	0			0			0											
08/18/19 4:00	0			0			0											
08/18/19 5:00	0			0			0											
08/18/19 6:00	0			0			0											
08/18/19 7:00	0			0			0											
08/18/19 8:00	0			0			0											
08/18/19 9:00	0			0			0											
08/18/19 10:00	0			0			0											
08/18/19 11:00	0			0			0											
08/18/19 12:00	0			0			0											
08/18/19 13:00	0			0			0											
08/18/19 14:00	0			0			0											
08/18/19 15:00	0			0			0											
08/18/19 16:00	0			0			0											
08/18/19 17:00	0			0			0											
08/18/19 18:00	0			0			0											
08/18/19 19:00	0			0			0											
08/18/19 20:00	0			0			0											
08/18/19 21:00	0			0			0											
08/18/19 22:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/18/19 23:00	0			0			0											
08/19/19 0:00	0			0			0											
08/19/19 1:00	0			0			0											
08/19/19 2:00	0			0			0											
08/19/19 3:00	0			0			0											
08/19/19 4:00	0			0			0											
08/19/19 5:00	0			0			0											
08/19/19 6:00	0			0			0											
08/19/19 7:00	0			0			0											
08/19/19 8:00	0			0			0											
08/19/19 9:00	0			0			0											
08/19/19 10:00	0			0			0											
08/19/19 11:00	0			0			0											
08/19/19 12:00	0			0			0											
08/19/19 13:00	0			0			0											
08/19/19 14:00	0			0			0											
08/19/19 15:00	0			0			0											
08/19/19 16:00	0			0			0											
08/19/19 17:00	0			0			0											
08/19/19 18:00	0			0			0											
08/19/19 19:00	0			0			0											
08/19/19 20:00	0			0			0											
08/19/19 21:00	0			0			0											
08/19/19 22:00	0			0			0											
08/19/19 23:00	0			0			0											
08/20/19 0:00	0			0			0											
08/20/19 1:00	0			0			0											
08/20/19 2:00	0			0			0											
08/20/19 3:00	0			0			0											
08/20/19 4:00	0			0			0											
08/20/19 5:00	0			0			0											
08/20/19 6:00	0			0			0											
08/20/19 7:00	0			0			0											
08/20/19 8:00	0			0			0											
08/20/19 9:00	0			0			0											
08/20/19 10:00	0			0			0											
08/20/19 11:00	0			0			0											
08/20/19 12:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/20/19 13:00	0			0			0											
08/20/19 14:00	0			0			0											
08/20/19 15:00	0			0			0											
08/20/19 16:00	0			0			0											
08/20/19 17:00	0			0			0											
08/20/19 18:00	0			0			0											
08/20/19 19:00	0			0			0											
08/20/19 20:00	0			0			0											
08/20/19 21:00	0			0			0											
08/20/19 22:00	0			0			0											
08/20/19 23:00	0			0			0											
08/21/19 0:00	0			0			0											
08/21/19 1:00	0			0			0											
08/21/19 2:00	0			0			0											
08/21/19 3:00	0			0			0											
08/21/19 4:00	0			0			0											
08/21/19 5:00	0			0			0											
08/21/19 6:00	0			0			0											
08/21/19 7:00	0			0			0											
08/21/19 8:00	0			0			0											
08/21/19 9:00	0			0			0											
08/21/19 10:00	0			0			0											
08/21/19 11:00	0			0			0											
08/21/19 12:00	0			0			0											
08/21/19 13:00	0			0			0											
08/21/19 14:00	0			0			0											
08/21/19 15:00	0			0			0											
08/21/19 16:00	0			0			0											
08/21/19 17:00	0			0			0											
08/21/19 18:00	0			0			0											
08/21/19 19:00	0			0			0											
08/21/19 20:00	0			0			0											
08/21/19 21:00	0			0			0											
08/21/19 22:00	0			0			0											
08/21/19 23:00	0			0			0											
08/22/19 0:00	0			0			0											
08/22/19 1:00	0			0			0											
08/22/19 2:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/22/19 3:00	0			0			0											
08/22/19 4:00	0			0			0											
08/22/19 5:00	0			0			0											
08/22/19 6:00	0			0			0											
08/22/19 7:00	0			0			0											
08/22/19 8:00	0			0			0											
08/22/19 9:00	0			0			0											
08/22/19 10:00	0			0			0											
08/22/19 11:00	0			0			0											
08/22/19 12:00	0			0			0											
08/22/19 13:00	0			0			0											
08/22/19 14:00	0			0			0											
08/22/19 15:00	0			0			0											
08/22/19 16:00	0			0			0											
08/22/19 17:00	0			0			0											
08/22/19 18:00	0			0			0											
08/22/19 19:00	0			0			0											
08/22/19 20:00	0			0			0											
08/22/19 21:00	0			0			0											
08/22/19 22:00	0			0			0											
08/22/19 23:00	0			0			0											
08/23/19 0:00	0			0			0											
08/23/19 1:00	0			0			0											
08/23/19 2:00	0			0			0											
08/23/19 3:00	0			0			0											
08/23/19 4:00	0			0			0											
08/23/19 5:00	0			0			0											
08/23/19 6:00	0			0			0											
08/23/19 7:00	0			0			0											
08/23/19 8:00	0			0			0											
08/23/19 9:00	0			0			0											
08/23/19 10:00	0			0			0											
08/23/19 11:00	0			0			0											
08/23/19 12:00	0			0			0											
08/23/19 13:00	0			0			0											
08/23/19 14:00	0			0			0											
08/23/19 15:00	0			0			0											
08/23/19 16:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/23/19 17:00	0			0			0											
08/23/19 18:00	0			0			0											
08/23/19 19:00	0			0			0											
08/23/19 20:00	0			0			0											
08/23/19 21:00	0			0			0											
08/23/19 22:00	0			0			0											
08/23/19 23:00	0			0			0											
08/24/19 0:00	0			0			0											
08/24/19 1:00	0			0			0											
08/24/19 2:00	0			0			0											
08/24/19 3:00	0			0			0											
08/24/19 4:00	0			0			0											
08/24/19 5:00	0			0			0											
08/24/19 6:00	0			0			0											
08/24/19 7:00	0			0			0											
08/24/19 8:00	0			0			0											
08/24/19 9:00	0			0			0											
08/24/19 10:00	0			0			0											
08/24/19 11:00	0			0			0											
08/24/19 12:00	0			0			0											
08/24/19 13:00	0			0			0											
08/24/19 14:00	0			0			0											
08/24/19 15:00	0			0			0											
08/24/19 16:00	0			0			0											
08/24/19 17:00	0			0			0											
08/24/19 18:00	0			0			0											
08/24/19 19:00	0			0			0											
08/24/19 20:00	0			0			0											
08/24/19 21:00	0			0			0											
08/24/19 22:00	0			0			0											
08/24/19 23:00	0			0			0											
08/25/19 0:00	0			0			0											
08/25/19 1:00	0			0			0											
08/25/19 2:00	0			0			0											
08/25/19 3:00	0			0			0											
08/25/19 4:00	0			0			0											
08/25/19 5:00	0			0			0											
08/25/19 6:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
08/25/19 7:00	1			0			3											
08/25/19 8:00	1			0			16											
08/25/19 9:00	1			0			29											
08/25/19 10:00	1			0			44											
08/25/19 11:00	1			0			54											
08/25/19 12:00	1			0			65											
08/25/19 13:00	1			0			73											
08/25/19 14:00	1			0			74											
08/25/19 15:00	1			0			74											
08/25/19 16:00	1			0			70											
08/25/19 17:00	1			0			66											
08/25/19 18:00	1			0			62											
08/25/19 19:00	1			0			62											
08/25/19 20:00	1			0			64											
08/25/19 21:00	1			0			62											
08/25/19 22:00	1			0			60											
08/25/19 23:00	1			0			52											
08/26/19 0:00	1			0			46											
08/26/19 1:00	1			0			40											
08/26/19 2:00	1			0			37											
08/26/19 3:00	1			0			37											
08/26/19 4:00	1			0			37											
08/26/19 5:00	1			0			37											
08/26/19 6:00	1			0			38											
08/26/19 7:00	1			0			39											
08/26/19 8:00	1			0			43											
08/26/19 9:00	1			0			49											
08/26/19 10:00	1			0			59											
08/26/19 11:00	1			0			67											
08/26/19 12:00	1			0			72											
08/26/19 13:00	1			0			71											
08/26/19 14:00	1			0			68											
08/26/19 15:00	1			0			61											
08/26/19 16:00	1			0			59											
08/26/19 17:00	1			0			59											
08/26/19 18:00	1			0			62											
08/26/19 19:00	1			0			61											
08/26/19 20:00	1			0			62											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/26/19 21:00	1			0			57											
08/26/19 22:00	1			0			53											
08/26/19 23:00	1			0			46											
08/27/19 0:00	1			0			47											
08/27/19 1:00	1			0			48											
08/27/19 2:00	1			0			48											
08/27/19 3:00	1			0			46											
08/27/19 4:00	1			0			47											
08/27/19 5:00	1			3			47											
08/27/19 6:00	1			15			46											
08/27/19 7:00	1			29			43											
08/27/19 8:00	1			40			41											
08/27/19 9:00	1			41			42											
08/27/19 10:00	1			41			43											
08/27/19 11:00	1			41			43											
08/27/19 12:00	1			43			46											
08/27/19 13:00	1			51			53											
08/27/19 14:00	1			59			61											
08/27/19 15:00	1			68			70											
08/27/19 16:00	1			71			73											
08/27/19 17:00	1			74			76											
08/27/19 18:00	1			73			75											
08/27/19 19:00	1			73			75											
08/27/19 20:00	1			73			75											
08/27/19 21:00	1			68			70											
08/27/19 22:00	1			59			61											
08/27/19 23:00	1			48			49											
08/28/19 0:00	1			42			42											
08/28/19 1:00	1			39			40											
08/28/19 2:00	1			38			40											
08/28/19 3:00	1			37			40											
08/28/19 4:00	1			37			41											
08/28/19 5:00	1			38			43											
08/28/19 6:00	1			41			47											
08/28/19 7:00	1			53			58											
08/28/19 8:00	1			66			69											
08/28/19 9:00	1			76			78											
08/28/19 10:00	1			77			79											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/28/19 11:00	1			77			79											
08/28/19 12:00	1			77			79											
08/28/19 13:00	1			77			79											
08/28/19 14:00	1			76			78											
08/28/19 15:00	1			76			78											
08/28/19 16:00	1			75			78											
08/28/19 17:00	1			75			78											
08/28/19 18:00	1			75			78											
08/28/19 19:00	1			73			76											
08/28/19 20:00	1			70			72											
08/28/19 21:00	1			61			63											
08/28/19 22:00	1			52			53											
08/28/19 23:00	1			42			44											
08/29/19 0:00	1			39			41											
08/29/19 1:00	1			37			39											
08/29/19 2:00	1			37			40											
08/29/19 3:00	1			36			39											
08/29/19 4:00	1			36			40											
08/29/19 5:00	1			36			40											
08/29/19 6:00	1			37			40											
08/29/19 7:00	1			38			41											
08/29/19 8:00	1			40			43											
08/29/19 9:00	1			43			47											
08/29/19 10:00	1			49			52											
08/29/19 11:00	1			56			58											
08/29/19 12:00	1			63			64											
08/29/19 13:00	1			66			68											
08/29/19 14:00	1			68			70											
08/29/19 15:00	1			68			70											
08/29/19 16:00	1			69			71											
08/29/19 17:00	1			69			72											
08/29/19 18:00	1			70			72											
08/29/19 19:00	1			70			72											
08/29/19 20:00	1			66			68											
08/29/19 21:00	1			59			61											
08/29/19 22:00	1			49			51											
08/29/19 23:00	1			32			34											
08/30/19 0:00	0			15			17											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/30/19 1:00	0			2			3											
08/30/19 2:00	0			0			0											
08/30/19 3:00	0			0			0											
08/30/19 4:00	0			0			0											
08/30/19 5:00	0			0			0											
08/30/19 6:00	0			0			0											
08/30/19 7:00	0			0			0											
08/30/19 8:00	0			0			0											
08/30/19 9:00	0			0			0											
08/30/19 10:00	0			0			0											
08/30/19 11:00	0			0			0											
08/30/19 12:00	0			0			0											
08/30/19 13:00	0			0			0											
08/30/19 14:00	0			0			0											
08/30/19 15:00	0			0			0											
08/30/19 16:00	0			0			0											
08/30/19 17:00	0			0			0											
08/30/19 18:00	0			0			0											
08/30/19 19:00	0			0			0											
08/30/19 20:00	0			0			0											
08/30/19 21:00	0			0			0											
08/30/19 22:00	0			0			0											
08/30/19 23:00	0			0			0											
08/31/19 0:00	0			0			0											
08/31/19 1:00	0			0			0											
08/31/19 2:00	0			0			0											
08/31/19 3:00	0			0			0											
08/31/19 4:00	0			0			0											
08/31/19 5:00	0			0			0											
08/31/19 6:00	0			0			0											
08/31/19 7:00	0			0			0											
08/31/19 8:00	0			0			0											
08/31/19 9:00	0			0			0											
08/31/19 10:00	0			0			0											
08/31/19 11:00	0			0			0											
08/31/19 12:00	0			0			0											
08/31/19 13:00	0			0			0											
08/31/19 14:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/31/19 15:00	0			0			0											
08/31/19 16:00	0			0			0											
08/31/19 17:00	0			0			0											
08/31/19 18:00	0			0			0											
08/31/19 19:00	0			0			0											
08/31/19 20:00	0			0			0											
08/31/19 21:00	0			0			0											
08/31/19 22:00	0			0			0											
08/31/19 23:00	0			0			0											
09/01/19 0:00	0			0			0											
09/01/19 1:00	0			0			0											
09/01/19 2:00	0			0			0											
09/01/19 3:00	0			0			0											
09/01/19 4:00	0			0			0											
09/01/19 5:00	0			0			0											
09/01/19 6:00	0			0			0											
09/01/19 7:00	0			0			0											
09/01/19 8:00	0			0			0											
09/01/19 9:00	0			0			0											
09/01/19 10:00	0			0			0											
09/01/19 11:00	0			0			0											
09/01/19 12:00	0			0			0											
09/01/19 13:00	0			0			0											
09/01/19 14:00	0			0			0											
09/01/19 15:00	0			0			0											
09/01/19 16:00	0			0			0											
09/01/19 17:00	0			0			0											
09/01/19 18:00	0			0			0											
09/01/19 19:00	0			0			0											
09/01/19 20:00	0			0			0											
09/01/19 21:00	0			0			0											
09/01/19 22:00	0			0			0											
09/01/19 23:00	0			0			0											
09/02/19 0:00	0			0			0											
09/02/19 1:00	0			0			0											
09/02/19 2:00	0			0			0											
09/02/19 3:00	0			0			0											
09/02/19 4:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/02/19 5:00	0			0			0											
09/02/19 6:00	0			0			0											
09/02/19 7:00	0			0			0											
09/02/19 8:00	0			0			0											
09/02/19 9:00	0			0			0											
09/02/19 10:00	0			0			0											
09/02/19 11:00	0			0			0											
09/02/19 12:00	0			0			0											
09/02/19 13:00	0			0			0											
09/02/19 14:00	0			0			0											
09/02/19 15:00	0			0			0											
09/02/19 16:00	0			0			0											
09/02/19 17:00	0			0			0											
09/02/19 18:00	0			0			0											
09/02/19 19:00	0			0			0											
09/02/19 20:00	0			0			0											
09/02/19 21:00	0			0			0											
09/02/19 22:00	0			0			0											
09/02/19 23:00	0			0			0											
09/03/19 0:00	0			0			0											
09/03/19 1:00	0			0			0											
09/03/19 2:00	0			0			0											
09/03/19 3:00	0			0			0											
09/03/19 4:00	0			0			0											
09/03/19 5:00	0			0			0											
09/03/19 6:00	0			0			0											
09/03/19 7:00	0			0			0											
09/03/19 8:00	0			0			0											
09/03/19 9:00	0			0			0											
09/03/19 10:00	0			0			0											
09/03/19 11:00	0			0			0											
09/03/19 12:00	0			0			0											
09/03/19 13:00	0			0			0											
09/03/19 14:00	0			0			0											
09/03/19 15:00	0			0			0											
09/03/19 16:00	0			0			0											
09/03/19 17:00	0			0			0											
09/03/19 18:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/03/19 19:00	0			0			0											
09/03/19 20:00	0			0			0											
09/03/19 21:00	0			0			0											
09/03/19 22:00	0			0			0											
09/03/19 23:00	0			0			0											
09/04/19 0:00	0			0			0											
09/04/19 1:00	0			0			0											
09/04/19 2:00	0			0			0											
09/04/19 3:00	0			0			0											
09/04/19 4:00	0			0			0											
09/04/19 5:00	1			2			0											
09/04/19 6:00	1			16			2											
09/04/19 7:00	1			28			14											
09/04/19 8:00	1			38			26											
09/04/19 9:00	1			42			42											
09/04/19 10:00	1			47			49											
09/04/19 11:00	1			57			59											
09/04/19 12:00	1			63			65											
09/04/19 13:00	1			68			70											
09/04/19 14:00	1			71			73											
09/04/19 15:00	1			73			76											
09/04/19 16:00	1			75			78											
09/04/19 17:00	1			68			71											
09/04/19 18:00	1			60			63											
09/04/19 19:00	1			52			55											
09/04/19 20:00	1			57			60											
09/04/19 21:00	1			54			57											
09/04/19 22:00	1			49			51											
09/04/19 23:00	1			44			46											
09/05/19 0:00	1			45			48											
09/05/19 1:00	1			46			50											
09/05/19 2:00	1			41			46											
09/05/19 3:00	1			38			42											
09/05/19 4:00	1			37			42											
09/05/19 5:00	1			38			42											
09/05/19 6:00	1			39			43											
09/05/19 7:00	1			40			45											
09/05/19 8:00	1			44			49											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/05/19 9:00	1			51			55											
09/05/19 10:00	1			57			60											
09/05/19 11:00	1			63			64											
09/05/19 12:00	1			66			67											
09/05/19 13:00	1			70			72											
09/05/19 14:00	1			73			76											
09/05/19 15:00	1			76			79											
09/05/19 16:00	1			74			77											
09/05/19 17:00	1			72			75											
09/05/19 18:00	1			68			71											
09/05/19 19:00	1			63			66											
09/05/19 20:00	1			57			59											
09/05/19 21:00	1			53			56											
09/05/19 22:00	1			50			53											
09/05/19 23:00	1			35			40											
09/06/19 0:00	0			18			21											
09/06/19 1:00	0			2			4											
09/06/19 2:00	0			0			0											
09/06/19 3:00	0			0			0											
09/06/19 4:00	0			0			0											
09/06/19 5:00	0			0			0											
09/06/19 6:00	0			0			0											
09/06/19 7:00	0			0			0											
09/06/19 8:00	0			0			0											
09/06/19 9:00	0			0			0											
09/06/19 10:00	0			0			0											
09/06/19 11:00	0			0			0											
09/06/19 12:00	0			0			0											
09/06/19 13:00	0			0			0											
09/06/19 14:00	0			0			0											
09/06/19 15:00	0			0			0											
09/06/19 16:00	0			0			0											
09/06/19 17:00	0			0			0											
09/06/19 18:00	0			0			0											
09/06/19 19:00	0			0			0											
09/06/19 20:00	0			0			0											
09/06/19 21:00	0			0			0											
09/06/19 22:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/06/19 23:00	0			0			0											
09/07/19 0:00	0			0			0											
09/07/19 1:00	0			0			0											
09/07/19 2:00	0			0			0											
09/07/19 3:00	0			0			0											
09/07/19 4:00	0			0			0											
09/07/19 5:00	0			0			0											
09/07/19 6:00	0			0			0											
09/07/19 7:00	0			0			0											
09/07/19 8:00	0			0			0											
09/07/19 9:00	0			0			0											
09/07/19 10:00	0			0			0											
09/07/19 11:00	0			0			0											
09/07/19 12:00	0			0			0											
09/07/19 13:00	0			0			0											
09/07/19 14:00	0			0			0											
09/07/19 15:00	0			0			0											
09/07/19 16:00	0			0			0											
09/07/19 17:00	0			0			0											
09/07/19 18:00	0			0			0											
09/07/19 19:00	0			0			0											
09/07/19 20:00	0			0			0											
09/07/19 21:00	0			0			0											
09/07/19 22:00	0			0			0											
09/07/19 23:00	0			0			0											
09/08/19 0:00	0			0			0											
09/08/19 1:00	0			0			0											
09/08/19 2:00	0			0			0											
09/08/19 3:00	0			0			0											
09/08/19 4:00	0			0			0											
09/08/19 5:00	0			0			0											
09/08/19 6:00	0			0			0											
09/08/19 7:00	0			0			0											
09/08/19 8:00	0			0			0											
09/08/19 9:00	0			0			0											
09/08/19 10:00	0			0			0											
09/08/19 11:00	0			0			0											
09/08/19 12:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/08/19 13:00	0			0			0											
09/08/19 14:00	0			0			0											
09/08/19 15:00	0			0			0											
09/08/19 16:00	0			0			0											
09/08/19 17:00	0			0			0											
09/08/19 18:00	0			0			0											
09/08/19 19:00	0			0			0											
09/08/19 20:00	0			0			0											
09/08/19 21:00	0			0			0											
09/08/19 22:00	0			0			0											
09/08/19 23:00	0			0			0											
09/09/19 0:00	0			0			0											
09/09/19 1:00	0			0			0											
09/09/19 2:00	0			0			0											
09/09/19 3:00	0			0			0											
09/09/19 4:00	0			0			0											
09/09/19 5:00	0			0			0											
09/09/19 6:00	0			0			0											
09/09/19 7:00	0			0			0											
09/09/19 8:00	0			0			0											
09/09/19 9:00	0			0			0											
09/09/19 10:00	0			0			0											
09/09/19 11:00	0			0			0											
09/09/19 12:00	0			0			0											
09/09/19 13:00	0			0			0											
09/09/19 14:00	0			0			0											
09/09/19 15:00	0			0			0											
09/09/19 16:00	0			0			0											
09/09/19 17:00	0			0			0											
09/09/19 18:00	0			0			0											
09/09/19 19:00	0			0			0											
09/09/19 20:00	0			0			0											
09/09/19 21:00	0			0			0											
09/09/19 22:00	1			0			3											
09/09/19 23:00	1			0			11											
09/10/19 0:00	1			0			21											
09/10/19 1:00	1			0			27											
09/10/19 2:00	1			0			27											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/10/19 3:00	1			0			26											
09/10/19 4:00	1			0			28											
09/10/19 5:00	1			0			30											
09/10/19 6:00	1			0			32											
09/10/19 7:00	1			0			34											
09/10/19 8:00	1			0			38											
09/10/19 9:00	1			0			40											
09/10/19 10:00	1			0			45											
09/10/19 11:00	1			0			48											
09/10/19 12:00	1			0			58											
09/10/19 13:00	1			0			58											
09/10/19 14:00	1			0			64											
09/10/19 15:00	1			0			59											
09/10/19 16:00	1			0			66											
09/10/19 17:00	1			0			68											
09/10/19 18:00	1			0			75											
09/10/19 19:00	1			0			73											
09/10/19 20:00	1			0			63											
09/10/19 21:00	1			0			54											
09/10/19 22:00	1			0			46											
09/10/19 23:00	1			0			44											
09/11/19 0:00	1			0			41											
09/11/19 1:00	1			0			38											
09/11/19 2:00	1			0			36											
09/11/19 3:00	1			0			36											
09/11/19 4:00	1			0			37											
09/11/19 5:00	1			0			37											
09/11/19 6:00	1			0			38											
09/11/19 7:00	1			0			38											
09/11/19 8:00	1			2			38											
09/11/19 9:00	1			14			37											
09/11/19 10:00	1			31			42											
09/11/19 11:00	1			49			50											
09/11/19 12:00	1			61			42											
09/11/19 13:00	1			58			24											
09/11/19 14:00	1			61			4											
09/11/19 15:00	1			51			0											
09/11/19 16:00	1			57			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/11/19 17:00	1			53			0											
09/11/19 18:00	1			57			0											
09/11/19 19:00	1			50			0											
09/11/19 20:00	1			51			0											
09/11/19 21:00	1			50			0											
09/11/19 22:00	1			52			0											
09/11/19 23:00	1			46			0											
09/12/19 0:00	1			45			0											
09/12/19 1:00	1			42			0											
09/12/19 2:00	1			38			0											
09/12/19 3:00	1			36			0											
09/12/19 4:00	1			36			0											
09/12/19 5:00	1			36			0											
09/12/19 6:00	1			36			0											
09/12/19 7:00	1			37			0											
09/12/19 8:00	1			47			3											
09/12/19 9:00	1			49			15											
09/12/19 10:00	1			56			36											
09/12/19 11:00	1			48			51											
09/12/19 12:00	1			36			62											
09/12/19 13:00	1			16			59											
09/12/19 14:00	1			1			64											
09/12/19 15:00	1			0			52											
09/12/19 16:00	1			0			58											
09/12/19 17:00	1			0			60											
09/12/19 18:00	1			0			75											
09/12/19 19:00	1			0			77											
09/12/19 20:00	1			0			76											
09/12/19 21:00	1			0			67											
09/12/19 22:00	1			0			55											
09/12/19 23:00	1			0			32											
09/13/19 0:00	0			0			16											
09/13/19 1:00	0			0			2											
09/13/19 2:00	0			0			0											
09/13/19 3:00	0			0			0											
09/13/19 4:00	0			0			0											
09/13/19 5:00	0			0			0											
09/13/19 6:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/13/19 7:00	0			0			0											
09/13/19 8:00	0			0			0											
09/13/19 9:00	0			0			0											
09/13/19 10:00	0			0			0											
09/13/19 11:00	0			0			0											
09/13/19 12:00	0			0			0											
09/13/19 13:00	0			0			0											
09/13/19 14:00	0			0			0											
09/13/19 15:00	0			0			0											
09/13/19 16:00	0			0			0											
09/13/19 17:00	0			0			0											
09/13/19 18:00	0			0			0											
09/13/19 19:00	0			0			0											
09/13/19 20:00	0			0			0											
09/13/19 21:00	0			0			0											
09/13/19 22:00	0			0			0											
09/13/19 23:00	0			0			0											
09/14/19 0:00	0			0			0											
09/14/19 1:00	0			0			0											
09/14/19 2:00	0			0			0											
09/14/19 3:00	0			0			0											
09/14/19 4:00	0			0			0											
09/14/19 5:00	0			0			0											
09/14/19 6:00	0			0			0											
09/14/19 7:00	0			0			0											
09/14/19 8:00	0			0			0											
09/14/19 9:00	0			0			0											
09/14/19 10:00	0			0			0											
09/14/19 11:00	0			0			0											
09/14/19 12:00	0			0			0											
09/14/19 13:00	0			0			0											
09/14/19 14:00	0			0			0											
09/14/19 15:00	0			0			0											
09/14/19 16:00	0			0			0											
09/14/19 17:00	0			0			0											
09/14/19 18:00	0			0			0											
09/14/19 19:00	0			0			0											
09/14/19 20:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/14/19 21:00	0			0			0											
09/14/19 22:00	0			0			0											
09/14/19 23:00	0			0			0											
09/15/19 0:00	0			0			0											
09/15/19 1:00	0			0			0											
09/15/19 2:00	0			0			0											
09/15/19 3:00	0			0			0											
09/15/19 4:00	0			0			0											
09/15/19 5:00	0			0			0											
09/15/19 6:00	0			0			0											
09/15/19 7:00	0			0			0											
09/15/19 8:00	0			0			0											
09/15/19 9:00	0			0			0											
09/15/19 10:00	0			0			0											
09/15/19 11:00	0			0			0											
09/15/19 12:00	0			0			0											
09/15/19 13:00	0			0			0											
09/15/19 14:00	0			0			0											
09/15/19 15:00	0			0			0											
09/15/19 16:00	0			0			0											
09/15/19 17:00	0			0			0											
09/15/19 18:00	0			0			0											
09/15/19 19:00	0			0			0											
09/15/19 20:00	0			0			0											
09/15/19 21:00	0			0			0											
09/15/19 22:00	0			0			0											
09/15/19 23:00	0			0			0											
09/16/19 0:00	0			0			0											
09/16/19 1:00	0			0			0											
09/16/19 2:00	0			0			0											
09/16/19 3:00	0			0			0											
09/16/19 4:00	0			0			0											
09/16/19 5:00	0			0			0											
09/16/19 6:00	0			0			0											
09/16/19 7:00	0			0			0											
09/16/19 8:00	0			0			0											
09/16/19 9:00	0			0			0											
09/16/19 10:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/16/19 11:00	0			0			0											
09/16/19 12:00	0			0			0											
09/16/19 13:00	0			0			0											
09/16/19 14:00	0			0			0											
09/16/19 15:00	0			0			0											
09/16/19 16:00	0			0			0											
09/16/19 17:00	0			0			0											
09/16/19 18:00	0			0			0											
09/16/19 19:00	0			0			0											
09/16/19 20:00	0			0			0											
09/16/19 21:00	0			0			0											
09/16/19 22:00	0			0			0											
09/16/19 23:00	0			0			0											
09/17/19 0:00	0			0			0											
09/17/19 1:00	0			0			0											
09/17/19 2:00	0			0			0											
09/17/19 3:00	0			0			0											
09/17/19 4:00	0			0			0											
09/17/19 5:00	0			0			0											
09/17/19 6:00	0			0			0											
09/17/19 7:00	0			0			0											
09/17/19 8:00	0			0			0											
09/17/19 9:00	0			0			0											
09/17/19 10:00	0			0			0											
09/17/19 11:00	0			0			0											
09/17/19 12:00	0			0			0											
09/17/19 13:00	0			0			0											
09/17/19 14:00	0			0			0											
09/17/19 15:00	0			0			0											
09/17/19 16:00	0			0			0											
09/17/19 17:00	0			0			0											
09/17/19 18:00	0			0			0											
09/17/19 19:00	0			0			0											
09/17/19 20:00	0			0			0											
09/17/19 21:00	0			0			0											
09/17/19 22:00	0			0			0											
09/17/19 23:00	0			0			0											
09/18/19 0:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/18/19 1:00	0			0			0											
09/18/19 2:00	0			0			0											
09/18/19 3:00	0			0			0											
09/18/19 4:00	0			0			0											
09/18/19 5:00	0			0			0											
09/18/19 6:00	0			0			0											
09/18/19 7:00	0			0			0											
09/18/19 8:00	0			0			0											
09/18/19 9:00	0			0			0											
09/18/19 10:00	0			0			0											
09/18/19 11:00	0			0			0											
09/18/19 12:00	0			0			0											
09/18/19 13:00	0			0			0											
09/18/19 14:00	0			0			0											
09/18/19 15:00	0			0			0											
09/18/19 16:00	0			0			0											
09/18/19 17:00	0			0			0											
09/18/19 18:00	0			0			0											
09/18/19 19:00	0			0			0											
09/18/19 20:00	0			0			0											
09/18/19 21:00	0			0			0											
09/18/19 22:00	0			0			0											
09/18/19 23:00	0			0			0											
09/19/19 0:00	0			0			0											
09/19/19 1:00	0			0			0											
09/19/19 2:00	0			0			0											
09/19/19 3:00	0			0			0											
09/19/19 4:00	0			0			0											
09/19/19 5:00	0			0			0											
09/19/19 6:00	0			0			0											
09/19/19 7:00	0			0			0											
09/19/19 8:00	0			0			0											
09/19/19 9:00	0			0			0											
09/19/19 10:00	0			0			0											
09/19/19 11:00	0			0			0											
09/19/19 12:00	0			0			0											
09/19/19 13:00	0			0			0											
09/19/19 14:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/19/19 15:00	0			0			0											
09/19/19 16:00	0			0			0											
09/19/19 17:00	0			0			0											
09/19/19 18:00	0			0			0											
09/19/19 19:00	0			0			0											
09/19/19 20:00	0			0			0											
09/19/19 21:00	0			0			0											
09/19/19 22:00	0			0			0											
09/19/19 23:00	0			0			0											
09/20/19 0:00	0			0			0											
09/20/19 1:00	0			0			0											
09/20/19 2:00	0			0			0											
09/20/19 3:00	0			0			0											
09/20/19 4:00	0			0			0											
09/20/19 5:00	0			0			0											
09/20/19 6:00	0			0			0											
09/20/19 7:00	0			0			0											
09/20/19 8:00	0			0			0											
09/20/19 9:00	0			0			0											
09/20/19 10:00	0			0			0											
09/20/19 11:00	0			0			0											
09/20/19 12:00	0			0			0											
09/20/19 13:00	0			0			0											
09/20/19 14:00	0			0			0											
09/20/19 15:00	0			0			0											
09/20/19 16:00	0			0			0											
09/20/19 17:00	0			0			0											
09/20/19 18:00	0			0			0											
09/20/19 19:00	0			0			0											
09/20/19 20:00	0			0			0											
09/20/19 21:00	0			0			0											
09/20/19 22:00	0			0			0											
09/20/19 23:00	0			0			0											
09/21/19 0:00	0			0			0											
09/21/19 1:00	0			0			0											
09/21/19 2:00	0			0			0											
09/21/19 3:00	0			0			0											
09/21/19 4:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/21/19 5:00	0			0			0											
09/21/19 6:00	0			0			0											
09/21/19 7:00	0			0			0											
09/21/19 8:00	0			0			0											
09/21/19 9:00	0			0			0											
09/21/19 10:00	0			0			0											
09/21/19 11:00	0			0			0											
09/21/19 12:00	0			0			0											
09/21/19 13:00	0			0			0											
09/21/19 14:00	0			0			0											
09/21/19 15:00	0			0			0											
09/21/19 16:00	0			0			0											
09/21/19 17:00	0			0			0											
09/21/19 18:00	0			0			0											
09/21/19 19:00	0			0			0											
09/21/19 20:00	0			0			0											
09/21/19 21:00	0			0			0											
09/21/19 22:00	0			0			0											
09/21/19 23:00	0			0			0											
09/22/19 0:00	0			0			0											
09/22/19 1:00	0			0			0											
09/22/19 2:00	0			0			0											
09/22/19 3:00	0			0			0											
09/22/19 4:00	0			0			0											
09/22/19 5:00	0			0			0											
09/22/19 6:00	0			0			0											
09/22/19 7:00	0			0			0											
09/22/19 8:00	0			0			0											
09/22/19 9:00	0			0			0											
09/22/19 10:00	0			0			0											
09/22/19 11:00	0			0			0											
09/22/19 12:00	0			0			0											
09/22/19 13:00	0			0			0											
09/22/19 14:00	0			0			0											
09/22/19 15:00	0			0			0											
09/22/19 16:00	0			0			0											
09/22/19 17:00	0			0			0											
09/22/19 18:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/22/19 19:00	0			0			0											
09/22/19 20:00	0			0			0											
09/22/19 21:00	0			0			0											
09/22/19 22:00	0			0			0											
09/22/19 23:00	0			0			0											
09/23/19 0:00	0			0			0											
09/23/19 1:00	0			0			0											
09/23/19 2:00	0			0			0											
09/23/19 3:00	0			0			0											
09/23/19 4:00	0			0			0											
09/23/19 5:00	0			0			0											
09/23/19 6:00	0			0			0											
09/23/19 7:00	1			0			2											
09/23/19 8:00	1			0			15											
09/23/19 9:00	1			0			28											
09/23/19 10:00	1			0			44											
09/23/19 11:00	1			0			54											
09/23/19 12:00	1			0			63											
09/23/19 13:00	1			0			68											
09/23/19 14:00	1			0			69											
09/23/19 15:00	1			0			68											
09/23/19 16:00	1			0			68											
09/23/19 17:00	1			0			68											
09/23/19 18:00	1			0			67											
09/23/19 19:00	1			0			67											
09/23/19 20:00	1			0			66											
09/23/19 21:00	1			0			64											
09/23/19 22:00	1			0			54											
09/23/19 23:00	1			0			52											
09/24/19 0:00	1			0			55											
09/24/19 1:00	1			0			64											
09/24/19 2:00	1			0			65											
09/24/19 3:00	1			0			65											
09/24/19 4:00	1			0			67											
09/24/19 5:00	1			0			63											
09/24/19 6:00	1			0			58											
09/24/19 7:00	1			0			56											
09/24/19 8:00	1			11			54											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/24/19 9:00	1			27			53											
09/24/19 10:00	1			44			50											
09/24/19 11:00	1			50			53											
09/24/19 12:00	1			54			56											
09/24/19 13:00	1			58			59											
09/24/19 14:00	1			61			62											
09/24/19 15:00	1			62			63											
09/24/19 16:00	1			66			68											
09/24/19 17:00	1			71			74											
09/24/19 18:00	1			75			77											
09/24/19 19:00	1			70			73											
09/24/19 20:00	1			62			64											
09/24/19 21:00	1			58			60											
09/24/19 22:00	1			54			55											
09/24/19 23:00	1			49			51											
09/25/19 0:00	1			41			43											
09/25/19 1:00	1			36			39											
09/25/19 2:00	1			36			39											
09/25/19 3:00	1			36			39											
09/25/19 4:00	1			36			39											
09/25/19 5:00	1			36			38											
09/25/19 6:00	1			36			38											
09/25/19 7:00	1			36			38											
09/25/19 8:00	1			36			37											
09/25/19 9:00	1			36			38											
09/25/19 10:00	1			39			40											
09/25/19 11:00	1			45			47											
09/25/19 12:00	1			57			59											
09/25/19 13:00	1			67			69											
09/25/19 14:00	1			73			75											
09/25/19 15:00	1			73			75											
09/25/19 16:00	1			73			75											
09/25/19 17:00	1			73			75											
09/25/19 18:00	1			69			72											
09/25/19 19:00	1			67			70											
09/25/19 20:00	1			65			69											
09/25/19 21:00	1			62			65											
09/25/19 22:00	1			52			57											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/25/19 23:00	1			41			45											
09/26/19 0:00	1			37			40											
09/26/19 1:00	1			36			38											
09/26/19 2:00	1			36			38											
09/26/19 3:00	1			36			38											
09/26/19 4:00	1			36			38											
09/26/19 5:00	1			36			38											
09/26/19 6:00	1			36			38											
09/26/19 7:00	1			36			38											
09/26/19 8:00	1			37			38											
09/26/19 9:00	1			41			43											
09/26/19 10:00	1			49			51											
09/26/19 11:00	1			58			60											
09/26/19 12:00	1			64			66											
09/26/19 13:00	1			65			67											
09/26/19 14:00	1			68			70											
09/26/19 15:00	1			70			72											
09/26/19 16:00	1			73			75											
09/26/19 17:00	1			71			74											
09/26/19 18:00	1			69			72											
09/26/19 19:00	1			63			66											
09/26/19 20:00	1			56			58											
09/26/19 21:00	1			47			49											
09/26/19 22:00	1			39			43											
09/26/19 23:00	1			25			40											
09/27/19 0:00	1			12			38											
09/27/19 1:00	1			0			37											
09/27/19 2:00	1			0			36											
09/27/19 3:00	1			0			36											
09/27/19 4:00	1			0			36											
09/27/19 5:00	1			0			38											
09/27/19 6:00	1			0			40											
09/27/19 7:00	1			0			43											
09/27/19 8:00	1			0			47											
09/27/19 9:00	1			0			59											
09/27/19 10:00	1			0			69											
09/27/19 11:00	1			0			77											
09/27/19 12:00	1			0			77											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/27/19 13:00	1			0			77											
09/27/19 14:00	1			0			77											
09/27/19 15:00	1			0			77											
09/27/19 16:00	1			0			77											
09/27/19 17:00	1			0			77											
09/27/19 18:00	1			0			77											
09/27/19 19:00	1			0			77											
09/27/19 20:00	1			0			77											
09/27/19 21:00	1			0			66											
09/27/19 22:00	1			0			52											
09/27/19 23:00	1			0			29											
09/28/19 0:00	0			0			13											
09/28/19 1:00	0			0			2											
09/28/19 2:00	0			0			0											
09/28/19 3:00	0			0			0											
09/28/19 4:00	0			0			0											
09/28/19 5:00	0			0			0											
09/28/19 6:00	0			0			0											
09/28/19 7:00	0			0			0											
09/28/19 8:00	0			0			0											
09/28/19 9:00	0			0			0											
09/28/19 10:00	0			0			0											
09/28/19 11:00	0			0			0											
09/28/19 12:00	0			0			0											
09/28/19 13:00	0			0			0											
09/28/19 14:00	0			0			0											
09/28/19 15:00	0			0			0											
09/28/19 16:00	0			0			0											
09/28/19 17:00	0			0			0											
09/28/19 18:00	0			0			0											
09/28/19 19:00	0			0			0											
09/28/19 20:00	0			0			0											
09/28/19 21:00	0			0			0											
09/28/19 22:00	0			0			0											
09/28/19 23:00	0			0			0											
09/29/19 0:00	0			0			0											
09/29/19 1:00	0			0			0											
09/29/19 2:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/29/19 3:00	0			0			0											
09/29/19 4:00	0			0			0											
09/29/19 5:00	0			0			0											
09/29/19 6:00	0			0			0											
09/29/19 7:00	0			0			0											
09/29/19 8:00	0			0			0											
09/29/19 9:00	0			0			0											
09/29/19 10:00	0			0			0											
09/29/19 11:00	0			0			0											
09/29/19 12:00	0			0			0											
09/29/19 13:00	0			0			0											
09/29/19 14:00	0			0			0											
09/29/19 15:00	0			0			0											
09/29/19 16:00	0			0			0											
09/29/19 17:00	0			0			0											
09/29/19 18:00	0			0			0											
09/29/19 19:00	0			0			0											
09/29/19 20:00	0			0			0											
09/29/19 21:00	0			0			0											
09/29/19 22:00	0			0			0											
09/29/19 23:00	0			0			0											
09/30/19 0:00	0			0			0											
09/30/19 1:00	0			0			0											
09/30/19 2:00	0			0			0											
09/30/19 3:00	0			0			0											
09/30/19 4:00	0			0			0											
09/30/19 5:00	0			0			0											
09/30/19 6:00	1			2			0											
09/30/19 7:00	1			15			0											
09/30/19 8:00	1			29			0											
09/30/19 9:00	1			45			0											
09/30/19 10:00	1			50			2											
09/30/19 11:00	1			50			16											
09/30/19 12:00	1			33			35											
09/30/19 13:00	1			14			52											
09/30/19 14:00	1			1			62											
09/30/19 15:00	1			0			68											
09/30/19 16:00	1			0			72											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/30/19 17:00	1			0			54											
09/30/19 18:00	0			0			29											
09/30/19 19:00	0			0			6											
09/30/19 20:00	0			0			0											
09/30/19 21:00	0			0			0											
09/30/19 22:00	0			0			0											
09/30/19 23:00	0			0			0											

CEMs Log

Date/Time	Operator	Description
09/26/19 2:05	Operator (ME)	CHANGED OUT O2 BOTTLE ON CT1, NEW VALUE = 18.04. CYLINDER #
09/09/19	Administrator (DE)	UPDATED MONTHLY GCV VALUE TO 104,700 FOR CT1, CT2, AND GCV GAS.
09/06/19 8:30	Administrator (VRL)	9/05/19 - Calibrated CT1 SCR Nox analyzer and performed error check.
08/22/19 9:50	Administrator (RG)	CO ANALYZER CT1, REPLACED TRANSDUCER FLOW BOARD INSIDE
08/20/19	Administrator (VRL)	Edit data for 6/10/19. Manually entered load data and unit operation data. Validate unit operation data from 6/9/19 00:06 to 6/11/19 07:53.
08/15/19	Administrator (VRL)	Manual cal CT1 inlet Nox
08/15/19 9:45	Administrator (VRL)	Performed cal CT2 inlet Nox
08/14/19	Administrator (VRL)	Manually adjusted CT1 SCR Nox high/low zero/span and performed cal error check.
08/07/19	Administrator (BRB)	Performed CGAs and Linieritys on unit 1 on Monday 8/5.
		Performed Liniaritys on Unit 2 on Monday 8/5.
		Performed CGAs on unit 2 on Tuesday 8/6.
08/07/19 2:42	Administrator (DWN)	UNIT 1 & UNIT 2 GCV VALUES UPDATED TO 104600 FOR AUGUST
08/04/19	Administrator (RC)	CHANGED OUT LOW NOX BOTTLE FOR CT2 NEW VALUES NOX-8.77 / CO-8.84 CYLINDER #SX54138
08/01/19 9:38	Administrator (VRL)	Adjusted CT1 stack Nox zero and span. Performed cal error check.
08/01/19 2:02	Administrator (ME)	CHANGED OUT LOW NOX / CO BOTTLE, CT1. NEW VALUES, NOX = 8.91 PPM. CO = 8.85 PPM. CYLINDER # CC177053.
07/26/19	Administrator (ME)	CHANGED OUT HIGH NOX / CO BOTTLE, CT1. NEW VALUES NOX = 180.7 PPM, CO = 180.3 PPM. CYLINDER # SX62134
07/26/19	Administrator (VRL)	Verified and updated fuel flowmeter transmitter span and range values consistent to field devices
07/26/19 8:52	Administrator (VRL)	Adjusted zero and span on CT1 SCR Nox. Performed cal error check.
07/24/19 4:10	Administrator (LHR)	CHANGED OUT CT2 02 AND HIGH SPAN CYLINDERS. NEW CYLINDER #'s SX41696 & SX26184. NEW VALUES - O2_18.02 %, CO_177.4, NOX_177.2.
07/23/19 9:04	Administrator (VRL)	Trim CT2 SCR Nox low / high range zero and span. Perform cal error check
07/23/19 9:02	Administrator (VRL)	Trim CT1 SCR Nox low / high range zero and span. Perform cal error check
07/19/19	Operator (VRL)	CT1 and CT2 SCR nox out of service. Flowing gas to verify no leaks after new ammonia scrubbers got up to temp.
07/07/19	Operator (BH)	UPDATED CEMS LOG FOR JUNE 2019 GCV VALUE 104,200

Date/Time	Operator	Description
07/06/19	Operator (DE)	UPDATED MONTHLY GCV VALUE TO 104200 FOR ALL THREE ENTRIES
07/04/19 1:08	Operator (ME)	CHANGED OUT CT1 02 CYLINDER. NEW CYLINDER # CC215154. NEW VALUE, 18.00 %.
07/03/19 9:19	Operator (BRB)	Ran manual calibration on unit 1-O2, Zeros, LOWs and Highs
		Brad Brown

Cylinder Gas Audit

Facility:	ROSEVILLE ENERGY			Instrument Name:	CT1_CODualRg_P_Instrume
Unit/Stack:	CT1	Test Date:	08/05/2019	Performance Spec:	15 Pct
Parameter/Scale:	CO / High	Test Result:	**Pass**	Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
08/05/2019	09:47	L	200	50.300	49.700	25.2 %
08/05/2019	09:52	M	200	107.500	109.700	53.8 %
08/05/2019	10:05	L	200	50.300	49.600	25.2 %
08/05/2019	10:10	M	200	107.500	109.300	53.8 %
08/05/2019	10:22	L	200	50.300	49.600	25.2 %
08/05/2019	10:27	M	200	107.500	109.600	53.8 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	50.300	49.633	Std	**1.3**
M	107.500	109.533	Std	**1.9**

Cylinder Gas Audit

Facility: ROSEVILLE ENERGY
Unit/Stack: CT1
Parameter/Scale: CO / Low

Test Date: 08/05/2019
Test Result: **Pass**

Instrument Name: CT1_CODualRg_P_Instrume
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
08/05/2019	11:38	L	10	2.400	2.200	24.0 %
08/05/2019	11:43	M	10	5.400	5.500	54.0 %
08/05/2019	11:50	L	10	2.400	2.200	24.0 %
08/05/2019	11:55	M	10	5.400	5.600	54.0 %
08/05/2019	12:02	L	10	2.400	2.200	24.0 %
08/05/2019	12:07	M	10	5.400	5.500	54.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	2.400	2.200	Std	**8.3**
M	5.400	5.533	Std	**2.5**

Cylinder Gas Audit

Facility:	ROSEVILLE ENERGY			Instrument Name:	CT2_CODualRg_P_Instrume
Unit/Stack:	CT2	Test Date:	08/06/2019	Performance Spec:	15 Pct
Parameter/Scale:	CO / Low	Test Result:	**Pass**	Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
08/06/2019	06:35	L	10	2.400	2.300	24.0 %
08/06/2019	06:40	M	10	5.400	5.600	54.0 %
08/06/2019	06:47	L	10	2.400	2.300	24.0 %
08/06/2019	06:52	M	10	5.400	5.600	54.0 %
08/06/2019	06:59	L	10	2.400	2.300	24.0 %
08/06/2019	07:04	M	10	5.400	5.600	54.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	2.400	2.300	Std	**4.2**
M	5.400	5.600	Std	**3.7**

Cylinder Gas Audit

Facility:	ROSEVILLE ENERGY			Instrument Name:	CT2_CODualRg_P_Instrume
Unit/Stack:	CT2	Test Date:	08/05/2019	Performance Spec:	15 Pct
Parameter/Scale:	CO / High	Test Result:	**Pass**	Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
08/05/2019	13:01	L	200	50.000	50.300	25.0 %
08/05/2019	13:07	M	200	109.700	114.000	54.9 %
08/05/2019	13:19	L	200	50.000	50.300	25.0 %
08/05/2019	13:24	M	200	109.700	113.600	54.9 %
08/05/2019	13:36	L	200	50.000	50.100	25.0 %
08/05/2019	13:41	M	200	109.700	113.800	54.9 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	50.000	50.233	Std	**0.5**
M	109.700	113.800	Std	**3.7**

Linearity Report

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY		
EDR Site ID:	CT001	Component ID:	A15	ReasonForTest:	QA
		Component Type:	NOXA	Grace Period:	0
Instrument Name:	CT1_NOXDualRg_P_Instrume	Test End Date/Time:	08/05/2019	Scale:	High
Performance Spec:	5 %	Test No.:	94	Highest Error:	0.1
		Status (Pass/Fail):	**Passed**		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
08/05/2019	0947	L	200.0	50.4	50.1		25.2 %
08/05/2019	0952	M	200.0	107.4	107.1		53.7 %
08/05/2019	0958	H	200.0	180.7	180.8		90.4 %
08/05/2019	1005	L	200.0	50.4	50.7		25.2 %
08/05/2019	1010	M	200.0	107.4	107.4		53.7 %
08/05/2019	1015	H	200.0	180.7	180.9		90.4 %
08/05/2019	1022	L	200.0	50.4	50.6		25.2 %
08/05/2019	1027	M	200.0	107.4	107.3		53.7 %
08/05/2019	1032	H	200.0	180.7	181.0		90.4 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	50.400	50.467	No	**0.1**
M	107.400	107.267	No	**0.1**
H	180.700	180.900	No	**0.1**

Linearity Report

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY		
EDR Site ID:	CT001	Component ID:	A16	ReasonForTest:	QA
		Component Type:	O2D	Grace Period:	0
Instrument Name:	CT1_O2D_P_Instrument	Test End Date/Time:	08/05/2019	Scale:	High
Performance Spec:	5 Eng Units	Test No.:	95	Highest Error:	5.4
		Status (Pass/Fail):	**PassAPS**		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
08/05/2019	1241	L	21.0	5.6	5.3		26.7 %
08/05/2019	1246	M	21.0	11.1	10.9		52.9 %
08/05/2019	1252	H	21.0	18.0	18.0		85.7 %
08/05/2019	1259	L	21.0	5.6	5.3		26.7 %
08/05/2019	1304	M	21.0	11.1	10.9		52.9 %
08/05/2019	1309	H	21.0	18.0	18.0		85.7 %
08/05/2019	1316	L	21.0	5.6	5.3		26.7 %
08/05/2019	1321	M	21.0	11.1	10.9		52.9 %
08/05/2019	1326	H	21.0	18.0	18.0		85.7 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.600	5.300	Yes	**0.3**
M	11.100	10.900	No	**1.8**
H	18.000	18.000	No	**0.0**

Linearity Report

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY		
EDR Site ID:	CT002	Component ID:	A21	ReasonForTest:	QA
		Component Type:	NOXA	Grace Period:	0
Instrument Name:	CT2_NOXDualRg_P_Instrume	Test End Date/Time:	08/05/2019	Scale:	High
Performance Spec:	5 %	Test No.:	93	Highest Error:	0.4
		Status (Pass/Fail):	**Passed**		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
08/05/2019	1301	L	200.0	49.0	48.7		24.5 %
08/05/2019	1307	M	200.0	108.9	108.5		54.5 %
08/05/2019	1312	H	200.0	177.2	176.8		88.6 %
08/05/2019	1319	L	200.0	49.0	49.1		24.5 %
08/05/2019	1324	M	200.0	108.9	108.5		54.5 %
08/05/2019	1329	H	200.0	177.2	176.9		88.6 %
08/05/2019	1336	L	200.0	49.0	49.0		24.5 %
08/05/2019	1341	M	200.0	108.9	108.4		54.5 %
08/05/2019	1346	H	200.0	177.2	176.8		88.6 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	49.000	48.933	No	**0.1**
M	108.900	108.467	No	**0.4**
H	177.200	176.833	No	**0.2**

Linearity Report

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY		
EDR Site ID:	CT002	Component ID:	A22	ReasonForTest:	QA
		Component Type:	O2D	Grace Period:	0
Instrument Name:	CT2_O2D_P_Instrument	Test End Date/Time:	08/05/2019	Scale:	High
Performance Spec:	5 %	Test No.:	94	Highest Error:	0.9
		Status (Pass/Fail):	**Passed**		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
08/05/2019	1354	L	21.0	5.6	5.5		26.7 %
08/05/2019	1359	M	21.0	11.1	11.0		52.9 %
08/05/2019	1404	H	21.0	18.0	18.0		85.7 %
08/05/2019	1411	L	21.0	5.6	5.6		26.7 %
08/05/2019	1416	M	21.0	11.1	11.0		52.9 %
08/05/2019	1421	H	21.0	18.0	18.0		85.7 %
08/05/2019	1428	L	21.0	5.6	5.6		26.7 %
08/05/2019	1433	M	21.0	11.1	11.0		52.9 %
08/05/2019	1438	H	21.0	18.0	18.0		85.7 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.600	5.567	No	**0.6**
M	11.100	11.000	No	**0.9**
H	18.000	18.000	No	**0.0**

Roseville Energy Park
Revision History

RegPerfect® by Teledyne Monitor Labs, Inc.
Teledyne Monitor Labs, Inc.
35 Inverness Drive East
Englewood, CO 80112-5189
Telephone: (800) 846-6062
http://www.teledyne-ml.com/
http://www.regperfect.com/
©1998-2005 Teledyne Monitor Labs, Inc. All rights reserved.
RegPerfect® is a registered trademark of Teledyne Monitor Labs, Inc.

NOTE: This server's C drive is only 20 GB in size!! Do not place large files on this drive.

8/22/19 Taylor Sullivan
EDR check. Re-generated Q2 EDRs to be resubmitted.

7/18,22/19 Taylor Sullivan
Q2 EDRs

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/01/2019 00:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/01/2019 01:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/01/2019 02:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/01/2019 03:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/01/2019 04:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/01/2019 05:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/01/2019 06:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/01/2019 07:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/01/2019 08:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/01/2019 09:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/01/2019 10:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/01/2019 11:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/01/2019 12:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/01/2019 13:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/01/2019 14:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/01/2019 15:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/01/2019 16:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/01/2019 17:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/01/2019 18:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/01/2019 19:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/01/2019 20:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/01/2019 21:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/01/2019 22:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/01/2019 23:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/02/2019 00:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/02/2019 01:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/02/2019 02:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/02/2019 03:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/02/2019 04:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/02/2019 05:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/02/2019 06:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/02/2019 07:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/02/2019 08:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/02/2019 09:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/02/2019 10:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/02/2019 11:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/02/2019 12:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/02/2019 13:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/02/2019 14:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/02/2019 15:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/02/2019 16:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/02/2019 17:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/02/2019 18:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/02/2019 19:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/02/2019 20:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/02/2019 21:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/02/2019 22:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/02/2019 23:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/03/2019 00:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/03/2019 01:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/03/2019 02:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/03/2019 03:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/03/2019 04:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/03/2019 05:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/03/2019 06:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/03/2019 07:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/03/2019 08:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/03/2019 09:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/03/2019 10:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/03/2019 11:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/03/2019 12:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/03/2019 13:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/03/2019 14:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/03/2019 15:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/03/2019 16:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/03/2019 17:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/03/2019 18:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/03/2019 19:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/03/2019 20:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/03/2019 21:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/03/2019 22:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/03/2019 23:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/04/2019 00:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/04/2019 01:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/04/2019 02:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/04/2019 03:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/04/2019 04:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/04/2019 05:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/04/2019 06:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/04/2019 07:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/04/2019 08:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/04/2019 09:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/04/2019 10:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/04/2019 11:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/04/2019 12:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/04/2019 13:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/04/2019 14:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/04/2019 15:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/04/2019 16:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/04/2019 17:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/04/2019 18:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/04/2019 19:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/04/2019 20:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/04/2019 21:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/04/2019 22:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/04/2019 23:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/05/2019 00:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/05/2019 01:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/05/2019 02:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/05/2019 03:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/05/2019 04:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/05/2019 05:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/05/2019 06:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/05/2019 07:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/05/2019 08:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/05/2019 09:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/05/2019 10:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/05/2019 11:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/05/2019 12:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/05/2019 13:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/05/2019 14:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/05/2019 15:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/05/2019 16:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/05/2019 17:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/05/2019 18:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/05/2019 19:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/05/2019 20:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/05/2019 21:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/05/2019 22:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/05/2019 23:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/06/2019 00:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/06/2019 01:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/06/2019 02:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/06/2019 03:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/06/2019 04:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/06/2019 05:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/06/2019 06:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/06/2019 07:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/06/2019 08:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/06/2019 09:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/06/2019 10:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/06/2019 11:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/06/2019 12:00	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
07/06/2019 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/06/2019 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/06/2019 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/06/2019 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/06/2019 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/06/2019 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/06/2019 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/06/2019 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/06/2019 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/06/2019 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/06/2019 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,983.3	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	103,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/07/2019 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/07/2019 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/07/2019 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/07/2019 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/07/2019 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/07/2019 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/07/2019 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/07/2019 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/07/2019 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/07/2019 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/07/2019 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/07/2019 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/07/2019 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/07/2019 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/07/2019 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/07/2019 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/07/2019 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/07/2019 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/07/2019 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/07/2019 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/07/2019 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/07/2019 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/07/2019 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/07/2019 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/08/2019 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/08/2019 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/08/2019 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/08/2019 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/08/2019 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/08/2019 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/08/2019 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/08/2019 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/08/2019 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/08/2019 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/08/2019 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/08/2019 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/08/2019 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/08/2019 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/08/2019 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/08/2019 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/08/2019 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/08/2019 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/08/2019 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/08/2019 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/08/2019 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/08/2019 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/08/2019 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/08/2019 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/09/2019 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/09/2019 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/09/2019 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/09/2019 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/09/2019 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/09/2019 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/09/2019 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/09/2019 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/09/2019 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/09/2019 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/09/2019 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/09/2019 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/09/2019 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/09/2019 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/09/2019 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/09/2019 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/09/2019 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/09/2019 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/09/2019 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/09/2019 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/09/2019 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/09/2019 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/09/2019 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/09/2019 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/10/2019 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/10/2019 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/10/2019 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/10/2019 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/10/2019 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/10/2019 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/10/2019 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/10/2019 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/10/2019 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/10/2019 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/10/2019 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/10/2019 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/10/2019 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/10/2019 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/10/2019 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/10/2019 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/10/2019 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/10/2019 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/10/2019 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/10/2019 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/10/2019 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/10/2019 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/10/2019 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/10/2019 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/11/2019 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/11/2019 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/11/2019 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/11/2019 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/11/2019 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/11/2019 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/11/2019 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/11/2019 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/11/2019 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/11/2019 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/11/2019 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/11/2019 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/11/2019 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/11/2019 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/11/2019 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/11/2019 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/11/2019 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/11/2019 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/11/2019 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/11/2019 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/11/2019 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/11/2019 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/11/2019 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/11/2019 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/12/2019 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/12/2019 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/12/2019 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/12/2019 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/12/2019 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/12/2019 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/12/2019 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/12/2019 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/12/2019 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/12/2019 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/12/2019 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/12/2019 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/12/2019 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/12/2019 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/12/2019 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/12/2019 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/12/2019 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/12/2019 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/12/2019 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/12/2019 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/12/2019 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/12/2019 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/12/2019 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/12/2019 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/13/2019 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/13/2019 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/13/2019 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/13/2019 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/13/2019 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/13/2019 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/13/2019 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/13/2019 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/13/2019 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/13/2019 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/13/2019 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/13/2019 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/13/2019 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/13/2019 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/13/2019 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/13/2019 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/13/2019 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/13/2019 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/13/2019 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/13/2019 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/13/2019 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/13/2019 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/13/2019 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/13/2019 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/14/2019 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/14/2019 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/14/2019 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/14/2019 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/14/2019 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/14/2019 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/14/2019 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/14/2019 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/14/2019 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/14/2019 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/14/2019 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/14/2019 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/14/2019 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/14/2019 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/14/2019 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/14/2019 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/14/2019 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/14/2019 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/14/2019 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/14/2019 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/14/2019 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/14/2019 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/14/2019 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/14/2019 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/15/2019 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/15/2019 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/15/2019 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/15/2019 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/15/2019 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/15/2019 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/15/2019 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/15/2019 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/15/2019 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/15/2019 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/15/2019 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/15/2019 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/15/2019 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/15/2019 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/15/2019 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/15/2019 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/15/2019 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/15/2019 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/15/2019 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/15/2019 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/15/2019 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/15/2019 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/15/2019 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/15/2019 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/16/2019 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/16/2019 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/16/2019 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/16/2019 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/16/2019 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/16/2019 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/16/2019 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/16/2019 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/16/2019 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/16/2019 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/16/2019 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/16/2019 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/16/2019 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/16/2019 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/16/2019 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/16/2019 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/16/2019 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/16/2019 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/16/2019 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/16/2019 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/16/2019 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/16/2019 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/16/2019 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/16/2019 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/17/2019 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/17/2019 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/17/2019 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/17/2019 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/17/2019 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/17/2019 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/17/2019 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/17/2019 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/17/2019 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/17/2019 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/17/2019 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/17/2019 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/17/2019 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/17/2019 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/17/2019 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/17/2019 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/17/2019 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/17/2019 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/17/2019 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/17/2019 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/17/2019 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/17/2019 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/17/2019 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/17/2019 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/18/2019 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/18/2019 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/18/2019 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/18/2019 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/18/2019 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/18/2019 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/18/2019 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/18/2019 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/18/2019 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/18/2019 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/18/2019 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/18/2019 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/18/2019 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/18/2019 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/18/2019 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/18/2019 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/18/2019 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/18/2019 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/18/2019 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/18/2019 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/18/2019 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/18/2019 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/18/2019 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/18/2019 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/19/2019 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/19/2019 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/19/2019 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/19/2019 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/19/2019 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/19/2019 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/19/2019 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/19/2019 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/19/2019 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/19/2019 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/19/2019 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/19/2019 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/19/2019 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/19/2019 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/19/2019 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/19/2019 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/19/2019 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/19/2019 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/19/2019 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/19/2019 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/19/2019 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/19/2019 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/19/2019 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/19/2019 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/20/2019 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/20/2019 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/20/2019 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/20/2019 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/20/2019 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/20/2019 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/20/2019 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/20/2019 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/20/2019 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/20/2019 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/20/2019 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/20/2019 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/20/2019 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/20/2019 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/20/2019 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/20/2019 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/20/2019 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/20/2019 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/20/2019 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/20/2019 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/20/2019 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/20/2019 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/20/2019 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/20/2019 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/21/2019 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/21/2019 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/21/2019 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/21/2019 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/21/2019 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/21/2019 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/21/2019 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/21/2019 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/21/2019 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/21/2019 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/21/2019 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/21/2019 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/21/2019 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/21/2019 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/21/2019 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/21/2019 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/21/2019 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/21/2019 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/21/2019 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/21/2019 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/21/2019 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/21/2019 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/21/2019 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/21/2019 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/22/2019 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/22/2019 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/22/2019 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/22/2019 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/22/2019 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/22/2019 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/22/2019 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/22/2019 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/22/2019 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/22/2019 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/22/2019 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/22/2019 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/22/2019 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/22/2019 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/22/2019 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/22/2019 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/22/2019 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/22/2019 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/22/2019 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/22/2019 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/22/2019 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/22/2019 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/22/2019 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/22/2019 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/23/2019 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/23/2019 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/23/2019 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/23/2019 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/23/2019 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
07/23/2019 05:00	1,469.9	0.0	1,469.9	104,200.0	153.2	0.00	0.0	0.0
07/23/2019 06:00	3,388.2	0.0	3,388.2	104,200.0	353.1	0.00	0.0	0.0
07/23/2019 07:00	3,561.9	0.0	3,561.9	104,200.0	371.1	0.44	0.2	0.7
07/23/2019 08:00	3,762.2	0.0	3,762.2	104,200.0	392.0	0.47	0.2	0.8
07/23/2019 09:00	4,160.0	0.0	4,160.0	104,200.0	433.5	0.52	0.3	0.9
07/23/2019 10:00	4,123.6	39.8	4,127.6	104,200.0	430.1	0.52	0.3	0.9
07/23/2019 11:00	4,160.0	1,222.5	5,382.5	104,200.0	560.9	0.67	0.3	1.1
07/23/2019 12:00	4,152.7	1,904.2	6,056.9	104,200.0	631.1	0.76	0.4	1.3
07/23/2019 13:00	4,155.7	1,921.0	6,076.7	104,200.0	633.2	0.76	0.4	1.3
07/23/2019 14:00	4,163.5	1,909.7	6,073.2	104,200.0	632.8	0.76	0.4	1.3
07/23/2019 15:00	4,154.9	1,908.8	6,063.7	104,200.0	631.8	0.76	0.4	1.3
07/23/2019 16:00	4,157.4	1,902.8	6,060.2	104,200.0	631.5	0.76	0.4	1.3
07/23/2019 17:00	4,165.4	1,918.6	6,084.0	104,200.0	634.0	0.76	0.4	1.3
07/23/2019 18:00	4,165.0	1,924.5	6,089.5	104,200.0	634.5	0.76	0.4	1.3
07/23/2019 19:00	4,167.0	1,930.0	6,097.0	104,200.0	635.3	0.76	0.4	1.3
07/23/2019 20:00	4,177.4	1,939.9	6,117.3	104,200.0	637.4	0.76	0.4	1.3
07/23/2019 21:00	4,184.9	1,947.6	6,132.5	104,200.0	639.0	0.77	0.4	1.3
07/23/2019 22:00	4,201.0	1,950.6	6,151.6	104,200.0	641.0	0.77	0.4	1.3
07/23/2019 23:00	4,224.1	1,939.4	6,163.5	104,200.0	642.2	0.77	0.4	1.3
Average/Sum#:	3,931.3	1,282.1	5,211.5	104,200.0	543.0	0.69	0.4	1.2
Minimum:	1,469.9	0.0	1,469.9	104,200.0	153.2	0.44	0.2	0.7
Maximum:	4,224.1	1,950.6	6,163.5	104,200.0	642.2	0.77	0.4	1.3
%SI	20.83	20.83	20.83	0.00	20.83	29.17	29.17	29.17

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/24/2019 00:00	4,233.2	1,907.1	6,140.3	104,200.0	639.8	0.77	0.4	1.3
07/24/2019 01:00	4,236.0	1,909.2	6,145.2	104,200.0	640.3	0.77	0.4	1.3
07/24/2019 02:00	4,239.0	1,850.0	6,089.0	104,200.0	634.5	0.76	0.4	1.3
07/24/2019 03:00	4,242.7	1,847.5	6,090.2	104,200.0	634.6	0.76	0.4	1.3
07/24/2019 04:00	4,251.8	1,851.2	6,103.0	104,200.0	635.9	0.76	0.4	1.3
07/24/2019 05:00	4,257.1	1,857.5	6,114.6	104,200.0	637.1	0.76	0.4	1.3
07/24/2019 06:00	4,259.6	1,849.6	6,109.2	104,200.0	636.6	0.76	0.4	1.3
07/24/2019 07:00	4,246.2	1,841.5	6,087.7	104,200.0	634.3	0.76	0.4	1.3
07/24/2019 08:00	4,208.5	1,843.8	6,052.3	104,200.0	630.6	0.76	0.4	1.3
07/24/2019 09:00	4,179.5	1,878.7	6,058.2	104,200.0	631.3	0.76	0.4	1.3
07/24/2019 10:00	4,167.4	1,902.3	6,069.7	104,200.0	632.5	0.76	0.4	1.3
07/24/2019 11:00	4,168.2	1,898.3	6,066.5	104,200.0	632.1	0.76	0.4	1.3
07/24/2019 12:00	4,158.0	1,917.8	6,075.8	104,200.0	633.1	0.76	0.4	1.3
07/24/2019 13:00	4,142.8	1,935.1	6,077.9	104,200.0	633.3	0.76	0.4	1.3
07/24/2019 14:00	4,145.9	1,922.5	6,068.4	104,200.0	632.3	0.76	0.4	1.3
07/24/2019 15:00	4,157.2	1,920.8	6,078.0	104,200.0	633.3	0.76	0.4	1.3
07/24/2019 16:00	4,135.5	1,912.7	6,048.2	104,200.0	630.2	0.76	0.4	1.3
07/24/2019 17:00	4,130.7	1,925.6	6,056.3	104,200.0	631.1	0.76	0.4	1.3
07/24/2019 18:00	4,127.6	1,930.8	6,058.4	104,200.0	631.3	0.76	0.4	1.3
07/24/2019 19:00	4,120.5	1,875.6	5,996.1	104,200.0	624.8	0.75	0.4	1.2
07/24/2019 20:00	4,133.8	1,894.7	6,028.5	104,200.0	628.2	0.76	0.4	1.3
07/24/2019 21:00	4,156.7	1,918.2	6,074.9	104,200.0	633.0	0.76	0.4	1.3
07/24/2019 22:00	4,147.0	1,772.1	5,919.1	104,200.0	616.8	0.74	0.4	1.2
07/24/2019 23:00	4,089.5	114.2	4,126.0	104,200.0	429.9	0.53	0.3	0.9
Average/Sum#:	4,180.6	1,811.5	5,988.9	104,200.0	624.0	0.75	0.4	1.3
Minimum:	4,089.5	114.2	4,126.0	104,200.0	429.9	0.53	0.3	0.9
Maximum:	4,259.6	1,935.1	6,145.2	104,200.0	640.3	0.77	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/25/2019 00:00	4,189.2	172.1	4,361.3	104,200.0	454.4	0.55	0.3	0.9
07/25/2019 01:00	4,198.1	141.7	4,321.4	104,200.0	450.3	0.54	0.3	0.9
07/25/2019 02:00	4,172.0	0.0	4,172.0	104,200.0	434.7	0.52	0.3	0.9
07/25/2019 03:00	3,994.3	0.0	3,994.3	104,200.0	416.2	0.50	0.2	0.8
07/25/2019 04:00	4,068.5	0.0	4,068.5	104,200.0	423.9	0.51	0.3	0.8
07/25/2019 05:00	4,102.3	0.0	4,102.3	104,200.0	427.5	0.52	0.3	0.9
07/25/2019 06:00	4,083.7	0.0	4,083.7	104,200.0	425.5	0.51	0.3	0.9
07/25/2019 07:00	4,222.4	151.2	4,255.7	104,200.0	443.4	0.55	0.3	0.9
07/25/2019 08:00	4,190.4	1,869.0	6,059.4	104,200.0	631.4	0.76	0.4	1.3
07/25/2019 09:00	4,180.6	1,915.0	6,095.6	104,200.0	635.2	0.76	0.4	1.3
07/25/2019 10:00	4,151.0	1,908.7	6,059.7	104,200.0	631.4	0.76	0.4	1.3
07/25/2019 11:00	4,142.3	1,913.1	6,055.4	104,200.0	631.0	0.76	0.4	1.3
07/25/2019 12:00	4,140.9	1,928.8	6,069.7	104,200.0	632.5	0.76	0.4	1.3
07/25/2019 13:00	4,145.5	1,932.7	6,078.2	104,200.0	633.3	0.76	0.4	1.3
07/25/2019 14:00	4,148.9	1,916.7	6,065.6	104,200.0	632.0	0.76	0.4	1.3
07/25/2019 15:00	4,137.1	1,891.8	6,028.9	104,200.0	628.2	0.76	0.4	1.3
07/25/2019 16:00	4,151.6	1,181.6	5,333.2	104,200.0	555.7	0.66	0.3	1.1
07/25/2019 17:00	4,152.6	1,035.0	5,187.6	104,200.0	540.5	0.65	0.3	1.1
07/25/2019 18:00	4,158.4	549.6	4,708.0	104,200.0	490.6	0.59	0.3	1.0
07/25/2019 19:00	4,171.2	910.0	5,081.2	104,200.0	529.5	0.64	0.3	1.1
07/25/2019 20:00	4,171.9	1,510.8	5,682.7	104,200.0	592.1	0.71	0.4	1.2
07/25/2019 21:00	4,160.4	1,190.9	5,351.3	104,200.0	557.6	0.67	0.3	1.1
07/25/2019 22:00	4,176.5	47.7	4,198.9	104,200.0	437.5	0.53	0.3	0.9
07/25/2019 23:00	4,123.8	220.1	4,218.4	104,200.0	439.6	0.54	0.3	0.9
Average/Sum#:	4,147.2	932.8	5,068.0	104,200.0	528.1	0.64	0.3	1.1
Minimum:	3,994.3	0.0	3,994.3	104,200.0	416.2	0.50	0.2	0.8
Maximum:	4,222.4	1,932.7	6,095.6	104,200.0	635.2	0.76	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/26/2019 00:00	4,197.7	605.5	4,803.2	104,200.0	500.5	0.60	0.3	1.0
07/26/2019 01:00	4,056.1	9.8	4,056.8	104,200.0	422.7	0.51	0.3	0.8
07/26/2019 02:00	4,164.5	0.0	4,164.5	104,200.0	433.9	0.52	0.3	0.9
07/26/2019 03:00	4,191.0	0.0	4,191.0	104,200.0	436.7	0.53	0.3	0.9
07/26/2019 04:00	4,180.0	0.0	4,180.0	104,200.0	435.6	0.53	0.3	0.9
07/26/2019 05:00	3,893.7	0.0	3,893.7	104,200.0	405.7	0.49	0.2	0.8
07/26/2019 06:00	4,236.4	353.3	4,572.0	104,200.0	476.4	0.57	0.3	1.0
07/26/2019 07:00	4,237.9	407.7	4,645.6	104,200.0	484.1	0.58	0.3	1.0
07/26/2019 08:00	4,217.8	406.4	4,624.2	104,200.0	481.8	0.58	0.3	1.0
07/26/2019 09:00	4,199.4	507.5	4,706.9	104,200.0	490.5	0.59	0.3	1.0
07/26/2019 10:00	4,185.8	1,049.7	5,235.5	104,200.0	545.5	0.66	0.3	1.1
07/26/2019 11:00	4,174.3	1,899.5	6,073.8	104,200.0	632.9	0.76	0.4	1.3
07/26/2019 12:00	4,172.2	1,909.0	6,081.2	104,200.0	633.7	0.76	0.4	1.3
07/26/2019 13:00	4,165.6	1,478.3	5,643.9	104,200.0	588.1	0.70	0.4	1.2
07/26/2019 14:00	4,159.6	1,476.5	5,636.1	104,200.0	587.3	0.70	0.4	1.2
07/26/2019 15:00	4,154.0	1,897.5	6,051.5	104,200.0	630.6	0.76	0.4	1.3
07/26/2019 16:00	4,161.2	1,910.5	6,071.7	104,200.0	632.7	0.76	0.4	1.3
07/26/2019 17:00	4,175.1	1,913.0	6,088.1	104,200.0	634.4	0.76	0.4	1.3
07/26/2019 18:00	4,178.8	1,699.1	5,877.9	104,200.0	612.5	0.74	0.4	1.2
07/26/2019 19:00	4,194.0	1,375.7	5,569.7	104,200.0	580.4	0.70	0.3	1.2
07/26/2019 20:00	4,188.1	1,660.0	5,848.1	104,200.0	609.4	0.73	0.4	1.2
07/26/2019 21:00	4,183.0	1,779.2	5,962.2	104,200.0	621.3	0.74	0.4	1.2
07/26/2019 22:00	4,185.2	932.8	5,118.0	104,200.0	533.3	0.64	0.3	1.1
07/26/2019 23:00	4,190.0	762.3	4,952.3	104,200.0	516.0	0.62	0.3	1.0
Average/Sum#:	4,168.4	1,001.4	5,168.7	104,200.0	538.6	0.65	0.3	1.1
Minimum:	3,893.7	0.0	3,893.7	104,200.0	405.7	0.49	0.2	0.8
Maximum:	4,237.9	1,913.0	6,088.1	104,200.0	634.4	0.76	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/27/2019 00:00	4,198.6	433.0	4,631.6	104,200.0	482.6	0.58	0.3	1.0
07/27/2019 01:00	4,204.8	351.4	4,556.2	104,200.0	474.8	0.57	0.3	1.0
07/27/2019 02:00	3,830.2	48.9	3,837.5	104,200.0	399.9	0.49	0.2	0.8
07/27/2019 03:00	3,457.5	0.0	3,457.5	104,200.0	360.3	0.43	0.2	0.7
07/27/2019 04:00	3,407.1	0.0	3,407.1	104,200.0	355.0	0.43	0.2	0.7
07/27/2019 05:00	3,272.0	0.0	3,272.0	104,200.0	340.9	0.41	0.2	0.7
07/27/2019 06:00	3,313.5	0.0	3,313.5	104,200.0	345.3	0.41	0.2	0.7
07/27/2019 07:00	3,862.6	0.0	3,862.6	104,200.0	402.5	0.48	0.2	0.8
07/27/2019 08:00	3,863.4	0.0	3,863.4	104,200.0	402.6	0.48	0.2	0.8
07/27/2019 09:00	3,625.3	0.0	3,625.3	104,200.0	377.8	0.45	0.2	0.8
07/27/2019 10:00	3,917.5	0.0	3,917.5	104,200.0	408.2	0.49	0.2	0.8
07/27/2019 11:00	4,146.2	0.0	4,146.2	104,200.0	432.0	0.52	0.3	0.9
07/27/2019 12:00	4,122.6	0.0	4,122.6	104,200.0	429.6	0.52	0.3	0.9
07/27/2019 13:00	4,102.5	0.0	4,102.5	104,200.0	427.5	0.51	0.3	0.9
07/27/2019 14:00	4,061.2	0.0	4,061.2	104,200.0	423.2	0.51	0.3	0.8
07/27/2019 15:00	3,884.7	82.8	3,898.8	104,200.0	406.3	0.49	0.2	0.8
07/27/2019 16:00	4,056.1	1,816.2	5,872.3	104,200.0	611.9	0.73	0.4	1.2
07/27/2019 17:00	4,078.7	1,827.2	5,905.9	104,200.0	615.4	0.74	0.4	1.2
07/27/2019 18:00	4,072.6	1,807.8	5,880.4	104,200.0	612.7	0.74	0.4	1.2
07/27/2019 19:00	4,048.1	1,792.4	5,840.5	104,200.0	608.6	0.73	0.4	1.2
07/27/2019 20:00	4,069.2	1,822.5	5,891.7	104,200.0	613.9	0.74	0.4	1.2
07/27/2019 21:00	4,123.5	1,809.3	5,932.8	104,200.0	618.2	0.74	0.4	1.2
07/27/2019 22:00	4,122.7	1,439.2	5,418.0	104,200.0	564.6	0.70	0.3	1.2
07/27/2019 23:00	3,654.1	0.0	3,654.1	104,200.0	380.8	0.46	0.2	0.8
Average/Sum#:	3,895.6	551.3	4,436.3	104,200.0	462.3	0.56	0.3	0.9
Minimum:	3,272.0	0.0	3,272.0	104,200.0	340.9	0.41	0.2	0.7
Maximum:	4,204.8	1,827.2	5,932.8	104,200.0	618.2	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/28/2019 00:00	3,459.5	0.0	3,459.5	104,200.0	360.5	0.43	0.2	0.7
07/28/2019 01:00	3,202.1	0.0	3,202.1	104,200.0	333.7	0.40	0.2	0.7
07/28/2019 02:00	3,011.0	0.0	3,011.0	104,200.0	313.7	0.38	0.2	0.6
07/28/2019 03:00	3,069.3	0.0	3,069.3	104,200.0	319.8	0.38	0.2	0.6
07/28/2019 04:00	3,094.2	0.0	3,094.2	104,200.0	322.4	0.39	0.2	0.6
07/28/2019 05:00	3,129.9	0.0	3,129.9	104,200.0	326.1	0.39	0.2	0.7
07/28/2019 06:00	3,154.5	0.0	3,154.5	104,200.0	328.7	0.39	0.2	0.7
07/28/2019 07:00	3,361.6	0.0	3,361.6	104,200.0	350.3	0.42	0.2	0.7
07/28/2019 08:00	3,363.0	0.0	3,363.0	104,200.0	350.4	0.42	0.2	0.7
07/28/2019 09:00	3,458.0	0.0	3,458.0	104,200.0	360.3	0.43	0.2	0.7
07/28/2019 10:00	4,071.2	0.0	4,071.2	104,200.0	424.2	0.51	0.3	0.8
07/28/2019 11:00	4,073.5	54.0	4,080.5	104,200.0	425.2	0.52	0.3	0.9
07/28/2019 12:00	4,061.1	1,295.7	5,356.8	104,200.0	558.2	0.67	0.3	1.1
07/28/2019 13:00	4,070.2	1,752.4	5,822.6	104,200.0	606.7	0.73	0.4	1.2
07/28/2019 14:00	4,061.5	1,903.1	5,964.6	104,200.0	621.5	0.75	0.4	1.2
07/28/2019 15:00	4,049.3	1,901.6	5,950.9	104,200.0	620.1	0.74	0.4	1.2
07/28/2019 16:00	4,050.0	1,898.8	5,948.8	104,200.0	619.9	0.74	0.4	1.2
07/28/2019 17:00	4,040.5	1,899.5	5,940.0	104,200.0	618.9	0.74	0.4	1.2
07/28/2019 18:00	4,060.8	1,835.9	5,896.7	104,200.0	614.4	0.74	0.4	1.2
07/28/2019 19:00	4,077.0	910.9	4,987.9	104,200.0	519.7	0.63	0.3	1.0
07/28/2019 20:00	4,102.1	1,779.4	5,881.5	104,200.0	612.9	0.73	0.4	1.2
07/28/2019 21:00	4,080.6	1,656.5	5,737.1	104,200.0	597.8	0.72	0.4	1.2
07/28/2019 22:00	4,097.7	892.9	4,990.6	104,200.0	520.0	0.63	0.3	1.0
07/28/2019 23:00	4,134.2	55.6	4,147.0	104,200.0	432.1	0.53	0.3	0.9
Average/Sum#:	3,722.2	743.2	4,461.6	104,200.0	464.9	0.56	0.3	0.9
Minimum:	3,011.0	0.0	3,011.0	104,200.0	313.7	0.38	0.2	0.6
Maximum:	4,134.2	1,903.1	5,964.6	104,200.0	621.5	0.75	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/29/2019 00:00	3,949.0	0.0	3,949.0	104,200.0	411.5	0.49	0.2	0.8
07/29/2019 01:00	3,903.9	0.0	3,903.9	104,200.0	406.8	0.49	0.2	0.8
07/29/2019 02:00	3,830.3	0.0	3,830.3	104,200.0	399.1	0.48	0.2	0.8
07/29/2019 03:00	3,794.1	0.0	3,794.1	104,200.0	395.3	0.47	0.2	0.8
07/29/2019 04:00	3,749.1	0.0	3,749.1	104,200.0	390.7	0.47	0.2	0.8
07/29/2019 05:00	4,093.7	49.7	4,098.7	104,200.0	427.1	0.52	0.3	0.9
07/29/2019 06:00	4,215.4	697.4	4,912.8	104,200.0	511.9	0.62	0.3	1.0
07/29/2019 07:00	4,213.9	1,005.8	5,219.7	104,200.0	543.9	0.65	0.3	1.1
07/29/2019 08:00	3,992.6	0.0	3,992.6	104,200.0	416.0	0.50	0.2	0.8
07/29/2019 09:00	3,939.1	13.2	3,939.5	104,200.0	410.5	0.50	0.2	0.8
07/29/2019 10:00	4,167.1	899.5	5,066.6	104,200.0	527.9	0.63	0.3	1.1
07/29/2019 11:00	4,162.0	1,327.7	5,489.7	104,200.0	572.0	0.69	0.3	1.1
07/29/2019 12:00	4,146.5	14.3	4,147.5	104,200.0	432.2	0.52	0.3	0.9
07/29/2019 13:00	4,128.7	1,630.6	5,759.3	104,200.0	600.1	0.72	0.4	1.2
07/29/2019 14:00	4,125.8	1,941.1	6,066.9	104,200.0	632.2	0.76	0.4	1.3
07/29/2019 15:00	4,109.1	1,922.6	6,031.7	104,200.0	628.5	0.75	0.4	1.3
07/29/2019 16:00	4,090.5	1,738.9	5,829.4	104,200.0	607.4	0.73	0.4	1.2
07/29/2019 17:00	4,089.4	1,752.6	5,842.0	104,200.0	608.7	0.73	0.4	1.2
07/29/2019 18:00	4,100.5	1,675.5	5,776.0	104,200.0	601.9	0.72	0.4	1.2
07/29/2019 19:00	4,111.9	985.9	5,097.8	104,200.0	531.2	0.64	0.3	1.1
07/29/2019 20:00	4,141.2	1,554.6	5,695.8	104,200.0	593.5	0.71	0.4	1.2
07/29/2019 21:00	4,163.4	1,107.5	5,270.9	104,200.0	549.2	0.66	0.3	1.1
07/29/2019 22:00	4,105.0	110.2	4,151.3	104,200.0	432.6	0.53	0.3	0.9
07/29/2019 23:00	3,009.5	0.0	3,009.5	104,200.0	313.6	0.38	0.2	0.6
Average/Sum#:	4,013.8	767.8	4,776.0	104,200.0	497.7	0.60	0.3	1.0
Minimum:	3,009.5	0.0	3,009.5	104,200.0	313.6	0.38	0.2	0.6
Maximum:	4,215.4	1,941.1	6,066.9	104,200.0	632.2	0.76	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/30/2019 00:00	2,870.1	0.0	2,870.1	104,200.0	299.1	0.36	0.2	0.6
07/30/2019 01:00	2,850.8	0.0	2,850.8	104,200.0	297.1	0.36	0.2	0.6
07/30/2019 02:00	2,847.8	0.0	2,847.8	104,200.0	296.7	0.36	0.2	0.6
07/30/2019 03:00	2,847.9	0.0	2,847.9	104,200.0	296.8	0.36	0.2	0.6
07/30/2019 04:00	2,850.1	0.0	2,850.1	104,200.0	297.0	0.36	0.2	0.6
07/30/2019 05:00	3,286.4	0.0	3,286.4	104,200.0	342.4	0.41	0.2	0.7
07/30/2019 06:00	3,386.1	0.0	3,386.1	104,200.0	352.8	0.42	0.2	0.7
07/30/2019 07:00	3,638.7	0.0	3,638.7	104,200.0	379.2	0.46	0.2	0.8
07/30/2019 08:00	3,632.2	0.0	3,632.2	104,200.0	378.5	0.45	0.2	0.8
07/30/2019 09:00	3,507.0	0.0	3,507.0	104,200.0	365.4	0.44	0.2	0.7
07/30/2019 10:00	3,475.5	0.0	3,475.5	104,200.0	362.1	0.43	0.2	0.7
07/30/2019 11:00	3,302.0	0.0	3,302.0	104,200.0	344.1	0.41	0.2	0.7
07/30/2019 12:00	3,192.4	0.0	3,192.4	104,200.0	332.6	0.40	0.2	0.7
07/30/2019 13:00	3,026.1	0.0	3,026.1	104,200.0	315.3	0.38	0.2	0.6
07/30/2019 14:00	3,056.5	0.0	3,056.5	104,200.0	318.5	0.38	0.2	0.6
07/30/2019 15:00	3,049.5	0.0	3,049.5	104,200.0	317.8	0.38	0.2	0.6
07/30/2019 16:00	4,059.7	10.6	4,061.0	104,200.0	423.2	0.51	0.3	0.8
07/30/2019 17:00	4,134.0	35.4	4,145.3	104,200.0	431.9	0.52	0.3	0.9
07/30/2019 18:00	3,641.9	0.0	3,641.9	104,200.0	379.5	0.45	0.2	0.8
07/30/2019 19:00	3,394.5	0.0	3,394.5	104,200.0	353.7	0.42	0.2	0.7
07/30/2019 20:00	3,492.3	0.0	3,492.3	104,200.0	363.9	0.44	0.2	0.7
07/30/2019 21:00	3,326.5	0.0	3,326.5	104,200.0	346.6	0.42	0.2	0.7
07/30/2019 22:00	3,533.7	0.0	3,533.7	104,200.0	368.2	0.44	0.2	0.7
07/30/2019 23:00	3,158.8	0.0	3,158.8	104,200.0	329.1	0.40	0.2	0.7
Average/Sum#:	3,315.0	1.9	3,315.5	104,200.0	345.5	0.42	0.2	0.7
Minimum:	2,847.8	0.0	2,847.8	104,200.0	296.7	0.36	0.2	0.6
Maximum:	4,134.0	35.4	4,145.3	104,200.0	431.9	0.52	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/31/2019 00:00	3,019.6	0.0	3,019.6	104,200.0	314.6	0.38	0.2	0.6
07/31/2019 01:00	2,920.9	0.0	2,920.9	104,200.0	304.4	0.36	0.2	0.6
07/31/2019 02:00	2,918.1	0.0	2,918.1	104,200.0	304.1	0.36	0.2	0.6
07/31/2019 03:00	2,924.5	0.0	2,924.5	104,200.0	304.7	0.36	0.2	0.6
07/31/2019 04:00	2,909.0	0.0	2,909.0	104,200.0	303.1	0.36	0.2	0.6
07/31/2019 05:00	2,877.4	0.0	2,877.4	104,200.0	299.8	0.36	0.2	0.6
07/31/2019 06:00	2,926.7	0.0	2,926.7	104,200.0	305.0	0.37	0.2	0.6
07/31/2019 07:00	3,045.9	0.0	3,045.9	104,200.0	317.4	0.38	0.2	0.6
07/31/2019 08:00	3,122.8	0.0	3,122.8	104,200.0	325.4	0.39	0.2	0.7
07/31/2019 09:00	2,943.6	0.0	2,943.6	104,200.0	306.7	0.37	0.2	0.6
07/31/2019 10:00	2,862.6	0.0	2,862.6	104,200.0	298.3	0.36	0.2	0.6
07/31/2019 11:00	2,876.0	0.0	2,876.0	104,200.0	299.7	0.36	0.2	0.6
07/31/2019 12:00	3,455.9	0.0	3,455.9	104,200.0	360.1	0.43	0.2	0.7
07/31/2019 13:00	3,800.4	2.2	3,800.5	104,200.0	396.0	0.47	0.2	0.8
07/31/2019 14:00	4,129.6	1,400.8	5,530.4	104,200.0	576.3	0.69	0.3	1.2
07/31/2019 15:00	4,109.7	1,276.9	5,386.6	104,200.0	561.3	0.67	0.3	1.1
07/31/2019 16:00	4,110.5	1,175.5	5,286.0	104,200.0	550.8	0.66	0.3	1.1
07/31/2019 17:00	4,121.5	1,106.9	5,228.4	104,200.0	544.8	0.65	0.3	1.1
07/31/2019 18:00	4,132.7	1,100.8	5,233.5	104,200.0	545.3	0.65	0.3	1.1
07/31/2019 19:00	4,156.3	1,146.7	5,303.0	104,200.0	552.6	0.66	0.3	1.1
07/31/2019 20:00	3,896.2	37.4	3,901.8	104,200.0	406.6	0.49	0.2	0.8
07/31/2019 21:00	3,659.1	0.0	3,659.1	104,200.0	381.3	0.46	0.2	0.8
07/31/2019 22:00	3,039.6	0.0	3,039.6	104,200.0	316.7	0.38	0.2	0.6
07/31/2019 23:00	2,927.3	0.0	2,927.3	104,200.0	305.0	0.37	0.2	0.6
Average/Sum#:	3,370.2	302.0	3,670.8	104,200.0	382.5	0.46	0.2	0.8
Minimum:	2,862.6	0.0	2,862.6	104,200.0	298.3	0.36	0.2	0.6
Maximum:	4,156.3	1,400.8	5,530.4	104,200.0	576.3	0.69	0.3	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/01/2019 00:00	2,902.1	0.0	2,902.1	104,200.0	302.4	0.36	0.2	0.6
08/01/2019 01:00	2,890.2	0.0	2,890.2	104,200.0	301.2	0.36	0.2	0.6
08/01/2019 02:00	2,878.9	0.0	2,878.9	104,200.0	300.0	0.36	0.2	0.6
08/01/2019 03:00	2,867.7	0.0	2,867.7	104,200.0	298.8	0.36	0.2	0.6
08/01/2019 04:00	2,870.1	0.0	2,870.1	104,200.0	299.1	0.36	0.2	0.6
08/01/2019 05:00	2,883.9	0.0	2,883.9	104,200.0	300.5	0.36	0.2	0.6
08/01/2019 06:00	2,901.3	0.0	2,901.3	104,200.0	302.3	0.36	0.2	0.6
08/01/2019 07:00	2,963.9	0.0	2,963.9	104,200.0	308.8	0.37	0.2	0.6
08/01/2019 08:00	2,933.0	0.0	2,933.0	104,200.0	305.6	0.37	0.2	0.6
08/01/2019 09:00	3,000.1	0.0	3,000.1	104,200.0	312.6	0.38	0.2	0.6
08/01/2019 10:00	2,892.2	0.0	2,892.2	104,200.0	301.4	0.36	0.2	0.6
08/01/2019 11:00	2,946.2	0.0	2,946.2	104,200.0	307.0	0.37	0.2	0.6
08/01/2019 12:00	4,022.1	0.0	4,022.1	104,200.0	419.1	0.50	0.3	0.8
08/01/2019 13:00	4,132.5	0.0	4,132.5	104,200.0	430.6	0.52	0.3	0.9
08/01/2019 14:00	4,120.0	0.0	4,120.0	104,200.0	429.3	0.52	0.3	0.9
08/01/2019 15:00	4,108.8	27.5	4,112.4	104,200.0	428.5	0.52	0.3	0.9
08/01/2019 16:00	4,114.1	496.4	4,610.5	104,200.0	480.4	0.58	0.3	1.0
08/01/2019 17:00	4,125.2	558.0	4,683.2	104,200.0	488.0	0.58	0.3	1.0
08/01/2019 18:00	4,144.7	1,212.6	5,357.3	104,200.0	558.2	0.67	0.3	1.1
08/01/2019 19:00	4,132.7	22.9	4,135.0	104,200.0	430.9	0.52	0.3	0.9
08/01/2019 20:00	3,063.0	0.0	3,063.0	104,200.0	319.2	0.38	0.2	0.6
08/01/2019 21:00	2,955.8	0.0	2,955.8	104,200.0	308.0	0.37	0.2	0.6
08/01/2019 22:00	2,944.2	0.0	2,944.2	104,200.0	306.8	0.37	0.2	0.6
08/01/2019 23:00	2,915.9	0.0	2,915.9	104,200.0	303.8	0.36	0.2	0.6
Average/Sum#:	3,321.2	96.6	3,415.9	104,200.0	355.9	0.43	0.2	0.7
Minimum:	2,867.7	0.0	2,867.7	104,200.0	298.8	0.36	0.2	0.6
Maximum:	4,144.7	1,212.6	5,357.3	104,200.0	558.2	0.67	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/02/2019 00:00	2,906.2	0.0	2,906.2	104,200.0	302.8	0.36	0.2	0.6
08/02/2019 01:00	2,903.9	0.0	2,903.9	104,200.0	302.6	0.36	0.2	0.6
08/02/2019 02:00	2,894.6	0.0	2,894.6	104,200.0	301.6	0.36	0.2	0.6
08/02/2019 03:00	2,886.4	0.0	2,886.4	104,200.0	300.8	0.36	0.2	0.6
08/02/2019 04:00	2,868.2	0.0	2,868.2	104,200.0	298.9	0.36	0.2	0.6
08/02/2019 05:00	2,862.7	0.0	2,862.7	104,200.0	298.3	0.36	0.2	0.6
08/02/2019 06:00	2,874.7	0.0	2,874.7	104,200.0	299.5	0.36	0.2	0.6
08/02/2019 07:00	2,878.5	0.0	2,878.5	104,200.0	299.9	0.36	0.2	0.6
08/02/2019 08:00	2,870.1	0.0	2,870.1	104,200.0	299.1	0.36	0.2	0.6
08/02/2019 09:00	2,866.3	0.0	2,866.3	104,200.0	298.7	0.36	0.2	0.6
08/02/2019 10:00	2,865.3	0.0	2,865.3	104,200.0	298.6	0.36	0.2	0.6
08/02/2019 11:00	2,897.2	0.0	2,897.2	104,200.0	301.9	0.36	0.2	0.6
08/02/2019 12:00	3,193.8	0.0	3,193.8	104,200.0	332.8	0.40	0.2	0.7
08/02/2019 13:00	4,058.6	286.2	4,253.2	104,200.0	443.2	0.54	0.3	0.9
08/02/2019 14:00	4,114.6	261.1	4,375.7	104,200.0	455.9	0.55	0.3	0.9
08/02/2019 15:00	4,105.8	1,539.0	5,644.8	104,200.0	588.2	0.71	0.4	1.2
08/02/2019 16:00	4,104.7	1,599.9	5,704.6	104,200.0	594.4	0.71	0.4	1.2
08/02/2019 17:00	4,085.6	1,682.3	5,767.9	104,200.0	601.0	0.72	0.4	1.2
08/02/2019 18:00	4,084.1	936.0	5,020.1	104,200.0	523.1	0.63	0.3	1.0
08/02/2019 19:00	4,100.9	246.1	4,347.0	104,200.0	453.0	0.54	0.3	0.9
08/02/2019 20:00	3,434.9	0.0	3,434.9	104,200.0	357.9	0.43	0.2	0.7
08/02/2019 21:00	3,011.4	0.0	3,011.4	104,200.0	313.8	0.38	0.2	0.6
08/02/2019 22:00	2,975.0	0.0	2,975.0	104,200.0	310.0	0.37	0.2	0.6
08/02/2019 23:00	2,984.9	0.0	2,984.9	104,200.0	311.0	0.37	0.2	0.6
Average/Sum#:	3,284.5	272.9	3,553.6	104,200.0	370.3	0.44	0.2	0.7
Minimum:	2,862.7	0.0	2,862.7	104,200.0	298.3	0.36	0.2	0.6
Maximum:	4,114.6	1,682.3	5,767.9	104,200.0	601.0	0.72	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/03/2019 00:00	2,962.9	0.0	2,962.9	104,200.0	308.7	0.37	0.2	0.6
08/03/2019 01:00	2,859.4	0.0	2,859.4	104,200.0	297.9	0.36	0.2	0.6
08/03/2019 02:00	2,857.3	0.0	2,857.3	104,200.0	297.7	0.36	0.2	0.6
08/03/2019 03:00	2,859.5	0.0	2,859.5	104,200.0	298.0	0.36	0.2	0.6
08/03/2019 04:00	2,862.0	0.0	2,862.0	104,200.0	298.2	0.36	0.2	0.6
08/03/2019 05:00	2,857.5	0.0	2,857.5	104,200.0	297.8	0.36	0.2	0.6
08/03/2019 06:00	2,864.5	0.0	2,864.5	104,200.0	298.5	0.36	0.2	0.6
08/03/2019 07:00	2,963.4	0.0	2,963.4	104,200.0	308.8	0.37	0.2	0.6
08/03/2019 08:00	2,942.7	0.0	2,942.7	104,200.0	306.6	0.37	0.2	0.6
08/03/2019 09:00	2,939.8	0.0	2,939.8	104,200.0	306.3	0.37	0.2	0.6
08/03/2019 10:00	3,009.1	0.0	3,009.1	104,200.0	313.5	0.38	0.2	0.6
08/03/2019 11:00	3,101.8	0.0	3,101.8	104,200.0	323.2	0.39	0.2	0.6
08/03/2019 12:00	3,282.3	0.0	3,282.3	104,200.0	342.0	0.41	0.2	0.7
08/03/2019 13:00	4,085.0	366.4	4,444.1	104,200.0	463.1	0.56	0.3	0.9
08/03/2019 14:00	4,078.3	771.6	4,849.9	104,200.0	505.4	0.61	0.3	1.0
08/03/2019 15:00	4,063.8	1,925.4	5,989.2	104,200.0	624.1	0.75	0.4	1.2
08/03/2019 16:00	4,074.8	1,872.2	5,947.0	104,200.0	619.7	0.74	0.4	1.2
08/03/2019 17:00	4,072.4	1,686.1	5,758.5	104,200.0	600.0	0.72	0.4	1.2
08/03/2019 18:00	4,078.2	1,829.0	5,907.2	104,200.0	615.5	0.74	0.4	1.2
08/03/2019 19:00	4,115.5	1,330.6	5,446.1	104,200.0	567.5	0.68	0.3	1.1
08/03/2019 20:00	4,132.5	404.9	4,525.3	104,200.0	471.5	0.57	0.3	0.9
08/03/2019 21:00	3,685.2	0.0	3,685.2	104,200.0	384.0	0.46	0.2	0.8
08/03/2019 22:00	3,355.3	0.0	3,355.3	104,200.0	349.6	0.42	0.2	0.7
08/03/2019 23:00	3,044.4	0.0	3,044.4	104,200.0	317.2	0.38	0.2	0.6
Average/Sum#:	3,381.2	424.4	3,804.8	104,200.0	396.5	0.48	0.3	0.8
Minimum:	2,857.3	0.0	2,857.3	104,200.0	297.7	0.36	0.2	0.6
Maximum:	4,132.5	1,925.4	5,989.2	104,200.0	624.1	0.75	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/04/2019 00:00	2,979.8	0.0	2,979.8	104,200.0	310.5	0.37	0.2	0.6
08/04/2019 01:00	2,965.9	0.0	2,965.9	104,200.0	309.0	0.37	0.2	0.6
08/04/2019 02:00	2,951.6	0.0	2,951.6	104,200.0	307.6	0.37	0.2	0.6
08/04/2019 03:00	2,931.3	0.0	2,931.3	104,200.0	305.4	0.37	0.2	0.6
08/04/2019 04:00	2,873.2	0.0	2,873.2	104,200.0	299.4	0.36	0.2	0.6
08/04/2019 05:00	2,915.9	0.0	2,915.9	104,200.0	303.8	0.37	0.2	0.6
08/04/2019 06:00	2,870.0	0.0	2,870.0	104,200.0	299.1	0.36	0.2	0.6
08/04/2019 07:00	2,887.9	0.0	2,887.9	104,200.0	300.9	0.36	0.2	0.6
08/04/2019 08:00	2,910.9	0.0	2,910.9	104,200.0	303.3	0.36	0.2	0.6
08/04/2019 09:00	2,903.6	0.0	2,903.6	104,200.0	302.6	0.36	0.2	0.6
08/04/2019 10:00	2,940.3	0.0	2,940.3	104,200.0	306.4	0.37	0.2	0.6
08/04/2019 11:00	3,176.2	0.0	3,176.2	104,200.0	331.0	0.40	0.2	0.7
08/04/2019 12:00	3,909.1	535.8	4,214.5	104,200.0	439.2	0.56	0.3	0.9
08/04/2019 13:00	4,094.5	1,412.7	5,507.2	104,200.0	573.9	0.69	0.3	1.1
08/04/2019 14:00	4,085.5	1,329.5	5,415.0	104,200.0	564.2	0.68	0.3	1.1
08/04/2019 15:00	4,093.5	1,465.6	5,559.1	104,200.0	579.3	0.70	0.3	1.2
08/04/2019 16:00	4,074.3	1,185.3	5,259.6	104,200.0	548.1	0.66	0.3	1.1
08/04/2019 17:00	4,079.4	1,403.6	5,483.0	104,200.0	571.3	0.69	0.3	1.1
08/04/2019 18:00	4,090.8	1,808.2	5,899.0	104,200.0	614.7	0.74	0.4	1.2
08/04/2019 19:00	4,113.9	1,818.0	5,931.9	104,200.0	618.1	0.74	0.4	1.2
08/04/2019 20:00	4,135.3	1,361.2	5,496.5	104,200.0	572.7	0.69	0.3	1.1
08/04/2019 21:00	4,143.6	463.5	4,607.1	104,200.0	480.1	0.58	0.3	1.0
08/04/2019 22:00	4,109.1	14.2	4,111.2	104,200.0	428.4	0.52	0.3	0.9
08/04/2019 23:00	3,069.4	0.0	3,069.4	104,200.0	319.8	0.39	0.2	0.6
Average/Sum#:	3,471.0	533.2	3,994.2	104,200.0	416.2	0.50	0.3	0.8
Minimum:	2,870.0	0.0	2,870.0	104,200.0	299.1	0.36	0.2	0.6
Maximum:	4,143.6	1,818.0	5,931.9	104,200.0	618.1	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/05/2019 00:00	2,850.8	0.0	2,850.8	104,200.0	297.1	0.36	0.2	0.6
08/05/2019 01:00	2,854.1	0.0	2,854.1	104,200.0	297.4	0.36	0.2	0.6
08/05/2019 02:00	2,854.2	0.0	2,854.2	104,200.0	297.4	0.36	0.2	0.6
08/05/2019 03:00	2,851.4	0.0	2,851.4	104,200.0	297.1	0.36	0.2	0.6
08/05/2019 04:00	2,849.3	0.0	2,849.3	104,200.0	296.9	0.36	0.2	0.6
08/05/2019 05:00	2,849.7	0.0	2,849.7	104,200.0	296.9	0.36	0.2	0.6
08/05/2019 06:00	2,964.7	0.0	2,964.7	104,200.0	308.9	0.37	0.2	0.6
08/05/2019 07:00	2,959.9	0.0	2,959.9	104,200.0	308.4	0.37	0.2	0.6
08/05/2019 08:00	2,941.9	0.0	2,941.9	104,200.0	306.5	0.37	0.2	0.6
08/05/2019 09:00	2,977.2	0.0	2,977.2	104,200.0	310.2	0.37	0.2	0.6
08/05/2019 10:00	2,979.3	0.0	2,979.3	104,200.0	310.4	0.37	0.2	0.6
08/05/2019 11:00	3,073.8	0.0	3,073.8	104,200.0	320.3	0.38	0.2	0.6
08/05/2019 12:00	3,693.6	0.0	3,693.6	104,200.0	384.9	0.46	0.2	0.8
08/05/2019 13:00	4,039.4	0.0	4,039.4	104,200.0	420.9	0.51	0.3	0.8
08/05/2019 14:00	4,006.8	0.0	4,006.8	104,200.0	417.5	0.50	0.3	0.8
08/05/2019 15:00	4,083.8	1,475.0	5,558.8	104,200.0	579.2	0.69	0.3	1.2
08/05/2019 16:00	4,079.5	1,550.1	5,629.6	104,200.0	586.6	0.71	0.4	1.2
08/05/2019 17:00	4,088.8	1,923.4	6,012.2	104,200.0	626.5	0.75	0.4	1.3
08/05/2019 18:00	4,088.6	1,922.6	6,011.2	104,200.0	626.4	0.75	0.4	1.3
08/05/2019 19:00	4,101.8	1,352.1	5,453.9	104,200.0	568.3	0.68	0.3	1.1
08/05/2019 20:00	4,142.1	121.1	4,182.1	104,200.0	435.8	0.53	0.3	0.9
08/05/2019 21:00	3,838.5	0.0	3,838.5	104,200.0	400.0	0.48	0.2	0.8
08/05/2019 22:00	3,146.8	0.0	3,146.8	104,200.0	327.9	0.39	0.2	0.7
08/05/2019 23:00	2,871.6	0.0	2,871.6	104,200.0	299.2	0.36	0.2	0.6
Average/Sum#:	3,382.8	347.7	3,727.1	104,200.0	388.4	0.47	0.2	0.8
Minimum:	2,849.3	0.0	2,849.3	104,200.0	296.9	0.36	0.2	0.6
Maximum:	4,142.1	1,923.4	6,012.2	104,200.0	626.5	0.75	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/06/2019 00:00	2,840.5	0.0	2,840.5	104,200.0	296.0	0.36	0.2	0.6
08/06/2019 01:00	2,841.9	0.0	2,841.9	104,200.0	296.1	0.36	0.2	0.6
08/06/2019 02:00	2,844.4	0.0	2,844.4	104,200.0	296.4	0.36	0.2	0.6
08/06/2019 03:00	2,884.0	0.0	2,884.0	104,200.0	300.5	0.36	0.2	0.6
08/06/2019 04:00	2,923.2	0.0	2,923.2	104,200.0	304.6	0.36	0.2	0.6
08/06/2019 05:00	3,101.5	0.0	3,101.5	104,200.0	323.2	0.39	0.2	0.6
08/06/2019 06:00	3,095.2	0.0	3,095.2	104,200.0	322.5	0.39	0.2	0.6
08/06/2019 07:00	3,093.3	0.0	3,093.3	104,200.0	322.3	0.39	0.2	0.6
08/06/2019 08:00	3,082.0	0.0	3,082.0	104,200.0	321.1	0.39	0.2	0.6
08/06/2019 09:00	2,894.4	0.0	2,894.4	104,200.0	301.6	0.36	0.2	0.6
08/06/2019 10:00	3,213.2	0.0	3,213.2	104,200.0	334.8	0.40	0.2	0.7
08/06/2019 11:00	3,836.3	0.0	3,836.3	104,200.0	399.7	0.48	0.2	0.8
08/06/2019 12:00	4,031.5	0.0	4,031.5	104,200.0	420.1	0.50	0.3	0.8
08/06/2019 13:00	4,081.4	306.2	4,341.7	104,200.0	452.4	0.55	0.3	0.9
08/06/2019 14:00	4,080.0	1,891.6	5,971.6	104,200.0	622.2	0.75	0.4	1.2
08/06/2019 15:00	4,070.9	1,750.0	5,820.9	104,200.0	606.5	0.73	0.4	1.2
08/06/2019 16:00	4,057.0	1,788.8	5,845.8	104,200.0	609.1	0.73	0.4	1.2
08/06/2019 17:00	4,084.1	1,908.6	5,992.7	104,200.0	624.4	0.75	0.4	1.2
08/06/2019 18:00	4,125.5	1,523.8	5,649.3	104,200.0	588.7	0.71	0.4	1.2
08/06/2019 19:00	4,131.7	616.2	4,747.9	104,200.0	494.7	0.59	0.3	1.0
08/06/2019 20:00	4,129.3	700.9	4,830.2	104,200.0	503.3	0.60	0.3	1.0
08/06/2019 21:00	4,095.2	0.0	4,095.2	104,200.0	426.7	0.51	0.3	0.9
08/06/2019 22:00	3,285.6	0.0	3,285.6	104,200.0	342.4	0.41	0.2	0.7
08/06/2019 23:00	2,900.8	0.0	2,900.8	104,200.0	302.3	0.36	0.2	0.6
Average/Sum#:	3,488.5	436.9	3,923.5	104,200.0	408.8	0.49	0.3	0.8
Minimum:	2,840.5	0.0	2,840.5	104,200.0	296.0	0.36	0.2	0.6
Maximum:	4,131.7	1,908.6	5,992.7	104,200.0	624.4	0.75	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/07/2019 00:00	2,844.6	0.0	2,844.6	104,200.0	296.4	0.36	0.2	0.6
08/07/2019 01:00	2,841.1	0.0	2,841.1	104,200.0	296.0	0.36	0.2	0.6
08/07/2019 02:00	2,841.9	0.0	2,841.9	104,600.0	297.3	0.36	0.2	0.6
08/07/2019 03:00	2,847.2	0.0	2,847.2	104,600.0	297.8	0.36	0.2	0.6
08/07/2019 04:00	2,865.3	0.0	2,865.3	104,600.0	299.7	0.36	0.2	0.6
08/07/2019 05:00	2,870.6	0.0	2,870.6	104,600.0	300.3	0.36	0.2	0.6
08/07/2019 06:00	2,966.3	0.0	2,966.3	104,600.0	310.3	0.37	0.2	0.6
08/07/2019 07:00	2,956.3	0.0	2,956.3	104,600.0	309.2	0.37	0.2	0.6
08/07/2019 08:00	3,048.8	0.0	3,048.8	104,600.0	318.9	0.38	0.2	0.6
08/07/2019 09:00	3,069.2	0.0	3,069.2	104,600.0	321.0	0.38	0.2	0.6
08/07/2019 10:00	3,073.2	0.0	3,073.2	104,600.0	321.5	0.38	0.2	0.6
08/07/2019 11:00	3,230.0	0.0	3,230.0	104,600.0	337.9	0.40	0.2	0.7
08/07/2019 12:00	3,728.6	0.0	3,728.6	104,600.0	390.0	0.46	0.2	0.8
08/07/2019 13:00	4,112.5	249.6	4,349.6	104,600.0	455.0	0.54	0.3	0.9
08/07/2019 14:00	4,109.8	1,150.7	5,260.5	104,600.0	550.2	0.66	0.3	1.1
08/07/2019 15:00	4,098.7	1,450.0	5,548.7	104,600.0	580.4	0.69	0.3	1.2
08/07/2019 16:00	4,076.1	1,631.5	5,707.6	104,600.0	597.0	0.71	0.4	1.2
08/07/2019 17:00	4,092.6	1,929.2	6,021.8	104,600.0	629.9	0.75	0.4	1.3
08/07/2019 18:00	4,112.3	1,512.7	5,625.0	104,600.0	588.4	0.70	0.4	1.2
08/07/2019 19:00	4,123.6	230.3	4,324.0	104,600.0	452.3	0.55	0.3	0.9
08/07/2019 20:00	3,566.7	0.0	3,566.7	104,600.0	373.1	0.44	0.2	0.7
08/07/2019 21:00	3,360.0	0.0	3,360.0	104,600.0	351.5	0.42	0.2	0.7
08/07/2019 22:00	2,856.0	0.0	2,856.0	104,600.0	298.7	0.36	0.2	0.6
08/07/2019 23:00	3,214.0	0.0	3,214.0	104,600.0	336.2	0.40	0.2	0.7
Average/Sum#:	3,371.1	339.8	3,709.0	104,566.7	387.9	0.46	0.2	0.8
Minimum:	2,841.1	0.0	2,841.1	104,200.0	296.0	0.36	0.2	0.6
Maximum:	4,123.6	1,929.2	6,021.8	104,600.0	629.9	0.75	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/08/2019 00:00	2,934.6	0.0	2,934.6	104,600.0	307.0	0.37	0.2	0.6
08/08/2019 01:00	2,845.6	0.0	2,845.6	104,600.0	297.6	0.36	0.2	0.6
08/08/2019 02:00	2,847.7	0.0	2,847.7	104,600.0	297.9	0.36	0.2	0.6
08/08/2019 03:00	2,847.1	0.0	2,847.1	104,600.0	297.8	0.36	0.2	0.6
08/08/2019 04:00	2,700.2	0.0	2,700.2	104,600.0	282.4	0.36	0.2	0.6
08/08/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/08/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/08/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/08/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/08/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/08/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/08/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/08/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/08/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/08/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/08/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/08/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/08/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/08/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/08/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/08/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/08/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/08/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/08/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	2,835.0	0.0	2,835.0	104,600.0	296.5	0.36	0.2	0.6
Minimum:	2,700.2	0.0	2,700.2	104,600.0	282.4	0.36	0.2	0.6
Maximum:	2,934.6	0.0	2,934.6	104,600.0	307.0	0.37	0.2	0.6
%SI	79.17	79.17	79.17	0.00	79.17	79.17	79.17	79.17

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/09/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/09/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/09/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/09/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/09/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/09/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/09/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/09/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/09/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/09/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/09/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/09/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/09/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/09/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/09/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/09/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/09/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/09/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/09/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/09/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/09/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/09/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/09/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/09/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/10/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/10/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/10/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/10/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/10/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/10/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/10/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/10/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/10/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/10/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/10/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/10/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/10/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/10/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/10/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/10/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/10/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/10/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/10/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/10/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/10/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/10/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/10/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/10/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/11/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/11/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/11/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/11/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/11/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/11/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/11/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/11/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/11/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/11/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/11/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/11/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/11/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/11/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/11/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/11/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/11/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/11/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/11/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/11/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/11/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/11/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/11/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/11/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/12/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/12/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/12/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/12/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/12/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/12/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/12/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/12/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/12/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/12/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/12/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/12/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/12/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/12/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/12/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/12/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/12/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/12/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/12/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/12/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/12/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/12/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/12/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/12/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/13/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/13/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/13/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/13/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/13/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/13/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/13/2019 06:00	1,526.4	0.0	1,526.4	104,600.0	159.7	0.00	0.0	0.0
08/13/2019 07:00	4,178.9	0.0	4,178.9	104,600.0	437.1	0.53	0.3	0.9
08/13/2019 08:00	4,196.0	0.0	4,196.0	104,600.0	438.9	0.52	0.3	0.9
08/13/2019 09:00	3,738.2	0.0	3,738.2	104,600.0	391.0	0.47	0.2	0.8
08/13/2019 10:00	3,616.7	0.0	3,616.7	104,600.0	378.3	0.45	0.2	0.8
08/13/2019 11:00	4,071.7	0.0	4,071.7	104,600.0	425.9	0.51	0.3	0.8
08/13/2019 12:00	3,619.1	0.0	3,619.1	104,600.0	378.6	0.45	0.2	0.8
08/13/2019 13:00	3,568.2	0.0	3,568.2	104,600.0	373.2	0.45	0.2	0.7
08/13/2019 14:00	3,642.1	10.1	3,642.8	104,600.0	381.0	0.46	0.2	0.8
08/13/2019 15:00	4,093.0	1,830.9	5,923.9	104,600.0	619.6	0.74	0.4	1.2
08/13/2019 16:00	4,089.4	1,949.5	6,038.9	104,600.0	631.7	0.76	0.4	1.3
08/13/2019 17:00	4,107.2	1,963.7	6,070.9	104,600.0	635.0	0.76	0.4	1.3
08/13/2019 18:00	4,108.1	1,319.8	5,427.9	104,600.0	567.8	0.68	0.3	1.1
08/13/2019 19:00	4,108.5	1,850.3	5,958.8	104,600.0	623.3	0.75	0.4	1.2
08/13/2019 20:00	4,131.0	1,700.2	5,831.2	104,600.0	609.9	0.73	0.4	1.2
08/13/2019 21:00	4,146.8	1,197.3	5,344.1	104,600.0	559.0	0.67	0.3	1.1
08/13/2019 22:00	4,144.9	498.9	4,643.8	104,600.0	485.7	0.58	0.3	1.0
08/13/2019 23:00	4,137.5	1,267.4	5,404.9	104,600.0	565.4	0.67	0.3	1.1
Average/Sum#:	3,845.8	754.9	4,600.1	104,600.0	481.2	0.60	0.3	1.0
Minimum:	1,526.4	0.0	1,526.4	104,600.0	159.7	0.45	0.2	0.7
Maximum:	4,196.0	1,963.7	6,070.9	104,600.0	635.0	0.76	0.4	1.3
%SI	25.00	25.00	25.00	0.00	25.00	29.17	29.17	29.17

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/14/2019 00:00	4,154.6	840.1	4,994.7	104,600.0	522.4	0.62	0.3	1.0
08/14/2019 01:00	4,164.9	706.6	4,871.5	104,600.0	509.6	0.61	0.3	1.0
08/14/2019 02:00	4,178.3	404.1	4,582.4	104,600.0	479.3	0.57	0.3	1.0
08/14/2019 03:00	4,192.6	441.7	4,634.3	104,600.0	484.7	0.58	0.3	1.0
08/14/2019 04:00	4,219.9	1,528.3	5,748.2	104,600.0	601.3	0.72	0.4	1.2
08/14/2019 05:00	4,217.9	1,596.9	5,814.8	104,600.0	608.2	0.73	0.4	1.2
08/14/2019 06:00	4,221.1	1,686.3	5,772.5	104,600.0	603.8	0.74	0.4	1.2
08/14/2019 07:00	3,496.2	0.0	3,496.2	104,600.0	365.7	0.44	0.2	0.7
08/14/2019 08:00	2,894.6	0.0	2,894.6	104,600.0	302.8	0.36	0.2	0.6
08/14/2019 09:00	2,852.0	0.0	2,852.0	104,600.0	298.3	0.36	0.2	0.6
08/14/2019 10:00	2,858.0	0.0	2,858.0	104,600.0	298.9	0.36	0.2	0.6
08/14/2019 11:00	2,872.6	0.0	2,872.6	104,600.0	300.5	0.36	0.2	0.6
08/14/2019 12:00	2,915.0	0.0	2,915.0	104,600.0	304.9	0.37	0.2	0.6
08/14/2019 13:00	4,039.9	44.0	4,051.8	104,600.0	423.8	0.51	0.3	0.9
08/14/2019 14:00	4,059.0	231.6	4,290.6	104,600.0	448.8	0.54	0.3	0.9
08/14/2019 15:00	4,062.6	1,816.3	5,878.9	104,600.0	614.9	0.73	0.4	1.2
08/14/2019 16:00	4,055.3	1,879.6	5,934.9	104,600.0	620.8	0.74	0.4	1.2
08/14/2019 17:00	4,065.2	1,865.5	5,930.7	104,600.0	620.4	0.74	0.4	1.2
08/14/2019 18:00	4,078.0	1,085.0	5,163.0	104,600.0	540.0	0.64	0.3	1.1
08/14/2019 19:00	4,088.1	1,597.3	5,685.4	104,600.0	594.7	0.71	0.4	1.2
08/14/2019 20:00	4,047.9	898.6	4,748.8	104,600.0	496.7	0.62	0.3	1.0
08/14/2019 21:00	3,760.3	0.0	3,760.3	104,600.0	393.3	0.47	0.2	0.8
08/14/2019 22:00	3,768.5	0.0	3,768.5	104,600.0	394.2	0.47	0.2	0.8
08/14/2019 23:00	2,852.8	0.0	2,852.8	104,600.0	298.4	0.36	0.2	0.6
Average/Sum#:	3,754.8	692.6	4,432.2	104,600.0	463.6	0.56	0.3	0.9
Minimum:	2,852.0	0.0	2,852.0	104,600.0	298.3	0.36	0.2	0.6
Maximum:	4,221.1	1,879.6	5,934.9	104,600.0	620.8	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/15/2019 00:00	2,856.8	0.0	2,856.8	104,600.0	298.8	0.36	0.2	0.6
08/15/2019 01:00	2,851.0	0.0	2,851.0	104,600.0	298.2	0.36	0.2	0.6
08/15/2019 02:00	2,848.9	0.0	2,848.9	104,600.0	298.0	0.36	0.2	0.6
08/15/2019 03:00	2,844.9	0.0	2,844.9	104,600.0	297.6	0.36	0.2	0.6
08/15/2019 04:00	2,852.9	0.0	2,852.9	104,600.0	298.4	0.36	0.2	0.6
08/15/2019 05:00	2,848.2	0.0	2,848.2	104,600.0	297.9	0.36	0.2	0.6
08/15/2019 06:00	3,420.3	0.0	3,420.3	104,600.0	357.8	0.43	0.2	0.7
08/15/2019 07:00	3,435.0	0.0	3,435.0	104,600.0	359.3	0.43	0.2	0.7
08/15/2019 08:00	3,606.6	0.0	3,606.6	104,600.0	377.3	0.45	0.2	0.8
08/15/2019 09:00	3,671.1	0.0	3,671.1	104,600.0	384.0	0.46	0.2	0.8
08/15/2019 10:00	3,507.9	0.0	3,507.9	104,600.0	366.9	0.44	0.2	0.7
08/15/2019 11:00	3,425.1	0.0	3,425.1	104,600.0	358.3	0.43	0.2	0.7
08/15/2019 12:00	3,903.8	0.0	3,903.8	104,600.0	408.3	0.49	0.2	0.8
08/15/2019 13:00	3,972.6	82.0	3,989.0	104,600.0	417.2	0.51	0.3	0.8
08/15/2019 14:00	4,046.1	1,816.3	5,862.4	104,600.0	613.2	0.73	0.4	1.2
08/15/2019 15:00	4,040.7	1,895.8	5,936.5	104,600.0	621.0	0.74	0.4	1.2
08/15/2019 16:00	4,025.4	1,890.7	5,916.1	104,600.0	618.8	0.74	0.4	1.2
08/15/2019 17:00	4,020.8	1,890.1	5,910.9	104,600.0	618.3	0.74	0.4	1.2
08/15/2019 18:00	4,022.3	1,708.2	5,730.5	104,600.0	599.4	0.72	0.4	1.2
08/15/2019 19:00	4,028.2	1,100.0	5,128.2	104,600.0	536.4	0.64	0.3	1.1
08/15/2019 20:00	4,040.9	667.9	4,708.8	104,600.0	492.5	0.59	0.3	1.0
08/15/2019 21:00	4,035.7	271.1	4,306.8	104,600.0	450.5	0.54	0.3	0.9
08/15/2019 22:00	4,008.4	88.5	4,088.1	104,600.0	427.6	0.51	0.3	0.9
08/15/2019 23:00	2,886.4	0.0	2,886.4	104,600.0	301.9	0.36	0.2	0.6
Average/Sum#:	3,550.0	475.4	4,022.3	104,600.0	420.7	0.50	0.3	0.8
Minimum:	2,844.9	0.0	2,844.9	104,600.0	297.6	0.36	0.2	0.6
Maximum:	4,046.1	1,895.8	5,936.5	104,600.0	621.0	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/16/2019 00:00	2,853.5	0.0	2,853.5	104,600.0	298.5	0.36	0.2	0.6
08/16/2019 01:00	2,844.5	0.0	2,844.5	104,600.0	297.5	0.36	0.2	0.6
08/16/2019 02:00	2,838.7	0.0	2,838.7	104,600.0	296.9	0.35	0.2	0.6
08/16/2019 03:00	2,836.0	0.0	2,836.0	104,600.0	296.6	0.35	0.2	0.6
08/16/2019 04:00	2,836.2	0.0	2,836.2	104,600.0	296.7	0.35	0.2	0.6
08/16/2019 05:00	2,833.1	0.0	2,833.1	104,600.0	296.3	0.35	0.2	0.6
08/16/2019 06:00	2,882.6	0.0	2,882.6	104,600.0	301.5	0.36	0.2	0.6
08/16/2019 07:00	3,164.3	0.0	3,164.3	104,600.0	331.0	0.40	0.2	0.7
08/16/2019 08:00	3,174.9	0.0	3,174.9	104,600.0	332.1	0.39	0.2	0.7
08/16/2019 09:00	3,341.4	0.0	3,341.4	104,600.0	349.5	0.41	0.2	0.7
08/16/2019 10:00	3,984.0	0.0	3,984.0	104,600.0	416.7	0.50	0.2	0.8
08/16/2019 11:00	3,749.3	0.0	3,749.3	104,600.0	392.2	0.47	0.2	0.8
08/16/2019 12:00	4,036.2	700.3	4,547.4	104,600.0	475.7	0.59	0.3	1.0
08/16/2019 13:00	4,030.9	1,099.9	5,130.8	104,600.0	536.7	0.64	0.3	1.1
08/16/2019 14:00	4,018.7	1,553.7	5,572.4	104,600.0	582.9	0.70	0.3	1.2
08/16/2019 15:00	4,010.9	1,887.9	5,898.8	104,600.0	617.0	0.74	0.4	1.2
08/16/2019 16:00	4,004.3	1,192.1	5,196.4	104,600.0	543.5	0.65	0.3	1.1
08/16/2019 17:00	4,011.4	1,478.9	5,490.3	104,600.0	574.3	0.69	0.3	1.1
08/16/2019 18:00	4,019.5	1,070.6	5,090.1	104,600.0	532.4	0.64	0.3	1.1
08/16/2019 19:00	4,042.0	1,215.0	5,257.0	104,600.0	549.9	0.66	0.3	1.1
08/16/2019 20:00	4,045.7	1,450.2	5,495.9	104,600.0	574.9	0.69	0.3	1.1
08/16/2019 21:00	4,060.2	875.5	4,935.7	104,600.0	516.3	0.62	0.3	1.0
08/16/2019 22:00	4,094.2	863.6	4,957.8	104,600.0	518.6	0.62	0.3	1.0
08/16/2019 23:00	4,119.8	1,783.1	5,902.9	104,600.0	617.4	0.74	0.4	1.2
Average/Sum#:	3,576.3	632.1	4,200.6	104,600.0	439.4	0.53	0.3	0.9
Minimum:	2,833.1	0.0	2,833.1	104,600.0	296.3	0.35	0.2	0.6
Maximum:	4,119.8	1,887.9	5,902.9	104,600.0	617.4	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/17/2019 00:00	4,130.2	1,541.6	5,671.8	104,600.0	593.3	0.71	0.4	1.2
08/17/2019 01:00	4,143.7	936.5	5,080.2	104,600.0	531.4	0.64	0.3	1.1
08/17/2019 02:00	3,880.8	36.5	3,883.4	104,600.0	406.2	0.49	0.2	0.8
08/17/2019 03:00	3,596.1	0.0	3,596.1	104,600.0	376.2	0.45	0.2	0.7
08/17/2019 04:00	3,523.6	0.0	3,523.6	104,600.0	368.6	0.44	0.2	0.7
08/17/2019 05:00	3,479.0	0.0	3,479.0	104,600.0	363.9	0.43	0.2	0.7
08/17/2019 06:00	3,295.2	0.0	3,295.2	104,600.0	344.7	0.41	0.2	0.7
08/17/2019 07:00	3,545.5	0.0	3,545.5	104,600.0	370.9	0.44	0.2	0.7
08/17/2019 08:00	3,566.3	0.0	3,566.3	104,600.0	373.0	0.45	0.2	0.7
08/17/2019 09:00	3,567.0	0.0	3,567.0	104,600.0	373.1	0.45	0.2	0.7
08/17/2019 10:00	3,590.4	0.0	3,590.4	104,600.0	375.6	0.45	0.2	0.7
08/17/2019 11:00	3,559.9	0.0	3,559.9	104,600.0	372.4	0.45	0.2	0.7
08/17/2019 12:00	3,097.2	0.0	3,097.2	104,600.0	324.0	0.39	0.2	0.6
08/17/2019 13:00	3,068.6	0.0	3,068.6	104,600.0	321.0	0.39	0.2	0.6
08/17/2019 14:00	3,329.0	0.0	3,329.0	104,600.0	348.2	0.42	0.2	0.7
08/17/2019 15:00	3,371.3	0.0	3,371.3	104,600.0	352.6	0.42	0.2	0.7
08/17/2019 16:00	4,033.0	380.2	4,329.6	104,600.0	452.9	0.55	0.3	0.9
08/17/2019 17:00	4,085.8	1,910.0	5,995.8	104,600.0	627.2	0.75	0.4	1.3
08/17/2019 18:00	4,123.2	1,837.6	5,960.8	104,600.0	623.5	0.75	0.4	1.2
08/17/2019 19:00	4,151.7	1,159.5	5,311.2	104,600.0	555.6	0.67	0.3	1.1
08/17/2019 20:00	4,170.3	841.8	5,012.1	104,600.0	524.3	0.63	0.3	1.0
08/17/2019 21:00	4,174.3	854.3	5,028.6	104,600.0	526.0	0.63	0.3	1.0
08/17/2019 22:00	4,061.6	539.6	4,509.5	104,600.0	471.7	0.59	0.3	1.0
08/17/2019 23:00	1,710.3	0.0	1,710.3	104,600.0	178.9	0.00	0.0	0.0
Average/Sum#:	3,635.6	418.2	4,045.1	104,600.0	423.1	0.52	0.3	0.8
Minimum:	1,710.3	0.0	1,710.3	104,600.0	178.9	0.39	0.2	0.6
Maximum:	4,174.3	1,910.0	5,995.8	104,600.0	627.2	0.75	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	4.17	4.17	4.17

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/18/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/18/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/18/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/18/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/18/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/18/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/18/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/18/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/18/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/18/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/18/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/18/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/18/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/18/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/18/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/18/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/18/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/18/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/18/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/18/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/18/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/18/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/18/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/18/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/19/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/19/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/19/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/19/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/19/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/19/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/19/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/19/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/19/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/19/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/19/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/19/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/19/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/19/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/19/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/19/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/19/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/19/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/19/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/19/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/19/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/19/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/19/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/19/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/20/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/20/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/20/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/20/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/20/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/20/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/20/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/20/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/20/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/20/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/20/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/20/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/20/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/20/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/20/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/20/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/20/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/20/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/20/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/20/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/20/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/20/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/20/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/20/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/21/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/21/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/21/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/21/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/21/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/21/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/21/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/21/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/21/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/21/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/21/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/21/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/21/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/21/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/21/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/21/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/21/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/21/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/21/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/21/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/21/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/21/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/21/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/21/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/22/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/22/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/22/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/22/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/22/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/22/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/22/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/22/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/22/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/22/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/22/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/22/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/22/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/22/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/22/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/22/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/22/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/22/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/22/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/22/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/22/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/22/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/22/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/22/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/23/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/23/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/23/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/23/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/23/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/23/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/23/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/23/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/23/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/23/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/23/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/23/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/23/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/23/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/23/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/23/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/23/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/23/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/23/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/23/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/23/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/23/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/23/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/23/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/24/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/24/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/24/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/24/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/24/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/24/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/24/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/24/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/24/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/24/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/24/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/24/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/24/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/24/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/24/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/24/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/24/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/24/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/24/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/24/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/24/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/24/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/24/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/24/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/25/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/25/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/25/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/25/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/25/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/25/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/25/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/25/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/25/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/25/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/25/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/25/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/25/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/25/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/25/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/25/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/25/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/25/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/25/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/25/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/25/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/25/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/25/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/25/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/26/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/26/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/26/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/26/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/26/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/26/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/26/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/26/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/26/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/26/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/26/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/26/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/26/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/26/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/26/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/26/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/26/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/26/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/26/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/26/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/26/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/26/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/26/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/26/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/27/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/27/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/27/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/27/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/27/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/27/2019 05:00	1,528.6	0.0	1,528.6	104,600.0	159.9	0.00	0.0	0.0
08/27/2019 06:00	3,132.2	0.0	3,132.2	104,600.0	327.6	0.38	0.2	0.6
08/27/2019 07:00	3,118.9	0.0	3,118.9	104,600.0	326.2	0.39	0.2	0.7
08/27/2019 08:00	3,105.5	0.0	3,105.5	104,600.0	324.8	0.39	0.2	0.7
08/27/2019 09:00	3,112.1	0.0	3,112.1	104,600.0	325.5	0.39	0.2	0.7
08/27/2019 10:00	3,177.2	0.0	3,177.2	104,600.0	332.3	0.40	0.2	0.7
08/27/2019 11:00	3,150.8	0.0	3,150.8	104,600.0	329.6	0.39	0.2	0.7
08/27/2019 12:00	3,456.1	26.9	3,458.3	104,600.0	361.7	0.44	0.2	0.7
08/27/2019 13:00	4,043.9	833.1	4,877.0	104,600.0	510.1	0.61	0.3	1.0
08/27/2019 14:00	4,042.6	945.3	4,987.9	104,600.0	521.7	0.62	0.3	1.0
08/27/2019 15:00	4,041.6	1,915.9	5,957.5	104,600.0	623.2	0.75	0.4	1.2
08/27/2019 16:00	4,028.8	1,896.8	5,925.6	104,600.0	619.8	0.74	0.4	1.2
08/27/2019 17:00	4,038.3	1,774.5	5,812.8	104,600.0	608.0	0.73	0.4	1.2
08/27/2019 18:00	4,075.6	1,699.5	5,775.1	104,600.0	604.1	0.72	0.4	1.2
08/27/2019 19:00	4,097.5	1,662.7	5,760.2	104,600.0	602.5	0.72	0.4	1.2
08/27/2019 20:00	4,097.0	1,552.6	5,649.6	104,600.0	590.9	0.71	0.4	1.2
08/27/2019 21:00	4,108.9	85.3	4,128.5	104,600.0	431.8	0.53	0.3	0.9
08/27/2019 22:00	3,471.2	0.0	3,471.2	104,600.0	363.1	0.44	0.2	0.7
08/27/2019 23:00	3,076.9	0.0	3,076.9	104,600.0	321.8	0.38	0.2	0.6
Average/Sum#:	3,521.2	652.2	4,168.7	104,600.0	436.0	0.54	0.3	0.9
Minimum:	1,528.6	0.0	1,528.6	104,600.0	159.9	0.38	0.2	0.6
Maximum:	4,108.9	1,915.9	5,957.5	104,600.0	623.2	0.75	0.4	1.2
%SI	20.83	20.83	20.83	0.00	20.83	25.00	25.00	25.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/28/2019 00:00	3,034.9	0.0	3,034.9	104,600.0	317.5	0.38	0.2	0.6
08/28/2019 01:00	2,926.0	0.0	2,926.0	104,600.0	306.1	0.37	0.2	0.6
08/28/2019 02:00	2,898.5	0.0	2,898.5	104,600.0	303.2	0.36	0.2	0.6
08/28/2019 03:00	2,878.3	0.0	2,878.3	104,600.0	301.1	0.36	0.2	0.6
08/28/2019 04:00	3,052.7	0.0	3,052.7	104,600.0	319.3	0.38	0.2	0.6
08/28/2019 05:00	3,085.0	0.0	3,085.0	104,600.0	322.7	0.38	0.2	0.6
08/28/2019 06:00	3,390.4	0.9	3,390.4	104,600.0	354.6	0.42	0.2	0.7
08/28/2019 07:00	4,200.1	1,719.8	5,919.9	104,600.0	619.2	0.74	0.4	1.2
08/28/2019 08:00	4,192.2	1,815.2	6,007.4	104,600.0	628.4	0.75	0.4	1.3
08/28/2019 09:00	4,169.7	1,839.9	6,009.6	104,600.0	628.6	0.75	0.4	1.3
08/28/2019 10:00	4,157.1	1,884.5	6,041.6	104,600.0	632.0	0.76	0.4	1.3
08/28/2019 11:00	4,147.8	1,944.5	6,092.3	104,600.0	637.3	0.76	0.4	1.3
08/28/2019 12:00	4,128.8	1,961.1	6,089.9	104,600.0	637.0	0.76	0.4	1.3
08/28/2019 13:00	4,100.0	1,927.6	6,027.6	104,600.0	630.5	0.75	0.4	1.3
08/28/2019 14:00	4,086.5	1,908.1	5,994.6	104,600.0	627.0	0.75	0.4	1.2
08/28/2019 15:00	4,078.3	1,895.0	5,973.3	104,600.0	624.8	0.75	0.4	1.2
08/28/2019 16:00	4,079.9	1,896.6	5,976.5	104,600.0	625.1	0.75	0.4	1.2
08/28/2019 17:00	4,092.6	1,863.5	5,956.1	104,600.0	623.0	0.74	0.4	1.2
08/28/2019 18:00	4,112.2	1,777.8	5,890.0	104,600.0	616.1	0.74	0.4	1.2
08/28/2019 19:00	4,125.0	1,294.5	5,419.5	104,600.0	566.9	0.68	0.3	1.1
08/28/2019 20:00	4,145.0	529.1	4,647.6	104,600.0	486.1	0.58	0.3	1.0
08/28/2019 21:00	3,544.9	0.0	3,544.9	104,600.0	370.8	0.44	0.2	0.7
08/28/2019 22:00	3,234.7	0.0	3,234.7	104,600.0	338.3	0.41	0.2	0.7
08/28/2019 23:00	2,912.9	0.0	2,912.9	104,600.0	304.7	0.36	0.2	0.6
Average/Sum#:	3,698.9	1,010.8	4,708.5	104,600.0	492.5	0.59	0.3	1.0
Minimum:	2,878.3	0.0	2,878.3	104,600.0	301.1	0.36	0.2	0.6
Maximum:	4,200.1	1,961.1	6,092.3	104,600.0	637.3	0.76	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/29/2019 00:00	3,035.9	0.0	3,035.9	104,600.0	317.6	0.38	0.2	0.6
08/29/2019 01:00	2,861.7	0.0	2,861.7	104,600.0	299.3	0.36	0.2	0.6
08/29/2019 02:00	2,856.7	0.0	2,856.7	104,600.0	298.8	0.36	0.2	0.6
08/29/2019 03:00	2,863.3	0.0	2,863.3	104,600.0	299.5	0.36	0.2	0.6
08/29/2019 04:00	2,949.5	0.0	2,949.5	104,600.0	308.5	0.37	0.2	0.6
08/29/2019 05:00	2,863.7	0.0	2,863.7	104,600.0	299.5	0.36	0.2	0.6
08/29/2019 06:00	2,986.7	0.0	2,986.7	104,600.0	312.4	0.37	0.2	0.6
08/29/2019 07:00	3,005.3	0.0	3,005.3	104,600.0	314.4	0.38	0.2	0.6
08/29/2019 08:00	3,206.3	0.0	3,206.3	104,600.0	335.4	0.40	0.2	0.7
08/29/2019 09:00	3,568.5	0.0	3,568.5	104,600.0	373.3	0.45	0.2	0.7
08/29/2019 10:00	4,008.5	0.0	4,008.5	104,600.0	419.3	0.50	0.3	0.8
08/29/2019 11:00	4,143.6	569.7	4,701.9	104,600.0	491.8	0.59	0.3	1.0
08/29/2019 12:00	4,138.8	954.0	5,092.8	104,600.0	532.7	0.64	0.3	1.1
08/29/2019 13:00	4,115.6	855.6	4,971.2	104,600.0	520.0	0.62	0.3	1.0
08/29/2019 14:00	4,091.9	1,146.4	5,238.3	104,600.0	547.9	0.65	0.3	1.1
08/29/2019 15:00	4,091.8	1,195.8	5,287.6	104,600.0	553.1	0.66	0.3	1.1
08/29/2019 16:00	4,091.8	1,214.3	5,306.1	104,600.0	555.0	0.66	0.3	1.1
08/29/2019 17:00	4,118.8	1,201.4	5,320.2	104,600.0	556.5	0.67	0.3	1.1
08/29/2019 18:00	4,142.2	1,272.4	5,414.6	104,600.0	566.4	0.68	0.3	1.1
08/29/2019 19:00	4,163.9	991.1	5,155.0	104,600.0	539.2	0.64	0.3	1.1
08/29/2019 20:00	4,160.8	7.8	4,161.2	104,600.0	435.3	0.52	0.3	0.9
08/29/2019 21:00	3,722.5	0.0	3,722.5	104,600.0	389.4	0.47	0.2	0.8
08/29/2019 22:00	3,128.6	0.0	3,128.6	104,600.0	327.3	0.39	0.2	0.7
08/29/2019 23:00	1,416.1	0.0	1,416.1	104,600.0	148.1	0.00	0.0	0.0
Average/Sum#:	3,488.9	392.0	3,880.1	104,600.0	405.9	0.50	0.2	0.8
Minimum:	1,416.1	0.0	1,416.1	104,600.0	148.1	0.36	0.2	0.6
Maximum:	4,163.9	1,272.4	5,414.6	104,600.0	566.4	0.68	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	4.17	4.17	4.17

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/30/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/30/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/30/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/30/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/30/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/30/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/30/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/30/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/30/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/30/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/30/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/30/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/30/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/30/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/30/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/30/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/30/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/30/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/30/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/30/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/30/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/30/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/30/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/30/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/31/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/31/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/31/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/31/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/31/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/31/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/31/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/31/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/31/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/31/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/31/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/31/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/31/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/31/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/31/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/31/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/31/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/31/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/31/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/31/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/31/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/31/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/31/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
08/31/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/01/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/01/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/01/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/01/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/01/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/01/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/01/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/01/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/01/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/01/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/01/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/01/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/01/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/01/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/01/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/01/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/01/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/01/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/01/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/01/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/01/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/01/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/01/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/01/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/02/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/02/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/02/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/02/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/02/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/02/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/02/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/02/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/02/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/02/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/02/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/02/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/02/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/02/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/02/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/02/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/02/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/02/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/02/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/02/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/02/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/02/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/02/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/02/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/03/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/03/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/03/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/03/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/03/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/03/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/03/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/03/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/03/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/03/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/03/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/03/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/03/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/03/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/03/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/03/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/03/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/03/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/03/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/03/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/03/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/03/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/03/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/03/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/04/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/04/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/04/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/04/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/04/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/04/2019 05:00	1,430.3	0.0	1,430.3	104,600.0	149.6	0.00	0.0	0.0
09/04/2019 06:00	4,195.4	0.0	4,195.4	104,600.0	438.8	0.53	0.3	0.9
09/04/2019 07:00	3,886.7	0.0	3,886.7	104,600.0	406.5	0.49	0.2	0.8
09/04/2019 08:00	3,459.8	0.0	3,459.8	104,600.0	361.9	0.43	0.2	0.7
09/04/2019 09:00	3,698.4	0.0	3,698.4	104,600.0	386.9	0.46	0.2	0.8
09/04/2019 10:00	3,943.1	22.3	3,944.9	104,600.0	412.6	0.50	0.2	0.8
09/04/2019 11:00	4,144.5	992.2	5,136.7	104,600.0	537.3	0.64	0.3	1.1
09/04/2019 12:00	4,123.3	1,100.9	5,224.2	104,600.0	546.5	0.65	0.3	1.1
09/04/2019 13:00	4,101.4	1,314.5	5,415.9	104,600.0	566.5	0.68	0.3	1.1
09/04/2019 14:00	4,088.2	1,931.3	6,019.5	104,600.0	629.6	0.75	0.4	1.3
09/04/2019 15:00	4,093.7	1,933.4	6,027.1	104,600.0	630.4	0.75	0.4	1.3
09/04/2019 16:00	4,092.2	1,872.5	5,964.7	104,600.0	623.9	0.75	0.4	1.2
09/04/2019 17:00	3,814.6	36.1	3,818.9	104,600.0	399.5	0.48	0.2	0.8
09/04/2019 18:00	3,707.2	0.0	3,707.2	104,600.0	387.8	0.46	0.2	0.8
09/04/2019 19:00	3,808.2	0.0	3,808.2	104,600.0	398.3	0.47	0.2	0.8
09/04/2019 20:00	4,148.3	901.2	5,049.5	104,600.0	528.2	0.63	0.3	1.1
09/04/2019 21:00	3,206.9	4.0	3,207.0	104,600.0	335.5	0.40	0.2	0.7
09/04/2019 22:00	2,988.5	0.0	2,988.5	104,600.0	312.6	0.37	0.2	0.6
09/04/2019 23:00	3,722.6	0.0	3,722.6	104,600.0	389.4	0.47	0.2	0.8
Average/Sum#:	3,718.6	532.0	4,247.7	104,600.0	444.3	0.55	0.3	0.9
Minimum:	1,430.3	0.0	1,430.3	104,600.0	149.6	0.37	0.2	0.6
Maximum:	4,195.4	1,933.4	6,027.1	104,600.0	630.4	0.75	0.4	1.3
%SI	20.83	20.83	20.83	0.00	20.83	25.00	25.00	25.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/05/2019 00:00	3,404.0	0.0	3,404.0	104,600.0	356.1	0.42	0.2	0.7
09/05/2019 01:00	3,138.7	0.0	3,138.7	104,600.0	328.3	0.39	0.2	0.7
09/05/2019 02:00	2,858.7	0.0	2,858.7	104,600.0	299.0	0.36	0.2	0.6
09/05/2019 03:00	2,872.9	0.0	2,872.9	104,600.0	300.5	0.36	0.2	0.6
09/05/2019 04:00	3,068.3	0.0	3,068.3	104,600.0	320.9	0.38	0.2	0.6
09/05/2019 05:00	2,905.5	0.0	2,905.5	104,600.0	303.9	0.36	0.2	0.6
09/05/2019 06:00	3,024.3	0.0	3,024.3	104,600.0	316.3	0.38	0.2	0.6
09/05/2019 07:00	3,265.8	0.0	3,265.8	104,600.0	341.6	0.41	0.2	0.7
09/05/2019 08:00	3,586.6	0.0	3,586.6	104,600.0	375.2	0.45	0.2	0.7
09/05/2019 09:00	4,172.4	164.1	4,303.7	104,600.0	450.2	0.54	0.3	0.9
09/05/2019 10:00	4,176.7	507.1	4,683.8	104,600.0	489.9	0.58	0.3	1.0
09/05/2019 11:00	4,163.9	775.8	4,939.7	104,600.0	516.7	0.62	0.3	1.0
09/05/2019 12:00	4,141.2	1,034.5	5,175.7	104,600.0	541.4	0.65	0.3	1.1
09/05/2019 13:00	4,135.1	1,961.6	6,096.7	104,600.0	637.7	0.76	0.4	1.3
09/05/2019 14:00	4,131.7	1,951.4	6,083.1	104,600.0	636.3	0.76	0.4	1.3
09/05/2019 15:00	4,137.3	1,935.7	6,073.0	104,600.0	635.2	0.76	0.4	1.3
09/05/2019 16:00	4,136.1	1,253.9	5,390.0	104,600.0	563.8	0.67	0.3	1.1
09/05/2019 17:00	4,137.5	1,210.6	5,348.1	104,600.0	559.4	0.67	0.3	1.1
09/05/2019 18:00	4,147.7	650.1	4,797.8	104,600.0	501.8	0.60	0.3	1.0
09/05/2019 19:00	3,957.0	1.4	3,957.0	104,600.0	413.9	0.50	0.2	0.8
09/05/2019 20:00	3,650.2	0.0	3,650.2	104,600.0	381.8	0.46	0.2	0.8
09/05/2019 21:00	3,868.3	0.0	3,868.3	104,600.0	404.6	0.48	0.2	0.8
09/05/2019 22:00	3,563.4	0.0	3,563.4	104,600.0	372.7	0.45	0.2	0.8
09/05/2019 23:00	1,514.1	0.0	1,514.1	104,600.0	158.4	0.00	0.0	0.0
Average/Sum#:	3,589.9	476.9	4,065.4	104,600.0	425.2	0.52	0.3	0.9
Minimum:	1,514.1	0.0	1,514.1	104,600.0	158.4	0.36	0.2	0.6
Maximum:	4,176.7	1,961.6	6,096.7	104,600.0	637.7	0.76	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	4.17	4.17	4.17

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/06/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/06/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/06/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/06/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/06/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/06/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/06/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/06/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/06/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/06/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/06/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/06/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/06/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/06/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/06/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/06/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/06/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/06/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/06/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/06/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/06/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/06/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/06/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/06/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/07/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/07/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/07/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/07/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/07/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/07/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/07/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/07/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/07/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/07/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/07/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/07/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/07/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/07/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/07/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/07/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/07/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/07/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/07/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/07/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/07/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/07/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/07/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/07/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/08/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/08/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/08/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/08/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/08/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/08/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/08/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/08/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/08/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/08/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/08/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/08/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/08/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/08/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/08/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/08/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/08/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/08/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/08/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/08/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/08/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/08/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/08/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/08/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/09/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/09/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/09/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/09/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/09/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/09/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/09/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/09/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/09/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/09/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/09/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/09/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
09/09/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/09/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/09/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/09/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/09/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/09/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/09/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/09/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/09/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/09/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/09/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/09/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,650.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/10/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/10/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/10/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/10/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/10/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/10/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/10/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/10/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/10/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/10/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/10/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/10/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/10/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/10/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/10/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/10/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/10/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/10/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/10/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/10/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/10/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/10/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/10/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/10/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/11/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/11/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/11/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/11/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/11/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/11/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/11/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/11/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/11/2019 08:00	1,404.6	0.0	1,404.6	104,700.0	147.1	0.00	0.0	0.0
09/11/2019 09:00	3,027.0	0.0	3,027.0	104,700.0	316.9	0.39	0.2	0.6
09/11/2019 10:00	3,759.0	0.0	3,759.0	104,700.0	393.6	0.47	0.2	0.8
09/11/2019 11:00	4,211.7	122.5	4,334.2	104,700.0	453.8	0.55	0.3	0.9
09/11/2019 12:00	4,197.7	1,234.1	5,431.8	104,700.0	568.7	0.68	0.3	1.1
09/11/2019 13:00	3,329.0	40.3	3,332.2	104,700.0	348.9	0.42	0.2	0.7
09/11/2019 14:00	4,163.7	1,405.8	5,569.5	104,700.0	583.1	0.70	0.3	1.2
09/11/2019 15:00	3,236.6	9.5	3,237.1	104,700.0	338.9	0.41	0.2	0.7
09/11/2019 16:00	4,173.0	397.3	4,558.4	104,700.0	477.3	0.58	0.3	1.0
09/11/2019 17:00	4,181.6	354.7	4,536.3	104,700.0	475.0	0.57	0.3	0.9
09/11/2019 18:00	3,813.3	48.5	3,823.0	104,700.0	400.3	0.49	0.2	0.8
09/11/2019 19:00	3,162.4	0.0	3,162.4	104,700.0	331.1	0.40	0.2	0.7
09/11/2019 20:00	4,177.2	770.3	4,885.9	104,700.0	511.6	0.62	0.3	1.0
09/11/2019 21:00	3,565.1	0.0	3,565.1	104,700.0	373.3	0.45	0.2	0.7
09/11/2019 22:00	3,554.3	0.0	3,554.3	104,700.0	372.1	0.45	0.2	0.7
09/11/2019 23:00	3,551.9	0.0	3,551.9	104,700.0	371.9	0.45	0.2	0.7
Average/Sum#:	3,594.3	273.9	3,858.3	104,700.0	404.0	0.51	0.2	0.8
Minimum:	1,404.6	0.0	1,404.6	104,700.0	147.1	0.39	0.2	0.6
Maximum:	4,211.7	1,405.8	5,569.5	104,700.0	583.1	0.70	0.3	1.2
%SI	33.33	33.33	33.33	0.00	33.33	37.50	37.50	37.50

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/12/2019 00:00	3,358.7	0.0	3,358.7	104,700.0	351.7	0.42	0.2	0.7
09/12/2019 01:00	2,988.7	0.0	2,988.7	104,700.0	312.9	0.38	0.2	0.6
09/12/2019 02:00	2,987.6	0.0	2,987.6	104,700.0	312.8	0.38	0.2	0.6
09/12/2019 03:00	2,983.9	0.0	2,983.9	104,700.0	312.4	0.37	0.2	0.6
09/12/2019 04:00	2,978.6	0.0	2,978.6	104,700.0	311.9	0.37	0.2	0.6
09/12/2019 05:00	3,003.4	0.0	3,003.4	104,700.0	314.5	0.38	0.2	0.6
09/12/2019 06:00	3,018.1	0.0	3,018.1	104,700.0	316.0	0.38	0.2	0.6
09/12/2019 07:00	3,143.9	0.0	3,143.9	104,700.0	329.2	0.40	0.2	0.7
09/12/2019 08:00	4,229.4	1,255.6	5,459.9	104,700.0	571.7	0.69	0.3	1.1
09/12/2019 09:00	3,283.9	6.4	3,284.3	104,700.0	343.9	0.41	0.2	0.7
09/12/2019 10:00	4,186.5	134.3	4,304.7	104,700.0	450.7	0.54	0.3	0.9
09/12/2019 11:00	3,416.0	0.0	3,416.0	104,700.0	357.7	0.45	0.2	0.7
09/12/2019 12:00	1,052.3	0.0	1,052.3	104,700.0	110.2	0.00	0.0	0.0
09/12/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/12/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/12/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/12/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/12/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/12/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/12/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/12/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/12/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/12/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/12/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Average/Sum#:	3,125.5	107.4	3,229.2	104,700.0	338.1	0.43	0.2	0.7
Minimum:	1,052.3	0.0	1,052.3	104,700.0	110.2	0.37	0.2	0.6
Maximum:	4,229.4	1,255.6	5,459.9	104,700.0	571.7	0.69	0.3	1.1
%SI	45.83	45.83	45.83	0.00	45.83	50.00	50.00	50.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/13/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/13/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/13/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/13/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/13/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/13/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/13/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/13/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/13/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/13/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/13/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/13/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/13/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/13/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/13/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/13/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/13/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/13/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/13/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/13/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/13/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/13/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/13/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/13/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/14/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/14/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/14/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/14/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/14/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/14/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/14/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/14/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/14/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/14/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/14/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/14/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/14/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/14/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/14/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/14/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/14/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/14/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/14/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/14/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/14/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/14/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/14/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/14/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/15/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/15/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/15/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/15/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/15/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/15/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/15/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/15/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/15/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/15/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/15/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/15/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/15/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/15/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/15/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/15/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/15/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/15/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/15/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/15/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/15/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/15/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/15/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/15/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/16/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/16/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/16/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/16/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/16/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/16/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/16/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/16/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/16/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/16/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/16/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/16/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/16/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/16/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/16/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/16/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/16/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/16/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/16/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/16/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/16/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/16/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/16/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/16/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/17/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/17/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/17/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/17/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/17/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/17/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/17/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/17/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/17/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/17/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/17/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/17/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/17/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/17/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/17/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/17/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/17/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/17/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/17/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/17/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/17/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/17/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/17/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/17/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/18/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/18/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/18/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/18/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/18/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/18/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/18/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/18/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/18/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/18/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/18/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/18/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/18/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/18/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/18/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/18/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/18/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/18/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/18/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/18/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/18/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/18/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/18/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/18/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/19/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/19/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/19/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/19/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/19/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/19/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/19/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/19/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/19/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/19/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/19/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/19/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/19/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/19/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/19/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/19/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/19/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/19/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/19/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/19/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/19/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/19/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/19/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/19/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/20/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/20/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/20/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/20/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/20/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/20/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/20/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/20/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/20/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/20/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/20/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/20/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/20/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/20/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/20/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/20/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/20/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/20/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/20/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/20/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/20/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/20/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/20/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/20/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/21/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/21/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/21/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/21/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/21/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/21/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/21/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/21/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/21/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/21/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/21/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/21/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/21/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/21/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/21/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/21/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/21/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/21/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/21/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/21/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/21/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/21/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/21/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/21/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/22/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/22/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/22/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/22/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/22/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/22/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/22/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/22/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/22/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/22/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/22/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/22/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/22/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/22/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/22/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/22/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/22/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/22/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/22/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/22/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/22/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/22/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/22/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/22/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/23/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/23/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/23/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/23/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/23/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/23/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/23/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/23/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/23/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/23/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/23/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/23/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/23/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/23/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/23/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/23/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/23/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/23/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/23/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/23/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/23/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/23/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/23/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/23/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/24/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/24/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/24/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/24/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/24/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/24/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/24/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/24/2019 07:00	75.3	0.0	75.3	104,700.0	7.9	0.00	0.0	0.0
09/24/2019 08:00	2,947.3	0.0	2,947.3	104,700.0	308.6	0.40	0.2	0.7
09/24/2019 09:00	3,512.4	0.0	3,512.4	104,700.0	367.7	0.44	0.2	0.7
09/24/2019 10:00	3,778.5	0.0	3,778.5	104,700.0	395.6	0.48	0.2	0.8
09/24/2019 11:00	3,700.0	0.0	3,700.0	104,700.0	387.4	0.46	0.2	0.8
09/24/2019 12:00	4,098.3	82.6	4,178.4	104,700.0	437.5	0.53	0.3	0.9
09/24/2019 13:00	4,113.5	500.0	4,613.5	104,700.0	483.0	0.58	0.3	1.0
09/24/2019 14:00	4,104.5	251.6	4,356.1	104,700.0	456.1	0.55	0.3	0.9
09/24/2019 15:00	4,090.9	477.4	4,568.3	104,700.0	478.3	0.58	0.3	1.0
09/24/2019 16:00	4,081.7	1,963.6	6,045.3	104,700.0	632.9	0.76	0.4	1.3
09/24/2019 17:00	4,080.2	1,956.0	6,036.2	104,700.0	632.0	0.76	0.4	1.3
09/24/2019 18:00	4,090.0	1,423.4	5,513.4	104,700.0	577.3	0.69	0.3	1.2
09/24/2019 19:00	4,099.9	457.5	4,520.8	104,700.0	473.3	0.57	0.3	1.0
09/24/2019 20:00	3,728.6	0.0	3,728.6	104,700.0	390.4	0.47	0.2	0.8
09/24/2019 21:00	4,115.0	166.0	4,244.5	104,700.0	444.4	0.54	0.3	0.9
09/24/2019 22:00	3,669.8	0.0	3,669.8	104,700.0	384.2	0.46	0.2	0.8
09/24/2019 23:00	2,912.8	0.0	2,912.8	104,700.0	305.0	0.37	0.2	0.6
Average/Sum#:	3,599.9	428.1	4,023.6	104,700.0	421.3	0.54	0.3	0.9
Minimum:	75.3	0.0	75.3	104,700.0	7.9	0.37	0.2	0.6
Maximum:	4,115.0	1,963.6	6,045.3	104,700.0	632.9	0.76	0.4	1.3
%SI	29.17	29.17	29.17	0.00	29.17	33.33	33.33	33.33

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/25/2019 00:00	2,840.3	0.0	2,840.3	104,700.0	297.4	0.36	0.2	0.6
09/25/2019 01:00	2,837.5	0.0	2,837.5	104,700.0	297.1	0.36	0.2	0.6
09/25/2019 02:00	2,832.1	0.0	2,832.1	104,700.0	296.5	0.36	0.2	0.6
09/25/2019 03:00	2,835.0	0.0	2,835.0	104,700.0	296.8	0.36	0.2	0.6
09/25/2019 04:00	2,839.3	0.0	2,839.3	104,700.0	297.3	0.36	0.2	0.6
09/25/2019 05:00	2,835.3	0.0	2,835.3	104,700.0	296.9	0.36	0.2	0.6
09/25/2019 06:00	2,847.0	0.0	2,847.0	104,700.0	298.1	0.36	0.2	0.6
09/25/2019 07:00	2,878.9	0.0	2,878.9	104,700.0	301.4	0.36	0.2	0.6
09/25/2019 08:00	2,846.6	0.0	2,846.6	104,700.0	298.0	0.36	0.2	0.6
09/25/2019 09:00	2,903.4	0.0	2,903.4	104,700.0	304.0	0.37	0.2	0.6
09/25/2019 10:00	3,304.0	0.0	3,304.0	104,700.0	345.9	0.42	0.2	0.7
09/25/2019 11:00	3,897.5	62.6	3,903.8	104,700.0	408.7	0.50	0.2	0.8
09/25/2019 12:00	4,079.3	1,567.9	5,647.2	104,700.0	591.3	0.71	0.4	1.2
09/25/2019 13:00	4,045.9	1,900.0	5,945.9	104,700.0	622.5	0.75	0.4	1.2
09/25/2019 14:00	4,031.5	1,603.7	5,635.2	104,700.0	590.0	0.71	0.4	1.2
09/25/2019 15:00	4,023.9	1,585.2	5,609.1	104,700.0	587.3	0.70	0.4	1.2
09/25/2019 16:00	4,024.0	1,790.6	5,814.6	104,700.0	608.8	0.73	0.4	1.2
09/25/2019 17:00	4,027.3	1,765.8	5,793.1	104,700.0	606.5	0.73	0.4	1.2
09/25/2019 18:00	4,021.9	140.1	4,049.9	104,700.0	424.0	0.52	0.3	0.9
09/25/2019 19:00	4,072.6	1,207.6	5,280.2	104,700.0	552.8	0.66	0.3	1.1
09/25/2019 20:00	4,072.0	1,190.3	5,202.8	104,700.0	544.7	0.66	0.3	1.1
09/25/2019 21:00	3,523.6	0.0	3,523.6	104,700.0	368.9	0.44	0.2	0.7
09/25/2019 22:00	3,035.8	0.0	3,035.8	104,700.0	317.8	0.38	0.2	0.6
09/25/2019 23:00	2,828.8	0.0	2,828.8	104,700.0	296.2	0.36	0.2	0.6
Average/Sum#:	3,395.1	533.9	3,919.6	104,700.0	410.4	0.50	0.3	0.8
Minimum:	2,828.8	0.0	2,828.8	104,700.0	296.2	0.36	0.2	0.6
Maximum:	4,079.3	1,900.0	5,945.9	104,700.0	622.5	0.75	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/26/2019 00:00	2,832.1	0.0	2,832.1	104,700.0	296.5	0.36	0.2	0.6
09/26/2019 01:00	2,839.1	0.0	2,839.1	104,700.0	297.3	0.36	0.2	0.6
09/26/2019 02:00	2,834.6	0.0	2,834.6	104,700.0	296.8	0.36	0.2	0.6
09/26/2019 03:00	2,840.1	0.0	2,840.1	104,700.0	297.4	0.36	0.2	0.6
09/26/2019 04:00	2,845.3	0.0	2,845.3	104,700.0	297.9	0.36	0.2	0.6
09/26/2019 05:00	2,852.6	0.0	2,852.6	104,700.0	298.7	0.36	0.2	0.6
09/26/2019 06:00	2,850.3	0.0	2,850.3	104,700.0	298.4	0.36	0.2	0.6
09/26/2019 07:00	2,883.8	0.0	2,883.8	104,700.0	301.9	0.36	0.2	0.6
09/26/2019 08:00	2,974.0	0.0	2,974.0	104,700.0	311.4	0.37	0.2	0.6
09/26/2019 09:00	3,508.3	9.0	3,508.8	104,700.0	367.4	0.44	0.2	0.7
09/26/2019 10:00	4,117.5	291.5	4,409.0	104,700.0	461.6	0.56	0.3	0.9
09/26/2019 11:00	4,106.2	643.3	4,749.5	104,700.0	497.3	0.60	0.3	1.0
09/26/2019 12:00	4,082.4	843.7	4,926.1	104,700.0	515.8	0.62	0.3	1.0
09/26/2019 13:00	4,074.5	859.7	4,934.2	104,700.0	516.6	0.62	0.3	1.0
09/26/2019 14:00	4,075.4	1,676.1	5,751.5	104,700.0	602.2	0.72	0.4	1.2
09/26/2019 15:00	4,066.8	1,485.1	5,551.9	104,700.0	581.3	0.70	0.3	1.2
09/26/2019 16:00	4,087.9	1,771.5	5,859.4	104,700.0	613.5	0.74	0.4	1.2
09/26/2019 17:00	4,108.1	1,092.7	5,200.8	104,700.0	544.5	0.65	0.3	1.1
09/26/2019 18:00	4,130.2	665.8	4,749.4	104,700.0	497.3	0.60	0.3	1.0
09/26/2019 19:00	4,096.4	0.0	4,096.4	104,700.0	428.9	0.51	0.3	0.9
09/26/2019 20:00	3,386.2	0.0	3,386.2	104,700.0	354.5	0.43	0.2	0.7
09/26/2019 21:00	3,051.8	0.0	3,051.8	104,700.0	319.5	0.39	0.2	0.6
09/26/2019 22:00	2,767.6	0.0	2,767.6	104,700.0	289.8	0.36	0.2	0.6
09/26/2019 23:00	1,061.3	0.0	1,061.3	104,700.0	111.1	0.00	0.0	0.0
Average/Sum#:	3,353.0	389.1	3,739.8	104,700.0	391.6	0.49	0.3	0.8
Minimum:	1,061.3	0.0	1,061.3	104,700.0	111.1	0.36	0.2	0.6
Maximum:	4,130.2	1,771.5	5,859.4	104,700.0	613.5	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	4.17	4.17	4.17

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/27/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/27/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/27/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/27/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/27/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/27/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/27/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/27/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/27/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/27/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/27/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/27/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/27/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/27/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/27/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/27/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/27/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/27/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/27/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/27/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/27/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/27/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/27/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/27/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/28/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/28/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/28/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/28/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/28/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/28/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/28/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/28/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/28/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/28/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/28/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/28/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/28/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/28/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/28/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/28/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/28/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/28/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/28/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/28/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/28/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/28/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/28/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/28/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/29/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/29/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/29/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/29/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/29/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/29/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/29/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/29/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/29/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/29/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/29/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/29/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/29/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/29/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/29/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/29/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/29/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/29/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/29/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/29/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/29/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/29/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/29/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/29/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:16 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/30/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/30/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/30/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/30/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/30/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/30/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/30/2019 06:00	1,441.5	0.0	1,441.5	104,700.0	150.9	0.00	0.0	0.0
09/30/2019 07:00	4,107.1	0.0	4,107.1	104,700.0	430.0	0.52	0.3	0.9
09/30/2019 08:00	4,139.1	0.0	4,139.1	104,700.0	433.4	0.52	0.3	0.9
09/30/2019 09:00	4,270.5	0.0	4,270.5	104,700.0	447.1	0.54	0.3	0.9
09/30/2019 10:00	4,241.9	0.0	4,241.9	104,700.0	444.1	0.53	0.3	0.9
09/30/2019 11:00	3,360.0	0.0	3,360.0	104,700.0	351.8	0.43	0.2	0.7
09/30/2019 12:00	1,088.2	0.0	1,088.2	104,700.0	113.9	0.00	0.0	0.0
09/30/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/30/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/30/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/30/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/30/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/30/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/30/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/30/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/30/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/30/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
09/30/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Average/Sum#:	3,235.5	0.0	3,235.5	104,700.0	338.7	0.51	0.3	0.9
Minimum:	1,088.2	0.0	1,088.2	104,700.0	113.9	0.43	0.2	0.7
Maximum:	4,270.5	0.0	4,270.5	104,700.0	447.1	0.54	0.3	0.9
%SI	70.83	70.83	70.83	0.00	70.83	79.17	79.17	79.17

CO Ppmvdc EDS/CMS Summary Report

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:14 **Location:** Roseville, CA
Description: Electric Utility

CMS Data from: CT1_CO_Ppmvdc_1H
EDS Data from: CT1_CO_Ppmvdc_3H
Emission Limitation: 4
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 04/09/2006 14:00
Process Unit(s) Description:

Operating time for EDS: 709.00 Hour(s)
Operating time for CMS: 709.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	4
2. Total CMS Downtime	4
3. Total Downtime as a percentage of operating time	0.56
4. Total Availability as a percentage of operating time	99.44

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

NOx Ppmvdc EDS/CMS Summary Report

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:17 **Location:** Roseville, CA
Description: Electric Utility

CMS Data from: CT1_NOx_Ppmvdc_1H
EDS Data from: CT1_NOx_Ppmvdc_1H
Emission Limitation: 2.0
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 04/09/2006 14:00
Process Unit(s) Description:

Operating time for EDS: 709.00 Hour(s)
Operating time for CMS: 709.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	4
2. Total CMS Downtime	4
3. Total Downtime as a percentage of operating time	0.56
4. Total Availability as a percentage of operating time	99.44

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

CO Invalid Data

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:15 **Location:** Roseville, CA

Tag Name: CT1_CO_Ppm_1H

Total Operating Time: 709.00 Hour(s)
Non-Operating Time: 1,499.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	08/05/2019 09:00	08/05/2019 10:59	2	3 - Quality assurance calibration	

Total Operating Time:	**709.00 Hour(s)**
Total Monitor Downtime (Online only):	**2.00 Hour(s)**
Percent Monitor Availability:	**99.72 %**
Percent Monitor Downtime:	**0.28 %**

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Quality assurance calibration	2	100.00

NOx Invalid Data

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:17 **Location:** Roseville, CA

Tag Name: CT1_NOx_Ppm_1H

Total Operating Time: 709.00 Hour(s)
Non-Operating Time: 1,499.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	07/23/2019 05:00	07/23/2019 05:59	1		
2	07/23/2019 06:00	07/23/2019 06:59	1	8 - No prior online calibration within 26 hours	
3	08/05/2019 09:00	08/05/2019 09:59	1	3 - Quality assurance calibration	
4	08/05/2019 10:00	08/05/2019 10:59	1	3 - Quality assurance calibration	

Total Operating Time:	**709.00 Hour(s)**
Total Monitor Downtime (Online only):	**4.00 Hour(s)**
Percent Monitor Availability:	**99.44 %**
Percent Monitor Downtime:	**0.56 %**

Report Code	Type	Text	Duration	Duration Percent
8	Reason	No prior online calibration within 26 hours	1	25.00
3	Reason	Quality assurance calibration	2	50.00

NOx SCR Invalid Data

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:19 **Location:** Roseville, CA

Tag Name: CT1_NOx_SCR_Ppm_1H

Total Operating Time: 709.00 Hour(s)
Non-Operating Time: 1,499.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	**709.00 Hour(s)**
Total Monitor Downtime (Online only):	**0.00 Hour(s)**
Percent Monitor Availability:	**100.00 %**
Percent Monitor Downtime:	**0.00 %**

O2 Invalid Data

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:29 **Location:** Roseville, CA

Tag Name: CT1_O2Dry_Pct_1H

Total Operating Time: 709.00 Hour(s)
Non-Operating Time: 1,499.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	07/23/2019 05:00	07/23/2019 05:59	1		
2	07/23/2019 06:00	07/23/2019 06:59	1	8 - No prior online calibration within 26 hours	
3	08/05/2019 09:00	08/05/2019 09:59	1	3 - Quality assurance calibration	
4	08/05/2019 10:00	08/05/2019 10:59	1	3 - Quality assurance calibration	

Total Operating Time:	**709.00 Hour(s)**
Total Monitor Downtime (Online only):	**4.00 Hour(s)**
Percent Monitor Availability:	**99.44 %**
Percent Monitor Downtime:	**0.56 %**

Report Code	Type	Text	Duration	Duration Percent
8	Reason	No prior online calibration within 26 hours	1	25.00
3	Reason	Quality assurance calibration	2	50.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:33 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/01/2019 00:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/01/2019 01:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/01/2019 02:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/01/2019 03:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/01/2019 04:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/01/2019 05:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/01/2019 06:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/01/2019 07:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/01/2019 08:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/01/2019 09:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/01/2019 10:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/01/2019 11:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/01/2019 12:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/01/2019 13:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/01/2019 14:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/01/2019 15:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/01/2019 16:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/01/2019 17:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/01/2019 18:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/01/2019 19:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/01/2019 20:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/01/2019 21:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/01/2019 22:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/01/2019 23:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:33 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/02/2019 00:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/02/2019 01:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/02/2019 02:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/02/2019 03:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/02/2019 04:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/02/2019 05:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/02/2019 06:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/02/2019 07:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/02/2019 08:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/02/2019 09:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/02/2019 10:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/02/2019 11:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/02/2019 12:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/02/2019 13:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/02/2019 14:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/02/2019 15:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/02/2019 16:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/02/2019 17:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/02/2019 18:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/02/2019 19:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/02/2019 20:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/02/2019 21:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/02/2019 22:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/02/2019 23:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:33 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/03/2019 00:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/03/2019 01:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/03/2019 02:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/03/2019 03:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/03/2019 04:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/03/2019 05:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/03/2019 06:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/03/2019 07:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/03/2019 08:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/03/2019 09:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/03/2019 10:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/03/2019 11:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/03/2019 12:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/03/2019 13:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/03/2019 14:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/03/2019 15:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/03/2019 16:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/03/2019 17:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/03/2019 18:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/03/2019 19:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/03/2019 20:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/03/2019 21:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/03/2019 22:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/03/2019 23:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:33 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/04/2019 00:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/04/2019 01:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/04/2019 02:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/04/2019 03:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/04/2019 04:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/04/2019 05:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/04/2019 06:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/04/2019 07:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/04/2019 08:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/04/2019 09:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/04/2019 10:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/04/2019 11:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/04/2019 12:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/04/2019 13:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/04/2019 14:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/04/2019 15:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/04/2019 16:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/04/2019 17:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/04/2019 18:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/04/2019 19:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/04/2019 20:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/04/2019 21:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/04/2019 22:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/04/2019 23:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:33 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/05/2019 00:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/05/2019 01:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/05/2019 02:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/05/2019 03:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/05/2019 04:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/05/2019 05:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/05/2019 06:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/05/2019 07:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/05/2019 08:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/05/2019 09:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/05/2019 10:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/05/2019 11:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/05/2019 12:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/05/2019 13:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/05/2019 14:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/05/2019 15:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/05/2019 16:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/05/2019 17:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/05/2019 18:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/05/2019 19:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/05/2019 20:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/05/2019 21:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/05/2019 22:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/05/2019 23:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:33 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/06/2019 00:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/06/2019 01:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/06/2019 02:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/06/2019 03:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/06/2019 04:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/06/2019 05:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/06/2019 06:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/06/2019 07:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/06/2019 08:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/06/2019 09:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/06/2019 10:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/06/2019 11:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/06/2019 12:00	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
07/06/2019 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/06/2019 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/06/2019 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/06/2019 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/06/2019 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/06/2019 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/06/2019 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/06/2019 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/06/2019 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/06/2019 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/06/2019 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,983.3	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	103,800.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:33 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/07/2019 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/07/2019 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/07/2019 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/07/2019 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/07/2019 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/07/2019 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/07/2019 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/07/2019 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/07/2019 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/07/2019 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/07/2019 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/07/2019 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/07/2019 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/07/2019 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/07/2019 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/07/2019 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/07/2019 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/07/2019 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/07/2019 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/07/2019 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/07/2019 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/07/2019 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/07/2019 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/07/2019 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:33 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/08/2019 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/08/2019 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/08/2019 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/08/2019 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/08/2019 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/08/2019 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/08/2019 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/08/2019 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/08/2019 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/08/2019 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/08/2019 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/08/2019 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/08/2019 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/08/2019 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/08/2019 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/08/2019 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/08/2019 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/08/2019 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/08/2019 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/08/2019 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/08/2019 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/08/2019 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/08/2019 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/08/2019 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:33 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/09/2019 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/09/2019 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/09/2019 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/09/2019 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/09/2019 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/09/2019 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/09/2019 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/09/2019 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/09/2019 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/09/2019 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/09/2019 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/09/2019 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/09/2019 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/09/2019 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/09/2019 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/09/2019 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/09/2019 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/09/2019 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/09/2019 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/09/2019 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/09/2019 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/09/2019 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/09/2019 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/09/2019 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:33 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/10/2019 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/10/2019 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/10/2019 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/10/2019 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/10/2019 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/10/2019 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/10/2019 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/10/2019 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/10/2019 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/10/2019 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/10/2019 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/10/2019 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/10/2019 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/10/2019 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/10/2019 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/10/2019 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/10/2019 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/10/2019 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/10/2019 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/10/2019 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/10/2019 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/10/2019 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/10/2019 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/10/2019 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:33 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/11/2019 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/11/2019 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/11/2019 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/11/2019 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/11/2019 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/11/2019 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/11/2019 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/11/2019 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/11/2019 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/11/2019 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/11/2019 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/11/2019 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/11/2019 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/11/2019 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/11/2019 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/11/2019 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/11/2019 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/11/2019 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/11/2019 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/11/2019 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/11/2019 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/11/2019 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/11/2019 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/11/2019 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:33 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/12/2019 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/12/2019 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/12/2019 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/12/2019 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/12/2019 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/12/2019 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/12/2019 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/12/2019 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/12/2019 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/12/2019 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/12/2019 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/12/2019 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/12/2019 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/12/2019 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/12/2019 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/12/2019 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/12/2019 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/12/2019 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/12/2019 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/12/2019 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/12/2019 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/12/2019 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/12/2019 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/12/2019 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:33 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/13/2019 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/13/2019 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/13/2019 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/13/2019 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/13/2019 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/13/2019 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/13/2019 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/13/2019 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/13/2019 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/13/2019 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/13/2019 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/13/2019 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/13/2019 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/13/2019 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/13/2019 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/13/2019 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/13/2019 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/13/2019 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/13/2019 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/13/2019 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/13/2019 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/13/2019 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/13/2019 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/13/2019 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:33 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/14/2019 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/14/2019 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/14/2019 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/14/2019 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/14/2019 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/14/2019 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/14/2019 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/14/2019 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/14/2019 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/14/2019 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/14/2019 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/14/2019 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/14/2019 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/14/2019 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/14/2019 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/14/2019 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/14/2019 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/14/2019 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/14/2019 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/14/2019 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/14/2019 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/14/2019 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/14/2019 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/14/2019 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:33 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/15/2019 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/15/2019 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/15/2019 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/15/2019 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/15/2019 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/15/2019 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/15/2019 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/15/2019 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/15/2019 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/15/2019 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/15/2019 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/15/2019 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/15/2019 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/15/2019 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/15/2019 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/15/2019 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/15/2019 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/15/2019 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/15/2019 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/15/2019 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/15/2019 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/15/2019 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/15/2019 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/15/2019 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:33 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/16/2019 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/16/2019 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/16/2019 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/16/2019 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/16/2019 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/16/2019 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/16/2019 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/16/2019 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/16/2019 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/16/2019 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/16/2019 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/16/2019 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/16/2019 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/16/2019 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/16/2019 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/16/2019 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/16/2019 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/16/2019 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/16/2019 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/16/2019 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/16/2019 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/16/2019 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/16/2019 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/16/2019 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:33 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/17/2019 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/17/2019 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/17/2019 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/17/2019 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/17/2019 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/17/2019 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/17/2019 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/17/2019 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/17/2019 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/17/2019 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/17/2019 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/17/2019 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/17/2019 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/17/2019 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/17/2019 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/17/2019 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/17/2019 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/17/2019 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/17/2019 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/17/2019 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/17/2019 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/17/2019 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/17/2019 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/17/2019 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/18/2019 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/18/2019 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/18/2019 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/18/2019 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/18/2019 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/18/2019 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/18/2019 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/18/2019 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/18/2019 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/18/2019 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/18/2019 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/18/2019 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/18/2019 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/18/2019 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/18/2019 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/18/2019 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/18/2019 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/18/2019 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/18/2019 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/18/2019 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/18/2019 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/18/2019 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/18/2019 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/18/2019 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/19/2019 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/19/2019 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/19/2019 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/19/2019 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/19/2019 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/19/2019 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/19/2019 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/19/2019 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/19/2019 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/19/2019 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/19/2019 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/19/2019 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/19/2019 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/19/2019 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/19/2019 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/19/2019 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/19/2019 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/19/2019 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/19/2019 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/19/2019 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/19/2019 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/19/2019 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/19/2019 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/19/2019 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/20/2019 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/20/2019 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/20/2019 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/20/2019 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/20/2019 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/20/2019 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/20/2019 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/20/2019 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/20/2019 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/20/2019 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/20/2019 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/20/2019 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/20/2019 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/20/2019 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/20/2019 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/20/2019 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/20/2019 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/20/2019 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/20/2019 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/20/2019 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/20/2019 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/20/2019 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/20/2019 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/20/2019 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/21/2019 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/21/2019 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/21/2019 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/21/2019 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/21/2019 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/21/2019 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/21/2019 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/21/2019 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/21/2019 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/21/2019 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/21/2019 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/21/2019 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/21/2019 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/21/2019 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/21/2019 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/21/2019 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/21/2019 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/21/2019 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/21/2019 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/21/2019 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/21/2019 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/21/2019 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/21/2019 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/21/2019 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/22/2019 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/22/2019 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/22/2019 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/22/2019 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/22/2019 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/22/2019 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/22/2019 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/22/2019 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/22/2019 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/22/2019 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/22/2019 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/22/2019 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/22/2019 12:00	353.2	0.0	353.2	104,200.0	36.8	0.0	0.0	0.0
07/22/2019 13:00	2,994.4	0.0	2,994.4	104,200.0	312.0	0.5	0.2	0.8
07/22/2019 14:00	4,377.5	0.0	4,377.5	104,200.0	456.1	0.5	0.3	0.9
07/22/2019 15:00	3,883.2	0.0	3,883.2	104,200.0	404.6	0.5	0.2	0.8
07/22/2019 16:00	3,622.5	0.0	3,622.5	104,200.0	377.5	0.5	0.2	0.8
07/22/2019 17:00	3,619.7	0.0	3,619.7	104,200.0	377.2	0.5	0.2	0.8
07/22/2019 18:00	3,688.6	0.0	3,688.6	104,200.0	384.4	0.5	0.2	0.8
07/22/2019 19:00	3,554.4	0.0	3,554.4	104,200.0	370.4	0.4	0.2	0.7
07/22/2019 20:00	3,540.0	0.0	3,540.0	104,200.0	368.9	0.4	0.2	0.7
07/22/2019 21:00	3,478.2	0.0	3,478.2	104,200.0	362.4	0.4	0.2	0.7
07/22/2019 22:00	3,524.5	0.0	3,524.5	104,200.0	367.3	0.4	0.2	0.7
07/22/2019 23:00	3,531.5	0.0	3,531.5	104,200.0	368.0	0.4	0.2	0.7
Average/Sum#:	3,347.3	0.0	3,347.3	104,200.0	348.8	0.5	0.2	0.8
Minimum:	353.2	0.0	353.2	104,200.0	36.8	0.4	0.2	0.7
Maximum:	4,377.5	0.0	4,377.5	104,200.0	456.1	0.5	0.3	0.9
%SI	50.00	50.00	50.00	0.00	50.00	54.17	54.17	54.17

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/23/2019 00:00	3,532.2	0.0	3,532.2	104,200.0	368.1	0.4	0.2	0.7
07/23/2019 01:00	3,534.8	0.0	3,534.8	104,200.0	368.3	0.4	0.2	0.7
07/23/2019 02:00	3,536.0	0.0	3,536.0	104,200.0	368.5	0.4	0.2	0.7
07/23/2019 03:00	3,538.9	0.0	3,538.9	104,200.0	368.8	0.4	0.2	0.7
07/23/2019 04:00	3,540.8	0.0	3,540.8	104,200.0	369.0	0.4	0.2	0.7
07/23/2019 05:00	3,541.6	0.0	3,541.6	104,200.0	369.0	0.4	0.2	0.7
07/23/2019 06:00	3,624.6	0.0	3,624.6	104,200.0	377.7	0.5	0.2	0.8
07/23/2019 07:00	3,816.2	0.0	3,816.2	104,200.0	397.6	0.5	0.2	0.8
07/23/2019 08:00	4,039.2	0.0	4,039.2	104,200.0	420.9	0.5	0.3	0.8
07/23/2019 09:00	4,467.9	0.0	4,467.9	104,200.0	465.6	0.6	0.3	0.9
07/23/2019 10:00	4,414.9	0.0	4,414.9	104,200.0	460.0	0.6	0.3	0.9
07/23/2019 11:00	4,274.7	0.0	4,274.7	104,200.0	445.4	0.5	0.3	0.9
07/23/2019 12:00	1,542.8	0.0	1,542.8	104,200.0	160.8	0.0	0.0	0.0
07/23/2019 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/23/2019 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/23/2019 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/23/2019 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/23/2019 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/23/2019 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/23/2019 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/23/2019 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/23/2019 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/23/2019 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/23/2019 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,646.5	0.0	3,646.5	104,200.0	380.0	0.5	0.2	0.8
Minimum:	1,542.8	0.0	1,542.8	104,200.0	160.8	0.4	0.2	0.7
Maximum:	4,467.9	0.0	4,467.9	104,200.0	465.6	0.6	0.3	0.9
%SI	45.83	45.83	45.83	0.00	45.83	50.00	50.00	50.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/24/2019 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/24/2019 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/24/2019 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/24/2019 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/24/2019 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/24/2019 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/24/2019 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/24/2019 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/24/2019 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/24/2019 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/24/2019 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/24/2019 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/24/2019 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/24/2019 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/24/2019 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/24/2019 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/24/2019 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/24/2019 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/24/2019 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/24/2019 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/24/2019 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/24/2019 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/24/2019 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/24/2019 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/25/2019 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/25/2019 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/25/2019 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/25/2019 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/25/2019 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/25/2019 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/25/2019 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/25/2019 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/25/2019 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/25/2019 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/25/2019 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/25/2019 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/25/2019 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/25/2019 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/25/2019 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/25/2019 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/25/2019 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/25/2019 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/25/2019 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/25/2019 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/25/2019 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/25/2019 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/25/2019 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/25/2019 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/26/2019 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/26/2019 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/26/2019 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/26/2019 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/26/2019 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/26/2019 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/26/2019 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/26/2019 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/26/2019 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/26/2019 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/26/2019 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/26/2019 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/26/2019 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/26/2019 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/26/2019 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/26/2019 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/26/2019 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/26/2019 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/26/2019 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/26/2019 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/26/2019 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/26/2019 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/26/2019 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/26/2019 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/27/2019 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/27/2019 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/27/2019 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/27/2019 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/27/2019 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/27/2019 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/27/2019 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/27/2019 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/27/2019 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/27/2019 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/27/2019 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/27/2019 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/27/2019 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/27/2019 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/27/2019 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/27/2019 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/27/2019 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/27/2019 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/27/2019 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/27/2019 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/27/2019 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/27/2019 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
07/27/2019 22:00	1,617.1	0.0	1,617.1	104,200.0	168.5	0.0	0.0	0.0
07/27/2019 23:00	3,646.9	0.0	3,646.9	104,200.0	380.0	0.5	0.2	0.8
Average/Sum#:	2,632.0	0.0	2,632.0	104,200.0	274.3	0.5	0.2	0.8
Minimum:	1,617.1	0.0	1,617.1	104,200.0	168.5	0.5	0.2	0.8
Maximum:	3,646.9	0.0	3,646.9	104,200.0	380.0	0.5	0.2	0.8
%SI	91.67	91.67	91.67	0.00	91.67	95.83	95.83	95.83

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/28/2019 00:00	3,720.1	0.0	3,720.1	104,200.0	387.6	0.5	0.2	0.8
07/28/2019 01:00	3,446.7	0.0	3,446.7	104,200.0	359.1	0.4	0.2	0.7
07/28/2019 02:00	3,232.6	0.0	3,232.6	104,200.0	336.8	0.4	0.2	0.7
07/28/2019 03:00	3,296.8	0.0	3,296.8	104,200.0	343.5	0.4	0.2	0.7
07/28/2019 04:00	3,335.0	0.0	3,335.0	104,200.0	347.5	0.4	0.2	0.7
07/28/2019 05:00	3,366.8	0.0	3,366.8	104,200.0	350.8	0.4	0.2	0.7
07/28/2019 06:00	3,390.9	0.0	3,390.9	104,200.0	353.3	0.4	0.2	0.7
07/28/2019 07:00	3,609.5	0.0	3,609.5	104,200.0	376.1	0.5	0.2	0.8
07/28/2019 08:00	3,619.0	0.0	3,619.0	104,200.0	377.1	0.5	0.2	0.8
07/28/2019 09:00	3,711.6	0.0	3,711.6	104,200.0	386.7	0.5	0.2	0.8
07/28/2019 10:00	4,388.5	0.0	4,388.5	104,200.0	457.3	0.5	0.3	0.9
07/28/2019 11:00	4,376.4	39.4	4,381.5	104,200.0	456.6	0.6	0.3	0.9
07/28/2019 12:00	4,369.8	1,277.2	5,647.0	104,200.0	588.4	0.7	0.4	1.2
07/28/2019 13:00	4,380.7	1,770.8	6,151.5	104,200.0	641.0	0.8	0.4	1.3
07/28/2019 14:00	4,371.4	1,898.8	6,270.2	104,200.0	653.4	0.8	0.4	1.3
07/28/2019 15:00	4,366.4	1,891.7	6,258.1	104,200.0	652.1	0.8	0.4	1.3
07/28/2019 16:00	4,363.9	1,889.6	6,253.5	104,200.0	651.6	0.8	0.4	1.3
07/28/2019 17:00	4,354.1	1,869.0	6,223.1	104,200.0	648.4	0.8	0.4	1.3
07/28/2019 18:00	4,382.4	1,804.7	6,187.1	104,200.0	644.7	0.8	0.4	1.3
07/28/2019 19:00	4,409.7	908.3	5,318.0	104,200.0	554.1	0.7	0.3	1.1
07/28/2019 20:00	4,431.3	1,770.4	6,201.7	104,200.0	646.2	0.8	0.4	1.3
07/28/2019 21:00	4,439.1	1,634.0	6,073.1	104,200.0	632.8	0.8	0.4	1.3
07/28/2019 22:00	4,457.1	892.6	5,349.7	104,200.0	557.4	0.7	0.3	1.1
07/28/2019 23:00	4,478.4	37.3	4,485.1	104,200.0	467.3	0.6	0.3	0.9
Average/Sum#:	4,012.4	736.8	4,746.5	104,200.0	494.6	0.6	0.3	1.0
Minimum:	3,232.6	0.0	3,232.6	104,200.0	336.8	0.4	0.2	0.7
Maximum:	4,478.4	1,898.8	6,270.2	104,200.0	653.4	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/29/2019 00:00	4,257.8	0.0	4,257.8	104,200.0	443.7	0.5	0.3	0.9
07/29/2019 01:00	4,210.5	0.0	4,210.5	104,200.0	438.7	0.5	0.3	0.9
07/29/2019 02:00	4,130.1	0.0	4,130.1	104,200.0	430.4	0.5	0.3	0.9
07/29/2019 03:00	4,096.0	0.0	4,096.0	104,200.0	426.8	0.5	0.3	0.9
07/29/2019 04:00	4,047.6	0.0	4,047.6	104,200.0	421.8	0.5	0.3	0.8
07/29/2019 05:00	4,419.2	36.3	4,422.8	104,200.0	460.9	0.6	0.3	0.9
07/29/2019 06:00	4,558.5	679.6	5,238.1	104,200.0	545.8	0.7	0.3	1.1
07/29/2019 07:00	4,546.5	991.4	5,518.1	104,200.0	575.0	0.7	0.3	1.2
07/29/2019 08:00	4,304.8	0.0	4,304.8	104,200.0	448.6	0.5	0.3	0.9
07/29/2019 09:00	4,243.5	10.5	4,243.8	104,200.0	442.2	0.5	0.3	0.9
07/29/2019 10:00	4,492.0	882.5	5,374.5	104,200.0	560.0	0.7	0.3	1.1
07/29/2019 11:00	4,474.1	1,313.5	5,787.6	104,200.0	603.1	0.7	0.4	1.2
07/29/2019 12:00	4,456.8	11.4	4,457.7	104,200.0	464.5	0.6	0.3	0.9
07/29/2019 13:00	4,440.9	1,614.6	6,055.5	104,200.0	631.0	0.8	0.4	1.3
07/29/2019 14:00	4,430.5	1,917.6	6,348.1	104,200.0	661.5	0.8	0.4	1.3
07/29/2019 15:00	4,427.6	1,905.7	6,333.3	104,200.0	659.9	0.8	0.4	1.3
07/29/2019 16:00	4,408.9	1,736.1	6,145.0	104,200.0	640.3	0.8	0.4	1.3
07/29/2019 17:00	4,407.8	1,727.3	6,135.1	104,200.0	639.3	0.8	0.4	1.3
07/29/2019 18:00	4,426.4	1,647.5	6,073.9	104,200.0	632.9	0.8	0.4	1.3
07/29/2019 19:00	4,456.7	922.2	5,378.9	104,200.0	560.5	0.7	0.3	1.1
07/29/2019 20:00	4,488.6	1,480.9	5,969.5	104,200.0	622.0	0.7	0.4	1.2
07/29/2019 21:00	4,514.2	1,114.4	5,628.6	104,200.0	586.5	0.7	0.4	1.2
07/29/2019 22:00	4,441.2	72.5	4,464.4	104,200.0	465.2	0.6	0.3	0.9
07/29/2019 23:00	3,246.2	0.0	3,246.2	104,200.0	338.3	0.4	0.2	0.7
Average/Sum#:	4,330.3	752.7	5,077.8	104,200.0	529.1	0.6	0.3	1.1
Minimum:	3,246.2	0.0	3,246.2	104,200.0	338.3	0.4	0.2	0.7
Maximum:	4,558.5	1,917.6	6,348.1	104,200.0	661.5	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/30/2019 00:00	3,160.7	0.0	3,160.7	104,200.0	329.3	0.4	0.2	0.7
07/30/2019 01:00	3,195.8	0.0	3,195.8	104,200.0	333.0	0.4	0.2	0.7
07/30/2019 02:00	3,191.1	0.0	3,191.1	104,200.0	332.5	0.4	0.2	0.7
07/30/2019 03:00	3,190.8	0.0	3,190.8	104,200.0	332.5	0.4	0.2	0.7
07/30/2019 04:00	3,195.7	0.0	3,195.7	104,200.0	333.0	0.4	0.2	0.7
07/30/2019 05:00	3,696.8	0.0	3,696.8	104,200.0	385.2	0.5	0.2	0.8
07/30/2019 06:00	3,855.0	0.0	3,855.0	104,200.0	401.7	0.5	0.2	0.8
07/30/2019 07:00	4,191.4	0.0	4,191.4	104,200.0	436.7	0.5	0.3	0.9
07/30/2019 08:00	4,245.6	0.0	4,245.6	104,200.0	442.4	0.5	0.3	0.9
07/30/2019 09:00	4,139.9	0.0	4,139.9	104,200.0	431.4	0.5	0.3	0.9
07/30/2019 10:00	4,170.4	0.0	4,170.4	104,200.0	434.6	0.5	0.3	0.9
07/30/2019 11:00	4,043.7	0.0	4,043.7	104,200.0	421.4	0.5	0.3	0.8
07/30/2019 12:00	3,981.1	0.0	3,981.1	104,200.0	414.8	0.5	0.2	0.8
07/30/2019 13:00	3,235.7	0.0	3,235.7	104,200.0	337.2	0.4	0.2	0.7
07/30/2019 14:00	3,349.1	0.0	3,349.1	104,200.0	349.0	0.4	0.2	0.7
07/30/2019 15:00	3,431.0	0.0	3,431.0	104,200.0	357.5	0.4	0.2	0.7
07/30/2019 16:00	4,407.0	0.6	4,407.1	104,200.0	459.2	0.6	0.3	0.9
07/30/2019 17:00	4,475.7	8.7	4,476.3	104,200.0	466.4	0.6	0.3	0.9
07/30/2019 18:00	3,937.8	0.0	3,937.8	104,200.0	410.3	0.5	0.2	0.8
07/30/2019 19:00	3,725.2	0.0	3,725.2	104,200.0	388.2	0.5	0.2	0.8
07/30/2019 20:00	3,913.7	0.0	3,913.7	104,200.0	407.8	0.5	0.2	0.8
07/30/2019 21:00	3,779.6	0.0	3,779.6	104,200.0	393.8	0.5	0.2	0.8
07/30/2019 22:00	3,863.7	0.0	3,863.7	104,200.0	402.6	0.5	0.2	0.8
07/30/2019 23:00	3,408.5	0.0	3,408.5	104,200.0	355.2	0.4	0.2	0.7
Average/Sum#:	3,741.0	0.4	3,741.1	104,200.0	389.8	0.5	0.2	0.8
Minimum:	3,160.7	0.0	3,160.7	104,200.0	329.3	0.4	0.2	0.7
Maximum:	4,475.7	8.7	4,476.3	104,200.0	466.4	0.6	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/31/2019 00:00	3,262.8	0.0	3,262.8	104,200.0	340.0	0.4	0.2	0.7
07/31/2019 01:00	3,153.3	0.0	3,153.3	104,200.0	328.6	0.4	0.2	0.7
07/31/2019 02:00	3,151.0	0.0	3,151.0	104,200.0	328.3	0.4	0.2	0.7
07/31/2019 03:00	3,160.4	0.0	3,160.4	104,200.0	329.3	0.4	0.2	0.7
07/31/2019 04:00	3,148.1	0.0	3,148.1	104,200.0	328.0	0.4	0.2	0.7
07/31/2019 05:00	3,110.4	0.0	3,110.4	104,200.0	324.1	0.4	0.2	0.6
07/31/2019 06:00	3,156.6	0.0	3,156.6	104,200.0	328.9	0.4	0.2	0.7
07/31/2019 07:00	3,331.4	0.0	3,331.4	104,200.0	347.1	0.4	0.2	0.7
07/31/2019 08:00	3,473.9	0.0	3,473.9	104,200.0	362.0	0.4	0.2	0.7
07/31/2019 09:00	3,288.2	0.0	3,288.2	104,200.0	342.6	0.4	0.2	0.7
07/31/2019 10:00	3,112.3	0.0	3,112.3	104,200.0	324.3	0.4	0.2	0.6
07/31/2019 11:00	3,109.7	0.0	3,109.7	104,200.0	324.0	0.4	0.2	0.6
07/31/2019 12:00	3,759.6	0.0	3,759.6	104,200.0	391.8	0.5	0.2	0.8
07/31/2019 13:00	4,124.6	0.2	4,124.6	104,200.0	429.8	0.5	0.3	0.9
07/31/2019 14:00	4,455.9	1,385.9	5,841.8	104,200.0	608.7	0.7	0.4	1.2
07/31/2019 15:00	4,445.2	1,268.8	5,714.0	104,200.0	595.4	0.7	0.4	1.2
07/31/2019 16:00	4,443.5	1,165.4	5,608.9	104,200.0	584.4	0.7	0.4	1.2
07/31/2019 17:00	4,455.2	1,097.4	5,552.6	104,200.0	578.6	0.7	0.3	1.2
07/31/2019 18:00	4,468.5	1,091.0	5,559.5	104,200.0	579.3	0.7	0.3	1.2
07/31/2019 19:00	4,500.8	1,140.8	5,641.6	104,200.0	587.9	0.7	0.4	1.2
07/31/2019 20:00	4,205.7	35.6	4,210.3	104,200.0	438.7	0.5	0.3	0.9
07/31/2019 21:00	3,979.6	0.0	3,979.6	104,200.0	414.7	0.5	0.2	0.8
07/31/2019 22:00	3,282.7	0.0	3,282.7	104,200.0	342.1	0.4	0.2	0.7
07/31/2019 23:00	3,185.7	0.0	3,185.7	104,200.0	331.9	0.4	0.2	0.7
Average/Sum#:	3,656.9	299.4	3,955.0	104,200.0	412.1	0.5	0.3	0.8
Minimum:	3,109.7	0.0	3,109.7	104,200.0	324.0	0.4	0.2	0.6
Maximum:	4,500.8	1,385.9	5,841.8	104,200.0	608.7	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/01/2019 00:00	3,179.4	0.0	3,179.4	104,200.0	331.3	0.4	0.2	0.7
08/01/2019 01:00	3,187.5	0.0	3,187.5	104,200.0	332.1	0.4	0.2	0.7
08/01/2019 02:00	3,206.9	0.0	3,206.9	104,200.0	334.2	0.4	0.2	0.7
08/01/2019 03:00	3,217.5	0.0	3,217.5	104,200.0	335.3	0.4	0.2	0.7
08/01/2019 04:00	3,239.3	0.0	3,239.3	104,200.0	337.5	0.4	0.2	0.7
08/01/2019 05:00	3,269.9	0.0	3,269.9	104,200.0	340.7	0.4	0.2	0.7
08/01/2019 06:00	3,291.9	0.0	3,291.9	104,200.0	343.0	0.4	0.2	0.7
08/01/2019 07:00	3,374.4	0.0	3,374.4	104,200.0	351.6	0.4	0.2	0.7
08/01/2019 08:00	3,367.4	0.0	3,367.4	104,200.0	350.9	0.4	0.2	0.7
08/01/2019 09:00	3,480.2	0.0	3,480.2	104,200.0	362.6	0.4	0.2	0.7
08/01/2019 10:00	3,411.2	0.0	3,411.2	104,200.0	355.4	0.4	0.2	0.7
08/01/2019 11:00	3,461.0	0.0	3,461.0	104,200.0	360.6	0.4	0.2	0.7
08/01/2019 12:00	4,380.1	0.0	4,380.1	104,200.0	456.4	0.5	0.3	0.9
08/01/2019 13:00	4,455.6	0.0	4,455.6	104,200.0	464.3	0.6	0.3	0.9
08/01/2019 14:00	4,440.8	0.0	4,440.8	104,200.0	462.7	0.6	0.3	0.9
08/01/2019 15:00	4,435.8	16.9	4,437.8	104,200.0	462.4	0.6	0.3	0.9
08/01/2019 16:00	4,439.6	426.6	4,866.2	104,200.0	507.1	0.6	0.3	1.0
08/01/2019 17:00	4,448.1	544.7	4,992.8	104,200.0	520.2	0.6	0.3	1.0
08/01/2019 18:00	4,470.8	1,187.9	5,658.7	104,200.0	589.6	0.7	0.4	1.2
08/01/2019 19:00	4,462.2	15.3	4,463.4	104,200.0	465.1	0.6	0.3	0.9
08/01/2019 20:00	3,250.8	0.0	3,250.8	104,200.0	338.7	0.4	0.2	0.7
08/01/2019 21:00	3,149.4	0.0	3,149.4	104,200.0	328.2	0.4	0.2	0.7
08/01/2019 22:00	3,161.2	0.0	3,161.2	104,200.0	329.4	0.4	0.2	0.7
08/01/2019 23:00	3,144.5	0.0	3,144.5	104,200.0	327.7	0.4	0.2	0.7
Average/Sum#:	3,663.6	91.3	3,753.7	104,200.0	391.1	0.5	0.2	0.8
Minimum:	3,144.5	0.0	3,144.5	104,200.0	327.7	0.4	0.2	0.7
Maximum:	4,470.8	1,187.9	5,658.7	104,200.0	589.6	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/02/2019 00:00	3,141.5	0.0	3,141.5	104,200.0	327.3	0.4	0.2	0.7
08/02/2019 01:00	3,148.1	0.0	3,148.1	104,200.0	328.0	0.4	0.2	0.7
08/02/2019 02:00	3,159.1	0.0	3,159.1	104,200.0	329.2	0.4	0.2	0.7
08/02/2019 03:00	3,161.1	0.0	3,161.1	104,200.0	329.4	0.4	0.2	0.7
08/02/2019 04:00	3,173.0	0.0	3,173.0	104,200.0	330.6	0.4	0.2	0.7
08/02/2019 05:00	3,179.0	0.0	3,179.0	104,200.0	331.3	0.4	0.2	0.7
08/02/2019 06:00	3,171.9	0.0	3,171.9	104,200.0	330.5	0.4	0.2	0.7
08/02/2019 07:00	3,171.1	0.0	3,171.1	104,200.0	330.4	0.4	0.2	0.7
08/02/2019 08:00	3,176.7	0.0	3,176.7	104,200.0	331.0	0.4	0.2	0.7
08/02/2019 09:00	3,179.8	0.0	3,179.8	104,200.0	331.3	0.4	0.2	0.7
08/02/2019 10:00	3,168.0	0.0	3,168.0	104,200.0	330.1	0.4	0.2	0.7
08/02/2019 11:00	3,178.2	0.0	3,178.2	104,200.0	331.2	0.4	0.2	0.7
08/02/2019 12:00	3,517.5	0.0	3,517.5	104,200.0	366.5	0.4	0.2	0.7
08/02/2019 13:00	4,360.4	234.2	4,519.7	104,200.0	471.0	0.6	0.3	1.0
08/02/2019 14:00	4,430.4	259.0	4,689.4	104,200.0	488.6	0.6	0.3	1.0
08/02/2019 15:00	4,437.8	1,529.1	5,966.9	104,200.0	621.8	0.7	0.4	1.2
08/02/2019 16:00	4,434.9	1,585.8	6,020.7	104,200.0	627.4	0.8	0.4	1.3
08/02/2019 17:00	4,417.6	1,668.4	6,086.0	104,200.0	634.2	0.8	0.4	1.3
08/02/2019 18:00	4,413.7	933.6	5,347.3	104,200.0	557.2	0.7	0.3	1.1
08/02/2019 19:00	4,434.3	210.8	4,630.3	104,200.0	482.5	0.6	0.3	1.0
08/02/2019 20:00	3,676.0	0.0	3,676.0	104,200.0	383.0	0.5	0.2	0.8
08/02/2019 21:00	3,231.3	0.0	3,231.3	104,200.0	336.7	0.4	0.2	0.7
08/02/2019 22:00	3,224.2	0.0	3,224.2	104,200.0	336.0	0.4	0.2	0.7
08/02/2019 23:00	3,273.2	0.0	3,273.2	104,200.0	341.1	0.4	0.2	0.7
Average/Sum#:	3,577.5	267.5	3,841.3	104,200.0	400.3	0.5	0.2	0.8
Minimum:	3,141.5	0.0	3,141.5	104,200.0	327.3	0.4	0.2	0.7
Maximum:	4,437.8	1,668.4	6,086.0	104,200.0	634.2	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/03/2019 00:00	3,282.2	0.0	3,282.2	104,200.0	342.0	0.4	0.2	0.7
08/03/2019 01:00	3,131.5	0.0	3,131.5	104,200.0	326.3	0.4	0.2	0.7
08/03/2019 02:00	3,124.5	0.0	3,124.5	104,200.0	325.6	0.4	0.2	0.7
08/03/2019 03:00	3,125.4	0.0	3,125.4	104,200.0	325.7	0.4	0.2	0.7
08/03/2019 04:00	3,123.0	0.0	3,123.0	104,200.0	325.4	0.4	0.2	0.7
08/03/2019 05:00	3,121.2	0.0	3,121.2	104,200.0	325.2	0.4	0.2	0.7
08/03/2019 06:00	3,122.3	0.0	3,122.3	104,200.0	325.3	0.4	0.2	0.7
08/03/2019 07:00	3,239.2	0.0	3,239.2	104,200.0	337.5	0.4	0.2	0.7
08/03/2019 08:00	3,242.8	0.0	3,242.8	104,200.0	337.9	0.4	0.2	0.7
08/03/2019 09:00	3,266.6	0.0	3,266.6	104,200.0	340.4	0.4	0.2	0.7
08/03/2019 10:00	3,362.3	0.0	3,362.3	104,200.0	350.4	0.4	0.2	0.7
08/03/2019 11:00	3,461.6	0.0	3,461.6	104,200.0	360.7	0.4	0.2	0.7
08/03/2019 12:00	3,662.9	0.0	3,662.9	104,200.0	381.7	0.5	0.2	0.8
08/03/2019 13:00	4,396.7	357.3	4,754.0	104,200.0	495.4	0.6	0.3	1.0
08/03/2019 14:00	4,389.8	759.7	5,149.5	104,200.0	536.6	0.6	0.3	1.1
08/03/2019 15:00	4,385.2	1,913.2	6,298.4	104,200.0	656.3	0.8	0.4	1.3
08/03/2019 16:00	4,398.7	1,869.0	6,267.7	104,200.0	653.1	0.8	0.4	1.3
08/03/2019 17:00	4,397.8	1,671.1	6,068.9	104,200.0	632.4	0.8	0.4	1.3
08/03/2019 18:00	4,402.0	1,815.2	6,217.2	104,200.0	647.8	0.8	0.4	1.3
08/03/2019 19:00	4,447.1	1,322.7	5,769.8	104,200.0	601.2	0.7	0.4	1.2
08/03/2019 20:00	4,466.7	406.0	4,852.4	104,200.0	505.6	0.6	0.3	1.0
08/03/2019 21:00	3,966.9	0.0	3,966.9	104,200.0	413.4	0.5	0.2	0.8
08/03/2019 22:00	3,598.2	0.0	3,598.2	104,200.0	374.9	0.5	0.2	0.8
08/03/2019 23:00	3,264.0	0.0	3,264.0	104,200.0	340.1	0.4	0.2	0.7
Average/Sum#:	3,682.4	421.4	4,103.0	104,200.0	427.5	0.5	0.3	0.9
Minimum:	3,121.2	0.0	3,121.2	104,200.0	325.2	0.4	0.2	0.7
Maximum:	4,466.7	1,913.2	6,298.4	104,200.0	656.3	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/04/2019 00:00	3,224.1	0.0	3,224.1	104,200.0	336.0	0.4	0.2	0.7
08/04/2019 01:00	3,236.6	0.0	3,236.6	104,200.0	337.3	0.4	0.2	0.7
08/04/2019 02:00	3,249.4	0.0	3,249.4	104,200.0	338.6	0.4	0.2	0.7
08/04/2019 03:00	3,265.8	0.0	3,265.8	104,200.0	340.3	0.4	0.2	0.7
08/04/2019 04:00	3,242.6	0.0	3,242.6	104,200.0	337.9	0.4	0.2	0.7
08/04/2019 05:00	3,306.2	0.0	3,306.2	104,200.0	344.5	0.4	0.2	0.7
08/04/2019 06:00	3,174.8	0.0	3,174.8	104,200.0	330.8	0.4	0.2	0.7
08/04/2019 07:00	3,195.7	0.0	3,195.7	104,200.0	333.0	0.4	0.2	0.7
08/04/2019 08:00	3,249.1	0.0	3,249.1	104,200.0	338.6	0.4	0.2	0.7
08/04/2019 09:00	3,259.3	0.0	3,259.3	104,200.0	339.6	0.4	0.2	0.7
08/04/2019 10:00	3,273.4	0.0	3,273.4	104,200.0	341.1	0.4	0.2	0.7
08/04/2019 11:00	3,508.3	0.0	3,508.3	104,200.0	365.6	0.4	0.2	0.7
08/04/2019 12:00	4,262.3	506.4	4,556.0	104,200.0	474.7	0.6	0.3	1.0
08/04/2019 13:00	4,416.3	1,400.8	5,817.1	104,200.0	606.1	0.7	0.4	1.2
08/04/2019 14:00	4,409.4	1,321.4	5,730.8	104,200.0	597.1	0.7	0.4	1.2
08/04/2019 15:00	4,422.4	1,452.8	5,875.2	104,200.0	612.2	0.7	0.4	1.2
08/04/2019 16:00	4,410.8	1,177.1	5,587.9	104,200.0	582.3	0.7	0.3	1.2
08/04/2019 17:00	4,409.5	1,391.4	5,800.9	104,200.0	604.5	0.7	0.4	1.2
08/04/2019 18:00	4,422.0	1,791.9	6,213.9	104,200.0	647.5	0.8	0.4	1.3
08/04/2019 19:00	4,449.3	1,804.8	6,254.1	104,200.0	651.7	0.8	0.4	1.3
08/04/2019 20:00	4,472.7	1,360.2	5,832.9	104,200.0	607.8	0.7	0.4	1.2
08/04/2019 21:00	4,494.5	480.1	4,974.6	104,200.0	518.4	0.6	0.3	1.0
08/04/2019 22:00	4,475.5	4.3	4,476.1	104,200.0	466.4	0.6	0.3	0.9
08/04/2019 23:00	3,314.0	0.0	3,314.0	104,200.0	345.3	0.4	0.2	0.7
Average/Sum#:	3,797.7	528.8	4,317.5	104,200.0	449.9	0.5	0.3	0.9
Minimum:	3,174.8	0.0	3,174.8	104,200.0	330.8	0.4	0.2	0.7
Maximum:	4,494.5	1,804.8	6,254.1	104,200.0	651.7	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/05/2019 00:00	3,072.9	0.0	3,072.9	104,200.0	320.2	0.4	0.2	0.6
08/05/2019 01:00	3,076.8	0.0	3,076.8	104,200.0	320.6	0.4	0.2	0.6
08/05/2019 02:00	3,078.9	0.0	3,078.9	104,200.0	320.8	0.4	0.2	0.6
08/05/2019 03:00	3,080.0	0.0	3,080.0	104,200.0	320.9	0.4	0.2	0.6
08/05/2019 04:00	3,079.9	0.0	3,079.9	104,200.0	320.9	0.4	0.2	0.6
08/05/2019 05:00	3,080.7	0.0	3,080.7	104,200.0	321.0	0.4	0.2	0.6
08/05/2019 06:00	3,224.4	0.0	3,224.4	104,200.0	336.0	0.4	0.2	0.7
08/05/2019 07:00	3,242.3	0.0	3,242.3	104,200.0	337.8	0.4	0.2	0.7
08/05/2019 08:00	3,259.3	0.0	3,259.3	104,200.0	339.6	0.4	0.2	0.7
08/05/2019 09:00	3,314.4	0.0	3,314.4	104,200.0	345.4	0.4	0.2	0.7
08/05/2019 10:00	3,340.0	0.0	3,340.0	104,200.0	348.0	0.4	0.2	0.7
08/05/2019 11:00	3,461.2	0.0	3,461.2	104,200.0	360.7	0.4	0.2	0.7
08/05/2019 12:00	4,139.6	0.0	4,139.6	104,200.0	431.3	0.5	0.3	0.9
08/05/2019 13:00	4,375.1	0.0	4,375.1	104,200.0	455.9	0.5	0.3	0.9
08/05/2019 14:00	4,365.3	0.0	4,365.3	104,200.0	454.9	0.5	0.3	0.9
08/05/2019 15:00	4,406.2	1,459.9	5,866.1	104,200.0	611.2	0.7	0.4	1.2
08/05/2019 16:00	4,403.0	1,535.7	5,938.7	104,200.0	618.8	0.7	0.4	1.2
08/05/2019 17:00	4,415.5	1,910.4	6,325.9	104,200.0	659.2	0.8	0.4	1.3
08/05/2019 18:00	4,418.8	1,912.2	6,331.0	104,200.0	659.7	0.8	0.4	1.3
08/05/2019 19:00	4,433.8	1,360.8	5,794.6	104,200.0	603.8	0.7	0.4	1.2
08/05/2019 20:00	4,478.7	122.8	4,519.2	104,200.0	470.9	0.6	0.3	1.0
08/05/2019 21:00	4,160.1	0.0	4,160.1	104,200.0	433.5	0.5	0.3	0.9
08/05/2019 22:00	3,400.7	0.0	3,400.7	104,200.0	354.4	0.4	0.2	0.7
08/05/2019 23:00	3,097.8	0.0	3,097.8	104,200.0	322.8	0.4	0.2	0.6
Average/Sum#:	3,683.6	345.9	4,026.0	104,200.0	419.5	0.5	0.3	0.8
Minimum:	3,072.9	0.0	3,072.9	104,200.0	320.2	0.4	0.2	0.6
Maximum:	4,478.7	1,912.2	6,331.0	104,200.0	659.7	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/06/2019 00:00	3,055.8	0.0	3,055.8	104,200.0	318.4	0.4	0.2	0.6
08/06/2019 01:00	3,056.1	0.0	3,056.1	104,200.0	318.4	0.4	0.2	0.6
08/06/2019 02:00	3,060.6	0.0	3,060.6	104,200.0	318.9	0.4	0.2	0.6
08/06/2019 03:00	3,109.0	0.0	3,109.0	104,200.0	324.0	0.4	0.2	0.6
08/06/2019 04:00	3,152.6	0.0	3,152.6	104,200.0	328.5	0.4	0.2	0.7
08/06/2019 05:00	3,358.4	0.0	3,358.4	104,200.0	349.9	0.4	0.2	0.7
08/06/2019 06:00	3,365.4	0.0	3,365.4	104,200.0	350.7	0.4	0.2	0.7
08/06/2019 07:00	3,370.8	0.0	3,370.8	104,200.0	351.2	0.4	0.2	0.7
08/06/2019 08:00	3,381.2	0.0	3,381.2	104,200.0	352.3	0.4	0.2	0.7
08/06/2019 09:00	3,184.9	0.0	3,184.9	104,200.0	331.9	0.4	0.2	0.7
08/06/2019 10:00	3,562.5	0.0	3,562.5	104,200.0	371.2	0.4	0.2	0.7
08/06/2019 11:00	4,113.4	0.0	4,113.4	104,200.0	428.6	0.5	0.3	0.9
08/06/2019 12:00	4,333.4	0.0	4,333.4	104,200.0	451.5	0.5	0.3	0.9
08/06/2019 13:00	4,398.7	320.2	4,686.9	104,200.0	488.4	0.6	0.3	1.0
08/06/2019 14:00	4,398.9	1,879.0	6,277.9	104,200.0	654.2	0.8	0.4	1.3
08/06/2019 15:00	4,395.8	1,734.4	6,130.2	104,200.0	638.8	0.8	0.4	1.3
08/06/2019 16:00	4,381.4	1,774.1	6,155.5	104,200.0	641.4	0.8	0.4	1.3
08/06/2019 17:00	4,412.3	1,894.3	6,306.6	104,200.0	657.1	0.8	0.4	1.3
08/06/2019 18:00	4,461.0	1,547.0	6,008.0	104,200.0	626.0	0.8	0.4	1.3
08/06/2019 19:00	4,469.0	610.7	5,079.7	104,200.0	529.3	0.6	0.3	1.1
08/06/2019 20:00	4,473.9	706.0	5,179.9	104,200.0	539.7	0.6	0.3	1.1
08/06/2019 21:00	4,441.8	0.0	4,441.8	104,200.0	462.8	0.6	0.3	0.9
08/06/2019 22:00	3,529.9	0.0	3,529.9	104,200.0	367.8	0.4	0.2	0.7
08/06/2019 23:00	3,113.8	0.0	3,113.8	104,200.0	324.5	0.4	0.2	0.7
Average/Sum#:	3,774.2	436.1	4,208.9	104,200.0	438.6	0.5	0.3	0.9
Minimum:	3,055.8	0.0	3,055.8	104,200.0	318.4	0.4	0.2	0.6
Maximum:	4,473.9	1,894.3	6,306.6	104,200.0	657.1	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/07/2019 00:00	3,060.3	0.0	3,060.3	104,200.0	318.9	0.4	0.2	0.6
08/07/2019 01:00	3,061.2	0.0	3,061.2	104,200.0	319.0	0.4	0.2	0.6
08/07/2019 02:00	3,064.0	0.0	3,064.0	104,600.0	320.5	0.4	0.2	0.6
08/07/2019 03:00	3,073.3	0.0	3,073.3	104,600.0	321.5	0.4	0.2	0.6
08/07/2019 04:00	3,103.1	0.0	3,103.1	104,600.0	324.6	0.4	0.2	0.6
08/07/2019 05:00	3,102.8	0.0	3,102.8	104,600.0	324.6	0.4	0.2	0.6
08/07/2019 06:00	3,219.9	0.0	3,219.9	104,600.0	336.8	0.4	0.2	0.7
08/07/2019 07:00	3,234.1	0.0	3,234.1	104,600.0	338.3	0.4	0.2	0.7
08/07/2019 08:00	3,394.3	0.0	3,394.3	104,600.0	355.0	0.4	0.2	0.7
08/07/2019 09:00	3,458.9	0.0	3,458.9	104,600.0	361.8	0.4	0.2	0.7
08/07/2019 10:00	3,477.3	0.0	3,477.3	104,600.0	363.7	0.4	0.2	0.7
08/07/2019 11:00	3,463.6	0.0	3,463.6	104,600.0	362.3	0.4	0.2	0.7
08/07/2019 12:00	4,060.5	0.0	4,060.5	104,600.0	424.7	0.5	0.3	0.8
08/07/2019 13:00	4,414.7	231.8	4,639.5	104,600.0	485.3	0.6	0.3	1.0
08/07/2019 14:00	4,413.3	1,145.0	5,558.3	104,600.0	581.4	0.7	0.3	1.2
08/07/2019 15:00	4,412.3	1,437.0	5,849.3	104,600.0	611.8	0.7	0.4	1.2
08/07/2019 16:00	4,399.5	1,617.1	6,016.6	104,600.0	629.3	0.8	0.4	1.3
08/07/2019 17:00	4,411.8	1,908.8	6,320.6	104,600.0	661.1	0.8	0.4	1.3
08/07/2019 18:00	4,436.6	1,518.1	5,954.7	104,600.0	622.9	0.7	0.4	1.2
08/07/2019 19:00	4,454.8	239.0	4,662.7	104,600.0	487.7	0.6	0.3	1.0
08/07/2019 20:00	3,846.9	0.0	3,846.9	104,600.0	402.4	0.5	0.2	0.8
08/07/2019 21:00	3,646.6	0.0	3,646.6	104,600.0	381.4	0.5	0.2	0.8
08/07/2019 22:00	3,083.1	0.0	3,083.1	104,600.0	322.5	0.4	0.2	0.6
08/07/2019 23:00	3,525.2	0.0	3,525.2	104,600.0	368.7	0.4	0.2	0.7
Average/Sum#:	3,659.1	337.4	3,994.9	104,566.7	417.8	0.5	0.3	0.8
Minimum:	3,060.3	0.0	3,060.3	104,200.0	318.9	0.4	0.2	0.6
Maximum:	4,454.8	1,908.8	6,320.6	104,600.0	661.1	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/08/2019 00:00	3,259.5	0.0	3,259.5	104,600.0	340.9	0.4	0.2	0.7
08/08/2019 01:00	3,075.4	0.0	3,075.4	104,600.0	321.7	0.4	0.2	0.6
08/08/2019 02:00	3,077.0	0.0	3,077.0	104,600.0	321.9	0.4	0.2	0.6
08/08/2019 03:00	3,078.5	0.0	3,078.5	104,600.0	322.0	0.4	0.2	0.6
08/08/2019 04:00	3,037.8	0.0	3,037.8	104,600.0	317.8	0.4	0.2	0.6
08/08/2019 05:00	1,425.6	0.0	1,425.6	104,600.0	149.1	0.0	0.0	0.0
08/08/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/08/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/08/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/08/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/08/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/08/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/08/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/08/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/08/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/08/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/08/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/08/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/08/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/08/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/08/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/08/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/08/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/08/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	2,825.6	0.0	2,825.6	104,600.0	295.6	0.4	0.2	0.6
Minimum:	1,425.6	0.0	1,425.6	104,600.0	149.1	0.4	0.2	0.6
Maximum:	3,259.5	0.0	3,259.5	104,600.0	340.9	0.4	0.2	0.7
%SI	75.00	75.00	75.00	0.00	75.00	79.17	79.17	79.17

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/09/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/09/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/09/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/09/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/09/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/09/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/09/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/09/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/09/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/09/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/09/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/09/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/09/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/09/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/09/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/09/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/09/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/09/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/09/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/09/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/09/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/09/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/09/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/09/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/10/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/10/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/10/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/10/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/10/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/10/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/10/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/10/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/10/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/10/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/10/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/10/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/10/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/10/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/10/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/10/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/10/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/10/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/10/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/10/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/10/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/10/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/10/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/10/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/11/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/11/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/11/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/11/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/11/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/11/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/11/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/11/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/11/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/11/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/11/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/11/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/11/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/11/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/11/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/11/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/11/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/11/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/11/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/11/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/11/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/11/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/11/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/11/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/12/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/12/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/12/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/12/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/12/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/12/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/12/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/12/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/12/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/12/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/12/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/12/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/12/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/12/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/12/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/12/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/12/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/12/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/12/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/12/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/12/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/12/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/12/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/12/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/13/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/13/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/13/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/13/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/13/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/13/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/13/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/13/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/13/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/13/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/13/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/13/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/13/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/13/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/13/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/13/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/13/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/13/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/13/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/13/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/13/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/13/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/13/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/13/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/14/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/14/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/14/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/14/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/14/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/14/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/14/2019 06:00	1,777.5	0.0	1,777.5	104,600.0	185.9	0.0	0.0	0.0
08/14/2019 07:00	3,677.4	0.0	3,677.4	104,600.0	384.7	0.4	0.2	0.7
08/14/2019 08:00	3,115.2	0.0	3,115.2	104,600.0	325.8	0.4	0.2	0.7
08/14/2019 09:00	3,088.8	0.0	3,088.8	104,600.0	323.1	0.4	0.2	0.6
08/14/2019 10:00	3,076.1	0.0	3,076.1	104,600.0	321.8	0.4	0.2	0.6
08/14/2019 11:00	3,067.2	0.0	3,067.2	104,600.0	320.8	0.4	0.2	0.6
08/14/2019 12:00	3,115.1	0.0	3,115.1	104,600.0	325.8	0.4	0.2	0.6
08/14/2019 13:00	4,358.4	38.4	4,368.8	104,600.0	457.0	0.6	0.3	0.9
08/14/2019 14:00	4,381.9	231.2	4,613.1	104,600.0	482.5	0.6	0.3	1.0
08/14/2019 15:00	4,402.6	1,802.3	6,204.9	104,600.0	649.0	0.8	0.4	1.3
08/14/2019 16:00	4,402.6	1,863.2	6,265.8	104,600.0	655.4	0.8	0.4	1.3
08/14/2019 17:00	4,408.1	1,851.4	6,259.5	104,600.0	654.7	0.8	0.4	1.3
08/14/2019 18:00	4,431.1	1,093.0	5,524.1	104,600.0	577.8	0.7	0.3	1.2
08/14/2019 19:00	4,451.0	1,590.7	6,041.7	104,600.0	632.0	0.8	0.4	1.3
08/14/2019 20:00	4,406.7	919.9	5,161.0	104,600.0	539.8	0.7	0.3	1.1
08/14/2019 21:00	4,093.5	0.0	4,093.5	104,600.0	428.2	0.5	0.3	0.9
08/14/2019 22:00	4,327.4	0.0	4,327.4	104,600.0	452.6	0.5	0.3	0.9
08/14/2019 23:00	3,098.0	0.0	3,098.0	104,600.0	324.1	0.4	0.2	0.6
Average/Sum#:	3,759.9	521.7	4,270.8	104,600.0	446.7	0.6	0.3	0.9
Minimum:	1,777.5	0.0	1,777.5	104,600.0	185.9	0.4	0.2	0.6
Maximum:	4,451.0	1,863.2	6,265.8	104,600.0	655.4	0.8	0.4	1.3
%SI	25.00	25.00	25.00	0.00	25.00	29.17	29.17	29.17

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/15/2019 00:00	3,066.3	0.0	3,066.3	104,600.0	320.7	0.4	0.2	0.6
08/15/2019 01:00	3,073.6	0.0	3,073.6	104,600.0	321.5	0.4	0.2	0.6
08/15/2019 02:00	3,070.8	0.0	3,070.8	104,600.0	321.2	0.4	0.2	0.6
08/15/2019 03:00	3,073.7	0.0	3,073.7	104,600.0	321.5	0.4	0.2	0.6
08/15/2019 04:00	3,073.2	0.0	3,073.2	104,600.0	321.5	0.4	0.2	0.6
08/15/2019 05:00	3,075.4	0.0	3,075.4	104,600.0	321.7	0.4	0.2	0.6
08/15/2019 06:00	3,722.4	0.0	3,722.4	104,600.0	389.4	0.5	0.2	0.8
08/15/2019 07:00	3,755.3	0.0	3,755.3	104,600.0	392.8	0.5	0.2	0.8
08/15/2019 08:00	4,002.2	0.0	4,002.2	104,600.0	418.6	0.5	0.3	0.8
08/15/2019 09:00	4,081.1	0.0	4,081.1	104,600.0	426.9	0.5	0.3	0.9
08/15/2019 10:00	3,866.2	0.0	3,866.2	104,600.0	404.4	0.5	0.2	0.8
08/15/2019 11:00	3,762.3	0.0	3,762.3	104,600.0	393.5	0.5	0.2	0.8
08/15/2019 12:00	4,146.6	0.0	4,146.6	104,600.0	433.7	0.5	0.3	0.9
08/15/2019 13:00	4,258.3	84.1	4,275.1	104,600.0	447.2	0.5	0.3	0.9
08/15/2019 14:00	4,373.6	1,815.8	6,189.4	104,600.0	647.4	0.8	0.4	1.3
08/15/2019 15:00	4,372.7	1,902.4	6,275.1	104,600.0	656.4	0.8	0.4	1.3
08/15/2019 16:00	4,368.4	1,900.0	6,268.4	104,600.0	655.7	0.8	0.4	1.3
08/15/2019 17:00	4,356.2	1,896.7	6,252.9	104,600.0	654.1	0.8	0.4	1.3
08/15/2019 18:00	4,358.0	1,714.4	6,072.4	104,600.0	635.2	0.8	0.4	1.3
08/15/2019 19:00	4,379.1	1,094.7	5,473.8	104,600.0	572.6	0.7	0.3	1.1
08/15/2019 20:00	4,391.1	674.1	5,065.2	104,600.0	529.8	0.6	0.3	1.1
08/15/2019 21:00	4,401.8	270.7	4,672.5	104,600.0	488.7	0.6	0.3	1.0
08/15/2019 22:00	4,364.4	49.2	4,408.7	104,600.0	461.2	0.6	0.3	0.9
08/15/2019 23:00	3,101.3	0.0	3,101.3	104,600.0	324.4	0.4	0.2	0.6
Average/Sum#:	3,853.9	475.1	4,326.0	104,600.0	452.5	0.6	0.3	0.9
Minimum:	3,066.3	0.0	3,066.3	104,600.0	320.7	0.4	0.2	0.6
Maximum:	4,401.8	1,902.4	6,275.1	104,600.0	656.4	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/16/2019 00:00	3,103.3	0.0	3,103.3	104,600.0	324.6	0.4	0.2	0.6
08/16/2019 01:00	3,078.3	0.0	3,078.3	104,600.0	322.0	0.4	0.2	0.6
08/16/2019 02:00	3,052.2	0.0	3,052.2	104,600.0	319.3	0.4	0.2	0.6
08/16/2019 03:00	3,052.3	0.0	3,052.3	104,600.0	319.3	0.4	0.2	0.6
08/16/2019 04:00	3,054.9	0.0	3,054.9	104,600.0	319.5	0.4	0.2	0.6
08/16/2019 05:00	3,058.1	0.0	3,058.1	104,600.0	319.9	0.4	0.2	0.6
08/16/2019 06:00	3,107.3	0.0	3,107.3	104,600.0	325.0	0.4	0.2	0.6
08/16/2019 07:00	3,423.2	0.0	3,423.2	104,600.0	358.1	0.4	0.2	0.7
08/16/2019 08:00	3,467.2	0.0	3,467.2	104,600.0	362.7	0.4	0.2	0.7
08/16/2019 09:00	3,677.6	0.0	3,677.6	104,600.0	384.7	0.5	0.2	0.8
08/16/2019 10:00	4,293.5	0.0	4,293.5	104,600.0	449.1	0.5	0.3	0.9
08/16/2019 11:00	4,032.0	0.0	4,032.0	104,600.0	421.7	0.5	0.3	0.8
08/16/2019 12:00	4,364.6	702.6	4,877.5	104,600.0	510.2	0.6	0.3	1.1
08/16/2019 13:00	4,344.5	1,089.6	5,434.1	104,600.0	568.4	0.7	0.3	1.1
08/16/2019 14:00	4,337.0	1,538.9	5,875.9	104,600.0	614.6	0.7	0.4	1.2
08/16/2019 15:00	4,334.5	1,870.7	6,205.2	104,600.0	649.1	0.8	0.4	1.3
08/16/2019 16:00	4,337.3	1,189.4	5,526.7	104,600.0	578.1	0.7	0.3	1.2
08/16/2019 17:00	4,338.4	1,466.1	5,804.5	104,600.0	607.2	0.7	0.4	1.2
08/16/2019 18:00	4,355.7	1,074.9	5,430.6	104,600.0	568.0	0.7	0.3	1.1
08/16/2019 19:00	4,388.5	1,202.8	5,591.3	104,600.0	584.8	0.7	0.3	1.2
08/16/2019 20:00	4,401.0	1,454.8	5,855.8	104,600.0	612.5	0.7	0.4	1.2
08/16/2019 21:00	4,421.0	868.2	5,289.2	104,600.0	553.3	0.7	0.3	1.1
08/16/2019 22:00	4,276.8	671.5	4,827.4	104,600.0	504.9	0.6	0.3	1.1
08/16/2019 23:00	1,672.6	0.0	1,672.6	104,600.0	175.0	0.0	0.0	0.0
Average/Sum#:	3,748.8	547.1	4,282.9	104,600.0	448.0	0.6	0.3	0.9
Minimum:	1,672.6	0.0	1,672.6	104,600.0	175.0	0.4	0.2	0.6
Maximum:	4,421.0	1,870.7	6,205.2	104,600.0	649.1	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	4.17	4.17	4.17

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/17/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/17/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/17/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/17/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/17/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/17/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/17/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/17/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/17/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/17/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/17/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/17/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/17/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/17/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/17/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/17/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/17/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/17/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/17/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/17/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/17/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/17/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/17/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/17/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/18/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/18/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/18/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/18/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/18/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/18/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/18/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/18/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/18/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/18/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/18/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/18/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/18/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/18/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/18/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/18/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/18/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/18/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/18/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/18/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/18/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/18/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/18/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/18/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/19/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/19/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/19/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/19/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/19/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/19/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/19/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/19/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/19/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/19/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/19/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/19/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/19/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/19/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/19/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/19/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/19/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/19/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/19/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/19/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/19/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/19/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/19/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/19/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/20/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/20/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/20/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/20/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/20/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/20/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/20/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/20/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/20/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/20/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/20/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/20/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/20/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/20/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/20/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/20/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/20/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/20/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/20/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/20/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/20/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/20/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/20/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/20/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/21/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/21/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/21/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/21/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/21/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/21/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/21/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/21/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/21/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/21/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/21/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/21/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/21/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/21/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/21/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/21/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/21/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/21/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/21/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/21/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/21/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/21/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/21/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/21/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/22/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/22/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/22/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/22/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/22/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/22/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/22/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/22/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/22/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/22/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/22/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/22/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/22/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/22/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/22/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/22/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/22/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/22/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/22/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/22/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/22/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/22/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/22/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/22/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/23/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/23/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/23/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/23/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/23/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/23/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/23/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/23/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/23/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/23/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/23/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/23/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/23/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/23/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/23/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/23/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/23/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/23/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/23/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/23/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/23/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/23/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/23/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/23/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/24/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/24/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/24/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/24/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/24/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/24/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/24/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/24/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/24/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/24/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/24/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/24/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/24/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/24/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/24/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/24/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/24/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/24/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/24/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/24/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/24/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/24/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/24/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/24/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/25/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/25/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/25/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/25/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/25/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/25/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/25/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/25/2019 07:00	1,740.3	0.0	1,740.3	104,600.0	182.0	0.0	0.0	0.0
08/25/2019 08:00	4,406.8	0.0	4,406.8	104,600.0	461.0	0.6	0.3	0.9
08/25/2019 09:00	4,440.1	0.0	4,440.1	104,600.0	464.4	0.6	0.3	0.9
08/25/2019 10:00	4,444.3	36.6	4,448.7	104,600.0	465.3	0.6	0.3	0.9
08/25/2019 11:00	4,432.3	1,450.3	5,882.6	104,600.0	615.3	0.7	0.4	1.2
08/25/2019 12:00	4,413.1	1,864.6	6,277.7	104,600.0	656.6	0.8	0.4	1.3
08/25/2019 13:00	4,397.4	1,867.8	6,265.2	104,600.0	655.3	0.8	0.4	1.3
08/25/2019 14:00	4,381.2	1,859.8	6,241.0	104,600.0	652.8	0.8	0.4	1.3
08/25/2019 15:00	4,385.2	1,835.7	6,220.9	104,600.0	650.7	0.8	0.4	1.3
08/25/2019 16:00	4,371.3	746.6	5,117.9	104,600.0	535.3	0.6	0.3	1.1
08/25/2019 17:00	4,373.1	610.8	4,983.9	104,600.0	521.3	0.6	0.3	1.0
08/25/2019 18:00	4,398.0	613.0	5,011.0	104,600.0	524.2	0.6	0.3	1.0
08/25/2019 19:00	4,428.0	627.4	5,055.4	104,600.0	528.8	0.6	0.3	1.1
08/25/2019 20:00	4,447.4	1,277.9	5,623.1	104,600.0	588.2	0.7	0.4	1.2
08/25/2019 21:00	4,458.8	0.0	4,458.8	104,600.0	466.4	0.6	0.3	0.9
08/25/2019 22:00	4,347.8	0.0	4,347.8	104,600.0	454.8	0.5	0.3	0.9
08/25/2019 23:00	3,835.9	0.0	3,835.9	104,600.0	401.2	0.5	0.2	0.8
Average/Sum#:	4,217.7	752.4	4,962.2	104,600.0	519.0	0.7	0.3	1.1
Minimum:	1,740.3	0.0	1,740.3	104,600.0	182.0	0.5	0.2	0.8
Maximum:	4,458.8	1,867.8	6,277.7	104,600.0	656.6	0.8	0.4	1.3
%SI	29.17	29.17	29.17	0.00	29.17	33.33	33.33	33.33

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/26/2019 00:00	3,255.9	0.0	3,255.9	104,600.0	340.6	0.4	0.2	0.7
08/26/2019 01:00	3,222.8	0.0	3,222.8	104,600.0	337.1	0.4	0.2	0.7
08/26/2019 02:00	3,214.0	0.0	3,214.0	104,600.0	336.2	0.4	0.2	0.7
08/26/2019 03:00	3,213.0	0.0	3,213.0	104,600.0	336.1	0.4	0.2	0.7
08/26/2019 04:00	3,226.0	0.0	3,226.0	104,600.0	337.4	0.4	0.2	0.7
08/26/2019 05:00	3,276.7	0.0	3,276.7	104,600.0	342.7	0.4	0.2	0.7
08/26/2019 06:00	3,431.7	0.0	3,431.7	104,600.0	359.0	0.4	0.2	0.7
08/26/2019 07:00	3,500.3	0.0	3,500.3	104,600.0	366.1	0.4	0.2	0.7
08/26/2019 08:00	3,834.8	0.0	3,834.8	104,600.0	401.1	0.5	0.2	0.8
08/26/2019 09:00	4,457.7	154.6	4,496.4	104,600.0	470.3	0.6	0.3	1.0
08/26/2019 10:00	4,432.1	1,595.5	6,027.6	104,600.0	630.5	0.8	0.4	1.3
08/26/2019 11:00	4,408.5	1,604.3	6,012.8	104,600.0	628.9	0.8	0.4	1.3
08/26/2019 12:00	4,386.8	1,596.9	5,983.7	104,600.0	625.9	0.7	0.4	1.2
08/26/2019 13:00	4,372.7	1,224.0	5,596.7	104,600.0	585.4	0.7	0.3	1.2
08/26/2019 14:00	4,369.1	820.1	5,189.2	104,600.0	542.8	0.7	0.3	1.1
08/26/2019 15:00	4,282.0	35.1	4,287.3	104,600.0	448.5	0.5	0.3	0.9
08/26/2019 16:00	4,446.4	725.6	5,172.0	104,600.0	541.0	0.6	0.3	1.1
08/26/2019 17:00	4,398.2	761.6	5,159.8	104,600.0	539.7	0.6	0.3	1.1
08/26/2019 18:00	4,371.6	669.9	5,041.5	104,600.0	527.3	0.6	0.3	1.1
08/26/2019 19:00	4,333.8	314.2	4,516.0	104,600.0	472.4	0.6	0.3	1.0
08/26/2019 20:00	4,420.0	1,082.9	5,318.8	104,600.0	556.3	0.7	0.3	1.1
08/26/2019 21:00	3,851.7	0.0	3,851.7	104,600.0	402.9	0.5	0.2	0.8
08/26/2019 22:00	3,671.1	0.0	3,671.1	104,600.0	384.0	0.5	0.2	0.8
08/26/2019 23:00	3,865.4	0.0	3,865.4	104,600.0	404.3	0.5	0.2	0.8
Average/Sum#:	3,926.8	441.0	4,348.6	104,600.0	454.9	0.5	0.3	0.9
Minimum:	3,213.0	0.0	3,213.0	104,600.0	336.1	0.4	0.2	0.7
Maximum:	4,457.7	1,604.3	6,027.6	104,600.0	630.5	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/27/2019 00:00	4,125.7	0.0	4,125.7	104,600.0	431.5	0.5	0.3	0.9
08/27/2019 01:00	3,846.8	0.0	3,846.8	104,600.0	402.4	0.5	0.2	0.8
08/27/2019 02:00	3,829.2	0.0	3,829.2	104,600.0	400.5	0.5	0.2	0.8
08/27/2019 03:00	3,753.2	0.0	3,753.2	104,600.0	392.6	0.5	0.2	0.8
08/27/2019 04:00	4,135.7	0.0	4,135.7	104,600.0	432.6	0.5	0.3	0.9
08/27/2019 05:00	3,885.9	0.0	3,885.9	104,600.0	406.5	0.5	0.2	0.8
08/27/2019 06:00	3,505.1	0.0	3,505.1	104,600.0	366.6	0.4	0.2	0.7
08/27/2019 07:00	3,358.4	0.0	3,358.4	104,600.0	351.3	0.4	0.2	0.7
08/27/2019 08:00	3,341.5	0.0	3,341.5	104,600.0	349.5	0.4	0.2	0.7
08/27/2019 09:00	3,347.5	0.0	3,347.5	104,600.0	350.1	0.4	0.2	0.7
08/27/2019 10:00	3,435.0	0.0	3,435.0	104,600.0	359.3	0.4	0.2	0.7
08/27/2019 11:00	3,408.0	0.0	3,408.0	104,600.0	356.5	0.4	0.2	0.7
08/27/2019 12:00	3,814.9	21.1	3,816.6	104,600.0	399.2	0.5	0.2	0.8
08/27/2019 13:00	4,372.9	823.0	5,195.9	104,600.0	543.5	0.6	0.3	1.1
08/27/2019 14:00	4,363.0	934.7	5,297.7	104,600.0	554.1	0.7	0.3	1.1
08/27/2019 15:00	4,357.2	1,904.2	6,261.4	104,600.0	654.9	0.8	0.4	1.3
08/27/2019 16:00	4,343.3	1,867.4	6,210.7	104,600.0	649.6	0.8	0.4	1.3
08/27/2019 17:00	4,353.6	1,759.7	6,113.3	104,600.0	639.5	0.8	0.4	1.3
08/27/2019 18:00	4,395.7	1,684.5	6,080.2	104,600.0	636.0	0.8	0.4	1.3
08/27/2019 19:00	4,423.9	1,648.6	6,072.5	104,600.0	635.2	0.8	0.4	1.3
08/27/2019 20:00	4,448.8	1,546.6	5,995.4	104,600.0	627.1	0.8	0.4	1.2
08/27/2019 21:00	4,449.1	83.4	4,467.4	104,600.0	467.3	0.6	0.3	0.9
08/27/2019 22:00	3,714.6	0.0	3,714.6	104,600.0	388.5	0.5	0.2	0.8
08/27/2019 23:00	3,299.2	0.0	3,299.2	104,600.0	345.1	0.4	0.2	0.7
Average/Sum#:	3,929.5	511.4	4,437.4	104,600.0	464.1	0.6	0.3	0.9
Minimum:	3,299.2	0.0	3,299.2	104,600.0	345.1	0.4	0.2	0.7
Maximum:	4,449.1	1,904.2	6,261.4	104,600.0	654.9	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/28/2019 00:00	3,294.8	0.0	3,294.8	104,600.0	344.6	0.4	0.2	0.7
08/28/2019 01:00	3,231.2	0.0	3,231.2	104,600.0	338.0	0.4	0.2	0.7
08/28/2019 02:00	3,253.1	0.0	3,253.1	104,600.0	340.3	0.4	0.2	0.7
08/28/2019 03:00	3,279.9	0.0	3,279.9	104,600.0	343.1	0.4	0.2	0.7
08/28/2019 04:00	3,507.5	0.0	3,507.5	104,600.0	366.9	0.4	0.2	0.7
08/28/2019 05:00	3,575.1	0.0	3,575.1	104,600.0	374.0	0.4	0.2	0.7
08/28/2019 06:00	3,923.6	0.1	3,923.6	104,600.0	410.4	0.5	0.2	0.8
08/28/2019 07:00	4,542.8	1,704.2	6,247.0	104,600.0	653.4	0.8	0.4	1.3
08/28/2019 08:00	4,536.6	1,816.9	6,353.5	104,600.0	664.6	0.8	0.4	1.3
08/28/2019 09:00	4,510.0	1,836.6	6,346.6	104,600.0	663.9	0.8	0.4	1.3
08/28/2019 10:00	4,488.6	1,868.5	6,357.1	104,600.0	665.0	0.8	0.4	1.3
08/28/2019 11:00	4,462.3	1,931.2	6,393.5	104,600.0	668.8	0.8	0.4	1.3
08/28/2019 12:00	4,443.7	1,932.0	6,375.7	104,600.0	666.9	0.8	0.4	1.3
08/28/2019 13:00	4,425.7	1,913.7	6,339.4	104,600.0	663.1	0.8	0.4	1.3
08/28/2019 14:00	4,412.1	1,907.8	6,319.9	104,600.0	661.1	0.8	0.4	1.3
08/28/2019 15:00	4,409.3	1,901.9	6,311.2	104,600.0	660.2	0.8	0.4	1.3
08/28/2019 16:00	4,411.3	1,891.0	6,302.3	104,600.0	659.2	0.8	0.4	1.3
08/28/2019 17:00	4,426.1	1,880.5	6,306.6	104,600.0	659.7	0.8	0.4	1.3
08/28/2019 18:00	4,449.5	1,785.3	6,234.8	104,600.0	652.2	0.8	0.4	1.3
08/28/2019 19:00	4,469.4	1,288.1	5,757.5	104,600.0	602.2	0.7	0.4	1.2
08/28/2019 20:00	4,490.8	513.6	4,978.7	104,600.0	520.8	0.6	0.3	1.0
08/28/2019 21:00	3,839.9	0.0	3,839.9	104,600.0	401.7	0.5	0.2	0.8
08/28/2019 22:00	3,521.7	0.0	3,521.7	104,600.0	368.4	0.4	0.2	0.7
08/28/2019 23:00	3,190.6	0.0	3,190.6	104,600.0	333.7	0.4	0.2	0.7
Average/Sum#:	4,045.7	1,007.1	5,051.7	104,600.0	528.4	0.6	0.3	1.0
Minimum:	3,190.6	0.0	3,190.6	104,600.0	333.7	0.4	0.2	0.7
Maximum:	4,542.8	1,932.0	6,393.5	104,600.0	668.8	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/29/2019 00:00	3,363.1	0.0	3,363.1	104,600.0	351.8	0.4	0.2	0.7
08/29/2019 01:00	3,205.3	0.0	3,205.3	104,600.0	335.3	0.4	0.2	0.7
08/29/2019 02:00	3,208.7	0.0	3,208.7	104,600.0	335.6	0.4	0.2	0.7
08/29/2019 03:00	3,219.9	0.0	3,219.9	104,600.0	336.8	0.4	0.2	0.7
08/29/2019 04:00	3,329.6	0.0	3,329.6	104,600.0	348.3	0.4	0.2	0.7
08/29/2019 05:00	3,213.1	0.0	3,213.1	104,600.0	336.1	0.4	0.2	0.7
08/29/2019 06:00	3,329.4	0.0	3,329.4	104,600.0	348.3	0.4	0.2	0.7
08/29/2019 07:00	3,369.6	0.0	3,369.6	104,600.0	352.5	0.4	0.2	0.7
08/29/2019 08:00	3,602.2	0.0	3,602.2	104,600.0	376.8	0.5	0.2	0.8
08/29/2019 09:00	4,011.6	0.0	4,011.6	104,600.0	419.6	0.5	0.3	0.8
08/29/2019 10:00	4,411.9	0.0	4,411.9	104,600.0	461.5	0.6	0.3	0.9
08/29/2019 11:00	4,468.6	546.7	5,004.4	104,600.0	523.5	0.6	0.3	1.0
08/29/2019 12:00	4,455.8	948.4	5,404.2	104,600.0	565.3	0.7	0.3	1.1
08/29/2019 13:00	4,440.5	847.1	5,287.6	104,600.0	553.1	0.7	0.3	1.1
08/29/2019 14:00	4,422.2	1,135.8	5,558.0	104,600.0	581.4	0.7	0.3	1.2
08/29/2019 15:00	4,415.4	1,185.1	5,600.5	104,600.0	585.8	0.7	0.4	1.2
08/29/2019 16:00	4,419.7	1,205.0	5,624.7	104,600.0	588.3	0.7	0.4	1.2
08/29/2019 17:00	4,444.6	1,191.0	5,635.6	104,600.0	589.5	0.7	0.4	1.2
08/29/2019 18:00	4,478.6	1,263.8	5,742.4	104,600.0	600.7	0.7	0.4	1.2
08/29/2019 19:00	4,507.9	971.8	5,479.7	104,600.0	573.2	0.7	0.3	1.1
08/29/2019 20:00	4,508.3	3.4	4,508.4	104,600.0	471.6	0.6	0.3	0.9
08/29/2019 21:00	4,021.3	0.0	4,021.3	104,600.0	420.6	0.5	0.3	0.8
08/29/2019 22:00	3,401.8	0.0	3,401.8	104,600.0	355.8	0.4	0.2	0.7
08/29/2019 23:00	1,873.8	0.0	1,873.8	104,600.0	196.0	0.0	0.0	0.0
Average/Sum#:	3,838.5	387.4	4,225.3	104,600.0	442.0	0.5	0.3	0.9
Minimum:	1,873.8	0.0	1,873.8	104,600.0	196.0	0.4	0.2	0.7
Maximum:	4,508.3	1,263.8	5,742.4	104,600.0	600.7	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	4.17	4.17	4.17

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/30/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/30/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/30/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/30/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/30/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/30/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/30/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/30/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/30/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/30/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/30/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/30/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/30/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/30/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/30/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/30/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/30/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/30/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/30/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/30/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/30/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/30/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/30/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/30/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/31/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/31/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/31/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/31/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/31/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/31/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/31/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/31/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/31/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/31/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/31/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/31/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/31/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/31/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/31/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/31/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/31/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/31/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/31/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/31/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/31/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/31/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/31/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
08/31/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/01/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/01/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/01/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/01/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/01/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/01/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/01/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/01/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/01/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/01/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/01/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/01/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/01/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/01/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/01/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/01/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/01/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/01/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/01/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/01/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/01/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/01/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/01/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/01/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/02/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/02/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/02/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/02/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/02/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/02/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/02/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/02/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/02/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/02/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/02/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/02/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/02/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/02/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/02/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/02/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/02/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/02/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/02/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/02/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/02/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/02/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/02/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/02/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/03/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/03/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/03/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/03/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/03/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/03/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/03/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/03/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/03/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/03/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/03/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/03/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/03/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/03/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/03/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/03/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/03/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/03/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/03/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/03/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/03/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/03/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/03/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/03/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/04/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/04/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/04/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/04/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/04/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/04/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/04/2019 06:00	1,530.1	0.0	1,530.1	104,600.0	160.0	0.0	0.0	0.0
09/04/2019 07:00	4,133.8	0.0	4,133.8	104,600.0	432.4	0.5	0.3	0.9
09/04/2019 08:00	3,732.5	0.0	3,732.5	104,600.0	390.4	0.5	0.2	0.8
09/04/2019 09:00	4,003.5	0.0	4,003.5	104,600.0	418.8	0.5	0.3	0.8
09/04/2019 10:00	4,314.7	16.4	4,316.0	104,600.0	451.5	0.5	0.3	0.9
09/04/2019 11:00	4,464.1	980.5	5,444.6	104,600.0	569.5	0.7	0.3	1.1
09/04/2019 12:00	4,444.8	1,093.5	5,538.3	104,600.0	579.3	0.7	0.3	1.2
09/04/2019 13:00	4,442.5	1,302.0	5,744.5	104,600.0	600.9	0.7	0.4	1.2
09/04/2019 14:00	4,430.4	1,921.7	6,352.1	104,600.0	664.4	0.8	0.4	1.3
09/04/2019 15:00	4,432.6	1,925.1	6,357.7	104,600.0	665.0	0.8	0.4	1.3
09/04/2019 16:00	4,433.3	1,885.6	6,318.9	104,600.0	661.0	0.8	0.4	1.3
09/04/2019 17:00	4,141.7	70.5	4,150.9	104,600.0	434.2	0.5	0.3	0.9
09/04/2019 18:00	4,083.3	0.0	4,083.3	104,600.0	427.1	0.5	0.3	0.9
09/04/2019 19:00	4,261.8	3.0	4,261.9	104,600.0	445.8	0.5	0.3	0.9
09/04/2019 20:00	4,495.4	941.2	5,436.6	104,600.0	568.7	0.7	0.3	1.1
09/04/2019 21:00	3,457.0	4.2	3,457.1	104,600.0	361.6	0.4	0.2	0.7
09/04/2019 22:00	3,251.6	0.0	3,251.6	104,600.0	340.1	0.4	0.2	0.7
09/04/2019 23:00	4,138.5	0.0	4,138.5	104,600.0	432.9	0.5	0.3	0.9
Average/Sum#:	4,010.6	563.5	4,569.6	104,600.0	478.0	0.6	0.3	1.0
Minimum:	1,530.1	0.0	1,530.1	104,600.0	160.0	0.4	0.2	0.7
Maximum:	4,495.4	1,925.1	6,357.7	104,600.0	665.0	0.8	0.4	1.3
%SI	25.00	25.00	25.00	0.00	25.00	29.17	29.17	29.17

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/05/2019 00:00	3,846.6	0.0	3,846.6	104,600.0	402.4	0.5	0.2	0.8
09/05/2019 01:00	3,634.3	0.0	3,634.3	104,600.0	380.1	0.5	0.2	0.8
09/05/2019 02:00	3,303.8	0.0	3,303.8	104,600.0	345.6	0.4	0.2	0.7
09/05/2019 03:00	3,250.8	0.0	3,250.8	104,600.0	340.0	0.4	0.2	0.7
09/05/2019 04:00	3,487.4	0.0	3,487.4	104,600.0	364.8	0.4	0.2	0.7
09/05/2019 05:00	3,345.1	0.0	3,345.1	104,600.0	349.9	0.4	0.2	0.7
09/05/2019 06:00	3,489.1	0.0	3,489.1	104,600.0	365.0	0.4	0.2	0.7
09/05/2019 07:00	3,762.4	0.0	3,762.4	104,600.0	393.5	0.5	0.2	0.8
09/05/2019 08:00	4,128.3	0.0	4,128.3	104,600.0	431.8	0.5	0.3	0.9
09/05/2019 09:00	4,505.0	159.7	4,632.8	104,600.0	484.6	0.6	0.3	1.0
09/05/2019 10:00	4,505.1	500.8	5,005.9	104,600.0	523.6	0.6	0.3	1.0
09/05/2019 11:00	4,489.9	769.4	5,259.3	104,600.0	550.1	0.7	0.3	1.1
09/05/2019 12:00	4,467.7	1,023.7	5,491.4	104,600.0	574.4	0.7	0.3	1.1
09/05/2019 13:00	4,471.3	1,943.8	6,415.1	104,600.0	671.0	0.8	0.4	1.3
09/05/2019 14:00	4,470.9	1,936.0	6,406.9	104,600.0	670.2	0.8	0.4	1.3
09/05/2019 15:00	4,473.9	1,925.8	6,399.7	104,600.0	669.4	0.8	0.4	1.3
09/05/2019 16:00	4,476.6	1,248.7	5,725.3	104,600.0	598.9	0.7	0.4	1.2
09/05/2019 17:00	4,481.6	1,212.9	5,694.5	104,600.0	595.6	0.7	0.4	1.2
09/05/2019 18:00	4,496.1	655.1	5,151.2	104,600.0	538.8	0.6	0.3	1.1
09/05/2019 19:00	4,328.3	0.7	4,328.3	104,600.0	452.7	0.5	0.3	0.9
09/05/2019 20:00	4,035.8	0.0	4,035.8	104,600.0	422.1	0.5	0.3	0.8
09/05/2019 21:00	4,332.4	0.0	4,332.4	104,600.0	453.2	0.5	0.3	0.9
09/05/2019 22:00	3,914.1	0.0	3,914.1	104,600.0	409.4	0.5	0.2	0.8
09/05/2019 23:00	2,155.6	0.0	2,155.6	104,600.0	225.5	0.0	0.0	0.0
Average/Sum#:	3,993.8	474.0	4,466.5	104,600.0	467.2	0.6	0.3	0.9
Minimum:	2,155.6	0.0	2,155.6	104,600.0	225.5	0.4	0.2	0.7
Maximum:	4,505.1	1,943.8	6,415.1	104,600.0	671.0	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	4.17	4.17	4.17

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/06/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/06/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/06/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/06/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/06/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/06/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/06/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/06/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/06/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/06/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/06/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/06/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/06/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/06/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/06/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/06/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/06/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/06/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/06/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/06/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/06/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/06/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/06/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/06/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/07/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/07/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/07/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/07/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/07/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/07/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/07/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/07/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/07/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/07/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/07/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/07/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/07/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/07/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/07/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/07/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/07/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/07/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/07/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/07/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/07/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/07/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/07/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/07/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/08/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/08/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/08/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/08/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/08/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/08/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/08/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/08/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/08/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/08/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/08/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/08/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/08/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/08/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/08/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/08/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/08/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/08/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/08/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/08/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/08/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/08/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/08/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/08/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/09/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/09/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/09/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/09/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/09/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/09/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/09/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/09/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/09/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/09/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/09/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/09/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
09/09/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/09/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/09/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/09/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/09/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/09/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/09/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/09/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/09/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/09/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/09/2019 22:00	1,757.4	0.0	1,757.4	104,700.0	184.0	0.0	0.0	0.0
09/09/2019 23:00	3,337.3	0.0	3,337.3	104,700.0	349.4	0.4	0.2	0.7
Average/Sum#:	2,547.4	0.0	2,547.4	104,650.0	266.7	0.4	0.2	0.7
Minimum:	1,757.4	0.0	1,757.4	104,600.0	184.0	0.4	0.2	0.7
Maximum:	3,337.3	0.0	3,337.3	104,700.0	349.4	0.4	0.2	0.7
%SI	91.67	91.67	91.67	0.00	91.67	95.83	95.83	95.83

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/10/2019 00:00	3,712.7	0.0	3,712.7	104,700.0	388.7	0.5	0.2	0.8
09/10/2019 01:00	3,350.9	0.0	3,350.9	104,700.0	350.8	0.4	0.2	0.7
09/10/2019 02:00	3,310.8	0.0	3,310.8	104,700.0	346.6	0.4	0.2	0.7
09/10/2019 03:00	3,474.7	0.0	3,474.7	104,700.0	363.8	0.4	0.2	0.7
09/10/2019 04:00	3,797.2	0.0	3,797.2	104,700.0	397.6	0.5	0.2	0.8
09/10/2019 05:00	3,732.1	0.0	3,732.1	104,700.0	390.8	0.5	0.2	0.8
09/10/2019 06:00	3,887.1	0.0	3,887.1	104,700.0	407.0	0.5	0.2	0.8
09/10/2019 07:00	4,314.2	0.0	4,314.2	104,700.0	451.7	0.5	0.3	0.9
09/10/2019 08:00	3,896.3	0.0	3,896.3	104,700.0	407.9	0.5	0.2	0.8
09/10/2019 09:00	3,425.0	0.0	3,425.0	104,700.0	358.6	0.4	0.2	0.7
09/10/2019 10:00	4,252.3	0.0	4,252.3	104,700.0	445.2	0.5	0.3	0.9
09/10/2019 11:00	4,241.0	0.0	4,241.0	104,700.0	444.0	0.5	0.3	0.9
09/10/2019 12:00	4,535.1	1,150.6	5,605.2	104,700.0	586.9	0.7	0.4	1.2
09/10/2019 13:00	4,284.8	25.9	4,286.9	104,700.0	448.8	0.5	0.3	0.9
09/10/2019 14:00	4,518.1	1,400.0	5,918.1	104,700.0	619.6	0.7	0.4	1.2
09/10/2019 15:00	4,296.9	42.8	4,302.5	104,700.0	450.5	0.5	0.3	0.9
09/10/2019 16:00	4,527.8	1,582.5	6,110.3	104,700.0	639.7	0.8	0.4	1.3
09/10/2019 17:00	4,535.6	1,761.2	6,296.8	104,700.0	659.3	0.8	0.4	1.3
09/10/2019 18:00	4,544.0	1,714.6	6,258.6	104,700.0	655.3	0.8	0.4	1.3
09/10/2019 19:00	4,551.4	1,026.2	5,577.6	104,700.0	584.0	0.7	0.4	1.2
09/10/2019 20:00	3,771.2	2.4	3,771.6	104,700.0	394.9	0.5	0.2	0.8
09/10/2019 21:00	3,811.2	0.0	3,811.2	104,700.0	399.0	0.5	0.2	0.8
09/10/2019 22:00	3,768.6	0.0	3,768.6	104,700.0	394.6	0.5	0.2	0.8
09/10/2019 23:00	3,456.9	0.0	3,456.9	104,700.0	361.9	0.4	0.2	0.7
Average/Sum#:	3,999.8	362.8	4,356.6	104,700.0	456.1	0.5	0.3	0.9
Minimum:	3,310.8	0.0	3,310.8	104,700.0	346.6	0.4	0.2	0.7
Maximum:	4,551.4	1,761.2	6,296.8	104,700.0	659.3	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/11/2019 00:00	3,220.7	0.0	3,220.7	104,700.0	337.2	0.4	0.2	0.7
09/11/2019 01:00	3,233.0	0.0	3,233.0	104,700.0	338.5	0.4	0.2	0.7
09/11/2019 02:00	3,241.1	0.0	3,241.1	104,700.0	339.3	0.4	0.2	0.7
09/11/2019 03:00	3,242.5	0.0	3,242.5	104,700.0	339.5	0.4	0.2	0.7
09/11/2019 04:00	3,322.3	0.0	3,322.3	104,700.0	347.8	0.4	0.2	0.7
09/11/2019 05:00	3,332.5	0.0	3,332.5	104,700.0	348.9	0.4	0.2	0.7
09/11/2019 06:00	3,329.8	0.0	3,329.8	104,700.0	348.6	0.4	0.2	0.7
09/11/2019 07:00	3,333.5	0.0	3,333.5	104,700.0	349.0	0.4	0.2	0.7
09/11/2019 08:00	3,319.8	0.0	3,319.8	104,700.0	347.6	0.4	0.2	0.7
09/11/2019 09:00	3,204.7	0.0	3,204.7	104,700.0	335.5	0.4	0.2	0.7
09/11/2019 10:00	4,097.1	0.1	4,097.1	104,700.0	429.0	0.5	0.3	0.9
09/11/2019 11:00	4,450.0	104.6	4,541.0	104,700.0	475.4	0.6	0.3	1.0
09/11/2019 12:00	1,999.4	0.0	1,999.4	104,700.0	209.3	0.0	0.0	0.0
09/11/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/11/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/11/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/11/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/11/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/11/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/11/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/11/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/11/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/11/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/11/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,332.8	8.1	3,339.8	104,700.0	349.7	0.4	0.2	0.7
Minimum:	1,999.4	0.0	1,999.4	104,700.0	209.3	0.4	0.2	0.7
Maximum:	4,450.0	104.6	4,541.0	104,700.0	475.4	0.6	0.3	1.0
%SI	45.83	45.83	45.83	0.00	45.83	50.00	50.00	50.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/12/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/12/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/12/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/12/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/12/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/12/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/12/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/12/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/12/2019 08:00	1,615.2	0.0	1,615.2	104,700.0	169.1	0.0	0.0	0.0
09/12/2019 09:00	3,357.4	0.0	3,357.4	104,700.0	351.5	0.4	0.2	0.7
09/12/2019 10:00	4,525.5	128.2	4,640.9	104,700.0	485.9	0.6	0.3	1.0
09/12/2019 11:00	4,116.8	0.0	4,116.8	104,700.0	431.0	0.5	0.3	0.9
09/12/2019 12:00	4,487.7	1,206.5	5,573.6	104,700.0	583.6	0.7	0.4	1.2
09/12/2019 13:00	4,285.5	24.9	4,288.0	104,700.0	449.0	0.5	0.3	0.9
09/12/2019 14:00	4,441.0	1,364.5	5,710.0	104,700.0	597.8	0.7	0.4	1.2
09/12/2019 15:00	3,795.6	0.0	3,795.6	104,700.0	397.4	0.5	0.2	0.8
09/12/2019 16:00	4,457.8	1,495.4	5,803.7	104,700.0	607.6	0.7	0.4	1.2
09/12/2019 17:00	4,466.7	1,898.7	6,365.4	104,700.0	666.5	0.8	0.4	1.3
09/12/2019 18:00	4,492.5	1,904.2	6,396.7	104,700.0	669.7	0.8	0.4	1.3
09/12/2019 19:00	4,502.7	1,889.0	6,391.7	104,700.0	669.2	0.8	0.4	1.3
09/12/2019 20:00	4,517.6	1,701.6	6,219.2	104,700.0	651.2	0.8	0.4	1.3
09/12/2019 21:00	3,941.6	7.1	3,941.8	104,700.0	412.7	0.5	0.2	0.8
09/12/2019 22:00	3,867.8	0.0	3,867.8	104,700.0	405.0	0.5	0.2	0.8
09/12/2019 23:00	1,800.1	0.0	1,800.1	104,700.0	188.5	0.0	0.0	0.0
Average/Sum#:	3,917.0	726.3	4,617.7	104,700.0	483.5	0.6	0.3	1.1
Minimum:	1,615.2	0.0	1,615.2	104,700.0	169.1	0.4	0.2	0.7
Maximum:	4,525.5	1,904.2	6,396.7	104,700.0	669.7	0.8	0.4	1.3
%SI	33.33	33.33	33.33	0.00	33.33	41.67	41.67	41.67

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/13/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/13/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/13/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/13/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/13/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/13/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/13/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/13/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/13/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/13/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/13/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/13/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/13/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/13/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/13/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/13/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/13/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/13/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/13/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/13/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/13/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/13/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/13/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/13/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/14/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/14/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/14/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/14/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/14/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/14/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/14/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/14/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/14/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/14/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/14/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/14/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/14/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/14/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/14/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/14/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/14/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/14/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/14/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/14/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/14/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/14/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/14/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/14/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/15/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/15/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/15/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/15/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/15/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/15/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/15/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/15/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/15/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/15/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/15/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/15/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/15/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/15/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/15/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/15/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/15/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/15/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/15/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/15/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/15/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/15/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/15/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/15/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/16/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/16/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/16/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/16/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/16/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/16/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/16/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/16/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/16/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/16/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/16/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/16/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/16/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/16/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/16/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/16/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/16/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/16/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/16/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/16/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/16/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/16/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/16/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/16/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/17/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/17/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/17/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/17/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/17/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/17/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/17/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/17/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/17/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/17/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/17/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/17/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/17/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/17/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/17/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/17/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/17/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/17/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/17/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/17/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/17/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/17/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/17/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/17/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/18/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/18/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/18/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/18/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/18/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/18/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/18/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/18/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/18/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/18/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/18/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/18/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/18/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/18/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/18/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/18/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/18/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/18/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/18/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/18/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/18/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/18/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/18/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/18/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/19/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/19/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/19/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/19/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/19/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/19/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/19/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/19/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/19/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/19/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/19/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/19/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/19/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/19/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/19/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/19/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/19/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/19/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/19/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/19/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/19/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/19/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/19/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/19/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/20/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/20/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/20/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/20/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/20/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/20/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/20/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/20/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/20/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/20/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/20/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/20/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/20/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/20/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/20/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/20/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/20/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/20/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/20/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/20/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/20/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/20/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/20/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/20/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/21/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/21/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/21/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/21/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/21/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/21/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/21/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/21/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/21/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/21/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/21/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/21/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/21/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/21/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/21/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/21/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/21/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/21/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/21/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/21/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/21/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/21/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/21/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/21/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/22/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/22/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/22/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/22/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/22/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/22/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/22/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/22/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/22/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/22/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/22/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/22/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/22/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/22/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/22/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/22/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/22/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/22/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/22/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/22/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/22/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/22/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/22/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/22/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/23/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/23/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/23/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/23/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/23/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/23/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/23/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/23/2019 07:00	1,577.3	0.0	1,577.3	104,700.0	165.1	0.0	0.0	0.0
09/23/2019 08:00	4,430.4	0.0	4,430.4	104,700.0	463.9	0.6	0.3	0.9
09/23/2019 09:00	4,497.7	0.0	4,497.7	104,700.0	470.9	0.6	0.3	0.9
09/23/2019 10:00	4,536.6	16.6	4,537.8	104,700.0	475.1	0.6	0.3	1.0
09/23/2019 11:00	4,513.1	1,170.4	5,683.5	104,700.0	595.1	0.7	0.4	1.2
09/23/2019 12:00	4,502.0	1,224.7	5,726.7	104,700.0	599.6	0.7	0.4	1.2
09/23/2019 13:00	4,494.2	1,231.9	5,726.1	104,700.0	599.5	0.7	0.4	1.2
09/23/2019 14:00	4,483.0	1,205.7	5,688.7	104,700.0	595.6	0.7	0.4	1.2
09/23/2019 15:00	4,477.5	945.6	5,423.1	104,700.0	567.8	0.7	0.3	1.1
09/23/2019 16:00	4,483.7	1,212.2	5,695.9	104,700.0	596.4	0.7	0.4	1.2
09/23/2019 17:00	4,507.6	1,177.0	5,684.6	104,700.0	595.2	0.7	0.4	1.2
09/23/2019 18:00	4,533.3	477.5	5,010.8	104,700.0	524.6	0.6	0.3	1.0
09/23/2019 19:00	4,548.2	1,179.7	5,727.9	104,700.0	599.7	0.7	0.4	1.2
09/23/2019 20:00	4,554.8	1,076.1	5,630.9	104,700.0	589.6	0.7	0.4	1.2
09/23/2019 21:00	4,355.9	22.8	4,357.7	104,700.0	456.3	0.5	0.3	0.9
09/23/2019 22:00	3,342.5	0.0	3,342.5	104,700.0	350.0	0.4	0.2	0.7
09/23/2019 23:00	4,485.6	542.6	4,919.7	104,700.0	515.1	0.6	0.3	1.1
Average/Sum#:	4,254.3	675.5	4,921.3	104,700.0	515.3	0.6	0.3	1.1
Minimum:	1,577.3	0.0	1,577.3	104,700.0	165.1	0.4	0.2	0.7
Maximum:	4,554.8	1,231.9	5,727.9	104,700.0	599.7	0.7	0.4	1.2
%SI	29.17	29.17	29.17	0.00	29.17	33.33	33.33	33.33

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/24/2019 00:00	4,610.5	595.9	5,206.4	104,700.0	545.1	0.7	0.3	1.1
09/24/2019 01:00	4,622.0	771.3	5,393.3	104,700.0	564.7	0.7	0.3	1.1
09/24/2019 02:00	4,622.8	611.5	5,234.3	104,700.0	548.0	0.7	0.3	1.1
09/24/2019 03:00	4,622.9	761.1	5,384.0	104,700.0	563.7	0.7	0.3	1.1
09/24/2019 04:00	4,623.3	1,222.1	5,845.4	104,700.0	612.0	0.7	0.4	1.2
09/24/2019 05:00	4,178.4	91.3	4,196.7	104,700.0	439.4	0.5	0.3	0.9
09/24/2019 06:00	4,169.3	0.0	4,169.3	104,700.0	436.5	0.5	0.3	0.9
09/24/2019 07:00	4,607.5	484.8	5,082.6	104,700.0	532.1	0.6	0.3	1.1
09/24/2019 08:00	3,944.1	251.8	3,999.5	104,700.0	418.7	0.5	0.3	0.9
09/24/2019 09:00	3,798.7	0.0	3,798.7	104,700.0	397.7	0.5	0.2	0.8
09/24/2019 10:00	4,179.4	0.0	4,179.4	104,700.0	437.6	0.5	0.3	0.9
09/24/2019 11:00	4,191.2	0.0	4,191.2	104,700.0	438.8	0.5	0.3	0.9
09/24/2019 12:00	4,358.2	8.2	4,366.2	104,700.0	457.1	0.5	0.3	0.9
09/24/2019 13:00	4,457.4	325.6	4,734.2	104,700.0	495.7	0.6	0.3	1.0
09/24/2019 14:00	4,449.8	249.0	4,698.8	104,700.0	492.0	0.6	0.3	1.0
09/24/2019 15:00	4,432.1	471.6	4,903.7	104,700.0	513.4	0.6	0.3	1.0
09/24/2019 16:00	4,427.1	1,949.8	6,376.9	104,700.0	667.7	0.8	0.4	1.3
09/24/2019 17:00	4,419.9	1,942.6	6,362.5	104,700.0	666.2	0.8	0.4	1.3
09/24/2019 18:00	4,427.4	1,414.9	5,842.3	104,700.0	611.7	0.7	0.4	1.2
09/24/2019 19:00	4,448.6	455.5	4,867.7	104,700.0	509.6	0.6	0.3	1.0
09/24/2019 20:00	4,068.9	0.0	4,068.9	104,700.0	426.0	0.5	0.3	0.9
09/24/2019 21:00	4,450.5	170.7	4,587.1	104,700.0	480.3	0.6	0.3	1.0
09/24/2019 22:00	4,016.2	0.0	4,016.2	104,700.0	420.5	0.5	0.3	0.8
09/24/2019 23:00	3,213.2	0.0	3,213.2	104,700.0	336.4	0.4	0.2	0.7
Average/Sum#:	4,305.8	490.7	4,779.9	104,700.0	500.5	0.6	0.3	1.0
Minimum:	3,213.2	0.0	3,213.2	104,700.0	336.4	0.4	0.2	0.7
Maximum:	4,623.3	1,949.8	6,376.9	104,700.0	667.7	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/25/2019 00:00	3,133.5	0.0	3,133.5	104,700.0	328.1	0.4	0.2	0.7
09/25/2019 01:00	3,150.9	0.0	3,150.9	104,700.0	329.9	0.4	0.2	0.7
09/25/2019 02:00	3,155.4	0.0	3,155.4	104,700.0	330.4	0.4	0.2	0.7
09/25/2019 03:00	3,152.5	0.0	3,152.5	104,700.0	330.1	0.4	0.2	0.7
09/25/2019 04:00	3,151.4	0.0	3,151.4	104,700.0	330.0	0.4	0.2	0.7
09/25/2019 05:00	3,136.0	0.0	3,136.0	104,700.0	328.3	0.4	0.2	0.7
09/25/2019 06:00	3,088.9	0.0	3,088.9	104,700.0	323.4	0.4	0.2	0.6
09/25/2019 07:00	3,133.6	0.0	3,133.6	104,700.0	328.1	0.4	0.2	0.7
09/25/2019 08:00	3,088.2	0.0	3,088.2	104,700.0	323.3	0.4	0.2	0.6
09/25/2019 09:00	3,146.6	0.0	3,146.6	104,700.0	329.4	0.4	0.2	0.7
09/25/2019 10:00	3,606.5	0.0	3,606.5	104,700.0	377.6	0.5	0.2	0.8
09/25/2019 11:00	4,231.5	52.1	4,236.7	104,700.0	443.6	0.5	0.3	0.9
09/25/2019 12:00	4,413.4	1,554.1	5,967.5	104,700.0	624.8	0.8	0.4	1.3
09/25/2019 13:00	4,383.3	1,887.1	6,270.4	104,700.0	656.5	0.8	0.4	1.3
09/25/2019 14:00	4,366.2	1,592.6	5,958.8	104,700.0	623.9	0.7	0.4	1.2
09/25/2019 15:00	4,358.8	1,570.3	5,929.1	104,700.0	620.8	0.7	0.4	1.2
09/25/2019 16:00	4,354.9	1,777.8	6,132.7	104,700.0	642.1	0.8	0.4	1.3
09/25/2019 17:00	4,364.4	1,761.9	6,126.3	104,700.0	641.4	0.8	0.4	1.3
09/25/2019 18:00	4,385.2	427.2	4,812.4	104,700.0	503.9	0.6	0.3	1.0
09/25/2019 19:00	4,420.1	1,223.0	5,643.1	104,700.0	590.8	0.7	0.4	1.2
09/25/2019 20:00	4,426.6	1,186.6	5,577.6	104,700.0	584.0	0.7	0.4	1.2
09/25/2019 21:00	4,016.3	0.0	4,016.3	104,700.0	420.5	0.5	0.3	0.8
09/25/2019 22:00	3,545.8	0.0	3,545.8	104,700.0	371.2	0.4	0.2	0.7
09/25/2019 23:00	3,142.0	0.0	3,142.0	104,700.0	329.0	0.4	0.2	0.7
Average/Sum#:	3,723.0	543.0	4,262.6	104,700.0	446.3	0.5	0.3	0.9
Minimum:	3,088.2	0.0	3,088.2	104,700.0	323.3	0.4	0.2	0.6
Maximum:	4,426.6	1,887.1	6,270.4	104,700.0	656.5	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/26/2019 00:00	3,141.8	0.0	3,141.8	104,700.0	328.9	0.4	0.2	0.7
09/26/2019 01:00	3,139.3	0.0	3,139.3	104,700.0	328.7	0.4	0.2	0.7
09/26/2019 02:00	3,152.4	0.0	3,152.4	104,700.0	330.1	0.4	0.2	0.7
09/26/2019 03:00	3,153.4	0.0	3,153.4	104,700.0	330.2	0.4	0.2	0.7
09/26/2019 04:00	3,150.7	0.0	3,150.7	104,700.0	329.9	0.4	0.2	0.7
09/26/2019 05:00	3,156.6	0.0	3,156.6	104,700.0	330.5	0.4	0.2	0.7
09/26/2019 06:00	3,091.9	0.0	3,091.9	104,700.0	323.7	0.4	0.2	0.6
09/26/2019 07:00	3,124.0	0.0	3,124.0	104,700.0	327.1	0.4	0.2	0.7
09/26/2019 08:00	3,251.5	0.0	3,251.5	104,700.0	340.4	0.4	0.2	0.7
09/26/2019 09:00	3,882.0	6.6	3,882.3	104,700.0	406.5	0.5	0.2	0.8
09/26/2019 10:00	4,463.5	283.4	4,746.9	104,700.0	497.0	0.6	0.3	1.0
09/26/2019 11:00	4,445.8	636.5	5,082.3	104,700.0	532.1	0.6	0.3	1.1
09/26/2019 12:00	4,434.9	836.2	5,271.1	104,700.0	551.9	0.7	0.3	1.1
09/26/2019 13:00	4,424.6	852.2	5,276.8	104,700.0	552.5	0.7	0.3	1.1
09/26/2019 14:00	4,417.5	1,659.9	6,077.4	104,700.0	636.3	0.8	0.4	1.3
09/26/2019 15:00	4,414.2	1,472.9	5,887.1	104,700.0	616.4	0.7	0.4	1.2
09/26/2019 16:00	4,431.8	1,758.2	6,190.0	104,700.0	648.1	0.8	0.4	1.3
09/26/2019 17:00	4,458.9	1,085.0	5,543.9	104,700.0	580.4	0.7	0.3	1.2
09/26/2019 18:00	4,488.6	664.7	5,106.8	104,700.0	534.7	0.6	0.3	1.1
09/26/2019 19:00	4,459.6	0.0	4,459.6	104,700.0	466.9	0.6	0.3	0.9
09/26/2019 20:00	3,681.2	0.0	3,681.2	104,700.0	385.4	0.5	0.2	0.8
09/26/2019 21:00	3,361.6	0.0	3,361.6	104,700.0	352.0	0.4	0.2	0.7
09/26/2019 22:00	3,208.8	0.0	3,208.8	104,700.0	336.0	0.4	0.2	0.7
09/26/2019 23:00	3,386.2	0.0	3,386.2	104,700.0	354.5	0.4	0.2	0.7
Average/Sum#:	3,763.4	385.7	4,146.8	104,700.0	434.2	0.5	0.3	0.9
Minimum:	3,091.9	0.0	3,091.9	104,700.0	323.7	0.4	0.2	0.6
Maximum:	4,488.6	1,758.2	6,190.0	104,700.0	648.1	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/27/2019 00:00	3,250.9	0.0	3,250.9	104,700.0	340.4	0.4	0.2	0.7
09/27/2019 01:00	3,259.1	0.0	3,259.1	104,700.0	341.2	0.4	0.2	0.7
09/27/2019 02:00	3,236.7	0.0	3,236.7	104,700.0	338.9	0.4	0.2	0.7
09/27/2019 03:00	3,235.5	0.0	3,235.5	104,700.0	338.8	0.4	0.2	0.7
09/27/2019 04:00	3,274.1	0.0	3,274.1	104,700.0	342.8	0.4	0.2	0.7
09/27/2019 05:00	3,522.4	0.0	3,522.4	104,700.0	368.8	0.4	0.2	0.7
09/27/2019 06:00	3,545.2	0.0	3,545.2	104,700.0	371.2	0.4	0.2	0.7
09/27/2019 07:00	3,878.9	0.0	3,878.9	104,700.0	406.1	0.5	0.2	0.8
09/27/2019 08:00	4,246.4	0.7	4,246.4	104,700.0	444.6	0.5	0.3	0.9
09/27/2019 09:00	4,492.6	1,821.2	6,313.8	104,700.0	661.1	0.8	0.4	1.3
09/27/2019 10:00	4,468.9	1,937.1	6,406.0	104,700.0	670.7	0.8	0.4	1.3
09/27/2019 11:00	4,482.4	1,908.5	6,390.9	104,700.0	669.1	0.8	0.4	1.3
09/27/2019 12:00	4,533.9	1,845.0	6,378.9	104,700.0	667.9	0.8	0.4	1.3
09/27/2019 13:00	4,528.6	1,852.6	6,381.2	104,700.0	668.1	0.8	0.4	1.3
09/27/2019 14:00	4,509.0	1,876.2	6,385.2	104,700.0	668.5	0.8	0.4	1.3
09/27/2019 15:00	4,498.5	1,886.2	6,384.7	104,700.0	668.5	0.8	0.4	1.3
09/27/2019 16:00	4,504.4	1,881.0	6,385.4	104,700.0	668.6	0.8	0.4	1.3
09/27/2019 17:00	4,512.4	1,874.8	6,387.2	104,700.0	668.7	0.8	0.4	1.3
09/27/2019 18:00	4,536.2	1,867.8	6,404.0	104,700.0	670.5	0.8	0.4	1.3
09/27/2019 19:00	4,560.7	1,829.9	6,390.6	104,700.0	669.1	0.8	0.4	1.3
09/27/2019 20:00	4,585.8	1,675.9	6,261.7	104,700.0	655.6	0.8	0.4	1.3
09/27/2019 21:00	3,767.0	31.3	3,771.1	104,700.0	394.8	0.5	0.2	0.8
09/27/2019 22:00	3,244.5	0.0	3,244.5	104,700.0	339.7	0.4	0.2	0.7
09/27/2019 23:00	1,608.4	0.0	1,608.4	104,700.0	168.4	0.0	0.0	0.0
Average/Sum#:	3,928.4	928.7	4,856.0	104,700.0	508.4	0.6	0.3	1.0
Minimum:	1,608.4	0.0	1,608.4	104,700.0	168.4	0.4	0.2	0.7
Maximum:	4,585.8	1,937.1	6,406.0	104,700.0	670.7	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	4.17	4.17	4.17

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/28/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/28/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/28/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/28/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/28/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/28/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/28/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/28/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/28/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/28/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/28/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/28/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/28/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/28/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/28/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/28/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/28/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/28/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/28/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/28/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/28/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/28/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/28/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/28/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/29/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/29/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/29/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/29/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/29/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/29/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/29/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/29/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/29/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/29/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/29/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/29/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/29/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/29/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/29/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/29/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/29/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/29/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/29/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/29/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/29/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/29/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/29/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/29/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/30/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/30/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/30/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/30/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/30/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/30/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/30/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/30/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/30/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/30/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/30/2019 10:00	1,511.8	0.0	1,511.8	104,700.0	158.3	0.0	0.0	0.0
09/30/2019 11:00	3,719.5	0.0	3,719.5	104,700.0	389.4	0.4	0.2	0.7
09/30/2019 12:00	4,495.6	0.0	4,495.6	104,700.0	470.7	0.6	0.3	0.9
09/30/2019 13:00	4,537.0	42.4	4,543.4	104,700.0	475.7	0.6	0.3	1.0
09/30/2019 14:00	4,524.6	1,439.2	5,963.8	104,700.0	624.4	0.7	0.4	1.2
09/30/2019 15:00	4,507.7	1,593.5	6,101.2	104,700.0	638.8	0.8	0.4	1.3
09/30/2019 16:00	4,518.0	1,314.4	5,701.0	104,700.0	596.9	0.7	0.4	1.2
09/30/2019 17:00	2,683.8	0.0	2,683.8	104,700.0	281.0	0.5	0.2	0.8
09/30/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/30/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/30/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/30/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/30/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
09/30/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,812.3	548.7	4,340.0	104,700.0	454.4	0.6	0.3	1.0
Minimum:	1,511.8	0.0	1,511.8	104,700.0	158.3	0.4	0.2	0.7
Maximum:	4,537.0	1,593.5	6,101.2	104,700.0	638.8	0.8	0.4	1.3
%SI	66.67	66.67	66.67	0.00	66.67	70.83	70.83	70.83

CO Ppmvdc EDS/CMS Summary Report

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:30 **Location:** Roseville, CA
Description: Electric Utility

CMS Data from: CT2_CO_Ppmvdc_1H
EDS Data from: CT2_CO_Ppmvdc_3H
Emission Limitation: 4
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 04/10/2006 07:00
Process Unit(s) Description:

Operating time for EDS: 694.00 Hour(s)
Operating time for CMS: 694.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	2
2. Total CMS Downtime	2
3. Total Downtime as a percentage of operating time	0.29
4. Total Availability as a percentage of operating time	99.71

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

NOx Ppmvdc EDS/CMS Summary Report

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:34 **Location:** Roseville, CA
Description: Electric Utility

CMS Data from: CT2_NOx_Ppmvdc_1H
EDS Data from: CT2_NOx_Ppmvdc_1H
Emission Limitation: 2.0
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 04/10/2006 07:00
Process Unit(s) Description:

Operating time for EDS: 694.00 Hour(s)
Operating time for CMS: 694.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	2
2. Total CMS Downtime	2
3. Total Downtime as a percentage of operating time	0.29
4. Total Availability as a percentage of operating time	99.71

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

CO Invalid Data

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:30 **Location:** Roseville, CA

Tag Name: CT2_CO_Ppm_1H

Total Operating Time: 694.00 Hour(s)
Non-Operating Time: 1,514.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	08/05/2019 13:00	08/05/2019 13:59	1	3 - Quality assurance calibration	
2	08/05/2019 14:00	08/05/2019 14:59	1	3 - Quality assurance calibration	

Total Operating Time:	694.00 Hour(s)
Total Monitor Downtime (Online only):	2.00 Hour(s)
Percent Monitor Availability:	99.71 %
Percent Monitor Downtime:	0.29 %

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Quality assurance calibration	2	100.00

NOx Invalid Data

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:35 **Location:** Roseville, CA

Tag Name: CT2_NOx_Ppm_1H

Total Operating Time: 694.00 Hour(s)
Non-Operating Time: 1,514.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	08/05/2019 13:00	08/05/2019 13:59	1	3 - Quality assurance calibration	
2	08/05/2019 14:00	08/05/2019 14:59	1	3 - Quality assurance calibration	

Total Operating Time:	694.00 Hour(s)
Total Monitor Downtime (Online only):	2.00 Hour(s)
Percent Monitor Availability:	99.71 %
Percent Monitor Downtime:	0.29 %

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Quality assurance calibration	2	100.00

NOx SCR Invalid Data

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:36 **Location:** Roseville, CA

Tag Name: CT2_NOx_SCR_Ppm_1H

Total Operating Time: 694.00 Hour(s)
Non-Operating Time: 1,514.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	**694.00 Hour(s)**
Total Monitor Downtime (Online only):	**0.00 Hour(s)**
Percent Monitor Availability:	**100.00 %**
Percent Monitor Downtime:	**0.00 %**

O2 Invalid Data

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:36 **Location:** Roseville, CA

Tag Name: CT2_O2Dry_Pct_1H

Total Operating Time: 694.00 Hour(s)
Non-Operating Time: 1,514.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	08/05/2019 13:00	08/05/2019 13:59	1	3 - Quality assurance calibration	
2	08/05/2019 14:00	08/05/2019 14:59	1	3 - Quality assurance calibration	

Total Operating Time:	**694.00 Hour(s)**
Total Monitor Downtime (Online only):	**2.00 Hour(s)**
Percent Monitor Availability:	**99.71 %**
Percent Monitor Downtime:	**0.29 %**

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Quality assurance calibration	2	100.00

ATTACHMENT 7

AQ-36

AQ-36: The project owner shall notify the _PCAPCD of any breakdown condition as soon as reasonably possible, but no later than two PCAPCD business hours after its detection.

Verification: The Project owner shall include the identification of all breakdowns, PCAPCD notification, resulting excess emission (if any) and corrective actions taken (if any) as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6

ATTACHMENT 8

AQ-37

AQ-37 Any Violation of any emission standard listed in this permit which is indicated by the CEMS shall be reported to the PCAPCD no later than 96 hours after such occurrence as per California Health and Safety Code 42706

Verification: The Project owner shall include all violations of emissions standards and corresponding PCAPCD notifications in the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

All Notices of Non Compliance are included in AQ-41.

Placer County
AIR POLLUTION CONTROL DISTRICT

110 Maple Street, Auburn, CA 95603 • (530) 745-2330 • Fax (530) 745-2373 • www.placerair.org
Erik C. White, Air Pollution Control Officer

NOTICE OF VIOLATION

August 9, 2019

Attn: Matt Garner
Roseville Energy Park
5120 Phillip Road
Roseville, CA 95747

Notice of Violation:

Number: 5295

Date(s): May 26, 2016

Location: 5120 Phillips Road, Roseville, California

This letter is your notice that the Placer County Air Pollution Control District (District), authorized and established by California Health and Safety Code Section 40002, has made the finding that you are responsible for violation(s) of District rules and regulations or state/federal air pollution laws. District rules can be viewed at http://www.placerair.org/rules.

Violation Circumstances:

The District has determined the following exceedances are enforceable violations which were not the result of equipment upset or breakdown conditions:

- NOx emission of 2.1 ppmvd at 15% O_2 from combustion turbine #2, on June 19, 2017, from 1:00 – 1:59 p.m., as reported in Non-Compliance Event #2017-004. This is a violation of District Permit to Operate REPR-09-02 Condition No. 49 which limits NOx emissions to 2.0 ppmvd at 15% O_2 over a 1-hour average period. The exceedance was the reported result of unstable automatic voltage regulation protection setpoints that were improperly established during a previous controls system upgrade.

- CO emission of 106.4 lb/hr during start-up of combustion turbine #2, on May 11, 2018, ending at 07:30 a.m., as reported in Non-Compliance Event #2018-005. This is a violation of District Permit to Operate REPR-09-02 Condition No. 51 which limits CO emissions during start-up to 89.5 lb/hr. The exceedance was the reported result of the commissioning of the new steam turbine.

- NH_3 emission of 11 ppmvd at 15% O_2, during start-up of combustion turbine #2, on May 11, 2018, on May 11, 2018, from 07:00 – 07:59 a.m., as reported in Non-Compliance Event #2018-006. This is a violation of District Permit to Operate PEPR-09-02 Condition No. 48 which limits NH_3 emissions to 10 ppmvd at 15% O_2 over a 1-hour average period. The exceedance was the reported result of the commissioning of the new steam turbine. Note when NH_3 exceeds 7 ppmvd you are required to replace, repair, or recondition the catalyst within 24 months.

- NOx emission of 2.2 ppmvd at 15% O_2 from combustion turbine #2 on October 26, 2018, during 11:00 – 11:59 p.m., as reported in Non-Compliance Event #2018-012. This is a violation of District Permit to Operate REPR-09-02 Condition No. 49 which limits NOx emissions to 2.0 ppmvd at 15% O_2 over a 1-hour average period. The exceedance was the reported result of a turbine ramp-up as requested by the Transmission Operator during a planned shutdown.

Settlement Offer:

As is provided for in State law, it is the District's policy to settle these matters through a mutual settlement process in lieu of pursuing this case in court. Accordingly, the District offers to settle this matter pursuant to the conditions listed in the proposed settlement agreement (enclosed), including a monetary penalty of **Two Thousand Two Hundred Dollars ($2,200)**. For the violations you have liability of up to $10,000 per violation per day pursuant to California Health and Safety Code Section 42400.4. The offer is reduced from the maximum to encourage settlement out of court and in consideration of the severity and circumstances of the violation(s).

If the terms listed in the agreement are acceptable, you are requested to sign and return the enclosed Settlement Agreement, with a check payable to the Placer County Air Pollution Control District in the amount of the penalty, or a receipt showing that you have paid the penalty online at http://www.placerair.org/onlinepayments.

Payment must be received no later than **September 17, 2019**. Upon receipt of the signed agreement and your payment, you will be provided with a letter acknowledging settlement of this matter.

Alternatively, if you would like to present additional facts or circumstances for the District to consider in settling this matter, you may attend a settlement conference on **Wednesday, August 28, 2019, at 1:00 p.m.**, or you may contact me at (530) 745-2337 to discuss this matter by telephone or to request an alternative meeting date.

If this case is not settled by **September 17, 2019**, then the settlement offer is withdrawn. Cases that are not resolved through this mutual process will be settled through court action.

If you have any questions regarding this matter or to request an alternative settlement conference date, please contact me at (530) 745-2337.

Sincerely,

Bruce Springsteen
Compliance and Enforcement Manager

Enclosures: Settlement Agreement

AGREEMENT

Notice of Violation No. 5295

Roseville Energy Park shall pay a settlement of **Two Thousand Two Hundred Dollars ($2,200)**, in lieu of civil penalties determined pursuant to California Health and Safety Code Section 42402 et seq. The total monetary settlement is to be paid no later than **September 17, 2019**.

***Return of this agreement is requested by* September 17, 2019**

Failure to meet any of these agreement conditions shall void this agreement. In consideration of this settlement, the District agrees to refrain from seeking additional penalties with regard to the violation(s) set forth in this Notice of Violation letter. Notwithstanding this agreement, any evidence used in this matter may also be used in subsequent, but separate, enforcement actions. The signatures below signify agreement with the stated terms and conditions. By agreeing to this terms the alleged violator does not indicate acceptance of guilt.

08/09/19

Bruce Springsteen
Compliance and Enforcement Manager
Placer County Air Pollution Control District

Date

Alleged Violator
Roseville Energy Park

Date

Please return this form, with a check payable to the *Placer County Air Pollution Control District* in the amount of the penalty, or a receipt showing that you have paid the penalty online at http://www.placerair.org/onlinepayments, to the *Placer County Air Pollution Control District, 110 Maple Street, Auburn, CA 95603*, in acknowledgment that these terms of settlement are acceptable.

RETURN THIS AGREEMENT WITH YOUR PAYMENT

AGREEMENT

Notice of Violation No. 5295

Roseville Energy Park shall pay a settlement of **Two Thousand Two Hundred Dollars ($2,200)**, in lieu of civil penalties determined pursuant to California Health and Safety Code Section 42402 et seq. The total monetary settlement is to be paid no later than **September 17, 2019**.

***Return of this agreement is requested by* September 17, 2019**

Failure to meet any of these agreement conditions shall void this agreement. In consideration of this settlement, the District agrees to refrain from seeking additional penalties with regard to the violation(s) set forth in this Notice of Violation letter. Notwithstanding this agreement, any evidence used in this matter may also be used in subsequent, but separate, enforcement actions. The signatures below signify agreement with the stated terms and conditions. By agreeing to these terms the alleged violator does not indicate acceptance of guilt.

Bruce Springsteen
Compliance and Enforcement Manager
Placer County Air Pollution Control District

08/09/19
Date

Alleged Violator
Roseville Energy Park

8/21/19
Date

Please return this form, with a check payable to the *Placer County Air Pollution Control District* in the amount of the penalty, or a receipt showing that you have paid the penalty online at http://www.placerair.org/onlinepayments, to the *Placer County Air Pollution Control District, 110 Maple Street, Auburn, CA 95603*, in acknowledgment that these terms of settlement are acceptable.

RETURN THIS AGREEMENT WITH YOUR PAYMENT

This is a "printer friendly" page. Please use the "print" option in your browser to print this screen.

OFFICIAL PAYMENTS

Placer County, CA

Air Pollution Control

Confirmation Number:	024962
Payment Date:	Wednesday, August 21, 2019
Payment Time:	03:08PM PT

Payer Information

Name:	Matt Garner
Street Address:	5120 Phillip Road Roseville, CA 95747 United States
Daytime Phone Number:	(916) 746 - 1689
E-mail Address:	mgarner@roseville.ca.us
Select One:	Notice of Violation (NOV) Fine
NOV or Invoice Number:	5295

Card Information

Card Type:	Visa
Card Number:	**********2926
Card Verification Number:	****

Payment Information

Payment Type:	Air Pollution Control
Payment Amount:	$2,200.00
Convenience Fee:	$49.50
Total Payment:	$2,249.50

RIGHT TO REFUND

You, the customer, are entitled to a refund of the money to be transmitted as the result of this agreement if Official Payments does not forward the money received from you within 10 days of the date of its receipt, or does not give instructions committing an equivalent amount of money to the person designated by you within 10 days of the date of the receipt of the funds from you unless otherwise instructed by you.

If your instructions as to when the moneys shall be forwarded or transmitted are not complied with and the money has not yet been forwarded or transmitted, you have a right to a refund of your money.

If you want a refund, you must mail or deliver your written request to Official Payments at 6060 Coventry Drive, Elkhorn, NE 68022. If you do not receive your refund, you may be entitled to your money back plus a penalty of up to $1,000 and attorney's fees pursuant to section 2102 of the California Financial Code.

Thank you for using Official Payments. If you have a question regarding your payment, please call us toll free at 1-800-487-4567. To make payments in the future, please visit our website at www.officialpayments.com.

Back

Copyright © 2019 Official Payments Corporation. All Rights Reserved.
Official Payments Corporation is licensed as a money transmitter by the New York State Department of Financial Services, the Georgia Department of Banking and Finance, and by all other states and territories, where required. NMLS #936777.

AGREEMENT

Notice of Violation No. 5295

Roseville Energy Park shall pay a settlement of **Two Thousand Two Hundred Dollars ($2,200)**, in lieu of civil penalties determined pursuant to California Health and Safety Code Section 42402 et seq. The total monetary settlement is to be paid no later than **September 17, 2019**.

***Return of this agreement is requested by* September 17, 2019**

Failure to meet any of these agreement conditions shall void this agreement. In consideration of this settlement, the District agrees to refrain from seeking additional penalties with regard to the violation(s) set forth in this Notice of Violation letter. Notwithstanding this agreement, any evidence used in this matter may also be used in subsequent, but separate, enforcement actions. The signatures below signify agreement with the stated terms and conditions. By agreeing to these terms the alleged violator does not indicate acceptance of guilt.

08/09/19

Bruce Springsteen
Compliance and Enforcement Manager
Placer County Air Pollution Control District

Date

8/21/19

Alleged Violator
Roseville Energy Park

Date

Please return this form, with a check payable to the *Placer County Air Pollution Control District* in the amount of the penalty, or a receipt showing that you have paid the penalty online at http://www.placerair.org/onlinepayments, to the *Placer County Air Pollution Control District, 110 Maple Street, Auburn, CA 95603*, in acknowledgment that these terms of settlement are acceptable.

RETURN THIS AGREEMENT WITH YOUR PAYMENT

This is a "printer friendly" page. Please use the "print" option in your browser to print this screen.

OFFICIAL PAYMENTS

Placer County, CA

Air Pollution Control

Confirmation Number:	024962
Payment Date:	Wednesday, August 21, 2019
Payment Time:	03:08PM PT

Payer Information

Name:	Matt Garner
Street Address:	5120 Phillip Road Roseville, CA 95747 United States
Daytime Phone Number:	(916) 746 - 1689
E-mail Address:	mgarner@roseville.ca.us
Select One:	Notice of Violation (NOV) Fine
NOV or Invoice Number:	5295

Card Information

Card Type:	Visa
Card Number:	**********2926
Card Verification Number:	****

Payment Information

Payment Type:	Air Pollution Control
Payment Amount:	$2,200.00
Convenience Fee:	$49.50
Total Payment:	$2,249.50

RIGHT TO REFUND

You, the customer, are entitled to a refund of the money to be transmitted as the result of this agreement if Official Payments does not forward the money received from you within 10 days of the date of its receipt, or does not give instructions committing an equivalent amount of money to the person designated by you within 10 days of the date of the receipt of the funds from you unless otherwise instructed by you.

If your instructions as to when the moneys shall be forwarded or transmitted are not complied with and the money has not yet been forwarded or transmitted, you have a right to a refund of your money.

If you want a refund, you must mail or deliver your written request to Official Payments at 6060 Coventry Drive, Elkhorn, NE 68022. If you do not receive your refund, you may be entitled to your money back plus a penalty of up to $1,000 and attorney's fees pursuant to section 2102 of the California Financial Code.

Thank you for using Official Payments. If you have a question regarding your payment, please call us toll free at 1-800-487-4567. To make payments in the future, please visit our website at www.officialpayments.com.

Back

Copyright © 2019 Official Payments Corporation. All Rights Reserved.
Official Payments Corporation is licensed as a money transmitter by the New York State Department of Financial Services, the Georgia Department of Banking and Finance, and by all other states and territories, where required. NMLS #936777.

FedEx Express **NEW** Package US Airbill

FedEx Tracking Number 8061 7572 6022

Form ID No. 0200

Sender's Copy

1 From *Please print and press hard.*

Date 8-22-19 Sender's FedEx Account Number 3348-6640-7

Sender's Name Roseville Energy Park Phone (916) 7410-1650

Company City of Roseville

Address 5120 Phillip Road

Dept./Floor/Suite/Room

City Roseville State CA ZIP 95747

2 Your Internal Billing Reference First 24 characters will appear on invoice. PCAPCD-NOV

3 To Recipient's Name Placer County Air Pollution Control District Phone ( )

Company

Address 110 Maple Street

We cannot deliver to P.O. boxes or P.O. ZIP codes. Dept./Floor/Suite/Room

Address

Use this line for the HOLD location address or for continuation of your shipping address.

City Auburn, CA State ZIP 95603

☐ HOLD Weekday FedEx location address REQUIRED. NOT available for FedEx First Overnight.

☐ HOLD Saturday FedEx location address REQUIRED. AVAILABLE ONLY for FedEx Priority Overnight and FedEx 2Day to select locations.

Easy new Peel-and-Stick airbill. No pouch needed.
Apply airbill directly to your package. See directions on back.

4 Express Package Service * To most locations.
NOTE: Service order has changed. Please select carefully.

Packages up to 150 lbs.
For packages over 150 lbs., use the new FedEx Express Freight US Airbill.

Next Business Day

- ☐ FedEx First Overnight — Earliest next business morning delivery to select locations. Friday shipments will be delivered on Monday unless SATURDAY Delivery is selected.
- ☐ FedEx Priority Overnight — Next business morning.* Friday shipments will be delivered on Monday unless SATURDAY Delivery is selected.
- ☐ FedEx Standard Overnight — Next business afternoon.* Saturday Delivery NOT available.

2 or 3 Business Days

- ☐ FedEx 2Day A.M. — Second business morning.* Saturday Delivery NOT available.
- ☐ FedEx 2Day — Second business afternoon.* Thursday shipments will be delivered on Monday unless SATURDAY Delivery is selected.
- ☒ FedEx Express Saver — Third business day.* Saturday Delivery NOT available.

5 Packaging * Declared value limit $500.

☒ FedEx Envelope* ☐ FedEx Pak* ☐ FedEx Box ☐ FedEx Tube ☐ Other

6 Special Handling and Delivery Signature Options

☐ SATURDAY Delivery — NOT available for FedEx Standard Overnight, FedEx 2Day A.M., or FedEx Express Saver.

☐ No Signature Required — Package may be left without obtaining a signature for delivery.

☒ Direct Signature — Someone at recipient's address may sign for delivery. *Fee applies.*

☐ Indirect Signature — If no one is available at recipient's address, someone at a neighboring address may sign for delivery. For residential deliveries only. *Fee applies.*

Does this shipment contain dangerous goods?
One box must be checked.

☒ No ☐ Yes As per attached Shipper's Declaration. ☐ Yes Shipper's Declaration not required. ☐ Dry Ice Dry Ice, 9, UN 1845 ____ x ____ kg

Dangerous goods (including dry ice) cannot be shipped in FedEx packaging or placed in a FedEx Express Drop Box. ☐ Cargo Aircraft Only

7 Payment *Bill to:*

Enter FedEx Acct. No. or Credit Card No. below.

☐ Sender Acct. No. in Section 1 will be billed. ☐ Recipient ☐ Third Party ☐ Credit Card ☐ Cash/Check

FedEx Acct. No. / Credit Card No. Exp. Date

Total Packages ____ Total Weight ____ lbs. Total Declared Value† $ ____ .00

†Our liability is limited to US$100 unless you declare a higher value. See back for details. By using this Airbill you agree to the service conditions on the back of this Airbill and in the current FedEx Service Guide, including terms that limit our liability.

644

Rev. Date 1/12 • Part #167002 • ©2012 FedEx • PRINTED IN U.S.A. SRF

PULL AND RETAIN THIS COPY BEFORE AFFIXING TO THE PACKAGE. NO POUCH NEEDED.

(https://www.fedex.com
us/home)

Sign Up or Log In

Welcome to FedEx

RATE & SHIP

TRACK

LOCATIONS

TRACKING ID
806175726022

TRACK

MULTIPLE TRACKING NUMBERS |
NEED HELP? (HTTPS://WWW.FEDEX.COM/EN-US/QUICK-HELP/TRACKING/F_QUICKHELP.HTML)

Delivered
Tuesday 8/27/2019 at 9:43 am

DELIVERED

Signed for by: R.MOORE

Add to Watch List

FROM

ROS US

TO

CA US

SEE FULL DETAILS

Personalize Your Deliveries

Need to customize this delivery? Learn how FedEx Delivery Manager® can help ensure your deliveries meet your schedule - not the other way.

Finish signing up to save.

Complete your FedEx account today to start saving up to 16% on eligible services, plus, enjoy free shipping supplies.

GET STARTED (HTTPS://WWW.FEDEX.COM/APPS/ENROLLMENT/ACCOUNT.HTML)

SAVING (HTTPS://WWW.FEDEX.COM/EN-US/ERATE.HTML)

More Than Shipping

Explore ways to become more efficient, see printing offers and solutions, or get insights and inspiration for your small business.

New to FedEx?

Get started with shipping basics, benefits of account creation and other FAQs for new customers.

LET US HELP (HTTPS://WWW.FEDEX.COM/EN-US/GET-STARTED.HTML)

Find FedEx on Your Schedule

Visit FedEx Office or thousands of other locations where you already shop, to find the FedEx services you need.

DISCOVER LOCATIONS (HTTPS://WWW.FEDEX.COM/EN-US/SHIPPING/STORE/ALL-LOCATION-TYPES.HTML)

The Road to Success

Their lessons learned can fuel your success. See how other entrepreneurs launched and scaled their small businesses.

LEARN FROM PEERS (HTTPS://SMALLBUSINESS.FEDEX.COM/SUCCESS.HTML)

OUR COMPANY

About FedEx (https://about.van.fedex.com/)

Our Portfolio (https://about.van.fedex.com/our-story/company-structure/)

Investor Relations (http://investors.fedex.com/)

FedEx Blog (https://about.van.fedex.com/blog/)

Corporate Responsibility (https://about.van.fedex.com/social-responsibility/csr-policy-statements/)

MORE FROM FEDEX

FedEx Compatible (https://www.fedex.com/en-us/compatible.html)

Developer Resource Center (https://www.fedex.com/en-us/developer.html)

FedEx Logistics (https://www.fedex.com

LANGUAGE

United States (http://www.fedex.com/?location=home)

English

/investor-home/default.aspx (https://about.van.fedex.com/en-us/home.html)

Careers (https://careers.fedex.com/fedex/)

Newsroom (https://newsroom.fedex.com/newsroom/global/english/)

Contact Us (http://www.fedex.com/us/customersupport/email/index.html)

FOLLOW FEDEX

(http://www.fedex.com/us/email)

(https://www.facebook.com/fedex) (https://twitter.com/fedex)

(http://www.instagram.com/fedex)

(http://www.linkedin.com/company/fedex)

(http://www.youtube.com/fedex) (https://www.pinterest.com/fedex)

© FedEx 1995-2019

Feedback (http://www.fedex.com/us/customersupport/email/index.html) |

Site Map (http://www.fedex.com/us/sitemap.html) |

Terms of Use (https://www.fedex.com/en-us/terms-of-use.html) |

Privacy & Security (https://www.fedex.com/en-us/trust-center.html)

From:	Bruce Springsteen
To:	Manfredi, Julie; Garner, Matt
Cc:	Zach Lee
Subject:	RE: Notice of Violation
Date:	Tuesday, September 10, 2019 2:52:49 PM
Attachments:	image008.png

EXTERNAL: This email originated from outside of the organization. Do not click on any links or open attachments unless you recognize the sender and know the content is safe.

Julie: Ok, thanks, sorry for not knowing this. Regards, Bruce

---

From: Manfredi, Julie <JManfredi@roseville.ca.us>
Sent: Tuesday, September 10, 2019 2:50 PM
To: Bruce Springsteen <BSprings@placer.ca.gov>; Garner, Matt <MGarner@roseville.ca.us>
Cc: Zach Lee <ZLee@placer.ca.gov>
Subject: RE: Notice of Violation

Hi Bruce,

The payment was made and Federal Expressed to the 110 Maple Street address on August 22, 2019. I do not believe it was addressed to your attention. Please let me know if it was not received by your office and we can track it with Federal Express.

Regards,

Julie Manfredi
Electric Compliance Analyst
Roseville Electric Utility
o: (916) 774-5674
f: (916) 759-7433

2090 Hilltop Circle | Roseville, CA | 95747

CONFIDENTIALITY NOTICE: This email message and any accompanying documents are for the sole use of the intended recipient(s) and may contain confidential and/or privileged attorney-client information or work product. DO NOT FORWARD. Any unauthorized review, use, disclosure or distribution is prohibited. If you are not the intended recipient, please contact the sender by reply email and destroy all copies of the original message. Thank you.

From: Bruce Springsteen [mailto:BSprings@placer.ca.gov]

Sent: Tuesday, September 10, 2019 2:36 PM
To: Garner, Matt <MGarner@roseville.ca.us>; Manfredi, Julie <JManfredi@roseville.ca.us>
Cc: Zach Lee <ZLee@placer.ca.gov>
Subject: Notice of Violation

EXTERNAL: This email originated from outside of the organization. Do not click on any links or open attachments unless you recognize the sender and know the content is safe.

Matt and Julie: FYI, attached is a copy of a violation notice that was put in the mail to you in early August. The offered settlement deadline is approaching. Sincerely,

Bruce Springsteen
Compliance and Enforcement Manager
Placer County Air Pollution Control District
110 Maple Street
Auburn, CA 95603
Direct: (530) 745-2337
Cell: (530) 308-4871
Main Office: (530) 745-2330
Fax: (530) 745-2373
E-Mail: bsprings@placer.ca.gov
==========

CONFIDENTIALITY NOTICE: This communication with its contents may contain confidential and/or legally privileged information. It is solely for the use of the intended recipient(s). Unauthorized interception, review, use or disclosure is prohibited and may violate applicable laws including the Electronic Communications Privacy Act. If you are not the intended recipient, please contact the sender and destroy all copies of the communication.

ATTACHMENT 9

AQ-40

AQ-40 The Project owner shall comply with the applicable requirements for quality assurance testing and maintenance of the continuous emission monitor equipment in accordance with the procedures and guidance specified in 40 CFR Part 60, Appendix F.

Verification: The Project owner shall include all CEMS quality assurance test failures that required corrective action as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

Cylinder Gas Audit

Facility:	ROSEVILLE ENERGY			Instrument Name:	CT1_CODualRg_P_Instrume
Unit/Stack:	CT1	Test Date:	08/05/2019	Performance Spec:	15 Pct
Parameter/Scale:	CO / High	Test Result:	**Pass**	Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
08/05/2019	09:47	L	200	50.300	49.700	25.2 %
08/05/2019	09:52	M	200	107.500	109.700	53.8 %
08/05/2019	10:05	L	200	50.300	49.600	25.2 %
08/05/2019	10:10	M	200	107.500	109.300	53.8 %
08/05/2019	10:22	L	200	50.300	49.600	25.2 %
08/05/2019	10:27	M	200	107.500	109.600	53.8 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	50.300	49.633	Std	**1.3**
M	107.500	109.533	Std	**1.9**

Cylinder Gas Audit

Facility: ROSEVILLE ENERGY
Unit/Stack: CT1
Parameter/Scale: CO / Low

Test Date: 08/05/2019
Test Result: **Pass**

Instrument Name: CT1_CODualRg_P_Instrume
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
08/05/2019	11:38	L	10	2.400	2.200	24.0 %
08/05/2019	11:43	M	10	5.400	5.500	54.0 %
08/05/2019	11:50	L	10	2.400	2.200	24.0 %
08/05/2019	11:55	M	10	5.400	5.600	54.0 %
08/05/2019	12:02	L	10	2.400	2.200	24.0 %
08/05/2019	12:07	M	10	5.400	5.500	54.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	2.400	2.200	Std	**8.3**
M	5.400	5.533	Std	**2.5**

Cylinder Gas Audit

Facility:	ROSEVILLE ENERGY			Instrument Name:	CT2_CODualRg_P_Instrume
Unit/Stack:	CT2	Test Date:	08/06/2019	Performance Spec:	15 Pct
Parameter/Scale:	CO / Low	Test Result:	**Pass**	Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
08/06/2019	06:35	L	10	2.400	2.300	24.0 %
08/06/2019	06:40	M	10	5.400	5.600	54.0 %
08/06/2019	06:47	L	10	2.400	2.300	24.0 %
08/06/2019	06:52	M	10	5.400	5.600	54.0 %
08/06/2019	06:59	L	10	2.400	2.300	24.0 %
08/06/2019	07:04	M	10	5.400	5.600	54.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	2.400	2.300	Std	**4.2**
M	5.400	5.600	Std	**3.7**

Cylinder Gas Audit

Facility:	ROSEVILLE ENERGY			Instrument Name:	CT2_CODualRg_P_Instrume
Unit/Stack:	CT2	Test Date:	08/05/2019	Performance Spec:	15 Pct
Parameter/Scale:	CO / High	Test Result:	**Pass**	Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
08/05/2019	13:01	L	200	50.000	50.300	25.0 %
08/05/2019	13:07	M	200	109.700	114.000	54.9 %
08/05/2019	13:19	L	200	50.000	50.300	25.0 %
08/05/2019	13:24	M	200	109.700	113.600	54.9 %
08/05/2019	13:36	L	200	50.000	50.100	25.0 %
08/05/2019	13:41	M	200	109.700	113.800	54.9 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	50.000	50.233	Std	**0.5**
M	109.700	113.800	Std	**3.7**

Linearity Report

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY		
EDR Site ID:	CT001	Component ID:	A15	ReasonForTest:	QA
		Component Type:	NOXA	Grace Period:	0
Instrument Name:	CT1_NOXDualRg_P_Instrume	Test End Date/Time:	08/05/2019	Scale:	High
Performance Spec:	5 %	Test No.:	94	Highest Error:	0.1
		Status (Pass/Fail):	**Passed**		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
08/05/2019	0947	L	200.0	50.4	50.1		25.2 %
08/05/2019	0952	M	200.0	107.4	107.1		53.7 %
08/05/2019	0958	H	200.0	180.7	180.8		90.4 %
08/05/2019	1005	L	200.0	50.4	50.7		25.2 %
08/05/2019	1010	M	200.0	107.4	107.4		53.7 %
08/05/2019	1015	H	200.0	180.7	180.9		90.4 %
08/05/2019	1022	L	200.0	50.4	50.6		25.2 %
08/05/2019	1027	M	200.0	107.4	107.3		53.7 %
08/05/2019	1032	H	200.0	180.7	181.0		90.4 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	50.400	50.467	No	**0.1**
M	107.400	107.267	No	**0.1**
H	180.700	180.900	No	**0.1**

Linearity Report

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY		
EDR Site ID:	CT001	Component ID:	A16	ReasonForTest:	QA
		Component Type:	O2D	Grace Period:	0
Instrument Name:	CT1_O2D_P_Instrument	Test End Date/Time:	08/05/2019	Scale:	High
Performance Spec:	5 Eng Units	Test No.:	95	Highest Error:	5.4
		Status (Pass/Fail):	**PassAPS**		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
08/05/2019	1241	L	21.0	5.6	5.3		26.7 %
08/05/2019	1246	M	21.0	11.1	10.9		52.9 %
08/05/2019	1252	H	21.0	18.0	18.0		85.7 %
08/05/2019	1259	L	21.0	5.6	5.3		26.7 %
08/05/2019	1304	M	21.0	11.1	10.9		52.9 %
08/05/2019	1309	H	21.0	18.0	18.0		85.7 %
08/05/2019	1316	L	21.0	5.6	5.3		26.7 %
08/05/2019	1321	M	21.0	11.1	10.9		52.9 %
08/05/2019	1326	H	21.0	18.0	18.0		85.7 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.600	5.300	Yes	**0.3**
M	11.100	10.900	No	**1.8**
H	18.000	18.000	No	**0.0**

Linearity Report

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY		
EDR Site ID:	CT002	Component ID:	A21	ReasonForTest:	QA
		Component Type:	NOXA	Grace Period:	0
Instrument Name:	CT2_NOXDualRg_P_Instrume	Test End Date/Time:	08/05/2019	Scale:	High
Performance Spec:	5 %	Test No.:	93	Highest Error:	0.4
		Status (Pass/Fail):	**Passed**		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
08/05/2019	1301	L	200.0	49.0	48.7		24.5 %
08/05/2019	1307	M	200.0	108.9	108.5		54.5 %
08/05/2019	1312	H	200.0	177.2	176.8		88.6 %
08/05/2019	1319	L	200.0	49.0	49.1		24.5 %
08/05/2019	1324	M	200.0	108.9	108.5		54.5 %
08/05/2019	1329	H	200.0	177.2	176.9		88.6 %
08/05/2019	1336	L	200.0	49.0	49.0		24.5 %
08/05/2019	1341	M	200.0	108.9	108.4		54.5 %
08/05/2019	1346	H	200.0	177.2	176.8		88.6 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	49.000	48.933	No	**0.1**
M	108.900	108.467	No	**0.4**
H	177.200	176.833	No	**0.2**

Linearity Report

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY		
EDR Site ID:	CT002	Component ID:	A22	ReasonForTest:	QA
		Component Type:	O2D	Grace Period:	0
Instrument Name:	CT2_O2D_P_Instrument	Test End Date/Time:	08/05/2019	Scale:	High
Performance Spec:	5 %	Test No.:	94	Highest Error:	0.9
		Status (Pass/Fail):	**Passed**		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
08/05/2019	1354	L	21.0	5.6	5.5		26.7 %
08/05/2019	1359	M	21.0	11.1	11.0		52.9 %
08/05/2019	1404	H	21.0	18.0	18.0		85.7 %
08/05/2019	1411	L	21.0	5.6	5.6		26.7 %
08/05/2019	1416	M	21.0	11.1	11.0		52.9 %
08/05/2019	1421	H	21.0	18.0	18.0		85.7 %
08/05/2019	1428	L	21.0	5.6	5.6		26.7 %
08/05/2019	1433	M	21.0	11.1	11.0		52.9 %
08/05/2019	1438	H	21.0	18.0	18.0		85.7 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.600	5.567	No	**0.6**
M	11.100	11.000	No	**0.9**
H	18.000	18.000	No	**0.0**

Roseville Energy Park
Revision History

RegPerfect® by Teledyne Monitor Labs, Inc.
Teledyne Monitor Labs, Inc.
35 Inverness Drive East
Englewood, CO 80112-5189
Telephone: (800) 846-6062
http://www.teledyne-ml.com/
http://www.regperfect.com/
©1998-2005 Teledyne Monitor Labs, Inc. All rights reserved.
RegPerfect® is a registered trademark of Teledyne Monitor Labs, Inc.

NOTE: This server's C drive is only 20 GB in size!! Do not place large files on this drive.

8/22/19 Taylor Sullivan
EDR check. Re-generated Q2 EDRs to be resubmitted.

7/18,22/19 Taylor Sullivan
Q2 EDRs

ATTACHMENT 10

AQ-41

AQ-41 The Project owner shall submit a written report to the APCO and the CPM for each calendar quarter, within 30 days of the end of the quarter, including: time intervals, data and magnitude of excess emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; averaging period used for data reporting shall correspond to the averaging period for each respective emission standard; applicable time and date of each period during which the CEMS was inoperative (except for zero and span checks) and the nature of the system repairs and adjustments; and a negative declaration when no excess emission occurred.

Verification: The Project owner shall include the excess emission report as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6

Excess Emission Report

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/15/2019 12:42 **Location:** Roseville, CA

Tag Name: ALL_NOx_Lb_1D
Total Operating Time: 40.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 52.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**40.00 Day(s)**
Total Duration (Online only):	**Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/15/2019 12:41 **Location:** Roseville, CA

Tag Name: ALL_CO_Lb_1D
Total Operating Time: 40.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 52.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**40.00 Day(s)**
Total Duration (Online only):	**Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/15/2019 12:42 **Location:** Roseville, CA

Tag Name: ALL_PM10_Lb_1D
Total Operating Time: 40.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 52.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**40.00 Day(s)**
Total Duration (Online only):	**Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/15/2019 12:43 **Location:** Roseville, CA

Tag Name: ALL_SO2_Lb_1D
Total Operating Time: 40.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 52.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**40.00 Day(s)**
Total Duration (Online only):	**Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/15/2019 12:43 **Location:** Roseville, CA

Tag Name: ALL_VOC_Lb_1D
Total Operating Time: 40.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 52.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**40.00 Day(s)**
Total Duration (Online only):	**Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

CO LbPerHr 3-Hour Rolling Excess Emissions

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:38 **Location:** Roseville, CA

Tag Name: CT1_CO_3Hr_LbPerHr_1H
Total Operating Time: 709.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,499.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**709.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

CO Ppmvdc 3-Hour Block Excess Emissions

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:38 **Location:** Roseville, CA

Tag Name: CT1_CO_Ppmvdc_3H
Total Operating Time: 709.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,499.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**709.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

CO LbPerHr SUSD 1-Hour Block Excess Emissions

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:39 **Location:** Roseville, CA

Tag Name: CT1_CO_SUSD_LbPerHr_1H
Total Operating Time: 709.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,499.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**709.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

NH3 Slip Ppmvdc 1-Hour Block Excess Emissions

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:39 **Location:** Roseville, CA

Tag Name: CT1_NH3Slip_Ppmvdc_1H
Total Operating Time: 709.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,499.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**709.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

NOx LbPerHr 1-Hour Block Excess Emissions

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:40 **Location:** Roseville, CA

Tag Name: CT1_NOx_Norm_LbPerHr_1H
Total Operating Time: 709.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,499.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**709.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

NOx Ppmvdc 1-Hour Block Excess Emissions

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:40 **Location:** Roseville, CA

Tag Name: CT1_NOx_Ppmvdc_1H
Total Operating Time: 709.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,499.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**709.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

NOx LbPerHr SUSD 1-Hour Block Excess Emissions

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:41 **Location:** Roseville, CA

Tag Name: CT1_NOx_SUSD_LbPerHr_1H
Total Operating Time: 709.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,499.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**709.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

PM10 LbPerHr 1-Hour Block Excess Emissions

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:41 **Location:** Roseville, CA

Tag Name: CT1_PM10_Norm_LbPerHr_1H
Total Operating Time: 709.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,499.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**709.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

SO2 LbPerHr 1-Hour Block Excess Emissions

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:42 **Location:** Roseville, CA

Tag Name: CT1_SO2_Norm_LbPerHr_1H
Total Operating Time: 709.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,499.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**709.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

VOC LbPerHr 1-Hour Block Excess Emissions

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:42 **Location:** Roseville, CA

Tag Name: CT1_VOC_Norm_LbPerHr_1H
Total Operating Time: 709.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,499.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**709.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

CO LbPerHr 3-Hour Rolling Excess Emissions

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:42 **Location:** Roseville, CA

Tag Name: CT2_CO_3Hr_LbPerHr_1H
Total Operating Time: 694.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,514.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**694.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

CO Ppmvdc 3-Hour Block Excess Emissions

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:43 **Location:** Roseville, CA

Tag Name: CT2_CO_Ppmvdc_3H
Total Operating Time: 694.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,514.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**694.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

CO LbPerHr SUSD 1-Hour Block Excess Emissions

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:43 **Location:** Roseville, CA

Tag Name: CT2_CO_SUSD_LbPerHr_1H
Total Operating Time: 694.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,514.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**694.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

NH3 Slip Ppmvdc 1-Hour Block Excess Emissions

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:44 **Location:** Roseville, CA

Tag Name: CT2_NH3Slip_Ppmvdc_1H
Total Operating Time: 694.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,514.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**694.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

NOx LbPerHr 1-Hour Block Excess Emissions

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:44 **Location:** Roseville, CA

Tag Name: CT2_NOx_Norm_LbPerHr_1H
Total Operating Time: 694.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,514.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**694.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

NOx Ppmvdc 1-Hour Block Excess Emissions

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:45 **Location:** Roseville, CA

Tag Name: CT2_NOx_Ppmvdc_1H
Total Operating Time: 694.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,514.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**694.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

NOx LbPerHr SUSD 1-Hour Block Excess Emissions

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:45 **Location:** Roseville, CA

Tag Name: CT2_NOx_SUSD_LbPerHr_1H
Total Operating Time: 694.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,514.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**694.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

PM10 LbPerHr 1-Hour Block Excess Emissions

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:45 **Location:** Roseville, CA

Tag Name: CT2_PM10_Norm_LbPerHr_1H
Total Operating Time: 694.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,514.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**694.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

SO2 LbPerHr 1-Hour Block Excess Emissions

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:46 **Location:** Roseville, CA

Tag Name: CT2_SO2_Norm_LbPerHr_1H
Total Operating Time: 694.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,514.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**694.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

VOC LbPerHr 1-Hour Block Excess Emissions

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:46 **Location:** Roseville, CA

Tag Name: CT2_VOC_Norm_LbPerHr_1H
Total Operating Time: 694.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 1,514.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**694.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 11

12 Month Running Summary Report

AQ42 12 Month Running Summary Report

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/15/2019 12:50 **Location:** Roseville, CA

Date	Units CT1 & CT2 NOx, Ton 1 Day(s) Sum	Running Sum	Units CT1 & CT2 VOC, Ton 1 Day(s) Sum	Running Sum
Jul 19	0.4979	0.4979	0.1557	0.1557
Aug 19	0.9671	1.4650	0.3022	0.4579
Sep 19	0.5519	2.0169	0.1574	0.6153
Sum/Avg	2.0169		0.6153	

ATTACHMENT 12

AQ-47

AQ-47 No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

In regards to AQ-47of Roseville Energy Park's 3Q19 QAQR, there were no violations of PCAPCD's Rule 205 for nuisance.

ATTACHMENT 13

AQ-48

AQ-48 Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited and is in violation of PCAPCD Rule 202, Visible Emissions.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

In regards to AQ-48 of Roseville Energy Park's 3Q19 QAQR, there were no violations of PCAPCD's Rule 202 for opacity.

ATTACHMENT 14

AQ-51

AQ-51 The ammonia slip shall not exceed 10 ppmv @ 15% o2 averaged over one hour. The SCR catalyst shall be replaced, repaired or otherwise reconditioned within 24 months of the ammonia slip reaching 7 ppm @ 15% O2 averaged over 24 hours. The SCR ammonia injection grid replacement, repair or reconditioning scheduled event may be cancelled if the Project owner can demonstrate to the CPM that, subsequent to the initial exceedance, the ammonia slip consistently remains below 7 ppm @ 15% O2 averaged over 24 hours and that the initial exceedance does not accurately indicate expected future operating conditions.

Compliance with ammonia slip limits shall be demonstrated by using the following calculation procedure:

Ammonia slip ppmv @ 15% O2 = ((a-(bxc/1,000,000)) x 1,000,000/b) x d,

Where

a = ammonia injection rate (lb/hr)/17(lb/lb mol)

b = dry exhaust gas flow rate (lb/hr)/ (29(lb/lb mol)

c = change in measured NOX conc. Ppmv @ 15% O2 across catalyst, and

d = correction factor

The correction factor shall be derived annually during compliance testing by comparing the measured and calculated ammonia slip.

<u>Verification:</u> The Project owner shall include the ammonia slip concentrations averaged on an hourly and 24 hour basis calculated via the protocol provided as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6. The Project owner shall notify the CPM within 10 days of an exceedance of the 7 ppm ammonia slip limit herein. The Project owner shall notify the CPM no less than 30 days prior to the scheduled date of the SCR catalyst replacement, repair or reconditioning event. If the Project owner finds that the exceedance of the 7 ppm slip limit does not accurately reflect the expected future operations provided for in this condition, the Project owner shall submit all relevant information to the CPM no less than 30 days prior to the scheduled date of the SCR catalyst replacement, repair or reconditioning event in order to cancel the event.

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/01/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/02/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/03/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/04/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/05/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/06/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/07/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/08/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/09/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/10/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/11/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/12/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/13/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/14/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/15/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/16/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/17/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/18/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/19/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/20/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/21/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/22/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/23/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2019 05:00	0	0.0	31.1	0.0	0.0	100,380.8	0.25	0.25
07/23/2019 06:00	0	0.0	14.6	0.0	15.4	231,360.6	1.00	1.00
07/23/2019 07:00	1	2.0	12.6	14.4	22.1	781,836.0	0.00	1.00
07/23/2019 08:00	1	1.9	12.7	14.4	24.5	825,868.2	0.00	1.00
07/23/2019 09:00	1	1.8	10.4	14.5	22.3	927,571.0	0.00	1.00
07/23/2019 10:00	1	1.8	9.6	14.5	21.7	920,296.0	0.00	1.00
07/23/2019 11:00	2	2.3	16.2	12.8	34.7	948,284.1	0.00	1.00
07/23/2019 12:00	3	2.6	19.1	11.8	44.0	949,718.4	0.00	1.00
07/23/2019 13:00	3	2.6	19.3	11.8	44.2	952,878.6	0.00	1.00
07/23/2019 14:00	3	2.6	19.5	11.8	45.2	952,276.6	0.00	1.00
07/23/2019 15:00	3	2.6	19.6	11.8	45.7	950,771.8	0.00	1.00
07/23/2019 16:00	4	2.6	19.6	11.8	46.0	950,320.3	0.00	1.00
07/23/2019 17:00	3	2.6	19.5	11.8	46.0	954,082.5	0.00	1.00
07/23/2019 18:00	3	2.6	19.5	11.8	46.1	954,834.9	0.00	1.00
07/23/2019 19:00	4	2.6	19.4	11.8	46.1	956,038.8	0.00	1.00
07/23/2019 20:00	4	2.6	19.1	11.7	46.0	948,772.9	0.00	1.00
07/23/2019 21:00	4	2.6	19.1	11.7	46.2	951,154.5	0.00	1.00
07/23/2019 22:00	4	2.6	19.1	11.7	46.9	954,131.6	0.00	1.00
07/23/2019 23:00	4	2.6	19.3	11.8	47.7	966,422.4	0.00	1.00
Average/Sum#:	3	2.4	17.9	12.5	36.4	932,074.0	1.25 #	18.25 #
Minimum:	1	1.8	9.6	11.7	0.0	781,836.0	0.00	0.00
Maximum:	4	2.6	31.1	14.5	47.7	966,422.4	1.00	1.00
%SI	29.17	29.17	20.83	29.17	20.83	29.17	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/24/2019 00:00	4	2.6	19.3	11.8	47.6	962,810.7	0.00	1.00
07/24/2019 01:00	4	2.6	19.3	11.8	47.6	963,563.1	0.00	1.00
07/24/2019 02:00	4	2.6	19.1	11.9	46.6	965,444.2	0.00	1.00
07/24/2019 03:00	4	2.6	19.1	11.9	46.8	965,596.3	0.00	1.00
07/24/2019 04:00	3	2.6	19.5	11.9	47.4	967,574.4	0.00	1.00
07/24/2019 05:00	4	2.6	19.3	11.9	48.1	969,400.3	0.00	1.00
07/24/2019 06:00	4	2.6	19.0	11.9	46.8	968,639.5	0.00	1.00
07/24/2019 07:00	4	2.6	18.9	11.9	46.1	965,139.9	0.00	1.00
07/24/2019 08:00	3	2.6	18.8	11.9	45.3	959,510.0	0.00	1.00
07/24/2019 09:00	3	2.6	18.8	11.8	44.6	950,019.4	0.00	1.00
07/24/2019 10:00	3	2.6	18.7	11.8	44.6	951,825.2	0.00	1.00
07/24/2019 11:00	3	2.6	18.6	11.8	43.8	951,223.2	0.00	1.00
07/24/2019 12:00	3	2.6	18.8	11.8	44.0	952,728.1	0.00	1.00
07/24/2019 13:00	3	2.6	18.9	11.8	43.3	953,029.1	0.00	1.00
07/24/2019 14:00	3	2.6	19.1	11.8	44.2	951,524.2	0.00	1.00
07/24/2019 15:00	4	2.6	19.5	11.8	46.0	953,029.1	0.00	1.00
07/24/2019 16:00	3	2.6	19.4	11.8	45.1	948,364.0	0.00	1.00
07/24/2019 17:00	3	2.6	19.3	11.8	44.7	949,718.4	0.00	1.00
07/24/2019 18:00	3	2.6	19.3	11.8	44.8	950,019.4	0.00	1.00
07/24/2019 19:00	3	2.6	19.0	11.8	43.5	940,237.8	0.00	1.00
07/24/2019 20:00	3	2.6	19.0	11.8	44.1	945,354.3	0.00	1.00
07/24/2019 21:00	3	2.6	19.1	11.8	45.1	952,577.6	0.00	1.00
07/24/2019 22:00	3	2.6	18.4	11.9	41.4	938,512.2	0.00	1.00
07/24/2019 23:00	1	2.0	9.8	14.3	18.9	891,993.2	0.00	1.00
Average/Sum#:	3	2.6	18.7	11.9	44.2	952,826.4	0.00 #	24.00 #
Minimum:	1	2.0	9.8	11.8	18.9	891,993.2	0.00	1.00
Maximum:	4	2.6	19.5	14.3	48.1	969,400.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/25/2019 00:00	2	1.9	9.9	14.2	24.8	928,755.9	0.00	1.00
07/25/2019 01:00	2	1.9	9.8	14.2	24.7	920,375.8	0.00	1.00
07/25/2019 02:00	2	1.8	9.2	14.5	23.8	930,138.7	0.00	1.00
07/25/2019 03:00	2	1.9	9.1	14.5	22.0	890,553.8	0.00	1.00
07/25/2019 04:00	1	1.8	9.7	14.5	23.2	907,029.7	0.00	1.00
07/25/2019 05:00	1	1.9	9.3	14.5	22.9	914,732.7	0.00	1.00
07/25/2019 06:00	2	1.9	9.1	14.5	23.0	910,453.2	0.00	1.00
07/25/2019 07:00	2	1.9	9.9	14.3	27.0	920,004.2	0.00	1.00
07/25/2019 08:00	3	2.5	18.6	11.9	45.3	960,727.3	0.00	1.00
07/25/2019 09:00	3	2.6	18.8	11.8	45.0	955,888.3	0.00	1.00
07/25/2019 10:00	3	2.6	18.6	11.8	43.6	950,169.8	0.00	1.00
07/25/2019 11:00	3	2.6	18.5	11.8	42.5	949,567.9	0.00	1.00
07/25/2019 12:00	3	2.6	18.6	11.8	43.3	951,825.2	0.00	1.00
07/25/2019 13:00	3	2.6	18.9	11.8	44.3	953,029.1	0.00	1.00
07/25/2019 14:00	3	2.6	19.2	11.8	44.9	951,072.8	0.00	1.00
07/25/2019 15:00	3	2.6	19.3	11.8	45.1	945,354.3	0.00	1.00
07/25/2019 16:00	2	2.3	16.8	12.8	33.9	939,492.8	0.00	1.00
07/25/2019 17:00	2	2.3	15.7	13.0	32.3	936,929.0	0.00	1.00
07/25/2019 18:00	1	2.1	13.0	13.7	26.6	933,110.6	0.00	1.00
07/25/2019 19:00	2	2.2	14.7	13.2	33.0	941,701.6	0.00	1.00
07/25/2019 20:00	3	2.4	17.7	12.4	40.5	953,924.9	0.00	1.00
07/25/2019 21:00	2	2.3	16.4	12.8	33.7	942,705.0	0.00	1.00
07/25/2019 22:00	1	2.0	9.6	14.4	21.9	921,728.0	0.00	1.00
07/25/2019 23:00	2	1.9	10.2	14.2	24.4	898,505.9	0.00	1.00
Average/Sum#:	2	2.2	14.2	13.2	33.0	933,657.4	0.00 #	24.00 #
Minimum:	1	1.8	9.1	11.8	21.9	890,553.8	0.00	1.00
Maximum:	3	2.6	19.3	14.5	45.3	960,727.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/26/2019 00:00	2	2.1	12.8	13.6	28.0	938,899.9	0.00	1.00
07/26/2019 01:00	1	1.9	9.2	14.5	22.2	904,462.0	0.00	1.00
07/26/2019 02:00	1	1.8	8.8	14.5	22.5	928,426.9	0.00	1.00
07/26/2019 03:00	2	1.8	8.9	14.5	23.3	934,418.2	0.00	1.00
07/26/2019 04:00	1	1.8	9.4	14.5	23.4	932,064.5	0.00	1.00
07/26/2019 05:00	1	1.9	11.0	14.4	23.9	854,731.5	0.00	1.00
07/26/2019 06:00	2	2.0	11.6	14.0	27.2	945,498.2	0.00	1.00
07/26/2019 07:00	2	2.0	12.0	13.9	26.9	947,054.8	0.00	1.00
07/26/2019 08:00	1	2.0	11.9	13.9	26.9	942,555.2	0.00	1.00
07/26/2019 09:00	1	2.0	13.0	13.8	27.1	946,060.1	0.00	1.00
07/26/2019 10:00	2	2.3	14.9	13.0	32.6	945,596.2	0.00	1.00
07/26/2019 11:00	3	2.6	18.7	11.8	43.8	952,427.1	0.00	1.00
07/26/2019 12:00	3	2.6	18.7	11.8	44.2	953,631.0	0.00	1.00
07/26/2019 13:00	2	2.4	17.6	12.5	36.6	958,760.1	0.00	1.00
07/26/2019 14:00	2	2.4	17.9	12.5	37.2	957,455.9	0.00	1.00
07/26/2019 15:00	3	2.6	19.2	11.8	45.5	948,966.0	0.00	1.00
07/26/2019 16:00	4	2.6	19.4	11.8	46.3	952,126.2	0.00	1.00
07/26/2019 17:00	4	2.6	19.5	11.8	46.7	954,684.4	0.00	1.00
07/26/2019 18:00	3	2.5	18.8	12.1	42.5	953,150.5	0.00	1.00
07/26/2019 19:00	2	2.4	17.8	12.6	37.9	957,607.1	0.00	1.00
07/26/2019 20:00	3	2.5	18.6	12.2	42.6	959,226.7	0.00	1.00
07/26/2019 21:00	3	2.6	18.8	12.0	43.7	955,981.3	0.00	1.00
07/26/2019 22:00	2	2.2	14.5	13.1	29.0	936,300.0	0.00	1.00
07/26/2019 23:00	2	2.2	13.4	13.4	27.5	942,164.0	0.00	1.00
Average/Sum#:	2	2.2	14.9	13.1	33.6	941,760.3	0.00 #	24.00 #
Minimum:	1	1.8	8.8	11.8	22.2	854,731.5	0.00	1.00
Maximum:	4	2.6	19.5	14.5	46.7	959,226.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/27/2019 00:00	1	2.0	11.9	13.8	25.3	930,822.8	0.00	1.00
07/27/2019 01:00	1	2.0	11.5	14.0	25.1	942,322.7	0.00	1.00
07/27/2019 02:00	1	1.9	10.9	14.3	22.2	829,746.7	0.00	1.00
07/27/2019 03:00	1	1.9	11.2	14.3	20.4	747,581.2	0.00	1.00
07/27/2019 04:00	1	1.9	11.7	14.3	20.5	736,584.3	0.00	1.00
07/27/2019 05:00	2	1.9	12.3	14.3	23.2	707,328.4	0.00	1.00
07/27/2019 06:00	2	1.9	11.9	14.3	21.9	716,457.9	0.00	1.00
07/27/2019 07:00	1	1.9	11.2	14.4	22.6	847,989.7	0.00	1.00
07/27/2019 08:00	1	1.9	10.5	14.4	21.8	848,200.4	0.00	1.00
07/27/2019 09:00	1	1.9	10.5	14.4	20.1	795,951.6	0.00	1.00
07/27/2019 10:00	1	1.9	9.5	14.5	20.4	873,436.0	0.00	1.00
07/27/2019 11:00	1	1.9	9.0	14.4	20.9	910,140.5	0.00	1.00
07/27/2019 12:00	1	1.9	8.8	14.5	20.2	919,226.1	0.00	1.00
07/27/2019 13:00	1	1.9	8.6	14.5	19.4	914,732.7	0.00	1.00
07/27/2019 14:00	1	1.9	8.4	14.5	18.4	905,531.9	0.00	1.00
07/27/2019 15:00	1	1.9	9.0	14.3	18.6	843,026.0	0.00	1.00
07/27/2019 16:00	3	2.5	17.7	11.9	40.1	931,056.4	0.00	1.00
07/27/2019 17:00	3	2.6	18.4	11.9	40.3	936,382.0	0.00	1.00
07/27/2019 18:00	3	2.6	18.3	11.9	39.7	932,273.7	0.00	1.00
07/27/2019 19:00	3	2.6	17.9	11.9	37.7	926,035.2	0.00	1.00
07/27/2019 20:00	3	2.6	18.1	11.9	39.3	934,099.6	0.00	1.00
07/27/2019 21:00	3	2.6	18.4	11.9	40.7	940,642.4	0.00	1.00
07/27/2019 22:00	2	2.4	16.7	12.3	34.1	899,043.0	0.00	1.00
07/27/2019 23:00	1	2.0	9.8	14.4	15.9	802,272.0	0.00	1.00
Average/Sum#:	2	2.1	12.6	13.6	26.2	865,453.5	0.00 #	24.00 #
Minimum:	1	1.9	8.4	11.9	15.9	707,328.4	0.00	1.00
Maximum:	3	2.6	18.4	14.5	40.7	942,322.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/28/2019 00:00	1	1.9	9.5	14.4	16.9	759,503.8	0.00	1.00
07/28/2019 01:00	1	1.9	11.4	14.3	19.1	692,389.3	0.00	1.00
07/28/2019 02:00	1	1.9	12.1	14.3	19.1	650,891.6	0.00	1.00
07/28/2019 03:00	2	1.9	12.4	14.3	20.5	663,548.4	0.00	1.00
07/28/2019 04:00	2	1.9	13.2	14.3	21.5	668,943.1	0.00	1.00
07/28/2019 05:00	2	1.9	12.7	14.3	21.3	676,620.1	0.00	1.00
07/28/2019 06:00	2	1.9	12.4	14.3	20.9	682,014.8	0.00	1.00
07/28/2019 07:00	1	1.9	11.1	14.3	18.9	726,832.4	0.00	1.00
07/28/2019 08:00	1	1.9	10.1	14.3	17.7	727,039.9	0.00	1.00
07/28/2019 09:00	1	1.9	9.4	14.4	17.2	759,082.5	0.00	1.00
07/28/2019 10:00	1	1.9	8.6	14.5	19.3	907,671.6	0.00	1.00
07/28/2019 11:00	1	1.9	8.7	14.4	19.6	895,814.2	0.00	1.00
07/28/2019 12:00	2	2.3	15.1	12.7	29.9	932,210.6	0.00	1.00
07/28/2019 13:00	3	2.6	17.3	12.0	36.6	933,516.6	0.00	1.00
07/28/2019 14:00	3	2.6	18.0	11.8	40.3	935,271.7	0.00	1.00
07/28/2019 15:00	3	2.6	18.1	11.8	41.2	933,164.9	0.00	1.00
07/28/2019 16:00	3	2.6	18.0	11.8	41.6	932,863.9	0.00	1.00
07/28/2019 17:00	3	2.6	17.7	11.8	40.2	931,359.1	0.00	1.00
07/28/2019 18:00	3	2.6	17.5	11.9	39.8	934,860.4	0.00	1.00
07/28/2019 19:00	2	2.2	13.5	13.2	26.7	924,272.5	0.00	1.00
07/28/2019 20:00	3	2.6	17.5	11.9	38.8	932,578.0	0.00	1.00
07/28/2019 21:00	3	2.5	16.8	12.1	35.9	930,274.9	0.00	1.00
07/28/2019 22:00	2	2.3	13.5	13.2	26.5	924,806.1	0.00	1.00
07/28/2019 23:00	1	1.9	9.1	14.4	20.7	910,351.2	0.00	1.00
Average/Sum#:	2	2.2	13.5	13.4	27.1	831,911.7	0.00 #	24.00 #
Minimum:	1	1.9	8.6	11.8	16.9	650,891.6	0.00	1.00
Maximum:	3	2.6	18.1	14.5	41.6	935,271.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/29/2019 00:00	1	1.9	8.8	14.5	19.7	880,497.1	0.00	1.00
07/29/2019 01:00	1	1.9	9.1	14.5	20.2	870,440.4	0.00	1.00
07/29/2019 02:00	1	1.9	9.8	14.4	21.4	840,826.6	0.00	1.00
07/29/2019 03:00	1	1.9	9.9	14.4	21.4	832,820.7	0.00	1.00
07/29/2019 04:00	1	1.8	11.5	14.4	22.3	823,129.4	0.00	1.00
07/29/2019 05:00	1	1.9	9.6	14.4	22.7	899,817.2	0.00	1.00
07/29/2019 06:00	2	2.1	12.5	13.5	28.5	947,308.6	0.00	1.00
07/29/2019 07:00	2	2.2	14.2	13.0	30.4	942,822.7	0.00	1.00
07/29/2019 08:00	1	1.9	8.9	14.5	20.3	890,125.8	0.00	1.00
07/29/2019 09:00	1	1.9	9.1	14.5	20.2	878,357.4	0.00	1.00
07/29/2019 10:00	2	2.2	13.2	13.2	28.7	938,856.0	0.00	1.00
07/29/2019 11:00	2	2.4	16.0	12.6	32.8	943,747.9	0.00	1.00
07/29/2019 12:00	1	1.9	8.7	14.4	20.3	910,561.9	0.00	1.00
07/29/2019 13:00	3	2.4	16.3	12.2	37.3	944,588.0	0.00	1.00
07/29/2019 14:00	3	2.6	17.8	11.7	41.2	941,032.7	0.00	1.00
07/29/2019 15:00	3	2.6	17.6	11.7	41.2	935,525.2	0.00	1.00
07/29/2019 16:00	3	2.6	16.8	12.0	37.4	934,593.7	0.00	1.00
07/29/2019 17:00	3	2.6	16.8	12.0	37.5	936,594.0	0.00	1.00
07/29/2019 18:00	3	2.5	16.8	12.1	36.8	936,655.2	0.00	1.00
07/29/2019 19:00	2	2.3	13.8	13.1	28.5	932,613.1	0.00	1.00
07/29/2019 20:00	3	2.5	16.8	12.3	36.5	945,062.1	0.00	1.00
07/29/2019 21:00	2	2.3	14.8	12.9	31.4	940,109.8	0.00	1.00
07/29/2019 22:00	1	2.0	9.8	14.3	22.0	897,595.4	0.00	1.00
07/29/2019 23:00	2	1.9	12.3	14.4	20.7	660,694.6	0.00	1.00
Average/Sum#:	2	2.2	13.0	13.4	28.3	900,182.3	0.00 #	24.00 #
Minimum:	1	1.8	8.7	11.7	19.7	660,694.6	0.00	1.00
Maximum:	3	2.6	17.8	14.5	41.2	947,308.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/30/2019 00:00	2	1.8	12.3	14.5	20.0	639,991.9	0.00	1.00
07/30/2019 01:00	2	1.8	12.3	14.5	20.1	635,712.5	0.00	1.00
07/30/2019 02:00	2	1.9	12.4	14.5	20.3	634,856.6	0.00	1.00
07/30/2019 03:00	2	1.8	12.3	14.5	20.2	635,070.6	0.00	1.00
07/30/2019 04:00	2	1.8	13.0	14.5	20.6	635,498.5	0.00	1.00
07/30/2019 05:00	2	1.9	12.6	14.3	23.8	710,440.8	0.00	1.00
07/30/2019 06:00	2	1.9	11.7	14.3	22.4	732,019.6	0.00	1.00
07/30/2019 07:00	1	1.9	11.2	14.4	21.8	798,901.1	0.00	1.00
07/30/2019 08:00	1	1.9	11.3	14.5	22.3	809,886.1	0.00	1.00
07/30/2019 09:00	1	1.9	11.4	14.4	22.1	769,827.2	0.00	1.00
07/30/2019 10:00	1	1.9	11.4	14.5	21.8	774,794.6	0.00	1.00
07/30/2019 11:00	1	1.9	11.1	14.4	19.8	724,952.2	0.00	1.00
07/30/2019 12:00	2	1.9	11.8	14.5	20.9	711,672.7	0.00	1.00
07/30/2019 13:00	2	1.8	12.8	14.5	21.7	674,655.5	0.00	1.00
07/30/2019 14:00	2	1.9	12.9	14.5	21.7	681,502.6	0.00	1.00
07/30/2019 15:00	2	1.8	12.7	14.5	21.5	680,004.8	0.00	1.00
07/30/2019 16:00	1	1.8	9.2	14.6	19.3	919,905.4	0.00	1.00
07/30/2019 17:00	1	1.9	9.3	14.4	21.5	909,929.8	0.00	1.00
07/30/2019 18:00	1	1.9	10.2	14.4	19.8	799,533.2	0.00	1.00
07/30/2019 19:00	1	1.9	9.8	14.3	18.4	733,887.0	0.00	1.00
07/30/2019 20:00	1	1.9	9.6	14.4	18.9	766,667.0	0.00	1.00
07/30/2019 21:00	2	1.9	9.9	14.3	19.0	719,155.3	0.00	1.00
07/30/2019 22:00	1	1.9	9.8	14.4	19.4	775,726.2	0.00	1.00
07/30/2019 23:00	2	1.9	12.5	14.3	22.2	682,844.8	0.00	1.00
Average/Sum#:	2	1.9	11.4	14.4	20.8	731,559.8	0.00 #	24.00 #
Minimum:	1	1.8	9.2	14.3	18.4	634,856.6	0.00	1.00
Maximum:	2	1.9	13.0	14.6	23.8	919,905.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/31/2019 00:00	2	1.9	13.2	14.4	22.8	662,801.4	0.00	1.00
07/31/2019 01:00	2	1.9	12.6	14.5	20.5	651,332.5	0.00	1.00
07/31/2019 02:00	2	1.9	12.6	14.4	20.7	640,679.9	0.00	1.00
07/31/2019 03:00	2	1.9	12.7	14.4	20.8	641,944.0	0.00	1.00
07/31/2019 04:00	2	1.8	13.1	14.4	20.5	638,573.1	0.00	1.00
07/31/2019 05:00	2	1.9	12.4	14.5	19.9	641,489.7	0.00	1.00
07/31/2019 06:00	2	1.9	12.6	14.5	21.5	652,616.3	0.00	1.00
07/31/2019 07:00	2	1.9	13.0	14.4	22.5	668,700.5	0.00	1.00
07/31/2019 08:00	2	1.9	12.8	14.4	22.3	685,554.9	0.00	1.00
07/31/2019 09:00	1	1.8	12.5	14.5	20.2	656,253.8	0.00	1.00
07/31/2019 10:00	1	1.8	12.5	14.6	20.4	648,411.6	0.00	1.00
07/31/2019 11:00	1	1.8	12.7	14.6	20.3	651,454.7	0.00	1.00
07/31/2019 12:00	1	1.8	10.6	14.6	18.6	782,745.6	0.00	1.00
07/31/2019 13:00	1	1.8	9.2	14.6	17.3	860,781.0	0.00	1.00
07/31/2019 14:00	2	2.3	16.3	12.6	33.5	950,842.5	0.00	1.00
07/31/2019 15:00	2	2.4	16.4	12.7	31.8	937,387.7	0.00	1.00
07/31/2019 16:00	2	2.3	16.0	12.8	31.3	931,208.6	0.00	1.00
07/31/2019 17:00	2	2.3	15.8	13.0	31.4	944,382.8	0.00	1.00
07/31/2019 18:00	2	2.3	15.7	13.0	31.4	945,249.5	0.00	1.00
07/31/2019 19:00	2	2.3	15.9	12.9	31.5	945,929.9	0.00	1.00
07/31/2019 20:00	1	1.9	9.8	14.4	20.2	856,627.6	0.00	1.00
07/31/2019 21:00	1	1.9	9.9	14.4	20.0	803,325.4	0.00	1.00
07/31/2019 22:00	2	1.9	12.0	14.4	19.8	667,225.7	0.00	1.00
07/31/2019 23:00	2	1.9	12.5	14.5	20.3	652,616.3	0.00	1.00
Average/Sum#:	2	2.0	13.0	14.1	23.3	754,922.3	0.00 #	24.00 #
Minimum:	1	1.8	9.2	12.6	17.3	638,573.1	0.00	1.00
Maximum:	2	2.4	16.4	14.6	33.5	950,842.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/01/2019 00:00	2	1.9	12.6	14.5	20.4	647,053.0	0.00	1.00
08/01/2019 01:00	1	1.8	12.5	14.5	20.0	644,485.4	0.00	1.00
08/01/2019 02:00	1	1.9	12.2	14.5	19.3	641,917.7	0.00	1.00
08/01/2019 03:00	1	1.8	12.1	14.5	19.1	639,350.0	0.00	1.00
08/01/2019 04:00	1	1.8	12.4	14.5	19.0	639,991.9	0.00	1.00
08/01/2019 05:00	2	1.9	12.1	14.5	19.3	642,987.5	0.00	1.00
08/01/2019 06:00	2	1.9	12.1	14.5	19.9	646,839.0	0.00	1.00
08/01/2019 07:00	2	1.9	12.6	14.4	21.1	650,581.9	0.00	1.00
08/01/2019 08:00	2	1.9	12.5	14.5	20.3	653,900.1	0.00	1.00
08/01/2019 09:00	2	1.8	12.7	14.4	22.4	658,587.8	0.00	1.00
08/01/2019 10:00	1	1.8	12.4	14.5	19.9	644,913.3	0.00	1.00
08/01/2019 11:00	1	1.8	12.1	14.6	19.8	667,322.7	0.00	1.00
08/01/2019 12:00	1	1.8	9.0	14.6	18.8	910,993.3	0.00	1.00
08/01/2019 13:00	1	1.8	8.9	14.5	19.5	921,365.8	0.00	1.00
08/01/2019 14:00	1	1.8	8.8	14.5	19.5	918,584.2	0.00	1.00
08/01/2019 15:00	1	1.9	8.9	14.5	19.8	916,872.4	0.00	1.00
08/01/2019 16:00	1	2.0	11.6	13.8	23.8	926,579.5	0.00	1.00
08/01/2019 17:00	1	2.1	12.1	13.7	24.0	928,165.4	0.00	1.00
08/01/2019 18:00	2	2.3	15.6	12.8	30.8	943,719.4	0.00	1.00
08/01/2019 19:00	1	1.9	8.9	14.4	20.4	907,823.0	0.00	1.00
08/01/2019 20:00	2	1.9	11.8	14.4	20.0	672,492.7	0.00	1.00
08/01/2019 21:00	2	1.9	12.6	14.4	21.2	648,896.5	0.00	1.00
08/01/2019 22:00	2	1.9	12.5	14.4	20.7	646,368.3	0.00	1.00
08/01/2019 23:00	2	1.9	12.3	14.5	20.0	650,048.6	0.00	1.00
Average/Sum#:	1	1.9	11.7	14.4	20.8	740,410.0	0.00 #	24.00 #
Minimum:	1	1.8	8.8	12.8	18.8	639,350.0	0.00	1.00
Maximum:	2	2.3	15.6	14.6	30.8	943,719.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/02/2019 00:00	1	1.9	12.1	14.5	19.6	647,908.9	0.00	1.00
08/02/2019 01:00	1	1.9	12.0	14.5	19.3	647,481.0	0.00	1.00
08/02/2019 02:00	1	1.9	11.8	14.5	19.1	645,341.2	0.00	1.00
08/02/2019 03:00	1	1.9	11.8	14.5	18.8	643,629.5	0.00	1.00
08/02/2019 04:00	1	1.8	12.3	14.5	18.8	639,564.0	0.00	1.00
08/02/2019 05:00	2	1.9	12.1	14.5	19.7	638,280.1	0.00	1.00
08/02/2019 06:00	2	1.9	11.8	14.5	19.1	640,847.8	0.00	1.00
08/02/2019 07:00	1	1.8	11.6	14.5	18.6	641,703.7	0.00	1.00
08/02/2019 08:00	1	1.8	11.6	14.5	18.3	639,991.9	0.00	1.00
08/02/2019 09:00	2	1.8	11.8	14.5	19.1	639,136.0	0.00	1.00
08/02/2019 10:00	2	1.8	12.1	14.6	19.7	649,063.7	0.00	1.00
08/02/2019 11:00	1	1.8	12.3	14.6	20.2	656,236.9	0.00	1.00
08/02/2019 12:00	1	1.8	12.1	14.5	20.9	712,100.7	0.00	1.00
08/02/2019 13:00	1	1.9	10.4	14.2	19.6	905,864.0	0.00	1.00
08/02/2019 14:00	1	2.0	9.9	14.1	20.6	918,118.5	0.00	1.00
08/02/2019 15:00	2	2.4	16.6	12.4	35.0	947,641.7	0.00	1.00
08/02/2019 16:00	2	2.5	17.2	12.2	36.3	935,615.9	0.00	1.00
08/02/2019 17:00	3	2.5	17.1	12.1	36.7	935,254.6	0.00	1.00
08/02/2019 18:00	1	2.2	13.7	13.1	26.0	918,392.2	0.00	1.00
08/02/2019 19:00	1	2.0	9.9	14.1	20.6	912,278.3	0.00	1.00
08/02/2019 20:00	1	1.9	9.6	14.3	17.3	742,601.5	0.00	1.00
08/02/2019 21:00	2	1.9	12.3	14.4	20.5	661,116.0	0.00	1.00
08/02/2019 22:00	1	1.9	12.5	14.5	20.3	663,314.9	0.00	1.00
08/02/2019 23:00	2	1.9	12.5	14.4	20.4	655,216.9	0.00	1.00
Average/Sum#:	1	2.0	12.4	14.1	21.9	734,862.5	0.00 #	24.00 #
Minimum:	1	1.8	9.6	12.1	17.3	638,280.1	0.00	1.00
Maximum:	3	2.5	17.2	14.6	36.7	947,641.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/03/2019 00:00	2	1.9	12.7	14.4	21.0	650,371.2	0.00	1.00
08/03/2019 01:00	1	1.8	12.1	14.5	18.7	637,424.3	0.00	1.00
08/03/2019 02:00	1	1.8	12.1	14.5	19.0	636,996.3	0.00	1.00
08/03/2019 03:00	1	1.8	11.9	14.5	18.6	637,638.2	0.00	1.00
08/03/2019 04:00	1	1.8	12.2	14.5	18.6	638,066.2	0.00	1.00
08/03/2019 05:00	1	1.9	12.0	14.5	19.0	637,210.3	0.00	1.00
08/03/2019 06:00	1	1.9	11.9	14.5	18.9	638,708.1	0.00	1.00
08/03/2019 07:00	2	1.9	12.7	14.4	21.5	650,581.9	0.00	1.00
08/03/2019 08:00	2	1.9	12.8	14.5	20.7	656,039.9	0.00	1.00
08/03/2019 09:00	2	1.8	12.8	14.5	21.0	655,398.0	0.00	1.00
08/03/2019 10:00	1	1.8	12.6	14.5	20.5	670,804.0	0.00	1.00
08/03/2019 11:00	1	1.8	12.0	14.5	19.3	691,559.3	0.00	1.00
08/03/2019 12:00	1	1.8	9.7	14.5	16.5	731,786.2	0.00	1.00
08/03/2019 13:00	1	2.0	10.4	14.0	19.5	919,102.1	0.00	1.00
08/03/2019 14:00	1	2.1	12.7	13.5	23.6	935,279.8	0.00	1.00
08/03/2019 15:00	3	2.7	17.9	11.7	39.0	928,975.8	0.00	1.00
08/03/2019 16:00	3	2.6	18.0	11.8	40.6	932,563.0	0.00	1.00
08/03/2019 17:00	3	2.5	17.2	12.1	37.5	933,698.4	0.00	1.00
08/03/2019 18:00	3	2.6	17.7	11.9	39.3	936,534.1	0.00	1.00
08/03/2019 19:00	2	2.4	16.4	12.6	33.1	936,323.3	0.00	1.00
08/03/2019 20:00	1	2.1	11.5	13.9	22.3	922,405.1	0.00	1.00
08/03/2019 21:00	1	1.9	9.5	14.4	18.9	809,013.8	0.00	1.00
08/03/2019 22:00	1	1.9	9.5	14.3	16.9	725,379.9	0.00	1.00
08/03/2019 23:00	2	1.9	12.4	14.4	20.9	668,279.1	0.00	1.00
Average/Sum#:	2	2.0	12.9	13.9	23.5	757,505.8	0.00 #	24.00 #
Minimum:	1	1.8	9.5	11.7	16.5	636,996.3	0.00	1.00
Maximum:	3	2.7	18.0	14.5	40.6	936,534.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/04/2019 00:00	2	1.9	12.9	14.4	21.6	654,163.5	0.00	1.00
08/04/2019 01:00	2	1.9	12.8	14.4	21.1	651,003.3	0.00	1.00
08/04/2019 02:00	2	1.9	12.8	14.4	20.9	648,053.8	0.00	1.00
08/04/2019 03:00	2	1.9	12.5	14.4	20.2	643,418.8	0.00	1.00
08/04/2019 04:00	1	1.9	12.5	14.5	18.4	640,633.8	0.00	1.00
08/04/2019 05:00	2	1.8	12.6	14.4	20.4	640,047.9	0.00	1.00
08/04/2019 06:00	1	1.9	11.8	14.5	18.1	639,991.9	0.00	1.00
08/04/2019 07:00	1	1.9	12.1	14.5	19.2	643,843.4	0.00	1.00
08/04/2019 08:00	1	1.8	12.5	14.5	19.7	648,978.8	0.00	1.00
08/04/2019 09:00	1	1.8	12.5	14.5	19.9	647,481.0	0.00	1.00
08/04/2019 10:00	1	1.8	12.3	14.5	19.5	655,611.9	0.00	1.00
08/04/2019 11:00	1	1.8	11.9	14.5	19.9	708,249.2	0.00	1.00
08/04/2019 12:00	1	2.0	11.0	13.9	20.8	859,216.0	0.00	1.00
08/04/2019 13:00	2	2.4	16.2	12.5	31.5	935,610.3	0.00	1.00
08/04/2019 14:00	2	2.4	15.8	12.6	31.1	930,878.6	0.00	1.00
08/04/2019 15:00	2	2.5	16.8	12.4	34.7	933,303.0	0.00	1.00
08/04/2019 16:00	2	2.3	15.3	12.8	30.5	926,643.8	0.00	1.00
08/04/2019 17:00	2	2.4	16.4	12.5	33.1	931,371.6	0.00	1.00
08/04/2019 18:00	3	2.6	17.6	11.9	39.4	935,316.9	0.00	1.00
08/04/2019 19:00	3	2.6	17.7	11.9	39.7	940,490.2	0.00	1.00
08/04/2019 20:00	2	2.4	15.9	12.5	33.0	933,654.0	0.00	1.00
08/04/2019 21:00	1	2.1	11.5	13.8	22.7	926,000.9	0.00	1.00
08/04/2019 22:00	1	1.9	8.7	14.4	19.9	902,556.0	0.00	1.00
08/04/2019 23:00	2	1.9	12.6	14.4	21.5	673,756.8	0.00	1.00
Average/Sum#:	2	2.1	13.5	13.7	24.9	777,094.8	0.00 #	24.00 #
Minimum:	1	1.8	8.7	11.9	18.1	639,991.9	0.00	1.00
Maximum:	3	2.6	17.7	14.5	39.7	940,490.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/05/2019 00:00	1	1.8	12.1	14.5	18.4	635,712.5	0.00	1.00
08/05/2019 01:00	1	1.8	12.0	14.5	18.3	636,354.4	0.00	1.00
08/05/2019 02:00	1	1.9	11.9	14.5	18.1	636,354.4	0.00	1.00
08/05/2019 03:00	1	1.8	11.9	14.5	18.1	635,712.5	0.00	1.00
08/05/2019 04:00	1	1.8	12.6	14.5	18.6	635,284.5	0.00	1.00
08/05/2019 05:00	1	1.9	12.4	14.5	19.5	635,284.5	0.00	1.00
08/05/2019 06:00	2	1.9	12.8	14.4	21.4	650,792.6	0.00	1.00
08/05/2019 07:00	2	1.9	12.8	14.4	20.6	649,739.2	0.00	1.00
08/05/2019 08:00	1	1.9	12.8	14.5	20.8	655,825.9	0.00	1.00
08/05/2019 09:00	0	0.0	12.8	0.0	21.9	203,251.4	0.00	1.00
08/05/2019 10:00	0	0.0	12.9	0.0	21.6	203,382.5	0.00	1.00
08/05/2019 11:00	1	1.8	12.1	14.5	19.8	685,354.1	0.00	1.00
08/05/2019 12:00	1	1.7	9.3	14.6	17.4	836,653.1	0.00	1.00
08/05/2019 13:00	1	1.8	8.1	14.6	16.9	914,905.9	0.00	1.00
08/05/2019 14:00	1	1.8	8.5	14.6	16.9	907,515.4	0.00	1.00
08/05/2019 15:00	2	2.4	16.6	12.5	33.8	944,250.7	0.00	1.00
08/05/2019 16:00	2	2.5	17.1	12.3	34.9	934,074.8	0.00	1.00
08/05/2019 17:00	3	2.6	18.6	11.8	41.2	942,796.0	0.00	1.00
08/05/2019 18:00	3	2.6	18.5	11.8	41.4	942,645.5	0.00	1.00
08/05/2019 19:00	2	2.4	16.7	12.6	33.0	937,643.2	0.00	1.00
08/05/2019 20:00	1	2.0	10.4	14.4	21.8	918,146.4	0.00	1.00
08/05/2019 21:00	1	1.8	10.2	14.7	21.4	883,499.6	0.00	1.00
08/05/2019 22:00	1	1.9	12.6	14.5	21.3	701,616.0	0.00	1.00
08/05/2019 23:00	1	1.8	13.2	14.6	20.5	650,367.9	0.00	1.00
Average/Sum#:	1	2.0	12.9	14.0	23.2	771,387.7	0.00 #	24.00 #
Minimum:	1	1.7	8.1	11.8	16.9	635,284.5	0.00	1.00
Maximum:	3	2.6	18.6	14.7	41.4	944,250.7	0.00	1.00
%SI	8.33	8.33	0.00	8.33	0.00	8.33	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/06/2019 00:00	1	1.8	13.2	14.6	20.5	643,412.1	0.00	1.00
08/06/2019 01:00	1	1.8	12.9	14.6	19.5	643,629.5	0.00	1.00
08/06/2019 02:00	1	1.8	12.8	14.6	19.3	644,281.6	0.00	1.00
08/06/2019 03:00	1	1.8	12.9	14.5	20.3	642,987.5	0.00	1.00
08/06/2019 04:00	1	1.8	13.6	14.5	20.7	651,760.4	0.00	1.00
08/06/2019 05:00	2	1.9	13.3	14.4	22.2	680,919.9	0.00	1.00
08/06/2019 06:00	2	1.9	13.2	14.4	21.7	679,445.2	0.00	1.00
08/06/2019 07:00	2	1.9	13.2	14.4	22.2	679,023.8	0.00	1.00
08/06/2019 08:00	2	1.9	13.1	14.4	21.9	676,495.6	0.00	1.00
08/06/2019 09:00	1	1.8	12.9	14.6	20.3	655,584.8	0.00	1.00
08/06/2019 10:00	1	1.8	12.3	14.5	20.5	716,380.1	0.00	1.00
08/06/2019 11:00	1	1.8	9.0	14.6	16.5	868,823.7	0.00	1.00
08/06/2019 12:00	1	1.8	8.5	14.6	17.1	913,167.0	0.00	1.00
08/06/2019 13:00	1	2.0	10.3	14.1	23.0	911,070.0	0.00	1.00
08/06/2019 14:00	3	2.6	18.7	11.8	39.6	936,325.1	0.00	1.00
08/06/2019 15:00	3	2.6	18.2	12.0	38.6	933,208.9	0.00	1.00
08/06/2019 16:00	3	2.6	18.1	12.0	39.1	937,209.4	0.00	1.00
08/06/2019 17:00	3	2.6	19.0	11.8	42.7	939,635.8	0.00	1.00
08/06/2019 18:00	3	2.4	17.9	12.3	38.2	937,418.8	0.00	1.00
08/06/2019 19:00	1	2.1	13.0	13.7	25.2	940,908.7	0.00	1.00
08/06/2019 20:00	1	2.1	13.0	13.5	25.6	931,393.6	0.00	1.00
08/06/2019 21:00	1	1.9	9.0	14.5	20.0	913,020.9	0.00	1.00
08/06/2019 22:00	1	1.9	11.2	14.4	18.6	721,370.6	0.00	1.00
08/06/2019 23:00	1	1.8	13.0	14.6	20.7	657,106.3	0.00	1.00
Average/Sum#:	2	2.0	13.4	13.9	24.8	785,607.5	0.00 #	24.00 #
Minimum:	1	1.8	8.5	11.8	16.5	642,987.5	0.00	1.00
Maximum:	3	2.6	19.0	14.6	42.7	940,908.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/07/2019 00:00	1	1.8	12.7	14.6	19.4	644,281.6	0.00	1.00
08/07/2019 01:00	1	1.8	12.6	14.6	19.3	643,412.1	0.00	1.00
08/07/2019 02:00	1	1.8	12.5	14.5	19.0	636,140.4	0.00	1.00
08/07/2019 03:00	1	1.8	12.4	14.5	18.8	637,210.3	0.00	1.00
08/07/2019 04:00	1	1.8	13.0	14.5	19.2	641,275.8	0.00	1.00
08/07/2019 05:00	1	1.8	13.0	14.5	20.4	642,559.6	0.00	1.00
08/07/2019 06:00	2	1.9	13.4	14.4	21.7	653,742.1	0.00	1.00
08/07/2019 07:00	1	1.9	13.1	14.5	20.8	661,603.2	0.00	1.00
08/07/2019 08:00	1	1.9	13.3	14.4	21.5	671,860.7	0.00	1.00
08/07/2019 09:00	1	1.9	13.2	14.4	21.7	676,285.0	0.00	1.00
08/07/2019 10:00	1	1.9	12.9	14.4	21.3	677,338.4	0.00	1.00
08/07/2019 11:00	1	1.9	11.4	14.4	18.8	711,890.0	0.00	1.00
08/07/2019 12:00	1	1.9	9.0	14.5	17.6	834,493.0	0.00	1.00
08/07/2019 13:00	1	2.0	9.3	14.2	21.5	929,982.2	0.00	1.00
08/07/2019 14:00	2	2.3	15.2	12.9	28.9	941,821.6	0.00	1.00
08/07/2019 15:00	2	2.4	16.7	12.5	34.3	946,207.0	0.00	1.00
08/07/2019 16:00	3	2.5	17.0	12.2	36.7	939,708.5	0.00	1.00
08/07/2019 17:00	3	2.6	17.9	11.8	41.2	947,912.5	0.00	1.00
08/07/2019 18:00	2	2.5	16.2	12.3	34.7	936,941.1	0.00	1.00
08/07/2019 19:00	2	2.0	9.5	14.1	22.6	910,868.6	0.00	1.00
08/07/2019 20:00	2	1.9	9.6	14.5	22.1	798,331.6	0.00	1.00
08/07/2019 21:00	2	1.9	9.9	14.5	20.6	752,113.5	0.00	1.00
08/07/2019 22:00	1	1.8	12.0	14.5	19.3	639,136.0	0.00	1.00
08/07/2019 23:00	2	1.9	12.3	14.4	22.7	708,308.4	0.00	1.00
Average/Sum#:	2	2.0	12.8	14.0	23.5	757,642.6	0.00 #	24.00 #
Minimum:	1	1.8	9.0	11.8	17.6	636,140.4	0.00	1.00
Maximum:	3	2.6	17.9	14.6	41.2	947,912.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/08/2019 00:00	2	1.8	12.7	14.5	21.5	656,895.8	0.00	1.00
08/08/2019 01:00	1	1.8	12.0	14.5	18.9	636,782.3	0.00	1.00
08/08/2019 02:00	2	1.8	12.1	14.5	19.5	637,424.3	0.00	1.00
08/08/2019 03:00	2	1.8	12.3	14.5	19.8	637,210.3	0.00	1.00
08/08/2019 04:00	1	3.1	17.9	14.7	17.2	623,750.7	0.15	1.00
08/08/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	2	2.1	13.4	14.5	19.4	638,412.7	0.15 #	5.00 #
Minimum:	1	1.8	12.0	14.5	17.2	623,750.7	0.00	0.00
Maximum:	2	3.1	17.9	14.7	21.5	656,895.8	0.15	1.00
%SI	79.17	79.17	79.17	79.17	79.17	79.17	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/09/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/10/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/11/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/12/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/13/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2019 06:00	0	24.7	30.8	17.7	0.0	683,428.4	0.25	0.25
08/13/2019 07:00	1	4.3	12.9	14.5	17.6	935,274.1	0.65	1.00
08/13/2019 08:00	1	1.9	9.8	14.5	24.3	939,125.6	0.00	1.00
08/13/2019 09:00	1	1.9	10.9	14.4	21.5	823,761.4	0.00	1.00
08/13/2019 10:00	1	1.9	9.7	14.5	20.3	809,458.2	0.00	1.00
08/13/2019 11:00	1	1.8	8.9	14.5	21.1	911,309.1	0.00	1.00
08/13/2019 12:00	1	1.9	9.5	14.5	19.8	810,100.1	0.00	1.00
08/13/2019 13:00	1	1.9	9.4	14.5	19.8	798,545.6	0.00	1.00
08/13/2019 14:00	1	1.8	9.3	14.5	19.7	815,235.5	0.00	1.00
08/13/2019 15:00	3	2.5	18.4	12.0	41.9	953,365.6	0.00	1.00
08/13/2019 16:00	3	2.6	19.5	11.7	43.5	940,288.5	0.00	1.00
08/13/2019 17:00	3	2.6	20.0	11.7	44.5	945,200.5	0.00	1.00
08/13/2019 18:00	2	2.4	17.2	12.6	33.8	936,818.3	0.00	1.00
08/13/2019 19:00	3	2.6	19.6	11.9	42.4	948,402.5	0.00	1.00
08/13/2019 20:00	3	2.5	19.0	12.1	40.1	949,104.5	0.00	1.00
08/13/2019 21:00	2	2.3	16.8	12.8	32.7	945,071.9	0.00	1.00
08/13/2019 22:00	1	2.1	13.0	13.8	25.0	936,802.0	0.00	1.00
08/13/2019 23:00	2	2.3	16.4	12.7	33.9	944,234.8	0.00	1.00
Average/Sum#:	2	3.6	15.1	13.6	27.9	890,307.0	0.90 #	17.25 #
Minimum:	1	1.8	8.9	11.7	0.0	683,428.4	0.00	0.00
Maximum:	3	24.7	30.8	17.7	44.5	953,365.6	0.65	1.00
%SI	29.17	25.00	25.00	25.00	25.00	25.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/14/2019 00:00	2	2.2	14.2	13.3	28.7	941,299.1	0.00	1.00
08/14/2019 01:00	1	2.1	13.5	13.5	27.0	943,052.3	0.00	1.00
08/14/2019 02:00	1	2.0	12.2	13.9	25.4	937,664.4	0.00	1.00
08/14/2019 03:00	2	2.0	12.6	13.9	27.7	948,228.6	0.00	1.00
08/14/2019 04:00	2	2.5	18.8	12.3	38.4	957,482.4	0.00	1.00
08/14/2019 05:00	3	2.5	18.9	12.2	40.6	957,337.8	0.00	1.00
08/14/2019 06:00	3	2.5	18.4	12.1	40.8	939,611.9	0.00	1.00
08/14/2019 07:00	1	2.0	12.7	14.4	20.5	770,459.2	0.00	1.00
08/14/2019 08:00	1	1.8	13.7	14.6	20.6	658,193.2	0.00	1.00
08/14/2019 09:00	1	1.8	13.8	14.6	19.8	648,411.6	0.00	1.00
08/14/2019 10:00	1	1.8	13.2	14.6	19.7	649,715.8	0.00	1.00
08/14/2019 11:00	1	1.8	12.7	14.6	18.7	653,193.7	0.00	1.00
08/14/2019 12:00	1	1.8	12.1	14.7	18.1	673,447.6	0.00	1.00
08/14/2019 13:00	1	1.8	8.7	14.5	18.7	906,815.7	0.00	1.00
08/14/2019 14:00	1	1.9	9.8	14.2	21.9	917,309.9	0.00	1.00
08/14/2019 15:00	3	2.5	18.8	12.0	39.5	946,133.8	0.00	1.00
08/14/2019 16:00	3	2.6	19.1	11.9	42.3	944,598.5	0.00	1.00
08/14/2019 17:00	3	2.6	19.1	11.9	43.1	943,989.9	0.00	1.00
08/14/2019 18:00	2	2.3	16.0	13.0	32.1	936,062.2	0.00	1.00
08/14/2019 19:00	2	2.5	18.8	12.3	38.8	946,972.9	0.00	1.00
08/14/2019 20:00	2	2.3	15.4	13.2	29.6	883,367.7	0.00	1.00
08/14/2019 21:00	1	1.7	9.9	14.6	21.8	854,912.1	0.00	1.00
08/14/2019 22:00	1	1.7	9.7	14.6	21.4	856,868.4	0.00	1.00
08/14/2019 23:00	1	1.7	12.8	14.6	19.6	648,628.9	0.00	1.00
Average/Sum#:	2	2.1	14.4	13.6	28.1	852,656.6	0.00 #	24.00 #
Minimum:	1	1.7	8.7	11.9	18.1	648,411.6	0.00	1.00
Maximum:	3	2.6	19.1	14.7	43.1	957,482.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/15/2019 00:00	1	1.7	12.9	14.6	20.0	649,498.4	0.00	1.00
08/15/2019 01:00	1	1.7	12.8	14.6	19.8	648,194.2	0.00	1.00
08/15/2019 02:00	1	1.7	12.5	14.6	19.2	647,759.5	0.00	1.00
08/15/2019 03:00	1	1.7	12.6	14.6	19.3	646,890.0	0.00	1.00
08/15/2019 04:00	1	1.7	12.8	14.6	18.8	648,628.9	0.00	1.00
08/15/2019 05:00	1	1.9	12.5	14.5	18.9	637,424.3	0.00	1.00
08/15/2019 06:00	1	1.9	12.1	14.5	21.9	765,593.8	0.00	1.00
08/15/2019 07:00	1	1.8	12.0	14.5	21.2	768,803.4	0.00	1.00
08/15/2019 08:00	1	1.8	11.6	14.6	21.9	820,133.0	0.00	1.00
08/15/2019 09:00	1	1.8	9.2	14.7	18.7	848,159.6	0.00	1.00
08/15/2019 10:00	1	1.8	10.2	14.6	17.7	797,526.7	0.00	1.00
08/15/2019 11:00	1	1.8	9.7	14.6	16.7	778,832.9	0.00	1.00
08/15/2019 12:00	1	1.8	8.9	14.6	17.3	887,517.4	0.00	1.00
08/15/2019 13:00	1	1.9	9.2	14.5	19.5	892,693.5	0.00	1.00
08/15/2019 14:00	3	2.5	18.3	12.0	38.3	943,518.0	0.00	1.00
08/15/2019 15:00	3	2.6	18.7	11.8	40.8	934,519.3	0.00	1.00
08/15/2019 16:00	3	2.6	18.7	11.8	41.3	931,208.6	0.00	1.00
08/15/2019 17:00	3	2.6	18.5	11.8	40.7	930,456.2	0.00	1.00
08/15/2019 18:00	3	2.5	17.6	12.0	36.9	922,284.2	0.00	1.00
08/15/2019 19:00	2	2.3	15.0	12.9	28.4	918,199.0	0.00	1.00
08/15/2019 20:00	1	2.2	12.6	13.5	23.9	911,407.4	0.00	1.00
08/15/2019 21:00	1	2.0	10.7	14.1	21.2	907,243.7	0.00	1.00
08/15/2019 22:00	1	1.9	9.4	14.3	19.9	887,221.0	0.00	1.00
08/15/2019 23:00	1	1.8	12.6	14.5	19.0	645,983.2	0.00	1.00
Average/Sum#:	1	2.0	13.0	13.9	24.2	807,070.7	0.00 #	24.00 #
Minimum:	1	1.7	8.9	11.8	16.7	637,424.3	0.00	1.00
Maximum:	3	2.6	18.7	14.7	41.3	943,518.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/16/2019 00:00	1	1.8	12.6	14.6	18.6	648,846.3	0.00	1.00
08/16/2019 01:00	1	1.8	12.8	14.6	19.4	646,672.6	0.00	1.00
08/16/2019 02:00	1	1.8	13.0	14.6	19.5	645,368.4	0.00	1.00
08/16/2019 03:00	1	1.8	12.8	14.6	19.4	644,716.3	0.00	1.00
08/16/2019 04:00	1	1.8	13.1	14.6	19.1	644,933.7	0.00	1.00
08/16/2019 05:00	1	1.9	12.5	14.5	19.1	634,000.7	0.00	1.00
08/16/2019 06:00	1	1.8	12.6	14.5	19.9	645,127.3	0.00	1.00
08/16/2019 07:00	1	1.8	12.9	14.5	21.6	708,249.2	0.00	1.00
08/16/2019 08:00	1	1.8	12.6	14.5	20.2	710,602.9	0.00	1.00
08/16/2019 09:00	1	1.8	11.5	14.5	19.7	747,834.1	0.00	1.00
08/16/2019 10:00	1	1.8	9.0	14.6	17.8	905,776.4	0.00	1.00
08/16/2019 11:00	1	1.8	9.7	14.5	18.2	839,200.4	0.00	1.00
08/16/2019 12:00	1	2.1	12.3	13.6	23.7	892,377.0	0.00	1.00
08/16/2019 13:00	2	2.3	14.8	13.0	27.9	930,341.9	0.00	1.00
08/16/2019 14:00	2	2.5	17.3	12.3	33.2	928,183.1	0.00	1.00
08/16/2019 15:00	3	2.6	18.3	11.7	38.6	918,407.4	0.00	1.00
08/16/2019 16:00	2	2.3	15.5	12.8	28.7	918,866.9	0.00	1.00
08/16/2019 17:00	2	2.5	17.1	12.4	33.3	925,247.6	0.00	1.00
08/16/2019 18:00	2	2.3	14.8	13.0	27.9	922,888.0	0.00	1.00
08/16/2019 19:00	2	2.3	15.8	12.8	30.4	929,687.0	0.00	1.00
08/16/2019 20:00	2	2.4	17.0	12.4	32.7	926,214.2	0.00	1.00
08/16/2019 21:00	1	2.2	14.0	13.2	26.7	918,225.7	0.00	1.00
08/16/2019 22:00	2	2.2	14.1	13.3	27.8	934,452.0	0.00	1.00
08/16/2019 23:00	3	2.5	18.5	12.0	41.9	949,980.5	0.00	1.00
Average/Sum#:	2	2.1	13.9	13.6	25.2	813,175.0	0.00 #	24.00 #
Minimum:	1	1.8	9.0	11.7	17.8	634,000.7	0.00	1.00
Maximum:	3	2.6	18.5	14.6	41.9	949,980.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/17/2019 00:00	2	2.5	18.2	12.3	36.5	944,743.6	0.00	1.00
08/17/2019 01:00	1	2.2	14.9	13.2	27.8	945,080.7	0.00	1.00
08/17/2019 02:00	1	1.9	10.4	14.4	19.6	855,784.9	0.00	1.00
08/17/2019 03:00	1	1.9	11.2	14.4	20.0	792,580.7	0.00	1.00
08/17/2019 04:00	1	1.9	12.0	14.4	20.0	776,569.0	0.00	1.00
08/17/2019 05:00	1	1.9	11.9	14.4	20.5	766,667.0	0.00	1.00
08/17/2019 06:00	1	1.9	12.2	14.3	20.8	715,213.0	0.00	1.00
08/17/2019 07:00	1	1.9	11.5	14.4	20.0	781,414.6	0.00	1.00
08/17/2019 08:00	1	1.9	11.3	14.4	19.8	785,838.9	0.00	1.00
08/17/2019 09:00	1	1.9	10.6	14.4	19.6	786,049.6	0.00	1.00
08/17/2019 10:00	1	1.9	10.1	14.4	19.3	791,316.6	0.00	1.00
08/17/2019 11:00	1	1.8	11.0	14.5	20.8	796,833.8	0.00	1.00
08/17/2019 12:00	1	1.9	12.8	14.5	21.1	693,271.1	0.00	1.00
08/17/2019 13:00	1	1.8	12.6	14.5	20.0	686,851.9	0.00	1.00
08/17/2019 14:00	1	1.9	10.0	14.4	16.3	733,590.1	0.00	1.00
08/17/2019 15:00	1	1.9	9.9	14.4	17.6	742,860.1	0.00	1.00
08/17/2019 16:00	1	2.0	11.8	14.0	23.7	898,858.4	0.00	1.00
08/17/2019 17:00	3	2.6	19.4	11.8	42.3	943,849.4	0.00	1.00
08/17/2019 18:00	3	2.6	19.1	11.8	41.1	938,281.4	0.00	1.00
08/17/2019 19:00	2	2.3	16.3	12.9	31.9	951,065.2	0.00	1.00
08/17/2019 20:00	1	2.2	14.6	13.3	28.3	944,722.6	0.00	1.00
08/17/2019 21:00	2	2.2	14.4	13.3	29.6	947,785.8	0.00	1.00
08/17/2019 22:00	1	2.1	13.2	13.7	24.7	897,163.2	0.05	1.00
08/17/2019 23:00	0	13.4	40.8	15.9	0.0	489,980.0	0.10	0.10
Average/Sum#:	1	2.5	14.2	13.9	23.4	816,932.2	0.15 #	23.10 #
Minimum:	1	1.8	9.9	11.8	0.0	489,980.0	0.00	0.10
Maximum:	3	13.4	40.8	15.9	42.3	951,065.2	0.10	1.00
%SI	4.17	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/18/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/19/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/20/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/21/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/22/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/23/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/24/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/25/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/26/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/27/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/27/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/27/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/27/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/27/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/27/2019 05:00	0	25.3	33.3	17.7	0.0	684,284.2	0.27	0.27
08/27/2019 06:00	2	5.6	16.1	14.4	15.9	690,189.9	0.75	1.00
08/27/2019 07:00	1	1.9	14.9	14.4	24.0	687,240.4	0.00	1.00
08/27/2019 08:00	1	1.9	14.5	14.5	23.7	694,982.9	0.00	1.00
08/27/2019 09:00	1	1.8	14.0	14.5	23.6	696,480.7	0.00	1.00
08/27/2019 10:00	1	1.8	12.8	14.5	21.0	711,030.8	0.00	1.00
08/27/2019 11:00	1	1.8	12.5	14.6	20.1	716,448.1	0.00	1.00
08/27/2019 12:00	1	1.8	10.3	14.7	17.3	798,904.5	0.00	1.00
08/27/2019 13:00	1	2.2	14.0	13.4	27.1	931,391.2	0.00	1.00
08/27/2019 14:00	2	2.2	14.4	13.2	28.5	927,829.5	0.00	1.00
08/27/2019 15:00	3	2.6	19.0	11.8	41.1	937,830.0	0.00	1.00
08/27/2019 16:00	3	2.6	18.7	11.8	41.2	932,713.4	0.00	1.00
08/27/2019 17:00	3	2.6	18.2	12.0	39.4	935,516.9	0.00	1.00
08/27/2019 18:00	3	2.5	18.5	12.1	39.4	940,078.7	0.00	1.00
08/27/2019 19:00	3	2.5	18.3	12.1	39.0	937,588.9	0.00	1.00
08/27/2019 20:00	2	2.5	18.0	12.3	37.1	940,921.9	0.00	1.00
08/27/2019 21:00	1	1.9	10.2	14.4	21.6	909,719.2	0.00	1.00
08/27/2019 22:00	1	1.9	11.9	14.4	20.1	764,981.5	0.00	1.00
08/27/2019 23:00	2	1.9	13.5	14.3	21.8	667,698.1	0.00	1.00
Average/Sum#:	2	3.5	16.0	13.7	26.4	816,096.4	1.02 #	18.27 #
Minimum:	1	1.8	10.2	11.8	0.0	667,698.1	0.00	0.00
Maximum:	3	25.3	33.3	17.7	41.2	940,921.9	0.75	1.00
%SI	25.00	20.83	20.83	20.83	20.83	20.83	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/28/2019 00:00	1	1.9	13.6	14.4	21.4	668,911.1	0.00	1.00
08/28/2019 01:00	1	1.9	12.9	14.4	19.4	644,893.5	0.00	1.00
08/28/2019 02:00	1	1.8	13.5	14.5	21.3	648,764.8	0.00	1.00
08/28/2019 03:00	1	1.8	13.4	14.5	20.6	644,271.4	0.00	1.00
08/28/2019 04:00	1	1.8	14.5	14.4	23.0	672,703.4	0.00	1.00
08/28/2019 05:00	2	1.9	14.3	14.4	23.6	679,866.5	0.00	1.00
08/28/2019 06:00	1	1.9	12.8	14.4	22.1	747,073.7	0.00	1.00
08/28/2019 07:00	3	2.5	18.3	12.2	40.4	974,652.4	0.00	1.00
08/28/2019 08:00	3	2.6	18.8	11.9	42.9	956,162.5	0.00	1.00
08/28/2019 09:00	3	2.6	18.8	11.9	42.7	956,466.9	0.00	1.00
08/28/2019 10:00	3	2.6	18.8	11.8	42.8	951,072.8	0.00	1.00
08/28/2019 11:00	3	2.6	18.9	11.7	43.6	948,624.1	0.00	1.00
08/28/2019 12:00	3	2.6	19.0	11.7	43.3	948,177.5	0.00	1.00
08/28/2019 13:00	3	2.6	18.9	11.8	42.2	948,815.5	0.00	1.00
08/28/2019 14:00	3	2.6	18.8	11.8	42.1	943,548.4	0.00	1.00
08/28/2019 15:00	3	2.6	18.7	11.8	41.4	940,237.8	0.00	1.00
08/28/2019 16:00	3	2.6	18.7	11.8	41.5	940,689.2	0.00	1.00
08/28/2019 17:00	3	2.6	18.6	11.8	40.9	937,529.0	0.00	1.00
08/28/2019 18:00	3	2.6	18.4	11.9	40.1	937,447.1	0.00	1.00
08/28/2019 19:00	2	2.4	17.1	12.6	33.0	935,333.4	0.00	1.00
08/28/2019 20:00	1	2.1	12.6	13.7	24.9	924,551.7	0.00	1.00
08/28/2019 21:00	1	1.9	11.5	14.4	20.4	781,203.9	0.00	1.00
08/28/2019 22:00	1	1.9	12.4	14.3	20.5	701,933.7	0.00	1.00
08/28/2019 23:00	1	1.9	12.1	14.5	17.7	651,974.4	0.00	1.00
Average/Sum#:	2	2.3	16.1	13.0	32.2	836,871.0	0.00 #	24.00 #
Minimum:	1	1.8	11.5	11.7	17.7	644,271.4	0.00	1.00
Maximum:	3	2.6	19.0	14.5	43.6	974,652.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/29/2019 00:00	2	1.9	13.3	14.4	21.6	669,121.8	0.00	1.00
08/29/2019 01:00	1	1.8	12.1	14.5	17.2	640,419.9	0.00	1.00
08/29/2019 02:00	1	1.8	12.2	14.5	17.9	639,350.0	0.00	1.00
08/29/2019 03:00	1	1.9	12.4	14.5	18.5	640,847.8	0.00	1.00
08/29/2019 04:00	1	1.8	13.4	14.4	20.4	649,949.9	0.00	1.00
08/29/2019 05:00	1	1.9	12.5	14.5	18.0	640,847.8	0.00	1.00
08/29/2019 06:00	2	1.9	13.1	14.4	20.9	658,166.4	0.00	1.00
08/29/2019 07:00	2	1.9	13.2	14.4	21.2	662,380.0	0.00	1.00
08/29/2019 08:00	1	1.9	12.8	14.4	21.4	706,623.0	0.00	1.00
08/29/2019 09:00	1	1.8	11.6	14.5	21.5	798,759.6	0.00	1.00
08/29/2019 10:00	1	1.9	9.0	14.5	18.6	897,186.9	0.00	1.00
08/29/2019 11:00	1	2.0	12.6	13.7	25.4	935,392.9	0.00	1.00
08/29/2019 12:00	1	2.2	14.5	13.2	27.7	947,392.7	0.00	1.00
08/29/2019 13:00	1	2.2	13.9	13.3	27.6	936,974.6	0.00	1.00
08/29/2019 14:00	2	2.3	15.8	12.9	29.6	937,884.5	0.00	1.00
08/29/2019 15:00	2	2.3	16.2	12.8	30.6	935,097.1	0.00	1.00
08/29/2019 16:00	2	2.3	16.4	12.8	31.2	938,309.3	0.00	1.00
08/29/2019 17:00	2	2.3	16.5	12.8	31.6	940,845.3	0.00	1.00
08/29/2019 18:00	2	2.4	17.0	12.7	32.8	945,904.8	0.00	1.00
08/29/2019 19:00	2	2.3	15.1	13.1	30.2	946,658.5	0.00	1.00
08/29/2019 20:00	1	1.9	9.5	14.5	21.9	931,422.6	0.00	1.00
08/29/2019 21:00	1	1.9	11.7	14.5	22.0	833,209.1	0.00	1.00
08/29/2019 22:00	1	2.0	13.4	14.3	19.7	679,110.0	0.08	1.00
08/29/2019 23:00	0	13.4	39.8	16.2	0.0	431,514.4	0.10	0.10
Average/Sum#:	1	2.5	14.5	14.0	22.8	789,307.0	0.18 #	23.10 #
Minimum:	1	1.8	9.0	12.7	0.0	431,514.4	0.00	0.10
Maximum:	2	13.4	39.8	16.2	32.8	947,392.7	0.10	1.00
%SI	4.17	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/30/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/31/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/01/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/02/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/03/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/04/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/04/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/04/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/04/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/04/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/04/2019 05:00	0	23.3	31.7	17.9	0.0	682,886.3	0.27	0.27
09/04/2019 06:00	1	4.4	13.5	14.5	18.9	938,911.6	0.62	1.00
09/04/2019 07:00	1	1.8	13.2	14.5	26.2	869,798.5	0.00	1.00
09/04/2019 08:00	1	1.9	13.4	14.5	23.5	774,366.7	0.00	1.00
09/04/2019 09:00	1	1.8	12.7	14.6	25.5	841,000.5	0.00	1.00
09/04/2019 10:00	1	1.8	10.7	14.5	21.0	882,850.8	0.00	1.00
09/04/2019 11:00	2	2.2	15.4	13.1	31.0	943,322.7	0.00	1.00
09/04/2019 12:00	2	2.3	16.3	13.0	31.6	947,329.7	0.00	1.00
09/04/2019 13:00	2	2.4	17.4	12.7	33.8	946,071.8	0.00	1.00
09/04/2019 14:00	3	2.6	19.4	11.8	42.5	947,461.1	0.00	1.00
09/04/2019 15:00	3	2.6	19.7	11.8	44.3	948,665.0	0.00	1.00
09/04/2019 16:00	3	2.6	19.7	11.8	44.6	938,883.4	0.00	1.00
09/04/2019 17:00	1	1.9	11.8	14.4	20.7	841,669.3	0.00	1.00
09/04/2019 18:00	1	1.8	12.1	14.5	22.1	829,785.6	0.00	1.00
09/04/2019 19:00	1	1.8	11.8	14.5	22.1	852,252.7	0.00	1.00
09/04/2019 20:00	2	2.2	15.1	13.3	30.4	951,749.9	0.00	1.00
09/04/2019 21:00	2	1.9	13.7	14.5	23.5	717,877.9	0.00	1.00
09/04/2019 22:00	1	1.8	14.0	14.5	22.1	668,878.2	0.00	1.00
09/04/2019 23:00	1	1.8	12.0	14.6	21.9	846,434.7	0.00	1.00
Average/Sum#:	2	3.3	15.5	13.9	26.6	861,589.3	0.89 #	18.27 #
Minimum:	1	1.8	10.7	11.8	0.0	668,878.2	0.00	0.00
Maximum:	3	23.3	31.7	17.9	44.6	951,749.9	0.62	1.00
%SI	25.00	20.83	20.83	20.83	20.83	20.83	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/05/2019 00:00	1	1.8	12.7	14.5	21.8	761,956.3	0.00	1.00
09/05/2019 01:00	1	1.9	13.5	14.4	21.9	691,664.7	0.00	1.00
09/05/2019 02:00	1	1.8	13.4	14.6	19.7	649,933.2	0.00	1.00
09/05/2019 03:00	1	1.8	13.6	14.6	20.5	653,193.7	0.00	1.00
09/05/2019 04:00	1	1.8	15.0	14.4	23.9	676,074.3	0.00	1.00
09/05/2019 05:00	1	1.8	14.0	14.5	21.0	650,262.6	0.00	1.00
09/05/2019 06:00	2	1.9	14.2	14.4	22.6	666,383.0	0.00	1.00
09/05/2019 07:00	1	1.9	13.5	14.4	23.0	719,685.2	0.00	1.00
09/05/2019 08:00	1	1.9	12.3	14.5	21.4	802,825.0	0.00	1.00
09/05/2019 09:00	1	1.9	10.2	14.3	23.1	934,113.4	0.00	1.00
09/05/2019 10:00	1	2.0	12.6	13.8	25.4	944,902.8	0.00	1.00
09/05/2019 11:00	1	2.1	13.6	13.4	27.1	943,442.1	0.00	1.00
09/05/2019 12:00	2	2.2	14.9	13.1	30.3	950,521.0	0.00	1.00
09/05/2019 13:00	3	2.6	18.8	11.8	44.5	959,650.5	0.00	1.00
09/05/2019 14:00	4	2.6	19.0	11.8	46.1	957,543.7	0.00	1.00
09/05/2019 15:00	4	2.6	18.8	11.8	45.6	955,888.3	0.00	1.00
09/05/2019 16:00	2	2.3	16.8	12.8	35.0	953,187.0	0.00	1.00
09/05/2019 17:00	2	2.3	16.7	12.8	34.1	945,748.1	0.00	1.00
09/05/2019 18:00	2	2.1	13.0	13.6	27.3	941,338.6	0.00	1.00
09/05/2019 19:00	1	1.9	8.7	14.6	20.2	899,690.1	0.00	1.00
09/05/2019 20:00	1	1.8	11.7	14.6	24.3	829,914.7	0.00	1.00
09/05/2019 21:00	1	1.8	9.2	14.6	22.1	879,474.8	0.00	1.00
09/05/2019 22:00	1	2.0	12.8	14.6	22.8	810,134.1	0.07	1.00
09/05/2019 23:00	0	14.7	42.5	16.2	0.0	461,525.2	0.07	0.07
Average/Sum#:	2	2.6	15.1	13.9	26.0	818,293.9	0.14 #	23.07 #
Minimum:	1	1.8	8.7	11.8	0.0	461,525.2	0.00	0.07
Maximum:	4	14.7	42.5	16.2	46.1	959,650.5	0.07	1.00
%SI	4.17	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/06/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/07/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/08/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/09/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/10/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/10/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/10/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/10/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/10/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/10/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/10/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/10/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/10/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/10/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/10/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/10/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/10/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/10/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/10/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/10/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/10/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/10/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/10/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/10/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/10/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/10/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/10/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/10/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/11/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/11/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/11/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/11/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/11/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/11/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/11/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/11/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/11/2019 08:00	0	24.1	30.9	18.0	0.0	694,628.7	0.25	0.25
09/11/2019 09:00	2	5.4	14.5	14.4	13.4	667,647.1	0.73	1.00
09/11/2019 10:00	1	1.8	12.2	14.5	25.4	842,196.0	0.00	1.00
09/11/2019 11:00	2	1.9	9.9	14.3	25.5	941,583.0	0.00	1.00
09/11/2019 12:00	3	2.3	15.9	12.8	38.7	961,471.2	0.00	1.00
09/11/2019 13:00	1	1.9	12.4	14.3	20.1	723,927.5	0.00	1.00
09/11/2019 14:00	3	2.4	16.9	12.6	40.7	962,061.9	0.00	1.00
09/11/2019 15:00	1	1.9	12.6	14.4	19.6	713,996.8	0.00	1.00
09/11/2019 16:00	1	2.0	12.2	14.0	27.0	947,284.4	0.00	1.00
09/11/2019 17:00	1	2.0	12.4	14.0	26.8	942,719.7	0.00	1.00
09/11/2019 18:00	2	1.9	10.7	14.4	23.7	843,354.7	0.00	1.00
09/11/2019 19:00	2	1.9	12.4	14.4	21.7	697,563.7	0.00	1.00
09/11/2019 20:00	2	2.1	13.7	13.4	31.0	934,130.0	0.00	1.00
09/11/2019 21:00	1	1.9	11.7	14.4	22.6	786,471.0	0.00	1.00
09/11/2019 22:00	2	1.9	11.7	14.4	22.8	783,942.8	0.00	1.00
09/11/2019 23:00	2	1.9	11.9	14.4	23.4	783,521.4	0.00	1.00
Average/Sum#:	2	3.6	13.9	14.3	23.9	826,656.2	0.98 #	15.25 #
Minimum:	1	1.8	9.9	12.6	0.0	667,647.1	0.00	0.00
Maximum:	3	24.1	30.9	18.0	40.7	962,061.9	0.73	1.00
%SI	37.50	33.33	33.33	33.33	33.33	33.33	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/12/2019 00:00	2	1.9	12.2	14.4	22.7	740,963.9	0.00	1.00
09/12/2019 01:00	2	1.9	12.8	14.4	21.5	659,219.8	0.00	1.00
09/12/2019 02:00	2	1.9	12.9	14.4	21.6	659,009.1	0.00	1.00
09/12/2019 03:00	2	1.9	12.9	14.4	21.5	658,166.4	0.00	1.00
09/12/2019 04:00	2	1.8	13.4	14.4	21.7	657,113.0	0.00	1.00
09/12/2019 05:00	2	1.9	13.3	14.4	22.7	662,590.7	0.00	1.00
09/12/2019 06:00	2	1.9	13.2	14.4	22.9	665,750.9	0.00	1.00
09/12/2019 07:00	2	1.9	12.6	14.4	22.7	693,560.8	0.00	1.00
09/12/2019 08:00	2	2.3	16.5	12.8	37.7	966,543.1	0.00	1.00
09/12/2019 09:00	1	1.9	11.7	14.4	19.8	724,530.8	0.00	1.00
09/12/2019 10:00	2	1.9	9.6	14.3	24.7	935,150.9	0.00	1.00
09/12/2019 11:00	2	2.6	12.0	14.4	18.6	753,604.8	0.15	1.00
09/12/2019 12:00	0	14.2	31.9	17.1	0.0	397,133.1	0.05	0.05
09/12/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/12/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/12/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/12/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/12/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/12/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/12/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/12/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/12/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/12/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/12/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	2	2.9	14.2	14.5	21.4	705,641.3	0.20 #	12.05 #
Minimum:	1	1.8	9.6	12.8	0.0	397,133.1	0.00	0.00
Maximum:	2	14.2	31.9	17.1	37.7	966,543.1	0.15	1.00
%SI	50.00	45.83	45.83	45.83	45.83	45.83	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/13/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/14/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/15/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/16/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/17/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/18/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/19/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/20/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/21/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/22/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/23/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/24/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2019 07:00	0	0.8	2.4	20.8	0.0	1,081,845.3	0.08	0.08
09/24/2019 08:00	3	11.0	20.0	15.0	11.7	716,278.6	0.92	1.00
09/24/2019 09:00	1	1.8	13.0	14.6	25.1	799,265.6	0.00	1.00
09/24/2019 10:00	1	1.8	12.3	14.7	25.2	873,781.1	0.00	1.00
09/24/2019 11:00	1	1.8	11.3	14.7	24.1	855,669.4	0.00	1.00
09/24/2019 12:00	2	1.9	9.6	14.3	23.4	907,762.4	0.00	1.00
09/24/2019 13:00	1	2.0	12.9	13.8	27.0	931,594.3	0.00	1.00
09/24/2019 14:00	1	1.9	11.9	14.2	25.2	932,230.5	0.00	1.00
09/24/2019 15:00	2	2.0	12.7	13.9	27.8	935,708.1	0.00	1.00
09/24/2019 16:00	3	2.6	19.1	11.7	44.0	942,074.7	0.00	1.00
09/24/2019 17:00	4	2.7	18.9	11.7	45.0	940,735.0	0.00	1.00
09/24/2019 18:00	2	2.4	17.2	12.4	36.8	930,080.8	0.00	1.00
09/24/2019 19:00	1	2.1	12.3	13.8	24.6	912,885.3	0.00	1.00
09/24/2019 20:00	1	1.9	10.7	14.5	23.1	835,348.9	0.00	1.00
09/24/2019 21:00	2	1.9	9.3	14.3	23.1	922,079.1	0.00	1.00
09/24/2019 22:00	2	1.9	11.3	14.5	24.5	822,082.6	0.00	1.00
09/24/2019 23:00	2	1.8	12.5	14.5	20.5	652,616.3	0.00	1.00
Average/Sum#:	2	2.5	12.8	14.3	25.4	881,884.6	1.00 #	16.08 #
Minimum:	1	0.8	2.4	11.7	0.0	652,616.3	0.00	0.00
Maximum:	4	11.0	20.0	20.8	45.0	1,081,845.3	0.92	1.00
%SI	33.33	29.17	29.17	29.17	29.17	29.17	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/25/2019 00:00	1	1.8	12.2	14.5	19.5	636,354.4	0.00	1.00
09/25/2019 01:00	2	1.8	12.2	14.5	19.5	635,712.5	0.00	1.00
09/25/2019 02:00	2	1.8	12.3	14.5	20.0	634,428.6	0.00	1.00
09/25/2019 03:00	2	1.8	12.0	14.5	19.4	635,070.6	0.00	1.00
09/25/2019 04:00	1	1.8	12.7	14.5	20.0	636,140.4	0.00	1.00
09/25/2019 05:00	2	1.9	12.5	14.5	20.7	635,284.5	0.00	1.00
09/25/2019 06:00	2	1.8	12.5	14.5	20.7	637,852.2	0.00	1.00
09/25/2019 07:00	2	1.8	12.6	14.5	21.3	644,913.3	0.00	1.00
09/25/2019 08:00	2	1.8	12.8	14.6	21.4	647,759.5	0.00	1.00
09/25/2019 09:00	2	1.8	12.8	14.6	21.4	660,801.6	0.00	1.00
09/25/2019 10:00	1	1.8	12.1	14.5	21.8	740,131.1	0.00	1.00
09/25/2019 11:00	1	1.8	9.2	14.5	20.4	874,505.9	0.00	1.00
09/25/2019 12:00	2	2.4	17.5	12.3	36.6	941,558.9	0.00	1.00
09/25/2019 13:00	3	2.6	18.0	11.8	41.0	936,776.6	0.00	1.00
09/25/2019 14:00	3	2.5	16.8	12.2	36.6	928,690.1	0.00	1.00
09/25/2019 15:00	3	2.5	16.8	12.3	36.2	935,189.5	0.00	1.00
09/25/2019 16:00	3	2.6	17.5	11.9	39.8	926,339.5	0.00	1.00
09/25/2019 17:00	3	2.6	17.2	11.9	38.9	922,839.9	0.00	1.00
09/25/2019 18:00	1	1.9	8.9	14.3	18.9	879,751.4	0.00	1.00
09/25/2019 19:00	2	2.3	15.9	12.8	32.6	934,589.9	0.00	1.00
09/25/2019 20:00	2	2.3	16.5	12.8	32.2	920,895.6	0.00	1.00
09/25/2019 21:00	1	1.9	9.7	14.4	19.5	777,201.0	0.00	1.00
09/25/2019 22:00	2	1.9	11.5	14.4	19.6	669,543.2	0.00	1.00
09/25/2019 23:00	1	1.8	12.6	14.6	20.2	643,846.8	0.00	1.00
Average/Sum#:	2	2.0	13.5	13.7	25.8	768,174.0	0.00 #	24.00 #
Minimum:	1	1.8	8.9	11.8	18.9	634,428.6	0.00	1.00
Maximum:	3	2.6	18.0	14.6	41.0	941,558.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/26/2019 00:00	1	1.8	12.6	14.6	20.1	644,498.9	0.00	1.00
09/26/2019 01:00	1	1.8	12.2	14.5	19.3	636,140.4	0.00	1.00
09/26/2019 02:00	2	1.8	12.1	14.5	19.3	635,070.6	0.00	1.00
09/26/2019 03:00	2	1.8	12.1	14.5	19.5	636,354.4	0.00	1.00
09/26/2019 04:00	1	1.8	12.6	14.5	19.3	637,424.3	0.00	1.00
09/26/2019 05:00	1	1.8	12.2	14.5	19.7	639,136.0	0.00	1.00
09/26/2019 06:00	2	1.9	12.1	14.5	19.5	638,494.1	0.00	1.00
09/26/2019 07:00	2	1.8	12.6	14.5	20.7	645,983.2	0.00	1.00
09/26/2019 08:00	2	1.9	12.8	14.5	21.7	666,310.6	0.00	1.00
09/26/2019 09:00	1	1.8	10.1	14.6	20.7	798,613.5	0.00	1.00
09/26/2019 10:00	2	2.0	10.0	14.1	23.3	929,597.5	0.00	1.00
09/26/2019 11:00	1	2.1	13.1	13.6	25.4	932,896.9	0.00	1.00
09/26/2019 12:00	1	2.2	13.8	13.3	27.3	929,406.7	0.00	1.00
09/26/2019 13:00	1	2.2	13.8	13.3	27.1	930,848.2	0.00	1.00
09/26/2019 14:00	3	2.5	17.4	12.2	37.4	947,893.5	0.00	1.00
09/26/2019 15:00	2	2.5	16.6	12.4	34.6	936,525.2	0.00	1.00
09/26/2019 16:00	3	2.6	17.9	11.9	39.7	933,491.0	0.00	1.00
09/26/2019 17:00	2	2.3	15.2	12.9	30.2	932,064.5	0.00	1.00
09/26/2019 18:00	2	2.1	12.5	13.5	26.2	920,290.2	0.00	1.00
09/26/2019 19:00	1	1.9	8.5	14.5	21.4	917,728.3	0.00	1.00
09/26/2019 20:00	2	1.9	10.1	14.4	20.5	746,863.0	0.00	1.00
09/26/2019 21:00	2	1.9	12.8	14.4	21.6	673,124.8	0.00	1.00
09/26/2019 22:00	1	2.7	14.6	14.6	16.1	629,935.2	0.12	1.00
09/26/2019 23:00	0	13.8	31.8	17.1	0.0	400,376.4	0.02	0.02
Average/Sum#:	2	2.5	13.7	14.1	22.9	764,127.8	0.14 #	23.02 #
Minimum:	1	1.8	8.5	11.9	0.0	400,376.4	0.00	0.02
Maximum:	3	13.8	31.8	17.1	39.7	947,893.5	0.12	1.00
%SI	4.17	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/27/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/28/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/29/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/30/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2019 06:00	0	23.6	30.2	17.9	0.0	688,820.5	0.27	0.27
09/30/2019 07:00	2	4.6	13.7	14.5	22.0	920,082.0	0.62	1.00
09/30/2019 08:00	2	1.8	12.6	14.6	30.4	942,077.0	0.00	1.00
09/30/2019 09:00	2	1.8	12.5	14.6	31.9	971,856.6	0.00	1.00
09/30/2019 10:00	2	1.8	12.4	14.6	32.4	965,335.5	0.00	1.00
09/30/2019 11:00	2	2.3	15.7	14.5	25.4	752,755.5	0.12	1.00
09/30/2019 12:00	0	14.8	39.4	16.8	0.0	380,432.8	0.07	0.07
09/30/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	2	7.2	19.5	15.4	20.3	803,051.4	1.08 #	5.34 #
Minimum:	2	1.8	12.4	14.5	0.0	380,432.8	0.00	0.00
Maximum:	2	23.6	39.4	17.9	32.4	971,856.6	0.62	1.00
%SI	79.17	70.83	70.83	70.83	70.83	70.83	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/01/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/02/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/03/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/04/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/05/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/06/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/07/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/08/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/09/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/10/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/11/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/12/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/13/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/14/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/15/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/16/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/17/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/18/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/19/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/20/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/21/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/22/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2019 12:00	0	2.3	5.2	20.2	0.0	719,926.0	0.08	0.08
07/22/2019 13:00	2	11.4	17.9	14.9	10.5	712,100.7	0.83	1.00
07/22/2019 14:00	1	1.8	13.3	14.5	26.4	975,928.8	0.00	1.00
07/22/2019 15:00	0	1.9	12.5	14.4	19.9	852,414.0	0.00	1.00
07/22/2019 16:00	0	1.9	11.7	14.4	18.0	795,319.5	0.00	1.00
07/22/2019 17:00	1	1.9	11.7	14.4	18.3	794,687.5	0.00	1.00
07/22/2019 18:00	1	1.9	11.7	14.4	18.9	809,856.5	0.00	1.00
07/22/2019 19:00	1	1.9	12.4	14.4	19.3	780,361.2	0.00	1.00
07/22/2019 20:00	1	1.9	12.2	14.3	18.7	765,425.2	0.00	1.00
07/22/2019 21:00	1	1.9	12.8	14.3	19.8	751,938.5	0.00	1.00
07/22/2019 22:00	1	1.9	12.6	14.3	19.3	762,105.4	0.00	1.00
07/22/2019 23:00	1	1.9	12.5	14.3	19.3	763,557.8	0.00	1.00
Average/Sum#:	1	2.7	12.2	14.9	17.4	790,301.8	0.91 #	11.08 #
Minimum:	0	1.8	5.2	14.3	0.0	712,100.7	0.00	0.00
Maximum:	2	11.4	17.9	20.2	26.4	975,928.8	0.83	1.00
%SI	54.17	50.00	50.00	50.00	50.00	50.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/23/2019 00:00	1	1.9	12.5	14.3	19.4	763,765.3	0.00	1.00
07/23/2019 01:00	1	1.9	12.6	14.3	19.5	764,180.3	0.00	1.00
07/23/2019 02:00	1	1.9	12.6	14.3	19.7	764,595.3	0.00	1.00
07/23/2019 03:00	1	1.9	12.7	14.3	19.9	765,217.7	0.00	1.00
07/23/2019 04:00	1	1.9	13.1	14.3	20.1	765,632.7	0.00	1.00
07/23/2019 05:00	1	1.9	12.9	14.3	20.1	765,632.7	0.00	1.00
07/23/2019 06:00	1	1.9	12.8	14.3	20.6	783,684.2	0.00	1.00
07/23/2019 07:00	1	1.9	11.6	14.4	19.3	837,666.4	0.00	1.00
07/23/2019 08:00	1	1.9	11.8	14.5	21.9	900,610.5	0.00	1.00
07/23/2019 09:00	1	1.7	12.7	14.5	28.8	996,256.2	0.00	1.00
07/23/2019 10:00	0	1.9	13.1	14.6	24.6	999,897.2	0.00	1.00
07/23/2019 11:00	1	1.9	13.8	14.5	23.8	953,033.8	0.07	1.00
07/23/2019 12:00	0	14.2	37.3	16.3	0.0	478,703.1	0.08	0.08
07/23/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	1	2.8	14.6	14.5	19.8	810,682.7	0.15 #	12.08 #
Minimum:	0	1.7	11.6	14.3	0.0	478,703.1	0.00	0.00
Maximum:	1	14.2	37.3	16.3	28.8	999,897.2	0.08	1.00
%SI	50.00	45.83	45.83	45.83	45.83	45.83	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/24/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/25/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/26/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/27/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2019 22:00	0	25.0	29.9	17.7	0.0	721,087.5	0.25	0.25
07/27/2019 23:00	0	5.5	12.9	14.3	12.9	788,456.5	0.57	1.00
Average/Sum#:	0	15.3	21.4	16.0	6.5	754,772.0	0.82 #	1.25 #
Minimum:	0	5.5	12.9	14.3	0.0	721,087.5	0.00	0.00
Maximum:	0	25.0	29.9	17.7	12.9	788,456.5	0.57	1.00
%SI	95.83	91.67	91.67	91.67	91.67	91.67	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/28/2019 00:00	1	1.9	12.1	14.4	19.1	816,598.3	0.00	1.00
07/28/2019 01:00	1	1.8	13.4	14.3	19.7	745,091.4	0.00	1.00
07/28/2019 02:00	1	1.8	13.3	14.4	18.9	709,572.5	0.00	1.00
07/28/2019 03:00	1	1.9	13.3	14.3	19.1	712,723.1	0.00	1.00
07/28/2019 04:00	1	1.9	13.9	14.3	20.0	721,022.7	0.00	1.00
07/28/2019 05:00	1	1.9	13.9	14.3	19.9	727,869.8	0.00	1.00
07/28/2019 06:00	1	1.9	13.5	14.3	19.7	733,057.0	0.00	1.00
07/28/2019 07:00	1	1.9	12.3	14.3	18.1	780,364.4	0.00	1.00
07/28/2019 08:00	1	1.9	11.8	14.3	17.6	782,439.3	0.00	1.00
07/28/2019 09:00	1	1.9	11.1	14.4	17.2	814,702.2	0.00	1.00
07/28/2019 10:00	1	1.9	12.5	14.5	25.9	978,496.5	0.00	1.00
07/28/2019 11:00	1	1.9	12.6	14.4	25.5	961,968.0	0.00	1.00
07/28/2019 12:00	2	2.3	16.8	12.8	34.1	994,776.9	0.00	1.00
07/28/2019 13:00	3	2.6	18.1	12.0	42.5	986,293.3	0.00	1.00
07/28/2019 14:00	3	2.6	18.6	11.8	45.5	983,276.8	0.00	1.00
07/28/2019 15:00	3	2.6	18.5	11.9	45.9	992,224.0	0.00	1.00
07/28/2019 16:00	3	2.6	18.6	11.9	46.3	991,463.3	0.00	1.00
07/28/2019 17:00	3	2.6	18.3	11.9	44.9	986,594.2	0.00	1.00
07/28/2019 18:00	3	2.6	18.3	12.0	44.5	991,986.4	0.00	1.00
07/28/2019 19:00	2	2.2	15.6	13.2	32.2	985,452.0	0.00	1.00
07/28/2019 20:00	3	2.6	18.2	12.0	43.5	994,294.4	0.00	1.00
07/28/2019 21:00	3	2.5	18.1	12.2	41.8	996,059.5	0.00	1.00
07/28/2019 22:00	2	2.2	15.8	13.2	32.8	991,321.0	0.00	1.00
07/28/2019 23:00	1	1.9	12.9	14.4	26.9	984,510.8	0.00	1.00
Average/Sum#:	2	2.2	15.1	13.4	30.1	890,089.9	0.00 #	24.00 #
Minimum:	1	1.8	11.1	11.8	17.2	709,572.5	0.00	1.00
Maximum:	3	2.6	18.6	14.5	46.3	996,059.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/29/2019 00:00	1	1.9	12.1	14.5	22.7	949,396.2	0.00	1.00
07/29/2019 01:00	1	1.9	12.1	14.5	23.1	938,697.6	0.00	1.00
07/29/2019 02:00	1	1.9	12.2	14.4	23.0	906,769.6	0.00	1.00
07/29/2019 03:00	1	1.9	12.1	14.4	22.1	899,185.1	0.00	1.00
07/29/2019 04:00	1	1.9	12.4	14.4	22.0	888,651.1	0.00	1.00
07/29/2019 05:00	1	1.9	12.7	14.5	26.6	986,199.5	0.00	1.00
07/29/2019 06:00	1	2.1	15.2	13.6	31.9	1,023,879.2	0.00	1.00
07/29/2019 07:00	2	2.2	16.5	13.1	34.0	1,009,511.6	0.00	1.00
07/29/2019 08:00	1	1.9	12.3	14.5	24.8	959,880.9	0.00	1.00
07/29/2019 09:00	1	1.9	12.1	14.5	23.5	946,186.7	0.00	1.00
07/29/2019 10:00	2	2.1	15.5	13.3	32.7	1,009,049.5	0.00	1.00
07/29/2019 11:00	2	2.4	17.4	12.7	37.6	1,007,194.9	0.00	1.00
07/29/2019 12:00	1	1.9	12.9	14.5	27.6	993,902.5	0.00	1.00
07/29/2019 13:00	3	2.4	17.6	12.3	41.5	1,004,775.3	0.00	1.00
07/29/2019 14:00	3	2.6	18.4	11.8	46.0	995,466.2	0.00	1.00
07/29/2019 15:00	3	2.6	18.0	11.8	45.2	993,058.4	0.00	1.00
07/29/2019 16:00	3	2.5	17.8	12.1	41.9	996,411.9	0.00	1.00
07/29/2019 17:00	3	2.5	17.9	12.1	41.8	994,855.7	0.00	1.00
07/29/2019 18:00	3	2.5	18.1	12.2	41.7	996,216.9	0.00	1.00
07/29/2019 19:00	2	2.2	15.5	13.2	32.9	996,834.2	0.00	1.00
07/29/2019 20:00	2	2.4	17.9	12.5	40.0	1,014,026.2	0.00	1.00
07/29/2019 21:00	2	2.3	16.8	13.0	36.1	1,016,667.6	0.00	1.00
07/29/2019 22:00	1	1.9	13.0	14.3	27.1	965,236.7	0.00	1.00
07/29/2019 23:00	1	1.9	13.0	14.4	19.1	712,732.7	0.00	1.00
Average/Sum#:	2	2.2	15.0	13.4	31.9	966,866.1	0.00 #	24.00 #
Minimum:	1	1.9	12.1	11.8	19.1	712,732.7	0.00	1.00
Maximum:	3	2.6	18.4	14.5	46.0	1,023,879.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/30/2019 00:00	1	1.9	13.5	14.5	21.4	704,611.6	0.00	1.00
07/30/2019 01:00	1	1.9	13.8	14.5	22.0	712,528.6	0.00	1.00
07/30/2019 02:00	1	1.9	13.8	14.5	22.0	711,458.8	0.00	1.00
07/30/2019 03:00	1	1.9	13.7	14.5	21.6	711,458.8	0.00	1.00
07/30/2019 04:00	1	1.8	14.0	14.4	21.7	701,566.6	0.00	1.00
07/30/2019 05:00	1	1.9	12.6	14.4	20.2	811,542.0	0.00	1.00
07/30/2019 06:00	1	1.9	12.2	14.4	20.9	846,304.3	0.00	1.00
07/30/2019 07:00	1	1.8	12.6	14.5	24.6	934,418.2	0.00	1.00
07/30/2019 08:00	1	1.8	12.7	14.5	25.0	946,614.6	0.00	1.00
07/30/2019 09:00	1	1.8	12.6	14.5	24.2	923,077.6	0.00	1.00
07/30/2019 10:00	1	1.8	12.6	14.6	24.9	944,685.5	0.00	1.00
07/30/2019 11:00	1	1.8	12.4	14.6	23.3	915,992.8	0.00	1.00
07/30/2019 12:00	1	1.8	12.3	14.6	23.1	901,646.4	0.00	1.00
07/30/2019 13:00	1	1.9	13.0	14.5	19.6	721,515.5	0.00	1.00
07/30/2019 14:00	1	1.9	13.0	14.5	20.4	746,764.2	0.00	1.00
07/30/2019 15:00	1	1.8	12.7	14.5	20.3	764,951.9	0.00	1.00
07/30/2019 16:00	1	1.8	12.5	14.6	25.4	998,158.2	0.00	1.00
07/30/2019 17:00	1	1.9	12.6	14.4	26.4	982,614.7	0.00	1.00
07/30/2019 18:00	1	1.9	11.7	14.4	20.1	864,422.8	0.00	1.00
07/30/2019 19:00	1	1.9	11.4	14.4	18.2	817,862.4	0.00	1.00
07/30/2019 20:00	1	1.9	11.6	14.4	20.6	859,155.8	0.00	1.00
07/30/2019 21:00	1	1.9	11.6	14.4	19.2	829,660.5	0.00	1.00
07/30/2019 22:00	1	1.9	11.7	14.4	20.2	848,200.4	0.00	1.00
07/30/2019 23:00	1	1.9	13.7	14.3	21.8	736,999.3	0.00	1.00
Average/Sum#:	1	1.9	12.7	14.5	22.0	830,675.5	0.00 #	24.00 #
Minimum:	1	1.8	11.4	14.3	18.2	701,566.6	0.00	1.00
Maximum:	1	1.9	14.0	14.6	26.4	998,158.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/31/2019 00:00	1	1.9	13.7	14.4	21.8	716,314.3	0.00	1.00
07/31/2019 01:00	1	1.9	13.2	14.5	20.3	703,113.8	0.00	1.00
07/31/2019 02:00	1	1.9	13.2	14.5	20.4	702,471.9	0.00	1.00
07/31/2019 03:00	1	1.9	13.2	14.5	20.7	704,611.6	0.00	1.00
07/31/2019 04:00	1	1.8	13.5	14.5	20.1	701,830.0	0.00	1.00
07/31/2019 05:00	1	1.8	14.0	14.5	22.0	693,485.1	0.00	1.00
07/31/2019 06:00	1	1.8	13.7	14.5	20.6	703,755.7	0.00	1.00
07/31/2019 07:00	1	1.9	13.8	14.4	21.4	731,272.6	0.00	1.00
07/31/2019 08:00	1	1.9	13.1	14.4	19.8	762,664.0	0.00	1.00
07/31/2019 09:00	1	1.9	13.4	14.5	21.2	733,070.0	0.00	1.00
07/31/2019 10:00	1	1.8	13.5	14.6	21.2	704,927.5	0.00	1.00
07/31/2019 11:00	1	1.8	13.5	14.6	21.6	704,275.4	0.00	1.00
07/31/2019 12:00	1	1.8	11.9	14.6	19.8	851,651.5	0.00	1.00
07/31/2019 13:00	1	1.8	12.3	14.6	22.9	934,251.7	0.00	1.00
07/31/2019 14:00	2	2.3	17.1	12.6	36.2	1,004,299.5	0.00	1.00
07/31/2019 15:00	2	2.4	17.0	12.7	36.3	994,335.7	0.00	1.00
07/31/2019 16:00	2	2.3	16.8	12.9	34.7	1,000,364.5	0.00	1.00
07/31/2019 17:00	2	2.3	16.8	13.0	34.8	1,002,973.4	0.00	1.00
07/31/2019 18:00	2	2.3	16.7	13.0	34.6	1,004,186.8	0.00	1.00
07/31/2019 19:00	2	2.3	16.9	12.9	35.1	1,006,355.7	0.00	1.00
07/31/2019 20:00	1	1.9	12.2	14.4	22.6	924,256.1	0.00	1.00
07/31/2019 21:00	1	1.9	11.5	14.4	19.5	873,692.8	0.00	1.00
07/31/2019 22:00	1	1.9	12.8	14.4	18.9	720,738.6	0.00	1.00
07/31/2019 23:00	1	1.9	13.1	14.5	19.7	710,174.9	0.00	1.00
Average/Sum#:	1	2.0	14.0	14.1	24.4	816,211.4	0.00 #	24.00 #
Minimum:	1	1.8	11.5	12.6	18.9	693,485.1	0.00	1.00
Maximum:	2	2.4	17.1	14.6	36.3	1,006,355.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/01/2019 00:00	1	1.9	13.4	14.5	20.5	708,891.1	0.00	1.00
08/01/2019 01:00	1	1.9	13.6	14.5	20.8	710,602.9	0.00	1.00
08/01/2019 02:00	1	1.9	13.6	14.5	21.0	715,096.3	0.00	1.00
08/01/2019 03:00	1	1.9	13.6	14.5	20.8	717,450.0	0.00	1.00
08/01/2019 04:00	1	1.8	14.0	14.4	20.9	711,047.3	0.00	1.00
08/01/2019 05:00	1	1.9	13.9	14.4	21.2	717,789.1	0.00	1.00
08/01/2019 06:00	1	1.9	13.8	14.4	21.1	722,634.7	0.00	1.00
08/01/2019 07:00	1	1.9	13.8	14.3	20.9	729,529.7	0.00	1.00
08/01/2019 08:00	1	1.9	13.5	14.4	20.6	739,278.5	0.00	1.00
08/01/2019 09:00	1	1.9	12.9	14.4	19.3	763,928.1	0.00	1.00
08/01/2019 10:00	1	1.8	13.6	14.4	19.9	748,759.1	0.00	1.00
08/01/2019 11:00	1	1.9	13.5	14.4	19.4	759,714.5	0.00	1.00
08/01/2019 12:00	1	1.8	12.7	14.6	24.1	992,071.9	0.00	1.00
08/01/2019 13:00	1	1.8	12.8	14.5	25.2	993,474.6	0.00	1.00
08/01/2019 14:00	1	1.9	12.5	14.5	23.9	990,051.0	0.00	1.00
08/01/2019 15:00	1	1.8	12.3	14.5	24.2	989,409.1	0.00	1.00
08/01/2019 16:00	1	2.0	13.5	13.9	26.8	992,050.2	0.00	1.00
08/01/2019 17:00	1	2.1	13.7	13.7	27.7	989,409.1	0.00	1.00
08/01/2019 18:00	2	2.3	16.4	12.8	33.1	996,805.7	0.00	1.00
08/01/2019 19:00	1	1.9	12.4	14.5	25.0	995,186.4	0.00	1.00
08/01/2019 20:00	0	1.9	12.4	14.5	16.6	724,725.1	0.00	1.00
08/01/2019 21:00	1	1.9	13.1	14.5	19.2	702,257.9	0.00	1.00
08/01/2019 22:00	1	1.9	13.3	14.5	19.5	704,825.6	0.00	1.00
08/01/2019 23:00	1	1.8	13.0	14.5	18.6	701,188.1	0.00	1.00
Average/Sum#:	1	1.9	13.4	14.3	22.1	813,174.0	0.00 #	24.00 #
Minimum:	0	1.8	12.3	12.8	16.6	701,188.1	0.00	1.00
Maximum:	2	2.3	16.4	14.6	33.1	996,805.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/02/2019 00:00	1	1.9	12.9	14.5	18.5	700,332.2	0.00	1.00
08/02/2019 01:00	1	1.8	12.9	14.5	18.5	701,830.0	0.00	1.00
08/02/2019 02:00	1	1.9	12.9	14.5	18.6	704,397.7	0.00	1.00
08/02/2019 03:00	1	1.9	13.0	14.5	18.8	704,825.6	0.00	1.00
08/02/2019 04:00	1	1.8	13.5	14.5	19.0	707,393.3	0.00	1.00
08/02/2019 05:00	1	1.9	13.4	14.5	19.4	708,891.1	0.00	1.00
08/02/2019 06:00	1	1.9	13.2	14.5	18.9	707,179.3	0.00	1.00
08/02/2019 07:00	1	1.9	13.3	14.5	19.6	706,965.3	0.00	1.00
08/02/2019 08:00	1	1.9	13.5	14.5	19.9	708,249.2	0.00	1.00
08/02/2019 09:00	1	1.9	13.6	14.5	20.5	708,891.1	0.00	1.00
08/02/2019 10:00	1	1.8	13.7	14.5	20.4	706,323.4	0.00	1.00
08/02/2019 11:00	1	1.8	13.6	14.6	20.5	719,926.0	0.00	1.00
08/02/2019 12:00	0	1.9	12.8	14.5	18.8	784,209.4	0.00	1.00
08/02/2019 13:00	1	1.9	13.3	14.2	25.7	962,684.9	0.00	1.00
08/02/2019 14:00	1	1.9	13.0	14.1	25.1	983,971.7	0.00	1.00
08/02/2019 15:00	2	2.4	17.5	12.4	37.5	1,001,774.2	0.00	1.00
08/02/2019 16:00	2	2.5	18.1	12.3	39.1	999,042.9	0.00	1.00
08/02/2019 17:00	3	2.5	18.2	12.2	40.0	998,263.2	0.00	1.00
08/02/2019 18:00	1	2.2	15.4	13.2	29.8	990,965.3	0.00	1.00
08/02/2019 19:00	1	2.0	12.7	14.1	25.1	971,687.2	0.00	1.00
08/02/2019 20:00	0	1.9	12.1	14.3	17.3	794,681.1	0.00	1.00
08/02/2019 21:00	1	1.9	12.9	14.4	19.2	709,361.8	0.00	1.00
08/02/2019 22:00	1	1.9	13.3	14.5	19.3	718,947.8	0.00	1.00
08/02/2019 23:00	1	1.9	13.4	14.4	19.7	718,631.8	0.00	1.00
Average/Sum#:	1	2.0	13.8	14.1	22.9	796,642.7	0.00 #	24.00 #
Minimum:	0	1.8	12.1	12.2	17.3	700,332.2	0.00	1.00
Maximum:	3	2.5	18.2	14.6	40.0	1,001,774.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/03/2019 00:00	1	1.9	13.5	14.4	19.9	720,527.9	0.00	1.00
08/03/2019 01:00	1	1.8	13.3	14.5	19.1	698,192.5	0.00	1.00
08/03/2019 02:00	1	1.8	13.1	14.5	18.9	696,694.7	0.00	1.00
08/03/2019 03:00	1	1.8	13.0	14.5	18.8	696,908.6	0.00	1.00
08/03/2019 04:00	1	1.8	13.3	14.5	18.4	696,266.7	0.00	1.00
08/03/2019 05:00	1	1.9	13.1	14.5	18.4	695,838.8	0.00	1.00
08/03/2019 06:00	1	1.9	13.1	14.5	18.7	696,052.7	0.00	1.00
08/03/2019 07:00	1	1.9	13.7	14.5	20.5	722,157.4	0.00	1.00
08/03/2019 08:00	1	1.9	13.7	14.5	20.5	723,013.3	0.00	1.00
08/03/2019 09:00	1	1.8	13.6	14.5	20.4	728,362.6	0.00	1.00
08/03/2019 10:00	1	1.9	12.9	14.5	18.4	749,759.9	0.00	1.00
08/03/2019 11:00	0	1.8	12.3	14.5	17.9	771,799.0	0.00	1.00
08/03/2019 12:00	0	1.8	11.8	14.6	18.6	829,697.3	0.00	1.00
08/03/2019 13:00	1	2.0	13.2	14.0	25.4	983,207.0	0.00	1.00
08/03/2019 14:00	1	2.1	14.2	13.5	27.9	993,017.7	0.00	1.00
08/03/2019 15:00	3	2.6	17.8	11.8	41.9	987,640.9	0.00	1.00
08/03/2019 16:00	3	2.6	18.1	11.9	43.5	993,745.6	0.00	1.00
08/03/2019 17:00	3	2.5	18.2	12.2	40.0	995,429.9	0.00	1.00
08/03/2019 18:00	3	2.6	18.0	12.0	42.3	996,756.3	0.00	1.00
08/03/2019 19:00	2	2.4	17.4	12.6	35.9	991,925.2	0.00	1.00
08/03/2019 20:00	1	2.1	13.7	13.9	26.7	989,115.7	0.00	1.00
08/03/2019 21:00	1	1.9	11.7	14.4	19.2	870,953.9	0.00	1.00
08/03/2019 22:00	0	1.9	11.8	14.3	16.8	777,874.5	0.00	1.00
08/03/2019 23:00	1	1.9	13.0	14.4	19.4	716,525.0	0.00	1.00
Average/Sum#:	1	2.0	14.1	13.9	24.5	821,727.6	0.00 #	24.00 #
Minimum:	0	1.8	11.7	11.8	16.8	695,838.8	0.00	1.00
Maximum:	3	2.6	18.2	14.6	43.5	996,756.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/04/2019 00:00	1	1.9	13.5	14.5	20.3	718,947.8	0.00	1.00
08/04/2019 01:00	1	1.9	13.6	14.4	20.5	710,625.9	0.00	1.00
08/04/2019 02:00	1	1.9	13.7	14.4	20.5	713,364.8	0.00	1.00
08/04/2019 03:00	1	1.9	13.7	14.4	20.5	716,946.3	0.00	1.00
08/04/2019 04:00	1	1.9	14.0	14.4	20.4	711,890.0	0.00	1.00
08/04/2019 05:00	1	1.9	14.0	14.4	20.5	725,794.9	0.00	1.00
08/04/2019 06:00	1	1.9	13.5	14.5	19.6	707,821.2	0.00	1.00
08/04/2019 07:00	1	1.9	13.6	14.5	19.9	712,528.6	0.00	1.00
08/04/2019 08:00	1	1.9	13.5	14.5	19.9	724,511.1	0.00	1.00
08/04/2019 09:00	1	1.9	13.4	14.5	19.9	726,650.8	0.00	1.00
08/04/2019 10:00	1	1.8	13.2	14.5	19.1	729,860.4	0.00	1.00
08/04/2019 11:00	0	1.9	12.5	14.5	18.2	782,283.7	0.00	1.00
08/04/2019 12:00	1	2.0	13.7	13.9	26.3	928,665.4	0.00	1.00
08/04/2019 13:00	2	2.4	17.1	12.6	35.0	1,000,009.8	0.00	1.00
08/04/2019 14:00	2	2.4	16.9	12.7	35.0	997,174.8	0.00	1.00
08/04/2019 15:00	2	2.4	17.6	12.5	37.7	998,049.5	0.00	1.00
08/04/2019 16:00	2	2.3	16.5	12.9	33.9	996,769.8	0.00	1.00
08/04/2019 17:00	2	2.4	17.2	12.6	36.3	997,369.9	0.00	1.00
08/04/2019 18:00	3	2.6	17.7	12.0	41.7	996,294.7	0.00	1.00
08/04/2019 19:00	3	2.6	17.8	12.0	42.3	1,002,757.2	0.00	1.00
08/04/2019 20:00	2	2.4	17.0	12.6	35.5	1,002,814.6	0.00	1.00
08/04/2019 21:00	1	2.1	13.7	13.8	27.0	999,872.7	0.00	1.00
08/04/2019 22:00	1	1.9	12.2	14.5	24.0	997,968.0	0.00	1.00
08/04/2019 23:00	1	1.9	13.2	14.4	19.0	727,480.4	0.00	1.00
Average/Sum#:	1	2.1	14.7	13.8	26.4	846,935.5	0.00 #	24.00 #
Minimum:	0	1.8	12.2	12.0	18.2	707,821.2	0.00	1.00
Maximum:	3	2.6	17.8	14.5	42.3	1,002,814.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/05/2019 00:00	1	1.9	12.8	14.6	18.0	696,015.4	0.00	1.00
08/05/2019 01:00	1	1.8	13.3	14.5	19.4	685,996.0	0.00	1.00
08/05/2019 02:00	1	1.8	13.7	14.5	19.8	686,424.0	0.00	1.00
08/05/2019 03:00	1	1.8	14.0	14.5	20.5	686,637.9	0.00	1.00
08/05/2019 04:00	1	1.8	14.6	14.5	20.8	686,637.9	0.00	1.00
08/05/2019 05:00	1	1.9	14.6	14.5	21.4	686,851.9	0.00	1.00
08/05/2019 06:00	1	1.9	13.8	14.4	20.3	707,887.1	0.00	1.00
08/05/2019 07:00	1	1.9	13.8	14.4	20.4	711,679.3	0.00	1.00
08/05/2019 08:00	1	1.9	13.7	14.4	20.3	715,471.6	0.00	1.00
08/05/2019 09:00	1	1.9	13.5	14.4	19.8	727,691.0	0.00	1.00
08/05/2019 10:00	1	1.9	13.4	14.4	19.8	733,168.7	0.00	1.00
08/05/2019 11:00	1	1.9	12.7	14.5	18.8	771,799.0	0.00	1.00
08/05/2019 12:00	1	1.8	12.8	14.7	24.4	952,633.4	0.00	1.00
08/05/2019 13:00	0	0.0	11.6	0.0	21.2	298,718.0	0.00	1.00
08/05/2019 14:00	0	0.0	11.5	0.0	21.2	298,062.8	0.00	1.00
08/05/2019 15:00	2	2.2	17.0	12.5	37.3	996,419.3	0.00	1.00
08/05/2019 16:00	2	2.5	17.4	12.4	37.7	996,941.0	0.00	1.00
08/05/2019 17:00	3	2.6	18.2	11.9	43.9	1,003,027.3	0.00	1.00
08/05/2019 18:00	3	2.6	18.1	11.8	44.0	992,757.4	0.00	1.00
08/05/2019 19:00	2	2.4	17.2	12.6	36.6	996,215.0	0.00	1.00
08/05/2019 20:00	1	1.9	13.3	14.3	26.7	977,063.5	0.00	1.00
08/05/2019 21:00	1	1.8	12.9	14.6	24.5	942,294.4	0.00	1.00
08/05/2019 22:00	1	1.9	13.4	14.4	19.4	746,652.3	0.00	1.00
08/05/2019 23:00	1	1.8	13.6	14.6	20.2	701,667.0	0.00	1.00
Average/Sum#:	1	2.0	14.2	14.0	24.9	809,178.7	0.00 #	24.00 #
Minimum:	1	1.8	11.5	11.8	18.0	685,996.0	0.00	1.00
Maximum:	3	2.6	18.2	14.7	44.0	1,003,027.3	0.00	1.00
%SI	8.33	8.33	0.00	8.33	0.00	8.33	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/06/2019 00:00	1	1.8	13.4	14.6	19.6	692,102.7	0.00	1.00
08/06/2019 01:00	1	1.8	13.2	14.6	19.3	692,102.7	0.00	1.00
08/06/2019 02:00	1	1.8	13.0	14.6	18.9	693,189.6	0.00	1.00
08/06/2019 03:00	1	1.8	13.4	14.5	20.3	693,271.1	0.00	1.00
08/06/2019 04:00	1	1.8	14.0	14.5	20.6	702,899.9	0.00	1.00
08/06/2019 05:00	1	1.9	14.1	14.4	21.2	737,171.7	0.00	1.00
08/06/2019 06:00	1	1.9	14.0	14.4	21.8	738,857.1	0.00	1.00
08/06/2019 07:00	1	1.9	13.9	14.4	20.5	739,910.5	0.00	1.00
08/06/2019 08:00	1	1.9	13.4	14.4	19.8	742,228.0	0.00	1.00
08/06/2019 09:00	1	1.8	13.8	14.6	21.7	721,447.5	0.00	1.00
08/06/2019 10:00	1	1.8	12.4	14.5	18.8	794,266.1	0.00	1.00
08/06/2019 11:00	1	1.8	12.3	14.6	22.6	931,643.3	0.00	1.00
08/06/2019 12:00	1	1.9	11.5	14.6	22.2	981,420.8	0.00	1.00
08/06/2019 13:00	1	1.9	13.1	14.1	27.6	983,568.9	0.00	1.00
08/06/2019 14:00	3	2.6	18.1	11.9	41.9	995,419.4	0.00	1.00
08/06/2019 15:00	3	2.5	17.9	12.1	41.6	994,077.6	0.00	1.00
08/06/2019 16:00	3	2.6	17.8	12.0	41.8	986,908.8	0.00	1.00
08/06/2019 17:00	3	2.6	18.3	11.9	45.0	999,832.0	0.00	1.00
08/06/2019 18:00	3	2.5	18.6	12.3	41.8	996,813.6	0.00	1.00
08/06/2019 19:00	1	2.1	14.6	13.7	29.8	1,006,717.1	0.00	1.00
08/06/2019 20:00	1	2.1	14.8	13.5	29.6	998,754.5	0.00	1.00
08/06/2019 21:00	1	1.9	12.3	14.5	25.0	990,265.0	0.00	1.00
08/06/2019 22:00	1	1.9	12.8	14.4	18.9	774,883.5	0.00	1.00
08/06/2019 23:00	1	1.8	13.3	14.6	19.9	705,362.2	0.00	1.00
Average/Sum#:	1	2.0	14.3	13.9	26.3	845,546.4	0.00 #	24.00 #
Minimum:	1	1.8	11.5	11.9	18.8	692,102.7	0.00	1.00
Maximum:	3	2.6	18.6	14.6	45.0	1,006,717.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/07/2019 00:00	1	1.8	12.8	14.6	18.7	693,189.6	0.00	1.00
08/07/2019 01:00	1	1.8	12.9	14.6	19.3	693,406.9	0.00	1.00
08/07/2019 02:00	1	1.8	13.4	14.6	20.2	696,667.5	0.00	1.00
08/07/2019 03:00	1	1.9	13.5	14.5	20.4	687,921.8	0.00	1.00
08/07/2019 04:00	1	1.8	14.0	14.5	20.7	694,554.9	0.00	1.00
08/07/2019 05:00	1	1.9	14.5	14.5	22.6	694,554.9	0.00	1.00
08/07/2019 06:00	1	1.9	14.0	14.4	21.1	709,572.5	0.00	1.00
08/07/2019 07:00	1	1.9	14.0	14.4	21.5	712,732.7	0.00	1.00
08/07/2019 08:00	1	1.9	13.4	14.4	19.7	747,916.4	0.00	1.00
08/07/2019 09:00	1	1.9	13.0	14.4	19.6	762,242.7	0.00	1.00
08/07/2019 10:00	1	1.9	12.8	14.4	19.4	766,245.6	0.00	1.00
08/07/2019 11:00	1	1.9	12.4	14.4	18.2	763,296.1	0.00	1.00
08/07/2019 12:00	1	1.9	11.3	14.5	20.1	908,741.5	0.00	1.00
08/07/2019 13:00	1	2.0	12.5	14.2	26.0	991,912.9	0.00	1.00
08/07/2019 14:00	1	2.3	16.2	12.9	31.8	995,229.2	0.00	1.00
08/07/2019 15:00	2	2.4	17.4	12.5	37.4	997,397.4	0.00	1.00
08/07/2019 16:00	2	2.5	17.7	12.3	39.2	1,002,068.3	0.00	1.00
08/07/2019 17:00	3	2.6	17.8	11.9	43.4	1,005,918.3	0.00	1.00
08/07/2019 18:00	2	2.4	17.3	12.4	37.8	1,003,546.4	0.00	1.00
08/07/2019 19:00	1	2.0	13.0	14.1	26.1	982,159.2	0.00	1.00
08/07/2019 20:00	1	1.9	12.1	14.5	20.8	861,025.6	0.00	1.00
08/07/2019 21:00	1	1.9	12.4	14.4	20.5	803,536.1	0.00	1.00
08/07/2019 22:00	1	1.8	13.5	14.6	20.7	701,014.9	0.00	1.00
08/07/2019 23:00	1	1.9	13.0	14.4	20.4	776,779.6	0.00	1.00
Average/Sum#:	1	2.0	14.0	14.0	24.4	818,818.0	0.00 #	24.00 #
Minimum:	1	1.8	11.3	11.9	18.2	687,921.8	0.00	1.00
Maximum:	3	2.6	17.8	14.6	43.4	1,005,918.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/08/2019 00:00	1	1.9	14.0	14.4	22.5	718,210.4	0.00	1.00
08/08/2019 01:00	1	1.8	14.3	14.5	22.3	688,349.7	0.00	1.00
08/08/2019 02:00	1	1.8	14.5	14.5	22.5	688,777.7	0.00	1.00
08/08/2019 03:00	1	1.8	14.7	14.5	23.0	688,991.6	0.00	1.00
08/08/2019 04:00	1	2.1	17.6	14.5	21.5	680,004.8	0.08	1.00
08/08/2019 05:00	0	14.9	37.4	16.6	0.0	474,839.9	0.07	0.07
08/08/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	1	4.1	18.8	14.8	18.6	656,529.0	0.15 #	5.07 #
Minimum:	1	1.8	14.0	14.4	0.0	474,839.9	0.00	0.00
Maximum:	1	14.9	37.4	16.6	23.0	718,210.4	0.08	1.00
%SI	79.17	75.00	75.00	75.00	75.00	75.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/09/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/10/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/11/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/12/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/13/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/14/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/14/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/14/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/14/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/14/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/14/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/14/2019 06:00	0	24.1	29.6	17.5	0.0	748,752.9	0.27	0.27
08/14/2019 07:00	1	4.8	14.9	14.4	17.4	810,488.6	0.52	1.00
08/14/2019 08:00	1	1.9	14.9	14.6	19.9	708,188.0	0.00	1.00
08/14/2019 09:00	1	1.8	14.5	14.6	20.2	702,319.1	0.00	1.00
08/14/2019 10:00	0	1.8	14.1	14.6	19.5	699,493.3	0.00	1.00
08/14/2019 11:00	0	1.8	13.4	14.7	18.3	708,566.7	0.00	1.00
08/14/2019 12:00	0	1.8	12.5	14.7	17.0	719,610.4	0.00	1.00
08/14/2019 13:00	1	1.8	13.2	14.5	24.7	977,854.6	0.00	1.00
08/14/2019 14:00	1	2.0	14.1	14.2	27.7	986,189.9	0.00	1.00
08/14/2019 15:00	3	2.5	19.5	12.0	43.6	998,602.7	0.00	1.00
08/14/2019 16:00	3	2.6	19.7	11.9	46.5	997,245.3	0.00	1.00
08/14/2019 17:00	3	2.6	19.8	12.0	46.8	1,007,373.2	0.00	1.00
08/14/2019 18:00	2	2.3	18.2	13.0	36.9	1,001,586.6	0.00	1.00
08/14/2019 19:00	2	2.5	20.0	12.3	43.2	1,006,367.7	0.00	1.00
08/14/2019 20:00	1	2.2	17.3	13.2	33.8	960,019.8	0.00	1.00
08/14/2019 21:00	1	1.7	14.1	14.6	28.1	930,773.8	0.00	1.00
08/14/2019 22:00	1	1.7	13.3	14.5	24.8	968,439.8	0.00	1.00
08/14/2019 23:00	1	1.8	13.6	14.6	18.9	704,492.8	0.00	1.00
Average/Sum#:	1	3.4	16.5	14.0	27.1	868,687.0	0.79 #	17.27 #
Minimum:	0	1.7	12.5	11.9	0.0	699,493.3	0.00	0.00
Maximum:	3	24.1	29.6	17.5	46.8	1,007,373.2	0.52	1.00
%SI	29.17	25.00	25.00	25.00	25.00	25.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/15/2019 00:00	1	1.7	13.7	14.6	19.6	697,102.2	0.00	1.00
08/15/2019 01:00	1	1.7	13.3	14.6	19.1	698,841.2	0.00	1.00
08/15/2019 02:00	1	1.7	13.3	14.6	19.3	698,189.1	0.00	1.00
08/15/2019 03:00	1	1.7	13.3	14.6	19.2	698,841.2	0.00	1.00
08/15/2019 04:00	0	1.7	13.3	14.6	18.5	698,841.2	0.00	1.00
08/15/2019 05:00	1	1.8	13.4	14.6	19.5	699,275.9	0.00	1.00
08/15/2019 06:00	1	1.8	12.5	14.5	19.7	833,209.1	0.00	1.00
08/15/2019 07:00	1	1.9	12.5	14.5	20.3	840,484.2	0.00	1.00
08/15/2019 08:00	1	1.8	12.9	14.7	24.0	924,582.3	0.00	1.00
08/15/2019 09:00	1	1.8	13.7	14.6	27.8	927,948.0	0.00	1.00
08/15/2019 10:00	0	1.6	12.7	14.7	19.7	893,218.1	0.00	1.00
08/15/2019 11:00	1	1.8	12.5	14.6	20.7	855,346.8	0.00	1.00
08/15/2019 12:00	1	1.8	12.0	14.5	21.5	927,999.0	0.00	1.00
08/15/2019 13:00	1	1.9	12.7	14.4	24.8	942,164.0	0.00	1.00
08/15/2019 14:00	3	2.5	18.9	12.0	42.7	996,140.8	0.00	1.00
08/15/2019 15:00	3	2.6	19.1	11.9	46.0	998,766.9	0.00	1.00
08/15/2019 16:00	3	2.6	19.1	11.9	46.1	997,701.7	0.00	1.00
08/15/2019 17:00	3	2.6	18.9	11.9	45.5	995,267.2	0.00	1.00
08/15/2019 18:00	3	2.5	18.5	12.1	42.7	988,475.4	0.00	1.00
08/15/2019 19:00	2	2.3	17.3	12.9	33.8	980,165.5	0.00	1.00
08/15/2019 20:00	1	2.2	15.4	13.5	30.2	980,433.8	0.00	1.00
08/15/2019 21:00	1	2.0	13.8	14.1	28.0	984,173.1	0.00	1.00
08/15/2019 22:00	1	1.9	13.2	14.3	25.9	956,937.2	0.00	1.00
08/15/2019 23:00	1	1.9	13.3	14.6	18.1	705,144.9	0.00	1.00
Average/Sum#:	1	2.0	14.6	13.9	27.2	871,635.4	0.00 #	24.00 #
Minimum:	0	1.6	12.0	11.9	18.1	697,102.2	0.00	1.00
Maximum:	3	2.6	19.1	14.7	46.1	998,766.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/16/2019 00:00	1	1.8	13.6	14.6	20.2	705,579.6	0.00	1.00
08/16/2019 01:00	1	1.8	13.8	14.6	19.9	699,928.0	0.00	1.00
08/16/2019 02:00	1	1.8	13.6	14.6	19.5	694,059.1	0.00	1.00
08/16/2019 03:00	1	1.8	13.5	14.6	19.3	694,059.1	0.00	1.00
08/16/2019 04:00	1	1.8	13.7	14.6	19.2	694,493.8	0.00	1.00
08/16/2019 05:00	1	1.8	13.2	14.6	18.8	695,363.3	0.00	1.00
08/16/2019 06:00	1	1.8	13.3	14.6	19.6	706,449.1	0.00	1.00
08/16/2019 07:00	1	1.9	13.6	14.4	19.4	754,447.5	0.00	1.00
08/16/2019 08:00	1	1.9	13.1	14.5	19.2	776,078.5	0.00	1.00
08/16/2019 09:00	1	1.9	12.4	14.6	20.5	836,218.3	0.00	1.00
08/16/2019 10:00	1	1.8	13.0	14.6	24.9	976,204.0	0.00	1.00
08/16/2019 11:00	1	1.9	12.0	14.5	20.8	902,322.3	0.00	1.00
08/16/2019 12:00	1	2.1	15.2	13.5	29.3	944,162.6	0.00	1.00
08/16/2019 13:00	2	2.3	16.7	13.0	33.5	985,292.2	0.00	1.00
08/16/2019 14:00	2	2.5	18.3	12.3	38.5	978,660.7	0.00	1.00
08/16/2019 15:00	3	2.6	18.7	11.8	44.0	976,805.9	0.00	1.00
08/16/2019 16:00	2	2.3	17.3	12.8	34.7	977,363.3	0.00	1.00
08/16/2019 17:00	2	2.4	18.2	12.4	38.4	978,252.3	0.00	1.00
08/16/2019 18:00	2	2.3	16.8	12.9	34.0	972,291.3	0.00	1.00
08/16/2019 19:00	2	2.3	17.6	12.9	35.8	1,001,049.2	0.00	1.00
08/16/2019 20:00	2	2.4	18.4	12.4	38.5	986,791.1	0.00	1.00
08/16/2019 21:00	1	2.2	16.1	13.3	32.4	996,977.0	0.00	1.00
08/16/2019 22:00	1	2.2	16.2	13.5	28.6	934,354.6	0.07	1.00
08/16/2019 23:00	0	17.5	37.5	16.1	0.0	499,269.3	0.08	0.08
Average/Sum#:	1	2.7	16.1	13.8	26.2	848,603.0	0.15 #	23.08 #
Minimum:	1	1.8	12.0	11.8	0.0	499,269.3	0.00	0.08
Maximum:	3	17.5	37.5	16.1	44.0	1,001,049.2	0.08	1.00
%SI	4.17	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/17/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/18/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/19/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/20/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/21/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/22/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/23/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/24/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/25/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2019 07:00	0	24.1	29.4	17.5	0.0	733,044.8	0.28	0.28
08/25/2019 08:00	0	5.2	15.0	14.5	21.4	986,413.5	0.50	1.00
08/25/2019 09:00	1	1.7	14.8	14.5	29.4	993,688.6	0.00	1.00
08/25/2019 10:00	1	1.8	14.3	14.5	28.4	995,614.3	0.00	1.00
08/25/2019 11:00	2	2.1	18.8	12.2	43.1	968,513.6	0.00	1.00
08/25/2019 12:00	3	2.2	19.8	11.9	48.0	999,071.2	0.00	1.00
08/25/2019 13:00	3	2.4	19.4	11.9	45.9	997,093.1	0.00	1.00
08/25/2019 14:00	3	2.5	19.2	11.9	44.5	993,289.2	0.00	1.00
08/25/2019 15:00	3	2.6	19.4	11.9	44.7	990,093.8	0.00	1.00
08/25/2019 16:00	1	2.2	15.6	13.4	28.6	977,403.8	0.00	1.00
08/25/2019 17:00	1	2.1	14.7	13.6	28.8	977,919.1	0.00	1.00
08/25/2019 18:00	1	2.1	14.8	13.6	29.5	983,359.3	0.00	1.00
08/25/2019 19:00	1	2.1	14.9	13.6	30.3	991,988.5	0.00	1.00
08/25/2019 20:00	2	2.3	18.0	12.7	37.7	982,311.5	0.00	1.00
08/25/2019 21:00	1	1.9	13.3	14.5	26.4	997,968.0	0.00	1.00
08/25/2019 22:00	1	1.8	13.2	14.5	24.5	973,147.2	0.00	1.00
08/25/2019 23:00	1	1.9	11.8	14.4	18.6	845,250.9	0.00	1.00
Average/Sum#:	2	3.6	16.8	13.6	31.2	963,892.4	0.78 #	16.28 #
Minimum:	0	1.7	11.8	11.9	0.0	733,044.8	0.00	0.00
Maximum:	3	24.1	29.4	17.5	48.0	999,071.2	0.50	1.00
%SI	33.33	29.17	29.17	29.17	29.17	29.17	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/26/2019 00:00	1	1.9	13.4	14.4	19.6	717,578.4	0.00	1.00
08/26/2019 01:00	1	1.9	13.8	14.4	20.9	710,204.6	0.00	1.00
08/26/2019 02:00	1	1.9	14.4	14.5	22.0	719,375.7	0.00	1.00
08/26/2019 03:00	1	1.9	14.5	14.5	22.3	719,161.8	0.00	1.00
08/26/2019 04:00	1	1.8	14.8	14.5	22.1	721,943.4	0.00	1.00
08/26/2019 05:00	1	1.9	14.6	14.5	22.3	733,284.0	0.00	1.00
08/26/2019 06:00	1	1.9	14.1	14.4	20.4	756,343.6	0.00	1.00
08/26/2019 07:00	1	1.9	13.5	14.4	20.0	771,301.9	0.00	1.00
08/26/2019 08:00	1	1.9	12.3	14.5	21.1	858,243.9	0.00	1.00
08/26/2019 09:00	1	1.9	13.6	14.3	28.6	975,818.6	0.00	1.00
08/26/2019 10:00	2	2.4	19.0	12.3	41.0	1,003,979.2	0.00	1.00
08/26/2019 11:00	2	2.5	19.0	12.3	41.0	1,001,431.4	0.00	1.00
08/26/2019 12:00	2	2.5	18.9	12.3	40.0	996,654.3	0.00	1.00
08/26/2019 13:00	2	2.4	17.3	12.8	34.4	989,705.0	0.00	1.00
08/26/2019 14:00	1	2.2	15.7	13.4	29.5	991,098.1	0.00	1.00
08/26/2019 15:00	1	1.9	12.2	14.5	21.8	959,666.9	0.00	1.00
08/26/2019 16:00	1	2.1	14.4	13.5	29.3	1,001,160.3	0.00	1.00
08/26/2019 17:00	1	2.1	15.1	13.5	31.0	998,754.5	0.00	1.00
08/26/2019 18:00	1	2.1	14.7	13.6	29.5	989,174.6	0.00	1.00
08/26/2019 19:00	1	2.0	13.4	14.0	25.8	937,559.5	0.00	1.00
08/26/2019 20:00	2	2.2	16.9	13.0	35.1	964,317.4	0.00	1.00
08/26/2019 21:00	1	1.9	11.9	14.4	18.7	848,832.4	0.00	1.00
08/26/2019 22:00	1	1.9	11.7	14.4	17.5	809,013.8	0.00	1.00
08/26/2019 23:00	1	1.9	11.8	14.4	19.6	851,782.0	0.00	1.00
Average/Sum#:	1	2.0	14.6	13.9	26.4	876,099.4	0.00 #	24.00 #
Minimum:	1	1.8	11.7	12.3	17.5	710,204.6	0.00	1.00
Maximum:	2	2.5	19.0	14.5	41.0	1,003,979.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/27/2019 00:00	1	1.8	13.1	14.6	25.6	937,947.0	0.00	1.00
08/27/2019 01:00	1	1.9	12.8	14.5	21.8	861,025.6	0.00	1.00
08/27/2019 02:00	1	1.8	12.8	14.5	22.1	856,960.1	0.00	1.00
08/27/2019 03:00	1	1.9	12.7	14.5	21.3	840,056.3	0.00	1.00
08/27/2019 04:00	1	1.7	13.8	14.6	26.5	940,338.1	0.00	1.00
08/27/2019 05:00	1	1.8	13.3	14.5	22.9	869,798.5	0.00	1.00
08/27/2019 06:00	1	1.8	14.0	14.5	22.5	784,423.4	0.00	1.00
08/27/2019 07:00	1	1.9	14.6	14.4	22.2	740,121.2	0.00	1.00
08/27/2019 08:00	1	1.9	14.5	14.4	22.0	736,329.0	0.00	1.00
08/27/2019 09:00	1	1.9	14.0	14.5	21.0	749,117.9	0.00	1.00
08/27/2019 10:00	1	1.9	13.2	14.5	19.6	768,803.4	0.00	1.00
08/27/2019 11:00	1	1.8	12.4	14.5	18.2	762,812.2	0.00	1.00
08/27/2019 12:00	1	1.8	12.0	14.6	21.0	867,736.8	0.00	1.00
08/27/2019 13:00	1	2.0	15.0	13.4	31.0	992,376.2	0.00	1.00
08/27/2019 14:00	1	2.1	15.7	13.2	31.5	985,452.0	0.00	1.00
08/27/2019 15:00	3	2.7	18.5	11.8	44.7	985,534.1	0.00	1.00
08/27/2019 16:00	3	2.6	18.2	11.9	44.0	988,420.1	0.00	1.00
08/27/2019 17:00	3	2.6	18.1	12.0	42.6	983,985.3	0.00	1.00
08/27/2019 18:00	3	2.5	18.6	12.2	42.7	1,001,096.4	0.00	1.00
08/27/2019 19:00	3	2.5	18.7	12.2	41.6	999,837.2	0.00	1.00
08/27/2019 20:00	2	2.5	18.8	12.4	40.8	1,010,313.0	0.00	1.00
08/27/2019 21:00	1	1.9	13.2	14.4	26.1	984,510.8	0.00	1.00
08/27/2019 22:00	0	1.9	12.1	14.4	17.9	818,494.4	0.00	1.00
08/27/2019 23:00	1	1.9	13.6	14.4	20.7	727,059.0	0.00	1.00
Average/Sum#:	1	2.0	14.7	13.8	27.9	883,022.8	0.00 #	24.00 #
Minimum:	0	1.7	12.0	11.8	17.9	727,059.0	0.00	1.00
Maximum:	3	2.7	18.8	14.6	44.7	1,010,313.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/28/2019 00:00	1	1.9	13.7	14.4	20.5	726,005.6	0.00	1.00
08/28/2019 01:00	1	1.9	13.6	14.4	20.5	712,100.7	0.00	1.00
08/28/2019 02:00	1	1.9	14.2	14.5	22.1	728,148.6	0.00	1.00
08/28/2019 03:00	1	1.9	14.3	14.4	22.0	722,845.4	0.00	1.00
08/28/2019 04:00	1	1.8	13.9	14.4	20.6	772,987.4	0.00	1.00
08/28/2019 05:00	1	1.8	13.4	14.4	20.4	787,945.7	0.00	1.00
08/28/2019 06:00	1	1.9	12.3	14.5	20.9	878,143.4	0.00	1.00
08/28/2019 07:00	3	2.4	18.0	12.2	42.0	1,028,484.9	0.00	1.00
08/28/2019 08:00	3	2.6	18.5	12.0	44.3	1,022,606.1	0.00	1.00
08/28/2019 09:00	3	2.6	18.5	12.0	44.1	1,021,529.0	0.00	1.00
08/28/2019 10:00	3	2.6	18.4	11.9	44.0	1,011,852.5	0.00	1.00
08/28/2019 11:00	3	2.6	18.3	11.8	44.4	1,006,451.7	0.00	1.00
08/28/2019 12:00	3	2.6	18.2	11.8	44.4	1,003,592.4	0.00	1.00
08/28/2019 13:00	3	2.6	18.5	11.9	45.0	1,008,961.5	0.00	1.00
08/28/2019 14:00	3	2.6	18.5	11.8	45.3	994,864.2	0.00	1.00
08/28/2019 15:00	3	2.6	18.4	11.9	44.9	1,004,548.9	0.00	1.00
08/28/2019 16:00	3	2.6	17.9	11.9	43.4	1,003,027.3	0.00	1.00
08/28/2019 17:00	3	2.6	17.9	11.9	43.4	1,003,788.1	0.00	1.00
08/28/2019 18:00	3	2.6	17.9	12.0	42.4	1,003,526.5	0.00	1.00
08/28/2019 19:00	2	2.4	17.2	12.7	35.5	1,005,691.9	0.00	1.00
08/28/2019 20:00	1	2.1	14.3	13.8	28.5	1,004,501.7	0.00	1.00
08/28/2019 21:00	1	1.9	11.8	14.4	18.9	846,304.3	0.00	1.00
08/28/2019 22:00	1	1.9	12.6	14.3	18.9	764,387.8	0.00	1.00
08/28/2019 23:00	1	1.9	12.8	14.4	18.9	703,041.4	0.00	1.00
Average/Sum#:	2	2.3	16.0	13.1	33.1	906,889.0	0.00 #	24.00 #
Minimum:	1	1.8	11.8	11.8	18.9	703,041.4	0.00	1.00
Maximum:	3	2.6	18.5	14.5	45.3	1,028,484.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/29/2019 00:00	1	1.9	13.7	14.3	21.0	729,944.7	0.00	1.00
08/29/2019 01:00	1	1.9	13.5	14.4	20.4	706,412.3	0.00	1.00
08/29/2019 02:00	1	1.9	13.4	14.4	20.4	707,044.3	0.00	1.00
08/29/2019 03:00	1	1.9	13.5	14.4	20.5	709,572.5	0.00	1.00
08/29/2019 04:00	1	1.9	14.2	14.3	21.3	722,682.6	0.00	1.00
08/29/2019 05:00	1	1.9	13.7	14.4	20.4	708,097.7	0.00	1.00
08/29/2019 06:00	1	1.9	13.9	14.4	21.1	733,800.8	0.00	1.00
08/29/2019 07:00	1	1.9	13.9	14.3	20.8	731,397.1	0.00	1.00
08/29/2019 08:00	1	1.9	12.6	14.4	19.1	793,844.8	0.00	1.00
08/29/2019 09:00	1	1.9	12.1	14.5	21.6	897,828.9	0.00	1.00
08/29/2019 10:00	1	1.8	11.8	14.5	22.4	987,483.4	0.00	1.00
08/29/2019 11:00	1	2.0	14.0	13.8	28.1	1,009,709.4	0.00	1.00
08/29/2019 12:00	1	2.2	15.6	13.2	30.3	1,005,370.9	0.00	1.00
08/29/2019 13:00	1	2.2	14.9	13.3	30.1	996,616.6	0.00	1.00
08/29/2019 14:00	2	2.3	16.2	12.9	32.3	995,229.2	0.00	1.00
08/29/2019 15:00	2	2.3	16.5	12.8	33.2	990,381.2	0.00	1.00
08/29/2019 16:00	2	2.3	16.6	12.8	33.7	994,607.9	0.00	1.00
08/29/2019 17:00	2	2.3	16.8	12.9	34.0	1,009,094.6	0.00	1.00
08/29/2019 18:00	2	2.4	17.3	12.8	35.5	1,015,571.9	0.00	1.00
08/29/2019 19:00	1	2.2	16.3	13.1	32.6	1,006,351.4	0.00	1.00
08/29/2019 20:00	1	1.9	12.8	14.5	26.3	1,009,094.6	0.00	1.00
08/29/2019 21:00	1	1.9	12.2	14.4	20.9	886,122.9	0.00	1.00
08/29/2019 22:00	1	1.9	13.6	14.3	19.6	738,244.2	0.05	1.00
08/29/2019 23:00	0	13.7	34.6	15.8	0.0	526,288.6	0.13	0.13
Average/Sum#:	1	2.5	15.2	14.0	24.4	858,783.0	0.18 #	23.13 #
Minimum:	1	1.8	11.8	12.8	0.0	526,288.6	0.00	0.13
Maximum:	2	13.7	34.6	15.8	35.5	1,015,571.9	0.13	1.00
%SI	4.17	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/30/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/31/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/01/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/02/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/03/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/04/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/04/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/04/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/04/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/04/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/04/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/04/2019 06:00	0	23.2	29.4	18.0	0.0	755,544.5	0.23	0.23
09/04/2019 07:00	0	6.2	15.2	14.5	18.3	925,217.3	0.53	1.00
09/04/2019 08:00	0	1.8	13.9	14.5	21.3	835,348.9	0.00	1.00
09/04/2019 09:00	0	1.8	13.9	14.6	23.8	910,341.2	0.00	1.00
09/04/2019 10:00	1	1.9	13.5	14.5	24.4	966,086.1	0.00	1.00
09/04/2019 11:00	1	2.2	17.4	13.2	32.8	1,012,840.5	0.00	1.00
09/04/2019 12:00	2	2.3	17.7	13.0	34.9	1,004,186.8	0.00	1.00
09/04/2019 13:00	2	2.4	18.1	12.7	36.1	1,003,520.9	0.00	1.00
09/04/2019 14:00	3	2.6	19.0	11.8	45.1	999,830.3	0.00	1.00
09/04/2019 15:00	3	2.6	19.1	11.9	46.1	1,011,852.5	0.00	1.00
09/04/2019 16:00	3	2.6	19.2	11.9	46.4	1,005,766.1	0.00	1.00
09/04/2019 17:00	1	1.9	12.8	14.4	22.3	914,775.5	0.00	1.00
09/04/2019 18:00	1	1.9	12.1	14.5	21.7	913,876.8	0.00	1.00
09/04/2019 19:00	1	1.9	12.4	14.5	23.9	953,889.7	0.00	1.00
09/04/2019 20:00	2	2.2	16.8	13.2	34.6	1,011,417.7	0.00	1.00
09/04/2019 21:00	1	1.9	13.9	14.4	21.7	761,821.3	0.00	1.00
09/04/2019 22:00	1	1.8	13.9	14.5	21.4	727,720.7	0.00	1.00
09/04/2019 23:00	1	1.8	12.6	14.6	23.9	940,990.2	0.00	1.00
Average/Sum#:	1	3.5	16.2	13.9	27.7	925,279.3	0.76 #	17.23 #
Minimum:	0	1.8	12.1	11.8	0.0	727,720.7	0.00	0.00
Maximum:	3	23.2	29.4	18.0	46.4	1,012,840.5	0.53	1.00
%SI	29.17	25.00	25.00	25.00	25.00	25.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/05/2019 00:00	1	1.8	12.5	14.5	21.0	861,025.6	0.00	1.00
09/05/2019 01:00	1	1.9	12.2	14.5	19.3	813,309.7	0.00	1.00
09/05/2019 02:00	1	1.9	14.0	14.5	22.2	739,489.2	0.00	1.00
09/05/2019 03:00	1	1.8	14.1	14.5	21.8	727,506.7	0.00	1.00
09/05/2019 04:00	1	1.9	13.9	14.4	20.1	768,563.1	0.00	1.00
09/05/2019 05:00	1	1.9	14.5	14.4	22.6	737,171.7	0.00	1.00
09/05/2019 06:00	1	1.8	13.5	14.4	20.3	768,984.5	0.00	1.00
09/05/2019 07:00	1	1.9	12.4	14.5	20.2	841,982.0	0.00	1.00
09/05/2019 08:00	1	1.9	12.7	14.5	24.3	923,933.5	0.00	1.00
09/05/2019 09:00	1	1.9	13.8	14.3	28.6	1,005,489.5	0.00	1.00
09/05/2019 10:00	1	2.0	14.8	13.8	30.3	1,009,902.3	0.00	1.00
09/05/2019 11:00	1	2.2	15.3	13.4	31.6	1,004,427.1	0.00	1.00
09/05/2019 12:00	2	2.2	16.3	13.1	34.0	1,008,458.2	0.00	1.00
09/05/2019 13:00	3	2.6	19.3	11.9	46.9	1,020,982.0	0.00	1.00
09/05/2019 14:00	3	2.6	19.5	11.9	48.0	1,019,764.7	0.00	1.00
09/05/2019 15:00	3	2.6	19.4	11.9	47.9	1,018,547.4	0.00	1.00
09/05/2019 16:00	2	2.3	17.8	12.8	37.9	1,012,528.7	0.00	1.00
09/05/2019 17:00	2	2.3	17.8	12.8	37.6	1,006,949.6	0.00	1.00
09/05/2019 18:00	1	2.1	15.4	13.6	32.1	1,010,747.8	0.00	1.00
09/05/2019 19:00	1	1.9	12.3	14.5	24.3	968,653.8	0.00	1.00
09/05/2019 20:00	1	1.9	12.2	14.6	22.5	917,514.3	0.00	1.00
09/05/2019 21:00	1	1.8	12.9	14.6	27.0	985,116.1	0.00	1.00
09/05/2019 22:00	1	1.8	12.7	14.5	22.3	876,003.7	0.00	1.00
09/05/2019 23:00	0	11.2	32.2	15.5	1.5	571,861.5	0.15	0.15
Average/Sum#:	1	2.4	15.5	13.9	27.7	900,788.0	0.15 #	23.15 #
Minimum:	1	1.8	12.2	11.9	1.5	571,861.5	0.00	0.15
Maximum:	3	11.2	32.2	15.5	48.0	1,020,982.0	0.15	1.00
%SI	4.17	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/06/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/07/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/08/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/09/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2019 22:00	0	23.4	28.0	17.5	0.0	741,100.3	0.28	0.28
09/09/2019 23:00	0	6.5	16.0	14.4	16.1	736,118.3	0.62	1.00
Average/Sum#:	0	15.0	22.0	16.0	8.1	738,609.3	0.90 #	1.28 #
Minimum:	0	6.5	16.0	14.4	0.0	736,118.3	0.00	0.00
Maximum:	0	23.4	28.0	17.5	16.1	741,100.3	0.62	1.00
%SI	95.83	91.67	91.67	91.67	91.67	91.67	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/10/2019 00:00	1	1.8	13.4	14.4	21.7	818,915.8	0.00	1.00
09/10/2019 01:00	0	1.7	15.3	14.3	24.2	727,869.8	0.00	1.00
09/10/2019 02:00	1	1.8	14.9	14.4	24.0	730,219.2	0.00	1.00
09/10/2019 03:00	1	1.9	14.4	14.3	21.1	754,843.3	0.00	1.00
09/10/2019 04:00	1	1.9	12.9	14.4	20.2	837,666.4	0.00	1.00
09/10/2019 05:00	1	1.9	12.9	14.4	20.7	823,340.1	0.00	1.00
09/10/2019 06:00	1	1.9	12.7	14.4	22.0	857,470.3	0.00	1.00
09/10/2019 07:00	1	1.9	12.9	14.5	25.2	966,514.1	0.00	1.00
09/10/2019 08:00	1	1.9	12.8	14.4	21.6	859,366.5	0.00	1.00
09/10/2019 09:00	1	1.9	13.8	14.3	21.5	744,053.9	0.00	1.00
09/10/2019 10:00	1	1.9	12.6	14.5	24.4	952,605.8	0.00	1.00
09/10/2019 11:00	1	1.9	12.7	14.5	24.3	950,038.2	0.00	1.00
09/10/2019 12:00	2	2.2	18.0	13.0	40.4	1,017,361.0	0.00	1.00
09/10/2019 13:00	1	1.9	13.0	14.5	23.8	960,308.8	0.00	1.00
09/10/2019 14:00	2	2.3	18.6	12.6	43.0	1,022,283.6	0.00	1.00
09/10/2019 15:00	1	1.9	13.1	14.4	23.7	949,116.4	0.00	1.00
09/10/2019 16:00	3	2.4	19.1	12.4	46.2	1,030,612.7	0.00	1.00
09/10/2019 17:00	3	2.5	20.1	12.1	47.4	1,025,979.0	0.00	1.00
09/10/2019 18:00	3	2.5	20.2	12.2	46.9	1,031,475.6	0.00	1.00
09/10/2019 19:00	2	2.2	17.7	13.1	36.1	1,025,312.6	0.00	1.00
09/10/2019 20:00	1	1.9	13.4	14.3	20.3	819,372.3	0.00	1.00
09/10/2019 21:00	1	1.9	12.4	14.5	21.0	853,750.5	0.00	1.00
09/10/2019 22:00	1	1.9	12.6	14.5	21.5	844,335.7	0.00	1.00
09/10/2019 23:00	1	1.9	13.8	14.4	21.4	762,453.4	0.00	1.00
Average/Sum#:	1	2.0	14.7	14.0	27.6	890,219.4	0.00 #	24.00 #
Minimum:	0	1.7	12.4	12.1	20.2	727,869.8	0.00	1.00
Maximum:	3	2.5	20.2	14.5	47.4	1,031,475.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/11/2019 00:00	1	1.9	14.2	14.5	22.6	721,515.5	0.00	1.00
09/11/2019 01:00	1	1.9	14.3	14.5	23.0	724,297.1	0.00	1.00
09/11/2019 02:00	1	1.9	14.4	14.5	23.1	726,008.9	0.00	1.00
09/11/2019 03:00	1	1.9	14.3	14.4	22.5	715,260.9	0.00	1.00
09/11/2019 04:00	1	1.9	14.9	14.4	23.2	732,747.4	0.00	1.00
09/11/2019 05:00	1	1.9	15.0	14.4	23.9	735,064.9	0.00	1.00
09/11/2019 06:00	1	1.9	14.9	14.4	23.8	734,432.8	0.00	1.00
09/11/2019 07:00	1	1.9	14.7	14.4	23.4	735,275.6	0.00	1.00
09/11/2019 08:00	1	1.9	14.6	14.4	22.8	732,326.0	0.00	1.00
09/11/2019 09:00	1	1.8	13.8	14.6	21.6	729,272.8	0.00	1.00
09/11/2019 10:00	1	1.9	12.0	14.4	21.1	903,820.1	0.00	1.00
09/11/2019 11:00	1	2.0	13.2	14.3	24.0	986,400.5	0.13	1.00
09/11/2019 12:00	0	15.3	31.9	15.6	0.0	540,793.4	0.13	0.13
09/11/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/11/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/11/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/11/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/11/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/11/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/11/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/11/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/11/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/11/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/11/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	1	2.9	15.6	14.5	21.2	747,478.1	0.26 #	12.13 #
Minimum:	1	1.8	12.0	14.3	0.0	540,793.4	0.00	0.00
Maximum:	1	15.3	31.9	15.6	24.0	986,400.5	0.13	1.00
%SI	50.00	45.83	45.83	45.83	45.83	45.83	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/12/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/12/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/12/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/12/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/12/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/12/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/12/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/12/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/12/2019 08:00	0	25.7	30.5	17.8	0.0	746,998.9	0.25	0.25
09/12/2019 09:00	0	6.3	14.6	14.3	14.6	729,322.2	0.57	1.00
09/12/2019 10:00	1	2.0	15.0	14.3	32.1	1,008,186.8	0.00	1.00
09/12/2019 11:00	1	1.9	14.0	14.5	24.5	922,221.7	0.00	1.00
09/12/2019 12:00	1	2.1	19.4	13.2	46.9	1,037,917.0	0.00	1.00
09/12/2019 13:00	1	1.9	13.9	14.5	25.6	960,736.8	0.00	1.00
09/12/2019 14:00	2	2.3	19.6	12.6	42.6	986,315.5	0.00	1.00
09/12/2019 15:00	1	2.0	12.9	14.4	19.9	837,245.0	0.00	1.00
09/12/2019 16:00	3	2.4	19.1	12.5	46.6	990,550.3	0.00	1.00
09/12/2019 17:00	3	2.6	20.8	11.9	50.0	1,014,134.8	0.00	1.00
09/12/2019 18:00	3	2.6	21.0	11.9	50.7	1,019,003.9	0.00	1.00
09/12/2019 19:00	3	2.6	21.1	11.9	50.3	1,018,243.1	0.00	1.00
09/12/2019 20:00	3	2.5	20.7	12.1	47.6	1,013,374.0	0.00	1.00
09/12/2019 21:00	0	1.9	13.1	14.4	19.8	869,479.1	0.00	1.00
09/12/2019 22:00	1	1.9	13.2	14.4	21.3	853,256.7	0.05	1.00
09/12/2019 23:00	0	13.3	39.0	15.9	0.0	516,273.0	0.10	0.10
Average/Sum#:	2	4.6	19.2	13.8	30.8	907,703.7	0.97 #	14.35 #
Minimum:	0	1.9	12.9	11.9	0.0	516,273.0	0.00	0.00
Maximum:	3	25.7	39.0	17.8	50.7	1,037,917.0	0.57	1.00
%SI	41.67	33.33	33.33	33.33	33.33	33.33	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/13/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/14/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/15/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/16/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/17/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/18/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/19/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/20/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/21/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/22/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/23/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2019 07:00	0	22.8	28.9	17.9	0.0	753,639.9	0.27	0.27
09/23/2019 08:00	1	6.4	16.8	14.5	26.1	992,618.7	0.58	1.00
09/23/2019 09:00	1	1.9	16.5	14.6	32.7	1,023,590.4	0.00	1.00
09/23/2019 10:00	1	1.8	15.8	14.5	31.8	1,016,583.6	0.00	1.00
09/23/2019 11:00	2	2.3	19.6	12.9	41.3	1,018,680.6	0.00	1.00
09/23/2019 12:00	2	2.3	19.9	12.8	41.2	1,013,712.2	0.00	1.00
09/23/2019 13:00	2	2.3	19.8	12.8	41.2	1,013,543.1	0.00	1.00
09/23/2019 14:00	2	2.3	19.7	12.9	40.6	1,019,536.5	0.00	1.00
09/23/2019 15:00	2	2.2	18.2	13.2	37.5	1,009,817.1	0.00	1.00
09/23/2019 16:00	2	2.3	19.4	12.9	40.6	1,020,905.9	0.00	1.00
09/23/2019 17:00	2	2.3	19.4	12.9	40.6	1,018,851.7	0.00	1.00
09/23/2019 18:00	1	2.1	16.5	13.8	34.1	1,011,831.0	0.00	1.00
09/23/2019 19:00	2	2.3	19.3	12.9	42.5	1,026,554.8	0.00	1.00
09/23/2019 20:00	2	2.3	19.2	13.0	40.6	1,022,041.3	0.00	1.00
09/23/2019 21:00	1	1.9	14.2	14.5	27.5	976,356.8	0.00	1.00
09/23/2019 22:00	1	1.9	15.0	14.3	22.5	726,209.9	0.00	1.00
09/23/2019 23:00	2	2.0	16.2	13.8	36.1	993,507.7	0.00	1.00
Average/Sum#:	2	3.6	18.5	13.8	33.9	979,881.2	0.85 #	16.27 #
Minimum:	1	1.8	14.2	12.8	0.0	726,209.9	0.00	0.00
Maximum:	2	22.8	28.9	17.9	42.5	1,026,554.8	0.58	1.00
%SI	33.33	29.17	29.17	29.17	29.17	29.17	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/24/2019 00:00	2	2.1	17.1	13.7	37.7	1,036,768.4	0.00	1.00
09/24/2019 01:00	2	2.1	17.8	13.4	39.5	1,031,085.3	0.00	1.00
09/24/2019 02:00	2	2.1	17.1	13.7	38.2	1,042,284.1	0.00	1.00
09/24/2019 03:00	2	2.1	17.6	13.5	40.1	1,043,168.3	0.00	1.00
09/24/2019 04:00	2	2.4	20.3	12.8	43.4	1,034,676.2	0.00	1.00
09/24/2019 05:00	1	2.0	14.5	14.2	26.1	898,097.1	0.00	1.00
09/24/2019 06:00	1	1.9	13.7	14.4	26.4	919,621.1	0.00	1.00
09/24/2019 07:00	2	2.0	16.5	13.9	38.2	1,040,958.2	0.00	1.00
09/24/2019 08:00	1	2.0	15.2	14.0	26.3	830,982.6	0.00	1.00
09/24/2019 09:00	1	1.9	12.8	14.4	21.9	837,877.0	0.00	1.00
09/24/2019 10:00	1	1.8	13.1	14.5	25.4	936,343.9	0.00	1.00
09/24/2019 11:00	1	1.9	13.1	14.5	25.8	938,911.6	0.00	1.00
09/24/2019 12:00	1	1.9	13.5	14.3	27.8	948,430.1	0.00	1.00
09/24/2019 13:00	1	2.0	14.8	14.1	32.4	998,270.1	0.00	1.00
09/24/2019 14:00	1	1.9	14.5	14.1	31.9	990,818.8	0.00	1.00
09/24/2019 15:00	2	2.0	14.9	13.9	33.8	1,004,375.0	0.00	1.00
09/24/2019 16:00	3	2.6	19.7	11.8	47.5	1,004,796.3	0.00	1.00
09/24/2019 17:00	4	2.6	19.6	11.8	48.8	1,002,539.0	0.00	1.00
09/24/2019 18:00	3	2.4	18.6	12.5	41.6	997,234.4	0.00	1.00
09/24/2019 19:00	1	2.1	15.2	13.9	32.0	996,941.0	0.00	1.00
09/24/2019 20:00	1	1.9	12.6	14.5	23.6	911,523.1	0.00	1.00
09/24/2019 21:00	1	1.9	14.1	14.2	31.1	981,693.3	0.00	1.00
09/24/2019 22:00	1	1.9	13.0	14.5	24.7	899,754.6	0.00	1.00
09/24/2019 23:00	1	1.9	14.2	14.5	22.1	719,803.7	0.00	1.00
Average/Sum#:	2	2.1	15.6	13.8	32.8	960,289.7	0.00 #	24.00 #
Minimum:	1	1.8	12.6	11.8	21.9	719,803.7	0.00	1.00
Maximum:	4	2.6	20.3	14.5	48.8	1,043,168.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/25/2019 00:00	1	1.8	14.2	14.5	22.1	702,044.0	0.00	1.00
09/25/2019 01:00	1	1.8	14.4	14.5	22.7	705,895.5	0.00	1.00
09/25/2019 02:00	1	1.9	14.4	14.5	22.8	706,965.3	0.00	1.00
09/25/2019 03:00	1	1.8	14.3	14.5	22.6	706,323.4	0.00	1.00
09/25/2019 04:00	1	1.8	14.6	14.5	22.6	706,109.4	0.00	1.00
09/25/2019 05:00	1	1.9	14.2	14.5	22.1	702,471.9	0.00	1.00
09/25/2019 06:00	1	1.8	14.9	14.5	23.5	691,987.3	0.00	1.00
09/25/2019 07:00	1	1.9	14.4	14.5	22.0	702,044.0	0.00	1.00
09/25/2019 08:00	1	1.8	14.3	14.6	22.0	702,753.8	0.00	1.00
09/25/2019 09:00	1	1.8	14.5	14.6	22.6	716,013.3	0.00	1.00
09/25/2019 10:00	1	1.9	13.1	14.6	20.9	820,785.2	0.00	1.00
09/25/2019 11:00	1	1.9	13.1	14.5	26.1	949,182.3	0.00	1.00
09/25/2019 12:00	2	2.4	18.8	12.4	40.4	1,006,607.5	0.00	1.00
09/25/2019 13:00	3	2.6	18.9	11.9	45.6	998,919.0	0.00	1.00
09/25/2019 14:00	3	2.5	18.6	12.3	41.9	993,469.6	0.00	1.00
09/25/2019 15:00	3	2.5	18.4	12.3	41.5	988,533.3	0.00	1.00
09/25/2019 16:00	3	2.6	18.7	12.0	44.5	987,985.8	0.00	1.00
09/25/2019 17:00	3	2.5	18.6	12.0	44.5	986,908.8	0.00	1.00
09/25/2019 18:00	1	2.1	14.6	13.9	31.5	985,789.9	0.00	1.00
09/25/2019 19:00	2	2.3	17.9	12.8	37.7	998,834.5	0.00	1.00
09/25/2019 20:00	2	2.3	18.1	12.8	38.2	987,338.1	0.00	1.00
09/25/2019 21:00	1	1.9	12.6	14.4	22.9	885,912.2	0.00	1.00
09/25/2019 22:00	1	1.9	13.1	14.4	20.7	782,046.7	0.00	1.00
09/25/2019 23:00	1	1.8	14.2	14.5	22.1	703,969.7	0.00	1.00
Average/Sum#:	2	2.1	15.5	13.8	29.3	838,287.1	0.00 #	24.00 #
Minimum:	1	1.8	12.6	11.9	20.7	691,987.3	0.00	1.00
Maximum:	3	2.6	18.9	14.6	45.6	1,006,607.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/26/2019 00:00	1	1.8	14.3	14.5	22.3	703,755.7	0.00	1.00
09/26/2019 01:00	1	1.9	14.2	14.5	22.2	703,327.8	0.00	1.00
09/26/2019 02:00	1	1.9	14.2	14.5	22.0	706,323.4	0.00	1.00
09/26/2019 03:00	1	1.9	14.2	14.5	22.1	706,537.4	0.00	1.00
09/26/2019 04:00	1	1.8	14.6	14.5	22.1	705,895.5	0.00	1.00
09/26/2019 05:00	1	1.9	14.3	14.5	21.9	707,179.3	0.00	1.00
09/26/2019 06:00	1	1.9	13.9	14.5	20.7	692,629.2	0.00	1.00
09/26/2019 07:00	1	1.8	14.1	14.5	21.5	699,904.2	0.00	1.00
09/26/2019 08:00	1	1.8	14.3	14.5	21.7	728,362.6	0.00	1.00
09/26/2019 09:00	1	1.8	13.0	14.6	23.2	883,604.8	0.00	1.00
09/26/2019 10:00	1	1.9	14.5	14.1	30.4	1,000,888.1	0.00	1.00
09/26/2019 11:00	1	2.1	15.7	13.6	31.6	998,179.1	0.00	1.00
09/26/2019 12:00	2	2.2	16.4	13.4	34.2	1,007,713.8	0.00	1.00
09/26/2019 13:00	2	2.2	16.5	13.3	34.1	995,535.5	0.00	1.00
09/26/2019 14:00	3	2.5	18.9	12.2	42.7	1,001,568.7	0.00	1.00
09/26/2019 15:00	2	2.4	18.5	12.5	40.5	1,004,896.7	0.00	1.00
09/26/2019 16:00	3	2.6	19.3	12.0	45.0	997,217.9	0.00	1.00
09/26/2019 17:00	2	2.3	17.7	13.0	37.3	1,006,093.6	0.00	1.00
09/26/2019 18:00	1	2.1	16.1	13.5	33.3	989,501.6	0.00	1.00
09/26/2019 19:00	1	1.9	14.0	14.5	29.7	999,037.9	0.00	1.00
09/26/2019 20:00	1	1.9	12.7	14.4	19.7	811,963.3	0.00	1.00
09/26/2019 21:00	1	1.9	14.4	14.3	22.6	730,359.7	0.00	1.00
09/26/2019 22:00	1	1.9	14.2	14.5	22.4	718,947.8	0.00	1.00
09/26/2019 23:00	1	1.9	14.2	14.4	22.8	746,863.0	0.00	1.00
Average/Sum#:	1	2.0	15.2	14.0	27.8	843,595.3	0.00 #	24.00 #
Minimum:	1	1.8	12.7	12.0	19.7	692,629.2	0.00	1.00
Maximum:	3	2.6	19.3	14.6	45.0	1,007,713.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/27/2019 00:00	1	1.9	14.6	14.4	23.1	717,157.0	0.00	1.00
09/27/2019 01:00	1	1.9	14.6	14.4	23.1	718,842.5	0.00	1.00
09/27/2019 02:00	1	1.9	14.6	14.4	23.1	713,996.8	0.00	1.00
09/27/2019 03:00	1	1.9	14.6	14.4	23.1	713,786.1	0.00	1.00
09/27/2019 04:00	1	1.8	14.9	14.4	22.9	722,213.4	0.00	1.00
09/27/2019 05:00	1	1.9	14.1	14.3	21.3	765,217.7	0.00	1.00
09/27/2019 06:00	1	1.9	14.0	14.3	21.6	770,197.5	0.00	1.00
09/27/2019 07:00	1	1.9	12.9	14.4	22.7	855,574.2	0.00	1.00
09/27/2019 08:00	1	1.8	13.7	14.5	27.4	951,322.0	0.00	1.00
09/27/2019 09:00	3	2.5	21.0	12.1	52.0	1,028,780.1	0.00	1.00
09/27/2019 10:00	4	2.6	21.7	11.9	53.3	1,020,525.5	0.00	1.00
09/27/2019 11:00	3	2.6	21.3	11.9	51.8	1,018,091.0	0.00	1.00
09/27/2019 12:00	3	2.6	20.7	12.0	49.7	1,027,683.8	0.00	1.00
09/27/2019 13:00	3	2.6	20.7	12.0	49.8	1,027,991.5	0.00	1.00
09/27/2019 14:00	3	2.6	20.7	11.9	49.7	1,017,178.0	0.00	1.00
09/27/2019 15:00	3	2.6	20.7	11.9	49.7	1,017,178.0	0.00	1.00
09/27/2019 16:00	3	2.6	20.7	11.9	49.9	1,017,330.2	0.00	1.00
09/27/2019 17:00	3	2.6	20.7	11.9	50.0	1,017,482.3	0.00	1.00
09/27/2019 18:00	3	2.6	20.8	11.9	50.5	1,020,221.2	0.00	1.00
09/27/2019 19:00	3	2.6	20.9	12.0	50.8	1,029,530.2	0.00	1.00
09/27/2019 20:00	3	2.5	20.9	12.2	49.3	1,031,947.8	0.00	1.00
09/27/2019 21:00	0	2.0	14.7	14.3	21.5	819,164.8	0.00	1.00
09/27/2019 22:00	1	2.0	16.0	14.3	21.7	704,838.6	0.08	1.00
09/27/2019 23:00	0	16.2	38.1	16.3	0.0	501,328.4	0.08	0.08
Average/Sum#:	2	2.8	18.7	13.3	35.8	884,482.4	0.16 #	23.08 #
Minimum:	0	1.8	12.9	11.9	0.0	501,328.4	0.00	0.08
Maximum:	4	16.2	38.1	16.3	53.3	1,031,947.8	0.08	1.00
%SI	4.17	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/28/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/29/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/30/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2019 10:00	0	24.2	30.0	18.1	0.0	774,213.9	0.25	0.25
09/30/2019 11:00	1	6.6	17.5	14.4	19.8	820,390.5	0.60	1.00
09/30/2019 12:00	1	1.8	17.4	14.6	36.9	1,023,155.6	0.00	1.00
09/30/2019 13:00	1	1.8	17.8	14.5	37.4	1,017,867.5	0.00	1.00
09/30/2019 14:00	3	2.3	23.1	12.7	51.3	1,042,766.6	0.00	1.00
09/30/2019 15:00	3	2.4	23.9	12.4	54.3	1,029,162.7	0.00	1.00
09/30/2019 16:00	2	2.3	22.7	12.8	48.6	1,009,147.4	0.00	1.00
09/30/2019 17:00	0	8.1	30.0	15.1	7.4	663,462.5	0.17	0.23
09/30/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	2	6.2	22.8	14.3	32.0	922,520.8	1.02 #	6.48 #
Minimum:	0	1.8	17.4	12.4	0.0	663,462.5	0.00	0.00
Maximum:	3	24.2	30.0	18.1	54.3	1,042,766.6	0.60	1.00
%SI	70.83	66.67	66.67	66.67	66.67	66.67	0.00	0.00

ATTACHMENT 15

AQ-55

AQ-55 The emissions rates from each gas turbine and heat recovery steam generator exhaust during startup and shutdown shall not exceed the following:

Turbine emissions limitations during Startup and Shutdown		
Pollutant	**Max Lbs/ Hr (worst case turbine**	**Pounds per Startup or Shutdown (both turbines combined)**
NOx	**37.1**	**122.8**
CO	**89.5**	**204.8**

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:01 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
07/01/2019	0.00	0.00	0.00	0.00	0.00
07/02/2019	0.00	0.00	0.00	0.00	0.00
07/03/2019	0.00	0.00	0.00	0.00	0.00
07/04/2019	0.00	0.00	0.00	0.00	0.00
07/05/2019	0.00	0.00	0.00	0.00	0.00
07/06/2019	0.00	0.00	0.00	0.00	0.00
07/07/2019	0.00	0.00	0.00	0.00	0.00
07/08/2019	0.00	0.00	0.00	0.00	0.00
07/09/2019	0.00	0.00	0.00	0.00	0.00
07/10/2019	0.00	0.00	0.00	0.00	0.00
07/11/2019	0.00	0.00	0.00	0.00	0.00
07/12/2019	0.00	0.00	0.00	0.00	0.00
07/13/2019	0.00	0.00	0.00	0.00	0.00
07/14/2019	0.00	0.00	0.00	0.00	0.00
07/15/2019	0.00	0.00	0.00	0.00	0.00
07/16/2019	0.00	0.00	0.00	0.00	0.00
07/17/2019	0.00	0.00	0.00	0.00	0.00
07/18/2019	0.00	0.00	0.00	0.00	0.00
07/19/2019	0.00	0.00	0.00	0.00	0.00
07/20/2019	0.00	0.00	0.00	0.00	0.00
07/21/2019	0.00	0.00	0.00	0.00	0.00
07/22/2019	27.81	37.22	2.49	4.96	8.30
07/23/2019	29.53	91.83	8.98	17.99	30.01
07/24/2019	7.40	93.50	8.98	17.98	29.95
07/25/2019	15.45	79.03	7.60	15.23	25.36
07/26/2019	14.85	80.58	7.75	15.52	25.86
07/27/2019	42.08	83.84	6.91	13.83	23.07
07/28/2019	31.86	144.37	13.84	27.61	46.05
07/29/2019	32.64	154.66	14.79	29.56	49.26
07/30/2019	34.96	111.05	10.60	21.19	35.32
07/31/2019	29.32	119.89	11.42	22.89	38.15
Monthly Avg/Sum*:	265.90 *	995.97 *	93.36 *	186.76 *	311.33 *
Daily Min:	7.40	37.22	2.49	4.96	8.30
Daily Max:	42.08	154.66	14.79	29.56	49.26
Jul 2019 - Jul 2019	265.90	995.97	93.36	186.76	311.33
QTD:	265.90 *	995.97 *	93.36 *	186.76 *	311.33 *
YTD 2019:	3,190.65 *	9,282.43 *	870.52 *	1,742.01 *	2,903.47 *

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:01 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
08/01/2019	32.28	112.72	10.75	21.54	35.87
08/02/2019	30.10	116.24	11.12	22.22	37.00
08/03/2019	29.83	124.10	11.85	23.77	39.57
08/04/2019	27.26	131.11	12.51	24.97	41.60
08/05/2019	25.16	111.76	11.62	23.28	38.76
08/06/2019	30.10	127.41	12.19	24.43	40.66
08/07/2019	30.47	121.93	11.59	23.24	38.66
08/08/2019	31.45	21.55	1.87	3.76	6.23
08/09/2019	0.00	0.00	0.00	0.00	0.00
08/10/2019	0.00	0.00	0.00	0.00	0.00
08/11/2019	0.00	0.00	0.00	0.00	0.00
08/12/2019	0.00	0.00	0.00	0.00	0.00
08/13/2019	31.38	63.44	5.12	10.24	17.09
08/14/2019	56.92	129.68	11.42	22.84	38.09
08/15/2019	31.31	129.75	12.57	25.18	41.94
08/16/2019	38.17	132.93	12.67	25.38	42.27
08/17/2019	21.76	63.82	5.98	12.01	20.00
08/18/2019	0.00	0.00	0.00	0.00	0.00
08/19/2019	0.00	0.00	0.00	0.00	0.00
08/20/2019	0.00	0.00	0.00	0.00	0.00
08/21/2019	0.00	0.00	0.00	0.00	0.00
08/22/2019	0.00	0.00	0.00	0.00	0.00
08/23/2019	0.00	0.00	0.00	0.00	0.00
08/24/2019	0.00	0.00	0.00	0.00	0.00
08/25/2019	38.98	65.25	5.20	10.44	17.38
08/26/2019	20.39	68.80	6.54	13.08	21.82
08/27/2019	57.36	131.96	11.59	23.16	38.61
08/28/2019	25.76	153.44	14.70	29.37	49.01
08/29/2019	60.99	128.03	12.03	24.04	40.10
08/30/2019	0.00	0.00	0.00	0.00	0.00
08/31/2019	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	619.67 *	1,933.92 *	181.32 *	362.95 *	604.66 *
Daily Min:	20.39	21.55	1.87	3.76	6.23
Daily Max:	60.99	153.44	14.70	29.37	49.01
Jul 2019 - Aug 2019	885.57	2,929.89	274.68	549.71	915.99
QTD:	885.57 *	2,929.89 *	274.68 *	549.71 *	915.99 *
YTD 2019:	3,810.32 *	11,216.35 *	1,051.84 *	2,104.96 *	3,508.13 *

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:01 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
09/01/2019	0.00	0.00	0.00	0.00	0.00
09/02/2019	0.00	0.00	0.00	0.00	0.00
09/03/2019	0.00	0.00	0.00	0.00	0.00
09/04/2019	84.83	128.20	10.09	20.18	33.62
09/05/2019	54.31	133.96	12.64	25.30	42.16
09/06/2019	0.00	0.00	0.00	0.00	0.00
09/07/2019	0.00	0.00	0.00	0.00	0.00
09/08/2019	0.00	0.00	0.00	0.00	0.00
09/09/2019	26.06	15.30	0.24	0.48	0.80
09/10/2019	21.23	68.35	6.57	13.13	21.90
09/11/2019	63.84	79.38	6.42	12.87	21.44
09/12/2019	68.03	88.44	7.04	14.09	23.47
09/13/2019	0.00	0.00	0.00	0.00	0.00
09/14/2019	0.00	0.00	0.00	0.00	0.00
09/15/2019	0.00	0.00	0.00	0.00	0.00
09/16/2019	0.00	0.00	0.00	0.00	0.00
09/17/2019	0.00	0.00	0.00	0.00	0.00
09/18/2019	0.00	0.00	0.00	0.00	0.00
09/19/2019	0.00	0.00	0.00	0.00	0.00
09/20/2019	0.00	0.00	0.00	0.00	0.00
09/21/2019	0.00	0.00	0.00	0.00	0.00
09/22/2019	0.00	0.00	0.00	0.00	0.00
09/23/2019	56.71	68.38	5.19	10.37	17.28
09/24/2019	82.79	131.06	11.51	22.99	38.34
09/25/2019	33.98	128.33	12.36	24.69	41.13
09/26/2019	44.70	124.85	11.84	23.67	39.36
09/27/2019	29.32	76.81	7.20	14.44	24.12
09/28/2019	0.00	0.00	0.00	0.00	0.00
09/29/2019	0.00	0.00	0.00	0.00	0.00
09/30/2019	104.05	60.53	3.27	6.56	10.91
Monthly Avg/Sum*:	669.85 *	1,103.59 *	94.37 *	188.77 *	314.53 *
Daily Min:	21.23	15.30	0.24	0.48	0.80
Daily Max:	104.05	133.96	12.64	25.30	42.16
Jul 2019 - Sep 2019	1,555.42	4,033.48	369.05	738.48	1,230.52
QTD:	1,555.42 *	4,033.48 *	369.05 *	738.48 *	1,230.52 *
YTD 2019:	4,480.17 *	12,319.94 *	1,146.21 *	2,293.73 *	3,822.66 *

Monthly Summary By Day Report

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:04 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)
07/01/2019	0.0	0.0	0.0	0.0
07/02/2019	0.0	0.0	0.0	0.0
07/03/2019	0.0	0.0	0.0	0.0
07/04/2019	0.0	0.0	0.0	0.0
07/05/2019	0.0	0.0	0.0	0.0
07/06/2019	0.0	0.0	0.0	0.0
07/07/2019	0.0	0.0	0.0	0.0
07/08/2019	0.0	0.0	0.0	0.0
07/09/2019	0.0	0.0	0.0	0.0
07/10/2019	0.0	0.0	0.0	0.0
07/11/2019	0.0	0.0	0.0	0.0
07/12/2019	0.0	0.0	0.1	0.0
07/13/2019	0.0	0.0	0.0	0.0
07/14/2019	0.0	0.0	0.0	0.0
07/15/2019	0.0	0.0	0.0	0.0
07/16/2019	0.0	0.0	0.0	0.0
07/17/2019	0.0	0.0	0.0	0.0
07/18/2019	0.0	0.0	0.0	0.0
07/19/2019	0.0	0.0	0.0	0.0
07/20/2019	0.0	0.0	0.0	0.0
07/21/2019	0.0	0.0	0.0	0.0
07/22/2019	0.0	0.0	20.2	12.4
07/23/2019	0.0	0.0	7.4	1.1
07/24/2019	0.0	0.0	0.0	0.0
07/25/2019	0.0	0.0	0.0	0.0
07/26/2019	0.0	0.0	0.0	0.0
07/27/2019	0.0	0.0	22.3	13.1
07/28/2019	0.0	0.0	0.0	0.0
07/29/2019	0.0	0.0	0.0	0.0
07/30/2019	0.0	0.0	0.0	0.0
07/31/2019	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	0.0 *	0.0 *	49.9 *	26.6 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	0.0	0.0	22.3	13.1
Jul 2019 - Jul 2019	0.0	0.0	49.9	26.6
QTD:	0.0 *	0.0 *	50.0 *	26.6 *
YTD 2019:	250.5 *	82.7 *	367.0 *	158.2 *

Monthly Summary By Day Report

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:04 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)
08/01/2019	0.0	0.0	0.0	0.0
08/02/2019	0.0	0.0	0.0	0.0
08/03/2019	0.0	0.0	0.0	0.0
08/04/2019	0.0	0.0	0.0	0.0
08/05/2019	0.0	0.0	0.0	0.0
08/06/2019	0.0	0.0	0.0	0.0
08/07/2019	0.0	0.0	0.0	0.0
08/08/2019	5.6	1.1	7.8	1.1
08/09/2019	0.0	0.0	0.0	0.0
08/10/2019	0.0	0.0	0.0	0.0
08/11/2019	0.0	0.0	0.0	0.0
08/12/2019	0.0	0.0	0.0	0.0
08/13/2019	23.3	11.9	0.0	0.0
08/14/2019	0.0	0.0	29.8	12.8
08/15/2019	0.0	0.0	0.0	0.0
08/16/2019	0.0	0.0	9.0	1.3
08/17/2019	7.3	1.1	0.0	0.0
08/18/2019	0.0	0.0	0.0	0.0
08/19/2019	0.0	0.0	0.0	0.0
08/20/2019	0.0	0.0	0.0	0.0
08/21/2019	0.0	0.0	0.0	0.0
08/22/2019	0.0	0.0	0.0	0.0
08/23/2019	0.0	0.0	0.0	0.0
08/24/2019	0.0	0.0	0.0	0.0
08/25/2019	0.0	0.0	26.2	14.0
08/26/2019	0.0	0.0	0.0	0.0
08/27/2019	29.1	13.0	0.0	0.0
08/28/2019	0.0	0.0	0.0	0.0
08/29/2019	7.9	1.1	9.3	1.5
08/30/2019	0.0	0.0	0.0	0.0
08/31/2019	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	73.2 *	28.2 *	82.1 *	30.7 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	29.1	13.0	29.8	14.0
Jul 2019 - Aug 2019	73.2	28.2	132.0	57.3
QTD:	73.2 *	28.2 *	132.1 *	57.3 *
YTD 2019:	323.7 *	110.9 *	449.1 *	188.9 *

Monthly Summary By Day Report

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:04 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)
09/01/2019	0.0	0.0	0.0	0.0
09/02/2019	0.0	0.0	0.0	0.0
09/03/2019	0.0	0.0	0.0	0.0
09/04/2019	30.3	12.0	28.7	13.6
09/05/2019	5.6	0.9	9.2	1.4
09/06/2019	0.0	0.0	0.0	0.0
09/07/2019	0.0	0.0	0.0	0.0
09/08/2019	0.0	0.0	0.0	0.0
09/09/2019	0.0	0.0	26.1	14.8
09/10/2019	0.0	0.0	0.0	0.0
09/11/2019	28.3	11.9	8.9	2.1
09/12/2019	12.5	1.3	32.0	15.1
09/13/2019	0.0	0.0	0.0	0.0
09/14/2019	0.0	0.0	0.0	0.0
09/15/2019	0.0	0.0	0.0	0.0
09/16/2019	0.0	0.0	0.0	0.0
09/17/2019	0.0	0.0	0.0	0.0
09/18/2019	0.0	0.0	0.0	0.0
09/19/2019	0.0	0.0	0.0	0.0
09/20/2019	0.0	0.0	0.0	0.0
09/21/2019	0.0	0.0	0.0	0.0
09/22/2019	0.0	0.0	0.0	0.0
09/23/2019	0.0	0.0	40.1	15.9
09/24/2019	39.0	12.0	0.0	0.0
09/25/2019	0.0	0.0	0.0	0.0
09/26/2019	6.7	1.0	0.0	0.0
09/27/2019	0.0	0.0	10.3	1.4
09/28/2019	0.0	0.0	0.0	0.0
09/29/2019	0.0	0.0	0.0	0.0
09/30/2019	39.4	13.7	43.6	16.7
Monthly Avg/Sum*:	161.8 *	52.8 *	198.9 *	81.0 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	39.4	13.7	43.6	16.7
Jul 2019 - Sep 2019	235.0	81.0	330.9	138.3
QTD:	235.0 *	81.0 *	331.0 *	138.3 *
YTD 2019:	485.5 *	163.7 *	648.0 *	269.9 *

Startup / Shutdown Events

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:05 **Location:** Roseville, CA

Unit Offline

Tag Name: CT1_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
07/01/2019 00:00	07/23/2019 04:00	533
08/08/2019 05:00	08/13/2019 05:00	121
08/18/2019 00:00	08/27/2019 04:00	221
08/30/2019 00:00	09/04/2019 04:00	125
09/06/2019 00:00	09/11/2019 07:00	128
09/12/2019 13:00	09/24/2019 06:00	282
09/27/2019 00:00	09/30/2019 05:00	78
09/30/2019 13:00	09/30/2019 23:00	11

Startup / Shutdown Events

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:05 **Location:** Roseville, CA

Operating Time Summary	
Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	1,499.00 Hour(s)
Offline Percentage:	67.89 %
Total Online:	709.00 Hour(s)
Online Percentage:	32.11 %

Startup / Shutdown Events

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:05 **Location:** Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	07/23/2019 05:45	07/23/2019 06:59	Cold Startup	75
2	08/08/2019 04:50	08/08/2019 04:58	Shutdown	9
3	08/13/2019 06:45	08/13/2019 07:38	Cold Startup	54
4	08/17/2019 22:57	08/17/2019 23:05	Shutdown	9
5	08/27/2019 05:44	08/27/2019 06:44	Cold Startup	61
6	08/29/2019 22:55	08/29/2019 23:05	Shutdown	11
7	09/04/2019 05:44	09/04/2019 06:36	Cold Startup	53
8	09/05/2019 22:56	09/05/2019 23:03	Shutdown	8
9	09/11/2019 08:45	09/11/2019 09:43	Cold Startup	59
10	09/12/2019 11:51	09/12/2019 12:02	Shutdown	12
11	09/24/2019 07:43	09/24/2019 07:43	Cold Startup	1
12	09/24/2019 07:43	09/24/2019 07:43	Shutdown	1
13	09/24/2019 07:56	09/24/2019 08:54	Cold Startup	59
14	09/26/2019 22:53	09/26/2019 23:00	Shutdown	8
15	09/30/2019 06:44	09/30/2019 07:36	Cold Startup	53
16	09/30/2019 11:53	09/30/2019 12:03	Shutdown	11

Startup / Shutdown Events

CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:05 **Location:** Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	8	415	0.99
Warm Startup	0		0.00
Shutdown	8	69	0.16
Total Process Events:	16	484	1.16

Total Report Time:	2,207.98 Hour(s)
Total Operating Time:	698.02 Hour(s)
Total Startup Time:	415 Minute(s)
Total Shutdown Time:	69 Minute(s)
Total Startup/Shutdown Time:	484 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	1.16 %

CT1 SUSD EVENT 1

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/23/19 5:40	0			0	X		0	X		0	X		0	X		0		
07/23/19 5:41	0			0	X		0	X		0	X		0	X		0		
07/23/19 5:42	0			0	X		0	X		0	X		0	X		0		
07/23/19 5:43	0			0	X		0	X		0	X		0	X		0		
07/23/19 5:44	0			0	X		0	X		0	X		0	X		0		
07/23/19 5:45	0			0.2	X		0	X		0	X		0	X		1		
07/23/19 5:46	4543.9			0.3	X		0	X		0	X		0	X		1		
07/23/19 5:47	30652.4			56.6	X		28.32	X		4.04	X		3.33	X		1		
07/23/19 5:48	47672.9			516.4	X		17.08	X		57.45	X		3.13	X		1		
07/23/19 5:49	69545.4			354.3	X		23.31	X		57.5	X		6.22	X		1		
07/23/19 5:50	114368.7			201.9	X		25.75	X		53.88	X		11.31	X		1		
07/23/19 5:51	135625.1			86.7	X		44.25	X		27.42	X		23.03	X		1		
07/23/19 5:52	146715.4			229.9	X		53.64	X		78.69	X		30.21	X		1		
07/23/19 5:53	166123.5			1841	X		38.98	X		713.34	X		24.85	X		1		
07/23/19 5:54	189151.2			1133.9	X		48	X		500.28	X		34.85	X		1		
07/23/19 5:55	214643.5			163.1	X		57.22	X		81.69	X		47.15	X		1		
07/23/19 5:56	234436.6			9.3	X		51.78	X		5.07	X		46.6	X		1		
07/23/19 5:57	261007.1			2	X		46.13	X		1.24	X		46.22	X		1		
07/23/19 5:58	284728.1			1.9	X		42.28	X		1.24	X		46.22	X		1		
07/23/19 5:59	305599.4			1.8	X		30.73	X		1.26	X		36.05	X		1		
07/23/19 6:00	326008.6			1.9	X		16.14	X		1.45	X		20.2	X		1		
07/23/19 6:01	337561			2	X		15.27	X		1.57	X		19.79	X		1		
07/23/19 6:02	339178.3			1.8	X		12.23	X		1.44	X		15.93	X		1		
07/23/19 6:03	339332.4			1.7	X		11.45	X		1.37	X		14.92	X		1		
07/23/19 6:04	343491.3			1.6	X		9.8	X		1.25	X		12.93	X		1		
07/23/19 6:05	354581.5			1.5	X		8.42	X		1.22	X		11.46	X		1		
07/23/19 6:06	358278.3			1.4	X		6.97	X		1.2	X		9.59	X		1		
07/23/19 6:07	359279.5			1.3	X		6.88	X		1.05	X		9.49	X		1		
07/23/19 6:08	363130.3			1.2	X		6.26	X		0.98	X		8.72	X		1		
07/23/19 6:09	365363.8			1.1	X		5.72	X		0.91	X		8.02	X		1		
07/23/19 6:10	367982.3			1	X		5.72	X		0.84	X		8.08	X		1		
07/23/19 6:11	370677.9			1	X		5.63	X		0.86	X		8.01	X		1		
07/23/19 6:12	371525.1			0.9	X		5.54	X		0.79	X		7.9	X		1		
07/23/19 6:13	372064.2			0.9	X		5.45	X		0.79	X		7.78	X		1		
07/23/19 6:14	372295.2			0.9	X		5.45	X		0.79	X		7.78	X		1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/23/19 6:15	371987.2			0.9	X		5.54	X		0.79	X		7.91	X		1		
07/23/19 6:16	371679.1			0.9	X		5.54	X		0.79	X		7.9	X		1		
07/23/19 6:17	370831.9			0.8	X		5.54	X		0.71	X		7.88	X		1		
07/23/19 6:18	370523.8			0.8	X		5.63	X		0.71	X		8	X		1		
07/23/19 6:19	370677.9			0.8	X		5.72	X		0.71	X		8.14	X		1		
07/23/19 6:20	370215.8			0.8	X		5.81	X		0.71	X		8.26	X		1		
07/23/19 6:21	369599.7			0.8	X		5.9	X		0.7	X		8.37	X		1		
07/23/19 6:22	367674.3			0.8	X		5.99	X		0.7	X		8.45	X		1		
07/23/19 6:23	352964.2			0.8	X		6.35	X		0.67	X		8.61	X		1		
07/23/19 6:24	342798.1			0.8	X		6.97	X		0.64	X		9.18	X		1		
07/23/19 6:25	340641.7			0.8	X		6.78	X		0.63	X		8.87	X		1		
07/23/19 6:26	339717.5			0.8	X		5.99	X		0.64	X		7.81	X		1		
07/23/19 6:27	337407			0.8	X		5.01	X		0.63	X		6.48	X		1		
07/23/19 6:28	327471.9			0.8	X		4.29	X		0.61	X		5.39	X		1		
07/23/19 6:29	320925.6			0.8	X		4.23	X		0.59	X		5.21	X		1		
07/23/19 6:30	319924.3			0.9	X		4.14	X		0.66	X		5.08	X		1		
07/23/19 6:31	319924.3			0.9	X		3.87	X		0.66	X		4.76	X		1		
07/23/19 6:32	319924.3			0.9	X		3.61	X		0.66	X		4.43	X		1		
07/23/19 6:33	319616.3			0.8	X		3.43	X		0.59	X		4.21	X		1		
07/23/19 6:34	319616.3			0.8	X		3.4	X		0.6	X		4.17	X		1		
07/23/19 6:35	319770.3			0.8	X		3.31	X		0.6	X		4.06	X		1		
07/23/19 6:36	319924.3			0.8	X		3.31	X		0.6	X		4.06	X		1		
07/23/19 6:37	319616.3			0.8	X		3.22	X		0.6	X		3.95	X		1		
07/23/19 6:38	319847.3			0.8	X		3.13	X		0.6	X		3.84	X		1		
07/23/19 6:39	320309.4			0.8	X		3.04	X		0.6	X		3.74	X		1		
07/23/19 6:40	320463.5			0.8	X		2.95	X		0.6	X		3.63	X		1		
07/23/19 6:41	320232.4			0.8	X		2.95	X		0.6	X		3.63	X		1		
07/23/19 6:42	320309.4			0.8	X		2.86	X		0.6	X		3.52	X		1		
07/23/19 6:43	320463.5			0.8	X		2.86	X		0.6	X		3.52	X		1		
07/23/19 6:44	320771.5			0.8	X		2.95	X		0.6	X		3.63	X		1		
07/23/19 6:45	320848.5			0.8	X		2.95	X		0.6	X		3.63	X		1		
07/23/19 6:46	320617.5			0.8	X		2.86	X		0.6	X		3.52	X		1		
07/23/19 6:47	320463.5			0.8	X		2.77	X		0.6	X		3.41	X		1		
07/23/19 6:48	320386.4			0.8	X		2.77	X		0.6	X		3.41	X		1		
07/23/19 6:49	320232.4			0.8	X		2.68	X		0.6	X		3.3	X		1		
07/23/19 6:50	320155.4			0.8	X		2.68	X		0.6	X		3.3	X		1		
07/23/19 6:51	319924.3			0.8	X		2.68	X		0.6	X		3.29	X		1		
07/23/19 6:52	319693.3			0.8	X		2.59	X		0.6	X		3.18	X		1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/23/19 6:53	320001.4			0.8	X		2.59	X		0.6	X		3.18	X		1		
07/23/19 6:54	319924.3			0.8	X		2.59	X		0.6	X		3.18	X		1		
07/23/19 6:55	327240.9			0.8	X		2.59	X		0.61	X		3.26	X		1		
07/23/19 6:56	332709			0.8	X		2.41	X		0.62	X		3.08	X		1		
07/23/19 6:57	333094.1			0.8	X		1.79	X		0.63	X		2.29	X		1		
07/23/19 6:58	333633.2			0.8	X		1.7	X		0.63	X		2.17	X		1		
07/23/19 6:59	333787.2			0.8	X		1.52	X		0.63	X		1.95	X		1		
07/23/19 7:00	337715			0.8	X		1.34	X		0.63	X		1.74	X		0		
07/23/19 7:01	344569.5			0.8	X		1.25	X		0.65	X		1.66	X		0		
07/23/19 7:02	347342			0.8	X		1.18	X		0.66	X		1.57	X		0		
07/23/19 7:03	349498.5			0.7	X		1.18	X		0.59	X		1.58	X		0		
07/23/19 7:04	352964.2			0.7	X		1.09	X		0.6	X		1.48	X		0		

CT1 SUSD EVENT 2

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/08/19 4:45	284266			0.6			1.75			0.43			1.91			0		
08/08/19 4:46	284343			0.6			1.66			0.43			1.81			0		
08/08/19 4:47	284343			0.6			1.75			0.43			1.91			0		
08/08/19 4:48	284497			0.6			1.75			0.43			1.91			0		
08/08/19 4:49	284574			0.6			1.75			0.43			1.91			0		
08/08/19 4:50	283726.8			0.6			1.75			0.43			1.91			1		
08/08/19 4:51	266013.2			0.6			1.75			0.4			1.79			1		
08/08/19 4:52	241830.2			0.7			3.65			0.37			3.39			1		
08/08/19 4:53	222114.1			0.6			8.22			0.3			7.01			1		
08/08/19 4:54	196852.8			0.5			15.22			0.24			11.5			1		
08/08/19 4:55	172900.9			2.3			18.38			0.92			12.2			1		
08/08/19 4:56	151336.4			80.2			20.78			28.3			12.07			1		
08/08/19 4:57	133468.7			598.9			21.39			186.46			10.96			1		
08/08/19 4:58	30652.4			1626			22.08			116.11			2.6			1		
08/08/19 4:59	0			0			22.24			0			0			0		
08/08/19 5:00	0			0			0.2			0			0			0		
08/08/19 5:01	0			0			0.1			0			0			0		
08/08/19 5:02	0			0			0.1			0			0			0		
08/08/19 5:03	0			0			0.1			0			0			0		

CT1 SUSD EVENT 3

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/13/19 6:40	0			0			0			0			0			0		
08/13/19 6:41	0			0			0			0			0			0		
08/13/19 6:42	0			0			0			0			0			0		
08/13/19 6:43	0			0			0			0			0			0		
08/13/19 6:44	0			0			0			0			0			0		
08/13/19 6:45	0			0.2			0			0			0			1		
08/13/19 6:46	6084.3			0.2			0			0			0			1		
08/13/19 6:47	31576.5			60			26.55			4.42			3.22			1		
08/13/19 6:48	48135			521.1			17.08			58.55			3.16			1		
08/13/19 6:49	71008.7			355.2			22.72			58.83			6.19			1		
08/13/19 6:50	118142.5			198.5			25.75			54.69			11.68			1		
08/13/19 6:51	138012.6			83.5			43.34			26.88			22.96			1		
08/13/19 6:52	154263			367.6			50.7			132.25			30.02			1		
08/13/19 6:53	175750.5			1737			44.08			711.94			29.73			1		
08/13/19 6:54	199779.4			593.9			56.73			276.8			43.51			1		
08/13/19 6:55	223654.4			56.4			63.98			29.4			54.92			1		
08/13/19 6:56	244217.6			3.8			66.64			2.17			62.48			1		
08/13/19 6:57	272097.4			1.8			59.93			1.12			62.59			1		
08/13/19 6:58	293815.9			1.7			41.77			1.16			47.12			1		
08/13/19 6:59	312992.9			1.7			22.56			1.27			27.1			1		
08/13/19 7:00	333402.2			1.9			14.84			1.48			18.99			1		
08/13/19 7:01	349806.5			1.9			13.8			1.56			18.52			1		
08/13/19 7:02	368213.4			1.8			10.48			1.51			14.81			1		
08/13/19 7:03	391549.2			1.5			8.99			1.41			13.51			1		
08/13/19 7:04	414654			1.4			8.2			1.34			13.06			1		
08/13/19 7:05	425513.3			1.2			7.02			1.21			11.47			1		
08/13/19 7:06	424820.1			1.1			6.91			1.1			11.28			1		
08/13/19 7:07	423895.9			1			6.36			1			10.35			1		
08/13/19 7:08	424281			1			6.18			1			10.06			1		
08/13/19 7:09	423510.8			1			5.99			1			9.74			1		
08/13/19 7:10	423356.8			0.9			5.81			0.91			9.44			1		
08/13/19 7:11	423125.8			0.9			5.81			0.91			9.43			1		
08/13/19 7:12	422509.6			0.9			5.72			0.91			9.27			1		
08/13/19 7:13	422740.7			0.9			5.72			0.91			9.28			1		
08/13/19 7:14	422509.6			0.8			5.62			0.82			9.12			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/13/19 7:15	422663.7			0.8			5.62			0.82			9.12			1		
08/13/19 7:16	422432.6			0.8			5.62			0.82			9.12			1		
08/13/19 7:17	422817.7			0.8			5.62			0.82			9.13			1		
08/13/19 7:18	422509.6			0.8			5.62			0.82			9.12			1		
08/13/19 7:19	422124.5			0.8			5.72			0.82			9.26			1		
08/13/19 7:20	421431.4			0.8			5.72			0.82			9.25			1		
08/13/19 7:21	421739.5			0.8			5.81			0.82			9.4			1		
08/13/19 7:22	421046.3			0.8			5.81			0.81			9.39			1		
08/13/19 7:23	422355.6			0.8			5.81			0.82			9.42			1		
08/13/19 7:24	421739.5			0.8			3.6			0.82			5.82			1		
08/13/19 7:25	422047.5			0.8			2.67			0.82			4.33			1		
08/13/19 7:26	421662.4			0.8			2.12			0.82			3.43			1		
08/13/19 7:27	421123.3			0.8			2.12			0.81			3.43			1		
08/13/19 7:28	420815.3			0.8			2.21			0.81			3.57			1		
08/13/19 7:29	420969.3			0.8			2.21			0.81			3.58			1		
08/13/19 7:30	421123.3			0.8			2.3			0.81			3.73			1		
08/13/19 7:31	421354.4			0.7			2.3			0.72			3.73			1		
08/13/19 7:32	421893.5			0.7			2.3			0.73			3.73			1		
08/13/19 7:33	421354.4			0.8			2.21			0.82			3.58			1		

CT1 SUSD EVENT 4

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/17/19 22:52	402793.5			1.2			1.66			1.13			2.57			0		
08/17/19 22:53	381768.2			0.9			1.66			0.82			2.43			0		
08/17/19 22:54	360126.7			0.8			1.72			0.69			2.38			0		
08/17/19 22:55	335943.7			0.8			2.06			0.63			2.65			0		
08/17/19 22:56	312453.8			0.8			2.11			0.58			2.54			0		
08/17/19 22:57	290581.3			0.9			2.03			0.6			2.26			1		
08/17/19 22:58	273252.7			0.9			1.88			0.57			1.97			1		
08/17/19 22:59	252535.4			0.8			2.18			0.48			2.11			1		
08/17/19 23:00	229892.7			0.7			6.37			0.35			5.62			1		
08/17/19 23:01	207404			0.6			12.6			0.29			10.03			1		
08/17/19 23:02	183144			0.5			17.26			0.23			12.13			1		
08/17/19 23:03	160501.3			5.5			19.79			2.07			12.19			1		
08/17/19 23:04	141863.4			337.6			21.35			111.68			11.63			1		
08/17/19 23:05	103355.4			1333.6			22.16			321.5			8.79			1		
08/17/19 23:06	0			0			23.05			0			0			0		
08/17/19 23:07	0			0			35.4			0			0			0		
08/17/19 23:08	0			0			0.1			0			0			0		
08/17/19 23:09	0			0			0.1			0			0			0		
08/17/19 23:10	0			0			0.1			0			0			0		

CT1 SUSD EVENT 5

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/27/19 5:39	0			0			0			0			0			0		
08/27/19 5:40	0			0			0			0			0			0		
08/27/19 5:41	0			0			0			0			0			0		
08/27/19 5:42	0			0			0			0			0			0		
08/27/19 5:43	0			0			0			0			0			0		
08/27/19 5:44	0			0.2			0			0			0			1		
08/27/19 5:45	7932.6			0.2			0			0			0			1		
08/27/19 5:46	32346.7			85.6			30.98			6.45			3.85			1		
08/27/19 5:47	48443			510			17.7			57.65			3.29			1		
08/27/19 5:48	68621.2			333.9			23.01			53.45			6.06			1		
08/27/19 5:49	114907.8			185.9			26.01			49.8			11.47			1		
08/27/19 5:50	135394.1			77.8			43.57			24.58			22.65			1		
08/27/19 5:51	142941.6			241.5			53.65			80.5			29.43			1		
08/27/19 5:52	160347.3			1849.9			42.02			691.96			25.86			1		
08/27/19 5:53	182527.9			1384.4			51.46			589.4			36.06			1		
08/27/19 5:54	206633.9			289.8			66.2			139.68			52.5			1		
08/27/19 5:55	228737.4			20.7			72.06			11.05			63.26			1		
08/27/19 5:56	252612.4			2.4			67.68			1.44			65.63			1		
08/27/19 5:57	277411.5			2			55.54			1.32			59.15			1		
08/27/19 5:58	292891.8			1.9			35.85			1.3			40.31			1		
08/27/19 5:59	293970			1.9			16.73			1.33			18.88			1		
08/27/19 6:00	296588.5			2			13.65			1.4			15.54			1		
08/27/19 6:01	314379.2			1.9			12.69			1.38			15.32			1		
08/27/19 6:02	319231.2			1.8			12.24			1.31			15			1		
08/27/19 6:03	319154.2			1.7			10.66			1.25			13.06			1		
08/27/19 6:04	318615.1			1.6			9.77			1.18			11.96			1		
08/27/19 6:05	318384			1.5			8.98			1.11			10.98			1		
08/27/19 6:06	317382.8			1.4			8.58			1.06			10.46			1		
08/27/19 6:07	315842.5			1.3			7.78			0.99			9.43			1		
08/27/19 6:08	316227.6			1.3			7.6			0.92			9.22			1		
08/27/19 6:09	315919.5			1.2			7.51			0.86			9.11			1		
08/27/19 6:10	315996.5			1.2			7.33			0.86			8.89			1		
08/27/19 6:11	315688.5			1.1			7.24			0.79			8.77			1		
08/27/19 6:12	315380.4			1.1			7.06			0.79			8.55			1		
08/27/19 6:13	316150.6			1.1			7.08			0.8			8.59			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/27/19 6:14	331091.7			1.1			6.99			0.84			8.88			1		
08/27/19 6:15	339255.3			1			6.44			0.79			8.39			1		
08/27/19 6:16	340795.7			0.9			6.18			0.73			8.08			1		
08/27/19 6:17	341411.8			0.9			6.27			0.73			8.21			1		
08/27/19 6:18	341565.8			0.9			6.36			0.73			8.34			1		
08/27/19 6:19	341950.9			0.9			6.45			0.74			8.47			1		
08/27/19 6:20	341950.9			0.9			6.64			0.74			8.71			1		
08/27/19 6:21	341488.8			0.8			6.73			0.66			8.82			1		
08/27/19 6:22	337792.1			0.8			6.91			0.65			8.97			1		
08/27/19 6:23	320694.5			0.8			7.1			0.62			8.74			1		
08/27/19 6:24	308294.9			0.9			7.9			0.65			9.34			1		
08/27/19 6:25	307370.8			0.9			7.87			0.64			9.28			1		
08/27/19 6:26	307370.8			0.9			8.08			0.65			9.53			1		
08/27/19 6:27	307062.7			0.9			8.26			0.65			9.74			1		
08/27/19 6:28	307139.7			0.9			8.35			0.65			9.84			1		
08/27/19 6:29	307062.7			0.9			6.72			0.65			7.92			1		
08/27/19 6:30	307216.7			0.9			3.54			0.65			4.17			1		
08/27/19 6:31	307139.7			0.9			3			0.65			3.53			1		
08/27/19 6:32	306831.6			0.9			3			0.65			3.53			1		
08/27/19 6:33	306831.6			0.9			3			0.65			3.53			1		
08/27/19 6:34	306831.6			0.9			3.27			0.65			3.85			1		
08/27/19 6:35	305830.4			0.9			3.54			0.65			4.16			1		
08/27/19 6:36	303211.9			0.9			3.63			0.64			4.23			1		
08/27/19 6:37	302595.8			0.9			3.18			0.64			3.69			1		
08/27/19 6:38	299669.2			0.9			2.81			0.63			3.24			1		
08/27/19 6:39	298899			0.8			2.63			0.57			3.02			1		

CT1 SUSD EVENT 6

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/29/19 22:50	312607.8			0.8			1.7			0.59			2.04			0		
08/29/19 22:51	312992.9			0.8			1.7			0.59			2.04			0		
08/29/19 22:52	313378			0.8			1.7			0.59			2.04			0		
08/29/19 22:53	313069.9			0.8			1.7			0.59			2.04			0		
08/29/19 22:54	313069.9			0.8			1.7			0.59			2.04			0		
08/29/19 22:55	313069.9			0.8			1.7			0.59			2.04			1		
08/29/19 22:56	301517.5			0.8			1.7			0.57			1.97			1		
08/29/19 22:57	279953.1			0.8			1.7			0.53			1.83			1		
08/29/19 22:58	259235.8			0.8			2			0.49			1.99			1		
08/29/19 22:59	236439			0.7			5.53			0.41			5.02			1		
08/29/19 23:00	215490.7			0.6			9.05			0.3			7.48			1		

CT1 SUSD EVENT 7

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/04/19 5:39	0			0			0			0			0			0		
09/04/19 5:40	0			0			0			0			0			0		
09/04/19 5:41	0			0			0			0			0			0		
09/04/19 5:42	0			0			0			0			0			0		
09/04/19 5:43	0			0			0			0			0			0		
09/04/19 5:44	0			0.3			0			0			0			1		
09/04/19 5:45	0			0.3			0			0			0			1		
09/04/19 5:46	4004.8			1.1			0.2			0			0			1		
09/04/19 5:47	30190.3			645.8			20.38			45.54			2.37			1		
09/04/19 5:48	46748.7			488.8			18.63			53.28			3.34			1		
09/04/19 5:49	80250.6			314.8			24.49			58.9			7.54			1		
09/04/19 5:50	128308.6			178.3			26.28			53.37			12.95			1		
09/04/19 5:51	136087.2			73.1			45.09			23.21			23.56			1		
09/04/19 5:52	153569.8			970.6			46.28			347.61			27.28			1		
09/04/19 5:53	174441.2			1817.2			44.42			739.51			29.75			1		
09/04/19 5:54	197160.9			723.3			57.49			332.55			43.5			1		
09/04/19 5:55	221652			79.9			67.58			41.32			57.51			1		
09/04/19 5:56	242215.2			5.7			66.55			3.2			61.88			1		
09/04/19 5:57	269632.9			2.8			58.89			1.79			60.97			1		
09/04/19 5:58	292275.6			2.7			42.54			1.82			47.73			1		
09/04/19 5:59	311991.7			2.7			24.3			1.99			29.11			1		
09/04/19 6:00	330937.6			3			14.75			2.28			18.74			1		
09/04/19 6:01	348266.2			3.1			13.54			2.54			18.1			1		
09/04/19 6:02	366056.9			3.3			10.66			2.78			14.97			1		
09/04/19 6:03	388853.7			3.4			9.08			3.13			13.55			1		
09/04/19 6:04	412343.5			3.5			8.2			3.37			12.99			1		
09/04/19 6:05	428131.8			3.6			7.01			3.59			11.51			1		
09/04/19 6:06	423433.8			3.7			7.38			3.64			11.99			1		
09/04/19 6:07	421970.5			4			6.36			3.9			10.3			1		
09/04/19 6:08	421277.4			4.1			6.18			4.08			9.99			1		
09/04/19 6:09	420969.3			4.1			6.08			4.07			9.83			1		
09/04/19 6:10	420276.2			4.1			5.9			3.98			9.52			1		
09/04/19 6:11	420507.2			4.1			5.9			3.98			9.52			1		
09/04/19 6:12	420430.2			4.1			5.9			3.98			9.52			1		
09/04/19 6:13	420661.3			3.8			5.9			3.71			9.53			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/04/19 6:14	422278.6			3.6			5.9			3.51			9.56			1		
09/04/19 6:15	424281			3.3			5.81			3.24			9.46			1		
09/04/19 6:16	424897.1			3.1			5.72			3.11			9.32			1		
09/04/19 6:17	425205.2			3.2			5.81			3.2			9.48			1		
09/04/19 6:18	425282.2			3.3			5.9			3.29			9.63			1		
09/04/19 6:19	425821.3			3.2			5.9			3.2			9.64			1		
09/04/19 6:20	425898.3			3			5.99			2.93			9.8			1		
09/04/19 6:21	425821.3			3			6.08			2.93			9.95			1		
09/04/19 6:22	426283.4			3			6.18			2.93			10.11			1		
09/04/19 6:23	425898.3			2.8			5.53			2.75			9.04			1		
09/04/19 6:24	425744.3			2.4			2.95			2.38			4.82			1		
09/04/19 6:25	425205.2			2.2			2.12			2.19			3.46			1		
09/04/19 6:26	426052.3			2.3			2.12			2.29			3.47			1		
09/04/19 6:27	425898.3			2.5			2.12			2.47			3.47			1		
09/04/19 6:28	425513.3			2.6			2.4			2.56			3.92			1		
09/04/19 6:29	424974.1			2.8			2.86			2.74			4.66			1		
09/04/19 6:30	425205.2			2.9			2.86			2.83			4.67			1		
09/04/19 6:31	424589.1			3.1			2.77			3.1			4.51			1		

CT1 SUSD EVENT 8

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/05/19 22:51	355582.8			0.8			1.66			0.69			2.26			0		
09/05/19 22:52	342027.9			0.8			1.75			0.66			2.3			0		
09/05/19 22:53	330013.4			0.8			1.82			0.63			2.3			0		
09/05/19 22:54	313840.1			0.9			1.82			0.66			2.19			0		
09/05/19 22:55	298976			0.9			1.79			0.62			2.05			0		
09/05/19 22:56	278566.8			0.9			1.82			0.59			1.94			1		
09/05/19 22:57	256694.2			0.8			1.75			0.5			1.73			1		
09/05/19 22:58	233666.5			0.8			4.19			0.41			3.76			1		
09/05/19 22:59	214797.5			0.7			8.46			0.34			6.97			1		
09/05/19 23:00	187996			0.5			15.07			0.23			10.87			1		
09/05/19 23:01	164891.2			2.8			18.41			1.09			11.65			1		
09/05/19 23:02	145560.2			146.7			20.52			49.81			11.47			1		
09/05/19 23:03	107206.2			1146.2			20.96			286.58			8.63			1		
09/05/19 23:04	0			0			22.71			0			0			0		
09/05/19 23:05	0			0			26.55			0			0			0		
09/05/19 23:06	0			0			0.2			0			0			0		
09/05/19 23:07	0			0			0.2			0			0			0		
09/05/19 23:08	0			0			0.1			0			0			0		

CT1 SUSD EVENT 9

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/11/19 8:40	0			0			0			0			0			0		
09/11/19 8:41	0			0			0			0			0			0		
09/11/19 8:42	0			0			0			0			0			0		
09/11/19 8:43	0			0			0			0			0			0		
09/11/19 8:44	0			0			0			0			0			0		
09/11/19 8:45	0			0.2			0			0			0			1		
09/11/19 8:46	0			0.2			0			0			0			1		
09/11/19 8:47	19485			129.8			64.9			5.93			4.88			1		
09/11/19 8:48	40664.4			588.9			17.7			56.16			2.78			1		
09/11/19 8:49	59225.3			427			21.43			59.26			4.89			1		
09/11/19 8:50	101045			240.8			25.57			57.02			9.96			1		
09/11/19 8:51	136472.3			121.4			36.88			38.85			19.41			1		
09/11/19 8:52	140862.2			57.8			53.49			19.09			29.07			1		
09/11/19 8:53	160347.3			1535.1			41.48			576.95			25.66			1		
09/11/19 8:54	181988.8			1551.4			46.36			661.54			32.53			1		
09/11/19 8:55	206787.9			356.2			61.21			172.63			48.82			1		
09/11/19 8:56	229507.6			29.4			67.85			15.8			60.06			1		
09/11/19 8:57	252304.3			2.6			65.92			1.54			64.16			1		
09/11/19 8:58	277796.6			1.8			55.54			1.19			59.52			1		
09/11/19 8:59	300362.3			1.8			37.06			1.23			42.94			1		
09/11/19 9:00	312453.8			1.8			18.13			1.33			21.85			1		
09/11/19 9:01	313609			2			14.23			1.47			17.21			1		
09/11/19 9:02	318692.1			1.9			13.19			1.43			16.21			1		
09/11/19 9:03	320309.4			1.7			11.54			1.3			14.26			1		
09/11/19 9:04	316227.6			1.6			10.06			1.22			12.28			1		
09/11/19 9:05	314379.2			1.6			9.16			1.17			11.11			1		
09/11/19 9:06	315149.3			1.5			8.37			1.11			10.17			1		
09/11/19 9:07	314610.3			1.4			7.66			1.04			9.3			1		
09/11/19 9:08	314456.2			1.3			7.31			0.97			8.86			1		
09/11/19 9:09	314148.2			1.3			6.88			0.92			8.34			1		
09/11/19 9:10	312684.8			1.2			6.79			0.85			8.19			1		
09/11/19 9:11	312145.8			1.2			6.62			0.85			7.96			1		
09/11/19 9:12	312376.8			1.1			6.44			0.79			7.76			1		
09/11/19 9:13	312453.8			1.1			6.35			0.79			7.65			1		
09/11/19 9:14	311221.5			1.1			6.26			0.78			7.51			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/11/19 9:15	310836.5			1			6.26			0.72			7.5			1		
09/11/19 9:16	310990.5			1			6.26			0.72			7.51			1		
09/11/19 9:17	311067.5			1			6.26			0.73			7.51			1		
09/11/19 9:18	310836.5			0.9			6.17			0.65			7.39			1		
09/11/19 9:19	310759.4			0.9			6.17			0.65			7.39			1		
09/11/19 9:20	310374.4			0.9			6.35			0.66			7.61			1		
09/11/19 9:21	310836.5			0.9			6.35			0.66			7.62			1		
09/11/19 9:22	310836.5			0.9			6.35			0.66			7.62			1		
09/11/19 9:23	303519.9			0.9			6.44			0.65			7.55			1		
09/11/19 9:24	288039.8			0.9			6.72			0.61			7.46			1		
09/11/19 9:25	285960.3			0.8			6.36			0.56			7.02			1		
09/11/19 9:26	285421.2			0.8			6.27			0.55			6.9			1		
09/11/19 9:27	286114.3			0.7			6.18			0.49			6.82			1		
09/11/19 9:28	286191.3			0.7			6.37			0.5			7.03			1		
09/11/19 9:29	285498.2			0.7			4.78			0.5			5.26			1		
09/11/19 9:30	285652.3			0.7			3.18			0.5			3.51			1		
09/11/19 9:31	285883.3			0.7			2.81			0.5			3.1			1		
09/11/19 9:32	285498.2			0.7			2.62			0.5			2.89			1		
09/11/19 9:33	285575.2			0.7			2.43			0.5			2.68			1		
09/11/19 9:34	285575.2			0.7			2.43			0.5			2.68			1		
09/11/19 9:35	285344.2			0.7			2.43			0.5			2.68			1		
09/11/19 9:36	285575.2			0.7			2.43			0.5			2.68			1		
09/11/19 9:37	285575.2			0.7			2.43			0.5			2.68			1		
09/11/19 9:38	285421.2			0.7			2.34			0.5			2.58			1		
09/11/19 9:39	285806.3			0.7			2.25			0.5			2.48			1		
09/11/19 9:40	285267.2			0.7			2.15			0.5			2.37			1		
09/11/19 9:41	285344.2			0.7			2.06			0.5			2.27			1		
09/11/19 9:42	284497			0.7			1.87			0.5			2.06			1		
09/11/19 9:43	284882.1			0.7			1.78			0.5			1.96			1		
09/11/19 9:44	284574			0.7			1.69			0.5			1.85			0		
09/11/19 9:45	285036.1			0.7			1.69			0.5			1.85			0		
09/11/19 9:46	284959.1			0.7			1.69			0.5			1.85			0		
09/11/19 9:47	285113.1			0.7			1.59			0.5			1.75			0		
09/11/19 9:48	285036.1			0.7			1.59			0.5			1.75			0		

CT1 SUSD EVENT 10

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/12/19 11:46	355582.8			0.8			1.72			0.68			2.37			0		
09/12/19 11:47	355428.7			0.8			1.72			0.68			2.36			0		
09/12/19 11:48	354966.6			0.8			1.72			0.68			2.36			0		
09/12/19 11:49	355120.7			0.8			1.72			0.68			2.36			0		
09/12/19 11:50	354735.6			0.8			1.72			0.68			2.36			0		
09/12/19 11:51	346186.8			0.8			1.72			0.66			2.3			1		
09/12/19 11:52	327086.8			0.8			1.72			0.63			2.18			1		
09/12/19 11:53	304444.1			0.8			1.88			0.57			2.2			1		
09/12/19 11:54	282879.7			0.9			2.41			0.59			2.63			1		
09/12/19 11:55	262162.4			0.8			2.45			0.5			2.48			1		
09/12/19 11:56	238210.4			0.7			5.15			0.42			4.73			1		
09/12/19 11:57	218032.2			0.7			9.44			0.35			7.94			1		
09/12/19 11:58	193079			0.5			16.75			0.24			12.48			1		
09/12/19 11:59	170975.5			3			19.59			1.18			12.92			1		
09/12/19 12:00	151028.3			187.6			21.32			66.39			12.42			1		
09/12/19 12:01	133930.8			1251.4			21.74			392.74			11.23			1		
09/12/19 12:02	30729.4			1886.2			22.53			135.96			2.67			1		
09/12/19 12:03	20563.3			0			22.42			146.4			1.78			0		
09/12/19 12:04	19562.1			0			0.2			0			0			0		
09/12/19 12:05	18329.8			0			0.1			0			0			0		
09/12/19 12:06	17482.6			0			0.1			0			0			0		
09/12/19 12:07	16866.5			0			0.1			0			0			0		

CT1 SUSD EVENT 11

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/24/19 7:38	0			0			0			0			0			0		
09/24/19 7:39	0			0			0			0			0			0		
09/24/19 7:40	0			0			0			0			0			0		
09/24/19 7:41	0			0			0			0			0			0		
09/24/19 7:42	0			0			0			0			0			0		
09/24/19 7:43	0			0.2			0			0			0			1		
09/24/19 7:44	0			0			0			0			0			0		
09/24/19 7:45	0			0			0			0			0			0		
09/24/19 7:46	0			0			0			0			0			0		
09/24/19 7:47	0			0			0			0			0			0		
09/24/19 7:48	0			0			0			0			0			0		

CT1 SUSD EVENT 11

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/24/19 7:38	0			0			0			0			0			0		
09/24/19 7:39	0			0			0			0			0			0		
09/24/19 7:40	0			0			0			0			0			0		
09/24/19 7:41	0			0			0			0			0			0		
09/24/19 7:42	0			0			0			0			0			0		
09/24/19 7:43	0			0.2			0			0			0			1		
09/24/19 7:44	0			0			0			0			0			0		
09/24/19 7:45	0			0			0			0			0			0		
09/24/19 7:46	0			0			0			0			0			0		
09/24/19 7:47	0			0			0			0			0			0		
09/24/19 7:48	0			0			0			0			0			0		

CT1 SUSD EVENT 13

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/24/19 7:51	0			0			0			0			0			0		
09/24/19 7:52	0			0			0			0			0			0		
09/24/19 7:53	0			0			0			0			0			0		
09/24/19 7:54	0			0			0			0			0			0		
09/24/19 7:55	0			0			0			0			0			0		
09/24/19 7:56	0			0.2			0			0			0			1		
09/24/19 7:57	0			0.2			0			0			0			1		
09/24/19 7:58	5853.2			1.6			0.1			0			0			1		
09/24/19 7:59	31807.6			690.9			23.01			51.5			2.82			1		
09/24/19 8:00	49675.3			491.6			19.56			57.22			3.75			1		
09/24/19 8:01	82869.2			306.8			25.96			59.61			8.3			1		
09/24/19 8:02	128924.7			162.1			31.81			48.99			15.82			1		
09/24/19 8:03	136626.3			62			52.05			19.84			27.44			1		
09/24/19 8:04	142864.6			846.2			45.23			283.37			24.93			1		
09/24/19 8:05	153723.9			1891.8			38.44			681.35			22.79			1		
09/24/19 8:06	174056.1			1783.3			40.79			727.32			27.38			1		
09/24/19 8:07	198085.1			709.2			52.95			329.26			40.46			1		
09/24/19 8:08	221343.9			70.5			63.56			36.58			54.25			1		
09/24/19 8:09	242677.3			5.3			65.37			3.02			61.19			1		
09/24/19 8:10	270326.1			2.3			59.32			1.47			61.84			1		
09/24/19 8:11	292121.6			2.2			43.2			1.5			48.67			1		
09/24/19 8:12	308834.1			2.1			23.07			1.53			27.48			1		
09/24/19 8:13	305830.4			2.2			14.06			1.55			16.58			1		
09/24/19 8:14	292583.7			2.1			13.28			1.43			14.98			1		
09/24/19 8:15	290427.2			1.9			10.74			1.32			12.04			1		
09/24/19 8:16	290273.2			1.8			9.3			1.22			10.41			1		
09/24/19 8:17	289888.1			1.6			8.85			1.09			9.9			1		
09/24/19 8:18	292583.7			1.5			8.08			1			9.12			1		
09/24/19 8:19	311991.7			1.4			7.35			1			8.85			1		
09/24/19 8:20	327086.8			1.3			7.26			0.97			9.16			1		
09/24/19 8:21	329705.4			1.2			6.62			0.9			8.41			1		
09/24/19 8:22	330013.4			1.2			6.44			0.91			8.2			1		
09/24/19 8:23	329936.4			1.2			6.44			0.9			8.19			1		
09/24/19 8:24	333402.2			1.1			6.44			0.84			8.28			1		
09/24/19 8:25	342413			1.1			6.26			0.87			8.27			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/24/19 8:26	344107.4			1			5.81			0.81			7.71			1		
09/24/19 8:27	344184.4			1			5.9			0.82			7.83			1		
09/24/19 8:28	343876.3			1			5.99			0.82			7.95			1		
09/24/19 8:29	345031.6			0.9			5.9			0.73			7.85			1		
09/24/19 8:30	345185.6			0.9			5.99			0.75			7.98			1		
09/24/19 8:31	345416.6			0.9			5.99			0.75			7.98			1		
09/24/19 8:32	345878.7			0.9			6.08			0.75			8.12			1		
09/24/19 8:33	347188			0.9			6.18			0.75			8.27			1		
09/24/19 8:34	347573.1			0.8			6.27			0.68			8.4			1		
09/24/19 8:35	338947.3			0.8			6.64			0.66			8.68			1		
09/24/19 8:36	334480.4			0.9			6.81			0.71			8.78			1		
09/24/19 8:37	332015.8			0.9			6.81			0.71			8.72			1		
09/24/19 8:38	331168.7			0.9			6.9			0.7			8.81			1		
09/24/19 8:39	331245.7			0.9			6.9			0.7			8.81			1		
09/24/19 8:40	330552.6			0.9			4.54			0.7			5.79			1		
09/24/19 8:41	331245.7			0.9			2.81			0.7			3.59			1		
09/24/19 8:42	326855.8			0.9			2.72			0.7			3.43			1		
09/24/19 8:43	322851			0.8			2.72			0.62			3.39			1		
09/24/19 8:44	322465.9			0.9			2.81			0.69			3.5			1		
09/24/19 8:45	322773.9			0.9			3			0.69			3.73			1		
09/24/19 8:46	322851			0.9			3.09			0.69			3.84			1		
09/24/19 8:47	322928			0.9			2.9			0.69			3.62			1		
09/24/19 8:48	321079.6			0.9			2.72			0.68			3.37			1		
09/24/19 8:49	320771.5			0.9			2.54			0.68			3.14			1		
09/24/19 8:50	320309.4			0.9			2.27			0.68			2.8			1		
09/24/19 8:51	320078.4			0.9			2.09			0.68			2.58			1		
09/24/19 8:52	319462.3			0.9			1.91			0.68			2.35			1		
09/24/19 8:53	319000.2			0.9			1.82			0.68			2.23			1		
09/24/19 8:54	319154.2			0.8			1.72			0.61			2.12			1		
09/24/19 8:55	319231.2			0.8			1.63			0.61			2.01			0		
09/24/19 8:56	319616.3			0.8			1.54			0.61			1.9			0		
09/24/19 8:57	319154.2			0.8			1.54			0.61			1.9			0		
09/24/19 8:58	319539.3			0.9			1.54			0.68			1.9			0		
09/24/19 8:59	319308.2			0.8			1.54			0.61			1.9			0		

CT1 SUSD EVENT 14

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/26/19 22:58	163967			3.2			19			1.22			12.02			1		
09/26/19 22:59	144019.9			228			20.92			76.95			11.62			1		
09/26/19 23:00	106128			1291			21.43			321.07			8.77			1		
09/26/19 23:01	0			0			23.42			0			0			0		
09/26/19 23:02	0			0			25.08			0			0			0		
09/26/19 23:03	0			0			0.1			0			0			0		
09/26/19 23:04	0			0			0.1			0			0			0		
09/26/19 23:05	0			0			0.1			0			0			0		

CT1 SUSD EVENT 15

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/30/19 6:39	0			0			0			0			0			0		
09/30/19 6:40	0			0			0			0			0			0		
09/30/19 6:41	0			0			0			0			0			0		
09/30/19 6:42	0			0			0			0			0			0		
09/30/19 6:43	0			0			0			0			0			0		
09/30/19 6:44	0			0.3			0			0			0			1		
09/30/19 6:45	0			0.3			0			0			0			1		
09/30/19 6:46	0			1.4			0.4			0			0			1		
09/30/19 6:47	24722.1			702.6			19.67			40.73			1.88			1		
09/30/19 6:48	48135			540.8			19.34			61.02			3.59			1		
09/30/19 6:49	85333.7			333.6			24.19			66.69			7.96			1		
09/30/19 6:50	130850.1			191.8			25.48			58.8			12.86			1		
09/30/19 6:51	139630			72			48.01			23.57			25.86			1		
09/30/19 6:52	155341.2			1143.3			45.73			416.13			27.39			1		
09/30/19 6:53	176289.6			1889.4			47.38			780.75			32.22			1		
09/30/19 6:54	200087.5			919.9			59.16			431.41			45.66			1		
09/30/19 6:55	223269.3			115.9			65.84			60.63			56.71			1		
09/30/19 6:56	242754.3			7.8			66.83			4.45			62.58			1		
09/30/19 6:57	271250.3			2.3			59.97			1.43			62.74			1		
09/30/19 6:58	295048.2			2			45.33			1.36			51.59			1		
09/30/19 6:59	313609			1.9			26.95			1.42			32.59			1		
09/30/19 7:00	333017.1			2.1			14.11			1.6			18.12			1		
09/30/19 7:01	351038.8			2.1			12.83			1.69			17.36			1		
09/30/19 7:02	367674.3			1.9			10.67			1.65			15.14			1		
09/30/19 7:03	390625			1.8			8.85			1.64			13.33			1		
09/30/19 7:04	411419.3			1.5			8.17			1.49			12.97			1		
09/30/19 7:05	419429			1.4			7.56			1.36			12.23			1		
09/30/19 7:06	420584.2			1.3			7.38			1.27			11.96			1		
09/30/19 7:07	420738.3			1.1			7.1			1.09			11.52			1		
09/30/19 7:08	420199.2			1.1			6.82			1.09			11.06			1		
09/30/19 7:09	420430.2			1.1			6.64			1.09			10.76			1		
09/30/19 7:10	420045.1			1.1			6.55			1.09			10.6			1		
09/30/19 7:11	418427.8			1			6.45			0.99			10.42			1		
09/30/19 7:12	417734.6			1			6.45			0.99			10.4			1		
09/30/19 7:13	417195.5			1			6.45			0.99			10.38			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/30/19 7:14	416887.5			1			6.45			0.99			10.38			1		
09/30/19 7:15	416425.4			1			6.36			0.99			10.22			1		
09/30/19 7:16	415886.3			1			6.36			0.99			10.2			1		
09/30/19 7:17	415732.2			0.9			6.27			0.9			10.05			1		
09/30/19 7:18	415347.1			0.9			6.27			0.9			10.04			1		
09/30/19 7:19	415347.1			0.9			6.36			0.9			10.19			1		
09/30/19 7:20	414654			0.9			6.45			0.9			10.32			1		
09/30/19 7:21	414345.9			0.9			6.55			0.9			10.46			1		
09/30/19 7:22	414345.9			0.9			6.64			0.9			10.61			1		
09/30/19 7:23	414422.9			0.8			5.44			0.81			8.69			1		
09/30/19 7:24	414500			0.8			2.86			0.81			4.57			1		
09/30/19 7:25	413960.8			0.8			2.4			0.8			3.83			1		
09/30/19 7:26	413806.8			0.8			2.3			0.8			3.68			1		
09/30/19 7:27	414191.9			0.8			2.77			0.81			4.42			1		
09/30/19 7:28	413575.8			0.8			3.13			0.8			5			1		
09/30/19 7:29	413806.8			0.8			3.13			0.8			5			1		
09/30/19 7:30	413267.7			0.8			3.04			0.8			4.85			1		
09/30/19 7:31	413344.7			0.8			2.49			0.8			3.97			1		
09/30/19 7:32	413267.7			0.8			2.21			0.8			3.53			1		
09/30/19 7:33	413190.7			0.8			2.12			0.8			3.38			1		
09/30/19 7:34	412882.6			0.8			2.03			0.8			3.23			1		
09/30/19 7:35	413036.7			0.8			1.84			0.8			2.94			1		
09/30/19 7:36	413267.7			0.8			1.84			0.8			2.94			1		
09/30/19 7:37	413036.7			0.8			1.75			0.8			2.79			0		
09/30/19 7:38	412574.6			0.8			1.75			0.8			2.79			0		
09/30/19 7:39	412728.6			0.8			1.66			0.8			2.64			0		
09/30/19 7:40	412343.5			0.8			1.66			0.8			2.64			0		
09/30/19 7:41	412574.6			0.8			1.66			0.8			2.64			0		

CT1 SUSD EVENT 16

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/30/19 11:58	215798.8			0.7			9.54			0.35			7.94			1		
09/30/19 11:59	190845.6			0.5			16.84			0.24			12.4			1		
09/30/19 12:00	167586.8			2.2			19.47			0.88			12.59			1		
09/30/19 12:01	147254.5			164.5			21.95			56.79			12.47			1		
09/30/19 12:02	120453			1107.2			21.89			312.52			10.17			1		
09/30/19 12:03	0			1892.6			22.53			0			0			1		
09/30/19 12:04	0			0			24.78			0			0			0		
09/30/19 12:05	0			0			0.2			0			0			0		
09/30/19 12:06	0			0			0.2			0			0			0		
09/30/19 12:07	0			0			0.1			0			0			0		
09/30/19 12:08	0			0			0.1			0			0			0		

Startup / Shutdown Events

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:07 **Location:** Roseville, CA

Unit Offline

Tag Name: CT2_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
07/01/2019 00:00	07/22/2019 11:00	516
07/23/2019 13:00	07/27/2019 21:00	105
08/08/2019 06:00	08/14/2019 05:00	144
08/17/2019 00:00	08/25/2019 06:00	199
08/30/2019 00:00	09/04/2019 05:00	126
09/06/2019 00:00	09/09/2019 21:00	94
09/11/2019 13:00	09/12/2019 07:00	19
09/13/2019 00:00	09/23/2019 06:00	247
09/28/2019 00:00	09/30/2019 09:00	58
09/30/2019 18:00	09/30/2019 23:00	6

Startup / Shutdown Events

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:07 **Location:** Roseville, CA

Operating Time Summary	
Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	1,514.00 Hour(s)
Offline Percentage:	68.57 %
Total Online:	694.00 Hour(s)
Online Percentage:	31.43 %

Startup / Shutdown Events

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:07 **Location:** Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	07/22/2019 12:55	07/22/2019 13:49	Cold Startup	55
2	07/23/2019 11:56	07/23/2019 12:04	Shutdown	9
3	07/27/2019 22:45	07/27/2019 23:33	Cold Startup	49
4	08/08/2019 04:55	08/08/2019 05:03	Shutdown	9
5	08/14/2019 06:44	08/14/2019 07:30	Cold Startup	47
6	08/16/2019 22:56	08/16/2019 23:04	Shutdown	9
7	08/25/2019 07:43	08/25/2019 08:29	Cold Startup	47
8	08/29/2019 22:57	08/29/2019 23:07	Shutdown	11
9	09/04/2019 06:46	09/04/2019 07:31	Cold Startup	46
10	09/05/2019 23:00	09/05/2019 23:08	Shutdown	9
11	09/09/2019 22:43	09/09/2019 23:36	Cold Startup	54
12	09/11/2019 11:52	09/11/2019 12:07	Shutdown	16
13	09/12/2019 08:45	09/12/2019 09:33	Cold Startup	49
14	09/12/2019 22:57	09/12/2019 23:05	Shutdown	9
15	09/23/2019 07:44	09/23/2019 08:34	Cold Startup	51
16	09/27/2019 22:55	09/27/2019 23:04	Shutdown	10
17	09/30/2019 10:45	09/30/2019 11:35	Cold Startup	51
18	09/30/2019 17:04	09/30/2019 17:13	Shutdown	10

Startup / Shutdown Events

CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/14/2019 10:07 **Location:** Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	9	449	1.10
Warm Startup	0		0.00
Shutdown	9	92	0.23
Total Process Events:	18	541	1.33

Total Report Time:	2,207.98 Hour(s)
Total Operating Time:	679.23 Hour(s)
Total Startup Time:	449 Minute(s)
Total Shutdown Time:	92 Minute(s)
Total Startup/Shutdown Time:	541 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	1.33 %

CT2 SUSD EVENT 1

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/22/19 12:50	0			0			0			0			0			0		
07/22/19 12:51	0			0			0			0			0			0		
07/22/19 12:52	0			0			0			0			0			0		
07/22/19 12:53	0			0			0			0			0			0		
07/22/19 12:54	4698			0			0			0			0			0		
07/22/19 12:55	0			0.2			0			0			0			1		
07/22/19 12:56	24645.1			0.2			0			0			0			1		
07/22/19 12:57	38122.9			1.3			0.3			0			0			1		
07/22/19 12:58	50676.5			454.3			18.54			53.69			3.61			1		
07/22/19 12:59	63153.1			365.2			19.67			53.8			4.77			1		
07/22/19 13:00	86951			212.9			23.87			43.18			7.97			1		
07/22/19 13:01	133930.8			110.6			30.98			34.57			15.93			1		
07/22/19 13:02	145175.1			35.8			46.81			12.12			26.09			1		
07/22/19 13:03	156188.4			17			44.25			6.19			26.52			1		
07/22/19 13:04	177752.9			1531.4			34.36			634.86			23.44			1		
07/22/19 13:05	203476.2			658.6			46.42			312.55			36.26			1		
07/22/19 13:06	228352.4			57.7			51.76			30.71			45.36			1		
07/22/19 13:07	253459.6			4.4			56.05			2.58			54.53			1		
07/22/19 13:08	279413.9			1.7			63.64			1.1			68.24			1		
07/22/19 13:09	304521.2			1.6			51.39			1.15			60.07			1		
07/22/19 13:10	315611.5			1.8			25.51			1.34			30.9			1		
07/22/19 13:11	314764.3			1.9			17.52			1.38			21.17			1		
07/22/19 13:12	313994.1			1.8			14.75			1.31			17.78			1		
07/22/19 13:13	313224			1.6			13.77			1.18			16.55			1		
07/22/19 13:14	312684.8			1.4			12.6			1.04			15.13			1		
07/22/19 13:15	312761.9			1.4			11.26			1.04			13.52			1		
07/22/19 13:16	312761.9			1.3			10.46			0.98			12.56			1		
07/22/19 13:17	311298.6			1.3			9.62			0.92			11.5			1		
07/22/19 13:18	312376.8			1.2			9.08			0.86			10.88			1		
07/22/19 13:19	311683.6			1.1			8.71			0.79			10.43			1		
07/22/19 13:20	309681.2			1			8.35			0.72			9.93			1		
07/22/19 13:21	311144.5			1			8.08			0.72			9.65			1		
07/22/19 13:22	311298.6			0.9			7.9			0.66			9.44			1		
07/22/19 13:23	308603			0.9			7.72			0.65			9.14			1		
07/22/19 13:24	309373.2			0.8			7.62			0.59			9.06			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/22/19 13:25	309296.2			0.9			7.53			0.65			8.95			1		
07/22/19 13:26	307293.7			0.9			7.65			0.66			9.03			1		
07/22/19 13:27	307986.9			0.9			7.74			0.66			9.15			1		
07/22/19 13:28	309681.2			0.8			7.74			0.6			9.21			1		
07/22/19 13:29	309065.1			0.8			7.84			0.6			9.3			1		
07/22/19 13:30	308063.9			0.8			7.93			0.6			9.38			1		
07/22/19 13:31	308371.9			0.8			7.93			0.6			9.38			1		
07/22/19 13:32	307293.7			0.8			7.93			0.59			9.35			1		
07/22/19 13:33	307293.7			0.7			7.93			0.53			9.35			1		
07/22/19 13:34	308757			0.7			8.02			0.53			9.51			1		
07/22/19 13:35	306985.7			0.7			8.11			0.53			9.56			1		
07/22/19 13:36	307447.8			0.7			8.2			0.53			9.68			1		
07/22/19 13:37	306600.6			0.7			8.3			0.53			9.77			1		
07/22/19 13:38	306677.6			0.7			8.39			0.53			9.88			1		
07/22/19 13:39	306831.6			0.7			6.45			0.53			7.6			1		
07/22/19 13:40	306523.6			0.7			3.69			0.53			4.34			1		
07/22/19 13:41	307909.8			0.7			3.32			0.53			3.92			1		
07/22/19 13:42	307524.8			0.7			2.95			0.53			3.48			1		
07/22/19 13:43	305522.4			0.7			2.67			0.53			3.14			1		
07/22/19 13:44	305676.4			0.7			2.4			0.53			2.81			1		

CT2 SUSD EVENT 2

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/23/19 11:51	426437.4			0.8			1.66			0.83			2.72			0		
07/23/19 11:52	404487.9			0.8			1.59			0.8			2.47			0		
07/23/19 11:53	381152			0.7			1.57			0.66			2.29			0		
07/23/19 11:54	354350.5			0.8			1.43			0.66			1.95			0		
07/23/19 11:55	327548.9			0.9			1.34			0.68			1.69			0		
07/23/19 11:56	306446.6			0.9			1.32			0.63			1.55			1		
07/23/19 11:57	284034.9			0.9			1.27			0.6			1.39			1		
07/23/19 11:58	261623.3			0.8			1.97			0.51			1.98			1		
07/23/19 11:59	239981.8			0.7			5.61			0.38			5.17			1		
07/23/19 12:00	213488.3			0.6			9.83			0.31			8.06			1		
07/23/19 12:01	188073			0.6			17.59			0.25			12.7			1		
07/23/19 12:02	163350.9			8.6			20.01			3.27			12.55			1		
07/23/19 12:03	145098.1			621.4			22.57			210.32			12.57			1		
07/23/19 12:04	61381.7			1598.9			25.12			229.06			5.92			1		
07/23/19 12:05	0			0			25.96			0			0			0		
07/23/19 12:06	0			0			11.8			0			0			0		
07/23/19 12:07	0			0			0.1			0			0			0		
07/23/19 12:08	0			0			0.1			0			0			0		
07/23/19 12:09	0			0			0.1			0			0			0		

CT2 SUSD EVENT 3

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/27/19 22:40	0			0			0			0			0			0		
07/27/19 22:41	0			0			0			0			0			0		
07/27/19 22:42	0			0			0			0			0			0		
07/27/19 22:43	0			0			0			0			0			0		
07/27/19 22:44	21025.4			0			0			0			0			0		
07/27/19 22:45	17020.5			0.4			0			0			0			1		
07/27/19 22:46	35042.3			0.4			0			0			0			1		
07/27/19 22:47	47595.9			45.5			22.76			5.05			4.16			1		
07/27/19 22:48	58532.1			440.4			17.11			60.14			3.85			1		
07/27/19 22:49	74859.5			287.7			23.04			50.23			6.62			1		
07/27/19 22:50	120684			160.1			25.14			45.04			11.64			1		
07/27/19 22:51	148332.8			64.7			40.86			22.38			23.27			1		
07/27/19 22:52	157420.6			108.3			51.67			39.77			31.22			1		
07/27/19 22:53	177906.9			1416.7			37.83			587.94			25.84			1		
07/27/19 22:54	201627.8			881.5			48.95			414.57			37.89			1		
07/27/19 22:55	227274.1			135.3			58.04			71.71			50.63			1		
07/27/19 22:56	251072.1			7			61.65			4.09			59.41			1		
07/27/19 22:57	276641.4			2			66.51			1.32			70.64			1		
07/27/19 22:58	304829.2			1.8			55.03			1.31			64.39			1		
07/27/19 22:59	326855.8			1.8			31.91			1.36			40.04			1		
07/27/19 23:00	346032.8			1.9			18.05			1.56			23.98			1		
07/27/19 23:01	352579.1			1.9			16.38			1.59			22.17			1		
07/27/19 23:02	353349.3			1.8			13.8			1.5			18.71			1		
07/27/19 23:03	351809			1.8			13.36			1.5			18.05			1		
07/27/19 23:04	355890.8			1.7			11.63			1.44			15.88			1		
07/27/19 23:05	357585.2			1.6			9.89			1.37			13.58			1		
07/27/19 23:06	358047.3			1.6			9.33			1.32			12.83			1		
07/27/19 23:07	357739.2			1.5			8.98			1.25			12.34			1		
07/27/19 23:08	358047.3			1.4			8.28			1.18			11.38			1		
07/27/19 23:09	356121.8			1.3			8.1			1.1			11.08			1		
07/27/19 23:10	355967.8			1.3			7.96			1.11			10.87			1		
07/27/19 23:11	355890.8			1.3			7.66			1.1			10.47			1		
07/27/19 23:12	355197.7			1.2			7.57			1.02			10.33			1		
07/27/19 23:13	353965.4			1.3			7.6			1.03			10.32			1		
07/27/19 23:14	360819.8			1.3			7.6			1.05			10.53			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/27/19 23:15	376531.1			1.2			7.15			1.02			10.34			1		
07/27/19 23:16	382461.3			1.2			6.72			1.05			9.86			1		
07/27/19 23:17	384386.7			1.1			6.81			0.98			10.04			1		
07/27/19 23:18	385233.9			1			7.08			0.9			10.47			1		
07/27/19 23:19	380767			1			7.26			0.89			10.61			1		
07/27/19 23:20	370831.9			1.1			7.53			0.94			10.72			1		
07/27/19 23:21	367289.2			1			7.96			0.84			11.22			1		
07/27/19 23:22	366133.9			1			7.87			0.84			11.06			1		
07/27/19 23:23	366210.9			1			7.87			0.84			11.06			1		
07/27/19 23:24	366750.1			1			7.78			0.84			10.95			1		
07/27/19 23:25	366056.9			1			7.33			0.84			10.3			1		
07/27/19 23:26	365440.8			1			4.29			0.84			6.02			1		
07/27/19 23:27	366365			1.1			3.22			0.92			4.53			1		
07/27/19 23:28	366596			1.1			2.59			0.92			3.65			1		
07/27/19 23:29	366210.9			1.1			2.23			0.92			3.14			1		
07/27/19 23:30	366210.9			1.1			2.15			0.92			3.02			1		
07/27/19 23:31	366210.9			1.1			1.88			0.92			2.64			1		
07/27/19 23:32	365671.8			1.1			1.7			0.91			2.38			1		
07/27/19 23:33	365748.8			1.1			1.61			0.92			2.26			1		
07/27/19 23:34	365363.8			1.1			1.43			0.91			2.01			0		
07/27/19 23:35	364747.7			1			1.34			0.84			1.88			0		
07/27/19 23:36	364362.6			1			1.25			0.84			1.75			0		
07/27/19 23:37	365671.8			1			1.16			0.84			1.63			0		
07/27/19 23:38	365132.7			1			1.16			0.84			1.63			0		

CT2 SUSD EVENT 4

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/08/19 4:50	308217.9			0.8			1.66			0.6			1.96			0		
08/08/19 4:51	307909.8			0.8			1.75			0.6			2.07			0		
08/08/19 4:52	305676.4			0.8			1.75			0.59			2.06			0		
08/08/19 4:53	308834.1			0.8			1.75			0.6			2.08			0		
08/08/19 4:54	306138.5			0.8			1.75			0.59			2.06			0		
08/08/19 4:55	305214.3			0.8			1.66			0.59			1.94			1		
08/08/19 4:56	287269.6			0.8			1.57			0.56			1.73			1		
08/08/19 4:57	264472.8			0.8			3			0.52			3.04			1		
08/08/19 4:58	243909.6			0.8			7.54			0.44			7.06			1		
08/08/19 4:59	216877			0.7			13.83			0.36			11.52			1		
08/08/19 5:00	190229.5			1			17.13			0.45			12.51			1		
08/08/19 5:01	168202.9			9			19.5			3.52			12.59			1		
08/08/19 5:02	148717.8			636.9			22.27			220.98			12.72			1		
08/08/19 5:03	63076.1			1670			23.77			245.61			5.75			1		
08/08/19 5:04	0			0			25.46			0			0			0		
08/08/19 5:05	0			0			11.8			0			0			0		
08/08/19 5:06	0			0			0.1			0			0			0		
08/08/19 5:07	0			0			0.1			0			0			0		
08/08/19 5:08	0			0			0.1			0			0			0		

CT2 SUSD EVENT 5

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/14/19 6:39	0			0			0			0			0			0		
08/14/19 6:40	0			0			0			0			0			0		
08/14/19 6:41	0			0			0			0			0			0		
08/14/19 6:42	0			0			0			0			0			0		
08/14/19 6:43	0			0			0			0			0			0		
08/14/19 6:44	26647.5			0.3			0			0			0			1		
08/14/19 6:45	39740.2			1.2			0.1			0			0			1		
08/14/19 6:46	52062.8			506			18.61			61.39			3.72			1		
08/14/19 6:47	63538.2			471.1			17.7			69.81			4.32			1		
08/14/19 6:48	86951			309			23.04			62.68			7.69			1		
08/14/19 6:49	134855			177.5			24.88			55.83			12.88			1		
08/14/19 6:50	154571.1			72.1			42.78			25.99			25.39			1		
08/14/19 6:51	163273.9			381.8			45.29			145.36			28.38			1		
08/14/19 6:52	181911.7			1688.1			37.48			716.45			26.18			1		
08/14/19 6:53	204554.4			1049.1			45.76			500.43			35.93			1		
08/14/19 6:54	229430.6			186.7			55.02			99.95			48.46			1		
08/14/19 6:55	254460.8			10.8			58.52			6.43			57.15			1		
08/14/19 6:56	277026.4			2.7			62.39			1.77			66.35			1		
08/14/19 6:57	305830.4			2.3			54.08			1.61			63.5			1		
08/14/19 6:58	328011			2.2			34.77			1.71			43.79			1		
08/14/19 6:59	341103.8			2.4			18.76			1.89			24.56			1		
08/14/19 7:00	341334.8			2.4			16.4			1.93			21.49			1		
08/14/19 7:01	339332.4			2.3			14.49			1.79			18.88			1		
08/14/19 7:02	344492.4			2.2			12.86			1.77			17			1		
08/14/19 7:03	349421.5			2.1			11.54			1.72			15.47			1		
08/14/19 7:04	365440.8			2			10.04			1.73			14.08			1		
08/14/19 7:05	375915			2			8.22			1.72			11.87			1		
08/14/19 7:06	387390.3			1.8			7.62			1.64			11.34			1		
08/14/19 7:07	388622.6			1.6			7.35			1.48			10.97			1		
08/14/19 7:08	388391.6			1.5			7.35			1.4			10.96			1		
08/14/19 7:09	396786.3			1.5			7.17			1.34			10.92			1		
08/14/19 7:10	400560.1			1.4			7.1			1.29			10.92			1		
08/14/19 7:11	402716.5			1.4			6.91			1.3			10.69			1		
08/14/19 7:12	404025.8			1.3			7.19			1.22			11.15			1		
08/14/19 7:13	403024.6			1.2			7.28			1.13			11.27			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/14/19 7:14	403486.7			1.2			7.38			1.13			11.42			1		
08/14/19 7:15	401330.2			1.2			7.47			1.12			11.5			1		
08/14/19 7:16	402331.4			1.1			7.47			1.04			11.53			1		
08/14/19 7:17	400791.1			1.1			7.56			1.03			11.63			1		
08/14/19 7:18	399712.9			1.1			7.65			1.03			11.74			1		
08/14/19 7:19	400098			1.1			7.74			1.03			11.89			1		
08/14/19 7:20	400945.2			1.1			7.74			1.03			11.92			1		
08/14/19 7:21	401099.2			1.1			7.84			1.03			12.06			1		
08/14/19 7:22	399173.8			1.1			7.93			1.03			12.15			1		
08/14/19 7:23	399404.8			1.1			4.87			1.05			7.47			1		
08/14/19 7:24	398403.6			1.1			2.86			1.03			4.37			1		
08/14/19 7:25	398942.8			1.1			2.49			1.03			3.81			1		
08/14/19 7:26	399250.8			1.1			2.21			1.03			3.39			1		
08/14/19 7:27	398557.7			1			1.94			0.94			2.96			1		
08/14/19 7:28	399558.9			1			1.78			0.96			2.73			1		
08/14/19 7:29	397325.4			1.1			1.59			1.04			2.43			1		
08/14/19 7:30	390856.1			1			1.4			0.94			2.11			1		
08/14/19 7:31	377532.3			1			1.29			0.89			1.87			0		
08/14/19 7:32	374297.6			1			1.18			0.87			1.7			0		
08/14/19 7:33	368906.5			1			1.09			0.86			1.54			0		
08/14/19 7:34	365517.8			1.1			1.09			0.93			1.53			0		
08/14/19 7:35	365748.8			1.1			1			0.93			1.4			0		

CT2 SUSD EVENT 6

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/16/19 22:51	424435			1.5			1.57			1.46			2.55			0		
08/16/19 22:52	401176.2			1.3			1.57			1.21			2.41			0		
08/16/19 22:53	376531.1			1.1			1.63			0.96			2.36			0		
08/16/19 22:54	350730.8			1.1			1.7			0.88			2.29			0		
08/16/19 22:55	324853.4			1.1			1.76			0.8			2.2			0		
08/16/19 22:56	306600.6			1.1			1.76			0.76			2.07			1		
08/16/19 22:57	290581.3			1			1.72			0.68			1.92			1		
08/16/19 22:58	266321.2			0.9			2.95			0.57			3.02			1		
08/16/19 22:59	248145.5			0.9			7.04			0.5			6.71			1		
08/16/19 23:00	220188.7			0.8			15.9			0.41			13.44			1		
08/16/19 23:01	193618.2			0.8			20.54			0.35			15.27			1		
08/16/19 23:02	171360.5			5.4			22.62			2.16			14.88			1		
08/16/19 23:03	151952.5			485.1			25			171.88			14.58			1		
08/16/19 23:04	99196.6			1577.3			27.53			365.07			10.49			1		
08/16/19 23:05	0			0			29.5			0			0			0		
08/16/19 23:06	0			0			29.5			0			0			0		
08/16/19 23:07	0			0			0.2			0			0			0		
08/16/19 23:08	0			0			0.2			0			0			0		
08/16/19 23:09	0			0			0.1			0			0			0		

CT2 SUSD EVENT 7

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/25/19 7:38	0			0			0			0			0			0		
08/25/19 7:39	0			0			0			0			0			0		
08/25/19 7:40	0			0			0			0			0			0		
08/25/19 7:41	0			0			0			0			0			0		
08/25/19 7:42	45131.4			0			0			0			0			0		
08/25/19 7:43	11706.4			0.3			0			0			0			1		
08/25/19 7:44	30883.4			0.3			0			0			0			1		
08/25/19 7:45	45285.4			51.6			25.08			5.45			4.36			1		
08/25/19 7:46	57068.8			494.9			17.04			65.92			3.74			1		
08/25/19 7:47	71316.8			370.8			21.24			61.67			5.81			1		
08/25/19 7:48	108900.6			212.7			24.67			54.03			10.32			1		
08/25/19 7:49	149565			106.2			34.69			37.06			19.92			1		
08/25/19 7:50	150874.3			38.6			50.82			13.6			29.43			1		
08/25/19 7:51	169512.2			1054.3			40.94			416.78			26.64			1		
08/25/19 7:52	192771			1440.8			41.97			647.93			31.07			1		
08/25/19 7:53	217647.1			416.7			53.1			211.55			44.37			1		
08/25/19 7:54	243293.5			36.7			59.38			20.82			55.46			1		
08/25/19 7:55	265243			3			64.11			1.83			65.28			1		
08/25/19 7:56	293353.8			2.1			63.04			1.42			70.99			1		
08/25/19 7:57	315842.5			1.9			46.45			1.38			56.32			1		
08/25/19 7:58	318461			1.8			24.83			1.37			30.35			1		
08/25/19 7:59	316843.7			1.9			16.82			1.43			20.45			1		
08/25/19 8:00	322080.8			2			16.54			1.48			20.45			1		
08/25/19 8:01	342567			1.8			14.93			1.43			19.63			1		
08/25/19 8:02	361667			1.7			14.93			1.43			20.73			1		
08/25/19 8:03	371217			1.6			11.98			1.39			17.07			1		
08/25/19 8:04	386081.1			1.5			10.8			1.39			16.01			1		
08/25/19 8:05	402716.5			1.5			9.8			1.36			15.15			1		
08/25/19 8:06	419197.9			1.3			9.96			1.26			16.02			1		
08/25/19 8:07	441994.7			1.2			9.18			1.26			15.57			1		
08/25/19 8:08	445691.4			1.1			8.71			1.17			14.9			1		
08/25/19 8:09	447154.8			1.1			9.5			1.15			16.3			1		
08/25/19 8:10	447693.8			1.1			9.46	X		1.17			16.26	X		1		
08/25/19 8:11	449080.1			1			9.22	X		1.06			15.89	X		1		
08/25/19 8:12	449927.3			1			9.27			1.08			16.01			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/25/19 8:13	449773.3			1			9.22			1.06			15.92			1		
08/25/19 8:14	450466.4			1			9.22			1.07			15.94			1		
08/25/19 8:15	449157.2			0.9			9.4			0.97			16.21			1		
08/25/19 8:16	452083.8			0.9			9.5			0.97			16.48			1		
08/25/19 8:17	448464			0.9			9.59			0.96			16.51			1		
08/25/19 8:18	450774.5			0.9			9.77			0.97			16.91			1		
08/25/19 8:19	449773.3			0.9			9.86			0.97			17.03			1		
08/25/19 8:20	450389.4			0.9			10.05			0.97			17.37			1		
08/25/19 8:21	450851.5			0.9			9.03			0.97			15.64			1		
08/25/19 8:22	451698.7			0.9			4.33			0.97			7.51			1		
08/25/19 8:23	450389.4			0.9			3.04			0.97			5.26			1		
08/25/19 8:24	450774.5			0.9			2.77			0.97			4.79			1		
08/25/19 8:25	450389.4			0.9			2.4			0.97			4.14			1		
08/25/19 8:26	450543.4			0.9			2.12			0.97			3.67			1		
08/25/19 8:27	450620.5			0.9			1.84			0.97			3.19			1		
08/25/19 8:28	451082.6			0.9			1.57			0.97			2.71			1		
08/25/19 8:29	450312.4			0.9			1.38			0.97			2.39			1		
08/25/19 8:30	449388.2			0.9			1.29			0.97			2.23			0		
08/25/19 8:31	451082.6			0.9			1.2			0.97			2.08			0		
08/25/19 8:32	449619.3			0.9			1.11			0.97			1.91			0		
08/25/19 8:33	450389.4			0.9			1.01			0.97			1.75			0		
08/25/19 8:34	451159.6			0.9			1.01			0.97			1.76			0		

CT2 SUSD EVENT 8

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/29/19 22:52	337407			1			1.79			0.77			2.32			0		
08/29/19 22:53	338716.3			1			1.79			0.78			2.32			0		
08/29/19 22:54	338023.1			1			1.7			0.78			2.2			0		
08/29/19 22:55	338639.2			1			1.61			0.78			2.09			0		
08/29/19 22:56	337946.1			1			1.61			0.78			2.09			0		
08/29/19 22:57	338100.1			1			1.61			0.78			2.09			1		
08/29/19 22:58	327240.9			0.9			1.7			0.68			2.13			1		
08/29/19 22:59	303365.9			1			1.7			0.7			1.98			1		
08/29/19 23:00	281031.3			1			2.12			0.66			2.29			1		
08/29/19 23:01	259697.9			0.9			5.62			0.57			5.6			1		
08/29/19 23:02	235437.8			0.8			9.64			0.43			8.71			1		
08/29/19 23:03	208790.3			0.7			19.91			0.36			15.96			1		
08/29/19 23:04	184222.2			3			22.21			1.29			15.71			1		
08/29/19 23:05	162426.7			197.4			25.21			74.8			15.72			1		
08/29/19 23:06	143018.7			1110.6			27.79			370.42			15.26			1		
08/29/19 23:07	24414.1			1914.8			29.5			108.87			2.76			1		
08/29/19 23:08	0			0			30.09			0			0			0		
08/29/19 23:09	0			0			0.2			0			0			0		
08/29/19 23:10	0			0			0.2			0			0			0		
08/29/19 23:11	0			0			0.1			0			0			0		
08/29/19 23:12	0			0			0.1			0			0			0		

CT2 SUSD EVENT 9

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/04/19 6:41	0			0			0			0			0			0		
09/04/19 6:42	0			0			0			0			0			0		
09/04/19 6:43	0			0			0			0			0			0		
09/04/19 6:44	0			0			0			0			0			0		
09/04/19 6:45	0			0			0			0			0			0		
09/04/19 6:46	19562.1			0.4			0			0			0			1		
09/04/19 6:47	36659.6			0.8			0.1			0			0			1		
09/04/19 6:48	49367.2			5.2			22.29			0.6			4.22			1		
09/04/19 6:49	61535.8			475.8			16.82			68.28			3.97			1		
09/04/19 6:50	79942.6			334.1			21.91			62.29			6.72			1		
09/04/19 6:51	125998.1			220.2			25.48			64.71			12.32			1		
09/04/19 6:52	151952.5			97.7			38.9			34.61			22.68			1		
09/04/19 6:53	160963.4			190.8			48.45			71.61			29.93			1		
09/04/19 6:54	180063.3			1669.9			39.33			701.24			27.18			1		
09/04/19 6:55	205016.5			1109.5			47.2			530.5			37.14			1		
09/04/19 6:56	229738.6			227.3			58.02			121.8			51.17			1		
09/04/19 6:57	254229.7			18.2			59.86			10.79			58.42			1		
09/04/19 6:58	279953.1			4.7			61.08			3.07			65.63			1		
09/04/19 6:59	307216.7			4.1			55.2			2.94			65.09			1		
09/04/19 7:00	328319.1			3.9			36.85			2.99			46.44			1		
09/04/19 7:01	350499.7			3.8			19.18			3.12			25.8			1		
09/04/19 7:02	368521.4			3.8			17.61			3.28			24.92			1		
09/04/19 7:03	373450.4			3.5			13.8			3.02			19.78			1		
09/04/19 7:04	376300			2.9			12.86			2.55			18.57			1		
09/04/19 7:05	375144.8			2.4			11.71			2.08			16.87			1		
09/04/19 7:06	389700.8			2			10.83			1.84			16.2			1		
09/04/19 7:07	408107.6			1.8			9.74			1.7			15.27			1		
09/04/19 7:08	419120.9			1.7			8.94			1.62			14.39			1		
09/04/19 7:09	423587.8			1.5			8.94			1.46			14.54			1		
09/04/19 7:10	425744.3			1.4			9.13			1.37			14.91			1		
09/04/19 7:11	425282.2			1.3			9.03			1.28			14.75			1		
09/04/19 7:12	425821.3			1.2			9.13			1.19			14.92			1		
09/04/19 7:13	424743.1			1.2			9.31	X		1.19			15.18	X		1		
09/04/19 7:14	424666.1			1.2			9.31	X		1.19			15.18	X		1		
09/04/19 7:15	423202.8			1.2			9.22			1.18			14.98			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/04/19 7:16	421123.3			1.2			9.31			1.18			15.05			1		
09/04/19 7:17	422201.6			1.2			9.31			1.18			15.09			1		
09/04/19 7:18	421585.4			1.2			9.4			1.18			15.22			1		
09/04/19 7:19	420199.2			1.2			9.5			1.17			15.31			1		
09/04/19 7:20	421277.4			1.1			9.59			1.09			15.51			1		
09/04/19 7:21	420430.2			1.1			9.93			1.1			16.02			1		
09/04/19 7:22	420353.2			1			10.02			1.01			16.17			1		
09/04/19 7:23	421508.4			1			10.11			1.01			16.36			1		
09/04/19 7:24	419506			1.1			7.3			1.1			11.76			1		
09/04/19 7:25	418889.9			1			3.6			0.99			5.78			1		
09/04/19 7:26	417657.6			1			2.81			1			4.5			1		
09/04/19 7:27	419197.9			1			2.34			1.01			3.77			1		
09/04/19 7:28	417426.6			1			2.15			1			3.45			1		
09/04/19 7:29	418735.8			1			1.97			1.01			3.16			1		
09/04/19 7:30	418735.8			1			1.78			1.01			2.86			1		
09/04/19 7:31	417503.6			1			1.59			1			2.55			1		
09/04/19 7:32	419583			1			1.5			1.01			2.41			0		
09/04/19 7:33	419737.1			1			1.4			1.01			2.26			0		
09/04/19 7:34	416810.4			1			1.31			1			2.1			0		
09/04/19 7:35	417503.6			1			1.22			1			1.95			0		
09/04/19 7:36	418581.8			1			1.12			1.01			1.81			0		

CT2 SUSD EVENT 10

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/05/19 22:55	324314.3			1.1			1.7			0.81			2.11			0		
09/05/19 22:56	307524.8			1.1			1.82			0.78			2.14			0		
09/05/19 22:57	306369.5			1.1			1.75			0.79			2.06			0		
09/05/19 22:58	305676.4			0.9			1.69			0.67			1.98			0		
09/05/19 22:59	306061.5			0.9			1.69			0.67			1.98			0		
09/05/19 23:00	306061.5			0.9			1.59			0.67			1.87			1		
09/05/19 23:01	289503			0.9			1.59			0.63			1.77			1		
09/05/19 23:02	266937.4			0.9			2.62			0.58			2.69			1		
09/05/19 23:03	246220.1			0.9			6.58			0.5			6.22			1		
09/05/19 23:04	219649.5			0.8			16.28			0.42			13.72			1		
09/05/19 23:05	194850.4			0.8			20.82			0.35			15.57			1		
09/05/19 23:06	169204.1			6			23.1			2.38			15			1		
09/05/19 23:07	148640.8			533.4			25.61			184.97			14.62			1		
09/05/19 23:08	98965.5			1557.9			27.86			359.55			10.58			1		
09/05/19 23:09	0			0			34.09			0			0			0		
09/05/19 23:10	0			0			29.5			0			0			0		
09/05/19 23:11	0			0			0.2			0			0			0		
09/05/19 23:12	0			0			0.2			0			0			0		
09/05/19 23:13	0			0			0.1			0			0			0		

CT2 SUSD EVENT 11

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/09/19 22:38	0			0			0			0			0			0		
09/09/19 22:39	0			0			0			0			0			0		
09/09/19 22:40	0			0			0			0			0			0		
09/09/19 22:41	0			0			0			0			0			0		
09/09/19 22:42	0			0			0			0			0			0		
09/09/19 22:43	8394.7			0.4			0			0			0			1		
09/09/19 22:44	28187.8			0.4			0			0			0			1		
09/09/19 22:45	42281.8			59			26.55			5.85			4.33			1		
09/09/19 22:46	54758.4			506			16.31			64.9			3.44			1		
09/09/19 22:47	67080.9			428.9			19.18			67.4			4.96			1		
09/09/19 22:48	98272.4			275.6			24.16			63.48			9.16			1		
09/09/19 22:49	145252.1			165.7			25.4			56.42			14.23			1		
09/09/19 22:50	154263			61.6			46.39			22.29			27.6			1		
09/09/19 22:51	172361.8			786			43.62			317.56			29.01			1		
09/09/19 22:52	195928.6			1461.7			44.33			671.07			33.5			1		
09/09/19 22:53	222268.1			438.4			56.64			228.34			48.56			1		
09/09/19 22:54	245295.9			42.8			59.13			24.63			55.94			1		
09/09/19 22:55	266937.4			3.5			61.89			2.17			63.73			1		
09/09/19 22:56	295972.4			1.9			61.48			1.29			70.19			1		
09/09/19 22:57	323621.1			1.8			44.86			1.35			55.99			1		
09/09/19 22:58	333556.2			1.8			24.92			1.45			32.06			1		
09/09/19 22:59	333171.1			2			17.61			1.56			22.63			1		
09/09/19 23:00	331630.8			2			17.08			1.57			21.85			1		
09/09/19 23:01	331399.7			1.9			15.59			1.5			19.92			1		
09/09/19 23:02	330552.6			1.8			14			1.36			17.85			1		
09/09/19 23:03	330167.5			1.7			12.77			1.29			16.26			1		
09/09/19 23:04	330321.5			1.6			12.34			1.25			15.72			1		
09/09/19 23:05	330090.5			1.5			11.71			1.18			14.91			1		
09/09/19 23:06	328935.2			1.4			10.82			1.1			13.72			1		
09/09/19 23:07	330167.5			1.3			10.64			1.04			13.55			1		
09/09/19 23:08	336174.7			1.3			10.37			1.06			13.45			1		
09/09/19 23:09	335481.6			1.3			10.19			0.98			13.19			1		
09/09/19 23:10	335943.7			1.3			10.19			0.99			13.2			1		
09/09/19 23:11	335404.6			1.3			10.01			0.98			12.95			1		
09/09/19 23:12	334249.3			1.3			10.01			0.98			12.91			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/09/19 23:13	333633.2			1.3			9.92			0.98			12.77			1		
09/09/19 23:14	333710.2			1.2			9.92			0.91			12.77			1		
09/09/19 23:15	332709			1.2			9.92			0.91			12.73			1		
09/09/19 23:16	332632			1.1			9.92			0.84			12.73			1		
09/09/19 23:17	332015.8			1.1			10.01			0.83			12.82			1		
09/09/19 23:18	332400.9			1.1			9.92			0.84			12.72			1		
09/09/19 23:19	332323.9			1.2			9.92			0.91			12.72			1		
09/09/19 23:20	331091.7			1.1			10.1			0.83			12.9			1		
09/09/19 23:21	330783.6			1.1			10.1			0.83			12.89			1		
09/09/19 23:22	331707.8			1.1			10.35			0.85			13.24			1		
09/09/19 23:23	329859.4			1.1			10.53			0.84			13.4			1		
09/09/19 23:24	332015.8			1.1			10.71			0.85			13.72			1		
09/09/19 23:25	331245.7			1.1			10.8			0.85			13.8			1		
09/09/19 23:26	330244.5			1			8.99			0.77			11.45			1		
09/09/19 23:27	331476.8			1			4.63			0.78			5.92			1		
09/09/19 23:28	330321.5			1			3.72			0.77			4.74			1		
09/09/19 23:29	329782.4			1			3.09			0.77			3.93			1		
09/09/19 23:30	330013.4			1			2.81			0.77			3.58			1		
09/09/19 23:31	331399.7			1			2.54			0.78			3.25			1		
09/09/19 23:32	330629.6			1			2.18			0.77			2.78			1		
09/09/19 23:33	330552.6			1			2			0.77			2.55			1		
09/09/19 23:34	330090.5			1			1.82			0.77			2.31			1		
09/09/19 23:35	330090.5			1			1.63			0.77			2.08			1		
09/09/19 23:36	331091.7			1			1.54			0.77			1.97			1		
09/09/19 23:37	330244.5			1			1.36			0.77			1.73			0		
09/09/19 23:38	330167.5			1			1.27			0.77			1.62			0		
09/09/19 23:39	328473.1			1			1.27			0.77			1.61			0		
09/09/19 23:40	329705.4			1			1.18			0.77			1.5			0		
09/09/19 23:41	330552.6			1			1.09			0.77			1.39			0		

CT2 SUSD EVENT 12

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/11/19 11:47	453085			2.1			1.67			2.31			3			0		
09/11/19 11:48	451775.7			2.1			1.67			2.3			3			0		
09/11/19 11:49	451698.7			2.1			1.7			2.34			3.05			0		
09/11/19 11:50	452545.8			2.1			1.7			2.32			3.03			0		
09/11/19 11:51	453316			2.1			1.7			2.3			3			0		
09/11/19 11:52	452006.8			2.2			1.7			2.37			2.96			1		
09/11/19 11:53	451929.7			2.3			1.75			2.44			3.05			1		
09/11/19 11:54	432675.7			2			1.75			2.06			2.92			1		
09/11/19 11:55	408800.8			1.5			1.94			1.41			3.05			1		
09/11/19 11:56	385850			1.2			2.45			1.07			3.65			1		
09/11/19 11:57	361050.9			1.1			2.86			0.91			3.98			1		
09/11/19 11:58	334942.5			1.1			3.08			0.83			3.98			1		
09/11/19 11:59	311452.6			1.1			3.35			0.84			4.02			1		
09/11/19 12:00	288193.8			1.1			3.63			0.74			4.04			1		
09/11/19 12:01	265474.1			1			5.99			0.64			6.14			1		
09/11/19 12:02	245603.9			1			6.19			0.56			5.86			1		
09/11/19 12:03	219033.4			0.8			22.38			0.42			18.9			1		
09/11/19 12:04	192308.9			1.6			26.55			0.72			19.69			1		
09/11/19 12:05	168511			13.9			27.58			5.47			17.92			1		
09/11/19 12:06	151028.3			668.1			29.21			236.46			17.01			1		
09/11/19 12:07	69391.4			1703.6			31.02			277.23			8.31			1		
09/11/19 12:08	0			0			32.99			0			0			0		
09/11/19 12:09	0			0			23.6			0			0			0		
09/11/19 12:10	0			0			0.2			0			0			0		
09/11/19 12:11	0			0			0.2			0			0			0		
09/11/19 12:12	0			0			0.1			0			0			0		

CT2 SUSD EVENT 13

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/12/19 8:40	0			0			0			0			0			0		
09/12/19 8:41	0			0			0			0			0			0		
09/12/19 8:42	0			0			0			0			0			0		
09/12/19 8:43	0			0			0			0			0			0		
09/12/19 8:44	0			0			0			0			0			0		
09/12/19 8:45	13554.8			0.3			0			0			0			1		
09/12/19 8:46	32500.7			0.6			0			0			0			1		
09/12/19 8:47	45901.5			55.3			26.55			5.96			4.7			1		
09/12/19 8:48	57607.9			482.6			20.95			65.14			4.65			1		
09/12/19 8:49	73165.2			327.3			25.29			56.12			7.14			1		
09/12/19 8:50	112674.4			201.4			33.79			53.2			14.69			1		
09/12/19 8:51	151952.5			97.7			45.55			34.8			26.7			1		
09/12/19 8:52	158729.9			48.1			61.77			17.9			37.82			1		
09/12/19 8:53	180063.3			1266.8			53.62			534.51			37.24			1		
09/12/19 8:54	203630.2			1004.4			55.97			479.36			43.96			1		
09/12/19 8:55	229584.6			185.7			57.31			99.94			50.76			1		
09/12/19 8:56	253459.6			10.2			58.26			6.06			56.96			1		
09/12/19 8:57	276564.3			2			60.31			1.27			64.34			1		
09/12/19 8:58	304213.1			1.7			53.59			1.19			62.88			1		
09/12/19 8:59	329166.3			1.7			33.68			1.33			42.75			1		
09/12/19 9:00	339409.4			1.8			17.44			1.47			22.83			1		
09/12/19 9:01	340795.7			1.9			15.06			1.55			19.79			1		
09/12/19 9:02	340333.6			1.8			13.39			1.47			17.57			1		
09/12/19 9:03	339871.5			1.7			12.58			1.38			16.49			1		
09/12/19 9:04	337407			1.7			12.06			1.32			15.7			1		
09/12/19 9:05	338408.2			1.6			11.54			1.26			15.06			1		
09/12/19 9:06	337098.9			1.5			11.1			1.18			14.43			1		
09/12/19 9:07	337869.1			1.5			10.74			1.19			14			1		
09/12/19 9:08	337407			1.4			10.48			1.11			13.64			1		
09/12/19 9:09	338408.2			1.2			10.39			0.98			13.56			1		
09/12/19 9:10	336328.8			1.3			10.55			0.99			13.68			1		
09/12/19 9:11	335943.7			1.3			10.46			0.99			13.55			1		
09/12/19 9:12	336251.8			1.2			10.37			0.92			13.45			1		
09/12/19 9:13	334942.5			1.2			10.37			0.91			13.4			1		
09/12/19 9:14	335712.6			1.2			10.28			0.91			13.31			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/12/19 9:15	335019.5			1.2			10.19			0.91			13.17			1		
09/12/19 9:16	336944.9			1.1			10.28			0.85			13.36			1		
09/12/19 9:17	335019.5			1.1			10.28			0.84			13.29			1		
09/12/19 9:18	334634.4			1.1			10.37			0.84			13.39			1		
09/12/19 9:19	335019.5			1.1			10.37			0.84			13.4			1		
09/12/19 9:20	334403.3			1.1			10.37			0.84			13.37			1		
09/12/19 9:21	332169.9			1.1			10.46			0.84			13.4			1		
09/12/19 9:22	334403.3			1.1			10.64			0.84			13.72			1		
09/12/19 9:23	334249.3			1.1			10.55			0.84			13.6			1		
09/12/19 9:24	333633.2			1			6.35			0.77			8.17			1		
09/12/19 9:25	332709			1			3.93			0.77			5.05			1		
09/12/19 9:26	333633.2			1			3.4			0.77			4.37			1		
09/12/19 9:27	328473.1			1			2.95			0.76			3.74			1		
09/12/19 9:28	322388.9			1			2.77			0.74			3.45			1		
09/12/19 9:29	322080.8			1			2.36			0.75			2.93			1		
09/12/19 9:30	321464.7			0.9			2.18			0.68			2.7			1		
09/12/19 9:31	320232.4			0.9			1.82			0.68			2.24			1		
09/12/19 9:32	319770.3			1			1.63			0.75			2.02			1		
09/12/19 9:33	319000.2			1			1.54			0.75			1.9			1		
09/12/19 9:34	318615.1			1			1.45			0.75			1.78			0		
09/12/19 9:35	319000.2			0.9			1.27			0.68			1.56			0		
09/12/19 9:36	318384			0.9			1.18			0.68			1.45			0		
09/12/19 9:37	318538.1			0.9			1.18			0.68			1.45			0		
09/12/19 9:38	318692.1			0.9			1.18			0.68			1.45			0		

CT2 SUSD EVENT 14

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/12/19 22:52	415193.1			1.4			2.3			1.35			3.69			0		
09/12/19 22:53	394167.8			1.4			2.03			1.28			3.08			0		
09/12/19 22:54	368367.4			1.3			1.88			1.16			2.67			0		
09/12/19 22:55	342644.1			1.3			1.76			1.06			2.33			0		
09/12/19 22:56	317382.8			1.4			1.59			1.05			1.94			0		
09/12/19 22:57	307139.7			1.4			1.43			1.03			1.69			1		
09/12/19 22:58	291890.5			1.4			1.18			0.93			1.33			1		
09/12/19 22:59	268785.8			1.2			2.12			0.75			2.2			1		
09/12/19 23:00	249608.8			1.1			6			0.67			5.77			1		
09/12/19 23:01	222730.2			1			6.3			0.52			5.41			1		
09/12/19 23:02	194465.3			1.1			18.59			0.51			13.94			1		
09/12/19 23:03	172592.8			7.5			21.47			3.05			14.29			1		
09/12/19 23:04	152645.7			570.4			24.46			204.05			14.4			1		
09/12/19 23:05	88029.3			1565.8			26.88			323.16			9.13			1		
09/12/19 23:06	0			0			33.04			0			0			0		
09/12/19 23:07	0			0			17.7			0			0			0		
09/12/19 23:08	0			0			0.1			0			0			0		
09/12/19 23:09	0			0			0.1			0			0			0		
09/12/19 23:10	0			0			0.1			0			0			0		
09/12/19 23:11	0			0			0.1			0			0			0		
09/12/19 23:12	0			0			0.1			0			0			0		
09/12/19 23:13	0			0			0.1			0			0			0		

CT2 SUSD EVENT 15

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/23/19 7:39	0			0			0			0			0			0		
09/23/19 7:40	0			0			0			0			0			0		
09/23/19 7:41	0			0			0			0			0			0		
09/23/19 7:42	0			0			0			0			0			0		
09/23/19 7:43	4081.8			0			0			0			0			0		
09/23/19 7:44	8317.7			0.3			0			0			0			1		
09/23/19 7:45	29266.1			0.3			0			0			0			1		
09/23/19 7:46	44438.2			41.3			23.6			4.3			4.04			1		
09/23/19 7:47	56683.8			534.6			16.06			70.96			3.51			1		
09/23/19 7:48	68775.3			443.7			19.77			71.51			5.24			1		
09/23/19 7:49	105049.8			282.6			24.72			69.59			10.02			1		
09/23/19 7:50	149257			150.2			33.19			52.55			19.11			1		
09/23/19 7:51	154031.9			58.4			48.77			21.09			28.98			1		
09/23/19 7:52	161348.5			1035.9			37.72			391.65			23.47			1		
09/23/19 7:53	177059.7			1857.8			34.36			771.01			23.47			1		
09/23/19 7:54	199548.4			1390.3			39.66			650.11			30.52			1		
09/23/19 7:55	222807.2			430.8			50.74			225			43.61			1		
09/23/19 7:56	248607.6			42.1			57.08			24.51			54.73			1		
09/23/19 7:57	272790.6			3.7			62.18			2.39			65.42			1		
09/23/19 7:58	299592.1			2.5			60.93			1.79			70.42			1		
09/23/19 7:59	326162.7			2.3			41.85			1.76			52.65			1		
09/23/19 8:00	346725.9			2.2			23.6			1.79			31.56			1		
09/23/19 8:01	365209.8			2.3			18.39			1.93			25.91			1		
09/23/19 8:02	373758.5			2.3			15.96			1.98			23.01			1		
09/23/19 8:03	384617.8			2.1			13.65			1.91			20.25			1		
09/23/19 8:04	400637.1			1.9			12.59			1.82			19.46			1		
09/23/19 8:05	411188.3			1.9			10.91			1.81			17.3			1		
09/23/19 8:06	421123.3			1.7			10.53			1.7			17.1			1		
09/23/19 8:07	437835.8			1.5			10.26			1.58			17.32			1		
09/23/19 8:08	457937			1.5			9.5			1.58			16.77			1		
09/23/19 8:09	457628.9			1.4			10.51			1.48			18.55			1		
09/23/19 8:10	454702.3			1.3			10.51			1.38			18.43			1		
09/23/19 8:11	456550.7			1.3			10.42			1.38			18.34			1		
09/23/19 8:12	454625.3			1.3			10.42			1.38			18.27			1		
09/23/19 8:13	453932.1			1.3			10.6			1.37			18.56			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/23/19 8:14	452930.9			1.3			10.69			1.37			18.68			1		
09/23/19 8:15	454163.2			1.2			10.69			1.28			18.73			1		
09/23/19 8:16	452853.9			1.2			10.79			1.27			18.84			1		
09/23/19 8:17	453162			1.1			10.88			1.18			19.02			1		
09/23/19 8:18	451082.6			1.2			11.24			1.29			19.55			1		
09/23/19 8:19	452776.9			1.2			11.25			1.27			19.64			1		
09/23/19 8:20	451621.7			1.1			11.61			1.19			20.23			1		
09/23/19 8:21	453085			1.1			11.71			1.19			20.46			1		
09/23/19 8:22	452006.8			1.1			11.99			1.19			20.9			1		
09/23/19 8:23	451775.7			1.1			7.12			1.19			12.4			1		
09/23/19 8:24	451929.7			1.1			3.56			1.19			6.2			1		
09/23/19 8:25	451082.6			1			3.09			1.09			5.38			1		
09/23/19 8:26	451467.6			1			2.81			1.09			4.89			1		
09/23/19 8:27	451544.7			1.1			2.72			1.19			4.73			1		
09/23/19 8:28	450774.5			1.1			2.62			1.19			4.56			1		
09/23/19 8:29	451390.6			1.1			2.53			1.19			4.4			1		
09/23/19 8:30	450158.3			1.1			2.34			1.19			4.07			1		
09/23/19 8:31	451929.7			1.1			2.15			1.19			3.75			1		
09/23/19 8:32	451929.7			1			1.87			1.09			3.27			1		
09/23/19 8:33	451929.7			1.1			1.78			1.19			3.1			1		
09/23/19 8:34	450312.4			1.1			1.59			1.19			2.77			1		
09/23/19 8:35	451390.6			1			1.5			1.09			2.61			0		
09/23/19 8:36	450466.4			1			1.4			1.09			2.44			0		
09/23/19 8:37	448464			1			1.4			1.08			2.43			0		
09/23/19 8:38	450081.3			1			1.31			1.09			2.28			0		
09/23/19 8:39	449850.3			1			1.22			1.09			2.11			0		

CT2 SUSD EVENT 16

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/27/19 22:50	324391.3			1.1			1.63			0.83			2.04			0		
09/27/19 22:51	322851			1.1			1.63			0.82			2.03			0		
09/27/19 22:52	324237.3			1.1			1.63			0.83			2.04			0		
09/27/19 22:53	323929.2			1.1			1.63			0.83			2.04			0		
09/27/19 22:54	322851			1.1			1.54			0.82			1.92			0		
09/27/19 22:55	324314.3			1.1			1.72			0.83			2.16			1		
09/27/19 22:56	312607.8			1.1			1.72			0.8			2.08			1		
09/27/19 22:57	289272			1.1			1.82			0.74			2.03			1		
09/27/19 22:58	266629.3			1.1			4.12			0.7			4.24			1		
09/27/19 22:59	245681			1.1			8.03			0.61			7.61			1		
09/27/19 23:00	217262.1			0.9			16.56			0.47			13.88			1		
09/27/19 23:01	192077.8			1.8			19.29			0.82			14.29			1		
09/27/19 23:02	169358.1			11.9			21.29			4.73			13.91			1		
09/27/19 23:03	149334			826.1			23.6			289.05			13.59			1		
09/27/19 23:04	76168.8			1777.8			25.62			317.16			7.52			1		
09/27/19 23:05	0			0			28.1			0			0			0		
09/27/19 23:06	0			0			17.7			0			0			0		
09/27/19 23:07	0			0			0.1			0			0			0		
09/27/19 23:08	0			0			0.1			0			0			0		
09/27/19 23:09	0			0			0.1			0			0			0		

CT2 SUSD EVENT 17

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/30/19 10:40	0			0			0			0			0			0		
09/30/19 10:41	0			0			0			0			0			0		
09/30/19 10:42	0			0			0			0			0			0		
09/30/19 10:43	0			0			0			0			0			0		
09/30/19 10:44	0			0			0			0			0			0		
09/30/19 10:45	7855.6			0.3			0			0			0			1		
09/30/19 10:46	30575.3			0.4			0			0			0			1		
09/30/19 10:47	44669.3			50.2			26.55			5.25			4.58			1		
09/30/19 10:48	56298.7			549.4			16.06			72.43			3.49			1		
09/30/19 10:49	69699.5			419.5			19.47			68.55			5.24			1		
09/30/19 10:50	106128			271.1			24.72			67.43			10.12			1		
09/30/19 10:51	149334			151.7			31.96			53.07			18.4			1		
09/30/19 10:52	156573.5			56.6			50.74			20.78			30.64			1		
09/30/19 10:53	166200.5			1086.1			45.41			423.04			29.11			1		
09/30/19 10:54	185993.6			1793.9			49.46			781.85			35.47			1		
09/30/19 10:55	209329.4			958			60.59			470.08			48.93			1		
09/30/19 10:56	234975.7			174			62.84			95.8			56.95			1		
09/30/19 10:57	258080.5			12.9			60.97			7.81			60.69			1		
09/30/19 10:58	281724.4			2.6			62.61			1.73			68.04			1		
09/30/19 10:59	310220.3			2.2			57.5			1.6			68.8			1		
09/30/19 11:00	334018.3			2			38.21			1.56			49.23			1		
09/30/19 11:01	355120.7			2.1			20.04			1.73			27.45			1		
09/30/19 11:02	371140			2.2			17.87			1.89			25.59			1		
09/30/19 11:03	387467.3			2.2			13.91			2			20.79			1		
09/30/19 11:04	396401.2			2.1			12.25			1.91			18.72			1		
09/30/19 11:05	402023.4			1.9			11.08			1.77			17.19			1		
09/30/19 11:06	404256.8			1.7			10.53			1.63			16.42			1		
09/30/19 11:07	406721.3			1.5			9.98			1.47			15.66			1		
09/30/19 11:08	406182.3			1.5			9.44			1.38			14.79			1		
09/30/19 11:09	406413.3			1.4			9.44			1.3			14.8			1		
09/30/19 11:10	405181			1.4			9.35			1.29			14.61			1		
09/30/19 11:11	404179.8			1.3			9.26			1.2			14.43			1		
09/30/19 11:12	403409.7			1.3			9.17			1.2			14.27			1		
09/30/19 11:13	403563.7			1.2			9.26			1.12			14.41			1		
09/30/19 11:14	402639.5			1.2			9.35			1.11			14.52			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/30/19 11:15	402639.5			1.2			9.44			1.11			14.66			1		
09/30/19 11:16	402639.5			1.2			9.59			1.13			14.89			1		
09/30/19 11:17	402639.5			1.2			9.59			1.13			14.89			1		
09/30/19 11:18	400021			1.1			9.77			1.04			15.08			1		
09/30/19 11:19	400714.1			1.1			9.86			1.04			15.24			1		
09/30/19 11:20	400329			1.1			9.96			1.04			15.37			1		
09/30/19 11:21	400868.1			1.1			10.14			1.04			15.68			1		
09/30/19 11:22	400021			1.1			10.23			1.04			15.79			1		
09/30/19 11:23	400252			1.1			10.33			1.04			15.94			1		
09/30/19 11:24	400329			1.1			8.2			1.04			12.67			1		
09/30/19 11:25	399866.9			1.1			3.78			1.04			5.83			1		
09/30/19 11:26	394552.8			1			3.13			0.94			4.77			1		
09/30/19 11:27	374528.7			1.1			2.9			0.96			4.2			1		
09/30/19 11:28	369753.7			1.1			2.86			0.93			4.08			1		
09/30/19 11:29	367828.3			1.2			2.77			1			3.93			1		
09/30/19 11:30	367289.2			1.2			2.5			1			3.55			1		
09/30/19 11:31	366519			1.2			2.27			1.01			3.21			1		
09/30/19 11:32	366442			1.2			2			1.01			2.82			1		
09/30/19 11:33	364978.7			1.1			1.82			0.93			2.56			1		
09/30/19 11:34	365286.8			1.1			1.72			0.93			2.43			1		
09/30/19 11:35	361281.9			1.1			1.63			0.92			2.28			1		
09/30/19 11:36	359202.5			1.2			1.54			0.99			2.14			0		
09/30/19 11:37	356429.9			1.2			1.54			0.99			2.12			0		
09/30/19 11:38	353580.3			1.2			1.45			0.98			1.98			0		
09/30/19 11:39	351886			1.2			1.43			0.96			1.94			0		
09/30/19 11:40	351963			1.2			1.34			0.96			1.82			0		

CT2 SUSD EVENT 18

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/30/19 16:59	434986.2			1.1			1.97			1.15			3.3			0		
09/30/19 17:00	411727.4			1			2.06			0.99			3.27			0		
09/30/19 17:01	388006.5			1			2.03			0.92			3.03			0		
09/30/19 17:02	362052.1			1.1			2			0.92			2.79			0		
09/30/19 17:03	336636.8			1.1			1.79			0.85			2.32			0		
09/30/19 17:04	325546.5			1.2			1.7			0.89			2.13			1		
09/30/19 17:05	312299.8			1.2			1.82			0.86			2.19			1		
09/30/19 17:06	288347.8			1.1			2.03			0.75			2.26			1		
09/30/19 17:07	266629.3			1			3.84			0.64			3.95			1		
09/30/19 17:08	246143			1			7.54			0.56			7.16			1		
09/30/19 17:09	219495.5			0.8			17.09			0.42			14.47			1		
09/30/19 17:10	192308.9			0.8			21.1			0.36			15.65			1		
09/30/19 17:11	170744.4			6.4			23.22			2.57			15.29			1		
09/30/19 17:12	150797.3			489.4			25.18			172.98			14.65			1		
09/30/19 17:13	86566			1612			26.3			326.93			8.78			1		
09/30/19 17:14	0			0			27.7			0			0			0		
09/30/19 17:15	0			0			17.7			0			0			0		
09/30/19 17:16	0			0			0.2			0			0			0		
09/30/19 17:17	0			0			0.1			0			0			0		
09/30/19 17:18	0			0			0.1			0			0			0		

ATTACHMENT 16

AQ-57

AQ-57 The emissions rates from each gas turbine and heat recovery steam generator exhaust during startup and shutdown or excursions shall not exceed the following:

Combustion Turbine emissions limitations per Turbine excluding Startup and Shutdown	
Pollutant	**Pounds/Hour**
CO	6.2 3hr rolling
NOX	5.1 1 hour rolling
PM-10	4.7
SOX	1.0
VOC	1.8

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6

AQ-57 If the Alstom GX100 turbines are selected for the Project, emission rates from each gas turbine and heat recovery steam generator exhaust, except during startup and/or shutdown, or excursions shall not exceed the following:

Alstom GTX100 - COMBUSTION TURBINE EMISSION LIMITATIONS PER TURBINE EXCLUDING STARTUP AND SHUTDOWN	
POLLUTANT	POUNDS/HOUR
Carbon Monoxide (CO)	6.2 (three-hour rolling average)
Nitrogen Oxides (NOx)	5.1 (one-hour average)
PM10	4.7
Sulfur Oxides (SOx)	1.0
Volatile Organic Compounds (VOCs)	1.8

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emission limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

AQ57 CT1 HOURLY EMISSIONS

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/01/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/02/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/04/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/05/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/07/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/08/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/10/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/11/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/13/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/15/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/16/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/18/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/19/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/21/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/23/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/19 5:00	0	X		0	X		0	X		0.18			0.09192			0.31		
07/23/19 6:00	0	X		0	X		0	X		0.42			0.21186			0.71		
07/23/19 7:00	0.8			1.8			1			0.45			0.22266			0.74		
07/23/19 8:00	0.7			1.7			1			0.47			0.2352			0.78		
07/23/19 9:00	0.7			1.7			1			0.52			0.2601			0.87		
07/23/19 10:00	0.8			1.7			1			0.52			0.25806			0.86		
07/23/19 11:00	0.4			1.7			2			0.67			0.33654			1.12		
07/23/19 12:00	0.2			1.7			3			0.76			0.37866			1.26		
07/23/19 13:00	0.1			1.7			3			0.76			0.37992			1.27		
07/23/19 14:00	0.1			1.7			3			0.76			0.37968			1.27		
07/23/19 15:00	0.1			1.7			3			0.76			0.37908			1.26		
07/23/19 16:00	0.1			1.7			4			0.76			0.3789			1.26		
07/23/19 17:00	0.1			1.7			3			0.76			0.3804			1.27		
07/23/19 18:00	0.1			1.7			3			0.76			0.3807			1.27		
07/23/19 19:00	0.2			1.7			4			0.76			0.38118			1.27		
07/23/19 20:00	0.2			1.7			4			0.76			0.38244			1.27		
07/23/19 21:00	0.2			1.7			4			0.77			0.3834			1.28		
07/23/19 22:00	0.2			1.7			4			0.77			0.3846			1.28		
07/23/19 23:00	0.2			1.7			4			0.77			0.38532			1.28		
07/24/19 0:00	0.2			1.7			4			0.77			0.38388			1.28		
07/24/19 1:00	0.2			1.7			4			0.77			0.38418			1.28		
07/24/19 2:00	0.2			1.7			4			0.76			0.3807			1.27		
07/24/19 3:00	0.2			1.7			4			0.76			0.38076			1.27		
07/24/19 4:00	0.2			1.7			3			0.76			0.38154			1.27		
07/24/19 5:00	0.2			1.7			4			0.76			0.38226			1.27		
07/24/19 6:00	0.2			1.7			4			0.76			0.38196			1.27		
07/24/19 7:00	0.2			1.7			4			0.76			0.38058			1.27		
07/24/19 8:00	0.2			1.7			3			0.76			0.37836			1.26		
07/24/19 9:00	0.2			1.7			3			0.76			0.37878			1.26		
07/24/19 10:00	0.2			1.7			3			0.76			0.3795			1.27		
07/24/19 11:00	0.2			1.7			3			0.76			0.37926			1.26		
07/24/19 12:00	0.2			1.7			3			0.76			0.37986			1.27		
07/24/19 13:00	0.2			1.7			3			0.76			0.37998			1.27		
07/24/19 14:00	0.2			1.7			3			0.76			0.37938			1.26		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/24/19 15:00	0.2			1.7			4			0.76			0.37998			1.27		
07/24/19 16:00	0.2			1.7			3			0.76			0.37812			1.26		
07/24/19 17:00	0.2			1.7			3			0.76			0.37866			1.26		
07/24/19 18:00	0.2			1.7			3			0.76			0.37878			1.26		
07/24/19 19:00	0.2			1.7			3			0.75			0.37488			1.25		
07/24/19 20:00	0.2			1.7			3			0.75			0.37692			1.26		
07/24/19 21:00	0.2			1.7			3			0.76			0.3798			1.27		
07/24/19 22:00	0.2			1.7			3			0.74			0.37008			1.23		
07/24/19 23:00	1.1			1.8			1			0.52			0.25794			0.86		
07/25/19 0:00	1.3			1.7			2			0.55			0.27264			0.91		
07/25/19 1:00	1.3			1.7			2			0.54			0.27018			0.9		
07/25/19 2:00	0.8			1.7			2			0.52			0.26082			0.87		
07/25/19 3:00	0.8			1.7			2			0.5			0.24972			0.83		
07/25/19 4:00	0.8			1.7			1			0.51			0.25434			0.85		
07/25/19 5:00	0.9			1.7			1			0.51			0.2565			0.86		
07/25/19 6:00	0.8			1.7			2			0.51			0.2553			0.85		
07/25/19 7:00	1			1.7			2			0.53			0.26604			0.89		
07/25/19 8:00	0.2			1.6			3			0.76			0.37884			1.26		
07/25/19 9:00	0.2			1.7			3			0.76			0.38112			1.27		
07/25/19 10:00	0.2			1.7			3			0.76			0.37884			1.26		
07/25/19 11:00	0.2			1.7			3			0.76			0.3786			1.26		
07/25/19 12:00	0.2			1.7			3			0.76			0.3795			1.27		
07/25/19 13:00	0.2			1.7			3			0.76			0.37998			1.27		
07/25/19 14:00	0.2			1.7			3			0.76			0.3792			1.26		
07/25/19 15:00	0.2			1.7			3			0.75			0.37692			1.26		
07/25/19 16:00	0.3			1.7			2			0.67			0.33342			1.11		
07/25/19 17:00	0.4			1.7			2			0.65			0.3243			1.08		
07/25/19 18:00	0.9			1.7			1			0.59			0.29436			0.98		
07/25/19 19:00	0.6			1.7			2			0.64			0.3177			1.06		
07/25/19 20:00	0.3			1.7			3			0.71			0.35526			1.18		
07/25/19 21:00	0.4			1.7			2			0.67			0.33456			1.12		
07/25/19 22:00	1.1			1.8			1			0.53			0.2625			0.88		
07/25/19 23:00	0.9			1.7			2			0.53			0.26376			0.88		
07/26/19 0:00	0.8			1.7			2			0.6			0.3003			1		
07/26/19 1:00	0.9			1.8			1			0.51			0.25362			0.85		
07/26/19 2:00	0.7			1.7			1			0.52			0.26034			0.87		
07/26/19 3:00	0.7			1.7			2			0.52			0.26202			0.87		
07/26/19 4:00	0.8			1.7			1			0.52			0.26136			0.87		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/26/19 5:00	0.8			1.7			1			0.49			0.24342			0.81		
07/26/19 6:00	1.2			1.7			2			0.57			0.28584			0.95		
07/26/19 7:00	1.2			1.7			2			0.58			0.29046			0.97		
07/26/19 8:00	1.1			1.7			1			0.58			0.28908			0.96		
07/26/19 9:00	1			1.7			1			0.59			0.2943			0.98		
07/26/19 10:00	0.5			1.7			2			0.65			0.3273			1.09		
07/26/19 11:00	0.2			1.7			3			0.76			0.37974			1.27		
07/26/19 12:00	0.2			1.7			3			0.76			0.38022			1.27		
07/26/19 13:00	0.2			1.7			2			0.71			0.35286			1.18		
07/26/19 14:00	0.2			1.7			2			0.7			0.35238			1.17		
07/26/19 15:00	0.2			1.7			3			0.76			0.37836			1.26		
07/26/19 16:00	0.2			1.7			4			0.76			0.37962			1.27		
07/26/19 17:00	0.2			1.7			4			0.76			0.38064			1.27		
07/26/19 18:00	0.2			1.7			3			0.74			0.3675			1.23		
07/26/19 19:00	0.3			1.7			2			0.7			0.34824			1.16		
07/26/19 20:00	0.2			1.7			3			0.73			0.36564			1.22		
07/26/19 21:00	0.2			1.7			3			0.75			0.37278			1.24		
07/26/19 22:00	0.5			1.7			2			0.64			0.31998			1.07		
07/26/19 23:00	0.7			1.7			2			0.62			0.3096			1.03		
07/27/19 0:00	1.1			1.7			1			0.58			0.28956			0.97		
07/27/19 1:00	1.2			1.7			1			0.57			0.28488			0.95		
07/27/19 2:00	0.9			1.7			1			0.48			0.23994			0.8		
07/27/19 3:00	0.9			1.7			1			0.43			0.21618			0.72		
07/27/19 4:00	0.9			1.7			1			0.43			0.213			0.71		
07/27/19 5:00	1			1.7			2			0.41			0.20454			0.68		
07/27/19 6:00	1			1.7			2			0.41			0.20718			0.69		
07/27/19 7:00	0.9			1.7			1			0.48			0.2415			0.81		
07/27/19 8:00	0.9			1.7			1			0.48			0.24156			0.81		
07/27/19 9:00	0.9			1.7			1			0.45			0.22668			0.76		
07/27/19 10:00	0.8			1.7			1			0.49			0.24492			0.82		
07/27/19 11:00	1.5			1.7			1			0.52			0.2592			0.86		
07/27/19 12:00	1.4			1.7			1			0.52			0.25776			0.86		
07/27/19 13:00	1.4			1.7			1			0.51			0.2565			0.86		
07/27/19 14:00	1.5			1.7			1			0.51			0.25392			0.85		
07/27/19 15:00	1.5			1.7			1			0.49			0.24378			0.81		
07/27/19 16:00	0.3			1.7			3			0.73			0.36714			1.22		
07/27/19 17:00	0.2			1.7			3			0.74			0.36924			1.23		
07/27/19 18:00	0.2			1.7			3			0.74			0.36762			1.23		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/27/19 19:00	0.2			1.7			3			0.73			0.36516			1.22		
07/27/19 20:00	0.3			1.7			3			0.74			0.36834			1.23		
07/27/19 21:00	0.2			1.7			3			0.74			0.37092			1.24		
07/27/19 22:00	0.4			1.6			2			0.68			0.33876			1.13		
07/27/19 23:00	0.9			1.8			1			0.46			0.22848			0.76		
07/28/19 0:00	0.9			1.7			1			0.43			0.2163			0.72		
07/28/19 1:00	1			1.7			1			0.4			0.20022			0.67		
07/28/19 2:00	0.9			1.7			1			0.38			0.18822			0.63		
07/28/19 3:00	0.9			1.7			2			0.38			0.19188			0.64		
07/28/19 4:00	1			1.7			2			0.39			0.19344			0.64		
07/28/19 5:00	1			1.7			2			0.39			0.19566			0.65		
07/28/19 6:00	1			1.7			2			0.39			0.19722			0.66		
07/28/19 7:00	1			1.7			1			0.42			0.21018			0.7		
07/28/19 8:00	0.9			1.7			1			0.42			0.21024			0.7		
07/28/19 9:00	0.8			1.7			1			0.43			0.21618			0.72		
07/28/19 10:00	1.3			1.7			1			0.51			0.25452			0.85		
07/28/19 11:00	1.4			1.7			1			0.51			0.25512			0.85		
07/28/19 12:00	0.4			1.7			2			0.67			0.33492			1.12		
07/28/19 13:00	0.2			1.7			3			0.73			0.36402			1.21		
07/28/19 14:00	0.2			1.7			3			0.75			0.3729			1.24		
07/28/19 15:00	0.2			1.7			3			0.74			0.37206			1.24		
07/28/19 16:00	0.1			1.7			3			0.74			0.37194			1.24		
07/28/19 17:00	0.2			1.7			3			0.74			0.37134			1.24		
07/28/19 18:00	0.2			1.7			3			0.74			0.36864			1.23		
07/28/19 19:00	0.5			1.7			2			0.62			0.31182			1.04		
07/28/19 20:00	0.2			1.7			3			0.74			0.36774			1.23		
07/28/19 21:00	0.2			1.7			3			0.72			0.35868			1.2		
07/28/19 22:00	0.5			1.7			2			0.62			0.312			1.04		
07/28/19 23:00	0.9			1.8			1			0.52			0.25926			0.86		
07/29/19 0:00	0.8			1.7			1			0.49			0.2469			0.82		
07/29/19 1:00	0.8			1.7			1			0.49			0.24408			0.81		
07/29/19 2:00	0.8			1.7			1			0.48			0.23946			0.8		
07/29/19 3:00	0.8			1.7			1			0.47			0.23718			0.79		
07/29/19 4:00	0.8			1.7			1			0.47			0.23442			0.78		
07/29/19 5:00	0.9			1.7			1			0.51			0.25626			0.85		
07/29/19 6:00	0.8			1.7			2			0.61			0.30714			1.02		
07/29/19 7:00	0.5			1.7			2			0.65			0.32634			1.09		
07/29/19 8:00	0.8			1.8			1			0.5			0.2496			0.83		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/29/19 9:00	0.7			1.7			1			0.49			0.2463			0.82		
07/29/19 10:00	0.6			1.7			2			0.63			0.31674			1.06		
07/29/19 11:00	0.3			1.7			2			0.69			0.3432			1.14		
07/29/19 12:00	1.3			1.8			1			0.52			0.25932			0.86		
07/29/19 13:00	0.4			1.7			3			0.72			0.36006			1.2		
07/29/19 14:00	0.2			1.7			3			0.76			0.37932			1.26		
07/29/19 15:00	0.2			1.7			3			0.75			0.3771			1.26		
07/29/19 16:00	0.1			1.7			3			0.73			0.36444			1.21		
07/29/19 17:00	0.1			1.7			3			0.73			0.36522			1.22		
07/29/19 18:00	0.2			1.7			3			0.72			0.36114			1.2		
07/29/19 19:00	0.5			1.7			2			0.64			0.31872			1.06		
07/29/19 20:00	0.2			1.7			3			0.71			0.3561			1.19		
07/29/19 21:00	0.4			1.7			2			0.66			0.32952			1.1		
07/29/19 22:00	0.9			1.8			1			0.52			0.25956			0.87		
07/29/19 23:00	0.7			1.7			2			0.38			0.18816			0.63		
07/30/19 0:00	0.7			1.7			2			0.36			0.17946			0.6		
07/30/19 1:00	0.7			1.7			2			0.36			0.17826			0.59		
07/30/19 2:00	0.7			1.7			2			0.36			0.17802			0.59		
07/30/19 3:00	0.7			1.7			2			0.36			0.17808			0.59		
07/30/19 4:00	0.7			1.7			2			0.36			0.1782			0.59		
07/30/19 5:00	0.9			1.7			2			0.41			0.20544			0.68		
07/30/19 6:00	0.9			1.7			2			0.42			0.21168			0.71		
07/30/19 7:00	0.8			1.7			1			0.46			0.22752			0.76		
07/30/19 8:00	0.8			1.7			1			0.45			0.2271			0.76		
07/30/19 9:00	0.8			1.7			1			0.44			0.21924			0.73		
07/30/19 10:00	0.8			1.7			1			0.43			0.21726			0.72		
07/30/19 11:00	0.8			1.7			1			0.41			0.20646			0.69		
07/30/19 12:00	0.8			1.7			2			0.4			0.19956			0.67		
07/30/19 13:00	0.8			1.7			2			0.38			0.18918			0.63		
07/30/19 14:00	0.8			1.7			2			0.38			0.1911			0.64		
07/30/19 15:00	0.8			1.7			2			0.38			0.19068			0.64		
07/30/19 16:00	0.8			1.7			1			0.51			0.25392			0.85		
07/30/19 17:00	0.9			1.7			1			0.52			0.25914			0.86		
07/30/19 18:00	0.7			1.7			1			0.46			0.2277			0.76		
07/30/19 19:00	0.8			1.7			1			0.42			0.21222			0.71		
07/30/19 20:00	0.8			1.7			1			0.44			0.21834			0.73		
07/30/19 21:00	0.8			1.7			2			0.42			0.20796			0.69		
07/30/19 22:00	0.8			1.7			1			0.44			0.22092			0.74		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/30/19 23:00	0.9			1.7			2			0.39			0.19746			0.66		
07/31/19 0:00	0.8			1.7			2			0.38			0.18876			0.63		
07/31/19 1:00	0.8			1.7			2			0.37			0.18264			0.61		
07/31/19 2:00	0.8			1.7			2			0.36			0.18246			0.61		
07/31/19 3:00	0.8			1.7			2			0.37			0.18282			0.61		
07/31/19 4:00	0.8			1.7			2			0.36			0.18186			0.61		
07/31/19 5:00	0.8			1.7			2			0.36			0.17988			0.6		
07/31/19 6:00	0.8			1.7			2			0.37			0.183			0.61		
07/31/19 7:00	0.8			1.7			2			0.38			0.19044			0.63		
07/31/19 8:00	0.9			1.7			2			0.39			0.19524			0.65		
07/31/19 9:00	0.7			1.7			1			0.37			0.18402			0.61		
07/31/19 10:00	0.7			1.7			1			0.36			0.17898			0.6		
07/31/19 11:00	0.7			1.7			1			0.36			0.17982			0.6		
07/31/19 12:00	0.8			1.7			1			0.43			0.21606			0.72		
07/31/19 13:00	0.8			1.7			1			0.48			0.2376			0.79		
07/31/19 14:00	0.4			1.7			2			0.69			0.34578			1.15		
07/31/19 15:00	0.3			1.7			2			0.67			0.33678			1.12		
07/31/19 16:00	0.4			1.7			2			0.66			0.33048			1.1		
07/31/19 17:00	0.4			1.7			2			0.65			0.32688			1.09		
07/31/19 18:00	0.4			1.7			2			0.65			0.32718			1.09		
07/31/19 19:00	0.4			1.7			2			0.66			0.33156			1.11		
07/31/19 20:00	0.8			1.8			1			0.49			0.24396			0.81		
07/31/19 21:00	0.8			1.7			1			0.46			0.22878			0.76		
07/31/19 22:00	0.8			1.7			2			0.38			0.19002			0.63		
07/31/19 23:00	0.8			1.7			2			0.37			0.183			0.61		
08/01/19 0:00	0.7			1.7			2			0.36			0.18144			0.6		
08/01/19 1:00	0.7			1.7			1			0.36			0.18072			0.6		
08/01/19 2:00	0.7			1.7			1			0.36			0.18			0.6		
08/01/19 3:00	0.7			1.7			1			0.36			0.17928			0.6		
08/01/19 4:00	0.7			1.7			1			0.36			0.17946			0.6		
08/01/19 5:00	0.7			1.7			2			0.36			0.1803			0.6		
08/01/19 6:00	0.7			1.7			2			0.36			0.18138			0.6		
08/01/19 7:00	0.7			1.7			2			0.37			0.18528			0.62		
08/01/19 8:00	0.7			1.7			2			0.37			0.18336			0.61		
08/01/19 9:00	0.8			1.7			2			0.38			0.18756			0.63		
08/01/19 10:00	0.7			1.7			1			0.36			0.18084			0.6		
08/01/19 11:00	0.7			1.7			1			0.37			0.1842			0.61		
08/01/19 12:00	0.7			1.7			1			0.5			0.25146			0.84		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/01/19 13:00	0.7			1.7			1			0.52			0.25836			0.86		
08/01/19 14:00	0.7			1.7			1			0.52			0.25758			0.86		
08/01/19 15:00	0.8			1.7			1			0.51			0.2571			0.86		
08/01/19 16:00	0.9			1.7			1			0.58			0.28824			0.96		
08/01/19 17:00	0.9			1.7			1			0.59			0.2928			0.98		
08/01/19 18:00	0.3			1.7			2			0.67			0.33492			1.12		
08/01/19 19:00	0.8			1.8			1			0.52			0.25854			0.86		
08/01/19 20:00	0.7			1.7			2			0.38			0.19152			0.64		
08/01/19 21:00	0.8			1.7			2			0.37			0.1848			0.62		
08/01/19 22:00	0.7			1.7			2			0.37			0.18408			0.61		
08/01/19 23:00	0.7			1.7			2			0.36			0.18228			0.61		
08/02/19 0:00	0.7			1.7			1			0.36			0.18168			0.61		
08/02/19 1:00	0.7			1.7			1			0.36			0.18156			0.61		
08/02/19 2:00	0.7			1.7			1			0.36			0.18096			0.6		
08/02/19 3:00	0.7			1.7			1			0.36			0.18048			0.6		
08/02/19 4:00	0.7			1.7			1			0.36			0.17934			0.6		
08/02/19 5:00	0.7			1.7			2			0.36			0.17898			0.6		
08/02/19 6:00	0.7			1.7			2			0.36			0.1797			0.6		
08/02/19 7:00	0.7			1.7			1			0.36			0.17994			0.6		
08/02/19 8:00	0.7			1.7			1			0.36			0.17946			0.6		
08/02/19 9:00	0.7			1.7			2			0.36			0.17922			0.6		
08/02/19 10:00	0.7			1.7			2			0.36			0.17916			0.6		
08/02/19 11:00	0.7			1.7			1			0.36			0.18114			0.6		
08/02/19 12:00	0.8			1.7			1			0.4			0.19968			0.67		
08/02/19 13:00	1			1.7			1			0.53			0.26592			0.89		
08/02/19 14:00	1			1.7			1			0.55			0.27354			0.91		
08/02/19 15:00	0.3			1.7			2			0.71			0.35292			1.18		
08/02/19 16:00	0.2			1.7			2			0.71			0.35664			1.19		
08/02/19 17:00	0.2			1.7			3			0.72			0.3606			1.2		
08/02/19 18:00	0.5			1.7			1			0.63			0.31386			1.05		
08/02/19 19:00	1			1.8			1			0.54			0.2718			0.91		
08/02/19 20:00	0.9			1.7			1			0.43			0.21474			0.72		
08/02/19 21:00	0.8			1.7			2			0.38			0.18828			0.63		
08/02/19 22:00	0.8			1.7			1			0.37			0.186			0.62		
08/02/19 23:00	0.8			1.7			2			0.37			0.1866			0.62		
08/03/19 0:00	0.8			1.7			2			0.37			0.18522			0.62		
08/03/19 1:00	0.8			1.7			1			0.36			0.17874			0.6		
08/03/19 2:00	0.7			1.7			1			0.36			0.17862			0.6		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/03/19 3:00	0.7			1.7			1			0.36			0.1788			0.6		
08/03/19 4:00	0.7			1.7			1			0.36			0.17892			0.6		
08/03/19 5:00	0.8			1.7			1			0.36			0.17868			0.6		
08/03/19 6:00	0.7			1.7			1			0.36			0.1791			0.6		
08/03/19 7:00	0.8			1.7			2			0.37			0.18528			0.62		
08/03/19 8:00	0.8			1.7			2			0.37			0.18396			0.61		
08/03/19 9:00	0.7			1.7			2			0.37			0.18378			0.61		
08/03/19 10:00	0.8			1.7			1			0.38			0.1881			0.63		
08/03/19 11:00	0.8			1.7			1			0.39			0.19392			0.65		
08/03/19 12:00	0.8			1.7			1			0.41			0.2052			0.68		
08/03/19 13:00	1.1			1.7			1			0.56			0.27786			0.93		
08/03/19 14:00	0.7			1.7			1			0.61			0.30324			1.01		
08/03/19 15:00	0.2			1.7			3			0.75			0.37446			1.25		
08/03/19 16:00	0.2			1.7			3			0.74			0.37182			1.24		
08/03/19 17:00	0.2			1.7			3			0.72			0.36			1.2		
08/03/19 18:00	0.2			1.7			3			0.74			0.3693			1.23		
08/03/19 19:00	0.2			1.7			2			0.68			0.3405			1.14		
08/03/19 20:00	1			1.7			1			0.57			0.2829			0.94		
08/03/19 21:00	0.8			1.7			1			0.46			0.2304			0.77		
08/03/19 22:00	0.8			1.7			1			0.42			0.20976			0.7		
08/03/19 23:00	0.8			1.7			2			0.38			0.19032			0.63		
08/04/19 0:00	0.8			1.7			2			0.37			0.1863			0.62		
08/04/19 1:00	0.8			1.7			2			0.37			0.1854			0.62		
08/04/19 2:00	0.8			1.7			2			0.37			0.18456			0.62		
08/04/19 3:00	0.7			1.7			2			0.37			0.18324			0.61		
08/04/19 4:00	0.7			1.7			1			0.36			0.17964			0.6		
08/04/19 5:00	0.8			1.7			2			0.36			0.18228			0.61		
08/04/19 6:00	0.7			1.7			1			0.36			0.17946			0.6		
08/04/19 7:00	0.7			1.7			1			0.36			0.18054			0.6		
08/04/19 8:00	0.8			1.7			1			0.36			0.18198			0.61		
08/04/19 9:00	0.7			1.7			1			0.36			0.18156			0.61		
08/04/19 10:00	0.7			1.7			1			0.37			0.18384			0.61		
08/04/19 11:00	0.8			1.7			1			0.4			0.1986			0.66		
08/04/19 12:00	0.7			1.7			1			0.53			0.26352			0.88		
08/04/19 13:00	0.2			1.7			2			0.69			0.34434			1.15		
08/04/19 14:00	0.3			1.7			2			0.68			0.33852			1.13		
08/04/19 15:00	0.2			1.7			2			0.7			0.34758			1.16		
08/04/19 16:00	0.3			1.7			2			0.66			0.32886			1.1		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/04/19 17:00	0.2			1.7			2			0.69			0.34278			1.14		
08/04/19 18:00	0.1			1.7			3			0.74			0.36882			1.23		
08/04/19 19:00	0.1			1.7			3			0.74			0.37086			1.24		
08/04/19 20:00	0.2			1.7			2			0.69			0.34362			1.15		
08/04/19 21:00	1			1.7			1			0.58			0.28806			0.96		
08/04/19 22:00	0.9			1.7			1			0.51			0.25704			0.86		
08/04/19 23:00	0.8			1.7			2			0.38			0.19188			0.64		
08/05/19 0:00	0.7			1.7			1			0.36			0.17826			0.59		
08/05/19 1:00	0.7			1.7			1			0.36			0.17844			0.59		
08/05/19 2:00	0.7			1.7			1			0.36			0.17844			0.59		
08/05/19 3:00	0.7			1.7			1			0.36			0.17826			0.59		
08/05/19 4:00	0.7			1.7			1			0.36			0.17814			0.59		
08/05/19 5:00	0.8			1.7			1			0.36			0.17814			0.59		
08/05/19 6:00	0.8			1.7			2			0.37			0.18534			0.62		
08/05/19 7:00	0.8			1.7			2			0.37			0.18504			0.62		
08/05/19 8:00	0.8			1.7			1			0.37			0.1839			0.61		
08/05/19 9:00	0	X		0	X		0	X		0.37			0.18612			0.62		
08/05/19 10:00	0	X		0	X		0	X		0.37			0.18624			0.62		
08/05/19 11:00	0.7			1.7			1			0.38			0.19218			0.64		
08/05/19 12:00	0.7			1.6			1			0.46			0.23094			0.77		
08/05/19 13:00	0.7			1.7			1			0.51			0.25254			0.84		
08/05/19 14:00	0.7			1.7			1			0.5			0.2505			0.84		
08/05/19 15:00	0.2			1.7			2			0.7			0.34752			1.16		
08/05/19 16:00	0.1			1.7			2			0.7			0.35196			1.17		
08/05/19 17:00	0.1			1.7			3			0.75			0.3759			1.25		
08/05/19 18:00	0.1			1.7			3			0.75			0.37584			1.25		
08/05/19 19:00	0.2			1.7			2			0.68			0.34098			1.14		
08/05/19 20:00	0.8			1.8			1			0.52			0.26148			0.87		
08/05/19 21:00	0.8			1.7			1			0.48			0.24			0.8		
08/05/19 22:00	0.8			1.7			1			0.39			0.19674			0.66		
08/05/19 23:00	0.7			1.7			1			0.36			0.17952			0.6		
08/06/19 0:00	0.7			1.7			1			0.36			0.1776			0.59		
08/06/19 1:00	0.7			1.7			1			0.36			0.17766			0.59		
08/06/19 2:00	0.7			1.7			1			0.36			0.17784			0.59		
08/06/19 3:00	0.7			1.7			1			0.36			0.1803			0.6		
08/06/19 4:00	0.7			1.7			1			0.37			0.18276			0.61		
08/06/19 5:00	0.9			1.7			2			0.39			0.19392			0.65		
08/06/19 6:00	0.8			1.7			2			0.39			0.1935			0.65		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/06/19 7:00	0.8			1.7			2			0.39			0.19338			0.64		
08/06/19 8:00	0.8			1.7			2			0.39			0.19266			0.64		
08/06/19 9:00	0.7			1.7			1			0.36			0.18096			0.6		
08/06/19 10:00	0.8			1.7			1			0.4			0.20088			0.67		
08/06/19 11:00	0.7			1.7			1			0.48			0.23982			0.8		
08/06/19 12:00	0.7			1.7			1			0.5			0.25206			0.84		
08/06/19 13:00	1.1			1.7			1			0.54			0.27144			0.9		
08/06/19 14:00	0.1			1.7			3			0.75			0.37332			1.24		
08/06/19 15:00	0.1			1.7			3			0.73			0.3639			1.21		
08/06/19 16:00	0.1			1.7			3			0.73			0.36546			1.22		
08/06/19 17:00	0.1			1.7			3			0.75			0.37464			1.25		
08/06/19 18:00	0.1			1.7			3			0.71			0.35322			1.18		
08/06/19 19:00	0.7			1.7			1			0.59			0.29682			0.99		
08/06/19 20:00	0.6			1.7			1			0.6			0.30198			1.01		
08/06/19 21:00	0.7			1.7			1			0.51			0.25602			0.85		
08/06/19 22:00	0.7			1.7			1			0.41			0.20544			0.68		
08/06/19 23:00	0.7			1.7			1			0.36			0.18138			0.6		
08/07/19 0:00	0.7			1.7			1			0.36			0.17784			0.59		
08/07/19 1:00	0.7			1.7			1			0.36			0.1776			0.59		
08/07/19 2:00	0.6			1.7			1			0.36			0.17838			0.59		
08/07/19 3:00	0.6			1.7			1			0.36			0.17868			0.6		
08/07/19 4:00	0.7			1.7			1			0.36			0.17982			0.6		
08/07/19 5:00	0.7			1.7			1			0.36			0.18018			0.6		
08/07/19 6:00	0.7			1.7			2			0.37			0.18618			0.62		
08/07/19 7:00	0.7			1.7			1			0.37			0.18552			0.62		
08/07/19 8:00	0.8			1.7			1			0.38			0.19134			0.64		
08/07/19 9:00	0.8			1.7			1			0.39			0.1926			0.64		
08/07/19 10:00	0.8			1.7			1			0.39			0.1929			0.64		
08/07/19 11:00	0.8			1.7			1			0.41			0.20274			0.68		
08/07/19 12:00	0.7			1.7			1			0.47			0.234			0.78		
08/07/19 13:00	1.2			1.7			1			0.55			0.273			0.91		
08/07/19 14:00	0.3			1.7			2			0.66			0.33012			1.1		
08/07/19 15:00	0.1			1.7			2			0.7			0.34824			1.16		
08/07/19 16:00	0.1			1.7			3			0.72			0.3582			1.19		
08/07/19 17:00	0.1			1.7			3			0.76			0.37794			1.26		
08/07/19 18:00	0.2			1.7			2			0.71			0.35304			1.18		
08/07/19 19:00	1			1.8			2			0.54			0.27138			0.9		
08/07/19 20:00	0.7			1.7			2			0.45			0.22386			0.75		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/07/19 21:00	0.7			1.7			2			0.42			0.2109			0.7		
08/07/19 22:00	0.7			1.7			1			0.36			0.17922			0.6		
08/07/19 23:00	0.8			1.7			2			0.4			0.20172			0.67		
08/08/19 0:00	0.7			1.7			2			0.37			0.1842			0.61		
08/08/19 1:00	0.6			1.7			1			0.36			0.17856			0.6		
08/08/19 2:00	0.6			1.7			2			0.36			0.17874			0.6		
08/08/19 3:00	0.6			1.7			2			0.36			0.17868			0.6		
08/08/19 4:00	0.6			1.7			1			0.34			0.16944			0.56		
08/08/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/09/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/11/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/12/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/13/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/13/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/13/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/13/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/13/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/13/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/13/19 6:00	0			0			0	X		0.19			0.09582			0.32		
08/13/19 7:00	0.7			1.7			1			0.52			0.26226			0.87		
08/13/19 8:00	0.7			1.7			1			0.53			0.26334			0.88		
08/13/19 9:00	0.7			1.7			1			0.47			0.2346			0.78		
08/13/19 10:00	0.6			1.7			1			0.45			0.22698			0.76		
08/13/19 11:00	0.7			1.7			1			0.51			0.25554			0.85		
08/13/19 12:00	0.7			1.7			1			0.45			0.22716			0.76		
08/13/19 13:00	0.7			1.7			1			0.45			0.22392			0.75		
08/13/19 14:00	0.7			1.7			1			0.46			0.2286			0.76		
08/13/19 15:00	0.2			1.7			3			0.74			0.37176			1.24		
08/13/19 16:00	0.1			1.7			3			0.76			0.37902			1.26		
08/13/19 17:00	0.1			1.7			3			0.76			0.381			1.27		
08/13/19 18:00	0.3			1.7			2			0.68			0.34068			1.14		
08/13/19 19:00	0.1			1.7			3			0.75			0.37398			1.25		
08/13/19 20:00	0.1			1.7			3			0.73			0.36594			1.22		
08/13/19 21:00	0.3			1.7			2			0.67			0.3354			1.12		
08/13/19 22:00	1.1			1.7			1			0.58			0.29142			0.97		
08/13/19 23:00	0.4			1.7			2			0.68			0.33924			1.13		
08/14/19 0:00	0.6			1.7			2			0.63			0.31344			1.04		
08/14/19 1:00	0.7			1.7			1			0.61			0.30576			1.02		
08/14/19 2:00	1.1			1.7			1			0.58			0.28758			0.96		
08/14/19 3:00	1.1			1.7			2			0.58			0.29082			0.97		
08/14/19 4:00	0.2			1.7			2			0.72			0.36078			1.2		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/14/19 5:00	0.3			1.7			3			0.73			0.36492			1.22		
08/14/19 6:00	0.4			1.7			3			0.72			0.36228			1.21		
08/14/19 7:00	1			1.8			1			0.44			0.21942			0.73		
08/14/19 8:00	0.7			1.7			1			0.36			0.18168			0.61		
08/14/19 9:00	0.7			1.7			1			0.36			0.17898			0.6		
08/14/19 10:00	0.7			1.7			1			0.36			0.17934			0.6		
08/14/19 11:00	0.7			1.7			1			0.36			0.1803			0.6		
08/14/19 12:00	0.8			1.7			1			0.37			0.18294			0.61		
08/14/19 13:00	0.9			1.7			1			0.51			0.25428			0.85		
08/14/19 14:00	1.4			1.7			1			0.54			0.26928			0.9		
08/14/19 15:00	0.1			1.7			3			0.74			0.36894			1.23		
08/14/19 16:00	0.1			1.7			3			0.74			0.37248			1.24		
08/14/19 17:00	0.1			1.7			3			0.74			0.37224			1.24		
08/14/19 18:00	0.3			1.7			2			0.65			0.324			1.08		
08/14/19 19:00	0.1			1.7			2			0.71			0.35682			1.19		
08/14/19 20:00	0.4			1.8			2			0.6			0.29802			0.99		
08/14/19 21:00	0.8			1.6			1			0.47			0.23598			0.79		
08/14/19 22:00	0.8			1.6			1			0.47			0.23652			0.79		
08/14/19 23:00	0.7			1.6			1			0.36			0.17904			0.6		
08/15/19 0:00	0.7			1.6			1			0.36			0.17928			0.6		
08/15/19 1:00	0.7			1.6			1			0.36			0.17892			0.6		
08/15/19 2:00	0.7			1.6			1			0.36			0.1788			0.6		
08/15/19 3:00	0.7			1.6			1			0.36			0.17856			0.6		
08/15/19 4:00	0.7			1.6			1			0.36			0.17904			0.6		
08/15/19 5:00	0.8			1.7			1			0.36			0.17874			0.6		
08/15/19 6:00	1.1			1.7			1			0.43			0.21468			0.72		
08/15/19 7:00	0.8			1.7			1			0.43			0.21558			0.72		
08/15/19 8:00	0.7			1.7			1			0.45			0.22638			0.75		
08/15/19 9:00	0.8			1.7			1			0.46			0.2304			0.77		
08/15/19 10:00	0.7			1.7			1			0.44			0.22014			0.73		
08/15/19 11:00	0.7			1.7			1			0.43			0.21498			0.72		
08/15/19 12:00	0.7			1.7			1			0.49			0.24498			0.82		
08/15/19 13:00	0.8			1.7			1			0.5			0.25032			0.83		
08/15/19 14:00	0.1			1.7			3			0.74			0.36792			1.23		
08/15/19 15:00	0.1			1.7			3			0.75			0.3726			1.24		
08/15/19 16:00	0.1			1.7			3			0.74			0.37128			1.24		
08/15/19 17:00	0.1			1.7			3			0.74			0.37098			1.24		
08/15/19 18:00	0.1			1.7			3			0.72			0.35964			1.2		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/15/19 19:00	0.3			1.7			2			0.64			0.32184			1.07		
08/15/19 20:00	0.7			1.7			1			0.59			0.2955			0.99		
08/15/19 21:00	1			1.7			1			0.54			0.2703			0.9		
08/15/19 22:00	1.3			1.7			1			0.51			0.25656			0.86		
08/15/19 23:00	0.8			1.7			1			0.36			0.18114			0.6		
08/16/19 0:00	0.7			1.7			1			0.36			0.1791			0.6		
08/16/19 1:00	0.7			1.7			1			0.36			0.1785			0.6		
08/16/19 2:00	0.7			1.7			1			0.36			0.17814			0.59		
08/16/19 3:00	0.7			1.7			1			0.36			0.17796			0.59		
08/16/19 4:00	0.7			1.7			1			0.36			0.17802			0.59		
08/16/19 5:00	1.4			1.7			1			0.36			0.17778			0.59		
08/16/19 6:00	0.8			1.7			1			0.36			0.1809			0.6		
08/16/19 7:00	0.8			1.7			1			0.4			0.1986			0.66		
08/16/19 8:00	0.9			1.7			1			0.4			0.19926			0.66		
08/16/19 9:00	0.8			1.7			1			0.42			0.2097			0.7		
08/16/19 10:00	0.8			1.7			1			0.5			0.25002			0.83		
08/16/19 11:00	0.7			1.7			1			0.47			0.23532			0.78		
08/16/19 12:00	0.5			1.7			1			0.57			0.28542			0.95		
08/16/19 13:00	0.4			1.7			2			0.64			0.32202			1.07		
08/16/19 14:00	0.1			1.7			2			0.7			0.34974			1.17		
08/16/19 15:00	0.1			1.7			3			0.74			0.3702			1.23		
08/16/19 16:00	0.3			1.7			2			0.65			0.3261			1.09		
08/16/19 17:00	0.1			1.7			2			0.69			0.34458			1.15		
08/16/19 18:00	0.3			1.7			2			0.64			0.31944			1.06		
08/16/19 19:00	0.3			1.7			2			0.66			0.32994			1.1		
08/16/19 20:00	0.1			1.7			2			0.69			0.34494			1.15		
08/16/19 21:00	0.5			1.7			1			0.62			0.30978			1.03		
08/16/19 22:00	0.5			1.7			2			0.62			0.31116			1.04		
08/16/19 23:00	0.2			1.7			3			0.74			0.37044			1.23		
08/17/19 0:00	0.2			1.7			2			0.71			0.35598			1.19		
08/17/19 1:00	0.5			1.7			1			0.64			0.31884			1.06		
08/17/19 2:00	0.7			1.8			1			0.49			0.24372			0.81		
08/17/19 3:00	0.7			1.7			1			0.45			0.22572			0.75		
08/17/19 4:00	0.7			1.7			1			0.44			0.22116			0.74		
08/17/19 5:00	0.8			1.7			1			0.44			0.21834			0.73		
08/17/19 6:00	0.8			1.7			1			0.41			0.20682			0.69		
08/17/19 7:00	0.7			1.7			1			0.45			0.22254			0.74		
08/17/19 8:00	0.7			1.7			1			0.45			0.2238			0.75		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/17/19 9:00	0.7			1.7			1			0.45			0.22386			0.75		
08/17/19 10:00	0.7			1.7			1			0.45			0.22536			0.75		
08/17/19 11:00	0.7			1.7			1			0.45			0.22344			0.74		
08/17/19 12:00	0.7			1.7			1			0.39			0.1944			0.65		
08/17/19 13:00	0.7			1.7			1			0.39			0.1926			0.64		
08/17/19 14:00	0.7			1.7			1			0.42			0.20892			0.7		
08/17/19 15:00	0.7			1.7			1			0.42			0.21156			0.71		
08/17/19 16:00	0.9			1.7			1			0.54			0.27174			0.91		
08/17/19 17:00	0.1			1.7			3			0.75			0.37632			1.25		
08/17/19 18:00	0.1			1.7			3			0.75			0.3741			1.25		
08/17/19 19:00	0.4			1.7			2			0.67			0.33336			1.11		
08/17/19 20:00	0.6			1.7			1			0.63			0.31458			1.05		
08/17/19 21:00	0.5			1.7			2			0.63			0.3156			1.05		
08/17/19 22:00	0.8			1.7			1			0.57			0.28302			0.94		
08/17/19 23:00	0			0			0	X		0.21			0.10734			0.36		
08/18/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/18/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/20/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/22/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/23/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/25/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/25/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/25/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/25/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/25/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/25/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/25/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/25/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/25/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/25/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/25/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/25/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/25/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/25/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/25/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/25/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/25/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/25/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/25/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/25/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/25/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/25/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/25/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/25/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/26/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/26/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/26/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/26/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/26/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/26/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/26/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/26/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/26/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/26/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/26/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/26/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/26/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/26/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/26/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/26/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/26/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/26/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/26/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/26/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/26/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/26/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/26/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/26/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/27/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/27/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/27/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/27/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/27/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/27/19 5:00	0			0			0	X		0.19			0.09594			0.32		
08/27/19 6:00	0.8			1.5			2			0.39			0.19656			0.66		
08/27/19 7:00	0.8			1.7			1			0.39			0.19572			0.65		
08/27/19 8:00	0.8			1.7			1			0.39			0.19488			0.65		
08/27/19 9:00	0.9			1.7			1			0.39			0.1953			0.65		
08/27/19 10:00	0.8			1.7			1			0.4			0.19938			0.66		
08/27/19 11:00	0.8			1.7			1			0.4			0.19776			0.66		
08/27/19 12:00	0.8			1.7			1			0.43			0.21702			0.72		
08/27/19 13:00	0.6			1.7			1			0.61			0.30606			1.02		
08/27/19 14:00	0.5			1.7			2			0.63			0.31302			1.04		
08/27/19 15:00	0.1			1.7			3			0.75			0.37392			1.25		
08/27/19 16:00	0.1			1.7			3			0.74			0.37188			1.24		
08/27/19 17:00	0.1			1.7			3			0.73			0.3648			1.22		
08/27/19 18:00	0.1			1.7			3			0.72			0.36246			1.21		
08/27/19 19:00	0.1			1.7			3			0.72			0.3615			1.21		
08/27/19 20:00	0.2			1.7			2			0.71			0.35454			1.18		
08/27/19 21:00	0.9			1.8			1			0.52			0.25908			0.86		
08/27/19 22:00	0.8			1.7			1			0.44			0.21786			0.73		
08/27/19 23:00	0.8			1.7			2			0.39			0.19308			0.64		
08/28/19 0:00	0.8			1.7			1			0.38			0.1905			0.64		
08/28/19 1:00	0.7			1.7			1			0.37			0.18366			0.61		
08/28/19 2:00	0.7			1.7			1			0.36			0.18192			0.61		
08/28/19 3:00	0.7			1.7			1			0.36			0.18066			0.6		
08/28/19 4:00	0.9			1.7			1			0.38			0.19158			0.64		
08/28/19 5:00	0.9			1.7			2			0.39			0.19362			0.65		
08/28/19 6:00	0.9			1.7			1			0.43			0.21276			0.71		
08/28/19 7:00	0.4			1.7			3			0.74			0.37152			1.24		
08/28/19 8:00	0.2			1.7			3			0.75			0.37704			1.26		
08/28/19 9:00	0.2			1.7			3			0.75			0.37716			1.26		
08/28/19 10:00	0.2			1.7			3			0.76			0.3792			1.26		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/28/19 11:00	0.2			1.7			3			0.76			0.38238			1.27		
08/28/19 12:00	0.2			1.7			3			0.76			0.3822			1.27		
08/28/19 13:00	0.1			1.7			3			0.76			0.3783			1.26		
08/28/19 14:00	0.1			1.7			3			0.75			0.3762			1.25		
08/28/19 15:00	0.1			1.7			3			0.75			0.37488			1.25		
08/28/19 16:00	0.1			1.7			3			0.75			0.37506			1.25		
08/28/19 17:00	0.2			1.7			3			0.75			0.3738			1.25		
08/28/19 18:00	0.1			1.7			3			0.74			0.36966			1.23		
08/28/19 19:00	0.3			1.7			2			0.68			0.34014			1.13		
08/28/19 20:00	0.9			1.7			1			0.58			0.29166			0.97		
08/28/19 21:00	0.8			1.7			1			0.44			0.22248			0.74		
08/28/19 22:00	0.8			1.7			1			0.41			0.20298			0.68		
08/28/19 23:00	0.7			1.7			1			0.37			0.18282			0.61		
08/29/19 0:00	0.8			1.7			2			0.38			0.19056			0.64		
08/29/19 1:00	0.7			1.7			1			0.36			0.17958			0.6		
08/29/19 2:00	0.7			1.7			1			0.36			0.17928			0.6		
08/29/19 3:00	0.7			1.7			1			0.36			0.1797			0.6		
08/29/19 4:00	0.8			1.6			1			0.37			0.1851			0.62		
08/29/19 5:00	0.8			1.7			1			0.36			0.1797			0.6		
08/29/19 6:00	0.8			1.7			2			0.37			0.18744			0.62		
08/29/19 7:00	0.8			1.7			2			0.38			0.18864			0.63		
08/29/19 8:00	0.8			1.7			1			0.4			0.20124			0.67		
08/29/19 9:00	0.8			1.7			1			0.45			0.22398			0.75		
08/29/19 10:00	0.7			1.7			1			0.5			0.25158			0.84		
08/29/19 11:00	1			1.7			1			0.59			0.29508			0.98		
08/29/19 12:00	0.5			1.7			1			0.64			0.31962			1.07		
08/29/19 13:00	0.6			1.7			1			0.62			0.312			1.04		
08/29/19 14:00	0.4			1.7			2			0.66			0.32874			1.1		
08/29/19 15:00	0.3			1.7			2			0.66			0.33186			1.11		
08/29/19 16:00	0.3			1.7			2			0.67			0.333			1.11		
08/29/19 17:00	0.3			1.7			2			0.67			0.3339			1.11		
08/29/19 18:00	0.3			1.7			2			0.68			0.33984			1.13		
08/29/19 19:00	0.4			1.7			2			0.65			0.32352			1.08		
08/29/19 20:00	0.8			1.7			1			0.52			0.26118			0.87		
08/29/19 21:00	0.8			1.7			1			0.47			0.23364			0.78		
08/29/19 22:00	0.8			1.7			1			0.39			0.19638			0.65		
08/29/19 23:00	0			0			0	X		0.18			0.08886			0.3		
08/30/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/30/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/31/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/02/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/03/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/04/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/04/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/04/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/04/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/04/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/04/19 5:00	0			0			0	X		0.18			0.08976			0.3		
09/04/19 6:00	3.2			1.7			1			0.53			0.26328			0.88		
09/04/19 7:00	0.9			1.7			1			0.49			0.2439			0.81		
09/04/19 8:00	0.9			1.7			1			0.43			0.21714			0.72		
09/04/19 9:00	0.8			1.7			1			0.46			0.23214			0.77		
09/04/19 10:00	0.8			1.7			1			0.5			0.24756			0.83		
09/04/19 11:00	0.5			1.7			2			0.64			0.32238			1.07		
09/04/19 12:00	0.4			1.7			2			0.66			0.3279			1.09		
09/04/19 13:00	0.3			1.7			2			0.68			0.3399			1.13		
09/04/19 14:00	0.2			1.7			3			0.76			0.37776			1.26		
09/04/19 15:00	0.2			1.7			3			0.76			0.37824			1.26		
09/04/19 16:00	0.2			1.7			3			0.75			0.37434			1.25		
09/04/19 17:00	0.7			1.7			1			0.48			0.2397			0.8		
09/04/19 18:00	0.7			1.7			1			0.47			0.23268			0.78		
09/04/19 19:00	0.7			1.7			1			0.48			0.23898			0.8		
09/04/19 20:00	0.6			1.7			2			0.63			0.31692			1.06		
09/04/19 21:00	0.9			1.8			2			0.4			0.2013			0.67		
09/04/19 22:00	0.8			1.7			1			0.38			0.18756			0.63		
09/04/19 23:00	0.8			1.7			1			0.47			0.23364			0.78		
09/05/19 0:00	0.8			1.7			1			0.43			0.21366			0.71		
09/05/19 1:00	0.9			1.7			1			0.39			0.19698			0.66		
09/05/19 2:00	0.7			1.7			1			0.36			0.1794			0.6		
09/05/19 3:00	0.7			1.7			1			0.36			0.1803			0.6		
09/05/19 4:00	0.8			1.6			1			0.39			0.19254			0.64		
09/05/19 5:00	0.8			1.7			1			0.36			0.18234			0.61		
09/05/19 6:00	0.8			1.7			2			0.38			0.18978			0.63		
09/05/19 7:00	0.9			1.7			1			0.41			0.20496			0.68		
09/05/19 8:00	0.8			1.7			1			0.45			0.22512			0.75		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/05/19 9:00	1.4			1.7			1			0.54			0.27012			0.9		
09/05/19 10:00	1			1.7			1			0.59			0.29394			0.98		
09/05/19 11:00	0.6			1.7			1			0.62			0.31002			1.03		
09/05/19 12:00	0.5			1.7			2			0.65			0.32484			1.08		
09/05/19 13:00	0.2			1.7			3			0.77			0.38262			1.28		
09/05/19 14:00	0.1			1.7			4			0.76			0.38178			1.27		
09/05/19 15:00	0.1			1.7			4			0.76			0.38112			1.27		
09/05/19 16:00	0.3			1.7			2			0.68			0.33828			1.13		
09/05/19 17:00	0.3			1.7			2			0.67			0.33564			1.12		
09/05/19 18:00	0.7			1.7			2			0.6			0.30108			1		
09/05/19 19:00	0.8			1.8			1			0.5			0.24834			0.83		
09/05/19 20:00	0.8			1.7			1			0.46			0.22908			0.76		
09/05/19 21:00	0.7			1.7			1			0.49			0.24276			0.81		
09/05/19 22:00	0.8			1.7			1			0.45			0.22362			0.75		
09/05/19 23:00	0			0			0	X		0.19			0.09504			0.32		
09/06/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/06/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/08/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/10/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/10/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/10/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/10/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/10/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/10/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/10/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/10/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/10/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/10/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/10/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/10/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/10/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/10/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/10/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/10/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/10/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/10/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/10/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/10/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/10/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/10/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/10/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/10/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/11/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/11/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/11/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/11/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/11/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/11/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/11/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/11/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/11/19 8:00	0			0			0	X		0.18			0.08826			0.29		
09/11/19 9:00	0.7			1.6			2			0.38			0.19014			0.63		
09/11/19 10:00	0.8			1.7			1			0.47			0.23616			0.79		
09/11/19 11:00	1.4			1.7			2			0.54			0.27228			0.91		
09/11/19 12:00	0.5			1.7			3			0.68			0.34122			1.14		
09/11/19 13:00	0.8			1.7			1			0.42			0.20934			0.7		
09/11/19 14:00	0.4			1.7			3			0.7			0.34986			1.17		
09/11/19 15:00	0.8			1.7			1			0.41			0.20334			0.68		
09/11/19 16:00	1			1.7			1			0.57			0.28638			0.95		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/11/19 17:00	1.1			1.7			1			0.57			0.285			0.95		
09/11/19 18:00	0.9			1.7			2			0.48			0.24018			0.8		
09/11/19 19:00	0.8			1.7			2			0.4			0.19866			0.66		
09/11/19 20:00	0.7			1.7			2			0.61			0.30696			1.02		
09/11/19 21:00	0.8			1.8			1			0.45			0.22398			0.75		
09/11/19 22:00	0.8			1.7			2			0.45			0.22326			0.74		
09/11/19 23:00	0.9			1.7			2			0.45			0.22314			0.74		
09/12/19 0:00	0.9			1.7			2			0.42			0.21102			0.7		
09/12/19 1:00	0.9			1.7			2			0.38			0.18774			0.63		
09/12/19 2:00	0.8			1.7			2			0.38			0.18768			0.63		
09/12/19 3:00	0.8			1.7			2			0.37			0.18744			0.62		
09/12/19 4:00	0.8			1.7			2			0.37			0.18714			0.62		
09/12/19 5:00	0.9			1.7			2			0.38			0.1887			0.63		
09/12/19 6:00	0.9			1.7			2			0.38			0.1896			0.63		
09/12/19 7:00	0.8			1.7			2			0.4			0.19752			0.66		
09/12/19 8:00	0.5			1.6			2			0.69			0.34302			1.14		
09/12/19 9:00	0.8			1.8			1			0.41			0.20634			0.69		
09/12/19 10:00	1.3			1.7			2			0.54			0.27042			0.9		
09/12/19 11:00	0.8			1.7			2			0.43			0.21462			0.72		
09/12/19 12:00	0			0			0	X		0.13			0.06612			0.22		
09/12/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/12/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/12/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/12/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/12/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/12/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/12/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/12/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/12/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/12/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/12/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/13/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/14/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/16/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/18/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/19/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/21/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/22/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/23/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/23/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/23/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/23/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/23/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/23/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/23/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/23/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/23/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/23/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/23/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/23/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/23/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/23/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/23/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/23/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/23/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/23/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/23/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/23/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/23/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/23/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/23/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/23/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/24/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/24/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/24/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/24/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/24/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/24/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/24/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/24/19 7:00	0			0			0	X		0.01			0.00474			0.02		
09/24/19 8:00	0.8			1.6			3			0.37			0.18516			0.62		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/24/19 9:00	0.8			1.7			1			0.44			0.22062			0.74		
09/24/19 10:00	0.8			1.7			1			0.47			0.23736			0.79		
09/24/19 11:00	0.9			1.7			1			0.46			0.23244			0.77		
09/24/19 12:00	1.3			1.7			2			0.53			0.2625			0.88		
09/24/19 13:00	1			1.7			1			0.58			0.2898			0.97		
09/24/19 14:00	1.1			1.7			1			0.55			0.27366			0.91		
09/24/19 15:00	1			1.7			2			0.57			0.28698			0.96		
09/24/19 16:00	0.2			1.7			3			0.76			0.37974			1.27		
09/24/19 17:00	0.2			1.7			4			0.76			0.3792			1.26		
09/24/19 18:00	0.2			1.7			2			0.69			0.34638			1.15		
09/24/19 19:00	1			1.7			1			0.57			0.28398			0.95		
09/24/19 20:00	0.8			1.7			1			0.47			0.23424			0.78		
09/24/19 21:00	1.3			1.7			2			0.53			0.26664			0.89		
09/24/19 22:00	0.8			1.7			2			0.46			0.23052			0.77		
09/24/19 23:00	0.9			1.7			2			0.37			0.183			0.61		
09/25/19 0:00	0.9			1.7			1			0.36			0.17844			0.59		
09/25/19 1:00	0.8			1.7			2			0.36			0.17826			0.59		
09/25/19 2:00	1.1			1.7			2			0.36			0.1779			0.59		
09/25/19 3:00	1.1			1.7			2			0.36			0.17808			0.59		
09/25/19 4:00	1.3			1.7			1			0.36			0.17838			0.59		
09/25/19 5:00	1.3			1.7			2			0.36			0.17814			0.59		
09/25/19 6:00	1			1.7			2			0.36			0.17886			0.6		
09/25/19 7:00	1			1.7			2			0.36			0.18084			0.6		
09/25/19 8:00	0.8			1.7			2			0.36			0.1788			0.6		
09/25/19 9:00	0.7			1.7			2			0.36			0.1824			0.61		
09/25/19 10:00	0.8			1.7			1			0.42			0.20754			0.69		
09/25/19 11:00	0.8			1.7			1			0.49			0.24522			0.82		
09/25/19 12:00	0.3			1.7			2			0.71			0.35478			1.18		
09/25/19 13:00	0.2			1.7			3			0.75			0.3735			1.25		
09/25/19 14:00	0.2			1.7			3			0.71			0.354			1.18		
09/25/19 15:00	0.2			1.7			3			0.7			0.35238			1.17		
09/25/19 16:00	0.2			1.7			3			0.73			0.36528			1.22		
09/25/19 17:00	0.2			1.7			3			0.73			0.3639			1.21		
09/25/19 18:00	0.7			1.8			1			0.51			0.2544			0.85		
09/25/19 19:00	0.4			1.7			2			0.66			0.33168			1.11		
09/25/19 20:00	0.4			1.7			2			0.65			0.32682			1.09		
09/25/19 21:00	0.9			1.8			1			0.44			0.22134			0.74		
09/25/19 22:00	0.8			1.7			2			0.38			0.19068			0.64		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/25/19 23:00	0.8			1.7			1			0.36			0.17772			0.59		
09/26/19 0:00	0.8			1.7			1			0.36			0.1779			0.59		
09/26/19 1:00	0.9			1.7			1			0.36			0.17838			0.59		
09/26/19 2:00	0.8			1.7			2			0.36			0.17808			0.59		
09/26/19 3:00	0.8			1.7			2			0.36			0.17844			0.59		
09/26/19 4:00	0.8			1.6			1			0.36			0.17874			0.6		
09/26/19 5:00	0.9			1.7			1			0.36			0.17922			0.6		
09/26/19 6:00	0.8			1.7			2			0.36			0.17904			0.6		
09/26/19 7:00	0.8			1.7			2			0.36			0.18114			0.6		
09/26/19 8:00	0.9			1.7			2			0.37			0.18684			0.62		
09/26/19 9:00	0.9			1.7			1			0.44			0.22044			0.73		
09/26/19 10:00	1.3			1.7			2			0.55			0.27696			0.92		
09/26/19 11:00	0.9			1.7			1			0.6			0.29838			0.99		
09/26/19 12:00	0.6			1.7			1			0.62			0.30948			1.03		
09/26/19 13:00	0.5			1.7			1			0.62			0.30996			1.03		
09/26/19 14:00	0.3			1.7			3			0.72			0.36132			1.2		
09/26/19 15:00	0.3			1.7			2			0.7			0.34878			1.16		
09/26/19 16:00	0.2			1.7			3			0.74			0.3681			1.23		
09/26/19 17:00	0.4			1.7			2			0.65			0.3267			1.09		
09/26/19 18:00	0.7			1.7			2			0.6			0.29838			0.99		
09/26/19 19:00	0.8			1.7			1			0.51			0.25734			0.86		
09/26/19 20:00	0.9			1.7			2			0.43			0.2127			0.71		
09/26/19 21:00	0.9			1.7			2			0.38			0.1917			0.64		
09/26/19 22:00	0.7			1.7			1			0.35			0.17388			0.58		
09/26/19 23:00	0			0			0	X		0.13			0.06666			0.22		
09/27/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/27/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/29/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/30/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/30/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/30/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/30/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/30/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/30/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/30/19 6:00	0			0			0	X		0.18			0.09054			0.3		
09/30/19 7:00	0.8			1.7			2			0.52			0.258			0.86		
09/30/19 8:00	0.8			1.7			2			0.52			0.26004			0.87		
09/30/19 9:00	0.8			1.7			2			0.54			0.26826			0.89		
09/30/19 10:00	0.8			1.7			2			0.53			0.26646			0.89		
09/30/19 11:00	0.8			1.7			2			0.42			0.21108			0.7		
09/30/19 12:00	0			0			0	X		0.14			0.06834			0.23		
09/30/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/30/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/30/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/30/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/30/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/30/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/30/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/30/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/30/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/30/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/30/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	

AQ57 CT2 HOURLY EMISSIONS

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/01/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/02/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/04/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/05/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/07/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/08/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/10/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/11/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/13/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/14/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/15/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/15/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/16/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/16/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/17/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/18/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/18/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/19/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/19/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/20/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/21/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/19 12:00	0			0	X		0			0	X		0.02208			0.07		
07/22/19 13:00	0.7			2			1.3			0	X		0.1872			0.62		
07/22/19 14:00	0.8			1			1.6			0	X		0.27366			0.91		
07/22/19 15:00	0.8			0			1.7			0	X		0.24276			0.81		
07/22/19 16:00	0.8			0			1.7			0	X		0.2265			0.76		
07/22/19 17:00	0.8			1			1.7			0	X		0.22632			0.75		
07/22/19 18:00	0.8			1			1.7			0	X		0.23064			0.77		
07/22/19 19:00	0.8			1			1.7			0	X		0.22224			0.74		
07/22/19 20:00	0.9			1			1.7			0	X		0.22134			0.74		
07/22/19 21:00	0.9			1			1.7			0	X		0.21744			0.72		
07/22/19 22:00	0.9			1			1.7			0	X		0.22038			0.73		
07/22/19 23:00	0.9			1			1.7			0	X		0.2208			0.74		
07/23/19 0:00	0.9			1			1.7			0	X		0.22086			0.74		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/23/19 1:00	0.9			1			1.7			0	X		0.22098			0.74		
07/23/19 2:00	0.9			1			1.7			0	X		0.2211			0.74		
07/23/19 3:00	0.9			1			1.7			0	X		0.22128			0.74		
07/23/19 4:00	0.9			1			1.7			0	X		0.2214			0.74		
07/23/19 5:00	0.9			1			1.7			0.18			0.2214			0.74		
07/23/19 6:00	0.9			1			1.7			0.42			0.22662			0.76		
07/23/19 7:00	0.8			1			1.7			0.45			0.23856			0.8		
07/23/19 8:00	0.8			1			1.7			0.47			0.25254			0.84		
07/23/19 9:00	0.8			1			1.6			0.52			0.27936			0.93		
07/23/19 10:00	0.7			0			1.7			0.52			0.276			0.92		
07/23/19 11:00	0.8			1			1.7			0.67			0.26724			0.89		
07/23/19 12:00	0			0	X		0			0.76			0.09648			0.32		
07/23/19 13:00	0	X		0	X		0	X		0.76			0	X		0	X	
07/23/19 14:00	0	X		0	X		0	X		0.76			0	X		0	X	
07/23/19 15:00	0	X		0	X		0	X		0.76			0	X		0	X	
07/23/19 16:00	0	X		0	X		0	X		0.76			0	X		0	X	
07/23/19 17:00	0	X		0	X		0	X		0.76			0	X		0	X	
07/23/19 18:00	0	X		0	X		0	X		0.76			0	X		0	X	
07/23/19 19:00	0	X		0	X		0	X		0.76			0	X		0	X	
07/23/19 20:00	0	X		0	X		0	X		0.76			0	X		0	X	
07/23/19 21:00	0	X		0	X		0	X		0.77			0	X		0	X	
07/23/19 22:00	0	X		0	X		0	X		0.77			0	X		0	X	
07/23/19 23:00	0	X		0	X		0	X		0.77			0	X		0	X	
07/24/19 0:00	0	X		0	X		0	X		0.77			0	X		0	X	
07/24/19 1:00	0	X		0	X		0	X		0.77			0	X		0	X	
07/24/19 2:00	0	X		0	X		0	X		0.76			0	X		0	X	
07/24/19 3:00	0	X		0	X		0	X		0.76			0	X		0	X	
07/24/19 4:00	0	X		0	X		0	X		0.76			0	X		0	X	
07/24/19 5:00	0	X		0	X		0	X		0.76			0	X		0	X	
07/24/19 6:00	0	X		0	X		0	X		0.76			0	X		0	X	
07/24/19 7:00	0	X		0	X		0	X		0.76			0	X		0	X	
07/24/19 8:00	0	X		0	X		0	X		0.76			0	X		0	X	
07/24/19 9:00	0	X		0	X		0	X		0.76			0	X		0	X	
07/24/19 10:00	0	X		0	X		0	X		0.76			0	X		0	X	
07/24/19 11:00	0	X		0	X		0	X		0.76			0	X		0	X	
07/24/19 12:00	0	X		0	X		0	X		0.76			0	X		0	X	
07/24/19 13:00	0	X		0	X		0	X		0.76			0	X		0	X	
07/24/19 14:00	0	X		0	X		0	X		0.76			0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/24/19 15:00	0	X		0	X		0	X		0.76			0	X		0	X	
07/24/19 16:00	0	X		0	X		0	X		0.76			0	X		0	X	
07/24/19 17:00	0	X		0	X		0	X		0.76			0	X		0	X	
07/24/19 18:00	0	X		0	X		0	X		0.76			0	X		0	X	
07/24/19 19:00	0	X		0	X		0	X		0.75			0	X		0	X	
07/24/19 20:00	0	X		0	X		0	X		0.75			0	X		0	X	
07/24/19 21:00	0	X		0	X		0	X		0.76			0	X		0	X	
07/24/19 22:00	0	X		0	X		0	X		0.74			0	X		0	X	
07/24/19 23:00	0	X		0	X		0	X		0.52			0	X		0	X	
07/25/19 0:00	0	X		0	X		0	X		0.55			0	X		0	X	
07/25/19 1:00	0	X		0	X		0	X		0.54			0	X		0	X	
07/25/19 2:00	0	X		0	X		0	X		0.52			0	X		0	X	
07/25/19 3:00	0	X		0	X		0	X		0.5			0	X		0	X	
07/25/19 4:00	0	X		0	X		0	X		0.51			0	X		0	X	
07/25/19 5:00	0	X		0	X		0	X		0.51			0	X		0	X	
07/25/19 6:00	0	X		0	X		0	X		0.51			0	X		0	X	
07/25/19 7:00	0	X		0	X		0	X		0.53			0	X		0	X	
07/25/19 8:00	0	X		0	X		0	X		0.76			0	X		0	X	
07/25/19 9:00	0	X		0	X		0	X		0.76			0	X		0	X	
07/25/19 10:00	0	X		0	X		0	X		0.76			0	X		0	X	
07/25/19 11:00	0	X		0	X		0	X		0.76			0	X		0	X	
07/25/19 12:00	0	X		0	X		0	X		0.76			0	X		0	X	
07/25/19 13:00	0	X		0	X		0	X		0.76			0	X		0	X	
07/25/19 14:00	0	X		0	X		0	X		0.76			0	X		0	X	
07/25/19 15:00	0	X		0	X		0	X		0.75			0	X		0	X	
07/25/19 16:00	0	X		0	X		0	X		0.67			0	X		0	X	
07/25/19 17:00	0	X		0	X		0	X		0.65			0	X		0	X	
07/25/19 18:00	0	X		0	X		0	X		0.59			0	X		0	X	
07/25/19 19:00	0	X		0	X		0	X		0.64			0	X		0	X	
07/25/19 20:00	0	X		0	X		0	X		0.71			0	X		0	X	
07/25/19 21:00	0	X		0	X		0	X		0.67			0	X		0	X	
07/25/19 22:00	0	X		0	X		0	X		0.53			0	X		0	X	
07/25/19 23:00	0	X		0	X		0	X		0.53			0	X		0	X	
07/26/19 0:00	0	X		0	X		0	X		0.6			0	X		0	X	
07/26/19 1:00	0	X		0	X		0	X		0.51			0	X		0	X	
07/26/19 2:00	0	X		0	X		0	X		0.52			0	X		0	X	
07/26/19 3:00	0	X		0	X		0	X		0.52			0	X		0	X	
07/26/19 4:00	0	X		0	X		0	X		0.52			0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/26/19 5:00	0	X		0	X		0	X		0.49			0	X		0	X	
07/26/19 6:00	0	X		0	X		0	X		0.57			0	X		0	X	
07/26/19 7:00	0	X		0	X		0	X		0.58			0	X		0	X	
07/26/19 8:00	0	X		0	X		0	X		0.58			0	X		0	X	
07/26/19 9:00	0	X		0	X		0	X		0.59			0	X		0	X	
07/26/19 10:00	0	X		0	X		0	X		0.65			0	X		0	X	
07/26/19 11:00	0	X		0	X		0	X		0.76			0	X		0	X	
07/26/19 12:00	0	X		0	X		0	X		0.76			0	X		0	X	
07/26/19 13:00	0	X		0	X		0	X		0.71			0	X		0	X	
07/26/19 14:00	0	X		0	X		0	X		0.7			0	X		0	X	
07/26/19 15:00	0	X		0	X		0	X		0.76			0	X		0	X	
07/26/19 16:00	0	X		0	X		0	X		0.76			0	X		0	X	
07/26/19 17:00	0	X		0	X		0	X		0.76			0	X		0	X	
07/26/19 18:00	0	X		0	X		0	X		0.74			0	X		0	X	
07/26/19 19:00	0	X		0	X		0	X		0.7			0	X		0	X	
07/26/19 20:00	0	X		0	X		0	X		0.73			0	X		0	X	
07/26/19 21:00	0	X		0	X		0	X		0.75			0	X		0	X	
07/26/19 22:00	0	X		0	X		0	X		0.64			0	X		0	X	
07/26/19 23:00	0	X		0	X		0	X		0.62			0	X		0	X	
07/27/19 0:00	0	X		0	X		0	X		0.58			0	X		0	X	
07/27/19 1:00	0	X		0	X		0	X		0.57			0	X		0	X	
07/27/19 2:00	0	X		0	X		0	X		0.48			0	X		0	X	
07/27/19 3:00	0	X		0	X		0	X		0.43			0	X		0	X	
07/27/19 4:00	0	X		0	X		0	X		0.43			0	X		0	X	
07/27/19 5:00	0	X		0	X		0	X		0.41			0	X		0	X	
07/27/19 6:00	0	X		0	X		0	X		0.41			0	X		0	X	
07/27/19 7:00	0	X		0	X		0	X		0.48			0	X		0	X	
07/27/19 8:00	0	X		0	X		0	X		0.48			0	X		0	X	
07/27/19 9:00	0	X		0	X		0	X		0.45			0	X		0	X	
07/27/19 10:00	0	X		0	X		0	X		0.49			0	X		0	X	
07/27/19 11:00	0	X		0	X		0	X		0.52			0	X		0	X	
07/27/19 12:00	0	X		0	X		0	X		0.52			0	X		0	X	
07/27/19 13:00	0	X		0	X		0	X		0.51			0	X		0	X	
07/27/19 14:00	0	X		0	X		0	X		0.51			0	X		0	X	
07/27/19 15:00	0	X		0	X		0	X		0.49			0	X		0	X	
07/27/19 16:00	0	X		0	X		0	X		0.73			0	X		0	X	
07/27/19 17:00	0	X		0	X		0	X		0.74			0	X		0	X	
07/27/19 18:00	0	X		0	X		0	X		0.74			0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/27/19 19:00	0	X		0	X		0	X		0.73			0	X		0	X	
07/27/19 20:00	0	X		0	X		0	X		0.74			0	X		0	X	
07/27/19 21:00	0	X		0	X		0	X		0.74			0	X		0	X	
07/27/19 22:00	0			0	X		0			0.68			0.1011			0.34		
07/27/19 23:00	1			0			1.3			0.46			0.228			0.76		
07/28/19 0:00	1			1			1.7			0.43			0.23256			0.78		
07/28/19 1:00	1			1			1.6			0.4			0.21546			0.72		
07/28/19 2:00	0.9			1			1.6			0.38			0.20208			0.67		
07/28/19 3:00	1			1			1.7			0.38			0.2061			0.69		
07/28/19 4:00	1			1			1.7			0.39			0.2085			0.7		
07/28/19 5:00	1.1			1			1.7			0.39			0.21048			0.7		
07/28/19 6:00	1.1			1			1.7			0.39			0.21198			0.71		
07/28/19 7:00	1.1			1			1.7			0.42			0.22566			0.75		
07/28/19 8:00	1			1			1.7			0.42			0.22626			0.75		
07/28/19 9:00	0.9			1			1.7			0.43			0.23202			0.77		
07/28/19 10:00	1.7			1			1.7			0.51			0.27438			0.91		
07/28/19 11:00	1.8			1			1.7			0.51			0.27396			0.91		
07/28/19 12:00	0.5			2			1.7			0.67			0.35304			1.18		
07/28/19 13:00	0.3			3			1.7			0.73			0.3846			1.28		
07/28/19 14:00	0.3			3			1.7			0.75			0.39204			1.31		
07/28/19 15:00	0.3			3			1.7			0.74			0.39126			1.3		
07/28/19 16:00	0.3			3			1.7			0.74			0.39096			1.3		
07/28/19 17:00	0.3			3			1.7			0.74			0.38904			1.3		
07/28/19 18:00	0.3			3			1.7			0.74			0.38682			1.29		
07/28/19 19:00	0.6			2			1.7			0.62			0.33246			1.11		
07/28/19 20:00	0.3			3			1.7			0.74			0.38772			1.29		
07/28/19 21:00	0.3			3			1.7			0.72			0.37968			1.27		
07/28/19 22:00	0.6			2			1.7			0.62			0.33444			1.11		
07/28/19 23:00	1			1			1.7			0.52			0.28038			0.93		
07/29/19 0:00	0.9			1			1.7			0.49			0.26622			0.89		
07/29/19 1:00	0.9			1			1.7			0.49			0.26322			0.88		
07/29/19 2:00	0.9			1			1.7			0.48			0.25824			0.86		
07/29/19 3:00	0.9			1			1.7			0.47			0.25608			0.85		
07/29/19 4:00	0.9			1			1.7			0.47			0.25308			0.84		
07/29/19 5:00	0.9			1			1.7			0.51			0.27654			0.92		
07/29/19 6:00	0.9			1			1.7			0.61			0.32748			1.09		
07/29/19 7:00	0.6			2			1.7			0.65			0.345			1.15		
07/29/19 8:00	0.9			1			1.7			0.5			0.26916			0.9		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/29/19 9:00	0.9			1			1.7			0.49			0.26532			0.88		
07/29/19 10:00	0.7			2			1.7			0.63			0.336			1.12		
07/29/19 11:00	0.4			2			1.7			0.69			0.36186			1.21		
07/29/19 12:00	1.6			1			1.8			0.52			0.2787			0.93		
07/29/19 13:00	0.5			3			1.7			0.72			0.3786			1.26		
07/29/19 14:00	0.3			3			1.7			0.76			0.3969			1.32		
07/29/19 15:00	0.3			3			1.7			0.75			0.39594			1.32		
07/29/19 16:00	0.3			3			1.7			0.73			0.38418			1.28		
07/29/19 17:00	0.3			3			1.7			0.73			0.38358			1.28		
07/29/19 18:00	0.3			3			1.7			0.72			0.37974			1.27		
07/29/19 19:00	0.6			2			1.7			0.64			0.3363			1.12		
07/29/19 20:00	0.3			2			1.7			0.71			0.3732			1.24		
07/29/19 21:00	0.4			2			1.7			0.66			0.3519			1.17		
07/29/19 22:00	1			1			1.7			0.52			0.27912			0.93		
07/29/19 23:00	0.9			1			1.7			0.38			0.20298			0.68		
07/30/19 0:00	0.8			1			1.7			0.36			0.19758			0.66		
07/30/19 1:00	0.9			1			1.7			0.36			0.1998			0.67		
07/30/19 2:00	0.8			1			1.7			0.36			0.1995			0.67		
07/30/19 3:00	0.9			1			1.7			0.36			0.1995			0.67		
07/30/19 4:00	0.9			1			1.7			0.36			0.1998			0.67		
07/30/19 5:00	1			1			1.7			0.41			0.23112			0.77		
07/30/19 6:00	0.9			1			1.7			0.42			0.24102			0.8		
07/30/19 7:00	0.9			1			1.7			0.46			0.26202			0.87		
07/30/19 8:00	0.9			1			1.7			0.45			0.26544			0.88		
07/30/19 9:00	0.9			1			1.7			0.44			0.25884			0.86		
07/30/19 10:00	0.9			1			1.7			0.43			0.26076			0.87		
07/30/19 11:00	0.9			1			1.7			0.41			0.25284			0.84		
07/30/19 12:00	0.9			1			1.7			0.4			0.24888			0.83		
07/30/19 13:00	0.9			1			1.7			0.38			0.20232			0.67		
07/30/19 14:00	0.9			1			1.7			0.38			0.2094			0.7		
07/30/19 15:00	1			1			1.7			0.38			0.2145			0.72		
07/30/19 16:00	1			1			1.7			0.51			0.27552			0.92		
07/30/19 17:00	1.2			1			1.7			0.52			0.27984			0.93		
07/30/19 18:00	0.9			1			1.7			0.46			0.24618			0.82		
07/30/19 19:00	0.9			1			1.7			0.42			0.23292			0.78		
07/30/19 20:00	0.9			1			1.7			0.44			0.24468			0.82		
07/30/19 21:00	0.9			1			1.7			0.42			0.23628			0.79		
07/30/19 22:00	0.9			1			1.7			0.44			0.24156			0.81		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
07/30/19 23:00	1			1			1.7			0.39			0.21312			0.71		
07/31/19 0:00	0.9			1			1.7			0.38			0.204			0.68		
07/31/19 1:00	0.8			1			1.7			0.37			0.19716			0.66		
07/31/19 2:00	0.8			1			1.7			0.36			0.19698			0.66		
07/31/19 3:00	0.9			1			1.7			0.37			0.19758			0.66		
07/31/19 4:00	0.8			1			1.7			0.36			0.1968			0.66		
07/31/19 5:00	0.8			1			1.7			0.36			0.19446			0.65		
07/31/19 6:00	0.8			1			1.7			0.37			0.19734			0.66		
07/31/19 7:00	0.9			1			1.7			0.38			0.20826			0.69		
07/31/19 8:00	1			1			1.7			0.39			0.2172			0.72		
07/31/19 9:00	0.9			1			1.7			0.37			0.20556			0.69		
07/31/19 10:00	0.8			1			1.7			0.36			0.19458			0.65		
07/31/19 11:00	0.8			1			1.7			0.36			0.1944			0.65		
07/31/19 12:00	0.9			1			1.7			0.43			0.23508			0.78		
07/31/19 13:00	0.9			1			1.7			0.48			0.25788			0.86		
07/31/19 14:00	0.6			2			1.6			0.69			0.36522			1.22		
07/31/19 15:00	0.4			2			1.7			0.67			0.35724			1.19		
07/31/19 16:00	0.4			2			1.7			0.66			0.35064			1.17		
07/31/19 17:00	0.4			2			1.7			0.65			0.34716			1.16		
07/31/19 18:00	0.4			2			1.7			0.65			0.34758			1.16		
07/31/19 19:00	0.4			2			1.7			0.66			0.35274			1.18		
07/31/19 20:00	0.9			1			1.7			0.49			0.26322			0.88		
07/31/19 21:00	0.9			1			1.7			0.46			0.24882			0.83		
07/31/19 22:00	0.8			1			1.7			0.38			0.20526			0.68		
07/31/19 23:00	0.8			1			1.7			0.37			0.19914			0.66		
08/01/19 0:00	0.8			1			1.7			0.36			0.19878			0.66		
08/01/19 1:00	0.8			1			1.7			0.36			0.19926			0.66		
08/01/19 2:00	0.8			1			1.7			0.36			0.20052			0.67		
08/01/19 3:00	0.8			1			1.7			0.36			0.20118			0.67		
08/01/19 4:00	0.8			1			1.7			0.36			0.2025			0.68		
08/01/19 5:00	0.9			1			1.7			0.36			0.20442			0.68		
08/01/19 6:00	0.9			1			1.7			0.36			0.2058			0.69		
08/01/19 7:00	0.9			1			1.7			0.37			0.21096			0.7		
08/01/19 8:00	0.9			1			1.7			0.37			0.21054			0.7		
08/01/19 9:00	0.9			1			1.7			0.38			0.21756			0.73		
08/01/19 10:00	0.9			1			1.6			0.36			0.21324			0.71		
08/01/19 11:00	0.9			1			1.7			0.37			0.21636			0.72		
08/01/19 12:00	0.8			1			1.7			0.5			0.27384			0.91		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/01/19 13:00	0.8			1			1.7			0.52			0.27858			0.93		
08/01/19 14:00	0.8			1			1.7			0.52			0.27762			0.93		
08/01/19 15:00	1			1			1.7			0.51			0.27744			0.92		
08/01/19 16:00	1.1			1			1.7			0.58			0.30426			1.01		
08/01/19 17:00	0.9			1			1.7			0.59			0.31212			1.04		
08/01/19 18:00	0.5			2			1.7			0.67			0.35376			1.18		
08/01/19 19:00	0.9			1			1.7			0.52			0.27906			0.93		
08/01/19 20:00	0.8			0			1.7			0.38			0.20322			0.68		
08/01/19 21:00	0.8			1			1.7			0.37			0.19692			0.66		
08/01/19 22:00	0.8			1			1.7			0.37			0.19764			0.66		
08/01/19 23:00	0.8			1			1.7			0.36			0.19662			0.66		
08/02/19 0:00	0.7			1			1.7			0.36			0.19638			0.65		
08/02/19 1:00	0.8			1			1.7			0.36			0.1968			0.66		
08/02/19 2:00	0.8			1			1.7			0.36			0.19752			0.66		
08/02/19 3:00	0.8			1			1.7			0.36			0.19764			0.66		
08/02/19 4:00	0.8			1			1.7			0.36			0.19836			0.66		
08/02/19 5:00	0.8			1			1.7			0.36			0.19878			0.66		
08/02/19 6:00	0.8			1			1.7			0.36			0.1983			0.66		
08/02/19 7:00	0.8			1			1.7			0.36			0.19824			0.66		
08/02/19 8:00	0.8			1			1.7			0.36			0.1986			0.66		
08/02/19 9:00	0.8			1			1.7			0.36			0.19878			0.66		
08/02/19 10:00	0.8			1			1.7			0.36			0.19806			0.66		
08/02/19 11:00	0.8			1			1.7			0.36			0.19872			0.66		
08/02/19 12:00	0.9			0			1.7			0.4			0.2199			0.73		
08/02/19 13:00	1.2			1			1.7			0.53			0.2826			0.94		
08/02/19 14:00	1.2			1			1.7			0.55			0.29316			0.98		
08/02/19 15:00	0.4			2			1.7			0.71			0.37308			1.24		
08/02/19 16:00	0.3			2			1.7			0.71			0.37644			1.25		
08/02/19 17:00	0.3			3			1.7			0.72			0.38052			1.27		
08/02/19 18:00	0.5			1			1.7			0.63			0.33432			1.11		
08/02/19 19:00	1.1			1			1.7			0.54			0.2895			0.97		
08/02/19 20:00	0.9			0			1.7			0.43			0.2298			0.77		
08/02/19 21:00	0.9			1			1.7			0.38			0.20202			0.67		
08/02/19 22:00	0.9			1			1.7			0.37			0.2016			0.67		
08/02/19 23:00	0.9			1			1.7			0.37			0.20466			0.68		
08/03/19 0:00	0.9			1			1.7			0.37			0.2052			0.68		
08/03/19 1:00	0.8			1			1.7			0.36			0.19578			0.65		
08/03/19 2:00	0.8			1			1.7			0.36			0.19536			0.65		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/03/19 3:00	0.8			1			1.7			0.36			0.19542			0.65		
08/03/19 4:00	0.8			1			1.7			0.36			0.19524			0.65		
08/03/19 5:00	0.8			1			1.7			0.36			0.19512			0.65		
08/03/19 6:00	0.8			1			1.7			0.36			0.19518			0.65		
08/03/19 7:00	0.9			1			1.7			0.37			0.2025			0.68		
08/03/19 8:00	0.9			1			1.7			0.37			0.20274			0.68		
08/03/19 9:00	0.9			1			1.7			0.37			0.20424			0.68		
08/03/19 10:00	0.9			1			1.7			0.38			0.21024			0.7		
08/03/19 11:00	0.9			0			1.7			0.39			0.21642			0.72		
08/03/19 12:00	0.9			0			1.7			0.41			0.22902			0.76		
08/03/19 13:00	1.3			1			1.7			0.56			0.29724			0.99		
08/03/19 14:00	0.8			1			1.7			0.61			0.32196			1.07		
08/03/19 15:00	0.3			3			1.7			0.75			0.39378			1.31		
08/03/19 16:00	0.3			3			1.7			0.74			0.39186			1.31		
08/03/19 17:00	0.3			3			1.7			0.72			0.37944			1.26		
08/03/19 18:00	0.3			3			1.7			0.74			0.38868			1.3		
08/03/19 19:00	0.4			2			1.7			0.68			0.36072			1.2		
08/03/19 20:00	1			1			1.7			0.57			0.30336			1.01		
08/03/19 21:00	0.9			1			1.7			0.46			0.24804			0.83		
08/03/19 22:00	0.9			0			1.7			0.42			0.22494			0.75		
08/03/19 23:00	0.9			1			1.7			0.38			0.20406			0.68		
08/04/19 0:00	0.9			1			1.7			0.37			0.2016			0.67		
08/04/19 1:00	0.8			1			1.7			0.37			0.20238			0.67		
08/04/19 2:00	0.9			1			1.7			0.37			0.20316			0.68		
08/04/19 3:00	0.9			1			1.7			0.37			0.20418			0.68		
08/04/19 4:00	0.8			1			1.7			0.36			0.20274			0.68		
08/04/19 5:00	0.9			1			1.7			0.36			0.2067			0.69		
08/04/19 6:00	0.8			1			1.7			0.36			0.19848			0.66		
08/04/19 7:00	0.8			1			1.7			0.36			0.1998			0.67		
08/04/19 8:00	0.9			1			1.7			0.36			0.20316			0.68		
08/04/19 9:00	0.9			1			1.7			0.36			0.20376			0.68		
08/04/19 10:00	0.8			1			1.7			0.37			0.20466			0.68		
08/04/19 11:00	0.9			0			1.7			0.4			0.21936			0.73		
08/04/19 12:00	0.8			1			1.7			0.53			0.28482			0.95		
08/04/19 13:00	0.4			2			1.7			0.69			0.36366			1.21		
08/04/19 14:00	0.4			2			1.7			0.68			0.35826			1.19		
08/04/19 15:00	0.3			2			1.7			0.7			0.36732			1.22		
08/04/19 16:00	0.4			2			1.7			0.66			0.34938			1.16		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/04/19 17:00	0.4			2			1.7			0.69			0.3627			1.21		
08/04/19 18:00	0.3			3			1.7			0.74			0.3885			1.3		
08/04/19 19:00	0.3			3			1.7			0.74			0.39102			1.3		
08/04/19 20:00	0.4			2			1.7			0.69			0.36468			1.22		
08/04/19 21:00	1			1			1.7			0.58			0.31104			1.04		
08/04/19 22:00	0.9			1			1.7			0.51			0.27984			0.93		
08/04/19 23:00	0.9			1			1.7			0.38			0.20718			0.69		
08/05/19 0:00	0.8			1			1.7			0.36			0.19212			0.64		
08/05/19 1:00	0.7			1			1.7			0.36			0.19236			0.64		
08/05/19 2:00	0.8			1			1.7			0.36			0.19248			0.64		
08/05/19 3:00	0.8			1			1.7			0.36			0.19254			0.64		
08/05/19 4:00	0.8			1			1.7			0.36			0.19254			0.64		
08/05/19 5:00	0.8			1			1.7			0.36			0.1926			0.64		
08/05/19 6:00	0.9			1			1.7			0.37			0.2016			0.67		
08/05/19 7:00	0.9			1			1.7			0.37			0.20268			0.68		
08/05/19 8:00	0.9			1			1.7			0.37			0.20376			0.68		
08/05/19 9:00	0.9			1			1.7			0.37			0.20724			0.69		
08/05/19 10:00	0.9			1			1.7			0.37			0.2088			0.7		
08/05/19 11:00	1			1			1.7			0.38			0.21642			0.72		
08/05/19 12:00	0.9			1			1.7			0.46			0.25878			0.86		
08/05/19 13:00	0	X		0	X		0	X		0.51			0.27354			0.91		
08/05/19 14:00	0	X		0	X		0	X		0.5			0.27294			0.91		
08/05/19 15:00	0.4			2			1.5			0.7			0.36672			1.22		
08/05/19 16:00	0.3			2			1.7			0.7			0.37128			1.24		
08/05/19 17:00	0.3			3			1.7			0.75			0.39552			1.32		
08/05/19 18:00	0.3			3			1.7			0.75			0.39582			1.32		
08/05/19 19:00	0.4			2			1.7			0.68			0.36228			1.21		
08/05/19 20:00	1			1			1.7			0.52			0.28254			0.94		
08/05/19 21:00	0.9			1			1.7			0.48			0.2601			0.87		
08/05/19 22:00	1			1			1.7			0.39			0.21264			0.71		
08/05/19 23:00	0.9			1			1.7			0.36			0.19368			0.65		
08/06/19 0:00	0.8			1			1.7			0.36			0.19104			0.64		
08/06/19 1:00	0.8			1			1.7			0.36			0.19104			0.64		
08/06/19 2:00	0.8			1			1.7			0.36			0.19134			0.64		
08/06/19 3:00	0.9			1			1.7			0.36			0.1944			0.65		
08/06/19 4:00	0.8			1			1.7			0.37			0.1971			0.66		
08/06/19 5:00	1			1			1.7			0.39			0.20994			0.7		
08/06/19 6:00	1			1			1.7			0.39			0.21042			0.7		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/06/19 7:00	1			1			1.7			0.39			0.21072			0.7		
08/06/19 8:00	1			1			1.7			0.39			0.21138			0.7		
08/06/19 9:00	0.9			1			1.7			0.36			0.19914			0.66		
08/06/19 10:00	0.9			1			1.7			0.4			0.22272			0.74		
08/06/19 11:00	0.9			1			1.7			0.48			0.25716			0.86		
08/06/19 12:00	0.8			1			1.7			0.5			0.2709			0.9		
08/06/19 13:00	1.6			1			1.7			0.54			0.29304			0.98		
08/06/19 14:00	0.3			3			1.7			0.75			0.39252			1.31		
08/06/19 15:00	0.3			3			1.7			0.73			0.38328			1.28		
08/06/19 16:00	0.3			3			1.7			0.73			0.38484			1.28		
08/06/19 17:00	0.3			3			1.7			0.75			0.39426			1.31		
08/06/19 18:00	0.3			3			1.7			0.71			0.3756			1.25		
08/06/19 19:00	0.9			1			1.7			0.59			0.31758			1.06		
08/06/19 20:00	0.8			1			1.7			0.6			0.32382			1.08		
08/06/19 21:00	0.9			1			1.7			0.51			0.27768			0.93		
08/06/19 22:00	1			1			1.7			0.41			0.22068			0.74		
08/06/19 23:00	0.8			1			1.7			0.36			0.1947			0.65		
08/07/19 0:00	0.8			1			1.7			0.36			0.19134			0.64		
08/07/19 1:00	0.8			1			1.7			0.36			0.1914			0.64		
08/07/19 2:00	0.8			1			1.7			0.36			0.1923			0.64		
08/07/19 3:00	0.8			1			1.7			0.36			0.1929			0.64		
08/07/19 4:00	0.8			1			1.7			0.36			0.19476			0.65		
08/07/19 5:00	0.8			1			1.7			0.36			0.19476			0.65		
08/07/19 6:00	0.9			1			1.7			0.37			0.20208			0.67		
08/07/19 7:00	1			1			1.7			0.37			0.20298			0.68		
08/07/19 8:00	1			1			1.7			0.38			0.213			0.71		
08/07/19 9:00	1			1			1.7			0.39			0.21708			0.72		
08/07/19 10:00	1			1			1.7			0.39			0.21822			0.73		
08/07/19 11:00	1			1			1.7			0.41			0.21738			0.72		
08/07/19 12:00	0.9			1			1.7			0.47			0.25482			0.85		
08/07/19 13:00	1.8			1			1.7			0.55			0.29118			0.97		
08/07/19 14:00	0.5			1			1.7			0.66			0.34884			1.16		
08/07/19 15:00	0.4			2			1.7			0.7			0.36708			1.22		
08/07/19 16:00	0.3			2			1.7			0.72			0.37758			1.26		
08/07/19 17:00	0.3			3			1.7			0.76			0.39666			1.32		
08/07/19 18:00	0.3			2			1.7			0.71			0.37374			1.25		
08/07/19 19:00	1.1			1			1.7			0.54			0.29262			0.98		
08/07/19 20:00	0.9			1			1.7			0.45			0.24144			0.8		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/07/19 21:00	1			1			1.7			0.42			0.22884			0.76		
08/07/19 22:00	0.8			1			1.7			0.36			0.1935			0.65		
08/07/19 23:00	1			1			1.7			0.4			0.22122			0.74		
08/08/19 0:00	1			1			1.7			0.37			0.20454			0.68		
08/08/19 1:00	0.8			1			1.7			0.36			0.19302			0.64		
08/08/19 2:00	0.8			1			1.7			0.36			0.19314			0.64		
08/08/19 3:00	0.8			1			1.7			0.36			0.1932			0.64		
08/08/19 4:00	0.8			1			1.7			0.34			0.19068			0.64		
08/08/19 5:00	0			0	X		0			0	X		0.08946			0.3		
08/08/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/09/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/09/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/10/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/11/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/11/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/12/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/12/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/13/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/13/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/13/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/13/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/13/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/13/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/13/19 6:00	0	X		0	X		0	X		0.19			0	X		0	X	
08/13/19 7:00	0	X		0	X		0	X		0.52			0	X		0	X	
08/13/19 8:00	0	X		0	X		0	X		0.53			0	X		0	X	
08/13/19 9:00	0	X		0	X		0	X		0.47			0	X		0	X	
08/13/19 10:00	0	X		0	X		0	X		0.45			0	X		0	X	
08/13/19 11:00	0	X		0	X		0	X		0.51			0	X		0	X	
08/13/19 12:00	0	X		0	X		0	X		0.45			0	X		0	X	
08/13/19 13:00	0	X		0	X		0	X		0.45			0	X		0	X	
08/13/19 14:00	0	X		0	X		0	X		0.46			0	X		0	X	
08/13/19 15:00	0	X		0	X		0	X		0.74			0	X		0	X	
08/13/19 16:00	0	X		0	X		0	X		0.76			0	X		0	X	
08/13/19 17:00	0	X		0	X		0	X		0.76			0	X		0	X	
08/13/19 18:00	0	X		0	X		0	X		0.68			0	X		0	X	
08/13/19 19:00	0	X		0	X		0	X		0.75			0	X		0	X	
08/13/19 20:00	0	X		0	X		0	X		0.73			0	X		0	X	
08/13/19 21:00	0	X		0	X		0	X		0.67			0	X		0	X	
08/13/19 22:00	0	X		0	X		0	X		0.58			0	X		0	X	
08/13/19 23:00	0	X		0	X		0	X		0.68			0	X		0	X	
08/14/19 0:00	0	X		0	X		0	X		0.63			0	X		0	X	
08/14/19 1:00	0	X		0	X		0	X		0.61			0	X		0	X	
08/14/19 2:00	0	X		0	X		0	X		0.58			0	X		0	X	
08/14/19 3:00	0	X		0	X		0	X		0.58			0	X		0	X	
08/14/19 4:00	0	X		0	X		0	X		0.72			0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/14/19 5:00	0	X		0	X		0	X		0.73			0	X		0	X	
08/14/19 6:00	0			0	X		0			0.72			0.11154			0.37		
08/14/19 7:00	1.1			1			1.5			0.44			0.23082			0.77		
08/14/19 8:00	0.8			1			1.8			0.36			0.19548			0.65		
08/14/19 9:00	0.8			1			1.6			0.36			0.19386			0.65		
08/14/19 10:00	0.8			0			1.7			0.36			0.19308			0.64		
08/14/19 11:00	0.9			0			1.7			0.36			0.19248			0.64		
08/14/19 12:00	0.9			0			1.7			0.37			0.19548			0.65		
08/14/19 13:00	1.2			1			1.7			0.51			0.2742			0.91		
08/14/19 14:00	1.7			1			1.7			0.54			0.2895			0.97		
08/14/19 15:00	0.3			3			1.7			0.74			0.3894			1.3		
08/14/19 16:00	0.3			3			1.7			0.74			0.39324			1.31		
08/14/19 17:00	0.3			3			1.7			0.74			0.39282			1.31		
08/14/19 18:00	0.5			2			1.7			0.65			0.34668			1.16		
08/14/19 19:00	0.3			2			1.7			0.71			0.3792			1.26		
08/14/19 20:00	0.6			1			1.7			0.6			0.32388			1.08		
08/14/19 21:00	0.9			1			1.6			0.47			0.25692			0.86		
08/14/19 22:00	0.9			1			1.6			0.47			0.27156			0.91		
08/14/19 23:00	0.9			1			1.6			0.36			0.19446			0.65		
08/15/19 0:00	0.8			1			1.6			0.36			0.19242			0.64		
08/15/19 1:00	0.8			1			1.6			0.36			0.1929			0.64		
08/15/19 2:00	0.8			1			1.6			0.36			0.19272			0.64		
08/15/19 3:00	0.8			1			1.6			0.36			0.1929			0.64		
08/15/19 4:00	0.9			0			1.6			0.36			0.1929			0.64		
08/15/19 5:00	1			1			1.7			0.36			0.19302			0.64		
08/15/19 6:00	1.2			1			1.7			0.43			0.23364			0.78		
08/15/19 7:00	1			1			1.7			0.43			0.23568			0.79		
08/15/19 8:00	1			1			1.7			0.45			0.25116			0.84		
08/15/19 9:00	1			1			1.7			0.46			0.25614			0.85		
08/15/19 10:00	1			0			1.5			0.44			0.24264			0.81		
08/15/19 11:00	0.9			1			1.7			0.43			0.2361			0.79		
08/15/19 12:00	0.8			1			1.7			0.49			0.26022			0.87		
08/15/19 13:00	1			1			1.7			0.5			0.26832			0.89		
08/15/19 14:00	0.3			3			1.7			0.74			0.38844			1.29		
08/15/19 15:00	0.3			3			1.7			0.75			0.39384			1.31		
08/15/19 16:00	0.3			3			1.7			0.74			0.39342			1.31		
08/15/19 17:00	0.3			3			1.7			0.74			0.39246			1.31		
08/15/19 18:00	0.3			3			1.7			0.72			0.38112			1.27		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/15/19 19:00	0.4			2			1.7			0.64			0.34356			1.15		
08/15/19 20:00	0.8			1			1.7			0.59			0.31788			1.06		
08/15/19 21:00	1.2			1			1.7			0.54			0.29322			0.98		
08/15/19 22:00	1.4			1			1.7			0.51			0.27672			0.92		
08/15/19 23:00	0.9			1			1.7			0.36			0.19464			0.65		
08/16/19 0:00	0.9			1			1.7			0.36			0.19476			0.65		
08/16/19 1:00	0.9			1			1.7			0.36			0.1932			0.64		
08/16/19 2:00	0.8			1			1.7			0.36			0.19158			0.64		
08/16/19 3:00	0.9			1			1.7			0.36			0.19158			0.64		
08/16/19 4:00	0.9			1			1.7			0.36			0.1917			0.64		
08/16/19 5:00	1.4			1			1.7			0.36			0.19194			0.64		
08/16/19 6:00	1			1			1.7			0.36			0.195			0.65		
08/16/19 7:00	1.1			1			1.7			0.4			0.21486			0.72		
08/16/19 8:00	1.1			1			1.7			0.4			0.21762			0.73		
08/16/19 9:00	1			1			1.7			0.42			0.23082			0.77		
08/16/19 10:00	0.9			1			1.7			0.5			0.26946			0.9		
08/16/19 11:00	0.9			1			1.7			0.47			0.25302			0.84		
08/16/19 12:00	0.7			1			1.7			0.57			0.30612			1.02		
08/16/19 13:00	0.5			2			1.7			0.64			0.34104			1.14		
08/16/19 14:00	0.3			2			1.7			0.7			0.36876			1.23		
08/16/19 15:00	0.3			3			1.7			0.74			0.38946			1.3		
08/16/19 16:00	0.4			2			1.7			0.65			0.34686			1.16		
08/16/19 17:00	0.3			2			1.7			0.69			0.36432			1.21		
08/16/19 18:00	0.5			2			1.7			0.64			0.3408			1.14		
08/16/19 19:00	0.4			2			1.7			0.66			0.35088			1.17		
08/16/19 20:00	0.3			2			1.7			0.69			0.3675			1.23		
08/16/19 21:00	0.7			1			1.7			0.62			0.33198			1.11		
08/16/19 22:00	0.8			1			1.7			0.62			0.30294			1.01		
08/16/19 23:00	0			0	X		0			0.74			0.105			0.35		
08/17/19 0:00	0	X		0	X		0	X		0.71			0	X		0	X	
08/17/19 1:00	0	X		0	X		0	X		0.64			0	X		0	X	
08/17/19 2:00	0	X		0	X		0	X		0.49			0	X		0	X	
08/17/19 3:00	0	X		0	X		0	X		0.45			0	X		0	X	
08/17/19 4:00	0	X		0	X		0	X		0.44			0	X		0	X	
08/17/19 5:00	0	X		0	X		0	X		0.44			0	X		0	X	
08/17/19 6:00	0	X		0	X		0	X		0.41			0	X		0	X	
08/17/19 7:00	0	X		0	X		0	X		0.45			0	X		0	X	
08/17/19 8:00	0	X		0	X		0	X		0.45			0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/17/19 9:00	0	X		0	X		0	X		0.45			0	X		0	X	
08/17/19 10:00	0	X		0	X		0	X		0.45			0	X		0	X	
08/17/19 11:00	0	X		0	X		0	X		0.45			0	X		0	X	
08/17/19 12:00	0	X		0	X		0	X		0.39			0	X		0	X	
08/17/19 13:00	0	X		0	X		0	X		0.39			0	X		0	X	
08/17/19 14:00	0	X		0	X		0	X		0.42			0	X		0	X	
08/17/19 15:00	0	X		0	X		0	X		0.42			0	X		0	X	
08/17/19 16:00	0	X		0	X		0	X		0.54			0	X		0	X	
08/17/19 17:00	0	X		0	X		0	X		0.75			0	X		0	X	
08/17/19 18:00	0	X		0	X		0	X		0.75			0	X		0	X	
08/17/19 19:00	0	X		0	X		0	X		0.67			0	X		0	X	
08/17/19 20:00	0	X		0	X		0	X		0.63			0	X		0	X	
08/17/19 21:00	0	X		0	X		0	X		0.63			0	X		0	X	
08/17/19 22:00	0	X		0	X		0	X		0.57			0	X		0	X	
08/17/19 23:00	0	X		0	X		0	X		0.21			0	X		0	X	
08/18/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/18/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/18/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/19/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/20/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/20/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/21/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/22/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/22/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/23/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/23/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/24/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/25/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/25/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/25/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/25/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/25/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/25/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/25/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/25/19 7:00	0			0	X		0			0	X		0.1092			0.36		
08/25/19 8:00	0.9			0			1.6			0	X		0.2766			0.92		
08/25/19 9:00	0.9			1			1.6			0	X		0.27864			0.93		
08/25/19 10:00	0.9			1			1.7			0	X		0.27918			0.93		
08/25/19 11:00	0.4			2			1.4			0	X		0.36918			1.23		
08/25/19 12:00	0.3			3			1.4			0	X		0.39396			1.31		
08/25/19 13:00	0.3			3			1.5			0	X		0.39318			1.31		
08/25/19 14:00	0.3			3			1.6			0	X		0.39168			1.31		
08/25/19 15:00	0.3			3			1.7			0	X		0.39042			1.3		
08/25/19 16:00	0.8			1			1.7			0	X		0.32118			1.07		
08/25/19 17:00	1			1			1.7			0	X		0.31278			1.04		
08/25/19 18:00	1			1			1.7			0	X		0.31452			1.05		
08/25/19 19:00	1			1			1.7			0	X		0.31728			1.06		
08/25/19 20:00	0.5			2			1.7			0	X		0.35292			1.18		
08/25/19 21:00	1			1			1.7			0	X		0.27984			0.93		
08/25/19 22:00	1			1			1.7			0	X		0.27288			0.91		
08/25/19 23:00	1			1			1.7			0	X		0.24072			0.8		
08/26/19 0:00	1			1			1.7			0	X		0.20436			0.68		
08/26/19 1:00	1			1			1.7			0	X		0.20226			0.67		
08/26/19 2:00	1			1			1.7			0	X		0.20172			0.67		
08/26/19 3:00	1			1			1.7			0	X		0.20166			0.67		
08/26/19 4:00	1			1			1.7			0	X		0.20244			0.67		
08/26/19 5:00	1.1			1			1.7			0	X		0.20562			0.69		
08/26/19 6:00	1.1			1			1.7			0	X		0.2154			0.72		
08/26/19 7:00	1.1			1			1.7			0	X		0.21966			0.73		
08/26/19 8:00	1			1			1.7			0	X		0.24066			0.8		
08/26/19 9:00	1.2			1			1.7			0	X		0.28218			0.94		
08/26/19 10:00	0.4			2			1.7			0	X		0.3783			1.26		
08/26/19 11:00	0.3			2			1.7			0	X		0.37734			1.26		
08/26/19 12:00	0.3			2			1.7			0	X		0.37554			1.25		
08/26/19 13:00	0.4			2			1.7			0	X		0.35124			1.17		
08/26/19 14:00	0.7			1			1.7			0	X		0.32568			1.09		
08/26/19 15:00	1			1			1.8			0	X		0.2691			0.9		
08/26/19 16:00	0.9			1			1.7			0	X		0.3246			1.08		
08/26/19 17:00	0.8			1			1.7			0	X		0.32382			1.08		
08/26/19 18:00	0.9			1			1.7			0	X		0.31638			1.05		
08/26/19 19:00	1.1			1			1.7			0	X		0.28344			0.94		
08/26/19 20:00	0.7			2			1.6			0	X		0.33378			1.11		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/26/19 21:00	1			1			1.7			0	X		0.24174			0.81		
08/26/19 22:00	1			1			1.7			0	X		0.2304			0.77		
08/26/19 23:00	1			1			1.7			0	X		0.24258			0.81		
08/27/19 0:00	1			1			1.7			0	X		0.2589			0.86		
08/27/19 1:00	1			1			1.7			0	X		0.24144			0.8		
08/27/19 2:00	1			1			1.7			0	X		0.2403			0.8		
08/27/19 3:00	1			1			1.7			0	X		0.23556			0.79		
08/27/19 4:00	1			1			1.6			0	X		0.25956			0.87		
08/27/19 5:00	1			1			1.7			0.19			0.2439			0.81		
08/27/19 6:00	1			1			1.7			0.39			0.21996			0.73		
08/27/19 7:00	1.1			1			1.7			0.39			0.21078			0.7		
08/27/19 8:00	1.1			1			1.7			0.39			0.2097			0.7		
08/27/19 9:00	1.1			1			1.7			0.39			0.21006			0.7		
08/27/19 10:00	1			1			1.7			0.4			0.21558			0.72		
08/27/19 11:00	1			1			1.7			0.4			0.2139			0.71		
08/27/19 12:00	1.1			1			1.7			0.43			0.23952			0.8		
08/27/19 13:00	0.8			1			1.5			0.61			0.3261			1.09		
08/27/19 14:00	0.7			1			1.6			0.63			0.33246			1.11		
08/27/19 15:00	0.3			3			1.7			0.75			0.39294			1.31		
08/27/19 16:00	0.3			3			1.7			0.74			0.38976			1.3		
08/27/19 17:00	0.3			3			1.7			0.73			0.3837			1.28		
08/27/19 18:00	0.3			3			1.7			0.72			0.3816			1.27		
08/27/19 19:00	0.3			3			1.7			0.72			0.38112			1.27		
08/27/19 20:00	0.3			2			1.7			0.71			0.37626			1.25		
08/27/19 21:00	1.1			1			1.7			0.52			0.28038			0.93		
08/27/19 22:00	1			0			1.7			0.44			0.2331			0.78		
08/27/19 23:00	1			1			1.7			0.39			0.20706			0.69		
08/28/19 0:00	1			1			1.7			0.38			0.20676			0.69		
08/28/19 1:00	1			1			1.7			0.37			0.2028			0.68		
08/28/19 2:00	1			1			1.7			0.36			0.20418			0.68		
08/28/19 3:00	1			1			1.7			0.36			0.20586			0.69		
08/28/19 4:00	1.1			1			1.6			0.38			0.22014			0.73		
08/28/19 5:00	1.1			1			1.7			0.39			0.2244			0.75		
08/28/19 6:00	1			1			1.7			0.43			0.24624			0.82		
08/28/19 7:00	0.5			3			1.7			0.74			0.39204			1.31		
08/28/19 8:00	0.3			3			1.7			0.75			0.39876			1.33		
08/28/19 9:00	0.3			3			1.7			0.75			0.39834			1.33		
08/28/19 10:00	0.3			3			1.7			0.76			0.399			1.33		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/28/19 11:00	0.3			3			1.7			0.76			0.40128			1.34		
08/28/19 12:00	0.3			3			1.7			0.76			0.40014			1.33		
08/28/19 13:00	0.3			3			1.7			0.76			0.39786			1.33		
08/28/19 14:00	0.3			3			1.7			0.75			0.39666			1.32		
08/28/19 15:00	0.3			3			1.7			0.75			0.39612			1.32		
08/28/19 16:00	0.3			3			1.7			0.75			0.39552			1.32		
08/28/19 17:00	0.3			3			1.7			0.75			0.39582			1.32		
08/28/19 18:00	0.3			3			1.7			0.74			0.39132			1.3		
08/28/19 19:00	0.4			2			1.7			0.68			0.36132			1.2		
08/28/19 20:00	1			1			1.7			0.58			0.31248			1.04		
08/28/19 21:00	0.9			1			1.7			0.44			0.24102			0.8		
08/28/19 22:00	1			1			1.7			0.41			0.22104			0.74		
08/28/19 23:00	0.9			1			1.7			0.37			0.20022			0.67		
08/29/19 0:00	1			1			1.7			0.38			0.21108			0.7		
08/29/19 1:00	0.9			1			1.7			0.36			0.20118			0.67		
08/29/19 2:00	0.9			1			1.7			0.36			0.20136			0.67		
08/29/19 3:00	0.9			1			1.7			0.36			0.20208			0.67		
08/29/19 4:00	1			1			1.7			0.37			0.20898			0.7		
08/29/19 5:00	0.9			1			1.7			0.36			0.20166			0.67		
08/29/19 6:00	1			1			1.7			0.37			0.20898			0.7		
08/29/19 7:00	1			1			1.7			0.38			0.2115			0.71		
08/29/19 8:00	0.9			1			1.7			0.4			0.22608			0.75		
08/29/19 9:00	0.9			1			1.7			0.45			0.25176			0.84		
08/29/19 10:00	0.8			1			1.7			0.5			0.2769			0.92		
08/29/19 11:00	1.1			1			1.7			0.59			0.3141			1.05		
08/29/19 12:00	0.6			1			1.7			0.64			0.33918			1.13		
08/29/19 13:00	0.7			1			1.7			0.62			0.33186			1.11		
08/29/19 14:00	0.4			2			1.7			0.66			0.34884			1.16		
08/29/19 15:00	0.4			2			1.7			0.66			0.35148			1.17		
08/29/19 16:00	0.4			2			1.7			0.67			0.35298			1.18		
08/29/19 17:00	0.4			2			1.7			0.67			0.3537			1.18		
08/29/19 18:00	0.4			2			1.7			0.68			0.36042			1.2		
08/29/19 19:00	0.6			1			1.7			0.65			0.34392			1.15		
08/29/19 20:00	0.9			1			1.7			0.52			0.28296			0.94		
08/29/19 21:00	0.9			1			1.7			0.47			0.25236			0.84		
08/29/19 22:00	1			1			1.7			0.39			0.21348			0.71		
08/29/19 23:00	0			0	X		0			0.18			0.1176			0.39		
08/30/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/30/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/30/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
08/31/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/31/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/01/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/02/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/02/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/03/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/03/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/04/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/04/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/04/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/04/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/04/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/04/19 5:00	0	X		0	X		0	X		0.18			0	X		0	X	
09/04/19 6:00	0			0	X		0			0.53			0.096			0.32		
09/04/19 7:00	1			0			1.5			0.49			0.25944			0.86		
09/04/19 8:00	1.1			0			1.7			0.43			0.23424			0.78		
09/04/19 9:00	1			0			1.7			0.46			0.25128			0.84		
09/04/19 10:00	1.2			1			1.7			0.5			0.2709			0.9		
09/04/19 11:00	0.7			1			1.7			0.64			0.3417			1.14		
09/04/19 12:00	0.6			2			1.7			0.66			0.34758			1.16		
09/04/19 13:00	0.5			2			1.7			0.68			0.36054			1.2		
09/04/19 14:00	0.4			3			1.7			0.76			0.39864			1.33		
09/04/19 15:00	0.3			3			1.7			0.76			0.399			1.33		
09/04/19 16:00	0.3			3			1.7			0.75			0.3966			1.32		
09/04/19 17:00	0.9			1			1.7			0.48			0.26052			0.87		
09/04/19 18:00	0.9			1			1.7			0.47			0.25626			0.85		
09/04/19 19:00	0.9			1			1.7			0.48			0.26748			0.89		
09/04/19 20:00	0.8			2			1.7			0.63			0.34122			1.14		
09/04/19 21:00	1.1			1			1.7			0.4			0.21696			0.72		
09/04/19 22:00	1			1			1.7			0.38			0.20406			0.68		
09/04/19 23:00	1			1			1.7			0.47			0.25974			0.87		
09/05/19 0:00	1			1			1.7			0.43			0.24144			0.8		
09/05/19 1:00	1.1			1			1.7			0.39			0.22806			0.76		
09/05/19 2:00	1.1			1			1.7			0.36			0.20736			0.69		
09/05/19 3:00	1			1			1.7			0.36			0.204			0.68		
09/05/19 4:00	1.1			1			1.7			0.39			0.21888			0.73		
09/05/19 5:00	1.1			1			1.7			0.36			0.20994			0.7		
09/05/19 6:00	1.1			1			1.7			0.38			0.219			0.73		
09/05/19 7:00	1			1			1.7			0.41			0.2361			0.79		
09/05/19 8:00	1			1			1.7			0.45			0.25908			0.86		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/05/19 9:00	1.8			1			1.7			0.54			0.29076			0.97		
09/05/19 10:00	1.2			1			1.7			0.59			0.31416			1.05		
09/05/19 11:00	0.9			1			1.7			0.62			0.33006			1.1		
09/05/19 12:00	0.7			2			1.7			0.65			0.34464			1.15		
09/05/19 13:00	0.4			3			1.7			0.77			0.4026			1.34		
09/05/19 14:00	0.3			3			1.7			0.76			0.40212			1.34		
09/05/19 15:00	0.3			3			1.7			0.76			0.40164			1.34		
09/05/19 16:00	0.5			2			1.7			0.68			0.35934			1.2		
09/05/19 17:00	0.5			2			1.7			0.67			0.35736			1.19		
09/05/19 18:00	0.9			1			1.7			0.6			0.32328			1.08		
09/05/19 19:00	1			1			1.7			0.5			0.27162			0.91		
09/05/19 20:00	1			1			1.7			0.46			0.25326			0.84		
09/05/19 21:00	0.9			1			1.7			0.49			0.27192			0.91		
09/05/19 22:00	1			1			1.7			0.45			0.24564			0.82		
09/05/19 23:00	0			0	X		0			0.19			0.1353			0.45		
09/06/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/06/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/06/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/07/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/08/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/08/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/09/19 22:00	0			0	X		0			0	X		0.1104			0.37		
09/09/19 23:00	1			0			1.3			0	X		0.20964			0.7		
09/10/19 0:00	1			1			1.7			0	X		0.23322			0.78		
09/10/19 1:00	1.1			0			1.6			0	X		0.21048			0.7		
09/10/19 2:00	1			1			1.6			0	X		0.20796			0.69		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/10/19 3:00	1.1			1			1.7			0	X		0.21828			0.73		
09/10/19 4:00	1			1			1.8			0	X		0.23856			0.8		
09/10/19 5:00	1			1			1.7			0	X		0.23448			0.78		
09/10/19 6:00	1			1			1.7			0	X		0.2442			0.81		
09/10/19 7:00	1			1			1.7			0	X		0.27102			0.9		
09/10/19 8:00	1			1			1.7			0	X		0.24474			0.82		
09/10/19 9:00	1			1			1.7			0	X		0.21516			0.72		
09/10/19 10:00	1			1			1.7			0	X		0.26712			0.89		
09/10/19 11:00	1			1			1.7			0	X		0.2664			0.89		
09/10/19 12:00	0.7			2			1.7			0	X		0.35214			1.17		
09/10/19 13:00	1			1			1.8			0	X		0.26928			0.9		
09/10/19 14:00	0.6			2			1.6			0	X		0.37176			1.24		
09/10/19 15:00	1			1			1.8			0	X		0.2703			0.9		
09/10/19 16:00	0.6			3			1.6			0	X		0.38382			1.28		
09/10/19 17:00	0.4			3			1.7			0	X		0.39558			1.32		
09/10/19 18:00	0.4			3			1.7			0	X		0.39318			1.31		
09/10/19 19:00	0.7			2			1.7			0	X		0.3504			1.17		
09/10/19 20:00	1.2			1			1.7			0	X		0.23694			0.79		
09/10/19 21:00	1			1			1.7			0	X		0.2394			0.8		
09/10/19 22:00	1.1			1			1.7			0	X		0.23676			0.79		
09/10/19 23:00	1.2			1			1.7			0	X		0.21714			0.72		
09/11/19 0:00	1.1			1			1.7			0	X		0.20232			0.67		
09/11/19 1:00	1.1			1			1.7			0	X		0.2031			0.68		
09/11/19 2:00	1.1			1			1.7			0	X		0.20358			0.68		
09/11/19 3:00	1.1			1			1.7			0	X		0.2037			0.68		
09/11/19 4:00	1.1			1			1.7			0	X		0.20868			0.7		
09/11/19 5:00	1.3			1			1.7			0	X		0.20934			0.7		
09/11/19 6:00	1.3			1			1.7			0	X		0.20916			0.7		
09/11/19 7:00	1.1			1			1.7			0	X		0.2094			0.7		
09/11/19 8:00	1.1			1			1.7			0.18			0.20856			0.7		
09/11/19 9:00	0.9			1			1.7			0.38			0.2013			0.67		
09/11/19 10:00	0.9			1			1.7			0.47			0.2574			0.86		
09/11/19 11:00	2.2			1			1.7			0.54			0.28524			0.95		
09/11/19 12:00	0			0	X		0			0.68			0.12558			0.42		
09/11/19 13:00	0	X		0	X		0	X		0.42			0	X		0	X	
09/11/19 14:00	0	X		0	X		0	X		0.7			0	X		0	X	
09/11/19 15:00	0	X		0	X		0	X		0.41			0	X		0	X	
09/11/19 16:00	0	X		0	X		0	X		0.57			0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/11/19 17:00	0	X		0	X		0	X		0.57			0	X		0	X	
09/11/19 18:00	0	X		0	X		0	X		0.48			0	X		0	X	
09/11/19 19:00	0	X		0	X		0	X		0.4			0	X		0	X	
09/11/19 20:00	0	X		0	X		0	X		0.61			0	X		0	X	
09/11/19 21:00	0	X		0	X		0	X		0.45			0	X		0	X	
09/11/19 22:00	0	X		0	X		0	X		0.45			0	X		0	X	
09/11/19 23:00	0	X		0	X		0	X		0.45			0	X		0	X	
09/12/19 0:00	0	X		0	X		0	X		0.42			0	X		0	X	
09/12/19 1:00	0	X		0	X		0	X		0.38			0	X		0	X	
09/12/19 2:00	0	X		0	X		0	X		0.38			0	X		0	X	
09/12/19 3:00	0	X		0	X		0	X		0.37			0	X		0	X	
09/12/19 4:00	0	X		0	X		0	X		0.37			0	X		0	X	
09/12/19 5:00	0	X		0	X		0	X		0.38			0	X		0	X	
09/12/19 6:00	0	X		0	X		0	X		0.38			0	X		0	X	
09/12/19 7:00	0	X		0	X		0	X		0.4			0	X		0	X	
09/12/19 8:00	0			0	X		0			0.69			0.10146			0.34		
09/12/19 9:00	0.9			0			1.4			0.41			0.2109			0.7		
09/12/19 10:00	1.5			1			1.7			0.54			0.29154			0.97		
09/12/19 11:00	1			1			1.7			0.43			0.2586			0.86		
09/12/19 12:00	0.8			1			1.6			0.13			0.35016			1.17		
09/12/19 13:00	1			1			1.8			0	X		0.2694			0.9		
09/12/19 14:00	0.5			2			1.6			0	X		0.35868			1.2		
09/12/19 15:00	1			1			1.8			0	X		0.23844			0.79		
09/12/19 16:00	0.6			3			1.7			0	X		0.36456			1.22		
09/12/19 17:00	0.4			3			1.7			0	X		0.3999			1.33		
09/12/19 18:00	0.4			3			1.7			0	X		0.40182			1.34		
09/12/19 19:00	0.4			3			1.7			0	X		0.40152			1.34		
09/12/19 20:00	0.5			3			1.7			0	X		0.39072			1.3		
09/12/19 21:00	1.1			0			1.7			0	X		0.24762			0.83		
09/12/19 22:00	1.3			1			1.7			0	X		0.243			0.81		
09/12/19 23:00	0			0	X		0			0	X		0.1131			0.38		
09/13/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/13/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/13/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/14/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/14/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/15/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/16/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/16/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/17/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/18/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/18/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/19/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/19/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/20/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/21/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/21/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/22/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/22/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/23/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/23/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/23/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/23/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/23/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/23/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/23/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/23/19 7:00	0			0	X		0			0	X		0.09906			0.33		
09/23/19 8:00	1			1			1.5			0	X		0.27834			0.93		
09/23/19 9:00	1			1			1.7			0	X		0.28254			0.94		
09/23/19 10:00	1.1			1			1.7			0	X		0.28506			0.95		
09/23/19 11:00	0.7			2			1.7			0	X		0.35706			1.19		
09/23/19 12:00	0.6			2			1.7			0	X		0.35976			1.2		
09/23/19 13:00	0.6			2			1.7			0	X		0.3597			1.2		
09/23/19 14:00	0.6			2			1.7			0	X		0.35736			1.19		
09/23/19 15:00	0.8			2			1.7			0	X		0.34068			1.14		
09/23/19 16:00	0.6			2			1.7			0	X		0.35784			1.19		
09/23/19 17:00	0.6			2			1.7			0	X		0.35712			1.19		
09/23/19 18:00	1.2			1			1.7			0	X		0.31476			1.05		
09/23/19 19:00	0.7			2			1.7			0	X		0.35982			1.2		
09/23/19 20:00	0.7			2			1.7			0	X		0.35376			1.18		
09/23/19 21:00	1.1			1			1.8			0	X		0.27378			0.91		
09/23/19 22:00	1.1			1			1.7			0	X		0.21			0.7		
09/23/19 23:00	1.1			2			1.7			0	X		0.30906			1.03		
09/24/19 0:00	1.1			2			1.7			0	X		0.32706			1.09		
09/24/19 1:00	0.9			2			1.7			0	X		0.33882			1.13		
09/24/19 2:00	1.1			2			1.7			0	X		0.3288			1.1		
09/24/19 3:00	1			2			1.7			0	X		0.33822			1.13		
09/24/19 4:00	0.6			2			1.7			0	X		0.3672			1.22		
09/24/19 5:00	1.1			1			1.8			0	X		0.26364			0.88		
09/24/19 6:00	1.1			1			1.7			0	X		0.2619			0.87		
09/24/19 7:00	1.4			2			1.7			0.01			0.31926			1.06		
09/24/19 8:00	1			1			1.7			0.37			0.25122			0.84		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/24/19 9:00	1.1			1			1.7			0.44			0.23862			0.8		
09/24/19 10:00	1			1			1.7			0.47			0.26256			0.88		
09/24/19 11:00	1			1			1.7			0.46			0.26328			0.88		
09/24/19 12:00	1.9			1			1.7			0.53			0.27426			0.91		
09/24/19 13:00	1.4			1			1.7			0.58			0.29742			0.99		
09/24/19 14:00	1.5			1			1.7			0.55			0.2952			0.98		
09/24/19 15:00	1.2			2			1.7			0.57			0.30804			1.03		
09/24/19 16:00	0.4			3			1.7			0.76			0.40062			1.34		
09/24/19 17:00	0.4			4			1.7			0.76			0.39972			1.33		
09/24/19 18:00	0.5			3			1.7			0.69			0.36702			1.22		
09/24/19 19:00	1.2			1			1.7			0.57			0.30576			1.02		
09/24/19 20:00	1			1			1.7			0.47			0.2556			0.85		
09/24/19 21:00	1.7			1			1.7			0.53			0.28818			0.96		
09/24/19 22:00	1.1			1			1.7			0.46			0.2523			0.84		
09/24/19 23:00	1.2			1			1.7			0.37			0.20184			0.67		
09/25/19 0:00	1.2			1			1.7			0.36			0.19686			0.66		
09/25/19 1:00	1.2			1			1.7			0.36			0.19794			0.66		
09/25/19 2:00	1.4			1			1.7			0.36			0.19824			0.66		
09/25/19 3:00	1.5			1			1.7			0.36			0.19806			0.66		
09/25/19 4:00	1.6			1			1.7			0.36			0.198			0.66		
09/25/19 5:00	1.5			1			1.7			0.36			0.19698			0.66		
09/25/19 6:00	1.2			1			1.7			0.36			0.19404			0.65		
09/25/19 7:00	1.2			1			1.7			0.36			0.19686			0.66		
09/25/19 8:00	1			1			1.7			0.36			0.19398			0.65		
09/25/19 9:00	1			1			1.7			0.36			0.19764			0.66		
09/25/19 10:00	1.1			1			1.7			0.42			0.22656			0.76		
09/25/19 11:00	1.1			1			1.7			0.49			0.26616			0.89		
09/25/19 12:00	0.5			2			1.7			0.71			0.37488			1.25		
09/25/19 13:00	0.4			3			1.7			0.75			0.3939			1.31		
09/25/19 14:00	0.4			3			1.7			0.71			0.37434			1.25		
09/25/19 15:00	0.4			3			1.7			0.7			0.37248			1.24		
09/25/19 16:00	0.4			3			1.7			0.73			0.38526			1.28		
09/25/19 17:00	0.4			3			1.7			0.73			0.38484			1.28		
09/25/19 18:00	1.1			1			1.8			0.51			0.30234			1.01		
09/25/19 19:00	0.5			2			1.7			0.66			0.35448			1.18		
09/25/19 20:00	0.6			2			1.7			0.65			0.3504			1.17		
09/25/19 21:00	1.1			1			1.7			0.44			0.2523			0.84		
09/25/19 22:00	1.2			1			1.7			0.38			0.22272			0.74		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/25/19 23:00	1.1			1			1.7			0.36			0.1974			0.66		
09/26/19 0:00	1			1			1.7			0.36			0.19734			0.66		
09/26/19 1:00	1.1			1			1.7			0.36			0.19722			0.66		
09/26/19 2:00	1.1			1			1.7			0.36			0.19806			0.66		
09/26/19 3:00	1.1			1			1.7			0.36			0.19812			0.66		
09/26/19 4:00	1.1			1			1.7			0.36			0.19794			0.66		
09/26/19 5:00	1.1			1			1.7			0.36			0.1983			0.66		
09/26/19 6:00	1			1			1.7			0.36			0.19422			0.65		
09/26/19 7:00	1.1			1			1.7			0.36			0.19626			0.65		
09/26/19 8:00	1.2			1			1.7			0.37			0.20424			0.68		
09/26/19 9:00	1.2			1			1.7			0.44			0.2439			0.81		
09/26/19 10:00	1.8			1			1.7			0.55			0.2982			0.99		
09/26/19 11:00	1.1			1			1.7			0.6			0.31926			1.06		
09/26/19 12:00	0.8			2			1.7			0.62			0.33114			1.1		
09/26/19 13:00	0.8			2			1.7			0.62			0.3315			1.11		
09/26/19 14:00	0.5			3			1.7			0.72			0.38178			1.27		
09/26/19 15:00	0.5			2			1.7			0.7			0.36984			1.23		
09/26/19 16:00	0.4			3			1.7			0.74			0.38886			1.3		
09/26/19 17:00	0.6			2			1.7			0.65			0.34824			1.16		
09/26/19 18:00	1			1			1.7			0.6			0.32082			1.07		
09/26/19 19:00	1			1			1.7			0.51			0.28014			0.93		
09/26/19 20:00	1.1			1			1.7			0.43			0.23124			0.77		
09/26/19 21:00	1.1			1			1.7			0.38			0.2112			0.7		
09/26/19 22:00	1			1			1.7			0.35			0.2016			0.67		
09/26/19 23:00	1			1			1.7			0.13			0.2127			0.71		
09/27/19 0:00	1			1			1.7			0	X		0.20424			0.68		
09/27/19 1:00	1			1			1.7			0	X		0.20472			0.68		
09/27/19 2:00	1			1			1.7			0	X		0.20334			0.68		
09/27/19 3:00	1			1			1.7			0	X		0.20328			0.68		
09/27/19 4:00	1			1			1.7			0	X		0.20568			0.69		
09/27/19 5:00	1.1			1			1.7			0	X		0.22128			0.74		
09/27/19 6:00	1.1			1			1.7			0	X		0.22272			0.74		
09/27/19 7:00	1			1			1.7			0	X		0.24366			0.81		
09/27/19 8:00	1			1			1.7			0	X		0.26676			0.89		
09/27/19 9:00	0.6			3			1.7			0	X		0.39666			1.32		
09/27/19 10:00	0.4			4			1.7			0	X		0.40242			1.34		
09/27/19 11:00	0.4			3			1.7			0	X		0.40146			1.34		
09/27/19 12:00	0.4			3			1.7			0	X		0.40074			1.34		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/27/19 13:00	0.4			3			1.7			0	X		0.40086			1.34		
09/27/19 14:00	0.4			3			1.7			0	X		0.4011			1.34		
09/27/19 15:00	0.4			3			1.7			0	X		0.4011			1.34		
09/27/19 16:00	0.4			3			1.7			0	X		0.40116			1.34		
09/27/19 17:00	0.4			3			1.7			0	X		0.40122			1.34		
09/27/19 18:00	0.4			3			1.7			0	X		0.4023			1.34		
09/27/19 19:00	0.4			3			1.7			0	X		0.40146			1.34		
09/27/19 20:00	0.4			3			1.7			0	X		0.39336			1.31		
09/27/19 21:00	1.2			0			1.8			0	X		0.23688			0.79		
09/27/19 22:00	1.1			1			1.7			0	X		0.20382			0.68		
09/27/19 23:00	0			0	X		0			0	X		0.10104			0.34		
09/28/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/29/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/29/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/30/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/30/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/30/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/30/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/30/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/30/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/30/19 6:00	0	X		0	X		0	X		0.18			0	X		0	X	
09/30/19 7:00	0	X		0	X		0	X		0.52			0	X		0	X	
09/30/19 8:00	0	X		0	X		0	X		0.52			0	X		0	X	
09/30/19 9:00	0	X		0	X		0	X		0.54			0	X		0	X	
09/30/19 10:00	0			0	X		0			0.53			0.09498			0.32		
09/30/19 11:00	1.2			1			1.5			0.42			0.23364			0.78		
09/30/19 12:00	1			1			1.7			0.14			0.28242			0.94		
09/30/19 13:00	1.1			1			1.7			0	X		0.28542			0.95		
09/30/19 14:00	0.6			3			1.7			0	X		0.37464			1.25		
09/30/19 15:00	0.4			3			1.7			0	X		0.38328			1.28		
09/30/19 16:00	0.6			2			1.7			0	X		0.35814			1.19		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc	Value	Sl	Modc
09/30/19 17:00	1.1			0			2			0	X		0.1686			0.56		
09/30/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/30/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/30/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/30/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/30/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/30/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	

ATTACHMENT 17

AQ-59

AQ-59 The Daily Emissions shall not exceed the following rates:

POLLUTANT	TWO TURBINES	AUX BOILER	COOLING TOWER	EMERGENCY DIESEL GENERATOR	DIESEL FIRE PUMP
NOX	406.0	16.8	-	4.31	1.72
CO	629.5	52.8	-	0.84	0.09
VOC	223.1	7.2	-	0.16	0.05
PM-10	226.8	14.4	16.3	0.14	0.03
SO2	47.1	1.92	-	0.10	0.19

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:01 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
07/01/2019	0.00	0.00	0.00	0.00	0.00
07/02/2019	0.00	0.00	0.00	0.00	0.00
07/03/2019	0.00	0.00	0.00	0.00	0.00
07/04/2019	0.00	0.00	0.00	0.00	0.00
07/05/2019	0.00	0.00	0.00	0.00	0.00
07/06/2019	0.00	0.00	0.00	0.00	0.00
07/07/2019	0.00	0.00	0.00	0.00	0.00
07/08/2019	0.00	0.00	0.00	0.00	0.00
07/09/2019	0.00	0.00	0.00	0.00	0.00
07/10/2019	0.00	0.00	0.00	0.00	0.00
07/11/2019	0.00	0.00	0.00	0.00	0.00
07/12/2019	0.00	0.00	0.00	0.00	0.00
07/13/2019	0.00	0.00	0.00	0.00	0.00
07/14/2019	0.00	0.00	0.00	0.00	0.00
07/15/2019	0.00	0.00	0.00	0.00	0.00
07/16/2019	0.00	0.00	0.00	0.00	0.00
07/17/2019	0.00	0.00	0.00	0.00	0.00
07/18/2019	0.00	0.00	0.00	0.00	0.00
07/19/2019	0.00	0.00	0.00	0.00	0.00
07/20/2019	0.00	0.00	0.00	0.00	0.00
07/21/2019	0.00	0.00	0.00	0.00	0.00
07/22/2019	27.81	37.22	2.49	4.96	8.30
07/23/2019	29.53	91.83	8.98	17.99	30.01
07/24/2019	7.40	93.50	8.98	17.98	29.95
07/25/2019	15.45	79.03	7.60	15.23	25.36
07/26/2019	14.85	80.58	7.75	15.52	25.86
07/27/2019	42.08	83.84	6.91	13.83	23.07
07/28/2019	31.86	144.37	13.84	27.61	46.05
07/29/2019	32.64	154.66	14.79	29.56	49.26
07/30/2019	34.96	111.05	10.60	21.19	35.32
07/31/2019	29.32	119.89	11.42	22.89	38.15
Monthly Avg/Sum*:	265.90 *	995.97 *	93.36 *	186.76 *	311.33 *
Daily Min:	7.40	37.22	2.49	4.96	8.30
Daily Max:	42.08	154.66	14.79	29.56	49.26
Jul 2019 - Jul 2019	265.90	995.97	93.36	186.76	311.33
QTD:	265.90 *	995.97 *	93.36 *	186.76 *	311.33 *
YTD 2019:	3,190.65 *	9,282.43 *	870.52 *	1,742.01 *	2,903.47 *

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:01 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
08/01/2019	32.28	112.72	10.75	21.54	35.87
08/02/2019	30.10	116.24	11.12	22.22	37.00
08/03/2019	29.83	124.10	11.85	23.77	39.57
08/04/2019	27.26	131.11	12.51	24.97	41.60
08/05/2019	25.16	111.76	11.62	23.28	38.76
08/06/2019	30.10	127.41	12.19	24.43	40.66
08/07/2019	30.47	121.93	11.59	23.24	38.66
08/08/2019	31.45	21.55	1.87	3.76	6.23
08/09/2019	0.00	0.00	0.00	0.00	0.00
08/10/2019	0.00	0.00	0.00	0.00	0.00
08/11/2019	0.00	0.00	0.00	0.00	0.00
08/12/2019	0.00	0.00	0.00	0.00	0.00
08/13/2019	31.38	63.44	5.12	10.24	17.09
08/14/2019	56.92	129.68	11.42	22.84	38.09
08/15/2019	31.31	129.75	12.57	25.18	41.94
08/16/2019	38.17	132.93	12.67	25.38	42.27
08/17/2019	21.76	63.82	5.98	12.01	20.00
08/18/2019	0.00	0.00	0.00	0.00	0.00
08/19/2019	0.00	0.00	0.00	0.00	0.00
08/20/2019	0.00	0.00	0.00	0.00	0.00
08/21/2019	0.00	0.00	0.00	0.00	0.00
08/22/2019	0.00	0.00	0.00	0.00	0.00
08/23/2019	0.00	0.00	0.00	0.00	0.00
08/24/2019	0.00	0.00	0.00	0.00	0.00
08/25/2019	38.98	65.25	5.20	10.44	17.38
08/26/2019	20.39	68.80	6.54	13.08	21.82
08/27/2019	57.36	131.96	11.59	23.16	38.61
08/28/2019	25.76	153.44	14.70	29.37	49.01
08/29/2019	60.99	128.03	12.03	24.04	40.10
08/30/2019	0.00	0.00	0.00	0.00	0.00
08/31/2019	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	619.67 *	1,933.92 *	181.32 *	362.95 *	604.66 *
Daily Min:	20.39	21.55	1.87	3.76	6.23
Daily Max:	60.99	153.44	14.70	29.37	49.01
Jul 2019 - Aug 2019	885.57	2,929.89	274.68	549.71	915.99
QTD:	885.57 *	2,929.89 *	274.68 *	549.71 *	915.99 *
YTD 2019:	3,810.32 *	11,216.35 *	1,051.84 *	2,104.96 *	3,508.13 *

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:01 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
09/01/2019	0.00	0.00	0.00	0.00	0.00
09/02/2019	0.00	0.00	0.00	0.00	0.00
09/03/2019	0.00	0.00	0.00	0.00	0.00
09/04/2019	84.83	128.20	10.09	20.18	33.62
09/05/2019	54.31	133.96	12.64	25.30	42.16
09/06/2019	0.00	0.00	0.00	0.00	0.00
09/07/2019	0.00	0.00	0.00	0.00	0.00
09/08/2019	0.00	0.00	0.00	0.00	0.00
09/09/2019	26.06	15.30	0.24	0.48	0.80
09/10/2019	21.23	68.35	6.57	13.13	21.90
09/11/2019	63.84	79.38	6.42	12.87	21.44
09/12/2019	68.03	88.44	7.04	14.09	23.47
09/13/2019	0.00	0.00	0.00	0.00	0.00
09/14/2019	0.00	0.00	0.00	0.00	0.00
09/15/2019	0.00	0.00	0.00	0.00	0.00
09/16/2019	0.00	0.00	0.00	0.00	0.00
09/17/2019	0.00	0.00	0.00	0.00	0.00
09/18/2019	0.00	0.00	0.00	0.00	0.00
09/19/2019	0.00	0.00	0.00	0.00	0.00
09/20/2019	0.00	0.00	0.00	0.00	0.00
09/21/2019	0.00	0.00	0.00	0.00	0.00
09/22/2019	0.00	0.00	0.00	0.00	0.00
09/23/2019	56.71	68.38	5.19	10.37	17.28
09/24/2019	82.79	131.06	11.51	22.99	38.34
09/25/2019	33.98	128.33	12.36	24.69	41.13
09/26/2019	44.70	124.85	11.84	23.67	39.36
09/27/2019	29.32	76.81	7.20	14.44	24.12
09/28/2019	0.00	0.00	0.00	0.00	0.00
09/29/2019	0.00	0.00	0.00	0.00	0.00
09/30/2019	104.05	60.53	3.27	6.56	10.91
Monthly Avg/Sum*:	669.85 *	1,103.59 *	94.37 *	188.77 *	314.53 *
Daily Min:	21.23	15.30	0.24	0.48	0.80
Daily Max:	104.05	133.96	12.64	25.30	42.16
Jul 2019 - Sep 2019	1,555.42	4,033.48	369.05	738.48	1,230.52
QTD:	1,555.42 *	4,033.48 *	369.05 *	738.48 *	1,230.52 *
YTD 2019:	4,480.17 *	12,319.94 *	1,146.21 *	2,293.73 *	3,822.66 *

Monthly Summary By Day Report

Unit CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:09 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
07/01/2019	0.00	0.00	0.0	0.00	0.00
07/02/2019	0.00	0.00	0.0	0.00	0.00
07/03/2019	0.00	0.00	0.0	0.00	0.00
07/04/2019	0.00	0.00	0.0	0.00	0.00
07/05/2019	0.00	0.00	0.0	0.00	0.00
07/06/2019	0.00	0.00	0.0	0.00	0.00
07/07/2019	0.00	0.00	0.0	0.00	0.00
07/08/2019	0.00	0.00	0.0	0.00	0.00
07/09/2019	0.00	0.00	0.0	0.00	0.00
07/10/2019	0.00	0.00	0.0	0.00	0.00
07/11/2019	0.00	0.00	0.0	0.00	0.00
07/12/2019	0.00	0.00	0.0	0.00	0.00
07/13/2019	0.00	0.00	0.0	0.00	0.00
07/14/2019	0.00	0.00	0.0	0.00	0.00
07/15/2019	0.00	0.00	0.0	0.00	0.00
07/16/2019	0.00	0.00	0.0	0.00	0.00
07/17/2019	0.00	0.00	0.0	0.00	0.00
07/18/2019	0.00	0.00	0.0	0.00	0.00
07/19/2019	0.00	0.00	0.0	0.00	0.00
07/20/2019	0.00	0.00	0.0	0.00	0.00
07/21/2019	0.00	0.00	0.0	0.00	0.00
07/22/2019	0.00	0.00	0.0	0.00	0.00
07/23/2019	6.04	60.94	6.3	12.25	20.40
07/24/2019	7.40	93.50	9.5	17.98	29.95
07/25/2019	15.45	79.03	8.0	15.23	25.36
07/26/2019	14.85	80.58	8.1	15.52	25.86
07/27/2019	19.18	69.81	6.7	13.32	22.22
07/28/2019	14.15	69.98	7.0	13.38	22.32
07/29/2019	14.21	75.00	7.1	14.32	23.87
07/30/2019	15.16	52.19	5.0	9.96	16.59
07/31/2019	13.28	57.69	5.4	11.02	18.35
Monthly Avg/Sum*:	119.72 *	638.72 *	63.1 *	122.98 *	204.92 *
Daily Min:	6.04	52.19	5.0	9.96	16.59
Daily Max:	19.18	93.50	9.5	17.98	29.95
Jul 2019 - Jul 2019	119.72	638.72	63.1	122.98	204.92
QTD:	119.72 *	638.72 *	63.1 *	122.98 *	204.92 *
YTD 2019:	1,186.64 *	4,270.44 *	420.9 *	808.56 *	1,347.26 *

Monthly Summary By Day Report

Unit CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:09 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
08/01/2019	14.27	53.57	5.6	10.26	17.09
08/02/2019	13.54	55.70	5.8	10.66	17.81
08/03/2019	13.37	59.61	6.0	11.45	19.06
08/04/2019	11.76	62.65	6.1	12.00	20.01
08/05/2019	10.77	54.50	5.9	11.19	18.62
08/06/2019	12.63	61.39	6.3	11.79	19.60
08/07/2019	12.38	58.63	5.8	11.21	18.61
08/08/2019	16.84	10.41	1.0	1.79	2.97
08/09/2019	0.00	0.00	0.0	0.00	0.00
08/10/2019	0.00	0.00	0.0	0.00	0.00
08/11/2019	0.00	0.00	0.0	0.00	0.00
08/12/2019	0.00	0.00	0.0	0.00	0.00
08/13/2019	31.38	63.44	5.1	10.24	17.09
08/14/2019	14.07	69.26	7.0	13.35	22.27
08/15/2019	13.24	62.56	6.3	12.12	20.23
08/16/2019	11.56	65.54	6.3	12.67	21.06
08/17/2019	21.76	63.82	5.8	12.01	20.00
08/18/2019	0.00	0.00	0.0	0.00	0.00
08/19/2019	0.00	0.00	0.0	0.00	0.00
08/20/2019	0.00	0.00	0.0	0.00	0.00
08/21/2019	0.00	0.00	0.0	0.00	0.00
08/22/2019	0.00	0.00	0.0	0.00	0.00
08/23/2019	0.00	0.00	0.0	0.00	0.00
08/24/2019	0.00	0.00	0.0	0.00	0.00
08/25/2019	0.00	0.00	0.0	0.00	0.00
08/26/2019	0.00	0.00	0.0	0.00	0.00
08/27/2019	38.21	62.38	5.1	9.80	16.34
08/28/2019	10.26	73.78	7.4	14.17	23.64
08/29/2019	27.47	61.20	5.7	11.53	19.23
08/30/2019	0.00	0.00	0.0	0.00	0.00
08/31/2019	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	273.51 *	938.44 *	91.2 *	176.24 *	293.63 *
Daily Min:	10.26	10.41	1.0	1.79	2.97
Daily Max:	38.21	73.78	7.4	14.17	23.64
Jul 2019 - Aug 2019	393.23	1,577.16	154.3	299.22	498.55
QTD:	393.23 *	1,577.16 *	154.3 *	299.22 *	498.55 *
YTD 2019:	1,460.15 *	5,208.88 *	512.1 *	984.80 *	1,640.89 *

Monthly Summary By Day Report

Unit CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:09 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
09/01/2019	0.00	0.00	0.0	0.00	0.00
09/02/2019	0.00	0.00	0.0	0.00	0.00
09/03/2019	0.00	0.00	0.0	0.00	0.00
09/04/2019	42.25	62.31	4.7	10.02	16.67
09/05/2019	20.86	63.50	5.9	12.08	20.11
09/06/2019	0.00	0.00	0.0	0.00	0.00
09/07/2019	0.00	0.00	0.0	0.00	0.00
09/08/2019	0.00	0.00	0.0	0.00	0.00
09/09/2019	0.00	0.00	0.0	0.00	0.00
09/10/2019	0.00	0.00	0.0	0.00	0.00
09/11/2019	39.47	49.95	3.6	7.63	12.70
09/12/2019	20.90	28.26	2.6	5.16	8.58
09/13/2019	0.00	0.00	0.0	0.00	0.00
09/14/2019	0.00	0.00	0.0	0.00	0.00
09/15/2019	0.00	0.00	0.0	0.00	0.00
09/16/2019	0.00	0.00	0.0	0.00	0.00
09/17/2019	0.00	0.00	0.0	0.00	0.00
09/18/2019	0.00	0.00	0.0	0.00	0.00
09/19/2019	0.00	0.00	0.0	0.00	0.00
09/20/2019	0.00	0.00	0.0	0.00	0.00
09/21/2019	0.00	0.00	0.0	0.00	0.00
09/22/2019	0.00	0.00	0.0	0.00	0.00
09/23/2019	0.00	0.00	0.0	0.00	0.00
09/24/2019	54.53	55.46	4.3	8.58	14.32
09/25/2019	13.43	61.12	6.3	11.84	19.69
09/26/2019	22.82	59.30	5.8	11.16	18.54
09/27/2019	0.00	0.00	0.0	0.00	0.00
09/28/2019	0.00	0.00	0.0	0.00	0.00
09/29/2019	0.00	0.00	0.0	0.00	0.00
09/30/2019	48.79	25.30	1.4	2.59	4.31
Monthly Avg/Sum*:	263.05 *	405.20 *	34.6 *	69.06 *	114.92 *
Daily Min:	13.43	25.30	1.4	2.59	4.31
Daily Max:	54.53	63.50	6.3	12.08	20.11
Jul 2019 - Sep 2019	656.28	1,982.36	188.9	368.28	613.47
QTD:	656.28 *	1,982.36 *	188.9 *	368.28 *	613.47 *
YTD 2019:	1,723.20 *	5,614.08 *	546.7 *	1,053.86 *	1,755.81 *

Monthly Summary By Day Report

Unit CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:08 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
07/01/2019	0.00	0.00	0.0	0.00	0.00
07/02/2019	0.00	0.00	0.0	0.00	0.00
07/03/2019	0.00	0.00	0.0	0.00	0.00
07/04/2019	0.00	0.00	0.0	0.00	0.00
07/05/2019	0.00	0.00	0.0	0.00	0.00
07/06/2019	0.00	0.00	0.0	0.00	0.00
07/07/2019	0.00	0.00	0.0	0.00	0.00
07/08/2019	0.00	0.00	0.0	0.00	0.00
07/09/2019	0.00	0.00	0.0	0.00	0.00
07/10/2019	0.00	0.00	0.0	0.00	0.00
07/11/2019	0.00	0.00	0.0	0.00	0.00
07/12/2019	0.00	0.00	0.0	0.00	0.00
07/13/2019	0.00	0.00	0.0	0.00	0.00
07/14/2019	0.00	0.00	0.0	0.00	0.00
07/15/2019	0.00	0.00	0.0	0.00	0.00
07/16/2019	0.00	0.00	0.0	0.00	0.00
07/17/2019	0.00	0.00	0.0	0.00	0.00
07/18/2019	0.00	0.00	0.0	0.00	0.00
07/19/2019	0.00	0.00	0.0	0.00	0.00
07/20/2019	0.00	0.00	0.0	0.00	0.00
07/21/2019	0.00	0.00	0.0	0.00	0.00
07/22/2019	27.81	37.22	2.3	4.96	8.30
07/23/2019	19.35	30.89	2.8	5.74	9.61
07/24/2019	0.00	0.00	0.0	0.00	0.00
07/25/2019	0.00	0.00	0.0	0.00	0.00
07/26/2019	0.00	0.00	0.0	0.00	0.00
07/27/2019	22.90	14.03	0.2	0.51	0.85
07/28/2019	17.71	74.39	7.1	14.23	23.73
07/29/2019	18.43	79.66	8.0	15.24	25.39
07/30/2019	19.80	58.86	5.5	11.23	18.73
07/31/2019	16.04	62.20	6.0	11.87	19.80
Monthly Avg/Sum*:	142.04 *	357.25 *	31.9 *	63.78 *	106.41 *
Daily Min:	16.04	14.03	0.2	0.51	0.85
Daily Max:	27.81	79.66	8.0	15.24	25.39
Jul 2019 - Jul 2019	142.04	357.25	31.9	63.78	106.41
QTD:	142.04 *	357.25 *	31.9 *	63.78 *	106.41 *
YTD 2019:	1,990.40 *	5,011.99 *	471.4 *	933.45 *	1,556.21 *

Monthly Summary By Day Report

Unit CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:08 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
08/01/2019	18.01	59.15	5.7	11.28	18.78
08/02/2019	16.56	60.54	5.8	11.56	19.19
08/03/2019	16.46	64.49	6.1	12.32	20.51
08/04/2019	15.50	68.46	6.6	12.97	21.59
08/05/2019	14.39	57.26	6.3	12.09	20.14
08/06/2019	17.47	66.02	6.4	12.64	21.06
08/07/2019	18.09	63.30	6.0	12.03	20.05
08/08/2019	14.61	11.14	1.0	1.97	3.26
08/09/2019	0.00	0.00	0.0	0.00	0.00
08/10/2019	0.00	0.00	0.0	0.00	0.00
08/11/2019	0.00	0.00	0.0	0.00	0.00
08/12/2019	0.00	0.00	0.0	0.00	0.00
08/13/2019	0.00	0.00	0.0	0.00	0.00
08/14/2019	42.85	60.42	4.8	9.49	15.82
08/15/2019	18.07	67.19	6.6	13.06	21.71
08/16/2019	26.61	67.39	6.4	12.71	21.21
08/17/2019	0.00	0.00	0.0	0.00	0.00
08/18/2019	0.00	0.00	0.0	0.00	0.00
08/19/2019	0.00	0.00	0.0	0.00	0.00
08/20/2019	0.00	0.00	0.0	0.00	0.00
08/21/2019	0.00	0.00	0.0	0.00	0.00
08/22/2019	0.00	0.00	0.0	0.00	0.00
08/23/2019	0.00	0.00	0.0	0.00	0.00
08/24/2019	0.00	0.00	0.0	0.00	0.00
08/25/2019	38.98	65.25	5.3	10.44	17.38
08/26/2019	20.39	68.80	6.4	13.08	21.82
08/27/2019	19.15	69.58	6.5	13.36	22.27
08/28/2019	15.50	79.66	7.5	15.20	25.37
08/29/2019	33.52	66.83	6.3	12.51	20.87
08/30/2019	0.00	0.00	0.0	0.00	0.00
08/31/2019	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	346.16 *	995.48 *	93.7 *	186.71 *	311.03 *
Daily Min:	14.39	11.14	1.0	1.97	3.26
Daily Max:	42.85	79.66	7.5	15.20	25.37
Jul 2019 - Aug 2019	488.20	1,352.73	125.6	250.49	417.44
QTD:	488.20 *	1,352.73 *	125.6 *	250.49 *	417.44 *
YTD 2019:	2,336.56 *	6,007.47 *	565.1 *	1,120.16 *	1,867.24 *

Monthly Summary By Day Report

Unit CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:08 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
09/01/2019	0.00	0.00	0.0	0.00	0.00
09/02/2019	0.00	0.00	0.0	0.00	0.00
09/03/2019	0.00	0.00	0.0	0.00	0.00
09/04/2019	42.58	65.89	5.2	10.16	16.95
09/05/2019	33.45	70.46	6.5	13.22	22.05
09/06/2019	0.00	0.00	0.0	0.00	0.00
09/07/2019	0.00	0.00	0.0	0.00	0.00
09/08/2019	0.00	0.00	0.0	0.00	0.00
09/09/2019	26.06	15.30	0.2	0.48	0.80
09/10/2019	21.23	68.35	6.5	13.13	21.90
09/11/2019	24.37	29.43	2.6	5.24	8.74
09/12/2019	47.13	60.18	4.5	8.93	14.89
09/13/2019	0.00	0.00	0.0	0.00	0.00
09/14/2019	0.00	0.00	0.0	0.00	0.00
09/15/2019	0.00	0.00	0.0	0.00	0.00
09/16/2019	0.00	0.00	0.0	0.00	0.00
09/17/2019	0.00	0.00	0.0	0.00	0.00
09/18/2019	0.00	0.00	0.0	0.00	0.00
09/19/2019	0.00	0.00	0.0	0.00	0.00
09/20/2019	0.00	0.00	0.0	0.00	0.00
09/21/2019	0.00	0.00	0.0	0.00	0.00
09/22/2019	0.00	0.00	0.0	0.00	0.00
09/23/2019	56.71	68.38	5.5	10.37	17.28
09/24/2019	28.26	75.60	7.4	14.41	24.02
09/25/2019	20.55	67.21	6.7	12.85	21.44
09/26/2019	21.88	65.55	6.1	12.51	20.82
09/27/2019	29.32	76.81	7.1	14.44	24.12
09/28/2019	0.00	0.00	0.0	0.00	0.00
09/29/2019	0.00	0.00	0.0	0.00	0.00
09/30/2019	55.26	35.23	2.0	3.97	6.60
Monthly Avg/Sum*:	406.80 *	698.39 *	60.3 *	119.71 *	199.61 *
Daily Min:	20.55	15.30	0.2	0.48	0.80
Daily Max:	56.71	76.81	7.4	14.44	24.12
Jul 2019 - Sep 2019	895.00	2,051.12	185.9	370.20	617.05
QTD:	895.00 *	2,051.12 *	185.9 *	370.20 *	617.05 *
YTD 2019:	2,743.36 *	6,705.86 *	625.4 *	1,239.87 *	2,066.85 *

ATTACHMENT 18

AQ-60

AQ-60 If the Alstom GTX100 turbine are selected, the quarterly emissions shall not exceed the levels shown below:

Alstom GTX100 Gas Turbines					
Pollutant	Quarter 1 (lbs/quarter) Two turbines	Quarter 2 (lbs/quarter) Two Turbines	Quarter 3 (lbs/quarter) Two turbines	Quarter 4 (lbs/quarter) Two Turbines	Tons/ Year Two Turbines
NOx	15,399	12,965	17,496	15,422	30.64
CO	26,787	32,590	28,175	29,862	58.71
VOCs	5,791	7,306	6,630	6,848	13.29
PM0	16,300	13,692	17,789	17,569	32.67
SOx	3,385	2,843	3,694	3,648	6.78

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emission limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:01 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
07/01/2019	0.00	0.00	0.00	0.00	0.00
07/02/2019	0.00	0.00	0.00	0.00	0.00
07/03/2019	0.00	0.00	0.00	0.00	0.00
07/04/2019	0.00	0.00	0.00	0.00	0.00
07/05/2019	0.00	0.00	0.00	0.00	0.00
07/06/2019	0.00	0.00	0.00	0.00	0.00
07/07/2019	0.00	0.00	0.00	0.00	0.00
07/08/2019	0.00	0.00	0.00	0.00	0.00
07/09/2019	0.00	0.00	0.00	0.00	0.00
07/10/2019	0.00	0.00	0.00	0.00	0.00
07/11/2019	0.00	0.00	0.00	0.00	0.00
07/12/2019	0.00	0.00	0.00	0.00	0.00
07/13/2019	0.00	0.00	0.00	0.00	0.00
07/14/2019	0.00	0.00	0.00	0.00	0.00
07/15/2019	0.00	0.00	0.00	0.00	0.00
07/16/2019	0.00	0.00	0.00	0.00	0.00
07/17/2019	0.00	0.00	0.00	0.00	0.00
07/18/2019	0.00	0.00	0.00	0.00	0.00
07/19/2019	0.00	0.00	0.00	0.00	0.00
07/20/2019	0.00	0.00	0.00	0.00	0.00
07/21/2019	0.00	0.00	0.00	0.00	0.00
07/22/2019	27.81	37.22	2.49	4.96	8.30
07/23/2019	29.53	91.83	8.98	17.99	30.01
07/24/2019	7.40	93.50	8.98	17.98	29.95
07/25/2019	15.45	79.03	7.60	15.23	25.36
07/26/2019	14.85	80.58	7.75	15.52	25.86
07/27/2019	42.08	83.84	6.91	13.83	23.07
07/28/2019	31.86	144.37	13.84	27.61	46.05
07/29/2019	32.64	154.66	14.79	29.56	49.26
07/30/2019	34.96	111.05	10.60	21.19	35.32
07/31/2019	29.32	119.89	11.42	22.89	38.15
Monthly Avg/Sum*:	265.90 *	995.97 *	93.36 *	186.76 *	311.33 *
Daily Min:	7.40	37.22	2.49	4.96	8.30
Daily Max:	42.08	154.66	14.79	29.56	49.26
Jul 2019 - Jul 2019	265.90	995.97	93.36	186.76	311.33
QTD:	265.90 *	995.97 *	93.36 *	186.76 *	311.33 *
YTD 2019:	3,190.65 *	9,282.43 *	870.52 *	1,742.01 *	2,903.47 *

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:01 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
08/01/2019	32.28	112.72	10.75	21.54	35.87
08/02/2019	30.10	116.24	11.12	22.22	37.00
08/03/2019	29.83	124.10	11.85	23.77	39.57
08/04/2019	27.26	131.11	12.51	24.97	41.60
08/05/2019	25.16	111.76	11.62	23.28	38.76
08/06/2019	30.10	127.41	12.19	24.43	40.66
08/07/2019	30.47	121.93	11.59	23.24	38.66
08/08/2019	31.45	21.55	1.87	3.76	6.23
08/09/2019	0.00	0.00	0.00	0.00	0.00
08/10/2019	0.00	0.00	0.00	0.00	0.00
08/11/2019	0.00	0.00	0.00	0.00	0.00
08/12/2019	0.00	0.00	0.00	0.00	0.00
08/13/2019	31.38	63.44	5.12	10.24	17.09
08/14/2019	56.92	129.68	11.42	22.84	38.09
08/15/2019	31.31	129.75	12.57	25.18	41.94
08/16/2019	38.17	132.93	12.67	25.38	42.27
08/17/2019	21.76	63.82	5.98	12.01	20.00
08/18/2019	0.00	0.00	0.00	0.00	0.00
08/19/2019	0.00	0.00	0.00	0.00	0.00
08/20/2019	0.00	0.00	0.00	0.00	0.00
08/21/2019	0.00	0.00	0.00	0.00	0.00
08/22/2019	0.00	0.00	0.00	0.00	0.00
08/23/2019	0.00	0.00	0.00	0.00	0.00
08/24/2019	0.00	0.00	0.00	0.00	0.00
08/25/2019	38.98	65.25	5.20	10.44	17.38
08/26/2019	20.39	68.80	6.54	13.08	21.82
08/27/2019	57.36	131.96	11.59	23.16	38.61
08/28/2019	25.76	153.44	14.70	29.37	49.01
08/29/2019	60.99	128.03	12.03	24.04	40.10
08/30/2019	0.00	0.00	0.00	0.00	0.00
08/31/2019	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	619.67 *	1,933.92 *	181.32 *	362.95 *	604.66 *
Daily Min:	20.39	21.55	1.87	3.76	6.23
Daily Max:	60.99	153.44	14.70	29.37	49.01
Jul 2019 - Aug 2019	885.57	2,929.89	274.68	549.71	915.99
QTD:	885.57 *	2,929.89 *	274.68 *	549.71 *	915.99 *
YTD 2019:	3,810.32 *	11,216.35 *	1,051.84 *	2,104.96 *	3,508.13 *

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:01 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
09/01/2019	0.00	0.00	0.00	0.00	0.00
09/02/2019	0.00	0.00	0.00	0.00	0.00
09/03/2019	0.00	0.00	0.00	0.00	0.00
09/04/2019	84.83	128.20	10.09	20.18	33.62
09/05/2019	54.31	133.96	12.64	25.30	42.16
09/06/2019	0.00	0.00	0.00	0.00	0.00
09/07/2019	0.00	0.00	0.00	0.00	0.00
09/08/2019	0.00	0.00	0.00	0.00	0.00
09/09/2019	26.06	15.30	0.24	0.48	0.80
09/10/2019	21.23	68.35	6.57	13.13	21.90
09/11/2019	63.84	79.38	6.42	12.87	21.44
09/12/2019	68.03	88.44	7.04	14.09	23.47
09/13/2019	0.00	0.00	0.00	0.00	0.00
09/14/2019	0.00	0.00	0.00	0.00	0.00
09/15/2019	0.00	0.00	0.00	0.00	0.00
09/16/2019	0.00	0.00	0.00	0.00	0.00
09/17/2019	0.00	0.00	0.00	0.00	0.00
09/18/2019	0.00	0.00	0.00	0.00	0.00
09/19/2019	0.00	0.00	0.00	0.00	0.00
09/20/2019	0.00	0.00	0.00	0.00	0.00
09/21/2019	0.00	0.00	0.00	0.00	0.00
09/22/2019	0.00	0.00	0.00	0.00	0.00
09/23/2019	56.71	68.38	5.19	10.37	17.28
09/24/2019	82.79	131.06	11.51	22.99	38.34
09/25/2019	33.98	128.33	12.36	24.69	41.13
09/26/2019	44.70	124.85	11.84	23.67	39.36
09/27/2019	29.32	76.81	7.20	14.44	24.12
09/28/2019	0.00	0.00	0.00	0.00	0.00
09/29/2019	0.00	0.00	0.00	0.00	0.00
09/30/2019	104.05	60.53	3.27	6.56	10.91
Monthly Avg/Sum*:	669.85 *	1,103.59 *	94.37 *	188.77 *	314.53 *
Daily Min:	21.23	15.30	0.24	0.48	0.80
Daily Max:	104.05	133.96	12.64	25.30	42.16
Jul 2019 - Sep 2019	1,555.42	4,033.48	369.05	738.48	1,230.52
QTD:	1,555.42 *	4,033.48 *	369.05 *	738.48 *	1,230.52 *
YTD 2019:	4,480.17 *	12,319.94 *	1,146.21 *	2,293.73 *	3,822.66 *

Monthly Summary By Day Report

Unit CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:09 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
07/01/2019	0.00	0.00	0.0	0.00	0.00
07/02/2019	0.00	0.00	0.0	0.00	0.00
07/03/2019	0.00	0.00	0.0	0.00	0.00
07/04/2019	0.00	0.00	0.0	0.00	0.00
07/05/2019	0.00	0.00	0.0	0.00	0.00
07/06/2019	0.00	0.00	0.0	0.00	0.00
07/07/2019	0.00	0.00	0.0	0.00	0.00
07/08/2019	0.00	0.00	0.0	0.00	0.00
07/09/2019	0.00	0.00	0.0	0.00	0.00
07/10/2019	0.00	0.00	0.0	0.00	0.00
07/11/2019	0.00	0.00	0.0	0.00	0.00
07/12/2019	0.00	0.00	0.0	0.00	0.00
07/13/2019	0.00	0.00	0.0	0.00	0.00
07/14/2019	0.00	0.00	0.0	0.00	0.00
07/15/2019	0.00	0.00	0.0	0.00	0.00
07/16/2019	0.00	0.00	0.0	0.00	0.00
07/17/2019	0.00	0.00	0.0	0.00	0.00
07/18/2019	0.00	0.00	0.0	0.00	0.00
07/19/2019	0.00	0.00	0.0	0.00	0.00
07/20/2019	0.00	0.00	0.0	0.00	0.00
07/21/2019	0.00	0.00	0.0	0.00	0.00
07/22/2019	0.00	0.00	0.0	0.00	0.00
07/23/2019	6.04	60.94	6.3	12.25	20.40
07/24/2019	7.40	93.50	9.5	17.98	29.95
07/25/2019	15.45	79.03	8.0	15.23	25.36
07/26/2019	14.85	80.58	8.1	15.52	25.86
07/27/2019	19.18	69.81	6.7	13.32	22.22
07/28/2019	14.15	69.98	7.0	13.38	22.32
07/29/2019	14.21	75.00	7.1	14.32	23.87
07/30/2019	15.16	52.19	5.0	9.96	16.59
07/31/2019	13.28	57.69	5.4	11.02	18.35
Monthly Avg/Sum*:	119.72 *	638.72 *	63.1 *	122.98 *	204.92 *
Daily Min:	6.04	52.19	5.0	9.96	16.59
Daily Max:	19.18	93.50	9.5	17.98	29.95
Jul 2019 - Jul 2019	119.72	638.72	63.1	122.98	204.92
QTD:	119.72 *	638.72 *	63.1 *	122.98 *	204.92 *
YTD 2019:	1,186.64 *	4,270.44 *	420.9 *	808.56 *	1,347.26 *

Monthly Summary By Day Report

Unit CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:09 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
08/01/2019	14.27	53.57	5.6	10.26	17.09
08/02/2019	13.54	55.70	5.8	10.66	17.81
08/03/2019	13.37	59.61	6.0	11.45	19.06
08/04/2019	11.76	62.65	6.1	12.00	20.01
08/05/2019	10.77	54.50	5.9	11.19	18.62
08/06/2019	12.63	61.39	6.3	11.79	19.60
08/07/2019	12.38	58.63	5.8	11.21	18.61
08/08/2019	16.84	10.41	1.0	1.79	2.97
08/09/2019	0.00	0.00	0.0	0.00	0.00
08/10/2019	0.00	0.00	0.0	0.00	0.00
08/11/2019	0.00	0.00	0.0	0.00	0.00
08/12/2019	0.00	0.00	0.0	0.00	0.00
08/13/2019	31.38	63.44	5.1	10.24	17.09
08/14/2019	14.07	69.26	7.0	13.35	22.27
08/15/2019	13.24	62.56	6.3	12.12	20.23
08/16/2019	11.56	65.54	6.3	12.67	21.06
08/17/2019	21.76	63.82	5.8	12.01	20.00
08/18/2019	0.00	0.00	0.0	0.00	0.00
08/19/2019	0.00	0.00	0.0	0.00	0.00
08/20/2019	0.00	0.00	0.0	0.00	0.00
08/21/2019	0.00	0.00	0.0	0.00	0.00
08/22/2019	0.00	0.00	0.0	0.00	0.00
08/23/2019	0.00	0.00	0.0	0.00	0.00
08/24/2019	0.00	0.00	0.0	0.00	0.00
08/25/2019	0.00	0.00	0.0	0.00	0.00
08/26/2019	0.00	0.00	0.0	0.00	0.00
08/27/2019	38.21	62.38	5.1	9.80	16.34
08/28/2019	10.26	73.78	7.4	14.17	23.64
08/29/2019	27.47	61.20	5.7	11.53	19.23
08/30/2019	0.00	0.00	0.0	0.00	0.00
08/31/2019	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	273.51 *	938.44 *	91.2 *	176.24 *	293.63 *
Daily Min:	10.26	10.41	1.0	1.79	2.97
Daily Max:	38.21	73.78	7.4	14.17	23.64
Jul 2019 - Aug 2019	393.23	1,577.16	154.3	299.22	498.55
QTD:	393.23 *	1,577.16 *	154.3 *	299.22 *	498.55 *
YTD 2019:	1,460.15 *	5,208.88 *	512.1 *	984.80 *	1,640.89 *

Monthly Summary By Day Report

Unit CT1

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:09 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
09/01/2019	0.00	0.00	0.0	0.00	0.00
09/02/2019	0.00	0.00	0.0	0.00	0.00
09/03/2019	0.00	0.00	0.0	0.00	0.00
09/04/2019	42.25	62.31	4.7	10.02	16.67
09/05/2019	20.86	63.50	5.9	12.08	20.11
09/06/2019	0.00	0.00	0.0	0.00	0.00
09/07/2019	0.00	0.00	0.0	0.00	0.00
09/08/2019	0.00	0.00	0.0	0.00	0.00
09/09/2019	0.00	0.00	0.0	0.00	0.00
09/10/2019	0.00	0.00	0.0	0.00	0.00
09/11/2019	39.47	49.95	3.6	7.63	12.70
09/12/2019	20.90	28.26	2.6	5.16	8.58
09/13/2019	0.00	0.00	0.0	0.00	0.00
09/14/2019	0.00	0.00	0.0	0.00	0.00
09/15/2019	0.00	0.00	0.0	0.00	0.00
09/16/2019	0.00	0.00	0.0	0.00	0.00
09/17/2019	0.00	0.00	0.0	0.00	0.00
09/18/2019	0.00	0.00	0.0	0.00	0.00
09/19/2019	0.00	0.00	0.0	0.00	0.00
09/20/2019	0.00	0.00	0.0	0.00	0.00
09/21/2019	0.00	0.00	0.0	0.00	0.00
09/22/2019	0.00	0.00	0.0	0.00	0.00
09/23/2019	0.00	0.00	0.0	0.00	0.00
09/24/2019	54.53	55.46	4.3	8.58	14.32
09/25/2019	13.43	61.12	6.3	11.84	19.69
09/26/2019	22.82	59.30	5.8	11.16	18.54
09/27/2019	0.00	0.00	0.0	0.00	0.00
09/28/2019	0.00	0.00	0.0	0.00	0.00
09/29/2019	0.00	0.00	0.0	0.00	0.00
09/30/2019	48.79	25.30	1.4	2.59	4.31
Monthly Avg/Sum*:	263.05 *	405.20 *	34.6 *	69.06 *	114.92 *
Daily Min:	13.43	25.30	1.4	2.59	4.31
Daily Max:	54.53	63.50	6.3	12.08	20.11
Jul 2019 - Sep 2019	656.28	1,982.36	188.9	368.28	613.47
QTD:	656.28 *	1,982.36 *	188.9 *	368.28 *	613.47 *
YTD 2019:	1,723.20 *	5,614.08 *	546.7 *	1,053.86 *	1,755.81 *

Monthly Summary By Day Report

Unit CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:08 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
07/01/2019	0.00	0.00	0.0	0.00	0.00
07/02/2019	0.00	0.00	0.0	0.00	0.00
07/03/2019	0.00	0.00	0.0	0.00	0.00
07/04/2019	0.00	0.00	0.0	0.00	0.00
07/05/2019	0.00	0.00	0.0	0.00	0.00
07/06/2019	0.00	0.00	0.0	0.00	0.00
07/07/2019	0.00	0.00	0.0	0.00	0.00
07/08/2019	0.00	0.00	0.0	0.00	0.00
07/09/2019	0.00	0.00	0.0	0.00	0.00
07/10/2019	0.00	0.00	0.0	0.00	0.00
07/11/2019	0.00	0.00	0.0	0.00	0.00
07/12/2019	0.00	0.00	0.0	0.00	0.00
07/13/2019	0.00	0.00	0.0	0.00	0.00
07/14/2019	0.00	0.00	0.0	0.00	0.00
07/15/2019	0.00	0.00	0.0	0.00	0.00
07/16/2019	0.00	0.00	0.0	0.00	0.00
07/17/2019	0.00	0.00	0.0	0.00	0.00
07/18/2019	0.00	0.00	0.0	0.00	0.00
07/19/2019	0.00	0.00	0.0	0.00	0.00
07/20/2019	0.00	0.00	0.0	0.00	0.00
07/21/2019	0.00	0.00	0.0	0.00	0.00
07/22/2019	27.81	37.22	2.3	4.96	8.30
07/23/2019	19.35	30.89	2.8	5.74	9.61
07/24/2019	0.00	0.00	0.0	0.00	0.00
07/25/2019	0.00	0.00	0.0	0.00	0.00
07/26/2019	0.00	0.00	0.0	0.00	0.00
07/27/2019	22.90	14.03	0.2	0.51	0.85
07/28/2019	17.71	74.39	7.1	14.23	23.73
07/29/2019	18.43	79.66	8.0	15.24	25.39
07/30/2019	19.80	58.86	5.5	11.23	18.73
07/31/2019	16.04	62.20	6.0	11.87	19.80
Monthly Avg/Sum*:	142.04 *	357.25 *	31.9 *	63.78 *	106.41 *
Daily Min:	16.04	14.03	0.2	0.51	0.85
Daily Max:	27.81	79.66	8.0	15.24	25.39
Jul 2019 - Jul 2019	142.04	357.25	31.9	63.78	106.41
QTD:	142.04 *	357.25 *	31.9 *	63.78 *	106.41 *
YTD 2019:	1,990.40 *	5,011.99 *	471.4 *	933.45 *	1,556.21 *

Monthly Summary By Day Report

Unit CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:08 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
08/01/2019	18.01	59.15	5.7	11.28	18.78
08/02/2019	16.56	60.54	5.8	11.56	19.19
08/03/2019	16.46	64.49	6.1	12.32	20.51
08/04/2019	15.50	68.46	6.6	12.97	21.59
08/05/2019	14.39	57.26	6.3	12.09	20.14
08/06/2019	17.47	66.02	6.4	12.64	21.06
08/07/2019	18.09	63.30	6.0	12.03	20.05
08/08/2019	14.61	11.14	1.0	1.97	3.26
08/09/2019	0.00	0.00	0.0	0.00	0.00
08/10/2019	0.00	0.00	0.0	0.00	0.00
08/11/2019	0.00	0.00	0.0	0.00	0.00
08/12/2019	0.00	0.00	0.0	0.00	0.00
08/13/2019	0.00	0.00	0.0	0.00	0.00
08/14/2019	42.85	60.42	4.8	9.49	15.82
08/15/2019	18.07	67.19	6.6	13.06	21.71
08/16/2019	26.61	67.39	6.4	12.71	21.21
08/17/2019	0.00	0.00	0.0	0.00	0.00
08/18/2019	0.00	0.00	0.0	0.00	0.00
08/19/2019	0.00	0.00	0.0	0.00	0.00
08/20/2019	0.00	0.00	0.0	0.00	0.00
08/21/2019	0.00	0.00	0.0	0.00	0.00
08/22/2019	0.00	0.00	0.0	0.00	0.00
08/23/2019	0.00	0.00	0.0	0.00	0.00
08/24/2019	0.00	0.00	0.0	0.00	0.00
08/25/2019	38.98	65.25	5.3	10.44	17.38
08/26/2019	20.39	68.80	6.4	13.08	21.82
08/27/2019	19.15	69.58	6.5	13.36	22.27
08/28/2019	15.50	79.66	7.5	15.20	25.37
08/29/2019	33.52	66.83	6.3	12.51	20.87
08/30/2019	0.00	0.00	0.0	0.00	0.00
08/31/2019	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	346.16 *	995.48 *	93.7 *	186.71 *	311.03 *
Daily Min:	14.39	11.14	1.0	1.97	3.26
Daily Max:	42.85	79.66	7.5	15.20	25.37
Jul 2019 - Aug 2019	488.20	1,352.73	125.6	250.49	417.44
QTD:	488.20 *	1,352.73 *	125.6 *	250.49 *	417.44 *
YTD 2019:	2,336.56 *	6,007.47 *	565.1 *	1,120.16 *	1,867.24 *

Monthly Summary By Day Report

Unit CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:08 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
09/01/2019	0.00	0.00	0.0	0.00	0.00
09/02/2019	0.00	0.00	0.0	0.00	0.00
09/03/2019	0.00	0.00	0.0	0.00	0.00
09/04/2019	42.58	65.89	5.2	10.16	16.95
09/05/2019	33.45	70.46	6.5	13.22	22.05
09/06/2019	0.00	0.00	0.0	0.00	0.00
09/07/2019	0.00	0.00	0.0	0.00	0.00
09/08/2019	0.00	0.00	0.0	0.00	0.00
09/09/2019	26.06	15.30	0.2	0.48	0.80
09/10/2019	21.23	68.35	6.5	13.13	21.90
09/11/2019	24.37	29.43	2.6	5.24	8.74
09/12/2019	47.13	60.18	4.5	8.93	14.89
09/13/2019	0.00	0.00	0.0	0.00	0.00
09/14/2019	0.00	0.00	0.0	0.00	0.00
09/15/2019	0.00	0.00	0.0	0.00	0.00
09/16/2019	0.00	0.00	0.0	0.00	0.00
09/17/2019	0.00	0.00	0.0	0.00	0.00
09/18/2019	0.00	0.00	0.0	0.00	0.00
09/19/2019	0.00	0.00	0.0	0.00	0.00
09/20/2019	0.00	0.00	0.0	0.00	0.00
09/21/2019	0.00	0.00	0.0	0.00	0.00
09/22/2019	0.00	0.00	0.0	0.00	0.00
09/23/2019	56.71	68.38	5.5	10.37	17.28
09/24/2019	28.26	75.60	7.4	14.41	24.02
09/25/2019	20.55	67.21	6.7	12.85	21.44
09/26/2019	21.88	65.55	6.1	12.51	20.82
09/27/2019	29.32	76.81	7.1	14.44	24.12
09/28/2019	0.00	0.00	0.0	0.00	0.00
09/29/2019	0.00	0.00	0.0	0.00	0.00
09/30/2019	55.26	35.23	2.0	3.97	6.60
Monthly Avg/Sum*:	406.80 *	698.39 *	60.3 *	119.71 *	199.61 *
Daily Min:	20.55	15.30	0.2	0.48	0.80
Daily Max:	56.71	76.81	7.4	14.44	24.12
Jul 2019 - Sep 2019	895.00	2,051.12	185.9	370.20	617.05
QTD:	895.00 *	2,051.12 *	185.9 *	370.20 *	617.05 *
YTD 2019:	2,743.36 *	6,705.86 *	625.4 *	1,239.87 *	2,066.85 *

ATTACHMENT 19

AQ-63

AQ-63 The Total Facility Emissions shall not exceed the following quarterly emissions rates.

POLLUTANT	Q1 (LBS)	Q2 (LBS)	Q3 (LBS)	Q4 (LBS)	TONS/YEAR
NOX	15546	13412	17646	15572	31.09
CO	27121	33872	28515	30202	59.86
VOC	5832	7455	6672	6890	13.42
PM-10	17854	15513	19378	19158	35.95
SO2	3400	2893	3709	3663	6.83

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:01 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
07/01/2019	0.00	0.00	0.00	0.00	0.00
07/02/2019	0.00	0.00	0.00	0.00	0.00
07/03/2019	0.00	0.00	0.00	0.00	0.00
07/04/2019	0.00	0.00	0.00	0.00	0.00
07/05/2019	0.00	0.00	0.00	0.00	0.00
07/06/2019	0.00	0.00	0.00	0.00	0.00
07/07/2019	0.00	0.00	0.00	0.00	0.00
07/08/2019	0.00	0.00	0.00	0.00	0.00
07/09/2019	0.00	0.00	0.00	0.00	0.00
07/10/2019	0.00	0.00	0.00	0.00	0.00
07/11/2019	0.00	0.00	0.00	0.00	0.00
07/12/2019	0.00	0.00	0.00	0.00	0.00
07/13/2019	0.00	0.00	0.00	0.00	0.00
07/14/2019	0.00	0.00	0.00	0.00	0.00
07/15/2019	0.00	0.00	0.00	0.00	0.00
07/16/2019	0.00	0.00	0.00	0.00	0.00
07/17/2019	0.00	0.00	0.00	0.00	0.00
07/18/2019	0.00	0.00	0.00	0.00	0.00
07/19/2019	0.00	0.00	0.00	0.00	0.00
07/20/2019	0.00	0.00	0.00	0.00	0.00
07/21/2019	0.00	0.00	0.00	0.00	0.00
07/22/2019	27.81	37.22	2.49	4.96	8.30
07/23/2019	29.53	91.83	8.98	17.99	30.01
07/24/2019	7.40	93.50	8.98	17.98	29.95
07/25/2019	15.45	79.03	7.60	15.23	25.36
07/26/2019	14.85	80.58	7.75	15.52	25.86
07/27/2019	42.08	83.84	6.91	13.83	23.07
07/28/2019	31.86	144.37	13.84	27.61	46.05
07/29/2019	32.64	154.66	14.79	29.56	49.26
07/30/2019	34.96	111.05	10.60	21.19	35.32
07/31/2019	29.32	119.89	11.42	22.89	38.15
Monthly Avg/Sum*:	265.90 *	995.97 *	93.36 *	186.76 *	311.33 *
Daily Min:	7.40	37.22	2.49	4.96	8.30
Daily Max:	42.08	154.66	14.79	29.56	49.26
Jul 2019 - Jul 2019	265.90	995.97	93.36	186.76	311.33
QTD:	265.90 *	995.97 *	93.36 *	186.76 *	311.33 *
YTD 2019:	3,190.65 *	9,282.43 *	870.52 *	1,742.01 *	2,903.47 *

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:01 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
08/01/2019	32.28	112.72	10.75	21.54	35.87
08/02/2019	30.10	116.24	11.12	22.22	37.00
08/03/2019	29.83	124.10	11.85	23.77	39.57
08/04/2019	27.26	131.11	12.51	24.97	41.60
08/05/2019	25.16	111.76	11.62	23.28	38.76
08/06/2019	30.10	127.41	12.19	24.43	40.66
08/07/2019	30.47	121.93	11.59	23.24	38.66
08/08/2019	31.45	21.55	1.87	3.76	6.23
08/09/2019	0.00	0.00	0.00	0.00	0.00
08/10/2019	0.00	0.00	0.00	0.00	0.00
08/11/2019	0.00	0.00	0.00	0.00	0.00
08/12/2019	0.00	0.00	0.00	0.00	0.00
08/13/2019	31.38	63.44	5.12	10.24	17.09
08/14/2019	56.92	129.68	11.42	22.84	38.09
08/15/2019	31.31	129.75	12.57	25.18	41.94
08/16/2019	38.17	132.93	12.67	25.38	42.27
08/17/2019	21.76	63.82	5.98	12.01	20.00
08/18/2019	0.00	0.00	0.00	0.00	0.00
08/19/2019	0.00	0.00	0.00	0.00	0.00
08/20/2019	0.00	0.00	0.00	0.00	0.00
08/21/2019	0.00	0.00	0.00	0.00	0.00
08/22/2019	0.00	0.00	0.00	0.00	0.00
08/23/2019	0.00	0.00	0.00	0.00	0.00
08/24/2019	0.00	0.00	0.00	0.00	0.00
08/25/2019	38.98	65.25	5.20	10.44	17.38
08/26/2019	20.39	68.80	6.54	13.08	21.82
08/27/2019	57.36	131.96	11.59	23.16	38.61
08/28/2019	25.76	153.44	14.70	29.37	49.01
08/29/2019	60.99	128.03	12.03	24.04	40.10
08/30/2019	0.00	0.00	0.00	0.00	0.00
08/31/2019	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	619.67 *	1,933.92 *	181.32 *	362.95 *	604.66 *
Daily Min:	20.39	21.55	1.87	3.76	6.23
Daily Max:	60.99	153.44	14.70	29.37	49.01
Jul 2019 - Aug 2019	885.57	2,929.89	274.68	549.71	915.99
QTD:	885.57 *	2,929.89 *	274.68 *	549.71 *	915.99 *
YTD 2019:	3,810.32 *	11,216.35 *	1,051.84 *	2,104.96 *	3,508.13 *

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:01 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
09/01/2019	0.00	0.00	0.00	0.00	0.00
09/02/2019	0.00	0.00	0.00	0.00	0.00
09/03/2019	0.00	0.00	0.00	0.00	0.00
09/04/2019	84.83	128.20	10.09	20.18	33.62
09/05/2019	54.31	133.96	12.64	25.30	42.16
09/06/2019	0.00	0.00	0.00	0.00	0.00
09/07/2019	0.00	0.00	0.00	0.00	0.00
09/08/2019	0.00	0.00	0.00	0.00	0.00
09/09/2019	26.06	15.30	0.24	0.48	0.80
09/10/2019	21.23	68.35	6.57	13.13	21.90
09/11/2019	63.84	79.38	6.42	12.87	21.44
09/12/2019	68.03	88.44	7.04	14.09	23.47
09/13/2019	0.00	0.00	0.00	0.00	0.00
09/14/2019	0.00	0.00	0.00	0.00	0.00
09/15/2019	0.00	0.00	0.00	0.00	0.00
09/16/2019	0.00	0.00	0.00	0.00	0.00
09/17/2019	0.00	0.00	0.00	0.00	0.00
09/18/2019	0.00	0.00	0.00	0.00	0.00
09/19/2019	0.00	0.00	0.00	0.00	0.00
09/20/2019	0.00	0.00	0.00	0.00	0.00
09/21/2019	0.00	0.00	0.00	0.00	0.00
09/22/2019	0.00	0.00	0.00	0.00	0.00
09/23/2019	56.71	68.38	5.19	10.37	17.28
09/24/2019	82.79	131.06	11.51	22.99	38.34
09/25/2019	33.98	128.33	12.36	24.69	41.13
09/26/2019	44.70	124.85	11.84	23.67	39.36
09/27/2019	29.32	76.81	7.20	14.44	24.12
09/28/2019	0.00	0.00	0.00	0.00	0.00
09/29/2019	0.00	0.00	0.00	0.00	0.00
09/30/2019	104.05	60.53	3.27	6.56	10.91
Monthly Avg/Sum*:	669.85 *	1,103.59 *	94.37 *	188.77 *	314.53 *
Daily Min:	21.23	15.30	0.24	0.48	0.80
Daily Max:	104.05	133.96	12.64	25.30	42.16
Jul 2019 - Sep 2019	1,555.42	4,033.48	369.05	738.48	1,230.52
QTD:	1,555.42 *	4,033.48 *	369.05 *	738.48 *	1,230.52 *
YTD 2019:	4,480.17 *	12,319.94 *	1,146.21 *	2,293.73 *	3,822.66 *

Tons 12 Month Rolling Summary

CT1 and CT2 Combined

From: 07/01/2019 00:00 **To:** 09/30/2019 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/14/2019 10:02 **Location:** Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2 CO, Ton 1 Day(s) Sum	Rolling Sum	Units CT1 & CT2 NOx, Ton 1 Day(s) Sum	Rolling Sum	Units CT1 & CT2 PM10, Ton 1 Day(s) Sum	Rolling Sum	Units CT1 & CT2 SO2, Ton 1 Day(s) Sum	Rolling Sum	Units CT1 & CT2 VOC, Ton 1 Day(s) Sum	Rolling Sum
Jul 2019	0.1329	3.6349	0.4979	9.8697	0.0934	1.8340	0.0467	0.9169	0.1557	3.0568
Aug 2019	0.3100	3.5358	0.9671	9.0841	0.1814	1.6947	0.0908	0.8474	0.3022	2.8241
Sep 2019	0.3350	3.8708	0.5519	9.6360	0.0943	1.7890	0.0471	0.8945	0.1574	2.9815
Sum/Avg	3.8708		9.6360		1.7890		0.8945		2.9815	
Limit Value										

Replace the dates with the ones you need

7/1/2019 0:00
9/30/2019 0:00

1D

TOWER AVG.

2442

	519-AIT-9504-1
7/1/19 0:00	1155.2
7/2/19 0:00	1156.8
7/3/19 0:00	1156.7
7/4/19 0:00	1155.9
7/5/19 0:00	1182.4
7/6/19 0:00	1193.6
7/7/19 0:00	1192.8
7/8/19 0:00	1188.1
7/9/19 0:00	1188.7
7/10/19 0:00	1211.4
7/11/19 0:00	1245.6
7/12/19 0:00	1266.3
7/13/19 0:00	1278.0
7/14/19 0:00	1349.0
7/15/19 0:00	1291.8
7/16/19 0:00	1294.6
7/17/19 0:00	1282.8
7/18/19 0:00	1302.5
7/19/19 0:00	1293.5
7/20/19 0:00	1281.5
7/21/19 0:00	1338.4
7/22/19 0:00	1337.8
7/23/19 0:00	1750.5
7/24/19 0:00	2262.3
7/25/19 0:00	2740.9
7/26/19 0:00	3426.1
7/27/19 0:00	2907.4
7/28/19 0:00	3208.3
7/29/19 0:00	3583.8
7/30/19 0:00	4048.9
7/31/19 0:00	3944.6
8/1/19 0:00	3899.5
8/2/19 0:00	3677.1
8/3/19 0:00	4002.5
8/4/19 0:00	3943.4
8/5/19 0:00	4032.4
8/6/19 0:00	4359.8
8/7/19 0:00	4253.1
8/8/19 0:00	4066.8
8/9/19 0:00	3613.6
8/10/19 0:00	3157.2
8/11/19 0:00	2866.7
8/12/19 0:00	2687.6
8/13/19 0:00	2530.4
8/14/19 0:00	3154.1
8/15/19 0:00	3575.2
8/16/19 0:00	3728.7
8/17/19 0:00	4377.2
8/18/19 0:00	4580.0

8/19/19 0:00	3122.2
8/20/19 0:00	2281.1
8/21/19 0:00	1923.8
8/22/19 0:00	1649.6
8/23/19 0:00	1615.7
8/24/19 0:00	1547.1
8/25/19 0:00	1508.3
8/26/19 0:00	2267.8
8/27/19 0:00	3061.3
8/28/19 0:00	3343.7
8/29/19 0:00	4294.9
8/30/19 0:00	3725.2
8/31/19 0:00	2286.5
9/1/19 0:00	1814.6
9/2/19 0:00	1625.1
9/3/19 0:00	1470.4
9/4/19 0:00	1378.9
9/5/19 0:00	2564.4
9/6/19 0:00	3569.6
9/7/19 0:00	2505.6
9/8/19 0:00	1846.6
9/9/19 0:00	1726.7
9/10/19 0:00	1646.4
9/11/19 0:00	2433.8
9/12/19 0:00	2886.3
9/13/19 0:00	2785.1
9/14/19 0:00	1987.4
9/15/19 0:00	2100.0
9/16/19 0:00	1837.6
9/17/19 0:00	1636.1
9/18/19 0:00	1579.0
9/19/19 0:00	1536.7
9/20/19 0:00	1483.4
9/21/19 0:00	1460.5
9/22/19 0:00	1464.5
9/23/19 0:00	1440.3
9/24/19 0:00	2566.4
9/25/19 0:00	3930.7
9/26/19 0:00	4364.3
9/27/19 0:00	5008.0
9/28/19 0:00	4821.0

Resize to show al size to show all values

ROSEVILLE ENERGY PARK COOLING TOWER EMISSIONS

POLLUTANT	LBS PER DAY	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4
PM-10	**16.3**	**1471**	**1487**	**1504**	**1504**

Whereas compliance with the PM-10 emission limit shall be demonstrated as;
Cooling tower recirculation rate * total dissolved solids of blowdown ***** design drift rate

	53814	Gallons per minute
	* 8.33	Pounds per gallon
	* 1440	Minutes per day
Circ pump flow rate	**64,550,969**	Pounds per day

	2442	Average daily conductivity umhos
	0.00000064	Conversion to TDS ppm
Total dissolved solids	**0.00156288**	

Design drift rate	**0.005%**
PM-10 pounds per day	**5.04**
	92 Days in quarter
PM-10 pounds this quarter	**464**

3Q19

fill only these

ATTACHMENT 20

AQ68

AQ68 A water sample analysis of cooling tower water shall be performed within 180 days of initial operation and annually thereafter.

Verification; The Project owner shall submit to the CPM and the PCAPCD the initial and annual cooling tower water sample analysis for approval no later than 60 days following the date of test performance.

The Cooling Tower Water Analysis was reported with the 3Q19 QAQR.

ATTACHMENT 21

AQ-69

AQ-69 No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

In regards to AQ-69 of Roseville Energy Park's 3Q19 QAQR, there were no violations of PCAPCD's Rule 205 for nuisance.

ATTACHMENT 22

AQ-70

AQ-70 PM-10 emission rates from the cooling tower shall not exceed the following limits

Cooling Tower Emissions Limitations					
Pollutant	Lbs/day	Quarter 1	Quarter 2	Quarter 3	Quarter 4
PM 10	16.3	1471	1487	1504	1504

Verification: the Project owner shall include all the necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly air Quality Report required in condition of Certification AQ-SC6.

Replace the dates with the ones you need

7/1/2019 0:00
9/30/2019 0:00

1D

TOWER AVG.

2442

	519-AIT-9504-1
7/1/19 0:00	1155.2
7/2/19 0:00	1156.8
7/3/19 0:00	1156.7
7/4/19 0:00	1155.9
7/5/19 0:00	1182.4
7/6/19 0:00	1193.6
7/7/19 0:00	1192.8
7/8/19 0:00	1188.1
7/9/19 0:00	1188.7
7/10/19 0:00	1211.4
7/11/19 0:00	1245.6
7/12/19 0:00	1266.3
7/13/19 0:00	1278.0
7/14/19 0:00	1349.0
7/15/19 0:00	1291.8
7/16/19 0:00	1294.6
7/17/19 0:00	1282.8
7/18/19 0:00	1302.5
7/19/19 0:00	1293.5
7/20/19 0:00	1281.5
7/21/19 0:00	1338.4
7/22/19 0:00	1337.8
7/23/19 0:00	1750.5
7/24/19 0:00	2262.3
7/25/19 0:00	2740.9
7/26/19 0:00	3426.1
7/27/19 0:00	2907.4
7/28/19 0:00	3208.3
7/29/19 0:00	3583.8
7/30/19 0:00	4048.9
7/31/19 0:00	3944.6
8/1/19 0:00	3899.5
8/2/19 0:00	3677.1
8/3/19 0:00	4002.5
8/4/19 0:00	3943.4
8/5/19 0:00	4032.4
8/6/19 0:00	4359.8
8/7/19 0:00	4253.1
8/8/19 0:00	4066.8
8/9/19 0:00	3613.6
8/10/19 0:00	3157.2
8/11/19 0:00	2866.7
8/12/19 0:00	2687.6
8/13/19 0:00	2530.4
8/14/19 0:00	3154.1
8/15/19 0:00	3575.2
8/16/19 0:00	3728.7
8/17/19 0:00	4377.2
8/18/19 0:00	4580.0

8/19/19 0:00	3122.2
8/20/19 0:00	2281.1
8/21/19 0:00	1923.8
8/22/19 0:00	1649.6
8/23/19 0:00	1615.7
8/24/19 0:00	1547.1
8/25/19 0:00	1508.3
8/26/19 0:00	2267.8
8/27/19 0:00	3061.3
8/28/19 0:00	3343.7
8/29/19 0:00	4294.9
8/30/19 0:00	3725.2
8/31/19 0:00	2286.5
9/1/19 0:00	1814.6
9/2/19 0:00	1625.1
9/3/19 0:00	1470.4
9/4/19 0:00	1378.9
9/5/19 0:00	2564.4
9/6/19 0:00	3569.6
9/7/19 0:00	2505.6
9/8/19 0:00	1846.6
9/9/19 0:00	1726.7
9/10/19 0:00	1646.4
9/11/19 0:00	2433.8
9/12/19 0:00	2886.3
9/13/19 0:00	2785.1
9/14/19 0:00	1987.4
9/15/19 0:00	2100.0
9/16/19 0:00	1837.6
9/17/19 0:00	1636.1
9/18/19 0:00	1579.0
9/19/19 0:00	1536.7
9/20/19 0:00	1483.4
9/21/19 0:00	1460.5
9/22/19 0:00	1464.5
9/23/19 0:00	1440.3
9/24/19 0:00	2566.4
9/25/19 0:00	3930.7
9/26/19 0:00	4364.3
9/27/19 0:00	5008.0
9/28/19 0:00	4821.0

Resize to show al size to show all values

ROSEVILLE ENERGY PARK COOLING TOWER EMISSIONS

POLLUTANT	LBS PER DAY	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4
PM-10	**16.3**	**1471**	**1487**	**1504**	**1504**

Whereas compliance with the PM-10 emission limit shall be demonstrated as;
Cooling tower recirculation rate * total dissolved solids of blowdown ***** design drift rate

	53814	Gallons per minute
	* 8.33	Pounds per gallon
	* 1440	Minutes per day
Circ pump flow rate	**64,550,969**	Pounds per day

	2442	Average daily conductivity umhos
	0.00000064	Conversion to TDS ppm
Total dissolved solids	**0.00156288**	

Design drift rate	**0.005%**
PM-10 pounds per day	**5.04**
	92 Days in quarter
PM-10 pounds this quarter	**464**

3Q19

fill only these

ATTACHMENT 23

AQ-71

AQ-71 Compliance with the cooling tower PM-10 emission limit shall be demonstrated as follows: PM-10 = cooling water recirculation rate* total dissolved solids concentration in the blow own water* design drift rate.

Verification: the Project owner shall include all the necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly air Quality Report required in condition of Certification AQ-SC6.

Replace the dates with the ones you need

7/1/2019 0:00
9/30/2019 0:00

1D

TOWER AVG.

2442

	519-AIT-9504-1
7/1/19 0:00	1155.2
7/2/19 0:00	1156.8
7/3/19 0:00	1156.7
7/4/19 0:00	1155.9
7/5/19 0:00	1182.4
7/6/19 0:00	1193.6
7/7/19 0:00	1192.8
7/8/19 0:00	1188.1
7/9/19 0:00	1188.7
7/10/19 0:00	1211.4
7/11/19 0:00	1245.6
7/12/19 0:00	1266.3
7/13/19 0:00	1278.0
7/14/19 0:00	1349.0
7/15/19 0:00	1291.8
7/16/19 0:00	1294.6
7/17/19 0:00	1282.8
7/18/19 0:00	1302.5
7/19/19 0:00	1293.5
7/20/19 0:00	1281.5
7/21/19 0:00	1338.4
7/22/19 0:00	1337.8
7/23/19 0:00	1750.5
7/24/19 0:00	2262.3
7/25/19 0:00	2740.9
7/26/19 0:00	3426.1
7/27/19 0:00	2907.4
7/28/19 0:00	3208.3
7/29/19 0:00	3583.8
7/30/19 0:00	4048.9
7/31/19 0:00	3944.6
8/1/19 0:00	3899.5
8/2/19 0:00	3677.1
8/3/19 0:00	4002.5
8/4/19 0:00	3943.4
8/5/19 0:00	4032.4
8/6/19 0:00	4359.8
8/7/19 0:00	4253.1
8/8/19 0:00	4066.8
8/9/19 0:00	3613.6
8/10/19 0:00	3157.2
8/11/19 0:00	2866.7
8/12/19 0:00	2687.6
8/13/19 0:00	2530.4
8/14/19 0:00	3154.1
8/15/19 0:00	3575.2
8/16/19 0:00	3728.7
8/17/19 0:00	4377.2
8/18/19 0:00	4580.0

8/19/19 0:00	3122.2
8/20/19 0:00	2281.1
8/21/19 0:00	1923.8
8/22/19 0:00	1649.6
8/23/19 0:00	1615.7
8/24/19 0:00	1547.1
8/25/19 0:00	1508.3
8/26/19 0:00	2267.8
8/27/19 0:00	3061.3
8/28/19 0:00	3343.7
8/29/19 0:00	4294.9
8/30/19 0:00	3725.2
8/31/19 0:00	2286.5
9/1/19 0:00	1814.6
9/2/19 0:00	1625.1
9/3/19 0:00	1470.4
9/4/19 0:00	1378.9
9/5/19 0:00	2564.4
9/6/19 0:00	3569.6
9/7/19 0:00	2505.6
9/8/19 0:00	1846.6
9/9/19 0:00	1726.7
9/10/19 0:00	1646.4
9/11/19 0:00	2433.8
9/12/19 0:00	2886.3
9/13/19 0:00	2785.1
9/14/19 0:00	1987.4
9/15/19 0:00	2100.0
9/16/19 0:00	1837.6
9/17/19 0:00	1636.1
9/18/19 0:00	1579.0
9/19/19 0:00	1536.7
9/20/19 0:00	1483.4
9/21/19 0:00	1460.5
9/22/19 0:00	1464.5
9/23/19 0:00	1440.3
9/24/19 0:00	2566.4
9/25/19 0:00	3930.7
9/26/19 0:00	4364.3
9/27/19 0:00	5008.0
9/28/19 0:00	4821.0

Resize to show al size to show all values

ROSEVILLE ENERGY PARK COOLING TOWER EMISSIONS

POLLUTANT	LBS PER DAY	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4
PM-10	**16.3**	**1471**	**1487**	**1504**	**1504**

Whereas compliance with the PM-10 emission limit shall be demonstrated as;
Cooling tower recirculation rate * total dissolved solids of blowdown ***** design drift rate

	53814	Gallons per minute
	* 8.33	Pounds per gallon
	* 1440	Minutes per day
Circ pump flow rate	**64,550,969**	Pounds per day

	2442	Average daily conductivity umhos
	0.00000064	Conversion to TDS ppm
Total dissolved solids	**0.00156288**	

Design drift rate	**0.005%**
PM-10 pounds per day	**5.04**
	92 Days in quarter
PM-10 pounds this quarter	**464**

3Q19

fill only these

ATTACHMENT 24

AQ-86

AQ-86 Operation for maintenance and testing of the emergency diesel engine and generator shall be limited to 50 hours per year.

Verification: The Project owner shall include all necessary operational data to demonstrate compliance with the limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

DATE	TECH	TIME START-S/D		RUNTIME TOTAL HRS.	RUNTIME YTD MINUTES
12/24/18	E.O.	13:37 - 14:07	BI-WEEKLY TEST	97	805
1/6/19	MAB	1241 - 1311	BI-WEEKLY TEST	97	30
1-20-19	Ray	0825 - 0855	Bi-Weekly Test	98	60
1-29-19	Ray	1013 - 1043	Bi Weekly Test	98	90
2-17-19	Ry	1035 - 1105	Bi Weekly Test	99	120
3-11-19	E.O.	0724 - 0730	OUTAGE / BLACK PLANT	99	126
4-29-19	me	0920-0950	TEST / Warm oil for Start	99	156
4/29/2019	ME	1202-1206	Post Maint Prime/TEST	99	160
7-18-19	RL	1311-1347	TEST-INTELLIGEN RCFANC	100	195
8-22-19	RL	DIESE DELIVERY 16.0 GALS			
9-20-19	AB	1026-1029	TEST RUN	100	198
9-20-19	AB	1416-1421	TEST RUN	100	203
9-20-19	AB	1424-1434	TEST RUN	100	213
10-10-19	me	1100-1124	TEST Run / TroubleShooting	100	237
10-10-19	me	1136-1144	TEST Run / TroubleShooting	101	245
10-10-19	me	1150-1158	TEST Run / TroubleShooting	101	253
10-10-19	me	1206-1207	TEST Run / TROUBLESHOOTING	101	254
10-13-19	MAB	0942-0947	WEEKLY TEST RUN	101	259

ATTACHMENT 25

AQ-87

AQ-87 Operation for other than maintenance and testing purposes shall be limited to involuntary interruptions of electrical power. Operation shall not exceed 24 hours without prior authorization by the Air Pollution Control Officer.

Verification: The Project owner shall include all necessary operational data to demonstrate compliance with the limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

DATE	START	Reason	STOP	INITIALS	TOTAL	YTD
11/6/2018	0949	Inspection/Weekly test	1019	MR	146.7	18.7
11-16-18		Cosco Fire caused pump start		DWN	147.0	19.0
11-18-18	1434	Weekly Test	1504	DWN	147.5	19.5
11-25-2018	1430	Weekly Test	1500	RJ	148.0	20.0
12-2-18	1608	Weekly Test Run	1638	BP	148.5	20.5
12-9-18	14	Weekly test Run	1850	KDS	149.0	21.0
12-16-18	1200	WEEKLY TEST RUN	1230	AB	149.5	21.5
12-24-18	15:39	WEEKLY TEST RUN	16:09	E.O.	150.0	22.0
12-30-18	13:49	WEEKLY TEST RUN		E.O.	150.5	22.5

2019

DATE	START	Reason	STOP	INITIALS	TOTAL	YTD
1-6-19	1348	WEEKLY TEST RUN	1418	GAB	151	.5
1-13-19	1339	WEEKLY TEST RUN	1409	AB	151.5	1.0
1-20-19	1027	Weekly Test	1057	RJ	152	1.5
1-27-19	1211	WEEKLY TEST	1241	GAB	152.5	2.0
1-29-19	1029	Weekly Test	1059	RJ	153.0	2.5
2-10-19	1522	Weekly Test	1552	MR	153.5	3.0
2-17-19	1500	Weekly Test	1530	RJ	154.0	3.5
2-24-19	1630	weekly test	1700	BP	154.5	4.0
3-10-19	1535	WEEKLY TEST	1605	RC	155.0	4.5
3-17-19	1412	Weekly Test	1442	RJ	155.5	5.0
3-24-19	1235	Weekly Test	1305	KDS	156.0	5.5
3-30-19	1646	WEEKLY TEST RUN	1716	GAB	156.5	6.0
4-7-19	1530	WEEKLY TES RUN	1600	RC	157.0	6.5
4-14-19	1412	Weekly Test Run	1442	RJ	157.5	7.0
4/21/19	1448	Weekly Test Run	1518	MR	158.0	7.5
4/28/19	1357	Weekly Test Run	1427	MR	158.5	8.0
4/29/19	1043	Post Maint Drive	1045	MR	158.5	8.0
5/5/19	1430	WEEKLY TEST RUN	1500	RC	159.0	8.5
5/6/19	1325	MAINTENANCE PM	1330	RC	159.1	8.6
5/7/19	1131	TEST RUN AFTER REPAIR	1133	AB	159.1	8.6
5-12-19	1120	Weekly Test	1150	RJ	159.6	9.1
5-19-19	1108	Weekly Test	1138	BP	160.1	9.6
5/26/19	1324	Weekly Test	1354	MR	160.6	10.1
6-2-19	1220	WEEKLY TEST	1250	RC	161.1	10.6

DATE	START	Reason	STOP	INITIALS	TOTAL	YTD
6-09-2019	1320	Weekly Test	1350	RJ	161.6	11.1
6-15-2019	1611	Weekly Test	1641	MR	162.1	11.6
6-22-2019	1630	Weekly Test	1700	MR	162.6	12.1
6-30-2019	1020	WEEKLY TEST	1050	RC	163.1	12.6
7-7-2019	1128	Weekly Test	1158	RJ	163.6	13.1
7-14-2019	1450	Weekly Test	1520	BP	164.1	13.6
7-20-2019	1332	Weekly test	1402	BP	164.6	14.1
7-29-2019	1630	WEEKLY TEST	1700	EO	165.1	14.6
08-04-2019	1115	Weekly Test	1145	RJ	165.6	15.1
8-11-19	1910	WEEKLY TEST	1940	RC	166.1	15.6
8-18-19	1505	WEEKLY TEST	1535	RC	166.6	16.1
8-22-19	DIESEL	DELIVERY	660.0 GALLONS	RC		
8-25-19	1620	WEEKLY TEST	1650	RC	167.1	16.6
9-1-19	1602	WEEKLY TEST	1632	EO.	167.6	17.1
9-8-19	1545	Weekly Test	1615	GAB	168.1	17.6
9-15-19	1625	WEEKLY TEST	1655	RC	168.6	18.1
9-22-19	1515	Weekly Test	1545	DWN	169.1	18.6
10-6-19	1210	Weekly test	1240	BP	169.6	19.1
10-13-19	1043	Weekly test	1113	MR	170.1	19.6

ATTACHMENT 26

AQ-88

AQ-88 The Sulfur content of the Diesel fuel used shall not exceed 15 ppm by weight.

Verification: The Project owner shall include a summary of diesel fuel purchase records showing amounts delivered, date delivered and fuel type with the Quarterly Air Quality Report as required in Condition of Certification AQ-SC6.

60 YEARS OF SERVICE
RAMOS OIL COMPANY

P.O. BOX 401
WEST SACRAMENTO, CA 95691-0401

01 Sacramento 916-371-2570 08 Williams 530-473-2811
03 Dixon 707-678-2061 09 Isleton 916-777-6545
04 Fairfield 707-425-5780 11 Marysville 530-743-4647
05 Stockton 209-465-6255 14 Lincoln 916-645-2170
06 Woodland 530-661-1200

REMIT TO: P.O. BOX 401
WEST SACRAMENTO, CA 95691-0401

HAZARDOUS MATERIAL EMERGENCY
CALL 1-800-456-7745

Scan here to sign up for Online Bill Pay →

ACCOUNT: 23464
INVOICE: 64089
WH: 11
DATE: 08-22-19

66.517617.S21

ROSEVILLE ENERGY PARK
CITY OF ROSEVILLE
5120 PHILLIP RD
ROSEVILLE, CA 95747

RAMOS OIL INC.
PO BOX 401
WEST SACRAMENTO, CA 95691-0401

DO NOT ATTACH WITH STAPLE OR PAPERCLIP
PLEASE DETACH AT PERFORATION AND RETURN UPPER PORTION WITH YOUR PAYMENT

CUST. PURCHASE ORDER NUMBER	SALESMAN	TERMS	DEL. ZONE	DUE DATE
P1901249	JOSH GRAVES	Net 30 Days	0	09-21-19

DELIVERY DATE	DRIVER	TRUCK NUMBER	TERMINAL	B/L NUMBER
08-22-19	258ROBERT R	11702		

NO. OF PKG'S	BULK OR SIZE	PRODUCT DELIVERED	ORDERED	DELIVERED	TAXES	PRICE	AMOUNT
		NA1993, RED DYED DIESEL COMBUSTIBLE, 3, PGIII #2D 15ppm sulfur (maxium) Dyed Diesel fuel non taxable use only, penalty for taxable use.					
	BULK	DSL #2 DYED CARB ULTRA LOW	96	96	T	2.76200	265.15
		REC CA OIL SPILL TAX		96		0.00000	0.00
		L.U.S.T. TAX		96		0.00100	0.10
		FED OIL SPILL TAX		96		0.00000	0.00
		AB 32 DSL IMPLEMENTATION FEE		96		0.00190	0.18
1	EACH	WET HOSE FEE	1	1	T	75.00000	75.00
		ENVIRONMENTAL SURCHARGE			T	0.00850	0.82

Roseville Energy Park
SEP 4 2019

Ship to:
ROSEVILLE ENERGY PARK
CITY OF ROSEVILLE
5120 PHILLIP RD
ROSEVILLE, CA 95747

SALES TAX →	24.74
TOTAL →	365.99

CUSTOMER AGREES TO PAY FINANCE CHARGE ON PAST DUE BALANCE OF 1.5% PER MONTH OR THE MAXIMUM RATE ALLOWED IN CUSTOMER'S STATE OF RESIDENCE, WHICHEVER IS LESS, AND FURTHER AGREES TO PAY REASONABLE ATTORNEY'S FEES AND COSTS IF COLLECTION IS REQUIRED. VENUE FOR PURPOSES OF ENFORCEMENT OF THIS OBLIGATION SHALL BE YOLO COUNTY.

ALL CLAIMS FOR ENVIRONMENTAL DAMAGE DURING DELIVERY OF ANY RAMOS OIL PRODUCT MUST BE MADE WITHIN 15 DAYS FOLLOWING DELIVERY.

ERRORS IN PRICE, EXTENSION AND ADDITION SUBJECT TO CORRECTION.

DELIVERED BY (SIGNATURE IN FULL) X

RECEIVED IN GOOD ORDER X

TOTAL → 365.99

ATTACHMENT 27

AQ-89

AQ-89 Records of operation and maintenance shall be kept by the owner or Operator for a period of five years and shall be made available to the PCAPCD upon request. Information required for reporting to the PCAPCD includes, but is not limited to:

1. The hours of operation the engine was run for maintenance and testing;
2. The hours of operation the engine was run during interruption of electrical power; and
3. Records of the sulfur content of the diesel used.

VERIFICATION: The Project owner shall include these records as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

DATE	TECH	TIME START-S/D		RUNTIME TOTAL HRS.	RUNTIME YTD MINUTES
12/24/18	E.O.	13:37 - 14:07	BI-WEEKLY TEST	97	805
1/6/19	MAB	1241 - 1311	BI-WEEKLY TEST	97	30
1-20-19	Ray	0825 - 0855	Bi-Weekly Test	98	60
1-29-19	Ray	1013 - 1043	Bi Weekly Test	98	90
2-17-19	Ry	1035 - 1105	Bi Weekly Test	99	120
3-11-19	E.O.	0724 - 0730	OUTAGE / BLACK PLANT	99	126
4-29-19	me	0920-0950	TEST / Warm oil for Start	99	156
4/29/2019	ME	1202-1206	Post Maint Prime/TEST	99	160
7-18-19	RL	1311-1347	TEST-INTELLIGEN RCFANC	100	195
8-22-19	RL	DIESE DELIVERY 16.0 GALS			
9-20-19	AB	1026-1029	TEST RUN	100	198
9-20-19	AB	1416-1421	TEST RUN	100	203
9-20-19	AB	1424-1434	TEST RUN	100	213
10-10-19	me	1100-1124	TEST Run / TroubleShooting	100	237
10-10-19	me	1136-1144	TEST Run / TroubleShooting	101	245
10-10-19	me	1150-1158	TEST Run / TroubleShooting	101	253
10-10-19	me	1206-1207	TEST Run / TROUBLESHOOTING	101	254
10-13-19	MAB	0942-0947	WEEKLY TEST RUN	101	259

ATTACHMENT 28

AQ-90

AQ-90 No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6.

In regards to AQ-90 of Roseville Energy Park's 3Q19 QAQR, there were no violations of PCAPCD's Rule 205 for nuisance.

ATTACHMENT 29

AQ-91

AQ-91 Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited and is in violation of PCAPCD Rule 202, Visible Emissions.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6.

In regards to AQ-91of Roseville Energy Park's 3Q19 QAQR, there were no violations of PCAPCD's Rule 202 for opacity from the diesel fire pump.

ATTACHMENT 30

AQ-99

AQ-99 Operation for maintenance and testing of the emergency diesel engine and generator shall be limited to 50 hours per year.

Verification: The Project shall include all necessary operational data to demonstrate compliance with the limits provided as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

DATE	TECH	TIME START-S/D		RUNTIME TOTAL HRS.	RUNTIME YTD MINUTES
12/24/18	E.O.	13:37 - 14:07	BI-WEEKLY TEST	97	805
1/6/19	MAB	1241 - 1311	BI-WEEKLY TEST	97	30
1-20-19	Ray	0825 - 0555	Bi-Weekly Test	98	60
1-29-19	Ray	1013 - 1043	Bi Weekly Test	98	90
2-17-19	Ry	1035 - 1105	Bi Weekly Test	99	120
3-11-19	E.O.	0724 - 0730	OUTAGE / BLACK PLANT	99	126
4-29-19	me	0920-0950	TEST / Warm oil for Start	99	156
4/29/2019	ME	1202-1206	Post Maint Prime/TEST	99	160
7-18-19	RL	1311-1347	TEST-INTELLIGEN RCFANC	100	195
8-22-19	RL	DIESEL DELIVERY 16.0 GALS			
9-20-19	AB	1026-1029	TEST RUN	100	198
9-20-19	AB	1416-1421	TEST RUN	100	203
9-20-19	AB	1424-1434	TEST RUN	100	213
10-10-19	me	1100-1124	TEST RUN / TroubleShooting	100	237
10-10-19	me	1136-1144	TEST RUN / TroubleShooting	101	245
10-10-19	me	1150-1158	TEST RUN / TroubleShooting	101	253
10-10-19	me	1206-1207	TEST RUN / TROUBLESHOOTING	101	254
10-13-19	MAB	0942-0947	WEEKLY TEST RUN	101	259

ATTACHMENT 31

AQ-100

AQ-100 In regards to the Emergency diesel Generator; Operation for other than maintenance and testing purposes shall be limited to involuntary interruptions of electrical power. Operation shall not exceed 24 hours without prior authorization by the Air Pollution Control Officer.

DATE	TECH	TIME START-S/D		RUNTIME TOTAL HRS.	RUNTIME YTD MINUTES
12/24/18	E.O.	13:37 - 14:07	BI-WEEKLY TEST	97	805
1/6/19	MAB	1241 - 1311	BI-WEEKLY TEST	97	30
1-20-19	Ray	0825 - 0855	Bi-Weekly Test	98	60
1-29-19	Ray	1013 - 1043	Bi Weekly Test	98	90
2-17-19	Ry	1035 - 1105	Bi Weekly Test	99	120
3-11-19	E.O.	0724 - 0730	OUTAGE / BLACK PLANT	99	126
4-29-19	me	0920-0950	TEST / Warm oil for Start	99	156
4/29/2019	ME	1202-1206	Post Maint Prime/TEST	99	160
7-18-19	RL	1311-1347	TEST-INTELLIGEN RCFANC	100	195
8-22-19	RL	DIESE DELIVERY 16.0 GALS			
9-20-19	AB	1026-1029	TEST RUN	100	198
9-20-19	AB	1416-1421	TEST RUN	100	203
9-20-19	AB	1424-1434	TEST RUN	100	213
10-10-19	me	1100-1124	TEST RUN / TroubleShooting	100	237
10-10-19	me	1136-1144	TEST RUN / TroubleShooting	101	245
10-10-19	me	1150-1158	TEST RUN / TroubleShooting	101	253
10-10-19	me	1206-1207	TEST RUN / TROUBLESHOOTING	101	254
10-13-19	MAB	0942-0947	WEEKLY TEST RUN	101	259

ATTACHMENT 32

AQ-101

AQ-101 The sulfur content of the diesel used shall not exceed 15ppm by weight

Verification: The Project owner shall include a summary of diesel fuel purchase records showing amounts delivered, date delivered and fuel type with the Quarterly Air Quality Report in Condition of Certification AQ-SC6

60 YEARS OF SERVICE
RAMOS OIL COMPANY

P.O. BOX 401
WEST SACRAMENTO, CA 95691-0401

01 Sacramento 916-371-2570 08 Williams 530-473-2811
03 Dixon 707-678-2061 09 Isleton 916-777-6545
04 Fairfield 707-425-5780 11 Marysville 530-743-4647
05 Stockton 209-465-6255 14 Lincoln 916-645-2170
06 Woodland 530-661-1200

REMIT TO: P.O. BOX 401
WEST SACRAMENTO, CA 95691-0401

HAZARDOUS MATERIAL EMERGENCY
CALL 1-800-456-7745

Scan here to sign up for Online Bill Pay →

ACCOUNT: 23464
INVOICE: 64089
WH: 11
DATE: 08-22-19

66.517617.S21

ROSEVILLE ENERGY PARK
CITY OF ROSEVILLE
5120 PHILLIP RD
ROSEVILLE, CA 95747

RAMOS OIL INC.
PO BOX 401
WEST SACRAMENTO, CA 95691-0401

DO NOT ATTACH WITH STAPLE OR PAPERCLIP
PLEASE DETACH AT PERFORATION AND RETURN UPPER PORTION WITH YOUR PAYMENT

CUST. PURCHASE ORDER NUMBER	SALESMAN	TERMS	DEL. ZONE	DUE DATE
P1901249	JOSH GRAVES	Net 30 Days	0	09-21-19

DELIVERY DATE	DRIVER	TRUCK NUMBER	TERMINAL	B/L NUMBER
08-22-19	258ROBERT R	11702		

NO. OF PKG'S	BULK OR SIZE	PRODUCT DELIVERED	ORDERED	DELIVERED	TAXES	PRICE	AMOUNT
		NA1993, RED DYED DIESEL COMBUSTIBLE, 3, PGIII #2D 15ppm sulfur (maxium) Dyed Diesel fuel non taxable use only, penalty for taxable use.					
	BULK	DSL #2 DYED CARB ULTRA LOW	96	96	T	2.76200	265.15
		REC CA OIL SPILL TAX		96		0.00000	0.00
		L.U.S.T. TAX		96		0.00100	0.10
		FED OIL SPILL TAX		96		0.00000	0.00
		AB 32 DSL IMPLEMENTATION FEE		96		0.00190	0.18
1	EACH	WET HOSE FEE	1	1	T	75.00000	75.00
		ENVIRONMENTAL SURCHARGE			T	0.00850	0.82

Roseville Energy Park
SEP 4 2019

Ship to:
ROSEVILLE ENERGY PARK
CITY OF ROSEVILLE
5120 PHILLIP RD
ROSEVILLE, CA 95747

SALES TAX →	24.74
TOTAL →	365.99

CUSTOMER AGREES TO PAY FINANCE CHARGE ON PAST DUE BALANCE OF 1.5% PER MONTH OR THE MAXIMUM RATE ALLOWED IN CUSTOMER'S STATE OF RESIDENCE, WHICHEVER IS LESS, AND FURTHER AGREES TO PAY REASONABLE ATTORNEY'S FEES AND COSTS IF COLLECTION IS REQUIRED. VENUE FOR PURPOSES OF ENFORCEMENT OF THIS OBLIGATION SHALL BE YOLO COUNTY.

ALL CLAIMS FOR ENVIRONMENTAL DAMAGE DURING DELIVERY OF ANY RAMOS OIL PRODUCT MUST BE MADE WITHIN 15 DAYS FOLLOWING DELIVERY.

DELIVERED BY (SIGNATURE IN FULL) X

RECEIVED IN GOOD ORDER X

ERRORS IN PRICE, EXTENSION AND ADDITION SUBJECT TO CORRECTION.

TOTAL → 365.99

ATTACHMENT 33

AQ-102

AQ-102 Records of operation and maintenance shall be kept by the owner or operator for a period of five years and shall be made available to the PCAPCD by request. Information required for reporting to the PCAPCD includes, but is not limited to:

A. Hours of operation the engine was run for maintenance and testing
B. Hours of operation the engine was run during interruption of electrical power
C. Records of sulfur content of the diesel fuel used

Verification: The Project owner shall include these records as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

DATE	TECH	TIME START-S/D		RUNTIME TOTAL HRS.	RUNTIME YTD MINUTES
12/24/18	E.O.	13:37 - 14:07	BI-WEEKLY TEST	97	805
1/6/19	MAB	1241 - 1311	BI-WEEKLY TEST	97	30
1-20-19	Ray	0825 - 0555	Bi-Weekly Test	98	60
1-29-19	Ray	1013 - 1043	Bi Weekly Test	98	90
2-17-19	Ry	1035 - 1105	Bi Weekly Test	99	120
3-11-19	E.O.	0724 - 0730	OUTAGE / BLACK PLANT	99	126
4-29-19	me	0920-0950	TEST / Warm oil for Start	99	156
4/29/2019	ME	1202-1206	Post Maint Prime/TEST	99	160
7-18-19	RL	1311-1347	TEST-INTELLIGEN RCFANC	100	195
8-22-19	RL	DIESE DELIVERY 16.0 GALS			
9-20-19	AB	1026-1029	TEST RUN	100	198
9-20-19	AB	1416-1421	TEST RUN	100	203
9-20-19	AB	1424-1434	TEST RUN	100	213
10-10-19	me	1100-1124	TEST Run / TroubleShooting	100	237
10-10-19	me	1136-1144	TEST Run / TroubleShooting	101	245
10-10-19	me	1150-1158	TEST Run / TroubleShooting	101	253
10-10-19	me	1206-1207	TEST Run / TROUBLESHOOTING	101	254
10-13-19	MAB	0942-0947	WEEKLY TEST RUN	101	259

ATTACHMENT 34

AQ-103

AQ-103 No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6.

In regards to AQ-103 of Roseville Energy Park's 3Q19 QAQR, there were no violations of PCAPCD's Rule 205 for nuisance.

ATTACHMENT 35

AQ-104

AQ-104 Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited and is in violation of PCAPCD Rule 202, Visible Emissions.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite opacity complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

In regards to AQ-104 of Roseville Energy Park's 3Q19 QAQR, there were no violations of PCAPCD's Rule 202 for opacity from stack emissions of the emergency diesel generator.