

DOCKETED

Docket Number:	81-AFC-03C
Project Title:	NCPA Geothermal Project No. 3 - Compliance
TN #:	231916
Document Title:	Monthly Emissions Summary Report 02-2019
Description:	SUMMARY OF H2S EMISSIONS
Filer:	Anthony Edward Allegra
Organization:	Northern California Power Agency - Geothermal Project
Submitter Role:	Public Agency
Submission Date:	2/3/2020 2:05:27 PM
Docketed Date:	2/3/2020

NORTHERN CALIFORNIA POWER AGENCY

SUMMARY OF H2S EMISSIONS

Month: February

Year: 2019

UNIT NUMBER	EMISSION LIMIT	DATE	SOURCE TEST RESULTS	REMARKS
1	5.0 lbs/hr	02/22/2019	4.44 lbs/hr	Fe Feedrate: 7 lbs/hr H2O2 Feedrate: 0 lbs/hr Sweet Gas H2S: 2.23 ppm Fe in Circ. Wtr.: 0.84 ppm
2	5.0 lbs/hr	02/22/2019	3.12 lbs/hr	Fe Feedrate: 7 lbs/hr H2O2 Feedrate: 0 lbs/hr Sweet Gas H2S: 2.23 ppm Fe in Circ. Wtr.: 1.26 ppm
4	5.5 lbs/hr	02/19/2019	3.74 lbs/hr	Fe Feedrate: 11.5 lbs/hr H2O2 Feedrate: 0 lbs/hr Sweet Gas H2S: 4.5 ppm Fe in Circ. Wtr.: 1.12 ppm

Notes/Comments: Plant 2 forced outage 02/02/2019 - 02/03/2019.

Hours in Month: 672	*Hours Houston Atlas On-Line:	<u>Plant 1</u> 672	<u>Plant 2</u> 657.25
----------------------------	--------------------------------------	------------------------------	---------------------------------

***Note:** Calibration hours are considered on-line hours.