

DOCKETED

Docket Number:	81-AFC-03C
Project Title:	NCPA Geothermal Project No. 3 - Compliance
TN #:	231913
Document Title:	Monthly Emissions Summary Report 03-2019
Description:	SUMMARY OF H2S EMISSIONS
Filer:	Anthony Edward Allegra
Organization:	Northern California Power Agency - Geothermal Project
Submitter Role:	Public Agency
Submission Date:	2/3/2020 2:05:27 PM
Docketed Date:	2/3/2020

NORTHERN CALIFORNIA POWER AGENCY

SUMMARY OF H2S EMISSIONS

Month: March

Year: 2019

UNIT NUMBER	EMISSION LIMIT	DATE	SOURCE TEST RESULTS	REMARKS
1	5.0 lbs/hr	03/18/2019	0.84 lbs/hr	Fe Feedrate: 7 lbs/hr H2O2 Feedrate: 0 lbs/hr Sweet Gas H2S: 1.76 ppm Fe in Circ. Wtr.: 0.34 ppm
2	5.0 lbs/hr	03/18/2019	0.15 lbs/hr	Fe Feedrate: 7 lbs/hr H2O2 Feedrate: 0 lbs/hr Sweet Gas H2S: 1.76 ppm Fe in Circ. Wtr.: 2.18 ppm
4	5.5 lbs/hr	03/19/2019	2.47 lbs/hr	Fe Feedrate: 11.5 lbs/hr H2O2 Feedrate: 0 lbs/hr Sweet Gas H2S: 2.83 ppm Fe in Circ. Wtr.: 1.15 ppm

Notes/Comments: Plant 2 forced outage 03/08/2019 - 03/11/2019.

Hours in Month: 744	*Hours Houston Atlas On-Line:	<u>Plant 1</u> 744	<u>Plant 2</u> 666.75
----------------------------	--------------------------------------	---------------------------	------------------------------

***Note:** Calibration hours are considered on-line hours.