

DOCKETED

Docket Number:	81-AFC-03C
Project Title:	NCPA Geothermal Project No. 3 - Compliance
TN #:	231912
Document Title:	Monthly Emissions Summary Report 05-2019
Description:	SUMMARY OF H2S EMISSIONS
Filer:	Anthony Edward Allegra
Organization:	Northern California Power Agency - Geothermal Project
Submitter Role:	Public Agency
Submission Date:	2/3/2020 2:05:27 PM
Docketed Date:	2/3/2020

NORTHERN CALIFORNIA POWER AGENCY

SUMMARY OF H2S EMISSIONS

Month: May

Year: 2019

UNIT NUMBER	EMISSION LIMIT	DATE	SOURCE TEST RESULTS	REMARKS
1	5.0 lbs/hr	05/31/2019	0.4 lbs/hr	Fe Feedrate: 7 lbs/hr H2O2 Feedrate: 0 lbs/hr Sweet Gas H2S: 3 ppm Fe in Circ. Wtr.: 2.03 ppm
2	5.0 lbs/hr	05/31/2019	0.43 lbs/hr	Fe Feedrate: 7 lbs/hr H2O2 Feedrate: 0 lbs/hr Sweet Gas H2S: 3 ppm Fe in Circ. Wtr.: 2.02 ppm
4	5.5 lbs/hr	05/29/2019	0.18 lbs/hr	Fe Feedrate: 11.8 lbs/hr H2O2 Feedrate: 0 lbs/hr Sweet Gas H2S: 0.1 ppm Fe in Circ. Wtr.: 1.30 ppm

Notes/Comments: Plant 1 out-of-service 5/1/19 thru 5/17/19 for scheduled outage.

Plant 2 out-of-service 5/7/19 due to forced outage.

Hours in Month: 744

***Hours Houston Atlas On-Line:**

Plant 1

Plant 2

346.25

743.75

***Note:** Calibration hours are considered on-line hours.