

## DOCKETED

|                         |  |
|-------------------------|--|
| <b>Docket Number:</b>   | 12-AFC-03  |
| <b>Project Title:</b>   | Redondo Beach Energy Project   |
| <b>TN #:</b>            | 201896   |
| <b>Document Title:</b>  | Response to South Coast Air Quality Management District from Redondo Beach Energy Projects re Greenhouse Gas Emissions |
| <b>Description:</b>     | N/A  |
| <b>Filer:</b>           | Sarah Madams   |
| <b>Organization:</b>    | CH2M HILL  |
| <b>Submitter Role:</b>  | Applicant Consultant   |
| <b>Submission Date:</b> | 3/20/2014 4:55:01 PM   |
| <b>Docketed Date:</b>   | 3/20/2014  |



AES Southland Development  
690 N. Studebaker Road  
Long Beach, CA 90803  
tel 562 493 7891  
fax 562 493 7320

March 17, 2014

Vicky Lee  
Air Quality Engineer  
South Coast Air Quality Management District  
21865 Copley Drive  
Diamond Bar, CA 90803

**Re: Redondo Beach Energy Project Response  
(Facility ID 115536)**

Dear Ms. Lee:

This letter provides the information you requested via electronic mail regarding the Redondo Beach Energy Project's (RBEP) greenhouse gas (GHG) emissions.

**NSPS for GHG Emissions from Electric Utility Generating Units**

1. NSPS for GHG Emissions from Electric Utility Generating Units

- a. Is the  $MWh_{gross}$  you provided in previous calculations the same as the gross energy output in megawatt-hours ( $P_{gross}$ ) defined for the NSPS?

**Response:** Yes. For RBEP, the equations presented in Section 60.5540 of the proposed New Source Performance Standard (NSPS) Subpart TTTT is  $P_{gross}$  equals electric power from the combustion turbine generator plus electric power from the steam turbine generator.

- b. Please provide thermal efficiency calculations demonstrating that RBEP will be able to meet 1000 lb  $CO_2/MWh_{gross}$  standard.

**Response:** Compliance with the proposed NSPS carbon dioxide ( $CO_2$ ) efficiency of 1,000 pounds of  $CO_2$  per megawatt-hour (lb  $CO_2/MWh$ ) on a gross basis is based on RBEP's operating profile. Once this regulation is promulgated, AES will operate RBEP in compliance with the NSPS by increasing the amount of time RBEP is operated at the

most efficient heat rates. Using the table from our February 14, 2014 letter, we have revised Tables 2 through 4 from our February 7, 2014 letter to present an operating profile that demonstrates RBEP's compliance with the proposed NSPS. Revisions to Table 2, as shown in Table 2R, include the use of the most efficient heat rate in the 2 on 1 configuration, as opposed to the average heat rate over the range of operating loads.

**Table 2R**  
**RBEP Heat Rates and Electrical Production – REVISED**

| Parameter   | Turbine Output (%) |         |         |         |          |
|---|--------------------|---------|---------|---------|----------|
|   | 70                 | 80      | 90      | 100     | 100 + DB |
| <b><i>Heat Rates for a 1 on 1 Configuration</i></b> |                    |         |         |         |          |
| Hours per Configuration per Year                    |                    |         | 125     |         |          |
| Net Plant Electrical Output (kW)                    | 116,977            | 130,750 | 144,285 | 161,150 | 203,570  |
| Net Plant Heat Rate (Btu/kWh-LHV)                   | 7,969              | 7,796   | 7,669   | 7,578   | 7,979    |
| Estimated Gross Heat Rate (Btu/kWh-LHV)             | 7,737              | 7,569   | 7,446   | 7,357   | 7,747    |
| Estimated Net Heat Rate (Btu/kWh-HHV)               | 8,766              | 8,576   | 8,436   | 8,336   | 8,777    |
| Average Power Output (kW)                           |                    |         | 151,346 |         |          |
| Average Net Heat Rate (Btu/kWh-HHV)                 |                    |         | 8,578   |         |          |
| Average Gross Heat Rate (Btu/kWh-HHV)               |                    |         | 8,328   |         |          |
| <b><i>Heat Rates for a 2 on 1 Configuration</i></b> |                    |         |         |         |          |
| Hours per Configuration per Year                    |                    |         | 5,515   |         |          |
| Net Plant Electrical Output (kW)                    | 241,081            | 268,702 | 295,720 | 329,459 | 367,913  |
| Net Plant Heat Rate (Btu/kWh-LHV)                   | 7,733              | 7,587   | 7,484   | 7,413   | 7,683    |
| Estimated Gross Heat Rate (Btu/kWh-LHV)             | 7,508              | 7,366   | 7,266   | 7,197   | 7,459    |
| Estimated Net Heat Rate (Btu/kWh-HHV)               | 8,506              | 8,346   | 8,232   | 8,154   | 8,451    |
| Average Power Output (kW)                           |                    |         | 300,575 |         |          |
| Most Efficient Net Heat Rate (Btu/kWh-HHV)          |                    |         | 8,154   |         |          |
| Most Efficient Gross Heat Rate (Btu/kWh-HHV)        |                    |         | 7,917   |         |          |
| <b><i>Heat Rates for a 3 on 1 Configuration</i></b> |                    |         |         |         |          |
| Hours per Configuration per Year                    |                    |         | 730     |         |          |
| Net Plant Electrical Output (kW)                    | 367,918            | 403,656 | 443,066 | 492,265 | N/A      |
| Net Plant Heat Rate (Btu/kWh-LHV)                   | 7,681              | 7,575   | 7,492   | 7,440   | N/A      |
| Estimated Gross Heat Rate (Btu/kWh-LHV)             | 7,457              | 7,354   | 7,274   | 7,223   | N/A      |
| Estimated Net Heat Rate (Btu/kWh-HHV)               | 8,449              | 8,333   | 8,241   | 8,184   | N/A      |
| Average Power Output (kW)                           |                    |         | 414,031 |         |          |
| Average Net Heat Rate (Btu/kWh-HHV)                 |                    |         | 8,335   |         |          |
| Average Gross Heat Rate (Btu/kWh-HHV)               |                    |         | 8,092   |         |          |

Btu/kWh = British thermal unit(s) per kilowatt-hours

DB = duct burner

HHV = higher heating value

kW = kilowatt(s)

LHV = lower heating value

---

N/A = Not applicable

In Table 3R, the number of start-up and shutdown events was reduced from 624 to 300, with 295 combined hot and warm start-ups, 5 cold start-ups, and 300 shutdown events per turbine.

**Table 3R**  
**Start-up and Shutdown Heat Rates and Hours - REVISED**

|   |        |
|---|--------|
| Start-up (9 Minutes) Heat Rate (Btu/kWh-HHV, Net)           | 20,094 |
| Shutdown (9 Minutes) Heat Rate (Btu/kWh-HHV, Net)           | 18,172 |
| Start-up (Balance of Start) Heat Rate (Btu/kWh-HHV, Net)    | 8,766  |
| Shutdown (Balance of Shutdown) Heat Rate (Btu/kWh-HHV, Net) | 8,766  |
| Start-up Hours (9 Minutes)                                  | 45     |
| Shutdown Hours (9 Minutes)                                  | 47.5   |
| Start-up Hours (Balance of Start-up) <sup>1</sup>           | 122.3  |
| Shutdown Hours (Balance of Shutdown) <sup>1</sup>           | 2.5    |

<sup>1</sup> Balance for a cold start-up is 81 minutes (81 min / 60 min \* 5 start-ups), for warm/hot start-ups are 23.5 minutes, and for a shutdown is 0.5 minutes.

AES expects that, after commissioning, RBEP will experience a permanent 3 percent performance degradation. Between major maintenance events, AES assumes an additional 5 percent performance degradation can occur, which can be recovered through inspection and maintenance of plant equipment. AES understands that, when NSPS Subpart TTTT is promulgated, RBEP may be subject to a CO<sub>2</sub> emission limit and AES will manage RBEP operation to comply with an applicable CO<sub>2</sub> emission limitation by developing and implementing a maintenance program that incorporates the equipment manufacturers' recommended inspection and maintenance activities.

Table 4R presents RBEP's GHG efficiency estimates based on Tables 2R and 3R. Based on these calculations, RBEP's expected operating profile GHG efficiency is 976 lb CO<sub>2</sub>/MWh on a gross basis, assuming a 3 percent performance degradation.

**Table 4R**  
**RBEP GHG Efficiency – REVISED**

|   |       |
|---|-------|
| Overall Net Heat Rate (Btu/kWh-HHV)                                 | 8,348 |
| Overall Gross Heat Rate (Btu/kWh-HHV)                               | 8,105 |
| Net Heat Rate Basis (lb CO <sub>2</sub> /MWh)                       | 976   |
| Gross Heat Rate Basis (lb CO <sub>2</sub> /MWh)                     | 948   |
| Net Heat Rate Basis with 3% degradation (lb CO <sub>2</sub> /MWh)   | 1,005 |
| Gross Heat Rate Basis with 3% degradation (lb CO <sub>2</sub> /MWh) | 976   |

Ms. Vicky Lee  
March 17, 2014  
Page 4

As noted in Section 2.4 of the air permit application, AES expects RBEP to have a capacity factor between 15 and 25 percent, which means the proposed NSPS Subpart TTTT CO<sub>2</sub> emission limitation would not apply.

If you have any additional questions, please contact either me or Jerry Salamy (916-286-0207).

Sincerely,

A handwritten signature in blue ink that reads "S. O'Kane". The signature is stylized with a large, looping initial "S" and a cursive "O'Kane".

Stephen O'Kane  
Vice-President  
AES Southland Development, LLC

cc: J. Didlo/AES  
G. Wheatland/ESH  
J. Salamy/CH2M HILL  
S. Madams/CH2M HILL